



Conco Services LLC

530 Jones Street
Verona, PA 15147 U.S.A.
Tel: 1-800-345-3476
Fax: 412-826-8255
www.conco.net

**Eddy Current Report
For**

**East Kentucky Power Cooperative
Spurlock Station
Unit 2**

LPFWH-3

June 2021

Conco Job #32764

Prepared By:

Approved By:



TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>
1.0	SCOPE OF WORK
2.0	INSPECTION SUMMARY
2.1	Data Management Codes
2.1.1	Data Report Legend
2.1.2	Graphic Legend
2.2	Results Summary
2.2.1	Results Map
2.2.2	Data Report
2.2.3	To Be Plugged Map
2.2.4	Tube Sheet Layout Map
3.0	INSPECTION PROCEDURE
3.1	Examination Technique Specification Sheet (ETSS)
3.2	Calibration Summary
3.3	Calibration Curves
3.4	CSC-NDE-11.0 Rev 4
4.0	CERTIFICATIONS
4.1	Personnel
4.2	Equipment
4.3	Calibration Standards



1.0 SCOPE OF WORK

During the June 2021 unscheduled maintenance at Spurlock Station, Unit 2, East Kentucky Power Cooperative, an Eddy Current inspection was performed on 100% of the tubes in LPFWH-3. The tube specifications are as follows:

Material	OD Dimension	Wall Thickness	BWG	Length
304 SS	0.750"	0.035"	20	30' ASL

This inspection of Unit 2, LPFWH-3 was performed as part of an ongoing maintenance program at East Kentucky Power Cooperative. The current results will be compared to future inspections to assure performance, monitor for any future damage and trend the progression of previously recorded damage.

Eddy Current Testing is used to inspect a wide range of non-ferrous material for defects and degradation without damaging the test specimen. A digital multi-frequency tester with two-channel mixing was used. The tester is set with high sensitivity to small defects meanwhile still able to size large volume wear.



2.0 INSPECTION SUMMARY

	Manufacturer	Type	Serial Number
Test System	CoreStar	Omni 200	0007-0901
Analysis Software	CoreStar	EddyVision 8.1	N/A
Calibration Standard	Ecutec	ASME	CSC-434
Calibration Standard	Ecutec	Wall Thinning	CSC-432
Probe	CoreStar	630 ESH/HF	N/A
Probe	CoreStar	610 ESH/HF	N/A

Unit 2 LPFWH-3

Outlet

The results of this inspection are summarized in the Results Summary Table and on the Results Map. At the time of this inspection, there were no previous test results available.

A 100% Eddy Current inspection was performed on the Unit 2, LPFWH-3. Of the 741 Outlet-end tubes inspected, there were 22 tubes that recorded damage ranging from 21% - 93% wall loss. There were 19 tubes recording dents. There were 2 tubes that were restricted (Row 15 Tube 35 and Row 16 Tube 34) and retested with a downsized probe, after the retests, they remained restricted.

Inlet

A 100% Eddy Current inspection was performed on the Unit 2, LPFWH-3. Of the 741 Inlet-end tubes inspected, there were 9 tubes that recorded damage ranging from 33% - 66% wall loss. There were 2 tubes recording dents. There was 1 tube that was restricted and retested with a downsized probe, after the retests, the restriction remained. This restricted tube is located in Row 18 Tube 30 (a peripheral tube) and is the photographed (supplied by the plant) tube that showed wear at the support. The restriction did not allow the probe to reach this region of concern.

There was no evidence of tube-to-tube wear or steam erosion during this inspection. There was no evidence of degradation of the tube-to-tubesheet joints.

No plugging criteria was specified at the time of this inspection, however, based on Eddy Current testing results, it was decided to plug 3 tubes (6 U-Bend tubes), these tube locations are provided on the To Be Plugged Map.

Keeping these tubes as clean as possible will help enhance the performance of this heat exchanger. Re-inspect this heat exchanger 1 to 2 operating cycles to assure performance, monitor for any future damage, and trend the progression of previously recorded damage.

DATA REPORT
LEGEND

CHANNEL

Channel the indication was sized on
 Channel 1 typically for freespan indications
 Channel M# typically for tubesupport indications
 Channel 6 typically for wear type indications

SECTION

ROW

TUBE

PERCENT

Amount of wall loss

Nearest support structure

Distance off of that structure


sec	row	tub	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
B	1	14				NDD				NTE	STE
B	1	15	4.49	9	23	IDI	1	TS1	79.91	NTE	STE
B	1	16				PLG				NTE	STE

VOLTS
Volume of lost material


INDICATION CODE

PHASE
 Measured in degrees
 <40 typically indicates an ID defect
 >40 typically indicates an OD defect

Directionally indicates the tube test. In this case the tube was tested from the North tube end to the South tube end



Channel : Frequency




Locat


Percent of Wall Loss

Data Cursor


Expanded View of the Strip Chart



Landmarks



Strip Charts






**Results Summary
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3**

	06-2021 Inspection		
Total Tubes in Component (U-Tubes)	741		
Total Tubes Inspected (Straight Lengths)	1482		
Tubes Recording Damage:	Totals	Inlet	Outlet
Approx. Wall Loss 90% & Greater	0	0	1
Approx. Wall Loss 80% to 89%	0	0	0
Approx. Wall Loss 70% to 79%	0	0	0
Approx. Wall Loss 60% to 69%	0	1	0
Approx. Wall Loss 50% to 59%	0	2	2
Approx. Wall Loss 40% to 49%	0	2	2
Approx. Wall Loss 30% to 39%	0	4	5
Approx. Wall Loss 20% to 29%	0	0	12
Tubes Recording Dents	0	2	17
Tubes Recording Permeability Variations (PVN)			
Restricted Tubes (Complete Inspection Not Possible)	0	1	2
Obstructed Tubes (No Test Possible)	0	0	0
Previously Plugged U-Tubes	0		
U-Tubes Recommended for Plugging	3 SL (6 U-Tubes)		
Total of Previously Plugged U-Tubes & U-Tubes Recommended for Plugging	3 SL (6 U-Tubes)		

RESULTS MAP
EAST KENTUCKY POWER COOPERATIVE
SPURLOCK STATION
UNIT 2
LPFWH-3
06-2021

VIEW FROM:INLET/OUTLET



SYM	HITS	TUBES	VIS	TYPE	DESCRIPTION
■	0	0	0	QUERY	OBS_RESULTS.qry
■	3	3	1	QUERY	RES_RESULTS.qry
●	1437	1437	1435	QUERY	NDD_RESULTS.qry
■	2	2	2	QUERY	PVN_RESULTS
●	21	19	19	QUERY	DNT_RESULTS.qry
●	5	5	5	QUERY	20-29%_RESULTS.qry
▲	10	10	10	QUERY	30-39%_RESULTS.qry
●	4	4	4	QUERY	40-49%_RESULTS.qry
▲	2	2	4	QUERY	50-59%_RESULTS.qry
●	1	1	1	QUERY	60-69%_RESULTS.qry
▲	0	0	0	QUERY	70-79%_RESULTS.qry
●	0	0	0	QUERY	80-89%_RESULTS.qry
▲	1	1	1	QUERY	90-100%_RESULTS.qry
●	0	0	0	QUERY	PLUG_RESULTS.qry
	1,486	1,484	1,482		

Model LPFWH-3 (1,482 tubes)
0 open tubes

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	1	1				NDD				UB	IO
IN	1	2				NDD				UB	IO
IN	1	3				NDD				UB	IO
IN	1	4				NDD				UB	IO
IN	1	5				NDD				UB	IO
IN	1	6				NDD				UB	IO
IN	1	7				NDD				UB	IO
IN	1	8				NDD				UB	IO
IN	1	9				NDD				UB	IO
IN	1	10				NDD				UB	IO
IN	1	11				NDD				UB	IO
IN	1	12				NDD				UB	IO
IN	1	13				NDD				UB	IO
IN	1	14				NDD				UB	IO
IN	1	15				NDD				UB	IO
IN	1	16				NDD				UB	IO
IN	1	17				NDD				UB	IO
IN	1	18				NDD				UB	IO
IN	1	19				NDD				UB	IO
IN	1	20				NDD				UB	IO
IN	1	21				NDD				UB	IO
IN	1	22				NDD				UB	IO
IN	1	23				NDD				UB	IO
IN	1	24				NDD				UB	IO
IN	1	25				NDD				UB	IO
IN	1	26				NDD				UB	IO
IN	1	27				NDD				UB	IO
IN	1	28				NDD				UB	IO
IN	1	29				NDD				UB	IO
IN	1	30				NDD				UB	IO
IN	1	31				NDD				UB	IO
IN	1	32				NDD				UB	IO
IN	1	33				NDD				UB	IO
IN	1	34				NDD				UB	IO
IN	1	35				NDD				UB	IO
IN	1	36				NDD				UB	IO
IN	1	37				NDD				UB	IO
IN	1	38				NDD				UB	IO
IN	1	39				NDD				UB	IO
IN	1	40				NDD				UB	IO
IN	1	41				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	2	1				NDD				UB	IO
IN	2	2				NDD				UB	IO
IN	2	3				NDD				UB	IO
IN	2	4				NDD				UB	IO
IN	2	5				NDD				UB	IO
IN	2	6				NDD				UB	IO
IN	2	7				NDD				UB	IO
IN	2	8				NDD				UB	IO
IN	2	9				NDD				UB	IO
IN	2	10				NDD				UB	IO
IN	2	11				NDD				UB	IO
IN	2	12				NDD				UB	IO
IN	2	13				NDD				UB	IO
IN	2	14				NDD				UB	IO
IN	2	15				NDD				UB	IO
IN	2	16				NDD				UB	IO
IN	2	17				NDD				UB	IO
IN	2	18				NDD				UB	IO
IN	2	19				NDD				UB	IO
IN	2	20				NDD				UB	IO
IN	2	21				NDD				UB	IO
IN	2	22				NDD				UB	IO
IN	2	23				NDD				UB	IO
IN	2	24				NDD				UB	IO
IN	2	25				NDD				UB	IO
IN	2	26				NDD				UB	IO
IN	2	27				NDD				UB	IO
IN	2	28				NDD				UB	IO
IN	2	29				NDD				UB	IO
IN	2	30				NDD				UB	IO
IN	2	31				NDD				UB	IO
IN	2	32				NDD				UB	IO
IN	2	33				NDD				UB	IO
IN	2	34				NDD				UB	IO
IN	2	35				NDD				UB	IO
IN	2	36				NDD				UB	IO
IN	2	37				NDD				UB	IO
IN	2	38				NDD				UB	IO
IN	2	39				NDD				UB	IO
IN	2	40				NDD				UB	IO
IN	2	41				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	2	42				NDD				UB	IO
IN	3	1				NDD				UB	IO
IN	3	2				NDD				UB	IO
IN	3	3				NDD				UB	IO
IN	3	4				NDD				UB	IO
IN	3	5				NDD				UB	IO
IN	3	6				NDD				UB	IO
IN	3	7				NDD				UB	IO
IN	3	8				NDD				UB	IO
IN	3	9				NDD				UB	IO
IN	3	10				NDD				UB	IO
IN	3	11				NDD				UB	IO
IN	3	12				NDD				UB	IO
IN	3	13				NDD				UB	IO
IN	3	14				NDD				UB	IO
IN	3	15				NDD				UB	IO
IN	3	16				NDD				UB	IO
IN	3	17				NDD				UB	IO
IN	3	18				NDD				UB	IO
IN	3	19				NDD				UB	IO
IN	3	20				NDD				UB	IO
IN	3	21				NDD				UB	IO
IN	3	22				NDD				UB	IO
IN	3	23				NDD				UB	IO
IN	3	24				NDD				UB	IO
IN	3	25				NDD				UB	IO
IN	3	26				NDD				UB	IO
IN	3	27				NDD				UB	IO
IN	3	28				NDD				UB	IO
IN	3	29				NDD				UB	IO
IN	3	30				NDD				UB	IO
IN	3	31				NDD				UB	IO
IN	3	32				NDD				UB	IO
IN	3	33				NDD				UB	IO
IN	3	34				NDD				UB	IO
IN	3	35				NDD				UB	IO
IN	3	36				NDD				UB	IO
IN	3	37				NDD				UB	IO
IN	3	38				NDD				UB	IO
IN	3	39				NDD				UB	IO
IN	3	40				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	3	41				NDD				UB	IO
IN	4	1				NDD				UB	IO
IN	4	2				NDD				UB	IO
IN	4	3				NDD				UB	IO
IN	4	4				NDD				UB	IO
IN	4	5				NDD				UB	IO
IN	4	6				NDD				UB	IO
IN	4	7				NDD				UB	IO
IN	4	8				NDD				UB	IO
IN	4	9				NDD				UB	IO
IN	4	10				NDD				UB	IO
IN	4	11				NDD				UB	IO
IN	4	12				NDD				UB	IO
IN	4	13				NDD				UB	IO
IN	4	14				NDD				UB	IO
IN	4	15				NDD				UB	IO
IN	4	16				NDD				UB	IO
IN	4	17				NDD				UB	IO
IN	4	18				NDD				UB	IO
IN	4	19				NDD				UB	IO
IN	4	20				NDD				UB	IO
IN	4	21				NDD				UB	IO
IN	4	22				NDD				UB	IO
IN	4	23				NDD				UB	IO
IN	4	24				NDD				UB	IO
IN	4	25				NDD				UB	IO
IN	4	26				NDD				UB	IO
IN	4	27				NDD				UB	IO
IN	4	28				NDD				UB	IO
IN	4	29				NDD				UB	IO
IN	4	30				NDD				UB	IO
IN	4	31				NDD				UB	IO
IN	4	32				NDD				UB	IO
IN	4	33				NDD				UB	IO
IN	4	34				NDD				UB	IO
IN	4	35				NDD				UB	IO
IN	4	36				NDD				UB	IO
IN	4	37				NDD				UB	IO
IN	4	38				NDD				UB	IO
IN	4	39				NDD				UB	IO
IN	4	40				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	4	41				NDD				UB	IO
IN	4	42	32.26	188		DNT	1	IN	198.64	UB	IO
IN	5	1				NDD				UB	IO
IN	5	2				NDD				UB	IO
IN	5	3				NDD				UB	IO
IN	5	4				NDD				UB	IO
IN	5	5				NDD				UB	IO
IN	5	6				NDD				UB	IO
IN	5	7	4.12	16	41	IDI	1	IN	168.72	UB	IO
IN	5	8				NDD				UB	IO
IN	5	9				NDD				UB	IO
IN	5	10				NDD				UB	IO
IN	5	11				NDD				UB	IO
IN	5	12				NDD				UB	IO
IN	5	13				NDD				UB	IO
IN	5	14				NDD				UB	IO
IN	5	15				NDD				UB	IO
IN	5	16				NDD				UB	IO
IN	5	17				NDD				UB	IO
IN	5	18				NDD				UB	IO
IN	5	19				NDD				UB	IO
IN	5	20				NDD				UB	IO
IN	5	21				NDD				UB	IO
IN	5	22				NDD				UB	IO
IN	5	23				NDD				UB	IO
IN	5	24				NDD				UB	IO
IN	5	25				NDD				UB	IO
IN	5	26				NDD				UB	IO
IN	5	27				NDD				UB	IO
IN	5	28				NDD				UB	IO
IN	5	29				NDD				UB	IO
IN	5	30				NDD				UB	IO
IN	5	31				NDD				UB	IO
IN	5	32				NDD				UB	IO
IN	5	33				NDD				UB	IO
IN	5	34				NDD				UB	IO
IN	5	35				NDD				UB	IO
IN	5	36				NDD				UB	IO
IN	5	37				NDD				UB	IO
IN	5	38				NDD				UB	IO
IN	5	39				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	5	40				NDD				UB	IO
IN	5	41				NDD				UB	IO
IN	6	1				NDD				UB	IO
IN	6	2				NDD				UB	IO
IN	6	3				NDD				UB	IO
IN	6	4				NDD				UB	IO
IN	6	5				NDD				UB	IO
IN	6	6				NDD				UB	IO
IN	6	7				NDD				UB	IO
IN	6	8				NDD				UB	IO
IN	6	9				NDD				UB	IO
IN	6	10				NDD				UB	IO
IN	6	11				NDD				UB	IO
IN	6	12				NDD				UB	IO
IN	6	13				NDD				UB	IO
IN	6	14				NDD				UB	IO
IN	6	15				NDD				UB	IO
IN	6	16				NDD				UB	IO
IN	6	17				NDD				UB	IO
IN	6	18				NDD				UB	IO
IN	6	19				NDD				UB	IO
IN	6	20				NDD				UB	IO
IN	6	21				NDD				UB	IO
IN	6	22				NDD				UB	IO
IN	6	23				NDD				UB	IO
IN	6	24				NDD				UB	IO
IN	6	25				NDD				UB	IO
IN	6	26				NDD				UB	IO
IN	6	27				NDD				UB	IO
IN	6	28				NDD				UB	IO
IN	6	29				NDD				UB	IO
IN	6	30				NDD				UB	IO
IN	6	31				NDD				UB	IO
IN	6	32				NDD				UB	IO
IN	6	33				NDD				UB	IO
IN	6	34				NDD				UB	IO
IN	6	35				NDD				UB	IO
IN	6	36				NDD				UB	IO
IN	6	37				NDD				UB	IO
IN	6	38				NDD				UB	IO
IN	6	39				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	6	40				NDD				UB	IO
IN	6	41				NDD				UB	IO
IN	6	42				NDD				UB	IO
IN	7	1				NDD				UB	IO
IN	7	2				NDD				UB	IO
IN	7	3				NDD				UB	IO
IN	7	4				NDD				UB	IO
IN	7	5				NDD				UB	IO
IN	7	6				NDD				UB	IO
IN	7	7				NDD				UB	IO
IN	7	8				NDD				UB	IO
IN	7	9				NDD				UB	IO
IN	7	10				NDD				UB	IO
IN	7	11				NDD				UB	IO
IN	7	12				NDD				UB	IO
IN	7	13				NDD				UB	IO
IN	7	14				NDD				UB	IO
IN	7	15				NDD				UB	IO
IN	7	16				NDD				UB	IO
IN	7	17				NDD				UB	IO
IN	7	18				NDD				UB	IO
IN	7	19				NDD				UB	IO
IN	7	20				NDD				UB	IO
IN	7	21				NDD				UB	IO
IN	7	22				NDD				UB	IO
IN	7	23				NDD				UB	IO
IN	7	24				NDD				UB	IO
IN	7	25				NDD				UB	IO
IN	7	26				NDD				UB	IO
IN	7	27				NDD				UB	IO
IN	7	28				NDD				UB	IO
IN	7	29				NDD				UB	IO
IN	7	30				NDD				UB	IO
IN	7	31				NDD				UB	IO
IN	7	32				NDD				UB	IO
IN	7	33				NDD				UB	IO
IN	7	34				NDD				UB	IO
IN	7	35				NDD				UB	IO
IN	7	36				NDD				UB	IO
IN	7	37				NDD				UB	IO
IN	7	38				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	7	39				NDD				UB	IO
IN	7	40				NDD				UB	IO
IN	7	41	0.76	14	35	IDI	1	IN	233.52	UB	IO
IN	8	1	2.32	14	35	IDI	1	IN	93.97	UB	IO
IN	8	2				NDD				UB	IO
IN	8	3				NDD				UB	IO
IN	8	4				NDD				UB	IO
IN	8	5				NDD				UB	IO
IN	8	6				NDD				UB	IO
IN	8	7				NDD				UB	IO
IN	8	8				NDD				UB	IO
IN	8	9				NDD				UB	IO
IN	8	10				NDD				UB	IO
IN	8	11				NDD				UB	IO
IN	8	12				NDD				UB	IO
IN	8	13	84.99	190		DNT	1	IN	232.87	UB	IO
IN	8	14				NDD				UB	IO
IN	8	15				NDD				UB	IO
IN	8	16				NDD				UB	IO
IN	8	17				NDD				UB	IO
IN	8	18				NDD				UB	IO
IN	8	19				NDD				UB	IO
IN	8	20				NDD				UB	IO
IN	8	21				NDD				UB	IO
IN	8	22				NDD				UB	IO
IN	8	23				NDD				UB	IO
IN	8	24				NDD				UB	IO
IN	8	25				NDD				UB	IO
IN	8	26				NDD				UB	IO
IN	8	27				NDD				UB	IO
IN	8	28				NDD				UB	IO
IN	8	29				NDD				UB	IO
IN	8	30				NDD				UB	IO
IN	8	31				NDD				UB	IO
IN	8	32				NDD				UB	IO
IN	8	33				NDD				UB	IO
IN	8	34				NDD				UB	IO
IN	8	35				NDD				UB	IO
IN	8	36				NDD				UB	IO
IN	8	37				NDD				UB	IO
IN	8	38	2.27	16	41	IDI	3	IN	132.68	UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	8	39				NDD				UB	IO
IN	8	40				NDD				UB	IO
IN	8	41				NDD				UB	IO
IN	8	42				NDD				UB	IO
IN	9	1				NDD				UB	IO
IN	9	2				NDD				UB	IO
IN	9	3				NDD				UB	IO
IN	9	4				NDD				UB	IO
IN	9	5				NDD				UB	IO
IN	9	6				NDD				UB	IO
IN	9	7				NDD				UB	IO
IN	9	8				NDD				UB	IO
IN	9	9				NDD				UB	IO
IN	9	10				NDD				UB	IO
IN	9	11				NDD				UB	IO
IN	9	12				NDD				UB	IO
IN	9	13				NDD				UB	IO
IN	9	14				NDD				UB	IO
IN	9	15				NDD				UB	IO
IN	9	16				NDD				UB	IO
IN	9	17				NDD				UB	IO
IN	9	18				NDD				UB	IO
IN	9	19				NDD				UB	IO
IN	9	20				NDD				UB	IO
IN	9	21				NDD				UB	IO
IN	9	22				NDD				UB	IO
IN	9	23				NDD				UB	IO
IN	9	24				NDD				UB	IO
IN	9	25				NDD				UB	IO
IN	9	26				NDD				UB	IO
IN	9	27				NDD				UB	IO
IN	9	28				NDD				UB	IO
IN	9	29				NDD				UB	IO
IN	9	30				NDD				UB	IO
IN	9	31				NDD				UB	IO
IN	9	32				NDD				UB	IO
IN	9	33				NDD				UB	IO
IN	9	34				NDD				UB	IO
IN	9	35				NDD				UB	IO
IN	9	36				NDD				UB	IO
IN	9	37				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	9	38				NDD				UB	IO
IN	9	39				NDD				UB	IO
IN	9	40				NDD				UB	IO
IN	9	41				NDD				UB	IO
IN	10	1				NDD				UB	IO
IN	10	2				NDD				UB	IO
IN	10	3				NDD				UB	IO
IN	10	4				NDD				UB	IO
IN	10	5				NDD				UB	IO
IN	10	6				NDD				UB	IO
IN	10	7				NDD				UB	IO
IN	10	8				NDD				UB	IO
IN	10	9				NDD				UB	IO
IN	10	10				NDD				UB	IO
IN	10	11				NDD				UB	IO
IN	10	12				NDD				UB	IO
IN	10	13				NDD				UB	IO
IN	10	14				NDD				UB	IO
IN	10	15				NDD				UB	IO
IN	10	16				NDD				UB	IO
IN	10	17				NDD				UB	IO
IN	10	18				NDD				UB	IO
IN	10	19				NDD				UB	IO
IN	10	20				NDD				UB	IO
IN	10	21				NDD				UB	IO
IN	10	22				NDD				UB	IO
IN	10	23				NDD				UB	IO
IN	10	24				NDD				UB	IO
IN	10	25				NDD				UB	IO
IN	10	26				NDD				UB	IO
IN	10	27				NDD				UB	IO
IN	10	28				NDD				UB	IO
IN	10	29				NDD				UB	IO
IN	10	30				NDD				UB	IO
IN	10	31				NDD				UB	IO
IN	10	32				NDD				UB	IO
IN	10	33				NDD				UB	IO
IN	10	34				NDD				UB	IO
IN	10	35				NDD				UB	IO
IN	10	36				NDD				UB	IO
IN	10	37				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	10	38				NDD				UB	IO
IN	10	39				NDD				UB	IO
IN	10	40				NDD				UB	IO
IN	11	1				NDD				UB	IO
IN	11	2				NDD				UB	IO
IN	11	3				NDD				UB	IO
IN	11	4				NDD				UB	IO
IN	11	5				NDD				UB	IO
IN	11	6				NDD				UB	IO
IN	11	7				NDD				UB	IO
IN	11	8				NDD				UB	IO
IN	11	9				NDD				UB	IO
IN	11	10				NDD				UB	IO
IN	11	11				NDD				UB	IO
IN	11	12				NDD				UB	IO
IN	11	13				NDD				UB	IO
IN	11	14				NDD				UB	IO
IN	11	15				NDD				UB	IO
IN	11	16				NDD				UB	IO
IN	11	17				NDD				UB	IO
IN	11	18				NDD				UB	IO
IN	11	19				NDD				UB	IO
IN	11	20				NDD				UB	IO
IN	11	21				NDD				UB	IO
IN	11	22				NDD				UB	IO
IN	11	23				NDD				UB	IO
IN	11	24				NDD				UB	IO
IN	11	25				NDD				UB	IO
IN	11	26				NDD				UB	IO
IN	11	27				NDD				UB	IO
IN	11	28				NDD				UB	IO
IN	11	29				NDD				UB	IO
IN	11	30				NDD				UB	IO
IN	11	31				NDD				UB	IO
IN	11	32				NDD				UB	IO
IN	11	33				NDD				UB	IO
IN	11	34				NDD				UB	IO
IN	11	35				NDD				UB	IO
IN	11	36				NDD				UB	IO
IN	11	37				NDD				UB	IO
IN	11	38				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	11	39				NDD				UB	IO
IN	12	1				NDD				UB	IO
IN	12	2				NDD				UB	IO
IN	12	3				NDD				UB	IO
IN	12	4				NDD				UB	IO
IN	12	5				NDD				UB	IO
IN	12	6				NDD				UB	IO
IN	12	7				NDD				UB	IO
IN	12	8				NDD				UB	IO
IN	12	9				NDD				UB	IO
IN	12	10				NDD				UB	IO
IN	12	11				NDD				UB	IO
IN	12	12				NDD				UB	IO
IN	12	13				NDD				UB	IO
IN	12	14				NDD				UB	IO
IN	12	15				NDD				UB	IO
IN	12	16				NDD				UB	IO
IN	12	17				NDD				UB	IO
IN	12	18				NDD				UB	IO
IN	12	19				NDD				UB	IO
IN	12	20				NDD				UB	IO
IN	12	21				NDD				UB	IO
IN	12	22				NDD				UB	IO
IN	12	23				NDD				UB	IO
IN	12	24				NDD				UB	IO
IN	12	25				NDD				UB	IO
IN	12	26				NDD				UB	IO
IN	12	27				NDD				UB	IO
IN	12	28				NDD				UB	IO
IN	12	29				NDD				UB	IO
IN	12	30				NDD				UB	IO
IN	12	31				NDD				UB	IO
IN	12	32				NDD				UB	IO
IN	12	33				NDD				UB	IO
IN	12	34				NDD				UB	IO
IN	12	35				NDD				UB	IO
IN	12	36				NDD				UB	IO
IN	12	37				NDD				UB	IO
IN	12	38				NDD				UB	IO
IN	13	1				NDD				UB	IO
IN	13	2				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	13	3				NDD				UB	IO
IN	13	4				NDD				UB	IO
IN	13	5	1.02	13	33	IDI	1	IN	198.45	UB	IO
IN	13	6				NDD				UB	IO
IN	13	7				NDD				UB	IO
IN	13	8				NDD				UB	IO
IN	13	9				NDD				UB	IO
IN	13	10				NDD				UB	IO
IN	13	11				NDD				UB	IO
IN	13	12				NDD				UB	IO
IN	13	13				NDD				UB	IO
IN	13	14				NDD				UB	IO
IN	13	15				NDD				UB	IO
IN	13	16				NDD				UB	IO
IN	13	17				NDD				UB	IO
IN	13	18				NDD				UB	IO
IN	13	19				NDD				UB	IO
IN	13	20				NDD				UB	IO
IN	13	21				NDD				UB	IO
IN	13	22	10.54	26	66	IDI	1	IN	6.73	UB	IO
IN	13	23				NDD				UB	IO
IN	13	24				NDD				UB	IO
IN	13	25				NDD				UB	IO
IN	13	26				NDD				UB	IO
IN	13	27				NDD				UB	IO
IN	13	28				NDD				UB	IO
IN	13	29				NDD				UB	IO
IN	13	30				NDD				UB	IO
IN	13	31				NDD				UB	IO
IN	13	32				NDD				UB	IO
IN	13	33				NDD				UB	IO
IN	13	34				NDD				UB	IO
IN	13	35				NDD				UB	IO
IN	14	1				NDD				UB	IO
IN	14	2				NDD				UB	IO
IN	14	3				NDD				UB	IO
IN	14	4				NDD				UB	IO
IN	14	5				NDD				UB	IO
IN	14	6				NDD				UB	IO
IN	14	7				NDD				UB	IO
IN	14	8				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	14	9				NDD				UB	IO
IN	14	10				NDD				UB	IO
IN	14	11				NDD				UB	IO
IN	14	12				NDD				UB	IO
IN	14	13				NDD				UB	IO
IN	14	14				NDD				UB	IO
IN	14	15				NDD				UB	IO
IN	14	16				NDD				UB	IO
IN	14	17				NDD				UB	IO
IN	14	18				NDD				UB	IO
IN	14	19				NDD				UB	IO
IN	14	20				NDD				UB	IO
IN	14	21				NDD				UB	IO
IN	14	22				NDD				UB	IO
IN	14	23				NDD				UB	IO
IN	14	24				NDD				UB	IO
IN	14	25				NDD				UB	IO
IN	14	26				NDD				UB	IO
IN	14	27				NDD				UB	IO
IN	14	28				NDD				UB	IO
IN	14	29				NDD				UB	IO
IN	14	30				NDD				UB	IO
IN	14	31				NDD				UB	IO
IN	14	32				NDD				UB	IO
IN	14	33				NDD				UB	IO
IN	14	34				NDD				UB	IO
IN	14	35				NDD				UB	IO
IN	14	36				NDD				UB	IO
IN	15	1				NDD				UB	IO
IN	15	2				NDD				UB	IO
IN	15	3				NDD				UB	IO
IN	15	4				NDD				UB	IO
IN	15	5				NDD				UB	IO
IN	15	6				NDD				UB	IO
IN	15	7				NDD				UB	IO
IN	15	8				NDD				UB	IO
IN	15	9				NDD				UB	IO
IN	15	10				NDD				UB	IO
IN	15	11				NDD				UB	IO
IN	15	12				NDD				UB	IO
IN	15	13				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	15	14				NDD				UB	IO
IN	15	15				NDD				UB	IO
IN	15	16				NDD				UB	IO
IN	15	17				NDD				UB	IO
IN	15	18				NDD				UB	IO
IN	15	19				NDD				UB	IO
IN	15	20				NDD				UB	IO
IN	15	21				NDD				UB	IO
IN	15	22				NDD				UB	IO
IN	15	23				NDD				UB	IO
IN	15	24				NDD				UB	IO
IN	15	25				NDD				UB	IO
IN	15	26				NDD				UB	IO
IN	15	27				NDD				UB	IO
IN	15	28				NDD				UB	IO
IN	15	29				NDD				UB	IO
IN	15	30				NDD				UB	IO
IN	15	31				NDD				UB	IO
IN	15	32				NDD				UB	IO
IN	15	33				NDD				UB	IO
IN	15	34				NDD				UB	IO
IN	15	35				NDD				UB	IO
IN	16	1				NDD				UB	IO
IN	16	2				NDD				UB	IO
IN	16	3				NDD				UB	IO
IN	16	4				NDD				UB	IO
IN	16	5				NDD				UB	IO
IN	16	6				NDD				UB	IO
IN	16	7				NDD				UB	IO
IN	16	8				NDD				UB	IO
IN	16	9				NDD				UB	IO
IN	16	10				NDD				UB	IO
IN	16	11				NDD				UB	IO
IN	16	12				NDD				UB	IO
IN	16	13				NDD				UB	IO
IN	16	14				NDD				UB	IO
IN	16	15				NDD				UB	IO
IN	16	16				NDD				UB	IO
IN	16	17				NDD				UB	IO
IN	16	18				NDD				UB	IO
IN	16	19				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	16	20				NDD				UB	IO
IN	16	21				NDD				UB	IO
IN	16	22				NDD				UB	IO
IN	16	23				NDD				UB	IO
IN	16	24				NDD				UB	IO
IN	16	25				NDD				UB	IO
IN	16	26				NDD				UB	IO
IN	16	27				NDD				UB	IO
IN	16	28				NDD				UB	IO
IN	16	29				NDD				UB	IO
IN	16	30				NDD				UB	IO
IN	16	31				NDD				UB	IO
IN	16	32				NDD				UB	IO
IN	16	33				NDD				UB	IO
IN	16	34				NDD				UB	IO
IN	17	1				NDD				UB	IO
IN	17	2				NDD				UB	IO
IN	17	3				NDD				UB	IO
IN	17	4				NDD				UB	IO
IN	17	5				NDD				UB	IO
IN	17	6				NDD				UB	IO
IN	17	7				NDD				UB	IO
IN	17	8				NDD				UB	IO
IN	17	9				NDD				UB	IO
IN	17	10				NDD				UB	IO
IN	17	11				NDD				UB	IO
IN	17	12				NDD				UB	IO
IN	17	13				NDD				UB	IO
IN	17	14				NDD				UB	IO
IN	17	15				NDD				UB	IO
IN	17	16				NDD				UB	IO
IN	17	17				NDD				UB	IO
IN	17	18				NDD				UB	IO
IN	17	19				NDD				UB	IO
IN	17	20				NDD				UB	IO
IN	17	21				NDD				UB	IO
IN	17	22				NDD				UB	IO
IN	17	23				NDD				UB	IO
IN	17	24				NDD				UB	IO
IN	17	25				NDD				UB	IO
IN	17	26				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	17	27				NDD				UB	IO
IN	17	28				NDD				UB	IO
IN	17	29				NDD				UB	IO
IN	17	30				NDD				UB	IO
IN	17	31				NDD				UB	IO
IN	18	1				NDD				UB	IO
IN	18	2				NDD				UB	IO
IN	18	3				NDD				UB	IO
IN	18	4				NDD				UB	IO
IN	18	5				NDD				UB	IO
IN	18	6	4.20	13	33	IDI	1	IN	98.68	UB	IO
IN	18	7				NDD				UB	IO
IN	18	8				NDD				UB	IO
IN	18	9				NDD				UB	IO
IN	18	10				NDD				UB	IO
IN	18	11				NDD				UB	IO
IN	18	12				NDD				UB	IO
IN	18	13				NDD				UB	IO
IN	18	14				NDD				UB	IO
IN	18	15				NDD				UB	IO
IN	18	16				NDD				UB	IO
IN	18	17				NDD				UB	IO
IN	18	18				NDD				UB	IO
IN	18	19				NDD				UB	IO
IN	18	20				NDD				UB	IO
IN	18	21				NDD				UB	IO
IN	18	22				NDD				UB	IO
IN	18	23				NDD				UB	IO
IN	18	24				NDD				UB	IO
IN	18	25				NDD				UB	IO
IN	18	26				NDD				UB	IO
IN	18	27				NDD				UB	IO
IN	18	28				NDD				UB	IO
IN	18	29				NDD				UB	IO
IN	18	30				RES	1	IN	35.58	UB	IO
IN	18	30				RES	1	IN	60.21	UB	IO
IN	19	1				NDD				UB	IO
IN	19	2				NDD				UB	IO
IN	19	3				NDD				UB	IO
IN	19	4				NDD				UB	IO
IN	19	5				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	19	6				NDD				UB	IO
IN	19	7				NDD				UB	IO
IN	19	8				NDD				UB	IO
IN	19	9				NDD				UB	IO
IN	19	10				NDD				UB	IO
IN	19	11				NDD				UB	IO
IN	19	12				NDD				UB	IO
IN	19	13				NDD				UB	IO
IN	19	14				NDD				UB	IO
IN	19	15				NDD				UB	IO
IN	19	16				NDD				UB	IO
IN	19	17				NDD				UB	IO
IN	19	18				NDD				UB	IO
IN	19	19				NDD				UB	IO
IN	19	20				NDD				UB	IO
IN	19	21				NDD				UB	IO
IN	19	22				NDD				UB	IO
IN	19	23				NDD				UB	IO
IN	19	24				NDD				UB	IO
IN	19	25				NDD				UB	IO
IN	19	26				NDD				UB	IO
IN	20	1				NDD				UB	IO
IN	20	2				NDD				UB	IO
IN	20	3				NDD				UB	IO
IN	20	4				NDD				UB	IO
IN	20	5				NDD				UB	IO
IN	20	6				NDD				UB	IO
IN	20	7				NDD				UB	IO
IN	20	8				NDD				UB	IO
IN	20	9				NDD				UB	IO
IN	20	10				NDD				UB	IO
IN	20	11				NDD				UB	IO
IN	20	12				NDD				UB	IO
IN	20	13				NDD				UB	IO
IN	20	14				NDD				UB	IO
IN	20	15				NDD				UB	IO
IN	20	16				NDD				UB	IO
IN	20	17				NDD				UB	IO
IN	20	18				NDD				UB	IO
IN	20	19				NDD				UB	IO
IN	20	20				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
IN	20	21				NDD				UB	IO
IN	20	22				NDD				UB	IO
IN	20	23				NDD				UB	IO
IN	20	24				NDD				UB	IO
OU	1	1				NDD				UB	IO
OU	1	2				NDD				UB	IO
OU	1	3				NDD				UB	IO
OU	1	4				NDD				UB	IO
OU	1	5				NDD				UB	IO
OU	1	6				NDD				UB	IO
OU	1	7				NDD				UB	IO
OU	1	8				NDD				UB	IO
OU	1	9				NDD				UB	IO
OU	1	10				NDD				UB	IO
OU	1	11				NDD				UB	IO
OU	1	12				NDD				UB	IO
OU	1	13				NDD				UB	IO
OU	1	14				NDD				UB	IO
OU	1	15				NDD				UB	IO
OU	1	16				NDD				UB	IO
OU	1	17				NDD				UB	IO
OU	1	18				NDD				UB	IO
OU	1	19				NDD				UB	IO
OU	1	20				NDD				UB	IO
OU	1	21				NDD				UB	IO
OU	1	22				NDD				UB	IO
OU	1	23				NDD				UB	IO
OU	1	24				NDD				UB	IO
OU	1	25				NDD				UB	IO
OU	1	26				NDD				UB	IO
OU	1	27				NDD				UB	IO
OU	1	28				NDD				UB	IO
OU	1	29				NDD				UB	IO
OU	1	30				NDD				UB	IO
OU	1	31				NDD				UB	IO
OU	1	32				NDD				UB	IO
OU	1	33				NDD				UB	IO
OU	1	34				NDD				UB	IO
OU	1	35				NDD				UB	IO
OU	1	36				NDD				UB	IO
OU	1	37				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	1	38				NDD				UB	IO
OU	1	39				NDD				UB	IO
OU	1	40				NDD				UB	IO
OU	1	41				NDD				UB	IO
OU	2	1				NDD				UB	IO
OU	2	2				NDD				UB	IO
OU	2	3				NDD				UB	IO
OU	2	4				NDD				UB	IO
OU	2	5				NDD				UB	IO
OU	2	6	3.03	21	53	IDI	1	OU	198.58	UB	IO
OU	2	7				NDD				UB	IO
OU	2	8				NDD				UB	IO
OU	2	9				NDD				UB	IO
OU	2	10				NDD				UB	IO
OU	2	11				NDD				UB	IO
OU	2	12				NDD				UB	IO
OU	2	13				NDD				UB	IO
OU	2	14				NDD				UB	IO
OU	2	15				NDD				UB	IO
OU	2	16				NDD				UB	IO
OU	2	17				NDD				UB	IO
OU	2	18				NDD				UB	IO
OU	2	19				NDD				UB	IO
OU	2	20				NDD				UB	IO
OU	2	21				NDD				UB	IO
OU	2	22				NDD				UB	IO
OU	2	23				NDD				UB	IO
OU	2	24				NDD				UB	IO
OU	2	25				NDD				UB	IO
OU	2	26				NDD				UB	IO
OU	2	27				NDD				UB	IO
OU	2	28				NDD				UB	IO
OU	2	29				NDD				UB	IO
OU	2	30	7.24	19	48	IDI	1	OU	160.27	UB	IO
OU	2	31				NDD				UB	IO
OU	2	32				NDD				UB	IO
OU	2	33				NDD				UB	IO
OU	2	34				NDD				UB	IO
OU	2	35				NDD				UB	IO
OU	2	36				NDD				UB	IO
OU	2	37				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	2	38				NDD				UB	IO
OU	2	39				NDD				UB	IO
OU	2	40				NDD				UB	IO
OU	2	41				NDD				UB	IO
OU	2	42				NDD				UB	IO
OU	3	1				NDD				UB	IO
OU	3	2				NDD				UB	IO
OU	3	3				NDD				UB	IO
OU	3	4				NDD				UB	IO
OU	3	5				NDD				UB	IO
OU	3	6				NDD				UB	IO
OU	3	7				NDD				UB	IO
OU	3	8	2.54	11	29	IDI	1	OU	219.00	UB	IO
OU	3	9				NDD				UB	IO
OU	3	10				NDD				UB	IO
OU	3	11	3.23	10	25	IDI	1	OU	77.63	UB	IO
OU	3	12	21.90	32		PVN	1	OU	-0.04	UB	IO
OU	3	13				NDD				UB	IO
OU	3	14				NDD				UB	IO
OU	3	15				NDD				UB	IO
OU	3	16				NDD				UB	IO
OU	3	17				NDD				UB	IO
OU	3	18				NDD				UB	IO
OU	3	19				NDD				UB	IO
OU	3	20				NDD				UB	IO
OU	3	21				NDD				UB	IO
OU	3	22				NDD				UB	IO
OU	3	23				NDD				UB	IO
OU	3	24				NDD				UB	IO
OU	3	25	0.82	11	27	IDI	1	OU	72.19	UB	IO
OU	3	26				NDD				UB	IO
OU	3	27				NDD				UB	IO
OU	3	28				NDD				UB	IO
OU	3	29				NDD				UB	IO
OU	3	30				NDD				UB	IO
OU	3	31				NDD				UB	IO
OU	3	32				NDD				UB	IO
OU	3	33	5.34	12	31	IDI	1	OU	232.78	UB	IO
OU	3	34				NDD				UB	IO
OU	3	35				NDD				UB	IO
OU	3	36				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	3	37				NDD				UB	IO
OU	3	38				NDD				UB	IO
OU	3	39				NDD				UB	IO
OU	3	40				NDD				UB	IO
OU	3	41	4.13	12	31	IDI	1	OU	130.84	UB	IO
OU	4	1				NDD				UB	IO
OU	4	2				NDD				UB	IO
OU	4	3				NDD				UB	IO
OU	4	4				NDD				UB	IO
OU	4	5				NDD				UB	IO
OU	4	6				NDD				UB	IO
OU	4	7				NDD				UB	IO
OU	4	8				NDD				UB	IO
OU	4	9				NDD				UB	IO
OU	4	10				NDD				UB	IO
OU	4	11				NDD				UB	IO
OU	4	12				NDD				UB	IO
OU	4	13				NDD				UB	IO
OU	4	14				NDD				UB	IO
OU	4	15				NDD				UB	IO
OU	4	16				NDD				UB	IO
OU	4	17	2.19	17	44	IDI	1	OU	157.06	UB	IO
OU	4	18				NDD				UB	IO
OU	4	19				NDD				UB	IO
OU	4	20				NDD				UB	IO
OU	4	21				NDD				UB	IO
OU	4	22				NDD				UB	IO
OU	4	23				NDD				UB	IO
OU	4	24				NDD				UB	IO
OU	4	25				NDD				UB	IO
OU	4	26				NDD				UB	IO
OU	4	27				NDD				UB	IO
OU	4	28				NDD				UB	IO
OU	4	29				NDD				UB	IO
OU	4	30				NDD				UB	IO
OU	4	31				NDD				UB	IO
OU	4	32	4.86	12	3	IDI	1	OU	171.23	UB	IO
OU	4	33				NDD				UB	IO
OU	4	34				NDD				UB	IO
OU	4	35				NDD				UB	IO
OU	4	36				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	4	37				NDD				UB	IO
OU	4	38				NDD				UB	IO
OU	4	39				NDD				UB	IO
OU	4	40				NDD				UB	IO
OU	4	41				NDD				UB	IO
OU	4	42				NDD				UB	IO
OU	5	1	27.91	185		DNT	1	OU	176.75	UB	IO
OU	5	2				NDD				UB	IO
OU	5	3				NDD				UB	IO
OU	5	4				NDD				UB	IO
OU	5	5	3.53	20	5	IDI	1	OU	118.26	UB	IO
OU	5	6				NDD				UB	IO
OU	5	7				NDD				UB	IO
OU	5	8				NDD				UB	IO
OU	5	9				NDD				UB	IO
OU	5	10				NDD				UB	IO
OU	5	11				NDD				UB	IO
OU	5	12				NDD				UB	IO
OU	5	13				NDD				UB	IO
OU	5	14				NDD				UB	IO
OU	5	15				NDD				UB	IO
OU	5	16	2.90	14	36	IDI	1	OU	56.47	UB	IO
OU	5	17				NDD				UB	IO
OU	5	18				NDD				UB	IO
OU	5	19				NDD				UB	IO
OU	5	20				NDD				UB	IO
OU	5	21				NDD				UB	IO
OU	5	22				NDD				UB	IO
OU	5	23				NDD				UB	IO
OU	5	24				NDD				UB	IO
OU	5	25				NDD				UB	IO
OU	5	26				NDD				UB	IO
OU	5	27				NDD				UB	IO
OU	5	28				NDD				UB	IO
OU	5	29				NDD				UB	IO
OU	5	30				NDD				UB	IO
OU	5	31				NDD				UB	IO
OU	5	32				NDD				UB	IO
OU	5	33				NDD				UB	IO
OU	5	34				NDD				UB	IO
OU	5	35				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	5	36				NDD				UB	IO
OU	5	37				NDD				UB	IO
OU	5	38				NDD				UB	IO
OU	5	39				NDD				UB	IO
OU	5	40				NDD				UB	IO
OU	5	41				NDD				UB	IO
OU	6	1				NDD				UB	IO
OU	6	2	6.75	0	38	WAR	6	OU	75.56	UB	IO
OU	6	3				NDD				UB	IO
OU	6	4				NDD				UB	IO
OU	6	5				NDD				UB	IO
OU	6	6				NDD				UB	IO
OU	6	7				NDD				UB	IO
OU	6	8				NDD				UB	IO
OU	6	9				NDD				UB	IO
OU	6	10				NDD				UB	IO
OU	6	11				NDD				UB	IO
OU	6	12				NDD				UB	IO
OU	6	13				NDD				UB	IO
OU	6	14				NDD				UB	IO
OU	6	15				NDD				UB	IO
OU	6	16				NDD				UB	IO
OU	6	17				NDD				UB	IO
OU	6	18				NDD				UB	IO
OU	6	19				NDD				UB	IO
OU	6	20				NDD				UB	IO
OU	6	21				NDD				UB	IO
OU	6	22				NDD				UB	IO
OU	6	23				NDD				UB	IO
OU	6	24				NDD				UB	IO
OU	6	25				NDD				UB	IO
OU	6	26				NDD				UB	IO
OU	6	27				NDD				UB	IO
OU	6	28				NDD				UB	IO
OU	6	29				NDD				UB	IO
OU	6	30				NDD				UB	IO
OU	6	31				NDD				UB	IO
OU	6	32				NDD				UB	IO
OU	6	33				NDD				UB	IO
OU	6	34				NDD				UB	IO
OU	6	35				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	6	36				NDD				UB	IO
OU	6	37				NDD				UB	IO
OU	6	38				NDD				UB	IO
OU	6	39				NDD				UB	IO
OU	6	40				NDD				UB	IO
OU	6	41				NDD				UB	IO
OU	6	42				NDD				UB	IO
OU	7	1				NDD				UB	IO
OU	7	2				NDD				UB	IO
OU	7	3				NDD				UB	IO
OU	7	4				NDD				UB	IO
OU	7	5				NDD				UB	IO
OU	7	6				NDD				UB	IO
OU	7	7				NDD				UB	IO
OU	7	8				NDD				UB	IO
OU	7	9				NDD				UB	IO
OU	7	10				NDD				UB	IO
OU	7	11				NDD				UB	IO
OU	7	12				NDD				UB	IO
OU	7	13				NDD				UB	IO
OU	7	14	2.10	11	28	IDI	1	OU	195.03	UB	IO
OU	7	15				NDD				UB	IO
OU	7	16				NDD				UB	IO
OU	7	17				NDD				UB	IO
OU	7	18				NDD				UB	IO
OU	7	19				NDD				UB	IO
OU	7	20				NDD				UB	IO
OU	7	21				NDD				UB	IO
OU	7	22				NDD				UB	IO
OU	7	23				NDD				UB	IO
OU	7	24				NDD				UB	IO
OU	7	25				NDD				UB	IO
OU	7	26				NDD				UB	IO
OU	7	27				NDD				UB	IO
OU	7	28				NDD				UB	IO
OU	7	29				NDD				UB	IO
OU	7	30				NDD				UB	IO
OU	7	31				NDD				UB	IO
OU	7	32				NDD				UB	IO
OU	7	33				NDD				UB	IO
OU	7	34				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	7	35				NDD				UB	IO
OU	7	36				NDD				UB	IO
OU	7	37				NDD				UB	IO
OU	7	38				NDD				UB	IO
OU	7	39				NDD				UB	IO
OU	7	40				NDD				UB	IO
OU	7	41				NDD				UB	IO
OU	8	1				NDD				UB	IO
OU	8	2				NDD				UB	IO
OU	8	3				NDD				UB	IO
OU	8	4				NDD				UB	IO
OU	8	5				NDD				UB	IO
OU	8	6				NDD				UB	IO
OU	8	7				NDD				UB	IO
OU	8	8				NDD				UB	IO
OU	8	9				NDD				UB	IO
OU	8	10				NDD				UB	IO
OU	8	11				NDD				UB	IO
OU	8	12				NDD				UB	IO
OU	8	13				NDD				UB	IO
OU	8	14				NDD				UB	IO
OU	8	15				NDD				UB	IO
OU	8	16				NDD				UB	IO
OU	8	17				NDD				UB	IO
OU	8	18				NDD				UB	IO
OU	8	19				NDD				UB	IO
OU	8	20				NDD				UB	IO
OU	8	21				NDD				UB	IO
OU	8	22				NDD				UB	IO
OU	8	23				NDD				UB	IO
OU	8	24				NDD				UB	IO
OU	8	25				NDD				UB	IO
OU	8	26				NDD				UB	IO
OU	8	27				NDD				UB	IO
OU	8	28				NDD				UB	IO
OU	8	29				NDD				UB	IO
OU	8	30				NDD				UB	IO
OU	8	31				NDD				UB	IO
OU	8	32				NDD				UB	IO
OU	8	33				NDD				UB	IO
OU	8	34				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	8	35				NDD				UB	IO
OU	8	36				NDD				UB	IO
OU	8	37				NDD				UB	IO
OU	8	38	2.96	9	23	IDI	1	OU	196.13	UB	IO
OU	8	39				NDD				UB	IO
OU	8	40				NDD				UB	IO
OU	8	41				NDD				UB	IO
OU	8	42				NDD				UB	IO
OU	9	1				NDD				UB	IO
OU	9	2				NDD				UB	IO
OU	9	3				NDD				UB	IO
OU	9	4				NDD				UB	IO
OU	9	5				NDD				UB	IO
OU	9	6				NDD				UB	IO
OU	9	7				NDD				UB	IO
OU	9	8				NDD				UB	IO
OU	9	9				NDD				UB	IO
OU	9	10				NDD				UB	IO
OU	9	11				NDD				UB	IO
OU	9	12				NDD				UB	IO
OU	9	13				NDD				UB	IO
OU	9	14				NDD				UB	IO
OU	9	15				NDD				UB	IO
OU	9	16				NDD				UB	IO
OU	9	17				NDD				UB	IO
OU	9	18				NDD				UB	IO
OU	9	19				NDD				UB	IO
OU	9	20				NDD				UB	IO
OU	9	21				NDD				UB	IO
OU	9	22				NDD				UB	IO
OU	9	23				NDD				UB	IO
OU	9	24				NDD				UB	IO
OU	9	25				NDD				UB	IO
OU	9	26				NDD				UB	IO
OU	9	27				NDD				UB	IO
OU	9	28				NDD				UB	IO
OU	9	29				NDD				UB	IO
OU	9	30				NDD				UB	IO
OU	9	31				NDD				UB	IO
OU	9	32				NDD				UB	IO
OU	9	33				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	9	34				NDD				UB	IO
OU	9	35				NDD				UB	IO
OU	9	36				NDD				UB	IO
OU	9	37				NDD				UB	IO
OU	9	38				NDD				UB	IO
OU	9	39				NDD				UB	IO
OU	9	40				NDD				UB	IO
OU	9	41				NDD				UB	IO
OU	10	1				NDD				UB	IO
OU	10	2				NDD				UB	IO
OU	10	3				NDD				UB	IO
OU	10	4				NDD				UB	IO
OU	10	5				NDD				UB	IO
OU	10	6				NDD				UB	IO
OU	10	7				NDD				UB	IO
OU	10	8				NDD				UB	IO
OU	10	9				NDD				UB	IO
OU	10	10				NDD				UB	IO
OU	10	11				NDD				UB	IO
OU	10	12				NDD				UB	IO
OU	10	13				NDD				UB	IO
OU	10	14				NDD				UB	IO
OU	10	15				NDD				UB	IO
OU	10	16				NDD				UB	IO
OU	10	17				NDD				UB	IO
OU	10	18				NDD				UB	IO
OU	10	19				NDD				UB	IO
OU	10	20				NDD				UB	IO
OU	10	21				NDD				UB	IO
OU	10	22				NDD				UB	IO
OU	10	23				NDD				UB	IO
OU	10	24				NDD				UB	IO
OU	10	25				NDD				UB	IO
OU	10	26				NDD				UB	IO
OU	10	27				NDD				UB	IO
OU	10	28				NDD				UB	IO
OU	10	29				NDD				UB	IO
OU	10	30				NDD				UB	IO
OU	10	31				NDD				UB	IO
OU	10	32				NDD				UB	IO
OU	10	33				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	10	34				NDD				UB	IO
OU	10	35				NDD				UB	IO
OU	10	36				NDD				UB	IO
OU	10	37				NDD				UB	IO
OU	10	38				NDD				UB	IO
OU	10	39				NDD				UB	IO
OU	10	40				NDD				UB	IO
OU	11	1				NDD				UB	IO
OU	11	2				NDD				UB	IO
OU	11	3				NDD				UB	IO
OU	11	4				NDD				UB	IO
OU	11	5				NDD				UB	IO
OU	11	6				NDD				UB	IO
OU	11	7				NDD				UB	IO
OU	11	8				NDD				UB	IO
OU	11	9				NDD				UB	IO
OU	11	10				NDD				UB	IO
OU	11	11				NDD				UB	IO
OU	11	12				NDD				UB	IO
OU	11	13				NDD				UB	IO
OU	11	14				NDD				UB	IO
OU	11	15				NDD				UB	IO
OU	11	16				NDD				UB	IO
OU	11	17				NDD				UB	IO
OU	11	18				NDD				UB	IO
OU	11	19				NDD				UB	IO
OU	11	20				NDD				UB	IO
OU	11	21				NDD				UB	IO
OU	11	22				NDD				UB	IO
OU	11	23				NDD				UB	IO
OU	11	24				NDD				UB	IO
OU	11	25				NDD				UB	IO
OU	11	26				NDD				UB	IO
OU	11	27				NDD				UB	IO
OU	11	28				NDD				UB	IO
OU	11	29				NDD				UB	IO
OU	11	30				NDD				UB	IO
OU	11	31				NDD				UB	IO
OU	11	32				NDD				UB	IO
OU	11	33				NDD				UB	IO
OU	11	34				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	11	35				NDD				UB	IO
OU	11	36				NDD				UB	IO
OU	11	37				NDD				UB	IO
OU	11	38				NDD				UB	IO
OU	11	39				NDD				UB	IO
OU	12	1				NDD				UB	IO
OU	12	2				NDD				UB	IO
OU	12	3				NDD				UB	IO
OU	12	4				NDD				UB	IO
OU	12	5				NDD				UB	IO
OU	12	6				NDD				UB	IO
OU	12	7				NDD				UB	IO
OU	12	8				NDD				UB	IO
OU	12	9				NDD				UB	IO
OU	12	10				NDD				UB	IO
OU	12	11				NDD				UB	IO
OU	12	12				NDD				UB	IO
OU	12	13				NDD				UB	IO
OU	12	14				NDD				UB	IO
OU	12	15				NDD				UB	IO
OU	12	16				NDD				UB	IO
OU	12	17				NDD				UB	IO
OU	12	18				NDD				UB	IO
OU	12	19				NDD				UB	IO
OU	12	20				NDD				UB	IO
OU	12	21				NDD				UB	IO
OU	12	22				NDD				UB	IO
OU	12	23				NDD				UB	IO
OU	12	24				NDD				UB	IO
OU	12	25				NDD				UB	IO
OU	12	26				NDD				UB	IO
OU	12	27				NDD				UB	IO
OU	12	28				NDD				UB	IO
OU	12	29				NDD				UB	IO
OU	12	30				NDD				UB	IO
OU	12	31				NDD				UB	IO
OU	12	32				NDD				UB	IO
OU	12	33				NDD				UB	IO
OU	12	34				NDD				UB	IO
OU	12	35				NDD				UB	IO
OU	12	36				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	12	37				NDD				UB	IO
OU	12	38				NDD				UB	IO
OU	13	1				NDD				UB	IO
OU	13	2				NDD				UB	IO
OU	13	3				NDD				UB	IO
OU	13	4				NDD				UB	IO
OU	13	5				NDD				UB	IO
OU	13	6				NDD				UB	IO
OU	13	7				NDD				UB	IO
OU	13	8				NDD				UB	IO
OU	13	9				NDD				UB	IO
OU	13	10				NDD				UB	IO
OU	13	11				NDD				UB	IO
OU	13	12				NDD				UB	IO
OU	13	13				NDD				UB	IO
OU	13	14				NDD				UB	IO
OU	13	15				NDD				UB	IO
OU	13	16				NDD				UB	IO
OU	13	17				NDD				UB	IO
OU	13	18				NDD				UB	IO
OU	13	19				NDD				UB	IO
OU	13	20				NDD				UB	IO
OU	13	21				NDD				UB	IO
OU	13	22				NDD				UB	IO
OU	13	23				NDD				UB	IO
OU	13	24				NDD				UB	IO
OU	13	25				NDD				UB	IO
OU	13	26				NDD				UB	IO
OU	13	27				NDD				UB	IO
OU	13	28				NDD				UB	IO
OU	13	29				NDD				UB	IO
OU	13	30				NDD				UB	IO
OU	13	31				NDD				UB	IO
OU	13	32				NDD				UB	IO
OU	13	33				NDD				UB	IO
OU	13	34				NDD				UB	IO
OU	13	35				NDD				UB	IO
OU	14	1	76.95	186		DNT	M1	OU	255.55	UB	IO
OU	14	2				NDD				UB	IO
OU	14	3				NDD				UB	IO
OU	14	4				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	14	5				NDD				UB	IO
OU	14	6				NDD				UB	IO
OU	14	7				NDD				UB	IO
OU	14	8				NDD				UB	IO
OU	14	9				NDD				UB	IO
OU	14	10				NDD				UB	IO
OU	14	11				NDD				UB	IO
OU	14	12				NDD				UB	IO
OU	14	13				NDD				UB	IO
OU	14	14				NDD				UB	IO
OU	14	15				NDD				UB	IO
OU	14	16				NDD				UB	IO
OU	14	17				NDD				UB	IO
OU	14	18				NDD				UB	IO
OU	14	19				NDD				UB	IO
OU	14	20				NDD				UB	IO
OU	14	21	1.17	59	93	ODI	1	OU	74.92	UB	IO
OU	14	22				NDD				UB	IO
OU	14	23				NDD				UB	IO
OU	14	24				NDD				UB	IO
OU	14	25				NDD				UB	IO
OU	14	26				NDD				UB	IO
OU	14	27				NDD				UB	IO
OU	14	28				NDD				UB	IO
OU	14	29				NDD				UB	IO
OU	14	30				NDD				UB	IO
OU	14	31				NDD				UB	IO
OU	14	32				NDD				UB	IO
OU	14	33				NDD				UB	IO
OU	14	34				NDD				UB	IO
OU	14	35				NDD				UB	IO
OU	14	36	45.94	186		DNT	M1	OU	225.00	UB	IO
OU	14	36	38.48	187		DNT	M1	OU	135.00	UB	IO
OU	15	1	48.81	188		DNT	M1	OU	225.00	UB	IO
OU	15	2				NDD				UB	IO
OU	15	3				NDD				UB	IO
OU	15	4				NDD				UB	IO
OU	15	5				NDD				UB	IO
OU	15	6				NDD				UB	IO
OU	15	7				NDD				UB	IO
OU	15	8				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	15	9				NDD				UB	IO
OU	15	10				NDD				UB	IO
OU	15	11				NDD				UB	IO
OU	15	12				NDD				UB	IO
OU	15	13				NDD				UB	IO
OU	15	14				NDD				UB	IO
OU	15	15				NDD				UB	IO
OU	15	16				NDD				UB	IO
OU	15	17				NDD				UB	IO
OU	15	18				NDD				UB	IO
OU	15	19				NDD				UB	IO
OU	15	20				NDD				UB	IO
OU	15	21				NDD				UB	IO
OU	15	22				NDD				UB	IO
OU	15	23				NDD				UB	IO
OU	15	24				NDD				UB	IO
OU	15	25				NDD				UB	IO
OU	15	26				NDD				UB	IO
OU	15	27				NDD				UB	IO
OU	15	28				NDD				UB	IO
OU	15	29				NDD				UB	IO
OU	15	30				NDD				UB	IO
OU	15	31				NDD				UB	IO
OU	15	32				NDD				UB	IO
OU	15	33				NDD				UB	IO
OU	15	34				NDD				UB	IO
OU	15	35				RES	1	OU	225.62	TS4	IO
OU	15	35	32.09	187		DNT	M1	OU	135.00	TS4	IO
OU	15	35	120.68	183		PVN	1	OU	225.70	TS6	IO
OU	16	1	65.27	7		DNT	M1	OU	225.00	UB	IO
OU	16	2				NDD				UB	IO
OU	16	3				NDD				UB	IO
OU	16	4				NDD				UB	IO
OU	16	5				NDD				UB	IO
OU	16	6				NDD				UB	IO
OU	16	7				NDD				UB	IO
OU	16	8				NDD				UB	IO
OU	16	9				NDD				UB	IO
OU	16	10				NDD				UB	IO
OU	16	11				NDD				UB	IO
OU	16	12				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	16	13				NDD				UB	IO
OU	16	14				NDD				UB	IO
OU	16	15				NDD				UB	IO
OU	16	16				NDD				UB	IO
OU	16	17				NDD				UB	IO
OU	16	18				NDD				UB	IO
OU	16	19				NDD				UB	IO
OU	16	20				NDD				UB	IO
OU	16	21				NDD				UB	IO
OU	16	22				NDD				UB	IO
OU	16	23				NDD				UB	IO
OU	16	24				NDD				UB	IO
OU	16	25				NDD				UB	IO
OU	16	26				NDD				UB	IO
OU	16	27				NDD				UB	IO
OU	16	28				NDD				UB	IO
OU	16	29				NDD				UB	IO
OU	16	30				NDD				UB	IO
OU	16	31				NDD				UB	IO
OU	16	32				NDD				UB	IO
OU	16	33				NDD				UB	IO
OU	16	34				RES	1	OU	226.61	TS4	IO
OU	16	34	113.19	186		DNT	M1	OU	135.00	TS4	IO
OU	16	34	173.75	183		PVN	1	OU	225.92	TS2	IO
OU	17	1	79.70	186		DNT	M1	OU	225.00	UB	IO
OU	17	2				NDD				UB	IO
OU	17	3				NDD				UB	IO
OU	17	4				NDD				UB	IO
OU	17	5				NDD				UB	IO
OU	17	6				NDD				UB	IO
OU	17	7				NDD				UB	IO
OU	17	8				NDD				UB	IO
OU	17	9				NDD				UB	IO
OU	17	10				NDD				UB	IO
OU	17	11				NDD				UB	IO
OU	17	12				NDD				UB	IO
OU	17	13				NDD				UB	IO
OU	17	14				NDD				UB	IO
OU	17	15				NDD				UB	IO
OU	17	16				NDD				UB	IO
OU	17	17				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	17	18				NDD				UB	IO
OU	17	19				NDD				UB	IO
OU	17	20				NDD				UB	IO
OU	17	21				NDD				UB	IO
OU	17	22				NDD				UB	IO
OU	17	23				NDD				UB	IO
OU	17	24				NDD				UB	IO
OU	17	25				NDD				UB	IO
OU	17	26				NDD				UB	IO
OU	17	27				NDD				UB	IO
OU	17	28	24.35	23		PVN	1	OU	10.23	UB	IO
OU	17	29				NDD				UB	IO
OU	17	30				NDD				UB	IO
OU	17	31	60.59	187		DNT	M1	OU	224.58	UB	IO
OU	18	1	126.91	186		DNT	M1	OU	224.86	UB	IO
OU	18	2	77.40	188		DNT	M1	OU	223.61	UB	IO
OU	18	3				NDD				UB	IO
OU	18	4				NDD				UB	IO
OU	18	5				NDD				UB	IO
OU	18	6				NDD				UB	IO
OU	18	7				NDD				UB	IO
OU	18	8				NDD				UB	IO
OU	18	9				NDD				UB	IO
OU	18	10				NDD				UB	IO
OU	18	11				NDD				UB	IO
OU	18	12				NDD				UB	IO
OU	18	13				NDD				UB	IO
OU	18	14				NDD				UB	IO
OU	18	15				NDD				UB	IO
OU	18	16				NDD				UB	IO
OU	18	17				NDD				UB	IO
OU	18	18				NDD				UB	IO
OU	18	19				NDD				UB	IO
OU	18	20				NDD				UB	IO
OU	18	21				NDD				UB	IO
OU	18	22	3.54	13	33	IDI	1	OU	199.43	UB	IO
OU	18	23	31.86	186		DNT	1	OU	0.04	UB	IO
OU	18	24				NDD				UB	IO
OU	18	25				NDD				UB	IO
OU	18	26				NDD				UB	IO
OU	18	27				NDD				UB	IO

Data Report
 East Kentucky Power Cooperative
 Spurlock Station
 Unit 2
 LPFWH-3
 06-2021


sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	18	28				NDD				UB	IO
OU	18	29				NDD				UB	IO
OU	18	30	111.72	187		DNT	M1	OU	224.27	UB	IO
OU	18	30	36.30	189		DNT	M1	OU	134.97	UB	IO
OU	19	1	116.39	188		DNT	M1	OU	225.00	UB	IO
OU	19	2				NDD				UB	IO
OU	19	3				NDD				UB	IO
OU	19	4				NDD				UB	IO
OU	19	5				NDD				UB	IO
OU	19	6				NDD				UB	IO
OU	19	7				NDD				UB	IO
OU	19	8				NDD				UB	IO
OU	19	9				NDD				UB	IO
OU	19	10				NDD				UB	IO
OU	19	11				NDD				UB	IO
OU	19	12				NDD				UB	IO
OU	19	13				NDD				UB	IO
OU	19	14				NDD				UB	IO
OU	19	15				NDD				UB	IO
OU	19	16				NDD				UB	IO
OU	19	17				NDD				UB	IO
OU	19	18				NDD				UB	IO
OU	19	19				NDD				UB	IO
OU	19	20				NDD				UB	IO
OU	19	21				NDD				UB	IO
OU	19	22				NDD				UB	IO
OU	19	23				NDD				UB	IO
OU	19	24				NDD				UB	IO
OU	19	25				NDD				UB	IO
OU	19	26	61.43	189		DNT	M1	OU	225.00	UB	IO
OU	20	1	64.91	187		DNT	M1	OU	225.00	UB	IO
OU	20	2				NDD				UB	IO
OU	20	3				NDD				UB	IO
OU	20	4				NDD				UB	IO
OU	20	5				NDD				UB	IO
OU	20	6				NDD				UB	IO
OU	20	7				NDD				UB	IO
OU	20	8				NDD				UB	IO
OU	20	9				NDD				UB	IO
OU	20	10				NDD				UB	IO
OU	20	11				NDD				UB	IO

Data Report
East Kentucky Power Cooperative
Spurlock Station
Unit 2
LPFWH-3
06-2021

sec	row	tube	volts	phase	pcnt	defect	chan	loc_land	loc_off	beg_test	end_test
OU	20	12				NDD				UB	IO
OU	20	13				NDD				UB	IO
OU	20	14				NDD				UB	IO
OU	20	15				NDD				UB	IO
OU	20	16				NDD				UB	IO
OU	20	17				NDD				UB	IO
OU	20	18				NDD				UB	IO
OU	20	19				NDD				UB	IO
OU	20	20				NDD				UB	IO
OU	20	21				NDD				UB	IO
OU	20	22				NDD				UB	IO
OU	20	23				NDD				UB	IO
OU	20	24	27.71	190		DNT	M1	OU	224.70	UB	IO

TO BE PLUGGED MAP
EAST KENTUCKY POWER COOPERATIVE
SPURLOCK STATION
UNIT 2
LPFWH-3
06-2021


VIEW FROM: INLET/OUTLET



SYM	HITS	TUBES	VIS	TYPE	DESCRIPTION	Model LPFWH-3 (1,482 tubes) 1,476 open tubes
■	6	6	6	LIST FILL	To Be Plugged Map	
	6	6	6			

TUBESHEET LAYOUT MAP
EAST KENTUCKY POWER COOPERATIVE
SPURLOCK STATION
UNIT 2
LPFWH-3

VIEW FROM:INLET/OUTLET



Model LPFWH-3 (1,482 tubes)
1,482 open tubes



3.0 INSPECTION PROCEDURE

Technicians

Conco EC technicians are certified to CSC-QAP-9.1 (SNT-TC-1A guidelines, CP-189) and also trained in confined space, first aid, and CPR. All Conco Analysts have passed an industry recognized Data-Analysis level IIA or level IIIA class.

Process

All inspections are performed in accordance with CSC-NDE-11.0 Rev 4 Data Acquisition and Analysis. Conco will use CoreStar equipment recording data with 4 frequencies and on 8 channels (4-differential channels and 4-absolute channels). The data will be recorded on medium consistent with the tester used (Magnetic Optical disk, compact flash disk, or USB flash drive). The data will be interpreted by qualified data analyst using the CoreStar analysis software. The results will be stored in the CoreStar DBMS software. This will enable future trending and inspection planning of the unit. While on site, Conco will visually inspect the tube sheet and they will generate a list of plugged tubes to be included on the tube sheet maps. All test equipment will be visually inspected prior to use to ensure the equipment is suitable for the inspection. All test equipment will also be within calibration as per manufacture specifications.

Eddy Current probes are purchased to conform to specific metallurgical characteristics, inside diameter and wall thickness of the tubes in this proposal. The probe diameter is calculated to achieve a fill-factor of approximately 85% between the probe head diameter and the tube ID.

We propose to use our services on a "best effort" basis. The detection of particular defect or variable in the material tested cannot be guaranteed.



CONCO SERVICES LLC
 530 JONES STREET · VERONA, PA 15147
 (412) 828-1166 · FAX: (412) 826-8255

Form No	1085
Title	Examination Technique Specification Sheet OMNI
Revision:	2
Date:	January 3, 2017
Page 1 of 4	

Utility/Site/Unit: East Kentucky Power Cooperative/Spurlock/Unit 2		ETSS Version: 1		Date: 06/10/2021	
Component: LPFWH		Component ID: 3			
Examination Scope					
Applicability: This technique is for the bobbin examination of 0.750" x .035" wall 304 SS tubes					
Instrument			Tubing		
Manufacturer/Model: CoreStar OMNI 200/100			Material Type: 304 SS		
			# Of Tubes: 741 U-Bend (1482 Straight Length)		
			OD/Wall (inch): 0.75" / 0.035"		
Data Recording Equipment			Length: ~30'		
Manuf./Media: Hard drive / Network or Equiv			Calibration Standard(s)		
Software			Type/SN: ASME CSC-434		
Manufacturer: Corestar			Type/SN: Wall Thinning CSC-432		
			Type/SN: Internal Reference		
			Analog Signal Path		
Version/Revision: 8.1			Probe Shaft /Length: 40"		
Examination Procedure			Extension Type & Length N/A		
Number/Revision: CSC-NDE-11.0 Rev 4			Slip Ring Model Number: N/A		
Scan Parameters					
Scan Direction: Pull					
Digitization Rate, Samples Per Inch (minimum): ≥ 30 SPI		Axial Direction: Pull	N/A	Circ. Direction	N/A
Probe Speed	Sample Rate	RPM Set	RPM Min	RPM Max	
46 inches / second	2000 (Max.)	N/A	N/A	N/A	
30 inches / second	1200 (Min.)	N/A	N/A	N/A	
Probe/Motor Unit					
Description (Model/Diameter/Frequency/Coil Dimensions)		Manufacturer		Length	
630 ESH/MF		Corestar		N/A	
610 ESH/MF		Corestar		N/A	
Data Acquisition					
Calibration Coil 1 Channels					
Channel & Frequency	Channel #1 600 kHz	Channel #3 300 kHz	Channel #5 150 kHz	Channel #7 75 kHz	
Phase Rotation	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	
Span Setting	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	
Drive Voltage	75%	75%	75%	75%	
Gain Setting	14	14	14	14	
Calibration Coil 2 Channels					
Channel & Frequency	Channel #2 600 kHz	Channel #4 300 kHz	Channel #6 150 kHz	Channel #8 75 kHz	
Phase Rotation	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	
Span Setting	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	
Drive Voltage	75%	75%	75%	75%	
Gain setting	8	8	8	8	

Examination Technique Specification Sheet

Configuration Board Settings

OMNI-200 1 - 035 WALL 304 SS.cfg

File Edit View Probe Util Help

TEST LINK BALANCE REF NULL HW NULL IP Address 192.168.9.1

Config Options Scope Waveform Freq Sweep Status

Sample Rate 1,600 Num Chan 8 Trigger Internal

Config Options Probe Options AUX Chans

Continuous Mode Ghent/S10 Time

32-bit Mode High Speed RPC Encoders

Dynamic Gain Array Outputs RMS

Internal Reference X-Probe Clock Gains

Time Slew Sample Index

Increment Caps Status & IO

Auto Stop Sample Flags

No Powerdown

Synch Outputs Or

TIME SLOT	#	DRIVER		COIL									
		FREQUENCY	DRIVE	1	2	3	4	5	6	7	8		
1	1	600.000 KHz	100.00%	1	2								
2	1	300.000 KHz	100.00%	3	4								
3	1	150.000 KHz	100.00%	5	6								
4	1	75.000 KHz	100.00%	7	8								

SLOT	DELAY (µs)	INTEG (wave)	TIME (µs)	ENCODER				
				1	2	3	4	5
1	40	68	154					
2	40	34	154					
3	40	18	161					
4	40	8	147					

SLOT	COIL INPUT GAIN (dB)							
	1	2	3	4	5	6	7	8
1	14	8						
2	14	8						
3	14	8						
4	14	8						

COIL	DR1	DR3	BC	HN	RPT	CAP	NAME
1	DIF					A	0
2	ABS					A	0
3							
4							
5							
6							
7							
8							

618 of 625 µs


OK Cancel

Special Instructions for Data Acquisition

1. Probes should be pulled @ 40 inches/second or less.
2. Review each data channel and ensure that adequate/expected signal responses are achieved before recording the calibration. Do not record data until the proper spans and rotations have been set.
3. Monitor the data by setting the left strip chart to channel 1 vertical, right strip chart to channel 6 vertical and the lissajous display set to channel 1 as a minimum. The operator will determine the specific strip chart settings and lissajous display to verify the system is functioning properly and that data quality is acceptable.
4. Follow the Conco NDE procedure CSC-NDE-11.0 Rev 4.
5. Encode the tube ID's as per map for respective sections.
6. The initial exam attempt shall be performed with the 630 ESH/HF probe.
7. Tubes that will not allow the probe to enter, report as "Obstructed".
8. Tubes unable to be examine the desired extent, report as "Restricted".
9. Write a message for all tubes that are unable to be examined full length explaining the reason.
10. Encode the ASME Std. as "999", Thinning Std as "999" with a message.
11. Perform "System Null" only if "Display Null" is ineffective in balancing the signal.

Examination Technique Specification Sheet

Data Analysis						
Calibration Differential Channels						
Channel & Frequency	Channel #1 600 kHz	Channel #3 300 kHz	Channel #5 150 kHz	Channel #7 75 kHz		
Phase Rotation	100% TWH 40 degrees \pm 3	100% TWH 40 degrees \pm 3	100% TWH 40 degrees \pm 3	100% TWH 40 degrees \pm 3		
Span Setting Minimum	100% TWH @ 4 divisions	100% TWH @ 4 divisions	100% TWH @ 4 divisions	100% TWH @ 4 divisions		
Calibration Absolute Channels						
Channel & Frequency	Channel #2 600 kHz	Channel #4 300 kHz	Channel #6 150 kHz	Channel #8 75 kHz		
Phase Rotation	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up		
Span Setting Minimum	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions		
Calibration Process and Other Channels						
Channel & Frequency	M-1 1/5 Diff	M-2 4/6 Abs.	M-3 / Diff.	M-4 / Diff.		
Phase Rotation	100% TWH 40 degrees \pm 3	Probe Motion Horiz. Flaws Up				
Span Setting Minimum	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions				
Suppress On	Support Ring	Support Ring				
Voltage Normalization				Calibration Curves		
CH	Signal	Set	Normalize	Type	CH	Set Points
1	4x20% FBH	4 Vp-p	Save/Store to all	Phase Curve	1, 3, 5, M1	100,60,20%
1	4x20% FBH	4 Vp-p	Save/Store to all	Magnitude Curve	6, M2	75, 50,25%
Data Screening						
Left Strip Chart	Center Strip Chart	Right Strip Chart	Left Lissajous	Right Lissajous		
Channel M1 Vertical	Channel 1 Vertical	Channel 6 Vertical	Channel 1	Channel 6		

Special Instructions for Analysis	
<ol style="list-style-type: none"> 1. Calibration curves shall be constructed using the "As-Built" dimensions from the calibration standard drawings. 2. Normalize to 4 volts on the 4 X 20% flat bottom holes using channel #1 differential and store to all channels. 3. All Quantifiable indications of tube wall degradation \geq 20% TW and 1 Volt shall be reported (however, not to exceed 6 reportable ID defects). 4. Locate all defect indications in inches measured from the test end. 5. Previously reported indications shall be addressed by the primary analyst. Report previously reported Inds. In same channel as history. Report previous indications that are not found as "INF" and indications not recordable as "INR". 6. If test data appears to be un-interpretable shall be report as "RBD". 	
Job Lead Approval  Signature /Date: Tom Dolgas Level IIA / 06-10-2021	Customer Approval (if required) Signature /Date
Additional Component Information	

Site

Owner: EKPC

Site Code: SPURLOCK Unit: 2

Comp: LP_FWH-3 Model: default

Outage: 06-2021 Date: 06/10/2021

Cal

Cal Num: 2 Disk Leg: INLET

Material: 304 SS ID: 0.750 OD: 0.750

Operators

Operator ID: W4524 Level: II

Operator ID: B6068 Level: I

Standards

Type: ASME SN: CSC-434

Type: W/T SN: CSC-432

Type: SN:

Probe

Model: 630 ESH/HF Vendor: CORESTAR

Ext Type: Vendor:

Head Size: 630 Head SN:

Shaft Length: 65 Shaft SN:

Ext Length: 0 Ref Head SN:

Slip SN: Ref Shaft SN:

Tester Config

IDX	TYPE	CHAN	FREQ	SPAN	Y/X	ROT	COIL	CTX
1	DATA32	1	600 KHz	90		210°	1 DIF	1
2	DATA32	2	600 KHz	40		227°	2 ABS	1
3	DATA32	3	300 KHz	136		52°	1 DIF	2
4	DATA32	4	300 KHz	40		64°	2 ABS	2
5	DATA32	5	150 KHz	60		321°	1 DIF	3
6	DATA32	6	150 KHz	204		339°	2 ABS	3
7	DATA32	7	75 KHz	40		262°	1 DIF	4
8	DATA32	8	75 KHz	40		282°	2 ABS	4

Config: 035 WALL 304 SS

Auto Mode: Manual

Sample Rate: 1,600 Num Cha: 8 Offset: 1,734

Acq Speed: 24.00 RPC RPM Acq Dir: PULL

File

Source: CoreStar Samples: 28,960

Procedure:

Software: CoreStar EddyVision 8.1

Equipment


Tester: OMNI-200 SN: 0007-0910

Pusher: SN:

Fixture: SN:


OMNI 200 SN 0007-0910 CAL DUE 20JULY2021

CH 1 600 KHz DEG Curve




Phase	%	Phase	%	Phase	%	Phase	%	Phase	%	Phase	%
0.0	0	33.0	83	66.0	92	99.0	77	132.0	56	165.0	25
1.0	3	34.0	86	67.0	91	100.0	76	133.0	55	166.0	24
2.0	5	35.0	88	68.0	91	101.0	76	134.0	54	167.0	23
3.0	8	36.0	91	69.0	90	102.0	75	135.0	53	168.0	22
4.0	10	37.0	93	70.0	90	103.0	75	136.0	53	169.0	21
5.0	13	38.0	96	71.0	90	104.0	74	137.0	52	170.0	20
6.0	15	39.0	98	72.0	89	105.0	74	138.0	51	171.0	19
7.0	18	40.0	100	73.0	89	106.0	73	139.0	50	172.0	17
8.0	20	41.0	100	74.0	88	107.0	72	140.0	49	173.0	16
9.0	23	42.0	99	75.0	88	108.0	72	141.0	49	174.0	15
10.0	25	43.0	99	76.0	88	109.0	71	142.0	48	175.0	14
11.0	28	44.0	99	77.0	87	110.0	71	143.0	47	176.0	13
12.0	30	45.0	98	78.0	87	111.0	70	144.0	46	177.0	11
13.0	33	46.0	98	79.0	86	112.0	69	145.0	45	178.0	10
14.0	35	47.0	98	80.0	86	113.0	69	146.0	44	179.0	9
15.0	38	48.0	98	81.0	86	114.0	68	147.0	43		
16.0	40	49.0	97	82.0	85	115.0	68	148.0	42		
17.0	43	50.0	97	83.0	85	116.0	67	149.0	41		
18.0	45	51.0	97	84.0	84	117.0	66	150.0	41		
19.0	48	52.0	96	85.0	84	118.0	66	151.0	40		
20.0	50	53.0	96	86.0	83	119.0	65	152.0	39		
21.0	53	54.0	96	87.0	83	120.0	64	153.0	38		
22.0	55	55.0	95	88.0	82	121.0	64	154.0	37		
23.0	58	56.0	95	89.0	82	122.0	63	155.0	36		
24.0	60	57.0	95	90.0	81	123.0	62	156.0	35		
25.0	63	58.0	94	91.0	81	124.0	62	157.0	34		
26.0	65	59.0	94	92.0	80	125.0	61	158.0	33		
27.0	68	60.0	94	93.0	80	126.0	60	159.0	32		
28.0	71	61.0	93	94.0	79	127.0	59	160.0	31		
29.0	73	62.0	93	95.0	79	128.0	59	161.0	30		
30.0	76	63.0	93	96.0	78	129.0	58	162.0	29		
31.0	78	64.0	92	97.0	78	130.0	57	163.0	28		
32.0	81	65.0	92	98.0	77	131.0	57	164.0	26		

CH 3 300 KHz DEG Curve




Phase	%	Phase	%	Phase	%	Phase	%	Phase	%	Phase	%
0.0	0	33.0	82	66.0	82	99.0	44	132.0	0	165.0	0
1.0	2	34.0	85	67.0	81	100.0	43	133.0	0	166.0	0
2.0	5	35.0	87	68.0	80	101.0	41	134.0	0	167.0	0
3.0	7	36.0	89	69.0	79	102.0	40	135.0	0	168.0	0
4.0	10	37.0	92	70.0	78	103.0	38	136.0	0	169.0	0
5.0	12	38.0	94	71.0	77	104.0	37	137.0	0	170.0	0
6.0	15	39.0	97	72.0	76	105.0	35	138.0	0	171.0	0
7.0	17	40.0	99	73.0	75	106.0	34	139.0	0	172.0	0
8.0	20	41.0	100	74.0	74	107.0	32	140.0	0	173.0	0
9.0	22	42.0	99	75.0	73	108.0	30	141.0	0	174.0	0
10.0	25	43.0	98	76.0	72	109.0	29	142.0	0	175.0	0
11.0	27	44.0	98	77.0	71	110.0	27	143.0	0	176.0	0
12.0	30	45.0	97	78.0	70	111.0	25	144.0	0	177.0	0
13.0	32	46.0	97	79.0	69	112.0	23	145.0	0	178.0	0
14.0	35	47.0	96	80.0	68	113.0	22	146.0	0	179.0	0
15.0	37	48.0	95	81.0	67	114.0	20	147.0	0		
16.0	40	49.0	95	82.0	66	115.0	18	148.0	0		
17.0	42	50.0	94	83.0	65	116.0	16	149.0	0		
18.0	45	51.0	93	84.0	64	117.0	14	150.0	0		
19.0	47	52.0	93	85.0	62	118.0	12	151.0	0		
20.0	50	53.0	92	86.0	61	119.0	10	152.0	0		
21.0	52	54.0	91	87.0	60	120.0	8	153.0	0		
22.0	55	55.0	90	88.0	59	121.0	6	154.0	0		
23.0	57	56.0	90	89.0	58	122.0	4	155.0	0		
24.0	60	57.0	89	90.0	56	123.0	2	156.0	0		
25.0	62	58.0	88	91.0	55	124.0	0	157.0	0		
26.0	65	59.0	87	92.0	54	125.0	0	158.0	0		
27.0	67	60.0	87	93.0	53	126.0	0	159.0	0		
28.0	70	61.0	86	94.0	51	127.0	0	160.0	0		
29.0	72	62.0	85	95.0	50	128.0	0	161.0	0		
30.0	75	63.0	84	96.0	49	129.0	0	162.0	0		
31.0	77	64.0	83	97.0	47	130.0	0	163.0	0		
32.0	80	65.0	82	98.0	46	131.0	0	164.0	0		

CH 5 150 KHz DEG Curve




Phase	%	Phase	%	Phase	%	Phase	%	Phase	%	Phase	%
0.0	0	33.0	83	66.0	57	99.0	0	132.0	0	165.0	0
1.0	3	34.0	86	67.0	55	100.0	0	133.0	0	166.0	0
2.0	5	35.0	88	68.0	53	101.0	0	134.0	0	167.0	0
3.0	8	36.0	91	69.0	51	102.0	0	135.0	0	168.0	0
4.0	10	37.0	93	70.0	49	103.0	0	136.0	0	169.0	0
5.0	13	38.0	96	71.0	47	104.0	0	137.0	0	170.0	0
6.0	15	39.0	98	72.0	45	105.0	0	138.0	0	171.0	0
7.0	18	40.0	100	73.0	42	106.0	0	139.0	0	172.0	0
8.0	20	41.0	98	74.0	40	107.0	0	140.0	0	173.0	0
9.0	23	42.0	97	75.0	38	108.0	0	141.0	0	174.0	0
10.0	25	43.0	95	76.0	36	109.0	0	142.0	0	175.0	0
11.0	28	44.0	94	77.0	34	110.0	0	143.0	0	176.0	0
12.0	30	45.0	92	78.0	32	111.0	0	144.0	0	177.0	0
13.0	33	46.0	91	79.0	29	112.0	0	145.0	0	178.0	0
14.0	35	47.0	89	80.0	27	113.0	0	146.0	0	179.0	0
15.0	38	48.0	88	81.0	25	114.0	0	147.0	0		
16.0	40	49.0	86	82.0	23	115.0	0	148.0	0		
17.0	43	50.0	85	83.0	20	116.0	0	149.0	0		
18.0	45	51.0	83	84.0	18	117.0	0	150.0	0		
19.0	48	52.0	81	85.0	15	118.0	0	151.0	0		
20.0	50	53.0	80	86.0	13	119.0	0	152.0	0		
21.0	53	54.0	78	87.0	11	120.0	0	153.0	0		
22.0	55	55.0	76	88.0	8	121.0	0	154.0	0		
23.0	58	56.0	75	89.0	6	122.0	0	155.0	0		
24.0	60	57.0	73	90.0	3	123.0	0	156.0	0		
25.0	63	58.0	71	91.0	0	124.0	0	157.0	0		
26.0	65	59.0	70	92.0	0	125.0	0	158.0	0		
27.0	68	60.0	68	93.0	0	126.0	0	159.0	0		
28.0	70	61.0	66	94.0	0	127.0	0	160.0	0		
29.0	73	62.0	64	95.0	0	128.0	0	161.0	0		
30.0	75	63.0	62	96.0	0	129.0	0	162.0	0		
31.0	78	64.0	60	97.0	0	130.0	0	163.0	0		
32.0	80	65.0	58	98.0	0	131.0	0	164.0	0		

CH 6 150 KHz VOLT Curve




Volts	%	Volts	%	Volts	%	Volts	%	Volts	%
0.0	0	16.5	59	33.0	76	49.5	87	66.0	95
0.5	6	17.0	59	33.5	77	50.0	87	66.5	95
1.0	10	17.5	60	34.0	77	50.5	88	67.0	95
1.5	14	18.0	61	34.5	77	51.0	88	67.5	95
2.0	18	18.5	62	35.0	78	51.5	88	68.0	95
2.5	21	19.0	62	35.5	78	52.0	88	68.5	96
3.0	23	19.5	63	36.0	79	52.5	89	69.0	96
3.5	26	20.0	63	36.5	79	53.0	89	69.5	96
4.0	28	20.5	64	37.0	79	53.5	89	70.0	96
4.5	30	21.0	65	37.5	80	54.0	89	70.5	96
5.0	32	21.5	65	38.0	80	54.5	90	71.0	97
5.5	34	22.0	66	38.5	80	55.0	90	71.5	97
6.0	36	22.5	66	39.0	81	55.5	90	72.0	97
6.5	38	23.0	67	39.5	81	56.0	90	72.5	97
7.0	39	23.5	68	40.0	81	56.5	91	73.0	97
7.5	41	24.0	68	40.5	82	57.0	91	73.5	98
8.0	42	24.5	69	41.0	82	57.5	91	74.0	98
8.5	43	25.0	69	41.5	82	58.0	91	74.5	98
9.0	45	25.5	70	42.0	83	58.5	91	75.0	98
9.5	46	26.0	70	42.5	83	59.0	92	75.5	98
10.0	47	26.5	71	43.0	83	59.5	92	76.0	98
10.5	48	27.0	71	43.5	84	60.0	92	76.5	99
11.0	49	27.5	72	44.0	84	60.5	92	77.0	99
11.5	50	28.0	72	44.5	84	61.0	93	77.5	99
12.0	51	28.5	72	45.0	84	61.5	93	78.0	99
12.5	52	29.0	73	45.5	85	62.0	93	78.5	99
13.0	53	29.5	73	46.0	85	62.5	93	79.0	100
13.5	54	30.0	74	46.5	85	63.0	93	79.5	100
14.0	55	30.5	74	47.0	86	63.5	94	80.0	100
14.5	56	31.0	75	47.5	86	64.0	94	80.5	100
15.0	56	31.5	75	48.0	86	64.5	94	81.0	100
15.5	57	32.0	75	48.5	86	65.0	94		
16.0	58	32.5	76	49.0	87	65.5	94		

MIX 1 1:5 DEG Curve



Phase	%	Phase	%	Phase	%	Phase	%	Phase	%	Phase	%
0.0	0	33.0	83	66.0	88	99.0	67	132.0	37	165.0	0
1.0	3	34.0	86	67.0	88	100.0	67	133.0	36	166.0	0
2.0	5	35.0	88	68.0	87	101.0	66	134.0	35	167.0	0
3.0	8	36.0	91	69.0	86	102.0	65	135.0	34	168.0	0
4.0	10	37.0	93	70.0	86	103.0	64	136.0	33	169.0	0
5.0	13	38.0	96	71.0	85	104.0	63	137.0	32	170.0	0
6.0	15	39.0	99	72.0	85	105.0	63	138.0	31	171.0	0
7.0	18	40.0	100	73.0	84	106.0	62	139.0	29	172.0	0
8.0	20	41.0	99	74.0	84	107.0	61	140.0	28	173.0	0
9.0	23	42.0	99	75.0	83	108.0	60	141.0	27	174.0	0
10.0	25	43.0	99	76.0	83	109.0	59	142.0	26	175.0	0
11.0	28	44.0	98	77.0	82	110.0	59	143.0	25	176.0	0
12.0	30	45.0	98	78.0	81	111.0	58	144.0	23	177.0	0
13.0	33	46.0	97	79.0	81	112.0	57	145.0	22	178.0	0
14.0	35	47.0	97	80.0	80	113.0	56	146.0	21	179.0	0
15.0	38	48.0	97	81.0	80	114.0	55	147.0	20		
16.0	40	49.0	96	82.0	79	115.0	54	148.0	18		
17.0	43	50.0	96	83.0	78	116.0	53	149.0	17		
18.0	45	51.0	95	84.0	78	117.0	52	150.0	16		
19.0	48	52.0	95	85.0	77	118.0	51	151.0	14		
20.0	51	53.0	94	86.0	76	119.0	51	152.0	13		
21.0	53	54.0	94	87.0	76	120.0	50	153.0	12		
22.0	56	55.0	93	88.0	75	121.0	49	154.0	10		
23.0	58	56.0	93	89.0	74	122.0	48	155.0	9		
24.0	61	57.0	93	90.0	74	123.0	47	156.0	8		
25.0	63	58.0	92	91.0	73	124.0	46	157.0	6		
26.0	66	59.0	92	92.0	72	125.0	45	158.0	5		
27.0	68	60.0	91	93.0	72	126.0	44	159.0	3		
28.0	71	61.0	91	94.0	71	127.0	43	160.0	2		
29.0	73	62.0	90	95.0	70	128.0	42	161.0	0		
30.0	76	63.0	90	96.0	70	129.0	41	162.0	0		
31.0	78	64.0	89	97.0	69	130.0	40	163.0	0		
32.0	81	65.0	89	98.0	68	131.0	38	164.0	0		

MIX 2 4:6 VOLT Curve



Volts	%	Volts	%	Volts	%	Volts	%	Volts	%	Volts	%	Volts	%	Volts	%	Volts	%
0.0	0	6.6	56	13.2	71	19.8	80	26.4	86	33.0	91	39.6	95	46.2	99		
0.2	6	6.8	56	13.4	71	20.0	80	26.6	86	33.2	91	39.8	96	46.4	99		
0.4	11	7.0	57	13.6	71	20.2	80	26.8	87	33.4	92	40.0	96	46.6	99		
0.6	15	7.2	57	13.8	72	20.4	80	27.0	87	33.6	92	40.2	96	46.8	99		
0.8	18	7.4	58	14.0	72	20.6	81	27.2	87	33.8	92	40.4	96	47.0	99		
1.0	21	7.6	59	14.2	72	20.8	81	27.4	87	34.0	92	40.6	96	47.2	99		
1.2	24	7.8	59	14.4	73	21.0	81	27.6	87	34.2	92	40.8	96	47.4	100		
1.4	26	8.0	60	14.6	73	21.2	81	27.8	87	34.4	92	41.0	96	47.6	100		
1.6	29	8.2	60	14.8	73	21.4	81	28.0	88	34.6	92	41.2	96	47.8	100		
1.8	30	8.4	61	15.0	73	21.6	82	28.2	88	34.8	92	41.4	96	48.0	100		
2.0	32	8.6	61	15.2	74	21.8	82	28.4	88	35.0	93	41.6	97	48.2	100		
2.2	34	8.8	62	15.4	74	22.0	82	28.6	88	35.2	93	41.8	97	48.4	100		
2.4	36	9.0	62	15.6	74	22.2	82	28.8	88	35.4	93	42.0	97	48.6	100		
2.6	37	9.2	63	15.8	75	22.4	82	29.0	88	35.6	93	42.2	97	48.8	100		
2.8	38	9.4	63	16.0	75	22.6	83	29.2	88	35.8	93	42.4	97				
3.0	40	9.6	64	16.2	75	22.8	83	29.4	89	36.0	93	42.6	97				
3.2	41	9.8	64	16.4	75	23.0	83	29.6	89	36.2	93	42.8	97				
3.4	42	10.0	65	16.6	76	23.2	83	29.8	89	36.4	93	43.0	97				
3.6	43	10.2	65	16.8	76	23.4	83	30.0	89	36.6	94	43.2	97				
3.8	44	10.4	65	17.0	76	23.6	84	30.2	89	36.8	94	43.4	98				
4.0	45	10.6	66	17.2	77	23.8	84	30.4	89	37.0	94	43.6	98				
4.2	46	10.8	66	17.4	77	24.0	84	30.6	90	37.2	94	43.8	98				
4.4	47	11.0	67	17.6	77	24.2	84	30.8	90	37.4	94	44.0	98				
4.6	48	11.2	67	17.8	77	24.4	84	31.0	90	37.6	94	44.2	98				
4.8	49	11.4	67	18.0	78	24.6	85	31.2	90	37.8	94	44.4	98				
5.0	50	11.6	68	18.2	78	24.8	85	31.4	90	38.0	94	44.6	98				
5.2	51	11.8	68	18.4	78	25.0	85	31.6	90	38.2	95	44.8	98				
5.4	51	12.0	69	18.6	78	25.2	85	31.8	90	38.4	95	45.0	98				
5.6	52	12.2	69	18.8	79	25.4	85	32.0	91	38.6	95	45.2	98				
5.8	53	12.4	69	19.0	79	25.6	85	32.2	91	38.8	95	45.4	99				
6.0	54	12.6	70	19.2	79	25.8	86	32.4	91	39.0	95	45.6	99				
6.2	54	12.8	70	19.4	79	26.0	86	32.6	91	39.2	95	45.8	99				
6.4	55	13.0	70	19.6	79	26.2	86	32.8	91	39.4	95	46.0	99				



CONCO SERVICES LLC
 530 JONES STREET · VERONA, PA 15147
 (412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 1 of 12	

Title: Data Acquisition & Analysis

	Name	Date	Initials
Written	Frank Jerina	June 15, 2010	On File
Revised	James Kocher	January 7, 2021	Jak
Reviewed	James Halloran	January 8, 2021	JH
Approved	Regina Godish	Jan 8, 2021	RG
Approved	Edward Saxon	JAN 8, 2021	ES
LIII Approval	Jeff Pomarico	1/8/2021	JP

1. Purpose/ Scope

This procedure establishes the techniques for performing multi-frequency eddy current (ET) examination of non-ferromagnetic heat exchanger tubing. This includes magnetic saturation techniques for mildly ferritic thin walled tubing. All personnel utilizing the procedure shall follow each manufacturer's instructions and operations of the applicable instrumentation used.

2. Attachments

2.1. Sample Examination Technique Specification Sheet (ETSS)

3. References

3.1. ASME Boiler and Pressure Vessel Code, Section XI (2007 edition, through 2009 addenda).

3.2. ASME Boiler and Pressure Vessel Code, Section V, Article 8 (2007 edition, through 2009 addenda).

3.3. CSC-QAP-9.1 – "Certification of NDE Personnel"

3.4. CSC-QAP-12.1 – "Control of M&TE"

3.5. CSC-NDE-3.4 – "Optimum Test Frequency Manual"

4. Definitions

4.1. ASME – American society of Mechanical Engineers.

4.2. Absolute Test (external-reference) – An eddy current test utilizing one inspection coil in the test material, which references against another single coil in a reference material.

4.3. Differential Test (self-comparison) – An eddy current test arrangement utilizing, two or more inspection coils electrically connected in series opposition, which compares a section of the test specimen against another section of the same test specimen.

4.4. ASME Calibration Standard – A specimen of the same material, size, wall thickness, and heat treatment, as the material being inspected. This standard may contain artificial discontinuities used for system set-up.

4.5. Reference Standard – A material of the same size, wall thickness, and heat treatment, as the material being inspected. This standard shall be free from defects and used for comparison purposes.



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 2 of 12	

- 4.6. Examination Technique Specification Sheet (ETSS) – Documentation completed by the Lead Analyst (or designee), that outlines the eddy current parameters for a particular inspection. The ETSS contains specific information regarding the test subject, frequency selection, setup parameters, proper probes and test equipment required to complete the inspection. The ETSS also outlines the analysis parameters such as voltage settings, reporting channels, curves (phase or magnitude), reporting thresholds and applicable codes for defects and other conditions encountered.
5. Responsibilities
 - 5.1. Level IT personnel may operate equipment under the direct supervision of a Level II or Level III. Level IT personnel shall not evaluate or accept the results of a nondestructive examination.
 - 5.2. Level I personnel shall use written procedures when performing specific setups, calibrations, and examinations and when recording data. The activities shall be conducted under the direct guidance of Level II or Level III personnel. Level I NDE personnel shall not evaluate or accept the results of a nondestructive examination.
 - 5.3. Level II personnel shall be familiar with the operation of the equipment, applicable examination techniques, and recording of the examination data. Level II personnel shall be familiar with the codes, standards, and specifications of any inspection being performed.
 - 5.4. Level IIA personnel shall be responsible for data interpretation or evaluation and give guidance to Level II personnel as needed. The Data Analyst has the right to request a retest on any tube with an unusual condition. The Lead Analyst may alter the original inspection technique or plans to address any special condition encountered. The Lead Analyst is responsible for the correct inspection probes, calibration standards, and any other information on the ETSS sheet.
 - 5.5. Level III personnel shall hold the same responsibilities as Level IIA. The Level III, with approval of the customer, may alter the original inspection technique or plans to address any special condition encountered. The Level III is responsible for the correct inspection probes, calibration standards, and any other information on the ETSS sheet.
6. Procedure
 - 6.1. Code and Procedure Requirements – All Eddy Current technicians shall be familiar with this procedure and examination program prior to the start of the examination.
 - 6.2. Personnel Criteria – Personnel performing Eddy Current examinations shall be certified in accordance with the Quality Assurance Procedure CSC-QAP-9.1, “Certification of NDE Personnel” or their employers, written practice that has been approved by Conco Services Corporation.
 - 6.3. Heat Exchangers under inspection must be shut down or isolated and the system drained. Manways shall be opened and sufficient time should be allowed for cool down prior to the start of the job.
 - 6.4. All personnel engaging in eddy current at operating nuclear facilities shall receive instructions and understand radiation rules and guidelines in effect at the plant site.
 - 6.5. Equipment



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 3 of 12	

6.5.1. Eddy current test instrument

6.5.1.1. The eddy current test instrument shall be capable of multi-frequency inspection in multiplexed mode, simultaneous injection mode and operation in the differential and/or absolute mode.

6.5.1.2. The eddy current test instrument shall be capable of recording and playing back data, real time, in a format suitable for evaluation and archival storage.

6.5.1.3. The test instrument outputs shall provide phase and amplitude information.

6.5.1.4. The eddy current inspection system shall be capable of detecting and recording dimensional changes, metallurgical changes, deposits and determine if discontinuities are ID or OD initiated.

6.5.1.5. Testing equipment shall hold current calibration in accordance with CSC-QAP-12.1 and the interval shall not exceed one year or whenever the equipment has been overhauled or repaired as a result of malfunction or damage.

6.5.2. The acceptable eddy current probes for an inspection shall be listed on the ETSS and may include bobbin coil, cross-wound and pancake coil designs from various manufacturers. The sensitivity for the differential bobbin probes technique shall be sufficient to produce a response from the 20% flat bottom holes with a minimum peak to peak response of 30% screen height of the Lissajous. A minimum fill factor of 80% should be used. For special interest regions (i.e. obstructions and restrictions), a lower fill factor may be used. If the minimum sensitivity requirements can not be met, the test will be considered a best effort examination. Customer approval shall be obtained prior to examination. Customer requirements for higher fill factor values will be followed and documented on the ETSS.

6.5.3. ASME Calibration Standards

6.5.3.1. The ASME calibration standard shall be manufactured in accordance with the specifications of the ASME Boiler and Pressure Vessel Code, Section V, Article 8. The standard shall contain the following artificial discontinuities at a minimum: 100% through wall hole, 60% through wall flat bottom hole, and four 20% through wall flat bottom holes spaced 90 degrees apart in a single plane around the tube circumference.

6.5.3.2. A simulated support ring should be used to simulate a support plate in the unit being inspected. If an "artificial" ring cannot be obtained, a support plate in the unit can be used for mixing/process channels.

6.5.3.3. Each standard shall be identified by a unique serial number and have an associated drawing or data sheet showing the actual flaw depths. The eddy current system response shall become part of the permanent record of the standard.

6.5.3.4. Other calibration standards may be used in addition to the ASME standard for unique applications.

6.5.4. Digital Data Analysis System

6.5.4.1. The eddy current data analysis system shall be capable of displaying and evaluating the recorded data from all frequency channels.



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 4 of 12	

- 6.5.4.2. The system shall have multi-parameter mixing capability.
- 6.5.4.3. The system shall have a minimum resolution of 12 bits per data point.
- 6.5.4.4. The Lissajous display shall have a minimum resolution of 7 bits full scale.
- 6.5.4.5. The strip chart display shall have a minimum resolution of 6 bits full scale.
- 6.5.4.6. The strip chart display shall be selectable to display either the X or Y component of the raw or processed (mixed) data.
- 6.5.4.7. In addition, the system shall meet the “General System Requirements”, stated in ASME Boiler and Pressure Vessel Code, Section V, Article 8, II-830.5.1.

6.6. System Set-up

6.6.1. Preparation

- 6.6.1.1. Review all safety and radiological procedures with plant personnel as applicable (i.e. air sample, radiation surveys, confined space requirements, etc.)
- 6.6.1.2. Review all Foreign Material Exclusion (FME) procedures with plant personnel as necessary.
- 6.6.1.3. Examine work area for any potential hazards or interference and resolve any problems.
- 6.6.1.4. Establish location of the test station and placement of the test instrument.
- 6.6.1.5. Locate 110 VAC power source. (Clean power source)
- 6.6.1.6. Establish location of cable routing.
- 6.6.1.7. Acquire copies of the ETSS and all applicable procedures from the Lead Analyst (or designee). Verify the probes and standards listed on the ETSS are appropriate for the component or material to be examined.
- 6.6.1.8. Acquire copies of the inspection plan and tubesheet maps if available. Verify that the tubesheet map is correct for the component and the view or test end is correct.

6.6.2. Equipment Set-up

- 6.6.2.1. Connect and power-up eddy current system per owners manual
- 6.6.2.2. Attach probe extensions, of equal length, and probes to the test instrument
- 6.6.2.3. Establish communication for personnel engaging in the examination
- 6.6.2.4. Set configurations for channels and gain setting on test instrument.
- 6.6.2.5. Verify recording path
- 6.6.2.6. Set and verify pull speed (if a probe pusher is being used).



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 5 of 12	

6.6.3. Acquisition Set-Up (Configuration)

6.6.3.1. Test Parameters

6.6.3.1.1. Set the frequencies, drives, and gains in the configuration of the test instrument, per the ETSS. The primary frequency shall be set to obtain a response of the 4X20% FBH's to fall within 90° to 120° from the 100% thruwall hole set at 40°.

6.6.3.1.2. Set the proper sample rate, in the test instrument, per the ETSS. The sample rate should meet the minimum of 30 samples per inch of tubing per ASME Section V, Article 8.

6.6.3.1.3. With the proper settings, a signal-to-noise ratio of 3:1 or higher shall be obtained.

6.6.3.1.4. Assure the reference probe has been placed in the reference tubing or the component. Test systems with internal reference capabilities can be used in lieu of a reference probe.

6.6.3.1.5. Place the test probe in the end of the ASME Calibration standard assuring that none of the coils are influenced by the flaws in the standard and perform a hardware null.

6.6.3.1.6. Open a calibration group, with the proper recording path, to allow the calibration standard data to be recorded.

6.6.3.1.7. Turn on the acquire function of the tester and assure data is in the strip charts, on the left of the acquisition screen.

6.6.3.1.8. Assure both the reference, and test probes are in good metal and center the data in the Lissajous.

6.6.3.1.9. Push the test probe out of the end of the ASME Calibration standard.

6.6.3.1.10. Start recording the data and pull the probe back through the calibration. (If a probe pusher is being used for the inspection, it should be used to pull the calibration standards also. If this is the case, care should be taken to minimize snap of the probe as it is retracted through the calibration standard.)

6.6.3.1.11. Stop recording data and review the calibration standard to ensure compliance with the ETSS.

6.6.3.1.12. Set spans and rotations on all absolute and differential channels for the ASME standard, identified on the approved ETSS.

6.6.3.1.13. Store the set-up with the new values for the spans and rotations of the calibration standard.

6.6.3.1.14. Repeat steps from above, (6.6.3.1 – (6.6.3.1.6) through (6.6.3.1.9)) for all calibration standards being used for the inspection.



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 6 of 12	

Note: If Wear Scar and/or Thinning Standards are being used, check all channels to assure that none of the signals are saturated. If any signals are saturated, adjust the gains in the configuration screen, notify the Level IIA/III of changes needed to ETSS, and repeat the entire calibration process with the updated ETSS settings.

6.7. Examination

6.7.1. Summary Form

6.7.1.1. Select the “Summary Form” and complete all designated input areas. The summary form shall be written to the storage media and contain the following information as a minimum:

Owner
Plant site and unit number
Heat Exchanger identification and test end
Recording media identification (i.e. calibration group)
Date of examination
Serial number of the calibration standard(s)
Operator’s identification and certification level
Examination frequencies
Lengths of probe and probe extension cables
Size and type of probes
Probe manufacturer’s name and manufacturer’s part number or probe description
Serial number of the eddy current test instrument
Calibration “Due Date”, from the test instrument being used

6.7.2. Record Calibration Standards

6.7.2.1. Identify the ASME standard run as Row 999 Tube 999 or as stated on the ETSS. If other standards are utilized refer to the ETSS for identification.

6.7.2.2. Place the test probe in a defect-free portion of the standard and balance the tester.

6.7.2.3. Record a minimum of three standard runs in the direction and at the speed that the inspection will be performed.

6.7.2.4. Retrieve a standard run from the storage media to verify proper system operation.

6.7.2.5. Calibration standard runs shall be recorded for the following conditions:

6.7.2.5.1. At the beginning and end of a directory/cal group or when changing storage media

6.7.2.5.2. At the beginning and end of a work shift

6.7.2.5.3. When changing equipment, including probes and cables

6.7.2.5.4. When four hours time has elapsed since the last calibration verification

6.7.2.5.5. When a power failure or system lockup has occurred

6.7.2.5.6. At anytime the operator deems it necessary to check the system integrity

6.7.2.6. A written message to the data disk should precede or follow a calibration run stating



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 7 of 12	

the reason the calibration run is being performed.

6.7.2.7. If a system is found out of tolerance, recalibration is required. This should be noted by recording an updated summary and message to the recording media. In addition to this, if any part of the test system is changed, due to damage or any other issue, recalibration is required.

6.7.2.8. The analyst will determine if any or all tubes need to be retested.

6.7.2.9. The “End of Calibration” standard run shall be performed at the same pull speed used during the examination.

6.7.2.10. If a calibration run cannot be performed at the four-hour interval, a detailed message shall be recorded on the recording media stating the reason for the “missed” standard run and the site lead shall be notified. A calibration standard run shall then be performed at the first opportunity and prior to the continuation of the inspection.

6.7.3. Typical examination process

6.7.3.1. Identify and encode the tube identification using the appropriate identification/numbering scheme.

6.7.3.2. Insert the probe into the tube to be examined, check balance of the data and rebalance if required.

6.7.3.3. Insert the Probe to the intended examination extent.

6.7.3.4. Initiate data recording.

6.7.3.5. Withdraw the probe at the speed noted on the ETSS.

6.7.3.6. Monitor the data quality during the recording process. Ensure that acceptable data is being acquired in all channels.

6.7.3.7. Stop recording data when the examination is complete.

6.7.4. If the probe cannot traverse the entire length of the scheduled examination and the tube is considered restricted, record a message identifying the tube number or group of tubes. Include an explanation as to why the tubes(s) cannot be examined over the entire length (if known).

6.7.5. When an error in tube identification occurs, the operator shall clearly identify which tube entries are incorrect with a recorded message.

6.8. Data Analysis and Reporting

6.8.1. Evaluate the recorded digital data from the acquisition process.

6.8.2. Evaluate any indications. Indication types that must be reported shall be characterized using the frequencies or frequency mixes and analysis curves (Phase or Magnitude) appropriate for the damage mechanism as identified in the Examination Technique Specification Sheet (ETSS).



CONCO SERVICES LLC
530 JONES STREET · VERONA, PA 15147
(412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 8 of 12	

- 6.8.3. Provide a preliminary report following the examination. Include in the report a record indicating the tube(s) examined, any scanning limitations, the location and depth (or descriptive code) of each reported flaw, and any specific reporting requirements identified by the customer.
- 6.8.4. Unless otherwise requested by the customer, only the deepest flaw in each tube will be identified.
- 6.8.5. Graphic printouts of typical and questionable defect types shall be added at the customer's request.
- 6.8.6. Report all obstructions restrictions, or conditions known to limit the desired extent of test for all tubes on the examination plan (e.g. dents, tube cleanliness, foreign material).
- 6.8.7. Report any addition conditions deemed necessary.
7. Records
- 7.1. Records and documentation are handled in accordance to CSC-QAP-17.1.
- 7.2. A copy of this procedure, personnel certifications and equipment certifications shall be submitted to the customer upon request.
- 7.3. The examination results and technical information regarding test parameters and inspection requirements shall be included in the final report.



CONCO SERVICES LLC
 530 JONES STREET · VERONA, PA 15147
 (412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 9 of 12	

Attachment 2.1 Sample ETSS



CONCO SERVICES LLC
 530 JONES STREET · VERONA, PA 15147
 (412) 828-1166 · FAX: (412) 826-8255

Form No	1085
Title	Examination Technique Specification Sheet OMNI
Revision:	2
Date:	January 3, 2017
Page 1 of 4	

Utility/Site/Unit: Sample ETSS		ETSS Version:		Date:	
Component:		Component ID:			
Examination Scope					
Applicability:					
Instrument			Tubing		
Manufacturer/Model: CoreStar OMNI 200/100			Material Type:		
			# Of Tubes:		
			OD/Wall (inch):		
Data Recording Equipment			Length:		
Manuf./Media: Hard drive / Network or Equiv			Calibration Standard(s)		
Software			Type/SN: ASME		
Manufacturer: Corestar			Type/SN: Wall Thinning		
			Type/SN: Reference		
			Analog Signal Path		
Version/Revision: 8.0			Probe Shaft /Length:		
Examination Procedure			Extension Type & Length N/A		
Number/Revision: CSC-NDE-11.0 Rev 3			Slip Ring Model Number: N/A		
Scan Parameters					
Scan Direction: Pull					
Digitization Rate, Samples Per Inch (minimum): ≥ 30 SPI		Axial Direction:	N/A	Circ. Direction	N/A
		Pull			
Probe Speed	Sample Rate	RPM Set	RPM Min	RPM Max	
46 inches / second	2000 (Max.)	N/A	N/A	N/A	
30 inches / second	1200 (Min.)	N/A	N/A	N/A	
Probe/Motor Unit					
Description (Model/Diameter/Frequency/Coil Dimensions)			Manufacturer		Length
Data Acquisition					
Calibration Coil 1 Channels					
Channel & Frequency	Channel #1 kHz	Channel #3 kHz	Channel #5 kHz	Channel #7 kHz	
Phase Rotation	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	100% TWH 40 degrees ± 3	
Span Setting	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	4 x 20% FBH's @ 3 divisions	
Drive Voltage	75%	75%	75%	75%	
Gain Setting	14	14	14	14	
Calibration Coil 2 Channels					
Channel & Frequency	Channel #2 kHz	Channel #4 kHz	Channel #6 kHz	Channel #8 kHz	
Phase Rotation	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	
Span Setting	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	4 x 20% FBH's @ 1.5 divisions	
Drive Voltage	75%	75%	75%	75%	
Gain setting	8	8	8	8	



Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 10 of 12	

Examination Technique Specification Sheet

Configuration Board Settings

OMNI-200 1 - Titanium v.020.cfg

File Edit View Probe Util Help

TEST LINK BALANCE REF NULL HW NULL IP Address [192.1.6.101]

Config Options Scope Waveform Freq Sweep Status

Sample Rate 1,500 Num Chan 8 Trigger Internal

TIME	DRIVER	COIL
SCU1	FREQUENCY	DRIVE
1	800.000 kHz	75.004
2	400.000 kHz	75.004
3	200.000 kHz	75.004
4	100.000 kHz	75.004

SLOT	DELAY (µs)	INTEG (waves)	TIME (µs)	ENCODER
1	10	144	191	
2	10	61	163	
3	10	36	191	
4	10	10	111	

SLOT	COIL	INUT	GAIN	(dB)
1	14	0		
2	14	0		
3	14	0		
4	14	0		

COIL	DR1	DR2	DR3	DR4	DR5	DR6	DR7	DR8	DR9	DR10	DR11	DR12	DR13	DR14	DR15	DR16	DR17	DR18	DR19	DR20	DR21	DR22	DR23	DR24	DR25	DR26	DR27	DR28	DR29	DR30	DR31	DR32	DR33	DR34	DR35	DR36	DR37	DR38	DR39	DR40	DR41	DR42	DR43	DR44	DR45	DR46	DR47	DR48	DR49	DR50	DR51	DR52	DR53	DR54	DR55	DR56	DR57	DR58	DR59	DR60	DR61	DR62	DR63	DR64	DR65	DR66	DR67	DR68	DR69	DR70	DR71	DR72	DR73	DR74	DR75	DR76	DR77	DR78	DR79	DR80	DR81	DR82	DR83	DR84	DR85	DR86	DR87	DR88	DR89	DR90	DR91	DR92	DR93	DR94	DR95	DR96	DR97	DR98	DR99	DR100
1	DR1	DR2	DR3	DR4	DR5	DR6	DR7	DR8	DR9	DR10	DR11	DR12	DR13	DR14	DR15	DR16	DR17	DR18	DR19	DR20	DR21	DR22	DR23	DR24	DR25	DR26	DR27	DR28	DR29	DR30	DR31	DR32	DR33	DR34	DR35	DR36	DR37	DR38	DR39	DR40	DR41	DR42	DR43	DR44	DR45	DR46	DR47	DR48	DR49	DR50	DR51	DR52	DR53	DR54	DR55	DR56	DR57	DR58	DR59	DR60	DR61	DR62	DR63	DR64	DR65	DR66	DR67	DR68	DR69	DR70	DR71	DR72	DR73	DR74	DR75	DR76	DR77	DR78	DR79	DR80	DR81	DR82	DR83	DR84	DR85	DR86	DR87	DR88	DR89	DR90	DR91	DR92	DR93	DR94	DR95	DR96	DR97	DR98	DR99	DR100

Special Instructions for Data Acquisition

- Probes should be pulled @ 40 inches/second or less.
- Review each data channel and ensure that adequate/expected signal responses are achieved before recording the calibration. Do not record data until the proper spans and rotations have been set.
- Monitor the data by setting the left strip chart to channel 1 vertical, right strip chart to channel 6 vertical and the lissajous display set to channel 1 as a minimum. The operator will determine the specific strip chart settings and lissajous display to verify the system is functioning properly and that data quality is acceptable.
- Follow the Conco NDE procedure CSC-NDE-11.0 Rev 3.
- Encode the tube ID's as per map for respective sections.
- The initial exam attempt shall be performed with the XXX ESH/HF probe.
- Tubes that will not allow the probe to enter report as "Obstructed".
- Tubes that are unable to examine the desired extent report as "Restricted".
- Write a message for all tubes that are unable to be examined full length explaining the reason.
- Encode the ASME Std. as "999", Thinning Std as "999" with a message.
- Perform "System Null" only if "Display Null" is ineffective in balancing the signal.



CONCO SERVICES LLC
 530 JONES STREET · VERONA, PA 15147
 (412) 828-1166 · FAX: (412) 826-8255

Procedure No	CSC-NDE-11.0
Title	Data Acquisition & Analysis
Revision:	4
Date:	January 7, 2021
Page 11 of 12	

Examination Technique Specification Sheet

Page 3 of 4

Data Analysis						
Calibration Differential Channels						
Channel & Frequency	Channel #1 kHz	Channel #3 kHz	Channel #5 kHz	Channel #7 kHz		
Phase Rotation	100% TWH 40 degrees + 3	100% TWH 40 degrees + 3	100% TWH 40 degrees + 3	100% TWH 40 degrees + 3	100% TWH 40 degrees + 3	
Span Setting Minimum	100% TWH @ 4 divisions	100% TWH @ 4 divisions	100% TWH @ 4 divisions	100% TWH @ 4 divisions	100% TWH @ 4 divisions	
Calibration Absolute Channels						
Channel & Frequency	Channel #2 kHz	Channel #4 kHz	Channel #6 kHz	Channel #8 kHz		
Phase Rotation	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	Probe Motion Horiz. Flaws Up	
Span Setting Minimum	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions	
Calibration Process and Other Channels						
Channel & Frequency	M-1 / Diff	M-2 / Abs.	P-3 / Diff.	P-4 / Diff.		
Phase Rotation	100% TWH 40 degrees + 3	Probe Motion Horiz. Flaws Up				
Span Setting Minimum	100% TWH @ 1.5 divisions	100% TWH @ 1.5 divisions				
Suppress On	Support Ring	Support Ring				
Voltage Normalization			Calibration Curves			
CH	Signal	Set	Normalize	Type	CH	Set Points
1	4x20% FBH	4 Vp-p	Save/Store to all	Phase Curve	1, 3, 5, M1	100,60,20%
1	4x20% FBH	4 Vp-p	Save/Store to all	Magnitude Curve	6,M2	75, 50,25%
Data Screening						
Left Strip Chart	Center Strip Chart	Right Strip Chart	Left Lissajous	Right Lissajous		
Channel P1 Vertical	Channel 1 Vertical	Channel 6 Vertical	Channel 1	Channel 3		
Special Instructions for Analysis						
<ol style="list-style-type: none"> Calibration curves shall be constructed using the "As-Built" dimensions from the calibration standard drawings. Normalize to 4 volts on the 4 X 20% flat bottom holes using channel #1 differential and store to all channels. All Quantifiable indications of tube wall degradation $\geq 20\%$ TW and 1 Volt shall be reported (however, not to exceed 6 reportable ID defects). Locate all defect indications in inches measured from the test end. Previously reported indications shall be addressed by the primary analyst. Report previously reported Inds. In same channel as history. Report previous indications that are not found as "INF" and indications not recordable as "INR". If test data appears to be un-interpretable shall be report as "RBD". 						
Job Lead Approval			Customer Approval (if required)			
Signature /Date			Signature /Date			
Additional Component Information						



4.0 CERTIFICATIONS

The following personnel were involved with this inspection:

Tom Dolgas	ET IIA	Conco Services
Kevin Willyard	ECT II	Conco Services
Mike Berkoben	ECT I	Conco Services

The following testers were used on this inspection:

Corestar OMNI 200 S/N	0007-0910
-----------------------	-----------

The following calibration standards were used on this inspection:

ASME	CSC-434
Wall Thinning	CSC-432

Note: see following pages for a copy of all certifications and standard drawings



NDE CERTIFICATION

Name: Dolgas, Thomas

SSN: XXX-XX-9803

Method / Level: ECT-IIA

EDUCATION & TRAINING

Date(s)	School / Facility	Location	Subject	Term	Certification
5-27-75	Windber Area HS	Windber, PA	N/A	N/A	Diploma
9-18-09	System One	Cheswick, PA	NDE	448 Hours	Transcript
2-22-11	Conco Services Corp.	Verona, PA	ECT-I	40 Hours	Attn. Record
6-18-12	Conco Services Corp.	Verona, PA	ECT-II	40 Hours	Attn. Record
1-19-15	JECNDT, LLC	Verona, PA	ECT-IIA	80 Hours	Attn. Record
1-9-18	Conco Services Corp.	Verona, PA	ECT-IIA	24 Hours	Attn. Record
11-17-20	Conco Services, LLC	Verona, PA	ECT-IIA	24 Hours	Attn. Record

NDE EXPERIENCE

Date(s)	Company	NDE Method / Highest Level
2-28-11	Conco Services Corp.	ECT-IT
5-25-11	Conco Services Corp.	ECT-I
6-22-12	Conco Services Corp.	ECT-II
2-3-15	Conco Services Corp.	ECT-IIA

EXAMINATION GRADES

General: 96%	Date: 11-17-20	Basic: N/A	Date:	Specific: 88%	Date: 11-18-20
Method: N/A	Date:	Practical 99.7%	Date: 11-18-20	LIII Practical: N/A	Date:
Demonstration 100%	Date: 11-19-20	ASNT: N/A	Date:	ASNT No.	
Composite Grade: 95.9%					

LIMITATIONS / REMARKS:

Demonstration exam is the L-II acquisition practical for data collection in the field.
Tom Dolgas is a certified receipt inspector.

This certifies that the above-named individual has satisfactorily completed the physical and technical qualifications required by the current Conco Procedure CSC-QAP-9.1 Rev.13, Certification of NDE Personnel.

CERTIFICATION DATE: 11-20-2020

EXPIRATION DATE: 11-17-2023

Certified By: _____

Title: ET Level III-A

Printed Name: James A. Kocher

Initial Certification

Re-Certification

Form No	1049
Title	NDE Certification
Revision:	4
Date:	8/11/2015
Page 1 of 1	



NDE CERTIFICATION

Name: Willyard, Kevin D.

SSN: XXX-XX-4524

Method / Level: ECT-II

EDUCATION & TRAINING

Date(s)	School / Facility	Location	Subject	Term	Certification
6-1983	Freeport Area High School	Freeport, PA	N/A	N/A	Diploma
8-1998	Master Lee Energy Svcs.	Latrobe, PA	ECT-I	40 Hrs	Attn. Record
1-17-02	Conco Services Corp.	Verona, PA	ECT-I	8 Hrs	Attn. Record
1-22-05	Conco Services Corp.	Verona, PA	ECT-I	9 Hrs	Attn. Record
1-19-09	Conco Services Corp.	Verona, PA	ECT-I	24 Hrs	Attn. Record
1-3-11	Conco Services Corp.	Verona, PA	ECT-II	40 Hrs	Attn. Record
7-18-16	Conco Services Corp.	Verona, PA	ECT-II	24 Hrs	Attn. Record
7-8-19	Conco Services Corp.	Verona, PA	ECT-II	24 Hrs	Attn. Record

NDE EXPERIENCE

Date(s)	Company	NDE Method / Highest Level
8-14-98	Conco Services Corp.	ECT-IT
12-4-99	Conco Services Corp.	ECT-I
1-24-11	Conco Services Corp.	ECT-II

EXAMINATION GRADES


General: 94%	Date: 7-8-19	Basic: N/A	Date:	Specific: 96%	Date: 7-8-19
Method: N/A	Date:	Practical: 100%	Date: 7-10-19	LIII Practical: N/A	Date:
Demonstration: N/A	Date:	ASNT: N/A	Date:	ASNT No.	
Composite Grade: 96.6%					

LIMITATIONS / REMARKS:

This certifies that the above-named individual has satisfactorily completed the physical and technical qualifications required by the current Conco Procedure CSC-QAP-9.1 Rev.13, Certification of NDE Personnel.

CERTIFICATION DATE: 7-11-2019

EXPIRATION DATE: 7-8-2022

Certified By:  Title: ET L-III

Printed Name: James A. Kocher

Initial Certification

Re-Certification

Form No	1049
Title	NDE Certification
Revision:	4
Date:	8/11/2015
Page 1 of 1	



NDE CERTIFICATION

Name: Berkoben, Michael

SSN: XXX-XX-6068

Method / Level: ECT-I

EDUCATION & TRAINING

Date(s)	School / Facility	Location	Subject	Term	Certification
3-14-16	Commonwealth of PA	Harrisburg, PA	N/A	N/A	Diploma
9-4-18	Conco Services Corp.	Verona, PA	ECT-I	40 Hours	Attn. Record

NDE EXPERIENCE

Date(s)	Company	NDE Method / Highest Level
9-10-18	Conco Services Corp.	ECT-IT
11-21-19	Conco Services Corp.	ECT-I

EXAMINATION GRADES

General: 90%	Date: 9-6-18	Basic: N/A	Date:	Specific: 100%	Date: 9-6-18
Method: N/A	Date:	Practical: 100%	Date: 9-7-18	LIII Practical: N/A	Date:
Demonstration: N/A	Date:	ASNT: N/A	Date:	ASNT No.	
Composite Grade: 96.6 %					

LIMITATIONS / REMARKS:

This certifies that the above-named individual has satisfactorily completed the physical and technical qualifications required by the current Conco Procedure CSC-QAP-9.1 Rev.12, Certification of NDE Personnel.

CERTIFICATION DATE: 11-21-2019 EXPIRATION DATE: 9-6-2021

Certified By: Title: ET L-III A

Printed Name: James A. Kocher

Initial Certification Re-Certification

CORESTAR INTERNATIONAL CORPORATION

EQUIPMENT CALIBRATION CERTIFICATE

INSTRUMENT

LAB TEMP: 75.0 °F

Certificate Number: CB-200220	Instrument S/N: 0007-0910
Instrument: OMNI-200™ AM201R1-10	Calibration Date: 21-Jul-2020
Customer: Conco	Calibration Due: 20-Jul-2021
Instruction Number: CIC-HI002, Rev 5	Calibration Interval: 1 Year

VOLTAGE SPECIFICATION

Instrument: Agilent Model 34401A Digital Multimeter	Instrument S/N: US36141491
Calibration Interval: 1 year	Calibration Date: 07-Feb-2020
	Calibration Due: 07-Feb-2021

Voltage (Vdc)	Measured Value (Vdc)	Tolerance
+3.3	+3.304	+/- 0.100
+15.0	+15.116	+/- 0.200
-15.0	-15.070	+/- 0.200

FREQUENCY SPECIFICATION

Instrument: Agilent Model 53131A Universal Counter	Instrument S/N: MY40003653
Calibration Interval: 1 year	Calibration Date: 07-Feb-2020
	Calibration Due: 07-Feb-2021

Frequency (Hz)	Measured Value (Hz)	Tolerance
100	100	+/- 5
2,000	2,000	+/- 100
30,000	30,000	+/- 1,500
400,000	399,999	+/- 20,000
2,000,000	1,999,997	+/- 100,000

COIL GAIN CALIBRATION SPECIFICATION

Calibration Frequencies: 5 kHz to 1 MHz	Calibration Module SN: 0269-0307
Test Parameters: See instructions	

NOTE: The complete table of measured values for each frequency, gain setting, and coil number is permanently stored in the instrument hardware. To view and print the report, go to the Calibration menu in the Tester Config screen.

Gain Step (decibels)	Average Value (Volt/Volt)	Tolerance	Pass	Fail
-22 db	0.087	.087 ±.002 V/V	X	
-16 db	0.174	.173 ±.005 V/V	X	
-10 db	0.335	.337 ±.010 V/V	X	
-4 db	0.661	.664 ±.019 V/V	X	

CORESTAR INTERNATIONAL CORPORATION

EQUIPMENT CALIBRATION CERTIFICATE

INSTRUMENT

Certificate Number: CB-200220	Instrument S/N: 0007-0910
--------------------------------------	----------------------------------

COIL GAIN CALIBRATION SPECIFICATION (continued)

Gain Step (decibels)	Average Value (Volt/Volt)	Tolerance	Pass	Fail
2 db	1.315	1.312 ±.039 V/V	X	
8 db	2.647	2.652 ±.079 V/V	X	
14 db	5.104	5.141 ±.154 V/V	X	
20 db	10.000	10.000 V/V Reference	n/a	n/a

COIL FUNCTIONAL CHECK

Test Frequency: 400 kHz			Probe SN: 0045-0806			
Test Parameters: See instructions			Standard SN: AS-034-03			
Coil	TSP Volt	Measured	Tolerance	TSP Phase	Measured	Tolerance
1	4.58 V	4.81	± .45 V	21°	21	± 2.0°
2	4.58 V	4.88	± .45 V	21°	21	± 2.0°
3	4.58 V	4.84	± .45 V	21°	21	± 2.0°
4	4.58 V	4.87	± .45 V	21°	20	± 2.0°
5	4.80 V	4.98	± .48 V	23°	22	± 2.0°
6	4.80 V	5.01	± .48 V	23°	22	± 2.0°
7	4.80 V	5.04	± .48 V	23°	23	± 2.0°
8	4.80 V	5.01	± .48 V	23°	22	± 2.0°

QA RELEASE

All measurement ratios between the standards referenced on this certificate and the M&TE calibrated are greater than or equal to 4:1.

Yes No

All of the equipment used in the calibration of this instrument is traceable to NIST.

Yes No

All test requirements have been met and the checklist is complete.

Yes No

Technician Signature: David Thomas Date: 7-21-2020

QA Signature: Rebecca Casaró Date: 7-21-2020

CORESTAR INTERNATIONAL CORPORATION

AS FOUND EQUIPMENT CALIBRATION CERTIFICATE

INSTRUMENT

LAB TEMP: 74.6 °F

Certificate Number: CB-200219	Instrument S/N: 0007-0910
Instrument: OMNI-200™ AM201R1-10	Date: 21-Jul-2020
Customer: Conco	
Instruction Number: CIC-HI002, Rev. 5	

VOLTAGE SPECIFICATION

Instrument: Agilent Model 34401A Digital Multimeter	Instrument S/N: US36141491		
Calibration Interval: 1 year	Calibration Date: 07-Feb-2020		
	Calibration Due: 07-Feb-2021		
Voltage (Vdc)	Measured Value (Vdc)	Tolerance (Vdc)	As Found (Vdc)
+3.3	+3.308	+/- 0.100	+3.304
+15.0	+15.117	+/- 0.200	+15.116
-15.0	-15.070	+/- 0.200	-15.070

FREQUENCY SPECIFICATION

Instrument: Agilent Model 53131A Universal Counter	Instrument S/N: MY40003653		
Calibration Interval: 1 year	Calibration Date: 07-Feb-2020		
	Calibration Due: 07-Feb-2021		
Frequency (Hz)	Measured Value (Hz)	Tolerance (Hz)	As Found (Hz)
100	100	+/- 5	100
2,000	2,000	+/- 100	2,000
30,000	30,000	+/- 1,500	30,000
400,000	399,999	+/- 20,000	399,999
2,000,000	1,999,997	+/- 100,000	1,999,997

COIL GAIN CALIBRATION SPECIFICATION

Calibration Frequencies: 5 kHz to 1 MHz **Calibration Module SN:** 0269-0307
Test Parameters: See instructions

NOTE: The complete table of measured values for each frequency, gain setting, and coil number is permanently stored in the instrument hardware. To view and print the report, go to the Calibration menu in the Tester Config screen.

Gain Step (decibels)	Average Value (Volt/Volt)	Tolerance	As Found (Volt/Volt)
-22 db	0.087	.087 ±.002 V/V	0.087
-16 db	0.174	.173 ±.005 V/V	0.174
-10 db	0.335	.337 ±.010 V/V	0.335
-4 db	0.661	.664 ±.019 V/V	0.661

CORESTAR INTERNATIONAL CORPORATION AS FOUND EQUIPMENT CALIBRATION CERTIFICATE

INSTRUMENT

Certificate Number: CB-200219	Instrument S/N: 0007-0910
--------------------------------------	----------------------------------

COIL GAIN CALIBRATION SPECIFICATION (continued)

Gain Step (decibels)	Average Value (Volt/Volt)	Tolerance	As Found (Volt/Volt)
2 db	1.315	1.312 ±.039 V/V	1.315
8 db	2.647	2.652 ±.079 V/V	2.647
14 db	5.104	5.141 ±.154 V/V	5.104
20 db	10.000	10.000 V/V Reference	10.000

COIL FUNCTIONAL CHECK

Test Frequency: 400 kHz					Probe SN: 0045-0806				
Test Parameters: See instructions					Standard SN: AS-034-03				
Coil	TSP Volt	Measured	As Found	Tolerance	TSP Phase	Measured	As Found	Tolerance	
1	4.58 V	4.86	4.81	± .45 V	21°	22	21	± 2.0°	
2	4.58 V	4.85	4.88	± .45 V	21°	21	21	± 2.0°	
3	4.58 V	4.86	4.84	± .45 V	21°	19	21	± 2.0°	
4	4.58 V	4.84	4.87	± .45 V	21°	20	20	± 2.0°	
5	4.80 V	4.97	4.98	± .48 V	23°	23	22	± 2.0°	
6	4.80 V	5.00	5.01	± .48 V	23°	24	22	± 2.0°	
7	4.80 V	5.04	5.04	± .48 V	23°	23	23	± 2.0°	
8	4.80 V	4.99	5.01	± .48 V	23°	24	22	± 2.0°	

All measurement ratios between the standards referenced on this certificate and the M&TE calibrated are greater than or equal to 4:1.

Yes No

All of the equipment used in the calibration of this instrument is traceable to NIST.

Yes No

All test requirements have been met and the checklist is complete.

Yes No

Technician Signature: David Thomas *DAVID THOMAS* Date: 7-21-2020

QA Signature: Rebecca Cisano *Rebecca Cisano* Date: 7-21-2020

CSC-434


ECUTEC

CALIBRATION STANDARD CERTIFICATION

REV. 01
DATE: 02/10/10


SPECIFIED DEPTH 20% 100% 80% 60% 40% 20% 10%

LOCATION	A	B	C	D	E	F	G	H	I	J
ACTUAL DEPTH	.007"	THRU	.028"	.021"	.014"	.007"	.0035"			
% OF WALL LOSS	20%	100%	80%	60%	40%	20%	10%			
DIA OF DEFECT +/- .005	.062"	see note	.078"	.109"	.187"	.187"	.125"			



MATERIAL	304 STAINLESS STEEL
O D CONFIGURATION	PRIME
I D CONFIGURATION	PRIME
O D DIAMETER	.750"
NOMINAL WALL	.035"
F P I	N/A
MEASUREMENT	INCH
DATE MACHINED	09/30/10
Q A APPROVAL	T MC

LOCATION A SHOWS AN I D GROOVE X 360 DEGREES
 LOCATION B SHOWS A THRU WALL HOLE
 LOCATIONS C, D, & E SHOW O D FLAT BOTTOM HOLES
 LOCATION F SHOWS 4 O D FLAT BOTTOM HOLES 90 DEGREES APART
 LOCATION G SHOWS AN O D GROOVE X 360 DEGREES



NOTE: HOLE DIAMETER AT LOCATION B IS .052" IN TUBES .750" IN DIAMETER AND LESS, .067" IN TUBES ABOVE .750" IN DIAMETER.

NOTE: DUE TO TUBE GEOMETRY 360 DEGREE O D & I D GROOVES MAY BE LESS THAN 360 DEGREES ON SHALLOW DEPTHS AND ARE AS MACHINED

NOTE: MEASUREMENT GIVEN FOR 4 FLAT BOTTOM HOLES 90 DEGREES APART IS AN AVERAGE TAKEN FROM ALL 4 MEASUREMENTS

UNLESS OTHERWISE SPECIFIED
 DIM. ARE AS FOLLOWS:

DECIMAL	FRACT. +/- 1/16
XXXX	+/- .003
XXX	+/- .015
XX	+/- .05
ANGULAR	+/- 5 DEGREES

DEFECT DEPTHS ARE +/- .003 OR 20% WHICH EVER IS LESS

SCALE:
 NONE
 DRAWN BY:
 T MCNABB

ECUTEC INC.
ASME CODE CAL. STD.

DRAWN FOR:
 CONCO
 S/N EU010768
**ALL MEASURING DEVICES ARE
 NIST CERTIFIED**


CSC-432

ECUTECH

CALIBRATION STANDARD CERTIFICATION

SPECIFIED DEPTH 25% 50% 75%

LOCATION	A	B	C	D	E	F	G	H	I	J
ACTUAL DEPTH	.0092"	.0185"	.0287"							
% OF WALL LOSS	25%	50%	77.7%							
FLAW WIDTH/DIA. +/- .005"	1.0"	1.0"	1.0"							



ALL LOCATIONS SHOW O D FLATS 1.00" IN LENGTH AXIALLY MILLED @ 0 DEG. & 180 DEG.

MATERIAL	304 STAINLESS STEEL
O D CONFIGURATION	PRIME
I D CONFIGURATION	PRIME
O D DIAMETER	.750"
NOMINAL WALL	.037"
F P I	N/A
MEASUREMENT	INCH
DATE MACHINED	09/30/10
Q A APPROVAL	T MC
NOTE: MEASUREMENT GIVEN FOR O D FLATS IS AN AVERAGE TAKEN FROM BOTH SIDES	

UNLESS OTHERWISE SPECIFIED DIM. ARE AS FOLLOWS:	
DECIMAL	FRACT. +/- 1/16
XXXX	+/- .003
XXX	+/- .015
XX	+/- .05
ANGULAR	+/- 5 DEGREES
DEFECT DEPTHS ARE +/- .003 OR 20% WHICH EVER IS LESS	

SCALE:	NONE
DRAWN BY:	T MCNABB

ECUTECH INC. 180 DEGREE THINNING STD.02
DRAWN FOR: CONCO
S/N EU010943 ALL MEASURING DEVICES ARE NIST CERTIFIED
320