

Cooper Power Station- Unit 01					Duration			Cause or Reason	Type of Outage
Date	Time Of	Available MW	Forced or Scheduled	Status	Hours	Minutes			
	11/01/2023	0000	0.0	Scheduled	Maintenance	721	0	UNIT 1 IN PLANNED MAINTENANCE OUTAGE.	Planned in Advance
	12/01/2023	0000	0.0	Scheduled	Maintenance	82	7	PLANNED OUTAGE FOR ECONOMIZER TUBE REPLACEMENT.	Planned in Advance
	12/07/2023	1440	0.0	Scheduled	Maintenance	92	0	OFFLINE, RETURNED TO PLANNED OUTAGE.	Planned in Advance
	12/11/2023	1728	0.0	Scheduled	Maintenance	40	18	OFFLINE, RETURNED TO PLANNED OUTAGE.	Planned in Advance
	12/14/2023	1024	0.0	Scheduled	Maintenance	85	36	OFFLINE, RETURNED TO PLANNED OUTAGE.	Planned in Advance
	01/28/2024	0712	0.0	Forced	Maintenance	2	41	COOPER 1 ENTERED A FORCED OUTAGE DUE TO A WRONG ENTRY VIA THE BOILER TUNER.	Minor Problem
	03/02/2024	0000	0.0	Scheduled	Maintenance	719	0	COOPER 1 STARTED A PLANNED OUTAGE WITH AN ERD OF 4/15/2024.	Planned in Advance
	04/01/2024	0000	0.0	Scheduled	Maintenance	336	0	PLANNED MAINTENANCE OUTAGE - ERD OF 4/15/2024.	Planned in Advance
Cooper Power Station- Unit 02					Duration			Cause or Reason	Type of Outage
Date	Time Of	Available MW	Forced or Scheduled	Status	Hours	Minutes			
	11/05/2023	0000	0.0	Scheduled	Maintenance	625	0	COOPER 2 ENTERED A PLANNED OUTAGE TO PERFORM GENERAL MAINTENANCE.	Planned in Advance
	12/01/2023	0000	0.0	Scheduled	Maintenance	240	0	COOPER 2 CONTINUES ITS PLANNED MAINTENANCE OUTAGE, WITH AN ERD OF 12/11/2023.	Planned in Advance
	03/02/2024	0000	0.0	Scheduled	Maintenance	719	0	COOPER 2 HAS STARTED A PLANNED OUTAGE WITH AN ERD OF 4/15/2024.	Planned in Advance
	04/01/2024	0000	0.0	Scheduled	Maintenance	275	3	PLANNED MAINTENANCE OUTAGE - ERD 4/15/2024.	Planned in Advance

Spurlock Power Station- Unit 01					Duration		Cause or Reason	Type of Outage	
Date	Time Of	Available MW	Forced or Scheduled Status		Hours	Minutes			
	11/01/2023	0000	0.0	Scheduled	Maintenance	721	0	MAJOR TURBINE OVERHAUL.	Planned in Advance
	12/01/2023	0000	0.0	Scheduled	Maintenance	372	21	MAJOR TURBINE OVERHAUL.	Planned in Advance
	01/30/2024	1242	0.0	Forced	Maintenance	11	39	OTHER BOILER INSTRUMENT AND CONTROL PROBLEMS.	Minor Problem
	02/02/2024	0119	0.0	Scheduled	Maintenance	37	14	SECOND SUPERHEATER.	Minor Problem
	04/20/2024	0000	0.0	Scheduled	Maintenance	162	1	BALANCE OF PLANT OVERHAUL/OUTAGE.	Planned in Advance
	04/29/2024	0500	0.0	Forced	Maintenance	11	53	VIBRATION OF THE TURBINE GENERATOR UNIT.	Minor Problem
Spurlock Power Station- Unit 02					Duration		Cause or Reason	Type of Outage	
Date	Time Of	Available MW	Forced or Scheduled Status		Hours	Minutes			
	01/08/2024	0206	0.0	Scheduled	Maintenance	72	2	AIR HEATER FOULING.	Minor Problem
	01/22/2024	1703	0.0	Scheduled	Maintenance	81	59	GENERATOR LUBE OIL SYSTEM.	Minor Problem
	03/09/2024	0000	0.0	Scheduled	Maintenance	551	0	BOILER INSPECTIONS - SCHEDULED OR ROUTINE.	Planned in Advance
	04/01/2024	0000	0.0	Scheduled	Maintenance	157	7	BOILER INSPECTIONS - SCHEDULED OR ROUTINE.	Planned in Advance
	04/07/2024	1438	0.0	Forced	Maintenance	1	17	OTHER OIL AND GAS FUEL SUPPLY PROBLEMS.	Minor Problem
	04/08/2024	1047	0.0	Forced	Maintenance	0	53	MISCELLANEOUS TURBINE PIPING.	Minor Problem
	04/22/2024	2326	0.0	Forced	Maintenance	3	38	SWITCHYARD CIRCUIT BREAKERS.	Minor Problem
Spurlock Power Station- Unit 03					Duration		Cause or Reason	Type of Outage	
Date	Time Of	Available MW	Forced or Scheduled Status		Hours	Minutes			
	11/18/2023	0131	0.0	Scheduled	Maintenance	75	15	BOILER DRAIN SYSTEM.	Minor Problem
	04/13/2024	0000	0.0	Scheduled	Maintenance	432	0	BOILER INSPECTIONS-SCHEDULED OR ROUTINE.	Planned in Advance
Spurlock Power Station- Unit 04					Duration		Cause or Reason	Type of Outage	
Date	Time Of	Available MW	Forced or Scheduled Status		Hours	Minutes			
	11/01/2023	0000	0.0	Scheduled	Maintenance	99	29	BOILER INSPECTIONS - SCHEDULED OR ROUTINE.	Planned in Advance
	11/05/2023	1622	0.0	Forced	Maintenance	0	52	OTHER MISCELLANEOUS BOILER AIR AND GAS SYSTEM PROBLEMS.	Minor Problem
	11/12/2023	0920	0.0	Forced	Maintenance	2	30	SECONDARY AIR FANS/BLOWERS.	Minor Problem
	12/01/2023	0137	0.0	Scheduled	Maintenance	185	57	OTHER BED SOLIDS RECIRCULATION PROBLEMS.	Minor Problem
	03/23/2024	0208	0.0	Scheduled	Maintenance	213	52	FLUE GAS SOLIDS SEPARATOR REFACTORY.	Minor Problem
	04/01/2024	0000	0.0	Scheduled	Maintenance	94	18	FLUE GAS-SOLIDS SEPARATOR REFACTORY.	Minor Problem