

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION
PSC CASE 2025-00232

**IN RE MATTER OF: ELECTRONIC SOUTHERN WATER AND SEWER
DISTRICT UNACCOUNTED FOR WATER LOSS REDUCTION PLAN,
SURCHARGE & MONITORING**

**NOTICE OF FILING
SEPTEMBER 2026 WATER LOSS REPORT**

Comes Southern Water and Sewer District (“Southern Water”), by and through counsel, and provides the Public Service Commission with a notice of filing the September 2026 Water Loss Report. This report is filed in compliance with the order filed on August 15, 2025, in case 2025-00232, page 7, numerical paragraph 11.

During September of 2026, Southern Water produced and purchased 65,326,000 gallons of water. Of those 65,326,000 gallons: 21,775,000 gallons were sold; 3,580,000 gallons were accounted for as other water used; and 39,971,000 gallons were accounted for as water loss.

The total water loss percentage for September 2026 was 61.19%. Approximately 97.47% of water loss was due to line breaks. Approximately 3.5% of water loss was due to tank leaks located at Brush Creek and Ned’s Fork. Please refer to the attached *Monthly Water Loss Report* for a complete analysis and supporting information. Please see the *Monthly Manager’s September 2026 Report* for in-depth information regarding production, purchasing, sales, work orders, leaks, illegal hookups, delinquent accounts, and meter counts.

During the month of Septemeber 2026 Southern Water finished installing 95 meters that were received back from RG3 Meter Company (“RG3”), that had previously been submitted for warranty

repair to the manufacturer. As previously stated, due to the substantial delay in warranty work, Southern Water continues to be limited in their ability to correctly monitor water usage. Please refer to page 7 of the *Monthly Manager's September 2026 Report*. Bell Engineering and Southern Water are currently in the process of exchanging information and formulating plans as they prepare to begin their work on the water loss initiative.

CERTIFICATION

These responses are true and accurate to the best of preparer's knowledge, information and belief formed after reasonable inquiry. Filed on this 15th day of September 2026.

Respectfully Submitted by:



Earl M. McGuire

Attorney at Law

McGuire Law Office

132 South Lake Drive, Suite 203

P.O. Box 1746

Prestonsburg, KY 41653

(606) 889-2201

Counsel for Southern Water & Sewer District

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: Southern Water and Sewer District

For the Month of: September Year: 2026

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	49,694
3	Water Purchased	15,632
4	TOTAL PRODUCED AND PURCHASED	65,326
5		
6	WATER SALES	
7	Residential	17,337
8	Commercial	2,813
9	Industrial	
10	Bulk Loading Stations	
11	Wholesale	1,625
12	Public Authorities	
13	Other Sales (explain)	
14	TOTAL WATER SALES	21,775
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	1,491
18	Wastewater Plant	
19	System Flushing	1,000
20	Fire Department	15
21	Other Usage (explain) <u>Leak Adjustments and Misreads</u>	1074
22	TOTAL OTHER WATER USED	3,580
23		
24	WATER LOSS	
25	Tank Overflows	
26	Line Breaks	38,571
27	Line Leaks	
28	Excavation Damages	
29	Theft	
30	Other Loss (explain) <u>Brush Creek and Neds Fk Tank Leak</u>	1,400
31	TOTAL WATER LOSS	39,971
32		
33	Note: Line 14 + Line 22 + Line 31 MUST Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 divided by Line 4)	61.19%

Southern Water and Sewer District

Monthly Report for October

Produced

December – 47,783,000 gallons for an average of 1,547,387 gallons per day

January – 47,340,000 gallons for an average of 1,527,027 gallons per day

February -44,919,000 gallons for an average of 1,604,250 gallons per day

March – 50,713,000 gallons for an average of 1,635,000 gallons per day

April – 49,533,000 gallons for an average of 1,651,100 gallons per day

May – 50,974,000 gallons for an average of 1,644,323 gallons per day

June - 51,254,000 gallons for an average of 1,708,467 gallons per day

July – 51,038,000 gallons for an average of 1,646,387 gallons per day

August – 51,687,000 gallons for an average of 1,667,323 gallons per day

September – 49,694,000 gallons for an average of 1,656,467 gallons per day

Purchased from Pikeville

December – 14,093,000 gallons

January – 12,892,000 gallons

February – 12,548,000 gallons

March – 11,800,000 gallons

April – 11,638,000 gallons

May – 14,999,000 gallons

June – 14,383,000 gallons

July – 15,285,000 gallons

August – 13,925,000 gallons

September – 13,880,000

Purchased from Knott Co

December – 0 gallons

January – 0 gallons

February – 1,456,000 gallons

March – 386,000 gallons

April – 203,400 gallons

May – 297,000 gallons

June – 1,422,900 gallons

July – 1,649,300 gallons

August – 1,627,500 gallons

September – 1,577,000 gallons

Purchased from Prestonsburg

December - 0 gallons

January - 0 gallons

February – 7,136,000 gallons

March – 155,600 gallons

April - 0 gallons

May – 0 gallons

June – 2,089,000 gallons

July – 562,300 gallons

August – 175,400 gallons

September – 175,200 gallons

Sold to Hindman

December – 1,942,289 gallons

January – 2,486,659 gallons

February – 2,396,790 gallons

March – 2,532,236 gallons

April – 1,464,300 gallons

May – 1,589,259 gallons

June – 1,825,344 gallons

July – 1,247,900 gallons

August – 1,202,570 gallons

September – 1,574,724 gallons

Sold to Knott Co.

December – 17,372 gallons

January – 27,377 gallons

February – 26,138 gallons

March – 21,385 gallons

April – 22,106 gallons

May – 29,878 gallons

June – 29,928 gallons

July – 26,011 gallons

August - 71,341 gallons

September – 50,595 gallons

Total Work Orders

December – 330

January – 357

February – 337

March – 308

April – 343

May – 308

June – 282

July – 492

August - 255

Main Line Leaks

December – 3

January – 2

February – 6

March – 3

April – 4

May – 3

June – 4

July – 2

August -2

September - 1

Service Line Leaks

December - 18

January - 16

February - 14

March - 11

April - 13

May - 17

June - 15

July - 23

August - 18

September - 10

Illegal Hookups

December - 2

January - 1

February - 1

March - 1

April - 1

May - 0

June - 2

July - 3

August - 6

September - 3

Leaks in Base

December – 12

January – 2

February – 4

March - 6

April – 4

May – 6

June – 4

July – 4

August – 6

September - 8

Delinquent Accounts

December – 55

January – 45

February – 44

March – 27

April – 51

May – 27

June – 15

July – 12

August- 50

September - 33

Meter Count

June – 582 meters at RG3 for Repairs

948 Dead in the system

150 Meters that have been replaced by Zenners

We got 100 meters back from RG3 to work back into the system

July – We installed 163 meters that we received from RG3 which leaves a estimated 785 dead in the system now.

Zenner officially shut us out of their network so we have to manually read those meters. They tried to charge us roughly 1500.00 to use their network, when this was not in the original deal.

For the month of August we have finished installing the 450 meters we received back from RG3. We have 450-460 meters ready to ship back tomorrow along with 10 more with busted meter bottoms. Currently we have a estimated 600 dead in the system.

An additional 95 meter changeouts was performed again for the month of September.