

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION
PSC CASE 2025-00232

**IN RE MATTER OF: ELECTRONIC SOUTHERN WATER AND SEWER
DISTRICT UNACCOUNTED FOR WATER LOSS REDUCTION PLAN,
SURCHARGE & MONITORING**

NOTICE OF FILING
APRIL 2026 WATER LOSS REPORT


Comes Southern Water and Sewer District (“Southern”), by and through counsel, and provides the Public Service Commission with the attached Water Loss Report for April of 2026.

During April of 2026, Southern produced and purchased 61,374 gallons of water. Of those 61,374 gallons 22,473 gallons were sold, 4,144 gallons were accounted as other water used, and 34,757 gallons were accounted as water loss. The water loss percentage for April 2026 was 56.63%

CERTIFICATION

These responses are true and accurate to the best of preparer’s knowledge, information and belief formed after reasonable inquiry. Filed on this 15th day of May 2026.

Respectfully Submitted by:


Earl M. McGuire
Attorney at Law
McGuire Law Office
132 South Lake Drive, Suite 203
P.O. Box 1746
Prestonsburg, KY 41653
(606) 889-2201
Counsel for Southern Water & Sewer District

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: Southern Water & sewer District

For the Month of: April Year: 2026

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	49,533
3	Water Purchased	11,841
4	TOTAL PRODUCED AND PURCHASED	61,374
5		
6	WATER SALES	
7	Residential	18,318
8	Commercial	2,668
9	Industrial	
10	Bulk Loading Stations	
11	Wholesale	1,487
12	Public Authorities	
13	Other Sales (explain)	
14	TOTAL WATER SALES	22,473
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	1,486
18	Wastewater Plant	
19	System Flushing	800
20	Fire Department	18
21	Other Usage (explain) <u>Misreads and adjustments</u>	1840
22	TOTAL OTHER WATER USED	4,144
23		
24	WATER LOSS	
25	Tank Overflows	
26	Line Breaks	11,152
27	Line Leaks	11,152
28	Excavation Damages	11,153
29	Theft	
30	Other Loss (explain) <u>Brush Crk and Neds Fk Tank Leak</u>	1,300
31	TOTAL WATER LOSS	34,757
32		
33	Note: Line 14 + Line 22 + Line 31 MUST Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 divided by Line 4)	56.63%