

MYSO, LLC  
Response to Siting Board Staff's Post-Hearing Request for Information  
Case No. 2025-00395

Request No. 1:

Provide the entire corporate structure or membership interests of the entities that have ownership interests in MYSO, LLC.

Response:


Please see attached.

Responding Witness: Jacqui Kitchen



## BrightNight Organization Chart

\* All entities 100% owned unless (indicated) otherwise  
\*\* All limited liability companies organized under the laws of the state of Delaware



MYSO, LLC  
Response to Siting Board Staff's Post-Hearing Request for Information  
Case No. 2025-00395

Request No. 2:

Explain whether the Federal Emergency Management Agency will need to be consulted regarding this proposed project being constructed in a flood plain.

Response:

Consultation with the Federal Emergency Management Agency (FEMA) for development within the floodplain will not be necessary for the Project. Floodplain development is administered at the local and state level, rather than at the federal level. The Project has already consulted with the Graves County Floodplain Coordinator, who will sign off on a Stream Construction Permit (*i.e.*, Floodplain Permit) application to be submitted to the Kentucky Energy and Environment Cabinet, Division of Water, Floodplain Division. FEMA consultation is only required under certain circumstances, such as a request to change a FEMA flood map or if a development will alter the base flood elevation, neither of which will occur here as part of or resulting from Project construction.

Responding Witness: Bob Roy

MYSO, LLC  
Response to Siting Board Staff's Post-Hearing Request for Information  
Case No. 2025-00395

Request No. 3:

Provide a table with the distances from the nearest nonparticipating residence (dwelling not property line) who did not enter into a Good Neighbor Agreement to the following:

- a. Fencing.
- b. Closest solar panel.
- c. Closest inverter.
- d. Substation.
- e. Battery Storage.

Response:

See below for a table with the distances from the nearest nonparticipating residence who did not enter into a Good Neighbor Agreement to listed Project components. Distances were measured from the nearest point of the listed Receptor's dwelling to the nearest point of the correlating component.

| <b>Component</b> | <b>Receptor</b> | <b>Distance (ft)</b> |
|------------------|-----------------|----------------------|
| Fencing          | R-63            | 218                  |
| Solar Panel      | R-63            | 322                  |
| Inverter         | R-56            | 986                  |
| Substation       | R-138           | 2,687                |
| BESS             | R-138           | 2,651                |

Responding Witness: Matthew Batdorf