KENTUCKY-AMERICAN WATER COMPANY
CASE NO. 2026-00094
LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT'S
POST-HEARING REQUEST FOR INFORMATION

Witness: John Magner

1. Please refer to KAWC's response to the Attorney General's First Request for Information, Question 46(r) where the estimated cost for SIP-eligible main replacement for 2027 to 2029 is $425 per linear foot. Also please refer to the Hearing Testimony of John Magner concerning paving and restoration costs.[1] Provide the per foot cost of the $425 per linear foot cost that is attributed to restoration costs. If possible, please segregate the restoration costs by category e.g., paving, curb restoration, etc.

Response:

Kentucky American Water ("KAWC") uses an aggregate cost per foot when budgeting water main replacements, as the portions of this overall cost attributed to various project elements (materials, contract labor, restoration, etc.) can vary significantly based on the specific projects executed within a given year.

For projects implemented as part of KAWC's QIP Year 6, restoration costs represented approximately 26% of total project costs.

[1] HVT of the Oct. 13, 2026 Hearing at 02:59:30-02:59:46.