



an e-on company

RECEIVED

MAR 12 2009

PUBLIC SERVICE  
COMMISSION

Mr. Jeff Derouen  
Executive Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
Frankfort, KY 40602

**Louisville Gas and  
Electric Company**  
State Regulation and Rates  
220 West Main Street  
PO Box 32010  
Louisville, Kentucky 40232  
www.eon-us.com

March 12, 2009

Robert M. Conroy  
Director - Rates  
T 502-627-3324  
F 502-627-3213  
robert.conroy@eon-us.com

**RE: *AN EXAMINATION OF THE APPLICATION OF THE FUEL  
ADJUSTMENT CLAUSE OF LOUISVILLE GAS AND ELECTRIC  
COMPANY FROM NOVEMBER 1, 2006 THROUGH OCTOBER 31,  
2008 - CASE NO. 2008-00521***

Dear Mr. Derouen:

On February 11, 2009, Louisville Gas and Electric Company ("LG&E") filed its Response to the Information Requested in Appendix B of the Commission's Order dated January 23, 2009, in the above-referenced matter.

Since the filing on February 11, it has been discovered that page 5 of LG&E's Response to Question No. 14, which contains scheduled, actual and forced outages for Mill Creek Unit 2 for the period May 2008 through October 2008, inadvertently contained a typographical error regarding the duration of an outage which occurred in June 2008. Therefore, enclosed are an original and five copies of revised page 5 of LG&E's response to Question No. 14 reflecting the correct duration of the June 2008 outage.

Should you have any questions concerning the enclosed, please contact me at your convenience.

Sincerely,

Robert M. Conroy

Enclosures

VERIFICATION

COMMONWEALTH OF KENTUCKY )  
 ) SS:  
COUNTY OF JEFFERSON )

The undersigned, **Frederick D. Jackson**, being duly sworn, deposes and says that he is the Director of Generation Services for E.ON U.S. Services Inc., that he has personal knowledge of the matters set forth in the responses for which he is identified as the witness, and the answers contained therein are true and correct to the best of his information, knowledge and belief.

*Frederick D Jackson*  
**FREDERICK D. JACKSON**

Subscribed and sworn to before me, a Notary Public in and before said County and State, this 12<sup>th</sup> day of March 2009.

*Victoria B. Harper*  
(SEAL)  
Notary Public

My Commission Expires:  
*Sept 20, 2010*

Louisville Gas & Electric Company  
 Mill Creek Unit #2 - Coal - 301 MW  
 May 2008 through October 2008

Schedule vs Actual

| MONTH     | MAINTENANCE    |                           |                 |                 | HOURS OF DURATION |        | REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE |                                    |  |
|-----------|----------------|---------------------------|-----------------|-----------------|-------------------|--------|--|------------------------------------|--|
|           | Scheduled FROM | Scheduled TO              | Actual FROM     | Actual TO       | Scheduled         | Actual |  |                                    |  |
| May       | S              | 5/23/2008 22:02           | 5/26/2008 21:53 | 5/23/2008 22:02 | 5/26/2008 21:53   | 71:51  | 71:51  | Air heater - wash                  |  |
| June      | F              |                           |                 | 6/7/2008 9:52   | 6/8/2008 21:22    | 35:30  |  | Condenser tube leak                |  |
| July      | F              |                           |                 | 7/7/2008 2:00   | 7/13/2008 21:26   | 163:26 |  | Turbine turning gear               |  |
|           | F              |                           |                 | 7/13/2008 21:32 | 7/14/2008 11:36   | 14:04  |  | Turbine vacuum trip                |  |
|           | S              | 7/30/2008 13:34           | →               | 7/30/2008 13:34 | →                 | 34:26  | 34:26  | Second superheater boiler tube     |  |
| August    | S              | →                         | 8/1/2008 1:51   | →               | 8/1/2008 1:51     | 1:51   | 1:51   | Second superheater boiler tube     |  |
|           | S              | 8/30/2008 0:28            | 8/30/2008 22:33 | 8/30/2008 0:28  | 8/30/2008 22:33   | 22:05  | 22:05  | Waterwall boiler tube              |  |
| September | S              | 9/13/2008 0:00            | 9/21/2008 15:00 | 9/16/2008 22:17 | 9/21/2008 7:58    | 207:00 | 105:41   | Planned outage - boiler inspection |  |
| October   |                | No outages > or = 6 hours |                 |                 |                   |        |  |                                    |  |