

---

**From:** Freibert, Charlie  
**To:** Schetzel, Doug; Barker, Daryn  
**Sent:** 2/24/2009 1:53:32 PM  
**Subject:** RE: Invenergy PJM Point to Point

Doug,

I have left Dan 2 voice mails explaining that point of interconnection between PJM and LGEE is not a specific line but the electric summation of all lines connecting the control areas. Thus it is not appropriate to specify a specific line/interconnection point. I told Dan that I want to discuss this with him by phone to see if I have answered his question completely. I will let you know if I hear more. Thanks,

Charlie Freibert

Director Energy Marketing

E.ON US - LG&E/KU

220 West Main Street

Louisville, KY 40202

O502-627-3673

F502-627-3613

M502-553-9007

email: charlie.freibert@eon-us.com

---

**From:** Schetzel, Doug  
**Sent:** Tuesday, February 24, 2009 11:38 AM  
**To:** Freibert, Charlie; Barker, Daryn  
**Subject:** Invenergy PJM Point to Point

Dan Thompson of Invenergy wants to know the delivery point for our point to point request. Is it a specific point on the LGE or KU system or is it any LGE/KU PJM interconnection?

Douglas K. Schetzel

Director Business Development

E.ON U.S. LLC

220 West Main Street

Louisville, KY 40202

T 502-627-4838

M 502-552-3220

doug.schetzel@eon-us.com