



Steven L. Beshear
Governor

Leonard K. Peters
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

David L. Armstrong
Chairman

James W. Gardner
Vice Chairman


Charles R. Borders
Commissioner

March 10, 2010

PARTIES OF RECORD

Re: Case No. 2010-00034
Kenergy Corporation
Application to Establish a Sample Meter Testing Plan

Attached is a copy of the memorandum which is being filed in the record of the above-referenced case. If you have any comments you would like to make regarding the contents of the informal conference memorandum, please do so within five days of receipt of this letter. If you have any questions, please contact Quang Nguyen, Staff Attorney, at 502/564-3940, Extension 256.


Sincerely,

Jeff Derouen
Executive Director

QN/kar

Attachments

INTRA-AGENCY MEMORANDUM
KENTUCKY PUBLIC SERVICE COMMISSION

TO: Case File

FROM: Quang D. Nguyen, Staff Attorney 

DATE: March 10, 2010

RE: Case No. 2010-00034
Kenergy Corp. Sample Meter Testing Plan

Pursuant to a Commission Staff notice dated March 2, 2010, an informal conference was held at the Commission's offices on March 5, 2010. A list of the attendees is attached hereto. The purpose of the conference was to discuss issues relating to Kenergy Corp.'s ("Kenergy") application to establish a sample meter testing plan.

Kenergy explained its proposed sample meter testing plan is primarily based upon the American National Standard Institute ANSI/ASZC Z1.9-2003 (Sampling Procedures and Tables for Inspection). Kenergy's proposed plan also incorporated elements of 807 KAR 5:041, Section 16 regarding protocols of a failed test group. Commission Staff advised Kenergy that prior Commission approved sample meter test plans of other jurisdictional electric utilities included a provision of replacing or testing all meters in a failed test group within 18 months.

At the conclusion of the conference, Kenergy indicated that it will most likely amend its application in the near future. Any amended application will reflect changes to Kenergy's sample meter testing plan consistent with prior Commission approved sample meter testing plans.

There being no further discussions, the conference was adjourned.

Attachment

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

CASE NOS. 2010-00034

APPLICATION OF KENERGY CORP. FOR APPROVAL OF SAMPLE METER
TESTING PLAN

SIGN IN

March 5, 2010

PERSON

REPRESENTING

Quang D. Nguyen

PSC - Legal

Sandy Norick

Kenergy

John A. ...

Kenergy

Vicky Towns

PSC - FA

Elic Russell

PSC

Tuff Moore

PSC

James Bridges

DSS

Chris Hopgood

Kenergy

JORGE VALLADARES

PSC - Financial Analysis notes

STEVE KINGSOLVER

PSC