

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Conway		ABC	SRC-Conway	7.50Y	125.0	0.00	0.00	377.38	0	8066	2654	95	0.00	0.0	0.000	0.000	0	0	0	1275
PL.62144	Conway	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	79.58	15	1712	524	96	0.03	0.0	0.006	0.006	0	0	0	242
PL.62150	PL.62144	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	79.58	15	1712	524	96	0.05	0.0	0.015	0.009	0	0	0	242
----- Feeder No. 2 (Flat Gap F2) Beginning with Device PD.9331 -----																				
PD.9331	PL.62150	ABC	480VWE	7.50Y	125.0	0.00	0.01	79.58	0	1712	523	96	0.00	0.0	0.015	0.009	0	0	0	242
PL.62149	PD.9331	ABC	336 MCM AC	7.50Y	125.0	0.03	0.04	79.58	15	1712	523	96	0.29	0.0	0.070	0.055	0	0	0	242
PL.62148	PL.62149	ABC	336 MCM AC	7.49Y	124.8	0.19	0.23	79.58	15	1712	523	96	1.65	0.1	0.379	0.310	0	0	0	242
PL.62147	PL.62148	ABC	336 MCM AC	7.48Y	124.7	0.03	0.26	79.58	15	1710	519	96	0.23	0.0	0.422	0.043	5	1	2	242
PL.62145	PL.62147	C	#4 ACSR	7.48Y	124.7	0.00	0.26	0.14	0	1	0	100	0.00	0.0	0.426	0.004	0	0	0	1
PD.9313	PL.62145	C	40QA	7.48Y	124.7	0.00	0.26	0.14	0	1	0	100	0.00	0.0	0.426	0.004	0	0	0	1
PL.62126	PD.9313	C	#4 ACSR	7.48Y	124.7	0.00	0.26	0.14	0	1	0	100	0.00	0.0	0.453	0.027	1	0	1	1
PL.62146	PL.62147	ABC	336 MCM AC	7.48Y	124.7	0.02	0.28	79.31	15	1704	517	96	0.17	0.0	0.454	0.032	0	0	1	239
PL.62132	PL.62146	ABC	336 MCM AC	7.48Y	124.6	0.11	0.39	79.30	15	1704	516	96	0.95	0.1	0.635	0.181	13	4	1	238
PL.62133	PL.62132	ABC	336 MCM AC	7.47Y	124.6	0.04	0.42	78.48	15	1685	509	96	0.32	0.0	0.697	0.062	0	0	0	236
PL.37642	PL.62133	ABC	#1/0 ACSR	7.47Y	124.5	0.04	0.46	78.25	34	1680	507	96	0.46	0.0	0.725	0.028	0	0	0	235
PL.37362	PL.37642	A	#2 ACSR	7.47Y	124.5	0.00	0.46	2.67	2	19	6	95	0.00	0.0	0.726	0.001	0	0	0	2
PD.6082	PL.37362	A	60QA	7.47Y	124.5	0.00	0.46	2.67	4	19	6	95	0.00	0.0	0.726	0.001	0	0	0	2
PL.37363	PD.6082	A	#2 ACSR	7.47Y	124.5	0.00	0.46	2.67	2	19	6	95	0.00	0.0	0.740	0.014	19	6	2	2
PL.36735	PL.37642	ABC	#1/0 ACSR	7.47Y	124.5	0.06	0.53	77.37	34	1660	500	96	0.73	0.0	0.772	0.046	30	9	3	233
PL.59576	PL.36735	ABC	#1/0 ACSR	7.47Y	124.4	0.04	0.57	75.98	33	1630	491	96	0.42	0.0	0.799	0.027	0	0	0	230
PL.59577	PL.59576	ABC	#1/0 ACSR	7.46Y	124.4	0.07	0.64	75.16	33	1612	485	96	0.80	0.0	0.852	0.053	0	0	0	227
PL.59573	PL.59577	ABC	#1/0 ACSR	7.46Y	124.3	0.06	0.70	75.16	33	1611	485	96	0.62	0.0	0.893	0.041	0	0	0	227
PL.59574	PL.59573	A	#2 ACSR	7.46Y	124.3	0.00	0.70	3.23	2	23	7	96	0.00	0.0	0.911	0.018	23	7	2	2
PL.36745	PL.59574	A	#2 ACSR	7.46Y	124.3	0.00	0.70	0.00	0	0	0	100	0.00	0.0	0.940	0.028	0	0	0	0
PL.59572	PL.59573	ABC	#1/0 ACSR	7.46Y	124.3	0.01	0.71	52.91	23	1134	341	96	0.08	0.0	0.904	0.011	0	0	0	154
PL.37038	PL.59572	ABC	#1/0 ACSR	7.46Y	124.3	0.04	0.75	52.91	23	1134	341	96	0.33	0.0	0.948	0.044	0	0	0	154
PL.37391	PL.37038	ABC	#1/0 ACSR	7.45Y	124.2	0.05	0.80	52.78	23	1130	340	96	0.40	0.0	1.002	0.053	0	0	0	153
PL.38121	PL.37391	ABC	#1/0 ACSR	7.45Y	124.1	0.06	0.86	52.14	23	1116	335	96	0.46	0.0	1.066	0.064	22	7	3	152
PL.38122	PL.38121	ABC	#1/0 ACSR	7.44Y	124.0	0.12	0.98	51.09	22	1093	328	96	0.89	0.1	1.194	0.129	0	0	0	149
C PD.5912	PL.38122	ABC	50L	7.44Y	124.0	0.00	0.98	51.09	102	1093	327	96	0.00	0.0	1.194	0.129	0	0	0	149 C

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38123	PD.5912	ABC	#1/0 ACSR	7.44Y	124.0	0.00	0.98	51.09	22	1093	327	96	0.01	0.0	1.195	0.001	0	0	0	149
PL.37834	PL.38123	ABC	#1/0 ACSR	7.44Y	124.0	0.03	1.01	51.09	22	1093	327	96	0.25	0.0	1.231	0.036	0	0	0	149
PL.38707	PL.37834	ABC	#1/0 ACSR	7.43Y	123.8	0.15	1.17	48.81	21	1043	313	96	1.08	0.1	1.401	0.170	0	0	0	142
PL.38705	PL.38707	A	#2 ACSR	7.43Y	123.8	0.00	1.17	0.51	0	4	1	97	0.00	0.0	1.404	0.002	0	0	0	1
PD.5960	PL.38705	A	40QA	7.43Y	123.8	0.00	1.17	0.51	1	4	1	97	0.00	0.0	1.404	0.002	0	0	0	1
PL.38706	PD.5960	A	#2 ACSR	7.43Y	123.8	0.00	1.17	0.51	0	4	1	97	0.00	0.0	1.457	0.053	4	1	1	1
PL.37679	PL.38707	ABC	#1/0 ACSR	7.43Y	123.8	0.04	1.21	48.64	21	1039	311	96	0.28	0.0	1.446	0.045	0	0	0	141
PL.64240	PL.37679	ABC	#1/0 ACSR	7.42Y	123.7	0.06	1.27	46.88	20	1001	299	96	0.44	0.0	1.521	0.075	0	0	0	137
PL.64004	PL.64240	C	#2 ACSR	7.42Y	123.7	0.00	1.27	4.07	2	29	9	96	0.00	0.0	1.524	0.003	0	0	0	2
PD.9504	PL.64004	C	20QA	7.42Y	123.7	0.00	1.27	4.07	20	29	9	96	0.00	0.0	1.524	0.003	0	0	0	2
PL.64160	PD.9504	C	#2 ACSR	7.42Y	123.7	0.00	1.27	4.07	2	29	9	96	0.00	0.0	1.570	0.045	13	4	1	2
PL.64157	PL.64160	C	#2 ACSR	7.42Y	123.7	0.00	1.28	2.20	1	16	5	95	0.00	0.0	1.642	0.072	16	5	1	1
PL.64241	PL.64240	ABC	#1/0 ACSR	7.42Y	123.7	0.05	1.32	45.52	20	971	290	96	0.34	0.0	1.582	0.061	0	0	0	135
PL.64243	PL.64241	A	#4 ACSR	7.42Y	123.7	0.00	1.32	10.48	8	75	22	96	0.00	0.0	1.584	0.002	0	0	0	9
PD.6081	PL.64243	A	40QA	7.42Y	123.7	0.00	1.32	10.48	26	75	22	96	0.00	0.0	1.584	0.002	0	0	0	9
PL.37856	PD.6081	A	#4 ACSR	7.42Y	123.7	0.02	1.34	10.48	8	75	22	96	0.01	0.0	1.636	0.052	11	3	1	9
PL.38708	PL.37856	A	#4 ACSR	7.42Y	123.6	0.01	1.35	8.87	7	63	19	96	0.00	0.0	1.661	0.025	43	13	5	8
PL.38710	PL.38708	A	#4 ACSR	7.42Y	123.6	0.00	1.35	2.83	2	20	6	96	0.00	0.0	1.674	0.013	0	0	0	3
PL.38711	PL.38710	A	#4 ACSR	7.42Y	123.6	0.00	1.35	2.83	2	20	6	96	0.00	0.0	1.684	0.010	20	6	3	3
PL.64003	PL.64241	A	#4 ACSR	7.42Y	123.7	0.00	1.32	25.21	19	179	53	96	0.00	0.0	1.585	0.002	0	0	0	25
PD.9503	PL.64003	A	40QA	7.42Y	123.7	0.00	1.32	25.21	63	179	53	96	0.00	0.0	1.585	0.002	0	0	0	25
PL.64024	PD.9503	A	#4 ACSR	7.41Y	123.6	0.10	1.42	25.21	19	179	53	96	0.13	0.1	1.677	0.092	15	4	2	25
PL.64023	PL.64024	A	#4 ACSR	7.41Y	123.5	0.12	1.55	23.11	18	164	49	96	0.15	0.1	1.798	0.122	7	2	1	23
PL.64028	PL.64023	A	#4 ACSR	7.41Y	123.4	0.01	1.55	3.29	3	23	7	96	0.00	0.0	1.843	0.044	6	2	2	4
PL.64016	PL.64028	A	#4 ACSR	7.41Y	123.4	0.00	1.55	2.49	2	18	5	96	0.00	0.0	1.874	0.031	18	5	2	2
PL.64031	PL.64023	A	#4 ACSR	7.40Y	123.4	0.10	1.65	18.83	14	134	40	96	0.10	0.1	1.920	0.121	2	1	1	18
PL.64030	PL.64031	A	#4 ACSR	7.40Y	123.3	0.02	1.67	18.48	14	131	39	96	0.02	0.0	1.953	0.033	32	10	4	17
PL.64011	PL.64030	A	#4 ACSR	7.40Y	123.3	0.02	1.70	7.48	6	53	16	96	0.01	0.0	2.031	0.078	8	2	1	5
PL.64012	PL.64011	A	#4 ACSR	7.40Y	123.3	0.01	1.71	6.41	5	45	13	96	0.00	0.0	2.089	0.058	35	10	3	4
PL.64036	PL.64012	A	#4 ACSR	7.40Y	123.3	0.00	1.71	1.44	1	10	3	96	0.00	0.0	2.203	0.114	10	3	1	1
PL.64033	PL.64030	A	#4 ACSR	7.40Y	123.3	0.01	1.69	6.46	5	46	14	96	0.00	0.0	2.000	0.046	0	0	0	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64245	PL.64033	A	#4 ACSR	7.40Y	123.3	0.00	1.69	1.93	1	14	4	96	0.00	0.0	2.057	0.057	14	4	2	2
PL.64246	PL.64033	A	#4 ACSR	7.40Y	123.3	0.02	1.71	4.53	3	32	10	95	0.00	0.0	2.152	0.152	14	4	2	6
PL.61035	PL.64246	A	#4 ACSR	7.40Y	123.3	0.00	1.71	1.20	1	9	3	95	0.00	0.0	2.195	0.043	9	3	2	2
PL.38100	PL.64246	A	#4 ACSR	7.40Y	123.3	0.00	1.71	1.32	1	9	3	95	0.00	0.0	2.194	0.042	9	3	2	2
PL.64242	PL.64241	A	#4/0 ACSR	7.42Y	123.7	0.00	1.32	2.33	1	17	5	96	0.00	0.0	1.584	0.002	0	0	0	1
PD.5962	PL.64242	A	40QA	7.42Y	123.7	0.00	1.32	2.33	6	17	5	96	0.00	0.0	1.584	0.002	0	0	0	1
PL.37659	PD.5962	A	#4/0 ACSR	7.42Y	123.7	0.00	1.32	2.33	1	17	5	96	0.00	0.0	1.592	0.008	17	5	1	1
PL.64244	PL.64241	ABC	#1/0 ACSR	7.42Y	123.6	0.04	1.36	32.85	14	701	209	96	0.18	0.0	1.644	0.062	5	1	2	100
PL.38085	PL.64244	ABC	#1/0 ACSR	7.42Y	123.6	0.04	1.40	32.62	14	696	208	96	0.20	0.0	1.716	0.072	9	3	1	98
PL.38088	PL.38085	ABC	#1/0 ACSR	7.41Y	123.6	0.03	1.43	30.96	13	660	197	96	0.13	0.0	1.768	0.052	0	0	0	95
PL.38091	PL.38088	ABC	#1/0 ACSR	7.41Y	123.5	0.05	1.48	30.10	13	641	192	96	0.22	0.0	1.860	0.092	10	3	2	92
PL.38092	PL.38091	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.49	29.60	13	631	188	96	0.07	0.0	1.888	0.028	0	0	0	90
PL.38415	PL.38092	ABC	#1/0 ACSR	7.41Y	123.5	0.04	1.54	29.37	13	626	187	96	0.19	0.0	1.970	0.082	0	0	0	88
PL.37857	PL.38415	A	#2 ACSR	7.41Y	123.5	0.00	1.54	2.83	2	20	6	96	0.00	0.0	1.973	0.003	0	0	0	3
PD.5959	PL.37857	A	40QA	7.41Y	123.5	0.00	1.54	2.83	7	20	6	96	0.00	0.0	1.973	0.003	0	0	0	3
PL.37558	PD.5959	A	#2 ACSR	7.41Y	123.5	0.00	1.54	2.83	2	20	6	96	0.00	0.0	2.009	0.035	10	3	1	3
PL.37105	PL.37558	A	#2 ACSR	7.41Y	123.5	0.00	1.54	1.42	1	10	3	96	0.00	0.0	2.053	0.044	0	0	1	2
PL.37673	PL.37105	A	#2 ACSR	7.41Y	123.5	0.00	1.54	1.39	1	10	3	96	0.00	0.0	2.117	0.064	10	3	1	1
PL.37559	PL.38415	ABC	#1/0 ACSR	7.41Y	123.4	0.04	1.58	28.42	12	605	180	96	0.18	0.0	2.053	0.083	9	3	1	85
PL.64247	PL.37559	ABC	#1/0 ACSR	7.40Y	123.4	0.03	1.62	28.00	12	596	178	96	0.14	0.0	2.120	0.067	0	0	0	84
PL.64248	PL.64247	ABC	#1/0 ACSR	7.40Y	123.3	0.05	1.67	27.30	12	581	173	96	0.21	0.0	2.226	0.107	0	0	0	80
PL.37377	PL.64248	A	#4 ACSR	7.40Y	123.3	0.00	1.67	11.73	9	83	25	96	0.00	0.0	2.228	0.001	0	0	0	11
PD.5238	PL.37377	A	40QA	7.40Y	123.3	0.00	1.67	11.73	29	83	25	96	0.00	0.0	2.228	0.001	0	0	0	11
PL.37378	PD.5238	A	#4 ACSR	7.40Y	123.3	0.01	1.68	11.73	9	83	25	96	0.01	0.0	2.258	0.031	13	4	2	11
PL.38145	PL.37378	A	#4 ACSR	7.40Y	123.3	0.02	1.70	9.93	8	70	21	96	0.01	0.0	2.309	0.051	22	7	3	9
PL.37755	PL.38145	A	#4 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	2.379	0.070	0	0	0	0
PL.37622	PL.38145	A	#4 ACSR	7.40Y	123.3	0.02	1.72	6.78	5	48	14	96	0.01	0.0	2.375	0.066	3	1	2	6
PL.37623	PL.37622	A	#4 ACSR	7.40Y	123.3	0.01	1.73	6.34	5	45	13	96	0.00	0.0	2.402	0.027	0	0	0	4
PL.36736	PL.37623	A	#4 ACSR	7.40Y	123.3	0.00	1.73	6.34	5	45	13	96	0.00	0.0	2.430	0.028	45	13	4	4
PL.37883	PL.36736	A	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	2.464	0.034	0	0	0	0
PL.37624	PL.37623	A	#1/0 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	2.427	0.026	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37625	PL.37624	A	#1/0 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	2.457	0.029	0	0	0	0
PL.37379	PL.64248	A	#4 ACSR	7.40Y	123.3	0.00	1.67	1.65	1	12	3	97	0.00	0.0	2.228	0.001	0	0	0	3
PD.5239	PL.37379	A	40QA	7.40Y	123.3	0.00	1.67	1.65	4	12	3	97	0.00	0.0	2.228	0.001	0	0	0	3
PL.37380	PD.5239	A	#4 ACSR	7.40Y	123.3	0.00	1.67	1.65	1	12	3	97	0.00	0.0	2.259	0.031	12	3	3	3
PL.64250	PL.64248	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.68	22.85	10	486	145	96	0.04	0.0	2.258	0.032	0	0	0	66
PL.64249	PL.64250	A	#4 ACSR	7.40Y	123.3	0.00	1.68	1.11	1	8	2	97	0.00	0.0	2.259	0.001	0	0	0	1
PD.6074	PL.64249	A	40QA	7.40Y	123.3	0.00	1.68	1.11	3	8	2	97	0.00	0.0	2.259	0.001	0	0	0	1
PL.37198	PD.6074	A	#4 ACSR	7.40Y	123.3	0.00	1.68	1.11	1	8	2	97	0.00	0.0	2.282	0.023	8	2	1	1
PL.64156	PL.64250	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.70	21.74	9	462	138	96	0.07	0.0	2.318	0.060	22	7	2	62
PL.64577	PL.64156	ABC	#1/0 ACSR	7.40Y	123.3	0.00	1.70	20.70	9	440	131	96	0.00	0.0	2.318	0.000	0	0	0	60
PL.64578	PL.64577	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.72	20.70	9	440	131	96	0.05	0.0	2.362	0.044	0	0	0	60
PL.64253	PL.64578	A	#2 ACSR	7.40Y	123.3	0.00	1.72	3.32	2	24	7	96	0.00	0.0	2.362	0.001	0	0	0	3
PD.5223	PL.64253	A	40QA	7.40Y	123.3	0.00	1.72	3.32	8	24	7	96	0.00	0.0	2.362	0.001	0	0	0	3
PL.38697	PD.5223	A	#2 ACSR	7.40Y	123.3	0.00	1.72	3.32	2	24	7	96	0.00	0.0	2.380	0.018	12	3	2	3
PL.61392	PL.38697	A	#2 ACSR	7.40Y	123.3	0.00	1.72	1.69	1	12	4	95	0.00	0.0	2.399	0.019	0	0	0	1
PL.63058	PL.61392	A	#1/0 ACSR	7.40Y	123.3	0.00	1.72	1.69	1	12	4	95	0.00	0.0	2.447	0.048	12	4	1	1
PL.64252	PL.64578	A	#2 ACSR	7.40Y	123.3	0.00	1.72	3.29	2	23	7	96	0.00	0.0	2.363	0.001	0	0	0	3
PD.6073	PL.64252	A	40QA	7.40Y	123.3	0.00	1.72	3.29	8	23	7	96	0.00	0.0	2.363	0.001	0	0	0	3
PL.38696	PD.6073	A	#2 ACSR	7.40Y	123.3	0.00	1.72	3.29	2	23	7	96	0.00	0.0	2.396	0.033	23	7	3	3
PL.64254	PL.64578	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.75	18.50	8	393	117	96	0.06	0.0	2.437	0.075	39	12	5	54
PL.61408	PL.64254	A	#2 ACSR	7.40Y	123.3	0.00	1.75	0.00	0	0	0	100	0.00	0.0	2.466	0.029	0	0	0	0
PL.61409	PL.64254	ABC	#1/0 ACSR	7.39Y	123.2	0.01	1.76	16.65	7	354	105	96	0.04	0.0	2.486	0.049	9	3	1	49
PL.38698	PL.61409	C	#2 ACSR	7.39Y	123.2	0.00	1.76	1.98	1	14	4	96	0.00	0.0	2.486	0.000	0	0	0	1
PD.6072	PL.38698	C	40QA	7.39Y	123.2	0.00	1.76	1.98	5	14	4	96	0.00	0.0	2.486	0.000	0	0	0	1
PL.38699	PD.6072	C	#2 ACSR	7.39Y	123.2	0.00	1.76	1.98	1	14	4	96	0.00	0.0	2.513	0.027	14	4	1	1
PL.38700	PL.61409	A	6 A (CWC)	7.39Y	123.2	0.00	1.76	17.40	12	123	37	96	0.00	0.0	2.486	0.000	0	0	0	16
PD.5890	PL.38700	A	40QA	7.39Y	123.2	0.00	1.76	17.40	44	123	37	96	0.00	0.0	2.486	0.000	0	0	0	16
PL.37951	PD.5890	A	6 A (CWC)	7.39Y	123.2	0.07	1.83	17.40	12	123	37	96	0.06	0.0	2.571	0.085	3	1	1	16
PL.37556	PL.37951	A	6 A (CWC)	7.39Y	123.1	0.04	1.87	16.95	12	120	36	96	0.04	0.0	2.628	0.057	10	3	1	15
PL.37557	PL.37556	A	6 A (CWC)	7.38Y	123.1	0.06	1.92	15.56	11	110	33	96	0.05	0.0	2.705	0.077	0	0	0	14
PL.38704	PL.37557	A	#4 ACSR	7.38Y	123.1	0.00	1.93	2.35	2	17	5	96	0.00	0.0	2.745	0.040	15	4	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.36744	PL.38704	A	#4 ACSR	7.38Y	123.1	0.00	1.93	0.29	0	2	1	89	0.00	0.0	2.839	0.094	2	1	1	1
PL.38703	PL.37557	A	6 A (CWC)	7.38Y	123.0	0.03	1.96	13.21	9	94	28	96	0.02	0.0	2.756	0.052	6	2	1	11
PL.64574	PL.38703	A	#1/0 ACSR	7.38Y	123.0	0.01	1.96	11.21	5	79	24	96	0.00	0.0	2.784	0.028	0	0	0	9
PL.64575	PL.64574	A	#1/0 ACSR	7.38Y	123.0	0.00	1.96	11.21	5	79	24	96	0.00	0.0	2.784	0.000	0	0	0	9
PL.64576	PL.64575	A	#1/0 ACSR	7.38Y	123.0	0.03	1.99	11.21	5	79	24	96	0.01	0.0	2.881	0.097	0	0	1	9
PL.37952	PL.64576	A	6 A (CWC)	7.38Y	123.0	0.03	2.01	11.14	8	79	23	96	0.02	0.0	2.936	0.056	8	2	1	8
PL.37953	PL.37952	A	6 A (CWC)	7.38Y	122.9	0.04	2.06	10.02	7	71	21	96	0.02	0.0	3.025	0.088	0	0	0	7
PL.38130	PL.37953	A	6 A (CWC)	7.38Y	122.9	0.00	2.06	0.41	0	3	1	95	0.00	0.0	3.055	0.031	3	1	1	1
PL.37954	PL.37953	A	6 A (CWC)	7.38Y	122.9	0.01	2.07	9.61	7	68	20	96	0.00	0.0	3.061	0.036	42	12	3	6
PL.37955	PL.37954	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	3.72	3	26	8	96	0.00	0.0	3.089	0.028	0	0	0	3
PL.37957	PL.37955	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	2.40	2	17	5	96	0.00	0.0	3.103	0.014	0	0	0	2
PL.37958	PL.37957	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	2.40	2	17	5	96	0.00	0.0	3.132	0.029	0	0	0	2
PL.37858	PL.37958	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	2.40	2	17	5	96	0.00	0.0	3.170	0.038	9	3	1	2
PL.37859	PL.37858	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	1.17	1	8	2	97	0.00	0.0	3.244	0.074	8	2	1	1
PL.37956	PL.37955	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	1.33	1	9	3	95	0.00	0.0	3.124	0.035	9	3	1	1
PL.37639	PL.38703	A	6 A (CWC)	7.38Y	123.0	0.00	1.96	1.09	1	8	2	97	0.00	0.0	2.848	0.092	8	2	1	1
PL.38701	PL.61409	A	#4 ACSR	7.39Y	123.2	0.00	1.76	29.33	23	208	62	96	0.00	0.0	2.486	0.000	0	0	0	31
PD.6010	PL.38701	A	40QA	7.39Y	123.2	0.00	1.76	29.33	73	208	62	96	0.00	0.0	2.486	0.000	0	0	0	31
PL.38219	PD.6010	A	#4 ACSR	7.39Y	123.2	0.06	1.82	29.33	23	208	62	96	0.09	0.0	2.530	0.044	0	0	0	31
PL.38702	PL.38219	A	#4 ACSR	7.38Y	122.9	0.23	2.05	29.33	23	208	62	96	0.37	0.2	2.708	0.177	0	0	0	31
PL.37959	PL.38702	A	#4 ACSR	7.37Y	122.9	0.03	2.08	22.97	18	162	48	96	0.04	0.0	2.739	0.032	2	1	1	27
PL.37960	PL.37959	A	#4 ACSR	7.37Y	122.8	0.10	2.19	22.61	17	160	48	96	0.12	0.1	2.852	0.113	27	8	3	26
PL.37961	PL.37960	A	#4 ACSR	7.36Y	122.7	0.10	2.29	13.80	11	97	29	96	0.08	0.1	3.023	0.171	2	1	3	18
PL.38432	PL.37961	A	#4 ACSR	7.36Y	122.7	0.01	2.30	5.35	4	38	11	96	0.00	0.0	3.068	0.045	9	3	1	5
PL.38097	PL.38432	A	#4 ACSR	7.36Y	122.7	0.01	2.31	4.01	3	28	8	96	0.00	0.0	3.119	0.051	10	3	1	4
PL.38098	PL.38097	A	#4 ACSR	7.36Y	122.7	0.00	2.31	2.64	2	19	6	95	0.00	0.0	3.156	0.037	7	2	1	3
PL.61040	PL.38098	A	#1/0 ACSR	7.36Y	122.7	0.00	2.31	1.61	1	11	3	96	0.00	0.0	3.181	0.024	11	3	2	2
PL.37420	PL.37961	A	#4 ACSR	7.36Y	122.7	0.03	2.32	8.10	6	57	17	96	0.01	0.0	3.092	0.069	0	0	1	10
PL.38094	PL.37420	A	#4 ACSR	7.36Y	122.7	0.01	2.33	6.69	5	47	14	96	0.00	0.0	3.157	0.065	29	9	5	7
PL.38095	PL.38094	A	#4 ACSR	7.36Y	122.7	0.01	2.34	2.61	2	18	5	96	0.00	0.0	3.214	0.056	9	3	1	2
PL.38096	PL.38095	A	#4 ACSR	7.36Y	122.7	0.00	2.34	1.39	1	10	3	96	0.00	0.0	3.262	0.048	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37265	PL.37420	A	#2 ACSR	7.36Y	122.7	0.00	2.32	1.42	1	10	3	96	0.00	0.0	3.134	0.042	10	3	2	2
PL.36737	PL.37960	A	#4 ACSR	7.37Y	122.8	0.01	2.19	5.04	4	36	11	96	0.00	0.0	2.905	0.053	31	9	4	5
PL.36738	PL.36737	A	#4 ACSR	7.37Y	122.8	0.00	2.20	0.62	0	4	1	97	0.00	0.0	2.956	0.051	4	1	1	1
PL.37086	PL.38702	A	#4 ACSR	7.37Y	122.9	0.03	2.09	6.37	5	45	13	96	0.01	0.0	2.828	0.121	0	0	0	4
PL.37962	PL.37086	A	#4 ACSR	7.37Y	122.9	0.01	2.10	6.37	5	45	13	96	0.00	0.0	2.891	0.063	20	6	2	4
PL.37419	PL.37962	A	#4 ACSR	7.37Y	122.9	0.00	2.10	2.95	2	21	6	96	0.00	0.0	2.905	0.014	21	6	1	1
PL.37668	PL.37962	A	#4 ACSR	7.37Y	122.9	0.00	2.10	0.65	0	5	1	98	0.00	0.0	2.914	0.023	5	1	1	1
PL.64251	PL.64250	A	#4 ACSR	7.40Y	123.3	0.00	1.68	2.22	2	16	5	95	0.00	0.0	2.259	0.001	0	0	0	3
PD.5224	PL.64251	A	40QA	7.40Y	123.3	0.00	1.68	2.22	6	16	5	95	0.00	0.0	2.259	0.001	0	0	0	3
PL.37199	PD.5224	A	#4 ACSR	7.40Y	123.3	0.00	1.68	2.22	2	16	5	95	0.00	0.0	2.289	0.030	16	5	3	3
PL.64005	PL.64247	A	#2 ACSR	7.40Y	123.4	0.00	1.62	2.09	1	15	4	97	0.00	0.0	2.121	0.001	0	0	0	4
PD.9505	PL.64005	A	40QA	7.40Y	123.4	0.00	1.62	2.09	5	15	4	97	0.00	0.0	2.121	0.001	0	0	0	4
PL.64161	PD.9505	A	#2 ACSR	7.40Y	123.4	0.00	1.62	2.09	1	15	4	97	0.00	0.0	2.145	0.024	6	2	1	4
PL.64158	PL.64161	A	#2 ACSR	7.40Y	123.4	0.00	1.62	1.24	1	9	3	95	0.00	0.0	2.220	0.075	9	3	2	3
PL.64029	PL.64158	A	#2 ACSR	7.40Y	123.4	0.00	1.62	0.00	0	0	0	100	0.00	0.0	2.288	0.068	0	0	1	1
PL.37591	PL.38415	C	#2 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	1.972	0.002	0	0	0	0
PD.6080	PL.37591	C	40QA	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	1.972	0.002	0	0	0	0
PL.37592	PD.6080	C	#2 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	2.001	0.029	0	0	0	0
PL.38093	PL.38092	C	#2 ACSR	7.41Y	123.5	0.00	1.49	0.71	0	5	1	98	0.00	0.0	1.890	0.001	0	0	0	2
PD.5963	PL.38093	C	40QA	7.41Y	123.5	0.00	1.49	0.71	2	5	1	98	0.00	0.0	1.890	0.001	0	0	0	2
PL.52644	PD.5963	C	#2 ACSR	7.41Y	123.5	0.00	1.50	0.71	0	5	1	98	0.00	0.0	1.922	0.033	5	1	1	2
PL.52645	PL.52644	C	#2 ACSR	7.41Y	123.5	0.00	1.50	0.05	0	0	0	100	0.00	0.0	1.943	0.020	0	0	1	1
PL.38089	PL.38088	A	#2 ACSR	7.41Y	123.6	0.00	1.43	0.94	1	7	2	96	0.00	0.0	1.771	0.003	0	0	0	2
PD.5964	PL.38089	A	40QA	7.41Y	123.6	0.00	1.43	0.94	2	7	2	96	0.00	0.0	1.771	0.003	0	0	0	2
PL.38090	PD.5964	A	#2 ACSR	7.41Y	123.6	0.00	1.43	0.94	1	7	2	96	0.00	0.0	1.823	0.052	7	2	2	2
PL.38413	PL.38088	A	#4 ACSR	7.41Y	123.6	0.00	1.43	1.64	1	12	3	97	0.00	0.0	1.770	0.002	0	0	0	1
PD.6023	PL.38413	A	40QA	7.41Y	123.6	0.00	1.43	1.64	4	12	3	97	0.00	0.0	1.770	0.002	0	0	0	1
PL.38414	PD.6023	A	#4 ACSR	7.41Y	123.6	0.00	1.43	1.64	1	12	3	97	0.00	0.0	1.813	0.043	12	3	1	1
PL.38412	PL.38085	A	#2 ACSR	7.42Y	123.6	0.00	1.40	3.69	2	26	8	96	0.00	0.0	1.719	0.003	0	0	0	2
PD.6002	PL.38412	A	40QA	7.42Y	123.6	0.00	1.40	3.69	9	26	8	96	0.00	0.0	1.719	0.003	0	0	0	2
PL.38086	PD.6002	A	#2 ACSR	7.42Y	123.6	0.00	1.40	3.69	2	26	8	96	0.00	0.0	1.766	0.047	13	4	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38087	PL.38086	A	#2 ACSR	7.42Y	123.6	0.00	1.41	1.88	1	13	4	96	0.00	0.0	1.801	0.035	13	4	1	1
PL.37680	PL.37679	A	#2 ACSR	7.43Y	123.8	0.00	1.21	5.28	3	38	11	96	0.00	0.0	1.448	0.002	0	0	0	4
PD.5961	PL.37680	A	40QA	7.43Y	123.8	0.00	1.21	5.28	13	38	11	96	0.00	0.0	1.448	0.002	0	0	0	4
PL.37854	PD.5961	A	#2 ACSR	7.43Y	123.8	0.00	1.21	5.28	3	38	11	96	0.00	0.0	1.486	0.038	38	11	4	4
PL.37855	PL.37854	A	#2 ACSR	7.43Y	123.8	0.00	1.21	0.00	0	0	0	100	0.00	0.0	1.550	0.063	0	0	0	0
PL.37494	PL.37834	A	#1/0 ACSR	7.44Y	124.0	0.00	1.01	0.00	0	0	0	100	0.00	0.0	1.281	0.049	0	0	0	0
PL.38124	PL.37834	A	#4 ACSR	7.44Y	124.0	0.00	1.02	6.55	5	47	14	96	0.00	0.0	1.235	0.004	0	0	0	6
PD.6060	PL.38124	A	40QA	7.44Y	124.0	0.00	1.02	6.55	16	47	14	96	0.00	0.0	1.235	0.004	0	0	0	6
PL.38099	PD.6060	A	#4 ACSR	7.44Y	123.9	0.04	1.05	6.55	5	47	14	96	0.01	0.0	1.398	0.162	24	7	3	6
PL.38709	PL.38099	A	#4 ACSR	7.44Y	123.9	0.01	1.06	3.19	2	23	7	96	0.00	0.0	1.475	0.078	0	0	0	3
PL.38101	PL.38709	A	#4 ACSR	7.44Y	123.9	0.02	1.08	3.19	2	23	7	96	0.00	0.0	1.636	0.161	6	2	1	3
PL.38102	PL.38101	A	#4 ACSR	7.43Y	123.9	0.01	1.09	2.37	2	17	5	96	0.00	0.0	1.826	0.190	17	5	2	2
PL.37802	PL.38709	A	#2 ACSR	7.44Y	123.9	0.00	1.06	0.00	0	0	0	100	0.00	0.0	1.562	0.087	0	0	0	0
PL.37547	PL.37834	A	#1/0 ACSR	7.44Y	124.0	0.00	1.01	0.30	0	2	1	89	0.00	0.0	1.262	0.031	2	1	1	1
PL.37392	PL.37391	A	#2 ACSR	7.45Y	124.2	0.00	0.80	1.92	1	14	4	96	0.00	0.0	1.003	0.001	0	0	0	1
PD.6079	PL.37392	A	25QA	7.45Y	124.2	0.00	0.80	1.92	8	14	4	96	0.00	0.0	1.003	0.001	0	0	0	1
PL.38120	PD.6079	A	#2 ACSR	7.45Y	124.2	0.00	0.80	1.92	1	14	4	96	0.00	0.0	1.017	0.014	14	4	1	1
PL.37039	PL.37038	A	#4 ACSR	7.46Y	124.3	0.00	0.75	0.40	0	3	1	95	0.00	0.0	0.964	0.016	3	1	1	1
PL.37040	PL.37039	A	#4 ACSR	7.46Y	124.3	0.00	0.75	0.00	0	0	0	100	0.00	0.0	1.041	0.076	0	0	0	0
PL.59595	PL.59573	ABC	#1/0 ACSR	7.46Y	124.3	0.01	0.71	21.18	9	454	136	96	0.03	0.0	0.918	0.024	0	0	0	71
PD.8797	PL.59595	ABC	50L	7.46Y	124.3	0.00	0.71	21.18	42	454	136	96	0.00	0.0	0.918	0.024	0	0	0	71
PL.59596	PD.8797	ABC	#1/0 ACSR	7.46Y	124.3	0.01	0.71	21.18	9	454	136	96	0.02	0.0	0.935	0.018	5	1	2	71
PL.59575	PL.59596	ABC	#1/0 ACSR	7.46Y	124.3	0.01	0.72	20.95	9	449	135	96	0.02	0.0	0.954	0.019	7	2	2	69
PL.37042	PL.59575	ABC	#1/0 ACSR	7.46Y	124.3	0.02	0.74	20.61	9	442	132	96	0.06	0.0	1.005	0.051	21	6	3	67
PL.37041	PL.37042	ABC	#1/0 ACSR	7.45Y	124.2	0.01	0.75	19.63	9	421	126	96	0.04	0.0	1.047	0.042	9	3	1	64
PL.37868	PL.37041	ABC	#1/0 ACSR	7.45Y	124.2	0.02	0.78	19.21	8	412	123	96	0.07	0.0	1.116	0.069	0	0	0	62
PL.37046	PL.37868	C	#2 ACSR	7.45Y	124.2	0.00	0.78	0.92	1	7	2	96	0.00	0.0	1.116	0.000	0	0	0	2
PD.5985	PL.37046	C	40QA	7.45Y	124.2	0.00	0.78	0.92	2	7	2	96	0.00	0.0	1.116	0.000	0	0	0	2
PL.37047	PD.5985	C	#2 ACSR	7.45Y	124.2	0.00	0.78	0.92	1	7	2	96	0.00	0.0	1.132	0.016	7	2	2	2
PL.37751	PL.37868	ABC	#1/0 ACSR	7.45Y	124.2	0.02	0.79	18.90	8	405	121	96	0.05	0.0	1.165	0.050	0	0	0	60
PL.37048	PL.37751	C	#2 ACSR	7.45Y	124.2	0.00	0.79	0.00	0	0	0	100	0.00	0.0	1.166	0.001	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5965	PL.37048	C	40QA	7.45Y	124.2	0.00	0.79	0.00	0	0	0	100	0.00	0.0	1.166	0.001	0	0	0	2
PL.64236	PD.5965	C	#2 ACSR	7.45Y	124.2	0.00	0.79	0.00	0	0	0	100	0.00	0.0	1.186	0.020	0	0	0	2
PL.64010	PL.64236	C	#2 ACSR	7.45Y	124.2	0.00	0.79	0.00	0	0	0	100	0.00	0.0	1.205	0.019	0	0	2	2
PL.37049	PL.37751	ABC	#1/0 ACSR	7.45Y	124.2	0.04	0.84	18.90	8	405	121	96	0.11	0.0	1.285	0.120	0	0	0	58
PL.37068	PL.37049	ABC	#1/0 ACSR	7.43Y	123.9	0.27	1.11	18.90	8	405	121	96	0.75	0.2	2.089	0.803	11	3	1	58
PL.37069	PL.37068	ABC	#1/0 ACSR	7.43Y	123.8	0.06	1.17	18.38	8	393	117	96	0.16	0.0	2.274	0.185	8	3	1	57
PL.37070	PL.37069	ABC	#1/0 ACSR	7.43Y	123.8	0.01	1.18	17.99	8	384	114	96	0.03	0.0	2.314	0.041	0	0	0	56
PL.37089	PL.37070	A	#2 ACSR	7.43Y	123.8	0.00	1.18	0.00	0	0	0	100	0.00	0.0	2.314	0.000	0	0	0	0
PL.37869	PL.37070	ABC	#1/0 ACSR	7.43Y	123.8	0.02	1.21	17.99	8	384	114	96	0.06	0.0	2.384	0.070	11	3	2	56
PL.37090	PL.37869	ABC	#1/0 ACSR	7.43Y	123.8	0.02	1.22	17.49	8	373	111	96	0.05	0.0	2.441	0.057	7	2	1	54
PL.37091	PL.37090	ABC	#1/0 ACSR	7.43Y	123.8	0.01	1.24	17.16	7	366	109	96	0.03	0.0	2.480	0.038	0	0	0	53
PL.37092	PL.37091	ABC	#1/0 ACSR	7.43Y	123.8	0.01	1.25	16.05	7	343	102	96	0.03	0.0	2.522	0.043	0	0	0	51
PL.37652	PL.37092	C	#2 ACSR	7.43Y	123.8	0.00	1.25	1.29	1	9	3	95	0.00	0.0	2.523	0.001	0	0	0	2
PD.6041	PL.37652	C	40QA	7.43Y	123.8	0.00	1.25	1.29	3	9	3	95	0.00	0.0	2.523	0.001	0	0	0	2
PL.38650	PD.6041	C	#2 ACSR	7.43Y	123.8	0.00	1.25	1.29	1	9	3	95	0.00	0.0	2.551	0.028	9	3	2	2
PL.38651	PL.38650	C	#2 ACSR	7.43Y	123.8	0.00	1.25	0.00	0	0	0	100	0.00	0.0	2.578	0.027	0	0	0	0
PL.37651	PL.37092	A	#2 ACSR	7.43Y	123.8	0.00	1.25	0.51	0	4	1	97	0.00	0.0	2.523	0.001	0	0	0	1
PD.5990	PL.37651	A	40QA	7.43Y	123.8	0.00	1.25	0.51	1	4	1	97	0.00	0.0	2.523	0.001	0	0	0	1
PL.37460	PD.5990	A	#2 ACSR	7.43Y	123.8	0.00	1.25	0.51	0	4	1	97	0.00	0.0	2.564	0.041	0	0	0	1
PL.37366	PL.37460	A	#2 ACSR	7.43Y	123.8	0.00	1.25	0.51	0	4	1	97	0.00	0.0	2.605	0.041	0	0	0	1
PL.37611	PL.37366	A	#2 ACSR	7.43Y	123.8	0.00	1.25	0.51	0	4	1	97	0.00	0.0	2.653	0.048	4	1	1	1
PL.38234	PL.37366	A	#2 ACSR	7.43Y	123.8	0.00	1.25	0.00	0	0	0	100	0.00	0.0	2.696	0.090	0	0	0	0
PL.38235	PL.37092	ABC	#1/0 ACSR	7.42Y	123.7	0.05	1.30	15.45	7	330	98	96	0.11	0.0	2.690	0.168	0	0	1	48
PL.36760	PL.38235	ABC	#1/0 ACSR	7.42Y	123.7	0.01	1.30	15.44	7	330	98	96	0.02	0.0	2.719	0.029	8	2	2	47
PL.36761	PL.36760	ABC	#1/0 ACSR	7.42Y	123.7	0.02	1.32	15.05	7	321	96	96	0.04	0.0	2.778	0.059	0	0	0	45
PL.36762	PL.36761	C	#2 ACSR	7.42Y	123.7	0.00	1.32	1.15	1	8	2	97	0.00	0.0	2.778	0.000	0	0	0	1
PD.5986	PL.36762	C	40QA	7.42Y	123.7	0.00	1.32	1.15	3	8	2	97	0.00	0.0	2.778	0.000	0	0	0	1
PL.36763	PD.5986	C	#2 ACSR	7.42Y	123.7	0.00	1.32	1.15	1	8	2	97	0.00	0.0	2.794	0.016	0	0	0	1
PL.38402	PL.36763	C	#2 ACSR	7.42Y	123.7	0.00	1.32	1.15	1	8	2	97	0.00	0.0	2.941	0.148	8	2	1	1
PL.36764	PL.36761	ABC	#1/0 ACSR	7.42Y	123.7	0.01	1.33	14.67	6	313	93	96	0.03	0.0	2.831	0.054	0	0	0	44
PL.37737	PL.36764	C	#2 ACSR	7.42Y	123.7	0.00	1.33	2.76	2	20	6	96	0.00	0.0	2.856	0.025	20	6	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38084	PL.36764	ABC	#1/0 ACSR	7.42Y	123.7	0.01	1.34	12.73	6	272	81	96	0.02	0.0	2.880	0.048	0	0	0	36
PL.37601	PL.38084	ABC	#1/0 ACSR	7.42Y	123.6	0.01	1.36	12.73	6	272	81	96	0.03	0.0	2.943	0.063	11	3	2	36
PL.37632	PL.37601	B	#4 ACSR	7.42Y	123.6	0.00	1.36	23.29	18	166	49	96	0.00	0.0	2.943	0.000	0	0	0	23
PD.5987	PL.37632	B	40QA	7.42Y	123.6	0.00	1.36	23.29	58	166	49	96	0.00	0.0	2.943	0.000	0	0	0	23
PL.37103	PD.5987	B	#4 ACSR	7.42Y	123.6	0.03	1.39	23.29	18	166	49	96	0.04	0.0	2.976	0.033	1	0	1	23
PL.38579	PL.37103	B	#4 ACSR	7.42Y	123.6	0.00	1.40	1.13	1	8	2	97	0.00	0.0	3.043	0.067	8	2	2	2
PL.38580	PL.38579	B	#4 ACSR	7.42Y	123.6	0.00	1.40	0.00	0	0	0	100	0.00	0.0	3.069	0.026	0	0	0	0
PL.37085	PL.37103	B	#4 ACSR	7.41Y	123.6	0.04	1.44	21.97	17	156	46	96	0.05	0.0	3.020	0.045	7	2	1	20
PL.38581	PL.37085	B	#4 ACSR	7.41Y	123.5	0.08	1.52	20.93	16	149	44	96	0.09	0.1	3.105	0.085	0	0	0	19
PL.37685	PL.38581	B	#4 ACSR	7.41Y	123.5	0.00	1.52	1.37	1	10	3	96	0.00	0.0	3.163	0.058	10	3	1	1
PL.37230	PL.38581	B	#4 ACSR	7.40Y	123.4	0.08	1.59	19.56	15	139	41	96	0.08	0.1	3.197	0.091	16	5	2	18
PL.37545	PL.37230	B	#4 ACSR	7.40Y	123.4	0.00	1.59	0.30	0	2	1	89	0.00	0.0	3.256	0.059	2	1	1	1
PL.38582	PL.37230	B	#4 ACSR	7.40Y	123.4	0.06	1.65	16.98	13	121	36	96	0.05	0.0	3.270	0.073	0	0	0	15
PL.37231	PL.38582	B	#4 ACSR	7.40Y	123.3	0.02	1.67	10.05	8	71	21	96	0.01	0.0	3.337	0.067	47	14	5	9
PL.64237	PL.37231	B	#4 ACSR	7.40Y	123.3	0.02	1.68	3.46	3	25	7	96	0.00	0.0	3.439	0.102	0	0	0	4
PL.64034	PL.64237	B	#4 ACSR	7.40Y	123.3	0.01	1.69	3.46	3	25	7	96	0.00	0.0	3.502	0.062	17	5	3	4
PL.64035	PL.64034	B	#4 ACSR	7.40Y	123.3	0.01	1.70	1.10	1	8	2	97	0.00	0.0	3.843	0.341	8	2	1	1
PL.37232	PL.38582	B	#4 ACSR	7.40Y	123.3	0.02	1.67	5.47	4	39	12	96	0.01	0.0	3.347	0.077	0	0	0	5
PL.63949	PL.37232	B	#4 ACSR	7.40Y	123.3	0.01	1.67	5.47	4	39	12	96	0.00	0.0	3.390	0.043	21	6	2	5
PL.63951	PL.63949	B	#4 ACSR	7.40Y	123.3	0.01	1.68	2.58	2	18	5	96	0.00	0.0	3.457	0.068	0	0	0	3
PL.63953	PL.63951	B	#1/0 ACSR	7.40Y	123.3	0.00	1.68	1.30	1	9	3	95	0.00	0.0	3.545	0.088	0	0	0	1
PL.63954	PL.63953	B	#1/0 ACSR	7.40Y	123.3	0.00	1.68	1.30	1	9	3	95	0.00	0.0	3.574	0.029	9	3	1	1
PL.63952	PL.63951	B	#4 ACSR	7.40Y	123.3	0.00	1.68	1.28	1	9	3	95	0.00	0.0	3.498	0.041	0	0	0	2
PL.63950	PL.63952	B	#4 ACSR	7.40Y	123.3	0.00	1.68	0.00	0	0	0	100	0.00	0.0	3.529	0.031	0	0	0	0
PL.63947	PL.63952	B	#2 ACSR	7.40Y	123.3	0.00	1.68	0.39	0	3	1	95	0.00	0.0	3.636	0.138	3	1	1	1
PL.63948	PL.63952	B	#4 ACSR	7.40Y	123.3	0.00	1.69	0.89	1	6	2	95	0.00	0.0	3.593	0.095	6	2	1	1
PL.37686	PL.38582	B	#4 ACSR	7.40Y	123.4	0.00	1.65	1.47	1	10	3	96	0.00	0.0	3.359	0.089	10	3	1	1
PL.37543	PL.37085	B	#4 ACSR	7.41Y	123.6	0.00	1.44	0.00	0	0	0	100	0.00	0.0	3.058	0.037	0	0	0	0
PL.37299	PL.37085	B	#4 ACSR	7.41Y	123.6	0.00	1.44	0.00	0	0	0	100	0.00	0.0	3.048	0.027	0	0	0	0
PL.37104	PL.37601	C	#4 ACSR	7.42Y	123.6	0.00	1.36	13.32	10	95	28	96	0.00	0.0	2.943	0.000	0	0	0	11
PD.6024	PL.37104	C	40QA	7.42Y	123.6	0.00	1.36	13.32	33	95	28	96	0.00	0.0	2.943	0.000	0	0	0	11

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37602	PD.6024	C	#4 ACSR	7.42Y	123.6	0.01	1.37	13.32	10	95	28	96	0.01	0.0	2.960	0.017	0	0	0	11
PL.38572	PL.37602	C	#4 ACSR	7.42Y	123.6	0.04	1.41	13.32	10	95	28	96	0.03	0.0	3.030	0.069	12	4	1	11
PL.38573	PL.38572	C	#4 ACSR	7.41Y	123.6	0.03	1.44	11.67	9	83	25	96	0.02	0.0	3.092	0.062	9	3	2	10
PL.38574	PL.38573	C	#4 ACSR	7.41Y	123.5	0.02	1.46	9.25	7	66	20	96	0.01	0.0	3.151	0.059	26	8	1	7
PL.38575	PL.38574	C	#4 ACSR	7.41Y	123.5	0.02	1.48	5.53	4	39	12	96	0.00	0.0	3.255	0.104	22	7	3	6
PL.37376	PL.38575	C	#4 ACSR	7.41Y	123.5	0.00	1.48	1.44	1	10	3	96	0.00	0.0	3.287	0.033	10	3	1	1
PL.38576	PL.38575	C	#4 ACSR	7.41Y	123.5	0.00	1.48	0.98	1	7	2	96	0.00	0.0	3.337	0.082	7	2	1	2
PL.38577	PL.38576	C	#4 ACSR	7.41Y	123.5	0.00	1.48	0.00	0	0	0	100	0.00	0.0	3.410	0.074	0	0	0	1
PL.37813	PL.38577	C	#4 ACSR	7.41Y	123.5	0.00	1.48	0.00	0	0	0	100	0.00	0.0	3.439	0.029	0	0	0	0
PL.38578	PL.38577	C	#4 ACSR	7.41Y	123.5	0.00	1.48	0.00	0	0	0	100	0.00	0.0	3.462	0.051	0	0	1	1
PL.37336	PL.38578	C	#4 ACSR	7.41Y	123.5	0.00	1.48	0.00	0	0	0	100	0.00	0.0	3.475	0.014	0	0	0	0
PL.37386	PL.38573	C	#4 ACSR	7.41Y	123.6	0.00	1.44	1.20	1	9	3	95	0.00	0.0	3.135	0.043	8	3	1	1
PL.38082	PL.36764	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.95	1	14	4	96	0.00	0.0	2.832	0.001	0	0	0	2
PD.6042	PL.38082	C	40QA	7.42Y	123.7	0.00	1.33	1.95	5	14	4	96	0.00	0.0	2.832	0.001	0	0	0	2
PL.38083	PD.6042	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.95	1	14	4	96	0.00	0.0	2.858	0.026	14	4	2	2
PL.36765	PL.36764	A	#2 ACSR	7.42Y	123.7	0.00	1.33	1.10	1	8	2	97	0.00	0.0	2.832	0.001	0	0	0	4
PD.6025	PL.36765	A	40QA	7.42Y	123.7	0.00	1.33	1.10	3	8	2	97	0.00	0.0	2.832	0.001	0	0	0	4
PL.36766	PD.6025	A	#2 ACSR	7.42Y	123.7	0.00	1.33	1.10	1	8	2	97	0.00	0.0	2.887	0.055	8	2	4	4
PL.37093	PL.37091	C	#2 ACSR	7.43Y	123.8	0.00	1.24	3.35	2	24	7	96	0.00	0.0	2.480	0.001	0	0	0	2
PD.6083	PL.37093	C	40QA	7.43Y	123.8	0.00	1.24	3.35	8	24	7	96	0.00	0.0	2.480	0.001	0	0	0	2
PL.37459	PD.6083	C	#2 ACSR	7.43Y	123.8	0.00	1.24	3.35	2	24	7	96	0.00	0.0	2.501	0.020	24	7	2	2
PL.37043	PL.37041	AB	#4 ACSR	7.45Y	124.2	0.00	0.75	0.00	0	0	0	100	0.00	0.0	1.085	0.038	0	0	0	1
PL.37044	PL.37043	AB	#4 ACSR	7.45Y	124.2	0.00	0.75	0.00	0	0	0	100	0.00	0.0	1.129	0.044	0	0	1	1
PL.37045	PL.37044	AB	#4 ACSR	7.45Y	124.2	0.00	0.75	0.00	0	0	0	100	0.00	0.0	1.164	0.034	0	0	0	0
PL.59594	PL.59576	C	#2 ACSR	7.47Y	124.4	0.00	0.57	2.44	1	17	5	96	0.00	0.0	0.799	0.000	0	0	0	3
PD.5984	PL.59594	C	15T	7.47Y	124.4	0.00	0.57	2.44	0	17	5	96	0.00	0.0	0.799	0.000	0	0	0	3
PL.37364	PD.5984	C	#2 ACSR	7.47Y	124.4	0.00	0.57	2.44	1	17	5	96	0.00	0.0	0.824	0.025	7	2	1	3
PL.37365	PL.37364	C	#2 ACSR	7.47Y	124.4	0.00	0.57	1.43	1	10	3	96	0.00	0.0	0.867	0.043	10	3	2	2
PL.57988	PL.62133	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.68	0	5	1	98	0.00	0.0	0.699	0.002	0	0	0	1
PD.8400	PL.57988	C	40QA	7.47Y	124.6	0.00	0.42	0.68	2	5	1	98	0.00	0.0	0.699	0.002	0	0	0	1
PL.57989	PD.8400	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.68	0	5	1	98	0.00	0.0	0.701	0.002	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.57854	PL.57989	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.00	0	0	0	100	0.00	0.0	0.769	0.069	0	0	0	0
PL.57853	PL.57989	C	#2 ACSR	7.47Y	124.6	0.00	0.42	0.68	0	5	1	98	0.00	0.0	0.745	0.045	5	1	1	1
PL.62131	PL.62132	A	#2 ACSR	7.48Y	124.6	0.00	0.39	0.69	0	5	1	98	0.00	0.0	0.636	0.001	0	0	0	1
PD.9314	PL.62131	A	20QA	7.48Y	124.6	0.00	0.39	0.69	3	5	1	98	0.00	0.0	0.636	0.001	0	0	0	1
PL.62130	PD.9314	A	#2 ACSR	7.48Y	124.6	0.00	0.39	0.69	0	5	1	98	0.00	0.0	0.689	0.053	5	1	1	1
PL.62142	Conway	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	179.53	35	3828	1289	95	0.17	0.0	0.006	0.006	0	0	0	617
PL.62143	PL.62142	ABC	336 MCM AC	7.50Y	125.0	0.01	0.02	179.53	35	3828	1288	95	0.25	0.0	0.015	0.009	0	0	0	617
----- Feeder No. 1 (CopperCreek F1) Beginning with Device PD.9305 -----																				
PD.9305	PL.62143	ABC	480VWE	7.50Y	125.0	0.00	0.02	179.53	0	3828	1288	95	0.00	0.0	0.015	0.009	0	0	0	617
PL.62123	PD.9305	ABC	336 MCM AC	7.50Y	125.0	0.02	0.04	179.53	35	3828	1288	95	0.31	0.0	0.027	0.012	0	0	0	617
PL.62124	PL.62123	ABC	336 MCM AC	7.50Y	124.9	0.04	0.08	179.53	35	3828	1287	95	0.82	0.0	0.057	0.030	0	0	0	617
PL.62134	PL.62124	ABC	336 MCM AC	7.49Y	124.8	0.09	0.17	179.53	35	3827	1285	95	1.65	0.0	0.118	0.061	0	0	0	617
PL.62625	PL.62134	ABC	336 MCM AC	7.49Y	124.8	0.05	0.22	179.53	35	3825	1281	95	0.93	0.0	0.152	0.034	0	0	0	617
PL.62626	PL.62625	ABC	336 MCM AC	7.49Y	124.8	0.01	0.22	179.53	35	3824	1279	95	0.10	0.0	0.156	0.004	0	0	0	617
PL.62603	PL.62626	ABC	336 MCM AC	7.48Y	124.7	0.08	0.30	159.23	31	3387	1146	95	1.38	0.0	0.221	0.065	0	0	0	555
PL.62607	PL.62603	ABC	336 MCM AC	7.46Y	124.3	0.37	0.68	159.23	31	3386	1143	95	6.30	0.2	0.516	0.295	0	0	0	555
PL.62608	PL.62607	C	#2 ACSR	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	0.517	0.001	0	0	0	0
PD.9425	PL.62608	C	50T	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	0.517	0.001	0	0	0	0
PL.62604	PD.9425	C	#2 ACSR	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	0.536	0.018	0	0	0	0
PL.62629	PL.62604	C	#2 ACSR	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	0.538	0.002	0	0	0	0
PL.62630	PL.62629	C	#2 ACSR	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	0.572	0.035	0	0	0	0
PL.62627	PL.62607	ABC	336 MCM AC	7.46Y	124.3	0.00	0.68	159.23	31	3380	1128	95	0.08	0.0	0.520	0.004	0	0	0	555
PL.62628	PL.62627	ABC	336 MCM AC	7.46Y	124.3	0.05	0.73	159.23	31	3380	1128	95	0.82	0.0	0.558	0.038	0	0	0	555
PL.37353	PL.62628	ABC	336 MCM AC	7.45Y	124.2	0.04	0.76	158.64	31	3366	1123	95	0.62	0.0	0.587	0.029	4	1	1	554
PL.62609	PL.37353	A	#2 ACSR	7.45Y	124.2	0.00	0.76	1.10	1	8	2	97	0.00	0.0	0.589	0.002	0	0	0	1
PD.9427	PL.62609	A	50T	7.45Y	124.2	0.00	0.76	1.10	0	8	2	97	0.00	0.0	0.589	0.002	0	0	0	1
PL.62610	PD.9427	A	#2 ACSR	7.45Y	124.2	0.00	0.77	1.10	1	8	2	97	0.00	0.0	0.641	0.052	8	2	1	1
PL.62631	PL.37353	ABC	336 MCM AC	7.45Y	124.2	0.00	0.76	158.07	30	3354	1118	95	0.00	0.0	0.587	0.000	0	0	0	552
PL.62632	PL.62631	ABC	336 MCM AC	7.45Y	124.2	0.07	0.83	158.07	30	3354	1118	95	1.10	0.0	0.640	0.052	14	4	2	552

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62633	PL.62632	ABC	336 MCM AC	7.44Y	124.1	0.09	0.92	157.44	30	3339	1111	95	1.50	0.0	0.712	0.072	0	0	0	550
PL.62634	PL.62633	ABC	336 MCM AC	7.44Y	124.1	0.00	0.92	157.44	30	3337	1108	95	0.00	0.0	0.712	0.000	12	4	1	550
PL.62612	PL.62634	ABC	336 MCM AC	7.44Y	124.0	0.11	1.03	156.87	30	3325	1104	95	1.77	0.1	0.797	0.086	0	0	0	549
PL.62786	PL.62612	A	6 A (CWC)	7.44Y	124.0	0.00	1.03	3.20	2	23	7	96	0.00	0.0	0.799	0.002	0	0	0	3
PD.9428	PL.62786	A	50T	7.44Y	124.0	0.00	1.03	3.20	0	23	7	96	0.00	0.0	0.799	0.002	0	0	0	3
PL.62635	PD.9428	A	6 A (CWC)	7.44Y	124.0	0.00	1.03	3.20	2	23	7	96	0.00	0.0	0.801	0.002	0	0	0	3
PL.62636	PL.62635	A	6 A (CWC)	7.44Y	124.0	0.01	1.03	3.20	2	23	7	96	0.00	0.0	0.862	0.061	0	0	0	3
PL.37845	PL.62636	A	#4 ACSR	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	0.919	0.056	0	0	0	0
PL.37354	PL.62636	A	6 A (CWC)	7.44Y	124.0	0.00	1.04	3.20	2	23	7	96	0.00	0.0	0.912	0.050	23	7	3	3
PL.37355	PL.37354	A	6 A (CWC)	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	0.952	0.040	0	0	0	0
PL.62637	PL.62612	ABC	336 MCM AC	7.43Y	123.9	0.10	1.13	152.86	29	3238	1074	95	1.64	0.1	0.880	0.083	0	0	0	535
PL.62638	PL.62637	ABC	336 MCM AC	7.43Y	123.9	0.00	1.13	152.86	29	3236	1070	95	0.00	0.0	0.880	0.000	0	0	0	535
PL.62615	PL.62638	ABC	336 MCM AC	7.43Y	123.8	0.07	1.19	152.86	29	3236	1070	95	1.12	0.0	0.937	0.057	0	0	0	535
PL.62616	PL.62615	B	#1/0 ACSR	7.43Y	123.8	0.00	1.19	0.00	0	0	0	100	0.00	0.0	0.938	0.001	0	0	0	0
PD.9430	PL.62616	B	50T	7.43Y	123.8	0.00	1.19	0.00	0	0	0	100	0.00	0.0	0.938	0.001	0	0	0	0
PL.62639	PD.9430	B	#1/0 ACSR	7.43Y	123.8	0.00	1.19	0.00	0	0	0	100	0.00	0.0	0.942	0.003	0	0	0	0
PL.62640	PL.62639	B	#1/0 ACSR	7.43Y	123.8	0.00	1.19	0.00	0	0	0	100	0.00	0.0	0.945	0.004	0	0	0	0
PL.62641	PL.62615	ABC	336 MCM AC	7.43Y	123.8	0.02	1.22	152.86	29	3235	1068	95	0.35	0.0	0.955	0.018	0	0	0	535
PL.62642	PL.62641	ABC	336 MCM AC	7.43Y	123.8	0.00	1.22	152.86	29	3235	1067	95	0.00	0.0	0.955	0.000	34	10	4	535
PL.62614	PL.62642	B	#2 ACSR	7.43Y	123.8	0.00	1.22	0.00	0	0	0	100	0.00	0.0	0.986	0.031	0	0	0	0
PL.62643	PL.62642	ABC	336 MCM AC	7.43Y	123.8	0.00	1.22	151.27	29	3200	1057	95	0.07	0.0	0.959	0.004	0	0	0	531
PL.62644	PL.62643	ABC	336 MCM AC	7.42Y	123.7	0.12	1.34	151.27	29	3200	1057	95	1.89	0.1	1.057	0.098	0	0	0	531
PL.62537	PL.62644	B	#2 ACSR	7.42Y	123.7	0.00	1.34	0.00	0	0	0	100	0.00	0.0	1.058	0.001	0	0	0	0
PD.9381	PL.62537	B	50T	7.42Y	123.7	0.00	1.34	0.00	0	0	0	100	0.00	0.0	1.058	0.001	0	0	0	0
PL.62645	PD.9381	B	#2 ACSR	7.42Y	123.7	0.00	1.34	0.00	0	0	0	100	0.00	0.0	1.061	0.002	0	0	0	0
PL.62646	PL.62645	B	#2 ACSR	7.42Y	123.7	0.00	1.34	0.00	0	0	0	100	0.00	0.0	1.112	0.051	0	0	0	0
PL.62617	PL.62644	ABC	336 MCM AC	7.42Y	123.6	0.04	1.37	151.27	29	3198	1052	95	0.59	0.0	1.088	0.031	0	0	0	531
PL.62538	PL.62617	A	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.089	0.001	0	0	0	0
PD.9382	PL.62538	A	50T	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.089	0.001	0	0	0	0
PL.62649	PD.9382	A	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.103	0.014	0	0	0	0
PL.62650	PL.62649	A	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.108	0.005	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62647	PL.62617	ABC	336 MCM AC	7.42Y	123.6	0.00	1.37	151.27	29	3198	1051	95	0.03	0.0	1.089	0.001	0	0	0	531
PL.62648	PL.62647	ABC	336 MCM AC	7.41Y	123.6	0.07	1.44	151.27	29	3198	1051	95	1.13	0.0	1.148	0.059	6	2	1	531
PL.62651	PL.62648	ABC	336 MCM AC	7.41Y	123.6	0.00	1.45	150.69	29	3185	1045	95	0.07	0.0	1.151	0.004	0	0	0	529
PL.62652	PL.62651	ABC	336 MCM AC	7.40Y	123.4	0.15	1.60	150.69	29	3184	1044	95	2.43	0.1	1.278	0.127	0	0	0	529
PL.62653	PL.62652	ABC	336 MCM AC	7.40Y	123.4	0.01	1.61	149.69	29	3161	1032	95	0.13	0.0	1.285	0.007	0	0	0	527
PL.62655	PL.62653	ABC	336 MCM AC	7.40Y	123.3	0.06	1.67	149.69	29	3160	1032	95	1.03	0.0	1.340	0.055	0	0	0	527
PL.62656	PL.62655	ABC	336 MCM AC	7.40Y	123.3	0.00	1.67	149.69	29	3159	1030	95	0.01	0.0	1.340	0.000	0	0	0	527
PL.62663	PL.62656	C	#1/0 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	1.342	0.001	0	0	0	0
PD.9384	PL.62663	C	50T	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	1.342	0.001	0	0	0	0
PL.62664	PD.9384	C	#1/0 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	1.368	0.027	0	0	0	0
PL.62657	PL.62656	ABC	336 MCM AC	7.39Y	123.2	0.09	1.76	149.69	29	3159	1030	95	1.48	0.0	1.419	0.079	17	5	2	527
PL.62665	PL.62657	ABC	336 MCM AC	7.39Y	123.2	0.05	1.81	148.91	29	3141	1021	95	0.73	0.0	1.459	0.039	9	3	1	525
PL.63035	PL.62665	ABC	336 MCM AC	7.39Y	123.2	0.03	1.84	148.47	29	3131	1017	95	0.44	0.0	1.483	0.024	0	0	0	524
PL.63037	PL.63035	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	1.26	1	9	3	95	0.00	0.0	1.531	0.048	0	0	0	1
PL.63038	PL.63037	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	1.26	1	9	3	95	0.00	0.0	1.587	0.057	9	3	1	1
PL.63036	PL.63035	ABC	336 MCM AC	7.39Y	123.1	0.02	1.86	148.05	29	3122	1013	95	0.34	0.0	1.501	0.018	0	0	0	523
PL.62666	PL.63036	ABC	336 MCM AC	7.39Y	123.1	0.05	1.91	148.05	29	3122	1012	95	0.80	0.0	1.544	0.044	0	0	0	523
PL.62670	PL.62666	A	#1/0 ACSR	7.39Y	123.1	0.00	1.91	2.90	1	21	6	96	0.00	0.0	1.548	0.004	0	0	0	4
PD.9385	PL.62670	A	50T	7.39Y	123.1	0.00	1.91	2.90	0	21	6	96	0.00	0.0	1.548	0.004	0	0	0	4
PL.62671	PD.9385	A	#1/0 ACSR	7.39Y	123.1	0.00	1.91	2.90	1	21	6	96	0.00	0.0	1.563	0.015	0	0	0	4
PL.62658	PL.62671	A	6 A (CWC)	7.39Y	123.1	0.00	1.91	2.90	2	21	6	96	0.00	0.0	1.563	0.000	14	4	3	4
PL.38691	PL.62658	A	6 A (CWC)	7.39Y	123.1	0.00	1.91	0.94	1	7	2	96	0.00	0.0	1.586	0.023	0	0	0	1
PL.38692	PL.38691	A	6 A (CWC)	7.39Y	123.1	0.00	1.91	0.94	1	7	2	96	0.00	0.0	1.666	0.080	7	2	1	1
PL.62667	PL.62666	ABC	336 MCM AC	7.38Y	123.1	0.03	1.94	147.09	28	3100	1004	95	0.50	0.0	1.572	0.028	8	2	1	519
PL.62668	PL.62667	ABC	336 MCM AC	7.38Y	123.0	0.03	1.97	146.69	28	3091	1001	95	0.47	0.0	1.598	0.026	12	3	1	518
PL.62672	PL.62668	A	#1/0 ACSR	7.38Y	123.0	0.00	1.97	10.86	5	77	23	96	0.00	0.0	1.602	0.003	0	0	0	11
PD.9386	PL.62672	A	50T	7.38Y	123.0	0.00	1.97	10.86	0	77	23	96	0.00	0.0	1.602	0.003	0	0	0	11
PL.62673	PD.9386	A	#1/0 ACSR	7.38Y	123.0	0.00	1.97	10.86	5	77	23	96	0.00	0.0	1.615	0.013	11	3	1	11
PL.64303	PL.62673	A	6 A (CWC)	7.38Y	123.0	0.01	1.99	9.31	7	66	20	96	0.01	0.0	1.649	0.034	0	0	0	10
PL.64302	PL.64303	A	6 A (CWC)	7.38Y	123.0	0.00	1.99	9.31	7	66	20	96	0.00	0.0	1.649	0.000	42	12	4	10
PL.62662	PL.64302	A	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.43	0	3	1	95	0.00	0.0	1.661	0.012	3	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38693	PL.64302	A	6 A (CWC)	7.38Y	123.0	0.00	1.99	3.01	2	21	6	96	0.00	0.0	1.679	0.031	7	2	2	4
PL.38694	PL.38693	A	6 A (CWC)	7.38Y	123.0	0.00	1.99	1.98	1	14	4	96	0.00	0.0	1.714	0.035	14	4	2	2
PL.62669	PL.62668	ABC	336 MCM AC	7.38Y	123.0	0.03	2.01	142.53	27	3003	973	95	0.54	0.0	1.630	0.031	0	0	0	506
PL.62562	PL.62669	ABC	336 MCM AC	7.38Y	123.0	0.03	2.04	142.53	27	3002	972	95	0.51	0.0	1.660	0.030	0	0	0	506
PL.62565	PL.62562	A	#1/0 ACSR	7.38Y	123.0	0.00	2.04	0.26	0	2	1	89	0.00	0.0	1.663	0.004	0	0	0	2
PD.9387	PL.62565	A	50T	7.38Y	123.0	0.00	2.04	0.26	0	2	1	89	0.00	0.0	1.663	0.004	0	0	0	2
PL.62566	PD.9387	A	#1/0 ACSR	7.38Y	123.0	0.00	2.04	0.26	0	2	1	89	0.00	0.0	1.676	0.013	2	0	1	2
PL.62564	PL.62566	A	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.03	0	0	0	100	0.00	0.0	1.721	0.045	0	0	1	1
PL.62563	PL.62562	ABC	336 MCM AC	7.37Y	122.9	0.05	2.09	142.44	27	3000	970	95	0.78	0.0	1.705	0.046	15	4	2	504
PL.62871	PL.62563	ABC	336 MCM AC	7.37Y	122.8	0.10	2.19	141.74	27	2984	964	95	1.46	0.0	1.792	0.086	0	0	0	502
PL.62872	PL.62871	ABC	336 MCM AC	7.37Y	122.8	0.06	2.24	141.74	27	2982	961	95	0.87	0.0	1.843	0.052	8	2	1	502
PL.62873	PL.62872	C	6 A (CWC)	7.37Y	122.8	0.00	2.24	0.00	0	0	0	100	0.00	0.0	1.847	0.003	0	0	0	0
PL.62890	PL.62872	ABC	336 MCM AC	7.36Y	122.7	0.05	2.29	138.35	27	2910	937	95	0.75	0.0	1.890	0.046	0	0	0	489
PL.62889	PL.62890	ABC	336 MCM AC	7.36Y	122.7	0.03	2.33	138.35	27	2909	936	95	0.52	0.0	1.922	0.032	26	8	4	489
PL.62888	PL.62889	ABC	336 MCM AC	7.36Y	122.6	0.07	2.39	137.14	26	2883	927	95	0.99	0.0	1.984	0.062	0	0	0	485
PL.62887	PL.62888	A	6 A (CWC)	7.36Y	122.6	0.00	2.39	1.32	1	9	3	95	0.00	0.0	1.988	0.004	0	0	0	1
PD.9388	PL.62887	A	40T	7.36Y	122.6	0.00	2.39	1.32	0	9	3	95	0.00	0.0	1.988	0.004	0	0	0	1
PL.62570	PD.9388	A	6 A (CWC)	7.36Y	122.6	0.00	2.39	1.32	1	9	3	95	0.00	0.0	2.015	0.027	9	3	1	1
PL.62886	PL.62888	ABC	336 MCM AC	7.35Y	122.5	0.09	2.48	136.70	26	2873	922	95	1.27	0.0	2.065	0.081	0	0	0	484
PL.62571	PL.62886	A	#1/0 ACSR	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	2.068	0.004	0	0	0	0
PD.9389	PL.62571	A	40T	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	2.068	0.004	0	0	0	0
PL.62572	PD.9389	A	#1/0 ACSR	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	2.092	0.024	0	0	0	0
PL.62573	PL.62886	ABC	336 MCM AC	7.35Y	122.5	0.07	2.55	136.70	26	2871	919	95	1.02	0.0	2.130	0.065	0	0	0	484
PL.62574	PL.62573	A	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.48	0	3	1	95	0.00	0.0	2.133	0.003	0	0	0	1
PD.9390	PL.62574	A	40T	7.35Y	122.5	0.00	2.55	0.48	0	3	1	95	0.00	0.0	2.133	0.003	0	0	0	1
PL.62785	PD.9390	A	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.48	0	3	1	95	0.00	0.0	2.151	0.018	3	1	1	1
PL.62575	PL.62573	ABC	336 MCM AC	7.34Y	122.4	0.04	2.59	136.54	26	2867	915	95	0.65	0.0	2.172	0.042	0	0	0	483
PL.62576	PL.62575	ABC	336 MCM AC	7.34Y	122.4	0.05	2.64	136.54	26	2866	914	95	0.67	0.0	2.214	0.043	14	4	1	483
PL.62577	PL.62576	ABC	336 MCM AC	7.34Y	122.3	0.06	2.69	135.90	26	2852	908	95	0.83	0.0	2.268	0.053	15	4	2	482
PL.62659	PL.62577	C	#4 ACSR	7.34Y	122.3	0.00	2.69	0.00	0	0	0	100	0.00	0.0	2.268	0.000	0	0	0	0
PL.62704	PL.62577	ABC	336 MCM AC	7.34Y	122.3	0.03	2.72	135.19	26	2836	902	95	0.41	0.0	2.294	0.027	13	4	2	480

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62591	PL.62704	ABC	336 MCM AC	7.33Y	122.2	0.06	2.78	134.58	26	2823	897	95	0.81	0.0	2.348	0.053	11	3	3	478
PL.62590	PL.62591	A	#2 ACSR	7.33Y	122.2	0.00	2.78	1.26	1	9	3	95	0.00	0.0	2.348	0.001	0	0	0	1
PD.9391	PL.62590	A	40T	7.33Y	122.2	0.00	2.78	1.26	0	9	3	95	0.00	0.0	2.348	0.001	0	0	0	1
PL.62578	PD.9391	A	#2 ACSR	7.33Y	122.2	0.00	2.78	1.26	1	9	3	95	0.00	0.0	2.377	0.029	9	3	1	1
PL.62818	PL.62591	ABC	336 MCM AC	7.33Y	122.2	0.04	2.82	133.64	26	2802	889	95	0.61	0.0	2.388	0.041	21	6	2	474
PL.62820	PL.62818	A	#1/0 ACSR	7.33Y	122.2	0.00	2.82	1.74	1	12	4	95	0.00	0.0	2.392	0.003	0	0	0	3
PD.9452	PL.62820	A	40T	7.33Y	122.2	0.00	2.82	1.74	0	12	4	95	0.00	0.0	2.392	0.003	0	0	0	3
PL.62821	PD.9452	A	#1/0 ACSR	7.33Y	122.2	0.00	2.82	1.74	1	12	4	95	0.00	0.0	2.413	0.021	8	3	1	3
PL.62822	PL.62821	A	#1/0 ACSR	7.33Y	122.2	0.00	2.82	0.54	0	4	1	97	0.00	0.0	2.450	0.037	4	1	2	2
PL.62819	PL.62818	ABC	336 MCM AC	7.33Y	122.1	0.05	2.87	132.07	25	2769	878	95	0.69	0.0	2.435	0.047	3	1	1	469
PL.47464	PL.62819	ABC	#2 ACSR	7.33Y	122.1	0.01	2.87	5.67	3	119	36	96	0.01	0.0	2.473	0.038	0	0	0	25
PL.64476	PL.47464	B	#4 ACSR	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	2.478	0.004	0	0	0	0
PD.9545	PL.64476	B	20T	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	2.478	0.004	0	0	0	0
PL.64477	PD.9545	B	#4 ACSR	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	2.566	0.089	0	0	0	0
PL.46974	PL.64477	B	#4 ACSR	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	2.630	0.064	0	0	0	0
PL.62579	PL.47464	ABC	#2 ACSR	7.33Y	122.1	0.01	2.88	5.67	3	119	36	96	0.01	0.0	2.550	0.076	0	0	0	25
PL.62581	PL.62579	ABC	#2 ACSR	7.33Y	122.1	0.00	2.89	5.39	3	113	34	96	0.00	0.0	2.576	0.026	0	0	0	24
PL.62582	PL.62581	C	#2 ACSR	7.33Y	122.1	0.00	2.89	16.16	9	113	34	96	0.00	0.0	2.579	0.004	0	0	0	24
PD.9392	PL.62582	C	T	7.33Y	122.1	0.00	2.89	16.16	0	113	34	96	0.00	0.0	2.579	0.004	0	0	0	24
PL.62583	PD.9392	C	#2 ACSR	7.33Y	122.1	0.03	2.92	16.16	9	113	34	96	0.02	0.0	2.628	0.049	0	0	0	24
PL.37344	PL.62583	C	6 A (CWC)	7.32Y	122.1	0.01	2.93	16.16	12	113	34	96	0.01	0.0	2.644	0.016	0	0	0	24
PL.37319	PL.37344	C	6 A (CWC)	7.32Y	122.0	0.04	2.97	16.16	12	113	34	96	0.04	0.0	2.700	0.056	0	0	0	24
PD.5236	PL.37319	C	40T	7.32Y	122.0	0.00	2.97	16.16	0	113	34	96	0.00	0.0	2.700	0.056	0	0	0	24
PL.37320	PD.5236	C	6 A (CWC)	7.32Y	122.0	0.00	2.97	16.16	12	113	34	96	0.00	0.0	2.701	0.001	0	0	0	24
PL.37275	PL.37320	C	6 A (CWC)	7.32Y	122.0	0.02	2.99	16.16	12	113	34	96	0.02	0.0	2.725	0.024	0	0	0	24
PL.60236	PL.37275	C	6 A (CWC)	7.32Y	122.0	0.01	3.00	16.16	12	113	34	96	0.01	0.0	2.742	0.017	21	6	2	24
PL.60237	PL.60236	C	6 A (CWC)	7.32Y	122.0	0.04	3.04	8.03	6	56	17	96	0.02	0.0	2.843	0.101	0	0	0	14
PL.58532	PL.60237	C	6 A (CWC)	7.32Y	121.9	0.05	3.08	7.36	5	52	15	96	0.02	0.0	2.976	0.133	0	0	0	13
PD.8708	PL.58532	C	15T	7.32Y	121.9	0.00	3.08	7.36	0	52	15	96	0.00	0.0	2.976	0.133	0	0	0	13
PL.58533	PD.8708	C	6 A (CWC)	7.31Y	121.9	0.02	3.10	7.36	5	52	15	96	0.01	0.0	3.029	0.054	3	1	1	13
PL.37424	PL.58533	C	6 A (CWC)	7.31Y	121.8	0.05	3.15	6.89	5	48	14	96	0.02	0.0	3.201	0.172	2	1	1	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37517	PL.37424	C	6 A (CWC)	7.31Y	121.8	0.03	3.18	3.94	3	28	8	96	0.01	0.0	3.385	0.184	6	2	1	7
PL.37425	PL.37517	C	6 A (CWC)	7.31Y	121.8	0.00	3.18	0.72	1	5	1	98	0.00	0.0	3.438	0.052	0	0	0	2
PL.38113	PL.37425	C	6 A (CWC)	7.31Y	121.8	0.00	3.18	0.72	1	5	1	98	0.00	0.0	3.526	0.088	5	1	2	2
PL.38114	PL.37517	C	6 A (CWC)	7.31Y	121.8	0.01	3.19	2.42	2	17	5	96	0.00	0.0	3.462	0.076	0	0	1	4
PL.38112	PL.38114	C	6 A (CWC)	7.31Y	121.8	0.01	3.20	2.35	2	16	5	95	0.00	0.0	3.514	0.052	1	0	1	3
PL.38115	PL.38112	C	6 A (CWC)	7.31Y	121.8	0.00	3.20	2.17	2	15	5	95	0.00	0.0	3.575	0.061	8	2	1	2
PL.38116	PL.38115	C	6 A (CWC)	7.31Y	121.8	0.00	3.20	1.01	1	7	2	96	0.00	0.0	3.639	0.065	7	2	1	1
PL.38342	PL.37424	C	6 A (CWC)	7.31Y	121.8	0.01	3.16	2.60	2	18	5	96	0.00	0.0	3.358	0.156	11	3	2	4
PL.38117	PL.38342	C	6 A (CWC)	7.31Y	121.8	0.01	3.17	1.08	1	8	2	97	0.00	0.0	3.528	0.170	4	1	1	2
PL.38118	PL.38117	C	6 A (CWC)	7.31Y	121.8	0.00	3.18	0.53	0	4	1	97	0.00	0.0	3.891	0.363	4	1	1	1
PL.38119	PL.38118	C	6 A (CWC)	7.31Y	121.8	0.00	3.18	0.00	0	0	0	100	0.00	0.0	4.012	0.121	0	0	0	0
PL.38144	PL.38118	C	#2 ACSR	7.31Y	121.8	0.00	3.18	0.00	0	0	0	100	0.00	0.0	4.079	0.188	0	0	0	0
PL.37106	PL.60237	C	#4 ACSR	7.32Y	122.0	0.00	3.04	0.67	1	5	1	98	0.00	0.0	2.905	0.062	5	1	1	1
PL.60238	PL.60236	C	6 A (CWC)	7.32Y	122.0	0.00	3.00	5.20	4	36	11	96	0.00	0.0	2.745	0.003	0	0	0	8
PD.8949	PL.60238	C	25T	7.32Y	122.0	0.00	3.00	5.20	0	36	11	96	0.00	0.0	2.745	0.003	0	0	0	8
PL.60235	PD.8949	C	6 A (CWC)	7.32Y	122.0	0.04	3.04	5.20	4	36	11	96	0.01	0.0	2.919	0.173	0	0	1	8
PL.38337	PL.60235	C	6 A (CWC)	7.32Y	121.9	0.02	3.06	5.14	4	36	11	96	0.01	0.0	3.017	0.098	0	0	0	7
PL.38338	PL.38337	C	6 A (CWC)	7.32Y	121.9	0.02	3.08	3.65	3	26	8	96	0.00	0.0	3.115	0.097	0	0	0	6
PL.37280	PL.38338	C	#4 ACSR	7.32Y	121.9	0.00	3.08	1.15	1	8	2	97	0.00	0.0	3.191	0.076	8	2	1	1
PL.38339	PL.38338	C	6 A (CWC)	7.31Y	121.9	0.03	3.11	2.50	2	18	5	96	0.00	0.0	3.437	0.322	5	1	2	5
PL.38340	PL.38339	C	6 A (CWC)	7.31Y	121.9	0.02	3.13	1.78	1	12	4	95	0.00	0.0	3.634	0.197	0	0	0	3
PL.38341	PL.38340	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.31	0	2	1	89	0.00	0.0	3.846	0.213	0	0	0	2
PL.60241	PL.38341	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.31	0	2	1	89	0.00	0.0	3.846	0.000	0	0	0	2
PD.8950	PL.60241	C	15T	7.31Y	121.9	0.00	3.13	0.31	0	2	1	89	0.00	0.0	3.846	0.000	0	0	0	2
PL.60242	PD.8950	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.31	0	2	1	89	0.00	0.0	3.847	0.000	0	0	0	2
PL.60239	PL.60242	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.15	0	1	0	100	0.00	0.0	3.942	0.095	1	0	1	1
PL.60240	PL.60242	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.17	0	1	0	100	0.00	0.0	4.183	0.337	1	0	1	1
PL.37306	PL.38340	C	#4 ACSR	7.31Y	121.9	0.00	3.13	1.47	1	10	3	96	0.00	0.0	3.702	0.068	10	3	1	1
PL.37107	PL.38337	C	6 A (CWC)	7.32Y	121.9	0.00	3.07	1.49	1	10	3	96	0.00	0.0	3.072	0.055	10	3	1	1
PL.62580	PL.62579	B	#4 ACSR	7.33Y	122.1	0.00	2.88	0.85	1	6	2	95	0.00	0.0	2.551	0.001	0	0	0	1
PD.7428	PL.62580	B	40QA	7.33Y	122.1	0.00	2.88	0.85	2	6	2	95	0.00	0.0	2.551	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.46975	PD.7428	B	#4 ACSR	7.33Y	122.1	0.00	2.89	0.85	1	6	2	95	0.00	0.0	2.590	0.040	6	2	1	1
PL.47463	PL.62819	ABC	#2 ACSR	7.31Y	121.9	0.22	3.08	126.25	72	2645	840	95	4.40	0.2	2.502	0.067	8	2	1	443
PL.46922	PL.47463	ABC	#2 ACSR	7.30Y	121.7	0.20	3.29	125.63	72	2628	834	95	4.10	0.2	2.566	0.063	0	0	0	440
PL.46915	PL.46922	A	#4 ACSR	7.30Y	121.7	0.00	3.29	6.75	5	47	14	96	0.00	0.0	2.567	0.001	0	0	0	5
PD.7380	PL.46915	A	40QA	7.30Y	121.7	0.00	3.29	6.75	17	47	14	96	0.00	0.0	2.567	0.001	0	0	0	5
PL.46916	PD.7380	A	#4 ACSR	7.30Y	121.7	0.03	3.31	6.75	5	47	14	96	0.01	0.0	2.666	0.099	12	4	1	5
PL.46913	PL.46916	A	#4 ACSR	7.30Y	121.7	0.01	3.32	5.03	4	35	10	96	0.00	0.0	2.737	0.070	29	9	3	4
PL.58958	PL.46913	A	#4 ACSR	7.30Y	121.7	0.00	3.32	0.84	1	6	2	95	0.00	0.0	2.755	0.018	6	2	1	1
PL.63680	PL.46922	ABC	#2 ACSR	7.29Y	121.5	0.24	3.53	123.38	71	2576	817	95	4.84	0.2	2.643	0.078	0	0	0	435
PL.63682	PL.63680	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.55	17.97	8	377	112	96	0.06	0.0	2.712	0.068	0	0	0	71
PL.46917	PL.63682	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.57	17.15	7	359	107	96	0.04	0.0	2.766	0.055	0	0	0	69
PL.46921	PL.46917	ABC	#1/0 ACSR	7.29Y	121.4	0.00	3.57	17.15	7	359	107	96	0.00	0.0	2.767	0.001	0	0	0	69
PD.7558	PL.46921	ABC	50L	7.29Y	121.4	0.00	3.57	17.15	34	359	107	96	0.00	0.0	2.767	0.001	0	0	0	69
PL.46705	PD.7558	ABC	#1/0 ACSR	7.28Y	121.4	0.03	3.60	17.15	7	359	107	96	0.07	0.0	2.863	0.096	0	0	0	69
PL.47433	PL.46705	C	#2 ACSR	7.28Y	121.4	0.00	3.60	2.69	2	19	6	95	0.00	0.0	2.905	0.042	19	6	3	3
PL.63993	PL.46705	ABC	#1/0 ACSR	7.28Y	121.4	0.02	3.62	16.26	7	340	101	96	0.05	0.0	2.941	0.078	0	0	0	66
PL.63995	PL.63993	A	#4 ACSR	7.28Y	121.4	0.00	3.62	0.17	0	1	0	100	0.00	0.0	2.942	0.001	0	0	0	1
PD.7429	PL.63995	A	40QA	7.28Y	121.4	0.00	3.62	0.17	0	1	0	100	0.00	0.0	2.942	0.001	0	0	0	1
PL.48563	PD.7429	A	#4 ACSR	7.28Y	121.4	0.00	3.62	0.17	0	1	0	100	0.00	0.0	3.009	0.067	1	0	1	1
PL.63994	PL.63993	ABC	#1/0 ACSR	7.28Y	121.4	0.02	3.64	15.97	7	334	100	96	0.03	0.0	2.994	0.053	14	4	3	64
PL.48562	PL.63994	ABC	#1/0 ACSR	7.28Y	121.3	0.03	3.67	15.29	7	320	95	96	0.06	0.0	3.092	0.098	0	0	0	61
PL.48565	PL.48562	ABC	#1/0 ACSR	7.28Y	121.3	0.02	3.69	14.87	6	311	93	96	0.05	0.0	3.182	0.090	0	0	0	59
PL.48568	PL.48565	ABC	#1/0 ACSR	7.28Y	121.3	0.03	3.72	14.70	6	308	92	96	0.06	0.0	3.296	0.114	9	3	6	58
PL.48569	PL.48568	C	#2 ACSR	7.28Y	121.3	0.00	3.72	2.08	1	15	4	97	0.00	0.0	3.301	0.006	0	0	0	1
PD.7541	PL.48569	C	40QA	7.28Y	121.3	0.00	3.72	2.08	5	15	4	97	0.00	0.0	3.301	0.006	0	0	0	1
PL.48570	PD.7541	C	#2 ACSR	7.28Y	121.3	0.00	3.72	2.08	1	15	4	97	0.00	0.0	3.342	0.041	15	4	1	1
PL.48571	PL.48568	ABC	#1/0 ACSR	7.28Y	121.3	0.02	3.74	13.55	6	284	84	96	0.03	0.0	3.361	0.065	0	0	0	51
PL.48613	PL.48571	ABC	#1/0 ACSR	7.28Y	121.3	0.01	3.74	13.55	6	284	84	96	0.01	0.0	3.385	0.024	7	2	1	51
PL.48615	PL.48613	C	6 A (CWC)	7.28Y	121.3	0.00	3.74	2.67	2	19	6	95	0.00	0.0	3.391	0.006	0	0	0	2
PD.7447	PL.48615	C	40QA	7.28Y	121.3	0.00	3.74	2.67	7	19	6	95	0.00	0.0	3.391	0.006	0	0	0	2
PL.48616	PD.7447	C	6 A (CWC)	7.27Y	121.2	0.01	3.76	2.67	2	19	6	95	0.00	0.0	3.559	0.168	11	3	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48614	PL.48616	C	6 A (CWC)	7.27Y	121.2	0.00	3.76	1.14	1	8	2	97	0.00	0.0	3.577	0.018	8	2	1	1
PL.48617	PL.48613	ABC	#1/0 ACSR	7.27Y	121.2	0.02	3.76	12.34	5	258	77	96	0.03	0.0	3.470	0.085	2	1	1	48
PL.48620	PL.48617	ABC	#1/0 ACSR	7.27Y	121.2	0.01	3.77	12.22	5	256	76	96	0.02	0.0	3.510	0.040	0	0	0	47
PL.48621	PL.48620	ABC	#1/0 ACSR	7.27Y	121.2	0.02	3.79	12.22	5	256	76	96	0.04	0.0	3.616	0.106	0	0	0	46
PL.48624	PL.48621	A	#4 ACSR	7.27Y	121.2	0.01	3.80	23.24	18	162	48	96	0.01	0.0	3.621	0.005	0	0	0	28
PD.7450	PL.48624	A	40QA	7.27Y	121.2	0.00	3.80	23.24	58	162	48	96	0.00	0.0	3.621	0.005	0	0	0	28
PL.63996	PD.7450	A	#4 ACSR	7.27Y	121.2	0.05	3.85	23.24	18	162	48	96	0.06	0.0	3.666	0.045	0	0	0	28
PL.64168	PL.63996	A	#4 ACSR	7.26Y	121.1	0.07	3.92	15.01	12	105	31	96	0.05	0.1	3.782	0.115	19	6	3	17
PL.64165	PL.64168	A	#4 ACSR	7.26Y	121.1	0.00	3.92	0.73	1	5	2	93	0.00	0.0	3.833	0.051	5	2	1	1
PL.64170	PL.64168	A	#4 ACSR	7.26Y	121.1	0.02	3.94	7.22	6	50	15	96	0.01	0.0	3.863	0.081	25	7	4	9
PL.64275	PL.64170	A	#4 ACSR	7.26Y	121.0	0.02	3.96	3.62	3	25	7	96	0.00	0.0	4.032	0.169	8	2	1	5
PL.64207	PL.64275	A	#4 ACSR	7.26Y	121.0	0.00	3.96	2.41	2	17	5	96	0.00	0.0	4.073	0.041	9	3	3	4
PL.64208	PL.64207	A	#4 ACSR	7.26Y	121.0	0.00	3.96	1.13	1	8	2	97	0.00	0.0	4.098	0.026	8	2	1	1
PL.64169	PL.64168	A	#4 ACSR	7.26Y	121.1	0.01	3.93	4.40	3	31	9	96	0.00	0.0	3.831	0.049	14	4	2	4
PL.64277	PL.64169	A	#4 ACSR	7.26Y	121.1	0.01	3.93	2.45	2	17	5	96	0.00	0.0	3.918	0.087	0	0	0	2
PL.64171	PL.64277	A	#4 ACSR	7.26Y	121.1	0.01	3.95	2.45	2	17	5	96	0.00	0.0	4.047	0.129	8	2	1	2
PL.64172	PL.64171	A	#4 ACSR	7.26Y	121.1	0.00	3.95	1.31	1	9	3	95	0.00	0.0	4.174	0.127	9	3	1	1
PL.64278	PL.64277	A	#4 ACSR	7.26Y	121.1	0.00	3.93	0.00	0	0	0	100	0.00	0.0	3.988	0.070	0	0	0	0
PL.63998	PL.63996	A	#4 ACSR	7.27Y	121.1	0.01	3.86	5.11	4	36	11	96	0.00	0.0	3.757	0.091	28	8	3	6
PL.48627	PL.63998	A	#4 ACSR	7.27Y	121.1	0.00	3.86	1.07	1	7	2	96	0.00	0.0	3.757	0.000	0	0	0	3
PL.48630	PL.48627	A	#4 ACSR	7.27Y	121.1	0.00	3.86	1.07	1	7	2	96	0.00	0.0	3.788	0.031	2	1	2	3
PL.48631	PL.48630	A	#4 ACSR	7.27Y	121.1	0.00	3.86	0.79	1	6	2	95	0.00	0.0	3.855	0.066	6	2	1	1
PL.63997	PL.63996	A	#4 ACSR	7.27Y	121.1	0.00	3.85	3.11	2	22	6	96	0.00	0.0	3.711	0.044	10	3	2	5
PL.48626	PL.63997	A	#4 ACSR	7.27Y	121.1	0.00	3.85	1.66	1	12	3	97	0.00	0.0	3.777	0.066	12	3	3	3
PL.48625	PL.48621	B	#2 ACSR	7.27Y	121.2	0.02	3.82	13.43	8	94	28	96	0.01	0.0	3.665	0.048	0	0	0	18
PL.48634	PL.48625	B	#2 ACSR	7.27Y	121.2	0.02	3.83	12.23	7	85	25	96	0.01	0.0	3.714	0.049	0	0	1	17
PL.47265	PL.48634	B	#2 ACSR	7.27Y	121.2	0.00	3.83	0.00	0	0	0	100	0.00	0.0	3.772	0.058	0	0	0	0
PL.48635	PL.48634	B	#2 ACSR	7.27Y	121.1	0.03	3.87	12.23	7	85	25	96	0.02	0.0	3.798	0.084	7	2	1	16
PL.63999	PL.48635	B	#2 ACSR	7.27Y	121.1	0.05	3.91	11.16	6	78	23	96	0.03	0.0	3.936	0.139	0	0	0	15
PL.64000	PL.63999	B	#2 ACSR	7.27Y	121.1	0.00	3.92	1.92	1	13	4	96	0.00	0.0	3.976	0.039	8	2	1	2
PL.47499	PL.64000	B	#2 ACSR	7.26Y	121.1	0.00	3.92	0.72	0	5	1	98	0.00	0.0	4.147	0.171	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.64198	PL.63999	B	#2 ACSR	7.26Y	121.1	0.03	3.94	9.24	5	64	19	96	0.01	0.0	4.030	0.094	0	0	0	13
PL.64166	PL.64198	B	#2 ACSR	7.26Y	121.0	0.02	3.96	9.24	5	64	19	96	0.01	0.0	4.105	0.075	6	2	2	13
PL.64167	PL.64166	B	#2 ACSR	7.26Y	121.0	0.02	3.98	8.40	5	58	17	96	0.01	0.0	4.172	0.067	7	2	2	11
PL.64163	PL.64167	B	#2 ACSR	7.26Y	121.0	0.03	4.01	7.36	4	51	15	96	0.01	0.0	4.306	0.134	5	2	1	9
PL.64162	PL.64163	B	#2 ACSR	7.26Y	121.0	0.00	4.01	0.61	0	4	1	97	0.00	0.0	4.433	0.127	4	1	2	2
PL.64164	PL.64163	B	#2 ACSR	7.26Y	121.0	0.02	4.03	5.98	3	42	12	96	0.01	0.0	4.399	0.093	1	0	1	6
PL.64181	PL.64164	B	#2 ACSR	7.26Y	121.0	0.01	4.03	5.90	3	41	12	96	0.00	0.0	4.433	0.035	5	1	1	5
PL.64179	PL.64181	B	#2 ACSR	7.26Y	121.0	0.01	4.04	1.87	1	13	4	96	0.00	0.0	4.704	0.271	13	4	1	1
PL.64180	PL.64181	B	#2 ACSR	7.26Y	121.0	0.01	4.04	3.36	2	23	7	96	0.00	0.0	4.511	0.078	11	3	1	3
PL.64193	PL.64180	B	#2 ACSR	7.26Y	121.0	0.00	4.04	0.75	0	5	2	93	0.00	0.0	4.606	0.095	5	2	1	1
PL.64194	PL.64193	B	#2 ACSR	7.26Y	121.0	0.00	4.04	0.00	0	0	0	100	0.00	0.0	4.686	0.080	0	0	0	0
PL.64274	PL.64180	B	#2 ACSR	7.26Y	121.0	0.00	4.04	0.97	1	7	2	96	0.00	0.0	4.553	0.042	7	2	1	1
PL.48632	PL.48625	B	#2 ACSR	7.27Y	121.2	0.00	3.82	1.19	1	8	2	97	0.00	0.0	3.668	0.003	0	0	0	1
PD.7381	PL.48632	B	40QA	7.27Y	121.2	0.00	3.82	1.19	3	8	2	97	0.00	0.0	3.668	0.003	0	0	0	1
PL.48633	PD.7381	B	#2 ACSR	7.27Y	121.2	0.00	3.82	1.19	1	8	2	97	0.00	0.0	3.700	0.031	8	2	1	1
PL.48622	PL.48620	C	#4 ACSR	7.27Y	121.2	0.00	3.77	0.00	0	0	0	100	0.00	0.0	3.514	0.004	0	0	0	1
PD.7449	PL.48622	C	40QA	7.27Y	121.2	0.00	3.77	0.00	0	0	0	100	0.00	0.0	3.514	0.004	0	0	0	1
PL.48623	PD.7449	C	#4 ACSR	7.27Y	121.2	0.00	3.77	0.00	0	0	0	100	0.00	0.0	3.679	0.165	0	0	1	1
PL.48618	PL.48617	A	#2 ACSR	7.27Y	121.2	0.00	3.76	0.00	0	0	0	100	0.00	0.0	3.476	0.005	0	0	0	0
PD.7448	PL.48618	A	40QA	7.27Y	121.2	0.00	3.76	0.00	0	0	0	100	0.00	0.0	3.476	0.005	0	0	0	0
PL.48619	PD.7448	A	#2 ACSR	7.27Y	121.2	0.00	3.76	0.00	0	0	0	100	0.00	0.0	3.496	0.021	0	0	0	0
PL.48566	PL.48565	C	#4 ACSR	7.28Y	121.3	0.00	3.69	0.52	0	4	1	97	0.00	0.0	3.183	0.001	0	0	0	1
PD.7430	PL.48566	C	40QA	7.28Y	121.3	0.00	3.69	0.52	1	4	1	97	0.00	0.0	3.183	0.001	0	0	0	1
PL.48567	PD.7430	C	#4 ACSR	7.28Y	121.3	0.00	3.69	0.52	0	4	1	97	0.00	0.0	3.218	0.035	4	1	1	1
PL.48564	PL.48562	A	#2 ACSR	7.28Y	121.3	0.00	3.67	1.26	1	9	3	95	0.00	0.0	3.093	0.001	0	0	0	2
PD.7540	PL.48564	A	40QA	7.28Y	121.3	0.00	3.67	1.26	3	9	3	95	0.00	0.0	3.093	0.001	0	0	0	2
PL.48628	PD.7540	A	#2 ACSR	7.28Y	121.3	0.00	3.67	1.26	1	9	3	95	0.00	0.0	3.305	0.212	9	3	2	2
PL.48629	PL.48628	A	#2 ACSR	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	3.384	0.079	0	0	0	0
PL.64007	PL.63993	C	#4 ACSR	7.28Y	121.4	0.00	3.62	0.69	1	5	1	98	0.00	0.0	2.941	0.001	0	0	0	1
PD.9509	PL.64007	C	40QA	7.28Y	121.4	0.00	3.62	0.69	2	5	1	98	0.00	0.0	2.941	0.001	0	0	0	1
PL.64273	PD.9509	C	#4 ACSR	7.28Y	121.4	0.00	3.62	0.69	1	5	1	98	0.00	0.0	2.967	0.026	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64185	PL.64273	C	#4 ACSR	7.28Y	121.4	0.00	3.62	0.00	0	0	0	100	0.00	0.0	3.290	0.323	0	0	0	0
PL.46918	PL.63682	A	#4 ACSR	7.29Y	121.4	0.00	3.55	2.45	2	17	5	96	0.00	0.0	2.725	0.013	17	5	2	2
PL.46919	PL.46918	A	#4 ACSR	7.29Y	121.4	0.00	3.55	0.00	0	0	0	100	0.00	0.0	2.807	0.082	0	0	0	0
PL.46920	PL.46919	A	#4 ACSR	7.29Y	121.4	0.00	3.55	0.00	0	0	0	100	0.00	0.0	2.880	0.073	0	0	0	0
PL.63681	PL.63680	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	4.27	3	30	9	96	0.00	0.0	2.644	0.001	0	0	0	6
PD.7427	PL.63681	A	40QA	7.29Y	121.5	0.00	3.53	4.27	11	30	9	96	0.00	0.0	2.644	0.001	0	0	0	6
PL.46914	PD.7427	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	4.27	3	30	9	96	0.00	0.0	2.659	0.015	0	0	0	6
PL.47530	PL.46914	A	6 A (CWC)	7.29Y	121.5	0.00	3.54	1.00	1	7	2	96	0.00	0.0	2.701	0.041	7	2	1	1
PL.47689	PL.46914	A	6 A (CWC)	7.29Y	121.5	0.00	3.54	3.27	2	23	7	96	0.00	0.0	2.679	0.019	15	4	2	5
PL.58959	PL.47689	A	6 A (CWC)	7.29Y	121.5	0.00	3.54	1.18	1	8	2	97	0.00	0.0	2.730	0.052	8	2	3	3
PL.64192	PL.63680	ABC	336 MCM AC	7.28Y	121.4	0.06	3.59	103.99	20	2165	694	95	0.71	0.0	2.721	0.078	0	0	1	358
PL.64191	PL.64192	ABC	336 MCM AC	7.28Y	121.3	0.06	3.66	103.99	20	2164	692	95	0.69	0.0	2.797	0.076	0	0	0	357
PL.63678	PL.64191	ABC	336 MCM AC	7.28Y	121.3	0.05	3.70	103.19	20	2147	685	95	0.52	0.0	2.855	0.058	0	0	0	355
PL.47226	PL.63678	C	#2 ACSR	7.28Y	121.3	0.00	3.70	2.37	1	17	5	96	0.00	0.0	2.856	0.001	0	0	0	1
PD.7313	PL.47226	C	40QA	7.28Y	121.3	0.00	3.70	2.37	6	17	5	96	0.00	0.0	2.856	0.001	0	0	0	1
PL.47227	PD.7313	C	#2 ACSR	7.28Y	121.3	0.00	3.70	2.37	1	17	5	96	0.00	0.0	2.881	0.025	17	5	1	1
PL.47680	PL.63678	ABC	336 MCM AC	7.27Y	121.2	0.10	3.80	102.40	20	2130	679	95	1.07	0.1	2.976	0.122	0	0	0	354
PL.48059	PL.47680	ABC	336 MCM AC	7.27Y	121.2	0.03	3.83	96.12	19	1998	638	95	0.32	0.0	3.017	0.041	5	1	1	329
PL.48058	PL.48059	ABC	336 MCM AC	7.26Y	121.0	0.15	3.98	95.88	18	1992	636	95	1.57	0.1	3.220	0.203	0	0	0	328
PL.47550	PL.48058	ABC	336 MCM AC	7.25Y	120.9	0.11	4.09	91.42	18	1898	604	95	1.04	0.1	3.368	0.148	12	3	2	311
PL.48167	PL.47550	B	6 A (CWC)	7.25Y	120.9	0.00	4.09	7.06	5	49	15	96	0.00	0.0	3.370	0.001	0	0	0	8
PD.7314	PL.48167	B	50T	7.25Y	120.9	0.00	4.09	7.06	0	49	15	96	0.00	0.0	3.370	0.001	0	0	0	8
PL.57856	PD.7314	B	6 A (CWC)	7.25Y	120.9	0.03	4.11	7.06	5	49	15	96	0.01	0.0	3.463	0.093	12	3	1	8
PL.57857	PL.57856	B	6 A (CWC)	7.25Y	120.8	0.04	4.16	5.40	4	38	11	96	0.01	0.0	3.641	0.178	1	0	1	7
PL.57855	PL.57857	B	6 A (CWC)	7.25Y	120.8	0.05	4.20	5.31	4	37	11	96	0.01	0.0	3.836	0.195	3	1	1	6
PL.47676	PL.57855	B	6 A (CWC)	7.25Y	120.8	0.01	4.22	2.49	2	17	5	96	0.00	0.0	3.949	0.113	0	0	0	3
PL.47366	PL.47676	B	6 A (CWC)	7.25Y	120.8	0.00	4.22	0.67	0	5	1	98	0.00	0.0	4.057	0.107	5	1	1	1
PL.47677	PL.47676	B	6 A (CWC)	7.25Y	120.8	0.00	4.22	1.83	1	13	4	96	0.00	0.0	4.018	0.068	13	4	2	2
PL.47805	PL.57855	B	#2 ACSR	7.25Y	120.8	0.00	4.20	2.35	1	16	5	95	0.00	0.0	3.849	0.013	10	3	1	2
PL.47675	PL.47805	B	#2 ACSR	7.25Y	120.8	0.00	4.20	0.94	1	7	2	96	0.00	0.0	3.985	0.136	7	2	1	1
PL.47731	PL.47550	ABC	336 MCM AC	7.25Y	120.9	0.04	4.13	88.52	17	1836	584	95	0.42	0.0	3.432	0.063	0	0	1	301

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.47730	PL.47731	ABC	336 MCM AC	7.24Y	120.7	0.14	4.27	88.50	17	1835	583	95	1.32	0.1	3.633	0.201	1	0	1	300
PL.46743	PL.47730	ABC	336 MCM AC	7.24Y	120.7	0.06	4.33	88.43	17	1832	579	95	0.56	0.0	3.718	0.085	0	0	0	299
PL.46744	PL.46743	A	#4 ACSR	7.24Y	120.7	0.00	4.33	0.77	1	5	2	93	0.00	0.0	3.723	0.005	0	0	0	1
PD.7539	PL.46744	A	40QA	7.24Y	120.7	0.00	4.33	0.77	2	5	2	93	0.00	0.0	3.723	0.005	0	0	0	1
PL.47138	PD.7539	A	#4 ACSR	7.24Y	120.7	0.00	4.33	0.77	1	5	2	93	0.00	0.0	3.755	0.032	5	2	1	1
PL.46742	PL.46743	ABC	336 MCM AC	7.24Y	120.6	0.06	4.38	88.17	17	1826	576	95	0.56	0.0	3.803	0.085	0	0	0	298
PL.46741	PL.46742	ABC	336 MCM AC	7.24Y	120.6	0.00	4.39	88.17	17	1826	575	95	0.02	0.0	3.806	0.003	0	0	0	298
PL.46734	PL.46741	ABC	336 MCM AC	7.23Y	120.5	0.08	4.46	88.17	17	1826	575	95	0.74	0.0	3.919	0.113	0	0	0	298
PL.46735	PL.46734	A	#2 ACSR	7.23Y	120.5	0.00	4.46	0.61	0	4	1	97	0.00	0.0	3.925	0.006	0	0	0	1
PD.7519	PL.46735	A	40QA	7.23Y	120.5	0.00	4.46	0.61	2	4	1	97	0.00	0.0	3.925	0.006	0	0	0	1
PL.46740	PD.7519	A	#2 ACSR	7.23Y	120.5	0.00	4.46	0.61	0	4	1	97	0.00	0.0	3.988	0.063	4	1	1	1
PL.46733	PL.46734	ABC	336 MCM AC	7.23Y	120.5	0.05	4.51	87.97	17	1821	572	95	0.47	0.0	3.991	0.072	0	0	0	297
PL.48056	PL.46733	A	#2 ACSR	7.23Y	120.5	0.00	4.51	0.13	0	1	0	100	0.00	0.0	3.996	0.005	0	0	0	1
PD.7423	PL.48056	A	40QA	7.23Y	120.5	0.00	4.51	0.13	0	1	0	100	0.00	0.0	3.996	0.005	0	0	0	1
PL.48057	PD.7423	A	#2 ACSR	7.23Y	120.5	0.00	4.51	0.13	0	1	0	100	0.00	0.0	4.040	0.043	1	0	1	1
PL.48055	PL.46733	ABC	336 MCM AC	7.22Y	120.4	0.09	4.60	87.92	17	1820	571	95	0.86	0.0	4.124	0.132	0	0	1	296
PL.48054	PL.48055	ABC	336 MCM AC	7.22Y	120.3	0.09	4.69	87.91	17	1818	568	95	0.84	0.0	4.253	0.129	13	4	1	295
PL.48053	PL.48054	ABC	336 MCM AC	7.22Y	120.3	0.04	4.73	87.27	17	1804	563	95	0.40	0.0	4.316	0.063	0	0	0	294
PL.63677	PL.48053	ABC	336 MCM AC	7.20Y	120.1	0.20	4.94	86.35	17	1785	556	95	1.92	0.1	4.621	0.306	0	0	0	292
PL.63675	PL.63677	ABC	336 MCM AC	7.20Y	119.9	0.12	5.06	84.66	16	1748	541	96	1.11	0.1	4.805	0.184	0	0	0	284
PL.47532	PL.63675	A	#2 ACSR	7.20Y	119.9	0.00	5.06	0.17	0	1	0	100	0.00	0.0	4.843	0.038	1	0	1	1
PL.48561	PL.63675	ABC	336 MCM AC	7.19Y	119.9	0.04	5.10	84.61	16	1746	538	96	0.37	0.0	4.867	0.062	0	0	0	283
PL.48556	PL.48561	ABC	336 MCM AC	7.19Y	119.9	0.00	5.10	84.61	16	1745	537	96	0.00	0.0	4.867	0.000	0	0	0	283
PL.48555	PL.48556	ABC	336 MCM AC	7.19Y	119.9	0.03	5.12	84.20	16	1737	535	96	0.24	0.0	4.907	0.040	0	0	0	281
PL.62499	PL.48555	A	#2 ACSR	7.19Y	119.9	0.00	5.13	1.43	1	10	3	96	0.00	0.0	4.996	0.088	0	0	0	3
PD.9369	PL.62499	A	25T	7.19Y	119.9	0.00	5.13	1.43	0	10	3	96	0.00	0.0	4.996	0.088	0	0	0	3
PL.62500	PD.9369	A	#2 ACSR	7.19Y	119.9	0.00	5.13	1.43	1	10	3	96	0.00	0.0	4.999	0.004	0	0	0	3
PL.62434	PL.62500	A	#2 ACSR	7.19Y	119.9	0.00	5.13	0.27	0	2	1	89	0.00	0.0	5.119	0.120	0	0	0	2
PL.48048	PL.62434	A	#2 ACSR	7.19Y	119.9	0.00	5.13	0.27	0	2	1	89	0.00	0.0	5.120	0.001	0	0	0	2
PD.7517	PL.48048	A	40QA	7.19Y	119.9	0.00	5.13	0.27	1	2	1	89	0.00	0.0	5.120	0.001	0	0	0	2
PL.48049	PD.7517	A	#2 ACSR	7.19Y	119.9	0.00	5.13	0.27	0	2	1	89	0.00	0.0	5.190	0.070	1	0	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48050	PL.48049	A	#2 ACSR	7.19Y	119.9	0.00	5.13	0.06	0	0	0	100	0.00	0.0	5.259	0.069	0	0	1	1
PL.62498	PL.62500	A	#2 ACSR	7.19Y	119.9	0.01	5.13	1.15	1	8	2	97	0.00	0.0	5.438	0.439	8	2	1	1
PL.48554	PL.48555	ABC	336 MCM AC	7.19Y	119.8	0.10	5.22	83.73	16	1727	531	96	0.89	0.1	5.059	0.151	0	0	0	278
PL.48553	PL.48554	ABC	336 MCM AC	7.19Y	119.8	0.03	5.24	83.23	16	1716	526	96	0.23	0.0	5.099	0.040	18	5	2	277
PL.48550	PL.48553	ABC	336 MCM AC	7.18Y	119.7	0.04	5.28	82.35	16	1697	520	96	0.36	0.0	5.162	0.064	13	4	1	275
PL.57390	PL.48550	ABC	336 MCM AC	7.18Y	119.7	0.06	5.34	81.72	16	1684	515	96	0.52	0.0	5.256	0.094	8	2	1	274
PL.57387	PL.57390	ABC	#1/0 ACSR	7.18Y	119.6	0.03	5.37	64.23	28	1323	405	96	0.26	0.0	5.280	0.024	0	0	0	214
PL.47918	PL.57387	ABC	#1/0 ACSR	7.18Y	119.6	0.00	5.37	64.23	28	1322	405	96	0.01	0.0	5.280	0.001	0	0	0	214
PD.7555	PL.47918	ABC	100L	7.18Y	119.6	0.00	5.37	64.23	64	1322	405	96	0.00	0.0	5.280	0.001	0	0	0	214
PL.47919	PD.7555	ABC	#1/0 ACSR	7.18Y	119.6	0.02	5.39	64.23	28	1322	405	96	0.19	0.0	5.297	0.017	2	1	1	214
PL.57930	PL.47919	ABC	#1/0 ACSR	7.17Y	119.5	0.10	5.49	64.14	28	1320	404	96	0.91	0.1	5.381	0.084	10	3	3	213
PL.57931	PL.57930	ABC	#1/0 ACSR	7.17Y	119.5	0.06	5.55	63.65	28	1309	401	96	0.54	0.0	5.432	0.050	0	0	0	210
PL.64068	PL.57931	ABC	#1/0 ACSR	7.16Y	119.3	0.11	5.66	63.65	28	1309	400	96	1.05	0.1	5.529	0.098	6	2	1	210
PL.64069	PL.64068	ABC	#1/0 ACSR	7.16Y	119.3	0.04	5.70	63.37	28	1302	397	96	0.40	0.0	5.567	0.037	0	0	0	209
PL.48337	PL.64069	A	#4 ACSR	7.16Y	119.3	0.00	5.70	0.00	0	0	0	100	0.00	0.0	5.568	0.002	0	0	0	0
PD.7496	PL.48337	A	40QA	7.16Y	119.3	0.00	5.70	0.00	0	0	0	100	0.00	0.0	5.568	0.002	0	0	0	0
PL.48338	PD.7496	A	#4 ACSR	7.16Y	119.3	0.00	5.70	0.00	0	0	0	100	0.00	0.0	5.613	0.045	0	0	0	0
PL.48339	PL.48338	A	#4 ACSR	7.16Y	119.3	0.00	5.70	0.00	0	0	0	100	0.00	0.0	5.689	0.075	0	0	0	0
PL.48336	PL.64069	ABC	#1/0 ACSR	7.13Y	118.8	0.54	6.24	63.37	28	1302	397	96	4.96	0.4	6.035	0.468	16	5	3	209
PL.62584	PL.48336	ABC	#1/0 ACSR	7.12Y	118.7	0.01	6.26	45.11	20	923	280	96	0.08	0.0	6.050	0.015	0	0	0	149
RG.62	PL.62584	ABC	114.3 KVA	7.45Y	124.2	-5.43	0.82	45.11	30	923	280	96	percent Boost= 4.38 Tap= 7.0							149
PL.64259	RG.62	ABC	#1/0 ACSR	7.45Y	124.1	0.06	0.89	43.14	19	923	280	96	0.40	0.0	6.130	0.080	0	0	0	149
PL.64258	PL.64259	C	6 A (CWC)	7.45Y	124.1	0.00	0.89	2.35	2	17	5	96	0.00	0.0	6.178	0.048	17	5	2	2
PL.64276	PL.64259	ABC	#1/0 ACSR	7.44Y	124.1	0.04	0.92	42.36	18	906	274	96	0.22	0.0	6.177	0.047	9	3	1	147
PL.64186	PL.64276	ABC	#1/0 ACSR	7.44Y	124.0	0.04	0.96	41.95	18	897	272	96	0.22	0.0	6.224	0.047	22	6	2	146
PL.64188	PL.64186	B	#2 ACSR	7.44Y	124.0	0.00	0.96	0.73	0	5	2	93	0.00	0.0	6.225	0.001	0	0	0	2
PD.9506	PL.64188	B	40QA	7.44Y	124.0	0.00	0.96	0.73	2	5	2	93	0.00	0.0	6.225	0.001	0	0	0	2
PL.64006	PD.9506	B	#2 ACSR	7.44Y	124.0	0.00	0.96	0.73	0	5	2	93	0.00	0.0	6.334	0.110	0	0	0	2
PL.64260	PL.64006	B	#2 ACSR	7.44Y	124.0	0.00	0.96	0.23	0	2	0	100	0.00	0.0	6.374	0.040	2	0	1	1
PL.64261	PL.64006	B	#2 ACSR	7.44Y	124.0	0.00	0.96	0.50	0	4	1	97	0.00	0.0	6.454	0.120	4	1	1	1
PL.64187	PL.64186	ABC	#1/0 ACSR	7.44Y	124.0	0.04	1.00	40.69	18	870	263	96	0.25	0.0	6.280	0.056	0	0	1	142

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64204	PL.64187	ABC	#1/0 ACSR	7.44Y	124.0	0.04	1.04	40.69	18	869	263	96	0.21	0.0	6.328	0.049	0	0	2	141
PL.64205	PL.64204	C	#2 ACSR	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	6.330	0.001	0	0	0	1
PD.9507	PL.64205	C	40QA	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	6.330	0.001	0	0	0	1
PL.64213	PD.9507	C	#2 ACSR	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	6.375	0.045	0	0	1	1
PL.64206	PL.64204	ABC	#1/0 ACSR	7.43Y	123.9	0.05	1.08	40.69	18	869	263	96	0.29	0.0	6.393	0.065	0	0	0	138
PL.64262	PL.64206	ABC	#1/0 ACSR	7.43Y	123.9	0.01	1.10	40.69	18	869	263	96	0.08	0.0	6.412	0.019	0	0	0	138
PL.47495	PL.64262	ABC	#1/0 ACSR	7.43Y	123.9	0.03	1.12	40.69	18	869	263	96	0.16	0.0	6.448	0.036	0	0	0	138
PL.47498	PL.47495	ABC	#1/0 ACSR	7.43Y	123.8	0.05	1.17	40.69	18	869	262	96	0.27	0.0	6.509	0.061	0	0	0	138
PL.47758	PL.47498	A	#4 ACSR	7.43Y	123.8	0.00	1.17	0.00	0	0	0	100	0.00	0.0	6.548	0.039	0	0	0	0
PL.48340	PL.47498	ABC	#1/0 ACSR	7.43Y	123.8	0.06	1.23	40.69	18	868	262	96	0.34	0.0	6.585	0.076	0	0	0	138
PL.57393	PL.48340	ABC	#1/0 ACSR	7.42Y	123.7	0.04	1.26	40.07	17	855	258	96	0.22	0.0	6.637	0.052	15	5	2	136
PL.57394	PL.57393	ABC	#1/0 ACSR	7.42Y	123.7	0.04	1.30	39.35	17	839	253	96	0.20	0.0	6.686	0.049	0	0	0	134
PL.47693	PL.57394	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.60	0	4	1	97	0.00	0.0	6.730	0.044	4	1	1	1
PL.48341	PL.57394	ABC	#1/0 ACSR	7.42Y	123.6	0.06	1.36	39.15	17	835	252	96	0.33	0.0	6.768	0.082	7	2	1	133
PL.48342	PL.48341	ABC	#1/0 ACSR	7.42Y	123.6	0.04	1.40	38.29	17	816	246	96	0.22	0.0	6.825	0.057	29	9	3	131
PL.64263	PL.48342	ABC	#1/0 ACSR	7.41Y	123.6	0.03	1.43	36.93	16	787	237	96	0.16	0.0	6.869	0.044	0	0	0	128
PL.64264	PL.64263	C	#2 ACSR	7.41Y	123.6	0.00	1.43	0.00	0	0	0	100	0.00	0.0	6.870	0.001	0	0	0	1
PD.7581	PL.64264	C	25QA	7.41Y	123.6	0.00	1.43	0.00	0	0	0	100	0.00	0.0	6.870	0.001	0	0	0	1
PL.48343	PD.7581	C	#2 ACSR	7.41Y	123.6	0.00	1.43	0.00	0	0	0	100	0.00	0.0	6.898	0.027	0	0	1	1
PL.64270	PL.64263	ABC	#1/0 ACSR	7.41Y	123.5	0.03	1.46	36.93	16	787	237	96	0.18	0.0	6.919	0.050	1	0	1	127
PL.64271	PL.64270	C	#4 ACSR	7.41Y	123.5	0.00	1.46	3.48	3	25	7	96	0.00	0.0	6.921	0.001	0	0	0	4
PD.9508	PL.64271	C	40QA	7.41Y	123.5	0.00	1.46	3.48	9	25	7	96	0.00	0.0	6.921	0.001	0	0	0	4
PL.64203	PD.9508	C	#4 ACSR	7.41Y	123.5	0.01	1.47	3.48	3	25	7	96	0.00	0.0	6.983	0.063	13	4	1	4
PL.64202	PL.64203	C	#4 ACSR	7.41Y	123.5	0.00	1.47	0.95	1	7	2	96	0.00	0.0	7.032	0.048	7	2	2	2
PL.64178	PL.64203	C	#4 ACSR	7.41Y	123.5	0.00	1.47	0.76	1	5	2	93	0.00	0.0	7.068	0.085	5	2	1	1
PL.64272	PL.64270	ABC	#1/0 ACSR	7.41Y	123.5	0.03	1.49	35.24	15	750	226	96	0.17	0.0	6.973	0.053	23	7	1	121
PL.64196	PL.64272	ABC	#1/0 ACSR	7.41Y	123.5	0.04	1.54	34.18	15	728	219	96	0.22	0.0	7.043	0.071	12	3	2	120
PL.64195	PL.64196	A	#2 ACSR	7.41Y	123.5	0.00	1.54	0.22	0	2	0	100	0.00	0.0	7.061	0.018	2	0	2	2
PL.64174	PL.64196	C	#4 ACSR	7.41Y	123.5	0.00	1.54	5.05	4	36	11	96	0.00	0.0	7.065	0.022	11	3	1	3
PL.64173	PL.64174	C	#4 ACSR	7.41Y	123.4	0.01	1.55	3.44	3	24	7	96	0.00	0.0	7.183	0.118	24	7	2	2
PL.64197	PL.64196	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.54	31.87	14	678	204	96	0.00	0.0	7.044	0.000	0	0	0	113

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64265	PL.64197	ABC	#1/0 ACSR	7.40Y	123.4	0.06	1.59	31.87	14	678	204	96	0.26	0.0	7.141	0.097	7	2	1	113
PL.46895	PL.64265	ABC	#1/0 ACSR	7.40Y	123.4	0.05	1.64	31.56	14	671	202	96	0.21	0.0	7.220	0.080	0	0	0	112
PL.47748	PL.46895	C	#2 ACSR	7.40Y	123.4	0.00	1.64	1.39	1	10	3	96	0.00	0.0	7.221	0.001	0	0	0	1
PD.7378	PL.47748	C	40QA	7.40Y	123.4	0.00	1.64	1.39	3	10	3	96	0.00	0.0	7.221	0.001	0	0	0	1
PL.47749	PD.7378	C	#2 ACSR	7.40Y	123.4	0.00	1.64	1.39	1	10	3	96	0.00	0.0	7.262	0.041	10	3	1	1
PL.47750	PL.46895	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.66	31.09	14	661	199	96	0.08	0.0	7.251	0.031	0	0	0	111
PL.47830	PL.47750	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.70	30.03	13	638	192	96	0.16	0.0	7.319	0.068	1	0	1	108
PL.47831	PL.47830	ABC	#1/0 ACSR	7.39Y	123.2	0.08	1.78	30.00	13	638	192	96	0.36	0.1	7.468	0.149	3	1	1	107
PL.47832	PL.47831	ABC	#1/0 ACSR	7.39Y	123.1	0.08	1.86	29.87	13	634	191	96	0.36	0.1	7.619	0.151	0	0	0	106
PL.47833	PL.47832	A	#2 ACSR	7.39Y	123.1	0.00	1.86	1.46	1	10	3	96	0.00	0.0	7.625	0.006	0	0	0	1
PD.7176	PL.47833	A	40QA	7.39Y	123.1	0.00	1.86	1.46	4	10	3	96	0.00	0.0	7.625	0.006	0	0	0	1
PL.47834	PD.7176	A	#2 ACSR	7.39Y	123.1	0.00	1.86	1.46	1	10	3	96	0.00	0.0	7.690	0.065	10	3	1	1
PL.47837	PL.47832	ABC	#1/0 ACSR	7.39Y	123.1	0.03	1.89	29.38	13	624	187	96	0.11	0.0	7.668	0.049	0	0	0	105
PL.47835	PL.47837	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.41	0	3	1	95	0.00	0.0	7.674	0.006	0	0	0	1
PD.7323	PL.47835	A	40QA	7.39Y	123.1	0.00	1.89	0.41	1	3	1	95	0.00	0.0	7.674	0.006	0	0	0	1
PL.47836	PD.7323	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.41	0	3	1	95	0.00	0.0	7.736	0.062	3	1	1	1
PL.47838	PL.47837	ABC	#1/0 ACSR	7.38Y	123.0	0.08	1.97	29.25	13	621	186	96	0.35	0.1	7.821	0.153	0	0	0	104
PL.47839	PL.47838	A	#2 ACSR	7.38Y	123.0	0.00	1.97	0.00	0	0	0	100	0.00	0.0	7.826	0.005	0	0	0	0
PD.7322	PL.47839	A	40QA	7.38Y	123.0	0.00	1.97	0.00	0	0	0	100	0.00	0.0	7.826	0.005	0	0	0	0
PL.47840	PD.7322	A	#2 ACSR	7.38Y	123.0	0.00	1.97	0.00	0	0	0	100	0.00	0.0	7.855	0.028	0	0	0	0
PL.47647	PL.47838	C	#2 ACSR	7.38Y	123.0	0.00	1.97	0.45	0	3	1	95	0.00	0.0	7.855	0.034	3	1	1	1
PL.47841	PL.47838	ABC	#1/0 ACSR	7.38Y	123.0	0.02	1.99	29.09	13	617	185	96	0.08	0.0	7.857	0.035	0	0	0	103
PL.47556	PL.47841	A	#2 ACSR	7.38Y	123.0	0.00	1.99	0.00	0	0	0	100	0.00	0.0	7.887	0.030	0	0	0	0
PL.47842	PL.47841	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.01	29.09	13	617	185	96	0.11	0.0	7.907	0.050	0	0	0	103
PL.47843	PL.47842	ABC	#1/0 ACSR	7.38Y	122.9	0.05	2.07	28.05	12	595	178	96	0.22	0.0	8.015	0.108	18	5	2	101
PL.47846	PL.47843	C	#4 ACSR	7.38Y	122.9	0.00	2.07	6.39	5	45	13	96	0.00	0.0	8.020	0.005	0	0	0	9
PD.7516	PL.47846	C	40QA	7.38Y	122.9	0.00	2.07	6.39	16	45	13	96	0.00	0.0	8.020	0.005	0	0	0	9
PL.47847	PD.7516	C	#4 ACSR	7.38Y	122.9	0.01	2.08	6.39	5	45	13	96	0.00	0.0	8.076	0.057	25	7	5	9
PL.47848	PL.47847	C	#4 ACSR	7.37Y	122.9	0.01	2.09	2.84	2	20	6	96	0.00	0.0	8.283	0.207	20	6	4	4
PL.47849	PL.47843	ABC	#1/0 ACSR	7.37Y	122.9	0.04	2.10	25.09	11	532	159	96	0.13	0.0	8.095	0.080	6	2	1	90
PL.47641	PL.47849	C	#2 ACSR	7.37Y	122.9	0.00	2.10	1.74	1	12	4	95	0.00	0.0	8.116	0.021	12	4	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.47399	PL.47849	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.13	23.02	10	488	146	96	0.09	0.0	8.160	0.065	0	0	1	84
PL.47400	PL.47399	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.15	23.00	10	487	146	96	0.08	0.0	8.218	0.058	7	2	1	83
PL.47401	PL.47400	ABC	#1/0 ACSR	7.37Y	122.8	0.03	2.18	22.67	10	480	144	96	0.09	0.0	8.282	0.064	3	1	1	82
PL.47402	PL.47401	ABC	#1/0 ACSR	7.36Y	122.7	0.09	2.27	22.51	10	477	143	96	0.29	0.1	8.499	0.217	0	0	0	81
PL.47403	PL.47402	A	6 A (CWC)	7.36Y	122.7	0.00	2.27	8.22	6	58	17	96	0.00	0.0	8.503	0.004	0	0	0	8
PD.7379	PL.47403	A	40QA	7.36Y	122.7	0.00	2.27	8.22	21	58	17	96	0.00	0.0	8.503	0.004	0	0	0	8
PL.59558	PD.7379	A	6 A (CWC)	7.36Y	122.7	0.04	2.31	8.22	6	58	17	96	0.02	0.0	8.604	0.101	1	0	1	8
PL.59559	PL.59558	A	6 A (CWC)	7.36Y	122.6	0.05	2.36	8.06	6	57	17	96	0.02	0.0	8.754	0.150	5	1	1	7
PL.59560	PL.59559	A	6 A (CWC)	7.36Y	122.6	0.03	2.39	7.40	5	52	15	96	0.01	0.0	8.832	0.079	0	0	0	6
PL.59557	PL.59560	A	6 A (CWC)	7.35Y	122.6	0.03	2.42	5.36	4	38	11	96	0.01	0.0	9.016	0.184	21	6	3	4
PL.61956	PL.59557	A	#1/0 ACSR	7.35Y	122.6	0.00	2.43	2.36	1	17	5	96	0.00	0.0	9.180	0.164	17	5	1	1
PL.61770	PL.59560	A	6 A (CWC)	7.36Y	122.6	0.01	2.40	2.03	1	14	4	96	0.00	0.0	8.903	0.071	0	0	0	2
PL.61772	PL.61770	A	#1/0 ACSR	7.36Y	122.6	0.00	2.40	1.55	1	11	3	96	0.00	0.0	8.951	0.047	11	3	1	1
PL.61771	PL.61770	A	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.48	0	3	1	95	0.00	0.0	8.983	0.080	0	0	0	1
PL.60051	PL.61771	A	#1/0 ACSR	7.36Y	122.6	0.00	2.40	0.48	0	3	1	95	0.00	0.0	9.070	0.087	3	1	1	1
PL.47486	PL.47402	ABC	#1/0 ACSR	7.36Y	122.7	0.02	2.29	19.77	9	418	125	96	0.04	0.0	8.541	0.042	0	0	0	73
PL.47488	PL.47486	C	#4 ACSR	7.36Y	122.7	0.00	2.29	1.19	1	8	2	97	0.00	0.0	8.543	0.002	0	0	0	1
PD.7178	PL.47488	C	40QA	7.36Y	122.7	0.00	2.29	1.19	3	8	2	97	0.00	0.0	8.543	0.002	0	0	0	1
PL.47489	PD.7178	C	#4 ACSR	7.36Y	122.7	0.00	2.29	1.19	1	8	2	97	0.00	0.0	8.589	0.046	8	2	1	1
PL.47487	PL.47486	ABC	#1/0 ACSR	7.36Y	122.7	0.01	2.30	19.38	8	410	123	96	0.04	0.0	8.580	0.039	0	0	0	72
PL.47484	PL.47487	A	#2 ACSR	7.36Y	122.7	0.00	2.30	1.27	1	9	3	95	0.00	0.0	8.583	0.003	0	0	0	1
PD.7537	PL.47484	A	40QA	7.36Y	122.7	0.00	2.30	1.27	3	9	3	95	0.00	0.0	8.583	0.003	0	0	0	1
PL.47485	PD.7537	A	#2 ACSR	7.36Y	122.7	0.00	2.30	1.27	1	9	3	95	0.00	0.0	8.604	0.020	9	3	1	1
PL.47490	PL.47487	ABC	#1/0 ACSR	7.36Y	122.7	0.02	2.32	18.96	8	401	120	96	0.07	0.0	8.652	0.072	0	0	0	71
PL.47493	PL.47490	ABC	#1/0 ACSR	7.36Y	122.6	0.05	2.37	18.43	8	390	117	96	0.12	0.0	8.789	0.137	9	3	2	70
PL.47820	PL.47493	A	#2 ACSR	7.36Y	122.6	0.00	2.37	0.17	0	1	0	100	0.00	0.0	8.795	0.006	0	0	0	1
PD.7592	PL.47820	A	40QA	7.36Y	122.6	0.00	2.37	0.17	0	1	0	100	0.00	0.0	8.795	0.006	0	0	0	1
PL.47821	PD.7592	A	#2 ACSR	7.36Y	122.6	0.00	2.37	0.17	0	1	0	100	0.00	0.0	8.832	0.037	0	0	0	1
PL.47494	PL.47821	A	#2 ACSR	7.36Y	122.6	0.00	2.37	0.17	0	1	0	100	0.00	0.0	8.873	0.041	1	0	1	1
PL.64754	PL.47493	ABC	#1/0 ACSR	7.36Y	122.6	0.00	2.37	17.94	8	379	113	96	0.00	0.0	8.789	0.000	0	0	0	67
PL.64755	PL.64754	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.38	17.94	8	379	113	96	0.03	0.0	8.825	0.035	4	1	1	67

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.47822	PL.64755	ABC	#1/0 ACSR	7.36Y	122.6	0.02	2.40	17.75	8	375	112	96	0.05	0.0	8.881	0.057	4	1	1	66
PL.47823	PL.47822	ABC	#1/0 ACSR	7.35Y	122.6	0.02	2.42	17.57	8	372	111	96	0.05	0.0	8.940	0.058	1	0	2	65
PL.47824	PL.47823	ABC	#1/0 ACSR	7.35Y	122.5	0.04	2.46	17.52	8	370	111	96	0.11	0.0	9.076	0.137	0	0	0	63
PL.47903	PL.47824	C	#2 ACSR	7.35Y	122.5	0.00	2.46	0.00	0	0	0	100	0.00	0.0	9.112	0.036	0	0	1	1
PL.57829	PL.47824	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.48	17.52	8	370	111	96	0.03	0.0	9.122	0.046	30	9	4	62
PL.57830	PL.57829	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.49	16.12	7	341	102	96	0.03	0.0	9.169	0.047	6	2	1	58
PL.57831	PL.57830	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.50	15.83	7	334	100	96	0.02	0.0	9.198	0.029	19	6	2	57
PL.51797	PL.57831	ABC	#1/0 ACSR	7.35Y	122.5	0.02	2.52	14.91	6	315	94	96	0.05	0.0	9.284	0.085	3	1	1	55
PL.51798	PL.51797	C	6 A (CWC)	7.35Y	122.5	0.00	2.52	3.86	3	27	8	96	0.00	0.0	9.286	0.003	0	0	0	5
PD.9443	PL.51798	C	40QA	7.35Y	122.5	0.00	2.52	3.86	10	27	8	96	0.00	0.0	9.286	0.003	0	0	0	5
PL.64841	PD.9443	C	6 A (CWC)	7.35Y	122.5	0.02	2.54	3.86	3	27	8	96	0.00	0.0	9.378	0.092	0	0	0	5
PL.64843	PL.64841	C	#1/0 ACSR	7.35Y	122.5	0.00	2.54	0.00	0	0	0	100	0.00	0.0	9.428	0.050	0	0	1	1
PL.64842	PL.64841	C	6 A (CWC)	7.35Y	122.4	0.02	2.55	3.86	3	27	8	96	0.00	0.0	9.473	0.095	0	0	0	4
PL.62857	PL.64842	C	6 A (CWC)	7.35Y	122.4	0.00	2.56	1.87	1	13	4	96	0.00	0.0	9.500	0.027	13	4	1	1
PL.62858	PL.64842	C	6 A (CWC)	7.35Y	122.4	0.01	2.56	1.99	1	14	4	96	0.00	0.0	9.563	0.090	0	0	0	3
PL.62856	PL.62858	C	6 A (CWC)	7.35Y	122.4	0.01	2.57	1.99	1	14	4	96	0.00	0.0	9.656	0.093	3	1	1	3
PL.62855	PL.62856	C	6 A (CWC)	7.35Y	122.4	0.01	2.58	1.61	1	11	3	96	0.00	0.0	9.726	0.070	0	0	0	2
PL.61950	PL.62855	C	6 A (CWC)	7.34Y	122.4	0.01	2.59	1.61	1	11	3	96	0.00	0.0	10.081	0.355	11	3	2	2
PL.61951	PL.61950	C	6 A (CWC)	7.34Y	122.4	0.00	2.59	0.00	0	0	0	100	0.00	0.0	10.225	0.144	0	0	0	0
PL.51796	PL.62855	C	6 A (CWC)	7.35Y	122.4	0.00	2.58	0.00	0	0	0	100	0.00	0.0	9.792	0.066	0	0	0	0
PL.62860	PL.51797	A	6 A (CWC)	7.35Y	122.5	0.01	2.53	40.51	29	285	85	96	0.01	0.0	9.287	0.004	0	0	0	49
C PD.9442	PL.62860	A	35L	7.35Y	122.5	0.00	2.53	40.51	116	285	85	96	0.00	0.0	9.287	0.004	0	0	0	49 C
PL.62859	PD.9442	A	6 A (CWC)	7.34Y	122.3	0.13	2.66	40.51	29	285	85	96	0.28	0.1	9.357	0.070	0	0	0	49
PL.51800	PL.62859	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	0.82	1	6	2	95	0.00	0.0	9.360	0.004	0	0	0	2
PD.7420	PL.51800	A	40QA	7.34Y	122.3	0.00	2.66	0.82	2	6	2	95	0.00	0.0	9.360	0.004	0	0	0	2
PL.47825	PD.7420	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	0.82	1	6	2	95	0.00	0.0	9.402	0.042	6	2	2	2
PL.51749	PL.62859	A	6 A (CWC)	7.33Y	122.2	0.13	2.79	39.69	28	279	83	96	0.27	0.1	9.427	0.071	0	0	0	47
PL.51748	PL.51749	A	6 A (CWC)	7.33Y	122.2	0.05	2.83	39.69	28	279	83	96	0.10	0.0	9.454	0.026	0	0	0	47
PL.51802	PL.51748	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	1.56	1	11	3	96	0.00	0.0	9.510	0.056	4	1	2	4
PL.51801	PL.51802	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	1.05	1	7	2	96	0.00	0.0	9.563	0.053	0	0	0	2
PL.47876	PL.51801	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.00	0	0	0	100	0.00	0.0	9.681	0.118	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.45993	PL.51801	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	1.00	1	7	2	96	0.00	0.0	9.655	0.092	7	2	1	1
PL.46926	PL.51801	A	#2 ACSR	7.33Y	122.2	0.00	2.84	0.04	0	0	0	100	0.00	0.0	9.645	0.083	0	0	1	1
PL.46795	PL.51801	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.00	0	0	0	100	0.00	0.0	9.612	0.049	0	0	0	0
PL.51803	PL.51748	A	6 A (CWC)	7.32Y	122.0	0.19	3.02	38.13	27	268	80	96	0.38	0.1	9.562	0.109	4	1	1	43
PL.51804	PL.51803	A	6 A (CWC)	7.31Y	121.9	0.12	3.15	37.54	27	263	78	96	0.24	0.1	9.635	0.073	13	4	4	42
PL.64148	PL.51804	A	6 A (CWC)	7.30Y	121.7	0.11	3.26	35.69	25	250	74	96	0.21	0.1	9.704	0.068	0	0	0	38
PL.64199	PL.64148	A	6 A (CWC)	7.30Y	121.7	0.03	3.29	32.92	24	230	69	96	0.05	0.0	9.723	0.019	7	2	3	34
PL.64200	PL.64199	A	6 A (CWC)	7.30Y	121.6	0.10	3.39	25.19	18	176	52	96	0.13	0.1	9.818	0.095	24	7	3	26
PL.64209	PL.64200	A	6 A (CWC)	7.29Y	121.6	0.04	3.43	21.70	16	152	45	96	0.04	0.0	9.862	0.044	20	6	1	23
PL.64182	PL.64209	A	6 A (CWC)	7.29Y	121.5	0.08	3.51	18.11	13	127	38	96	0.07	0.1	9.955	0.093	0	0	1	21
PL.64183	PL.64182	A	#4 ACSR	7.29Y	121.5	0.02	3.53	6.19	5	43	13	96	0.01	0.0	10.042	0.087	0	0	0	6
PL.64150	PL.64183	A	#4 ACSR	7.29Y	121.4	0.03	3.56	6.19	5	43	13	96	0.01	0.0	10.153	0.111	0	0	0	6
PL.47706	PL.64150	A	#4 ACSR	7.29Y	121.4	0.00	3.56	0.87	1	6	2	95	0.00	0.0	10.215	0.062	6	2	1	1
PL.47922	PL.64150	A	#4 ACSR	7.28Y	121.4	0.03	3.60	5.32	4	37	11	96	0.01	0.0	10.296	0.144	0	0	0	5
PL.47723	PL.47922	A	#2 ACSR	7.28Y	121.4	0.00	3.60	1.31	1	9	3	95	0.00	0.0	10.356	0.060	9	3	1	1
PL.47539	PL.47922	A	#1/0 ACSR	7.28Y	121.4	0.00	3.60	1.54	1	11	3	96	0.00	0.0	10.367	0.071	11	3	1	1
PL.58955	PL.47922	A	#4 ACSR	7.28Y	121.4	0.01	3.61	2.46	2	17	5	96	0.00	0.0	10.406	0.110	10	3	1	2
PL.58956	PL.58955	A	#4 ACSR	7.28Y	121.4	0.00	3.61	1.01	1	7	2	96	0.00	0.0	10.466	0.060	7	2	1	1
PL.47923	PL.47922	A	#4 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	10.362	0.066	0	0	1	1
PL.60157	PL.47923	A	#4 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	10.454	0.092	0	0	0	0
PL.60158	PL.60157	A	#4 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	10.556	0.103	0	0	0	0
PL.47212	PL.47923	A	#2 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	10.467	0.105	0	0	0	0
PL.64184	PL.64182	A	6 A (CWC)	7.29Y	121.4	0.05	3.55	11.87	8	83	25	96	0.03	0.0	10.042	0.087	6	2	1	14
PL.64211	PL.64184	A	6 A (CWC)	7.29Y	121.4	0.01	3.57	10.99	8	77	23	96	0.01	0.0	10.066	0.024	9	3	2	13
PL.64212	PL.64211	A	6 A (CWC)	7.28Y	121.4	0.04	3.60	9.71	7	68	20	96	0.02	0.0	10.157	0.091	9	3	1	11
PL.64268	PL.64212	A	6 A (CWC)	7.28Y	121.4	0.04	3.65	6.04	4	42	13	96	0.01	0.0	10.316	0.159	0	0	0	7
PL.63674	PL.64268	A	6 A (CWC)	7.28Y	121.3	0.03	3.68	6.04	4	42	13	96	0.01	0.0	10.439	0.123	0	0	1	7
PL.48409	PL.63674	A	6 A (CWC)	7.28Y	121.3	0.01	3.70	6.04	4	42	13	96	0.00	0.0	10.492	0.053	0	0	0	6
PL.48410	PL.48409	A	#4 ACSR	7.28Y	121.3	0.01	3.71	1.74	1	12	4	95	0.00	0.0	10.640	0.148	0	0	0	2
PL.47215	PL.48410	A	#4 ACSR	7.28Y	121.3	0.00	3.71	0.99	1	7	2	96	0.00	0.0	10.696	0.056	7	2	1	1
PL.48411	PL.48410	A	#4 ACSR	7.28Y	121.3	0.01	3.71	0.75	1	5	2	93	0.00	0.0	10.994	0.354	5	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.48412	PL.48409	A	6 A (CWC)	7.28Y	121.3	0.02	3.71	4.30	3	30	9	96	0.00	0.0	10.585	0.093	0	0	1	4
PL.48413	PL.48412	A	6 A (CWC)	7.28Y	121.3	0.02	3.73	4.30	3	30	9	96	0.00	0.0	10.661	0.076	0	0	0	3
PL.47728	PL.48413	A	6 A (CWC)	7.28Y	121.3	0.01	3.73	2.74	2	19	6	95	0.00	0.0	10.743	0.082	19	6	1	1
PL.48414	PL.48413	A	6 A (CWC)	7.27Y	121.2	0.03	3.76	1.07	1	7	2	96	0.00	0.0	11.707	1.046	7	2	1	1
PL.47546	PL.48413	A	6 A (CWC)	7.28Y	121.3	0.00	3.73	0.49	0	3	1	95	0.00	0.0	10.716	0.055	3	1	1	1
PL.64151	PL.64268	A	#1/0 ACSR	7.28Y	121.4	0.00	3.65	0.00	0	0	0	100	0.00	0.0	10.509	0.193	0	0	0	0
PL.64269	PL.64212	A	#2 ACSR	7.28Y	121.4	0.00	3.61	2.45	1	17	5	96	0.00	0.0	10.225	0.068	16	5	2	3
PL.64190	PL.64269	A	#2 ACSR	7.28Y	121.4	0.00	3.61	0.13	0	1	0	100	0.00	0.0	10.315	0.090	1	0	1	1
PL.64201	PL.64209	A	6 A (CWC)	7.29Y	121.6	0.00	3.43	0.69	0	5	1	98	0.00	0.0	9.903	0.041	5	1	1	1
PL.64176	PL.64199	A	6 A (CWC)	7.30Y	121.7	0.00	3.29	6.66	5	47	14	96	0.00	0.0	9.738	0.016	18	5	1	5
PL.64177	PL.64176	A	6 A (CWC)	7.30Y	121.7	0.00	3.29	4.10	3	29	9	96	0.00	0.0	9.757	0.019	10	3	1	4
PL.64175	PL.64177	A	6 A (CWC)	7.30Y	121.7	0.01	3.30	1.78	1	12	4	95	0.00	0.0	9.888	0.131	12	4	1	1
PL.64189	PL.64177	A	#1/0 ACSR	7.30Y	121.7	0.00	3.29	0.86	0	6	2	95	0.00	0.0	9.809	0.052	0	0	0	2
PD.9512	PL.64189	A	20T	7.30Y	121.7	0.00	3.29	0.86	0	6	2	95	0.00	0.0	9.809	0.052	0	0	0	2
PL.64280	PD.9512	A	#1/0 ACSR	7.30Y	121.7	0.00	3.30	0.86	0	6	2	95	0.00	0.0	9.983	0.174	0	0	1	2
PL.64279	PL.64280	A	#1/0 ACSR	7.30Y	121.7	0.00	3.30	0.85	0	6	2	95	0.00	0.0	10.021	0.038	6	2	1	1
PL.64149	PL.64148	A	#4 ACSR	7.30Y	121.7	0.01	3.26	2.78	2	19	6	95	0.00	0.0	9.770	0.066	15	4	3	4
PL.47877	PL.64149	A	#4 ACSR	7.30Y	121.7	0.00	3.26	0.63	0	4	1	97	0.00	0.0	9.828	0.059	4	1	1	1
PL.51799	PL.62859	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	9.390	0.033	0	0	0	0
PL.47491	PL.47490	C	#4 ACSR	7.36Y	122.7	0.00	2.32	1.59	1	11	3	96	0.00	0.0	8.655	0.003	0	0	0	1
PD.7419	PL.47491	C	40QA	7.36Y	122.7	0.00	2.32	1.59	4	11	3	96	0.00	0.0	8.655	0.003	0	0	0	1
PL.47492	PD.7419	C	#4 ACSR	7.36Y	122.7	0.00	2.33	1.59	1	11	3	96	0.00	0.0	8.712	0.057	0	0	0	1
PL.48254	PL.47492	C	#4 ACSR	7.36Y	122.7	0.00	2.33	1.59	1	11	3	96	0.00	0.0	8.749	0.037	11	3	1	1
PL.62983	PL.47849	C	#2 ACSR	7.37Y	122.9	0.00	2.10	3.69	2	26	8	96	0.00	0.0	8.102	0.007	0	0	0	3
PD.9422	PL.62983	C	40QA	7.37Y	122.9	0.00	2.10	3.69	9	26	8	96	0.00	0.0	8.102	0.007	0	0	0	3
PL.62984	PD.9422	C	#2 ACSR	7.37Y	122.9	0.00	2.11	3.69	2	26	8	96	0.00	0.0	8.140	0.038	19	6	2	3
PL.47397	PL.62984	C	#2 ACSR	7.37Y	122.9	0.00	2.11	0.99	1	7	2	96	0.00	0.0	8.272	0.132	0	0	0	1
PL.47398	PL.47397	C	#2 ACSR	7.37Y	122.9	0.00	2.11	0.99	1	7	2	96	0.00	0.0	8.284	0.012	0	0	0	1
PL.47396	PL.47398	C	#2 ACSR	7.37Y	122.9	0.00	2.11	0.99	1	7	2	96	0.00	0.0	8.425	0.141	7	2	1	1
PL.57924	PL.47842	C	#1/0 ACSR	7.38Y	123.0	0.00	2.01	0.88	0	6	2	95	0.00	0.0	7.911	0.004	0	0	0	1
PD.8394	PL.57924	C	15T	7.38Y	123.0	0.00	2.01	0.88	0	6	2	95	0.00	0.0	7.911	0.004	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.57925	PD.8394	C	#1/0 ACSR	7.38Y	123.0	0.00	2.01	0.88	0	6	2	95	0.00	0.0	7.954	0.043	6	2	1	1
PL.47844	PL.47842	C	#2 ACSR	7.38Y	123.0	0.00	2.01	2.25	1	16	5	95	0.00	0.0	7.910	0.003	0	0	0	1
PD.7177	PL.47844	C	40QA	7.38Y	123.0	0.00	2.01	2.25	6	16	5	95	0.00	0.0	7.910	0.003	0	0	0	1
PL.47845	PD.7177	C	#2 ACSR	7.38Y	123.0	0.00	2.02	2.25	1	16	5	95	0.00	0.0	7.988	0.078	16	5	1	1
PL.47828	PL.47750	C	#2 ACSR	7.40Y	123.3	0.00	1.66	1.98	1	14	4	96	0.00	0.0	7.252	0.001	0	0	0	2
PD.7377	PL.47828	C	40QA	7.40Y	123.3	0.00	1.66	1.98	5	14	4	96	0.00	0.0	7.252	0.001	0	0	0	2
PL.47829	PD.7377	C	#2 ACSR	7.40Y	123.3	0.00	1.66	1.98	1	14	4	96	0.00	0.0	7.271	0.019	14	4	2	2
PL.47826	PL.47750	A	#4 ACSR	7.40Y	123.3	0.00	1.66	1.22	1	9	3	95	0.00	0.0	7.252	0.001	0	0	0	1
PD.7175	PL.47826	A	40QA	7.40Y	123.3	0.00	1.66	1.22	3	9	3	95	0.00	0.0	7.252	0.001	0	0	0	1
PL.47827	PD.7175	A	#4 ACSR	7.40Y	123.3	0.00	1.66	1.22	1	9	3	95	0.00	0.0	7.318	0.066	9	3	1	1
PL.64210	PL.64270	A	#4 ACSR	7.41Y	123.5	0.00	1.46	1.38	1	10	3	96	0.00	0.0	6.963	0.044	10	3	1	1
PL.61968	PL.48341	A	#2 ACSR	7.42Y	123.6	0.00	1.36	1.61	1	11	3	96	0.00	0.0	6.786	0.018	11	3	1	1
PL.47428	PL.48340	A	#4 ACSR	7.43Y	123.8	0.00	1.23	1.88	1	13	4	96	0.00	0.0	6.627	0.042	13	4	2	2
PL.47496	PL.64262	A	#4 ACSR	7.43Y	123.9	0.00	1.10	0.00	0	0	0	100	0.00	0.0	6.413	0.001	0	0	0	0
PD.7173	PL.47496	A	40QA	7.43Y	123.9	0.00	1.10	0.00	0	0	0	100	0.00	0.0	6.413	0.001	0	0	0	0
PL.47497	PD.7173	A	#4 ACSR	7.43Y	123.9	0.00	1.10	0.00	0	0	0	100	0.00	0.0	6.446	0.033	0	0	0	0
PL.57391	PL.48336	B	#1/0 ACSR	7.12Y	118.7	0.05	6.30	52.47	23	358	108	96	0.13	0.0	6.078	0.043	1	0	1	57
PL.57392	PL.57391	B	#4 ACSR	7.12Y	118.7	0.00	6.30	52.28	40	357	107	96	0.00	0.0	6.079	0.001	0	0	0	56
PD.7557	PL.57392	B	70L	7.12Y	118.7	0.00	6.30	52.28	75	357	107	96	0.00	0.0	6.079	0.001	0	0	0	56
PL.48415	PD.7557	B	#4 ACSR	7.11Y	118.6	0.14	6.44	52.28	40	357	107	96	0.40	0.1	6.139	0.061	0	0	0	56
PL.48465	PL.48415	B	#4 ACSR	7.11Y	118.5	0.02	6.46	4.72	4	32	10	95	0.00	0.0	6.228	0.089	0	0	0	7
PL.47404	PL.48465	B	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.00	0	0	0	100	0.00	0.0	6.419	0.191	0	0	0	0
PL.48466	PL.48465	B	#4 ACSR	7.11Y	118.5	0.03	6.49	4.72	4	32	10	95	0.01	0.0	6.358	0.130	2	0	1	7
PL.48468	PL.48466	B	#4 ACSR	7.11Y	118.5	0.00	6.49	0.15	0	1	0	100	0.00	0.0	6.389	0.031	0	0	0	1
PL.48469	PL.48468	B	#4 ACSR	7.11Y	118.5	0.00	6.49	0.15	0	1	0	100	0.00	0.0	6.450	0.061	1	0	1	1
PL.48467	PL.48466	B	#4 ACSR	7.11Y	118.5	0.01	6.50	4.33	3	30	9	96	0.00	0.0	6.419	0.061	0	0	0	5
PL.48470	PL.48467	B	#4 ACSR	7.11Y	118.5	0.00	6.50	4.33	3	30	9	96	0.00	0.0	6.419	0.001	2	0	1	5
PL.48471	PL.48470	B	#4 ACSR	7.11Y	118.5	0.01	6.51	4.11	3	28	8	96	0.00	0.0	6.490	0.071	8	2	2	4
PL.48472	PL.48471	B	#4 ACSR	7.11Y	118.5	0.00	6.51	2.89	2	20	6	96	0.00	0.0	6.543	0.054	20	6	2	2
PL.48473	PL.48415	B	#4 ACSR	7.11Y	118.5	0.08	6.52	47.56	37	324	97	96	0.21	0.1	6.178	0.039	5	1	1	49
PL.48474	PL.48473	B	#4 ACSR	7.10Y	118.4	0.09	6.61	46.83	36	319	96	96	0.22	0.1	6.220	0.042	0	0	0	48

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58957	PL.48474	B	#4 ACSR	7.10Y	118.4	0.00	6.62	1.87	1	13	4	96	0.00	0.0	6.332	0.112	13	4	2	2
PL.48475	PL.48474	B	#4 ACSR	7.09Y	118.2	0.16	6.77	44.96	35	306	92	96	0.38	0.1	6.298	0.078	0	0	0	46
PL.58978	PL.48475	B	#4 ACSR	7.08Y	118.0	0.23	7.00	44.96	35	305	92	96	0.55	0.2	6.411	0.113	0	0	1	46
L PL.58979	PL.58978	B	#4 ACSR	7.07Y	117.9	0.11	7.11	44.96	35	305	91	96	0.26	0.1	6.465	0.054	0	0	1	45 L
L PL.48476	PL.58979	B	#4 ACSR	7.06Y	117.6	0.27	7.37	44.94	35	305	91	96	0.64	0.2	6.600	0.135	8	2	1	44 L
L PL.48481	PL.48476	B	#4 ACSR	7.05Y	117.6	0.05	7.42	35.99	28	243	73	96	0.10	0.0	6.632	0.032	0	0	0	38 L
L PL.47365	PL.48481	B	#4 ACSR	7.05Y	117.6	0.00	7.42	0.01	0	0	0	100	0.00	0.0	6.676	0.044	0	0	1	1 L
L PL.48482	PL.48481	B	#4 ACSR	7.05Y	117.5	0.12	7.55	35.99	28	243	73	96	0.24	0.1	6.708	0.077	0	0	1	37 L
L PL.57644	PL.48482	B	#4 ACSR	7.04Y	117.3	0.13	7.68	34.73	27	234	70	96	0.24	0.1	6.792	0.083	5	1	1	34 L
L PL.57645	PL.57644	B	#4 ACSR	7.03Y	117.2	0.10	7.78	30.82	24	208	62	96	0.17	0.1	6.869	0.078	11	3	1	32 L
L PL.57646	PL.57645	B	#4 ACSR	7.02Y	117.0	0.17	7.96	29.18	22	197	59	96	0.27	0.1	7.006	0.137	9	3	2	31 L
L PL.48483	PL.57646	B	#4 ACSR	7.01Y	116.8	0.20	8.15	27.83	21	187	56	96	0.29	0.2	7.164	0.158	0	0	0	29 L
L PL.47757	PL.48483	B	#4 ACSR	7.01Y	116.8	0.00	8.15	1.15	1	8	2	97	0.00	0.0	7.219	0.055	8	2	1	1 L
L PL.48484	PL.48483	B	#4 ACSR	7.00Y	116.6	0.23	8.38	26.69	21	179	54	96	0.32	0.2	7.353	0.189	1	0	1	28 L
L PL.48485	PL.48484	B	#4 ACSR	6.99Y	116.6	0.06	8.44	26.56	20	178	53	96	0.09	0.0	7.405	0.052	5	2	1	27 L
L PL.48486	PL.48485	B	#4 ACSR	6.99Y	116.5	0.04	8.48	25.79	20	173	51	96	0.05	0.0	7.438	0.033	0	0	0	26 L
L PL.48489	PL.48486	B	#4 ACSR	6.98Y	116.4	0.12	8.60	24.48	19	164	49	96	0.16	0.1	7.549	0.111	4	1	1	23 L
L PL.48490	PL.48489	B	#4 ACSR	6.98Y	116.3	0.14	8.74	23.85	18	160	48	96	0.18	0.1	7.683	0.134	7	2	2	22 L
L PL.48543	PL.48490	B	#4 ACSR	6.98Y	116.3	0.01	8.74	6.85	5	46	14	96	0.00	0.0	7.709	0.026	2	1	1	6 L
L PL.48544	PL.48543	B	#4 ACSR	6.97Y	116.2	0.01	8.76	6.48	5	43	13	96	0.00	0.0	7.755	0.046	0	0	0	5 L
L PL.47322	PL.48544	B	#4 ACSR	6.97Y	116.2	0.00	8.76	2.03	2	14	4	96	0.00	0.0	7.834	0.079	14	4	1	1 L
L PL.48545	PL.48544	B	#4 ACSR	6.97Y	116.2	0.01	8.77	4.44	3	30	9	96	0.00	0.0	7.837	0.083	14	4	2	4 L
L PL.48546	PL.48545	B	#4 ACSR	6.97Y	116.2	0.01	8.78	2.36	2	16	5	95	0.00	0.0	7.908	0.071	6	2	1	2 L
L PL.48547	PL.48546	B	#4 ACSR	6.97Y	116.2	0.01	8.78	1.53	1	10	3	96	0.00	0.0	7.987	0.079	0	0	0	1 L
L PL.46924	PL.48547	B	#2 ACSR	6.97Y	116.2	0.00	8.78	0.00	0	0	0	100	0.00	0.0	8.079	0.092	0	0	0	0 L
L PL.48548	PL.48547	B	#4 ACSR	6.97Y	116.2	0.00	8.78	1.53	1	10	3	96	0.00	0.0	8.062	0.075	10	3	1	1 L
L PL.46736	PL.48547	B	#4 ACSR	6.97Y	116.2	0.00	8.78	0.00	0	0	0	100	0.00	0.0	8.056	0.069	0	0	0	0 L
L PL.46799	PL.48490	B	#4 ACSR	6.97Y	116.2	0.07	8.80	16.01	12	107	32	96	0.05	0.1	7.782	0.099	13	4	1	14 L
L PL.46800	PL.46799	B	#4 ACSR	6.96Y	116.0	0.18	8.98	14.03	11	94	28	96	0.13	0.1	8.093	0.311	17	5	2	13 L
L PL.47640	PL.46800	B	#4 ACSR	6.96Y	116.0	0.00	8.98	0.53	0	4	1	97	0.00	0.0	8.158	0.065	4	1	1	1 L
L PL.46801	PL.46800	B	#4 ACSR	6.96Y	116.0	0.01	8.99	10.98	8	73	22	96	0.01	0.0	8.112	0.020	0	0	0	10 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.62986	PL.46801	B	#4 ACSR	6.96Y	116.0	0.00	8.99	10.98	8	73	22	96	0.00	0.0	8.120	0.008	0	0	0	10 L
L PL.62987	PL.62986	B	#4 ACSR	6.96Y	116.0	0.04	9.03	10.98	8	73	22	96	0.02	0.0	8.197	0.077	0	0	0	10 L
L PL.57700	PL.62987	B	#4 ACSR	6.96Y	116.0	0.00	9.03	1.12	1	7	2	96	0.00	0.0	8.255	0.058	7	2	3	3 L
L PL.46948	PL.62987	B	#4 ACSR	6.95Y	115.9	0.05	9.08	8.80	7	59	17	96	0.02	0.0	8.329	0.132	0	0	0	6 L
L PL.47705	PL.46948	B	#2 ACSR	6.95Y	115.9	0.01	9.10	3.61	2	24	7	96	0.00	0.0	8.440	0.110	0	0	0	3 L
L PL.47362	PL.47705	B	#2 ACSR	6.95Y	115.9	0.00	9.10	0.79	0	5	2	93	0.00	0.0	8.471	0.031	5	2	1	1 L
L PL.48549	PL.47705	B	#2 ACSR	6.95Y	115.9	0.01	9.10	2.82	2	19	6	95	0.00	0.0	8.621	0.182	19	6	2	2 L
L PL.46949	PL.46948	B	#4 ACSR	6.95Y	115.9	0.01	9.09	5.18	4	35	10	96	0.00	0.0	8.364	0.035	10	3	1	3 L
L PL.47704	PL.46949	B	#4 ACSR	6.95Y	115.9	0.02	9.11	3.69	3	25	7	96	0.00	0.0	8.622	0.258	25	7	2	2 L
L PL.47653	PL.62987	B	#1/0 ACSR	6.96Y	116.0	0.00	9.03	1.07	0	7	2	96	0.00	0.0	8.224	0.027	7	2	1	1 L
L PL.62988	PL.62986	B	#2 ACSR	6.96Y	116.0	0.00	8.99	0.00	0	0	0	100	0.00	0.0	8.230	0.109	0	0	0	0 L
L PL.62989	PL.62988	B	#2 ACSR	6.96Y	116.0	0.00	8.99	0.00	0	0	0	100	0.00	0.0	8.350	0.120	0	0	0	0 L
L PL.48487	PL.48486	B	#4 ACSR	6.99Y	116.5	0.01	8.48	1.31	1	9	3	95	0.00	0.0	7.539	0.101	0	0	1	3 L
L PL.48488	PL.48487	B	#4 ACSR	6.99Y	116.5	0.00	8.49	1.30	1	9	3	95	0.00	0.0	7.604	0.065	2	1	1	2 L
L PL.48491	PL.48488	B	#4 ACSR	6.99Y	116.5	0.01	8.49	1.03	1	7	2	96	0.00	0.0	7.801	0.197	0	0	0	1 L
L PL.47363	PL.48491	B	#2 ACSR	6.99Y	116.5	0.00	8.50	1.03	1	7	2	96	0.00	0.0	7.895	0.094	7	2	1	1 L
L PL.48492	PL.48491	B	#4 ACSR	6.99Y	116.5	0.00	8.49	0.00	0	0	0	100	0.00	0.0	7.875	0.074	0	0	0	0 L
L PL.48542	PL.48492	B	#4 ACSR	6.99Y	116.5	0.00	8.49	0.00	0	0	0	100	0.00	0.0	8.055	0.180	0	0	0	0 L
L PL.57647	PL.57644	B	#1/0 ACSR	7.04Y	117.3	0.00	7.68	3.21	1	22	6	96	0.00	0.0	6.822	0.031	0	0	0	1 L
L PL.61388	PL.57647	B	#1/0 ACSR	7.04Y	117.3	0.00	7.68	3.21	1	22	6	96	0.00	0.0	6.860	0.037	22	6	1	1 L
L PL.47321	PL.48482	B	#4 ACSR	7.05Y	117.5	0.00	7.55	1.23	1	8	2	97	0.00	0.0	6.748	0.039	8	2	2	2 L
L PL.48477	PL.48476	B	#4 ACSR	7.06Y	117.6	0.00	7.38	7.73	6	52	16	96	0.00	0.0	6.612	0.011	0	0	0	5 L
L PL.48478	PL.48477	B	#4 ACSR	7.06Y	117.6	0.02	7.39	7.73	6	52	16	96	0.01	0.0	6.659	0.048	6	2	1	5 L
L PL.48479	PL.48478	B	#4 ACSR	7.06Y	117.6	0.01	7.41	6.81	5	46	14	96	0.00	0.0	6.729	0.070	37	11	3	4 L
L PL.48480	PL.48479	B	#4 ACSR	7.06Y	117.6	0.00	7.41	1.37	1	9	3	95	0.00	0.0	6.812	0.084	9	3	1	1 L
PL.47418	PL.48475	B	#4 ACSR	7.09Y	118.2	0.00	6.77	0.00	0	0	0	100	0.00	0.0	6.405	0.107	0	0	0	0
PL.57389	PL.57390	ABC	#3/0 ACSR	7.18Y	119.7	0.01	5.35	16.56	6	341	103	96	0.01	0.0	5.285	0.029	0	0	0	58
PL.47162	PL.57389	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.35	2.64	1	54	16	96	0.00	0.0	5.318	0.033	1	0	1	9
PL.47213	PL.47162	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.35	2.59	1	54	16	96	0.00	0.0	5.471	0.153	10	3	1	8
PL.57848	PL.47213	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.36	2.12	1	44	13	96	0.00	0.0	5.547	0.077	15	5	3	7
PL.57849	PL.57848	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.36	1.37	0	28	8	96	0.00	0.0	5.771	0.224	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48137	PL.57849	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.36	0.72	0	15	4	97	0.00	0.0	5.876	0.105	15	4	1	2
PL.57720	PL.48137	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.36	0.01	0	0	0	100	0.00	0.0	5.933	0.057	0	0	1	1
PL.62524	PL.57720	ABC	#3/0 ACSR	7.18Y	119.6	0.00	5.36	0.00	0	0	0	100	0.00	0.0	5.985	0.051	0	0	0	0
PD.9379-B	PL.62524	ABC	Open	7.18Y	119.6	0.00	5.36	0.00	0	0	0	100	0.00	0.0	5.985	0.051	0	0	0	0
PL.57659	PL.57849	A	#1/0 ACSR	7.18Y	119.6	0.00	5.36	1.94	1	13	4	96	0.00	0.0	5.813	0.041	0	0	0	2
PL.57660	PL.57659	A	#1/0 ACSR	7.18Y	119.6	0.00	5.36	1.94	1	13	4	96	0.00	0.0	5.836	0.023	13	4	2	2
PL.47303	PL.57389	C	#1/0 ACSR	7.18Y	119.6	0.00	5.35	41.77	18	287	87	96	0.01	0.0	5.289	0.003	0	0	0	49
PD.7559	PL.47303	C	100L	7.18Y	119.6	0.00	5.35	41.77	42	287	87	96	0.00	0.0	5.289	0.003	0	0	0	49
PL.57990	PD.7559	C	#1/0 ACSR	7.16Y	119.4	0.29	5.65	41.77	18	287	87	96	0.56	0.2	5.587	0.299	0	0	0	49
PL.57992	PL.57990	C	1/0 AL URD	7.16Y	119.4	0.00	5.65	0.82	0	6	1	99	0.00	0.0	5.648	0.061	6	2	1	1
PL.57991	PL.57990	C	#1/0 ACSR	7.15Y	119.2	0.11	5.76	40.95	18	281	85	96	0.21	0.1	5.704	0.116	2	1	1	48
PL.47415	PL.57991	C	#1/0 ACSR	7.15Y	119.1	0.10	5.86	40.62	18	278	84	96	0.19	0.1	5.809	0.105	0	0	0	47
PL.47416	PL.47415	C	#1/0 ACSR	7.15Y	119.1	0.05	5.91	40.62	18	278	84	96	0.09	0.0	5.861	0.052	0	0	0	47
PL.48333	PL.47416	C	#1/0 ACSR	7.14Y	119.1	0.03	5.94	35.80	16	245	74	96	0.06	0.0	5.901	0.040	0	0	0	43
PL.58667	PL.48333	C	#1/0 ACSR	7.14Y	118.9	0.13	6.07	35.80	16	245	74	96	0.22	0.1	6.057	0.156	0	0	0	43
PL.58666	PL.58667	C	#1/0 ACSR	7.14Y	118.9	0.00	6.08	1.67	1	11	3	96	0.00	0.0	6.113	0.056	11	3	1	1
PL.58668	PL.58667	C	#1/0 ACSR	7.13Y	118.8	0.14	6.22	34.14	15	233	70	96	0.22	0.1	6.234	0.177	0	0	0	42
PL.47913	PL.58668	C	#1/0 ACSR	7.12Y	118.7	0.04	6.25	32.62	14	223	67	96	0.05	0.0	6.281	0.047	2	1	1	41
PL.47914	PL.47913	C	#1/0 ACSR	7.12Y	118.7	0.04	6.29	32.35	14	221	66	96	0.06	0.0	6.338	0.057	15	4	1	40
PL.47915	PL.47914	C	#1/0 ACSR	7.11Y	118.6	0.14	6.43	30.18	13	206	62	96	0.19	0.1	6.534	0.195	0	0	1	39
PL.64592	PL.47915	C	#1/0 ACSR	7.11Y	118.5	0.05	6.48	30.18	13	206	61	96	0.06	0.0	6.600	0.067	9	3	1	38
PL.64593	PL.64592	C	#1/0 ACSR	7.11Y	118.5	0.00	6.48	28.88	13	197	59	96	0.00	0.0	6.600	0.000	0	0	0	37
PL.64591	PL.64593	C	#1/0 ACSR	7.11Y	118.5	0.04	6.52	28.88	13	197	59	96	0.05	0.0	6.655	0.055	0	0	0	37
PL.57787	PL.64591	C	#1/0 ACSR	7.11Y	118.5	0.03	6.54	24.11	10	164	49	96	0.03	0.0	6.702	0.046	4	1	1	31
PL.57788	PL.57787	C	#1/0 ACSR	7.11Y	118.4	0.02	6.56	23.48	10	160	48	96	0.02	0.0	6.736	0.034	0	0	0	30
PL.47176	PL.57788	C	#4 ACSR	7.11Y	118.4	0.00	6.56	0.48	0	3	1	95	0.00	0.0	6.756	0.021	3	1	3	3
PL.52293	PL.57788	C	#1/0 ACSR	7.10Y	118.4	0.04	6.60	23.01	10	157	47	96	0.04	0.0	6.817	0.081	13	4	1	27
PL.52129	PL.52293	C	#1/0 ACSR	7.10Y	118.3	0.08	6.68	19.35	8	132	39	96	0.07	0.1	6.985	0.169	0	0	0	25
PL.52131	PL.52129	C	#1/0 ACSR	7.10Y	118.3	0.00	6.68	4.17	2	28	8	96	0.00	0.0	6.986	0.001	0	0	0	7
PD.8017	PL.52131	C	40QA	7.10Y	118.3	0.00	6.68	4.17	10	28	8	96	0.00	0.0	6.986	0.001	0	0	0	7
PL.52133	PD.8017	C	#1/0 ACSR	7.10Y	118.3	0.00	6.68	4.17	2	28	8	96	0.00	0.0	7.019	0.033	0	0	0	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.64594	PL.52133	C	#1/0 ACSR	7.10Y	118.3	0.01	6.70	4.17	2	28	8	96	0.00	0.0	7.159	0.139	0	0	0	7
PL.64595	PL.64594	C	#2 ACSR	7.10Y	118.3	0.00	6.70	1.57	1	11	3	96	0.00	0.0	7.240	0.081	11	3	1	1
PL.64596	PL.64594	C	#1/0 ACSR	7.10Y	118.3	0.01	6.71	2.61	1	18	5	96	0.00	0.0	7.398	0.240	3	1	2	6
PL.52136	PL.64596	C	#1/0 ACSR	7.10Y	118.3	0.00	6.71	2.23	1	15	5	95	0.00	0.0	7.475	0.077	3	1	1	4
PL.52134	PL.52136	C	6 A (CWC)	7.10Y	118.3	0.00	6.71	0.01	0	0	0	100	0.00	0.0	7.638	0.163	0	0	1	1
PL.52137	PL.52136	C	#1/0 ACSR	7.10Y	118.3	0.01	6.72	1.80	1	12	4	95	0.00	0.0	7.738	0.263	0	0	0	2
PL.52135	PL.52137	C	6 A (CWC)	7.10Y	118.3	0.00	6.73	1.09	1	7	2	96	0.00	0.0	7.858	0.120	7	2	1	1
PL.52138	PL.52137	C	#1/0 ACSR	7.10Y	118.3	0.00	6.73	0.72	0	5	1	98	0.00	0.0	7.772	0.034	5	1	1	1
PL.52130	PL.52129	C	6 A (CWC)	7.10Y	118.3	0.00	6.68	0.00	0	0	0	100	0.00	0.0	7.324	0.339	0	0	0	0
PL.48644	PL.52130	C	6 A (CWC)	7.10Y	118.3	0.00	6.68	0.00	0	0	0	100	0.00	0.0	7.498	0.173	0	0	0	0
PL.48645	PL.48644	C	6 A (CWC)	7.10Y	118.3	0.00	6.68	0.00	0	0	0	100	0.00	0.0	7.727	0.229	0	0	0	0
PL.47701	PL.48644	C	6 A (CWC)	7.10Y	118.3	0.00	6.68	0.00	0	0	0	100	0.00	0.0	7.572	0.075	0	0	0	0
PL.52132	PL.52129	C	6 A (CWC)	7.10Y	118.3	0.00	6.68	1.25	1	9	3	95	0.00	0.0	7.012	0.027	9	3	1	1
PL.55965	PL.52129	C	#1/0 ACSR	7.10Y	118.3	0.05	6.73	13.92	6	95	28	96	0.03	0.0	7.152	0.167	5	2	2	17
PL.55966	PL.55965	C	#1/0 ACSR	7.09Y	118.2	0.06	6.79	13.18	6	90	27	96	0.03	0.0	7.331	0.179	0	0	0	15
PL.47504	PL.55966	C	#1/0 ACSR	7.09Y	118.2	0.00	6.79	0.77	0	5	2	93	0.00	0.0	7.356	0.025	0	0	1	2
PL.47505	PL.47504	C	#1/0 ACSR	7.09Y	118.2	0.00	6.79	0.77	0	5	2	93	0.00	0.0	7.423	0.066	5	2	1	1
PL.47500	PL.55966	C	#1/0 ACSR	7.09Y	118.2	0.01	6.80	9.64	4	66	19	96	0.01	0.0	7.388	0.057	0	0	0	10
PL.47506	PL.47500	C	6 A (CWC)	7.09Y	118.2	0.00	6.80	1.80	1	12	4	95	0.00	0.0	7.473	0.085	12	4	1	1
PL.47507	PL.47506	C	6 A (CWC)	7.09Y	118.2	0.00	6.80	0.00	0	0	0	100	0.00	0.0	7.596	0.123	0	0	0	0
PL.47501	PL.47500	C	#1/0 ACSR	7.09Y	118.2	0.01	6.81	7.83	3	53	16	96	0.00	0.0	7.450	0.063	0	0	0	9
PL.47519	PL.47501	C	#1/0 ACSR	7.09Y	118.2	0.00	6.81	0.65	0	4	1	97	0.00	0.0	7.475	0.024	4	1	1	1
PL.47508	PL.47501	C	#1/0 ACSR	7.09Y	118.2	0.02	6.83	7.18	3	49	15	96	0.01	0.0	7.553	0.102	0	0	0	8
PL.47509	PL.47508	C	#1/0 ACSR	7.09Y	118.1	0.03	6.86	6.77	3	46	14	96	0.01	0.0	7.763	0.210	0	0	0	7
PL.62585	PL.47509	C	#1/0 ACSR	7.09Y	118.1	0.00	6.86	0.00	0	0	0	100	0.00	0.0	7.856	0.093	0	0	0	0
PD.9393-A	PL.62585	C	Open	7.09Y	118.1	0.00	6.86	0.00	0	0	0	100	0.00	0.0	7.856	0.093	0	0	0	0
PL.47510	PL.47509	C	6 A (CWC)	7.09Y	118.1	0.02	6.88	6.22	4	42	13	96	0.01	0.0	7.854	0.091	16	5	1	6
PL.48636	PL.47510	C	6 A (CWC)	7.09Y	118.1	0.02	6.91	3.84	3	26	8	96	0.00	0.0	7.980	0.125	0	0	0	5
PL.48637	PL.48636	C	6 A (CWC)	7.08Y	118.1	0.01	6.92	3.84	3	26	8	96	0.00	0.0	8.057	0.077	0	0	0	5
PL.48638	PL.48637	C	6 A (CWC)	7.08Y	118.1	0.00	6.92	1.19	1	8	2	97	0.00	0.0	8.098	0.042	0	0	0	1
PL.48639	PL.48638	C	6 A (CWC)	7.08Y	118.1	0.00	6.92	1.19	1	8	2	97	0.00	0.0	8.099	0.001	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48640	PL.48637	C	6 A (CWC)	7.08Y	118.1	0.01	6.93	2.65	2	18	5	96	0.00	0.0	8.271	0.214	16	5	2	4
PL.48641	PL.48640	C	6 A (CWC)	7.08Y	118.1	0.00	6.93	0.00	0	0	0	100	0.00	0.0	8.507	0.236	0	0	0	0
PL.48642	PL.48640	C	6 A (CWC)	7.08Y	118.1	0.00	6.94	0.25	0	2	1	89	0.00	0.0	8.394	0.123	1	0	1	2
PL.48643	PL.48642	C	6 A (CWC)	7.08Y	118.1	0.00	6.94	0.12	0	1	0	100	0.00	0.0	8.607	0.214	1	0	1	1
PL.47708	PL.47509	C	6 A (CWC)	7.09Y	118.1	0.00	6.86	0.55	0	4	1	97	0.00	0.0	7.851	0.089	4	1	1	1
PL.47695	PL.47508	C	#1/0 ACSR	7.09Y	118.2	0.00	6.83	0.41	0	3	1	95	0.00	0.0	7.583	0.030	3	1	1	1
PL.47502	PL.55966	C	#2 ACSR	7.09Y	118.2	0.00	6.79	2.77	2	19	6	95	0.00	0.0	7.382	0.051	7	2	2	3
PL.47503	PL.47502	C	#2 ACSR	7.09Y	118.2	0.00	6.79	1.80	1	12	4	95	0.00	0.0	7.424	0.042	12	4	1	1
PL.52292	PL.52293	C	#4 ACSR	7.10Y	118.4	0.00	6.61	1.79	1	12	4	95	0.00	0.0	6.896	0.079	12	4	1	1
PL.57786	PL.64591	C	#2 ACSR	7.11Y	118.5	0.02	6.54	4.77	3	33	10	96	0.00	0.0	6.784	0.128	0	0	0	6
PL.47916	PL.57786	C	#2 ACSR	7.11Y	118.4	0.02	6.56	3.94	2	27	8	96	0.00	0.0	6.971	0.187	4	1	1	5
PL.47917	PL.47916	C	#2 ACSR	7.11Y	118.4	0.00	6.56	3.42	2	23	7	96	0.00	0.0	7.028	0.057	23	7	4	4
PL.47448	PL.57786	C	#2 ACSR	7.11Y	118.5	0.00	6.54	0.83	0	6	2	95	0.00	0.0	6.904	0.120	6	2	1	1
PL.58669	PL.58668	C	#1/0 ACSR	7.13Y	118.8	0.00	6.22	1.52	1	10	3	96	0.00	0.0	6.253	0.019	10	3	1	1
PL.48334	PL.47416	C	#2 ACSR	7.15Y	119.1	0.01	5.91	3.47	2	24	7	96	0.00	0.0	5.933	0.072	12	3	1	3
PL.48335	PL.48334	C	#2 ACSR	7.15Y	119.1	0.00	5.92	1.78	1	12	4	95	0.00	0.0	6.003	0.070	12	4	2	2
PL.47707	PL.47416	C	#4 ACSR	7.15Y	119.1	0.00	5.91	1.36	1	9	3	95	0.00	0.0	6.024	0.163	9	3	1	1
PL.57388	PL.57390	A	6 A (CWC)	7.18Y	119.7	0.00	5.34	1.61	1	11	3	96	0.00	0.0	5.257	0.001	0	0	0	1
PD.7174	PL.57388	A	25QA	7.18Y	119.7	0.00	5.34	1.61	6	11	3	96	0.00	0.0	5.257	0.001	0	0	0	1
PL.47304	PD.7174	A	6 A (CWC)	7.18Y	119.7	0.00	5.35	1.61	1	11	3	96	0.00	0.0	5.369	0.112	11	3	1	1
PL.48551	PL.48554	A	#2 ACSR	7.19Y	119.8	0.00	5.22	1.50	1	10	3	96	0.00	0.0	5.060	0.001	0	0	0	1
PD.7538	PL.48551	A	40QA	7.19Y	119.8	0.00	5.22	1.50	4	10	3	96	0.00	0.0	5.060	0.001	0	0	0	1
PL.48552	PD.7538	A	#2 ACSR	7.19Y	119.8	0.00	5.22	1.50	1	10	3	96	0.00	0.0	5.146	0.086	10	3	1	1
PL.48559	PL.48556	A	#2 ACSR	7.19Y	119.9	0.00	5.10	1.18	1	8	2	97	0.00	0.0	4.868	0.001	0	0	0	1
PD.7421	PL.48559	A	40QA	7.19Y	119.9	0.00	5.10	1.18	3	8	2	97	0.00	0.0	4.868	0.001	0	0	0	1
PL.48560	PD.7421	A	#2 ACSR	7.19Y	119.9	0.00	5.10	1.18	1	8	2	97	0.00	0.0	4.893	0.025	8	2	1	1
PL.48557	PL.48556	A	#2 ACSR	7.19Y	119.9	0.00	5.10	0.03	0	0	0	100	0.00	0.0	4.868	0.001	0	0	0	1
PD.7372	PL.48557	A	40QA	7.19Y	119.9	0.00	5.10	0.03	0	0	0	100	0.00	0.0	4.868	0.001	0	0	0	1
PL.48558	PD.7372	A	#2 ACSR	7.19Y	119.9	0.00	5.10	0.03	0	0	0	100	0.00	0.0	4.918	0.049	0	0	1	1
PL.63676	PL.63677	C	#4 ACSR	7.20Y	120.1	0.00	4.94	0.78	1	5	2	93	0.00	0.0	4.623	0.001	0	0	0	3
PD.7518	PL.63676	C	40QA	7.20Y	120.1	0.00	4.94	0.78	2	5	2	93	0.00	0.0	4.623	0.001	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48047	PD.7518	C	#4 ACSR	7.20Y	120.1	0.00	4.94	0.78	1	5	2	93	0.00	0.0	4.635	0.013	5	2	3	3
PL.64008	PL.63677	B	#4 ACSR	7.20Y	120.1	0.00	4.94	4.27	3	30	9	96	0.00	0.0	4.623	0.001	0	0	0	5
PD.9510	PL.64008	B	40QA	7.20Y	120.1	0.00	4.94	4.27	11	30	9	96	0.00	0.0	4.623	0.001	0	0	0	5
PL.64214	PD.9510	B	#4 ACSR	7.20Y	120.1	0.01	4.94	4.27	3	30	9	96	0.00	0.0	4.661	0.039	9	3	3	5
PL.64215	PL.64214	B	#4 ACSR	7.20Y	120.1	0.00	4.95	2.94	2	20	6	96	0.00	0.0	4.714	0.053	20	6	2	2
PL.48051	PL.48053	C	#2 ACSR	7.22Y	120.3	0.00	4.73	2.75	2	19	6	95	0.00	0.0	4.320	0.004	0	0	0	2
PD.7422	PL.48051	C	40QA	7.22Y	120.3	0.00	4.73	2.75	7	19	6	95	0.00	0.0	4.320	0.004	0	0	0	2
PL.48052	PD.7422	C	#2 ACSR	7.22Y	120.3	0.00	4.73	2.75	2	19	6	95	0.00	0.0	4.368	0.048	19	6	2	2
PL.47284	PL.46734	A	6 A (CWC)	7.23Y	120.5	0.00	4.46	0.00	0	0	0	100	0.00	0.0	3.945	0.026	0	0	0	0
CP.69	PL.46742	ABC	Cap (300)	7.24Y	120.6	0.00	4.38	0.00	0	0	0	100	0.00	0.0	3.803	0.026	0	0	0	0
PL.48168	PL.48058	C	6 A (CWC)	7.26Y	121.0	0.00	3.98	13.40	10	93	28	96	0.00	0.0	3.221	0.001	0	0	0	17
PD.7424	PL.48168	C	40QA	7.26Y	121.0	0.00	3.98	13.40	34	93	28	96	0.00	0.0	3.221	0.001	0	0	0	17
PL.48179	PD.7424	C	6 A (CWC)	7.26Y	121.0	0.03	4.01	13.40	10	93	28	96	0.02	0.0	3.266	0.045	5	1	1	17
PL.48180	PL.48179	C	6 A (CWC)	7.26Y	121.0	0.03	4.04	12.73	9	89	26	96	0.02	0.0	3.312	0.046	1	0	1	16
PL.46879	PL.48180	C	6 A (CWC)	7.25Y	120.8	0.12	4.15	12.62	9	88	26	96	0.08	0.1	3.517	0.205	0	0	0	15
PL.46880	PL.46879	C	6 A (CWC)	7.24Y	120.7	0.10	4.26	11.90	8	83	25	96	0.06	0.1	3.718	0.201	8	2	2	13
PL.46881	PL.46880	C	6 A (CWC)	7.24Y	120.7	0.02	4.28	10.70	8	74	22	96	0.01	0.0	3.764	0.046	0	0	0	11
PL.47159	PL.46881	C	#4 ACSR	7.24Y	120.7	0.00	4.28	0.21	0	1	0	100	0.00	0.0	3.781	0.017	1	0	1	1
PL.46882	PL.46881	C	#4 ACSR	7.24Y	120.7	0.04	4.32	10.49	8	73	22	96	0.02	0.0	3.855	0.091	13	4	2	10
PL.47732	PL.46882	C	#4 ACSR	7.24Y	120.7	0.03	4.35	8.58	7	60	18	96	0.01	0.0	3.937	0.083	12	4	1	8
PL.47733	PL.47732	C	#4 ACSR	7.24Y	120.6	0.01	4.36	6.85	5	48	14	96	0.00	0.0	3.989	0.051	13	4	2	7
PL.47722	PL.47733	C	#1/0 ACSR	7.24Y	120.6	0.00	4.36	0.94	0	7	2	96	0.00	0.0	4.040	0.051	7	2	1	1
PL.47734	PL.47733	C	#4 ACSR	7.24Y	120.6	0.02	4.38	4.09	3	28	8	96	0.00	0.0	4.101	0.112	8	2	1	4
PL.47735	PL.47734	C	#4 ACSR	7.24Y	120.6	0.00	4.38	2.96	2	21	6	96	0.00	0.0	4.134	0.033	18	5	2	3
PL.47736	PL.47735	C	#4 ACSR	7.24Y	120.6	0.00	4.38	0.36	0	2	1	89	0.00	0.0	4.203	0.069	2	1	1	1
PL.47652	PL.46881	C	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	3.935	0.171	0	0	0	0
PL.47549	PL.46879	C	6 A (CWC)	7.25Y	120.8	0.00	4.15	0.72	1	5	1	98	0.00	0.0	3.570	0.053	5	1	2	2
PL.47678	PL.47680	A	6 A (CWC)	7.27Y	121.2	0.00	3.80	18.85	13	131	39	96	0.00	0.0	2.977	0.001	0	0	0	25
PD.7425	PL.47678	A	40QA	7.27Y	121.2	0.00	3.80	18.85	47	131	39	96	0.00	0.0	2.977	0.001	0	0	0	25
PL.47679	PD.7425	A	6 A (CWC)	7.27Y	121.1	0.08	3.88	18.85	13	131	39	96	0.08	0.1	3.071	0.094	0	0	0	25
PL.47737	PL.47679	A	6 A (CWC)	7.26Y	121.1	0.07	3.95	5.58	4	39	12	96	0.02	0.0	3.345	0.274	5	2	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.63445	PL.47737	A	6 A (CWC)	7.26Y	121.0	0.01	3.95	4.83	3	34	10	96	0.00	0.0	3.385	0.040	8	2	2	5
PL.63446	PL.63445	A	6 A (CWC)	7.26Y	121.0	0.02	3.97	3.75	3	26	8	96	0.00	0.0	3.478	0.094	0	0	0	3
PL.47374	PL.63446	A	6 A (CWC)	7.26Y	121.0	0.00	3.97	0.00	0	0	0	100	0.00	0.0	3.537	0.058	0	0	0	0
PL.47771	PL.63446	A	6 A (CWC)	7.26Y	121.0	0.01	3.98	3.75	3	26	8	96	0.00	0.0	3.553	0.075	0	0	0	3
PL.47772	PL.47771	A	6 A (CWC)	7.26Y	121.0	0.00	3.98	0.00	0	0	0	100	0.00	0.0	3.617	0.064	0	0	0	0
PL.57527	PL.47771	A	6 A (CWC)	7.26Y	121.0	0.01	3.99	3.75	3	26	8	96	0.00	0.0	3.593	0.040	11	3	1	3
PL.57528	PL.57527	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	2.14	1	15	4	97	0.00	0.0	3.596	0.003	0	0	0	2
PD.8375	PL.57528	A	20QA	7.26Y	121.0	0.00	3.99	2.14	11	15	4	97	0.00	0.0	3.596	0.003	0	0	0	2
PL.59009	PD.8375	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	2.14	1	15	4	97	0.00	0.0	3.648	0.052	6	2	1	2
PL.60037	PL.59009	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	1.26	1	9	3	95	0.00	0.0	3.761	0.113	9	3	1	1
PL.47228	PL.47679	A	6 A (CWC)	7.27Y	121.1	0.01	3.89	13.27	9	92	27	96	0.01	0.0	3.086	0.015	5	1	1	18
PL.47229	PL.47228	A	6 A (CWC)	7.27Y	121.1	0.00	3.89	0.82	1	6	2	95	0.00	0.0	3.138	0.051	6	2	2	2
PL.47230	PL.47229	A	6 A (CWC)	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	3.191	0.054	0	0	0	0
PL.48060	PL.47228	A	6 A (CWC)	7.27Y	121.1	0.01	3.91	11.74	8	82	24	96	0.01	0.0	3.115	0.028	5	1	2	15
PL.48061	PL.48060	A	6 A (CWC)	7.26Y	121.1	0.02	3.93	11.03	8	77	23	96	0.01	0.0	3.158	0.043	0	0	0	13
PL.47687	PL.48061	A	6 A (CWC)	7.26Y	121.1	0.02	3.95	5.97	4	42	12	96	0.01	0.0	3.228	0.070	0	0	0	7
PL.46809	PL.47687	A	6 A (CWC)	7.26Y	121.1	0.00	3.95	1.43	1	10	3	96	0.00	0.0	3.256	0.028	10	3	3	3
PL.47773	PL.47687	A	6 A (CWC)	7.26Y	121.0	0.01	3.95	4.54	3	32	9	96	0.00	0.0	3.271	0.043	20	6	2	4
PL.48181	PL.47773	A	6 A (CWC)	7.26Y	121.0	0.00	3.96	1.65	1	11	3	96	0.00	0.0	3.309	0.038	0	0	0	2
PL.48182	PL.48181	A	6 A (CWC)	7.26Y	121.0	0.00	3.96	1.65	1	11	3	96	0.00	0.0	3.357	0.048	11	3	2	2
PL.57596	PL.48061	A	6 A (CWC)	7.26Y	121.1	0.01	3.93	5.06	4	35	10	96	0.00	0.0	3.193	0.036	4	1	2	6
PL.57597	PL.57596	A	6 A (CWC)	7.26Y	121.1	0.00	3.94	4.48	3	31	9	96	0.00	0.0	3.230	0.037	31	9	4	4
PL.63679	PL.64191	C	#2 ACSR	7.28Y	121.3	0.00	3.66	2.38	1	17	5	96	0.00	0.0	2.798	0.001	0	0	0	2
PD.7426	PL.63679	C	40QA	7.28Y	121.3	0.00	3.66	2.38	6	17	5	96	0.00	0.0	2.798	0.001	0	0	0	2
PL.47688	PD.7426	C	#2 ACSR	7.28Y	121.3	0.00	3.66	2.38	1	17	5	96	0.00	0.0	2.819	0.021	11	3	1	2
PL.48183	PL.47688	C	#2 ACSR	7.28Y	121.3	0.00	3.66	0.78	0	5	2	93	0.00	0.0	2.859	0.040	5	2	1	1
PL.64761	PL.47463	B	#1/0 ACSR	7.31Y	121.9	0.00	3.08	0.78	0	5	2	93	0.00	0.0	2.526	0.024	5	2	2	2
PL.62874	PL.62872	A	6 A (CWC)	7.37Y	122.8	0.00	2.24	8.99	6	63	19	96	0.00	0.0	1.847	0.003	0	0	0	12
PD.9440	PL.62874	A	50T	7.37Y	122.8	0.00	2.24	8.99	0	63	19	96	0.00	0.0	1.847	0.003	0	0	0	12
PL.62875	PD.9440	A	6 A (CWC)	7.36Y	122.7	0.03	2.27	8.99	6	63	19	96	0.01	0.0	1.920	0.073	0	0	0	12
PL.62569	PL.62875	A	6 A (CWC)	7.36Y	122.7	0.01	2.29	8.99	6	63	19	96	0.01	0.0	1.959	0.039	23	7	2	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37860	PL.62569	A	6 A (CWC)	7.36Y	122.7	0.00	2.29	0.68	0	5	1	98	0.00	0.0	1.998	0.040	5	1	3	3
PL.38695	PL.62569	A	6 A (CWC)	7.36Y	122.7	0.01	2.29	5.03	4	36	11	96	0.00	0.0	1.986	0.027	8	2	1	7
PL.37588	PL.38695	A	6 A (CWC)	7.36Y	122.7	0.00	2.29	1.42	1	10	3	96	0.00	0.0	2.017	0.031	10	3	2	2
PL.37589	PL.38695	A	6 A (CWC)	7.36Y	122.7	0.00	2.29	2.52	2	18	5	96	0.00	0.0	2.014	0.029	14	4	3	4
PL.37590	PL.37589	A	6 A (CWC)	7.36Y	122.7	0.00	2.30	0.54	0	4	1	97	0.00	0.0	2.056	0.042	0	0	0	1
PL.62567	PL.37590	A	#1/0 ACSR	7.36Y	122.7	0.00	2.30	0.54	0	4	1	97	0.00	0.0	2.122	0.066	4	1	1	1
PL.62568	PL.62875	A	6 A (CWC)	7.36Y	122.7	0.00	2.27	0.00	0	0	0	100	0.00	0.0	1.949	0.029	0	0	0	0
PL.63943	PL.62652	A	#4 ACSR	7.40Y	123.4	0.00	1.60	3.02	2	21	6	96	0.00	0.0	1.282	0.004	0	0	0	2
PD.9524	PL.63943	A	50T	7.40Y	123.4	0.00	1.60	3.02	0	21	6	96	0.00	0.0	1.282	0.004	0	0	0	2
PL.63944	PD.9524	A	#4 ACSR	7.40Y	123.4	0.01	1.61	3.02	2	21	6	96	0.00	0.0	1.349	0.067	0	0	0	2
PL.62654	PL.63944	A	#4 ACSR	7.40Y	123.4	0.00	1.61	3.02	2	21	6	96	0.00	0.0	1.349	0.000	21	6	2	2
PL.62589	PL.62648	A	#4 ACSR	7.41Y	123.6	0.00	1.44	0.92	1	7	2	96	0.00	0.0	1.149	0.001	0	0	0	1
PD.9394	PL.62589	A	50T	7.41Y	123.6	0.00	1.44	0.92	0	7	2	96	0.00	0.0	1.149	0.001	0	0	0	1
PL.62588	PD.9394	A	#4 ACSR	7.41Y	123.6	0.00	1.44	0.00	0	0	0	100	0.00	0.0	1.171	0.022	0	0	0	0
PL.62587	PD.9394	A	#4 ACSR	7.41Y	123.6	0.00	1.45	0.92	1	7	2	96	0.00	0.0	1.190	0.041	7	2	1	1
PL.62613	PL.62612	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	8.82	6	63	19	96	0.00	0.0	0.799	0.002	0	0	0	11
PD.9429	PL.62613	C	50T	7.44Y	124.0	0.00	1.03	8.82	0	63	19	96	0.00	0.0	0.799	0.002	0	0	0	11
PL.62611	PD.9429	C	6 A (CWC)	7.44Y	124.0	0.02	1.05	8.82	6	63	19	96	0.01	0.0	0.852	0.053	0	0	0	11
PL.37272	PL.62611	C	6 A (CWC)	7.44Y	123.9	0.00	1.05	1.55	1	11	3	96	0.00	0.0	0.919	0.067	0	0	0	2
PL.38688	PL.37272	C	6 A (CWC)	7.44Y	123.9	0.01	1.06	1.55	1	11	3	96	0.00	0.0	1.013	0.094	0	0	0	2
PL.38689	PL.38688	C	6 A (CWC)	7.44Y	123.9	0.01	1.07	1.55	1	11	3	96	0.00	0.0	1.128	0.115	5	2	1	2
PL.38690	PL.38689	C	6 A (CWC)	7.44Y	123.9	0.00	1.07	0.81	1	6	2	95	0.00	0.0	1.182	0.054	6	2	1	1
PL.37742	PL.62611	C	6 A (CWC)	7.44Y	123.9	0.01	1.06	7.27	5	52	15	96	0.00	0.0	0.912	0.061	52	15	9	9
PL.62605	PL.62628	C	#2 ACSR	7.46Y	124.3	0.00	0.73	1.74	1	12	4	95	0.00	0.0	0.560	0.002	0	0	0	1
PD.9426	PL.62605	C	50T	7.46Y	124.3	0.00	0.73	1.74	0	12	4	95	0.00	0.0	0.560	0.002	0	0	0	1
PL.62606	PD.9426	C	#2 ACSR	7.46Y	124.3	0.00	0.73	1.74	1	12	4	95	0.00	0.0	0.590	0.030	0	0	0	1
PL.37352	PL.62606	C	#2 ACSR	7.46Y	124.3	0.00	0.73	1.74	1	12	4	95	0.00	0.0	0.613	0.023	12	4	1	1
PL.62602	PL.62626	B	#4 ACSR	7.49Y	124.8	0.00	0.22	60.94	47	437	132	96	0.01	0.0	0.157	0.001	0	0	0	62
PD.6046	PL.62602	B	50T	7.49Y	124.8	0.00	0.22	60.94	0	437	132	96	0.00	0.0	0.157	0.001	0	0	0	62
PL.37853	PD.6046	B	#4 ACSR 6/	7.48Y	124.7	0.10	0.33	60.69	43	435	132	96	0.33	0.1	0.194	0.037	6	2	1	61
PL.38663	PL.37853	B	#4 ACSR 6/	7.46Y	124.4	0.27	0.60	59.84	43	428	130	96	0.86	0.2	0.291	0.097	5	1	2	60

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38664	PL.38663	B	#4 ACSR 6/	7.45Y	124.2	0.19	0.79	59.13	42	422	128	96	0.60	0.1	0.360	0.069	2	0	1	58
PL.37555	PL.38664	B	#4 ACSR 6/	7.44Y	124.0	0.22	1.00	56.08	40	400	121	96	0.64	0.2	0.442	0.082	0	0	0	52
PL.37339	PL.37555	B	6 A (CWC)	7.44Y	124.0	0.00	1.00	0.32	0	2	1	89	0.00	0.0	0.569	0.127	2	1	1	1
PL.38665	PL.37555	B	#4 ACSR 6/	7.42Y	123.7	0.32	1.32	55.76	40	397	120	96	0.96	0.2	0.566	0.123	0	0	0	51
PL.37831	PL.38665	B	#4 ACSR 6/	7.42Y	123.7	0.00	1.33	0.45	0	3	1	95	0.00	0.0	0.686	0.120	3	1	1	1
PL.38666	PL.38665	B	#4 ACSR 6/	7.41Y	123.5	0.21	1.53	55.30	40	393	118	96	0.60	0.2	0.647	0.082	12	4	2	50
PL.38667	PL.38666	B	#4 ACSR 6/	7.39Y	123.1	0.34	1.88	53.56	38	380	114	96	0.98	0.3	0.785	0.138	0	0	0	48
PL.37385	PL.38667	B	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.39	0	3	1	95	0.00	0.0	0.958	0.173	3	1	1	1
PL.38668	PL.38667	B	#4 ACSR 6/	7.38Y	123.0	0.17	2.05	53.17	38	376	113	96	0.47	0.1	0.855	0.070	17	5	1	47
PL.38669	PL.38668	B	6 A (CWC)	7.38Y	123.0	0.00	2.05	1.88	1	13	4	96	0.00	0.0	0.896	0.041	0	0	0	3
PL.38670	PL.38669	B	6 A (CWC)	7.38Y	122.9	0.00	2.05	0.66	0	5	1	98	0.00	0.0	0.986	0.090	5	1	1	1
PL.37381	PL.38669	B	#2 ACSR 6/	7.38Y	123.0	0.00	2.05	1.23	1	9	3	95	0.00	0.0	0.913	0.017	9	3	2	2
PL.38671	PL.38668	B	6 A (CWC)	7.36Y	122.7	0.21	2.26	48.94	35	346	104	96	0.55	0.2	0.950	0.095	0	0	0	43
PL.37706	PL.38671	B	#2 ACSR 6/	7.36Y	122.7	0.00	2.26	1.35	1	10	3	96	0.00	0.0	1.020	0.070	10	3	1	1
PL.64512	PL.38671	B	6 A (CWC)	7.35Y	122.6	0.18	2.44	47.59	34	336	101	96	0.45	0.1	1.032	0.082	0	0	0	42
PL.64510	PL.64512	B	6 A (CWC)	7.35Y	122.5	0.07	2.51	45.93	33	324	97	96	0.17	0.1	1.065	0.034	0	0	0	38
PL.64509	PL.64510	B	#4/0 ACSR	7.35Y	122.5	0.00	2.51	1.93	1	14	4	96	0.00	0.0	1.133	0.067	14	4	3	3
PL.64511	PL.64510	B	6 A (CWC)	7.34Y	122.4	0.10	2.61	44.00	31	310	93	96	0.23	0.1	1.117	0.052	19	6	2	35
PL.64514	PL.64511	B	#6 ACSR 6/	7.33Y	122.1	0.26	2.87	41.37	41	291	87	96	0.59	0.2	1.210	0.093	8	2	1	33
PL.38672	PL.64514	B	6 A (CWC)	7.32Y	122.0	0.17	3.04	40.17	29	282	84	96	0.35	0.1	1.304	0.094	18	5	2	32
PL.38673	PL.38672	B	6 A (CWC)	7.31Y	121.9	0.09	3.13	37.66	27	264	79	96	0.18	0.1	1.356	0.052	0	0	0	30
PL.37409	PL.38673	B	#4 ACSR 6/	7.30Y	121.7	0.13	3.26	36.03	26	252	75	96	0.25	0.1	1.434	0.077	0	0	0	29
PL.37188	PL.37409	B	6 A (CWC)	7.30Y	121.7	0.01	3.27	5.63	4	39	12	96	0.00	0.0	1.475	0.041	19	6	2	4
PL.37257	PL.37188	B	6 A (CWC)	7.30Y	121.7	0.00	3.27	2.96	2	21	6	96	0.00	0.0	1.501	0.026	21	6	2	2
PL.37410	PL.37409	B	#4 ACSR 6/	7.30Y	121.6	0.16	3.41	30.40	22	213	64	96	0.25	0.1	1.544	0.110	0	0	0	25
PL.38676	PL.37410	B	#4 ACSR 6/	7.29Y	121.6	0.01	3.42	1.62	1	11	3	96	0.00	0.0	1.632	0.088	0	0	0	1
PL.38677	PL.38676	B	#4 ACSR 6/	7.29Y	121.6	0.00	3.42	1.62	1	11	3	96	0.00	0.0	1.697	0.066	11	3	1	1
PL.37747	PL.37410	B	6 A (CWC)	7.29Y	121.5	0.13	3.54	28.78	21	201	60	96	0.20	0.1	1.643	0.099	5	1	1	24
PL.38438	PL.37747	B	6 A (CWC)	7.28Y	121.4	0.08	3.62	28.11	20	196	59	96	0.11	0.1	1.704	0.061	17	5	2	23
PL.37325	PL.38438	B	6 A (CWC)	7.28Y	121.4	0.00	3.62	1.44	1	10	3	96	0.00	0.0	1.749	0.045	10	3	1	1
PL.38674	PL.38438	B	6 A (CWC)	7.27Y	121.2	0.17	3.79	24.22	17	169	50	96	0.21	0.1	1.856	0.152	6	2	1	20

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37251	PL.38674	B	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.87	1	13	4	96	0.00	0.0	1.970	0.115	13	4	1	1
PL.38675	PL.38674	B	6 A (CWC)	7.27Y	121.1	0.12	3.91	21.51	15	150	45	96	0.14	0.1	1.978	0.122	0	0	0	18
PL.37633	PL.38675	B	6 A (CWC)	7.25Y	120.8	0.25	4.16	21.32	15	148	44	96	0.28	0.2	2.235	0.257	0	0	1	17
PL.37634	PL.37633	B	6 A (CWC)	7.25Y	120.8	0.07	4.22	20.12	14	140	42	96	0.07	0.0	2.309	0.074	11	3	1	15
PL.37367	PL.37634	B	6 A (CWC)	7.24Y	120.7	0.05	4.28	18.56	13	129	38	96	0.05	0.0	2.369	0.060	0	0	0	14
PL.61406	PL.37367	B	#1/0 ACSR	7.24Y	120.7	0.00	4.28	2.93	1	20	6	96	0.00	0.0	2.373	0.003	0	0	0	2
PD.9137	PL.61406	B	20T	7.24Y	120.7	0.00	4.28	2.93	0	20	6	96	0.00	0.0	2.373	0.003	0	0	0	2
PL.61407	PD.9137	B	#1/0 ACSR	7.24Y	120.7	0.00	4.28	2.93	1	20	6	96	0.00	0.0	2.429	0.056	8	2	1	2
PL.61405	PL.61407	B	#1/0 ACSR	7.24Y	120.7	0.00	4.28	1.81	1	13	4	96	0.00	0.0	2.449	0.020	13	4	1	1
PL.37368	PL.37367	B	6 A (CWC)	7.24Y	120.7	0.06	4.33	15.63	11	109	32	96	0.05	0.0	2.452	0.082	3	1	1	12
PL.37548	PL.37368	B	6 A (CWC)	7.24Y	120.7	0.00	4.34	0.79	1	5	2	93	0.00	0.0	2.486	0.034	5	2	1	1
PL.37371	PL.37368	B	6 A (CWC)	7.24Y	120.6	0.03	4.37	14.48	10	100	30	96	0.02	0.0	2.500	0.049	0	0	0	10
PL.62823	PL.37371	B	#4 ACSR	7.23Y	120.5	0.11	4.48	12.45	10	86	26	96	0.07	0.1	2.701	0.200	0	0	0	9
PL.62824	PL.62823	B	#4 ACSR	7.23Y	120.5	0.02	4.50	12.45	10	86	26	96	0.01	0.0	2.733	0.033	0	0	0	9
PL.62826	PL.62824	B	#1/0 ACSR	7.23Y	120.5	0.00	4.50	0.37	0	3	1	95	0.00	0.0	2.750	0.017	3	1	2	2
PL.62825	PL.62824	B	#4 ACSR	7.23Y	120.5	0.02	4.52	12.08	9	84	25	96	0.01	0.0	2.780	0.047	11	3	1	7
PL.37372	PL.62825	B	6 A (CWC)	7.23Y	120.5	0.02	4.54	10.56	8	73	22	96	0.01	0.0	2.811	0.031	0	0	0	6
PL.61030	PL.37372	B	6 A (CWC)	7.22Y	120.4	0.05	4.58	8.97	6	62	18	96	0.02	0.0	2.929	0.118	0	0	0	5
PL.61031	PL.61030	B	6 A (CWC)	7.22Y	120.4	0.01	4.59	8.08	6	56	17	96	0.00	0.0	2.951	0.021	18	5	1	4
PL.37220	PL.61031	B	6 A (CWC)	7.22Y	120.4	0.03	4.62	5.43	4	38	11	96	0.01	0.0	3.085	0.134	12	3	1	3
PL.61404	PL.37220	B	#1/0 ACSR	7.22Y	120.4	0.00	4.62	1.46	1	10	3	96	0.00	0.0	3.282	0.197	10	3	1	1
PL.38397	PL.37220	B	6 A (CWC)	7.22Y	120.4	0.00	4.62	2.30	2	16	5	95	0.00	0.0	3.156	0.071	16	5	1	1
PL.61032	PL.61030	B	#1/0 ACSR	7.22Y	120.4	0.00	4.58	0.89	0	6	2	95	0.00	0.0	2.983	0.054	6	2	1	1
PL.36758	PL.37372	B	#2 ACSR 6/	7.23Y	120.5	0.00	4.54	1.59	1	11	3	96	0.00	0.0	3.001	0.189	11	3	1	1
PL.37369	PL.37371	B	#4 ACSR 6/	7.24Y	120.6	0.00	4.37	2.03	1	14	4	96	0.00	0.0	2.529	0.028	0	0	0	1
PL.37370	PL.37369	B	#4 ACSR 6/	7.24Y	120.6	0.00	4.37	2.03	1	14	4	96	0.00	0.0	2.591	0.062	14	4	1	1
PL.37746	PL.37633	B	6 A (CWC)	7.25Y	120.8	0.00	4.16	1.19	1	8	2	97	0.00	0.0	2.299	0.063	8	2	1	1
PL.37862	PL.38675	B	6 A (CWC)	7.27Y	121.1	0.00	3.91	0.19	0	1	0	100	0.00	0.0	2.061	0.083	1	0	1	1
PL.38423	PL.37409	B	6 A (CWC)	7.30Y	121.7	0.00	3.26	0.00	0	0	0	100	0.00	0.0	1.475	0.041	0	0	0	0
PL.37705	PL.38673	B	#4 ACSR 6/	7.31Y	121.9	0.00	3.13	1.64	1	11	3	96	0.00	0.0	1.420	0.064	11	3	1	1
PL.64513	PL.64512	B	#4 ACSR 6/	7.35Y	122.6	0.00	2.44	1.65	1	12	3	97	0.00	0.0	1.066	0.034	0	0	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.37115	PL.64513	B	#4 ACSR 6/	7.35Y	122.6	0.00	2.44	1.64	1	12	3	97	0.00	0.0	1.112	0.047	6	2	1	3
PL.37116	PL.37115	B	#4 ACSR 6/	7.35Y	122.6	0.00	2.45	0.76	1	5	2	93	0.00	0.0	1.189	0.076	5	2	2	2
PL.38433	PL.38664	B	#4 ACSR 6/	7.45Y	124.2	0.02	0.81	2.84	2	20	6	96	0.00	0.0	0.515	0.156	3	1	1	5
PL.38434	PL.38433	B	#4 ACSR 6/	7.45Y	124.2	0.01	0.81	2.48	2	18	5	96	0.00	0.0	0.604	0.088	18	5	4	4
PL.64896	PD.6046	B	#1/0 ACSR	7.49Y	124.8	0.00	0.22	0.26	0	2	1	89	0.00	0.0	0.211	0.054	2	1	1	1
PL.62356	PL.64896	B	#4 ACSR	7.49Y	124.8	0.00	0.22	0.00	0	0	0	100	0.00	0.0	0.277	0.066	0	0	0	0
PL.62357	PL.64896	B	#4 ACSR	7.49Y	124.8	0.00	0.22	0.00	0	0	0	100	0.00	0.0	0.254	0.043	0	0	0	0
PL.62140	Conway	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	118.30	23	2525	842	95	0.08	0.0	0.006	0.006	0	0	0	416
PL.62141	PL.62140	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	118.30	23	2525	842	95	0.10	0.0	0.015	0.009	0	0	0	416

----- Feeder No. 3 (ScaffoldCaneF3) Beginning with Device PD.9312 -----																				
PD.9312	PL.62141	ABC	480VWE	7.50Y	125.0	0.00	0.01	118.30	0	2525	842	95	0.00	0.0	0.015	0.009	0	0	0	416
PL.62125	PD.9312	ABC	336 MCM AC	7.50Y	124.9	0.05	0.07	118.30	23	2525	842	95	0.68	0.0	0.073	0.057	0	0	0	416
PL.62127	PL.62125	ABC	336 MCM AC	7.48Y	124.6	0.29	0.36	118.30	23	2524	840	95	3.64	0.1	0.382	0.309	0	0	0	416
PL.62128	PL.62127	ABC	336 MCM AC	7.46Y	124.4	0.24	0.59	118.30	23	2521	832	95	3.00	0.1	0.636	0.254	0	0	0	416
PL.62129	PL.62128	ABC	336 MCM AC	7.46Y	124.3	0.08	0.68	118.30	23	2518	825	95	1.06	0.0	0.726	0.090	1	0	1	416
PL.38686	PL.62129	C	#1/0 ACSR	7.46Y	124.3	0.00	0.68	1.27	1	9	3	95	0.00	0.0	0.728	0.002	0	0	0	1
PD.5989	PL.38686	C	30QA	7.46Y	124.3	0.00	0.68	1.27	4	9	3	95	0.00	0.0	0.728	0.002	0	0	0	1
PL.38687	PD.5989	C	#1/0 ACSR	7.46Y	124.3	0.00	0.68	1.27	1	9	3	95	0.00	0.0	0.757	0.029	9	3	1	1
PL.37310	PL.62129	ABC	336 MCM AC	7.46Y	124.3	0.05	0.73	117.83	23	2506	819	95	0.64	0.0	0.781	0.055	0	0	0	414
PL.37311	PL.37310	A	#2 ACSR	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	0.782	0.001	0	0	0	0
PD.6059	PL.37311	A	30QA	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	0.782	0.001	0	0	0	0
PL.37312	PD.6059	A	#2 ACSR	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	0.830	0.047	0	0	0	0
PL.61769	PL.37310	ABC	336 MCM AC	7.45Y	124.2	0.04	0.77	117.83	23	2506	818	95	0.49	0.0	0.823	0.042	0	0	0	414
PL.61768	PL.61769	ABC	336 MCM AC	7.45Y	124.2	0.04	0.81	117.83	23	2505	816	95	0.52	0.0	0.868	0.045	0	0	0	414
PL.52505	PL.61768	ABC	336 MCM AC	7.45Y	124.2	0.00	0.81	117.83	23	2505	815	95	0.02	0.0	0.869	0.002	0	0	0	414
PL.52502	PL.52505	ABC	336 MCM AC	7.45Y	124.2	0.04	0.85	117.83	23	2505	815	95	0.49	0.0	0.911	0.042	0	0	0	414
PL.52503	PL.52502	ABC	336 MCM AC	7.43Y	123.9	0.26	1.11	117.08	23	2488	809	95	3.31	0.1	1.198	0.287	0	0	0	413
PL.38684	PL.52503	ABC	336 MCM AC	7.43Y	123.8	0.05	1.16	117.08	23	2485	802	95	0.69	0.0	1.258	0.060	0	0	0	413
PL.38681	PL.38684	A	#1/0 ACSR	7.43Y	123.8	0.00	1.16	1.59	1	11	3	96	0.00	0.0	1.259	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5968	PL.38681	A	25QA	7.43Y	123.8	0.00	1.16	1.59	6	11	3	96	0.00	0.0	1.259	0.001	0	0	0	1
PL.38682	PD.5968	A	#1/0 ACSR	7.43Y	123.8	0.00	1.17	1.59	1	11	3	96	0.00	0.0	1.289	0.030	0	0	0	1
PL.38683	PL.38682	A	#1/0 ACSR	7.43Y	123.8	0.00	1.17	1.59	1	11	3	96	0.00	0.0	1.334	0.045	11	3	1	1
PL.38680	PL.38684	ABC	336 MCM AC	7.43Y	123.8	0.03	1.19	116.56	22	2473	797	95	0.32	0.0	1.286	0.028	0	0	0	412
PL.38679	PL.38680	ABC	336 MCM AC	7.42Y	123.7	0.07	1.26	116.56	22	2473	796	95	0.87	0.0	1.361	0.076	8	2	1	412
PL.38026	PL.38679	A	#2 ACSR	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.362	0.001	0	0	0	0
PD.5974	PL.38026	A	60QA	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.362	0.001	0	0	0	0
PL.38678	PD.5974	A	#2 ACSR	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.401	0.039	0	0	0	0
PL.37768	PL.38679	ABC	336 MCM AC	7.42Y	123.7	0.09	1.34	116.16	22	2463	791	95	1.07	0.0	1.455	0.094	10	3	2	411
PL.37767	PL.37768	ABC	336 MCM AC	7.42Y	123.6	0.07	1.41	115.71	22	2453	786	95	0.86	0.0	1.532	0.076	0	0	0	409
PL.37112	PL.37767	ABC	336 MCM AC	7.41Y	123.5	0.08	1.49	115.36	22	2444	782	95	1.02	0.0	1.623	0.091	4	1	1	408
PL.37760	PL.37112	ABC	336 MCM AC	7.41Y	123.4	0.06	1.56	115.20	22	2440	778	95	0.77	0.0	1.693	0.069	0	0	0	407
PL.38021	PL.37760	ABC	336 MCM AC	7.40Y	123.4	0.05	1.61	114.82	22	2431	774	95	0.66	0.0	1.752	0.059	0	0	0	406
PL.38020	PL.38021	ABC	336 MCM AC	7.40Y	123.3	0.05	1.66	114.82	22	2430	773	95	0.57	0.0	1.804	0.052	0	0	0	406
PL.60038	PL.38020	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.66	12.91	6	273	88	95	0.01	0.0	1.831	0.027	17	5	1	39
PL.60039	PL.60038	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.67	12.13	5	256	83	95	0.01	0.0	1.854	0.023	0	0	0	38
PL.60042	PL.60039	ABC	#1/0 ACSR	7.40Y	123.3	0.00	1.67	12.13	5	256	83	95	0.00	0.0	1.857	0.003	0	0	0	38
PD.8846	PL.60042	ABC	70L	7.40Y	123.3	0.00	1.67	12.13	17	256	83	95	0.00	0.0	1.857	0.003	0	0	0	38
PL.60043	PD.8846	ABC	#1/0 ACSR	7.40Y	123.3	0.00	1.67	12.13	5	256	83	95	0.01	0.0	1.877	0.020	0	0	0	38
PL.60040	PL.60043	ABC	#4 ACSR	7.40Y	123.3	0.00	1.67	0.52	0	11	3	96	0.00	0.0	1.906	0.029	11	3	1	1
PL.60041	PL.60043	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.68	11.61	5	245	80	95	0.01	0.0	1.921	0.044	13	4	2	37
PL.38592	PL.60041	A	6 A (CWC)	7.40Y	123.3	0.00	1.68	1.92	1	14	4	96	0.00	0.0	1.921	0.000	0	0	0	2
PD.5971	PL.38592	A	40QA	7.40Y	123.3	0.00	1.68	1.92	5	14	4	96	0.00	0.0	1.921	0.000	0	0	0	2
PL.38593	PD.5971	A	6 A (CWC)	7.40Y	123.3	0.00	1.68	1.92	1	14	4	96	0.00	0.0	1.988	0.067	14	4	2	2
PL.38594	PL.60041	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.69	10.36	5	219	72	95	0.01	0.0	1.962	0.042	3	1	1	33
PL.38595	PL.38594	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.71	10.21	4	215	71	95	0.03	0.0	2.075	0.113	0	0	0	32
PL.37113	PL.38595	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.72	9.89	4	209	69	95	0.01	0.0	2.114	0.039	0	0	0	31
PL.37114	PL.37113	ABC	#1/0 ACSR	7.39Y	123.2	0.06	1.78	9.55	4	201	67	95	0.09	0.0	2.475	0.360	0	0	0	30
PL.38600	PL.37114	A	#2 ACSR	7.39Y	123.2	0.00	1.78	20.48	12	145	43	96	0.00	0.0	2.475	0.000	0	0	0	23
PD.5973	PL.38600	A	40QA	7.39Y	123.2	0.00	1.78	20.48	51	145	43	96	0.00	0.0	2.475	0.000	0	0	0	23
PL.38601	PD.5973	A	#2 ACSR	7.39Y	123.1	0.11	1.90	20.48	12	145	43	96	0.11	0.1	2.668	0.193	27	8	2	23

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.57560	PL.38601	A	#2 ACSR	7.38Y	123.1	0.03	1.92	12.67	7	90	27	96	0.02	0.0	2.741	0.072	0	0	0	19
PL.57561	PL.57560	A	#2 ACSR	7.38Y	123.1	0.01	1.93	7.16	4	51	15	96	0.00	0.0	2.790	0.049	10	3	1	11
PL.37920	PL.57561	A	#4 ACSR	7.38Y	123.1	0.01	1.94	2.90	2	21	6	96	0.00	0.0	2.878	0.088	6	2	2	5
PL.37635	PL.37920	A	#4 ACSR	7.38Y	123.1	0.00	1.95	1.88	1	13	4	96	0.00	0.0	2.966	0.088	10	3	1	2
PL.37636	PL.37635	A	#4 ACSR	7.38Y	123.1	0.00	1.95	0.45	0	3	1	95	0.00	0.0	3.022	0.056	3	1	1	1
PL.37921	PL.37920	A	#4 ACSR	7.38Y	123.1	0.00	1.95	0.21	0	1	0	100	0.00	0.0	3.151	0.273	1	0	1	1
PL.37725	PL.57561	A	#2 ACSR	7.38Y	123.1	0.00	1.94	1.61	1	11	3	96	0.00	0.0	2.828	0.039	11	3	2	2
PL.37922	PL.57561	A	#2 ACSR	7.38Y	123.1	0.01	1.94	1.25	1	9	3	95	0.00	0.0	2.957	0.167	3	1	1	3
PL.37923	PL.37922	A	#2 ACSR	7.38Y	123.1	0.00	1.94	0.79	0	6	2	95	0.00	0.0	2.997	0.040	0	0	1	2
PL.37924	PL.37923	A	#2 ACSR	7.38Y	123.1	0.00	1.94	0.79	0	6	2	95	0.00	0.0	3.029	0.032	6	2	1	1
PL.57562	PL.57560	A	#2 ACSR	7.38Y	123.1	0.02	1.94	5.51	3	39	12	96	0.01	0.0	2.852	0.112	0	0	0	8
PL.57563	PL.57562	A	#1/0 ACSR	7.38Y	123.1	0.00	1.94	1.46	1	10	3	96	0.00	0.0	2.856	0.004	0	0	0	2
PD.8378	PL.57563	A	20QA	7.38Y	123.1	0.00	1.94	1.46	7	10	3	96	0.00	0.0	2.856	0.004	0	0	0	2
PL.65308	PD.8378	A	#1/0 ACSR	7.38Y	123.1	0.00	1.94	1.46	1	10	3	96	0.00	0.0	2.904	0.047	10	3	2	2
PL.57526	PL.57562	A	#2 ACSR	7.38Y	123.1	0.01	1.95	4.05	2	29	9	96	0.00	0.0	2.892	0.040	0	0	0	6
PL.57349	PL.57526	A	#2 ACSR	7.38Y	123.0	0.01	1.95	4.05	2	29	9	96	0.00	0.0	2.943	0.050	6	2	1	6
PL.57347	PL.57349	A	#2 ACSR	7.38Y	123.0	0.00	1.96	0.61	0	4	1	97	0.00	0.0	3.012	0.069	4	1	2	2
PL.57346	PL.57349	A	#2 ACSR	7.38Y	123.0	0.00	1.96	2.59	1	18	5	96	0.00	0.0	3.007	0.064	11	3	1	3
PL.37423	PL.57346	A	#2 ACSR	7.38Y	123.0	0.00	1.96	1.00	1	7	2	96	0.00	0.0	3.035	0.028	0	0	0	2
PL.57348	PL.37423	A	#2 ACSR	7.38Y	123.0	0.00	1.96	1.00	1	7	2	96	0.00	0.0	3.060	0.026	7	2	2	2
PL.37421	PL.38601	A	#2 ACSR	7.39Y	123.1	0.00	1.90	4.07	2	29	9	96	0.00	0.0	2.694	0.025	0	0	0	2
PL.37422	PL.37421	A	#2 ACSR	7.39Y	123.1	0.00	1.90	2.58	1	18	5	96	0.00	0.0	2.732	0.039	18	5	1	1
PL.37293	PL.37421	A	#2 ACSR	7.39Y	123.1	0.00	1.90	1.49	1	11	3	96	0.00	0.0	2.729	0.035	11	3	1	1
PL.37778	PL.37114	ABC	#2 ACSR	7.39Y	123.2	0.01	1.80	2.74	2	56	23	93	0.01	0.0	2.680	0.205	0	0	1	7
PL.37687	PL.37778	C	#2 ACSR	7.39Y	123.2	0.01	1.80	1.35	1	10	3	96	0.00	0.0	2.817	0.137	0	0	0	2
PL.37828	PL.37687	C	#2 ACSR	7.39Y	123.2	0.00	1.80	1.35	1	10	3	96	0.00	0.0	2.861	0.043	6	2	1	2
PL.62706	PL.37828	C	#2 ACSR	7.39Y	123.2	0.00	1.80	0.57	0	4	1	97	0.00	0.0	2.861	0.000	0	0	0	1
PL.62705	PL.62706	C	#2 ACSR	7.39Y	123.2	0.00	1.80	0.57	0	4	1	97	0.00	0.0	2.963	0.102	4	1	1	1
PL.38662	PL.37778	ABC	#2 ACSR	7.39Y	123.2	0.00	1.80	2.17	1	44	20	91	0.00	0.0	2.681	0.001	0	0	0	3
PD.5995	PL.38662	ABC	40QA	7.39Y	123.2	0.00	1.80	2.17	5	44	20	91	0.00	0.0	2.681	0.001	0	0	0	3
PL.62707	PD.5995	ABC	#2 ACSR	7.39Y	123.2	0.00	1.80	2.17	1	44	20	91	0.00	0.0	2.713	0.032	8	3	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62708	PL.62707	ABC	#2 ACSR	7.39Y	123.2	0.01	1.80	1.78	1	35	17	90	0.00	0.0	2.956	0.243	31	15	1	2
PL.63075	PL.62708	ABC	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.23	0	5	2	93	0.00	0.0	2.958	0.002	5	2	1	1
PL.37338	PL.37778	C	#4 ACSR	7.39Y	123.2	0.00	1.80	0.34	0	2	1	89	0.00	0.0	2.761	0.081	2	1	1	1
PL.38598	PL.37113	C	#4 ACSR	7.40Y	123.3	0.00	1.72	1.02	1	7	2	96	0.00	0.0	2.115	0.000	0	0	0	1
PD.6003	PL.38598	C	40QA	7.40Y	123.3	0.00	1.72	1.02	3	7	2	96	0.00	0.0	2.115	0.000	0	0	0	1
PL.38599	PD.6003	C	#4 ACSR	7.40Y	123.3	0.00	1.72	1.02	1	7	2	96	0.00	0.0	2.152	0.037	7	2	1	1
PL.38596	PL.38595	C	#4 ACSR	7.40Y	123.3	0.00	1.71	0.96	1	7	2	96	0.00	0.0	2.077	0.002	0	0	0	1
PD.5972	PL.38596	C	40QA	7.40Y	123.3	0.00	1.71	0.96	2	7	2	96	0.00	0.0	2.077	0.002	0	0	0	1
PL.38597	PD.5972	C	#4 ACSR	7.40Y	123.3	0.00	1.71	0.96	1	7	2	96	0.00	0.0	2.112	0.035	7	2	1	1
PL.37554	PL.38020	ABC	336 MCM AC	7.40Y	123.3	0.03	1.69	101.91	20	2157	683	95	0.37	0.0	1.846	0.042	2	1	1	367
PL.37553	PL.37554	ABC	336 MCM AC	7.40Y	123.3	0.03	1.72	101.82	20	2155	682	95	0.37	0.0	1.889	0.043	10	3	2	366
PL.38357	PL.37553	ABC	336 MCM AC	7.39Y	123.2	0.04	1.76	101.35	20	2144	678	95	0.43	0.0	1.938	0.049	9	3	1	364
PL.38356	PL.38357	ABC	336 MCM AC	7.39Y	123.2	0.03	1.79	100.95	19	2135	675	95	0.34	0.0	1.978	0.040	13	4	1	363
PL.37536	PL.38356	ABC	336 MCM AC	7.39Y	123.2	0.03	1.83	99.46	19	2103	664	95	0.37	0.0	2.023	0.045	17	5	2	358
PL.37552	PL.37536	ABC	336 MCM AC	7.39Y	123.1	0.03	1.86	98.66	19	2086	658	95	0.32	0.0	2.061	0.039	0	0	0	356
PL.38450	PL.37552	ABC	336 MCM AC	7.39Y	123.1	0.02	1.88	98.66	19	2086	658	95	0.21	0.0	2.088	0.026	0	0	0	356
PL.37109	PL.38450	C	#2 ACSR	7.39Y	123.1	0.02	1.89	36.47	21	258	77	96	0.03	0.0	2.103	0.016	0	0	0	41
PL.37532	PL.37109	C	#2 ACSR	7.39Y	123.1	0.00	1.89	36.47	21	258	77	96	0.00	0.0	2.104	0.001	0	0	0	41
PD.6085	PL.37532	C	50L	7.39Y	123.1	0.00	1.89	36.47	73	258	77	96	0.00	0.0	2.104	0.001	0	0	0	41
PL.37533	PD.6085	C	#2 ACSR	7.38Y	123.1	0.05	1.94	36.47	21	258	77	96	0.09	0.0	2.148	0.044	5	2	1	41
PL.37551	PL.37533	C	#2 ACSR	7.38Y	123.0	0.04	1.98	35.72	20	253	76	96	0.07	0.0	2.181	0.033	1	0	1	40
PL.37531	PL.37551	C	#2 ACSR	7.38Y	123.0	0.06	2.05	35.52	20	251	75	96	0.11	0.0	2.237	0.057	4	1	2	39
PL.37550	PL.37531	C	#2 ACSR	7.37Y	122.8	0.11	2.15	34.99	20	247	74	96	0.19	0.1	2.336	0.099	8	2	1	37
PL.37184	PL.37550	C	#2 ACSR	7.37Y	122.8	0.09	2.24	33.90	19	239	72	96	0.15	0.1	2.418	0.082	13	4	1	36
PL.37183	PL.37184	C	#2 ACSR	7.36Y	122.7	0.06	2.30	32.03	18	226	68	96	0.10	0.0	2.482	0.063	9	3	1	35
PL.37529	PL.37183	C	#2 ACSR	7.35Y	122.6	0.12	2.43	30.80	18	217	65	96	0.19	0.1	2.611	0.130	10	3	3	34
PL.37530	PL.37529	C	#2 ACSR	7.35Y	122.5	0.09	2.52	28.10	16	198	59	96	0.13	0.1	2.713	0.102	1	0	1	30
PL.37343	PL.37530	C	6 A (CWC)	7.34Y	122.4	0.07	2.59	20.76	15	146	44	96	0.08	0.1	2.785	0.072	0	0	0	23
PL.37317	PL.37343	C	6 A (CWC)	7.34Y	122.3	0.13	2.71	19.90	14	140	42	96	0.13	0.1	2.923	0.138	0	0	0	22
PL.37523	PL.37317	C	6 A (CWC)	7.33Y	122.1	0.17	2.88	17.81	13	125	37	96	0.15	0.1	3.139	0.216	15	4	3	20
PL.37522	PL.37523	C	6 A (CWC)	7.32Y	122.0	0.11	2.99	15.71	11	110	33	96	0.09	0.1	3.302	0.163	8	2	1	17

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37521	PL.37522	C	6 A (CWC)	7.32Y	122.0	0.03	3.03	14.59	10	102	30	96	0.03	0.0	3.350	0.049	0	0	0	16
PL.37915	PL.37521	C	6 A (CWC)	7.32Y	121.9	0.03	3.06	12.75	9	89	27	96	0.02	0.0	3.406	0.055	8	2	2	15
PL.64506	PL.37915	C	6 A (CWC)	7.32Y	121.9	0.00	3.06	11.56	8	81	24	96	0.00	0.0	3.406	0.000	0	0	0	13
PL.64507	PL.64506	C	6 A (CWC)	7.31Y	121.9	0.03	3.09	11.56	8	81	24	96	0.02	0.0	3.470	0.065	0	0	0	13
PL.37914	PL.64507	C	6 A (CWC)	7.31Y	121.9	0.04	3.13	11.56	8	81	24	96	0.03	0.0	3.550	0.080	2	1	1	13
PL.37913	PL.37914	C	6 A (CWC)	7.31Y	121.8	0.05	3.18	11.20	8	79	23	96	0.03	0.0	3.643	0.092	4	1	1	12
PL.37252	PL.37913	C	#4 ACSR	7.31Y	121.8	0.00	3.18	0.00	0	0	0	100	0.00	0.0	3.702	0.059	0	0	0	0
PL.37912	PL.37913	C	6 A (CWC)	7.31Y	121.8	0.03	3.21	10.65	8	75	22	96	0.01	0.0	3.721	0.078	30	9	4	11
PL.37910	PL.37912	C	6 A (CWC)	7.31Y	121.8	0.03	3.24	6.34	5	44	13	96	0.01	0.0	3.825	0.104	12	4	1	7
PL.37911	PL.37910	C	6 A (CWC)	7.30Y	121.7	0.02	3.25	4.61	3	32	10	95	0.00	0.0	3.908	0.084	9	3	2	6
PL.37827	PL.37911	C	6 A (CWC)	7.30Y	121.7	0.00	3.25	3.27	2	23	7	96	0.00	0.0	3.926	0.018	0	0	0	4
PL.36870	PL.37827	C	#4 ACSR	7.30Y	121.7	0.00	3.25	0.00	0	0	0	100	0.00	0.0	3.964	0.038	0	0	1	1
PL.37909	PL.37827	C	6 A (CWC)	7.30Y	121.7	0.01	3.26	3.27	2	23	7	96	0.00	0.0	3.985	0.059	0	0	0	3
PL.61044	PL.37909	C	6 A (CWC)	7.30Y	121.7	0.01	3.27	3.27	2	23	7	96	0.00	0.0	4.063	0.078	12	4	1	3
PL.61045	PL.61044	C	6 A (CWC)	7.30Y	121.7	0.01	3.29	1.51	1	11	3	96	0.00	0.0	4.486	0.424	11	3	2	2
PL.38411	PL.37521	C	6 A (CWC)	7.32Y	122.0	0.01	3.04	1.85	1	13	4	96	0.00	0.0	3.496	0.145	0	0	0	1
PL.37916	PL.38411	C	6 A (CWC)	7.32Y	122.0	0.00	3.04	1.85	1	13	4	96	0.00	0.0	3.515	0.019	0	0	0	1
PL.37917	PL.37916	C	6 A (CWC)	7.32Y	122.0	0.01	3.05	1.85	1	13	4	96	0.00	0.0	3.587	0.071	0	0	0	1
PL.37918	PL.37917	C	6 A (CWC)	7.32Y	121.9	0.01	3.05	1.85	1	13	4	96	0.00	0.0	3.647	0.061	0	0	0	1
PL.37919	PL.37918	C	6 A (CWC)	7.32Y	121.9	0.00	3.05	1.85	1	13	4	96	0.00	0.0	3.710	0.063	13	4	1	1
PL.37524	PL.37317	C	#4 ACSR	7.34Y	122.3	0.00	2.72	2.09	2	15	4	97	0.00	0.0	2.984	0.062	7	2	1	2
PL.37525	PL.37524	C	#4 ACSR	7.34Y	122.3	0.00	2.72	1.12	1	8	2	97	0.00	0.0	3.025	0.041	8	2	1	1
PL.37397	PL.37343	C	6 A (CWC)	7.34Y	122.4	0.00	2.59	0.86	1	6	2	95	0.00	0.0	2.828	0.043	6	2	1	1
PL.37318	PL.37530	C	6 A (CWC)	7.35Y	122.5	0.02	2.54	7.27	5	51	15	96	0.01	0.0	2.779	0.066	11	3	1	6
PL.37526	PL.37318	C	6 A (CWC)	7.35Y	122.5	0.01	2.54	5.76	4	41	12	96	0.00	0.0	2.798	0.019	0	0	0	5
PL.37491	PL.37526	C	6 A (CWC)	7.35Y	122.5	0.00	2.55	3.70	3	26	8	96	0.00	0.0	2.856	0.058	26	8	3	3
PL.37527	PL.37526	C	6 A (CWC)	7.35Y	122.5	0.00	2.54	2.06	1	14	4	96	0.00	0.0	2.830	0.031	10	3	1	2
PL.37528	PL.37527	C	6 A (CWC)	7.35Y	122.5	0.00	2.55	0.69	0	5	1	98	0.00	0.0	2.884	0.054	5	1	1	1
PL.37710	PL.37318	C	#2 ACSR	7.35Y	122.5	0.00	2.54	0.00	0	0	0	100	0.00	0.0	2.819	0.040	0	0	0	0
PL.37274	PL.37529	C	6 A (CWC)	7.35Y	122.6	0.00	2.43	1.27	1	9	3	95	0.00	0.0	2.669	0.058	9	3	1	1
PL.37534	PL.38450	ABC	336 MCM AC	7.39Y	123.1	0.03	1.91	86.50	17	1827	580	95	0.31	0.0	2.136	0.049	5	1	1	315

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37535	PL.37534	ABC	336 MCM AC	7.38Y	123.0	0.06	1.97	86.26	17	1822	578	95	0.58	0.0	2.229	0.093	13	4	2	314
PL.52651	PL.37535	ABC	336 MCM AC	7.38Y	122.9	0.09	2.06	85.64	17	1808	572	95	0.86	0.0	2.369	0.140	0	0	0	312
PL.52650	PL.52651	ABC	336 MCM AC	7.38Y	122.9	0.00	2.06	85.64	17	1807	570	95	0.01	0.0	2.370	0.002	0	0	0	312
PL.38143	PL.52650	ABC	336 MCM AC	7.37Y	122.9	0.04	2.10	85.64	17	1807	570	95	0.33	0.0	2.423	0.053	0	0	0	312
PL.38142	PL.38143	ABC	336 MCM AC	7.37Y	122.9	0.02	2.12	85.64	17	1807	570	95	0.14	0.0	2.447	0.023	7	2	1	312
PL.63063	PL.38142	A	#1/0 ACSR	7.37Y	122.9	0.00	2.12	0.79	0	6	2	95	0.00	0.0	2.450	0.003	0	0	0	1
PD.9412	PL.63063	A	25T	7.37Y	122.9	0.00	2.12	0.79	0	6	2	95	0.00	0.0	2.450	0.003	0	0	0	1
PL.63064	PD.9412	A	#1/0 ACSR	7.37Y	122.9	0.00	2.12	0.79	0	6	2	95	0.00	0.0	2.481	0.032	6	2	1	1
PL.38141	PL.38142	ABC	336 MCM AC	7.37Y	122.9	0.03	2.14	85.07	16	1795	566	95	0.24	0.0	2.487	0.040	0	0	0	310
PL.37084	PL.38141	A	#2 ACSR	7.37Y	122.9	0.00	2.14	1.91	1	13	4	96	0.00	0.0	2.487	0.001	0	0	0	4
PD.5975	PL.37084	A	60QA	7.37Y	122.9	0.00	2.14	1.91	3	13	4	96	0.00	0.0	2.487	0.001	0	0	0	4
PL.38590	PD.5975	A	#2 ACSR	7.37Y	122.9	0.00	2.14	1.91	1	13	4	96	0.00	0.0	2.503	0.015	13	4	4	4
PL.38591	PL.38141	ABC	336 MCM AC	7.37Y	122.8	0.06	2.21	84.43	16	1781	561	95	0.60	0.0	2.586	0.099	8	2	2	306
PL.37504	PL.38591	ABC	336 MCM AC	7.37Y	122.8	0.04	2.25	84.06	16	1772	557	95	0.37	0.0	2.649	0.063	4	1	1	304
PL.64784	PL.37504	ABC	336 MCM AC	7.36Y	122.7	0.04	2.29	83.87	16	1768	555	95	0.38	0.0	2.714	0.065	14	4	1	303
PL.64783	PL.64784	ABC	336 MCM AC	7.36Y	122.7	0.00	2.29	83.22	16	1754	550	95	0.00	0.0	2.714	0.000	0	0	0	302
PL.37503	PL.64783	ABC	336 MCM AC	7.36Y	122.7	0.03	2.32	83.22	16	1754	550	95	0.29	0.0	2.764	0.050	0	0	0	302
PL.37499	PL.37503	ABC	336 MCM AC	7.35Y	122.6	0.12	2.44	83.22	16	1753	550	95	1.12	0.1	2.955	0.191	0	0	0	301
PL.37498	PL.37499	ABC	336 MCM AC	7.35Y	122.5	0.09	2.53	83.22	16	1752	547	95	0.81	0.0	3.093	0.138	0	0	0	301
PL.37832	PL.37498	A	#1/0 ACSR	7.35Y	122.5	0.00	2.53	1.10	0	8	2	97	0.00	0.0	3.213	0.119	8	2	1	1
PL.38217	PL.37498	ABC	336 MCM AC	7.34Y	122.4	0.09	2.62	82.85	16	1744	543	95	0.82	0.0	3.235	0.141	7	2	3	300
PL.37497	PL.38217	ABC	336 MCM AC	7.33Y	122.2	0.16	2.78	82.50	16	1736	539	96	1.42	0.1	3.483	0.248	6	2	1	297
PL.37496	PL.37497	ABC	336 MCM AC	7.33Y	122.2	0.04	2.82	82.21	16	1728	534	96	0.33	0.0	3.540	0.057	0	0	0	296
PL.38216	PL.37496	ABC	336 MCM AC	7.33Y	122.2	0.02	2.84	82.21	16	1728	533	96	0.16	0.0	3.569	0.029	0	0	0	296
PL.38215	PL.38216	ABC	336 MCM AC	7.33Y	122.1	0.04	2.87	82.21	16	1728	532	96	0.33	0.0	3.627	0.058	0	0	0	296
PL.58501	PL.38215	C	6 A (CWC)	7.33Y	122.1	0.00	2.87	3.30	2	23	7	96	0.00	0.0	3.630	0.003	0	0	0	5
PD.8698	PL.58501	C	20T	7.33Y	122.1	0.00	2.87	3.30	0	23	7	96	0.00	0.0	3.630	0.003	0	0	0	5
PL.58502	PD.8698	C	6 A (CWC)	7.33Y	122.1	0.01	2.88	3.30	2	23	7	96	0.00	0.0	3.666	0.036	0	0	1	5
PL.64235	PL.58502	C	6 A (CWC)	7.33Y	122.1	0.00	2.88	3.30	2	23	7	96	0.00	0.0	3.693	0.027	0	0	0	4
PL.64020	PL.64235	C	6 A (CWC)	7.33Y	122.1	0.00	2.88	0.23	0	2	0	100	0.00	0.0	3.923	0.230	0	0	0	1
PL.64021	PL.64020	C	6 A (CWC)	7.33Y	122.1	0.00	2.88	0.23	0	2	0	100	0.00	0.0	4.029	0.107	2	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64234	PL.64235	C	6 A (CWC)	7.33Y	122.1	0.00	2.89	3.07	2	22	6	96	0.00	0.0	3.728	0.036	12	4	2	3
PL.38437	PL.64234	C	6 A (CWC)	7.33Y	122.1	0.00	2.89	1.39	1	10	3	96	0.00	0.0	3.798	0.070	10	3	1	1
PL.37904	PL.38215	ABC	336 MCM AC	7.32Y	122.0	0.12	2.99	81.11	16	1704	525	96	1.08	0.1	3.821	0.194	0	0	0	291
PL.37903	PL.37904	ABC	336 MCM AC	7.32Y	122.0	0.05	3.04	81.11	16	1703	522	96	0.46	0.0	3.903	0.082	0	0	0	291
PL.37335	PL.37903	ABC	336 MCM AC	7.32Y	121.9	0.02	3.06	81.11	16	1703	521	96	0.17	0.0	3.933	0.030	0	0	0	291
PL.37213	PL.37335	ABC	336 MCM AC	7.31Y	121.9	0.02	3.09	60.67	12	1273	391	96	0.15	0.0	3.982	0.049	0	0	0	228
PL.38044	PL.37213	A	#2 ACSR	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	3.982	0.000	0	0	0	0
PD.6026	PL.38044	A	60QA	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	3.982	0.000	0	0	0	0
PL.37241	PD.6026	A	#2 ACSR	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	4.001	0.019	0	0	0	0
PL.37334	PL.37241	A	#2 ACSR	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	4.020	0.019	0	0	0	0
PL.37239	PL.37213	C	#2 ACSR	7.31Y	121.9	0.00	3.09	0.41	0	3	1	95	0.00	0.0	3.982	0.000	0	0	0	1
PD.5994	PL.37239	C	60QA	7.31Y	121.9	0.00	3.09	0.41	1	3	1	95	0.00	0.0	3.982	0.000	0	0	0	1
PL.37240	PD.5994	C	#2 ACSR	7.31Y	121.9	0.00	3.09	0.41	0	3	1	95	0.00	0.0	4.217	0.235	0	0	0	1
PL.37492	PL.37240	C	#2 ACSR	7.31Y	121.9	0.00	3.09	0.41	0	3	1	95	0.00	0.0	4.361	0.143	0	0	0	1
PL.37493	PL.37492	C	#2 ACSR	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	4.417	0.057	0	0	0	0
PL.37824	PL.37492	C	#4 ACSR	7.31Y	121.9	0.00	3.09	0.41	0	3	1	95	0.00	0.0	4.458	0.097	3	1	1	1
PL.38041	PL.37213	ABC	336 MCM AC	7.31Y	121.9	0.03	3.12	60.54	12	1270	390	96	0.20	0.0	4.048	0.066	0	0	0	227
PL.37297	PL.38041	ABC	336 MCM AC	7.31Y	121.8	0.07	3.19	60.54	12	1270	390	96	0.49	0.0	4.208	0.160	0	0	0	227
PL.38037	PL.37297	ABC	336 MCM AC	7.31Y	121.8	0.04	3.23	60.54	12	1269	388	96	0.30	0.0	4.304	0.096	0	0	0	227
PL.38036	PL.38037	ABC	336 MCM AC	7.30Y	121.7	0.03	3.26	60.54	12	1269	388	96	0.17	0.0	4.358	0.054	0	0	0	227
PL.38035	PL.38036	ABC	336 MCM AC	7.30Y	121.7	0.01	3.27	60.54	12	1269	387	96	0.09	0.0	4.389	0.031	0	0	0	227
PL.38034	PL.38035	ABC	336 MCM AC	7.30Y	121.7	0.02	3.30	60.54	12	1269	387	96	0.15	0.0	4.437	0.048	0	0	0	227
PL.38031	PL.38034	ABC	336 MCM AC	7.30Y	121.7	0.02	3.32	59.81	12	1253	382	96	0.15	0.0	4.485	0.048	0	0	0	226
PL.38134	PL.38031	ABC	336 MCM AC	7.30Y	121.6	0.05	3.37	58.59	11	1228	374	96	0.35	0.0	4.605	0.120	0	0	0	223
PL.58505	PL.38134	A	#2 ACSR	7.30Y	121.6	0.00	3.37	17.32	10	121	36	96	0.00	0.0	4.607	0.002	0	0	0	20
PD.8699	PL.58505	A	25T	7.30Y	121.6	0.00	3.37	17.32	0	121	36	96	0.00	0.0	4.607	0.002	0	0	0	20
PL.58506	PD.8699	A	#2 ACSR	7.30Y	121.6	0.01	3.39	17.32	10	121	36	96	0.01	0.0	4.629	0.022	0	0	0	20
PL.58503	PL.58506	A	#2 ACSR	7.30Y	121.6	0.03	3.41	9.44	5	66	20	96	0.01	0.0	4.728	0.099	6	2	1	11
PL.37900	PL.58503	A	#2 ACSR	7.29Y	121.6	0.01	3.42	8.55	5	60	18	96	0.00	0.0	4.754	0.026	0	0	0	10
PL.38103	PL.37900	A	#2 ACSR	7.29Y	121.6	0.02	3.44	8.55	5	60	18	96	0.01	0.0	4.834	0.079	0	0	0	10
PL.38104	PL.38103	A	#2 ACSR	7.29Y	121.6	0.00	3.45	2.98	2	21	6	96	0.00	0.0	4.882	0.048	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37382	PL.38104	A	#2 ACSR	7.29Y	121.6	0.00	3.45	0.00	0	0	0	100	0.00	0.0	4.928	0.046	0	0	0	0
PL.38105	PL.38104	A	#2 ACSR	7.29Y	121.5	0.01	3.45	2.98	2	21	6	96	0.00	0.0	4.937	0.055	0	0	2	5
PL.37969	PL.38105	A	#2 ACSR	7.29Y	121.5	0.00	3.45	2.00	1	14	4	96	0.00	0.0	5.010	0.073	14	4	2	2
PL.37970	PL.37969	A	#2 ACSR	7.29Y	121.5	0.00	3.45	0.00	0	0	0	100	0.00	0.0	5.064	0.054	0	0	0	0
PL.37628	PL.38105	A	#2 ACSR	7.29Y	121.5	0.00	3.45	0.94	1	7	2	96	0.00	0.0	4.962	0.025	7	2	1	1
PL.37812	PL.38103	A	#2 ACSR	7.29Y	121.5	0.01	3.45	5.57	3	39	12	96	0.00	0.0	4.928	0.095	39	12	5	5
PL.58504	PL.58506	A	#2 ACSR	7.30Y	121.6	0.02	3.40	7.88	5	55	16	96	0.01	0.0	4.701	0.072	14	4	2	9
PL.37872	PL.58504	A	#2 ACSR	7.30Y	121.6	0.00	3.40	0.00	0	0	0	100	0.00	0.0	4.749	0.048	0	0	1	1
PL.37901	PL.58504	A	#2 ACSR	7.30Y	121.6	0.01	3.42	5.85	3	41	12	96	0.00	0.0	4.780	0.079	0	0	0	6
PL.38106	PL.37901	A	#2 ACSR	7.29Y	121.6	0.01	3.42	3.98	2	28	8	96	0.00	0.0	4.827	0.047	7	2	2	3
PL.38107	PL.38106	A	#2 ACSR	7.29Y	121.6	0.00	3.42	2.91	2	20	6	96	0.00	0.0	4.864	0.037	20	6	1	1
PL.37971	PL.37901	A	#1/0 ACSR	7.29Y	121.6	0.00	3.42	1.87	1	13	4	96	0.00	0.0	4.816	0.036	1	0	1	3
PL.38336	PL.37971	A	#1/0 ACSR	7.29Y	121.6	0.00	3.42	1.78	1	12	4	95	0.00	0.0	4.849	0.033	12	4	2	2
PL.37890	PL.38134	ABC	336 MCM AC	7.30Y	121.6	0.02	3.39	52.82	10	1106	338	96	0.12	0.0	4.655	0.050	0	0	0	203
PL.37966	PL.37890	ABC	336 MCM AC	7.30Y	121.6	0.00	3.39	52.82	10	1106	337	96	0.01	0.0	4.660	0.005	0	0	0	203
PL.37968	PL.37966	ABC	336 MCM AC	7.30Y	121.6	0.00	3.40	52.82	10	1106	337	96	0.00	0.0	4.661	0.001	0	0	0	203
PL.37967	PL.37968	ABC	336 MCM AC	7.30Y	121.6	0.02	3.41	52.82	10	1106	337	96	0.09	0.0	4.701	0.040	10	3	1	203
PL.37965	PL.37967	ABC	336 MCM AC	7.29Y	121.6	0.01	3.42	52.33	10	1096	334	96	0.06	0.0	4.727	0.026	9	3	2	202
PL.37964	PL.37965	ABC	336 MCM AC	7.29Y	121.5	0.03	3.45	51.91	10	1087	331	96	0.17	0.0	4.802	0.075	12	4	2	200
PL.37963	PL.37964	ABC	336 MCM AC	7.29Y	121.5	0.02	3.47	51.32	10	1074	327	96	0.11	0.0	4.854	0.052	3	1	1	198
PL.37579	PL.37963	ABC	336 MCM AC	7.29Y	121.5	0.03	3.50	51.16	10	1071	326	96	0.15	0.0	4.924	0.071	10	3	1	197
PL.37578	PL.37579	ABC	336 MCM AC	7.29Y	121.5	0.03	3.53	50.70	10	1061	323	96	0.16	0.0	4.998	0.074	0	0	0	196
PL.37576	PL.37578	A	#2 ACSR	7.29Y	121.5	0.00	3.53	0.31	0	2	1	89	0.00	0.0	4.998	0.000	0	0	0	1
PD.6058	PL.37576	A	60QA	7.29Y	121.5	0.00	3.53	0.31	1	2	1	89	0.00	0.0	4.998	0.000	0	0	0	1
PL.37577	PD.6058	A	#2 ACSR	7.29Y	121.5	0.00	3.53	0.31	0	2	1	89	0.00	0.0	5.038	0.039	2	1	1	1
PL.37574	PL.37578	ABC	336 MCM AC	7.29Y	121.5	0.02	3.55	50.60	10	1059	322	96	0.11	0.0	5.048	0.050	0	0	0	195
PL.37569	PL.37574	ABC	336 MCM AC	7.29Y	121.4	0.02	3.57	50.60	10	1059	321	96	0.12	0.0	5.101	0.053	0	0	0	195
PL.37566	PL.37569	ABC	336 MCM AC	7.28Y	121.4	0.05	3.61	28.20	5	590	179	96	0.14	0.0	5.316	0.215	0	0	0	119
PL.37342	PL.37566	ABC	336 MCM AC	7.28Y	121.4	0.03	3.64	27.69	5	579	176	96	0.09	0.0	5.462	0.145	0	0	0	118
PL.61039	PL.37342	ABC	336 MCM AC	7.28Y	121.3	0.01	3.66	25.56	5	534	162	96	0.04	0.0	5.536	0.074	8	2	1	111
PL.61038	PL.61039	ABC	336 MCM AC	7.28Y	121.3	0.05	3.71	25.19	5	526	160	96	0.15	0.0	5.818	0.282	4	1	2	110

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.39309	PL.61038	ABC	336 MCM AC	7.28Y	121.3	0.00	3.71	25.01	5	523	158	96	0.00	0.0	5.819	0.001	0	0	0	108
PD.5246	PL.39309	ABC	60QA	7.28Y	121.3	0.00	3.71	25.01	42	523	158	96	0.00	0.0	5.819	0.001	0	0	0	108
PL.39308	PD.5246	ABC	336 MCM AC	7.28Y	121.3	0.01	3.72	25.01	5	523	158	96	0.02	0.0	5.860	0.041	0	0	0	108
PL.37564	PL.39308	ABC	336 MCM AC	7.28Y	121.3	0.01	3.73	25.01	5	523	158	96	0.02	0.0	5.902	0.043	9	3	2	108
PL.37563	PL.37564	ABC	336 MCM AC	7.27Y	121.2	0.03	3.76	24.60	5	514	156	96	0.08	0.0	6.064	0.162	0	0	0	106
PL.37561	PL.37563	A	6 A (CWC)	7.27Y	121.2	0.00	3.76	1.10	1	8	2	97	0.00	0.0	6.064	0.001	0	0	0	1
PD.5892	PL.37561	A	60QA	7.27Y	121.2	0.00	3.76	1.10	2	8	2	97	0.00	0.0	6.064	0.001	0	0	0	1
PL.37562	PD.5892	A	6 A (CWC)	7.27Y	121.2	0.00	3.76	1.10	1	8	2	97	0.00	0.0	6.101	0.037	8	2	1	1
PL.37560	PL.37563	ABC	336 MCM AC	7.27Y	121.2	0.01	3.77	24.23	5	506	153	96	0.04	0.0	6.142	0.078	8	2	1	105
PL.36769	PL.37560	ABC	336 MCM AC	7.27Y	121.2	0.02	3.80	23.85	5	498	151	96	0.06	0.0	6.267	0.125	3	1	2	104
PL.36768	PL.36769	ABC	336 MCM AC	7.27Y	121.2	0.02	3.82	23.71	5	495	150	96	0.06	0.0	6.393	0.126	0	0	0	102
PL.36767	PL.36768	ABC	336 MCM AC	7.27Y	121.2	0.02	3.84	23.71	5	495	150	96	0.06	0.0	6.511	0.118	5	1	1	102
PL.37549	PL.36767	ABC	336 MCM AC	7.27Y	121.2	0.00	3.85	23.48	5	490	148	96	0.01	0.0	6.533	0.022	0	0	0	101
PL.36747	PL.37549	ABC	336 MCM AC	7.27Y	121.2	0.00	3.85	23.48	5	490	148	96	0.01	0.0	6.553	0.020	0	0	0	101
PD.5908	PL.36747	ABC	280VWE	7.27Y	121.2	0.00	3.85	23.48	0	490	148	96	0.00	0.0	6.553	0.020	0	0	0	101
PL.38045	PD.5908	ABC	336 MCM AC	7.27Y	121.2	0.00	3.85	23.48	5	490	148	96	0.00	0.0	6.554	0.001	0	0	0	101
PL.36748	PL.38045	ABC	336 MCM AC	7.27Y	121.1	0.01	3.86	23.48	5	490	148	96	0.04	0.0	6.630	0.076	0	0	0	101
PL.38163	PL.36748	ABC	336 MCM AC	7.27Y	121.1	0.01	3.87	5.11	1	107	32	96	0.01	0.0	6.951	0.322	0	0	0	26
PL.38167	PL.38163	ABC	336 MCM AC	7.27Y	121.1	0.00	3.88	5.11	1	107	31	96	0.00	0.0	7.033	0.082	3	1	1	25
PL.38166	PL.38167	ABC	336 MCM AC	7.27Y	121.1	0.01	3.88	4.99	1	104	31	96	0.00	0.0	7.185	0.152	3	1	1	24
PL.38164	PL.38166	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	4.84	1	101	30	96	0.00	0.0	7.295	0.110	0	0	0	23
PL.38050	PL.38164	B	6 A (CWC)	7.27Y	121.1	0.02	3.91	11.49	8	80	24	96	0.01	0.0	7.336	0.041	0	0	0	15
PD.6089	PL.38050	B	50L	7.27Y	121.1	0.00	3.91	11.49	23	80	24	96	0.00	0.0	7.336	0.041	0	0	0	15
PL.38358	PD.6089	B	6 A (CWC)	7.26Y	121.1	0.03	3.94	11.49	8	80	24	96	0.02	0.0	7.404	0.069	11	3	2	15
PL.37870	PL.38358	B	6 A (CWC)	7.26Y	121.0	0.06	4.01	9.90	7	69	21	96	0.03	0.0	7.546	0.141	0	0	0	13
PL.37326	PL.37870	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	1.31	1	9	3	95	0.00	0.0	7.607	0.061	9	3	2	2
PL.38359	PL.37870	B	6 A (CWC)	7.25Y	120.9	0.11	4.12	8.59	6	60	18	96	0.05	0.1	7.833	0.287	5	1	1	11
PL.38360	PL.38359	B	6 A (CWC)	7.25Y	120.8	0.06	4.17	7.32	5	51	15	96	0.02	0.0	8.005	0.173	0	0	0	9
PL.37672	PL.38360	B	#4 ACSR	7.25Y	120.8	0.00	4.17	0.00	0	0	0	100	0.00	0.0	8.054	0.049	0	0	0	0
PL.61403	PL.38360	B	#1/0 ACSR	7.25Y	120.8	0.00	4.17	0.00	0	0	0	100	0.00	0.0	8.047	0.042	0	0	1	1
PL.62828	PL.38360	B	6 A (CWC)	7.25Y	120.8	0.03	4.21	7.32	5	51	15	96	0.01	0.0	8.097	0.092	0	0	0	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62829	PL.62828	B	6 A (CWC)	7.25Y	120.8	0.02	4.23	5.81	4	40	12	96	0.01	0.0	8.172	0.075	0	0	0	6
PL.62831	PL.62829	B	#1/0 ACSR	7.25Y	120.8	0.00	4.23	1.18	1	8	2	97	0.00	0.0	8.175	0.003	0	0	0	1
PD.9135	PL.62831	B	15T	7.25Y	120.8	0.00	4.23	1.18	0	8	2	97	0.00	0.0	8.175	0.003	0	0	0	1
PL.61389	PD.9135	B	#1/0 ACSR	7.25Y	120.8	0.00	4.23	1.18	1	8	2	97	0.00	0.0	8.224	0.048	8	2	1	1
PL.62830	PL.62829	B	6 A (CWC)	7.24Y	120.7	0.03	4.26	4.63	3	32	10	95	0.01	0.0	8.321	0.149	3	1	1	5
PL.38361	PL.62830	B	6 A (CWC)	7.24Y	120.7	0.03	4.29	4.25	3	30	9	96	0.01	0.0	8.473	0.151	0	0	0	4
PL.37826	PL.38361	B	#4 ACSR	7.24Y	120.7	0.00	4.29	0.27	0	2	1	89	0.00	0.0	8.529	0.057	2	1	1	1
PL.38859	PL.38361	B	6 A (CWC)	7.24Y	120.7	0.03	4.32	3.98	3	28	8	96	0.01	0.0	8.657	0.184	7	2	1	3
PL.37437	PL.38859	B	6 A (CWC)	7.24Y	120.7	0.02	4.33	2.94	2	20	6	96	0.00	0.0	8.776	0.119	0	0	0	2
PL.38860	PL.37437	B	6 A (CWC)	7.24Y	120.6	0.08	4.41	2.94	2	20	6	96	0.01	0.1	9.551	0.775	9	3	1	2
PL.38861	PL.38860	B	6 A (CWC)	7.24Y	120.6	0.00	4.41	1.58	1	11	3	96	0.00	0.0	9.603	0.052	11	3	1	1
PL.38862	PL.38861	B	6 A (CWC)	7.24Y	120.6	0.00	4.41	0.00	0	0	0	100	0.00	0.0	9.632	0.029	0	0	0	0
PL.62832	PL.62828	B	#1/0 ACSR	7.25Y	120.8	0.00	4.21	1.51	1	11	3	96	0.00	0.0	8.152	0.055	11	3	2	2
PL.37671	PL.38359	B	#4 ACSR	7.25Y	120.9	0.00	4.12	0.61	0	4	1	97	0.00	0.0	7.956	0.124	4	1	1	1
PL.37473	PL.38164	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	1.01	0	21	6	96	0.00	0.0	7.359	0.065	0	0	0	8
PL.38365	PL.37473	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	1.01	0	21	6	96	0.00	0.0	7.532	0.173	0	0	0	8
PL.38863	PL.38365	A	#2 ACSR	7.27Y	121.1	0.00	3.89	0.63	0	4	1	97	0.00	0.0	7.533	0.001	0	0	0	1
PD.5240	PL.38863	A	60QA	7.27Y	121.1	0.00	3.89	0.63	1	4	1	97	0.00	0.0	7.533	0.001	0	0	0	1
PL.38864	PD.5240	A	#2 ACSR	7.27Y	121.1	0.00	3.89	0.63	0	4	1	97	0.00	0.0	7.589	0.056	4	1	1	1
PL.38364	PL.38365	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.80	0	17	5	96	0.00	0.0	7.606	0.073	0	0	0	7
PL.38366	PL.38364	A	6 A (CWC)	7.27Y	121.1	0.00	3.89	2.12	2	15	4	97	0.00	0.0	7.608	0.002	0	0	0	6
PD.6016	PL.38366	A	75QA	7.27Y	121.1	0.00	3.89	2.12	3	15	4	97	0.00	0.0	7.608	0.002	0	0	0	6
PL.38367	PD.6016	A	6 A (CWC)	7.27Y	121.1	0.01	3.90	2.12	2	15	4	97	0.00	0.0	7.706	0.098	2	1	1	6
PL.38368	PL.38367	A	6 A (CWC)	7.26Y	121.1	0.04	3.94	1.83	1	13	3	97	0.00	0.0	8.236	0.529	0	0	0	5
PL.38369	PL.38368	A	6 A (CWC)	7.26Y	121.1	0.01	3.95	1.83	1	13	3	97	0.00	0.0	8.301	0.065	0	0	0	5
PL.61410	PL.38369	A	6 A (CWC)	7.26Y	121.0	0.01	3.96	1.83	1	13	3	97	0.00	0.0	8.444	0.143	0	0	0	5
PL.61411	PL.61410	A	6 A (CWC)	7.26Y	121.0	0.01	3.97	1.83	1	13	4	96	0.00	0.0	8.598	0.153	0	0	0	4
PL.37876	PL.61411	A	#4 ACSR	7.26Y	121.0	0.00	3.97	0.74	1	5	2	93	0.00	0.0	8.661	0.063	5	2	2	2
PL.38370	PL.61411	A	6 A (CWC)	7.26Y	121.0	0.00	3.98	1.09	1	8	2	97	0.00	0.0	8.673	0.075	2	1	1	2
PL.38371	PL.38370	A	6 A (CWC)	7.26Y	121.0	0.01	3.98	0.85	1	6	2	95	0.00	0.0	8.983	0.311	6	2	1	1
PL.61413	PL.61410	A	#1/0 ACSR	7.26Y	121.0	0.00	3.96	0.04	0	0	0	100	0.00	0.0	8.448	0.003	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.9138	PL.61413	A	25T	7.26Y	121.0	0.00	3.96	0.04	0	0	0	100	0.00	0.0	8.448	0.003	0	0	0	1
PL.61414	PD.9138	A	#1/0 ACSR	7.26Y	121.0	-0.00	3.96	0.04	0	0	0	100	0.00	0.0	8.498	0.050	0	0	0	1
PL.61412	PL.61414	A	1/0 AL URD	7.26Y	121.0	-0.00	3.96	0.04	0	0	0	100	0.00	0.0	8.579	0.081	0	0	1	1
PL.38440	PL.38364	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.09	0	2	1	89	0.00	0.0	7.726	0.120	2	1	1	1
PL.38655	PL.38440	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.755	0.029	0	0	0	0
PL.38656	PL.38655	C	#4 ACSR	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.755	0.001	0	0	0	0
PD.5245	PL.38656	C	75QA	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.755	0.001	0	0	0	0
PL.38657	PD.5245	C	#4 ACSR	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.823	0.067	0	0	0	0
PL.37324	PL.38655	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.811	0.056	0	0	0	0
PL.37323	PL.37324	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	7.897	0.086	0	0	0	0
PL.62171	PL.37323	ABC	336 MCM AC	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	8.365	0.468	0	0	0	0
PD.9281-B	PL.62171	ABC	Open	7.27Y	121.1	0.00	3.89	0.00	0	0	0	100	0.00	0.0	8.365	0.468	0	0	0	0
PL.38048	PL.38163	A	#4 ACSR	7.27Y	121.1	0.00	3.87	0.00	0	0	0	100	0.00	0.0	6.955	0.004	0	0	0	1
PD.5244	PL.38048	A	50QA	7.27Y	121.1	0.00	3.87	0.00	0	0	0	100	0.00	0.0	6.955	0.004	0	0	0	1
PL.38049	PD.5244	A	#4 ACSR	7.27Y	121.1	0.00	3.87	0.00	0	0	0	100	0.00	0.0	6.995	0.040	0	0	1	1
PL.58009	PL.36748	A	#4 ACSR	7.26Y	121.0	0.18	4.04	55.11	42	383	116	96	0.52	0.1	6.701	0.071	0	0	0	75
PL.58011	PL.58009	A	#4 ACSR	7.26Y	121.0	0.00	4.04	55.11	42	383	116	96	0.01	0.0	6.703	0.002	0	0	0	75
C PD.8398	PL.58011	A	50L	7.26Y	121.0	0.00	4.04	55.11	110	383	116	96	0.00	0.0	6.703	0.002	0	0	0	75 C
PL.58013	PD.8398	A	#4 ACSR	7.24Y	120.6	0.37	4.41	55.11	42	383	116	96	1.08	0.3	6.851	0.148	0	0	0	75
PL.58012	PL.58013	A	#4 ACSR	7.22Y	120.3	0.27	4.68	53.12	41	368	111	96	0.77	0.2	6.965	0.114	0	0	0	74
PL.37414	PL.58012	A	#4 ACSR	7.19Y	119.8	0.48	5.16	53.12	41	367	111	96	1.36	0.4	7.166	0.201	0	0	0	74
PL.38079	PL.37414	A	#4 ACSR	7.18Y	119.7	0.19	5.35	48.91	38	337	102	96	0.49	0.1	7.252	0.086	6	2	1	69
PL.36872	PL.38079	A	#4 ACSR	7.18Y	119.7	0.00	5.35	1.30	1	9	3	95	0.00	0.0	7.290	0.038	9	3	2	2
PL.38078	PL.38079	A	#4 ACSR	7.17Y	119.6	0.08	5.42	46.78	36	322	97	96	0.19	0.1	7.288	0.036	0	0	0	66
PL.38077	PL.38078	A	#4 ACSR	7.17Y	119.5	0.10	5.53	44.27	34	304	92	96	0.25	0.1	7.341	0.053	0	0	1	64
PL.37899	PL.38077	A	#4 ACSR	7.17Y	119.5	0.00	5.53	0.00	0	0	0	100	0.00	0.0	7.341	0.000	0	0	0	0
PL.38075	PL.38077	A	#4 ACSR	7.15Y	119.1	0.35	5.88	44.21	34	303	91	96	0.81	0.3	7.521	0.179	12	3	1	63
PL.38076	PL.38075	A	#4 ACSR	7.13Y	118.9	0.23	6.11	41.84	32	286	86	96	0.52	0.2	7.644	0.123	0	0	0	61
PL.38074	PL.38076	A	#4 ACSR	7.13Y	118.8	0.11	6.22	41.84	32	286	86	96	0.25	0.1	7.703	0.059	1	0	2	61
PL.38073	PL.38074	A	#4 ACSR	7.12Y	118.7	0.12	6.34	41.65	32	284	85	96	0.27	0.1	7.767	0.065	0	0	0	59
PL.63070	PL.38073	A	#4 ACSR	7.11Y	118.5	0.14	6.48	41.65	32	284	85	96	0.32	0.1	7.844	0.076	0	0	0	59

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.63071	PL.63070	A	#4 ACSR	7.10Y	118.4	0.13	6.61	40.10	31	273	82	96	0.27	0.1	7.917	0.073	10	3	1	58
PL.37587	PL.63071	A	#4 ACSR	7.09Y	118.2	0.17	6.78	38.61	30	263	79	96	0.35	0.1	8.015	0.098	0	0	0	57
PL.37584	PL.37587	A	#4 ACSR	7.09Y	118.2	0.01	6.79	4.69	4	32	9	96	0.00	0.0	8.083	0.068	0	0	1	5
PL.37586	PL.37584	A	#4 ACSR	7.09Y	118.2	0.01	6.80	4.65	4	32	9	96	0.00	0.0	8.148	0.065	10	3	1	4
PL.37896	PL.37586	A	#4 ACSR	7.09Y	118.2	0.00	6.81	3.12	2	21	6	96	0.00	0.0	8.184	0.036	11	3	1	3
PL.37897	PL.37896	A	#4 ACSR	7.09Y	118.2	0.00	6.81	1.51	1	10	3	96	0.00	0.0	8.267	0.083	10	3	1	2
PL.38422	PL.37897	A	#4 ACSR	7.09Y	118.2	0.00	6.81	0.03	0	0	0	100	0.00	0.0	8.314	0.048	0	0	1	1
L PL.37585	PL.37587	A	#4 ACSR	7.08Y	118.0	0.23	7.01	33.92	26	230	69	96	0.42	0.2	8.166	0.151	0	0	0	52 L
L PL.37582	PL.37585	A	6 A (CWC)	7.08Y	118.0	0.00	7.01	9.45	7	64	19	96	0.00	0.0	8.169	0.003	0	0	0	15 L
L PD.5976	PL.37582	A	40QA	7.08Y	118.0	0.00	7.01	9.45	24	64	19	96	0.00	0.0	8.169	0.003	0	0	0	15 L
L PL.38162	PD.5976	A	6 A (CWC)	7.07Y	117.9	0.14	7.15	9.45	7	64	19	96	0.07	0.1	8.485	0.317	0	0	1	15 L
L PL.38165	PL.38162	A	6 A (CWC)	7.07Y	117.8	0.08	7.23	9.45	7	64	19	96	0.04	0.1	8.665	0.179	0	0	0	14 L
L PL.38372	PL.38165	A	6 A (CWC)	7.07Y	117.8	0.01	7.24	7.40	5	50	15	96	0.00	0.0	8.703	0.038	4	1	1	13 L
L PL.38373	PL.38372	A	6 A (CWC)	7.06Y	117.7	0.05	7.29	6.81	5	46	14	96	0.02	0.0	8.863	0.161	4	1	1	12 L
L PL.38220	PL.38373	A	6 A (CWC)	7.06Y	117.6	0.07	7.36	4.73	3	32	10	95	0.02	0.1	9.181	0.318	0	0	0	9 L
L PL.63052	PL.38220	A	#1/0 ACSR	7.06Y	117.6	0.00	7.36	0.00	0	0	0	100	0.00	0.0	9.211	0.030	0	0	0	1 L
L PL.63053	PL.63052	A	#1/0 ACSR	7.06Y	117.6	0.00	7.36	0.00	0	0	0	100	0.00	0.0	9.259	0.048	0	0	1	1 L
L PL.37656	PL.38220	A	6 A (CWC)	7.06Y	117.6	0.01	7.36	1.31	1	9	3	95	0.00	0.0	9.279	0.098	1	0	1	3 L
L PL.63371	PL.37656	A	#1/0 ACSR	7.06Y	117.6	0.00	7.36	1.19	1	8	2	97	0.00	0.0	9.321	0.041	8	2	2	2 L
L PL.38221	PL.38220	A	6 A (CWC)	7.06Y	117.6	0.03	7.39	3.42	2	23	7	96	0.01	0.0	9.393	0.211	0	0	0	5 L
L PL.37349	PL.38221	A	6 A (CWC)	7.06Y	117.6	0.00	7.39	1.18	1	8	2	97	0.00	0.0	9.428	0.035	8	2	1	1 L
L PL.38376	PL.38221	A	6 A (CWC)	7.06Y	117.6	0.00	7.39	2.24	2	15	4	97	0.00	0.0	9.411	0.018	1	0	1	4 L
L PL.38222	PL.38376	A	6 A (CWC)	7.06Y	117.6	0.01	7.40	2.10	2	14	4	96	0.00	0.0	9.494	0.083	0	0	0	3 L
L PL.38378	PL.38222	A	6 A (CWC)	7.06Y	117.6	0.00	7.40	1.75	1	12	4	95	0.00	0.0	9.571	0.077	5	2	1	2 L
L PL.38377	PL.38378	A	6 A (CWC)	7.06Y	117.6	0.01	7.41	0.95	1	6	2	95	0.00	0.0	9.718	0.146	0	0	0	1 L
L PL.38379	PL.38377	A	6 A (CWC)	7.06Y	117.6	0.00	7.41	0.95	1	6	2	95	0.00	0.0	9.838	0.121	6	2	1	1 L
L PL.37108	PL.38222	A	6 A (CWC)	7.06Y	117.6	0.00	7.40	0.35	0	2	1	89	0.00	0.0	9.533	0.039	2	1	1	1 L
L PL.37788	PL.38373	A	#4 ACSR	7.06Y	117.7	0.00	7.29	0.00	0	0	0	100	0.00	0.0	8.950	0.087	0	0	0	0 L
L PL.38374	PL.38373	A	#4 ACSR	7.06Y	117.7	0.00	7.29	1.51	1	10	3	96	0.00	0.0	8.905	0.041	0	0	0	2 L
L PL.38375	PL.38374	A	#4 ACSR	7.06Y	117.7	0.00	7.29	1.51	1	10	3	96	0.00	0.0	9.004	0.099	10	3	2	2 L
L PL.37375	PL.38165	A	#1/0 ACSR	7.07Y	117.8	0.00	7.23	2.05	1	14	4	96	0.00	0.0	8.811	0.146	14	4	1	1 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.37583	PL.37585	A	#4 ACSR	7.08Y	117.9	0.07	7.07	24.46	19	166	50	96	0.09	0.1	8.226	0.060	0	0	0	37 L
L PL.57309	PL.37583	A	#4 ACSR	7.08Y	117.9	0.00	7.08	24.46	19	166	50	96	0.00	0.0	8.229	0.003	0	0	0	37 L
L PD.8274	PL.57309	A	60QA	7.08Y	117.9	0.00	7.08	24.46	41	166	50	96	0.00	0.0	8.229	0.003	0	0	0	37 L
L PL.57310	PD.8274	A	#4 ACSR	7.07Y	117.9	0.07	7.15	24.46	19	166	50	96	0.09	0.1	8.293	0.064	1	0	1	37 L
L PL.37895	PL.57310	A	#4 ACSR	7.07Y	117.8	0.09	7.23	24.37	19	165	49	96	0.11	0.1	8.375	0.082	9	3	1	36 L
L PL.38571	PL.37895	A	#4 ACSR	7.06Y	117.7	0.08	7.31	23.01	18	156	47	96	0.09	0.1	8.450	0.075	1	0	1	35 L
L PL.38570	PL.38571	A	#4 ACSR	7.06Y	117.6	0.09	7.40	22.80	18	154	46	96	0.10	0.1	8.535	0.085	2	1	1	34 L
L PL.38569	PL.38570	A	#4 ACSR	7.05Y	117.5	0.13	7.53	22.54	17	152	46	96	0.15	0.1	8.667	0.132	9	3	1	33 L
L PL.38568	PL.38569	A	#4 ACSR	7.04Y	117.3	0.22	7.75	21.22	16	143	43	96	0.25	0.2	8.897	0.231	1	0	1	32 L
L PL.37852	PL.38568	A	#4 ACSR	7.03Y	117.2	0.06	7.81	21.12	16	142	42	96	0.07	0.1	8.965	0.068	0	0	0	31 L
L PL.37250	PL.37852	A	#4 ACSR	7.03Y	117.2	0.00	7.81	0.06	0	0	0	100	0.00	0.0	9.049	0.084	0	0	1	1 L
L PL.37851	PL.37852	A	#4 ACSR	7.02Y	117.0	0.19	8.00	21.06	16	142	42	96	0.21	0.1	9.163	0.198	0	0	0	30 L
L PL.37849	PL.37851	A	#1/0 ACSR	7.02Y	117.0	0.00	8.00	1.29	1	9	3	95	0.00	0.0	9.242	0.079	0	0	0	1 L
L PL.37850	PL.37849	A	#1/0 ACSR	7.02Y	117.0	0.00	8.00	1.29	1	9	3	95	0.00	0.0	9.320	0.078	0	0	0	1 L
L PL.38567	PL.37850	A	#1/0 ACSR	7.02Y	117.0	0.00	8.00	1.29	1	9	3	95	0.00	0.0	9.347	0.026	9	3	1	1 L
L PL.38188	PL.37851	A	#4 ACSR	7.01Y	116.8	0.19	8.19	19.77	15	133	40	96	0.21	0.2	9.382	0.219	0	0	0	29 L
L PL.64231	PL.38188	A	#4 ACSR	7.00Y	116.7	0.06	8.25	18.96	15	127	38	96	0.06	0.0	9.453	0.071	0	0	0	28 L
L PL.64017	PL.64231	A	#4 ACSR	7.00Y	116.7	0.00	8.25	1.50	1	10	3	96	0.00	0.0	9.549	0.096	10	3	1	1 L
L PL.64230	PL.64231	A	#4 ACSR	7.00Y	116.7	0.09	8.34	17.46	13	117	35	96	0.07	0.1	9.575	0.122	25	7	1	27 L
L PL.38185	PL.64230	A	#4 ACSR	7.00Y	116.6	0.05	8.38	13.81	11	93	28	96	0.03	0.0	9.651	0.077	0	0	0	26 L
L PL.63073	PL.38185	A	#4 ACSR	6.99Y	116.6	0.06	8.44	13.06	10	88	26	96	0.04	0.0	9.751	0.099	0	0	0	22 L
L PL.63074	PL.63073	A	#4 ACSR	6.99Y	116.6	0.00	8.44	13.06	10	88	26	96	0.00	0.0	9.751	0.000	5	2	1	22 L
L PL.64483	PL.63074	A	#4 ACSR	6.99Y	116.5	0.02	8.46	12.28	9	82	24	96	0.01	0.0	9.781	0.030	0	0	0	21 L
L PL.64485	PL.64483	A	#1/0 ACSR	6.99Y	116.5	0.00	8.46	0.90	0	6	2	95	0.00	0.0	9.841	0.060	6	2	1	1 L
L PL.64484	PL.64483	A	#4 ACSR	6.99Y	116.5	0.05	8.50	11.37	9	76	23	96	0.03	0.0	9.873	0.092	3	1	1	20 L
L PL.37875	PL.64484	A	#4 ACSR	6.98Y	116.4	0.09	8.60	10.20	8	68	20	96	0.05	0.1	10.078	0.205	0	0	0	18 L
L PL.38181	PL.37875	A	#4 ACSR	6.98Y	116.4	0.00	8.60	2.29	2	15	5	95	0.00	0.0	10.135	0.057	7	2	3	5 L
L PL.38182	PL.38181	A	#4 ACSR	6.98Y	116.4	0.00	8.61	1.31	1	9	3	95	0.00	0.0	10.256	0.121	9	3	2	2 L
L PL.38177	PL.37875	A	#4 ACSR	6.98Y	116.3	0.06	8.65	7.72	6	52	15	96	0.02	0.0	10.240	0.162	0	0	0	12 L
L PL.37295	PL.38177	A	#4 ACSR	6.98Y	116.3	0.00	8.66	0.59	0	4	1	97	0.00	0.0	10.405	0.165	0	0	0	1 L
L PL.38408	PL.37295	A	#4 ACSR	6.98Y	116.3	0.00	8.66	0.00	0	0	0	100	0.00	0.0	10.724	0.319	0	0	0	0 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

L PL.37296	PL.37295	A	#4 ACSR	6.98Y	116.3	0.00	8.66	0.59	0	4	1	97	0.00	0.0	10.450	0.045	4	1	1	1 L
L PL.38557	PL.37296	A	#4 ACSR	6.98Y	116.3	0.00	8.66	0.00	0	0	0	100	0.00	0.0	10.518	0.068	0	0	0	0 L
L PL.38558	PL.38557	A	#4 ACSR	6.98Y	116.3	0.00	8.66	0.00	0	0	0	100	0.00	0.0	10.578	0.059	0	0	0	0 L
L PL.38559	PL.38177	A	#4 ACSR	6.98Y	116.3	0.02	8.68	7.13	5	48	14	96	0.01	0.0	10.317	0.077	0	0	0	11 L
L PL.37738	PL.38559	A	#4 ACSR	6.98Y	116.3	0.00	8.68	0.00	0	0	0	100	0.00	0.0	10.360	0.044	0	0	1	1 L
L PL.38560	PL.38559	A	#4 ACSR	6.98Y	116.3	0.02	8.70	7.13	5	48	14	96	0.01	0.0	10.386	0.069	0	0	0	10 L
L PL.38563	PL.38560	A	#4 ACSR	6.98Y	116.3	0.04	8.74	5.97	5	40	12	96	0.01	0.0	10.532	0.146	2	1	1	9 L
L PL.38561	PL.38563	A	#4 ACSR	6.98Y	116.3	0.00	8.74	5.66	4	38	11	96	0.00	0.0	10.555	0.024	21	6	4	8 L
L PL.38562	PL.38561	A	#4 ACSR	6.98Y	116.3	0.00	8.74	2.58	2	17	5	96	0.00	0.0	10.568	0.013	0	0	0	4 L
L PL.38564	PL.38562	A	#4 ACSR	6.98Y	116.3	0.00	8.75	2.58	2	17	5	96	0.00	0.0	10.595	0.027	6	2	1	4 L
L PL.38565	PL.38564	A	#4 ACSR	6.97Y	116.2	0.00	8.75	1.70	1	11	3	96	0.00	0.0	10.662	0.067	4	1	1	3 L
L PL.57282	PL.38565	A	#4 ACSR	6.97Y	116.2	0.00	8.75	1.11	1	7	2	96	0.00	0.0	10.703	0.041	7	2	2	2 L
L PL.37348	PL.38560	A	#4 ACSR	6.98Y	116.3	0.00	8.70	1.16	1	8	2	97	0.00	0.0	10.437	0.051	8	2	1	1 L
L PL.38178	PL.37875	A	#4 ACSR	6.98Y	116.4	0.00	8.60	0.20	0	1	0	100	0.00	0.0	10.157	0.079	1	0	1	1 L
L PL.38179	PL.38178	A	#4 ACSR	6.98Y	116.4	0.00	8.60	0.00	0	0	0	100	0.00	0.0	10.235	0.078	0	0	0	0 L
L PL.38180	PL.38179	A	#4 ACSR	6.98Y	116.4	0.00	8.60	0.00	0	0	0	100	0.00	0.0	10.279	0.045	0	0	0	0 L
L PL.37181	PL.64484	A	#4 ACSR	6.99Y	116.5	0.00	8.51	0.78	1	5	2	93	0.00	0.0	9.965	0.092	0	0	0	1 L
L PL.37182	PL.37181	A	#4 ACSR	6.99Y	116.5	0.00	8.51	0.78	1	5	2	93	0.00	0.0	10.000	0.035	5	2	1	1 L
L PL.37111	PL.38185	A	#4 ACSR	7.00Y	116.6	0.00	8.39	0.74	1	5	1	98	0.00	0.0	9.718	0.067	5	1	2	4 L
L PL.38183	PL.37111	A	#4 ACSR	7.00Y	116.6	0.00	8.39	0.01	0	0	0	100	0.00	0.0	9.797	0.079	0	0	1	2 L
L PL.38184	PL.38183	A	#4 ACSR	7.00Y	116.6	0.00	8.39	0.01	0	0	0	100	0.00	0.0	9.844	0.047	0	0	1	1 L
L PL.38186	PL.64230	A	#4 ACSR	7.00Y	116.7	0.00	8.34	0.00	0	0	0	100	0.00	0.0	9.658	0.084	0	0	0	0 L
L PL.38187	PL.38186	A	#4 ACSR	7.00Y	116.7	0.00	8.34	0.00	0	0	0	100	0.00	0.0	9.690	0.032	0	0	0	0 L
L PL.37351	PL.38188	A	#4 ACSR	7.01Y	116.8	0.00	8.19	0.81	1	5	2	93	0.00	0.0	9.466	0.084	5	2	1	1 L
PL.63072	PL.63070	A	#1/0 ACSR	7.11Y	118.5	0.00	6.48	1.55	1	11	3	96	0.00	0.0	7.892	0.048	11	3	1	1
PL.37712	PL.38075	A	#4 ACSR	7.15Y	119.1	0.00	5.88	0.69	1	5	1	98	0.00	0.0	7.675	0.154	5	1	1	1
PL.37203	PL.38078	A	#4 ACSR	7.17Y	119.6	0.01	5.43	2.51	2	17	5	96	0.00	0.0	7.422	0.133	17	5	2	2
PL.38080	PL.37414	A	#4 ACSR	7.19Y	119.8	0.00	5.16	2.82	2	19	6	95	0.00	0.0	7.216	0.050	15	5	2	3
PL.38081	PL.38080	A	#4 ACSR	7.19Y	119.8	0.00	5.16	0.58	0	4	1	97	0.00	0.0	7.256	0.040	4	1	1	1
PL.37415	PL.37414	A	#4 ACSR	7.19Y	119.8	0.01	5.17	1.39	1	10	3	96	0.00	0.0	7.340	0.174	5	2	1	2
PL.36746	PL.37415	A	#4 ACSR	7.19Y	119.8	0.00	5.17	0.60	0	4	1	97	0.00	0.0	7.386	0.046	4	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58010	PL.58013	A	#4 ACSR	7.24Y	120.6	0.01	4.41	1.99	2	14	4	96	0.00	0.0	6.966	0.115	14	4	1	1
PL.37565	PL.37342	A	6 A (CWC)	7.28Y	121.4	0.00	3.65	6.40	5	45	13	96	0.00	0.0	5.463	0.001	0	0	0	7
PD.6078	PL.37565	A	60QA	7.28Y	121.4	0.00	3.65	6.40	11	45	13	96	0.00	0.0	5.463	0.001	0	0	0	7
PL.64233	PD.6078	A	6 A (CWC)	7.28Y	121.4	0.00	3.65	6.40	5	45	13	96	0.00	0.0	5.478	0.015	0	0	0	7
PL.64014	PL.64233	A	6 A (CWC)	7.28Y	121.3	0.01	3.66	2.44	2	17	5	96	0.00	0.0	5.532	0.054	0	0	0	5
PL.64015	PL.64014	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	2.44	2	17	5	96	0.00	0.0	5.597	0.065	12	4	3	5
PL.64027	PL.64015	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.66	0	5	1	98	0.00	0.0	5.637	0.039	5	1	2	2
PL.64013	PL.64014	A	#2 ACSR	7.28Y	121.3	0.00	3.66	0.00	0	0	0	100	0.00	0.0	5.686	0.154	0	0	0	0
PL.64232	PL.64233	A	6 A (CWC)	7.28Y	121.3	0.00	3.65	3.96	3	28	8	96	0.00	0.0	5.494	0.015	28	8	2	2
PL.37567	PL.37566	A	#1/0 ACSR	7.28Y	121.4	0.00	3.61	1.52	1	11	3	96	0.00	0.0	5.322	0.006	0	0	0	1
PD.5237	PL.37567	A	60QA	7.28Y	121.4	0.00	3.61	1.52	3	11	3	96	0.00	0.0	5.322	0.006	0	0	0	1
PL.37568	PD.5237	A	#1/0 ACSR	7.28Y	121.4	0.00	3.62	1.52	1	11	3	96	0.00	0.0	5.376	0.054	11	3	1	1
PL.37110	PL.37569	B	#4 ACSR	7.29Y	121.4	0.02	3.58	67.16	52	468	142	96	0.05	0.0	5.106	0.005	0	0	0	75
PL.37572	PL.37110	B	#4 ACSR	7.28Y	121.4	0.00	3.59	67.16	52	468	142	96	0.01	0.0	5.107	0.001	0	0	0	75
C PD.6090	PL.37572	B	50L	7.28Y	121.4	0.00	3.59	67.16	134	468	142	96	0.00	0.0	5.107	0.001	0	0	0	75 C
PL.37573	PD.6090	B	#4 ACSR	7.28Y	121.3	0.16	3.74	67.16	52	468	142	96	0.57	0.1	5.160	0.053	3	1	1	75
PL.64225	PL.37573	B	6 A (CWC)	7.24Y	120.7	0.57	4.31	66.04	47	460	139	96	1.98	0.4	5.346	0.186	0	0	0	72
PL.64025	PL.64225	B	6 A (CWC)	7.23Y	120.4	0.26	4.57	66.04	47	458	138	96	0.90	0.2	5.432	0.085	0	0	0	71
PL.64018	PL.64025	B	6 A (CWC)	7.19Y	119.8	0.59	5.16	63.79	46	441	133	96	1.99	0.5	5.635	0.203	5	2	1	69
PL.64019	PL.64018	B	6 A (CWC)	7.18Y	119.6	0.21	5.37	63.05	45	434	130	96	0.69	0.2	5.707	0.072	0	0	0	68
PL.64255	PL.64019	B	6 A (CWC)	7.18Y	119.6	0.00	5.37	0.00	0	0	0	100	0.00	0.0	5.774	0.067	0	0	0	0
PL.64256	PL.64019	B	#4 ACSR	7.17Y	119.6	0.06	5.43	14.60	11	100	30	96	0.04	0.0	5.794	0.087	0	0	0	11
PL.37315	PL.64256	B	#4 ACSR	7.17Y	119.5	0.03	5.46	12.41	10	85	25	96	0.02	0.0	5.851	0.057	0	0	0	9
PL.38846	PL.37315	B	#4 ACSR	7.17Y	119.5	0.03	5.49	12.41	10	85	25	96	0.02	0.0	5.906	0.056	0	0	0	9
PL.37405	PL.38846	B	#4 ACSR	7.17Y	119.5	0.00	5.49	0.90	1	6	2	95	0.00	0.0	5.986	0.080	6	2	1	1
PL.38603	PL.38846	B	#4 ACSR	7.17Y	119.5	0.01	5.50	5.35	4	37	11	96	0.00	0.0	5.958	0.051	0	0	0	4
PL.38604	PL.38603	B	#4 ACSR	7.17Y	119.5	0.01	5.51	5.35	4	37	11	96	0.00	0.0	6.016	0.058	26	8	3	4
PL.38605	PL.38604	B	#4 ACSR	7.17Y	119.5	0.00	5.51	1.54	1	11	3	96	0.00	0.0	6.070	0.054	11	3	1	1
PL.36730	PL.38846	B	#4 ACSR	7.17Y	119.5	0.02	5.51	6.16	5	42	13	96	0.01	0.0	5.980	0.074	7	2	1	4
PL.38606	PL.36730	B	#4 ACSR	7.17Y	119.5	0.01	5.52	5.10	4	35	10	96	0.00	0.0	6.049	0.069	12	4	1	3
PL.37841	PL.38606	B	#4 ACSR	7.17Y	119.5	0.01	5.53	3.38	3	23	7	96	0.00	0.0	6.114	0.065	14	4	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38607	PL.37841	B	#4 ACSR	7.17Y	119.5	0.00	5.53	1.33	1	9	3	95	0.00	0.0	6.137	0.023	0	0	0	1
PL.38608	PL.38607	B	#4 ACSR	7.17Y	119.5	0.00	5.53	1.33	1	9	3	95	0.00	0.0	6.210	0.073	9	3	1	1
PL.37660	PL.64256	B	#4 ACSR	7.17Y	119.6	0.00	5.43	2.19	2	15	4	97	0.00	0.0	5.820	0.026	0	0	0	2
PL.36721	PL.37660	B	#1/0 ACSR	7.17Y	119.6	0.00	5.43	0.68	0	5	1	98	0.00	0.0	5.871	0.051	5	1	1	1
PL.60791	PL.37660	B	#4 ACSR	7.17Y	119.6	0.00	5.43	1.51	1	10	3	96	0.00	0.0	5.873	0.053	10	3	1	1
PL.64257	PL.64019	B	#4 ACSR	7.17Y	119.4	0.20	5.57	48.45	37	333	100	96	0.52	0.2	5.799	0.093	0	0	0	57
PL.38843	PL.64257	B	#4 ACSR	7.16Y	119.3	0.16	5.73	46.77	36	321	96	96	0.40	0.1	5.875	0.076	0	0	3	56
PL.37717	PL.38843	B	#4 ACSR	7.16Y	119.3	0.00	5.73	0.35	0	2	1	89	0.00	0.0	5.966	0.091	2	1	1	1
PL.38844	PL.38843	B	#4 ACSR	7.15Y	119.2	0.08	5.82	46.36	36	318	95	96	0.21	0.1	5.916	0.041	3	1	1	52
PL.38845	PL.38844	B	#4 ACSR	7.14Y	118.9	0.25	6.07	45.98	35	315	94	96	0.62	0.2	6.039	0.123	0	0	0	51
PL.64002	PL.38845	B	#4 ACSR	7.13Y	118.8	0.17	6.24	37.84	29	259	77	96	0.35	0.1	6.140	0.101	0	0	0	44
PL.64009	PL.64002	B	6 A (CWC)	7.13Y	118.8	0.00	6.24	11.10	8	76	23	96	0.00	0.0	6.143	0.003	0	0	0	14
PD.9511	PL.64009	B	25T	7.13Y	118.8	0.00	6.24	11.10	0	76	23	96	0.00	0.0	6.143	0.003	0	0	0	14
PL.64153	PD.9511	B	6 A (CWC)	7.12Y	118.7	0.08	6.32	11.10	8	76	23	96	0.04	0.1	6.294	0.151	2	1	1	14
PL.64037	PL.64153	B	6 A (CWC)	7.12Y	118.7	0.02	6.34	9.40	7	64	19	96	0.01	0.0	6.343	0.049	10	3	1	12
PL.64038	PL.64037	B	6 A (CWC)	7.12Y	118.6	0.02	6.36	7.89	6	54	16	96	0.01	0.0	6.412	0.070	9	3	2	11
PL.64152	PL.64038	B	6 A (CWC)	7.12Y	118.6	0.01	6.37	6.59	5	45	13	96	0.00	0.0	6.444	0.032	0	0	0	9
PL.64239	PL.64152	B	6 A (CWC)	7.11Y	118.6	0.07	6.44	3.02	2	21	6	96	0.01	0.1	6.924	0.480	0	0	0	7
PL.38193	PL.64239	B	6 A (CWC)	7.11Y	118.5	0.02	6.46	2.71	2	19	5	97	0.00	0.0	7.111	0.187	0	0	0	6
PL.38196	PL.38193	B	6 A (CWC)	7.11Y	118.5	0.02	6.48	2.38	2	16	5	95	0.00	0.0	7.301	0.190	0	0	0	5
PL.38197	PL.38196	B	6 A (CWC)	7.11Y	118.5	0.04	6.52	2.38	2	16	5	95	0.00	0.0	7.623	0.322	0	0	0	5
PL.38198	PL.38197	B	6 A (CWC)	7.11Y	118.5	0.00	6.52	0.83	1	6	2	95	0.00	0.0	7.663	0.039	0	0	0	1
PL.38199	PL.38198	B	6 A (CWC)	7.11Y	118.5	0.00	6.52	0.83	1	6	2	95	0.00	0.0	7.697	0.034	6	2	1	1
PL.38200	PL.38197	B	6 A (CWC)	7.11Y	118.4	0.04	6.56	1.55	1	11	3	96	0.00	0.0	8.190	0.566	0	0	0	4
PL.38853	PL.38200	B	6 A (CWC)	7.11Y	118.4	0.00	6.56	1.55	1	11	3	96	0.00	0.0	8.234	0.044	0	0	0	4
PL.36754	PL.38853	B	6 A (CWC)	7.11Y	118.4	0.01	6.57	0.46	0	3	1	95	0.00	0.0	8.646	0.412	0	0	0	2
PL.36755	PL.36754	B	6 A (CWC)	7.11Y	118.4	0.00	6.57	0.46	0	3	1	95	0.00	0.0	8.714	0.068	0	0	0	2
PL.38854	PL.36755	B	6 A (CWC)	7.11Y	118.4	0.00	6.57	0.46	0	3	1	95	0.00	0.0	8.784	0.070	2	0	1	2
PL.38855	PL.38854	B	6 A (CWC)	7.11Y	118.4	0.00	6.57	0.22	0	1	0	100	0.00	0.0	8.853	0.068	1	0	1	1
PL.37309	PL.38853	B	6 A (CWC)	7.11Y	118.4	0.00	6.56	0.03	0	0	0	100	0.00	0.0	8.275	0.040	0	0	1	1
PL.37836	PL.38853	B	#2 ACSR	7.11Y	118.4	0.01	6.57	1.07	1	7	2	96	0.00	0.0	8.595	0.361	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38194	PL.38193	B	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.33	0	2	1	89	0.00	0.0	7.210	0.099	2	1	1	1
PL.38195	PL.38194	B	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.00	0	0	0	100	0.00	0.0	7.470	0.260	0	0	0	0
PL.37406	PL.64239	B	6 A (CWC)	7.11Y	118.6	0.00	6.44	0.31	0	2	1	89	0.00	0.0	7.017	0.093	2	1	1	1
PL.64238	PL.64152	B	6 A (CWC)	7.12Y	118.6	0.02	6.39	3.57	3	24	7	96	0.00	0.0	6.590	0.146	0	0	0	2
PL.37417	PL.64238	B	#2 ACSR	7.12Y	118.6	0.00	6.39	1.46	1	10	3	96	0.00	0.0	6.620	0.030	10	3	1	1
PL.38192	PL.64238	B	6 A (CWC)	7.12Y	118.6	0.01	6.40	2.11	2	14	4	96	0.00	0.0	6.800	0.210	14	4	1	1
PL.64022	PL.64153	B	6 A (CWC)	7.12Y	118.7	0.00	6.32	1.37	1	9	3	95	0.00	0.0	6.373	0.079	9	3	1	1
PL.64001	PL.64002	B	#4 ACSR	7.12Y	118.7	0.11	6.35	26.74	21	183	54	96	0.16	0.1	6.230	0.091	0	0	0	30
PL.38852	PL.64001	B	#4 ACSR	7.12Y	118.6	0.06	6.41	23.17	18	158	47	96	0.07	0.0	6.288	0.057	14	4	1	28
PL.38189	PL.38852	B	#4 ACSR	7.11Y	118.5	0.05	6.45	21.11	16	144	43	96	0.05	0.0	6.336	0.048	0	0	0	27
PL.38849	PL.38189	B	6 A (CWC)	7.11Y	118.5	0.02	6.47	6.86	5	47	14	96	0.01	0.0	6.419	0.083	18	5	1	8
PL.37842	PL.38849	B	6 A (CWC)	7.11Y	118.5	0.01	6.49	4.25	3	29	9	96	0.00	0.0	6.491	0.072	0	0	0	7
PL.57945	PL.37842	B	6 A (CWC)	7.11Y	118.5	0.01	6.50	4.25	3	29	9	96	0.00	0.0	6.549	0.058	0	0	0	7
PL.57947	PL.57945	B	6 A (CWC)	7.11Y	118.5	0.00	6.50	2.68	2	18	5	96	0.00	0.0	6.572	0.023	2	1	1	6
PL.57781	PL.57947	B	6 A (CWC)	7.11Y	118.5	0.00	6.50	2.39	2	16	5	95	0.00	0.0	6.590	0.018	3	1	2	5
PL.57946	PL.57781	B	6 A (CWC)	7.11Y	118.5	0.01	6.51	2.01	1	14	4	96	0.00	0.0	6.650	0.059	0	0	0	3
PL.38850	PL.57946	B	6 A (CWC)	7.11Y	118.5	0.01	6.51	1.93	1	13	4	96	0.00	0.0	6.758	0.108	9	3	1	2
PL.38851	PL.38850	B	6 A (CWC)	7.11Y	118.5	0.00	6.51	0.56	0	4	1	97	0.00	0.0	6.781	0.023	4	1	1	1
PL.37658	PL.57946	B	#1/0 ACSR	7.11Y	118.5	0.00	6.51	0.08	0	1	0	100	0.00	0.0	6.734	0.084	1	0	1	1
PL.61401	PL.57945	B	#1/0 ACSR	7.11Y	118.5	0.00	6.50	1.58	1	11	3	96	0.00	0.0	6.581	0.032	0	0	0	1
PD.9136	PL.61401	B	10T	7.11Y	118.5	0.00	6.50	1.58	0	11	3	96	0.00	0.0	6.581	0.032	0	0	0	1
PL.61402	PD.9136	B	#1/0 ACSR	7.11Y	118.5	0.00	6.50	1.58	1	11	3	96	0.00	0.0	6.730	0.149	11	3	1	1
PL.37292	PL.37842	B	6 A (CWC)	7.11Y	118.5	0.00	6.49	0.00	0	0	0	100	0.00	0.0	6.539	0.048	0	0	0	0
PL.38611	PL.38189	B	#4 ACSR	7.11Y	118.5	0.00	6.45	13.31	10	91	27	96	0.00	0.0	6.337	0.002	0	0	0	18
PD.5907	PL.38611	B	100CodeSMo	7.11Y	118.5	0.00	6.45	13.31	0	91	27	96	0.00	0.0	6.337	0.002	0	0	0	18
PL.38848	PD.5907	B	#4 ACSR	7.11Y	118.5	0.07	6.52	13.31	10	91	27	96	0.05	0.1	6.452	0.115	0	0	0	18
PL.38610	PL.38848	B	#4 ACSR	7.11Y	118.4	0.04	6.56	13.31	10	91	27	96	0.03	0.0	6.528	0.076	3	1	1	18
PL.38190	PL.38610	B	#4 ACSR	7.10Y	118.4	0.02	6.59	2.39	2	16	5	95	0.00	0.0	6.856	0.328	13	4	1	3
PL.38191	PL.38190	B	#4 ACSR	7.10Y	118.4	0.00	6.59	0.00	0	0	0	100	0.00	0.0	6.963	0.107	0	0	1	1
PL.37206	PL.38190	B	#2 ACSR	7.10Y	118.4	0.00	6.59	0.52	0	4	1	97	0.00	0.0	7.061	0.205	4	1	1	1
PL.38856	PL.38610	B	#4 ACSR	7.09Y	118.2	0.28	6.84	10.41	8	71	21	96	0.16	0.2	7.128	0.600	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.37795	PL.38856	B	#4 ACSR	7.09Y	118.1	0.07	6.91	10.41	8	71	21	96	0.04	0.1	7.275	0.147	0	0	0	14
PL.38857	PL.37795	B	#4 ACSR	7.08Y	118.1	0.03	6.94	6.21	5	42	13	96	0.01	0.0	7.397	0.122	14	4	4	12
PL.38858	PL.38857	B	#4 ACSR	7.08Y	118.0	0.02	6.96	4.20	3	29	8	96	0.00	0.0	7.490	0.093	0	0	0	8
PL.38154	PL.38858	B	#4 ACSR	7.08Y	118.0	0.02	6.98	4.11	3	28	8	96	0.00	0.0	7.601	0.111	0	0	0	7
L PL.38155	PL.38154	B	#4 ACSR	7.08Y	118.0	0.03	7.01	4.11	3	28	8	96	0.01	0.0	7.768	0.167	0	0	0	6 L
L PL.38156	PL.38155	B	#4 ACSR	7.08Y	118.0	0.02	7.03	4.11	3	28	8	96	0.00	0.0	7.879	0.111	1	0	2	6 L
L PL.37769	PL.38156	B	#4 ACSR	7.08Y	117.9	0.03	7.06	3.90	3	26	8	96	0.01	0.0	8.037	0.159	0	0	0	4 L
L PL.37771	PL.37769	B	6 A (CWC)	7.08Y	117.9	0.01	7.07	2.90	2	20	6	96	0.00	0.0	8.133	0.095	12	3	1	2 L
L PL.61050	PL.37771	B	6 A (CWC)	7.08Y	117.9	0.01	7.07	1.17	1	8	2	97	0.00	0.0	8.397	0.264	8	2	1	1 L
L PL.61051	PL.61050	B	6 A (CWC)	7.08Y	117.9	0.00	7.07	0.00	0	0	0	100	0.00	0.0	9.136	0.739	0	0	0	0 L
L PL.38161	PL.61051	B	6 A (CWC)	7.08Y	117.9	0.00	7.07	0.00	0	0	0	100	0.00	0.0	9.426	0.290	0	0	0	0 L
L PL.37770	PL.37769	B	#4 ACSR	7.08Y	117.9	0.01	7.07	1.00	1	7	2	96	0.00	0.0	8.214	0.176	0	0	0	2 L
L PL.38157	PL.37770	B	#4 ACSR	7.08Y	117.9	0.00	7.07	1.00	1	7	2	96	0.00	0.0	8.268	0.054	7	2	1	2 L
L PL.38158	PL.38157	B	#4 ACSR	7.08Y	117.9	0.00	7.07	0.03	0	0	0	100	0.00	0.0	8.416	0.148	0	0	0	1 L
L PL.38159	PL.38158	B	#4 ACSR	7.08Y	117.9	0.00	7.07	0.03	0	0	0	100	0.00	0.0	8.483	0.068	0	0	1	1 L
L PL.38160	PL.38159	B	#4 ACSR	7.08Y	117.9	0.00	7.07	0.00	0	0	0	100	0.00	0.0	8.555	0.071	0	0	0	0 L
PL.38152	PL.38154	B	6 A (CWC)	7.08Y	118.0	0.00	6.98	0.01	0	0	0	100	0.00	0.0	7.773	0.172	0	0	1	1
PL.38153	PL.38152	B	6 A (CWC)	7.08Y	118.0	0.00	6.98	0.00	0	0	0	100	0.00	0.0	8.114	0.341	0	0	0	0
PL.36757	PL.38858	B	#2 ACSR	7.08Y	118.0	0.00	6.96	0.09	0	1	0	100	0.00	0.0	7.534	0.044	1	0	1	1
PL.57592	PL.37795	B	6 A (CWC)	7.08Y	118.1	0.01	6.93	4.20	3	29	8	96	0.00	0.0	7.367	0.092	19	6	1	2
PL.57593	PL.57592	B	6 A (CWC)	7.08Y	118.1	0.00	6.93	1.46	1	10	3	96	0.00	0.0	7.389	0.023	10	3	1	1
PL.37743	PL.38856	B	6 A (CWC)	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	7.463	0.335	0	0	0	0
PL.38609	PL.38848	B	#4 ACSR	7.11Y	118.5	0.00	6.52	0.00	0	0	0	100	0.00	0.0	6.511	0.059	0	0	0	0
PL.37322	PL.38189	B	6 A (CWC)	7.11Y	118.5	0.00	6.45	0.94	1	6	2	95	0.00	0.0	6.409	0.073	6	2	1	1
PL.37748	PL.64001	B	#4 ACSR	7.12Y	118.6	0.00	6.35	3.58	3	24	7	96	0.00	0.0	6.267	0.036	14	4	1	2
PL.36752	PL.37748	B	#4 ACSR	7.12Y	118.6	0.00	6.35	1.56	1	11	3	96	0.00	0.0	6.301	0.034	11	3	1	1
PL.36753	PL.36752	B	#4 ACSR	7.12Y	118.6	0.00	6.35	0.00	0	0	0	100	0.00	0.0	6.338	0.037	0	0	0	0
PL.37839	PL.38845	B	#4 ACSR	7.13Y	118.9	0.06	6.12	8.14	6	56	17	96	0.02	0.0	6.212	0.173	14	4	1	7
PL.37840	PL.37839	B	#4 ACSR	7.13Y	118.9	0.02	6.14	4.53	3	31	9	96	0.00	0.0	6.321	0.109	8	2	1	4
PL.37313	PL.37840	B	#4 ACSR	7.13Y	118.8	0.02	6.17	3.31	3	23	7	96	0.00	0.0	6.494	0.173	3	1	1	3
PL.37835	PL.37313	B	#4 ACSR	7.13Y	118.8	0.00	6.17	2.23	2	15	5	95	0.00	0.0	6.554	0.060	15	5	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37314	PL.37313	B	#4 ACSR	7.13Y	118.8	0.00	6.17	0.59	0	4	1	97	0.00	0.0	6.563	0.069	4	1	1	1
PL.61043	PL.37839	B	#4 ACSR	7.13Y	118.9	0.00	6.12	0.00	0	0	0	100	0.00	0.0	6.267	0.055	0	0	0	0
PL.61033	PL.37839	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	1.55	1	11	3	96	0.00	0.0	6.216	0.004	0	0	0	2
PD.9132	PL.61033	B	20T	7.13Y	118.9	0.00	6.12	1.55	0	11	3	96	0.00	0.0	6.216	0.004	0	0	0	2
PL.61034	PD.9132	B	#1/0 ACSR	7.13Y	118.9	0.00	6.13	1.55	1	11	3	96	0.00	0.0	6.244	0.029	11	3	2	2
PL.38391	PL.64257	B	6 A (CWC)	7.17Y	119.4	0.01	5.58	1.68	1	12	3	97	0.00	0.0	5.925	0.126	0	0	0	1
PL.38847	PL.38391	B	6 A (CWC)	7.16Y	119.4	0.01	5.59	1.68	1	12	3	97	0.00	0.0	5.993	0.069	0	0	0	1
PL.37740	PL.38847	B	6 A (CWC)	7.16Y	119.4	0.00	5.59	1.68	1	12	3	97	0.00	0.0	6.029	0.036	12	3	1	1
PL.38602	PL.38847	B	6 A (CWC)	7.16Y	119.4	0.00	5.59	0.00	0	0	0	100	0.00	0.0	6.185	0.191	0	0	0	0
PL.64026	PL.64025	B	6 A (CWC)	7.23Y	120.4	0.01	4.58	2.25	2	16	5	95	0.00	0.0	5.506	0.075	5	1	1	2
PL.64032	PL.64026	B	6 A (CWC)	7.23Y	120.4	0.01	4.58	1.54	1	11	3	96	0.00	0.0	5.686	0.180	11	3	1	1
PL.64224	PL.64225	B	6 A (CWC)	7.24Y	120.7	0.00	4.31	0.00	0	0	0	100	0.00	0.0	5.397	0.051	0	0	1	1
PL.38110	PL.37573	B	6 A (CWC)	7.28Y	121.3	0.00	3.75	0.76	1	5	2	93	0.00	0.0	5.203	0.043	0	0	0	2
PL.38108	PL.38110	B	6 A (CWC)	7.28Y	121.3	0.00	3.75	0.76	1	5	2	93	0.00	0.0	5.223	0.021	5	2	2	2
PL.38109	PL.38108	B	6 A (CWC)	7.28Y	121.3	0.00	3.75	0.00	0	0	0	100	0.00	0.0	5.248	0.025	0	0	0	0
PL.38111	PL.38110	B	6 A (CWC)	7.28Y	121.3	0.00	3.75	0.00	0	0	0	100	0.00	0.0	5.244	0.041	0	0	0	0
PL.37570	PL.37569	C	#4 ACSR	7.29Y	121.4	0.00	3.57	0.05	0	0	0	100	0.00	0.0	5.102	0.001	0	0	0	1
PD.5996	PL.37570	C	60QA	7.29Y	121.4	0.00	3.57	0.05	0	0	0	100	0.00	0.0	5.102	0.001	0	0	0	1
PL.37571	PD.5996	C	#4 ACSR	7.29Y	121.4	0.00	3.57	0.05	0	0	0	100	0.00	0.0	5.191	0.088	0	0	1	1
PL.37495	PL.37965	A	336 MCM AC	7.29Y	121.6	0.00	3.42	0.00	0	0	0	100	0.00	0.0	4.729	0.002	0	0	0	0
PD.6061	PL.37495	A	60QA	7.29Y	121.6	0.00	3.42	0.00	0	0	0	100	0.00	0.0	4.729	0.002	0	0	0	0
PL.38258	PD.6061	A	336 MCM AC	7.29Y	121.6	0.00	3.42	0.00	0	0	0	100	0.00	0.0	4.781	0.052	0	0	0	0
PL.38027	PL.38031	A	#2 ACSR	7.30Y	121.7	0.00	3.32	0.78	0	5	2	93	0.00	0.0	4.486	0.001	0	0	0	1
PD.5991	PL.38027	A	60QA	7.30Y	121.7	0.00	3.32	0.78	1	5	2	93	0.00	0.0	4.486	0.001	0	0	0	1
PL.38028	PD.5991	A	#2 ACSR	7.30Y	121.7	0.00	3.32	0.78	0	5	2	93	0.00	0.0	4.527	0.041	5	2	1	1
PL.38029	PL.38031	C	#2 ACSR	7.30Y	121.7	0.00	3.32	2.86	2	20	6	96	0.00	0.0	4.486	0.001	0	0	0	2
PD.6043	PL.38029	C	25T	7.30Y	121.7	0.00	3.32	2.86	0	20	6	96	0.00	0.0	4.486	0.001	0	0	0	2
PL.38030	PD.6043	C	#2 ACSR	7.30Y	121.7	0.00	3.32	2.86	2	20	6	96	0.00	0.0	4.523	0.037	0	0	0	2
PL.37820	PL.38030	C	#2 ACSR	7.30Y	121.7	0.00	3.32	1.78	1	12	4	95	0.00	0.0	4.562	0.039	0	0	0	1
PL.36871	PL.37820	C	#2 ACSR	7.30Y	121.7	0.00	3.33	1.78	1	12	4	95	0.00	0.0	4.606	0.044	12	4	1	1
PL.37821	PL.37820	C	#2 ACSR	7.30Y	121.7	0.00	3.32	0.00	0	0	0	100	0.00	0.0	4.848	0.286	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37823	PL.38030	C	#1/0 ACSR	7.30Y	121.7	0.00	3.32	1.08	0	8	2	97	0.00	0.0	4.548	0.025	8	2	1	1
PL.38032	PL.38034	A	#2 ACSR	7.30Y	121.7	0.00	3.30	2.19	1	15	5	95	0.00	0.0	4.437	0.001	0	0	0	1
PD.6062	PL.38032	A	60QA	7.30Y	121.7	0.00	3.30	2.19	4	15	5	95	0.00	0.0	4.437	0.001	0	0	0	1
PL.38033	PD.6062	A	#2 ACSR	7.30Y	121.7	0.00	3.30	2.19	1	15	5	95	0.00	0.0	4.473	0.036	15	5	1	1
PL.38038	PL.37297	A	6 A (CWC)	7.31Y	121.8	0.00	3.19	0.00	0	0	0	100	0.00	0.0	4.209	0.001	0	0	0	0
PD.5992	PL.38038	A	60QA	7.31Y	121.8	0.00	3.19	0.00	0	0	0	100	0.00	0.0	4.209	0.001	0	0	0	0
PL.38039	PD.5992	A	6 A (CWC)	7.31Y	121.8	0.00	3.19	0.00	0	0	0	100	0.00	0.0	4.262	0.053	0	0	0	0
PL.37294	PL.38039	A	6 A (CWC)	7.31Y	121.8	0.00	3.19	0.00	0	0	0	100	0.00	0.0	4.334	0.073	0	0	0	0
PL.38040	PL.38039	A	6 A (CWC)	7.31Y	121.8	0.00	3.19	0.00	0	0	0	100	0.00	0.0	4.328	0.066	0	0	0	0
PL.37882	PL.38041	C	#2 ACSR	7.31Y	121.9	0.00	3.12	0.00	0	0	0	100	0.00	0.0	4.049	0.001	0	0	0	0
PD.5993	PL.37882	C	60QA	7.31Y	121.9	0.00	3.12	0.00	0	0	0	100	0.00	0.0	4.049	0.001	0	0	0	0
PL.38042	PD.5993	C	#2 ACSR	7.31Y	121.9	0.00	3.12	0.00	0	0	0	100	0.00	0.0	4.081	0.033	0	0	0	0
PL.38043	PL.38042	C	#2 ACSR	7.31Y	121.9	0.00	3.12	0.00	0	0	0	100	0.00	0.0	4.112	0.031	0	0	0	0
PL.37117	PL.37335	B	#4 ACSR	7.31Y	121.9	0.08	3.15	61.31	47	429	130	96	0.28	0.1	3.964	0.031	0	0	0	63
PL.37787	PL.37117	B	#4 ACSR	7.31Y	121.9	0.00	3.15	61.31	47	429	129	96	0.01	0.0	3.965	0.001	0	0	0	63
C PD.5913	PL.37787	B	50L	7.31Y	121.9	0.00	3.15	61.31	123	429	129	96	0.00	0.0	3.965	0.001	0	0	0	63 C
PL.36728	PD.5913	B	#4 ACSR	7.30Y	121.7	0.11	3.26	61.31	47	429	129	96	0.35	0.1	4.005	0.040	14	4	4	63
PL.37902	PL.36728	B	#4 ACSR	7.30Y	121.6	0.12	3.37	59.32	46	415	125	96	0.37	0.1	4.050	0.045	14	4	1	59
PL.36729	PL.37902	B	#4 ACSR	7.28Y	121.4	0.25	3.63	57.39	44	401	121	96	0.77	0.2	4.149	0.100	8	2	1	58
PL.37204	PL.36729	B	#4 ACSR	7.28Y	121.4	0.00	3.63	0.00	0	0	0	100	0.00	0.0	4.212	0.063	0	0	0	0
PL.37905	PL.36729	B	#4 ACSR	7.24Y	120.7	0.64	4.27	56.23	43	392	118	96	1.92	0.5	4.403	0.253	0	0	0	57
PL.37253	PL.37905	B	#4 ACSR	7.24Y	120.7	0.01	4.28	1.35	1	9	3	95	0.00	0.0	4.612	0.210	5	1	1	2
PL.62833	PL.37253	B	#1/0 ACSR	7.24Y	120.7	0.00	4.28	0.68	0	5	1	98	0.00	0.0	4.680	0.068	0	0	0	1
PL.62834	PL.62833	B	#1/0 ACSR	7.24Y	120.7	0.00	4.28	0.68	0	5	1	98	0.00	0.0	4.740	0.059	5	1	1	1
PL.37906	PL.37905	B	#4 ACSR	7.23Y	120.5	0.22	4.48	54.88	42	381	114	96	0.63	0.2	4.491	0.088	4	1	1	55
PL.37907	PL.37906	B	#4 ACSR	7.22Y	120.3	0.23	4.71	54.33	42	376	113	96	0.67	0.2	4.585	0.095	0	0	0	54
PL.37908	PL.37907	B	#4 ACSR	7.20Y	120.1	0.22	4.93	50.58	39	350	105	96	0.60	0.2	4.684	0.098	0	0	0	52
PL.37697	PL.37908	B	#4 ACSR	7.19Y	119.8	0.25	5.19	50.58	39	349	104	96	0.69	0.2	4.796	0.112	0	0	0	52
PL.37208	PL.37697	B	#4 ACSR	7.18Y	119.7	0.07	5.26	32.97	25	227	68	96	0.13	0.1	4.845	0.050	0	0	0	44
PL.37837	PL.37208	B	#4 ACSR	7.16Y	119.3	0.42	5.68	9.80	8	67	20	96	0.22	0.3	5.826	0.981	3	1	1	19
PL.38585	PL.37837	B	6 A (CWC)	7.16Y	119.3	0.05	5.73	4.86	3	33	10	96	0.01	0.0	6.029	0.203	0	0	0	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38586	PL.38585	B	6 A (CWC)	7.15Y	119.2	0.06	5.79	4.86	3	33	10	96	0.02	0.0	6.327	0.298	2	1	1	7
PL.38583	PL.38586	B	6 A (CWC)	7.15Y	119.2	0.01	5.80	4.53	3	31	9	96	0.00	0.0	6.373	0.046	3	1	1	6
PL.58463	PL.38583	B	6 A (CWC)	7.15Y	119.2	0.03	5.83	3.83	3	26	8	96	0.01	0.0	6.546	0.173	0	0	0	4
PD.8686	PL.58463	B	20T	7.15Y	119.2	0.00	5.83	3.83	0	26	8	96	0.00	0.0	6.546	0.173	0	0	0	4
PL.58464	PD.8686	B	6 A (CWC)	7.15Y	119.1	0.02	5.85	3.83	3	26	8	96	0.00	0.0	6.646	0.100	0	0	0	4
PL.37125	PL.58464	B	6 A (CWC)	7.15Y	119.1	0.05	5.90	3.83	3	26	8	96	0.01	0.0	6.953	0.308	0	0	0	4
PL.37838	PL.37125	B	6 A (CWC)	7.15Y	119.1	0.00	5.90	0.46	0	3	1	95	0.00	0.0	6.976	0.022	3	1	1	1
PL.38587	PL.37125	B	6 A (CWC)	7.15Y	119.1	0.01	5.92	3.37	2	23	7	96	0.00	0.0	7.032	0.078	0	0	0	3
PL.37126	PL.38587	B	6 A (CWC)	7.14Y	119.1	0.03	5.94	3.02	2	21	6	96	0.00	0.0	7.226	0.194	0	0	0	2
PL.38588	PL.37126	B	6 A (CWC)	7.14Y	119.0	0.10	6.05	3.02	2	21	6	96	0.02	0.1	7.964	0.738	0	0	0	2
PL.38589	PL.38588	B	6 A (CWC)	7.14Y	118.9	0.01	6.05	3.02	2	21	6	96	0.00	0.0	8.058	0.094	21	6	2	2
PL.37865	PL.38587	B	6 A (CWC)	7.14Y	119.1	0.00	5.92	0.35	0	2	1	89	0.00	0.0	7.088	0.056	2	1	1	1
PL.37540	PL.37125	B	6 A (CWC)	7.15Y	119.1	0.00	5.90	0.00	0	0	0	100	0.00	0.0	6.993	0.040	0	0	0	0
PL.58522	PL.38583	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.28	0	2	1	89	0.00	0.0	6.376	0.003	0	0	0	1
PD.8706	PL.58522	B	20T	7.15Y	119.2	0.00	5.80	0.28	0	2	1	89	0.00	0.0	6.376	0.003	0	0	0	1
PL.58523	PD.8706	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.28	0	2	1	89	0.00	0.0	6.661	0.285	2	1	1	1
PL.38584	PL.58523	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.00	0	0	0	100	0.00	0.0	6.801	0.140	0	0	0	0
PL.37539	PL.37837	B	#4 ACSR	7.16Y	119.3	0.04	5.72	4.52	3	31	9	96	0.01	0.0	6.028	0.202	1	0	1	11
PL.37123	PL.37539	B	#4 ACSR	7.15Y	119.2	0.05	5.77	3.17	2	22	6	96	0.01	0.0	6.349	0.321	0	0	1	4
PL.37124	PL.37123	B	#4 ACSR	7.15Y	119.2	0.03	5.80	3.16	2	22	6	96	0.00	0.0	6.535	0.186	0	0	0	3
PL.39225	PL.37124	B	#4 ACSR	7.15Y	119.2	0.01	5.80	3.16	2	22	6	96	0.00	0.0	6.646	0.111	22	6	3	3
PL.39226	PL.39225	B	#4 ACSR	7.15Y	119.2	0.00	5.80	0.00	0	0	0	100	0.00	0.0	6.708	0.063	0	0	0	0
PL.37806	PL.37539	B	#4 ACSR	7.16Y	119.3	0.00	5.72	0.22	0	1	0	100	0.00	0.0	6.119	0.090	0	0	1	2
PL.37807	PL.37806	B	#4 ACSR	7.16Y	119.3	0.00	5.72	0.17	0	1	0	100	0.00	0.0	6.183	0.065	1	0	1	1
PL.64228	PL.37539	B	#4 ACSR	7.16Y	119.3	0.01	5.73	0.92	1	6	2	95	0.00	0.0	6.294	0.266	0	0	0	4
PL.64155	PL.64228	B	6 A (CWC)	7.16Y	119.3	0.00	5.73	0.12	0	1	0	100	0.00	0.0	6.384	0.089	1	0	2	2
PL.64227	PL.64228	B	6 A (CWC)	7.16Y	119.3	0.00	5.73	0.00	0	0	0	100	0.00	0.0	6.386	0.092	0	0	0	0
PL.64229	PL.64228	B	#4 ACSR	7.16Y	119.3	0.00	5.74	0.80	1	6	2	95	0.00	0.0	6.398	0.104	2	1	1	2
PL.37898	PL.64229	B	#4 ACSR	7.16Y	119.3	0.00	5.74	0.00	0	0	0	100	0.00	0.0	6.464	0.066	0	0	0	0
PL.37256	PL.64229	B	#4 ACSR	7.16Y	119.3	0.00	5.74	0.49	0	3	1	95	0.00	0.0	6.463	0.065	3	1	1	1
PL.62501	PL.37208	B	#4 ACSR	7.18Y	119.7	0.00	5.27	23.18	18	160	48	96	0.00	0.0	4.849	0.003	0	0	0	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.9370	PL.62501	B	25T	7.18Y	119.7	0.00	5.27	23.18	0	160	48	96	0.00	0.0	4.849	0.003	0	0	0	25
PL.62502	PD.9370	B	#4 ACSR	7.18Y	119.6	0.14	5.41	23.18	18	160	48	96	0.17	0.1	4.988	0.139	5	2	1	25
PL.37228	PL.62502	B	#4 ACSR	7.17Y	119.5	0.11	5.51	22.44	17	154	46	96	0.13	0.1	5.093	0.105	0	0	0	24
PL.37229	PL.37228	B	#4 ACSR	7.17Y	119.5	0.01	5.52	4.00	3	27	8	96	0.00	0.0	5.175	0.082	27	8	3	3
PL.37701	PL.37229	B	#4 ACSR	7.17Y	119.5	0.00	5.52	0.00	0	0	0	100	0.00	0.0	5.215	0.040	0	0	0	0
PL.37702	PL.37701	B	#4 ACSR	7.17Y	119.5	0.00	5.52	0.00	0	0	0	100	0.00	0.0	5.278	0.062	0	0	0	0
PL.37703	PL.37228	B	#4 ACSR	7.16Y	119.3	0.18	5.69	18.44	14	127	38	96	0.17	0.1	5.307	0.215	0	0	0	21
PL.37507	PL.37703	B	#4 ACSR	7.16Y	119.3	0.06	5.75	14.84	11	102	30	96	0.04	0.0	5.397	0.089	11	3	2	18
PL.37799	PL.37507	B	#4 ACSR	7.16Y	119.3	0.00	5.75	0.22	0	2	0	100	0.00	0.0	5.422	0.025	2	0	1	1
PL.37508	PL.37507	B	#4 ACSR	7.15Y	119.2	0.04	5.78	10.44	8	72	21	96	0.02	0.0	5.478	0.081	9	3	1	12
PL.37341	PL.37508	B	#4 ACSR	7.15Y	119.2	0.00	5.78	1.53	1	10	3	96	0.00	0.0	5.556	0.078	10	3	1	1
PL.37509	PL.37508	B	#4 ACSR	7.15Y	119.2	0.03	5.81	7.55	6	52	15	96	0.01	0.0	5.558	0.080	0	0	0	10
PL.37510	PL.37509	B	#4 ACSR	7.15Y	119.2	0.00	5.81	5.57	4	38	11	96	0.00	0.0	5.571	0.014	2	1	1	9
PL.37511	PL.37510	B	#4 ACSR	7.15Y	119.2	0.01	5.83	5.27	4	36	11	96	0.00	0.0	5.632	0.061	0	0	0	8
PL.37512	PL.37511	B	#4 ACSR	7.15Y	119.1	0.04	5.86	5.27	4	36	11	96	0.01	0.0	5.814	0.182	10	3	2	8
PL.37575	PL.37512	B	#4 ACSR	7.15Y	119.1	0.00	5.86	0.07	0	0	0	100	0.00	0.0	5.906	0.092	0	0	1	1
PL.37513	PL.37512	B	#4 ACSR	7.15Y	119.1	0.02	5.88	3.76	3	26	8	96	0.00	0.0	5.924	0.110	10	3	1	5
PL.37514	PL.37513	B	#4 ACSR	7.15Y	119.1	0.01	5.89	2.35	2	16	5	95	0.00	0.0	6.020	0.096	0	0	0	4
PL.37515	PL.37514	B	#4 ACSR	7.15Y	119.1	0.00	5.89	0.68	1	5	1	98	0.00	0.0	6.068	0.048	5	1	1	1
PL.37516	PL.37514	B	#4 ACSR	7.15Y	119.1	0.01	5.90	1.67	1	11	3	96	0.00	0.0	6.217	0.197	0	0	0	3
PL.36714	PL.37516	B	#4 ACSR	7.15Y	119.1	0.00	5.90	1.67	1	11	3	96	0.00	0.0	6.228	0.010	11	3	3	3
PL.37542	PL.37509	B	#4 ACSR	7.15Y	119.2	0.00	5.81	1.98	2	14	4	96	0.00	0.0	5.600	0.042	14	4	1	1
PL.37541	PL.37507	B	#4 ACSR	7.15Y	119.2	0.00	5.75	2.58	2	18	5	96	0.00	0.0	5.475	0.079	18	5	3	3
PL.61028	PL.37703	B	#1/0 ACSR	7.16Y	119.3	0.00	5.69	1.36	1	9	3	95	0.00	0.0	5.319	0.011	9	3	1	1
PL.37704	PL.37703	B	#4 ACSR	7.16Y	119.3	0.01	5.70	2.24	2	15	5	95	0.00	0.0	5.372	0.065	3	1	1	2
PL.37506	PL.37704	B	#4 ACSR	7.16Y	119.3	0.00	5.70	1.86	1	13	4	96	0.00	0.0	5.485	0.113	13	4	1	1
PL.37698	PL.37697	B	#4 ACSR	7.19Y	119.8	0.00	5.19	1.49	1	10	3	96	0.00	0.0	4.797	0.001	0	0	0	1
PD.6004	PL.37698	B	40QA	7.19Y	119.8	0.00	5.19	1.49	4	10	3	96	0.00	0.0	4.797	0.001	0	0	0	1
PL.37699	PD.6004	B	#4 ACSR	7.19Y	119.8	0.01	5.19	1.49	1	10	3	96	0.00	0.0	4.976	0.179	10	3	1	1
PL.37700	PL.37697	B	#4 ACSR	7.19Y	119.8	0.00	5.19	16.12	12	111	33	96	0.00	0.0	4.797	0.001	0	0	0	7
PD.6048	PL.37700	B	40QA	7.19Y	119.8	0.00	5.19	16.12	40	111	33	96	0.00	0.0	4.797	0.001	0	0	0	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37803	PD.6048	B	#4 ACSR	7.17Y	119.5	0.35	5.54	16.12	12	111	33	96	0.30	0.3	5.276	0.479	0	0	0	7
PL.37340	PL.37803	B	6 A (CWC)	7.17Y	119.5	0.00	5.54	0.00	0	0	0	100	0.00	0.0	5.381	0.105	0	0	0	0
PL.37804	PL.37803	B	#4 ACSR	7.17Y	119.4	0.04	5.57	16.12	12	111	33	96	0.03	0.0	5.330	0.055	0	0	0	7
PL.37218	PL.37804	B	#4 ACSR	7.16Y	119.4	0.02	5.60	16.12	12	111	33	96	0.02	0.0	5.364	0.033	6	2	1	7
PL.37219	PL.37218	B	#4 ACSR	7.16Y	119.4	0.03	5.63	15.30	12	105	31	96	0.03	0.0	5.414	0.050	0	0	0	6
PL.37290	PL.37219	B	#4 ACSR	7.16Y	119.4	0.01	5.64	6.97	5	48	14	96	0.00	0.0	5.453	0.039	0	0	0	2
PL.37805	PL.37290	B	#4 ACSR	7.16Y	119.4	0.00	5.64	0.00	0	0	0	100	0.00	0.0	5.543	0.090	0	0	0	0
PL.37863	PL.37290	B	6 A (CWC)	7.16Y	119.3	0.01	5.65	6.97	5	48	14	96	0.00	0.0	5.499	0.046	48	14	2	2
PL.64226	PL.37219	B	6 A (CWC)	7.16Y	119.3	0.02	5.66	8.33	6	57	17	96	0.01	0.0	5.478	0.064	0	0	0	4
PL.64159	PL.64226	B	6 A (CWC)	7.16Y	119.3	0.01	5.67	8.33	6	57	17	96	0.01	0.0	5.512	0.034	8	3	1	4
PL.64154	PL.64159	B	6 A (CWC)	7.16Y	119.3	0.01	5.68	7.09	5	49	14	96	0.00	0.0	5.561	0.049	49	14	3	3
PL.37205	PL.37804	B	6 A (CWC)	7.17Y	119.4	0.00	5.57	0.00	0	0	0	100	0.00	0.0	5.408	0.077	0	0	0	0
PL.37684	PL.37907	B	#2 ACSR	7.22Y	120.3	0.00	4.71	2.07	1	14	4	96	0.00	0.0	4.611	0.026	14	4	1	1
PL.36722	PL.37907	B	#2 ACSR	7.22Y	120.3	0.00	4.71	1.68	1	12	3	97	0.00	0.0	4.653	0.067	12	3	1	1
PL.37500	PL.37503	A	#4 ACSR	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	2.765	0.001	0	0	0	1
PD.6063	PL.37500	A	60QA	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	2.765	0.001	0	0	0	1
PL.37501	PD.6063	A	#4 ACSR	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	2.793	0.028	0	0	1	1
PL.37502	PL.37501	A	#4 ACSR	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	2.880	0.086	0	0	0	0
CP.98	PL.52651	ABC	Cap (300)	7.38Y	122.9	0.00	2.06	0.00	0	0	0	100	0.00	0.0	2.369	0.086	0	0	0	0
PL.38213	PL.38356	C	#2 ACSR	7.39Y	123.2	0.00	1.79	2.69	2	19	6	95	0.00	0.0	1.978	0.000	0	0	0	4
PD.6047	PL.38213	C	60QA	7.39Y	123.2	0.00	1.79	2.69	4	19	6	95	0.00	0.0	1.978	0.000	0	0	0	4
PL.38214	PD.6047	C	#2 ACSR	7.39Y	123.2	0.00	1.80	2.69	2	19	6	95	0.00	0.0	2.028	0.050	10	3	1	4
PL.37537	PL.38214	C	#2 ACSR	7.39Y	123.2	0.00	1.80	1.26	1	9	3	95	0.00	0.0	2.057	0.029	4	1	2	3
PL.37538	PL.37537	C	#2 ACSR	7.39Y	123.2	0.00	1.80	0.66	0	5	1	98	0.00	0.0	2.179	0.122	5	1	1	1
PL.38022	PL.37760	C	#2 ACSR	7.41Y	123.4	0.00	1.56	1.14	1	8	2	97	0.00	0.0	1.693	0.001	0	0	0	1
PD.5970	PL.38022	C	60QA	7.41Y	123.4	0.00	1.56	1.14	2	8	2	97	0.00	0.0	1.693	0.001	0	0	0	1
PL.38023	PD.5970	C	#2 ACSR	7.41Y	123.4	0.00	1.56	1.14	1	8	2	97	0.00	0.0	1.715	0.022	8	2	1	1
PL.38024	PL.37767	B	#4 ACSR	7.42Y	123.6	0.00	1.41	1.04	1	7	2	96	0.00	0.0	1.533	0.001	0	0	0	1
PD.5969	PL.38024	B	60QA	7.42Y	123.6	0.00	1.41	1.04	2	7	2	96	0.00	0.0	1.533	0.001	0	0	0	1
PL.38025	PD.5969	B	#4 ACSR	7.42Y	123.6	0.00	1.41	1.04	1	7	2	96	0.00	0.0	1.554	0.022	7	2	1	1
PL.52504	PL.52502	A	#1/0 ACSR	7.45Y	124.2	0.00	0.85	2.25	1	16	5	95	0.00	0.0	0.912	0.000	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Conway

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PD.5988	PL.52504	A	25QA	7.45Y	124.2	0.00	0.85	2.25	9	16	5	95	0.00	0.0	0.912	0.000	0	0	0	1
PL.38685	PD.5988	A	#1/0 ACSR	7.45Y	124.2	0.00	0.85	2.25	1	16	5	95	0.00	0.0	0.931	0.019	16	5	1	1
CP.73	PL.61768	ABC	Cap (300)	7.45Y	124.2	0.00	0.81	0.00	0	0	0	100	0.00	0.0	0.868	0.019	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	7868	0	0	0	0	0	198		0.00	8066	Lowest Voltage =	115.89	on Element PL.47704
KVAR	2342	0	0	-1	0	0	313			2654	Max Accm VoltD =	9.11	on Element PL.47704
											Max Elem VoltD =	0.64	on Element PL.37905