

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Goose Rock		ABC	SRC-Goose	7.50Y	125.0	0.00	0.00	511.59	0	10935	3596	95	0.00	0.0	0.000	0.000	0	0	0	2558
PL.1255	Goose Rock	ABC	1/0 AL URD	7.50Y	125.0	0.01	0.01	55.98	33	1210	351	96	0.08	0.0	0.007	0.007	0	0	0	273
PL.7157	PL.1255	ABC	1/0 AL URD	7.50Y	125.0	0.00	0.01	55.98	33	1210	351	96	0.02	0.0	0.009	0.002	0	0	0	273
----- Feeder No. 2 (Big Creek F2) Beginning with Device PD.1527 -----																				
PD.1527	PL.7157	ABC	480VWE	7.50Y	125.0	0.00	0.01	55.98	0	1210	351	96	0.00	0.0	0.009	0.002	0	0	0	273
PL.7158	PD.1527	ABC	1/0 AL URD	7.50Y	125.0	0.01	0.02	55.98	33	1210	351	96	0.12	0.0	0.020	0.011	0	0	0	273
PL.1388	PL.7158	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	55.99	11	1209	351	96	0.00	0.0	0.023	0.002	0	0	0	273
PD.204-A	PL.1388	ABC	Closed	7.50Y	125.0	0.00	0.02	55.99	0	1209	351	96	0.00	0.0	0.023	0.002	0	0	0	273
PD.204-B	PD.204-A	ABC	Closed	7.50Y	125.0	0.00	0.02	55.99	0	1209	351	96	0.00	0.0	0.023	0.002	0	0	0	273
PL.1389	PD.204-B	ABC	397 SPACER	7.50Y	125.0	0.01	0.04	55.99	11	1209	351	96	0.03	0.0	0.106	0.083	0	0	0	273
PL.47	PL.1389	ABC	397 SPACER	7.50Y	125.0	0.01	0.05	55.69	11	1203	349	96	0.02	0.0	0.150	0.044	11	3	3	270
PL.90	PL.47	ABC	397 SPACER	7.50Y	124.9	0.01	0.05	55.16	11	1192	346	96	0.02	0.0	0.196	0.046	0	0	1	267
PL.91	PL.90	ABC	397 SPACER	7.50Y	124.9	0.01	0.06	55.16	11	1192	346	96	0.01	0.0	0.227	0.031	28	8	4	266
PL.1298	PL.91	ABC	397 SPACER	7.50Y	124.9	0.01	0.07	53.87	10	1164	338	96	0.02	0.0	0.281	0.055	0	0	4	262
PL.92	PL.1298	ABC	397 SPACER	7.50Y	124.9	0.00	0.07	53.87	10	1164	337	96	0.01	0.0	0.304	0.023	9	2	1	258
PL.1297	PL.92	ABC	397 SPACER	7.50Y	124.9	0.01	0.08	53.46	10	1155	335	96	0.02	0.0	0.358	0.054	0	0	0	257
PL.48	PL.1297	ABC	397 SPACER	7.49Y	124.9	0.01	0.09	53.00	10	1145	332	96	0.01	0.0	0.388	0.030	7	2	1	253
PL.1296	PL.48	ABC	397 SPACER	7.49Y	124.9	0.01	0.10	52.69	10	1138	330	96	0.02	0.0	0.446	0.058	8	2	2	252
PL.94	PL.1296	ABC	397 SPACER	7.49Y	124.9	0.00	0.10	52.34	10	1130	327	96	0.01	0.0	0.474	0.027	12	3	2	250
PL.1295	PL.94	ABC	397 SPACER	7.49Y	124.9	0.01	0.11	51.77	10	1118	324	96	0.02	0.0	0.521	0.047	4	1	2	248
PL.95	PL.1295	ABC	397 SPACER	7.49Y	124.9	0.01	0.11	51.60	10	1114	323	96	0.01	0.0	0.553	0.032	34	9	1	246
PL.1294	PL.95	ABC	397 SPACER	7.49Y	124.9	0.01	0.12	50.02	10	1080	313	96	0.02	0.0	0.602	0.049	0	0	0	245
PL.96	PL.1294	ABC	397 SPACER	7.49Y	124.9	0.01	0.13	50.02	10	1080	313	96	0.01	0.0	0.640	0.039	19	5	7	245
PL.97	PL.96	ABC	397 SPACER	7.49Y	124.9	0.01	0.13	49.17	9	1062	307	96	0.02	0.0	0.691	0.051	0	0	0	238
PL.1308	PL.97	C	#4 ACSR	7.49Y	124.9	0.00	0.13	1.01	1	7	2	96	0.00	0.0	0.695	0.004	0	0	0	1
PD.167	PL.1308	C	65QA	7.49Y	124.9	0.00	0.13	1.01	0	7	2	96	0.00	0.0	0.695	0.004	0	0	0	1
PL.1309	PD.167	C	#4 ACSR	7.49Y	124.9	0.00	0.13	1.01	1	7	2	96	0.00	0.0	0.707	0.011	7	2	1	1
PL.1306	PL.97	A	#4 ACSR	7.49Y	124.9	0.00	0.13	3.37	3	24	7	96	0.00	0.0	0.694	0.003	0	0	0	6
PD.166	PL.1306	A	65QA	7.49Y	124.9	0.00	0.13	3.37	0	24	7	96	0.00	0.0	0.694	0.003	0	0	0	6
PL.1307	PD.166	A	#4 ACSR	7.49Y	124.9	0.01	0.14	3.37	3	24	7	96	0.00	0.0	0.776	0.082	18	5	4	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5	PL.1307	A	#4 ACSR	7.49Y	124.9	0.00	0.14	0.94	1	7	2	96	0.00	0.0	0.878	0.102	7	2	2	2
PL.1293	PL.97	ABC	397 SPACER	7.49Y	124.9	0.01	0.14	47.71	9	1030	298	96	0.02	0.0	0.743	0.052	0	0	0	231
PL.1312	PL.1293	B	6 A (CWC)	7.49Y	124.9	0.00	0.14	1.71	1	12	3	97	0.00	0.0	0.745	0.003	0	0	0	3
PD.169	PL.1312	B	65QA	7.49Y	124.9	0.00	0.14	1.71	0	12	3	97	0.00	0.0	0.745	0.003	0	0	0	3
PL.1313	PD.169	B	6 A (CWC)	7.49Y	124.9	0.00	0.14	1.71	1	12	3	97	0.00	0.0	0.808	0.063	12	3	3	3
PL.1310	PL.1293	B	6 A (CWC)	7.49Y	124.9	0.00	0.14	1.22	1	9	2	98	0.00	0.0	0.747	0.004	0	0	0	1
PD.168	PL.1310	B	65QA	7.49Y	124.9	0.00	0.14	1.22	0	9	2	98	0.00	0.0	0.747	0.004	0	0	0	1
PL.1311	PD.168	B	6 A (CWC)	7.49Y	124.9	0.00	0.14	1.22	1	9	2	98	0.00	0.0	0.759	0.012	9	2	1	1
PL.1292	PL.1293	ABC	397 SPACER	7.49Y	124.8	0.01	0.15	46.73	9	1009	292	96	0.03	0.0	0.834	0.091	0	0	0	227
PL.1280	PL.1292	B	#4 ACSR	7.49Y	124.8	0.00	0.16	2.65	2	19	5	97	0.00	0.0	0.837	0.003	0	0	0	4
PD.158	PL.1280	B	40QA	7.49Y	124.8	0.00	0.16	2.65	7	19	5	97	0.00	0.0	0.837	0.003	0	0	0	4
PL.1281	PD.158	B	#4 ACSR	7.49Y	124.8	0.00	0.16	2.65	2	19	5	97	0.00	0.0	0.859	0.022	19	5	4	4
PL.1314	PL.1292	ABC	397 SPACER	7.49Y	124.8	0.01	0.16	45.85	9	990	287	96	0.02	0.0	0.902	0.068	0	0	0	223
PL.1315	PL.1314	B	6 A (CWC)	7.49Y	124.8	0.00	0.16	1.40	1	10	3	96	0.00	0.0	0.904	0.003	0	0	0	1
PD.170	PL.1315	B	65QA	7.49Y	124.8	0.00	0.16	1.40	0	10	3	96	0.00	0.0	0.904	0.003	0	0	0	1
PL.1316	PD.170	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.40	1	10	3	96	0.00	0.0	0.924	0.020	10	3	1	1
PL.517	PL.1314	ABC	397 SPACER	7.49Y	124.8	0.01	0.17	44.86	9	968	280	96	0.02	0.0	0.974	0.072	6	2	1	218
PL.98	PL.517	ABC	397 SPACER	7.49Y	124.8	0.00	0.18	44.60	9	963	279	96	0.01	0.0	0.993	0.019	0	0	0	217
PL.50	PL.98	ABC	397 SPACER	7.49Y	124.8	0.01	0.18	43.37	8	936	271	96	0.01	0.0	1.047	0.054	4	1	2	211
PL.51	PL.50	ABC	397 SPACER	7.49Y	124.8	0.01	0.19	43.21	8	932	270	96	0.01	0.0	1.085	0.039	13	4	3	209
PL.1321	PL.51	B	#2 ACSR	7.49Y	124.8	0.00	0.19	2.90	2	21	6	96	0.00	0.0	1.089	0.004	0	0	0	4
PD.173	PL.1321	B	40QA	7.49Y	124.8	0.00	0.19	2.90	7	21	6	96	0.00	0.0	1.089	0.004	0	0	0	4
PL.1322	PD.173	B	#2 ACSR	7.49Y	124.8	0.00	0.19	2.90	2	21	6	96	0.00	0.0	1.098	0.009	21	6	4	4
PL.52	PL.51	ABC	397 SPACER	7.49Y	124.8	0.00	0.19	41.62	8	898	260	96	0.00	0.0	1.107	0.021	16	5	3	202
PL.53	PL.52	ABC	397 SPACER	7.49Y	124.8	0.01	0.20	40.88	8	882	256	96	0.01	0.0	1.163	0.056	16	5	2	199
PL.54	PL.53	ABC	397 SPACER	7.49Y	124.8	0.00	0.20	39.90	8	861	250	96	0.00	0.0	1.186	0.023	0	0	0	196
PL.514	PL.54	ABC	397 SPACER	7.49Y	124.8	0.01	0.21	39.40	8	850	247	96	0.01	0.0	1.257	0.071	7	2	2	194
PL.1327	PL.514	A	#2 HdCu -	7.49Y	124.8	0.00	0.21	6.72	3	48	14	96	0.00	0.0	1.261	0.004	0	0	0	9
PD.176	PL.1327	A	65QA	7.49Y	124.8	0.00	0.21	6.72	0	48	14	96	0.00	0.0	1.261	0.004	0	0	0	9
PL.1328	PD.176	A	#2 HdCu -	7.49Y	124.8	0.00	0.21	6.72	3	48	14	96	0.00	0.0	1.265	0.004	0	0	0	9
PL.951	PL.1328	A	#2 HdCu -	7.49Y	124.8	0.00	0.22	4.81	2	35	10	96	0.00	0.0	1.302	0.037	8	2	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.511	PL.951	A	#2 HdCu -	7.49Y	124.8	0.00	0.22	3.68	2	27	7	97	0.00	0.0	1.329	0.027	27	7	5	5
PL.296	PL.1328	A	#2 ACSR	7.49Y	124.8	0.00	0.21	1.92	1	14	4	96	0.00	0.0	1.284	0.020	0	0	0	2
PL.6	PL.296	A	#2 ACSR	7.49Y	124.8	0.00	0.21	1.92	1	14	4	96	0.00	0.0	1.301	0.017	0	0	0	2
PL.55	PL.6	A	#1/0 ACSR	7.49Y	124.8	0.00	0.22	1.92	1	14	4	96	0.00	0.0	1.346	0.045	14	4	2	2
PL.1032	PL.514	ABC	397 SPACER	7.49Y	124.8	0.00	0.22	36.83	7	794	231	96	0.01	0.0	1.295	0.037	0	0	0	183
PL.1329	PL.1032	ABC	#2 HdCu -	7.49Y	124.8	0.00	0.22	11.46	5	246	77	95	0.00	0.0	1.299	0.004	0	0	0	51
PD.177	PL.1329	ABC	150QA	7.49Y	124.8	0.00	0.22	11.46	0	246	77	95	0.00	0.0	1.299	0.004	0	0	0	51
PL.1330	PD.177	ABC	#2 HdCu -	7.49Y	124.8	0.01	0.22	11.46	5	246	77	95	0.01	0.0	1.328	0.029	1	0	1	51
PL.510	PL.1330	ABC	#2 HdCu -	7.49Y	124.8	0.01	0.23	11.40	5	244	76	95	0.01	0.0	1.361	0.033	11	3	3	50
PL.509	PL.510	ABC	#2 HdCu -	7.49Y	124.8	0.01	0.24	10.90	5	234	73	95	0.02	0.0	1.413	0.052	14	4	6	47
PL.508	PL.509	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.25	10.24	4	219	69	95	0.02	0.0	1.481	0.068	14	4	5	41
PL.506	PL.508	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.26	9.25	4	198	63	95	0.01	0.0	1.531	0.050	23	6	7	35
PL.507	PL.506	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.27	8.20	3	175	57	95	0.01	0.0	1.609	0.078	12	3	2	28
PL.1139	PL.507	A	6 A (CWC)	7.48Y	124.7	0.00	0.27	0.24	0	2	0	100	0.00	0.0	1.614	0.005	0	0	0	3
PD.98	PL.1139	A	40QA	7.48Y	124.7	0.00	0.27	0.24	1	2	0	100	0.00	0.0	1.614	0.005	0	0	0	3
PL.1140	PD.98	A	6 A (CWC)	7.48Y	124.7	0.00	0.27	0.24	0	2	0	100	0.00	0.0	1.626	0.012	2	0	3	3
PL.57	PL.507	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.27	7.55	3	161	53	95	0.00	0.0	1.638	0.028	0	0	0	23
PL.467	PL.57	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.28	7.55	3	161	53	95	0.00	0.0	1.666	0.028	22	6	2	23
PL.468	PL.467	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.28	6.55	3	139	47	95	0.00	0.0	1.703	0.037	15	4	2	21
PL.292	PL.468	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.29	5.25	2	111	39	94	0.01	0.0	1.787	0.085	11	3	3	17
PL.1183	PL.292	B	#4 ACSR	7.48Y	124.7	0.00	0.29	1.87	1	13	4	96	0.00	0.0	1.794	0.006	0	0	0	2
PD.120	PL.1183	B	65QA	7.48Y	124.7	0.00	0.29	1.87	0	13	4	96	0.00	0.0	1.794	0.006	0	0	0	2
PL.1184	PD.120	B	#4 ACSR	7.48Y	124.7	0.00	0.29	1.87	1	13	4	96	0.00	0.0	1.841	0.047	13	4	2	2
PL.293	PL.292	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.30	4.14	2	87	32	94	0.00	0.0	1.897	0.109	7	2	1	12
PL.289	PL.293	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.30	3.47	1	73	28	93	0.00	0.0	2.029	0.132	0	0	0	9
PL.1335	PL.289	ABC	#4 ACSR	7.48Y	124.7	0.00	0.30	3.47	3	73	28	93	0.00	0.0	2.032	0.003	0	0	0	9
PD.180	PL.1335	ABC	100QA	7.48Y	124.7	0.00	0.30	3.47	3	73	28	93	0.00	0.0	2.032	0.003	0	0	0	9
PL.1336	PD.180	ABC	#4 ACSR	7.48Y	124.7	0.01	0.32	3.47	3	73	28	93	0.01	0.0	2.115	0.083	6	2	2	9
PL.66	PL.1336	ABC	#4 ACSR	7.48Y	124.7	0.00	0.32	1.98	2	40	19	90	0.00	0.0	2.122	0.007	40	19	1	1
PL.1339	PL.1336	A	#4 ACSR	7.48Y	124.7	0.00	0.32	1.40	1	10	3	96	0.00	0.0	2.118	0.003	0	0	0	3
PD.182	PL.1339	A	15T	7.48Y	124.7	0.00	0.32	1.40	0	10	3	96	0.00	0.0	2.118	0.003	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1340	PD.182	A	#4 ACSR	7.48Y	124.7	0.01	0.32	1.40	1	10	3	96	0.00	0.0	2.217	0.099	0	0	0	3
PL.67	PL.1340	A	#4 ACSR	7.48Y	124.7	0.00	0.32	0.89	1	6	2	95	0.00	0.0	2.253	0.036	6	2	1	1
PL.69	PL.1340	A	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.51	0	4	1	97	0.00	0.0	2.263	0.046	0	0	0	2
PL.68	PL.69	A	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.00	0	0	0	100	0.00	0.0	2.277	0.014	0	0	0	0
PL.70	PL.69	A	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.51	0	4	1	97	0.00	0.0	2.343	0.081	4	1	2	2
PL.1337	PL.1336	A	#4 ACSR	7.48Y	124.7	0.00	0.32	2.30	2	17	5	96	0.00	0.0	2.118	0.003	0	0	0	3
PD.181	PL.1337	A	65QA	7.48Y	124.7	0.00	0.32	2.30	0	17	5	96	0.00	0.0	2.118	0.003	0	0	0	3
PL.1338	PD.181	A	#4 ACSR	7.48Y	124.7	0.00	0.32	2.30	2	17	5	96	0.00	0.0	2.167	0.049	10	3	2	3
PL.918	PL.1338	A	#4 ACSR	7.48Y	124.7	0.00	0.32	0.86	1	6	2	95	0.00	0.0	2.207	0.040	6	2	1	1
PL.1333	PL.293	A	#4 ACSR	7.48Y	124.7	0.00	0.30	1.00	1	7	2	96	0.00	0.0	1.900	0.003	0	0	0	2
PD.179	PL.1333	A	40QA	7.48Y	124.7	0.00	0.30	1.00	3	7	2	96	0.00	0.0	1.900	0.003	0	0	0	2
PL.1334	PD.179	A	#4 ACSR	7.48Y	124.7	0.00	0.30	1.00	1	7	2	96	0.00	0.0	1.902	0.002	0	0	0	2
PL.99	PL.1334	A	#4 ACSR	7.48Y	124.7	0.00	0.30	0.00	0	0	0	100	0.00	0.0	1.942	0.040	0	0	1	1
PL.286	PL.1334	A	#1/0 ACSR	7.48Y	124.7	0.00	0.30	1.00	0	7	2	96	0.00	0.0	1.907	0.005	0	0	0	1
PL.65	PL.286	A	#1/0 ACSR	7.48Y	124.7	0.00	0.30	1.00	0	7	2	96	0.00	0.0	1.931	0.024	7	2	1	1
PL.1331	PL.468	A	#4 ACSR	7.48Y	124.7	0.00	0.28	1.78	1	13	4	96	0.00	0.0	1.706	0.003	0	0	0	2
PD.178	PL.1331	A	65QA	7.48Y	124.7	0.00	0.28	1.78	0	13	4	96	0.00	0.0	1.706	0.003	0	0	0	2
PL.1332	PD.178	A	6 A (CWC)	7.48Y	124.7	0.00	0.29	1.78	1	13	4	96	0.00	0.0	1.761	0.055	0	0	0	2
PL.466	PL.1332	A	#4 ACSR	7.48Y	124.7	0.00	0.29	1.78	1	13	4	96	0.00	0.0	1.784	0.023	13	4	2	2
PL.916	PL.508	C	#1/0 ACSR	7.48Y	124.7	0.00	0.25	1.07	0	8	2	97	0.00	0.0	1.524	0.043	8	2	1	1
PL.512	PL.1032	ABC	397 SPACER	7.49Y	124.8	0.01	0.22	25.38	5	549	154	96	0.01	0.0	1.397	0.102	0	0	0	132
PL.568	PL.512	A	#4 ACSR	7.48Y	124.7	0.03	0.25	23.58	18	170	47	96	0.04	0.0	1.427	0.030	0	0	0	41
PL.1261	PL.568	A	#4 ACSR	7.48Y	124.7	0.00	0.26	23.58	18	170	47	96	0.00	0.0	1.430	0.003	0	0	0	41
PD.144	PL.1261	A	50L	7.48Y	124.7	0.00	0.26	23.58	47	170	47	96	0.00	0.0	1.430	0.003	0	0	0	41
PL.1262	PD.144	A	#4 ACSR	7.48Y	124.7	0.03	0.29	23.58	18	170	47	96	0.04	0.0	1.460	0.030	18	5	6	41
PL.82	PL.1262	A	#4 ACSR	7.48Y	124.6	0.06	0.35	21.07	16	152	42	96	0.07	0.0	1.530	0.070	13	4	3	35
PL.81	PL.82	A	#4 ACSR	7.48Y	124.6	0.04	0.39	16.48	13	119	33	96	0.03	0.0	1.584	0.053	13	4	5	27
PL.921	PL.81	A	#4 ACSR	7.48Y	124.6	0.00	0.39	4.85	4	35	10	96	0.00	0.0	1.597	0.013	0	0	0	9
PL.922	PL.921	A	#4 ACSR	7.48Y	124.6	0.00	0.40	4.85	4	35	10	96	0.00	0.0	1.624	0.026	21	6	4	9
PL.79	PL.922	A	#4 ACSR	7.48Y	124.6	0.00	0.40	0.85	1	6	2	95	0.00	0.0	1.654	0.031	0	0	0	3
PL.78	PL.79	A	#4 ACSR	7.48Y	124.6	0.00	0.40	0.85	1	6	2	95	0.00	0.0	1.708	0.054	6	2	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.77	PL.78	A	#4 ACSR	7.48Y	124.6	0.00	0.40	0.00	0	0	0	100	0.00	0.0	1.763	0.056	0	0	1	1
PL.83	PL.922	A	#4 ACSR	7.48Y	124.6	0.00	0.40	1.06	1	8	2	97	0.00	0.0	1.627	0.003	0	0	0	2
PL.80	PL.83	A	#4 ACSR	7.48Y	124.6	0.00	0.40	1.06	1	8	2	97	0.00	0.0	1.691	0.064	8	2	2	2
PL.570	PL.81	A	#4 ACSR	7.48Y	124.6	0.02	0.41	9.86	8	71	20	96	0.01	0.0	1.625	0.041	0	0	0	13
PL.571	PL.570	A	#4 ACSR	7.47Y	124.6	0.02	0.42	9.86	8	71	20	96	0.01	0.0	1.668	0.044	14	4	2	13
PL.76	PL.571	A	#4 ACSR	7.47Y	124.6	0.02	0.44	7.94	6	57	16	96	0.01	0.0	1.727	0.058	7	2	1	11
PL.294	PL.76	A	#4 ACSR	7.47Y	124.5	0.02	0.46	7.03	5	51	14	96	0.01	0.0	1.789	0.062	0	0	0	10
PL.295	PL.294	A	#4 ACSR	7.47Y	124.5	0.02	0.49	7.03	5	51	14	96	0.01	0.0	1.869	0.081	5	1	1	10
PL.89	PL.295	A	#4 ACSR	7.47Y	124.5	0.00	0.49	1.34	1	10	3	96	0.00	0.0	1.901	0.032	10	3	1	1
PL.87	PL.295	A	#4 ACSR	7.47Y	124.5	0.02	0.50	3.89	3	28	8	96	0.00	0.0	1.964	0.095	0	0	1	7
PL.574	PL.87	A	#4 ACSR	7.47Y	124.5	0.01	0.51	3.89	3	28	8	96	0.00	0.0	2.043	0.079	16	4	2	6
PL.575	PL.574	A	#4 ACSR	7.47Y	124.5	0.00	0.52	1.69	1	12	3	97	0.00	0.0	2.096	0.053	6	2	1	4
PL.576	PL.575	A	#4 ACSR	7.47Y	124.5	0.00	0.52	0.90	1	6	2	95	0.00	0.0	2.107	0.011	5	1	2	3
PL.86	PL.576	A	#4 ACSR	7.47Y	124.5	0.00	0.52	0.22	0	2	0	100	0.00	0.0	2.169	0.062	0	0	0	1
PL.578	PL.86	A	#4 ACSR	7.47Y	124.5	0.00	0.52	0.22	0	2	0	100	0.00	0.0	2.236	0.067	0	0	0	1
PL.579	PL.578	A	#4 ACSR	7.47Y	124.5	0.00	0.52	0.22	0	2	0	100	0.00	0.0	2.308	0.072	0	0	0	1
PL.577	PL.579	A	#4 ACSR	7.47Y	124.5	0.00	0.52	0.22	0	2	0	100	0.00	0.0	2.359	0.051	2	0	1	1
PL.88	PL.295	A	#4 ACSR	7.47Y	124.5	0.00	0.49	1.09	1	8	2	97	0.00	0.0	1.923	0.054	8	2	1	1
PL.85	PL.82	A	8 A (CWC)	7.48Y	124.6	0.01	0.36	2.76	3	20	6	96	0.00	0.0	1.562	0.032	5	1	1	5
PL.84	PL.85	A	8 A (CWC)	7.48Y	124.6	0.00	0.36	2.09	2	15	4	97	0.00	0.0	1.595	0.033	4	1	2	4
PL.572	PL.84	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	1.49	1	11	3	96	0.00	0.0	1.602	0.007	0	0	0	2
PL.573	PL.572	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	1.49	1	11	3	96	0.00	0.0	1.626	0.024	11	3	2	2
PL.502	PL.512	ABC	397 SPACER	7.49Y	124.8	0.01	0.23	17.52	3	379	107	96	0.00	0.0	1.493	0.096	0	0	0	91
PL.504	PL.502	ABC	397 SPACER	7.49Y	124.8	0.01	0.24	17.46	3	377	106	96	0.01	0.0	1.624	0.131	0	0	0	90
PL.1143	PL.504	A	#4 ACSR	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.628	0.004	0	0	0	0
PD.100	PL.1143	A	40QA	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.628	0.004	0	0	0	0
PL.1144	PD.100	A	#4 ACSR	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.635	0.007	0	0	0	0
PL.499	PL.504	ABC	397 SPACER	7.49Y	124.8	0.01	0.24	17.46	3	377	106	96	0.01	0.0	1.789	0.165	0	0	0	90
PL.494	PL.499	ABC	397 SPACER	7.48Y	124.7	0.01	0.26	17.46	3	377	106	96	0.01	0.0	2.048	0.260	7	2	1	90
PL.487	PL.494	ABC	397 SPACER	7.48Y	124.7	0.00	0.26	17.15	3	371	104	96	0.00	0.0	2.117	0.068	0	0	0	89
PL.485	PL.487	ABC	397 SPACER	7.48Y	124.7	0.01	0.27	17.15	3	371	104	96	0.00	0.0	2.225	0.108	7	2	1	89

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.100	PL.485	ABC	397 SPACER	7.48Y	124.7	0.00	0.27	16.82	3	364	102	96	0.00	0.0	2.241	0.016	4	1	1	88
PL.482	PL.100	ABC	397 SPACER	7.48Y	124.7	0.00	0.27	16.14	3	349	98	96	0.00	0.0	2.312	0.072	8	2	1	84
PL.480	PL.482	ABC	397 SPACER	7.48Y	124.7	0.00	0.27	15.79	3	341	96	96	0.00	0.0	2.371	0.059	0	0	0	83
PL.478	PL.480	ABC	336 MCM AC	7.48Y	124.7	0.01	0.28	15.79	3	341	96	96	0.01	0.0	2.416	0.045	0	0	0	83
PL.1349	PL.478	ABC	336 MCM AC	7.48Y	124.7	0.01	0.28	15.79	3	341	96	96	0.01	0.0	2.460	0.045	0	0	0	83
PL.58	PL.1349	ABC	336 MCM AC	7.48Y	124.7	0.00	0.29	14.56	3	315	88	96	0.00	0.0	2.487	0.027	0	0	0	78
PL.1352	PL.58	C	#1/0 ACSR	7.48Y	124.7	0.00	0.29	2.24	1	16	5	95	0.00	0.0	2.490	0.003	0	0	0	3
PD.187	PL.1352	C	65QA	7.48Y	124.7	0.00	0.29	2.24	0	16	5	95	0.00	0.0	2.490	0.003	0	0	0	3
PL.1353	PD.187	C	#1/0 ACSR	7.48Y	124.7	0.02	0.31	2.24	1	16	5	95	0.00	0.0	2.863	0.373	0	0	0	3
PL.17	PL.1353	C	#4 ACSR	7.48Y	124.7	0.00	0.31	1.76	1	13	4	96	0.00	0.0	2.904	0.041	13	4	2	2
PL.18	PL.1353	C	#4 ACSR	7.48Y	124.7	0.00	0.31	0.48	0	3	1	95	0.00	0.0	2.948	0.084	3	1	1	1
PL.1148	PL.58	ABC	336 MCM AC	7.48Y	124.7	0.01	0.30	13.82	3	299	84	96	0.02	0.0	2.595	0.108	0	0	0	75
PL.59	PL.1148	ABC	336 MCM AC	7.48Y	124.7	0.00	0.30	13.76	3	297	83	96	0.00	0.0	2.623	0.029	0	0	0	74
PL.472	PL.59	ABC	336 MCM AC	7.48Y	124.7	0.01	0.31	13.66	3	295	83	96	0.01	0.0	2.705	0.082	0	0	0	73
PL.1358	PL.472	A	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.41	0	3	1	95	0.00	0.0	2.709	0.003	0	0	0	2
PD.190	PL.1358	A	40QA	7.48Y	124.7	0.00	0.31	0.41	1	3	1	95	0.00	0.0	2.709	0.003	0	0	0	2
PL.1359	PD.190	A	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.41	0	3	1	95	0.00	0.0	2.721	0.012	3	1	2	2
PL.439	PL.472	ABC	336 MCM AC	7.48Y	124.7	0.00	0.31	13.52	3	292	82	96	0.00	0.0	2.733	0.027	1	0	1	71
PL.440	PL.439	ABC	336 MCM AC	7.48Y	124.7	0.00	0.32	13.48	3	291	82	96	0.00	0.0	2.759	0.027	0	0	0	70
PL.13	PL.440	ABC	336 MCM AC	7.48Y	124.7	0.00	0.32	12.93	2	279	78	96	0.01	0.0	2.805	0.046	0	0	0	68
PL.19	PL.13	A	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.78	0	6	2	95	0.00	0.0	2.831	0.026	6	2	1	1
PL.441	PL.13	ABC	336 MCM AC	7.48Y	124.7	0.01	0.33	12.67	2	274	77	96	0.02	0.0	2.916	0.111	0	0	0	67
PL.444	PL.441	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	12.67	2	274	77	96	0.00	0.0	2.940	0.024	2	1	1	67
PL.445	PL.444	ABC	336 MCM AC	7.48Y	124.7	0.01	0.34	12.56	2	271	76	96	0.01	0.0	2.994	0.054	0	0	0	66
PL.447	PL.445	ABC	336 MCM AC	7.48Y	124.7	0.01	0.35	12.28	2	265	74	96	0.01	0.0	3.074	0.080	5	1	1	63
PL.449	PL.447	ABC	336 MCM AC	7.48Y	124.6	0.01	0.35	12.04	2	260	73	96	0.01	0.0	3.178	0.103	0	0	0	62
PL.15	PL.449	ABC	336 MCM AC	7.48Y	124.6	0.01	0.36	11.92	2	258	72	96	0.01	0.0	3.236	0.058	0	0	0	60
PL.453	PL.15	ABC	336 MCM AC	7.48Y	124.6	0.00	0.36	11.92	2	258	72	96	0.01	0.0	3.290	0.054	3	1	2	60
PL.454	PL.453	ABC	336 MCM AC	7.48Y	124.6	0.00	0.37	11.77	2	254	71	96	0.01	0.0	3.342	0.053	0	0	0	58
PL.455	PL.454	ABC	336 MCM AC	7.48Y	124.6	0.01	0.38	11.24	2	243	68	96	0.01	0.0	3.433	0.090	0	0	0	56
PL.1161	PL.455	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	1.62	1	12	3	97	0.00	0.0	3.437	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.109	PL.1161	A	40QA	7.48Y	124.6	0.00	0.38	1.62	4	12	3	97	0.00	0.0	3.437	0.005	0	0	0	2
PL.1162	PD.109	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	1.62	1	12	3	97	0.00	0.0	3.447	0.010	12	3	2	2
PL.458	PL.455	ABC	336 MCM AC	7.48Y	124.6	0.01	0.39	10.71	2	231	65	96	0.01	0.0	3.547	0.115	0	0	0	54
PL.1165	PL.458	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	0.31	0	2	1	89	0.00	0.0	3.552	0.005	0	0	0	1
PD.111	PL.1165	A	40QA	7.48Y	124.6	0.00	0.39	0.31	1	2	1	89	0.00	0.0	3.552	0.005	0	0	0	1
PL.1166	PD.111	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	0.31	0	2	1	89	0.00	0.0	3.588	0.037	2	1	1	1
PL.436	PL.458	ABC	336 MCM AC	7.48Y	124.6	0.00	0.39	8.71	2	188	53	96	0.00	0.0	3.599	0.052	5	1	1	44
PL.437	PL.436	ABC	336 MCM AC	7.48Y	124.6	0.01	0.40	8.48	2	183	51	96	0.01	0.0	3.708	0.108	0	0	0	43
PL.246	PL.437	ABC	336 MCM AC	7.48Y	124.6	0.00	0.40	8.48	2	183	51	96	0.00	0.0	3.762	0.054	0	0	0	43
PL.1021	PL.246	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	2.25	1	16	5	95	0.00	0.0	3.766	0.005	0	0	0	4
PD.36	PL.1021	C	40QA	7.48Y	124.6	0.00	0.40	2.25	6	16	5	95	0.00	0.0	3.766	0.005	0	0	0	4
PL.1022	PD.36	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	2.25	1	16	5	95	0.00	0.0	3.786	0.020	16	5	4	4
PL.16	PL.246	ABC	336 MCM AC	7.48Y	124.6	0.00	0.40	7.73	1	167	47	96	0.00	0.0	3.816	0.054	0	0	0	39
PL.1171	PL.16	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.50	0	4	1	97	0.00	0.0	3.821	0.005	0	0	0	2
PD.114	PL.1171	C	40QA	7.48Y	124.6	0.00	0.40	0.50	1	4	1	97	0.00	0.0	3.821	0.005	0	0	0	2
PL.1172	PD.114	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.50	0	4	1	97	0.00	0.0	3.837	0.016	4	1	2	2
PL.433	PL.16	ABC	336 MCM AC	7.48Y	124.6	0.00	0.40	7.56	1	163	46	96	0.00	0.0	3.865	0.049	5	2	1	37
PL.434	PL.433	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	7.31	1	158	44	96	0.00	0.0	3.904	0.038	8	2	1	36
PL.431	PL.434	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	3.11	1	67	19	96	0.00	0.0	3.919	0.016	0	0	0	14
PL.10586	PL.431	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	3.11	1	67	19	96	0.00	0.0	3.969	0.050	4	1	1	14
PL.10587	PL.10586	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	2.91	1	63	18	96	0.00	0.0	4.021	0.051	6	2	1	13
PL.10585	PL.10587	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	2.61	1	56	16	96	0.00	0.0	4.060	0.039	0	0	0	12
PL.412	PL.10585	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	1.28	0	28	8	96	0.00	0.0	4.155	0.095	1	0	1	8
PL.416	PL.412	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	1.24	0	27	7	97	0.00	0.0	4.199	0.043	0	0	0	7
PL.417	PL.416	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.45	0	10	3	96	0.00	0.0	4.347	0.148	0	0	0	3
PL.421	PL.417	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.19	0	4	1	97	0.00	0.0	4.493	0.146	0	0	0	2
PL.65780	PL.421	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.09	0	2	1	89	0.00	0.0	4.548	0.055	0	0	0	1
PL.65781	PL.65780	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.09	0	2	1	89	0.00	0.0	4.700	0.152	2	1	1	1
PL.1371	PL.65781	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.747	0.046	0	0	0	0
PL.1372	PL.1371	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.749	0.003	0	0	0	0
PD.147-A	PL.1372	ABC	Open	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.749	0.003	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1017	PL.421	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.31	0	2	1	89	0.00	0.0	4.498	0.005	0	0	0	1
PD.34	PL.1017	A	40QA	7.48Y	124.6	0.00	0.41	0.31	1	2	1	89	0.00	0.0	4.498	0.005	0	0	0	1
PL.1018	PD.34	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.31	0	2	1	89	0.00	0.0	4.506	0.008	2	1	1	1
PL.1369	PL.417	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.78	1	6	2	95	0.00	0.0	4.350	0.003	0	0	0	1
PD.195	PL.1369	C	40QA	7.48Y	124.6	0.00	0.41	0.78	2	6	2	95	0.00	0.0	4.350	0.003	0	0	0	1
PL.1370	PD.195	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.78	1	6	2	95	0.00	0.0	4.402	0.052	6	2	1	1
PL.1173	PL.416	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.203	0.005	0	0	0	0
PD.115	PL.1173	C	40QA	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.203	0.005	0	0	0	0
PL.1174	PD.115	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	4.212	0.009	0	0	0	0
PL.1175	PL.416	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	2.36	1	17	5	96	0.00	0.0	4.203	0.005	0	0	0	4
PD.116	PL.1175	A	40QA	7.48Y	124.6	0.00	0.41	2.36	6	17	5	96	0.00	0.0	4.203	0.005	0	0	0	4
PL.1176	PD.116	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	2.36	1	17	5	96	0.00	0.0	4.226	0.022	3	1	1	4
PL.413	PL.1176	A	#4 ACSR	7.48Y	124.6	0.00	0.41	1.90	1	14	4	96	0.00	0.0	4.254	0.028	8	2	2	3
PL.414	PL.413	A	#4 ACSR	7.48Y	124.6	0.00	0.42	0.80	1	6	2	95	0.00	0.0	4.286	0.032	6	2	1	1
PL.1167	PL.10585	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	1.02	0	7	2	96	0.00	0.0	4.065	0.005	0	0	0	3
PD.112	PL.1167	A	25T	7.48Y	124.6	0.00	0.41	1.02	0	7	2	96	0.00	0.0	4.065	0.005	0	0	0	3
PL.1168	PD.112	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	1.02	0	7	2	96	0.00	0.0	4.082	0.017	7	2	3	3
PL.1169	PL.10585	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	2.98	1	21	6	96	0.00	0.0	4.065	0.005	0	0	0	1
PD.113	PL.1169	C	40QA	7.48Y	124.6	0.00	0.41	2.98	7	21	6	96	0.00	0.0	4.065	0.005	0	0	0	1
PL.1170	PD.113	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	2.98	1	21	6	96	0.00	0.0	4.082	0.017	0	0	0	1
PL.20	PL.1170	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	2.98	1	21	6	96	0.00	0.0	4.125	0.043	21	6	1	1
PL.1019	PL.434	B	#1/0 ACSR	7.48Y	124.6	0.00	0.41	11.53	5	83	23	96	0.00	0.0	3.908	0.005	0	0	0	21
PD.35	PL.1019	B	30T	7.48Y	124.6	0.00	0.41	11.53	0	83	23	96	0.00	0.0	3.908	0.005	0	0	0	21
PL.1020	PD.35	B	#1/0 ACSR	7.47Y	124.6	0.02	0.43	11.53	5	83	23	96	0.01	0.0	3.982	0.073	10	3	2	21
PL.430	PL.1020	B	#1/0 ACSR	7.47Y	124.6	0.02	0.45	10.20	4	73	21	96	0.01	0.0	4.085	0.104	10	3	1	19
PL.73	PL.430	B	8 A (CWC)	7.47Y	124.5	0.06	0.51	8.84	9	64	18	96	0.03	0.0	4.186	0.101	0	0	1	18
PL.428	PL.73	B	#4 ACSR	7.47Y	124.5	0.01	0.52	8.84	7	64	18	96	0.01	0.0	4.222	0.036	8	2	3	17
PL.566	PL.428	B	#4 ACSR	7.47Y	124.4	0.04	0.56	7.79	6	56	16	96	0.02	0.0	4.343	0.121	3	1	2	14
PL.565	PL.566	B	#4 ACSR	7.47Y	124.4	0.01	0.58	7.39	6	53	15	96	0.00	0.0	4.383	0.040	5	1	2	12
PL.74	PL.565	B	#4 ACSR	7.47Y	124.4	0.00	0.58	0.60	0	4	1	97	0.00	0.0	4.405	0.022	4	1	2	2
PL.563	PL.565	B	#4 ACSR	7.46Y	124.4	0.02	0.60	6.14	5	44	12	96	0.01	0.0	4.466	0.083	9	2	1	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.919	PL.563	B	#4 ACSR	7.46Y	124.4	0.01	0.61	4.95	4	36	10	96	0.00	0.0	4.507	0.041	0	0	0	7
PL.564	PL.919	B	#4 ACSR	7.46Y	124.4	0.01	0.61	4.95	4	36	10	96	0.00	0.0	4.545	0.038	6	2	1	7
PL.562	PL.564	B	#4 ACSR	7.46Y	124.4	0.02	0.63	4.15	3	30	8	97	0.00	0.0	4.637	0.091	7	2	2	6
PL.561	PL.562	B	#4 ACSR	7.46Y	124.4	0.01	0.64	3.24	2	23	7	96	0.00	0.0	4.713	0.077	0	0	0	4
PL.557	PL.561	B	#4 ACSR	7.46Y	124.4	0.01	0.65	2.69	2	19	5	97	0.00	0.0	4.851	0.137	19	5	3	3
PL.559	PL.561	B	#1/0 ACSR	7.46Y	124.4	0.00	0.64	0.55	0	4	1	97	0.00	0.0	4.760	0.046	4	1	1	1
PL.1163	PL.458	C	#1/0 ACSR	7.48Y	124.6	0.00	0.39	5.67	2	41	11	97	0.00	0.0	3.552	0.005	0	0	0	9
PD.110	PL.1163	C	40QA	7.48Y	124.6	0.00	0.39	5.67	14	41	11	97	0.00	0.0	3.552	0.005	0	0	0	9
PL.1164	PD.110	C	#1/0 ACSR	7.48Y	124.6	0.00	0.39	5.67	2	41	11	97	0.00	0.0	3.568	0.017	0	0	0	9
PL.465	PL.1164	C	#1/0 ACSR	7.48Y	124.6	0.00	0.39	5.67	2	41	11	97	0.00	0.0	3.602	0.034	16	4	4	9
PL.464	PL.465	C	6 A (CWC)	7.48Y	124.6	0.01	0.40	3.46	2	25	7	96	0.00	0.0	3.645	0.043	6	2	1	5
PL.914	PL.464	C	6 A (CWC)	7.48Y	124.6	0.00	0.40	2.61	2	19	5	97	0.00	0.0	3.694	0.049	6	2	2	4
PL.463	PL.914	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	1.73	1	12	3	97	0.00	0.0	3.756	0.062	9	2	1	2
PL.462	PL.463	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.51	0	4	1	97	0.00	0.0	3.810	0.054	0	0	0	1
PL.461	PL.462	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.51	0	4	1	97	0.00	0.0	3.833	0.023	4	1	1	1
PL.460	PL.461	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	3.929	0.096	0	0	0	0
PL.1159	PL.454	A	#1/0 ACSR	7.48Y	124.6	0.00	0.37	1.58	1	11	3	96	0.00	0.0	3.347	0.005	0	0	0	2
PD.108	PL.1159	A	40QA	7.48Y	124.6	0.00	0.37	1.58	4	11	3	96	0.00	0.0	3.347	0.005	0	0	0	2
PL.1160	PD.108	A	#1/0 ACSR	7.48Y	124.6	0.00	0.37	1.58	1	11	3	96	0.00	0.0	3.375	0.028	11	3	2	2
PL.911	PL.1160	A	#2 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	3.401	0.026	0	0	0	0
PL.912	PL.911	A	#2 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	3.417	0.016	0	0	0	0
PL.1157	PL.15	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	3.240	0.005	0	0	0	0
PD.107	PL.1157	A	40QA	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	3.240	0.005	0	0	0	0
PL.1158	PD.107	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	3.251	0.010	0	0	0	0
PL.1155	PL.449	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	3.182	0.005	0	0	0	0
PD.106	PL.1155	A	40QA	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	3.182	0.005	0	0	0	0
PL.1156	PD.106	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	3.199	0.017	0	0	0	0
PL.1153	PL.449	C	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.35	0	3	1	95	0.00	0.0	3.182	0.005	0	0	0	2
PD.105	PL.1153	C	40QA	7.48Y	124.6	0.00	0.35	0.35	1	3	1	95	0.00	0.0	3.182	0.005	0	0	0	2
PL.1154	PD.105	C	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.35	0	3	1	95	0.00	0.0	3.210	0.028	3	1	2	2
PL.1367	PL.445	C	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.83	0	6	2	95	0.00	0.0	2.997	0.003	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.194	PL.1367	C	40QA	7.48Y	124.7	0.00	0.34	0.83	2	6	2	95	0.00	0.0	2.997	0.003	0	0	0	3
PL.1368	PD.194	C	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.83	0	6	2	95	0.00	0.0	3.028	0.031	3	1	2	3
PL.450	PL.1368	C	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.36	0	3	1	95	0.00	0.0	3.082	0.053	3	1	1	1
PL.1365	PL.441	C	336 MCM AC	7.48Y	124.7	0.00	0.33	0.00	0	0	0	100	0.00	0.0	2.918	0.001	0	0	0	0
PL.1360	PL.440	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	1.65	1	12	3	97	0.00	0.0	2.763	0.003	0	0	0	2
PD.191	PL.1360	C	40QA	7.48Y	124.7	0.00	0.32	1.65	4	12	3	97	0.00	0.0	2.763	0.003	0	0	0	2
PL.1361	PD.191	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	1.65	1	12	3	97	0.00	0.0	2.781	0.018	12	3	2	2
PL.1356	PL.59	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	0.31	0	2	1	89	0.00	0.0	2.627	0.003	0	0	0	1
PD.189	PL.1356	C	40QA	7.48Y	124.7	0.00	0.30	0.31	1	2	1	89	0.00	0.0	2.627	0.003	0	0	0	1
PL.1357	PD.189	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	0.31	0	2	1	89	0.00	0.0	2.641	0.015	2	1	1	1
PL.1354	PL.1148	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	0.18	0	1	0	100	0.00	0.0	2.598	0.003	0	0	0	1
PD.188	PL.1354	C	40QA	7.48Y	124.7	0.00	0.30	0.18	0	1	0	100	0.00	0.0	2.598	0.003	0	0	0	1
PL.1355	PD.188	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	0.18	0	1	0	100	0.00	0.0	2.631	0.033	1	0	1	1
PL.72	PL.1349	C	#1/0 ACSR	7.48Y	124.7	0.00	0.29	3.67	2	26	7	97	0.00	0.0	2.470	0.010	6	2	2	5
PL.1350	PL.72	C	8 A (CWC)	7.48Y	124.7	0.00	0.29	2.80	3	20	6	96	0.00	0.0	2.473	0.003	0	0	0	3
PD.186	PL.1350	C	25T	7.48Y	124.7	0.00	0.29	2.80	0	20	6	96	0.00	0.0	2.473	0.003	0	0	0	3
PL.1351	PD.186	C	8 A (CWC)	7.48Y	124.7	0.01	0.29	2.80	3	20	6	96	0.00	0.0	2.515	0.042	0	0	0	3
PL.547	PL.1351	C	8 A (CWC)	7.48Y	124.7	0.01	0.30	1.89	2	14	4	96	0.00	0.0	2.620	0.105	8	2	1	2
PL.544	PL.547	C	#4 ACSR	7.48Y	124.7	0.01	0.31	0.76	1	5	2	93	0.00	0.0	2.916	0.296	5	2	1	1
PL.549	PL.1351	C	#1/0 ACSR	7.48Y	124.7	0.00	0.29	0.91	0	7	2	96	0.00	0.0	2.570	0.055	7	2	1	1
PL.1282	PL.100	A	#4 ACSR	7.48Y	124.7	0.00	0.27	1.44	1	10	3	96	0.00	0.0	2.244	0.003	0	0	0	3
PD.159	PL.1282	A	65QA	7.48Y	124.7	0.00	0.27	1.44	0	10	3	96	0.00	0.0	2.244	0.003	0	0	0	3
PL.1283	PD.159	A	#4 ACSR	7.48Y	124.7	0.00	0.27	1.44	1	10	3	96	0.00	0.0	2.246	0.002	0	0	0	3
PL.101	PL.1283	A	#4 ACSR	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	2.262	0.016	0	0	0	0
PL.285	PL.1283	A	8 A (CWC)	7.48Y	124.7	0.00	0.27	1.44	1	10	3	96	0.00	0.0	2.265	0.019	0	0	0	3
PL.553	PL.285	A	8 A (CWC)	7.48Y	124.7	0.00	0.27	1.44	1	10	3	96	0.00	0.0	2.288	0.023	9	3	2	3
PL.554	PL.553	A	8 A (CWC)	7.48Y	124.7	0.00	0.27	0.16	0	1	0	100	0.00	0.0	2.329	0.041	0	0	0	1
PL.552	PL.554	A	8 A (CWC)	7.48Y	124.7	0.00	0.27	0.16	0	1	0	100	0.00	0.0	2.369	0.041	0	0	0	1
PL.551	PL.552	A	8 A (CWC)	7.48Y	124.7	0.00	0.27	0.16	0	1	0	100	0.00	0.0	2.408	0.039	1	0	1	1
PL.1341	PL.502	B	#4 ACSR	7.49Y	124.8	0.00	0.23	0.19	0	1	0	100	0.00	0.0	1.495	0.003	0	0	0	1
PD.183	PL.1341	B	40QA	7.49Y	124.8	0.00	0.23	0.19	0	1	0	100	0.00	0.0	1.495	0.003	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1342	PD.183	B	#4 ACSR	7.49Y	124.8	0.00	0.23	0.19	0	1	0	100	0.00	0.0	1.511	0.015	1	0	1	1
PL.1325	PL.54	A	#2 ACSR	7.49Y	124.8	0.00	0.20	1.51	1	11	3	96	0.00	0.0	1.190	0.004	0	0	0	2
PD.175	PL.1325	A	40QA	7.49Y	124.8	0.00	0.20	1.51	4	11	3	96	0.00	0.0	1.190	0.004	0	0	0	2
PL.1326	PD.175	A	#2 ACSR	7.49Y	124.8	0.00	0.20	1.51	1	11	3	96	0.00	0.0	1.211	0.021	11	3	2	2
PL.1323	PL.53	B	#2 ACSR	7.49Y	124.8	0.00	0.20	0.68	0	5	1	98	0.00	0.0	1.166	0.003	0	0	0	1
PD.174	PL.1323	B	40QA	7.49Y	124.8	0.00	0.20	0.68	2	5	1	98	0.00	0.0	1.166	0.003	0	0	0	1
PL.1324	PD.174	B	#2 ACSR	7.49Y	124.8	0.00	0.20	0.68	0	5	1	98	0.00	0.0	1.199	0.033	5	1	1	1
PL.1319	PL.98	B	#4 ACSR	7.49Y	124.8	0.00	0.18	3.70	3	27	7	97	0.00	0.0	0.997	0.004	0	0	0	6
PD.172	PL.1319	B	40QA	7.49Y	124.8	0.00	0.18	3.70	9	27	7	97	0.00	0.0	0.997	0.004	0	0	0	6
PL.1320	PD.172	B	#4 ACSR	7.49Y	124.8	0.00	0.18	3.70	3	27	7	97	0.00	0.0	1.004	0.007	6	2	2	6
PL.516	PL.1320	B	#4 ACSR	7.49Y	124.8	0.00	0.18	2.92	2	21	6	96	0.00	0.0	1.020	0.016	15	4	3	4
PL.4	PL.516	B	#4 ACSR	7.49Y	124.8	0.00	0.18	0.82	1	6	2	95	0.00	0.0	1.107	0.087	6	2	1	1
PL.1317	PL.1314	B	6 A (CWC)	7.49Y	124.8	0.00	0.16	1.56	1	11	3	96	0.00	0.0	0.906	0.004	0	0	0	4
PD.171	PL.1317	B	65QA	7.49Y	124.8	0.00	0.16	1.56	0	11	3	96	0.00	0.0	0.906	0.004	0	0	0	4
PL.1318	PD.171	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.56	1	11	3	96	0.00	0.0	0.926	0.020	11	3	4	4
PL.1300	PL.1297	B	#2 ACSR	7.50Y	124.9	0.00	0.08	1.37	1	10	3	96	0.00	0.0	0.361	0.003	0	0	0	4
PD.163	PL.1300	B	65T	7.50Y	124.9	0.00	0.08	1.37	0	10	3	96	0.00	0.0	0.361	0.003	0	0	0	4
PL.1301	PD.163	B	#2 ACSR	7.50Y	124.9	0.00	0.08	1.37	1	10	3	96	0.00	0.0	0.364	0.003	0	0	0	4
PL.299	PL.1301	B	#4 ACSR	7.50Y	124.9	0.00	0.08	0.93	1	7	2	96	0.00	0.0	0.381	0.018	0	0	0	3
PL.1	PL.299	B	#4 ACSR	7.50Y	124.9	0.00	0.08	0.93	1	7	2	96	0.00	0.0	0.395	0.014	7	2	3	3
PL.93	PL.1301	B	#2 ACSR	7.50Y	124.9	0.00	0.08	0.44	0	3	1	95	0.00	0.0	0.379	0.015	3	1	1	1
PL.1287	PL.1389	B	6 A (CWC)	7.50Y	125.0	0.00	0.04	0.90	1	6	2	95	0.00	0.0	0.109	0.003	0	0	0	3
PD.161	PL.1287	B	65QA	7.50Y	125.0	0.00	0.04	0.90	0	6	2	95	0.00	0.0	0.109	0.003	0	0	0	3
PL.1288	PD.161	B	#2 ACSR	7.50Y	125.0	0.00	0.04	0.90	1	6	2	95	0.00	0.0	0.131	0.023	6	2	3	3
PL.1852	Goose Rock	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	260.48	50	5531	1937	94	0.32	0.0	0.006	0.006	0	0	0	1228
PL.7155	PL.1852	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	260.48	50	5531	1937	94	0.08	0.0	0.007	0.001	0	0	0	1228

----- Feeder No. 1 (Garrad F1) Beginning with Device PD.1526 -----

PD.1526	PL.7155	ABC	480VWE	7.50Y	125.0	0.00	0.01	260.48	0	5531	1936	94	0.00	0.0	0.007	0.001	0	0	0	1228
PL.7156	PD.1526	ABC	336 MCM AC	7.49Y	124.9	0.09	0.10	260.48	50	5531	1936	94	2.43	0.0	0.049	0.043	10	3	1	1228

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1390	PL.7156	ABC	336 MCM AC	7.48Y	124.6	0.31	0.41	260.02	50	5519	1928	94	8.47	0.2	0.198	0.149	0	0	0	1227
PL.2476	PL.1390	A	#4 ACSR	7.48Y	124.6	0.00	0.41	1.02	1	7	2	96	0.00	0.0	0.203	0.005	0	0	0	4
PD.309	PL.2476	A	40QA	7.48Y	124.6	0.00	0.41	1.02	3	7	2	96	0.00	0.0	0.203	0.005	0	0	0	4
PL.2477	PD.309	A	#4 ACSR	7.48Y	124.6	0.00	0.42	1.02	1	7	2	96	0.00	0.0	0.289	0.086	6	2	2	4
PL.1392	PL.2477	A	#1/0 ACSR	7.48Y	124.6	0.00	0.42	0.19	0	1	0	100	0.00	0.0	0.331	0.042	1	0	2	2
PL.1393	PL.1390	ABC	336 MCM AC	7.45Y	124.2	0.40	0.81	259.68	50	5503	1906	94	10.86	0.2	0.389	0.191	0	0	0	1223
PL.1395	PL.1393	ABC	336 MCM AC	7.44Y	123.9	0.25	1.06	244.12	47	5156	1787	94	6.54	0.1	0.520	0.130	0	0	0	1131
PL.5262	PL.1395	C	#1/0 ACSR	7.44Y	123.9	0.00	1.06	1.10	0	8	2	97	0.00	0.0	0.523	0.004	0	0	0	2
PD.894	PL.5262	C	40QA	7.44Y	123.9	0.00	1.06	1.10	3	8	2	97	0.00	0.0	0.523	0.004	0	0	0	2
PL.5263	PD.894	C	#1/0 ACSR	7.44Y	123.9	0.00	1.06	1.10	0	8	2	97	0.00	0.0	0.540	0.017	8	2	2	2
PL.5264	PL.1395	B	#1/0 ACSR	7.44Y	123.9	0.00	1.06	9.12	4	65	18	96	0.00	0.0	0.523	0.003	0	0	0	14
PD.895	PL.5264	B	70L	7.44Y	123.9	0.00	1.06	9.12	13	65	18	96	0.00	0.0	0.523	0.003	0	0	0	14
PL.5265	PD.895	B	#1/0 ACSR	7.43Y	123.9	0.03	1.09	9.12	4	65	18	96	0.01	0.0	0.667	0.144	6	2	1	14
PL.1584	PL.5265	B	6 A (CWC)	7.43Y	123.9	0.01	1.11	8.31	6	60	17	96	0.01	0.0	0.702	0.035	0	0	0	13
PL.1401	PL.1584	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	1.75	1	13	3	97	0.00	0.0	0.749	0.047	2	1	1	2
PL.1402	PL.1401	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	1.47	1	10	3	96	0.00	0.0	0.794	0.044	10	3	1	1
PL.1585	PL.1584	B	6 A (CWC)	7.43Y	123.9	0.02	1.13	6.56	5	47	13	96	0.01	0.0	0.779	0.077	2	1	2	11
PL.1403	PL.1585	B	6 A (CWC)	7.43Y	123.8	0.05	1.18	6.30	5	45	13	96	0.02	0.0	0.968	0.189	0	0	0	9
PL.1406	PL.1403	B	#2 ACSR	7.43Y	123.8	0.00	1.19	1.38	1	10	3	96	0.00	0.0	1.094	0.126	10	3	1	1
PL.1405	PL.1403	B	8 A (CWC)	7.42Y	123.7	0.08	1.26	4.93	5	35	10	96	0.02	0.1	1.213	0.245	0	0	0	8
PL.1410	PL.1405	B	8 A (CWC)	7.42Y	123.7	0.03	1.29	4.93	5	35	10	96	0.01	0.0	1.290	0.077	0	0	0	8
PL.1411	PL.1410	B	8 A (CWC)	7.42Y	123.7	0.04	1.33	4.93	5	35	10	96	0.01	0.0	1.460	0.170	15	4	2	8
PL.1413	PL.1411	B	#2 ACSR	7.42Y	123.7	0.00	1.33	0.71	0	5	1	98	0.00	0.0	1.488	0.028	5	1	1	2
PL.1418	PL.1413	B	#2 ACSR	7.42Y	123.7	0.00	1.33	0.06	0	0	0	100	0.00	0.0	1.647	0.159	0	0	1	1
PL.1414	PL.1411	B	#4 ACSR	7.42Y	123.7	0.00	1.34	2.06	2	15	4	97	0.00	0.0	1.501	0.041	0	0	0	4
PL.1416	PL.1414	B	#4 ACSR	7.42Y	123.7	0.00	1.34	0.96	1	7	2	96	0.00	0.0	1.662	0.161	7	2	2	2
PL.1415	PL.1414	B	#4 ACSR	7.42Y	123.7	0.00	1.34	1.09	1	8	2	97	0.00	0.0	1.523	0.022	8	2	2	2
PL.1399	PL.1395	ABC	336 MCM AC	7.43Y	123.9	0.06	1.13	240.72	46	5077	1751	95	1.58	0.0	0.552	0.032	0	0	0	1115
PL.1459	PL.1399	ABC	336 MCM AC	7.42Y	123.7	0.15	1.28	239.82	46	5056	1742	95	3.91	0.1	0.633	0.081	0	0	0	1112
PL.2412	PL.1459	C	#1/0 ACSR	7.42Y	123.7	0.00	1.28	0.72	0	5	1	98	0.00	0.0	0.637	0.005	0	0	0	1
PD.276	PL.2412	C	40QA	7.42Y	123.7	0.00	1.28	0.72	2	5	1	98	0.00	0.0	0.637	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2413	PD.276	C	#1/0 ACSR	7.42Y	123.7	0.00	1.28	0.72	0	5	1	98	0.00	0.0	0.643	0.005	0	0	0	1
PL.1464	PL.2413	C	#1/0 ACSR	7.42Y	123.7	0.00	1.28	0.72	0	5	1	98	0.00	0.0	0.684	0.041	0	0	0	1
PL.1472	PL.1464	C	#2 ACSR	7.42Y	123.7	0.00	1.28	0.72	0	5	1	98	0.00	0.0	0.756	0.072	0	0	0	1
PL.1473	PL.1472	C	#2 ACSR	7.42Y	123.7	0.00	1.28	0.72	0	5	1	98	0.00	0.0	0.796	0.040	5	1	1	1
PL.1465	PL.1459	ABC	336 MCM AC	7.42Y	123.7	0.05	1.33	239.58	46	5046	1731	95	1.22	0.0	0.658	0.025	0	0	0	1111
PL.1466	PL.1465	ABC	336 MCM AC	7.42Y	123.6	0.06	1.39	239.52	46	5044	1728	95	1.50	0.0	0.689	0.031	0	0	0	1110
PL.1496	PL.1466	ABC	336 MCM AC	7.40Y	123.3	0.30	1.68	235.03	45	4946	1698	95	7.37	0.1	0.847	0.158	0	0	0	1082
PL.1580	PL.1496	ABC	336 MCM AC	7.38Y	123.0	0.34	2.03	235.03	45	4939	1681	95	8.57	0.2	1.031	0.184	0	0	0	1082
PL.1581	PL.1580	ABC	336 MCM AC	7.37Y	122.8	0.18	2.20	234.42	45	4917	1657	95	4.40	0.1	1.126	0.095	0	0	0	1080
PL.2480	PL.1581	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.22	1	9	2	98	0.00	0.0	1.131	0.005	0	0	0	3
PD.311	PL.2480	C	50QA	7.37Y	122.8	0.00	2.20	1.22	2	9	2	98	0.00	0.0	1.131	0.005	0	0	0	3
PL.2481	PD.311	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.22	1	9	2	98	0.00	0.0	1.143	0.012	0	0	0	3
PL.1499	PL.2481	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	1.22	1	9	2	98	0.00	0.0	1.179	0.037	6	2	1	3
PL.2138	PL.1499	C	#4 ACSR	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	1.249	0.069	0	0	0	0
PL.2139	PL.2138	C	#4 ACSR	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	1.329	0.080	0	0	0	0
PL.1505	PL.1499	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	0.37	0	3	1	95	0.00	0.0	1.255	0.075	3	1	2	2
PL.1506	PL.1505	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	1.294	0.040	0	0	0	0
PL.1498	PL.1581	ABC	336 MCM AC	7.36Y	122.7	0.08	2.28	234.02	45	4904	1644	95	1.88	0.0	1.167	0.041	0	0	0	1077
PL.1501	PL.1498	ABC	336 MCM AC	7.35Y	122.5	0.25	2.53	234.02	45	4902	1640	95	6.22	0.1	1.302	0.135	0	0	0	1077
PL.2140	PL.1501	ABC	336 MCM AC	7.34Y	122.3	0.20	2.73	234.02	45	4896	1625	95	5.05	0.1	1.412	0.109	0	0	0	1077
PL.2141	PL.2140	ABC	336 MCM AC	7.33Y	122.2	0.05	2.78	234.02	45	4891	1614	95	1.26	0.0	1.439	0.027	5	1	1	1077
PL.1507	PL.2141	ABC	336 MCM AC	7.33Y	122.1	0.10	2.88	232.81	45	4864	1604	95	2.51	0.1	1.494	0.055	0	0	0	1069
PL.1509	PL.1507	ABC	336 MCM AC	7.32Y	122.1	0.07	2.95	232.81	45	4862	1598	95	1.66	0.0	1.530	0.036	0	0	0	1069
PL.1510	PL.1509	ABC	336 MCM AC	7.32Y	122.0	0.06	3.01	232.81	45	4860	1594	95	1.48	0.0	1.563	0.032	0	0	0	1069
PL.1511	PL.1510	ABC	336 MCM AC	7.32Y	121.9	0.06	3.07	225.85	44	4715	1537	95	1.58	0.0	1.599	0.037	0	0	0	1053
PL.1522	PL.1511	ABC	336 MCM AC	7.30Y	121.7	0.18	3.25	225.05	43	4697	1529	95	4.36	0.1	1.702	0.102	8	2	1	1051
PL.1528	PL.1522	ABC	336 MCM AC	7.30Y	121.7	0.07	3.32	223.73	43	4664	1511	95	1.70	0.0	1.742	0.040	0	0	0	1045
PL.2292	PL.1528	A	#1/0 ACSR	7.30Y	121.7	0.00	3.32	1.30	1	9	3	95	0.00	0.0	1.746	0.005	0	0	0	3
PD.219	PL.2292	A	40QA	7.30Y	121.7	0.00	3.32	1.30	3	9	3	95	0.00	0.0	1.746	0.005	0	0	0	3
PL.2293	PD.219	A	#1/0 ACSR	7.30Y	121.7	0.00	3.32	1.30	1	9	3	95	0.00	0.0	1.757	0.010	9	3	3	3
PL.1529	PL.1528	ABC	336 MCM AC	7.30Y	121.6	0.07	3.39	223.30	43	4654	1504	95	1.72	0.0	1.783	0.041	0	0	0	1042

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1539	PL.1529	ABC	336 MCM AC	7.29Y	121.4	0.17	3.56	222.84	43	4642	1497	95	4.12	0.1	1.881	0.098	0	0	0	1040
PL.1542	PL.1539	ABC	#1/0 ACSR	7.29Y	121.4	0.00	3.57	1.41	1	30	8	97	0.00	0.0	1.911	0.030	0	0	0	4
PL.1543	PL.1542	ABC	#1/0 ACSR	7.29Y	121.4	0.00	3.57	0.94	0	20	5	97	0.00	0.0	1.929	0.018	20	5	1	1
PL.2328	PL.1542	C	#1/0 ACSR	7.29Y	121.4	0.00	3.57	1.41	1	10	3	96	0.00	0.0	1.915	0.005	0	0	0	3
PD.236	PL.2328	C	40QA	7.29Y	121.4	0.00	3.57	1.41	4	10	3	96	0.00	0.0	1.915	0.005	0	0	0	3
PL.2329	PD.236	C	#1/0 ACSR	7.29Y	121.4	0.00	3.57	1.41	1	10	3	96	0.00	0.0	1.953	0.037	10	3	3	3
PL.1541	PL.1539	ABC	336 MCM AC	7.28Y	121.4	0.06	3.63	221.43	43	4608	1480	95	1.49	0.0	1.917	0.036	0	0	0	1036
PL.1544	PL.1541	ABC	336 MCM AC	7.27Y	121.2	0.20	3.83	220.99	43	4598	1474	95	4.89	0.1	2.036	0.119	0	0	0	1035
PL.1547	PL.1544	ABC	336 MCM AC	7.26Y	121.0	0.17	4.00	220.99	43	4593	1462	95	4.10	0.1	2.136	0.100	0	0	0	1035
PL.1549	PL.1547	ABC	336 MCM AC	7.25Y	120.9	0.08	4.08	220.44	42	4577	1449	95	1.97	0.0	2.184	0.048	0	0	0	1033
PL.2334	PL.1549	C	#1/0 ACSR	7.25Y	120.9	0.00	4.08	0.67	0	5	1	98	0.00	0.0	2.189	0.005	0	0	0	1
PD.239	PL.2334	C	40QA	7.25Y	120.9	0.00	4.08	0.67	2	5	1	98	0.00	0.0	2.189	0.005	0	0	0	1
PL.2335	PD.239	C	#1/0 ACSR	7.25Y	120.9	0.00	4.08	0.67	0	5	1	98	0.00	0.0	2.226	0.037	5	1	1	1
PL.1550	PL.1549	ABC	336 MCM AC	7.25Y	120.8	0.16	4.25	220.21	42	4570	1443	95	3.89	0.1	2.279	0.095	0	0	0	1032
PL.1552	PL.1550	ABC	336 MCM AC	7.23Y	120.5	0.24	4.48	216.52	42	4489	1413	95	5.56	0.1	2.420	0.141	0	0	0	1021
PL.1564	PL.1552	ABC	336 MCM AC	7.22Y	120.3	0.21	4.69	216.52	42	4484	1400	95	4.98	0.1	2.546	0.126	0	0	0	1021
PL.1568	PL.1564	ABC	336 MCM AC	7.21Y	120.1	0.17	4.86	216.02	42	4468	1385	96	3.95	0.1	2.647	0.101	0	0	0	1018
PL.2322	PL.1568	A	8 A (CWC)	7.21Y	120.1	0.00	4.86	0.61	1	4	1	97	0.00	0.0	2.651	0.004	0	0	0	5
PD.233	PL.2322	A	40QA	7.21Y	120.1	0.00	4.86	0.61	2	4	1	97	0.00	0.0	2.651	0.004	0	0	0	5
PL.2323	PD.233	A	8 A (CWC)	7.21Y	120.1	0.00	4.86	0.61	1	4	1	97	0.00	0.0	2.758	0.107	0	0	0	5
PL.1574	PL.2323	A	#4 ACSR	7.21Y	120.1	0.00	4.87	0.61	0	4	1	97	0.00	0.0	2.854	0.096	0	0	0	5
PL.1578	PL.1574	A	#2 ACSR	7.21Y	120.1	0.00	4.87	0.61	0	4	1	97	0.00	0.0	2.891	0.037	4	1	5	5
PL.2320	PL.1568	ABC	336 MCM AC	7.21Y	120.1	0.01	4.87	215.82	42	4460	1375	96	0.17	0.0	2.651	0.004	0	0	0	1013
PL.2321	PL.2320	ABC	336 MCM AC	7.19Y	119.9	0.22	5.09	215.82	42	4460	1374	96	5.26	0.1	2.785	0.134	0	0	0	1013
PL.1579	PL.2321	ABC	336 MCM AC	7.18Y	119.6	0.28	5.36	215.82	42	4455	1362	96	6.54	0.1	2.952	0.167	0	0	0	1013
PL.2490	PL.1579	C	#4 ACSR	7.18Y	119.6	0.00	5.37	1.28	1	9	2	98	0.00	0.0	2.956	0.005	0	0	0	1
PD.316	PL.2490	C	15T	7.18Y	119.6	0.00	5.37	1.28	0	9	2	98	0.00	0.0	2.956	0.005	0	0	0	1
PL.2491	PD.316	C	#4 ACSR	7.18Y	119.6	0.00	5.37	1.28	1	9	2	98	0.00	0.0	2.980	0.024	9	2	1	1
PL.1593	PL.1579	ABC	336 MCM AC	7.16Y	119.4	0.27	5.63	214.89	41	4429	1341	96	6.31	0.1	3.114	0.162	0	0	0	1011
PL.2338	PL.1593	C	#2 ACSR	7.16Y	119.4	0.00	5.63	0.64	0	4	1	97	0.00	0.0	3.118	0.005	0	0	0	1
PD.241	PL.2338	C	40QA	7.16Y	119.4	0.00	5.63	0.64	2	4	1	97	0.00	0.0	3.118	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2339	PD.241	C	#2 ACSR	7.16Y	119.4	0.00	5.63	0.64	0	4	1	97	0.00	0.0	3.130	0.012	4	1	1	1
PL.2492	PL.1593	A	#2 ACSR	7.16Y	119.4	0.00	5.63	5.00	3	35	10	96	0.00	0.0	3.118	0.004	0	0	0	5
PD.317	PL.2492	A	40QA	7.16Y	119.4	0.00	5.63	5.00	13	35	10	96	0.00	0.0	3.118	0.004	0	0	0	5
PL.2493	PD.317	A	#2 ACSR	7.16Y	119.4	0.00	5.64	5.00	3	35	10	96	0.00	0.0	3.152	0.034	8	2	1	5
PL.1599	PL.2493	A	#2 ACSR	7.16Y	119.4	0.00	5.64	2.11	1	15	4	97	0.00	0.0	3.197	0.044	15	4	2	2
PL.1598	PL.2493	A	#2 ACSR	7.16Y	119.4	0.00	5.64	1.66	1	11	3	96	0.00	0.0	3.176	0.024	11	3	2	2
PL.2131	PL.1593	ABC	336 MCM AC	7.16Y	119.3	0.10	5.73	213.00	41	4383	1316	96	2.25	0.1	3.173	0.059	0	0	0	1005
PL.2132	PL.2131	ABC	336 MCM AC	7.15Y	119.2	0.12	5.85	211.58	41	4352	1302	96	2.85	0.1	3.248	0.076	1	0	1	998
PL.1603	PL.2132	ABC	336 MCM AC	7.15Y	119.1	0.03	5.88	141.88	27	2913	879	96	0.50	0.0	3.278	0.030	2	1	3	622
PL.1775	PL.1603	ABC	336 MCM AC	7.14Y	119.0	0.10	5.98	141.76	27	2910	877	96	1.59	0.1	3.372	0.094	13	4	1	619
PL.2182	PL.1775	ABC	336 MCM AC	7.14Y	119.0	0.05	6.03	141.14	27	2896	870	96	0.72	0.0	3.415	0.043	0	0	0	618
PL.2266	PL.2182	ABC	336 MCM AC	7.14Y	119.0	0.02	6.05	137.67	27	2824	848	96	0.30	0.0	3.433	0.018	0	0	0	602
PL.2562	PL.2266	ABC	336 MCM AC	7.14Y	118.9	0.00	6.05	137.67	27	2823	847	96	0.04	0.0	3.436	0.003	0	0	0	602
PD.354	PL.2562	ABC	4804C	7.14Y	118.9	0.00	6.05	137.67	0	2823	847	96	0.00	0.0	3.436	0.003	0	0	0	602
PL.2563	PD.354	ABC	336 MCM AC	7.14Y	118.9	0.03	6.08	137.67	27	2823	847	96	0.43	0.0	3.463	0.027	0	0	0	602
PL.2009	PL.2563	ABC	336 MCM AC	7.14Y	118.9	0.00	6.08	137.67	27	2823	846	96	0.02	0.0	3.464	0.001	0	0	0	602
C RG.2	PL.2009	ABC	114.3 KVA	7.46Y	124.4	-5.44	0.64	137.67	92	2823	846	96	percent Boost= 4.38 Tap= 7.0						602	C
PL.2008	RG.2	ABC	336 MCM AC	7.46Y	124.4	0.00	0.64	131.65	25	2823	846	96	0.02	0.0	3.466	0.001	0	0	0	602
PL.2179	PL.2008	ABC	336 MCM AC	7.46Y	124.3	0.03	0.67	131.65	25	2823	846	96	0.38	0.0	3.492	0.026	0	0	1	602
PL.2180	PL.2179	ABC	336 MCM AC	7.46Y	124.3	0.06	0.73	131.63	25	2822	845	96	0.85	0.0	3.550	0.059	0	0	0	601
PL.2318	PL.2180	C	#1/0 ACSR	7.46Y	124.3	0.00	0.73	0.42	0	3	1	95	0.00	0.0	3.555	0.005	0	0	0	1
PD.232	PL.2318	C	40QA	7.46Y	124.3	0.00	0.73	0.42	1	3	1	95	0.00	0.0	3.555	0.005	0	0	0	1
PL.2319	PD.232	C	#1/0 ACSR	7.46Y	124.3	0.00	0.73	0.42	0	3	1	95	0.00	0.0	3.576	0.021	3	1	1	1
PL.2130	PL.2180	ABC	336 MCM AC	7.45Y	124.2	0.06	0.78	131.49	25	2818	842	96	0.85	0.0	3.608	0.058	0	0	0	600
PL.2128	PL.2130	ABC	336 MCM AC	7.45Y	124.2	0.03	0.81	131.49	25	2817	840	96	0.40	0.0	3.636	0.028	0	0	0	600
PL.2129	PL.2128	ABC	336 MCM AC	7.45Y	124.2	0.02	0.83	104.32	20	2232	675	96	0.24	0.0	3.662	0.026	0	0	0	476
PL.2316	PL.2129	C	#4 ACSR	7.45Y	124.2	0.00	0.83	4.79	4	34	10	96	0.00	0.0	3.667	0.005	0	0	0	8
PD.231	PL.2316	C	20T	7.45Y	124.2	0.00	0.83	4.79	0	34	10	96	0.00	0.0	3.667	0.005	0	0	0	8
PL.2317	PD.231	C	#4 ACSR	7.45Y	124.2	0.01	0.85	4.79	4	34	10	96	0.00	0.0	3.734	0.067	10	3	1	8
PL.1984	PL.2317	C	6 A (CWC)	7.45Y	124.1	0.01	0.85	3.34	2	24	7	96	0.00	0.0	3.780	0.046	3	1	2	7
PL.1985	PL.1984	C	6 A (CWC)	7.45Y	124.1	0.00	0.85	1.46	1	10	3	96	0.00	0.0	3.841	0.061	5	1	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1987	PL.1985	C	6 A (CWC)	7.45Y	124.1	0.00	0.86	0.75	1	5	2	93	0.00	0.0	3.878	0.037	5	2	2	2
PL.1986	PL.1984	C	#4 ACSR	7.45Y	124.1	0.00	0.85	1.49	1	11	3	96	0.00	0.0	3.819	0.039	11	3	2	2
PL.2177	PL.2129	ABC	336 MCM AC	7.45Y	124.1	0.03	0.86	102.73	20	2198	664	96	0.29	0.0	3.695	0.033	1	0	1	468
PL.2178	PL.2177	ABC	336 MCM AC	7.45Y	124.1	0.02	0.87	102.67	20	2196	663	96	0.19	0.0	3.716	0.022	0	0	0	467
PL.2125	PL.2178	ABC	336 MCM AC	7.45Y	124.1	0.02	0.90	102.43	20	2191	661	96	0.26	0.0	3.745	0.029	0	0	0	466
PL.2173	PL.2125	ABC	336 MCM AC	7.44Y	124.0	0.07	0.96	101.84	20	2178	656	96	0.76	0.0	3.832	0.087	3	1	1	464
PL.2174	PL.2173	ABC	336 MCM AC	7.44Y	124.0	0.02	0.98	101.71	20	2175	654	96	0.22	0.0	3.858	0.026	0	0	0	463
PL.2171	PL.2174	ABC	336 MCM AC	7.44Y	124.0	0.06	1.05	100.75	19	2154	648	96	0.72	0.0	3.942	0.084	0	0	0	460
PL.2172	PL.2171	ABC	336 MCM AC	7.44Y	123.9	0.02	1.07	100.75	19	2153	646	96	0.24	0.0	3.971	0.029	8	2	5	460
PL.2170	PL.2172	ABC	336 MCM AC	7.43Y	123.8	0.09	1.16	100.40	19	2145	643	96	0.96	0.0	4.083	0.112	0	0	0	455
PL.2312	PL.2170	C	#2 ACSR	7.43Y	123.8	0.00	1.16	3.24	2	23	6	97	0.00	0.0	4.088	0.005	0	0	0	3
PD.229	PL.2312	C	20T	7.43Y	123.8	0.00	1.16	3.24	0	23	6	97	0.00	0.0	4.088	0.005	0	0	0	3
PL.2313	PD.229	C	#2 ACSR	7.43Y	123.8	0.00	1.16	3.24	2	23	6	97	0.00	0.0	4.136	0.048	23	6	3	3
PL.2122	PL.2170	ABC	336 MCM AC	7.43Y	123.8	0.04	1.20	99.32	19	2121	635	96	0.44	0.0	4.136	0.053	0	0	0	452
PL.2308	PL.2122	C	#2 ACSR	7.43Y	123.8	0.00	1.20	1.44	1	10	3	96	0.00	0.0	4.141	0.005	0	0	0	3
PD.227	PL.2308	C	40QA	7.43Y	123.8	0.00	1.20	1.44	4	10	3	96	0.00	0.0	4.141	0.005	0	0	0	3
PL.2309	PD.227	C	#2 ACSR	7.43Y	123.8	0.00	1.20	1.44	1	10	3	96	0.00	0.0	4.169	0.028	10	3	3	3
PL.1793	PL.2309	C	#2 ACSR	7.43Y	123.8	0.00	1.20	0.00	0	0	0	100	0.00	0.0	4.197	0.028	0	0	0	0
PL.2120	PL.2122	ABC	336 MCM AC	7.43Y	123.8	0.02	1.22	98.84	19	2110	631	96	0.24	0.0	4.165	0.029	0	0	0	449
PL.2175	PL.2120	ABC	336 MCM AC	7.42Y	123.7	0.13	1.35	98.51	19	2103	628	96	1.39	0.1	4.335	0.170	3	1	2	448
PL.2176	PL.2175	ABC	336 MCM AC	7.42Y	123.6	0.04	1.39	98.39	19	2099	624	96	0.44	0.0	4.389	0.054	0	0	0	446
PL.2546	PL.2176	ABC	1/0 AL URD	7.42Y	123.6	0.00	1.39	7.13	4	146	62	92	0.00	0.0	4.394	0.005	0	0	0	4
PD.344	PL.2546	ABC	40QA	7.42Y	123.6	0.00	1.39	7.13	18	146	63	92	0.00	0.0	4.394	0.005	0	0	0	4
PL.2547	PD.344	ABC	1/0 AL URD	7.42Y	123.6	0.00	1.39	7.13	4	146	63	92	0.00	0.0	4.412	0.018	0	0	0	4
PL.1795	PL.2547	ABC	1/0 AL URD	7.42Y	123.6	0.01	1.40	6.89	4	140	61	92	0.01	0.0	4.453	0.042	0	0	0	3
PL.1804	PL.1795	ABC	1/0 AL URD	7.42Y	123.6	0.01	1.40	6.90	4	140	62	91	0.00	0.0	4.518	0.065	118	57	1	3
PL.1796	PL.1804	ABC	1/0 AL URD	7.42Y	123.6	0.00	1.40	1.04	1	23	5	98	0.00	0.0	4.558	0.039	0	0	0	2
PL.1797	PL.1796	A	1/0 AL URD	7.42Y	123.6	0.00	1.40	3.16	2	23	6	97	0.00	0.0	4.560	0.002	23	6	1	1
PL.1798	PL.1796	ABC	1/0 AL URD	7.42Y	123.6	0.00	1.40	0.02	0	0	0	100	0.00	0.0	4.588	0.030	0	0	0	1
PL.1799	PL.1798	A	1/0 AL URD	7.42Y	123.6	0.00	1.40	0.01	0	0	0	100	0.00	0.0	4.590	0.002	0	0	1	1
PL.1794	PL.2547	A	1/0 AL URD	7.42Y	123.6	0.00	1.39	0.74	0	5	1	98	0.00	0.0	4.414	0.002	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2112	PL.2176	ABC	336 MCM AC	7.41Y	123.6	0.04	1.42	91.31	18	1953	561	96	0.36	0.0	4.441	0.052	2	1	2	442
PL.1802	PL.2112	A	1/0 AL URD	7.41Y	123.6	0.00	1.42	3.84	2	27	7	97	0.00	0.0	4.445	0.005	0	0	0	7
PD.214	PL.1802	A	40QA	7.41Y	123.6	0.00	1.42	3.84	10	27	7	97	0.00	0.0	4.445	0.005	0	0	0	7
PL.2007	PD.214	A	1/0 AL URD	7.41Y	123.6	0.00	1.42	3.84	2	27	7	97	0.00	0.0	4.457	0.012	0	0	0	7
PL.1801	PL.2007	A	1/0 AL URD	7.41Y	123.6	0.00	1.43	3.84	2	27	7	97	0.00	0.0	4.487	0.030	27	8	4	7
PL.1800	PL.1801	A	1/0 AL URD	7.41Y	123.6	0.00	1.43	-0.01	0	0	0	100	0.00	0.0	4.513	0.026	0	0	3	3
PL.2113	PL.2112	ABC	336 MCM AC	7.41Y	123.5	0.08	1.50	89.92	17	1923	552	96	0.77	0.0	4.554	0.114	0	0	0	433
PL.2109	PL.2113	ABC	336 MCM AC	7.41Y	123.4	0.06	1.56	89.92	17	1922	550	96	0.61	0.0	4.644	0.090	0	0	0	433
PL.2278	PL.2109	B	#4 ACSR	7.41Y	123.4	0.00	1.56	1.56	1	11	3	96	0.00	0.0	4.649	0.005	0	0	0	1
PD.211	PL.2278	B	40QA	7.41Y	123.4	0.00	1.56	1.56	4	11	3	96	0.00	0.0	4.649	0.005	0	0	0	1
PL.2279	PD.211	B	#4 ACSR	7.41Y	123.4	0.00	1.56	1.56	1	11	3	96	0.00	0.0	4.675	0.027	11	3	1	1
PL.2110	PL.2109	ABC	336 MCM AC	7.40Y	123.4	0.08	1.63	89.40	17	1910	545	96	0.76	0.0	4.756	0.112	0	0	0	432
PL.2099	PL.2110	ABC	336 MCM AC	7.40Y	123.3	0.04	1.67	86.68	17	1851	527	96	0.37	0.0	4.815	0.058	2	0	1	417
PL.2282	PL.2099	A	#4 ACSR	7.40Y	123.3	0.00	1.67	2.96	2	21	6	96	0.00	0.0	4.819	0.005	0	0	0	11
PD.213	PL.2282	A	40QA	7.40Y	123.3	0.00	1.67	2.96	7	21	6	96	0.00	0.0	4.819	0.005	0	0	0	11
PL.2283	PD.213	A	#4 ACSR	7.40Y	123.3	0.00	1.68	2.96	2	21	6	96	0.00	0.0	4.846	0.027	21	6	11	11
PL.1588	PL.2099	ABC	336 MCM AC	7.40Y	123.3	0.01	1.69	85.61	16	1828	520	96	0.14	0.0	4.837	0.022	5	1	2	405
PL.1589	PL.1588	ABC	336 MCM AC	7.40Y	123.3	0.01	1.70	85.40	16	1823	519	96	0.12	0.0	4.857	0.020	0	0	0	403
PL.2095	PL.1589	ABC	336 MCM AC	7.40Y	123.3	0.03	1.73	85.40	16	1823	518	96	0.31	0.0	4.908	0.051	0	0	0	403
PL.2468	PL.2095	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.33	0	2	1	89	0.00	0.0	4.912	0.005	0	0	0	4
PD.305	PL.2468	C	40QA	7.40Y	123.3	0.00	1.73	0.33	1	2	1	89	0.00	0.0	4.912	0.005	0	0	0	4
PL.2469	PD.305	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.33	0	2	1	89	0.00	0.0	4.920	0.008	2	1	4	4
PL.2096	PL.2095	ABC	336 MCM AC	7.39Y	123.2	0.02	1.76	85.29	16	1821	517	96	0.23	0.0	4.945	0.037	0	0	0	399
PL.2360	PL.2096	C	#4 ACSR	7.39Y	123.2	0.00	1.76	1.42	1	10	3	96	0.00	0.0	4.949	0.005	0	0	0	1
PD.253	PL.2360	C	40QA	7.39Y	123.2	0.00	1.76	1.42	4	10	3	96	0.00	0.0	4.949	0.005	0	0	0	1
PL.2361	PD.253	C	#4 ACSR	7.39Y	123.2	0.00	1.76	1.42	1	10	3	96	0.00	0.0	4.978	0.029	0	0	0	1
PL.1849	PL.2361	C	#4 ACSR	7.39Y	123.2	0.00	1.76	1.42	1	10	3	96	0.00	0.0	5.008	0.030	10	3	1	1
PL.2187	PL.2096	ABC	336 MCM AC	7.39Y	123.2	0.02	1.77	84.82	16	1810	514	96	0.18	0.0	4.974	0.029	8	2	1	398
PL.2188	PL.2187	ABC	336 MCM AC	7.39Y	123.2	0.03	1.81	84.44	16	1802	511	96	0.30	0.0	5.024	0.050	0	0	0	397
PL.2094	PL.2188	ABC	336 MCM AC	7.39Y	123.2	0.02	1.82	39.25	8	838	236	96	0.07	0.0	5.081	0.057	0	0	0	182
PL.2362	PL.2094	C	#2 ACSR	7.39Y	123.2	0.00	1.82	1.11	1	8	2	97	0.00	0.0	5.086	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.254	PL.2362	C	40QA	7.39Y	123.2	0.00	1.82	1.11	3	8	2	97	0.00	0.0	5.086	0.005	0	0	0	1
PL.2363	PD.254	C	#2 ACSR	7.39Y	123.2	0.00	1.82	1.11	1	8	2	97	0.00	0.0	5.096	0.010	8	2	1	1
PL.2189	PL.2094	ABC	336 MCM AC	7.39Y	123.2	0.01	1.84	38.88	7	830	233	96	0.06	0.0	5.129	0.047	0	0	0	181
PL.2190	PL.2189	ABC	336 MCM AC	7.39Y	123.2	0.01	1.85	38.88	7	830	233	96	0.04	0.0	5.162	0.034	0	0	0	181
PL.2364	PL.2190	C	#4 ACSR	7.39Y	123.2	0.00	1.85	3.34	3	24	7	96	0.00	0.0	5.167	0.005	0	0	0	11
PD.255	PL.2364	C	40QA	7.39Y	123.2	0.00	1.85	3.34	8	24	7	96	0.00	0.0	5.167	0.005	0	0	0	11
PL.2365	PD.255	C	#4 ACSR	7.39Y	123.2	0.00	1.85	3.34	3	24	7	96	0.00	0.0	5.183	0.016	4	1	4	11
PL.1924	PL.2365	C	#4 ACSR	7.39Y	123.1	0.00	1.85	2.79	2	20	6	96	0.00	0.0	5.230	0.047	20	6	7	7
PL.2093	PL.2190	ABC	336 MCM AC	7.39Y	123.1	0.01	1.86	37.77	7	806	226	96	0.05	0.0	5.202	0.040	0	0	0	170
PL.2092	PL.2093	ABC	336 MCM AC	7.39Y	123.1	0.01	1.87	37.05	7	791	222	96	0.04	0.0	5.234	0.032	2	1	1	165
PL.1928	PL.2092	ABC	336 MCM AC	7.39Y	123.1	0.03	1.90	36.07	7	770	216	96	0.12	0.0	5.345	0.111	8	2	3	161
PL.2372	PL.1928	ABC	336 MCM AC	7.39Y	123.1	0.01	1.91	35.70	7	762	214	96	0.06	0.0	5.399	0.054	9	3	1	158
PL.2191	PL.2372	ABC	336 MCM AC	7.38Y	123.1	0.02	1.93	34.74	7	741	208	96	0.08	0.0	5.480	0.081	7	2	2	155
PL.2192	PL.2191	ABC	336 MCM AC	7.38Y	123.1	0.00	1.94	34.44	7	735	206	96	0.02	0.0	5.498	0.018	0	0	0	153
PL.2374	PL.2192	A	#4 ACSR	7.38Y	123.1	0.00	1.94	2.78	2	20	6	96	0.00	0.0	5.502	0.005	0	0	0	3
PD.259	PL.2374	A	40QA	7.38Y	123.1	0.00	1.94	2.78	7	20	6	96	0.00	0.0	5.502	0.005	0	0	0	3
PL.2375	PD.259	A	#4 ACSR	7.38Y	123.1	0.00	1.94	2.78	2	20	6	96	0.00	0.0	5.532	0.029	20	6	3	3
PL.2377	PL.2192	ABC	336 MCM AC	7.38Y	123.0	0.02	1.96	33.51	6	715	200	96	0.07	0.0	5.576	0.079	0	0	0	150
PL.2382	PL.2377	A	#4 ACSR	7.38Y	123.0	0.00	1.96	13.01	10	93	26	96	0.00	0.0	5.581	0.005	0	0	0	23
PD.262	PL.2382	A	40QA	7.38Y	123.0	0.00	1.96	13.01	33	93	26	96	0.00	0.0	5.581	0.005	0	0	0	23
PL.2383	PD.262	A	#4 ACSR	7.38Y	123.0	0.01	1.97	13.01	10	93	26	96	0.01	0.0	5.595	0.014	8	2	3	23
PL.1931	PL.2383	A	6 A (CWC)	7.38Y	123.0	0.00	1.97	1.43	1	10	3	96	0.00	0.0	5.616	0.020	2	1	1	3
PL.1932	PL.1931	A	#4 ACSR	7.38Y	123.0	0.00	1.97	1.13	1	8	2	97	0.00	0.0	5.644	0.029	7	2	1	2
PL.1933	PL.1932	A	#4 ACSR	7.38Y	123.0	0.00	1.97	0.10	0	1	0	100	0.00	0.0	5.664	0.020	1	0	1	1
PL.1930	PL.2383	A	#4 ACSR	7.38Y	123.0	0.01	1.98	10.52	8	75	21	96	0.01	0.0	5.627	0.032	13	4	1	17
PL.1938	PL.1930	A	#4 ACSR	7.38Y	123.0	0.01	1.99	8.64	7	61	17	96	0.01	0.0	5.659	0.032	0	0	0	16
PL.1939	PL.1938	A	#4 ACSR	7.38Y	123.0	0.02	2.01	8.55	7	61	17	96	0.01	0.0	5.713	0.054	0	0	0	15
PL.1941	PL.1939	A	#4 ACSR	7.38Y	123.0	0.02	2.03	8.55	7	61	17	96	0.01	0.0	5.766	0.053	13	4	3	15
PL.1942	PL.1941	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	2.76	2	20	5	97	0.00	0.0	5.792	0.026	9	3	1	5
PL.1945	PL.1942	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	1.47	1	10	3	96	0.00	0.0	5.843	0.051	10	3	4	4
PL.1943	PL.1941	A	#4 ACSR	7.38Y	123.0	0.01	2.04	2.75	2	20	5	97	0.00	0.0	5.829	0.063	6	2	5	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1946	PL.1943	A	#4 ACSR	7.38Y	123.0	0.00	2.04	1.88	1	13	4	96	0.00	0.0	5.876	0.047	13	4	1	1
PL.1944	PL.1941	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	1.21	1	9	2	98	0.00	0.0	5.805	0.039	9	2	1	1
PL.1940	PL.1938	A	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.09	0	1	0	100	0.00	0.0	5.712	0.053	1	0	1	1
PL.2087	PL.2377	ABC	336 MCM AC	7.38Y	123.0	0.01	1.96	29.18	6	622	174	96	0.03	0.0	5.620	0.044	2	1	1	127
PL.2085	PL.2087	ABC	336 MCM AC	7.38Y	123.0	0.01	1.98	25.02	5	534	149	96	0.03	0.0	5.678	0.057	0	0	0	110
PL.2197	PL.2085	ABC	336 MCM AC	7.38Y	123.0	0.02	2.00	22.40	4	478	134	96	0.06	0.0	5.809	0.131	2	1	1	103
PL.2198	PL.2197	ABC	336 MCM AC	7.38Y	123.0	0.00	2.00	22.29	4	475	133	96	0.01	0.0	5.830	0.021	0	0	0	102
PL.2388	PL.2198	A	#2 ACSR	7.38Y	123.0	0.00	2.00	4.21	2	30	8	97	0.00	0.0	5.835	0.004	0	0	0	8
PD.265	PL.2388	A	15T	7.38Y	123.0	0.00	2.00	4.21	0	30	8	97	0.00	0.0	5.835	0.004	0	0	0	8
PL.2389	PD.265	A	#2 ACSR	7.38Y	123.0	0.00	2.00	4.21	2	30	8	97	0.00	0.0	5.844	0.009	4	1	3	8
PL.1954	PL.2389	A	#2 ACSR	7.38Y	123.0	0.00	2.00	3.71	2	26	7	97	0.00	0.0	5.863	0.019	0	0	0	5
PL.1955	PL.1954	A	#2 ACSR	7.38Y	123.0	0.01	2.01	3.71	2	26	7	97	0.00	0.0	5.918	0.054	2	1	2	5
PL.1956	PL.1955	A	#2 ACSR	7.38Y	123.0	0.00	2.02	3.38	2	24	7	96	0.00	0.0	5.965	0.047	0	0	0	3
PL.1957	PL.1956	A	#2 ACSR	7.38Y	123.0	0.00	2.02	3.38	2	24	7	96	0.00	0.0	6.034	0.070	17	5	2	3
PL.1958	PL.1957	A	#1/0 ACSR	7.38Y	123.0	0.00	2.02	1.02	0	7	2	96	0.00	0.0	6.123	0.089	0	0	0	1
PL.1959	PL.1958	A	#1/0 ACSR	7.38Y	123.0	0.00	2.02	1.02	0	7	2	96	0.00	0.0	6.156	0.033	7	2	1	1
PL.1953	PL.2198	ABC	336 MCM AC	7.38Y	123.0	0.01	2.01	20.89	4	445	125	96	0.01	0.0	5.862	0.032	0	0	0	94
PL.1962	PL.1953	C	#4 ACSR	7.38Y	123.0	0.00	2.01	1.08	1	8	2	97	0.00	0.0	5.887	0.025	8	2	1	1
PL.2570	PL.1953	ABC	336 MCM AC	7.38Y	123.0	0.01	2.01	20.53	4	438	122	96	0.02	0.0	5.915	0.052	0	0	0	93
PL.2571	PL.2570	ABC	336 MCM AC	7.38Y	123.0	0.01	2.02	20.53	4	438	122	96	0.01	0.0	5.949	0.035	6	2	1	93
PL.2202	PL.2571	ABC	336 MCM AC	7.38Y	123.0	0.00	2.02	20.24	4	431	121	96	0.00	0.0	5.960	0.011	13	4	4	92
PL.10163	PL.2202	C	#4 ACSR	7.38Y	123.0	0.00	2.02	0.00	0	0	0	100	0.00	0.0	5.962	0.002	0	0	0	0
PL.2203	PL.2202	ABC	336 MCM AC	7.38Y	123.0	0.01	2.03	19.62	4	418	117	96	0.02	0.0	6.010	0.050	0	0	1	88
PL.2392	PL.2203	ABC	336 MCM AC	7.38Y	123.0	0.01	2.04	19.62	4	418	117	96	0.02	0.0	6.071	0.061	0	0	0	87
PL.2393	PL.2392	ABC	336 MCM AC	7.38Y	123.0	0.00	2.04	19.62	4	418	117	96	0.00	0.0	6.076	0.004	0	0	0	87
PL.2390	PL.2393	C	#4 ACSR	7.38Y	123.0	0.00	2.04	2.17	2	15	4	97	0.00	0.0	6.080	0.005	0	0	0	2
PD.266	PL.2390	C	20T	7.38Y	123.0	0.00	2.04	2.17	0	15	4	97	0.00	0.0	6.080	0.005	0	0	0	2
PL.2391	PD.266	C	#4 ACSR	7.38Y	123.0	0.00	2.04	2.17	2	15	4	97	0.00	0.0	6.122	0.042	15	4	2	2
PL.2530	PL.2393	A	#4 ACSR	7.38Y	123.0	0.00	2.04	3.30	3	23	7	96	0.00	0.0	6.080	0.005	0	0	0	3
PD.336	PL.2530	A	20QA	7.38Y	123.0	0.00	2.04	3.30	16	23	7	96	0.00	0.0	6.080	0.005	0	0	0	3
PL.2531	PD.336	A	#4 ACSR	7.38Y	123.0	0.00	2.04	3.30	3	23	7	96	0.00	0.0	6.095	0.015	8	2	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2204	PL.2531	A	#2 ACSR	7.38Y	123.0	0.00	2.04	2.23	1	16	4	97	0.00	0.0	6.112	0.016	8	2	1	2
PL.2205	PL.2204	A	#2 ACSR	7.38Y	123.0	0.00	2.04	1.10	1	8	2	97	0.00	0.0	6.146	0.034	8	2	1	1
PL.2083	PL.2393	ABC	336 MCM AC	7.38Y	123.0	0.01	2.04	17.80	3	379	106	96	0.01	0.0	6.117	0.042	8	2	2	82
PL.2532	PL.2083	C	#4 ACSR	7.38Y	123.0	0.00	2.04	2.10	2	15	4	97	0.00	0.0	6.122	0.005	0	0	0	3
PD.337	PL.2532	C	20QA	7.38Y	123.0	0.00	2.04	2.10	11	15	4	97	0.00	0.0	6.122	0.005	0	0	0	3
PL.2533	PD.337	C	#4 ACSR	7.38Y	123.0	0.00	2.05	2.10	2	15	4	97	0.00	0.0	6.157	0.034	15	4	3	3
PL.2084	PL.2083	ABC	336 MCM AC	7.38Y	123.0	0.01	2.05	16.73	3	357	100	96	0.01	0.0	6.158	0.041	5	1	2	77
PL.2082	PL.2084	ABC	336 MCM AC	7.38Y	122.9	0.01	2.05	16.48	3	351	98	96	0.01	0.0	6.208	0.049	10	3	2	73
PL.1965	PL.2082	B	#4 ACSR	7.37Y	122.9	0.04	2.10	19.15	15	136	38	96	0.04	0.0	6.258	0.050	0	0	0	25
PL.2206	PL.1965	B	#4 ACSR	7.37Y	122.9	0.00	2.10	5.57	4	40	11	96	0.00	0.0	6.286	0.028	30	8	5	6
PL.2207	PL.2206	B	#4 ACSR	7.37Y	122.9	0.00	2.10	1.41	1	10	3	96	0.00	0.0	6.307	0.021	10	3	1	1
PL.1966	PL.1965	B	#4 ACSR	7.37Y	122.9	0.02	2.12	13.59	10	96	27	96	0.02	0.0	6.296	0.038	0	0	1	19
PL.2560	PL.1966	B	6 A (CWC)	7.37Y	122.9	0.00	2.12	13.59	10	96	27	96	0.00	0.0	6.299	0.003	0	0	0	18
PD.353	PL.2560	B	35H	7.37Y	122.9	0.00	2.12	13.59	39	96	27	96	0.00	0.0	6.299	0.003	0	0	0	18
PL.2561	PD.353	B	6 A (CWC)	7.37Y	122.8	0.04	2.16	13.59	10	96	27	96	0.03	0.0	6.363	0.064	12	3	2	18
PL.2208	PL.2561	B	6 A (CWC)	7.37Y	122.8	0.03	2.19	11.87	8	84	24	96	0.02	0.0	6.430	0.066	12	3	2	16
PL.2081	PL.2208	B	6 A (CWC)	7.37Y	122.8	0.04	2.23	10.23	7	73	20	96	0.02	0.0	6.516	0.086	2	0	1	14
PL.1967	PL.2081	B	#4 ACSR	7.37Y	122.8	0.00	2.23	0.43	0	3	1	95	0.00	0.0	6.594	0.079	3	1	1	1
PL.2209	PL.2081	B	6 A (CWC)	7.36Y	122.7	0.03	2.26	9.56	7	68	19	96	0.02	0.0	6.595	0.079	10	3	2	12
PL.2210	PL.2209	B	6 A (CWC)	7.36Y	122.7	0.03	2.29	8.14	6	58	16	96	0.01	0.0	6.668	0.073	2	0	1	10
PL.2211	PL.2210	B	6 A (CWC)	7.36Y	122.7	0.02	2.32	7.90	6	56	16	96	0.01	0.0	6.739	0.071	10	3	1	9
PL.1968	PL.2211	B	6 A (CWC)	7.36Y	122.7	0.00	2.32	1.74	1	12	3	97	0.00	0.0	6.777	0.039	12	3	2	2
PL.2078	PL.2211	B	6 A (CWC)	7.36Y	122.6	0.04	2.36	4.78	3	34	9	97	0.01	0.0	6.965	0.227	9	3	1	6
PL.2215	PL.2078	B	6 A (CWC)	7.36Y	122.6	0.03	2.39	3.49	2	25	7	96	0.01	0.0	7.143	0.178	0	0	0	5
PL.2216	PL.2215	B	6 A (CWC)	7.35Y	122.6	0.03	2.42	3.49	2	25	7	96	0.01	0.0	7.340	0.197	0	0	0	5
PL.1969	PL.2216	B	6 A (CWC)	7.35Y	122.6	0.01	2.42	2.47	2	18	5	96	0.00	0.0	7.397	0.057	7	2	1	3
PL.1971	PL.1969	B	#4 ACSR	7.35Y	122.6	0.00	2.42	1.50	1	11	3	96	0.00	0.0	7.420	0.023	11	3	2	2
PL.1970	PL.2216	B	6 A (CWC)	7.35Y	122.6	0.00	2.42	1.01	1	7	2	96	0.00	0.0	7.377	0.036	7	2	2	2
PL.1964	PL.2082	ABC	336 MCM AC	7.38Y	122.9	0.01	2.06	9.63	2	205	57	96	0.01	0.0	6.292	0.084	13	4	2	46
PL.2080	PL.1964	ABC	336 MCM AC	7.38Y	122.9	0.01	2.07	9.01	2	192	54	96	0.01	0.0	6.374	0.082	0	0	0	44
PL.2534	PL.2080	C	#4 ACSR	7.38Y	122.9	0.00	2.07	0.96	1	7	2	96	0.00	0.0	6.379	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.338	PL.2534	C	40QA	7.38Y	122.9	0.00	2.07	0.96	2	7	2	96	0.00	0.0	6.379	0.005	0	0	0	1
PL.2535	PD.338	C	#4 ACSR	7.38Y	122.9	0.00	2.07	0.96	1	7	2	96	0.00	0.0	6.384	0.005	7	2	1	1
PL.2077	PL.2080	ABC	336 MCM AC	7.38Y	122.9	0.00	2.07	8.42	2	179	50	96	0.00	0.0	6.431	0.057	0	0	0	41
PL.2076	PL.2077	ABC	336 MCM AC	7.38Y	122.9	0.00	2.07	7.70	1	164	46	96	0.00	0.0	6.477	0.047	2	1	1	39
PL.2075	PL.2076	ABC	336 MCM AC	7.38Y	122.9	0.00	2.08	6.70	1	143	40	96	0.00	0.0	6.568	0.091	12	3	3	32
PL.2470	PL.2075	A	#4 ACSR	7.38Y	122.9	0.00	2.08	3.35	3	24	7	96	0.00	0.0	6.573	0.005	0	0	0	5
PD.306	PL.2470	A	20QA	7.38Y	122.9	0.00	2.08	3.35	17	24	7	96	0.00	0.0	6.573	0.005	0	0	0	5
PL.2471	PD.306	A	#4 ACSR	7.38Y	122.9	0.00	2.08	3.35	3	24	7	96	0.00	0.0	6.597	0.024	24	7	5	5
PL.2212	PL.2075	ABC	336 MCM AC	7.38Y	122.9	0.00	2.08	5.01	1	107	30	96	0.00	0.0	6.626	0.058	0	0	0	24
PL.2213	PL.2212	ABC	336 MCM AC	7.38Y	122.9	0.00	2.08	5.01	1	107	30	96	0.00	0.0	6.676	0.050	14	4	4	24
PL.2548	PL.2213	ABC	336 MCM AC	7.38Y	122.9	0.00	2.08	4.36	1	93	26	96	0.00	0.0	6.703	0.027	0	0	0	20
PD.345-A	PL.2548	ABC	Closed	7.38Y	122.9	0.00	2.08	4.36	0	93	26	96	0.00	0.0	6.703	0.027	0	0	0	20
PD.345-B	PD.345-A	ABC	Closed	7.38Y	122.9	0.00	2.08	4.36	0	93	26	96	0.00	0.0	6.703	0.027	0	0	0	20
PL.4873	PD.345-B	ABC	336 MCM AC	7.37Y	122.9	0.01	2.09	4.36	1	93	26	96	0.00	0.0	7.014	0.310	0	0	0	20
PL.4874	PL.4873	ABC	336 MCM AC	7.37Y	122.9	0.01	2.10	4.36	1	93	26	96	0.01	0.0	7.373	0.359	0	0	0	20
PL.4872	PL.4874	ABC	336 MCM AC	7.37Y	122.9	0.01	2.12	4.36	1	93	26	96	0.01	0.0	7.778	0.404	0	0	0	20
PD.346-A	PL.4872	ABC	Closed	7.37Y	122.9	0.00	2.12	4.36	0	93	26	96	0.00	0.0	7.778	0.404	0	0	0	20
PD.346-B	PD.346-A	ABC	Closed	7.37Y	122.9	0.00	2.12	4.36	0	93	26	96	0.00	0.0	7.778	0.404	0	0	0	20
PL.2551	PD.346-B	ABC	336 MCM AC	7.37Y	122.9	0.00	2.12	4.36	1	93	26	96	0.00	0.0	7.896	0.119	0	0	0	20
PL.1974	PL.2551	C	#2 ACSR	7.37Y	122.9	0.00	2.12	0.68	0	5	1	98	0.00	0.0	7.915	0.019	5	1	1	1
PL.2068	PL.2551	ABC	336 MCM AC	7.37Y	122.9	0.00	2.12	4.13	1	88	25	96	0.00	0.0	7.947	0.050	6	2	2	19
PL.2400	PL.2068	C	#4 ACSR	7.37Y	122.9	0.00	2.12	2.41	2	17	5	96	0.00	0.0	7.951	0.005	0	0	0	2
PD.270	PL.2400	C	20QA	7.37Y	122.9	0.00	2.12	2.41	12	17	5	96	0.00	0.0	7.951	0.005	0	0	0	2
PL.2401	PD.270	C	#4 ACSR	7.37Y	122.9	0.00	2.13	2.41	2	17	5	96	0.00	0.0	8.015	0.064	17	5	2	2
PL.2066	PL.2068	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	3.05	1	65	18	96	0.00	0.0	8.154	0.208	4	1	1	15
PL.2217	PL.2066	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	2.85	1	61	17	96	0.00	0.0	8.200	0.046	3	1	1	14
PL.2218	PL.2217	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	2.73	1	58	16	96	0.00	0.0	8.230	0.031	0	0	0	13
PL.2402	PL.2218	C	#4 ACSR	7.37Y	122.9	0.00	2.13	0.90	1	6	2	95	0.00	0.0	8.235	0.005	0	0	0	4
PD.271	PL.2402	C	20QA	7.37Y	122.9	0.00	2.13	0.90	5	6	2	95	0.00	0.0	8.235	0.005	0	0	0	4
PL.2403	PD.271	C	#4 ACSR	7.37Y	122.9	0.00	2.13	0.90	1	6	2	95	0.00	0.0	8.314	0.079	6	2	4	4
PL.2062	PL.2218	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	2.43	0	52	14	97	0.00	0.0	8.283	0.052	0	0	0	9

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2404	PL.2062	A	#4 ACSR	7.37Y	122.9	0.00	2.13	1.75	1	12	3	97	0.00	0.0	8.288	0.005	0	0	0	4
PD.272	PL.2404	A	20QA	7.37Y	122.9	0.00	2.13	1.75	9	12	3	97	0.00	0.0	8.288	0.005	0	0	0	4
PL.2405	PD.272	A	#4 ACSR	7.37Y	122.9	0.00	2.13	1.75	1	12	3	97	0.00	0.0	8.302	0.014	4	1	1	4
PL.2219	PL.2405	A	#4 ACSR	7.37Y	122.9	0.00	2.13	1.21	1	9	2	98	0.00	0.0	8.325	0.023	9	2	3	3
PL.2061	PL.2062	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	1.85	0	39	11	96	0.00	0.0	8.365	0.082	0	0	0	5
PL.2060	PL.2061	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.41	0	9	2	98	0.00	0.0	8.519	0.155	0	0	0	1
PL.2059	PL.2060	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	9.062	0.543	0	0	0	0
PL.4865	PL.2059	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	9.449	0.387	0	0	0	0
PL.4867	PL.4865	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	9.999	0.551	0	0	0	0
PL.4866	PL.4867	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.393	0.394	0	0	0	0
PL.7126	PL.4866	ABC	336 MCM AC	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.396	0.003	0	0	0	0
PD.1506-B	PL.7126	ABC	Open	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.396	0.003	0	0	0	0
PL.1980	PL.4866	ABC	#2 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.410	0.017	0	0	0	0
PL.64959	PL.1980	ABC	#2 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.410	0.000	0	0	0	0
PD.9573-A	PL.64959	ABC	Open	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	10.410	0.000	0	0	0	0
PL.4868	PL.2060	A	#2 ACSR	7.37Y	122.9	0.00	2.13	1.23	1	9	2	98	0.00	0.0	8.523	0.003	0	0	0	1
PD.898	PL.4868	A	20QA	7.37Y	122.9	0.00	2.13	1.23	6	9	2	98	0.00	0.0	8.523	0.003	0	0	0	1
PL.4869	PD.898	A	#2 ACSR	7.37Y	122.9	0.00	2.13	1.23	1	9	2	98	0.00	0.0	8.548	0.025	9	2	1	1
PL.4870	PL.2061	A	#4 ACSR	7.37Y	122.9	0.00	2.13	4.31	3	31	9	96	0.00	0.0	8.368	0.003	0	0	0	4
PD.899	PL.4870	A	20QA	7.37Y	122.9	0.00	2.13	4.31	22	31	9	96	0.00	0.0	8.368	0.003	0	0	0	4
PL.4871	PD.899	A	#4 ACSR	7.37Y	122.9	0.00	2.13	4.31	3	31	9	96	0.00	0.0	8.400	0.032	31	9	4	4
PL.1975	PL.4871	A	#4 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	8.407	0.006	0	0	0	0
PL.2472	PL.2066	A	#4 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	8.159	0.005	0	0	0	0
PD.307	PL.2472	A	20QA	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	8.159	0.005	0	0	0	0
PL.2473	PD.307	A	#4 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	8.213	0.054	0	0	0	0
PL.2398	PL.2076	A	#4 ACSR	7.38Y	122.9	0.00	2.07	2.74	2	19	5	97	0.00	0.0	6.482	0.005	0	0	0	6
PD.269	PL.2398	A	20QA	7.38Y	122.9	0.00	2.07	2.74	14	19	5	97	0.00	0.0	6.482	0.005	0	0	0	6
PL.2399	PD.269	A	#4 ACSR	7.38Y	122.9	0.00	2.08	2.74	2	19	5	97	0.00	0.0	6.538	0.056	19	5	6	6
PL.2540	PL.2077	C	#2 ACSR	7.38Y	122.9	0.00	2.07	2.14	1	15	4	97	0.00	0.0	6.435	0.005	0	0	0	2
PD.340	PL.2540	C	20QA	7.38Y	122.9	0.00	2.07	2.14	11	15	4	97	0.00	0.0	6.435	0.005	0	0	0	2
PL.2541	PD.340	C	#2 ACSR	7.38Y	122.9	0.00	2.07	2.14	1	15	4	97	0.00	0.0	6.461	0.026	5	2	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1972	PL.2541	C	#2 ACSR	7.38Y	122.9	0.00	2.07	1.37	1	10	3	96	0.00	0.0	6.477	0.015	10	3	1	1
PL.2396	PL.2077	A	#2 ACSR	7.38Y	122.9	0.00	2.07	0.00	0	0	0	100	0.00	0.0	6.435	0.005	0	0	0	0
PD.268	PL.2396	A	20QA	7.38Y	122.9	0.00	2.07	0.00	0	0	0	100	0.00	0.0	6.435	0.005	0	0	0	0
PL.2397	PD.268	A	#2 ACSR	7.38Y	122.9	0.00	2.07	0.00	0	0	0	100	0.00	0.0	6.454	0.019	0	0	0	0
PL.2538	PL.2080	A	#4 ACSR	7.38Y	122.9	0.00	2.07	0.82	1	6	2	95	0.00	0.0	6.379	0.005	0	0	0	2
PD.339	PL.2538	A	40QA	7.38Y	122.9	0.00	2.07	0.82	2	6	2	95	0.00	0.0	6.379	0.005	0	0	0	2
PL.2539	PD.339	A	#4 ACSR	7.38Y	122.9	0.00	2.07	0.82	1	6	2	95	0.00	0.0	6.394	0.015	6	2	2	2
PL.2394	PL.2084	A	#4 ACSR	7.38Y	123.0	0.00	2.05	0.09	0	1	0	100	0.00	0.0	6.163	0.005	0	0	0	2
PD.267	PL.2394	A	20QA	7.38Y	123.0	0.00	2.05	0.09	0	1	0	100	0.00	0.0	6.163	0.005	0	0	0	2
PL.2395	PD.267	A	#4 ACSR	7.38Y	123.0	0.00	2.05	0.09	0	1	0	100	0.00	0.0	6.198	0.035	1	0	2	2
CP.5	PL.2570	ABC	Cap (300)	7.38Y	123.0	0.00	2.01	0.00	0	0	0	100	0.00	0.0	5.915	0.035	0	0	0	0
PL.1947	PL.2085	B	#2 ACSR	7.38Y	123.0	0.01	1.98	7.85	4	56	16	96	0.00	0.0	5.704	0.026	0	0	0	7
PL.2386	PL.1947	B	#2 ACSR	7.38Y	123.0	0.00	1.98	7.85	4	56	16	96	0.00	0.0	5.709	0.005	0	0	0	7
PD.264	PL.2386	B	15T	7.38Y	123.0	0.00	1.98	7.85	0	56	16	96	0.00	0.0	5.709	0.005	0	0	0	7
PL.2387	PD.264	B	#2 ACSR	7.38Y	123.0	0.01	2.00	7.85	4	56	16	96	0.00	0.0	5.758	0.049	0	0	0	7
PL.1948	PL.2387	B	#2 ACSR	7.38Y	123.0	0.01	2.01	7.85	4	56	16	96	0.00	0.0	5.804	0.047	0	0	0	7
PL.1949	PL.1948	B	#4 ACSR	7.38Y	123.0	0.01	2.02	7.85	6	56	16	96	0.01	0.0	5.847	0.042	12	3	2	7
PL.1950	PL.1949	B	#4 ACSR	7.38Y	123.0	0.01	2.04	6.21	5	44	12	96	0.00	0.0	5.904	0.057	5	1	1	5
PL.1951	PL.1950	B	#4 ACSR	7.38Y	123.0	0.00	2.04	5.55	4	39	11	96	0.00	0.0	5.932	0.028	31	9	3	4
PL.1952	PL.1951	B	#2 ACSR	7.38Y	123.0	0.00	2.04	1.16	1	8	2	97	0.00	0.0	5.973	0.041	8	2	1	1
PL.2528	PL.2087	A	#4 ACSR	7.38Y	123.0	0.00	1.97	11.90	9	85	24	96	0.00	0.0	5.625	0.005	0	0	0	15
PD.335	PL.2528	A	30T	7.38Y	123.0	0.00	1.97	11.90	0	85	24	96	0.00	0.0	5.625	0.005	0	0	0	15
PL.2529	PD.335	A	#4 ACSR	7.38Y	123.0	0.02	1.99	11.90	9	85	24	96	0.01	0.0	5.659	0.034	0	0	0	15
PL.1934	PL.2529	A	#4 ACSR	7.38Y	123.0	0.03	2.02	11.41	9	81	23	96	0.02	0.0	5.726	0.066	0	0	0	12
PL.1937	PL.1934	A	#4 ACSR	7.38Y	123.0	0.00	2.02	0.36	0	3	1	95	0.00	0.0	5.765	0.039	3	1	1	1
PL.1935	PL.1934	A	#4 ACSR	7.38Y	123.0	0.03	2.05	9.78	8	70	19	97	0.01	0.0	5.796	0.071	11	3	1	9
PL.2199	PL.1935	A	#4 ACSR	7.38Y	122.9	0.01	2.06	8.17	6	58	16	96	0.00	0.0	5.827	0.030	14	4	2	8
PL.2200	PL.2199	A	#4 ACSR	7.38Y	122.9	0.01	2.06	6.15	5	44	12	96	0.00	0.0	5.855	0.029	8	2	1	6
PL.2201	PL.2200	A	#4 ACSR	7.38Y	122.9	0.00	2.07	5.03	4	36	10	96	0.00	0.0	5.883	0.028	26	7	3	5
PL.1961	PL.2201	A	#4 ACSR	7.38Y	122.9	0.00	2.07	1.43	1	10	3	96	0.00	0.0	5.931	0.048	0	0	0	2
PL.1963	PL.1961	A	#4 ACSR	7.38Y	122.9	0.00	2.07	0.00	0	0	0	100	0.00	0.0	5.954	0.023	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2195	PL.1961	A	#4 ACSR	7.38Y	122.9	0.00	2.07	1.43	1	10	3	96	0.00	0.0	5.958	0.027	4	1	1	2
PL.2196	PL.2195	A	#4 ACSR	7.38Y	122.9	0.00	2.07	0.86	1	6	2	95	0.00	0.0	5.975	0.016	6	2	1	1
PL.10162	PL.2201	A	#4 ACSR	7.38Y	122.9	0.00	2.07	0.00	0	0	0	100	0.00	0.0	5.931	0.048	0	0	0	0
PL.1936	PL.1934	A	#4 ACSR	7.38Y	123.0	0.00	2.02	1.26	1	9	2	98	0.00	0.0	5.795	0.069	9	2	2	2
PL.2193	PL.2529	A	#4 ACSR	7.38Y	123.0	0.00	1.99	0.50	0	4	1	97	0.00	0.0	5.686	0.026	3	1	1	3
PL.2194	PL.2193	A	#4 ACSR	7.38Y	123.0	0.00	1.99	0.13	0	1	0	100	0.00	0.0	5.716	0.030	1	0	2	2
PL.2384	PL.2087	A	#4 ACSR	7.38Y	123.0	0.00	1.96	0.26	0	2	1	89	0.00	0.0	5.625	0.005	0	0	0	1
PD.263	PL.2384	A	40QA	7.38Y	123.0	0.00	1.96	0.26	1	2	1	89	0.00	0.0	5.625	0.005	0	0	0	1
PL.2385	PD.263	A	#4 ACSR	7.38Y	123.0	0.00	1.97	0.26	0	2	1	89	0.00	0.0	5.658	0.033	0	0	0	1
PL.1929	PL.2385	A	#4 ACSR	7.38Y	123.0	0.00	1.97	0.26	0	2	1	89	0.00	0.0	5.691	0.033	2	1	1	1
PL.2370	PL.2372	C	#4 ACSR	7.39Y	123.1	0.00	1.91	1.57	1	11	3	96	0.00	0.0	5.403	0.005	0	0	0	2
PD.258	PL.2370	C	40QA	7.39Y	123.1	0.00	1.91	1.57	4	11	3	96	0.00	0.0	5.403	0.005	0	0	0	2
PL.2371	PD.258	C	#4 ACSR	7.39Y	123.1	0.00	1.91	1.57	1	11	3	96	0.00	0.0	5.414	0.011	11	3	2	2
PL.2358	PL.2092	C	#4 ACSR	7.39Y	123.1	0.00	1.87	2.67	2	19	5	97	0.00	0.0	5.239	0.005	0	0	0	3
PD.252	PL.2358	C	40QA	7.39Y	123.1	0.00	1.87	2.67	7	19	5	97	0.00	0.0	5.239	0.005	0	0	0	3
PL.2359	PD.252	C	#4 ACSR	7.39Y	123.1	0.00	1.87	2.67	2	19	5	97	0.00	0.0	5.265	0.026	19	5	3	3
PL.2366	PL.2093	A	#4 ACSR	7.39Y	123.1	0.00	1.86	2.15	2	15	4	97	0.00	0.0	5.207	0.005	0	0	0	5
PD.256	PL.2366	A	40QA	7.39Y	123.1	0.00	1.86	2.15	5	15	4	97	0.00	0.0	5.207	0.005	0	0	0	5
PL.2367	PD.256	A	#4 ACSR	7.39Y	123.1	0.00	1.86	2.15	2	15	4	97	0.00	0.0	5.233	0.027	9	2	4	5
PL.1925	PL.2367	A	#2 ACSR	7.39Y	123.1	0.00	1.86	0.93	1	7	2	96	0.00	0.0	5.245	0.012	0	0	0	1
PL.1926	PL.1925	A	#2 ACSR	7.39Y	123.1	0.00	1.86	0.93	1	7	2	96	0.00	0.0	5.258	0.012	0	0	0	1
PL.1927	PL.1926	A	#2 ACSR	7.39Y	123.1	0.00	1.86	0.93	1	7	2	96	0.00	0.0	5.301	0.043	7	2	1	1
PL.1850	PL.2188	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.84	45.19	20	964	275	96	0.22	0.0	5.067	0.043	43	12	10	215
PL.1851	PL.1850	ABC	#1/0 ACSR	7.39Y	123.1	0.04	1.88	43.17	19	920	262	96	0.23	0.0	5.113	0.046	11	3	3	205
PL.1854	PL.1851	ABC	#1/0 ACSR	7.38Y	123.1	0.04	1.92	42.68	19	910	259	96	0.28	0.0	5.170	0.057	0	0	0	202
PL.1855	PL.1854	ABC	8 A (CWC)	7.38Y	123.1	0.03	1.95	24.14	24	514	148	96	0.12	0.0	5.190	0.020	0	0	0	99
PL.1857	PL.1855	ABC	8 A (CWC)	7.38Y	123.0	0.08	2.03	24.14	24	514	148	96	0.33	0.1	5.245	0.055	6	2	1	99
PL.1861	PL.1857	ABC	8 A (CWC)	7.38Y	122.9	0.05	2.08	23.85	24	507	146	96	0.22	0.0	5.283	0.038	13	4	1	98
PL.2356	PL.1861	C	#2 ACSR	7.37Y	122.9	0.00	2.08	5.52	3	39	11	96	0.00	0.0	5.288	0.004	0	0	0	7
PD.251	PL.2356	C	40QA	7.37Y	122.9	0.00	2.08	5.52	14	39	11	96	0.00	0.0	5.288	0.004	0	0	0	7
PL.2357	PD.251	C	#2 ACSR	7.37Y	122.9	0.00	2.09	5.52	3	39	11	96	0.00	0.0	5.312	0.024	5	1	1	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2186	PL.2357	C	#2 ACSR	7.37Y	122.9	0.01	2.10	4.80	3	34	10	96	0.00	0.0	5.365	0.053	0	0	0	6
PL.4512	PL.2186	C	#4 ACSR	7.37Y	122.9	0.00	2.10	2.17	2	15	4	97	0.00	0.0	5.380	0.015	6	2	1	2
PL.4513	PL.4512	C	#4 ACSR	7.37Y	122.9	0.00	2.10	1.32	1	9	3	95	0.00	0.0	5.403	0.022	9	3	1	1
PL.2090	PL.2186	C	#2 ACSR	7.37Y	122.9	0.00	2.10	2.64	2	19	5	97	0.00	0.0	5.401	0.035	0	0	0	4
PL.1864	PL.2090	C	#4 ACSR	7.37Y	122.9	0.00	2.10	2.64	2	19	5	97	0.00	0.0	5.448	0.047	19	5	4	4
PL.1862	PL.1861	ABC	#2 ACSR	7.37Y	122.9	0.04	2.12	21.40	12	455	132	96	0.13	0.0	5.352	0.069	5	1	2	90
PL.1889	PL.1862	ABC	#2 ACSR	7.37Y	122.8	0.03	2.15	21.17	12	450	130	96	0.11	0.0	5.413	0.061	24	12	1	88
PL.1890	PL.1889	ABC	#2 ACSR	7.37Y	122.8	0.02	2.17	19.99	11	426	119	96	0.07	0.0	5.458	0.045	1	0	2	87
PL.1892	PL.1890	A	#2 ACSR	7.37Y	122.8	0.00	2.17	3.58	2	25	7	96	0.00	0.0	5.463	0.005	0	0	0	5
PD.333	PL.1892	A	40QA	7.37Y	122.8	0.00	2.17	3.58	9	25	7	96	0.00	0.0	5.463	0.005	0	0	0	5
PL.2006	PD.333	A	#2 ACSR	7.37Y	122.8	0.00	2.18	3.58	2	25	7	96	0.00	0.0	5.514	0.051	7	2	3	5
PL.1893	PL.2006	A	#4 ACSR	7.37Y	122.8	0.00	2.18	2.59	2	18	5	96	0.00	0.0	5.563	0.050	8	2	1	2
PL.1894	PL.1893	A	#4 ACSR	7.37Y	122.8	0.00	2.19	1.51	1	11	3	96	0.00	0.0	5.630	0.067	11	3	1	1
PL.2368	PL.1890	C	6 A (CWC)	7.37Y	122.8	0.00	2.18	12.57	9	89	25	96	0.00	0.0	5.463	0.005	0	0	0	16
PD.257	PL.2368	C	40QA	7.37Y	122.8	0.00	2.18	12.57	31	89	25	96	0.00	0.0	5.463	0.005	0	0	0	16
PL.2369	PD.257	C	6 A (CWC)	7.37Y	122.8	0.02	2.20	12.57	9	89	25	96	0.02	0.0	5.506	0.043	5	1	1	16
PL.1895	PL.2369	C	6 A (CWC)	7.37Y	122.8	0.05	2.25	11.91	9	84	24	96	0.03	0.0	5.589	0.083	0	0	0	15
PL.1896	PL.1895	C	#4 ACSR	7.36Y	122.7	0.01	2.26	7.20	6	51	14	96	0.00	0.0	5.623	0.034	7	2	1	9
PL.1902	PL.1896	C	#4 ACSR	7.36Y	122.7	0.01	2.27	6.26	5	44	12	96	0.00	0.0	5.662	0.039	8	2	2	8
PL.1903	PL.1902	C	#2 ACSR	7.36Y	122.7	0.00	2.27	1.14	1	8	2	97	0.00	0.0	5.736	0.074	8	2	2	2
PL.1904	PL.1902	C	#4 ACSR	7.36Y	122.7	0.01	2.27	3.95	3	28	8	96	0.00	0.0	5.704	0.041	8	2	1	4
PL.1905	PL.1904	C	#2 ACSR	7.36Y	122.7	0.00	2.28	2.19	1	16	4	97	0.00	0.0	5.768	0.065	8	2	1	2
PL.1907	PL.1905	C	#2 ACSR	7.36Y	122.7	0.00	2.28	1.02	1	7	2	96	0.00	0.0	5.829	0.061	7	2	1	1
PL.1906	PL.1904	C	#2 ACSR	7.36Y	122.7	0.00	2.27	0.65	0	5	1	98	0.00	0.0	5.810	0.107	5	1	1	1
PL.1897	PL.1895	C	#2 ACSR	7.36Y	122.7	0.00	2.25	4.71	3	33	9	96	0.00	0.0	5.622	0.033	12	3	2	6
PL.1898	PL.1897	C	#2 ACSR	7.36Y	122.7	0.00	2.25	3.04	2	22	6	96	0.00	0.0	5.647	0.025	0	0	1	4
PL.1899	PL.1898	C	#2 ACSR	7.36Y	122.7	0.01	2.26	3.04	2	22	6	96	0.00	0.0	5.742	0.096	0	0	0	3
PL.1901	PL.1899	C	#2 ACSR	7.36Y	122.7	0.00	2.26	1.42	1	10	3	96	0.00	0.0	5.765	0.023	10	3	1	1
PL.1900	PL.1899	C	#2 ACSR	7.36Y	122.7	0.00	2.26	1.62	1	11	3	96	0.00	0.0	5.779	0.037	11	3	2	2
PL.1891	PL.1890	ABC	#2 ACSR	7.37Y	122.8	0.02	2.19	14.57	8	310	87	96	0.05	0.0	5.512	0.054	11	3	2	64
PL.1908	PL.1891	ABC	#2 ACSR	7.37Y	122.8	0.02	2.21	9.17	5	195	55	96	0.03	0.0	5.600	0.088	25	7	5	44

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2380	PL.1908	A	6 A (CWC)	7.37Y	122.8	0.00	2.21	1.15	1	8	2	97	0.00	0.0	5.605	0.005	0	0	0	2
PD.261	PL.2380	A	10T	7.37Y	122.8	0.00	2.21	1.15	0	8	2	97	0.00	0.0	5.605	0.005	0	0	0	2
PL.2381	PD.261	A	6 A (CWC)	7.37Y	122.8	0.00	2.22	1.15	1	8	2	97	0.00	0.0	5.703	0.098	8	2	2	2
PL.1913	PL.1908	ABC	#2 ACSR	7.37Y	122.8	0.01	2.23	7.63	4	162	45	96	0.02	0.0	5.668	0.068	9	2	4	37
PL.1914	PL.1913	ABC	#2 ACSR	7.37Y	122.8	0.00	2.23	7.21	4	154	43	96	0.01	0.0	5.696	0.028	32	9	6	33
PL.1915	PL.1914	ABC	#2 ACSR	7.37Y	122.8	0.01	2.24	5.71	3	122	34	96	0.01	0.0	5.769	0.072	26	7	5	27
PL.1916	PL.1915	ABC	#2 ACSR	7.37Y	122.8	0.01	2.25	4.47	3	95	27	96	0.00	0.0	5.820	0.051	14	4	2	22
PL.1917	PL.1916	ABC	#2 ACSR	7.37Y	122.8	0.00	2.25	3.84	2	82	23	96	0.00	0.0	5.873	0.053	22	6	5	20
PL.2526	PL.1917	C	#2 ACSR	7.36Y	122.7	0.00	2.25	8.36	5	59	17	96	0.00	0.0	5.878	0.005	0	0	0	15
PD.334	PL.2526	C	40QA	7.36Y	122.7	0.00	2.25	8.36	21	59	17	96	0.00	0.0	5.878	0.005	0	0	0	15
PL.2527	PD.334	C	#2 ACSR	7.36Y	122.7	0.01	2.26	8.36	5	59	17	96	0.00	0.0	5.936	0.058	19	5	4	15
PL.1918	PL.2527	C	#2 ACSR	7.36Y	122.7	0.01	2.27	4.03	2	29	8	96	0.00	0.0	6.013	0.077	13	4	5	9
PL.1922	PL.1918	C	#4 ACSR	7.36Y	122.7	0.00	2.27	0.25	0	2	0	100	0.00	0.0	6.078	0.065	2	0	1	1
PL.1923	PL.1918	C	#1/0 ACSR	7.36Y	122.7	0.00	2.27	1.95	1	14	4	96	0.00	0.0	6.083	0.069	14	4	3	3
PL.1919	PL.2527	C	#2 ACSR	7.36Y	122.7	0.00	2.26	1.62	1	12	3	97	0.00	0.0	5.951	0.015	9	2	1	2
PL.1920	PL.1919	C	#2 ACSR	7.36Y	122.7	0.00	2.26	0.41	0	3	1	95	0.00	0.0	5.982	0.031	0	0	0	1
PL.1921	PL.1920	C	#2 ACSR	7.36Y	122.7	0.00	2.26	0.41	0	3	1	95	0.00	0.0	6.003	0.021	3	1	1	1
PL.2378	PL.1891	C	#4 ACSR	7.37Y	122.8	0.00	2.20	8.10	6	58	16	96	0.00	0.0	5.516	0.005	0	0	0	9
PD.260	PL.2378	C	40QA	7.37Y	122.8	0.00	2.20	8.10	20	58	16	96	0.00	0.0	5.516	0.005	0	0	0	9
PL.2379	PD.260	C	#4 ACSR	7.37Y	122.8	0.01	2.21	8.10	6	58	16	96	0.00	0.0	5.548	0.032	0	0	0	9
PL.1911	PL.2379	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	2.92	2	21	6	96	0.00	0.0	5.603	0.055	21	6	4	4
PL.1910	PL.2379	C	#4 ACSR	7.37Y	122.8	0.00	2.21	5.18	4	37	10	97	0.00	0.0	5.564	0.016	30	8	4	5
PL.1912	PL.1910	C	#4 ACSR	7.37Y	122.8	0.00	2.21	0.93	1	7	2	96	0.00	0.0	5.579	0.015	7	2	1	1
PL.1909	PL.1891	C	#4 ACSR	7.37Y	122.8	0.01	2.20	6.52	5	46	13	96	0.00	0.0	5.554	0.043	46	13	9	9
PL.2274	PL.1861	C	#4 ACSR	7.38Y	122.9	0.00	2.08	0.00	0	0	0	100	0.00	0.0	5.288	0.005	0	0	0	0
PL.1856	PL.1854	ABC	#2 ACSR	7.38Y	123.1	0.01	1.93	18.54	11	395	111	96	0.02	0.0	5.185	0.015	5	2	3	103
PL.1858	PL.1856	ABC	#2 ACSR	7.38Y	123.1	0.01	1.94	18.28	10	390	109	96	0.04	0.0	5.214	0.029	5	1	1	100
PL.1859	PL.1858	ABC	#2 ACSR	7.38Y	123.1	0.01	1.95	18.05	10	385	108	96	0.02	0.0	5.228	0.014	0	0	0	99
PL.1860	PL.1859	ABC	#2 ACSR	7.38Y	123.0	0.05	2.00	18.05	10	385	108	96	0.16	0.0	5.347	0.119	9	3	1	99
PL.1866	PL.1860	ABC	#2 ACSR	7.38Y	123.0	0.01	2.01	17.61	10	376	105	96	0.03	0.0	5.371	0.024	0	0	0	98
PL.1867	PL.1866	ABC	#2 ACSR	7.38Y	123.0	0.00	2.01	17.61	10	376	105	96	0.00	0.0	5.373	0.003	42	12	13	98

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1868	PL.1867	ABC	#2 ACSR	7.38Y	123.0	0.01	2.02	15.65	9	334	93	96	0.03	0.0	5.403	0.029	0	0	0	85
PL.1869	PL.1868	ABC	#2 ACSR	7.38Y	123.0	0.01	2.03	14.97	9	319	89	96	0.03	0.0	5.432	0.029	9	2	7	79
PL.1871	PL.1869	ABC	#2 ACSR	7.38Y	122.9	0.02	2.06	14.57	8	311	87	96	0.05	0.0	5.498	0.067	29	8	6	72
PL.2558	PL.1871	A	6 A (CWC)	7.38Y	122.9	0.00	2.06	23.63	17	168	47	96	0.00	0.0	5.501	0.003	0	0	0	31
PD.352	PL.2558	A	70L	7.38Y	122.9	0.00	2.06	23.63	34	168	47	96	0.00	0.0	5.501	0.003	0	0	0	31
PL.2559	PD.352	A	6 A (CWC)	7.37Y	122.9	0.09	2.15	23.63	17	168	47	96	0.11	0.1	5.582	0.081	4	1	1	31
PL.1872	PL.2559	A	8 A (CWC)	7.37Y	122.8	0.08	2.23	23.03	23	164	46	96	0.10	0.1	5.637	0.055	18	5	4	30
PL.1989	PL.1872	A	6 A (CWC)	7.36Y	122.7	0.05	2.27	6.13	4	44	12	96	0.02	0.0	5.807	0.170	0	0	0	6
PL.1990	PL.1989	A	6 A (CWC)	7.36Y	122.7	0.04	2.32	6.13	4	44	12	96	0.01	0.0	5.954	0.148	0	0	0	6
PL.1992	PL.1990	A	6 A (CWC)	7.36Y	122.7	0.01	2.33	2.14	2	15	4	97	0.00	0.0	6.073	0.118	0	0	0	2
PL.1998	PL.1992	A	6 A (CWC)	7.36Y	122.7	0.01	2.34	2.14	2	15	4	97	0.00	0.0	6.149	0.077	0	0	0	2
PL.2000	PL.1998	A	6 A (CWC)	7.36Y	122.7	0.01	2.34	2.14	2	15	4	97	0.00	0.0	6.270	0.121	15	4	2	2
PL.2271	PL.2000	A	6 A (CWC)	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	6.275	0.005	0	0	0	0
PL.1993	PL.1990	A	6 A (CWC)	7.36Y	122.7	0.02	2.33	3.99	3	28	8	96	0.00	0.0	6.069	0.115	8	2	1	4
PL.1995	PL.1993	A	6 A (CWC)	7.36Y	122.7	0.00	2.34	2.83	2	20	6	96	0.00	0.0	6.089	0.020	0	0	0	3
PL.2262	PL.1995	A	6 A (CWC)	7.36Y	122.7	0.01	2.34	2.83	2	20	6	96	0.00	0.0	6.184	0.095	20	6	3	3
PL.2263	PL.2262	A	6 A (CWC)	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	6.214	0.030	0	0	0	0
PL.1873	PL.1872	A	8 A (CWC)	7.36Y	122.7	0.03	2.26	14.39	14	102	28	96	0.03	0.0	5.672	0.035	7	2	1	20
PL.1875	PL.1873	A	8 A (CWC)	7.36Y	122.7	0.02	2.28	8.11	8	58	16	96	0.01	0.0	5.713	0.041	6	2	2	11
PL.1586	PL.1875	A	8 A (CWC)	7.36Y	122.7	0.01	2.29	7.31	7	52	14	97	0.00	0.0	5.734	0.020	8	2	2	9
PL.1587	PL.1586	A	8 A (CWC)	7.36Y	122.7	0.01	2.30	6.23	6	44	12	96	0.00	0.0	5.783	0.050	27	8	4	7
PL.1877	PL.1587	A	6 A (CWC)	7.36Y	122.7	0.00	2.31	2.36	2	17	5	96	0.00	0.0	5.839	0.056	12	3	2	3
PL.1878	PL.1877	A	#2 ACSR	7.36Y	122.7	0.00	2.31	0.73	0	5	1	98	0.00	0.0	5.866	0.027	5	1	1	1
PL.1876	PL.1873	A	6 A (CWC)	7.36Y	122.7	0.01	2.27	5.34	4	38	11	96	0.00	0.0	5.723	0.051	38	11	8	8
PL.2552	PL.1871	C	6 A (CWC)	7.38Y	122.9	0.00	2.06	16.03	11	114	32	96	0.00	0.0	5.501	0.003	0	0	0	35
PD.348	PL.2552	C	35H	7.38Y	122.9	0.00	2.06	16.03	46	114	32	96	0.00	0.0	5.501	0.003	0	0	0	35
PL.2553	PD.348	C	6 A (CWC)	7.37Y	122.9	0.03	2.09	16.03	11	114	32	96	0.02	0.0	5.544	0.044	18	5	4	35
PL.1879	PL.2553	C	6 A (CWC)	7.37Y	122.9	0.03	2.11	13.53	10	96	27	96	0.02	0.0	5.586	0.041	3	1	4	31
PL.1880	PL.1879	C	6 A (CWC)	7.37Y	122.9	0.01	2.13	13.12	9	93	26	96	0.01	0.0	5.607	0.022	0	0	0	27
PL.1881	PL.1880	C	6 A (CWC)	7.37Y	122.8	0.03	2.16	13.12	9	93	26	96	0.02	0.0	5.663	0.056	2	1	1	27
PL.1883	PL.1881	C	6 A (CWC)	7.37Y	122.8	0.00	2.16	2.68	2	19	5	97	0.00	0.0	5.694	0.031	0	0	1	13

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1884	PL.1883	C	6 A (CWC)	7.37Y	122.8	0.00	2.16	0.08	0	1	0	100	0.00	0.0	5.784	0.090	1	0	3	3
PL.1885	PL.1883	C	6 A (CWC)	7.37Y	122.8	0.00	2.17	2.57	2	18	5	96	0.00	0.0	5.713	0.018	0	0	0	9
PL.1886	PL.1885	C	#4 ACSR	7.37Y	122.8	0.00	2.17	2.57	2	18	5	96	0.00	0.0	5.737	0.024	18	5	9	9
PL.1882	PL.1881	C	6 A (CWC)	7.37Y	122.8	0.01	2.17	10.13	7	72	20	96	0.00	0.0	5.685	0.021	33	9	5	13
PL.1887	PL.1882	C	#4 ACSR	7.37Y	122.8	0.01	2.18	5.52	4	39	11	96	0.00	0.0	5.714	0.029	0	0	0	8
PL.1888	PL.1887	C	#4 ACSR	7.37Y	122.8	0.00	2.18	5.52	4	39	11	96	0.00	0.0	5.740	0.026	39	11	8	8
PL.1870	PL.1868	C	8 A (CWC)	7.38Y	123.0	0.00	2.03	2.04	2	14	4	96	0.00	0.0	5.452	0.050	14	4	6	6
PL.2280	PL.2110	C	#4 ACSR	7.40Y	123.4	0.00	1.64	8.16	6	58	16	96	0.00	0.0	4.761	0.005	0	0	0	15
PD.212	PL.2280	C	40QA	7.40Y	123.4	0.00	1.64	8.16	20	58	16	96	0.00	0.0	4.761	0.005	0	0	0	15
PL.2281	PD.212	C	#4 ACSR	7.40Y	123.4	0.01	1.64	8.16	6	58	16	96	0.00	0.0	4.784	0.023	24	7	6	15
PL.1803	PL.2281	C	#4 ACSR	7.40Y	123.3	0.02	1.66	4.82	4	34	10	96	0.01	0.0	4.876	0.092	0	0	0	9
PL.2097	PL.1803	C	#4 ACSR	7.40Y	123.3	0.01	1.67	3.38	3	24	7	96	0.00	0.0	4.925	0.048	0	0	0	8
PL.2098	PL.2097	C	#4 ACSR	7.40Y	123.3	0.01	1.68	3.38	3	24	7	96	0.00	0.0	4.984	0.059	0	0	0	8
PL.1841	PL.2098	C	#4 ACSR	7.40Y	123.3	0.00	1.68	1.41	1	10	3	96	0.00	0.0	5.047	0.063	10	3	1	1
PL.1840	PL.2098	C	#4 ACSR	7.40Y	123.3	0.00	1.68	1.97	2	14	4	96	0.00	0.0	5.026	0.043	0	0	0	7
PL.1842	PL.1840	C	#4 ACSR	7.40Y	123.3	0.00	1.69	1.97	2	14	4	96	0.00	0.0	5.082	0.056	0	0	0	7
PL.1590	PL.1842	C	#2 ACSR	7.40Y	123.3	0.00	1.69	1.97	1	14	4	96	0.00	0.0	5.129	0.047	7	2	1	7
PL.1591	PL.1590	C	#2 ACSR	7.40Y	123.3	0.00	1.69	0.98	1	7	2	96	0.00	0.0	5.209	0.080	0	0	0	6
PL.2026	PL.1591	C	#2 ACSR	7.40Y	123.3	0.00	1.70	0.98	1	7	2	96	0.00	0.0	5.331	0.121	0	0	0	6
PL.2027	PL.2026	C	#2 ACSR	7.40Y	123.3	0.00	1.70	0.98	1	7	2	96	0.00	0.0	5.380	0.049	0	0	0	6
PL.1843	PL.2027	C	#2 ACSR	7.40Y	123.3	0.00	1.70	0.98	1	7	2	96	0.00	0.0	5.418	0.038	0	0	0	6
PL.1844	PL.1843	C	#2 ACSR	7.40Y	123.3	0.00	1.70	0.98	1	7	2	96	0.00	0.0	5.444	0.026	0	0	0	6
PL.1845	PL.1844	C	#4 ACSR	7.40Y	123.3	0.00	1.70	0.30	0	2	1	89	0.00	0.0	5.475	0.030	2	1	5	5
PL.1847	PL.1845	C	#4 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	5.503	0.028	0	0	0	0
PL.1846	PL.1844	C	#4 ACSR	7.40Y	123.3	0.00	1.70	0.68	1	5	1	98	0.00	0.0	5.477	0.033	5	1	1	1
PL.1848	PL.1846	C	#4 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	5.544	0.067	0	0	0	0
PL.1838	PL.2097	C	#2 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	4.947	0.023	0	0	0	0
PL.2284	PL.1803	C	#4 ACSR	7.40Y	123.3	0.00	1.66	1.44	1	10	3	96	0.00	0.0	4.881	0.005	0	0	0	1
PD.215	PL.2284	C	40QA	7.40Y	123.3	0.00	1.66	1.44	4	10	3	96	0.00	0.0	4.881	0.005	0	0	0	1
PL.2285	PD.215	C	#4 ACSR	7.40Y	123.3	0.00	1.66	1.44	1	10	3	96	0.00	0.0	4.897	0.016	0	0	0	1
PL.1839	PL.2285	C	#4 ACSR	7.40Y	123.3	0.00	1.67	1.44	1	10	3	96	0.00	0.0	4.927	0.030	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	Element KW	KVAR	Cons On	Cons Thru
PL.2310	PL.2120	C	#2 ACSR	7.43Y	123.8	0.00	1.22	0.98	1	7	2	96	0.00	0.0	4.169	0.005	0	0	0	1
PD.228	PL.2310	C	40QA	7.43Y	123.8	0.00	1.22	0.98	2	7	2	96	0.00	0.0	4.169	0.005	0	0	0	1
PL.2311	PD.228	C	#1/0 ACSR	7.43Y	123.8	0.00	1.22	0.98	0	7	2	96	0.00	0.0	4.206	0.037	7	2	1	1
PL.2306	PL.2174	C	#4 ACSR	7.44Y	124.0	0.00	0.99	2.88	2	21	6	96	0.00	0.0	3.862	0.005	0	0	0	3
PD.226	PL.2306	C	40QA	7.44Y	124.0	0.00	0.99	2.88	7	21	6	96	0.00	0.0	3.862	0.005	0	0	0	3
PL.2307	PD.226	C	#4 ACSR	7.44Y	124.0	0.00	0.99	2.88	2	21	6	96	0.00	0.0	3.875	0.012	21	6	3	3
PL.2314	PL.2125	A	#2 ACSR	7.45Y	124.1	0.00	0.90	1.80	1	13	4	96	0.00	0.0	3.750	0.005	0	0	0	2
PD.230	PL.2314	A	40QA	7.45Y	124.1	0.00	0.90	1.80	4	13	4	96	0.00	0.0	3.750	0.005	0	0	0	2
PL.2315	PD.230	A	#2 ACSR	7.45Y	124.1	0.00	0.90	1.80	1	13	4	96	0.00	0.0	3.775	0.025	13	4	2	2
PL.1791	PL.2178	ABC	#2 ACSR	7.45Y	124.1	0.00	0.87	0.24	0	5	2	93	0.00	0.0	3.720	0.004	5	2	1	1
PL.1788	PL.2128	ABC	#1/0 ACSR	7.45Y	124.2	0.02	0.83	27.17	12	585	165	96	0.08	0.0	3.675	0.039	0	0	0	124
PL.2566	PL.1788	ABC	#1/0 ACSR	7.45Y	124.2	0.00	0.83	27.17	12	585	165	96	0.01	0.0	3.677	0.003	0	0	0	124
C PD.356	PL.2566	ABC	35H	7.45Y	124.2	0.00	0.83	27.17	78	585	165	96	0.00	0.0	3.677	0.003	0	0	0	124 C
PL.2567	PD.356	ABC	#1/0 ACSR	7.45Y	124.1	0.03	0.86	27.17	12	585	165	96	0.13	0.0	3.741	0.064	0	0	0	124
PL.1789	PL.2567	ABC	#1/0 ACSR	7.45Y	124.1	0.04	0.90	27.17	12	584	164	96	0.16	0.0	3.824	0.083	0	0	0	124
PL.2025	PL.1789	ABC	#1/0 ACSR	7.44Y	124.0	0.06	0.96	27.17	12	584	164	96	0.22	0.0	3.937	0.113	6	2	1	124
PL.1790	PL.2025	ABC	#1/0 ACSR	7.44Y	124.0	0.01	0.97	26.87	12	578	162	96	0.03	0.0	3.951	0.014	0	0	0	123
PL.2304	PL.1790	C	#2 ACSR	7.44Y	124.0	0.00	0.97	0.28	0	2	1	89	0.00	0.0	3.955	0.004	0	0	0	2
PD.225	PL.2304	C	40QA	7.44Y	124.0	0.00	0.97	0.28	1	2	1	89	0.00	0.0	3.955	0.004	0	0	0	2
PL.2305	PD.225	C	#2 ACSR	7.44Y	124.0	0.00	0.97	0.28	0	2	1	89	0.00	0.0	4.046	0.091	2	1	2	2
PL.2168	PL.1790	ABC	#1/0 ACSR	7.44Y	124.0	0.02	0.98	26.78	12	576	162	96	0.07	0.0	3.989	0.038	0	0	0	121
PL.2169	PL.2168	ABC	#1/0 ACSR	7.44Y	124.0	0.03	1.02	26.78	12	576	162	96	0.13	0.0	4.058	0.069	0	0	0	121
PL.2024	PL.2169	ABC	#1/0 ACSR	7.44Y	123.9	0.05	1.07	26.78	12	575	162	96	0.20	0.0	4.162	0.104	0	0	0	121
PL.2023	PL.2024	ABC	#1/0 ACSR	7.43Y	123.9	0.03	1.10	26.78	12	575	161	96	0.11	0.0	4.221	0.060	0	0	0	121
PL.66256	PL.2023	ABC	#1/0 ACSR	7.43Y	123.9	0.05	1.14	26.78	12	575	161	96	0.18	0.0	4.317	0.096	0	0	0	121
PL.66257	PL.66256	ABC	#1/0 ACSR	7.43Y	123.8	0.02	1.17	26.78	12	575	161	96	0.09	0.0	4.365	0.048	0	0	0	121
PL.2021	PL.66257	ABC	#1/0 ACSR	7.43Y	123.8	0.05	1.22	26.78	12	575	161	96	0.21	0.0	4.473	0.109	0	0	0	121
PL.2158	PL.2021	ABC	#1/0 ACSR	7.42Y	123.7	0.03	1.25	26.78	12	575	161	96	0.14	0.0	4.546	0.073	15	4	2	121
PL.2159	PL.2158	ABC	#1/0 ACSR	7.42Y	123.7	0.02	1.28	26.08	11	559	156	96	0.09	0.0	4.597	0.050	10	3	2	119
PL.2296	PL.2159	C	#2 ACSR	7.42Y	123.7	0.00	1.28	2.09	1	15	4	97	0.00	0.0	4.601	0.004	0	0	0	2
PD.221	PL.2296	C	40QA	7.42Y	123.7	0.00	1.28	2.09	5	15	4	97	0.00	0.0	4.601	0.004	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2297	PD.221	C	#2 ACSR	7.42Y	123.7	0.00	1.28	2.09	1	15	4	97	0.00	0.0	4.603	0.002	15	4	2	2
PL.2136	PL.2159	ABC	#1/0 ACSR	7.42Y	123.7	0.03	1.31	24.93	11	535	149	96	0.11	0.0	4.667	0.070	22	6	7	115
PL.2524	PL.2136	A	8 A (CWC)	7.42Y	123.7	0.01	1.31	20.45	20	146	41	96	0.01	0.0	4.671	0.005	0	0	0	30
PD.332	PL.2524	A	15T	7.42Y	123.7	0.00	1.31	20.45	0	146	41	96	0.00	0.0	4.671	0.005	0	0	0	30
PL.2525	PD.332	A	8 A (CWC)	7.42Y	123.6	0.10	1.41	20.45	20	146	41	96	0.11	0.1	4.744	0.073	0	0	0	30
PL.1807	PL.2525	A	8 A (CWC)	7.41Y	123.4	0.17	1.58	20.45	20	146	41	96	0.19	0.1	4.868	0.123	0	0	0	30
PL.2134	PL.1807	A	8 A (CWC)	7.40Y	123.3	0.10	1.68	20.45	20	146	41	96	0.11	0.1	4.945	0.077	10	3	2	30
PL.1808	PL.2134	A	#4 ACSR	7.40Y	123.3	0.00	1.68	1.71	1	12	3	97	0.00	0.0	4.963	0.018	12	3	1	1
PL.2160	PL.2134	A	8 A (CWC)	7.39Y	123.2	0.07	1.75	17.34	17	124	35	96	0.07	0.1	5.007	0.062	10	3	2	27
PL.2161	PL.2160	A	8 A (CWC)	7.39Y	123.2	0.04	1.80	15.90	16	113	32	96	0.04	0.0	5.049	0.042	0	0	0	25
PL.2162	PL.2161	A	8 A (CWC)	7.39Y	123.2	0.02	1.82	15.90	16	113	32	96	0.02	0.0	5.071	0.022	3	1	1	25
PL.2163	PL.2162	A	8 A (CWC)	7.38Y	123.1	0.10	1.92	15.53	16	111	31	96	0.08	0.1	5.169	0.098	11	3	3	24
PL.1809	PL.2163	A	8 A (CWC)	7.38Y	123.1	0.03	1.95	9.63	10	69	19	96	0.02	0.0	5.218	0.049	6	2	1	12
PL.2166	PL.1809	A	#4 ACSR	7.38Y	123.0	0.00	1.95	3.37	3	24	7	96	0.00	0.0	5.249	0.030	11	3	1	2
PL.2167	PL.2166	A	#4 ACSR	7.38Y	123.0	0.00	1.95	1.87	1	13	4	96	0.00	0.0	5.273	0.025	13	4	1	1
PL.1811	PL.1809	A	8 A (CWC)	7.38Y	123.0	0.01	1.96	2.13	2	15	4	97	0.00	0.0	5.287	0.069	4	1	1	4
PL.1813	PL.1811	A	#2 ACSR	7.38Y	123.0	0.00	1.96	1.62	1	12	3	97	0.00	0.0	5.338	0.051	12	3	3	3
PL.65779	PL.1811	A	#1/0 ACSR	7.38Y	123.0	0.00	1.96	0.00	0	0	0	100	0.00	0.0	5.358	0.071	0	0	0	0
PL.1812	PL.1809	A	#4 ACSR	7.38Y	123.0	0.00	1.95	3.26	3	23	6	97	0.00	0.0	5.248	0.030	0	0	0	5
PL.1836	PL.1812	A	8 A (CWC)	7.38Y	123.0	0.03	1.98	3.26	3	23	6	97	0.01	0.0	5.398	0.150	0	0	0	5
PL.1814	PL.1836	A	8 A (CWC)	7.38Y	123.0	0.02	2.01	3.26	3	23	6	97	0.00	0.0	5.499	0.101	0	0	0	5
PL.1815	PL.1814	A	8 A (CWC)	7.38Y	123.0	0.00	2.01	1.84	2	13	4	96	0.00	0.0	5.538	0.039	0	0	0	3
PL.1818	PL.1815	A	#4 ACSR	7.38Y	123.0	0.00	2.01	0.92	1	7	2	96	0.00	0.0	5.559	0.021	7	2	1	1
PL.1817	PL.1815	A	#4 ACSR	7.38Y	123.0	0.00	2.01	0.92	1	7	2	96	0.00	0.0	5.587	0.049	6	2	1	2
PL.1819	PL.1817	A	#4 ACSR	7.38Y	123.0	0.00	2.01	0.00	0	0	0	100	0.00	0.0	5.623	0.036	0	0	0	1
PL.1820	PL.1819	A	#4 ACSR	7.38Y	123.0	0.00	2.01	0.00	0	0	0	100	0.00	0.0	5.675	0.052	0	0	1	1
PL.1816	PL.1814	A	#4 ACSR	7.38Y	123.0	0.00	2.01	1.42	1	10	3	96	0.00	0.0	5.535	0.036	10	3	2	2
PL.2135	PL.2163	A	#4 ACSR	7.38Y	123.1	0.00	1.92	4.41	3	31	9	96	0.00	0.0	5.189	0.020	19	5	4	9
PL.1810	PL.2135	A	#1/0 ACSR	7.38Y	123.1	0.00	1.92	1.41	1	10	3	96	0.00	0.0	5.231	0.042	10	3	1	1
PL.2164	PL.2135	A	#4 ACSR	7.38Y	123.1	0.00	1.92	0.39	0	3	1	95	0.00	0.0	5.235	0.045	1	0	3	4
PL.2165	PL.2164	A	#4 ACSR	7.38Y	123.1	0.00	1.92	0.20	0	1	0	100	0.00	0.0	5.285	0.051	1	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1806	PL.2136	ABC	#1/0 ACSR	7.42Y	123.7	0.02	1.33	15.73	7	337	94	96	0.05	0.0	4.740	0.073	12	3	3	73
PL.2300	PL.1806	B	8 A (CWC)	7.41Y	123.6	0.12	1.45	37.55	38	268	75	96	0.25	0.1	4.786	0.047	0	0	0	56
PD.223	PL.2300	B	25T	7.41Y	123.6	0.00	1.45	37.55	0	268	75	96	0.00	0.0	4.786	0.047	0	0	0	56
PL.2301	PD.223	B	8 A (CWC)	7.41Y	123.5	0.08	1.53	37.55	38	268	75	96	0.17	0.1	4.821	0.034	25	7	4	56
PL.2150	PL.2301	B	8 A (CWC)	7.40Y	123.3	0.17	1.70	34.07	34	243	68	96	0.33	0.1	4.900	0.079	16	5	7	52
PL.2137	PL.2150	B	8 A (CWC)	7.40Y	123.3	0.01	1.71	8.22	8	59	16	97	0.00	0.0	4.919	0.019	0	0	1	11
PL.1826	PL.2137	B	8 A (CWC)	7.40Y	123.3	0.02	1.73	8.22	8	59	16	97	0.01	0.0	4.968	0.049	21	6	3	10
PL.2143	PL.1826	B	8 A (CWC)	7.39Y	123.2	0.02	1.76	5.32	5	38	11	96	0.01	0.0	5.054	0.086	20	5	3	7
PL.2144	PL.2143	B	8 A (CWC)	7.39Y	123.2	0.01	1.76	2.57	3	18	5	96	0.00	0.0	5.090	0.036	0	0	0	4
PL.1592	PL.2144	B	8 A (CWC)	7.39Y	123.2	0.01	1.77	2.57	3	18	5	96	0.00	0.0	5.133	0.044	7	2	2	4
PL.1834	PL.1592	B	6 A (CWC)	7.39Y	123.2	0.00	1.77	1.58	1	11	3	96	0.00	0.0	5.151	0.017	0	0	0	2
PL.1835	PL.1834	B	6 A (CWC)	7.39Y	123.2	0.00	1.77	1.58	1	11	3	96	0.00	0.0	5.192	0.041	11	3	2	2
PL.1825	PL.2150	B	8 A (CWC)	7.39Y	123.2	0.06	1.76	23.56	24	168	47	96	0.08	0.0	4.940	0.040	14	4	2	34
PL.2148	PL.1825	B	8 A (CWC)	7.39Y	123.2	0.05	1.81	21.59	22	154	43	96	0.05	0.0	4.975	0.036	31	9	7	32
PL.2149	PL.2148	B	8 A (CWC)	7.39Y	123.1	0.05	1.86	17.18	17	122	34	96	0.05	0.0	5.021	0.046	8	2	1	25
PL.2145	PL.2149	B	8 A (CWC)	7.39Y	123.1	0.04	1.90	16.04	16	114	32	96	0.03	0.0	5.058	0.036	14	4	2	24
PL.1827	PL.2145	B	8 A (CWC)	7.38Y	123.1	0.03	1.93	5.68	6	40	11	96	0.01	0.0	5.160	0.102	17	5	4	11
PL.1830	PL.1827	B	#1/0 ACSR	7.38Y	123.1	0.00	1.93	2.90	1	21	6	96	0.00	0.0	5.211	0.051	9	3	2	6
PL.1832	PL.1830	B	#1/0 ACSR	7.38Y	123.1	0.00	1.93	1.61	1	11	3	96	0.00	0.0	5.250	0.040	6	2	1	3
PL.1833	PL.1832	B	8 A (CWC)	7.38Y	123.1	0.00	1.93	0.70	1	5	1	98	0.00	0.0	5.296	0.046	5	1	2	2
PL.21313	PL.1830	B	#1/0 ACSR	7.38Y	123.1	0.00	1.93	0.01	0	0	0	100	0.00	0.0	5.232	0.022	0	0	0	1
PL.21314	PL.21313	B	#1/0 ACSR	7.38Y	123.1	0.00	1.93	0.01	0	0	0	100	0.00	0.0	5.302	0.070	0	0	1	1
PL.1831	PL.1827	B	#4 ACSR	7.38Y	123.1	0.00	1.93	0.45	0	3	1	95	0.00	0.0	5.230	0.071	3	1	1	1
PL.1829	PL.2145	B	#4 ACSR	7.39Y	123.1	0.00	1.90	5.06	4	36	10	96	0.00	0.0	5.084	0.027	36	10	6	6
PL.2146	PL.2145	B	#2 ACSR	7.39Y	123.1	0.00	1.90	2.90	2	21	6	96	0.00	0.0	5.088	0.030	18	5	3	4
PL.2147	PL.2146	B	#2 ACSR	7.39Y	123.1	0.00	1.90	0.31	0	2	1	89	0.00	0.0	5.117	0.029	2	1	1	1
PL.1828	PL.2145	B	#2 ACSR	7.39Y	123.1	0.00	1.90	0.48	0	3	1	95	0.00	0.0	5.074	0.016	3	1	1	1
PL.28010	PL.2145	B	#1/0 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	5.087	0.029	0	0	0	0
PL.2151	PL.1806	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	1.46	1	10	3	96	0.00	0.0	4.763	0.024	4	1	3	4
PL.2152	PL.2151	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.95	0	7	2	96	0.00	0.0	4.799	0.036	7	2	1	1
PL.2298	PL.1806	C	8 A (CWC)	7.42Y	123.7	0.00	1.33	6.45	6	46	13	96	0.00	0.0	4.744	0.005	0	0	0	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PD.222	PL.2298	C	40QA	7.42Y	123.7	0.00	1.33	6.45	16	46	13	96	0.00	0.0	4.744	0.005	0	0	0	10
PL.2299	PD.222	C	8 A (CWC)	7.42Y	123.7	0.02	1.35	6.45	6	46	13	96	0.01	0.0	4.796	0.052	23	6	3	10
PL.1821	PL.2299	C	8 A (CWC)	7.42Y	123.6	0.02	1.36	3.26	3	23	6	97	0.00	0.0	4.878	0.082	5	1	1	7
PL.1822	PL.1821	C	8 A (CWC)	7.42Y	123.6	0.01	1.37	2.61	3	19	5	97	0.00	0.0	4.924	0.046	3	1	1	6
PL.1823	PL.1822	C	8 A (CWC)	7.42Y	123.6	0.01	1.38	2.18	2	16	4	97	0.00	0.0	5.023	0.100	8	2	2	5
PL.2153	PL.1823	C	8 A (CWC)	7.42Y	123.6	0.00	1.38	0.63	1	4	1	97	0.00	0.0	5.067	0.043	2	1	1	2
PL.2154	PL.2153	C	8 A (CWC)	7.42Y	123.6	0.00	1.38	0.37	0	3	1	95	0.00	0.0	5.118	0.051	0	0	0	1
PL.1837	PL.2154	C	6 A (CWC)	7.42Y	123.6	0.00	1.38	0.37	0	3	1	95	0.00	0.0	5.169	0.051	3	1	1	1
PL.1824	PL.1823	C	8 A (CWC)	7.42Y	123.6	0.00	1.38	0.47	0	3	1	95	0.00	0.0	5.071	0.048	3	1	1	1
PL.2302	PL.2136	A	#4 ACSR	7.42Y	123.7	0.00	1.31	4.01	3	29	8	96	0.00	0.0	4.671	0.005	0	0	0	5
PD.224	PL.2302	A	40QA	7.42Y	123.7	0.00	1.31	4.01	10	29	8	96	0.00	0.0	4.671	0.005	0	0	0	5
PL.2303	PD.224	A	#4 ACSR	7.42Y	123.7	0.01	1.31	4.01	3	29	8	96	0.00	0.0	4.705	0.034	0	0	0	5
PL.2155	PL.2303	A	#4 ACSR	7.42Y	123.7	0.01	1.32	4.01	3	29	8	96	0.00	0.0	4.757	0.052	17	5	2	5
PL.2156	PL.2155	A	#4 ACSR	7.42Y	123.7	0.00	1.32	1.68	1	12	3	97	0.00	0.0	4.814	0.057	3	1	2	3
PL.2157	PL.2156	A	#4 ACSR	7.42Y	123.7	0.00	1.33	1.22	1	9	2	98	0.00	0.0	4.833	0.018	9	2	1	1
PL.1776	PL.2182	C	#2 ACSR	7.14Y	119.0	0.01	6.04	10.40	6	72	20	96	0.01	0.0	3.464	0.049	30	8	5	16
PL.2522	PL.1776	C	8 A (CWC)	7.14Y	119.0	0.00	6.04	6.07	6	42	12	96	0.00	0.0	3.469	0.005	0	0	0	11
PD.331	PL.2522	C	40QA	7.14Y	119.0	0.00	6.04	6.07	15	42	12	96	0.00	0.0	3.469	0.005	0	0	0	11
PL.2523	PD.331	C	8 A (CWC)	7.14Y	118.9	0.02	6.07	6.07	6	42	12	96	0.01	0.0	3.533	0.064	12	3	2	11
PL.1777	PL.2523	C	8 A (CWC)	7.13Y	118.9	0.03	6.10	4.33	4	30	8	97	0.01	0.0	3.640	0.107	0	0	0	9
PL.2183	PL.1777	C	8 A (CWC)	7.13Y	118.9	0.02	6.12	4.33	4	30	8	97	0.00	0.0	3.710	0.070	4	1	2	9
PL.2184	PL.2183	C	8 A (CWC)	7.13Y	118.9	0.02	6.14	3.68	4	25	7	96	0.00	0.0	3.811	0.100	4	1	1	7
PL.1779	PL.2184	C	8 A (CWC)	7.13Y	118.8	0.02	6.16	3.14	3	22	6	96	0.00	0.0	3.911	0.100	0	0	0	6
PL.1781	PL.1779	C	6 A (CWC)	7.13Y	118.8	0.01	6.17	3.14	2	22	6	96	0.00	0.0	3.990	0.080	0	0	0	6
PL.1783	PL.1781	C	6 A (CWC)	7.13Y	118.8	0.01	6.18	3.14	2	22	6	96	0.00	0.0	4.069	0.079	0	0	1	6
PL.1784	PL.1783	C	8 A (CWC)	7.13Y	118.8	0.00	6.18	0.40	0	3	1	95	0.00	0.0	4.124	0.055	2	0	1	2
PL.1787	PL.1784	C	#2 ACSR	7.13Y	118.8	0.00	6.18	0.15	0	1	0	100	0.00	0.0	4.156	0.032	0	0	0	1
PL.1981	PL.1787	C	#2 ACSR	7.13Y	118.8	0.00	6.18	0.15	0	1	0	100	0.00	0.0	4.250	0.094	1	0	1	1
PL.1785	PL.1783	C	#4 ACSR	7.13Y	118.8	0.00	6.18	2.69	2	19	5	97	0.00	0.0	4.104	0.035	11	3	2	3
PL.1786	PL.1785	C	#4 ACSR	7.13Y	118.8	0.00	6.19	1.14	1	8	2	97	0.00	0.0	4.145	0.041	8	2	1	1
PL.1602	PL.2132	ABC	336 MCM AC	7.15Y	119.1	0.05	5.90	69.64	13	1434	417	96	0.40	0.0	3.346	0.098	0	0	0	375

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4468	PL.1602	ABC	336 MCM AC	7.15Y	119.1	0.00	5.90	69.64	13	1434	416	96	0.01	0.0	3.350	0.003	0	0	0	375
PD.901	PL.4468	ABC	100L	7.15Y	119.1	0.00	5.90	69.64	70	1434	416	96	0.00	0.0	3.350	0.003	0	0	0	375
PL.4469	PD.901	ABC	336 MCM AC	7.15Y	119.1	0.01	5.92	69.64	13	1434	416	96	0.10	0.0	3.376	0.026	0	0	0	375
PL.2127	PL.4469	ABC	336 MCM AC	7.14Y	119.1	0.03	5.94	69.48	13	1430	415	96	0.22	0.0	3.429	0.053	0	0	0	374
PL.2126	PL.2127	ABC	336 MCM AC	7.14Y	119.0	0.08	6.02	68.89	13	1418	411	96	0.61	0.0	3.582	0.154	0	0	0	372
PL.2124	PL.2126	ABC	336 MCM AC	7.13Y	118.9	0.08	6.10	68.05	13	1400	404	96	0.59	0.0	3.734	0.152	0	0	0	369
PL.2123	PL.2124	ABC	336 MCM AC	7.13Y	118.9	0.01	6.11	67.96	13	1398	402	96	0.11	0.0	3.762	0.027	0	0	0	368
PL.2121	PL.2123	ABC	336 MCM AC	7.13Y	118.8	0.07	6.19	67.36	13	1385	399	96	0.56	0.0	3.908	0.146	0	0	0	365
PL.2013	PL.2121	ABC	336 MCM AC	7.13Y	118.8	0.06	6.25	67.36	13	1385	397	96	0.44	0.0	4.024	0.116	0	0	0	365
PL.2352	PL.2013	C	#4 ACSR	7.13Y	118.8	0.00	6.25	1.14	1	8	2	97	0.00	0.0	4.028	0.005	0	0	0	5
PD.249	PL.2352	C	40QA	7.13Y	118.8	0.00	6.25	1.14	3	8	2	97	0.00	0.0	4.028	0.005	0	0	0	5
PL.2353	PD.249	C	#4 ACSR	7.13Y	118.8	0.00	6.25	1.14	1	8	2	97	0.00	0.0	4.048	0.020	8	2	5	5
PL.2116	PL.2013	ABC	336 MCM AC	7.12Y	118.7	0.02	6.27	66.98	13	1376	394	96	0.14	0.0	4.061	0.038	0	0	0	360
PL.2354	PL.2116	A	#2 ACSR	7.12Y	118.7	0.00	6.27	5.60	3	38	11	96	0.00	0.0	4.066	0.005	0	0	0	6
PD.250	PL.2354	A	40QA	7.12Y	118.7	0.00	6.27	5.60	14	38	11	96	0.00	0.0	4.066	0.005	0	0	0	6
PL.2355	PD.250	A	#2 ACSR	7.12Y	118.7	0.00	6.27	5.60	3	38	11	96	0.00	0.0	4.085	0.019	5	1	2	6
PL.1607	PL.2355	A	8 A (CWC)	7.12Y	118.7	0.01	6.28	4.82	5	33	9	96	0.00	0.0	4.137	0.052	19	5	2	4
PL.1609	PL.1607	A	#4 ACSR	7.12Y	118.7	0.00	6.28	2.00	2	14	4	96	0.00	0.0	4.196	0.059	14	4	2	2
PL.2258	PL.2116	ABC	336 MCM AC	7.12Y	118.7	0.03	6.29	65.12	13	1338	383	96	0.18	0.0	4.112	0.051	0	0	0	354
PL.2259	PL.2258	ABC	336 MCM AC	7.12Y	118.7	0.05	6.34	65.12	13	1338	383	96	0.34	0.0	4.207	0.095	6	2	1	354
PL.2256	PL.2259	ABC	336 MCM AC	7.12Y	118.6	0.02	6.36	50.84	10	1044	300	96	0.12	0.0	4.262	0.055	2	0	1	290
PL.2257	PL.2256	ABC	336 MCM AC	7.12Y	118.6	0.02	6.38	50.77	10	1042	299	96	0.11	0.0	4.311	0.049	9	2	1	289
PL.2117	PL.2257	ABC	336 MCM AC	7.11Y	118.6	0.07	6.45	50.27	10	1032	296	96	0.38	0.0	4.492	0.180	6	2	1	287
PL.2114	PL.2117	ABC	336 MCM AC	7.11Y	118.5	0.02	6.46	49.65	10	1019	292	96	0.11	0.0	4.544	0.052	0	0	0	283
PL.2111	PL.2114	ABC	336 MCM AC	7.11Y	118.5	0.04	6.51	49.34	10	1012	290	96	0.23	0.0	4.654	0.110	0	0	0	280
PL.2498	PL.2111	C	#2 ACSR	7.11Y	118.5	0.00	6.51	0.97	1	7	2	96	0.00	0.0	4.659	0.005	0	0	0	3
PD.320	PL.2498	C	40QA	7.11Y	118.5	0.00	6.51	0.97	2	7	2	96	0.00	0.0	4.659	0.005	0	0	0	3
PL.2499	PD.320	C	#2 ACSR	7.11Y	118.5	0.00	6.51	0.97	1	7	2	96	0.00	0.0	4.678	0.020	0	0	0	3
PL.2108	PL.2499	C	#2 ACSR	7.11Y	118.5	0.00	6.51	0.15	0	1	0	100	0.00	0.0	4.704	0.026	1	0	1	1
PL.1651	PL.2499	C	#2 ACSR	7.11Y	118.5	0.00	6.51	0.82	0	6	2	95	0.00	0.0	4.705	0.027	6	2	2	2
PL.2456	PL.2111	A	#2 ACSR	7.11Y	118.5	0.00	6.51	0.64	0	4	1	97	0.00	0.0	4.659	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.298	PL.2456	A	40QA	7.11Y	118.5	0.00	6.51	0.64	2	4	1	97	0.00	0.0	4.659	0.005	0	0	0	1
PL.2457	PD.298	A	#2 ACSR	7.11Y	118.5	0.00	6.51	0.64	0	4	1	97	0.00	0.0	4.678	0.020	4	1	1	1
PL.2105	PL.2111	ABC	336 MCM AC	7.11Y	118.4	0.07	6.57	48.80	9	1001	286	96	0.36	0.0	4.835	0.181	0	0	0	276
PL.2254	PL.2105	ABC	336 MCM AC	7.10Y	118.4	0.04	6.61	48.45	9	993	283	96	0.22	0.0	4.948	0.113	0	0	0	269
PL.2255	PL.2254	ABC	336 MCM AC	7.10Y	118.4	0.02	6.63	48.45	9	993	283	96	0.11	0.0	5.005	0.057	0	0	0	269
PL.2106	PL.2255	ABC	336 MCM AC	7.10Y	118.3	0.03	6.66	47.96	9	983	279	96	0.16	0.0	5.089	0.085	1	0	1	266
PL.2466	PL.2106	A	#4 ACSR	7.10Y	118.3	0.00	6.66	1.12	1	8	2	97	0.00	0.0	5.094	0.005	0	0	0	3
PD.304	PL.2466	A	40QA	7.10Y	118.3	0.00	6.66	1.12	3	8	2	97	0.00	0.0	5.094	0.005	0	0	0	3
PL.2467	PD.304	A	#4 ACSR	7.10Y	118.3	0.00	6.66	1.12	1	8	2	97	0.00	0.0	5.117	0.023	8	2	3	3
PL.2107	PL.2106	ABC	336 MCM AC	7.10Y	118.3	0.04	6.70	47.54	9	974	277	96	0.19	0.0	5.189	0.099	0	0	0	262
PL.2104	PL.2107	ABC	336 MCM AC	7.10Y	118.3	0.02	6.72	37.99	7	778	221	96	0.07	0.0	5.250	0.061	0	0	0	205
PL.2414	PL.2104	A	#4 ACSR	7.10Y	118.3	0.00	6.72	2.89	2	20	6	96	0.00	0.0	5.255	0.005	0	0	0	2
PD.277	PL.2414	A	40QA	7.10Y	118.3	0.00	6.72	2.89	7	20	6	96	0.00	0.0	5.255	0.005	0	0	0	2
PL.2415	PD.277	A	#4 ACSR	7.10Y	118.3	0.00	6.72	2.89	2	20	6	96	0.00	0.0	5.268	0.013	20	6	2	2
PL.2103	PL.2104	ABC	336 MCM AC	7.10Y	118.3	0.02	6.73	35.88	7	735	209	96	0.07	0.0	5.314	0.064	0	0	0	200
PL.2502	PL.2103	C	#4 ACSR	7.10Y	118.3	0.00	6.73	1.16	1	8	2	97	0.00	0.0	5.318	0.005	0	0	0	2
PD.322	PL.2502	C	40QA	7.10Y	118.3	0.00	6.73	1.16	3	8	2	97	0.00	0.0	5.318	0.005	0	0	0	2
PL.2503	PD.322	C	#4 ACSR	7.10Y	118.3	0.00	6.73	1.16	1	8	2	97	0.00	0.0	5.338	0.020	8	2	2	2
PL.2102	PL.2103	ABC	336 MCM AC	7.10Y	118.3	0.01	6.75	35.04	7	717	204	96	0.06	0.0	5.369	0.056	2	0	1	196
PL.2504	PL.2102	C	#4 ACSR	7.10Y	118.3	0.00	6.75	0.66	1	4	1	97	0.00	0.0	5.374	0.004	0	0	0	1
PD.323	PL.2504	C	40QA	7.10Y	118.3	0.00	6.75	0.66	2	4	1	97	0.00	0.0	5.374	0.004	0	0	0	1
PL.2505	PD.323	C	#4 ACSR	7.10Y	118.3	0.00	6.75	0.66	1	4	1	97	0.00	0.0	5.377	0.004	4	1	1	1
PL.2267	PL.2102	ABC	336 MCM AC	7.09Y	118.2	0.02	6.76	34.74	7	711	202	96	0.06	0.0	5.433	0.064	26	10	6	194
PL.2268	PL.2267	ABC	336 MCM AC	7.09Y	118.2	0.01	6.77	33.43	6	685	193	96	0.03	0.0	5.467	0.033	11	3	3	188
PL.2225	PL.2268	ABC	336 MCM AC	7.09Y	118.2	0.01	6.78	32.91	6	674	190	96	0.02	0.0	5.491	0.024	3	1	2	185
PL.2226	PL.2225	ABC	336 MCM AC	7.09Y	118.2	0.02	6.80	32.76	6	671	189	96	0.07	0.0	5.573	0.083	6	2	3	183
PL.2420	PL.2226	C	#4 ACSR	7.09Y	118.2	0.00	6.80	14.61	11	100	28	96	0.00	0.0	5.578	0.004	0	0	0	24
PD.280	PL.2420	C	40QA	7.09Y	118.2	0.00	6.80	14.61	37	100	28	96	0.00	0.0	5.578	0.004	0	0	0	24
PL.2421	PD.280	C	#4 ACSR	7.09Y	118.2	0.04	6.84	14.61	11	100	28	96	0.03	0.0	5.641	0.064	11	3	2	24
PL.1688	PL.2421	C	8 A (CWC)	7.09Y	118.1	0.05	6.89	13.00	13	89	25	96	0.03	0.0	5.704	0.062	27	7	9	22
PL.1689	PL.1688	C	8 A (CWC)	7.09Y	118.1	0.03	6.91	9.11	9	62	17	96	0.01	0.0	5.754	0.050	15	4	3	13

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.1690	PL.1689	C	8 A (CWC)	7.08Y	118.1	0.02	6.94	5.98	6	41	11	97	0.01	0.0	5.842	0.088	24	7	5	9
PL.1692	PL.1690	C	8 A (CWC)	7.08Y	118.1	0.01	6.95	2.31	2	16	4	97	0.00	0.0	5.923	0.080	4	1	1	3
PL.1693	PL.1692	C	#2 ACSR	7.08Y	118.1	0.00	6.95	0.87	0	6	2	95	0.00	0.0	5.997	0.075	6	2	1	1
PL.1694	PL.1692	C	#4 ACSR	7.08Y	118.1	0.00	6.95	0.87	1	6	2	95	0.00	0.0	5.928	0.006	6	2	1	1
PL.65819	PL.1690	C	#1/0 ACSR	7.08Y	118.1	0.00	6.94	0.12	0	1	0	100	0.00	0.0	5.861	0.019	1	0	1	1
PL.1691	PL.1689	C	#4 ACSR	7.09Y	118.1	0.00	6.91	0.89	1	6	2	95	0.00	0.0	5.774	0.020	6	2	1	1
PL.2508	PL.2226	ABC	336 MCM AC	7.09Y	118.2	0.00	6.80	25.20	5	516	145	96	0.00	0.0	5.578	0.004	0	0	0	141
PL.2509	PL.2508	ABC	336 MCM AC	7.09Y	118.2	0.01	6.81	25.20	5	516	145	96	0.02	0.0	5.609	0.031	20	6	3	141
PL.2229	PL.2509	ABC	336 MCM AC	7.09Y	118.2	0.01	6.81	24.22	5	496	140	96	0.02	0.0	5.655	0.046	5	1	2	138
PL.2418	PL.2229	A	#4 ACSR	7.09Y	118.2	0.00	6.81	1.15	1	8	2	97	0.00	0.0	5.659	0.005	0	0	0	5
PD.279	PL.2418	A	40QA	7.09Y	118.2	0.00	6.81	1.15	3	8	2	97	0.00	0.0	5.659	0.005	0	0	0	5
PL.2419	PD.279	A	#4 ACSR	7.09Y	118.2	0.00	6.81	1.15	1	8	2	97	0.00	0.0	5.665	0.006	8	2	5	5
PL.2232	PL.2229	ABC	336 MCM AC	7.09Y	118.2	0.01	6.82	23.58	5	483	136	96	0.02	0.0	5.700	0.045	1	0	2	131
PL.2233	PL.2232	ABC	336 MCM AC	7.09Y	118.2	0.02	6.84	23.51	5	481	136	96	0.06	0.0	5.824	0.124	0	0	0	129
PL.2014	PL.2233	ABC	336 MCM AC	7.09Y	118.1	0.03	6.87	23.51	5	481	135	96	0.08	0.0	5.988	0.164	0	0	0	129
PL.2422	PL.2014	A	#4 ACSR	7.09Y	118.1	0.00	6.87	0.00	0	0	0	100	0.00	0.0	5.993	0.005	0	0	0	0
PD.281	PL.2422	A	40QA	7.09Y	118.1	0.00	6.87	0.00	0	0	0	100	0.00	0.0	5.993	0.005	0	0	0	0
PL.2423	PD.281	A	#1/0 ACSR	7.09Y	118.1	0.00	6.87	0.00	0	0	0	100	0.00	0.0	6.034	0.041	0	0	0	0
PL.2089	PL.2014	ABC	336 MCM AC	7.09Y	118.1	0.02	6.90	23.51	5	481	135	96	0.06	0.0	6.122	0.134	0	0	0	129
PL.2424	PL.2089	A	#4 ACSR	7.09Y	118.1	0.00	6.90	1.13	1	8	2	97	0.00	0.0	6.127	0.005	0	0	0	3
PD.282	PL.2424	A	40QA	7.09Y	118.1	0.00	6.90	1.13	3	8	2	97	0.00	0.0	6.127	0.005	0	0	0	3
PL.2425	PD.282	A	#4 ACSR	7.09Y	118.1	0.00	6.90	1.13	1	8	2	97	0.00	0.0	6.153	0.026	0	0	1	3
PL.1699	PL.2425	A	#4 ACSR	7.09Y	118.1	0.01	6.90	1.11	1	8	2	97	0.00	0.0	6.313	0.161	0	0	0	2
PL.1701	PL.1699	A	#4 ACSR	7.09Y	118.1	0.01	6.91	1.11	1	8	2	97	0.00	0.0	6.417	0.103	0	0	0	2
PL.1702	PL.1701	A	#4 ACSR	7.09Y	118.1	0.00	6.91	1.11	1	8	2	97	0.00	0.0	6.478	0.061	0	0	0	2
PL.1703	PL.1702	A	#4 ACSR	7.09Y	118.1	0.00	6.91	0.01	0	0	0	100	0.00	0.0	6.528	0.050	0	0	0	1
PL.1705	PL.1703	A	#2 ACSR	7.09Y	118.1	0.00	6.91	0.01	0	0	0	100	0.00	0.0	6.547	0.019	0	0	0	1
PL.1706	PL.1705	A	#4 ACSR	7.09Y	118.1	0.00	6.91	0.01	0	0	0	100	0.00	0.0	6.600	0.053	0	0	1	1
PL.1704	PL.1702	A	#4 ACSR	7.09Y	118.1	0.00	6.91	1.11	1	8	2	97	0.00	0.0	6.538	0.060	8	2	1	1
PL.2086	PL.2089	ABC	336 MCM AC	7.09Y	118.1	0.01	6.91	23.14	4	474	133	96	0.04	0.0	6.207	0.085	0	0	0	126
PL.2234	PL.2086	ABC	336 MCM AC	7.09Y	118.1	0.00	6.91	22.18	4	454	127	96	0.01	0.0	6.234	0.027	0	0	0	122

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2235	PL.2234	ABC	336 MCM AC	7.08Y	118.1	0.01	6.92	22.18	4	454	127	96	0.02	0.0	6.281	0.046	6	2	2	122
PL.65772	PL.2235	ABC	336 MCM AC	7.08Y	118.1	0.01	6.93	21.90	4	448	126	96	0.01	0.0	6.316	0.035	0	0	0	120
PL.65773	PL.65772	ABC	336 MCM AC	7.08Y	118.1	0.00	6.93	21.90	4	448	126	96	0.01	0.0	6.332	0.016	7	2	1	120
PL.2238	PL.65773	ABC	336 MCM AC	7.08Y	118.1	0.01	6.94	21.54	4	441	124	96	0.02	0.0	6.394	0.062	4	1	3	119
PL.2236	PL.2238	ABC	336 MCM AC	7.08Y	118.0	0.02	6.96	21.35	4	437	122	96	0.04	0.0	6.504	0.110	0	0	0	116
PL.2239	PL.2236	ABC	336 MCM AC	7.08Y	118.0	0.01	6.97	21.18	4	433	121	96	0.02	0.0	6.560	0.056	15	4	3	114
PL.2240	PL.2239	ABC	336 MCM AC	7.08Y	118.0	0.01	6.97	20.45	4	418	117	96	0.01	0.0	6.601	0.041	9	2	5	111
PL.2241	PL.2240	ABC	336 MCM AC	7.08Y	118.0	0.02	6.99	20.01	4	409	115	96	0.04	0.0	6.706	0.105	2	1	1	106
PL.2074	PL.2241	ABC	336 MCM AC	7.08Y	118.0	0.00	6.99	18.93	4	387	108	96	0.01	0.0	6.741	0.034	0	0	0	102
PL.2564	PL.2074	ABC	336 MCM AC	7.08Y	118.0	0.00	7.00	18.93	4	387	108	96	0.01	0.0	6.770	0.029	0	0	0	102
PD.355	PL.2564	ABC	50L	7.08Y	118.0	0.00	7.00	18.93	38	387	108	96	0.00	0.0	6.770	0.029	0	0	0	102
L PL.2565	PD.355	ABC	336 MCM AC	7.08Y	118.0	0.00	7.00	18.93	4	387	108	96	0.01	0.0	6.800	0.030	0	0	0	102 L
L PL.2512	PL.2565	C	#4 ACSR	7.08Y	118.0	0.00	7.00	11.13	9	76	21	96	0.00	0.0	6.805	0.004	0	0	0	17 L
L PD.326	PL.2512	C	25T	7.08Y	118.0	0.00	7.00	11.13	0	76	21	96	0.00	0.0	6.805	0.004	0	0	0	17 L
L PL.2513	PD.326	C	#4 ACSR	7.08Y	118.0	0.02	7.02	11.13	9	76	21	96	0.01	0.0	6.849	0.044	19	5	3	17 L
L PL.1710	PL.2513	C	#4 ACSR	7.08Y	117.9	0.06	7.08	8.39	6	57	16	96	0.03	0.0	7.001	0.152	0	0	0	14 L
L PL.1715	PL.1710	C	#4 ACSR	7.07Y	117.9	0.06	7.14	8.39	6	57	16	96	0.02	0.0	7.159	0.158	6	2	2	14 L
L PL.1718	PL.1715	C	8 A (CWC)	7.07Y	117.8	0.05	7.18	7.45	7	51	14	96	0.02	0.0	7.259	0.100	7	2	3	12 L
L PL.1721	PL.1718	C	#4 ACSR	7.07Y	117.8	0.02	7.20	6.35	5	43	12	96	0.01	0.0	7.324	0.065	0	0	0	9 L
L PL.1720	PL.1721	C	#4 ACSR	7.07Y	117.8	0.02	7.22	6.35	5	43	12	96	0.00	0.0	7.388	0.063	13	4	3	9 L
L PL.1723	PL.1720	C	#4 ACSR	7.07Y	117.8	0.01	7.22	4.47	3	30	8	97	0.00	0.0	7.422	0.034	5	1	1	6 L
L PL.1724	PL.1723	C	#4 ACSR	7.07Y	117.8	0.01	7.23	3.70	3	25	7	96	0.00	0.0	7.455	0.033	0	0	0	5 L
L PL.1725	PL.1724	C	#4 ACSR	7.07Y	117.8	0.00	7.23	3.70	3	25	7	96	0.00	0.0	7.476	0.022	0	0	0	5 L
L PL.2514	PL.1725	C	#4 ACSR	7.07Y	117.8	0.00	7.23	2.28	2	16	4	97	0.00	0.0	7.481	0.005	0	0	0	3 L
L PD.327	PL.2514	C	15T	7.07Y	117.8	0.00	7.23	2.28	0	16	4	97	0.00	0.0	7.481	0.005	0	0	0	3 L
L PL.2515	PD.327	C	#4 ACSR	7.07Y	117.8	0.01	7.24	2.28	2	16	4	97	0.00	0.0	7.556	0.075	0	0	0	3 L
L PL.1727	PL.2515	C	#4 ACSR	7.07Y	117.8	0.00	7.24	0.52	0	4	1	97	0.00	0.0	7.573	0.017	4	1	1	1 L
L PL.1728	PL.2515	C	#4 ACSR	7.07Y	117.8	0.01	7.25	1.76	1	12	3	97	0.00	0.0	7.672	0.116	0	0	0	2 L
L PL.1730	PL.1728	C	#4 ACSR	7.07Y	117.8	0.00	7.25	0.00	0	0	0	100	0.00	0.0	7.706	0.034	0	0	0	0 L
L PL.1731	PL.1728	C	#4 ACSR	7.06Y	117.7	0.01	7.26	1.76	1	12	3	97	0.00	0.0	7.795	0.123	0	0	0	2 L
L PL.1732	PL.1731	C	#4 ACSR	7.06Y	117.7	0.01	7.27	1.76	1	12	3	97	0.00	0.0	7.935	0.140	0	0	0	2 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.1734	PL.1732	C	#4 ACSR	7.06Y	117.7	0.00	7.27	1.33	1	9	3	95	0.00	0.0	7.989	0.054	9	3	1	1 L
L PL.1736	PL.1732	C	#2 ACSR	7.06Y	117.7	0.00	7.27	0.43	0	3	1	95	0.00	0.0	8.038	0.103	0	0	0	1 L
L PL.1737	PL.1736	C	#2 ACSR	7.06Y	117.7	0.00	7.27	0.43	0	3	1	95	0.00	0.0	8.181	0.143	0	0	0	1 L
L PL.1738	PL.1737	C	#1/0 ACSR	7.06Y	117.7	0.00	7.27	0.43	0	3	1	95	0.00	0.0	8.267	0.086	3	1	1	1 L
L PL.1726	PL.1725	C	#4 ACSR	7.07Y	117.8	0.00	7.23	1.42	1	10	3	96	0.00	0.0	7.492	0.016	10	3	2	2 L
L PL.2073	PL.2565	ABC	336 MCM AC	7.08Y	118.0	0.01	7.01	15.22	3	311	87	96	0.01	0.0	6.863	0.063	0	0	0	85 L
L PL.2072	PL.2073	ABC	336 MCM AC	7.08Y	118.0	0.02	7.03	14.62	3	299	84	96	0.03	0.0	7.018	0.155	0	0	0	82 L
L PL.65775	PL.2072	ABC	336 MCM AC	7.08Y	118.0	0.01	7.03	14.62	3	299	84	96	0.01	0.0	7.091	0.072	0	0	0	82 L
L PL.65777	PL.65775	C	#1/0 ACSR	7.08Y	118.0	0.00	7.03	0.00	0	0	0	100	0.00	0.0	7.136	0.046	0	0	0	0 L
L PD.9594	PL.65777	C	15T	7.08Y	118.0	0.00	7.03	0.00	0	0	0	100	0.00	0.0	7.136	0.046	0	0	0	0 L
L PL.65778	PD.9594	C	#1/0 ACSR	7.08Y	118.0	0.00	7.03	0.00	0	0	0	100	0.00	0.0	7.274	0.138	0	0	0	0 L
L PL.65776	PL.65775	ABC	336 MCM AC	7.08Y	118.0	0.01	7.04	14.62	3	299	84	96	0.01	0.0	7.147	0.056	0	0	0	82 L
L PL.2435	PL.65776	ABC	336 MCM AC	7.08Y	118.0	0.00	7.04	14.62	3	299	84	96	0.00	0.0	7.151	0.004	0	0	0	82 L
L PL.2242	PL.2435	ABC	336 MCM AC	7.08Y	118.0	0.01	7.05	14.28	3	292	82	96	0.01	0.0	7.214	0.064	2	1	1	79 L
L PL.2243	PL.2242	ABC	336 MCM AC	7.08Y	117.9	0.00	7.05	14.17	3	290	81	96	0.01	0.0	7.261	0.046	0	0	2	78 L
L PL.1740	PL.2243	ABC	336 MCM AC	7.08Y	117.9	0.01	7.06	14.17	3	290	81	96	0.01	0.0	7.318	0.057	0	0	1	76 L
L PL.2070	PL.1740	ABC	336 MCM AC	7.08Y	117.9	0.00	7.06	14.17	3	290	81	96	0.01	0.0	7.362	0.044	20	6	6	75 L
L PL.2071	PL.2070	ABC	336 MCM AC	7.08Y	117.9	0.01	7.07	9.39	2	192	54	96	0.01	0.0	7.440	0.078	32	9	5	54 L
L PL.2440	PL.2071	A	8 A (CWC)	7.08Y	117.9	0.00	7.07	5.76	6	39	11	96	0.00	0.0	7.445	0.005	0	0	0	10 L
L PD.289	PL.2440	A	25T	7.08Y	117.9	0.00	7.07	5.76	0	39	11	96	0.00	0.0	7.445	0.005	0	0	0	10 L
L PL.2441	PD.289	A	8 A (CWC)	7.08Y	117.9	0.00	7.07	5.76	6	39	11	96	0.00	0.0	7.453	0.009	0	0	0	10 L
L PL.1754	PL.2441	A	8 A (CWC)	7.08Y	117.9	0.01	7.08	5.76	6	39	11	96	0.00	0.0	7.473	0.019	14	4	5	10 L
L PL.1755	PL.1754	A	8 A (CWC)	7.07Y	117.9	0.01	7.08	3.70	4	25	7	96	0.00	0.0	7.499	0.027	10	3	2	5 L
L PL.1756	PL.1755	A	#2 ACSR	7.07Y	117.9	0.00	7.08	2.26	1	15	4	97	0.00	0.0	7.529	0.030	15	4	3	3 L
L PL.2069	PL.2071	ABC	336 MCM AC	7.08Y	117.9	0.00	7.07	5.91	1	121	34	96	0.00	0.0	7.523	0.083	0	0	0	39 L
L PL.2244	PL.2069	ABC	336 MCM AC	7.08Y	117.9	0.00	7.07	5.22	1	107	30	96	0.00	0.0	7.568	0.045	1	0	1	34 L
L PL.2245	PL.2244	ABC	336 MCM AC	7.08Y	117.9	0.00	7.07	5.16	1	105	29	96	0.00	0.0	7.612	0.044	5	1	2	33 L
L PL.2516	PL.2245	C	#4 ACSR	7.08Y	117.9	0.00	7.07	0.30	0	2	1	89	0.00	0.0	7.617	0.004	0	0	0	1 L
L PD.328	PL.2516	C	25T	7.08Y	117.9	0.00	7.07	0.30	0	2	1	89	0.00	0.0	7.617	0.004	0	0	0	1 L
L PL.2517	PD.328	C	#4 ACSR	7.08Y	117.9	0.00	7.07	0.30	0	2	1	89	0.00	0.0	7.654	0.038	2	1	1	1 L
L PL.1757	PL.2245	ABC	336 MCM AC	7.08Y	117.9	0.00	7.08	4.82	1	99	28	96	0.00	0.0	7.682	0.070	4	1	3	30 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.1758	PL.1757	ABC	336 MCM AC	7.08Y	117.9	0.00	7.08	4.63	1	95	26	96	0.00	0.0	7.733	0.051	0	0	0	27 L
L PL.1759	PL.1758	ABC	336 MCM AC	7.08Y	117.9	0.00	7.08	4.63	1	95	26	96	0.00	0.0	7.795	0.062	0	0	0	27 L
L PL.2520	PL.1759	C	#4 ACSR	7.08Y	117.9	0.00	7.08	0.36	0	2	1	89	0.00	0.0	7.799	0.005	0	0	0	1 L
L PD.330	PL.2520	C	25T	7.08Y	117.9	0.00	7.08	0.36	0	2	1	89	0.00	0.0	7.799	0.005	0	0	0	1 L
L PL.2521	PD.330	C	#4 ACSR	7.08Y	117.9	0.00	7.08	0.36	0	2	1	89	0.00	0.0	7.845	0.045	2	1	1	1 L
L PL.1761	PL.1759	ABC	336 MCM AC	7.08Y	117.9	0.00	7.08	4.51	1	92	26	96	0.00	0.0	7.870	0.075	0	0	0	26 L
L PL.1762	PL.1761	ABC	336 MCM AC	7.07Y	117.9	0.00	7.09	4.51	1	92	26	96	0.00	0.0	7.967	0.097	0	0	0	26 L
L PL.1764	PL.1762	ABC	336 MCM AC	7.07Y	117.9	0.00	7.09	4.51	1	92	26	96	0.00	0.0	8.072	0.105	0	0	1	26 L
L PL.1768	PL.1764	ABC	336 MCM AC	7.07Y	117.9	0.01	7.10	4.51	1	92	26	96	0.00	0.0	8.244	0.172	0	0	0	25 L
L PL.1769	PL.1768	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	4.27	1	87	24	96	0.00	0.0	8.293	0.049	0	0	0	23 L
L PL.1770	PL.1769	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	2.15	0	44	12	96	0.00	0.0	8.367	0.074	0	0	0	13 L
L PL.2064	PL.1770	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.58	0	32	9	96	0.00	0.0	8.420	0.053	0	0	0	10 L
L PL.2065	PL.2064	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	8.529	0.110	0	0	0	6 L
L PL.2016	PL.2065	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	8.628	0.099	0	0	0	6 L
L PL.2017	PL.2016	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	8.725	0.097	0	0	0	6 L
L PL.2018	PL.2017	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	8.827	0.102	0	0	0	6 L
L PL.2019	PL.2018	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	8.909	0.082	0	0	0	6 L
L PL.2020	PL.2019	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	9.022	0.112	0	0	0	6 L
L PL.2249	PL.2020	ABC	336 MCM AC	7.07Y	117.9	0.00	7.10	1.07	0	22	6	96	0.00	0.0	9.147	0.126	5	1	1	6 L
L PL.2250	PL.2249	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.84	0	17	5	96	0.00	0.0	9.218	0.071	0	0	0	5 L
L PL.2058	PL.2250	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.35	0	7	2	96	0.00	0.0	9.274	0.057	0	0	0	4 L
L PL.2251	PL.2058	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.27	0	5	2	93	0.00	0.0	9.338	0.063	0	0	0	2 L
L PL.2252	PL.2251	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.27	0	5	2	93	0.00	0.0	9.520	0.182	2	1	1	2 L
L PL.2253	PL.2252	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.18	0	4	1	97	0.00	0.0	9.626	0.106	0	0	0	1 L
L PL.2264	PL.2253	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.18	0	4	1	97	0.00	0.0	9.740	0.114	4	1	1	1 L
L PL.2265	PL.2264	ABC	336 MCM AC	7.07Y	117.9	0.00	7.11	0.00	0	0	0	100	0.00	0.0	9.800	0.061	0	0	0	0 L
L PD.205-A	PL.2265	ABC	Open	7.07Y	117.9	0.00	7.11	0.00	0	0	0	100	0.00	0.0	9.800	0.061	0	0	0	0 L
L PL.2452	PL.2058	C	#4 ACSR	7.07Y	117.9	0.00	7.11	0.26	0	2	0	100	0.00	0.0	9.279	0.005	0	0	0	2 L
L PD.295	PL.2452	C	20T	7.07Y	117.9	0.00	7.11	0.26	0	2	0	100	0.00	0.0	9.279	0.005	0	0	0	2 L
L PL.2453	PD.295	C	#4 ACSR	7.07Y	117.9	0.00	7.11	0.26	0	2	0	100	0.00	0.0	9.299	0.020	2	0	2	2 L
L PL.2450	PL.2250	A	#2 ACSR	7.07Y	117.9	0.00	7.11	1.47	1	10	3	96	0.00	0.0	9.222	0.005	0	0	0	1 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PD.294	PL.2450	A	20T	7.07Y	117.9	0.00	7.11	1.47	0	10	3	96	0.00	0.0	9.222	0.005	0	0	0	1 L
L PL.2451	PD.294	A	#2 ACSR	7.07Y	117.9	0.00	7.11	1.47	1	10	3	96	0.00	0.0	9.242	0.020	10	3	1	1 L
L PL.2448	PL.2064	C	#2 ACSR	7.07Y	117.9	0.00	7.10	1.53	1	10	3	96	0.00	0.0	8.425	0.005	0	0	0	4 L
L PD.293	PL.2448	C	20T	7.07Y	117.9	0.00	7.10	1.53	0	10	3	96	0.00	0.0	8.425	0.005	0	0	0	4 L
L PL.2449	PD.293	C	#2 ACSR	7.07Y	117.9	0.00	7.10	1.53	1	10	3	96	0.00	0.0	8.443	0.018	10	3	4	4 L
L PL.2446	PL.1770	A	#2 ACSR	7.07Y	117.9	0.00	7.10	1.71	1	12	3	97	0.00	0.0	8.371	0.004	0	0	0	3 L
L PD.292	PL.2446	A	20T	7.07Y	117.9	0.00	7.10	1.71	0	12	3	97	0.00	0.0	8.371	0.004	0	0	0	3 L
L PL.2447	PD.292	A	#2 ACSR	7.07Y	117.9	0.00	7.10	1.71	1	12	3	97	0.00	0.0	8.384	0.013	2	1	1	3 L
L PL.4519	PL.2447	A	#1/0 ACSR	7.07Y	117.9	0.00	7.10	1.40	1	10	3	96	0.00	0.0	8.408	0.024	10	3	2	2 L
L PL.2444	PL.1769	A	#2 ACSR	7.07Y	117.9	0.00	7.10	6.35	4	43	12	96	0.00	0.0	8.298	0.005	0	0	0	10 L
L PD.291	PL.2444	A	20T	7.07Y	117.9	0.00	7.10	6.35	0	43	12	96	0.00	0.0	8.298	0.005	0	0	0	10 L
L PL.2445	PD.291	A	#2 ACSR	7.07Y	117.9	0.00	7.10	6.35	4	43	12	96	0.00	0.0	8.320	0.023	15	4	3	10 L
L PL.2246	PL.2445	A	#2 ACSR	7.07Y	117.9	0.00	7.11	4.22	2	29	8	96	0.00	0.0	8.354	0.034	3	1	1	7 L
L PL.2247	PL.2246	A	8 A (CWC)	7.07Y	117.9	0.00	7.11	3.84	4	26	7	97	0.00	0.0	8.373	0.018	2	0	1	6 L
L PL.2248	PL.2247	A	8 A (CWC)	7.07Y	117.9	0.01	7.12	3.61	4	25	7	96	0.00	0.0	8.410	0.038	5	1	1	5 L
L PL.1772	PL.2248	A	#4 ACSR	7.07Y	117.9	0.00	7.12	1.40	1	10	3	96	0.00	0.0	8.466	0.055	10	3	1	1 L
L PL.1771	PL.2248	A	8 A (CWC)	7.07Y	117.9	0.01	7.13	1.42	1	10	3	96	0.00	0.0	8.516	0.106	0	0	0	3 L
L PL.1774	PL.1771	A	8 A (CWC)	7.07Y	117.9	0.00	7.13	1.42	1	10	3	96	0.00	0.0	8.549	0.033	10	3	3	3 L
L PL.2442	PL.1768	A	#2 ACSR	7.07Y	117.9	0.00	7.10	0.72	0	5	1	98	0.00	0.0	8.249	0.005	0	0	0	2 L
L PD.290	PL.2442	A	25T	7.07Y	117.9	0.00	7.10	0.72	0	5	1	98	0.00	0.0	8.249	0.005	0	0	0	2 L
L PL.2443	PD.290	A	#2 ACSR	7.07Y	117.9	0.00	7.10	0.72	0	5	1	98	0.00	0.0	8.275	0.026	5	1	2	2 L
L PL.2438	PL.2069	A	#2 ACSR	7.08Y	117.9	0.00	7.07	2.06	1	14	4	96	0.00	0.0	7.527	0.005	0	0	0	5 L
L PD.288	PL.2438	A	25T	7.08Y	117.9	0.00	7.07	2.06	0	14	4	96	0.00	0.0	7.527	0.005	0	0	0	5 L
L PL.2439	PD.288	A	#2 ACSR	7.08Y	117.9	0.00	7.07	2.06	1	14	4	96	0.00	0.0	7.534	0.007	14	4	5	5 L
L PL.2436	PL.2070	A	#4 ACSR	7.08Y	117.9	0.00	7.06	11.36	9	77	22	96	0.00	0.0	7.366	0.005	0	0	0	15 L
L PD.287	PL.2436	A	25T	7.08Y	117.9	0.00	7.06	11.36	0	77	22	96	0.00	0.0	7.366	0.005	0	0	0	15 L
L PL.2437	PD.287	A	#4 ACSR	7.07Y	117.9	0.02	7.08	11.36	9	77	22	96	0.01	0.0	7.412	0.046	24	7	5	15 L
L PL.1741	PL.2437	A	#4 ACSR	7.07Y	117.9	0.02	7.10	7.85	6	53	15	96	0.01	0.0	7.476	0.064	12	3	2	10 L
L PL.1742	PL.1741	A	#4 ACSR	7.07Y	117.9	0.02	7.13	6.11	5	42	12	96	0.01	0.0	7.567	0.091	4	1	1	8 L
L PL.1743	PL.1742	A	#4 ACSR	7.07Y	117.9	0.02	7.15	5.50	4	37	10	97	0.01	0.0	7.661	0.094	5	1	2	7 L
L PL.1744	PL.1743	A	#4 ACSR	7.07Y	117.8	0.01	7.16	4.78	4	33	9	96	0.00	0.0	7.726	0.065	8	2	1	5 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.1746	PL.1744	A	#4 ACSR	7.07Y	117.8	0.01	7.17	3.65	3	25	7	96	0.00	0.0	7.758	0.033	2	1	1	4 L
L PL.1747	PL.1746	A	#4 ACSR	7.07Y	117.8	0.01	7.18	2.91	2	20	6	96	0.00	0.0	7.833	0.075	0	0	0	2 L
L PL.1751	PL.1747	A	#4 ACSR	7.07Y	117.8	0.01	7.18	1.32	1	9	3	95	0.00	0.0	7.930	0.097	0	0	0	1 L
L PL.1752	PL.1751	A	#4 ACSR	7.07Y	117.8	0.00	7.18	1.32	1	9	3	95	0.00	0.0	7.989	0.059	9	3	1	1 L
L PL.1750	PL.1747	A	#4 ACSR	7.07Y	117.8	0.00	7.18	1.59	1	11	3	96	0.00	0.0	7.873	0.039	11	3	1	1 L
L PL.1748	PL.1746	A	#4 ACSR	7.07Y	117.8	0.00	7.17	0.40	0	3	1	95	0.00	0.0	7.819	0.061	3	1	1	1 L
L PL.2432	PL.2435	C	#4 ACSR	7.08Y	118.0	0.00	7.04	1.03	1	7	2	96	0.00	0.0	7.155	0.005	0	0	0	3 L
L PD.286	PL.2432	C	25T	7.08Y	118.0	0.00	7.04	1.03	0	7	2	96	0.00	0.0	7.155	0.005	0	0	0	3 L
L PL.2433	PD.286	C	#4 ACSR	7.08Y	118.0	0.00	7.04	1.03	1	7	2	96	0.00	0.0	7.211	0.056	7	2	3	3 L
L PL.2430	PL.2073	C	#4 ACSR	7.08Y	118.0	0.00	7.01	1.78	1	12	3	97	0.00	0.0	6.868	0.004	0	0	0	3 L
L PD.285	PL.2430	C	25T	7.08Y	118.0	0.00	7.01	1.78	0	12	3	97	0.00	0.0	6.868	0.004	0	0	0	3 L
L PL.2431	PD.285	C	#4 ACSR	7.08Y	118.0	0.00	7.01	1.78	1	12	3	97	0.00	0.0	6.899	0.031	3	1	2	3 L
L PL.1711	PL.2431	C	#4 ACSR	7.08Y	118.0	0.00	7.01	1.29	1	9	2	98	0.00	0.0	6.947	0.048	9	2	1	1 L
PL.2510	PL.2241	C	#4 ACSR	7.08Y	118.0	0.00	6.99	2.90	2	20	6	96	0.00	0.0	6.711	0.005	0	0	0	3
PD.325	PL.2510	C	40QA	7.08Y	118.0	0.00	6.99	2.90	7	20	6	96	0.00	0.0	6.711	0.005	0	0	0	3
PL.2511	PD.325	C	#4 ACSR	7.08Y	118.0	0.00	6.99	2.90	2	20	6	96	0.00	0.0	6.732	0.021	0	0	0	3
PL.1708	PL.2511	C	#4 ACSR	7.08Y	118.0	0.00	6.99	2.90	2	20	6	96	0.00	0.0	6.773	0.040	20	6	3	3
PL.1709	PL.1708	C	#4 ACSR	7.08Y	118.0	0.00	6.99	0.00	0	0	0	100	0.00	0.0	6.811	0.038	0	0	0	0
PL.2428	PL.2236	C	#4 ACSR	7.08Y	118.0	0.00	6.96	0.52	0	4	1	97	0.00	0.0	6.508	0.005	0	0	0	2
PD.284	PL.2428	C	40QA	7.08Y	118.0	0.00	6.96	0.52	1	4	1	97	0.00	0.0	6.508	0.005	0	0	0	2
PL.2429	PD.284	C	#4 ACSR	7.08Y	118.0	0.00	6.96	0.52	0	4	1	97	0.00	0.0	6.529	0.021	4	1	2	2
PL.1707	PL.2086	C	#4 ACSR	7.09Y	118.1	0.00	6.91	2.88	2	20	5	97	0.00	0.0	6.231	0.024	0	0	0	4
PD.283	PL.1707	C	15T	7.09Y	118.1	0.00	6.91	2.88	0	20	5	97	0.00	0.0	6.231	0.024	0	0	0	4
PL.2426	PD.283	C	8 A (CWC)	7.09Y	118.1	0.00	6.91	2.88	3	20	5	97	0.00	0.0	6.233	0.003	9	2	2	4
PL.2427	PL.2426	C	8 A (CWC)	7.09Y	118.1	0.00	6.92	1.61	2	11	3	96	0.00	0.0	6.278	0.044	11	3	2	2
PL.2506	PL.2226	A	#4 ACSR	7.09Y	118.2	0.00	6.80	7.11	5	49	14	96	0.00	0.0	5.578	0.005	0	0	0	15
PD.324	PL.2506	A	40QA	7.09Y	118.2	0.00	6.80	7.11	18	49	14	96	0.00	0.0	5.578	0.005	0	0	0	15
PL.2507	PD.324	A	#4 ACSR	7.09Y	118.2	0.00	6.80	7.11	5	49	14	96	0.00	0.0	5.594	0.016	13	4	3	15
PL.2230	PL.2507	A	8 A (CWC)	7.09Y	118.2	0.01	6.82	5.23	5	36	10	96	0.00	0.0	5.638	0.044	14	4	5	12
PL.2231	PL.2230	A	8 A (CWC)	7.09Y	118.2	0.01	6.82	3.12	3	21	6	96	0.00	0.0	5.672	0.034	5	1	2	7
PL.1695	PL.2231	A	8 A (CWC)	7.09Y	118.2	0.00	6.83	2.35	2	16	4	97	0.00	0.0	5.703	0.031	4	1	2	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1696	PL.1695	A	8 A (CWC)	7.09Y	118.2	0.00	6.83	1.70	2	12	3	97	0.00	0.0	5.731	0.028	8	2	1	3
PL.1697	PL.1696	A	8 A (CWC)	7.09Y	118.2	0.00	6.83	0.54	1	4	1	97	0.00	0.0	5.769	0.037	0	0	0	2
PL.1698	PL.1697	A	8 A (CWC)	7.09Y	118.2	0.00	6.83	0.54	1	4	1	97	0.00	0.0	5.810	0.042	4	1	2	2
PL.2416	PL.2103	A	#4 ACSR	7.10Y	118.3	0.00	6.73	1.35	1	9	3	95	0.00	0.0	5.318	0.005	0	0	0	2
PD.278	PL.2416	A	40QA	7.10Y	118.3	0.00	6.73	1.35	3	9	3	95	0.00	0.0	5.318	0.005	0	0	0	2
PL.2417	PD.278	A	#4 ACSR	7.10Y	118.3	0.00	6.73	1.35	1	9	3	95	0.00	0.0	5.339	0.021	9	3	2	2
PL.2500	PL.2104	C	#4 ACSR	7.10Y	118.3	0.00	6.72	3.44	3	24	7	96	0.00	0.0	5.255	0.005	0	0	0	3
PD.321	PL.2500	C	40QA	7.10Y	118.3	0.00	6.72	3.44	9	24	7	96	0.00	0.0	5.255	0.005	0	0	0	3
PL.2501	PD.321	C	#4 ACSR	7.10Y	118.3	0.00	6.72	3.44	3	24	7	96	0.00	0.0	5.274	0.020	24	7	3	3
PL.2464	PL.2107	A	#4 ACSR	7.10Y	118.3	0.00	6.70	0.00	0	0	0	100	0.00	0.0	5.193	0.005	0	0	0	0
PD.303	PL.2464	A	40QA	7.10Y	118.3	0.00	6.70	0.00	0	0	0	100	0.00	0.0	5.193	0.005	0	0	0	0
PL.2465	PD.303	A	#4 ACSR	7.10Y	118.3	0.00	6.70	0.00	0	0	0	100	0.00	0.0	5.204	0.011	0	0	0	0
PL.1655	PL.2107	B	8 A (CWC)	7.09Y	118.2	0.11	6.81	28.65	29	196	55	96	0.17	0.1	5.246	0.057	10	3	4	57
PL.2556	PL.1655	B	8 A (CWC)	7.09Y	118.2	0.00	6.81	27.22	27	186	52	96	0.01	0.0	5.249	0.003	0	0	0	53
C PD.351	PL.2556	B	35H	7.09Y	118.2	0.00	6.81	27.22	78	186	52	96	0.00	0.0	5.249	0.003	0	0	0	53 C
PL.2557	PD.351	B	8 A (CWC)	7.08Y	118.1	0.13	6.94	27.22	27	186	52	96	0.20	0.1	5.323	0.075	10	3	3	53
PL.1657	PL.2557	B	#4 ACSR	7.08Y	118.1	0.00	6.94	1.81	1	12	3	97	0.00	0.0	5.343	0.020	12	3	2	2
L PL.1656	PL.2557	B	8 A (CWC)	7.08Y	117.9	0.13	7.08	23.87	24	163	46	96	0.17	0.1	5.412	0.088	20	6	5	48 L
L PL.1658	PL.1656	B	8 A (CWC)	7.06Y	117.7	0.22	7.29	20.96	21	143	40	96	0.25	0.2	5.569	0.158	4	1	1	43 L
L PL.1660	PL.1658	B	8 A (CWC)	7.06Y	117.6	0.11	7.40	20.31	20	138	39	96	0.13	0.1	5.654	0.085	8	2	3	42 L
L PL.2260	PL.1660	B	8 A (CWC)	7.05Y	117.5	0.08	7.49	19.16	19	130	36	96	0.09	0.1	5.720	0.066	0	0	1	39 L
L PL.2261	PL.2260	B	8 A (CWC)	7.05Y	117.5	0.06	7.55	19.16	19	130	36	96	0.06	0.0	5.766	0.046	10	3	4	38 L
L PL.1661	PL.2261	B	8 A (CWC)	7.04Y	117.4	0.05	7.60	17.74	18	120	34	96	0.05	0.0	5.811	0.045	3	1	2	34 L
L PL.1663	PL.1661	B	8 A (CWC)	7.04Y	117.4	0.04	7.64	15.80	16	107	30	96	0.04	0.0	5.850	0.039	0	0	1	30 L
L PL.1664	PL.1663	B	8 A (CWC)	7.04Y	117.3	0.02	7.66	15.80	16	107	30	96	0.01	0.0	5.867	0.017	12	3	3	29 L
L PL.1665	PL.1664	B	#4 ACSR	7.04Y	117.3	0.04	7.70	14.05	11	95	27	96	0.03	0.0	5.942	0.075	12	3	3	26 L
L PL.1667	PL.1665	B	#4 ACSR	7.04Y	117.3	0.02	7.72	12.06	9	82	23	96	0.01	0.0	5.976	0.035	0	0	1	21 L
L PL.1669	PL.1667	B	#4 ACSR	7.04Y	117.3	0.02	7.74	12.05	9	82	23	96	0.01	0.0	6.010	0.034	1	0	1	20 L
L PL.1670	PL.1669	B	#4 ACSR	7.03Y	117.2	0.02	7.75	11.91	9	81	23	96	0.01	0.0	6.040	0.030	6	2	2	19 L
L PL.1671	PL.1670	B	8 A (CWC)	7.03Y	117.2	0.09	7.84	11.01	11	75	21	96	0.06	0.1	6.164	0.124	0	0	1	17 L
L PL.1673	PL.1671	B	#4 ACSR	7.03Y	117.2	0.00	7.84	0.43	0	3	1	95	0.00	0.0	6.211	0.047	3	1	1	1 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.1674	PL.1671	B	8 A (CWC)	7.03Y	117.1	0.05	7.89	10.58	11	72	20	96	0.03	0.0	6.233	0.069	0	0	0	15 L
L PL.1675	PL.1674	B	8 A (CWC)	7.02Y	117.1	0.04	7.93	10.58	11	72	20	96	0.03	0.0	6.294	0.061	0	0	0	15 L
L PL.1676	PL.1675	B	8 A (CWC)	7.02Y	117.0	0.06	8.00	10.58	11	72	20	96	0.03	0.0	6.391	0.097	14	4	3	15 L
L PL.1677	PL.1676	B	8 A (CWC)	7.02Y	117.0	0.04	8.04	8.48	8	57	16	96	0.02	0.0	6.468	0.076	12	3	2	12 L
L PL.1678	PL.1677	B	8 A (CWC)	7.02Y	116.9	0.03	8.06	6.64	7	45	13	96	0.01	0.0	6.528	0.060	4	1	1	10 L
L PL.1679	PL.1678	B	8 A (CWC)	7.01Y	116.9	0.03	8.09	6.01	6	41	11	97	0.01	0.0	6.611	0.083	3	1	1	9 L
L PL.1680	PL.1679	B	#4 ACSR	7.01Y	116.9	0.00	8.10	2.70	2	18	5	96	0.00	0.0	6.644	0.033	11	3	2	3 L
L PL.1681	PL.1680	B	#2 ACSR	7.01Y	116.9	0.00	8.10	1.13	1	8	2	97	0.00	0.0	6.670	0.026	0	0	0	1 L
L PL.1682	PL.1681	B	#2 ACSR	7.01Y	116.9	0.00	8.10	1.13	1	8	2	97	0.00	0.0	6.734	0.064	8	2	1	1 L
L PL.1683	PL.1679	B	#2 ACSR	7.01Y	116.9	0.00	8.09	0.00	0	0	0	100	0.00	0.0	6.675	0.064	0	0	0	1 L
L PL.1685	PL.1683	B	#2 ACSR	7.01Y	116.9	0.00	8.09	0.00	0	0	0	100	0.00	0.0	6.730	0.055	0	0	1	1 L
L PL.1684	PL.1679	B	8 A (CWC)	7.01Y	116.9	0.02	8.11	2.95	3	20	6	96	0.00	0.0	6.705	0.095	0	0	0	4 L
L PL.2133	PL.1684	B	8 A (CWC)	7.01Y	116.9	0.01	8.12	2.95	3	20	6	96	0.00	0.0	6.731	0.026	0	0	0	4 L
L PL.1687	PL.2133	B	#4 ACSR	7.01Y	116.9	0.00	8.12	0.71	1	5	1	98	0.00	0.0	6.759	0.028	0	0	0	1 L
L PL.1686	PL.1687	B	#4 ACSR	7.01Y	116.9	0.00	8.12	0.71	1	5	1	98	0.00	0.0	6.801	0.042	5	1	1	1 L
L PL.2227	PL.2133	B	8 A (CWC)	7.01Y	116.9	0.01	8.12	2.23	2	15	4	97	0.00	0.0	6.819	0.088	15	4	3	3 L
L PL.2228	PL.2227	B	#2 ACSR	7.01Y	116.9	0.00	8.12	0.00	0	0	0	100	0.00	0.0	6.869	0.050	0	0	0	0 L
L PL.1668	PL.1665	B	#4 ACSR	7.04Y	117.3	0.00	7.70	0.19	0	1	0	100	0.00	0.0	5.974	0.032	1	0	2	2 L
L PL.1662	PL.1661	B	#4 ACSR	7.04Y	117.4	0.00	7.60	1.45	1	10	3	96	0.00	0.0	5.825	0.014	10	3	2	2 L
PL.2454	PL.2255	C	#2 ACSR	7.10Y	118.4	0.00	6.63	1.47	1	10	3	96	0.00	0.0	5.009	0.005	0	0	0	3
PD.296	PL.2454	C	40QA	7.10Y	118.4	0.00	6.63	1.47	4	10	3	96	0.00	0.0	5.009	0.005	0	0	0	3
PL.2455	PD.296	C	#2 ACSR	7.10Y	118.4	0.00	6.63	1.47	1	10	3	96	0.00	0.0	5.045	0.036	10	3	3	3
PL.65771	PL.2254	C	#1/0 ACSR	7.10Y	118.4	0.00	6.61	0.00	0	0	0	100	0.00	0.0	4.978	0.030	0	0	0	0
PL.1646	PL.2105	C	#4 ACSR	7.11Y	118.4	0.00	6.57	1.06	1	7	2	96	0.00	0.0	4.839	0.005	0	0	0	7
PD.297	PL.1646	C	20T	7.11Y	118.4	0.00	6.57	1.06	0	7	2	96	0.00	0.0	4.839	0.005	0	0	0	7
PL.10178	PD.297	C	#4 ACSR	7.11Y	118.4	0.00	6.57	0.07	0	0	0	100	0.00	0.0	4.850	0.010	0	0	0	3
PL.21698	PL.10178	C	#4 ACSR	7.11Y	118.4	0.00	6.57	0.07	0	0	0	100	0.00	0.0	4.862	0.013	0	0	0	3
PL.21699	PL.21698	C	#4 ACSR	7.11Y	118.4	0.00	6.57	0.07	0	0	0	100	0.00	0.0	4.952	0.089	0	0	1	3
PL.1650	PL.21699	C	#2 ACSR	7.11Y	118.4	0.00	6.57	0.03	0	0	0	100	0.00	0.0	4.989	0.038	0	0	1	2
PL.1654	PL.1650	C	#2 ACSR	7.11Y	118.4	0.00	6.57	0.03	0	0	0	100	0.00	0.0	5.089	0.100	0	0	1	1
PL.2100	PD.297	C	#2 ACSR	7.11Y	118.4	0.00	6.57	0.99	1	7	2	96	0.00	0.0	4.853	0.013	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1653	PL.2100	C	#2 ACSR	7.11Y	118.4	0.00	6.57	0.99	1	7	2	96	0.00	0.0	4.862	0.009	1	0	1	4
PL.1652	PL.1653	C	#2 ACSR	7.11Y	118.4	0.00	6.57	0.83	0	6	2	95	0.00	0.0	4.908	0.046	6	2	3	3
PL.2458	PL.2114	C	#4 ACSR	7.11Y	118.5	0.00	6.46	0.92	1	6	2	95	0.00	0.0	4.548	0.005	0	0	0	3
PD.299	PL.2458	C	40QA	7.11Y	118.5	0.00	6.46	0.92	2	6	2	95	0.00	0.0	4.548	0.005	0	0	0	3
PL.2459	PD.299	C	#4 ACSR	7.11Y	118.5	0.00	6.47	0.92	1	6	2	95	0.00	0.0	4.588	0.039	6	2	3	3
PL.2460	PL.2117	C	#4 ACSR	7.11Y	118.6	0.00	6.45	1.03	1	7	2	96	0.00	0.0	4.496	0.004	0	0	0	3
PD.300	PL.2460	C	15T	7.11Y	118.6	0.00	6.45	1.03	0	7	2	96	0.00	0.0	4.496	0.004	0	0	0	3
PL.2461	PD.300	C	#4 ACSR	7.11Y	118.6	0.00	6.45	1.03	1	7	2	96	0.00	0.0	4.519	0.023	7	2	3	3
PL.2462	PL.2257	C	#4 ACSR	7.12Y	118.6	0.00	6.38	0.24	0	2	0	100	0.00	0.0	4.316	0.004	0	0	0	1
PD.301	PL.2462	C	40QA	7.12Y	118.6	0.00	6.38	0.24	1	2	0	100	0.00	0.0	4.316	0.004	0	0	0	1
PL.2463	PD.301	C	#4 ACSR	7.12Y	118.6	0.00	6.38	0.24	0	2	0	100	0.00	0.0	4.324	0.008	2	0	1	1
PL.1611	PL.2259	A	#4 ACSR	7.12Y	118.6	0.03	6.36	41.98	32	288	81	96	0.06	0.0	4.222	0.014	7	2	1	63
PL.1613	PL.1611	A	#4 ACSR	7.12Y	118.6	0.01	6.37	41.03	32	281	79	96	0.02	0.0	4.226	0.005	0	0	0	62
PD.302	PL.1613	A	30T	7.12Y	118.6	0.00	6.37	41.03	0	281	79	96	0.00	0.0	4.226	0.005	0	0	0	62
PL.2005	PD.302	A	#4 ACSR	7.11Y	118.5	0.12	6.49	39.62	30	272	76	96	0.24	0.1	4.295	0.069	19	5	3	58
PL.1616	PL.2005	A	#4 ACSR	7.11Y	118.4	0.09	6.58	32.07	25	220	61	96	0.15	0.1	4.357	0.062	1	0	1	51
PL.1620	PL.1616	A	#2 ACSR	7.11Y	118.4	0.00	6.58	2.58	1	18	5	96	0.00	0.0	4.370	0.013	18	5	2	2
PL.1612	PL.1616	A	#4 ACSR	7.11Y	118.4	0.00	6.58	1.10	1	8	2	97	0.00	0.0	4.406	0.049	8	2	3	3
PL.1621	PL.1616	A	#4 ACSR	7.10Y	118.4	0.03	6.61	28.19	22	193	54	96	0.05	0.0	4.382	0.025	4	1	1	45
PL.1622	PL.1621	A	#4 ACSR	7.10Y	118.4	0.04	6.65	27.55	21	188	53	96	0.06	0.0	4.414	0.033	3	1	1	44
PL.1623	PL.1622	A	#4 ACSR	7.10Y	118.3	0.05	6.70	27.06	21	185	52	96	0.08	0.0	4.460	0.046	9	3	3	43
PL.1624	PL.1623	A	#4 ACSR	7.10Y	118.3	0.01	6.71	5.65	4	39	11	96	0.00	0.0	4.504	0.043	12	3	4	12
PL.1644	PL.1624	A	#4 ACSR	7.10Y	118.3	0.01	6.72	3.95	3	27	8	96	0.00	0.0	4.547	0.044	10	3	4	8
PL.1645	PL.1644	A	#4 ACSR	7.10Y	118.3	0.00	6.72	2.45	2	17	5	96	0.00	0.0	4.568	0.021	17	5	4	4
PL.1625	PL.1623	A	#4 ACSR	7.10Y	118.3	0.00	6.71	2.58	2	18	5	96	0.00	0.0	4.518	0.058	18	5	3	3
PL.1626	PL.1623	A	#4 ACSR	7.09Y	118.2	0.06	6.76	17.52	13	120	33	96	0.06	0.0	4.535	0.075	0	0	0	25
PL.1628	PL.1626	A	#4 ACSR	7.09Y	118.2	0.00	6.76	0.58	0	4	1	97	0.00	0.0	4.570	0.034	4	1	2	2
PL.1627	PL.1626	A	#4 ACSR	7.09Y	118.2	0.01	6.77	16.93	13	116	32	96	0.01	0.0	4.552	0.017	0	0	0	23
PL.1629	PL.1627	A	#4 ACSR	7.09Y	118.2	0.03	6.80	16.93	13	116	32	96	0.02	0.0	4.589	0.037	10	3	3	23
PL.1630	PL.1629	A	#4 ACSR	7.09Y	118.2	0.03	6.83	14.86	11	101	28	96	0.02	0.0	4.635	0.046	0	0	0	19
PL.1632	PL.1630	A	#4 ACSR	7.09Y	118.1	0.02	6.85	14.86	11	101	28	96	0.02	0.0	4.670	0.036	7	2	2	19

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1633	PL.1632	A	#4 ACSR	7.09Y	118.1	0.03	6.88	13.80	11	94	26	96	0.02	0.0	4.720	0.050	3	1	1	17
PL.1634	PL.1633	A	#4 ACSR	7.09Y	118.1	0.02	6.90	13.33	10	91	25	96	0.01	0.0	4.757	0.037	5	1	4	16
PL.1635	PL.1634	A	#4 ACSR	7.08Y	118.1	0.03	6.93	12.61	10	86	24	96	0.02	0.0	4.808	0.051	10	3	1	12
PL.1636	PL.1635	A	#4 ACSR	7.08Y	118.1	0.01	6.94	11.09	9	76	21	96	0.01	0.0	4.836	0.028	25	7	3	11
PL.1637	PL.1636	A	#4 ACSR	7.08Y	118.0	0.02	6.96	7.49	6	51	14	96	0.01	0.0	4.887	0.051	8	2	2	8
PL.1638	PL.1637	A	#4 ACSR	7.08Y	118.0	0.02	6.97	6.28	5	43	12	96	0.01	0.0	4.944	0.057	0	0	0	6
PL.1639	PL.1638	A	#4 ACSR	7.08Y	118.0	0.00	6.98	4.29	3	29	8	96	0.00	0.0	4.978	0.034	18	5	2	4
PL.1641	PL.1639	A	#4 ACSR	7.08Y	118.0	0.00	6.98	1.59	1	11	3	96	0.00	0.0	5.029	0.052	9	2	1	2
PL.1642	PL.1641	A	#4 ACSR	7.08Y	118.0	0.00	6.98	0.28	0	2	1	89	0.00	0.0	5.064	0.034	2	1	1	1
PL.1643	PL.1642	A	#4 ACSR	7.08Y	118.0	0.00	6.98	0.00	0	0	0	100	0.00	0.0	5.121	0.057	0	0	0	0
PL.1640	PL.1638	A	#4 ACSR	7.08Y	118.0	0.00	6.98	1.99	2	14	4	96	0.00	0.0	4.989	0.046	14	4	2	2
PL.1631	PL.1629	A	#4 ACSR	7.09Y	118.2	0.00	6.80	0.55	0	4	1	97	0.00	0.0	4.667	0.078	4	1	1	1
PL.1617	PL.2005	A	#4 ACSR	7.11Y	118.5	0.01	6.50	4.77	4	33	9	96	0.00	0.0	4.375	0.080	15	4	2	4
PL.1619	PL.1617	A	#4 ACSR	7.11Y	118.5	0.00	6.50	1.38	1	9	3	95	0.00	0.0	4.416	0.041	9	3	1	1
PL.1618	PL.1617	A	#4 ACSR	7.11Y	118.5	0.00	6.50	1.19	1	8	2	97	0.00	0.0	4.394	0.019	8	2	1	1
PL.2118	PD.302	A	#4 ACSR	7.12Y	118.6	0.00	6.37	1.41	1	10	3	96	0.00	0.0	4.232	0.006	0	0	0	4
PL.1614	PL.2118	A	#4 ACSR	7.12Y	118.6	0.00	6.37	1.41	1	10	3	96	0.00	0.0	4.260	0.028	7	2	3	4
PL.1615	PL.1614	A	#4 ACSR	7.12Y	118.6	0.00	6.37	0.38	0	3	1	95	0.00	0.0	4.287	0.027	3	1	1	1
PL.2350	PL.2123	C	#4 ACSR	7.13Y	118.9	0.00	6.12	1.80	1	12	3	97	0.00	0.0	3.766	0.005	0	0	0	3
PD.248	PL.2350	C	40QA	7.13Y	118.9	0.00	6.12	1.80	4	12	3	97	0.00	0.0	3.766	0.005	0	0	0	3
PL.2351	PD.248	C	#4 ACSR	7.13Y	118.9	0.00	6.12	1.80	1	12	3	97	0.00	0.0	3.807	0.041	12	3	3	3
PL.2348	PL.2124	A	#2 ACSR	7.13Y	118.9	0.00	6.10	0.28	0	2	1	89	0.00	0.0	3.739	0.005	0	0	0	1
PD.247	PL.2348	A	40QA	7.13Y	118.9	0.00	6.10	0.28	1	2	1	89	0.00	0.0	3.739	0.005	0	0	0	1
PL.2349	PD.247	A	#2 ACSR	7.13Y	118.9	0.00	6.10	0.28	0	2	1	89	0.00	0.0	3.752	0.013	2	1	1	1
PL.2496	PL.2126	C	#2 ACSR	7.14Y	119.0	0.00	6.02	1.70	1	12	3	97	0.00	0.0	3.587	0.005	0	0	0	1
PD.319	PL.2496	C	40QA	7.14Y	119.0	0.00	6.02	1.70	4	12	3	97	0.00	0.0	3.587	0.005	0	0	0	1
PL.2497	PD.319	C	#2 ACSR	7.14Y	119.0	0.01	6.03	1.70	1	12	3	97	0.00	0.0	3.683	0.096	0	0	0	1
PL.1608	PL.2497	C	#2 ACSR	7.14Y	119.0	0.00	6.03	1.70	1	12	3	97	0.00	0.0	3.740	0.057	12	3	1	1
PL.2346	PL.2126	A	#2 ACSR	7.14Y	119.0	0.00	6.02	0.81	0	6	2	95	0.00	0.0	3.587	0.005	0	0	0	2
PD.246	PL.2346	A	40QA	7.14Y	119.0	0.00	6.02	0.81	2	6	2	95	0.00	0.0	3.587	0.005	0	0	0	2
PL.2347	PD.246	A	#2 ACSR	7.14Y	119.0	0.00	6.02	0.81	0	6	2	95	0.00	0.0	3.598	0.011	6	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1606	PL.2127	A	#4 ACSR	7.14Y	119.1	0.00	5.94	1.75	1	12	3	97	0.00	0.0	3.433	0.005	0	0	0	2
PD.245	PL.1606	A	40QA	7.14Y	119.1	0.00	5.94	1.75	4	12	3	97	0.00	0.0	3.433	0.005	0	0	0	2
PL.2010	PD.245	A	#4 ACSR	7.14Y	119.1	0.00	5.94	1.75	1	12	3	97	0.00	0.0	3.442	0.008	12	3	2	2
PL.2344	PL.4469	C	#4 ACSR	7.15Y	119.1	0.00	5.92	0.50	0	3	1	95	0.00	0.0	3.380	0.005	0	0	0	1
PD.244	PL.2344	C	40QA	7.15Y	119.1	0.00	5.92	0.50	1	3	1	95	0.00	0.0	3.380	0.005	0	0	0	1
PL.2345	PD.244	C	#4 ACSR	7.15Y	119.1	0.00	5.92	0.50	0	3	1	95	0.00	0.0	3.404	0.024	3	1	1	1
PL.2342	PL.2131	C	#2 ACSR	7.16Y	119.3	0.00	5.73	1.56	1	11	3	96	0.00	0.0	3.177	0.005	0	0	0	2
PD.243	PL.2342	C	40QA	7.16Y	119.3	0.00	5.73	1.56	4	11	3	96	0.00	0.0	3.177	0.005	0	0	0	2
PL.2343	PD.243	C	#2 ACSR	7.16Y	119.3	0.00	5.73	1.56	1	11	3	96	0.00	0.0	3.213	0.035	6	2	1	2
PL.1605	PL.2343	C	#2 ACSR	7.16Y	119.3	0.00	5.73	0.67	0	5	1	98	0.00	0.0	3.258	0.045	5	1	1	1
PL.2494	PL.2131	A	#4 ACSR	7.16Y	119.3	0.00	5.73	2.72	2	19	5	97	0.00	0.0	3.177	0.004	0	0	0	5
PD.318	PL.2494	A	15T	7.16Y	119.3	0.00	5.73	2.72	0	19	5	97	0.00	0.0	3.177	0.004	0	0	0	5
PL.2495	PD.318	A	#4 ACSR	7.16Y	119.3	0.00	5.73	2.72	2	19	5	97	0.00	0.0	3.196	0.019	19	5	5	5
PL.2340	PL.1579	B	#1/0 ACSR	7.18Y	119.6	0.00	5.37	1.52	1	10	3	96	0.00	0.0	2.956	0.004	0	0	0	1
PD.242	PL.2340	B	40QA	7.18Y	119.6	0.00	5.37	1.52	4	10	3	96	0.00	0.0	2.956	0.004	0	0	0	1
PL.2341	PD.242	B	#1/0 ACSR	7.18Y	119.6	0.00	5.37	1.52	1	10	3	96	0.00	0.0	2.968	0.012	0	0	0	1
PL.2185	PL.2341	B	#1/0 ACSR	7.18Y	119.6	0.00	5.37	1.52	1	10	3	96	0.00	0.0	2.993	0.025	10	3	1	1
PL.2324	PL.1564	C	#1/0 ACSR	7.22Y	120.3	0.00	4.69	1.51	1	11	3	96	0.00	0.0	2.551	0.005	0	0	0	3
PD.234	PL.2324	C	40QA	7.22Y	120.3	0.00	4.69	1.51	4	11	3	96	0.00	0.0	2.551	0.005	0	0	0	3
PL.2325	PD.234	C	#1/0 ACSR	7.22Y	120.3	0.00	4.69	1.51	1	11	3	96	0.00	0.0	2.592	0.041	2	1	1	3
PL.1569	PL.2325	C	#1/0 ACSR	7.22Y	120.3	0.00	4.69	1.25	1	9	2	98	0.00	0.0	2.615	0.024	9	2	2	2
PL.2336	PL.1550	C	#1/0 ACSR	7.25Y	120.8	0.00	4.25	11.07	5	77	22	96	0.00	0.0	2.284	0.005	0	0	0	11
PD.240	PL.2336	C	40QA	7.25Y	120.8	0.00	4.25	11.07	28	77	22	96	0.00	0.0	2.284	0.005	0	0	0	11
PL.2337	PD.240	C	#1/0 ACSR	7.24Y	120.7	0.01	4.26	11.07	5	77	22	96	0.01	0.0	2.330	0.047	11	3	1	11
PL.1553	PL.2337	C	#1/0 ACSR	7.24Y	120.7	0.01	4.27	9.49	4	66	18	96	0.00	0.0	2.358	0.028	2	1	1	10
PL.1554	PL.1553	C	#1/0 ACSR	7.24Y	120.7	0.01	4.27	5.34	2	37	10	97	0.00	0.0	2.465	0.107	28	8	2	3
PL.1558	PL.1554	C	6 A (CWC)	7.24Y	120.7	0.00	4.28	1.27	1	9	2	98	0.00	0.0	2.548	0.083	9	2	1	1
PL.1555	PL.1553	C	#4 ACSR	7.24Y	120.7	0.00	4.27	3.84	3	27	7	97	0.00	0.0	2.385	0.027	4	1	3	6
PL.1559	PL.1555	C	#1/0 ACSR	7.24Y	120.7	0.00	4.27	3.23	1	23	6	97	0.00	0.0	2.443	0.058	0	0	0	3
PL.1560	PL.1559	C	#1/0 ACSR	7.24Y	120.7	0.00	4.28	3.23	1	23	6	97	0.00	0.0	2.527	0.084	17	5	2	3
PL.1561	PL.1560	C	#1/0 ACSR	7.24Y	120.7	0.00	4.28	0.82	0	6	2	95	0.00	0.0	2.570	0.043	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2332	PL.1547	A	#1/0 ACSR	7.26Y	121.0	0.00	4.00	1.67	1	12	3	97	0.00	0.0	2.140	0.005	0	0	0	2
PD.238	PL.2332	A	40QA	7.26Y	121.0	0.00	4.00	1.67	4	12	3	97	0.00	0.0	2.140	0.005	0	0	0	2
PL.2333	PD.238	A	#1/0 ACSR	7.26Y	121.0	0.00	4.00	1.67	1	12	3	97	0.00	0.0	2.149	0.008	12	3	2	2
PL.2330	PL.1541	A	#1/0 ACSR	7.28Y	121.4	0.00	3.63	1.31	1	9	3	95	0.00	0.0	1.922	0.004	0	0	0	1
PD.237	PL.2330	A	40QA	7.28Y	121.4	0.00	3.63	1.31	3	9	3	95	0.00	0.0	1.922	0.004	0	0	0	1
PL.2331	PD.237	A	#1/0 ACSR	7.28Y	121.4	0.00	3.63	1.31	1	9	3	95	0.00	0.0	1.956	0.034	9	3	1	1
PL.4466	PL.1529	A	#1/0 ACSR	7.30Y	121.6	0.00	3.39	0.00	0	0	0	100	0.00	0.0	1.786	0.004	0	0	0	0
PD.1295	PL.4466	A	40QA	7.30Y	121.6	0.00	3.39	0.00	0	0	0	100	0.00	0.0	1.786	0.004	0	0	0	0
PL.4467	PD.1295	A	#1/0 ACSR	7.30Y	121.6	0.00	3.39	0.00	0	0	0	100	0.00	0.0	1.809	0.023	0	0	0	0
PL.4464	PL.1529	C	#1/0 ACSR	7.30Y	121.6	0.00	3.39	1.39	1	10	3	96	0.00	0.0	1.786	0.003	0	0	0	2
PD.1294	PL.4464	C	40QA	7.30Y	121.6	0.00	3.39	1.39	3	10	3	96	0.00	0.0	1.786	0.003	0	0	0	2
PL.4465	PD.1294	C	#1/0 ACSR	7.30Y	121.6	0.00	3.39	1.39	1	10	3	96	0.00	0.0	1.820	0.034	10	3	2	2
PL.2484	PL.1522	C	6 A (CWC)	7.30Y	121.7	0.00	3.25	2.78	2	20	5	97	0.00	0.0	1.706	0.005	0	0	0	5
PD.313	PL.2484	C	40QA	7.30Y	121.7	0.00	3.25	2.78	7	20	5	97	0.00	0.0	1.706	0.005	0	0	0	5
PL.2485	PD.313	C	6 A (CWC)	7.30Y	121.7	0.01	3.27	2.78	2	20	5	97	0.00	0.0	1.819	0.113	0	0	0	5
PL.2011	PL.2485	C	6 A (CWC)	7.30Y	121.7	0.01	3.28	2.78	2	20	5	97	0.00	0.0	1.935	0.115	2	1	1	5
PL.1537	PL.2011	C	6 A (CWC)	7.30Y	121.7	0.01	3.29	2.52	2	18	5	96	0.00	0.0	2.030	0.095	6	2	1	4
PL.1538	PL.1537	C	6 A (CWC)	7.30Y	121.7	0.00	3.29	1.67	1	12	3	97	0.00	0.0	2.118	0.088	12	3	3	3
PL.2290	PL.1511	A	#1/0 ACSR	7.32Y	121.9	0.00	3.07	2.41	1	17	5	96	0.00	0.0	1.604	0.005	0	0	0	2
PD.218	PL.2290	A	40QA	7.32Y	121.9	0.00	3.07	2.41	6	17	5	96	0.00	0.0	1.604	0.005	0	0	0	2
PL.2291	PD.218	A	#1/0 ACSR	7.32Y	121.9	0.00	3.07	2.41	1	17	5	96	0.00	0.0	1.626	0.022	9	3	1	2
PL.1521	PL.2291	A	#4 ACSR	7.32Y	121.9	0.00	3.07	1.13	1	8	2	97	0.00	0.0	1.676	0.050	8	2	1	1
PL.2544	PL.1510	ABC	#1/0 ACSR	7.32Y	122.0	0.00	3.01	5.62	2	115	45	93	0.00	0.0	1.567	0.005	0	0	0	9
PD.343	PL.2544	ABC	25T	7.32Y	122.0	0.00	3.01	5.62	0	115	45	93	0.00	0.0	1.567	0.005	0	0	0	9
PL.2545	PD.343	ABC	#1/0 ACSR	7.32Y	122.0	0.00	3.01	5.62	2	115	45	93	0.00	0.0	1.596	0.028	0	0	0	9
PL.1523	PL.2545	C	#4 ACSR	7.32Y	122.0	0.00	3.01	3.03	2	21	6	96	0.00	0.0	1.629	0.034	21	6	3	3
PL.1525	PL.2545	ABC	8 A (CWC)	7.32Y	122.0	0.01	3.02	4.62	5	94	39	92	0.01	0.0	1.624	0.029	17	5	2	6
PL.1524	PL.1525	ABC	8 A (CWC)	7.32Y	122.0	0.02	3.03	3.81	4	76	35	91	0.01	0.0	1.702	0.078	7	2	1	4
PL.1530	PL.1524	ABC	8 A (CWC)	7.32Y	122.0	0.00	3.04	3.47	3	69	33	90	0.00	0.0	1.721	0.019	0	0	0	3
PL.1531	PL.1530	ABC	8 A (CWC)	7.32Y	122.0	0.00	3.04	3.34	3	66	32	90	0.00	0.0	1.741	0.020	0	0	0	2
PL.1533	PL.1531	ABC	8 A (CWC)	7.32Y	122.0	0.00	3.04	0.00	0	0	0	100	0.00	0.0	1.765	0.023	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1534	PL.1531	ABC	#1/0 ACSR	7.32Y	122.0	0.00	3.04	3.34	1	66	32	90	0.00	0.0	1.788	0.047	2	0	1	2
PL.1535	PL.1534	ABC	#1/0 ACSR	7.32Y	122.0	0.00	3.05	3.27	1	65	31	90	0.00	0.0	1.817	0.029	0	0	0	1
PL.1536	PL.1535	ABC	#1/0 ACSR	7.32Y	122.0	0.00	3.05	3.27	1	65	31	90	0.00	0.0	1.841	0.024	65	31	1	1
PL.2294	PL.1530	C	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.40	0	3	1	95	0.00	0.0	1.726	0.005	0	0	0	1
PD.220	PL.2294	C	40QA	7.32Y	122.0	0.00	3.04	0.40	1	3	1	95	0.00	0.0	1.726	0.005	0	0	0	1
PL.2295	PD.220	C	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.40	0	3	1	95	0.00	0.0	1.752	0.027	0	0	0	1
PL.1532	PL.2295	C	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.40	0	3	1	95	0.00	0.0	1.782	0.029	3	1	1	1
PL.2482	PL.1510	A	#1/0 ACSR	7.32Y	122.0	0.00	3.01	4.03	2	28	8	96	0.00	0.0	1.567	0.005	0	0	0	7
PD.312	PL.2482	A	25T	7.32Y	122.0	0.00	3.01	4.03	0	28	8	96	0.00	0.0	1.567	0.005	0	0	0	7
PL.2483	PD.312	A	#1/0 ACSR	7.32Y	122.0	0.00	3.01	4.03	2	28	8	96	0.00	0.0	1.606	0.039	0	0	0	7
PL.1512	PL.2483	A	8 A (CWC)	7.32Y	122.0	0.03	3.04	4.03	4	28	8	96	0.01	0.0	1.704	0.098	0	0	0	7
PL.1513	PL.1512	A	8 A (CWC)	7.32Y	121.9	0.02	3.06	4.03	4	28	8	96	0.01	0.0	1.797	0.092	0	0	1	7
PL.1514	PL.1513	A	#4 ACSR	7.32Y	121.9	0.01	3.07	4.00	3	28	8	96	0.00	0.0	1.838	0.042	14	4	1	6
PL.1515	PL.1514	A	#4 ACSR	7.32Y	121.9	0.00	3.07	2.04	2	14	4	96	0.00	0.0	1.874	0.036	0	0	0	5
PL.1516	PL.1515	A	#2 ACSR	7.32Y	121.9	0.00	3.07	0.77	0	5	2	93	0.00	0.0	1.911	0.036	0	0	0	1
PL.1517	PL.1516	A	#2 ACSR	7.32Y	121.9	0.00	3.07	0.77	0	5	2	93	0.00	0.0	1.978	0.068	5	2	1	1
PL.1518	PL.1515	A	#4 ACSR	7.32Y	121.9	0.00	3.07	1.26	1	9	2	98	0.00	0.0	1.911	0.036	3	1	2	4
PL.1519	PL.1518	A	#2 ACSR	7.32Y	121.9	0.00	3.07	0.89	1	6	2	95	0.00	0.0	1.981	0.071	0	0	0	2
PL.1520	PL.1519	A	#2 ACSR	7.32Y	121.9	0.00	3.07	0.89	1	6	2	95	0.00	0.0	2.011	0.030	6	2	2	2
PL.2288	PL.2141	C	#1/0 ACSR	7.33Y	122.2	0.00	2.78	2.93	1	21	6	96	0.00	0.0	1.444	0.005	0	0	0	7
PD.217	PL.2288	C	40QA	7.33Y	122.2	0.00	2.78	2.93	7	21	6	96	0.00	0.0	1.444	0.005	0	0	0	7
PL.2289	PD.217	C	#1/0 ACSR	7.33Y	122.2	0.00	2.78	2.93	1	21	6	96	0.00	0.0	1.458	0.014	5	1	3	7
PL.2142	PL.2289	C	#1/0 ACSR	7.33Y	122.2	0.00	2.78	2.19	1	15	4	97	0.00	0.0	1.464	0.006	0	0	0	4
PL.1508	PL.2142	C	8 A (CWC)	7.33Y	122.2	0.00	2.79	2.19	2	15	4	97	0.00	0.0	1.509	0.045	15	4	4	4
PL.2286	PL.1581	A	#4 ACSR	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	1.131	0.005	0	0	0	0
PD.216	PL.2286	A	50QA	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	1.131	0.005	0	0	0	0
PL.2287	PD.216	A	#4 ACSR	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	1.163	0.032	0	0	0	0
PL.2488	PL.1580	C	#1/0 ACSR	7.38Y	123.0	0.00	2.03	1.82	1	13	4	96	0.00	0.0	1.036	0.005	0	0	0	2
PD.315	PL.2488	C	40QA	7.38Y	123.0	0.00	2.03	1.82	5	13	4	96	0.00	0.0	1.036	0.005	0	0	0	2
PL.2489	PD.315	C	#1/0 ACSR	7.38Y	123.0	0.00	2.03	1.82	1	13	4	96	0.00	0.0	1.068	0.031	13	4	2	2
PL.1467	PL.1466	ABC	#1/0 ACSR	7.42Y	123.6	0.00	1.39	4.50	2	96	27	96	0.00	0.0	0.693	0.005	0	0	0	28

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.341	PL.1467	ABC	50QA	7.42Y	123.6	0.00	1.39	4.50	9	96	27	96	0.00	0.0	0.693	0.005	0	0	0	28
PL.2003	PD.341	ABC	#1/0 ACSR	7.42Y	123.6	0.00	1.39	4.50	2	96	27	96	0.00	0.0	0.703	0.010	1	0	1	28
PL.1469	PL.2003	A	8 A (CWC)	7.41Y	123.6	0.05	1.44	13.36	13	95	27	96	0.04	0.0	0.757	0.053	0	0	0	27
PL.1471	PL.1469	A	#4 ACSR	7.41Y	123.6	0.00	1.44	1.59	1	11	3	96	0.00	0.0	0.777	0.021	11	3	2	2
PL.1474	PL.1469	A	8 A (CWC)	7.41Y	123.5	0.10	1.54	11.77	12	84	23	96	0.06	0.1	0.895	0.138	11	3	5	25
PL.1475	PL.1474	A	8 A (CWC)	7.41Y	123.4	0.03	1.56	10.19	10	73	20	96	0.01	0.0	0.933	0.038	0	0	0	20
PL.1476	PL.1475	A	8 A (CWC)	7.40Y	123.4	0.03	1.60	10.19	10	73	20	96	0.02	0.0	0.983	0.050	4	1	1	20
PL.1477	PL.1476	A	8 A (CWC)	7.40Y	123.3	0.10	1.69	9.62	10	69	19	96	0.05	0.1	1.138	0.154	1	0	1	19
PL.1479	PL.1477	A	8 A (CWC)	7.40Y	123.3	0.03	1.72	9.45	9	67	19	96	0.02	0.0	1.184	0.046	0	0	0	18
PL.1480	PL.1479	A	8 A (CWC)	7.39Y	123.2	0.03	1.76	9.45	9	67	19	96	0.02	0.0	1.239	0.055	0	0	0	18
PL.1482	PL.1480	A	8 A (CWC)	7.39Y	123.2	0.00	1.76	9.45	9	67	19	96	0.00	0.0	1.241	0.002	0	0	0	18
PL.1483	PL.1482	A	6 A (CWC)	7.39Y	123.2	0.04	1.80	9.45	7	67	19	96	0.02	0.0	1.345	0.103	4	1	2	18
PL.1484	PL.1483	A	6 A (CWC)	7.39Y	123.2	0.03	1.83	8.89	6	63	18	96	0.01	0.0	1.422	0.077	13	3	3	16
PL.1485	PL.1484	A	6 A (CWC)	7.39Y	123.1	0.03	1.86	7.13	5	51	14	96	0.01	0.0	1.525	0.104	3	1	1	13
PL.1486	PL.1485	A	6 A (CWC)	7.39Y	123.1	0.03	1.90	6.75	5	48	13	97	0.01	0.0	1.628	0.103	0	0	0	12
PL.1487	PL.1486	A	6 A (CWC)	7.38Y	123.1	0.04	1.94	6.75	5	48	13	97	0.01	0.0	1.766	0.139	7	2	1	12
PL.1489	PL.1487	A	8 A (CWC)	7.38Y	123.0	0.02	1.96	4.92	5	35	10	96	0.01	0.0	1.843	0.077	9	3	3	10
PL.1490	PL.1489	A	8 A (CWC)	7.38Y	123.0	0.03	1.98	3.59	4	26	7	97	0.01	0.0	1.955	0.112	0	0	0	7
PL.1493	PL.1490	A	8 A (CWC)	7.38Y	123.0	0.00	1.99	2.40	2	17	5	96	0.00	0.0	2.006	0.051	17	5	3	3
PL.1492	PL.1490	A	#4 ACSR	7.38Y	123.0	0.00	1.99	1.19	1	8	2	97	0.00	0.0	2.003	0.048	8	2	4	4
PL.10156	PL.1487	A	#1/0 ACSR	7.38Y	123.1	0.00	1.94	0.89	0	6	2	95	0.00	0.0	1.794	0.028	6	2	1	1
PL.1481	PL.1480	A	#4 ACSR	7.39Y	123.2	0.00	1.76	0.00	0	0	0	100	0.00	0.0	1.281	0.042	0	0	0	0
PL.2478	PL.1465	B	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.17	0	1	0	100	0.00	0.0	0.662	0.005	0	0	0	1
PD.310	PL.2478	B	40QA	7.42Y	123.7	0.00	1.33	0.17	0	1	0	100	0.00	0.0	0.662	0.005	0	0	0	1
PL.2479	PD.310	B	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.17	0	1	0	100	0.00	0.0	0.675	0.012	1	0	1	1
PL.2410	PL.1399	C	#2 ACSR	7.43Y	123.9	0.00	1.13	2.72	2	19	5	97	0.00	0.0	0.557	0.005	0	0	0	3
PD.275	PL.2410	C	30T	7.43Y	123.9	0.00	1.13	2.72	0	19	5	97	0.00	0.0	0.557	0.005	0	0	0	3
PL.2411	PD.275	C	#2 ACSR	7.43Y	123.9	0.00	1.13	2.72	2	19	5	97	0.00	0.0	0.573	0.017	10	3	2	3
PL.1460	PL.2411	C	#2 ACSR	7.43Y	123.9	0.00	1.13	1.36	1	10	3	96	0.00	0.0	0.617	0.044	0	0	0	1
PL.1461	PL.1460	C	#4 ACSR	7.43Y	123.9	0.00	1.13	1.36	1	10	3	96	0.00	0.0	0.664	0.047	10	3	1	1
PL.1583	PL.1393	ABC	336 MCM AC	7.45Y	124.2	0.00	0.81	15.59	3	336	94	96	0.00	0.0	0.405	0.015	0	0	0	92

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2554	PL.1583	B	8 A (CWC)	7.45Y	124.2	0.01	0.82	46.77	47	336	94	96	0.02	0.0	0.407	0.003	0	0	0	92
PD.350	PL.2554	B	70L	7.45Y	124.2	0.00	0.82	46.77	67	336	94	96	0.00	0.0	0.407	0.003	0	0	0	92
PL.2555	PD.350	B	8 A (CWC)	7.44Y	124.0	0.14	0.96	46.77	47	336	94	96	0.36	0.1	0.453	0.046	17	5	5	92
PL.1421	PL.2555	B	8 A (CWC)	7.43Y	123.9	0.15	1.11	42.20	42	302	85	96	0.36	0.1	0.507	0.054	0	0	1	84
PL.1425	PL.1421	B	8 A (CWC)	7.43Y	123.8	0.10	1.21	42.16	42	302	84	96	0.23	0.1	0.546	0.039	35	10	5	83
PL.1426	PL.1425	B	8 A (CWC)	7.42Y	123.7	0.13	1.34	37.23	37	266	74	96	0.27	0.1	0.599	0.052	6	2	3	78
PL.1429	PL.1426	B	8 A (CWC)	7.42Y	123.7	0.00	1.34	0.81	1	6	2	95	0.00	0.0	0.641	0.042	4	1	1	2
PL.1433	PL.1429	B	8 A (CWC)	7.42Y	123.7	0.00	1.35	0.27	0	2	1	89	0.00	0.0	0.676	0.035	2	1	1	1
PL.1434	PL.1433	B	8 A (CWC)	7.42Y	123.7	0.00	1.35	0.00	0	0	0	100	0.00	0.0	0.741	0.065	0	0	0	0
PL.1428	PL.1426	B	8 A (CWC)	7.42Y	123.7	0.00	1.35	1.28	1	9	3	95	0.00	0.0	0.647	0.048	9	3	1	1
PL.1432	PL.1428	B	8 A (CWC)	7.42Y	123.7	0.00	1.35	0.00	0	0	0	100	0.00	0.0	0.649	0.002	0	0	0	0
PL.1427	PL.1426	B	8 A (CWC)	7.42Y	123.6	0.06	1.40	34.30	34	245	69	96	0.11	0.0	0.624	0.025	4	1	3	72
PL.1430	PL.1427	B	8 A (CWC)	7.41Y	123.4	0.15	1.55	33.72	34	241	67	96	0.29	0.1	0.694	0.071	13	4	6	69
PL.1438	PL.1430	B	8 A (CWC)	7.40Y	123.3	0.12	1.67	29.67	30	212	59	96	0.20	0.1	0.754	0.060	2	0	1	60
PL.1439	PL.1438	B	8 A (CWC)	7.39Y	123.2	0.11	1.78	29.45	29	210	59	96	0.17	0.1	0.814	0.060	28	8	6	59
PL.1440	PL.1439	B	8 A (CWC)	7.39Y	123.1	0.11	1.89	24.35	24	173	48	96	0.15	0.1	0.884	0.070	10	3	3	52
PL.4514	PL.1440	B	8 A (CWC)	7.39Y	123.1	0.01	1.90	3.93	4	28	8	96	0.00	0.0	0.915	0.031	10	3	1	12
PL.4515	PL.4514	B	8 A (CWC)	7.38Y	123.1	0.02	1.92	2.46	2	18	5	96	0.00	0.0	1.045	0.130	0	0	0	11
PL.1445	PL.4515	B	8 A (CWC)	7.38Y	123.1	0.00	1.93	0.69	1	5	1	98	0.00	0.0	1.139	0.094	0	0	0	2
PL.1448	PL.1445	B	8 A (CWC)	7.38Y	123.1	0.00	1.93	0.69	1	5	1	98	0.00	0.0	1.192	0.053	5	1	2	2
PL.1446	PL.4515	B	#4 ACSR	7.38Y	123.1	0.00	1.92	1.77	1	13	4	96	0.00	0.0	1.089	0.044	8	2	7	9
PL.1447	PL.1446	B	#4 ACSR	7.38Y	123.1	0.00	1.92	0.68	1	5	1	98	0.00	0.0	1.142	0.053	5	1	2	2
PL.1449	PL.1447	B	#4 ACSR	7.38Y	123.1	0.00	1.92	0.00	0	0	0	100	0.00	0.0	1.217	0.076	0	0	0	0
PL.1443	PL.1440	B	8 A (CWC)	7.38Y	123.1	0.04	1.93	18.98	19	135	38	96	0.04	0.0	0.913	0.028	7	2	1	37
PL.2220	PL.1443	B	8 A (CWC)	7.38Y	123.0	0.04	1.97	17.93	18	128	36	96	0.04	0.0	0.945	0.032	9	2	2	36
PL.2221	PL.2220	B	8 A (CWC)	7.38Y	123.0	0.05	2.02	16.70	17	119	33	96	0.05	0.0	0.990	0.045	4	1	1	34
PL.1451	PL.2221	B	8 A (CWC)	7.38Y	123.0	0.02	2.04	16.10	16	114	32	96	0.02	0.0	1.013	0.022	27	7	4	33
PL.1452	PL.1451	B	#2 ACSR	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	1.064	0.051	0	0	1	1
PL.1453	PL.1451	B	8 A (CWC)	7.38Y	122.9	0.03	2.07	12.33	12	88	24	96	0.02	0.0	1.058	0.045	38	11	12	28
PL.1454	PL.1453	B	8 A (CWC)	7.37Y	122.9	0.02	2.09	6.95	7	49	14	96	0.01	0.0	1.119	0.061	25	7	7	16
PL.1455	PL.1454	B	8 A (CWC)	7.37Y	122.9	0.00	2.09	1.92	2	14	4	96	0.00	0.0	1.147	0.028	8	2	3	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2222	PL.1455	B	8 A (CWC)	7.37Y	122.9	0.00	2.09	0.82	1	6	2	95	0.00	0.0	1.208	0.062	0	0	1	4
PL.2223	PL.2222	B	8 A (CWC)	7.37Y	122.9	0.00	2.09	0.82	1	6	2	95	0.00	0.0	1.293	0.084	6	2	2	3
PL.2224	PL.2223	B	8 A (CWC)	7.37Y	122.9	0.00	2.09	0.02	0	0	0	100	0.00	0.0	1.379	0.086	0	0	0	1
PL.1458	PL.2224	B	8 A (CWC)	7.37Y	122.9	0.00	2.10	0.02	0	0	0	100	0.00	0.0	1.491	0.112	0	0	1	1
PL.1456	PL.1454	B	#4 ACSR	7.37Y	122.9	0.00	2.09	1.48	1	10	3	96	0.00	0.0	1.140	0.021	10	3	2	2
PL.1457	PL.1456	B	#4 ACSR	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	1.185	0.045	0	0	0	0
PL.1441	PL.1439	B	8 A (CWC)	7.39Y	123.2	0.00	1.78	1.10	1	8	2	97	0.00	0.0	0.857	0.043	8	2	1	1
PL.1436	PL.1430	B	#4 ACSR	7.41Y	123.4	0.00	1.56	2.23	2	16	4	97	0.00	0.0	0.722	0.027	0	0	0	3
PL.1435	PL.1436	B	#4 ACSR	7.41Y	123.4	0.00	1.56	2.23	2	16	4	97	0.00	0.0	0.750	0.028	4	1	1	3
PL.1437	PL.1435	B	#4 ACSR	7.41Y	123.4	0.00	1.56	1.70	1	12	3	97	0.00	0.0	0.816	0.066	12	3	2	2
PL.1420	PL.2555	B	#4 ACSR	7.44Y	124.0	0.00	0.96	2.22	2	16	4	97	0.00	0.0	0.466	0.013	0	0	0	3
PL.1422	PL.1420	B	#4 ACSR	7.44Y	124.0	0.01	0.97	2.22	2	16	4	97	0.00	0.0	0.539	0.073	0	0	1	3
PL.1423	PL.1422	B	#1/0 ACSR	7.44Y	124.0	0.00	0.97	0.98	0	7	2	96	0.00	0.0	0.594	0.055	7	2	1	1
PL.1424	PL.1422	B	#2 ACSR	7.44Y	124.0	0.00	0.97	1.23	1	9	2	98	0.00	0.0	0.570	0.031	9	2	1	1
PL.3087	Goose Rock	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.00	80.58	24	1724	562	95	0.04	0.0	0.005	0.005	0	0	0	387
PL.7161	PL.3087	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.01	80.58	24	1723	562	95	0.01	0.0	0.006	0.001	0	0	0	387

----- Feeder No. 4 (Schoolhouse F4) Beginning with Device PD.1529 -----

PD.1529	PL.7161	ABC	480VWE	7.50Y	125.0	0.00	0.01	80.58	0	1723	562	95	0.00	0.0	0.006	0.001	0	0	0	387
PL.7162	PD.1529	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.01	80.58	24	1723	562	95	0.05	0.0	0.011	0.005	0	0	0	387
PL.3992	PL.7162	ABC	#4/0 ACSR	7.49Y	124.9	0.09	0.10	80.58	24	1723	562	95	0.86	0.0	0.110	0.099	0	0	0	387
PL.3490	PL.3992	C	6 A (CWC)	7.49Y	124.9	0.00	0.10	0.39	0	3	1	95	0.00	0.0	0.115	0.005	0	0	0	1
PD.460	PL.3490	C	40QA	7.49Y	124.9	0.00	0.10	0.39	1	3	1	95	0.00	0.0	0.115	0.005	0	0	0	1
PL.3491	PD.460	C	6 A (CWC)	7.49Y	124.9	0.00	0.10	0.39	0	3	1	95	0.00	0.0	0.151	0.037	3	1	1	1
PL.3780	PL.3992	ABC	#4/0 ACSR	7.49Y	124.8	0.07	0.17	80.45	24	1720	560	95	0.68	0.0	0.189	0.078	0	0	0	386
PL.3781	PL.3780	ABC	#4/0 ACSR	7.49Y	124.8	0.08	0.24	80.24	24	1715	558	95	0.75	0.0	0.275	0.087	0	0	0	383
PL.3617	PL.3781	ABC	#4/0 ACSR	7.48Y	124.7	0.08	0.33	70.44	21	1513	460	96	0.71	0.0	0.383	0.107	9	3	1	382
PL.3619	PL.3617	ABC	#4/0 ACSR	7.48Y	124.6	0.08	0.41	70.01	21	1503	456	96	0.68	0.0	0.486	0.103	0	0	0	381
PL.2958	PL.3619	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	3.31	1	24	7	96	0.00	0.0	0.491	0.005	0	0	0	2
PD.458	PL.2958	A	40QA	7.48Y	124.6	0.00	0.41	3.31	8	24	7	96	0.00	0.0	0.491	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2959	PD.458	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	3.31	1	24	7	96	0.00	0.0	0.520	0.029	24	7	2	2
PL.3620	PL.3619	ABC	#4/0 ACSR	7.47Y	124.5	0.05	0.46	68.91	20	1479	448	96	0.43	0.0	0.555	0.069	8	2	4	379
PL.3621	PL.3620	ABC	#4/0 ACSR	7.47Y	124.5	0.02	0.48	68.30	20	1465	444	96	0.16	0.0	0.580	0.026	0	0	1	374
PL.3622	PL.3621	ABC	#4/0 ACSR	7.46Y	124.4	0.13	0.60	68.28	20	1465	443	96	1.05	0.1	0.750	0.169	0	0	0	373
PL.3537	PL.3622	ABC	#4/0 ACSR	7.46Y	124.3	0.13	0.73	68.28	20	1464	442	96	1.13	0.1	0.931	0.181	3	1	1	373
PL.3928	PL.3537	ABC	#4/0 ACSR	7.45Y	124.1	0.13	0.86	68.13	20	1459	439	96	1.07	0.1	1.103	0.172	0	0	0	372
PL.2954	PL.3928	C	#4 ACSR	7.45Y	124.1	0.00	0.86	1.12	1	8	2	97	0.00	0.0	1.108	0.005	0	0	0	1
PD.456	PL.2954	C	40QA	7.45Y	124.1	0.00	0.86	1.12	3	8	2	97	0.00	0.0	1.108	0.005	0	0	0	1
PL.32693	PD.456	C	#2 ACSR	7.45Y	124.1	0.00	0.86	1.12	1	8	2	97	0.00	0.0	1.168	0.060	8	2	1	1
PL.3514	PL.3928	ABC	#4/0 ACSR	7.44Y	124.0	0.13	0.99	67.76	20	1450	435	96	1.08	0.1	1.279	0.176	0	0	0	371
PL.3538	PL.3514	ABC	#4/0 ACSR	7.44Y	124.0	0.04	1.03	67.76	20	1449	433	96	0.32	0.0	1.331	0.052	6	2	1	371
PL.3624	PL.3538	ABC	#4/0 ACSR	7.44Y	123.9	0.05	1.08	66.56	20	1423	425	96	0.42	0.0	1.402	0.071	10	3	1	366
PL.3925	PL.3624	ABC	#4/0 ACSR	7.43Y	123.9	0.05	1.13	66.09	19	1413	421	96	0.43	0.0	1.475	0.073	3	1	1	365
PL.3926	PL.3925	ABC	#4/0 ACSR	7.43Y	123.8	0.08	1.21	65.93	19	1409	420	96	0.65	0.0	1.588	0.112	3	1	1	364
PL.3924	PL.3926	ABC	#4/0 ACSR	7.42Y	123.7	0.06	1.27	65.77	19	1405	418	96	0.45	0.0	1.666	0.079	9	2	1	363
PL.3919	PL.3924	ABC	#4/0 ACSR	7.42Y	123.7	0.06	1.33	65.36	19	1395	414	96	0.50	0.0	1.755	0.089	7	2	2	362
PL.3628	PL.3919	ABC	#4/0 ACSR	7.41Y	123.6	0.12	1.44	64.65	19	1380	409	96	0.92	0.1	1.920	0.165	1	0	1	359
PL.3923	PL.3628	ABC	#4/0 ACSR	7.41Y	123.5	0.05	1.49	64.60	19	1378	407	96	0.36	0.0	1.985	0.065	0	0	0	358
PL.3920	PL.3923	ABC	#4/0 ACSR	7.41Y	123.5	0.03	1.52	64.15	19	1368	404	96	0.26	0.0	2.033	0.048	5	1	1	356
PL.3921	PL.3920	ABC	#4/0 ACSR	7.41Y	123.4	0.04	1.56	63.93	19	1363	402	96	0.29	0.0	2.087	0.054	5	2	1	355
PL.3918	PL.3921	ABC	#4/0 ACSR	7.40Y	123.4	0.05	1.61	63.67	19	1357	400	96	0.37	0.0	2.156	0.069	0	0	0	354
PL.3630	PL.3918	ABC	#1/0 ACSR	7.40Y	123.3	0.09	1.70	63.48	28	1352	398	96	0.87	0.1	2.238	0.082	16	4	2	353
PL.3916	PL.3630	ABC	#1/0 ACSR	7.39Y	123.2	0.08	1.78	62.74	27	1336	393	96	0.72	0.1	2.308	0.070	14	4	3	351
PL.3917	PL.3916	ABC	#4/0 ACSR	7.39Y	123.2	0.06	1.84	62.09	18	1321	389	96	0.47	0.0	2.398	0.090	0	0	0	348
PL.4011	PL.3917	C	#4 ACSR	7.39Y	123.2	0.00	1.84	0.69	1	5	1	98	0.00	0.0	2.403	0.005	0	0	0	3
PD.451	PL.4011	C	40QA	7.39Y	123.2	0.00	1.84	0.69	2	5	1	98	0.00	0.0	2.403	0.005	0	0	0	3
PL.4012	PD.451	C	#4 ACSR	7.39Y	123.2	0.00	1.84	0.69	1	5	1	98	0.00	0.0	2.481	0.078	1	0	1	3
PL.3631	PL.4012	C	#4 ACSR	7.39Y	123.2	0.00	1.84	0.58	0	4	1	97	0.00	0.0	2.558	0.077	4	1	2	2
PL.3515	PL.3917	ABC	#4/0 ACSR	7.39Y	123.1	0.07	1.91	61.86	18	1316	386	96	0.56	0.0	2.508	0.110	5	1	1	345
PL.3915	PL.3515	ABC	#4/0 ACSR	7.38Y	123.0	0.11	2.02	61.63	18	1310	384	96	0.82	0.1	2.670	0.162	0	0	0	344
PL.4009	PL.3915	A	#4 ACSR	7.38Y	123.0	0.00	2.02	0.87	1	6	2	95	0.00	0.0	2.674	0.004	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.450	PL.4009	A	40QA	7.38Y	123.0	0.00	2.02	0.87	2	6	2	95	0.00	0.0	2.674	0.004	0	0	0	1
PL.4010	PD.450	A	#4 ACSR	7.38Y	123.0	0.00	2.02	0.87	1	6	2	95	0.00	0.0	2.714	0.040	6	2	1	1
PL.3885	PL.3915	ABC	#4/0 ACSR	7.37Y	122.9	0.06	2.08	61.35	18	1303	381	96	0.48	0.0	2.765	0.095	8	2	1	343
PL.3886	PL.3885	ABC	#4/0 ACSR	7.37Y	122.9	0.04	2.12	60.98	18	1295	378	96	0.29	0.0	2.824	0.059	0	0	0	342
PL.3887	PL.3886	ABC	#4/0 ACSR	7.37Y	122.8	0.03	2.15	60.98	18	1295	377	96	0.21	0.0	2.866	0.042	22	6	3	342
PL.3888	PL.3887	ABC	#4/0 ACSR	7.37Y	122.8	0.05	2.20	59.96	18	1273	371	96	0.40	0.0	2.950	0.083	9	2	2	339
PL.3889	PL.3888	ABC	#4/0 ACSR	7.36Y	122.7	0.06	2.27	59.54	18	1264	368	96	0.46	0.0	3.046	0.096	0	0	0	337
PL.3999	PL.3889	A	#2 ACSR	7.36Y	122.7	0.00	2.27	1.03	1	7	2	96	0.00	0.0	3.050	0.005	0	0	0	2
PD.445	PL.3999	A	40QA	7.36Y	122.7	0.00	2.27	1.03	3	7	2	96	0.00	0.0	3.050	0.005	0	0	0	2
PL.4000	PD.445	A	#2 ACSR	7.36Y	122.7	0.00	2.27	1.03	1	7	2	96	0.00	0.0	3.066	0.016	7	2	2	2
PL.3854	PL.3889	ABC	#4/0 ACSR	7.36Y	122.7	0.05	2.32	59.20	17	1256	365	96	0.38	0.0	3.128	0.082	15	4	5	335
PL.3997	PL.3854	A	#4 ACSR	7.36Y	122.7	0.00	2.32	2.55	2	18	5	96	0.00	0.0	3.132	0.005	0	0	0	4
PD.444	PL.3997	A	40QA	7.36Y	122.7	0.00	2.32	2.55	6	18	5	96	0.00	0.0	3.132	0.005	0	0	0	4
PL.3998	PD.444	A	#4 ACSR	7.36Y	122.7	0.00	2.32	2.55	2	18	5	96	0.00	0.0	3.195	0.063	18	5	4	4
PL.3880	PL.3854	ABC	#4/0 ACSR	7.36Y	122.6	0.05	2.37	57.65	17	1223	355	96	0.35	0.0	3.206	0.079	0	0	0	326
PL.3882	PL.3880	ABC	#4/0 ACSR	7.36Y	122.6	0.03	2.40	57.65	17	1222	355	96	0.22	0.0	3.256	0.049	11	3	2	326
PL.3883	PL.3882	ABC	#4/0 ACSR	7.35Y	122.6	0.03	2.42	57.13	17	1211	351	96	0.19	0.0	3.299	0.044	8	2	1	324
PL.3884	PL.3883	ABC	#4/0 ACSR	7.35Y	122.5	0.03	2.46	56.78	17	1203	349	96	0.24	0.0	3.356	0.057	0	0	0	323
PL.3881	PL.3884	ABC	#4/0 ACSR	7.35Y	122.5	0.03	2.48	56.78	17	1203	348	96	0.18	0.0	3.398	0.042	2	1	2	323
PL.3633	PL.3881	ABC	#4/0 ACSR	7.35Y	122.5	0.04	2.52	56.69	17	1201	347	96	0.27	0.0	3.461	0.063	0	0	0	321
PL.3993	PL.3633	B	#1/0 ACSR	7.35Y	122.5	0.00	2.52	5.28	2	37	10	97	0.00	0.0	3.466	0.005	0	0	0	12
PD.441	PL.3993	B	40QA	7.35Y	122.5	0.00	2.52	5.28	13	37	10	97	0.00	0.0	3.466	0.005	0	0	0	12
PL.3994	PD.441	B	#1/0 ACSR	7.35Y	122.5	0.00	2.52	5.28	2	37	10	97	0.00	0.0	3.490	0.024	8	2	2	12
PL.3909	PL.3994	B	#1/0 ACSR	7.35Y	122.5	0.01	2.53	4.19	2	30	8	97	0.00	0.0	3.590	0.100	0	0	0	10
PL.3634	PL.3909	B	#2 ACSR	7.35Y	122.5	0.00	2.54	1.10	1	8	2	97	0.00	0.0	3.647	0.057	0	0	0	1
PL.3827	PL.3634	B	#2 ACSR	7.35Y	122.5	0.00	2.54	1.10	1	8	2	97	0.00	0.0	3.774	0.126	8	2	1	1
PL.3516	PL.3909	B	#1/0 ACSR	7.35Y	122.5	0.01	2.54	3.08	1	22	6	96	0.00	0.0	3.674	0.084	0	0	0	9
PL.3910	PL.3516	B	#1/0 ACSR	7.35Y	122.5	0.01	2.55	3.08	1	22	6	96	0.00	0.0	3.802	0.127	15	4	5	9
PL.3911	PL.3910	B	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.91	0	6	2	95	0.00	0.0	3.853	0.051	6	2	4	4
PL.3912	PL.3911	B	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.00	0	0	0	100	0.00	0.0	3.932	0.080	0	0	0	0
PL.3913	PL.3912	B	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.00	0	0	0	100	0.00	0.0	4.093	0.161	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3850	PL.3633	ABC	#4/0 ACSR	7.35Y	122.4	0.04	2.56	54.93	16	1163	337	96	0.29	0.0	3.535	0.073	4	1	4	309
PL.3995	PL.3850	C	#2 ACSR	7.35Y	122.4	0.00	2.56	0.49	0	3	1	95	0.00	0.0	3.539	0.005	0	0	0	1
PD.442	PL.3995	C	40QA	7.35Y	122.4	0.00	2.56	0.49	1	3	1	95	0.00	0.0	3.539	0.005	0	0	0	1
PL.3996	PD.442	C	#2 ACSR	7.35Y	122.4	0.00	2.56	0.49	0	3	1	95	0.00	0.0	3.555	0.016	3	1	1	1
PL.3907	PL.3850	ABC	#4/0 ACSR	7.34Y	122.4	0.02	2.59	54.57	16	1155	334	96	0.16	0.0	3.576	0.041	9	3	4	304
PL.3908	PL.3907	ABC	#4/0 ACSR	7.34Y	122.4	0.02	2.61	54.14	16	1146	331	96	0.15	0.0	3.615	0.039	0	0	0	300
PL.3824	PL.3908	ABC	#4/0 ACSR	7.34Y	122.4	0.00	2.61	54.14	16	1146	331	96	0.00	0.0	3.617	0.001	0	0	0	300
RG.5	PL.3824	ABC	114.3 KVA	7.48Y	124.7	-2.34	0.27	54.14	36	1146	331	96	percent Boost= 1.88 Tap= 3.0				0	0	0	300
PL.3825	RG.5	ABC	#4/0 ACSR	7.48Y	124.7	0.00	0.27	53.12	16	1146	331	96	0.00	0.0	3.618	0.001	0	0	0	300
PL.3849	PL.3825	ABC	#4/0 ACSR	7.48Y	124.7	0.02	0.30	53.12	16	1146	331	96	0.14	0.0	3.657	0.039	23	6	3	300
PL.4028	PL.3849	C	#2 ACSR	7.48Y	124.7	0.00	0.30	2.12	1	15	4	97	0.00	0.0	3.661	0.005	0	0	0	7
PD.482	PL.4028	C	40QA	7.48Y	124.7	0.00	0.30	2.12	5	15	4	97	0.00	0.0	3.661	0.005	0	0	0	7
PL.4029	PD.482	C	#2 ACSR	7.48Y	124.7	0.00	0.30	2.12	1	15	4	97	0.00	0.0	3.720	0.058	15	4	7	7
PL.4007	PL.3849	A	#4 ACSR	7.48Y	124.7	0.00	0.30	2.06	2	15	4	97	0.00	0.0	3.661	0.005	0	0	0	3
PD.449	PL.4007	A	40QA	7.48Y	124.7	0.00	0.30	2.06	5	15	4	97	0.00	0.0	3.661	0.005	0	0	0	3
PL.4008	PD.449	A	#4 ACSR	7.48Y	124.7	0.00	0.30	2.06	2	15	4	97	0.00	0.0	3.698	0.037	15	4	3	3
PL.4048	PL.3849	ABC	#4/0 ACSR	7.48Y	124.7	0.02	0.32	50.69	15	1093	316	96	0.13	0.0	3.694	0.038	0	0	0	287
PD.492	PL.4048	ABC	100L	7.48Y	124.7	0.00	0.32	50.69	51	1093	316	96	0.00	0.0	3.694	0.038	0	0	0	287
PL.4049	PD.492	ABC	#4/0 ACSR	7.48Y	124.7	0.02	0.34	50.69	15	1093	316	96	0.15	0.0	3.738	0.043	10	3	2	287
PL.4005	PL.4049	A	#2 ACSR	7.48Y	124.7	0.00	0.34	0.30	0	2	1	89	0.00	0.0	3.742	0.005	0	0	0	1
PD.448	PL.4005	A	40QA	7.48Y	124.7	0.00	0.34	0.30	1	2	1	89	0.00	0.0	3.742	0.005	0	0	0	1
PL.4006	PD.448	A	#2 ACSR	7.48Y	124.7	0.00	0.34	0.30	0	2	1	89	0.00	0.0	3.798	0.056	2	1	1	1
PL.4026	PL.4049	ABC	#4/0 ACSR	7.48Y	124.6	0.05	0.39	50.13	15	1081	312	96	0.34	0.0	3.838	0.101	0	0	0	284
PL.4027	PL.4026	ABC	#4/0 ACSR	7.48Y	124.6	0.00	0.40	50.13	15	1080	311	96	0.01	0.0	3.843	0.004	13	4	4	284
PL.4042	PL.4027	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	26.00	11	187	53	96	0.00	0.0	3.845	0.003	0	0	0	51
PD.489	PL.4042	C	50L	7.48Y	124.6	0.00	0.40	26.00	52	187	53	96	0.00	0.0	3.845	0.003	0	0	0	51
PL.4043	PD.489	C	#1/0 ACSR	7.47Y	124.6	0.03	0.42	26.00	11	187	53	96	0.03	0.0	3.887	0.042	0	0	0	51
PL.3517	PL.4043	C	#1/0 ACSR	7.47Y	124.5	0.06	0.48	25.11	11	181	51	96	0.07	0.0	3.987	0.100	0	0	0	49
PL.3539	PL.3517	C	#1/0 ACSR	7.47Y	124.4	0.08	0.57	25.11	11	181	51	96	0.10	0.1	4.131	0.144	0	0	0	49
PL.3637	PL.3539	C	#2 ACSR	7.47Y	124.4	0.00	0.57	0.38	0	3	1	95	0.00	0.0	4.165	0.034	3	1	1	1
PL.3636	PL.3539	C	#1/0 ACSR	7.46Y	124.4	0.04	0.61	24.73	11	178	50	96	0.05	0.0	4.206	0.075	3	1	2	48

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3640	PL.3636	C	#1/0 ACSR	7.46Y	124.4	0.04	0.65	23.94	10	172	48	96	0.05	0.0	4.280	0.074	4	1	1	43
PL.3641	PL.3640	C	#1/0 ACSR	7.46Y	124.3	0.04	0.68	23.37	10	168	47	96	0.04	0.0	4.345	0.065	0	0	0	42
PL.3878	PL.3641	C	#1/0 ACSR	7.46Y	124.3	0.01	0.70	7.81	3	56	16	96	0.00	0.0	4.415	0.071	14	4	3	10
PL.3879	PL.3878	C	#1/0 ACSR	7.46Y	124.3	0.01	0.70	5.83	3	42	12	96	0.00	0.0	4.487	0.071	5	2	1	7
PL.4517	PL.3879	C	#2 ACSR	7.46Y	124.3	0.01	0.71	5.07	3	36	10	96	0.00	0.0	4.551	0.064	0	0	0	6
PL.4518	PL.4517	C	#2 ACSR	7.46Y	124.3	0.01	0.72	4.06	2	29	8	96	0.00	0.0	4.639	0.088	14	4	2	5
PL.3865	PL.4518	C	#2 ACSR	7.46Y	124.3	0.00	0.73	2.07	1	15	4	97	0.00	0.0	4.692	0.053	8	2	2	3
PL.3863	PL.3865	C	#2 ACSR	7.46Y	124.3	0.00	0.73	0.90	1	6	2	95	0.00	0.0	4.740	0.048	6	2	1	1
PL.4516	PL.4517	C	#1/0 ACSR	7.46Y	124.3	0.00	0.72	1.02	0	7	2	96	0.00	0.0	4.879	0.328	7	2	1	1
PL.3642	PL.3641	C	#1/0 ACSR	7.46Y	124.3	0.05	0.74	15.56	7	112	32	96	0.04	0.0	4.491	0.147	0	0	0	32
PL.3541	PL.3642	C	#1/0 ACSR	7.45Y	124.2	0.04	0.78	15.56	7	112	31	96	0.03	0.0	4.604	0.113	0	0	0	32
PL.3542	PL.3541	C	#1/0 ACSR	7.45Y	124.2	0.05	0.83	15.56	7	112	31	96	0.04	0.0	4.740	0.136	0	0	0	32
PL.3644	PL.3542	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.12	0	1	0	100	0.00	0.0	4.840	0.101	0	0	0	2
PL.3661	PL.3644	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	4.958	0.117	0	0	0	1
PL.3544	PL.3661	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	5.102	0.144	0	0	0	1
PL.3545	PL.3544	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	5.188	0.086	0	0	0	1
PL.3830	PL.3545	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	5.358	0.170	0	0	0	1
PL.4521	PL.3830	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	5.504	0.146	0	0	0	1
PL.4522	PL.4521	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.00	0	0	0	100	0.00	0.0	5.522	0.019	0	0	0	0
PL.4520	PL.4521	C	#1/0 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	5.600	0.096	1	0	1	1
PL.3662	PL.3644	C	#1/0 ACSR	7.45Y	124.2	0.00	0.83	0.01	0	0	0	100	0.00	0.0	4.892	0.052	0	0	1	1
PL.3871	PL.3542	C	#1/0 ACSR	7.45Y	124.2	0.02	0.84	15.39	7	110	31	96	0.01	0.0	4.782	0.043	1	0	1	29
PL.3872	PL.3871	C	#1/0 ACSR	7.45Y	124.1	0.04	0.88	15.21	7	109	31	96	0.03	0.0	4.885	0.103	0	0	0	28
PL.3548	PL.3872	C	#1/0 ACSR	7.44Y	124.1	0.04	0.92	15.21	7	109	31	96	0.03	0.0	5.012	0.127	0	0	0	28
PL.3549	PL.3548	C	#1/0 ACSR	7.44Y	124.0	0.04	0.96	15.21	7	109	31	96	0.03	0.0	5.128	0.116	0	0	0	28
PL.3550	PL.3549	C	#1/0 ACSR	7.44Y	124.0	0.05	1.01	15.21	7	109	31	96	0.03	0.0	5.258	0.130	0	0	0	28
PL.3873	PL.3550	C	#1/0 ACSR	7.44Y	124.0	0.02	1.03	15.21	7	109	31	96	0.02	0.0	5.327	0.069	9	3	1	28
PL.3874	PL.3873	C	#1/0 ACSR	7.44Y	124.0	0.01	1.04	13.93	6	100	28	96	0.01	0.0	5.360	0.032	1	0	1	27
PL.3875	PL.3874	C	#1/0 ACSR	7.43Y	123.9	0.05	1.09	13.85	6	99	28	96	0.03	0.0	5.514	0.155	2	1	1	26
PL.3876	PL.3875	C	#1/0 ACSR	7.43Y	123.9	0.01	1.10	13.58	6	97	27	96	0.01	0.0	5.541	0.026	0	0	0	25
PL.3877	PL.3876	C	#1/0 ACSR	7.43Y	123.9	0.03	1.13	13.58	6	97	27	96	0.02	0.0	5.640	0.099	2	1	1	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3855	PL.3877	C	#1/0 ACSR	7.43Y	123.8	0.03	1.16	13.29	6	95	27	96	0.02	0.0	5.737	0.097	0	0	0	23
PL.3782	PL.3855	C	#1/0 ACSR	7.43Y	123.8	0.04	1.20	13.29	6	95	27	96	0.02	0.0	5.859	0.122	0	0	0	23
PL.3783	PL.3782	C	#1/0 ACSR	7.43Y	123.8	0.04	1.24	13.29	6	95	27	96	0.03	0.0	6.003	0.144	8	2	2	23
PL.3647	PL.3783	C	#1/0 ACSR	7.42Y	123.7	0.03	1.27	11.29	5	81	23	96	0.02	0.0	6.112	0.109	0	0	0	20
PL.3649	PL.3647	C	#4 ACSR	7.42Y	123.7	0.00	1.27	2.11	2	15	4	97	0.00	0.0	6.140	0.028	5	1	3	8
PL.3650	PL.3649	C	#4 ACSR	7.42Y	123.7	0.00	1.28	1.39	1	10	3	96	0.00	0.0	6.181	0.041	2	0	1	5
PL.3858	PL.3650	C	#4 ACSR	7.42Y	123.7	0.00	1.28	1.16	1	8	2	97	0.00	0.0	6.271	0.090	0	0	0	4
PL.3859	PL.3858	C	#4 ACSR	7.42Y	123.7	0.00	1.28	1.16	1	8	2	97	0.00	0.0	6.276	0.005	4	1	1	4
PL.3658	PL.3859	C	#1/0 ACSR	7.42Y	123.7	0.00	1.28	0.57	0	4	1	97	0.00	0.0	6.281	0.005	0	0	0	3
PD.443	PL.3658	C	40QA	7.42Y	123.7	0.00	1.28	0.57	1	4	1	97	0.00	0.0	6.281	0.005	0	0	0	3
PL.3518	PD.443	C	#1/0 ACSR	7.42Y	123.7	0.00	1.28	0.00	0	0	0	100	0.00	0.0	6.326	0.046	0	0	0	0
PL.3860	PD.443	C	#4 ACSR	7.42Y	123.7	0.00	1.28	0.57	0	4	1	97	0.00	0.0	6.290	0.010	0	0	0	3
PL.3657	PL.3860	C	#4 ACSR	7.42Y	123.7	0.00	1.28	0.57	0	4	1	97	0.00	0.0	6.370	0.080	0	0	0	3
PL.3655	PL.3657	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.57	0	4	1	97	0.00	0.0	6.511	0.140	0	0	0	3
PL.3784	PL.3655	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.57	0	4	1	97	0.00	0.0	6.574	0.064	0	0	0	3
PL.3666	PL.3784	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.00	0	0	0	100	0.00	0.0	6.616	0.041	0	0	1	1
PL.3519	PL.3784	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.57	0	4	1	97	0.00	0.0	6.731	0.157	0	0	0	2
PL.3785	PL.3519	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.57	0	4	1	97	0.00	0.0	6.835	0.104	0	0	0	2
PL.3828	PL.3785	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.57	0	4	1	97	0.00	0.0	6.941	0.106	0	0	0	2
PL.3786	PL.3828	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.57	0	4	1	97	0.00	0.0	7.026	0.086	3	1	1	2
PL.3656	PL.3786	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.16	0	1	0	100	0.00	0.0	7.179	0.153	0	0	0	1
PL.3659	PL.3656	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.16	0	1	0	100	0.00	0.0	7.243	0.064	1	0	1	1
PL.3929	PL.3647	C	#1/0 ACSR	7.42Y	123.7	0.01	1.28	9.18	4	66	18	96	0.01	0.0	6.174	0.062	0	0	0	12
PL.3930	PL.3929	C	#1/0 ACSR	7.42Y	123.7	0.01	1.30	9.18	4	66	18	96	0.00	0.0	6.222	0.049	0	0	0	12
PL.3651	PL.3930	C	#4 ACSR	7.42Y	123.7	0.00	1.30	0.33	0	2	1	89	0.00	0.0	6.261	0.038	2	1	1	1
PL.3867	PL.3930	C	#1/0 ACSR	7.42Y	123.7	0.01	1.31	8.86	4	63	18	96	0.01	0.0	6.300	0.078	8	2	2	11
PL.3868	PL.3867	C	#1/0 ACSR	7.42Y	123.7	0.01	1.32	7.69	3	55	15	96	0.00	0.0	6.334	0.034	10	3	2	9
PL.3866	PL.3868	C	#1/0 ACSR	7.42Y	123.7	0.01	1.33	6.31	3	45	13	96	0.00	0.0	6.405	0.071	0	0	0	7
PL.3869	PL.3866	C	#1/0 ACSR	7.42Y	123.7	0.01	1.33	5.32	2	38	11	96	0.00	0.0	6.461	0.056	18	5	2	6
PL.3870	PL.3869	C	#1/0 ACSR	7.42Y	123.7	0.00	1.34	2.84	1	20	6	96	0.00	0.0	6.550	0.089	9	3	2	4
PL.3653	PL.3870	C	#4 ACSR	7.42Y	123.7	0.00	1.34	0.97	1	7	2	96	0.00	0.0	6.577	0.027	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3667	PL.3870	C	#4 ACSR	7.42Y	123.7	0.00	1.34	0.56	0	4	1	97	0.00	0.0	6.650	0.100	4	1	1	1
PL.3652	PL.3866	C	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.99	0	7	2	96	0.00	0.0	6.433	0.028	7	2	1	1
PL.3648	PL.3783	C	#2 ACSR	7.43Y	123.8	0.00	1.24	0.89	1	6	2	95	0.00	0.0	6.071	0.068	6	2	1	1
PL.3645	PL.3877	C	#4 ACSR	7.43Y	123.9	0.00	1.13	0.00	0	0	0	100	0.00	0.0	5.699	0.059	0	0	1	1
PL.3643	PL.3542	C	#2 ACSR	7.45Y	124.2	0.00	0.83	0.06	0	0	0	100	0.00	0.0	4.800	0.060	0	0	1	1
PL.3638	PL.3636	C	#2 ACSR	7.46Y	124.4	0.00	0.61	0.19	0	1	0	100	0.00	0.0	4.255	0.049	1	0	1	1
PL.3639	PL.3636	C	#2 ACSR	7.46Y	124.4	0.00	0.61	0.16	0	1	0	100	0.00	0.0	4.255	0.049	1	0	2	2
PL.28283	PL.4043	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.90	0	6	2	95	0.00	0.0	3.909	0.022	0	0	1	2
PL.28284	PL.28283	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.84	0	6	2	95	0.00	0.0	3.969	0.060	6	2	1	1
PL.4024	PL.4027	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.55	0	4	1	97	0.00	0.0	3.847	0.005	0	0	0	1
PD.481	PL.4024	C	50H	7.48Y	124.6	0.00	0.40	0.55	1	4	1	97	0.00	0.0	3.847	0.005	0	0	0	1
PL.4025	PD.481	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.55	0	4	1	97	0.00	0.0	3.864	0.016	4	1	1	1
PL.3905	PL.4027	ABC	#4/0 ACSR	7.47Y	124.6	0.03	0.42	40.68	12	876	254	96	0.14	0.0	3.907	0.064	3	1	1	228
PL.3906	PL.3905	ABC	#3/0 ACSR	7.47Y	124.5	0.08	0.50	40.56	14	874	253	96	0.41	0.0	4.057	0.150	0	0	0	227
PL.3832	PL.3906	ABC	#4/0 ACSR	7.47Y	124.5	0.04	0.55	40.56	12	873	252	96	0.23	0.0	4.160	0.103	0	0	0	227
PL.3788	PL.3832	ABC	#4/0 ACSR	7.46Y	124.4	0.08	0.62	40.56	12	873	252	96	0.39	0.0	4.337	0.177	0	0	0	227
PL.3790	PL.3788	ABC	#4/0 ACSR	7.46Y	124.3	0.07	0.70	40.56	12	873	251	96	0.37	0.0	4.505	0.168	0	0	0	227
PL.3833	PL.3790	ABC	#4/0 ACSR	7.46Y	124.3	0.05	0.75	40.56	12	872	250	96	0.26	0.0	4.623	0.118	0	0	0	227
PL.3520	PL.3833	ABC	#4/0 ACSR	7.45Y	124.2	0.08	0.82	40.40	12	869	249	96	0.39	0.0	4.800	0.177	0	0	0	225
PL.3791	PL.3520	ABC	#4/0 ACSR	7.45Y	124.1	0.08	0.90	40.40	12	868	248	96	0.41	0.0	4.987	0.187	0	0	0	225
PL.3779	PL.3791	ABC	#4/0 ACSR	7.44Y	124.0	0.10	1.00	40.40	12	868	248	96	0.49	0.1	5.212	0.225	0	0	0	225
PL.4003	PL.3779	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.32	0	2	1	89	0.00	0.0	5.216	0.005	0	0	0	2
PD.447	PL.4003	C	40QA	7.44Y	124.0	0.00	1.00	0.32	1	2	1	89	0.00	0.0	5.216	0.005	0	0	0	2
PL.4004	PD.447	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.32	0	2	1	89	0.00	0.0	5.239	0.022	2	1	2	2
PL.4040	PL.3779	B	6 A (CWC)	7.43Y	123.8	0.15	1.16	30.65	22	219	62	96	0.25	0.1	5.321	0.110	0	0	0	62
PD.488	PL.4040	B	70L	7.43Y	123.8	0.00	1.16	30.65	44	219	62	96	0.00	0.0	5.321	0.110	0	0	0	62
PL.4041	PD.488	B	6 A (CWC)	7.42Y	123.6	0.23	1.38	30.65	22	219	62	96	0.37	0.2	5.483	0.162	0	0	0	62
PL.3890	PL.4041	B	6 A (CWC)	7.41Y	123.6	0.06	1.44	30.65	22	219	61	96	0.09	0.0	5.522	0.040	3	1	1	62
PL.3891	PL.3890	B	6 A (CWC)	7.41Y	123.5	0.10	1.54	30.22	22	216	61	96	0.16	0.1	5.594	0.072	0	0	0	61
PL.3892	PL.3891	B	6 A (CWC)	7.41Y	123.4	0.02	1.56	30.22	22	216	60	96	0.04	0.0	5.612	0.018	7	2	2	61
PL.3664	PL.3892	B	6 A (CWC)	7.41Y	123.4	0.00	1.56	1.68	1	12	3	97	0.00	0.0	5.664	0.052	12	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3665	PL.3892	B	6 A (CWC)	7.39Y	123.2	0.20	1.76	27.62	20	197	55	96	0.30	0.2	5.772	0.160	0	0	0	57
PL.3893	PL.3665	B	6 A (CWC)	7.39Y	123.2	0.01	1.77	4.63	3	33	9	96	0.00	0.0	5.815	0.043	6	2	1	9
PL.3894	PL.3893	B	6 A (CWC)	7.39Y	123.2	0.02	1.79	3.80	3	27	8	96	0.00	0.0	5.910	0.096	0	0	0	8
PL.3671	PL.3894	B	6 A (CWC)	7.39Y	123.2	0.01	1.79	3.42	2	24	7	96	0.00	0.0	5.976	0.066	18	5	5	7
PL.3673	PL.3671	B	#1/0 ACSR	7.39Y	123.2	0.00	1.79	0.87	0	6	2	95	0.00	0.0	6.002	0.026	6	2	2	2
PL.3672	PL.3894	B	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.38	0	3	1	95	0.00	0.0	5.981	0.070	3	1	1	1
PL.3670	PL.3665	B	6 A (CWC)	7.39Y	123.1	0.14	1.91	23.00	16	164	46	96	0.17	0.1	5.907	0.135	0	0	0	48
PL.3674	PL.3670	B	6 A (CWC)	7.38Y	123.1	0.02	1.92	4.24	3	30	8	97	0.00	0.0	5.994	0.087	5	1	1	9
PL.3675	PL.3674	B	6 A (CWC)	7.38Y	123.1	0.00	1.92	0.49	0	3	1	95	0.00	0.0	6.002	0.008	0	0	0	1
PL.3677	PL.3675	B	6 A (CWC)	7.38Y	123.1	0.00	1.92	0.49	0	3	1	95	0.00	0.0	6.064	0.062	3	1	1	1
PL.3676	PL.3674	B	#2 ACSR	7.38Y	123.1	0.00	1.92	3.08	2	22	6	96	0.00	0.0	6.019	0.024	16	4	5	7
PL.3678	PL.3676	B	#1/0 ACSR	7.38Y	123.1	0.00	1.92	0.86	0	6	2	95	0.00	0.0	6.068	0.049	6	2	2	2
PL.3679	PL.3670	B	6 A (CWC)	7.38Y	123.0	0.10	2.00	18.76	13	133	37	96	0.10	0.1	6.022	0.115	0	0	0	39
PL.3901	PL.3679	B	6 A (CWC)	7.37Y	122.9	0.10	2.11	18.76	13	133	37	96	0.10	0.1	6.142	0.120	2	1	1	39
PL.3902	PL.3901	B	6 A (CWC)	7.37Y	122.9	0.02	2.13	18.48	13	131	37	96	0.02	0.0	6.167	0.024	1	0	1	38
PL.3680	PL.3902	B	6 A (CWC)	7.37Y	122.8	0.03	2.15	6.13	4	43	12	96	0.01	0.0	6.283	0.116	19	5	4	14
PL.3704	PL.3680	B	#2 ACSR	7.37Y	122.8	0.00	2.15	0.80	0	6	2	95	0.00	0.0	6.306	0.022	6	2	4	4
PL.3705	PL.3680	B	#4 ACSR	7.37Y	122.8	0.00	2.15	1.02	1	7	2	96	0.00	0.0	6.360	0.077	7	2	3	3
PL.3706	PL.3705	B	#4 ACSR	7.37Y	122.8	0.00	2.15	0.00	0	0	0	100	0.00	0.0	6.396	0.037	0	0	0	0
PL.3903	PL.3680	B	6 A (CWC)	7.37Y	122.8	0.00	2.16	1.67	1	12	3	97	0.00	0.0	6.343	0.060	5	1	1	3
PL.3904	PL.3903	B	6 A (CWC)	7.37Y	122.8	0.00	2.16	0.96	1	7	2	96	0.00	0.0	6.378	0.035	0	0	0	2
PL.3707	PL.3904	B	6 A (CWC)	7.37Y	122.8	0.00	2.16	0.64	0	5	1	98	0.00	0.0	6.516	0.138	5	1	1	1
PL.3708	PL.3904	B	#2 ACSR	7.37Y	122.8	0.00	2.16	0.32	0	2	1	89	0.00	0.0	6.407	0.029	2	1	1	1
PL.3846	PL.3902	B	6 A (CWC)	7.37Y	122.8	0.04	2.16	12.20	9	87	24	96	0.02	0.0	6.235	0.068	5	1	2	23
PL.3682	PL.3846	B	#4 ACSR	7.37Y	122.8	0.00	2.17	0.99	1	7	2	96	0.00	0.0	6.289	0.054	2	1	2	3
PL.3683	PL.3682	B	#4 ACSR	7.37Y	122.8	0.00	2.17	0.66	1	5	1	98	0.00	0.0	6.332	0.043	5	1	1	1
PL.3681	PL.3846	B	6 A (CWC)	7.37Y	122.8	0.04	2.20	10.54	8	75	21	96	0.02	0.0	6.324	0.089	9	2	3	18
PL.3685	PL.3681	B	6 A (CWC)	7.37Y	122.8	0.04	2.24	9.30	7	66	18	96	0.02	0.0	6.410	0.085	0	0	0	15
PL.3686	PL.3685	B	6 A (CWC)	7.37Y	122.8	0.01	2.25	9.30	7	66	18	96	0.00	0.0	6.429	0.019	0	0	0	15
PL.3899	PL.3686	B	6 A (CWC)	7.36Y	122.7	0.00	2.25	2.14	2	15	4	97	0.00	0.0	6.468	0.039	0	0	1	5
PL.3900	PL.3899	B	6 A (CWC)	7.36Y	122.7	0.01	2.27	2.07	1	15	4	97	0.00	0.0	6.606	0.138	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3898	PL.3900	B	6 A (CWC)	7.36Y	122.7	0.01	2.27	2.07	1	15	4	97	0.00	0.0	6.709	0.103	6	2	2	4
PL.3897	PL.3898	B	6 A (CWC)	7.36Y	122.7	0.00	2.28	1.19	1	8	2	97	0.00	0.0	6.810	0.101	6	2	1	2
PL.3710	PL.3897	B	#4 ACSR	7.36Y	122.7	0.00	2.28	0.28	0	2	1	89	0.00	0.0	6.864	0.054	2	1	1	1
PL.3687	PL.3686	B	#2 ACSR	7.36Y	122.7	0.02	2.27	7.16	4	51	14	96	0.01	0.0	6.535	0.106	0	0	0	10
PL.3709	PL.3687	B	6 A (CWC)	7.36Y	122.7	0.05	2.33	7.16	5	51	14	96	0.02	0.0	6.695	0.161	0	0	0	10
PL.3689	PL.3709	B	6 A (CWC)	7.36Y	122.7	0.01	2.34	2.39	2	17	5	96	0.00	0.0	6.786	0.090	0	0	0	4
PL.3694	PL.3689	B	6 A (CWC)	7.36Y	122.6	0.02	2.35	2.39	2	17	5	96	0.00	0.0	6.936	0.150	0	0	0	4
PL.3793	PL.3694	B	6 A (CWC)	7.36Y	122.6	0.01	2.36	2.39	2	17	5	96	0.00	0.0	7.007	0.071	0	0	0	4
PL.3695	PL.3793	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	7.048	0.042	0	0	0	0
PL.2273	PL.3695	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	7.053	0.005	0	0	0	0
PL.3703	PL.3793	B	6 A (CWC)	7.36Y	122.6	0.01	2.37	2.39	2	17	5	96	0.00	0.0	7.120	0.114	0	0	0	4
PL.3701	PL.3703	B	6 A (CWC)	7.36Y	122.6	0.00	2.38	1.87	1	13	4	96	0.00	0.0	7.174	0.054	10	3	1	3
PL.3699	PL.3701	B	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.46	0	3	1	95	0.00	0.0	7.206	0.033	0	0	0	2
PL.3697	PL.3699	B	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.18	0	1	0	100	0.00	0.0	7.259	0.052	1	0	1	1
PL.3700	PL.3699	B	#4 ACSR	7.36Y	122.6	0.00	2.38	0.28	0	2	1	89	0.00	0.0	7.219	0.013	0	0	0	1
PL.3698	PL.3700	B	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.28	0	2	1	89	0.00	0.0	7.253	0.034	2	1	1	1
PL.3702	PL.3703	B	#4 ACSR	7.36Y	122.6	0.00	2.37	0.52	0	4	1	97	0.00	0.0	7.188	0.067	4	1	1	1
PL.3690	PL.3709	B	#1/0 ACSR	7.36Y	122.7	0.01	2.33	4.77	2	34	9	97	0.00	0.0	6.766	0.070	0	0	0	6
PL.3522	PL.3690	B	#1/0 ACSR	7.36Y	122.7	0.00	2.34	2.56	1	18	5	96	0.00	0.0	6.835	0.069	9	3	1	3
PL.3711	PL.3522	B	#4 ACSR	7.36Y	122.7	0.00	2.34	1.22	1	9	2	98	0.00	0.0	6.872	0.037	3	1	1	2
PL.3693	PL.3711	B	#4 ACSR	7.36Y	122.7	0.00	2.34	0.78	1	6	2	95	0.00	0.0	6.884	0.012	6	2	1	1
PL.3691	PL.3690	B	#4 ACSR	7.36Y	122.7	0.00	2.34	2.21	2	16	4	97	0.00	0.0	6.830	0.064	16	4	3	3
PL.3684	PL.3681	B	6 A (CWC)	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	6.441	0.117	0	0	0	0
PL.3835	PL.3684	B	6 A (CWC)	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	6.501	0.059	0	0	0	0
PL.3669	PL.3779	ABC	#4/0 ACSR	7.44Y	124.0	0.01	1.02	30.08	9	645	184	96	0.05	0.0	5.256	0.045	15	4	4	161
PL.3713	PL.3669	A	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.43	0	3	1	95	0.00	0.0	5.309	0.053	0	0	0	2
PL.4020	PL.3713	A	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.43	0	3	1	95	0.00	0.0	5.314	0.005	0	0	0	2
PD.479	PL.4020	A	40QA	7.44Y	124.0	0.00	1.02	0.43	1	3	1	95	0.00	0.0	5.314	0.005	0	0	0	2
PL.4021	PD.479	A	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.43	0	3	1	95	0.00	0.0	5.356	0.042	3	1	2	2
PL.4022	PL.3669	A	6 A (CWC)	7.44Y	124.0	0.00	1.02	2.51	2	18	5	96	0.00	0.0	5.261	0.005	0	0	0	2
PD.480	PL.4022	A	40QA	7.44Y	124.0	0.00	1.02	2.51	6	18	5	96	0.00	0.0	5.261	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4023	PD.480	A	6 A (CWC)	7.44Y	124.0	0.00	1.02	2.51	2	18	5	96	0.00	0.0	5.289	0.028	18	5	2	2
PL.3714	PL.3669	ABC	#4/0 ACSR	7.44Y	124.0	0.03	1.05	28.40	8	609	174	96	0.11	0.0	5.358	0.101	13	4	2	153
PL.3847	PL.3714	ABC	#4/0 ACSR	7.44Y	123.9	0.03	1.08	27.81	8	597	170	96	0.12	0.0	5.472	0.115	9	3	1	151
PL.3848	PL.3847	ABC	#4/0 ACSR	7.43Y	123.9	0.02	1.10	27.17	8	583	166	96	0.08	0.0	5.556	0.083	0	0	0	149
PL.3523	PL.3848	ABC	#4/0 ACSR	7.43Y	123.8	0.06	1.16	25.65	8	550	157	96	0.18	0.0	5.757	0.201	0	0	0	143
PL.3794	PL.3523	ABC	#4/0 ACSR	7.43Y	123.8	0.04	1.20	25.65	8	550	157	96	0.12	0.0	5.899	0.142	0	0	0	143
PL.3721	PL.3794	ABC	#4/0 ACSR	7.43Y	123.8	0.05	1.24	25.64	8	550	157	96	0.15	0.0	6.068	0.169	0	0	0	142
PL.4014	PL.3721	A	6 A (CWC)	7.43Y	123.8	0.00	1.24	0.19	0	1	0	100	0.00	0.0	6.073	0.005	0	0	0	1
PD.476	PL.4014	A	40QA	7.43Y	123.8	0.00	1.24	0.19	0	1	0	100	0.00	0.0	6.073	0.005	0	0	0	1
PL.4015	PD.476	A	6 A (CWC)	7.43Y	123.8	0.00	1.24	0.19	0	1	0	100	0.00	0.0	6.110	0.037	1	0	1	1
PL.3722	PL.3721	ABC	#4/0 ACSR	7.42Y	123.7	0.06	1.30	25.58	8	548	156	96	0.18	0.0	6.278	0.210	0	0	0	141
PL.3723	PL.3722	ABC	#4/0 ACSR	7.42Y	123.6	0.06	1.37	25.38	7	544	154	96	0.20	0.0	6.516	0.238	0	0	0	140
PL.3726	PL.3723	ABC	#4/0 ACSR	7.42Y	123.6	0.04	1.40	23.36	7	500	142	96	0.11	0.0	6.668	0.151	0	0	0	129
PL.4047	PL.3726	ABC	#4/0 ACSR	7.42Y	123.6	0.01	1.41	23.36	7	500	142	96	0.02	0.0	6.697	0.030	7	2	2	129
PL.3851	PL.4047	ABC	#4/0 ACSR	7.41Y	123.6	0.03	1.44	23.03	7	493	140	96	0.08	0.0	6.816	0.119	7	2	1	127
PL.3852	PL.3851	ABC	#4/0 ACSR	7.41Y	123.5	0.03	1.47	22.48	7	481	136	96	0.07	0.0	6.923	0.107	3	1	1	122
PL.3796	PL.3852	ABC	#1/0 ACSR	7.41Y	123.4	0.11	1.57	22.36	10	478	136	96	0.35	0.1	7.187	0.264	0	0	0	121
PL.3510	PL.3796	C	6 A (CWC)	7.41Y	123.4	0.00	1.57	0.46	0	3	1	95	0.00	0.0	7.192	0.005	0	0	0	3
PD.471	PL.3510	C	40QA	7.41Y	123.4	0.00	1.57	0.46	1	3	1	95	0.00	0.0	7.192	0.005	0	0	0	3
PL.3511	PD.471	C	6 A (CWC)	7.41Y	123.4	0.00	1.57	0.46	0	3	1	95	0.00	0.0	7.282	0.091	3	1	3	3
PL.10580	PL.3796	ABC	#1/0 ACSR	7.40Y	123.4	0.04	1.62	22.21	10	475	134	96	0.14	0.0	7.294	0.107	0	0	0	118
PD.1910	PL.10580	ABC	70L	7.40Y	123.4	0.00	1.62	22.21	32	475	134	96	0.00	0.0	7.294	0.107	0	0	0	118
PL.10581	PD.1910	ABC	#1/0 ACSR	7.40Y	123.4	0.00	1.62	22.21	10	475	134	96	0.00	0.0	7.296	0.002	0	0	0	118
PL.4032	PL.10581	B	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.73	1	5	1	98	0.00	0.0	7.300	0.004	0	0	0	1
PD.484	PL.4032	B	40QA	7.40Y	123.4	0.00	1.62	0.73	2	5	1	98	0.00	0.0	7.300	0.004	0	0	0	1
PL.4033	PD.484	B	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.73	1	5	1	98	0.00	0.0	7.342	0.042	5	1	1	1
PL.3733	PL.4033	B	#4/0 ACSR	7.40Y	123.4	0.00	1.62	0.00	0	0	0	100	0.00	0.0	7.424	0.082	0	0	0	0
PL.4034	PL.10581	B	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.59	0	4	1	97	0.00	0.0	7.300	0.005	0	0	0	3
PD.485	PL.4034	B	15T	7.40Y	123.4	0.00	1.62	0.59	0	4	1	97	0.00	0.0	7.300	0.005	0	0	0	3
PL.4035	PD.485	B	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.59	0	4	1	97	0.00	0.0	7.405	0.105	4	1	3	3
PL.3732	PL.10581	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.66	21.76	9	465	131	96	0.14	0.0	7.405	0.110	0	0	0	114

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3525	PL.3732	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.70	20.43	9	436	123	96	0.12	0.0	7.512	0.106	1	0	1	107
PL.3735	PL.3525	ABC	#1/0 ACSR	7.39Y	123.2	0.07	1.77	20.36	9	435	123	96	0.21	0.0	7.699	0.188	0	0	0	106
PL.3983	PL.3735	ABC	#1/0 ACSR	7.39Y	123.2	0.05	1.82	20.36	9	435	123	96	0.15	0.0	7.837	0.138	2	1	5	106
PL.3985	PL.3983	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.84	20.24	9	432	122	96	0.07	0.0	7.905	0.068	1	0	1	101
PL.3986	PL.3985	ABC	#1/0 ACSR	7.39Y	123.1	0.03	1.87	20.17	9	430	121	96	0.09	0.0	7.989	0.085	7	2	2	100
PL.3984	PL.3986	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.89	19.82	9	423	119	96	0.06	0.0	8.046	0.057	0	0	0	98
PL.3506	PL.3984	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.85	0	6	2	95	0.00	0.0	8.051	0.004	0	0	0	1
PD.469	PL.3506	A	15T	7.39Y	123.1	0.00	1.89	0.85	0	6	2	95	0.00	0.0	8.051	0.004	0	0	0	1
PL.3507	PD.469	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.85	0	6	2	95	0.00	0.0	8.078	0.027	6	2	1	1
PL.3526	PL.3984	ABC	#1/0 ACSR	7.38Y	123.0	0.07	1.96	19.54	8	417	117	96	0.19	0.0	8.237	0.191	9	2	1	97
PL.3980	PL.3526	ABC	#1/0 ACSR	7.38Y	123.0	0.02	1.98	19.12	8	408	115	96	0.06	0.0	8.299	0.062	0	0	0	96
PL.3981	PL.3980	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.01	18.88	8	402	113	96	0.08	0.0	8.388	0.089	10	3	3	95
PL.3982	PL.3981	ABC	#1/0 ACSR	7.38Y	123.0	0.02	2.03	18.42	8	393	110	96	0.05	0.0	8.450	0.062	9	3	2	92
PL.4050	PL.3982	ABC	#1/0 ACSR	7.38Y	123.0	0.01	2.04	17.99	8	383	108	96	0.03	0.0	8.486	0.036	0	0	0	90
PL.4051	PL.4050	ABC	#1/0 ACSR	7.38Y	122.9	0.03	2.07	17.99	8	383	108	96	0.08	0.0	8.577	0.091	0	0	0	90
PL.3502	PL.4051	C	#2 ACSR	7.38Y	122.9	0.00	2.07	6.14	4	44	12	96	0.00	0.0	8.581	0.004	0	0	0	9
PD.467	PL.3502	C	40QA	7.38Y	122.9	0.00	2.07	6.14	15	44	12	96	0.00	0.0	8.581	0.004	0	0	0	9
PL.3503	PD.467	C	#2 ACSR	7.38Y	122.9	0.00	2.08	6.14	4	44	12	96	0.00	0.0	8.594	0.013	0	0	0	9
PL.3736	PL.3503	C	#2 ACSR	7.38Y	122.9	0.00	2.08	6.14	4	44	12	96	0.00	0.0	8.630	0.036	44	12	9	9
PL.3527	PL.4051	ABC	#1/0 ACSR	7.37Y	122.9	0.04	2.11	15.95	7	340	96	96	0.08	0.0	8.700	0.123	0	0	0	81
PL.3528	PL.3527	ABC	#1/0 ACSR	7.37Y	122.9	0.01	2.12	9.01	4	192	54	96	0.02	0.0	8.785	0.085	0	0	0	42
PL.3533	PL.3528	ABC	#1/0 ACSR	7.37Y	122.8	0.03	2.15	7.93	3	169	47	96	0.03	0.0	8.980	0.195	0	0	0	38
PL.3816	PL.3533	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.17	7.93	3	169	47	96	0.03	0.0	9.133	0.153	0	0	0	38
PL.3754	PL.3816	ABC	#1/0 ACSR	7.37Y	122.8	0.03	2.21	7.93	3	169	47	96	0.04	0.0	9.363	0.230	0	0	0	38
PL.3534	PL.3754	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.22	7.71	3	164	46	96	0.02	0.0	9.490	0.127	0	0	0	36
PL.3949	PL.3534	ABC	#3/0 ACSR	7.37Y	122.8	0.00	2.23	2.44	1	52	14	97	0.00	0.0	9.569	0.079	0	0	0	16
PL.3950	PL.3949	ABC	#3/0 ACSR	7.37Y	122.8	0.01	2.23	2.44	1	52	14	97	0.00	0.0	9.751	0.182	0	0	0	16
PL.3845	PL.3950	ABC	#1/0 ACSR	7.37Y	122.8	0.01	2.24	2.44	1	52	14	97	0.00	0.0	9.890	0.140	0	0	0	16
PL.3823	PL.3845	ABC	#1/0 ACSR	7.37Y	122.8	0.01	2.24	2.44	1	52	14	97	0.00	0.0	10.023	0.133	0	0	0	16
PL.3494	PL.3823	B	6 A (CWC)	7.36Y	122.7	0.03	2.28	7.31	5	52	14	97	0.01	0.0	10.120	0.096	0	0	0	16
PD.463	PL.3494	B	40QA	7.36Y	122.7	0.00	2.28	7.31	18	52	14	97	0.00	0.0	10.120	0.096	0	0	0	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3495	PD.463	B	6 A (CWC)	7.36Y	122.7	0.06	2.33	7.31	5	52	14	97	0.02	0.0	10.297	0.177	0	0	0	16
PL.3757	PL.3495	B	6 A (CWC)	7.36Y	122.7	0.00	2.34	1.94	1	14	4	96	0.00	0.0	10.360	0.063	7	2	2	3
PL.3760	PL.3757	B	6 A (CWC)	7.36Y	122.7	0.00	2.34	0.97	1	7	2	96	0.00	0.0	10.458	0.098	7	2	1	1
PL.32697	PL.3495	B	6 A (CWC)	7.36Y	122.6	0.02	2.36	5.37	4	38	11	96	0.01	0.0	10.394	0.097	3	1	1	13
PL.32696	PL.32697	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	4.93	4	35	10	96	0.00	0.0	10.415	0.022	1	0	1	12
PL.3938	PL.32696	B	6 A (CWC)	7.36Y	122.6	0.02	2.38	4.73	3	34	9	97	0.01	0.0	10.518	0.102	4	1	4	11
PL.3936	PL.3938	B	6 A (CWC)	7.36Y	122.6	0.01	2.39	4.24	3	30	8	97	0.00	0.0	10.573	0.055	3	1	2	7
PL.3935	PL.3936	B	6 A (CWC)	7.36Y	122.6	0.01	2.40	3.84	3	27	8	96	0.00	0.0	10.631	0.058	0	0	0	5
PL.3933	PL.3935	B	6 A (CWC)	7.36Y	122.6	0.01	2.41	3.28	2	23	6	97	0.00	0.0	10.680	0.049	6	2	1	4
PL.3934	PL.3933	B	6 A (CWC)	7.35Y	122.6	0.01	2.42	2.46	2	17	5	96	0.00	0.0	10.795	0.115	10	3	1	3
PL.3932	PL.3934	B	6 A (CWC)	7.35Y	122.6	0.00	2.42	0.98	1	7	2	96	0.00	0.0	10.882	0.087	1	0	1	2
PL.3775	PL.3932	B	6 A (CWC)	7.35Y	122.6	0.00	2.42	0.00	0	0	0	100	0.00	0.0	10.944	0.062	0	0	0	0
PL.3774	PL.3932	B	#2 ACSR	7.35Y	122.6	0.00	2.43	0.80	0	6	2	95	0.00	0.0	10.973	0.091	0	0	0	1
PL.3536	PL.3774	B	#2 ACSR	7.35Y	122.6	0.00	2.43	0.00	0	0	0	100	0.00	0.0	11.095	0.122	0	0	0	0
PL.3776	PL.3774	B	#4 ACSR	7.35Y	122.6	0.00	2.43	0.80	1	6	2	95	0.00	0.0	10.993	0.020	6	2	1	1
PL.3773	PL.3935	B	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.56	0	4	1	97	0.00	0.0	10.701	0.070	4	1	1	1
PL.3764	PL.3534	B	6 A (CWC)	7.36Y	122.7	0.03	2.26	15.83	11	112	31	96	0.03	0.0	9.539	0.049	13	4	3	20
PL.3766	PL.3764	B	6 A (CWC)	7.36Y	122.7	0.00	2.26	14.00	10	99	28	96	0.00	0.0	9.544	0.005	0	0	0	17
PD.462	PL.3766	B	20T	7.36Y	122.7	0.00	2.26	14.00	0	99	28	96	0.00	0.0	9.544	0.005	0	0	0	17
PL.3856	PD.462	B	6 A (CWC)	7.36Y	122.7	0.00	2.26	0.91	1	6	2	95	0.00	0.0	9.559	0.015	0	0	0	1
PL.3765	PL.3856	B	6 A (CWC)	7.36Y	122.7	0.00	2.26	0.91	1	6	2	95	0.00	0.0	9.570	0.010	6	2	1	1
PL.3535	PD.462	B	6 A (CWC)	7.36Y	122.7	0.03	2.29	13.09	9	93	26	96	0.02	0.0	9.597	0.053	8	2	1	16
PL.3767	PL.3535	B	6 A (CWC)	7.36Y	122.7	0.02	2.31	12.03	9	85	24	96	0.01	0.0	9.643	0.046	15	4	2	15
PL.3941	PL.3767	B	6 A (CWC)	7.36Y	122.7	0.03	2.35	8.84	6	63	18	96	0.01	0.0	9.722	0.079	0	0	1	12
PL.3947	PL.3941	B	6 A (CWC)	7.36Y	122.6	0.01	2.36	8.80	6	62	17	96	0.00	0.0	9.750	0.028	9	2	1	11
PL.3948	PL.3947	B	6 A (CWC)	7.36Y	122.6	0.01	2.37	7.55	5	54	15	96	0.00	0.0	9.790	0.040	18	5	2	10
PL.3770	PL.3948	B	6 A (CWC)	7.36Y	122.6	0.02	2.39	4.22	3	30	8	97	0.00	0.0	9.902	0.112	0	0	0	6
PL.3771	PL.3770	B	#4 ACSR	7.36Y	122.6	0.00	2.39	0.64	0	5	1	98	0.00	0.0	9.937	0.035	5	1	1	1
PL.3944	PL.3770	B	6 A (CWC)	7.36Y	122.6	0.01	2.40	3.58	3	25	7	96	0.00	0.0	9.967	0.064	3	1	1	5
PL.3945	PL.3944	B	6 A (CWC)	7.36Y	122.6	0.00	2.40	3.15	2	22	6	96	0.00	0.0	10.008	0.041	11	3	1	4
PL.3946	PL.3945	B	6 A (CWC)	7.36Y	122.6	0.00	2.41	1.61	1	11	3	96	0.00	0.0	10.085	0.077	5	1	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3942	PL.3946	B	6 A (CWC)	7.36Y	122.6	0.00	2.41	0.87	1	6	2	95	0.00	0.0	10.171	0.086	2	0	1	2
PL.3943	PL.3942	B	6 A (CWC)	7.36Y	122.6	0.00	2.42	0.65	0	5	1	98	0.00	0.0	10.319	0.148	0	0	0	1
PL.3821	PL.3943	B	6 A (CWC)	7.35Y	122.6	0.00	2.42	0.65	0	5	1	98	0.00	0.0	10.442	0.123	5	1	1	1
PL.3769	PL.3948	B	#2 ACSR	7.36Y	122.6	0.00	2.37	0.80	0	6	2	95	0.00	0.0	9.830	0.039	1	0	1	2
PL.3772	PL.3769	B	#1/0 ACSR	7.36Y	122.6	0.00	2.37	0.66	0	5	1	98	0.00	0.0	9.976	0.147	0	0	0	1
PL.3818	PL.3772	B	#1/0 ACSR	7.36Y	122.6	0.00	2.37	0.66	0	5	1	98	0.00	0.0	10.095	0.119	0	0	0	1
PL.3819	PL.3818	B	#1/0 ACSR	7.36Y	122.6	0.00	2.37	0.66	0	5	1	98	0.00	0.0	10.180	0.084	5	1	1	1
PL.3768	PL.3767	B	#4 ACSR	7.36Y	122.7	0.00	2.31	1.03	1	7	2	96	0.00	0.0	9.684	0.041	7	2	1	1
PL.3496	PL.3754	A	#2 ACSR	7.37Y	122.8	0.00	2.21	0.66	0	5	1	98	0.00	0.0	9.368	0.005	0	0	0	2
PD.464	PL.3496	A	40QA	7.37Y	122.8	0.00	2.21	0.66	2	5	1	98	0.00	0.0	9.368	0.005	0	0	0	2
PL.3497	PD.464	A	#2 ACSR	7.37Y	122.8	0.00	2.21	0.66	0	5	1	98	0.00	0.0	9.408	0.040	5	1	2	2
PL.3500	PL.3528	C	6 A (CWC)	7.37Y	122.9	0.00	2.12	3.22	2	23	6	97	0.00	0.0	8.790	0.005	0	0	0	4
PD.466	PL.3500	C	40QA	7.37Y	122.9	0.00	2.12	3.22	8	23	6	97	0.00	0.0	8.790	0.005	0	0	0	4
PL.3501	PD.466	C	6 A (CWC)	7.37Y	122.9	0.01	2.13	3.22	2	23	6	97	0.00	0.0	8.858	0.069	23	6	4	4
PL.4044	PL.3527	A	#1/0 ACSR	7.37Y	122.9	0.00	2.11	20.82	9	148	42	96	0.00	0.0	8.702	0.003	0	0	0	39
PL.10582	PL.4044	A	#1/0 ACSR	7.37Y	122.9	0.01	2.12	20.82	9	148	42	96	0.01	0.0	8.721	0.019	0	0	0	39
PD.1911	PL.10582	A	100CodeSMo	7.37Y	122.9	0.00	2.12	20.82	0	148	42	96	0.00	0.0	8.721	0.019	0	0	0	39
PL.10583	PD.1911	A	#1/0 ACSR	7.37Y	122.8	0.09	2.21	20.82	9	148	42	96	0.09	0.1	8.910	0.189	0	0	0	39
PL.3953	PL.10583	A	#1/0 ACSR	7.36Y	122.7	0.06	2.27	20.82	9	148	42	96	0.06	0.0	9.031	0.121	4	1	2	39
PL.3738	PL.3953	A	#1/0 ACSR	7.36Y	122.6	0.11	2.38	20.25	9	144	40	96	0.10	0.1	9.257	0.226	0	0	0	37
PL.3803	PL.3738	A	#1/0 ACSR	7.35Y	122.5	0.10	2.48	20.25	9	143	40	96	0.09	0.1	9.469	0.212	0	0	0	37
PL.3971	PL.3803	A	#1/0 ACSR	7.35Y	122.5	0.04	2.51	20.25	9	143	40	96	0.04	0.0	9.553	0.084	4	1	1	37
PL.3972	PL.3971	A	#1/0 ACSR	7.35Y	122.4	0.04	2.55	19.73	9	140	39	96	0.04	0.0	9.640	0.087	0	0	0	36
PL.3966	PL.3972	A	#1/0 ACSR	7.35Y	122.4	0.01	2.56	5.31	2	38	10	97	0.00	0.0	9.726	0.086	3	1	1	8
PL.3967	PL.3966	A	#1/0 ACSR	7.35Y	122.4	0.01	2.57	4.90	2	35	10	96	0.00	0.0	9.820	0.094	0	0	0	7
PL.3965	PL.3967	A	#1/0 ACSR	7.34Y	122.4	0.01	2.59	4.90	2	35	10	96	0.00	0.0	9.928	0.108	2	1	1	7
PL.3964	PL.3965	A	#1/0 ACSR	7.34Y	122.4	0.01	2.60	4.62	2	33	9	96	0.00	0.0	10.019	0.090	2	0	1	6
PL.3739	PL.3964	A	#4 ACSR	7.34Y	122.4	0.00	2.60	0.29	0	2	1	89	0.00	0.0	10.073	0.054	2	1	1	1
PL.3962	PL.3964	A	#1/0 ACSR	7.34Y	122.4	0.01	2.61	4.10	2	29	8	96	0.00	0.0	10.114	0.096	0	0	0	4
PL.3963	PL.3962	A	#1/0 ACSR	7.34Y	122.4	0.00	2.61	4.10	2	29	8	96	0.00	0.0	10.164	0.050	0	0	0	4
PL.3741	PL.3963	A	6 A (CWC)	7.34Y	122.4	0.00	2.61	0.17	0	1	0	100	0.00	0.0	10.197	0.033	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3742	PL.3741	A	6 A (CWC)	7.34Y	122.4	0.00	2.61	0.17	0	1	0	100	0.00	0.0	10.234	0.037	1	0	2	2
PL.3740	PL.3963	A	#1/0 ACSR	7.34Y	122.4	0.01	2.62	3.92	2	28	8	96	0.00	0.0	10.315	0.151	0	0	0	2
PL.3498	PL.3740	A	#1/0 ACSR	7.34Y	122.4	0.00	2.62	3.67	2	26	7	97	0.00	0.0	10.320	0.005	0	0	0	1
PD.465	PL.3498	A	40QA	7.34Y	122.4	0.00	2.62	3.67	9	26	7	97	0.00	0.0	10.320	0.005	0	0	0	1
PL.3743	PD.465	A	#1/0 ACSR	7.34Y	122.4	0.02	2.64	3.67	2	26	7	97	0.00	0.0	10.502	0.182	0	0	0	1
PL.3805	PL.3743	A	#1/0 ACSR	7.34Y	122.4	0.01	2.65	3.67	2	26	7	97	0.00	0.0	10.621	0.119	0	0	0	1
PL.3806	PL.3805	A	#1/0 ACSR	7.34Y	122.3	0.01	2.66	3.67	2	26	7	97	0.00	0.0	10.743	0.122	0	0	0	1
PL.3807	PL.3806	A	#1/0 ACSR	7.34Y	122.3	0.01	2.67	3.67	2	26	7	97	0.00	0.0	10.865	0.122	26	7	1	1
PL.3529	PL.3740	A	#1/0 ACSR	7.34Y	122.4	0.00	2.62	0.25	0	2	1	89	0.00	0.0	10.480	0.165	2	1	1	1
PL.3968	PL.3972	A	#1/0 ACSR	7.35Y	122.4	0.02	2.57	14.42	6	102	29	96	0.01	0.0	9.688	0.048	4	1	3	28
PL.3969	PL.3968	A	#1/0 ACSR	7.34Y	122.4	0.02	2.59	13.86	6	98	28	96	0.01	0.0	9.757	0.069	5	1	2	25
PL.3960	PL.3969	A	#1/0 ACSR	7.34Y	122.4	0.06	2.65	13.21	6	93	26	96	0.04	0.0	9.946	0.190	0	0	0	23
PL.3961	PL.3960	A	#1/0 ACSR	7.34Y	122.3	0.05	2.70	13.21	6	93	26	96	0.03	0.0	10.097	0.151	0	0	0	23
PL.3744	PL.3961	A	#4 ACSR	7.34Y	122.3	0.00	2.70	1.29	1	9	3	95	0.00	0.0	10.137	0.039	9	3	1	1
PL.3530	PL.3961	A	#1/0 ACSR	7.34Y	122.3	0.04	2.73	11.91	5	84	24	96	0.02	0.0	10.227	0.130	4	1	2	22
PL.3745	PL.3530	A	#1/0 ACSR	7.33Y	122.2	0.02	2.76	11.37	5	80	22	96	0.01	0.0	10.318	0.091	0	0	0	20
PL.3492	PL.3745	A	6 A (CWC)	7.33Y	122.2	0.00	2.76	8.85	6	63	17	97	0.00	0.0	10.323	0.004	0	0	0	15
PD.461	PL.3492	A	25T	7.33Y	122.2	0.00	2.76	8.85	0	63	17	97	0.00	0.0	10.323	0.004	0	0	0	15
PL.3493	PD.461	A	6 A (CWC)	7.33Y	122.2	0.03	2.79	8.85	6	63	17	97	0.01	0.0	10.397	0.074	0	0	0	15
PL.3748	PL.3493	A	6 A (CWC)	7.33Y	122.1	0.07	2.86	8.85	6	63	17	97	0.03	0.1	10.584	0.188	10	3	3	15
PL.3749	PL.3748	A	#4 ACSR	7.33Y	122.1	0.00	2.86	0.42	0	3	1	95	0.00	0.0	10.661	0.077	3	1	1	1
PL.3750	PL.3748	A	#4 ACSR	7.33Y	122.1	0.05	2.91	7.08	5	50	14	96	0.02	0.0	10.738	0.154	0	0	0	11
PL.3808	PL.3750	A	#4 ACSR	7.32Y	122.0	0.05	2.96	7.08	5	50	14	96	0.02	0.0	10.895	0.157	0	0	0	11
PL.3809	PL.3808	A	#4 ACSR	7.32Y	122.0	0.04	3.00	7.08	5	50	14	96	0.02	0.0	11.034	0.139	0	0	0	11
PL.3958	PL.3809	A	#4 ACSR	7.32Y	122.0	0.05	3.05	7.08	5	50	14	96	0.02	0.0	11.195	0.160	3	1	1	11
PL.3959	PL.3958	A	#4 ACSR	7.31Y	121.9	0.06	3.11	6.65	5	47	13	96	0.02	0.0	11.388	0.193	0	0	0	10
PL.3751	PL.3959	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.28	0	2	1	89	0.00	0.0	11.427	0.039	2	1	1	1
PL.3531	PL.3959	A	#4 ACSR	7.31Y	121.9	0.03	3.14	6.37	5	45	13	96	0.01	0.0	11.508	0.120	0	0	0	9
PL.3954	PL.3531	A	#4 ACSR	7.31Y	121.8	0.03	3.17	6.37	5	45	13	96	0.01	0.0	11.610	0.102	4	1	2	9
PL.3955	PL.3954	A	#4 ACSR	7.31Y	121.8	0.03	3.20	5.80	4	41	11	97	0.01	0.0	11.752	0.142	12	3	1	7
PL.3956	PL.3955	A	#4 ACSR	7.31Y	121.8	0.01	3.21	4.05	3	29	8	96	0.00	0.0	11.816	0.063	11	3	4	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3957	PL.3956	A	#4 ACSR	7.31Y	121.8	0.01	3.21	2.46	2	17	5	96	0.00	0.0	11.866	0.050	0	0	0	2
PL.3753	PL.3957	A	#4 ACSR	7.31Y	121.8	0.00	3.22	1.50	1	11	3	96	0.00	0.0	12.005	0.139	11	3	1	1
PL.3532	PL.3957	A	#4 ACSR	7.31Y	121.8	0.00	3.21	0.00	0	0	0	100	0.00	0.0	11.897	0.031	0	0	0	0
PL.3752	PL.3957	A	#4 ACSR	7.31Y	121.8	0.00	3.21	0.96	1	7	2	96	0.00	0.0	11.919	0.053	7	2	1	1
PL.4036	PL.3745	A	6 A (CWC)	7.33Y	122.2	0.00	2.76	2.52	2	18	5	96	0.00	0.0	10.323	0.005	0	0	0	5
PD.486	PL.4036	A	15T	7.33Y	122.2	0.00	2.76	2.52	0	18	5	96	0.00	0.0	10.323	0.005	0	0	0	5
PL.4037	PD.486	A	6 A (CWC)	7.33Y	122.2	0.01	2.76	2.52	2	18	5	96	0.00	0.0	10.416	0.093	6	2	1	5
PL.3940	PL.4037	A	6 A (CWC)	7.33Y	122.2	0.01	2.77	1.65	1	12	3	97	0.00	0.0	10.533	0.117	7	2	1	4
PL.3939	PL.3940	A	6 A (CWC)	7.33Y	122.2	0.01	2.78	0.61	0	4	1	97	0.00	0.0	10.713	0.180	0	0	0	3
PL.3842	PL.3939	A	6 A (CWC)	7.33Y	122.2	0.01	2.78	0.61	0	4	1	97	0.00	0.0	10.896	0.183	0	0	0	3
PL.3812	PL.3842	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.61	0	4	1	97	0.00	0.0	11.008	0.112	0	0	0	3
PL.3843	PL.3812	A	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.61	0	4	1	97	0.00	0.0	11.116	0.107	0	0	0	3
PL.3813	PL.3843	A	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.61	0	4	1	97	0.00	0.0	11.235	0.119	2	1	1	3
PL.3746	PL.3813	A	#4 ACSR	7.33Y	122.2	0.00	2.79	0.33	0	2	1	89	0.00	0.0	11.353	0.118	0	0	0	2
PL.3814	PL.3746	A	#4 ACSR	7.33Y	122.2	0.00	2.79	0.33	0	2	1	89	0.00	0.0	11.515	0.162	0	0	1	2
PL.3747	PL.3814	A	#2 ACSR	7.33Y	122.2	0.00	2.79	0.33	0	2	1	89	0.00	0.0	11.683	0.168	2	1	1	1
CP.8	PL.4050	ABC	Cap (300)	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	8.486	0.168	0	0	0	0
PL.3504	PL.3980	A	6 A (CWC)	7.38Y	123.0	0.00	1.98	0.72	1	5	1	98	0.00	0.0	8.304	0.005	0	0	0	1
PD.468	PL.3504	A	40QA	7.38Y	123.0	0.00	1.98	0.72	2	5	1	98	0.00	0.0	8.304	0.005	0	0	0	1
PL.3505	PD.468	A	6 A (CWC)	7.38Y	123.0	0.00	1.98	0.72	1	5	1	98	0.00	0.0	8.358	0.054	5	1	1	1
PL.3734	PL.3732	C	6 A (CWC)	7.40Y	123.3	0.01	1.67	4.02	3	29	8	96	0.00	0.0	7.462	0.057	1	0	1	7
PL.3508	PL.3734	C	6 A (CWC)	7.40Y	123.3	0.00	1.67	3.89	3	28	8	96	0.00	0.0	7.466	0.005	0	0	0	6
PD.470	PL.3508	C	20T	7.40Y	123.3	0.00	1.67	3.89	0	28	8	96	0.00	0.0	7.466	0.005	0	0	0	6
PL.3509	PD.470	C	6 A (CWC)	7.40Y	123.3	0.02	1.69	3.89	3	28	8	96	0.00	0.0	7.553	0.087	0	0	0	6
PL.3987	PL.3509	C	#4 ACSR	7.40Y	123.3	0.02	1.70	3.89	3	28	8	96	0.00	0.0	7.664	0.110	0	0	0	6
PL.3988	PL.3987	C	#4 ACSR	7.40Y	123.3	0.03	1.73	3.89	3	28	8	96	0.01	0.0	7.815	0.151	0	0	0	6
PL.3797	PL.3988	C	#4 ACSR	7.39Y	123.2	0.03	1.76	3.89	3	28	8	96	0.01	0.0	7.965	0.150	0	0	0	6
PL.3836	PL.3797	C	#4 ACSR	7.39Y	123.2	0.03	1.79	3.89	3	28	8	96	0.01	0.0	8.144	0.178	0	0	0	6
PL.3799	PL.3836	C	#4 ACSR	7.39Y	123.2	0.02	1.81	3.89	3	28	8	96	0.01	0.0	8.284	0.141	0	0	0	6
PL.3975	PL.3799	C	6 A (CWC)	7.39Y	123.2	0.01	1.83	3.89	3	28	8	96	0.00	0.0	8.388	0.103	12	3	2	6
PL.3976	PL.3975	C	6 A (CWC)	7.39Y	123.2	0.01	1.84	2.24	2	16	4	97	0.00	0.0	8.487	0.099	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3837	PL.3976	C	6 A (CWC)	7.39Y	123.2	0.01	1.85	2.24	2	16	4	97	0.00	0.0	8.674	0.187	15	4	3	4
PL.10578	PL.3837	C	6 A (CWC)	7.39Y	123.2	0.00	1.85	0.15	0	1	0	100	0.00	0.0	8.722	0.048	0	0	0	1
PL.10579	PL.10578	C	6 A (CWC)	7.39Y	123.2	0.00	1.85	0.15	0	1	0	100	0.00	0.0	8.771	0.049	0	0	0	1
PL.3838	PL.10579	C	6 A (CWC)	7.39Y	123.2	0.00	1.85	0.15	0	1	0	100	0.00	0.0	8.881	0.110	0	0	0	1
PL.3800	PL.3838	C	6 A (CWC)	7.39Y	123.2	0.00	1.85	0.15	0	1	0	100	0.00	0.0	9.022	0.140	0	0	0	1
PL.3801	PL.3800	C	6 A (CWC)	7.39Y	123.1	0.00	1.85	0.15	0	1	0	100	0.00	0.0	9.150	0.129	0	0	0	1
PL.3802	PL.3801	C	6 A (CWC)	7.39Y	123.1	0.00	1.85	0.15	0	1	0	100	0.00	0.0	9.294	0.143	0	0	0	1
PL.3977	PL.3802	C	6 A (CWC)	7.39Y	123.1	0.00	1.85	0.15	0	1	0	100	0.00	0.0	9.387	0.093	1	0	1	1
PL.3978	PL.3977	C	6 A (CWC)	7.39Y	123.1	0.00	1.85	0.00	0	0	0	100	0.00	0.0	9.439	0.052	0	0	0	0
PL.3512	PL.3851	C	#4 ACSR	7.41Y	123.6	0.00	1.44	0.60	0	4	1	97	0.00	0.0	6.821	0.005	0	0	0	4
PD.472	PL.3512	C	40QA	7.41Y	123.6	0.00	1.44	0.60	2	4	1	97	0.00	0.0	6.821	0.005	0	0	0	4
PL.3513	PD.472	C	#4 ACSR	7.41Y	123.6	0.00	1.44	0.60	0	4	1	97	0.00	0.0	6.846	0.026	4	1	2	4
PL.3730	PL.3513	C	#4 ACSR	7.41Y	123.6	0.00	1.44	0.00	0	0	0	100	0.00	0.0	6.907	0.060	0	0	2	2
PL.3728	PL.3723	A	6 A (CWC)	7.42Y	123.6	0.00	1.37	2.01	1	14	4	96	0.00	0.0	6.570	0.054	0	0	0	5
PL.3551	PL.3728	A	6 A (CWC)	7.42Y	123.6	0.00	1.37	2.01	1	14	4	96	0.00	0.0	6.575	0.004	0	0	0	5
PD.473	PL.3551	A	40QA	7.42Y	123.6	0.00	1.37	2.01	5	14	4	96	0.00	0.0	6.575	0.004	0	0	0	5
PL.3552	PD.473	A	6 A (CWC)	7.42Y	123.6	0.00	1.37	2.01	1	14	4	96	0.00	0.0	6.589	0.014	1	0	2	5
PL.3991	PL.3552	A	6 A (CWC)	7.42Y	123.6	0.01	1.38	1.85	1	13	4	96	0.00	0.0	6.725	0.137	4	1	1	3
PL.3989	PL.3991	A	6 A (CWC)	7.42Y	123.6	0.00	1.38	1.30	1	9	3	95	0.00	0.0	6.754	0.029	0	0	0	2
PL.3990	PL.3989	A	6 A (CWC)	7.42Y	123.6	0.00	1.39	1.30	1	9	3	95	0.00	0.0	6.828	0.074	9	3	2	2
PL.3727	PL.3723	A	#4 ACSR	7.42Y	123.6	0.01	1.37	4.06	3	29	8	96	0.00	0.0	6.594	0.078	23	6	5	6
PL.3553	PL.3727	A	#4 ACSR	7.42Y	123.6	0.00	1.37	0.89	1	6	2	95	0.00	0.0	6.598	0.005	0	0	0	1
PD.474	PL.3553	A	40QA	7.42Y	123.6	0.00	1.37	0.89	2	6	2	95	0.00	0.0	6.598	0.005	0	0	0	1
PL.3554	PD.474	A	#4 ACSR	7.42Y	123.6	0.00	1.38	0.89	1	6	2	95	0.00	0.0	6.644	0.045	6	2	1	1
PL.3555	PL.3722	A	6 A (CWC)	7.42Y	123.7	0.00	1.30	0.60	0	4	1	97	0.00	0.0	6.283	0.004	0	0	0	1
PD.475	PL.3555	A	40QA	7.42Y	123.7	0.00	1.30	0.60	1	4	1	97	0.00	0.0	6.283	0.004	0	0	0	1
PL.3729	PD.475	A	6 A (CWC)	7.42Y	123.7	0.00	1.30	0.60	0	4	1	97	0.00	0.0	6.384	0.101	4	1	1	1
PL.4030	PL.3794	C	#4 ACSR	7.43Y	123.8	0.00	1.20	0.03	0	0	0	100	0.00	0.0	5.904	0.005	0	0	0	1
PD.483	PL.4030	C	15T	7.43Y	123.8	0.00	1.20	0.03	0	0	0	100	0.00	0.0	5.904	0.005	0	0	0	1
PL.4031	PD.483	C	#4 ACSR	7.43Y	123.8	0.00	1.20	0.03	0	0	0	100	0.00	0.0	5.964	0.060	0	0	1	1
PL.4016	PL.3848	C	#4 ACSR	7.43Y	123.9	0.00	1.10	4.55	3	33	9	96	0.00	0.0	5.560	0.005	0	0	0	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.477	PL.4016	C	40QA	7.43Y	123.9	0.00	1.10	4.55	11	33	9	96	0.00	0.0	5.560	0.005	0	0	0	6
PL.4017	PD.477	C	#4 ACSR	7.43Y	123.9	0.01	1.11	4.55	3	33	9	96	0.00	0.0	5.612	0.052	6	2	1	6
PL.3715	PL.4017	C	#4 ACSR	7.43Y	123.9	0.01	1.12	3.72	3	27	7	97	0.00	0.0	5.651	0.039	0	0	0	5
PL.3717	PL.3715	C	#2 ACSR	7.43Y	123.9	0.00	1.12	1.39	1	10	3	96	0.00	0.0	5.708	0.057	0	0	0	1
PL.3718	PL.3717	C	#2 ACSR	7.43Y	123.9	0.00	1.12	1.39	1	10	3	96	0.00	0.0	5.745	0.037	10	3	1	1
PL.3716	PL.3715	C	#4 ACSR	7.43Y	123.9	0.00	1.12	2.34	2	17	5	96	0.00	0.0	5.719	0.068	17	5	4	4
PL.4018	PL.3847	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.64	0	5	1	98	0.00	0.0	5.477	0.005	0	0	0	1
PD.478	PL.4018	C	40QA	7.44Y	123.9	0.00	1.08	0.64	2	5	1	98	0.00	0.0	5.477	0.005	0	0	0	1
PL.4019	PD.478	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.64	0	5	1	98	0.00	0.0	5.510	0.033	5	1	1	1
PL.4001	PL.3833	C	6 A (CWC)	7.46Y	124.3	0.00	0.75	0.48	0	3	1	95	0.00	0.0	4.627	0.005	0	0	0	2
PD.446	PL.4001	C	40QA	7.46Y	124.3	0.00	0.75	0.48	1	3	1	95	0.00	0.0	4.627	0.005	0	0	0	2
PL.3712	PD.446	C	6 A (CWC)	7.46Y	124.3	0.00	0.75	0.48	0	3	1	95	0.00	0.0	4.761	0.134	3	1	2	2
PL.2946	PL.3918	C	#4 ACSR	7.40Y	123.4	0.00	1.61	0.59	0	4	1	97	0.00	0.0	2.161	0.005	0	0	0	1
PD.452	PL.2946	C	40QA	7.40Y	123.4	0.00	1.61	0.59	1	4	1	97	0.00	0.0	2.161	0.005	0	0	0	1
PL.2947	PD.452	C	#4 ACSR	7.40Y	123.4	0.00	1.61	0.59	0	4	1	97	0.00	0.0	2.207	0.047	4	1	1	1
PL.2948	PL.3923	A	#4 ACSR	7.41Y	123.5	0.00	1.49	1.35	1	10	3	96	0.00	0.0	1.990	0.005	0	0	0	2
PD.453	PL.2948	A	40QA	7.41Y	123.5	0.00	1.49	1.35	3	10	3	96	0.00	0.0	1.990	0.005	0	0	0	2
PL.2949	PD.453	A	#4 ACSR	7.41Y	123.5	0.00	1.49	1.35	1	10	3	96	0.00	0.0	2.063	0.073	10	3	2	2
PL.2950	PL.3919	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.11	1	8	2	97	0.00	0.0	1.760	0.005	0	0	0	1
PD.454	PL.2950	C	40QA	7.42Y	123.7	0.00	1.33	1.11	3	8	2	97	0.00	0.0	1.760	0.005	0	0	0	1
PL.2951	PD.454	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.11	1	8	2	97	0.00	0.0	1.807	0.048	0	0	0	1
PL.3629	PL.2951	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.11	1	8	2	97	0.00	0.0	1.837	0.030	8	2	1	1
PL.2952	PL.3538	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	2.70	2	19	5	97	0.00	0.0	1.335	0.005	0	0	0	4
PD.455	PL.2952	C	40QA	7.44Y	124.0	0.00	1.03	2.70	7	19	5	97	0.00	0.0	1.335	0.005	0	0	0	4
PL.2953	PD.455	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	2.70	2	19	5	97	0.00	0.0	1.355	0.020	3	1	1	4
PL.3625	PL.2953	C	6 A (CWC)	7.44Y	124.0	0.00	1.04	2.23	2	16	4	97	0.00	0.0	1.402	0.047	6	2	2	3
PL.3626	PL.3625	C	#2 ACSR	7.44Y	124.0	0.00	1.04	1.35	1	10	3	96	0.00	0.0	1.423	0.021	10	3	1	1
PL.3488	PL.3620	C	#1/0 ACSR	7.47Y	124.5	0.00	0.46	0.68	0	5	1	98	0.00	0.0	0.572	0.017	0	0	0	1
PD.459	PL.3488	C	40QA	7.47Y	124.5	0.00	0.46	0.68	2	5	1	98	0.00	0.0	0.572	0.017	0	0	0	1
PL.3489	PD.459	C	#1/0 ACSR	7.47Y	124.5	0.00	0.46	0.68	0	5	1	98	0.00	0.0	0.622	0.050	5	1	1	1
PL.3618	PL.3781	ABC	#1/0 ACSR	7.48Y	124.7	0.01	0.26	9.90	4	200	96	90	0.01	0.0	0.332	0.056	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4038	PL.3618	ABC	4/0 AL URD	7.48Y	124.7	0.00	0.26	9.90	4	200	96	90	0.00	0.0	0.336	0.005	0	0	0	1
PD.487	PL.4038	ABC	65T	7.48Y	124.7	0.00	0.26	9.90	0	200	96	90	0.00	0.0	0.336	0.005	0	0	0	1
PL.4039	PD.487	ABC	4/0 AL URD	7.48Y	124.7	0.00	0.26	9.90	4	200	96	90	0.00	0.0	0.379	0.043	200	97	1	1
PL.2956	PL.3780	C	6 A (CWC)	7.49Y	124.8	0.00	0.17	0.64	0	5	1	98	0.00	0.0	0.193	0.004	0	0	0	3
PD.457	PL.2956	C	40QA	7.49Y	124.8	0.00	0.17	0.64	2	5	1	98	0.00	0.0	0.193	0.004	0	0	0	3
PL.2957	PD.457	C	6 A (CWC)	7.49Y	124.8	0.00	0.17	0.64	0	5	1	98	0.00	0.0	0.242	0.048	5	1	3	3
PL.4053	Goose Rock	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	111.99	22	2410	734	96	0.05	0.0	0.005	0.005	0	0	0	666
PL.7159	PL.4053	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	111.99	22	2410	734	96	0.01	0.0	0.006	0.001	0	0	0	666

----- Feeder No. 3 (Brightshade F3) Beginning with Device PD.1528 -----

PD.1528	PL.7159	ABC	480VWE	7.50Y	125.0	0.00	0.00	111.99	0	2410	734	96	0.00	0.0	0.006	0.001	0	0	0	666
PL.7160	PD.1528	ABC	336 MCM AC	7.50Y	125.0	0.02	0.03	111.99	22	2410	734	96	0.30	0.0	0.034	0.028	0	0	0	666
PL.2860	PL.7160	ABC	336 MCM AC	7.49Y	124.9	0.10	0.13	111.99	22	2410	734	96	1.19	0.0	0.147	0.112	0	0	0	666
PL.2861	PL.2860	ABC	336 MCM AC	7.49Y	124.8	0.09	0.21	111.99	22	2409	731	96	1.07	0.0	0.248	0.101	0	0	0	666
PL.2862	PL.2861	ABC	336 MCM AC	7.48Y	124.7	0.06	0.27	111.99	22	2408	728	96	0.75	0.0	0.319	0.071	0	0	0	666
PL.2863	PL.2862	ABC	336 MCM AC	7.48Y	124.6	0.09	0.36	111.99	22	2407	727	96	1.07	0.0	0.420	0.101	0	0	0	666
PL.2575	PL.2863	C	#2 ACSR	7.48Y	124.6	0.00	0.36	2.78	2	20	6	96	0.00	0.0	0.443	0.023	0	0	1	4
PL.3420	PL.2575	C	#2 ACSR	7.48Y	124.6	0.00	0.36	2.78	2	20	6	96	0.00	0.0	0.447	0.005	0	0	0	3
PD.373	PL.3420	C	40QA	7.48Y	124.6	0.00	0.36	2.78	7	20	6	96	0.00	0.0	0.447	0.005	0	0	0	3
PL.3421	PD.373	C	#2 ACSR	7.48Y	124.6	0.01	0.37	2.78	2	20	6	96	0.00	0.0	0.601	0.154	20	6	3	3
PL.65760	PL.3421	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	0.709	0.108	0	0	0	0
PL.2579	PL.2863	ABC	336 MCM AC	7.47Y	124.5	0.15	0.51	109.73	21	2357	710	96	1.84	0.1	0.601	0.181	0	0	0	658
PL.2581	PL.2579	ABC	336 MCM AC	7.47Y	124.4	0.05	0.56	109.73	21	2355	706	96	0.55	0.0	0.656	0.054	0	0	0	658
PL.3169	PL.2581	ABC	336 MCM AC	7.46Y	124.4	0.09	0.65	109.00	21	2339	700	96	1.08	0.0	0.764	0.108	1	0	2	655
PL.3170	PL.3169	ABC	336 MCM AC	7.46Y	124.3	0.08	0.73	108.94	21	2337	698	96	1.00	0.0	0.864	0.100	0	0	0	653
PL.2864	PL.3170	ABC	336 MCM AC	7.45Y	124.2	0.08	0.81	108.94	21	2336	695	96	0.95	0.0	0.959	0.095	0	0	0	653
PL.2865	PL.2864	ABC	336 MCM AC	7.45Y	124.1	0.10	0.91	108.94	21	2335	693	96	1.24	0.1	1.084	0.124	0	0	0	653
PL.3590	PL.2865	ABC	336 MCM AC	7.44Y	124.1	0.02	0.94	93.05	18	1992	594	96	0.25	0.0	1.118	0.034	0	0	0	564
PD.429-A	PL.3590	ABC	Closed	7.44Y	124.1	0.00	0.94	93.05	0	1991	593	96	0.00	0.0	1.118	0.034	0	0	0	564
PD.429-B	PD.429-A	ABC	Closed	7.44Y	124.1	0.00	0.94	93.05	0	1991	593	96	0.00	0.0	1.118	0.034	0	0	0	564

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3591	PD.429-B	ABC	336 MCM AC	7.44Y	124.0	0.05	0.99	93.05	18	1991	593	96	0.55	0.0	1.193	0.076	0	0	0	564
PL.3424	PL.3591	C	#4 ACSR	7.44Y	124.0	0.00	0.99	0.34	0	2	1	89	0.00	0.0	1.198	0.005	0	0	0	1
PD.375	PL.3424	C	40QA	7.44Y	124.0	0.00	0.99	0.34	1	2	1	89	0.00	0.0	1.198	0.005	0	0	0	1
PL.3425	PD.375	C	#4 ACSR	7.44Y	124.0	0.00	0.99	0.34	0	2	1	89	0.00	0.0	1.223	0.025	2	1	1	1
PL.3091	PL.3591	ABC	336 MCM AC	7.44Y	123.9	0.07	1.06	92.94	18	1988	591	96	0.75	0.0	1.296	0.103	5	1	1	563
PL.3092	PL.3091	ABC	336 MCM AC	7.44Y	123.9	0.02	1.08	90.26	17	1930	574	96	0.17	0.0	1.321	0.025	0	0	0	552
PL.2585	PL.3092	ABC	336 MCM AC	7.43Y	123.9	0.03	1.10	90.26	17	1930	573	96	0.27	0.0	1.360	0.039	3	1	1	552
PL.3408	PL.2585	C	#4 ACSR	7.43Y	123.9	0.00	1.11	1.15	1	8	2	97	0.00	0.0	1.364	0.005	0	0	0	1
PD.368	PL.3408	C	15T	7.43Y	123.9	0.00	1.11	1.15	0	8	2	97	0.00	0.0	1.364	0.005	0	0	0	1
PL.3409	PD.368	C	#4 ACSR	7.43Y	123.9	0.00	1.11	1.15	1	8	2	97	0.00	0.0	1.380	0.016	8	2	1	1
PL.3411	PL.2585	ABC	336 MCM AC	7.43Y	123.8	0.06	1.17	89.71	17	1918	569	96	0.63	0.0	1.453	0.093	9	2	2	550
PL.3564	PL.3411	A	#2 ACSR	7.43Y	123.8	0.00	1.17	0.76	0	5	2	93	0.00	0.0	1.457	0.004	0	0	0	2
PD.417	PL.3564	A	40QA	7.43Y	123.8	0.00	1.17	0.76	2	5	2	93	0.00	0.0	1.457	0.004	0	0	0	2
PL.3565	PD.417	A	#2 ACSR	7.43Y	123.8	0.00	1.17	0.76	0	5	2	93	0.00	0.0	1.478	0.020	5	2	2	2
PL.2594	PL.3411	ABC	336 MCM AC	7.43Y	123.8	0.05	1.21	89.06	17	1903	564	96	0.45	0.0	1.521	0.068	23	6	4	546
PL.2595	PL.2594	ABC	336 MCM AC	7.42Y	123.7	0.04	1.26	87.99	17	1880	557	96	0.40	0.0	1.582	0.061	0	0	0	542
PL.3094	PL.2595	ABC	336 MCM AC	7.42Y	123.7	0.06	1.32	87.70	17	1873	554	96	0.61	0.0	1.676	0.094	1	0	1	541
PL.3404	PL.3094	A	#2 ACSR	7.42Y	123.7	0.00	1.32	9.38	5	67	19	96	0.00	0.0	1.680	0.005	0	0	0	16
PD.366	PL.3404	A	40QA	7.42Y	123.7	0.00	1.32	9.38	23	67	19	96	0.00	0.0	1.680	0.005	0	0	0	16
PL.3405	PD.366	A	#2 ACSR	7.42Y	123.7	0.01	1.33	9.38	5	67	19	96	0.00	0.0	1.714	0.033	0	0	0	16
PL.2596	PL.3405	A	#2 ACSR	7.42Y	123.7	0.02	1.34	9.38	5	67	19	96	0.01	0.0	1.770	0.056	0	0	0	16
PL.2597	PL.2596	A	6 A (CWC)	7.42Y	123.6	0.03	1.37	9.38	7	67	19	96	0.01	0.0	1.830	0.060	0	0	0	16
PL.2598	PL.2597	A	6 A (CWC)	7.42Y	123.6	0.05	1.42	9.38	7	67	19	96	0.02	0.0	1.935	0.106	0	0	0	16
PL.2599	PL.2598	A	#4 ACSR	7.41Y	123.6	0.01	1.42	5.79	4	41	12	96	0.00	0.0	1.968	0.033	2	1	1	10
PL.2604	PL.2599	A	#4 ACSR	7.41Y	123.6	0.01	1.43	5.45	4	39	11	96	0.00	0.0	2.006	0.038	8	2	1	9
PL.2605	PL.2604	A	#4 ACSR	7.41Y	123.6	0.01	1.44	4.28	3	31	9	96	0.00	0.0	2.068	0.062	5	1	1	8
PL.2606	PL.2605	A	#4 ACSR	7.41Y	123.6	0.00	1.44	0.96	1	7	2	96	0.00	0.0	2.121	0.052	7	2	1	1
PL.2607	PL.2605	A	#4 ACSR	7.41Y	123.5	0.01	1.45	2.64	2	19	5	97	0.00	0.0	2.148	0.080	0	0	1	6
PL.2608	PL.2607	A	#4 ACSR	7.41Y	123.5	0.01	1.46	2.64	2	19	5	97	0.00	0.0	2.229	0.081	7	2	1	5
PL.2609	PL.2608	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	2.287	0.058	0	0	0	0
PL.2610	PL.2608	A	#2 ACSR	7.41Y	123.5	0.00	1.46	1.68	1	12	3	97	0.00	0.0	2.245	0.016	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2611	PL.2610	A	#2 ACSR	7.41Y	123.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	2.316	0.070	0	0	1	1
PL.3402	PL.2610	A	#2 ACSR	7.41Y	123.5	0.00	1.46	1.68	1	12	3	97	0.00	0.0	2.250	0.005	0	0	0	3
PD.365	PL.3402	A	40QA	7.41Y	123.5	0.00	1.46	1.68	4	12	3	97	0.00	0.0	2.250	0.005	0	0	0	3
PL.3403	PD.365	A	#2 ACSR	7.41Y	123.5	0.00	1.46	1.68	1	12	3	97	0.00	0.0	2.263	0.013	12	3	3	3
PL.2600	PL.2598	A	#4 ACSR	7.41Y	123.6	0.01	1.42	3.59	3	26	7	97	0.00	0.0	1.996	0.061	5	1	2	6
PL.2601	PL.2600	A	#4 ACSR	7.41Y	123.6	0.00	1.43	2.90	2	21	6	96	0.00	0.0	2.030	0.034	0	0	0	4
PL.2603	PL.2601	A	#4 ACSR	7.41Y	123.6	0.00	1.43	1.94	1	14	4	96	0.00	0.0	2.072	0.042	14	4	2	2
PL.2602	PL.2601	A	#4 ACSR	7.41Y	123.6	0.00	1.43	0.97	1	7	2	96	0.00	0.0	2.082	0.052	7	2	2	2
PL.3095	PL.3094	ABC	336 MCM AC	7.42Y	123.6	0.06	1.38	84.54	16	1805	534	96	0.56	0.0	1.769	0.094	0	0	0	524
PL.3050	PL.3095	ABC	336 MCM AC	7.41Y	123.6	0.06	1.43	84.54	16	1804	532	96	0.54	0.0	1.859	0.090	0	0	0	524
PL.3166	PL.3050	ABC	336 MCM AC	7.41Y	123.5	0.04	1.47	84.29	16	1798	529	96	0.34	0.0	1.916	0.057	5	1	1	523
PL.3167	PL.3166	ABC	336 MCM AC	7.41Y	123.5	0.06	1.53	84.04	16	1793	527	96	0.54	0.0	2.006	0.090	0	0	0	522
PL.3416	PL.3167	C	#1/0 ACSR	7.41Y	123.5	0.00	1.53	0.97	0	7	2	96	0.00	0.0	2.010	0.005	0	0	0	3
PD.371	PL.3416	C	40QA	7.41Y	123.5	0.00	1.53	0.97	2	7	2	96	0.00	0.0	2.010	0.005	0	0	0	3
PL.3417	PD.371	C	#1/0 ACSR	7.41Y	123.5	0.00	1.53	0.97	0	7	2	96	0.00	0.0	2.034	0.023	0	0	0	3
PL.2612	PL.3417	C	#2 ACSR	7.41Y	123.5	0.00	1.53	0.97	1	7	2	96	0.00	0.0	2.087	0.053	7	2	3	3
PL.2871	PL.3167	ABC	336 MCM AC	7.40Y	123.4	0.11	1.64	83.72	16	1785	524	96	1.04	0.1	2.182	0.176	0	0	0	519
PL.3162	PL.2871	ABC	336 MCM AC	7.40Y	123.3	0.07	1.71	83.72	16	1784	522	96	0.63	0.0	2.289	0.106	3	1	2	519
PL.3163	PL.3162	ABC	336 MCM AC	7.39Y	123.2	0.08	1.78	83.59	16	1781	519	96	0.71	0.0	2.408	0.120	0	0	0	517
PL.3158	PL.3163	ABC	336 MCM AC	7.39Y	123.2	0.06	1.84	83.59	16	1780	518	96	0.54	0.0	2.500	0.091	0	0	0	517
PL.3159	PL.3158	ABC	336 MCM AC	7.39Y	123.1	0.02	1.86	83.59	16	1780	516	96	0.15	0.0	2.526	0.026	0	0	0	517
PL.3412	PL.3159	A	#2 ACSR	7.39Y	123.1	0.00	1.86	0.40	0	3	1	95	0.00	0.0	2.530	0.005	0	0	0	1
PD.369	PL.3412	A	40QA	7.39Y	123.1	0.00	1.86	0.40	1	3	1	95	0.00	0.0	2.530	0.005	0	0	0	1
PL.3413	PD.369	A	#2 ACSR	7.39Y	123.1	0.00	1.86	0.40	0	3	1	95	0.00	0.0	2.548	0.018	3	1	1	1
PL.3160	PL.3159	ABC	336 MCM AC	7.39Y	123.1	0.03	1.89	83.45	16	1777	515	96	0.31	0.0	2.578	0.052	0	0	0	516
PL.3161	PL.3160	ABC	336 MCM AC	7.38Y	123.0	0.07	1.96	83.45	16	1776	515	96	0.63	0.0	2.685	0.107	0	0	0	516
PL.2872	PL.3161	ABC	336 MCM AC	7.38Y	122.9	0.10	2.06	83.45	16	1776	513	96	0.95	0.1	2.848	0.163	13	4	4	516
PL.3592	PL.2872	B	#2 ACSR	7.38Y	122.9	0.00	2.06	43.65	25	310	88	96	0.01	0.0	2.851	0.003	0	0	0	97
C PD.430	PL.3592	B	50H	7.38Y	122.9	0.00	2.06	43.65	87	310	88	96	0.00	0.0	2.851	0.003	0	0	0	97 C
PL.3593	PD.430	B	#2 ACSR	7.36Y	122.7	0.20	2.26	43.65	25	310	88	96	0.44	0.1	2.994	0.143	0	0	0	97
PL.2615	PL.3593	B	#2 ACSR	7.36Y	122.6	0.15	2.41	42.40	24	300	85	96	0.32	0.1	3.107	0.113	4	1	1	95

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2617	PL.2615	B	#2 ACSR	7.35Y	122.5	0.10	2.51	41.88	24	296	84	96	0.22	0.1	3.184	0.077	0	0	0	94
PL.2618	PL.2617	B	#2 ACSR	7.35Y	122.4	0.05	2.56	41.88	24	296	84	96	0.10	0.0	3.220	0.036	0	0	0	94
PL.3156	PL.2618	B	#2 ACSR	7.34Y	122.4	0.04	2.60	41.88	24	296	84	96	0.09	0.0	3.251	0.031	0	0	0	94
PL.3157	PL.3156	B	#2 ACSR	7.34Y	122.3	0.10	2.70	41.88	24	296	84	96	0.21	0.1	3.324	0.073	0	0	0	94
PL.3155	PL.3157	B	#2 ACSR	7.33Y	122.2	0.08	2.78	41.88	24	296	84	96	0.18	0.1	3.386	0.062	0	0	0	94
PL.3153	PL.3155	B	#2 ACSR	7.32Y	122.1	0.15	2.93	41.88	24	296	83	96	0.32	0.1	3.499	0.113	4	1	2	94
PL.3154	PL.3153	B	#2 ACSR	7.32Y	122.0	0.05	2.98	41.31	24	291	82	96	0.11	0.0	3.538	0.039	7	2	2	92
PL.2621	PL.3154	B	#4 ACSR	7.32Y	122.0	0.00	2.98	0.95	1	7	2	96	0.00	0.0	3.603	0.064	2	1	1	3
PL.2622	PL.2621	B	#2 ACSR	7.32Y	122.0	0.00	2.98	0.63	0	4	1	97	0.00	0.0	3.628	0.025	4	1	2	2
PL.3119	PL.3154	B	#2 ACSR	7.32Y	122.0	0.06	3.04	39.36	22	277	78	96	0.12	0.0	3.587	0.049	4	1	2	87
PL.3120	PL.3119	B	#2 ACSR	7.31Y	121.9	0.09	3.13	37.74	22	266	75	96	0.18	0.1	3.664	0.077	2	1	1	84
PL.2624	PL.3120	B	#4 ACSR	7.31Y	121.9	0.01	3.14	3.91	3	28	8	96	0.00	0.0	3.749	0.085	15	4	2	3
PL.2623	PL.2624	B	#2 ACSR	7.31Y	121.9	0.00	3.14	1.72	1	12	3	97	0.00	0.0	3.793	0.044	12	3	1	1
PL.3121	PL.3120	B	#2 ACSR	7.30Y	121.7	0.15	3.27	33.51	19	236	66	96	0.25	0.1	3.801	0.137	0	0	0	80
PL.2874	PL.3121	B	#2 ACSR	7.30Y	121.6	0.14	3.42	33.51	19	236	66	96	0.24	0.1	3.937	0.135	5	1	2	80
PL.3152	PL.2874	B	#2 ACSR	7.29Y	121.5	0.08	3.49	32.83	19	231	65	96	0.13	0.1	4.014	0.077	11	3	2	78
PL.3122	PL.3152	B	#2 ACSR	7.29Y	121.5	0.05	3.55	28.91	17	203	57	96	0.08	0.0	4.074	0.060	3	1	2	69
PL.2626	PL.3122	B	#2 ACSR	7.28Y	121.4	0.07	3.61	28.45	16	200	56	96	0.09	0.0	4.148	0.074	4	1	4	67
PL.2630	PL.2626	B	#4 ACSR	7.28Y	121.4	0.00	3.61	1.63	1	11	3	96	0.00	0.0	4.173	0.026	11	3	1	1
PL.2632	PL.2626	B	#2 ACSR	7.27Y	121.2	0.14	3.75	26.27	15	184	52	96	0.18	0.1	4.319	0.171	7	2	4	62
PL.2634	PL.2632	B	#2 ACSR	7.27Y	121.2	0.07	3.82	25.24	14	177	50	96	0.09	0.1	4.406	0.087	1	0	1	58
PL.2635	PL.2634	B	#2 ACSR	7.27Y	121.2	0.01	3.84	25.16	14	176	49	96	0.02	0.0	4.425	0.019	8	2	1	57
PL.2636	PL.2635	B	#2 ACSR	7.27Y	121.2	0.01	3.84	24.00	14	168	47	96	0.01	0.0	4.432	0.007	0	0	1	56
PL.2637	PL.2636	B	#2 ACSR	7.27Y	121.1	0.03	3.87	22.22	13	156	44	96	0.03	0.0	4.472	0.040	1	0	2	54
PL.2639	PL.2637	B	#2 ACSR	7.27Y	121.1	0.04	3.91	17.64	10	123	35	96	0.04	0.0	4.551	0.079	10	3	4	46
PL.2642	PL.2639	B	#2 ACSR	7.27Y	121.1	0.00	3.91	0.46	0	3	1	95	0.00	0.0	4.634	0.084	3	1	2	2
PL.2645	PL.2642	B	#4 ACSR	7.27Y	121.1	0.00	3.91	0.00	0	0	0	100	0.00	0.0	4.741	0.107	0	0	0	0
PL.2646	PL.2645	B	#4 ACSR	7.27Y	121.1	0.00	3.91	0.00	0	0	0	100	0.00	0.0	4.806	0.065	0	0	0	0
PL.2643	PL.2639	B	#2 ACSR	7.26Y	121.0	0.07	3.98	15.76	9	110	31	96	0.05	0.0	4.708	0.157	23	6	4	40
PL.2648	PL.2643	B	#2 ACSR	7.26Y	120.9	0.07	4.05	12.48	7	87	24	96	0.05	0.1	4.893	0.185	3	1	3	36
PL.3394	PL.2648	B	#4 ACSR	7.26Y	120.9	0.00	4.05	2.64	2	18	5	96	0.00	0.0	4.897	0.005	0	0	0	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.360	PL.3394	B	20T	7.26Y	120.9	0.00	4.05	2.64	0	18	5	96	0.00	0.0	4.897	0.005	0	0	0	8
PL.3395	PD.360	B	#4 ACSR	7.26Y	120.9	0.01	4.07	2.64	2	18	5	96	0.00	0.0	5.022	0.124	0	0	0	8
PL.2878	PL.3395	B	#4 ACSR	7.26Y	120.9	0.01	4.08	2.64	2	18	5	96	0.00	0.0	5.134	0.113	0	0	0	8
PL.2651	PL.2878	B	#4 ACSR	7.25Y	120.9	0.02	4.10	2.64	2	18	5	96	0.00	0.0	5.291	0.157	3	1	1	8
PL.2652	PL.2651	B	#4 ACSR	7.25Y	120.9	0.01	4.11	2.24	2	16	4	97	0.00	0.0	5.407	0.116	0	0	0	7
PL.2653	PL.2652	B	#4 ACSR	7.25Y	120.9	0.01	4.12	2.24	2	16	4	97	0.00	0.0	5.519	0.113	5	1	1	7
PL.2654	PL.2653	B	#4 ACSR	7.25Y	120.9	0.01	4.13	1.55	1	11	3	96	0.00	0.0	5.679	0.160	0	0	0	6
PL.2879	PL.2654	B	#4 ACSR	7.25Y	120.9	0.01	4.14	1.55	1	11	3	96	0.00	0.0	5.773	0.093	0	0	0	6
PL.3052	PL.2879	B	#4 ACSR	7.25Y	120.9	0.01	4.15	1.55	1	11	3	96	0.00	0.0	5.880	0.107	0	0	0	6
PL.2880	PL.3052	B	#4 ACSR	7.25Y	120.8	0.01	4.15	1.55	1	11	3	96	0.00	0.0	5.992	0.112	0	0	0	6
PL.3053	PL.2880	B	#4 ACSR	7.25Y	120.8	0.01	4.16	1.55	1	11	3	96	0.00	0.0	6.080	0.088	0	0	0	6
PL.2881	PL.3053	B	#4 ACSR	7.25Y	120.8	0.01	4.17	1.55	1	11	3	96	0.00	0.0	6.176	0.097	0	0	0	6
PL.3054	PL.2881	B	#4 ACSR	7.25Y	120.8	0.01	4.17	1.55	1	11	3	96	0.00	0.0	6.255	0.079	0	0	0	6
PL.2882	PL.3054	B	#4 ACSR	7.25Y	120.8	0.01	4.18	1.55	1	11	3	96	0.00	0.0	6.352	0.097	0	0	0	6
PL.3055	PL.2882	B	#4 ACSR	7.25Y	120.8	0.01	4.19	1.55	1	11	3	96	0.00	0.0	6.457	0.105	0	0	0	6
PL.2883	PL.3055	B	#4 ACSR	7.25Y	120.8	0.01	4.19	1.55	1	11	3	96	0.00	0.0	6.532	0.075	0	0	0	6
PL.3056	PL.2883	B	#4 ACSR	7.25Y	120.8	0.01	4.20	1.55	1	11	3	96	0.00	0.0	6.632	0.100	0	0	0	6
PL.2655	PL.3056	B	#4 ACSR	7.25Y	120.8	0.00	4.20	1.55	1	11	3	96	0.00	0.0	6.679	0.047	0	0	0	6
PL.2656	PL.2655	B	#4 ACSR	7.25Y	120.8	0.01	4.21	1.36	1	9	3	95	0.00	0.0	6.847	0.169	0	0	0	3
PL.2696	PL.2656	B	#4 ACSR	7.25Y	120.8	0.00	4.22	1.36	1	9	3	95	0.00	0.0	6.927	0.080	0	0	0	3
PL.2698	PL.2696	B	#4 ACSR	7.25Y	120.8	0.00	4.22	0.63	0	4	1	97	0.00	0.0	6.996	0.069	4	1	1	1
PL.3386	PL.2696	B	#4 ACSR	7.25Y	120.8	0.00	4.22	0.72	1	5	1	98	0.00	0.0	7.096	0.169	3	1	1	2
PL.3387	PL.3386	B	#4 ACSR	7.25Y	120.8	0.00	4.22	0.30	0	2	1	89	0.00	0.0	7.259	0.163	0	0	0	1
PL.3135	PL.3387	B	#4 ACSR	7.25Y	120.8	0.00	4.22	0.30	0	2	1	89	0.00	0.0	7.332	0.072	0	0	0	1
PL.3136	PL.3135	B	#4 ACSR	7.25Y	120.8	0.00	4.22	0.30	0	2	1	89	0.00	0.0	7.351	0.019	2	1	1	1
PL.2825	PL.2655	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.20	0	1	0	100	0.00	0.0	6.758	0.080	0	0	0	3
PL.2658	PL.2825	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.20	0	1	0	100	0.00	0.0	6.922	0.164	0	0	0	3
PL.2657	PL.2658	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.20	0	1	0	100	0.00	0.0	7.007	0.085	0	0	0	3
PL.3171	PL.2657	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.20	0	1	0	100	0.00	0.0	7.090	0.083	1	0	1	3
PL.3172	PL.3171	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.05	0	0	0	100	0.00	0.0	7.188	0.098	0	0	0	2
PL.2660	PL.3172	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.05	0	0	0	100	0.00	0.0	7.277	0.089	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3143	PL.2660	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.05	0	0	0	100	0.00	0.0	7.334	0.057	0	0	1	2
PL.3144	PL.3143	B	#4 ACSR	7.25Y	120.8	0.00	4.20	0.05	0	0	0	100	0.00	0.0	7.363	0.029	0	0	1	1
PL.2659	PL.2825	B	#2 ACSR	7.25Y	120.8	0.00	4.20	0.00	0	0	0	100	0.00	0.0	6.791	0.032	0	0	0	0
PL.10154	PL.2648	B	#2 ACSR	7.26Y	120.9	0.00	4.05	9.40	5	66	18	96	0.00	0.0	4.896	0.003	0	0	0	25
PD.1878	PL.10154	B	20T	7.26Y	120.9	0.00	4.05	9.40	0	66	18	96	0.00	0.0	4.896	0.003	0	0	0	25
PL.10155	PD.1878	B	#2 ACSR	7.25Y	120.9	0.04	4.10	9.40	5	66	18	96	0.02	0.0	5.032	0.136	0	0	0	25
PL.2875	PL.10155	B	#2 ACSR	7.25Y	120.9	0.03	4.13	9.40	5	66	18	96	0.02	0.0	5.140	0.107	0	0	0	25
PL.2661	PL.2875	B	#2 ACSR	7.25Y	120.9	0.02	4.14	9.40	5	66	18	96	0.01	0.0	5.199	0.060	0	0	0	25
PL.3127	PL.2661	B	#2 ACSR	7.25Y	120.8	0.01	4.16	8.39	5	59	16	97	0.01	0.0	5.247	0.047	0	0	0	23
PL.2663	PL.3127	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.55	0	4	1	97	0.00	0.0	5.278	0.032	4	1	1	1
PL.2664	PL.3127	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.53	0	4	1	97	0.00	0.0	5.315	0.069	4	1	3	3
PL.3128	PL.3127	B	#2 ACSR	7.25Y	120.8	0.03	4.19	7.31	4	51	14	96	0.01	0.0	5.393	0.146	0	0	0	19
PL.3149	PL.3128	B	#2 ACSR	7.25Y	120.8	0.02	4.21	7.31	4	51	14	96	0.01	0.0	5.462	0.069	3	1	1	19
PL.3150	PL.3149	B	#2 ACSR	7.25Y	120.8	0.01	4.22	6.94	4	48	14	96	0.00	0.0	5.517	0.055	7	2	1	18
PL.3129	PL.3150	B	#2 ACSR	7.25Y	120.8	0.01	4.23	5.96	3	42	12	96	0.00	0.0	5.581	0.064	0	0	0	16
PL.2824	PL.3129	B	#2 ACSR	7.25Y	120.8	0.00	4.23	0.72	0	5	1	98	0.00	0.0	5.651	0.071	0	0	0	1
PL.2667	PL.2824	B	#4 ACSR	7.25Y	120.8	0.00	4.23	0.72	1	5	1	98	0.00	0.0	5.667	0.015	5	1	1	1
PL.2666	PL.3129	B	#2 ACSR	7.25Y	120.8	0.01	4.24	5.24	3	37	10	97	0.00	0.0	5.641	0.061	26	7	7	15
PL.2668	PL.2666	B	#2 ACSR	7.25Y	120.8	0.00	4.24	1.50	1	11	3	96	0.00	0.0	5.699	0.057	2	1	1	8
PL.2669	PL.2668	B	#2 ACSR	7.25Y	120.8	0.00	4.24	1.15	1	8	2	97	0.00	0.0	5.750	0.052	2	1	3	7
PL.3147	PL.2669	B	#2 ACSR	7.25Y	120.8	0.00	4.24	0.85	0	6	2	95	0.00	0.0	5.873	0.123	0	0	1	4
PL.3148	PL.3147	B	#2 ACSR	7.25Y	120.8	0.00	4.25	0.80	0	6	2	95	0.00	0.0	5.995	0.122	0	0	0	3
PL.2876	PL.3148	B	#2 ACSR	7.25Y	120.8	0.00	4.25	0.80	0	6	2	95	0.00	0.0	6.105	0.109	0	0	0	3
PL.3051	PL.2876	B	#2 ACSR	7.24Y	120.7	0.00	4.25	0.80	0	6	2	95	0.00	0.0	6.245	0.141	2	1	1	3
PL.3146	PL.3051	B	#2 ACSR	7.24Y	120.7	0.00	4.25	0.48	0	3	1	95	0.00	0.0	6.344	0.099	3	1	2	2
PL.2665	PL.3150	B	#2 ACSR	7.25Y	120.8	0.00	4.22	0.04	0	0	0	100	0.00	0.0	5.551	0.034	0	0	1	1
PL.2662	PL.2661	B	#2 ACSR	7.25Y	120.9	0.00	4.15	1.01	1	7	2	96	0.00	0.0	5.230	0.030	7	2	2	2
PL.2640	PL.2637	B	#2 ACSR	7.27Y	121.1	0.00	3.87	4.02	2	28	8	96	0.00	0.0	4.508	0.036	28	8	4	4
PL.2641	PL.2637	B	#4 ACSR	7.27Y	121.1	0.00	3.87	0.40	0	3	1	95	0.00	0.0	4.517	0.045	3	1	2	2
PL.2638	PL.2636	B	#4 ACSR	7.27Y	121.2	0.00	3.85	1.74	1	12	3	97	0.00	0.0	4.498	0.066	12	3	1	1
PL.2631	PL.2626	B	#4 ACSR	7.28Y	121.4	0.00	3.61	0.00	0	0	0	100	0.00	0.0	4.201	0.054	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2625	PL.3152	B	#4 ACSR	7.29Y	121.5	0.01	3.50	2.37	2	17	5	96	0.00	0.0	4.108	0.095	4	1	2	7
PL.2627	PL.2625	B	#4 ACSR	7.29Y	121.5	0.00	3.50	1.75	1	12	3	97	0.00	0.0	4.136	0.028	7	2	2	5
PL.2628	PL.2627	B	#4 ACSR	7.29Y	121.5	0.00	3.51	0.75	1	5	1	98	0.00	0.0	4.199	0.063	1	0	1	3
PL.2629	PL.2628	B	#2 ACSR	7.29Y	121.5	0.00	3.51	0.64	0	4	1	97	0.00	0.0	4.233	0.034	4	1	2	2
PL.2620	PL.3119	B	#4 ACSR	7.32Y	122.0	0.00	3.04	1.00	1	7	2	96	0.00	0.0	3.613	0.026	7	2	1	1
PL.2616	PL.3593	B	#4 ACSR	7.36Y	122.7	0.00	2.26	1.26	1	9	2	98	0.00	0.0	3.078	0.084	9	2	2	2
PL.2614	PL.2872	ABC	#2 ACSR	7.37Y	122.9	0.08	2.13	68.29	39	1452	419	96	0.83	0.1	2.891	0.044	1	0	1	415
PL.2670	PL.2614	ABC	#2 ACSR	7.36Y	122.7	0.18	2.31	68.25	39	1450	418	96	1.94	0.1	2.994	0.102	10	3	1	414
PL.3164	PL.2670	ABC	#2 ACSR	7.36Y	122.6	0.04	2.35	67.79	39	1439	415	96	0.48	0.0	3.019	0.026	5	1	1	413
PL.3165	PL.3164	ABC	#2 ACSR	7.35Y	122.5	0.10	2.46	67.54	39	1433	413	96	1.10	0.1	3.079	0.059	20	6	4	412
PL.2671	PL.3165	ABC	#2 ACSR	7.35Y	122.5	0.06	2.52	66.59	38	1411	407	96	0.67	0.0	3.116	0.037	0	0	0	408
PL.3426	PL.2671	A	#4 ACSR	7.35Y	122.5	0.00	2.52	0.54	0	4	1	97	0.00	0.0	3.120	0.005	0	0	0	1
PD.376	PL.3426	A	40QA	7.35Y	122.5	0.00	2.52	0.54	1	4	1	97	0.00	0.0	3.120	0.005	0	0	0	1
PL.3427	PD.376	A	#4 ACSR	7.35Y	122.5	0.00	2.52	0.54	0	4	1	97	0.00	0.0	3.208	0.087	4	1	1	1
PL.2826	PL.2671	ABC	#2 ACSR	7.34Y	122.4	0.12	2.64	66.41	38	1407	405	96	1.29	0.1	3.188	0.072	12	3	1	407
PL.3428	PL.2826	A	#1/0 ACSR	7.34Y	122.4	0.00	2.64	4.54	2	32	9	96	0.00	0.0	3.192	0.005	0	0	0	14
PD.377	PL.3428	A	15T	7.34Y	122.4	0.00	2.64	4.54	0	32	9	96	0.00	0.0	3.192	0.005	0	0	0	14
PL.3429	PD.377	A	#1/0 ACSR	7.34Y	122.4	0.01	2.64	4.54	2	32	9	96	0.00	0.0	3.253	0.061	13	4	4	14
PL.2674	PL.3429	A	#4 ACSR	7.34Y	122.4	0.01	2.65	2.70	2	19	5	97	0.00	0.0	3.304	0.050	6	2	7	10
PL.2675	PL.2674	A	#4 ACSR	7.34Y	122.3	0.00	2.65	1.79	1	13	4	96	0.00	0.0	3.366	0.063	0	0	0	3
PL.2676	PL.2675	A	#4 ACSR	7.34Y	122.3	0.00	2.65	0.95	1	7	2	96	0.00	0.0	3.432	0.066	7	2	1	1
PL.2677	PL.2675	A	#4 ACSR	7.34Y	122.3	0.00	2.65	0.84	1	6	2	95	0.00	0.0	3.408	0.042	6	2	2	2
PL.2672	PL.2826	ABC	#2 ACSR	7.34Y	122.3	0.09	2.72	64.33	37	1362	392	96	0.90	0.1	3.241	0.053	0	0	0	392
PL.2673	PL.2672	ABC	#2 ACSR	7.34Y	122.3	0.00	2.73	64.33	37	1361	392	96	0.02	0.0	3.242	0.001	0	0	0	392
RG.4	PL.2673	ABC	114.3 KVA	7.48Y	124.6	-2.34	0.39	64.33	43	1361	392	96	percent Boost= 1.88 Tap= 3.0						392	
PL.3046	RG.4	ABC	#2 ACSR	7.48Y	124.6	0.00	0.39	63.12	36	1361	392	96	0.02	0.0	3.243	0.001	0	0	0	392
PL.3047	PL.3046	ABC	#2 ACSR	7.47Y	124.5	0.09	0.48	63.12	36	1361	392	96	0.92	0.1	3.299	0.056	0	0	0	392
PL.3430	PL.3047	C	#1/0 ACSR	7.47Y	124.5	0.00	0.48	0.00	0	0	0	100	0.00	0.0	3.304	0.005	0	0	0	0
PD.378	PL.3430	C	40QA	7.47Y	124.5	0.00	0.48	0.00	0	0	0	100	0.00	0.0	3.304	0.005	0	0	0	0
PL.3431	PD.378	C	#1/0 ACSR	7.47Y	124.5	0.00	0.48	0.00	0	0	0	100	0.00	0.0	3.350	0.047	0	0	0	0
PL.3432	PL.3047	ABC	#2 ACSR	7.47Y	124.5	0.01	0.49	63.12	36	1360	391	96	0.07	0.0	3.304	0.004	0	0	0	392

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3433	PL.3432	ABC	#2 ACSR	7.46Y	124.3	0.17	0.66	63.12	36	1360	391	96	1.78	0.1	3.413	0.109	0	0	0	392
PL.2679	PL.3433	ABC	#2 ACSR	7.45Y	124.2	0.17	0.83	63.12	36	1358	390	96	1.69	0.1	3.516	0.103	0	0	0	392
PL.2885	PL.2679	ABC	#2 ACSR	7.44Y	124.0	0.18	1.01	63.12	36	1356	389	96	1.84	0.1	3.629	0.113	0	0	0	392
PL.3396	PL.2885	C	6 A (CWC)	7.44Y	124.0	0.00	1.01	1.41	1	10	3	96	0.00	0.0	3.634	0.005	0	0	0	3
PD.361	PL.3396	C	40QA	7.44Y	124.0	0.00	1.01	1.41	4	10	3	96	0.00	0.0	3.634	0.005	0	0	0	3
PL.3397	PD.361	C	6 A (CWC)	7.44Y	124.0	0.00	1.01	1.41	1	10	3	96	0.00	0.0	3.726	0.092	10	3	3	3
PL.2827	PL.2885	ABC	#2 ACSR	7.43Y	123.9	0.12	1.13	62.66	36	1344	385	96	1.22	0.1	3.705	0.076	0	0	0	389
PL.3613	PL.2827	ABC	#2 ACSR	7.43Y	123.8	0.12	1.24	62.66	36	1343	385	96	1.17	0.1	3.778	0.073	0	0	0	389
PL.3614	PL.3613	ABC	#2 ACSR	7.42Y	123.7	0.08	1.32	62.66	36	1342	384	96	0.81	0.1	3.829	0.051	0	0	0	389
PL.2682	PL.3614	ABC	#2 ACSR	7.41Y	123.6	0.11	1.44	62.09	35	1329	380	96	1.12	0.1	3.900	0.071	8	2	2	384
PL.2683	PL.2682	ABC	#2 ACSR	7.41Y	123.5	0.08	1.51	61.72	35	1320	377	96	0.75	0.1	3.948	0.048	0	0	0	382
PL.2685	PL.2683	ABC	#2 ACSR	7.40Y	123.4	0.08	1.59	43.98	25	940	270	96	0.55	0.1	4.018	0.069	0	0	0	255
PL.2686	PL.2685	ABC	#2 ACSR	7.40Y	123.3	0.11	1.70	43.98	25	939	270	96	0.75	0.1	4.113	0.095	0	0	0	255
PL.2843	PL.2686	ABC	#2 ACSR	7.39Y	123.2	0.10	1.79	43.72	25	933	268	96	0.68	0.1	4.200	0.087	0	0	0	254
PL.3605	PL.2843	ABC	#2 ACSR	7.39Y	123.1	0.09	1.89	43.72	25	932	267	96	0.66	0.1	4.285	0.085	0	0	0	254
PD.437	PL.3605	ABC	70L	7.39Y	123.1	0.00	1.89	43.72	62	931	267	96	0.00	0.0	4.285	0.085	0	0	0	254
PL.3606	PD.437	ABC	#2 ACSR	7.39Y	123.1	0.01	1.90	43.72	25	931	267	96	0.09	0.0	4.297	0.012	6	2	2	254
PL.3213	PL.3606	ABC	#2 ACSR	7.38Y	123.0	0.10	2.00	43.44	25	925	265	96	0.73	0.1	4.392	0.095	9	2	2	252
PL.3189	PL.3213	ABC	#2 ACSR	7.37Y	122.9	0.10	2.11	43.02	25	916	262	96	0.71	0.1	4.486	0.094	0	0	0	250
PL.3191	PL.3189	ABC	#2 ACSR	7.37Y	122.9	0.04	2.14	43.02	25	915	262	96	0.26	0.0	4.520	0.035	0	0	0	250
PL.3192	PL.3191	ABC	#2 ACSR	7.37Y	122.8	0.08	2.22	43.02	25	915	262	96	0.56	0.1	4.595	0.074	4	1	2	250
PL.3190	PL.3192	ABC	#2 ACSR	7.36Y	122.7	0.10	2.32	42.83	24	910	260	96	0.67	0.1	4.683	0.089	0	0	0	248
PL.2844	PL.3190	ABC	#2 ACSR	7.36Y	122.6	0.08	2.40	42.24	24	897	256	96	0.56	0.1	4.760	0.076	0	0	0	244
PL.3458	PL.2844	A	6 A (CWC)	7.36Y	122.6	0.00	2.40	8.79	6	62	17	96	0.00	0.0	4.764	0.005	0	0	0	10
PD.391	PL.3458	A	40QA	7.36Y	122.6	0.00	2.40	8.79	22	62	17	96	0.00	0.0	4.764	0.005	0	0	0	10
PL.3459	PD.391	A	6 A (CWC)	7.35Y	122.6	0.02	2.42	8.79	6	62	17	96	0.01	0.0	4.816	0.052	0	0	0	10
PL.3193	PL.3459	A	6 A (CWC)	7.35Y	122.6	0.01	2.44	8.79	6	62	17	96	0.01	0.0	4.850	0.034	15	4	1	10
PL.3194	PL.3193	A	6 A (CWC)	7.35Y	122.6	0.01	2.45	6.66	5	47	13	96	0.00	0.0	4.892	0.041	11	3	1	9
PL.3195	PL.3194	A	6 A (CWC)	7.35Y	122.5	0.01	2.46	5.17	4	37	10	97	0.00	0.0	4.942	0.050	0	0	0	8
PL.3196	PL.3195	A	6 A (CWC)	7.35Y	122.5	0.00	2.46	5.17	4	37	10	97	0.00	0.0	4.959	0.017	6	2	1	8
PL.3197	PL.3196	A	6 A (CWC)	7.35Y	122.5	0.01	2.47	4.39	3	31	9	96	0.00	0.0	5.027	0.068	19	5	4	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3198	PL.3197	A	6 A (CWC)	7.35Y	122.5	0.00	2.47	1.64	1	12	3	97	0.00	0.0	5.045	0.019	0	0	0	3
PL.2687	PL.3198	A	6 A (CWC)	7.35Y	122.5	0.00	2.47	0.89	1	6	2	95	0.00	0.0	5.077	0.032	6	2	1	1
PL.3199	PL.3198	A	6 A (CWC)	7.35Y	122.5	0.00	2.48	0.75	1	5	1	98	0.00	0.0	5.090	0.044	0	0	0	2
PL.3200	PL.3199	A	6 A (CWC)	7.35Y	122.5	0.00	2.48	0.75	1	5	1	98	0.00	0.0	5.158	0.068	5	1	2	2
PL.2845	PL.2844	ABC	#2 ACSR	7.35Y	122.5	0.10	2.50	39.31	22	834	239	96	0.65	0.1	4.862	0.103	0	0	0	234
PL.2688	PL.2845	ABC	#2 ACSR	7.35Y	122.4	0.08	2.58	39.31	22	833	238	96	0.50	0.1	4.941	0.079	1	0	3	234
PL.2689	PL.2688	C	#4 ACSR	7.34Y	122.4	0.00	2.59	2.39	2	17	5	96	0.00	0.0	4.985	0.044	11	3	3	4
PL.2690	PL.2689	C	#4 ACSR	7.34Y	122.4	0.00	2.59	0.83	1	6	2	95	0.00	0.0	5.019	0.034	6	2	1	1
PL.3214	PL.2688	ABC	#2 ACSR	7.34Y	122.3	0.08	2.67	38.46	22	815	233	96	0.52	0.1	5.027	0.086	1	0	1	227
PL.3215	PL.3214	ABC	#2 ACSR	7.34Y	122.3	0.06	2.73	38.42	22	813	233	96	0.38	0.0	5.090	0.062	0	0	0	226
PL.3470	PL.3215	A	#4 ACSR	7.34Y	122.3	0.00	2.73	0.85	1	6	2	95	0.00	0.0	5.094	0.005	0	0	0	1
PD.398	PL.3470	A	40QA	7.34Y	122.3	0.00	2.73	0.85	2	6	2	95	0.00	0.0	5.094	0.005	0	0	0	1
PL.3471	PD.398	A	#4 ACSR	7.34Y	122.3	0.00	2.73	0.85	1	6	2	95	0.00	0.0	5.130	0.036	6	2	1	1
PL.3216	PL.3215	ABC	#2 ACSR	7.33Y	122.2	0.12	2.85	38.14	22	807	231	96	0.74	0.1	5.216	0.126	8	2	1	225
PL.3217	PL.3216	ABC	#2 ACSR	7.32Y	122.1	0.09	2.94	37.76	22	798	228	96	0.55	0.1	5.309	0.094	0	0	0	224
PL.2996	PL.3217	ABC	#2 ACSR	7.32Y	122.0	0.07	3.01	37.76	22	798	228	96	0.42	0.1	5.381	0.072	0	0	0	224
PL.3067	PL.2996	ABC	#2 ACSR	7.31Y	121.9	0.13	3.13	37.76	22	797	227	96	0.78	0.1	5.515	0.133	0	0	0	224
PL.2997	PL.3067	ABC	#2 ACSR	7.30Y	121.7	0.15	3.29	37.76	22	797	227	96	0.94	0.1	5.676	0.161	0	0	0	224
PL.2998	PL.2997	ABC	#2 ACSR	7.30Y	121.6	0.11	3.39	37.76	22	796	227	96	0.65	0.1	5.787	0.111	0	0	0	224
PL.2712	PL.2998	ABC	#2 ACSR	7.29Y	121.5	0.11	3.50	37.76	22	795	226	96	0.65	0.1	5.899	0.111	0	0	0	224
PL.3570	PL.2712	C	6 A (CWC)	7.29Y	121.5	0.00	3.50	1.84	1	13	4	96	0.00	0.0	5.903	0.005	0	0	0	2
PD.420	PL.3570	C	40QA	7.29Y	121.5	0.00	3.50	1.84	5	13	4	96	0.00	0.0	5.903	0.005	0	0	0	2
PL.3571	PD.420	C	6 A (CWC)	7.29Y	121.5	0.00	3.50	1.84	1	13	4	96	0.00	0.0	5.961	0.058	13	4	2	2
PL.2919	PL.2712	ABC	#2 ACSR	7.29Y	121.5	0.04	3.54	37.15	21	781	222	96	0.21	0.0	5.936	0.038	0	0	2	222
PL.3611	PL.2919	ABC	#2 ACSR	7.28Y	121.4	0.07	3.61	37.15	21	781	222	96	0.42	0.1	6.010	0.074	0	0	0	220
PL.3612	PL.3611	ABC	#2 ACSR	7.28Y	121.3	0.10	3.70	37.15	21	781	222	96	0.58	0.1	6.113	0.103	0	0	0	220
PL.3130	PL.3612	ABC	#2 ACSR	7.27Y	121.2	0.09	3.79	36.99	21	777	221	96	0.51	0.1	6.205	0.092	8	2	2	217
PL.3572	PL.3130	C	6 A (CWC)	7.27Y	121.2	0.00	3.79	4.54	3	32	9	96	0.00	0.0	6.210	0.005	0	0	0	5
PD.421	PL.3572	C	40QA	7.27Y	121.2	0.00	3.79	4.54	11	32	9	96	0.00	0.0	6.210	0.005	0	0	0	5
PL.3573	PD.421	C	6 A (CWC)	7.27Y	121.2	0.01	3.80	4.54	3	32	9	96	0.00	0.0	6.268	0.058	32	9	5	5
PL.3444	PL.3130	B	6 A (CWC)	7.27Y	121.2	0.01	3.80	11.28	8	79	22	96	0.01	0.0	6.224	0.019	0	0	0	27

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.384	PL.3444	B	25T	7.27Y	121.2	0.00	3.80	11.28	0	79	22	96	0.00	0.0	6.224	0.019	0	0	0	27
PL.3445	PD.384	B	6 A (CWC)	7.27Y	121.2	0.03	3.82	11.28	8	79	22	96	0.02	0.0	6.277	0.053	2	1	2	27
PL.2925	PL.3445	B	6 A (CWC)	7.27Y	121.2	0.01	3.83	10.93	8	77	21	96	0.00	0.0	6.289	0.012	8	2	2	25
PL.2924	PL.2925	B	6 A (CWC)	7.27Y	121.1	0.05	3.88	9.78	7	69	19	96	0.02	0.0	6.406	0.117	8	2	1	23
PL.2714	PL.2924	B	6 A (CWC)	7.27Y	121.1	0.03	3.91	8.60	6	60	17	96	0.02	0.0	6.493	0.087	0	0	0	22
PL.2715	PL.2714	B	#4 ACSR	7.27Y	121.1	0.00	3.91	0.30	0	2	1	89	0.00	0.0	6.539	0.046	2	1	1	1
PL.2926	PL.2714	B	6 A (CWC)	7.26Y	121.1	0.03	3.95	8.30	6	58	16	96	0.01	0.0	6.589	0.096	10	3	2	21
PL.2927	PL.2926	B	6 A (CWC)	7.26Y	121.0	0.02	3.96	6.90	5	48	13	97	0.01	0.0	6.648	0.059	7	2	1	19
PL.2928	PL.2927	B	6 A (CWC)	7.26Y	121.0	0.01	3.97	5.88	4	41	11	97	0.00	0.0	6.690	0.043	9	3	3	18
PL.2922	PL.2928	B	#4 ACSR	7.26Y	121.0	0.01	3.98	4.56	4	32	9	96	0.00	0.0	6.727	0.036	11	3	1	15
PL.2923	PL.2922	B	#4 ACSR	7.26Y	121.0	0.01	3.99	2.94	2	21	6	96	0.00	0.0	6.831	0.104	2	1	1	14
PL.2911	PL.2923	B	#4 ACSR	7.26Y	121.0	0.01	4.00	2.65	2	19	5	97	0.00	0.0	6.904	0.073	0	0	0	13
PL.2912	PL.2911	B	#4 ACSR	7.26Y	121.0	0.01	4.02	2.65	2	19	5	97	0.00	0.0	7.024	0.120	0	0	0	13
PL.2913	PL.2912	B	#4 ACSR	7.26Y	121.0	0.01	4.03	2.65	2	19	5	97	0.00	0.0	7.100	0.076	0	0	0	13
PL.2914	PL.2913	B	#4 ACSR	7.26Y	121.0	0.02	4.04	2.65	2	19	5	97	0.00	0.0	7.240	0.141	0	0	0	13
PL.2846	PL.2914	B	#4 ACSR	7.26Y	121.0	0.01	4.05	1.64	1	11	3	96	0.00	0.0	7.317	0.076	0	0	0	7
PL.2716	PL.2846	B	#4 ACSR	7.26Y	120.9	0.01	4.06	1.64	1	11	3	96	0.00	0.0	7.448	0.131	0	0	0	7
PL.3068	PL.2716	B	#4 ACSR	7.26Y	120.9	0.01	4.06	1.64	1	11	3	96	0.00	0.0	7.535	0.087	0	0	0	7
PL.3002	PL.3068	B	#4 ACSR	7.26Y	120.9	0.01	4.07	1.64	1	11	3	96	0.00	0.0	7.672	0.137	0	0	0	7
PL.3140	PL.3002	B	#4 ACSR	7.26Y	120.9	0.01	4.08	1.64	1	11	3	96	0.00	0.0	7.783	0.111	0	0	0	7
PL.2718	PL.3140	B	#4 ACSR	7.25Y	120.9	0.00	4.08	0.94	1	7	2	96	0.00	0.0	7.860	0.077	0	0	0	4
PL.2717	PL.2718	B	#4 ACSR	7.25Y	120.9	0.00	4.09	0.94	1	7	2	96	0.00	0.0	7.953	0.093	0	0	0	4
PL.3069	PL.2717	B	#4 ACSR	7.25Y	120.9	0.00	4.09	0.94	1	7	2	96	0.00	0.0	8.068	0.115	0	0	0	4
PL.3003	PL.3069	B	#4 ACSR	7.25Y	120.9	0.01	4.10	0.94	1	7	2	96	0.00	0.0	8.197	0.130	0	0	0	4
PL.3070	PL.3003	B	#4 ACSR	7.25Y	120.9	0.00	4.10	0.94	1	7	2	96	0.00	0.0	8.301	0.104	0	0	0	4
PL.3004	PL.3070	B	#4 ACSR	7.25Y	120.9	0.01	4.11	0.94	1	7	2	96	0.00	0.0	8.450	0.149	0	0	0	4
PL.3005	PL.3004	B	#4 ACSR	7.25Y	120.9	0.00	4.11	0.94	1	7	2	96	0.00	0.0	8.527	0.077	0	0	0	4
PL.3071	PL.3005	B	#4 ACSR	7.25Y	120.9	0.00	4.12	0.94	1	7	2	96	0.00	0.0	8.625	0.098	0	0	0	4
PL.3006	PL.3071	B	#4 ACSR	7.25Y	120.9	0.00	4.12	0.94	1	7	2	96	0.00	0.0	8.732	0.107	0	0	0	4
PL.3177	PL.3006	B	#4 ACSR	7.25Y	120.9	0.01	4.13	0.94	1	7	2	96	0.00	0.0	8.901	0.169	0	0	0	4
PL.3178	PL.3177	B	#4 ACSR	7.25Y	120.9	0.00	4.13	0.94	1	7	2	96	0.00	0.0	8.996	0.095	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3072	PL.3178	B	#4 ACSR	7.25Y	120.9	0.00	4.14	0.94	1	7	2	96	0.00	0.0	9.086	0.091	0	0	0	4
PL.2719	PL.3072	B	#4 ACSR	7.25Y	120.9	0.01	4.14	0.94	1	7	2	96	0.00	0.0	9.245	0.158	0	0	0	4
PL.3007	PL.2719	B	#4 ACSR	7.25Y	120.9	0.00	4.15	0.94	1	7	2	96	0.00	0.0	9.361	0.116	0	0	0	4
PL.3175	PL.3007	B	#4 ACSR	7.25Y	120.9	0.00	4.15	0.94	1	7	2	96	0.00	0.0	9.415	0.054	4	1	1	4
PL.3176	PL.3175	B	#4 ACSR	7.25Y	120.8	0.00	4.15	0.38	0	3	1	95	0.00	0.0	9.505	0.090	0	0	0	3
PL.3073	PL.3176	B	#4 ACSR	7.25Y	120.8	0.00	4.15	0.38	0	3	1	95	0.00	0.0	9.593	0.089	0	0	0	3
PL.3008	PL.3073	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.38	0	3	1	95	0.00	0.0	9.754	0.160	0	0	0	3
PL.3173	PL.3008	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.32	0	2	1	89	0.00	0.0	9.889	0.135	1	0	1	2
PL.3174	PL.3173	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.11	0	1	0	100	0.00	0.0	10.018	0.129	0	0	0	1
PL.3009	PL.3174	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.11	0	1	0	100	0.00	0.0	10.171	0.153	1	0	1	1
PL.2720	PL.3008	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.06	0	0	0	100	0.00	0.0	9.805	0.051	0	0	1	1
PL.3141	PL.3140	B	#4 ACSR	7.26Y	120.9	0.00	4.08	0.70	1	5	1	98	0.00	0.0	7.810	0.027	5	1	3	3
PL.3440	PL.2914	B	#4 ACSR	7.26Y	121.0	0.00	4.04	1.01	1	7	2	96	0.00	0.0	7.245	0.005	0	0	0	6
PD.382	PL.3440	B	10T	7.26Y	121.0	0.00	4.04	1.01	0	7	2	96	0.00	0.0	7.245	0.005	0	0	0	6
PL.3441	PD.382	B	#4 ACSR	7.26Y	121.0	0.01	4.05	1.01	1	7	2	96	0.00	0.0	7.359	0.114	0	0	0	6
PL.2999	PL.3441	B	#4 ACSR	7.26Y	120.9	0.01	4.05	1.01	1	7	2	96	0.00	0.0	7.496	0.137	0	0	0	6
PL.3000	PL.2999	B	#4 ACSR	7.26Y	120.9	0.01	4.06	1.01	1	7	2	96	0.00	0.0	7.609	0.113	0	0	0	6
PL.3001	PL.3000	B	#4 ACSR	7.26Y	120.9	0.00	4.06	1.01	1	7	2	96	0.00	0.0	7.714	0.105	0	0	0	6
PL.2915	PL.3001	B	#4 ACSR	7.26Y	120.9	0.00	4.07	1.01	1	7	2	96	0.00	0.0	7.797	0.083	2	1	2	6
PL.2917	PL.2915	B	#4 ACSR	7.26Y	120.9	0.00	4.07	0.69	1	5	1	98	0.00	0.0	7.928	0.132	3	1	2	4
PL.2918	PL.2917	B	#4 ACSR	7.26Y	120.9	0.00	4.07	0.25	0	2	0	100	0.00	0.0	8.006	0.078	0	0	0	2
PL.2916	PL.2918	B	#4 ACSR	7.26Y	120.9	0.00	4.07	0.25	0	2	0	100	0.00	0.0	8.095	0.089	2	0	2	2
PL.3131	PL.3130	ABC	#2 ACSR	7.27Y	121.1	0.08	3.87	31.32	18	657	187	96	0.43	0.1	6.312	0.107	0	0	0	183
PL.3442	PL.3131	B	#2 ACSR	7.27Y	121.1	0.00	3.87	4.31	2	30	8	97	0.00	0.0	6.317	0.005	0	0	0	6
PD.383	PL.3442	B	40QA	7.27Y	121.1	0.00	3.87	4.31	11	30	8	97	0.00	0.0	6.317	0.005	0	0	0	6
PL.3443	PD.383	B	#2 ACSR	7.27Y	121.1	0.01	3.88	4.31	2	30	8	97	0.00	0.0	6.361	0.044	0	0	0	6
PL.2920	PL.3443	B	#2 ACSR	7.27Y	121.1	0.00	3.88	4.31	2	30	8	97	0.00	0.0	6.394	0.033	3	1	2	6
PL.2921	PL.2920	B	#2 ACSR	7.27Y	121.1	0.01	3.89	3.90	2	27	7	97	0.00	0.0	6.485	0.091	11	3	1	4
PL.2725	PL.2921	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.525	0.039	0	0	1	1
PL.33079	PL.2725	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.583	0.058	0	0	0	0
PL.33080	PL.33079	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.656	0.073	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33081	PL.33080	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.704	0.048	0	0	0	0
PL.33083	PL.33081	B	#1/0 ACSR	7.27Y	121.1	0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.706	0.001	0	0	0	0
PD.4894	PL.33083	B	10T	7.27Y	121.1	0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.706	0.001	0	0	0	0
PL.33084	PD.4894	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.751	0.046	0	0	0	0
PL.33085	PL.33084	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.803	0.052	0	0	0	0
PL.33086	PL.33085	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.854	0.050	0	0	0	0
PL.33087	PL.33086	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.896	0.042	0	0	0	0
PL.33088	PL.33087	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.935	0.039	0	0	0	0
PL.33089	PL.33088	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	6.978	0.043	0	0	0	0
PL.33090	PL.33089	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.044	0.067	0	0	0	0
PL.33091	PL.33090	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.099	0.055	0	0	0	0
PL.33092	PL.33091	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.138	0.039	0	0	0	0
PL.33093	PL.33092	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.194	0.056	0	0	0	0
PL.33094	PL.33093	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.254	0.060	0	0	0	0
PL.33095	PL.33094	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.335	0.080	0	0	0	0
PL.33096	PL.33095	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.379	0.045	0	0	0	0
PL.33097	PL.33096	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.426	0.047	0	0	0	0
PL.33098	PL.33097	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.469	0.042	0	0	0	0
PL.33099	PL.33098	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.492	0.023	0	0	0	0
PL.33100	PL.33099	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.522	0.030	0	0	0	0
PL.33101	PL.33100	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.582	0.060	0	0	0	0
PL.33102	PL.33101	B	#1/0 ACSR	7.27Y	121.1	-0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.627	0.045	0	0	0	0
PL.33103	PL.33102	B	1/0 AL URD	7.27Y	121.1	0.00	3.89	-0.02	0	0	0	100	0.00	0.0	7.672	0.045	0	0	0	0
PL.2724	PL.2921	B	#2 ACSR	7.27Y	121.1	0.00	3.89	2.39	1	17	5	96	0.00	0.0	6.511	0.026	17	5	2	2
PL.2847	PL.3131	ABC	#2 ACSR	7.26Y	121.1	0.06	3.94	29.89	17	627	179	96	0.30	0.0	6.396	0.084	7	2	1	177
PL.2721	PL.2847	ABC	#2 ACSR	7.26Y	121.0	0.08	4.01	29.47	17	618	176	96	0.37	0.1	6.501	0.105	0	0	0	175
PL.3010	PL.2721	ABC	#2 ACSR	7.25Y	120.9	0.08	4.09	29.47	17	617	176	96	0.37	0.1	6.606	0.105	0	0	0	175
PL.2723	PL.3010	C	6 A (CWC)	7.25Y	120.9	0.01	4.10	3.80	3	27	7	97	0.00	0.0	6.724	0.118	27	7	4	4
PL.3448	PL.2723	C	#4 ACSR	7.25Y	120.9	0.00	4.10	0.00	0	0	0	100	0.00	0.0	6.728	0.005	0	0	0	0
PD.386	PL.3448	C	40QA	7.25Y	120.9	0.00	4.10	0.00	0	0	0	100	0.00	0.0	6.728	0.005	0	0	0	0
PL.3449	PD.386	C	#4 ACSR	7.25Y	120.9	0.00	4.10	0.00	0	0	0	100	0.00	0.0	6.763	0.035	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2931	PL.3010	ABC	#2 ACSR	7.25Y	120.9	0.05	4.14	28.20	16	590	168	96	0.24	0.0	6.679	0.073	5	1	1	171
PL.2932	PL.2931	ABC	#2 ACSR	7.25Y	120.8	0.06	4.21	27.97	16	585	167	96	0.28	0.0	6.767	0.088	0	0	0	170
PL.3074	PL.2932	ABC	#2 ACSR	7.24Y	120.7	0.08	4.28	27.97	16	585	166	96	0.35	0.1	6.876	0.109	0	0	0	170
PL.2929	PL.3074	ABC	#2 ACSR	7.24Y	120.6	0.07	4.36	27.97	16	585	166	96	0.33	0.1	6.978	0.101	0	0	0	170
PL.2930	PL.2929	ABC	#2 ACSR	7.23Y	120.6	0.07	4.43	27.97	16	584	166	96	0.32	0.1	7.078	0.100	0	0	0	170
PL.3075	PL.2930	ABC	#2 ACSR	7.23Y	120.5	0.06	4.48	27.97	16	584	166	96	0.25	0.0	7.156	0.079	0	0	0	170
PL.3011	PL.3075	ABC	#2 ACSR	7.23Y	120.5	0.06	4.55	27.97	16	584	166	96	0.29	0.1	7.248	0.091	0	0	0	170
PL.3012	PL.3011	ABC	#2 ACSR	7.22Y	120.4	0.05	4.60	27.97	16	583	166	96	0.24	0.0	7.324	0.076	3	1	2	170
PL.3187	PL.3012	ABC	#2 ACSR	7.22Y	120.4	0.05	4.65	27.84	16	580	165	96	0.20	0.0	7.389	0.065	2	1	1	168
PL.3188	PL.3187	ABC	#2 ACSR	7.22Y	120.3	0.07	4.71	27.75	16	578	164	96	0.31	0.1	7.485	0.097	0	0	0	167
PL.3133	PL.3188	ABC	#2 ACSR	7.21Y	120.2	0.07	4.78	27.75	16	578	164	96	0.31	0.1	7.583	0.097	0	0	1	167
PL.3390	PL.3133	C	6 A (CWC)	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	7.587	0.005	0	0	0	0
PL.3134	PL.3133	ABC	#2 ACSR	7.21Y	120.1	0.08	4.86	27.74	16	578	164	96	0.35	0.1	7.694	0.112	0	0	0	166
PL.2726	PL.3134	ABC	#1/0 ACSR	7.21Y	120.1	0.05	4.92	27.74	12	577	164	96	0.22	0.0	7.803	0.109	0	0	0	166
PL.2727	PL.2726	C	6 A (CWC)	7.20Y	120.0	0.11	5.03	31.43	22	218	62	96	0.18	0.1	7.881	0.078	10	3	2	59
PL.3615	PL.2727	C	6 A (CWC)	7.19Y	119.9	0.10	5.13	30.05	21	208	59	96	0.17	0.1	7.957	0.076	0	0	0	57
RG.3	PL.3615	C	76.2 KVA	7.47Y	124.5	-4.67	0.46	30.05	30	208	59	96	percent Boost= 0.00 Tap= 0.0							57
PL.3616	RG.3	C	6 A (CWC)	7.47Y	124.5	0.08	0.54	28.92	21	208	59	96	0.13	0.1	8.019	0.063	0	0	0	57
C PD.431	PL.3616	C	35H	7.47Y	124.5	0.00	0.54	28.92	83	208	59	96	0.00	0.0	8.019	0.063	0	0	0	57 C
PL.3594	PD.431	C	6 A (CWC)	7.45Y	124.2	0.22	0.76	28.92	21	208	59	96	0.34	0.2	8.186	0.167	0	0	0	57
PL.2729	PL.3594	C	#4 ACSR	7.45Y	124.2	0.00	0.76	0.33	0	2	1	89	0.00	0.0	8.267	0.081	2	1	2	2
PL.3138	PL.3594	C	6 A (CWC)	7.44Y	124.1	0.18	0.94	28.59	20	205	58	96	0.27	0.1	8.322	0.136	0	0	0	55
PL.3139	PL.3138	C	6 A (CWC)	7.44Y	124.0	0.05	0.99	28.24	20	202	57	96	0.08	0.0	8.363	0.041	0	0	0	54
PL.3182	PL.3139	C	6 A (CWC)	7.43Y	123.8	0.17	1.16	28.24	20	202	57	96	0.25	0.1	8.496	0.133	3	1	1	54
PL.3183	PL.3182	C	6 A (CWC)	7.42Y	123.7	0.13	1.29	27.75	20	198	56	96	0.19	0.1	8.595	0.100	0	0	0	53
PL.3306	PL.3183	C	6 A (CWC)	7.42Y	123.6	0.11	1.40	27.75	20	198	56	96	0.16	0.1	8.681	0.085	0	0	1	53
PL.3307	PL.3306	C	6 A (CWC)	7.41Y	123.5	0.07	1.47	27.75	20	198	56	96	0.11	0.1	8.740	0.059	8	2	1	52
PL.3305	PL.3307	C	6 A (CWC)	7.40Y	123.4	0.11	1.59	26.65	19	190	54	96	0.16	0.1	8.832	0.091	0	0	0	51
PL.3013	PL.3305	C	6 A (CWC)	7.40Y	123.3	0.12	1.71	26.65	19	190	54	96	0.17	0.1	8.931	0.099	0	0	0	51
PL.3132	PL.3013	C	6 A (CWC)	7.39Y	123.1	0.18	1.89	26.21	19	187	53	96	0.24	0.1	9.088	0.157	17	5	6	49
PL.3319	PL.3132	C	6 A (CWC)	7.38Y	123.0	0.09	1.98	22.59	16	161	45	96	0.11	0.1	9.180	0.093	9	3	3	41

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3320	PL.3319	C	6 A (CWC)	7.38Y	123.0	0.05	2.03	21.28	15	151	43	96	0.06	0.0	9.232	0.052	5	1	2	38
PL.3321	PL.3320	C	6 A (CWC)	7.38Y	122.9	0.03	2.06	20.53	15	146	41	96	0.03	0.0	9.265	0.033	7	2	1	36
PL.3318	PL.3321	C	6 A (CWC)	7.37Y	122.9	0.06	2.12	19.61	14	139	39	96	0.06	0.0	9.333	0.068	0	0	0	35
PL.3324	PL.3318	C	6 A (CWC)	7.37Y	122.8	0.06	2.18	19.61	14	139	39	96	0.07	0.0	9.405	0.071	4	1	1	35
PL.3325	PL.3324	C	6 A (CWC)	7.37Y	122.8	0.05	2.23	19.06	14	135	38	96	0.05	0.0	9.459	0.054	0	0	0	34
PL.3326	PL.3325	C	6 A (CWC)	7.36Y	122.7	0.05	2.28	19.06	14	135	38	96	0.05	0.0	9.515	0.057	6	2	1	34
PL.3323	PL.3326	C	6 A (CWC)	7.36Y	122.6	0.07	2.35	18.23	13	129	36	96	0.07	0.1	9.606	0.091	8	2	2	33
PL.3322	PL.3323	C	6 A (CWC)	7.35Y	122.6	0.07	2.42	17.14	12	121	34	96	0.06	0.1	9.693	0.087	0	0	0	31
PL.3076	PL.3322	C	6 A (CWC)	7.35Y	122.5	0.10	2.52	17.14	12	121	34	96	0.09	0.1	9.815	0.123	0	0	0	31
PL.3014	PL.3076	C	6 A (CWC)	7.34Y	122.4	0.07	2.59	17.14	12	121	34	96	0.07	0.1	9.910	0.095	0	0	0	31
PL.3336	PL.3014	C	6 A (CWC)	7.34Y	122.3	0.07	2.66	17.14	12	121	34	96	0.06	0.0	9.994	0.084	2	1	1	31
PL.3337	PL.3336	C	6 A (CWC)	7.34Y	122.3	0.05	2.71	16.87	12	119	33	96	0.04	0.0	10.058	0.064	0	0	0	30
PL.3334	PL.3337	C	6 A (CWC)	7.33Y	122.2	0.08	2.79	16.87	12	119	33	96	0.07	0.1	10.168	0.109	5	1	1	30
PL.3335	PL.3334	C	6 A (CWC)	7.33Y	122.1	0.07	2.86	16.14	12	114	32	96	0.06	0.1	10.260	0.092	0	0	0	29
PL.3137	PL.3335	C	6 A (CWC)	7.33Y	122.1	0.03	2.89	16.14	12	114	32	96	0.03	0.0	10.306	0.047	4	1	1	29
PL.2747	PL.3137	C	6 A (CWC)	7.33Y	122.1	0.00	2.90	0.87	1	6	2	95	0.00	0.0	10.409	0.103	0	0	0	1
PL.3015	PL.2747	C	6 A (CWC)	7.33Y	122.1	0.00	2.90	0.87	1	6	2	95	0.00	0.0	10.529	0.120	0	0	0	1
PL.3016	PL.3015	C	6 A (CWC)	7.33Y	122.1	0.00	2.90	0.87	1	6	2	95	0.00	0.0	10.644	0.115	6	2	1	1
PL.3328	PL.3137	C	6 A (CWC)	7.32Y	122.1	0.04	2.94	14.70	11	104	29	96	0.03	0.0	10.374	0.067	8	2	1	27
PL.3329	PL.3328	C	6 A (CWC)	7.32Y	122.0	0.04	2.98	13.54	10	95	27	96	0.03	0.0	10.445	0.072	13	4	3	26
PL.3327	PL.3329	C	6 A (CWC)	7.32Y	122.0	0.03	3.01	11.68	8	82	23	96	0.02	0.0	10.511	0.066	10	3	1	23
PL.3330	PL.3327	C	6 A (CWC)	7.32Y	122.0	0.02	3.03	10.21	7	72	20	96	0.01	0.0	10.562	0.051	8	2	4	22
PL.3331	PL.3330	C	6 A (CWC)	7.32Y	121.9	0.05	3.08	9.08	6	64	18	96	0.02	0.0	10.674	0.112	0	0	0	18
PL.2748	PL.3331	C	6 A (CWC)	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	10.741	0.067	0	0	1	1
PL.2749	PL.3331	C	6 A (CWC)	7.31Y	121.9	0.04	3.12	9.08	6	64	18	96	0.02	0.0	10.774	0.101	0	0	0	17
PL.2750	PL.2749	C	6 A (CWC)	7.31Y	121.9	0.00	3.12	0.76	1	5	2	93	0.00	0.0	10.833	0.059	2	1	1	2
PL.2938	PL.2750	C	#1/0 ACSR	7.31Y	121.9	0.00	3.12	0.51	0	4	1	97	0.00	0.0	10.838	0.005	0	0	0	1
PD.408	PL.2938	C	40QA	7.31Y	121.9	0.00	3.12	0.51	1	4	1	97	0.00	0.0	10.838	0.005	0	0	0	1
PL.2939	PD.408	C	#1/0 ACSR	7.31Y	121.9	0.00	3.12	0.51	0	4	1	97	0.00	0.0	11.000	0.163	0	0	0	1
PL.3017	PL.2939	C	#1/0 ACSR	7.31Y	121.9	0.00	3.13	0.51	0	4	1	97	0.00	0.0	11.159	0.159	0	0	0	1
PL.3018	PL.3017	C	#1/0 ACSR	7.31Y	121.9	0.00	3.13	0.51	0	4	1	97	0.00	0.0	11.314	0.156	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3077	PL.3018	C	#1/0 ACSR	7.31Y	121.9	0.00	3.13	0.51	0	4	1	97	0.00	0.0	11.396	0.082	0	0	0	1
PL.3019	PL.3077	C	#1/0 ACSR	7.31Y	121.9	0.00	3.13	0.51	0	4	1	97	0.00	0.0	11.500	0.104	4	1	1	1
PL.2848	PL.2749	C	6 A (CWC)	7.31Y	121.8	0.04	3.16	8.31	6	59	16	97	0.02	0.0	10.887	0.113	0	0	0	15
PL.3332	PL.2848	C	#4 ACSR	7.31Y	121.8	0.00	3.17	1.46	1	10	3	96	0.00	0.0	10.967	0.080	8	2	2	3
PL.3333	PL.3332	C	#4 ACSR	7.31Y	121.8	0.00	3.17	0.34	0	2	1	89	0.00	0.0	11.013	0.046	0	0	0	1
PL.2752	PL.3333	C	#4 ACSR	7.31Y	121.8	0.00	3.17	0.34	0	2	1	89	0.00	0.0	11.054	0.041	2	1	1	1
PL.2751	PL.2848	C	#1/0 ACSR	7.31Y	121.8	0.01	3.18	6.85	3	48	14	96	0.00	0.0	10.976	0.089	0	0	0	12
PL.3020	PL.2751	C	#1/0 ACSR	7.31Y	121.8	0.02	3.20	6.85	3	48	14	96	0.01	0.0	11.098	0.122	0	0	0	12
PL.3021	PL.3020	C	#1/0 ACSR	7.31Y	121.8	0.02	3.22	6.85	3	48	13	97	0.01	0.0	11.229	0.131	0	0	0	12
PL.3022	PL.3021	C	#1/0 ACSR	7.31Y	121.8	0.02	3.24	6.85	3	48	13	97	0.01	0.0	11.378	0.149	0	0	0	12
PL.3023	PL.3022	C	#1/0 ACSR	7.30Y	121.7	0.02	3.26	6.85	3	48	13	97	0.01	0.0	11.491	0.113	0	0	0	12
PL.3024	PL.3023	C	#1/0 ACSR	7.30Y	121.7	0.02	3.28	6.85	3	48	13	97	0.01	0.0	11.643	0.152	0	0	0	12
PL.3025	PL.3024	C	#1/0 ACSR	7.30Y	121.7	0.02	3.30	6.85	3	48	13	97	0.01	0.0	11.775	0.133	0	0	0	12
PL.3026	PL.3025	C	#1/0 ACSR	7.30Y	121.7	0.02	3.33	6.85	3	48	13	97	0.01	0.0	11.918	0.143	0	0	0	12
PL.3027	PL.3026	C	#1/0 ACSR	7.30Y	121.7	0.01	3.34	6.85	3	48	13	97	0.00	0.0	12.004	0.086	7	2	2	12
PL.2753	PL.3027	C	#4 ACSR	7.30Y	121.6	0.02	3.36	5.83	4	41	11	97	0.00	0.0	12.065	0.061	0	0	0	10
PL.2849	PL.2753	C	#4 ACSR	7.30Y	121.6	0.02	3.37	3.81	3	27	7	97	0.00	0.0	12.158	0.093	0	0	0	7
PL.3338	PL.2849	C	#4 ACSR	7.30Y	121.6	0.01	3.38	3.81	3	27	7	97	0.00	0.0	12.239	0.080	4	1	1	7
PL.3339	PL.3338	C	#4 ACSR	7.30Y	121.6	0.01	3.40	3.24	2	23	6	97	0.00	0.0	12.373	0.134	21	6	3	6
PL.3340	PL.3339	C	#4 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.480	0.107	0	0	0	3
PL.2755	PL.3340	C	#4 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.637	0.157	0	0	0	3
PL.3028	PL.2755	C	#4 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.693	0.057	0	0	0	3
PL.2756	PL.3028	C	#4 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.732	0.039	0	0	0	3
PL.2757	PL.2756	C	#2 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.817	0.084	0	0	0	3
PL.3029	PL.2757	C	#2 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.900	0.084	0	0	0	3
PL.3341	PL.3029	C	#2 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.942	0.042	0	0	1	3
PL.3342	PL.3341	C	#2 ACSR	7.30Y	121.6	0.00	3.40	0.32	0	2	1	89	0.00	0.0	12.992	0.050	0	0	1	2
PL.2758	PL.3342	C	#2 ACSR	7.30Y	121.6	0.00	3.40	0.31	0	2	1	89	0.00	0.0	13.033	0.041	2	1	1	1
PL.2754	PL.2753	C	#2 ACSR	7.30Y	121.6	0.00	3.36	2.01	1	14	4	96	0.00	0.0	12.099	0.034	14	4	3	3
PL.2746	PL.3132	C	6 A (CWC)	7.39Y	123.1	0.00	1.89	1.26	1	9	2	98	0.00	0.0	9.168	0.080	9	2	2	2
PL.2745	PL.3013	C	#2 ACSR	7.40Y	123.3	0.00	1.71	0.43	0	3	1	95	0.00	0.0	8.975	0.044	3	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2744	PL.3138	C	#2 ACSR	7.44Y	124.1	0.00	0.94	0.35	0	3	1	95	0.00	0.0	8.352	0.030	3	1	1	1
PL.3609	PL.2726	ABC	#1/0 ACSR	7.20Y	120.1	0.02	4.94	17.27	8	359	101	96	0.06	0.0	7.881	0.077	0	0	0	107
PD.439	PL.3609	ABC	35L	7.20Y	120.1	0.00	4.94	17.27	49	359	101	96	0.00	0.0	7.881	0.077	0	0	0	107
PL.3610	PD.439	ABC	#1/0 ACSR	7.20Y	120.0	0.05	4.99	17.27	8	359	101	96	0.12	0.0	8.035	0.155	0	0	1	107
PL.2933	PL.3610	ABC	#1/0 ACSR	7.20Y	120.0	0.02	5.00	17.27	8	359	101	96	0.04	0.0	8.089	0.053	0	0	0	106
PL.2850	PL.2933	ABC	#1/0 ACSR	7.20Y	120.0	0.03	5.04	17.27	8	359	101	96	0.08	0.0	8.189	0.100	0	0	0	104
PL.3452	PL.2850	C	#4 ACSR	7.20Y	120.0	0.00	5.04	0.00	0	0	0	100	0.00	0.0	8.194	0.005	0	0	0	0
PD.388	PL.3452	C	40QA	7.20Y	120.0	0.00	5.04	0.00	0	0	0	100	0.00	0.0	8.194	0.005	0	0	0	0
PL.3453	PD.388	C	#4 ACSR	7.20Y	120.0	0.00	5.04	0.00	0	0	0	100	0.00	0.0	8.236	0.042	0	0	0	0
PL.3180	PL.2850	ABC	#1/0 ACSR	7.20Y	119.9	0.03	5.07	17.27	8	359	101	96	0.08	0.0	8.293	0.104	16	5	2	104
PL.3181	PL.3180	ABC	#1/0 ACSR	7.19Y	119.9	0.02	5.08	16.49	7	343	96	96	0.04	0.0	8.349	0.056	0	0	0	102
PL.3454	PL.3181	C	#4 ACSR	7.19Y	119.9	0.00	5.08	0.84	1	6	2	95	0.00	0.0	8.354	0.005	0	0	0	1
PD.389	PL.3454	C	40QA	7.19Y	119.9	0.00	5.08	0.84	2	6	2	95	0.00	0.0	8.354	0.005	0	0	0	1
PL.3455	PD.389	C	#4 ACSR	7.19Y	119.9	0.00	5.08	0.84	1	6	2	95	0.00	0.0	8.372	0.018	6	2	1	1
PL.2851	PL.3181	ABC	#1/0 ACSR	7.19Y	119.9	0.03	5.11	16.21	7	337	95	96	0.06	0.0	8.436	0.087	0	0	0	101
PL.3030	PL.2851	ABC	#1/0 ACSR	7.19Y	119.9	0.03	5.14	16.21	7	337	95	96	0.08	0.0	8.547	0.111	0	0	0	101
PL.3031	PL.3030	ABC	#1/0 ACSR	7.19Y	119.8	0.03	5.17	16.21	7	337	95	96	0.08	0.0	8.658	0.111	0	0	0	101
PL.3032	PL.3031	ABC	#1/0 ACSR	7.19Y	119.8	0.03	5.21	16.21	7	337	95	96	0.07	0.0	8.763	0.105	0	0	0	101
PL.3574	PL.3032	C	#4 ACSR	7.19Y	119.8	0.00	5.21	6.51	5	45	13	96	0.00	0.0	8.767	0.004	0	0	0	22
PD.422	PL.3574	C	40QA	7.19Y	119.8	0.00	5.21	6.51	16	45	13	96	0.00	0.0	8.767	0.004	0	0	0	22
PL.3575	PD.422	C	#4 ACSR	7.19Y	119.8	0.00	5.21	6.51	5	45	13	96	0.00	0.0	8.780	0.013	1	0	1	22
PL.2728	PL.3575	C	#4 ACSR	7.19Y	119.8	0.01	5.22	6.41	5	44	12	96	0.00	0.0	8.809	0.029	6	2	1	21
PL.2730	PL.2728	C	#4 ACSR	7.19Y	119.8	0.01	5.22	5.54	4	38	11	96	0.00	0.0	8.830	0.021	0	0	0	20
PL.3184	PL.2730	C	#4 ACSR	7.19Y	119.8	0.00	5.23	5.54	4	38	11	96	0.00	0.0	8.845	0.015	0	0	1	20
PL.3185	PL.3184	C	#4 ACSR	7.19Y	119.8	0.01	5.24	5.53	4	38	11	96	0.00	0.0	8.894	0.050	1	0	2	19
PL.3186	PL.3185	C	#4 ACSR	7.18Y	119.7	0.03	5.27	5.34	4	37	10	97	0.01	0.0	9.023	0.129	0	0	0	17
PL.3078	PL.3186	C	#4 ACSR	7.18Y	119.7	0.02	5.29	5.34	4	37	10	97	0.00	0.0	9.096	0.073	0	0	0	17
PL.3033	PL.3078	C	#4 ACSR	7.18Y	119.7	0.02	5.31	5.34	4	37	10	97	0.01	0.0	9.190	0.094	0	0	0	17
PL.3314	PL.3033	C	#4 ACSR	7.18Y	119.7	0.02	5.33	5.34	4	37	10	97	0.01	0.0	9.293	0.103	3	1	1	17
PL.3315	PL.3314	C	#4 ACSR	7.18Y	119.7	0.01	5.34	4.87	4	34	9	97	0.00	0.0	9.351	0.058	2	1	1	16
PL.3313	PL.3315	C	#4 ACSR	7.18Y	119.6	0.03	5.38	4.53	3	31	9	96	0.01	0.0	9.521	0.170	4	1	1	15

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3311	PL.3313	C	#4 ACSR	7.18Y	119.6	0.01	5.39	3.37	3	23	7	96	0.00	0.0	9.577	0.056	0	0	1	10
PL.3312	PL.3311	C	#4 ACSR	7.18Y	119.6	0.01	5.40	3.37	3	23	7	96	0.00	0.0	9.653	0.076	2	1	1	9
PL.3308	PL.3312	C	#4 ACSR	7.18Y	119.6	0.00	5.40	3.01	2	21	6	96	0.00	0.0	9.668	0.015	2	1	2	8
PL.3309	PL.3308	C	#4 ACSR	7.18Y	119.6	0.00	5.40	2.74	2	19	5	97	0.00	0.0	9.717	0.049	12	3	5	6
PL.3310	PL.3309	C	#4 ACSR	7.18Y	119.6	0.00	5.40	0.94	1	6	2	95	0.00	0.0	9.758	0.041	6	2	1	1
PL.2731	PL.3313	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.25	0	2	0	100	0.00	0.0	9.593	0.072	2	0	2	2
PL.3316	PL.3313	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.28	0	2	1	89	0.00	0.0	9.563	0.042	2	0	1	2
PL.3317	PL.3316	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.03	0	0	0	100	0.00	0.0	9.596	0.033	0	0	1	1
PL.2852	PL.3032	ABC	#1/0 ACSR	7.19Y	119.8	0.02	5.23	14.04	6	291	82	96	0.05	0.0	8.851	0.088	0	0	0	79
PL.3034	PL.2852	ABC	#1/0 ACSR	7.18Y	119.7	0.04	5.26	14.04	6	291	82	96	0.07	0.0	8.990	0.139	0	0	0	79
PL.2853	PL.3034	ABC	#1/0 ACSR	7.18Y	119.7	0.02	5.28	13.89	6	288	81	96	0.04	0.0	9.069	0.079	0	0	0	78
PL.2900	PL.2853	C	#2 ACSR 6/	7.18Y	119.7	0.00	5.28	1.94	1	13	4	96	0.00	0.0	9.079	0.010	7	2	1	2
PL.2901	PL.2900	C	#2 ACSR 6/	7.18Y	119.7	0.00	5.28	0.89	0	6	2	95	0.00	0.0	9.114	0.035	6	2	1	1
PL.3434	PL.2853	A	#4 ACSR	7.18Y	119.7	0.00	5.28	5.77	4	40	11	96	0.00	0.0	9.074	0.005	0	0	0	8
PD.379	PL.3434	A	40QA	7.18Y	119.7	0.00	5.28	5.77	14	40	11	96	0.00	0.0	9.074	0.005	0	0	0	8
PL.3435	PD.379	A	#4 ACSR	7.18Y	119.7	0.01	5.29	5.77	4	40	11	96	0.00	0.0	9.112	0.038	0	0	0	8
PL.2904	PL.3435	A	#4 ACSR	7.18Y	119.7	0.01	5.30	2.89	2	20	6	96	0.00	0.0	9.172	0.061	1	0	1	4
PL.2909	PL.2904	A	#4 ACSR	7.18Y	119.7	0.00	5.31	2.75	2	19	5	97	0.00	0.0	9.246	0.073	19	5	3	3
PL.2910	PL.2909	A	#4 ACSR	7.18Y	119.7	0.00	5.31	0.00	0	0	0	100	0.00	0.0	9.291	0.045	0	0	0	0
PL.2734	PL.3435	A	#4 ACSR	7.18Y	119.7	0.01	5.30	2.88	2	20	6	96	0.00	0.0	9.160	0.048	1	0	1	4
PL.2733	PL.2734	A	#4 ACSR	7.18Y	119.7	0.00	5.30	1.03	1	7	2	96	0.00	0.0	9.174	0.014	7	2	1	1
PL.2732	PL.2734	A	#4 ACSR	7.18Y	119.7	0.00	5.30	1.64	1	11	3	96	0.00	0.0	9.209	0.049	11	3	2	2
PL.2902	PL.2853	ABC	#1/0 ACSR	7.18Y	119.7	0.01	5.30	11.32	5	235	66	96	0.02	0.0	9.139	0.070	2	1	1	68
PL.2903	PL.2902	ABC	#1/0 ACSR	7.18Y	119.7	0.01	5.31	11.21	5	232	65	96	0.02	0.0	9.206	0.067	0	0	0	67
PL.3035	PL.2903	ABC	#1/0 ACSR	7.18Y	119.7	0.01	5.32	11.21	5	232	65	96	0.02	0.0	9.272	0.066	0	0	0	67
PL.2907	PL.3035	ABC	#1/0 ACSR	7.18Y	119.6	0.03	5.35	11.21	5	232	65	96	0.05	0.0	9.412	0.140	0	0	0	67
PL.2908	PL.2907	ABC	#1/0 ACSR	7.18Y	119.6	0.01	5.36	11.21	5	232	65	96	0.02	0.0	9.469	0.057	4	1	3	67
PL.2906	PL.2908	ABC	#1/0 ACSR	7.18Y	119.6	0.02	5.38	11.00	5	228	64	96	0.02	0.0	9.546	0.077	5	1	1	64
PL.2905	PL.2906	ABC	#1/0 ACSR	7.18Y	119.6	0.02	5.40	10.75	5	223	63	96	0.03	0.0	9.645	0.099	0	0	0	63
PL.3036	PL.2905	ABC	#1/0 ACSR	7.18Y	119.6	0.02	5.41	10.75	5	223	63	96	0.03	0.0	9.729	0.084	0	0	0	63
PL.3037	PL.3036	ABC	#1/0 ACSR	7.17Y	119.6	0.02	5.43	10.75	5	223	63	96	0.03	0.0	9.833	0.104	0	0	0	63

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3038	PL.3037	ABC	#1/0 ACSR	7.17Y	119.6	0.00	5.44	10.75	5	223	62	96	0.01	0.0	9.859	0.026	0	0	0	63
PL.2854	PL.3038	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.46	10.43	5	216	61	96	0.03	0.0	9.960	0.101	0	0	0	59
PL.2735	PL.2854	A	#1/0 ACSR	7.17Y	119.5	0.00	5.46	1.16	1	8	2	97	0.00	0.0	9.997	0.037	8	2	1	1
PL.2855	PL.2854	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.48	10.05	4	208	58	96	0.03	0.0	10.058	0.098	0	0	0	58
PL.3039	PL.2855	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.49	10.05	4	208	58	96	0.02	0.0	10.142	0.084	0	0	0	58
PL.3040	PL.3039	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.51	10.05	4	208	58	96	0.02	0.0	10.233	0.090	0	0	0	58
PL.3142	PL.3040	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.53	10.05	4	208	58	96	0.02	0.0	10.326	0.093	4	1	1	58
PL.3295	PL.3142	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.54	9.39	4	194	54	96	0.03	0.0	10.439	0.113	2	1	1	52
PL.3296	PL.3295	ABC	#1/0 ACSR	7.17Y	119.4	0.01	5.55	9.28	4	192	54	96	0.01	0.0	10.489	0.049	0	0	0	51
PL.2936	PL.3296	C	#2 ACSR	7.17Y	119.4	0.00	5.55	1.11	1	8	2	97	0.00	0.0	10.493	0.005	0	0	0	1
PD.407	PL.2936	C	40QA	7.17Y	119.4	0.00	5.55	1.11	3	8	2	97	0.00	0.0	10.493	0.005	0	0	0	1
PL.2937	PD.407	C	#2 ACSR	7.17Y	119.4	0.00	5.55	1.11	1	8	2	97	0.00	0.0	10.534	0.041	8	2	1	1
PL.2856	PL.3296	ABC	#1/0 ACSR	7.17Y	119.4	0.01	5.56	8.91	4	184	52	96	0.01	0.0	10.552	0.063	0	0	0	50
PL.3486	PL.2856	A	#1/0 ACSR	7.17Y	119.4	0.00	5.56	7.60	3	52	15	96	0.00	0.0	10.556	0.005	0	0	0	16
PD.405	PL.3486	A	40QA	7.17Y	119.4	0.00	5.56	7.60	19	52	15	96	0.00	0.0	10.556	0.005	0	0	0	16
PL.3487	PD.405	A	#1/0 ACSR	7.17Y	119.4	0.00	5.57	7.60	3	52	15	96	0.00	0.0	10.575	0.019	0	0	0	16
PL.3297	PL.3487	A	#1/0 ACSR	7.17Y	119.4	0.01	5.58	7.60	3	52	15	96	0.00	0.0	10.633	0.057	0	0	0	16
PL.3280	PL.3297	A	#1/0 ACSR	7.16Y	119.4	0.02	5.60	7.60	3	52	15	96	0.01	0.0	10.747	0.115	0	0	0	16
PL.3281	PL.3280	A	#1/0 ACSR	7.16Y	119.4	0.01	5.61	7.60	3	52	15	96	0.00	0.0	10.833	0.086	15	4	3	16
PL.3282	PL.3281	A	#1/0 ACSR	7.16Y	119.4	0.01	5.62	5.46	2	38	11	96	0.00	0.0	10.946	0.113	0	0	2	13
PL.2896	PL.3282	A	#1/0 ACSR	7.16Y	119.4	0.01	5.63	5.39	2	37	10	97	0.00	0.0	11.025	0.078	17	5	6	11
PL.2897	PL.2896	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	3.00	1	21	6	96	0.00	0.0	11.083	0.058	0	0	1	5
PL.2898	PL.2897	A	#1/0 ACSR	7.16Y	119.4	0.01	5.64	1.89	1	13	4	96	0.00	0.0	11.233	0.151	2	0	1	3
PL.2899	PL.2898	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	1.64	1	11	3	96	0.00	0.0	11.257	0.024	0	0	0	2
PL.2858	PL.2899	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	0.82	0	6	2	95	0.00	0.0	11.290	0.033	6	2	1	1
PL.2736	PL.2899	A	#4 ACSR	7.16Y	119.4	0.00	5.64	0.82	1	6	2	95	0.00	0.0	11.285	0.028	6	2	1	1
PL.2737	PL.2897	A	#2 ACSR	7.16Y	119.4	0.00	5.64	1.05	1	7	2	96	0.00	0.0	11.114	0.032	7	2	1	1
PL.2857	PL.2856	ABC	#1/0 ACSR	7.17Y	119.4	0.00	5.57	6.38	3	132	37	96	0.00	0.0	10.595	0.043	0	0	0	34
PL.2934	PL.2857	A	#2 ACSR	7.17Y	119.4	0.00	5.57	1.42	1	10	3	96	0.00	0.0	10.599	0.005	0	0	0	2
PD.406	PL.2934	A	40QA	7.17Y	119.4	0.00	5.57	1.42	4	10	3	96	0.00	0.0	10.599	0.005	0	0	0	2
PL.2935	PD.406	A	#2 ACSR	7.17Y	119.4	0.00	5.57	1.42	1	10	3	96	0.00	0.0	10.621	0.022	10	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2859	PL.2857	ABC	#1/0 ACSR	7.17Y	119.4	0.00	5.57	5.90	3	122	34	96	0.00	0.0	10.638	0.044	0	0	0	32
PL.3484	PL.2859	A	#4 ACSR	7.17Y	119.4	0.00	5.58	17.71	14	122	34	96	0.00	0.0	10.643	0.005	0	0	0	32
PD.404	PL.3484	A	25T	7.17Y	119.4	0.00	5.58	17.71	0	122	34	96	0.00	0.0	10.643	0.005	0	0	0	32
PL.3485	PD.404	A	#4 ACSR	7.16Y	119.4	0.04	5.61	17.71	14	122	34	96	0.03	0.0	10.691	0.048	10	3	3	32
PL.3279	PL.3485	A	#4 ACSR	7.16Y	119.3	0.11	5.73	16.23	12	112	31	96	0.10	0.1	10.853	0.162	6	2	2	29
PL.3278	PL.3279	A	#4 ACSR	7.15Y	119.2	0.03	5.76	15.30	12	105	30	96	0.03	0.0	10.904	0.052	4	1	2	27
PL.3277	PL.3278	A	#4 ACSR	7.15Y	119.1	0.10	5.86	14.73	11	102	28	96	0.08	0.1	11.059	0.155	0	0	0	25
PL.3293	PL.3277	A	#4 ACSR	7.14Y	119.1	0.05	5.92	14.73	11	101	28	96	0.04	0.0	11.144	0.084	5	1	1	25
PL.3294	PL.3293	A	#4 ACSR	7.14Y	119.0	0.07	5.99	14.07	11	97	27	96	0.05	0.1	11.254	0.110	0	0	0	24
PL.2738	PL.3294	A	#4 ACSR	7.14Y	119.0	0.06	6.04	14.07	11	97	27	96	0.04	0.0	11.345	0.091	0	0	0	24
PL.3290	PL.2738	A	#4 ACSR	7.13Y	118.9	0.06	6.10	14.07	11	97	27	96	0.04	0.0	11.446	0.102	10	3	1	24
PL.3291	PL.3290	A	#4 ACSR	7.13Y	118.9	0.03	6.13	12.55	10	86	24	96	0.02	0.0	11.492	0.046	4	1	2	23
PL.3292	PL.3291	A	#4 ACSR	7.13Y	118.8	0.06	6.18	11.98	9	82	23	96	0.04	0.0	11.597	0.104	0	0	0	21
PL.3041	PL.3292	A	#4 ACSR	7.13Y	118.8	0.05	6.24	11.98	9	82	23	96	0.04	0.0	11.699	0.102	0	0	0	21
PL.2740	PL.3041	A	#2 ACSR	7.13Y	118.8	0.00	6.24	1.99	1	14	4	96	0.00	0.0	11.765	0.066	14	4	2	2
PL.2739	PL.3041	A	#4 ACSR	7.12Y	118.7	0.04	6.28	9.99	8	69	19	96	0.02	0.0	11.804	0.105	10	3	2	19
PL.3288	PL.2739	A	#4 ACSR	7.12Y	118.7	0.00	6.29	1.69	1	12	3	97	0.00	0.0	11.879	0.075	10	3	2	3
PL.3289	PL.3288	A	#4 ACSR	7.12Y	118.7	0.00	6.29	0.25	0	2	0	100	0.00	0.0	11.949	0.071	2	0	1	1
PL.3285	PL.3289	A	#4 ACSR	7.12Y	118.7	0.00	6.29	0.00	0	0	0	100	0.00	0.0	12.100	0.150	0	0	0	0
PL.3042	PL.3285	A	#4 ACSR	7.12Y	118.7	0.00	6.29	0.00	0	0	0	100	0.00	0.0	12.206	0.106	0	0	0	0
PL.3079	PL.3042	A	#4 ACSR	7.12Y	118.7	0.00	6.29	0.00	0	0	0	100	0.00	0.0	12.286	0.080	0	0	0	0
PL.3043	PL.3079	A	#4 ACSR	7.12Y	118.7	0.00	6.29	0.00	0	0	0	100	0.00	0.0	12.345	0.059	0	0	0	0
PL.3286	PL.2739	A	#4 ACSR	7.12Y	118.7	0.02	6.30	6.85	5	47	13	96	0.01	0.0	11.862	0.058	1	0	2	14
PL.3287	PL.3286	A	#4 ACSR	7.12Y	118.7	0.01	6.31	6.68	5	46	13	96	0.00	0.0	11.917	0.055	13	4	1	12
PL.3283	PL.3287	A	#4 ACSR	7.12Y	118.7	0.01	6.32	4.72	4	32	9	96	0.00	0.0	11.967	0.050	9	2	3	11
PL.3284	PL.3283	A	#4 ACSR	7.12Y	118.7	0.01	6.33	3.47	3	24	7	96	0.00	0.0	12.006	0.039	6	2	1	8
PL.3301	PL.3284	A	#4 ACSR	7.12Y	118.7	0.02	6.35	2.65	2	18	5	96	0.00	0.0	12.147	0.141	0	0	0	7
PL.3302	PL.3301	A	#4 ACSR	7.12Y	118.6	0.02	6.36	2.65	2	18	5	96	0.00	0.0	12.281	0.134	0	0	0	7
PL.3044	PL.3302	A	#4 ACSR	7.12Y	118.6	0.01	6.37	2.65	2	18	5	96	0.00	0.0	12.355	0.074	0	0	0	7
PL.2741	PL.3044	A	#4 ACSR	7.12Y	118.6	0.00	6.37	1.32	1	9	3	95	0.00	0.0	12.422	0.067	0	0	0	5
PL.3298	PL.2741	A	#4 ACSR	7.12Y	118.6	0.01	6.38	1.32	1	9	3	95	0.00	0.0	12.537	0.115	1	0	2	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3299	PL.3298	A	#4 ACSR	7.12Y	118.6	0.00	6.38	1.22	1	8	2	97	0.00	0.0	12.613	0.076	0	0	0	3
PL.3300	PL.3299	A	#4 ACSR	7.12Y	118.6	0.01	6.39	1.22	1	8	2	97	0.00	0.0	12.744	0.130	0	0	0	3
PL.3303	PL.3300	A	#4 ACSR	7.12Y	118.6	0.00	6.40	1.22	1	8	2	97	0.00	0.0	12.891	0.147	8	2	3	3
PL.3304	PL.3303	A	#4 ACSR	7.12Y	118.6	0.00	6.40	0.00	0	0	0	100	0.00	0.0	13.019	0.128	0	0	0	0
PL.2743	PL.3304	A	#4 ACSR	7.12Y	118.6	0.00	6.40	0.00	0	0	0	100	0.00	0.0	13.077	0.058	0	0	0	0
PL.2742	PL.3044	A	#4 ACSR	7.12Y	118.6	0.00	6.37	1.34	1	9	3	95	0.00	0.0	12.405	0.050	9	3	2	2
PL.3482	PL.3142	A	#2 ACSR	7.17Y	119.5	0.00	5.53	1.46	1	10	3	96	0.00	0.0	10.330	0.005	0	0	0	5
PD.403	PL.3482	A	40QA	7.17Y	119.5	0.00	5.53	1.46	4	10	3	96	0.00	0.0	10.330	0.005	0	0	0	5
PL.3483	PD.403	A	#2 ACSR	7.17Y	119.5	0.00	5.53	1.46	1	10	3	96	0.00	0.0	10.358	0.028	10	3	5	5
PL.3438	PL.3038	A	#4 ACSR	7.17Y	119.6	0.00	5.44	0.95	1	7	2	96	0.00	0.0	9.864	0.005	0	0	0	4
PD.381	PL.3438	A	40QA	7.17Y	119.6	0.00	5.44	0.95	2	7	2	96	0.00	0.0	9.864	0.005	0	0	0	4
PL.3439	PD.381	A	#4 ACSR	7.17Y	119.6	0.00	5.44	0.95	1	7	2	96	0.00	0.0	9.918	0.054	7	2	4	4
PL.3436	PL.3034	C	#2 ACSR	7.18Y	119.7	0.00	5.26	0.44	0	3	1	95	0.00	0.0	8.994	0.005	0	0	0	1
PD.380	PL.3436	C	40QA	7.18Y	119.7	0.00	5.26	0.44	1	3	1	95	0.00	0.0	8.994	0.005	0	0	0	1
PL.3437	PD.380	C	#2 ACSR	7.18Y	119.7	0.00	5.26	0.44	0	3	1	95	0.00	0.0	9.011	0.016	3	1	1	1
PL.3450	PL.2933	C	#4 ACSR	7.20Y	120.0	0.00	5.00	0.00	0	0	0	100	0.00	0.0	8.094	0.005	0	0	0	2
PD.387	PL.3450	C	40QA	7.20Y	120.0	0.00	5.00	0.00	0	0	0	100	0.00	0.0	8.094	0.005	0	0	0	2
PL.3451	PD.387	C	#4 ACSR	7.20Y	120.0	0.00	5.00	0.00	0	0	0	100	0.00	0.0	8.105	0.012	0	0	1	2
PL.3179	PL.3451	C	#4 ACSR	7.20Y	120.0	0.00	5.00	0.00	0	0	0	100	0.00	0.0	8.177	0.072	0	0	1	1
PL.2722	PL.2847	A	#1/0 ACSR	7.26Y	121.1	0.00	3.94	0.32	0	2	1	89	0.00	0.0	6.430	0.035	2	1	1	1
PL.3446	PL.3612	A	6 A (CWC)	7.28Y	121.3	0.00	3.70	0.47	0	3	1	95	0.00	0.0	6.118	0.005	0	0	0	3
PD.385	PL.3446	A	15T	7.28Y	121.3	0.00	3.70	0.47	0	3	1	95	0.00	0.0	6.118	0.005	0	0	0	3
PL.3447	PD.385	A	6 A (CWC)	7.28Y	121.3	0.00	3.70	0.47	0	3	1	95	0.00	0.0	6.210	0.092	1	0	1	3
PL.2709	PL.3447	A	#4 ACSR	7.28Y	121.3	0.00	3.70	0.34	0	2	1	89	0.00	0.0	6.250	0.040	2	1	2	2
PL.2710	PL.3447	A	6 A (CWC)	7.28Y	121.3	0.00	3.70	0.00	0	0	0	100	0.00	0.0	6.247	0.037	0	0	0	0
CP.6	PL.3611	ABC	Cap (300)	7.28Y	121.4	0.00	3.61	0.00	0	0	0	100	0.00	0.0	6.010	0.037	0	0	0	0
PL.3456	PL.3190	A	#4 ACSR	7.36Y	122.7	0.00	2.32	1.77	1	13	3	97	0.00	0.0	4.688	0.005	0	0	0	4
PD.390	PL.3456	A	10T	7.36Y	122.7	0.00	2.32	1.77	0	13	3	97	0.00	0.0	4.688	0.005	0	0	0	4
PL.3457	PD.390	A	#4 ACSR	7.36Y	122.7	0.00	2.32	1.77	1	13	3	97	0.00	0.0	4.738	0.050	13	3	4	4
PL.3468	PL.2686	A	6 A (CWC)	7.40Y	123.3	0.00	1.70	0.79	1	6	2	95	0.00	0.0	4.117	0.005	0	0	0	1
PD.397	PL.3468	A	40QA	7.40Y	123.3	0.00	1.70	0.79	2	6	2	95	0.00	0.0	4.117	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3469	PD.397	A	6 A (CWC)	7.40Y	123.3	0.00	1.70	0.79	1	6	2	95	0.00	0.0	4.175	0.058	6	2	1	1
PL.2684	PL.2683	ABC	#1/0 ACSR	7.41Y	123.5	0.03	1.54	17.73	8	379	107	96	0.07	0.0	4.037	0.089	1	0	3	127
PL.3218	PL.2684	ABC	#1/0 ACSR	7.41Y	123.4	0.02	1.56	17.68	8	378	107	96	0.06	0.0	4.112	0.075	0	0	1	124
PL.3601	PL.3218	ABC	#1/0 ACSR	7.41Y	123.4	0.00	1.57	17.67	8	378	107	96	0.00	0.0	4.117	0.005	0	0	0	123
PD.435	PL.3601	ABC	70L	7.41Y	123.4	0.00	1.57	17.67	25	378	107	96	0.00	0.0	4.117	0.005	0	0	0	123
PL.3602	PD.435	ABC	#1/0 ACSR	7.40Y	123.4	0.03	1.59	17.67	8	378	107	96	0.07	0.0	4.201	0.084	3	1	1	123
PL.3219	PL.3602	ABC	#1/0 ACSR	7.40Y	123.4	0.03	1.62	17.52	8	375	106	96	0.07	0.0	4.290	0.088	1	0	1	122
PL.3220	PL.3219	ABC	#1/0 ACSR	7.40Y	123.4	0.03	1.65	17.45	8	373	105	96	0.06	0.0	4.371	0.082	17	5	4	121
PL.3221	PL.3220	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.67	16.65	7	356	100	96	0.05	0.0	4.435	0.064	8	2	4	117
PL.3225	PL.3221	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.67	16.29	7	348	98	96	0.02	0.0	4.468	0.032	5	1	1	113
PL.3226	PL.3225	ABC	#1/0 ACSR	7.40Y	123.3	0.01	1.69	16.04	7	343	97	96	0.03	0.0	4.517	0.049	0	0	1	112
PL.3227	PL.3226	ABC	#1/0 ACSR	7.40Y	123.3	0.02	1.71	16.04	7	343	97	96	0.06	0.0	4.603	0.086	0	0	0	111
PL.3223	PL.3227	ABC	#1/0 ACSR	7.40Y	123.3	0.03	1.74	16.04	7	343	96	96	0.06	0.0	4.690	0.088	5	2	1	111
PL.3224	PL.3223	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.76	15.78	7	337	95	96	0.06	0.0	4.779	0.089	3	1	1	110
PL.3222	PL.3224	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.79	15.64	7	334	94	96	0.05	0.0	4.861	0.082	3	1	2	109
PL.3474	PL.3222	ABC	#1/0 ACSR	7.39Y	123.2	0.00	1.79	15.32	7	327	92	96	0.00	0.0	4.865	0.005	0	0	0	105
PL.3475	PL.3474	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.81	15.32	7	327	92	96	0.06	0.0	4.955	0.090	2	0	1	105
PL.3237	PL.3475	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.84	15.25	7	325	92	96	0.07	0.0	5.065	0.110	2	1	1	104
PL.3238	PL.3237	ABC	#1/0 ACSR	7.39Y	123.1	0.03	1.87	15.15	7	323	91	96	0.07	0.0	5.176	0.111	7	2	2	103
PL.3236	PL.3238	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.89	14.81	6	316	89	96	0.03	0.0	5.236	0.060	10	3	2	101
PL.3234	PL.3236	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.91	14.34	6	306	86	96	0.04	0.0	5.317	0.081	2	1	1	99
PL.3235	PL.3234	ABC	#1/0 ACSR	7.38Y	123.1	0.02	1.93	14.23	6	304	85	96	0.04	0.0	5.397	0.080	5	1	1	98
PL.3233	PL.3235	ABC	#1/0 ACSR	7.38Y	123.1	0.02	1.95	14.01	6	299	84	96	0.04	0.0	5.471	0.074	2	1	1	97
PL.3480	PL.3233	A	#2 ACSR	7.38Y	123.1	0.00	1.95	0.52	0	4	1	97	0.00	0.0	5.476	0.005	0	0	0	1
PD.402	PL.3480	A	40QA	7.38Y	123.1	0.00	1.95	0.52	1	4	1	97	0.00	0.0	5.476	0.005	0	0	0	1
PL.3481	PD.402	A	#2 ACSR	7.38Y	123.1	0.00	1.95	0.52	0	4	1	97	0.00	0.0	5.492	0.016	4	1	1	1
PL.3117	PL.3233	ABC	#1/0 ACSR	7.38Y	123.0	0.04	1.99	13.74	6	293	82	96	0.07	0.0	5.618	0.147	0	0	0	95
PL.2829	PL.3117	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.01	13.64	6	291	82	96	0.05	0.0	5.722	0.104	0	0	0	94
PL.3058	PL.2829	ABC	#1/0 ACSR	7.38Y	123.0	0.02	2.03	13.64	6	291	82	96	0.04	0.0	5.793	0.071	0	0	0	94
PL.2888	PL.3058	ABC	#1/0 ACSR	7.38Y	122.9	0.02	2.05	13.64	6	291	82	96	0.04	0.0	5.881	0.089	0	0	0	94
PL.3229	PL.2888	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.08	13.64	6	291	81	96	0.07	0.0	6.016	0.135	5	1	1	94

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.3230	PL.3229	ABC	#1/0 ACSR	7.37Y	122.9	0.02	2.11	13.39	6	285	80	96	0.04	0.0	6.105	0.089	0	0	0	93
PL.3346	PL.3230	ABC	#1/0 ACSR	7.37Y	122.9	0.02	2.12	13.18	6	281	79	96	0.03	0.0	6.172	0.067	4	1	1	91
PL.3347	PL.3346	ABC	#1/0 ACSR	7.37Y	122.9	0.02	2.14	13.01	6	277	78	96	0.04	0.0	6.269	0.097	4	1	3	90
PL.3597	PL.3347	A	#4 ACSR	7.37Y	122.9	0.00	2.14	6.12	5	43	12	96	0.00	0.0	6.272	0.003	0	0	0	15
PD.433	PL.3597	A	35H	7.37Y	122.9	0.00	2.14	6.12	17	43	12	96	0.00	0.0	6.272	0.003	0	0	0	15
PL.3598	PD.433	A	#4 ACSR	7.37Y	122.8	0.02	2.16	6.12	5	43	12	96	0.01	0.0	6.338	0.066	3	1	1	15
PL.3345	PL.3598	A	#4 ACSR	7.37Y	122.8	0.02	2.18	5.65	4	40	11	96	0.01	0.0	6.416	0.078	0	0	0	14
PL.2764	PL.3345	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	6.541	0.125	0	0	0	0
PL.3343	PL.3345	A	#4 ACSR	7.37Y	122.8	0.01	2.20	5.65	4	40	11	96	0.00	0.0	6.471	0.055	0	0	0	14
PL.3344	PL.3343	A	#4 ACSR	7.37Y	122.8	0.04	2.24	5.65	4	40	11	96	0.01	0.0	6.634	0.163	0	0	0	14
PL.2759	PL.3344	A	#4 ACSR	7.36Y	122.7	0.03	2.27	5.65	4	40	11	96	0.01	0.0	6.753	0.120	0	0	0	14
PL.3065	PL.2759	A	#4 ACSR	7.36Y	122.7	0.02	2.28	5.65	4	40	11	96	0.01	0.0	6.824	0.070	0	0	0	14
PL.2889	PL.3065	A	#4 ACSR	7.36Y	122.7	0.04	2.33	5.65	4	40	11	96	0.01	0.0	6.991	0.167	0	0	0	14
PL.2890	PL.2889	A	#4 ACSR	7.36Y	122.6	0.03	2.36	5.65	4	40	11	96	0.01	0.0	7.125	0.135	0	0	0	14
PL.2891	PL.2890	A	#4 ACSR	7.36Y	122.6	0.03	2.39	5.65	4	40	11	96	0.01	0.0	7.225	0.100	0	0	0	14
PL.3348	PL.2891	A	#4 ACSR	7.36Y	122.6	0.01	2.39	5.65	4	40	11	96	0.00	0.0	7.256	0.031	6	2	2	14
PL.3349	PL.3348	A	#4 ACSR	7.35Y	122.6	0.03	2.42	4.75	4	34	9	97	0.01	0.0	7.393	0.137	0	0	0	12
PL.2892	PL.3349	A	#4 ACSR	7.35Y	122.5	0.03	2.45	4.75	4	34	9	97	0.01	0.0	7.535	0.142	0	0	0	12
PL.3123	PL.2892	A	#4 ACSR	7.35Y	122.5	0.03	2.48	4.75	4	34	9	97	0.01	0.0	7.660	0.125	0	0	0	12
PL.3124	PL.3123	A	#4 ACSR	7.35Y	122.5	0.03	2.51	4.75	4	34	9	97	0.01	0.0	7.845	0.185	11	3	3	12
PL.3125	PL.3124	A	#4 ACSR	7.35Y	122.5	0.01	2.52	2.86	2	20	6	96	0.00	0.0	7.952	0.107	4	1	1	8
PL.2767	PL.3125	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.76	1	5	1	98	0.00	0.0	8.079	0.128	0	0	0	4
PL.2830	PL.2767	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.30	0	2	1	89	0.00	0.0	8.139	0.060	0	0	0	3
PL.2831	PL.2830	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	8.174	0.035	0	0	0	0
PL.2769	PL.2830	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.30	0	2	1	89	0.00	0.0	8.226	0.086	0	0	0	3
PL.3350	PL.2769	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.30	0	2	1	89	0.00	0.0	8.320	0.095	1	0	1	3
PL.3351	PL.3350	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.14	0	1	0	100	0.00	0.0	8.481	0.161	0	0	0	2
PL.2893	PL.3351	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.14	0	1	0	100	0.00	0.0	8.586	0.105	0	0	0	2
PL.3066	PL.2893	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.14	0	1	0	100	0.00	0.0	8.656	0.070	0	0	0	2
PL.2894	PL.3066	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.14	0	1	0	100	0.00	0.0	8.729	0.073	1	0	2	2
PL.2768	PL.2767	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.46	0	3	1	95	0.00	0.0	8.124	0.045	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3126	PL.3125	A	#4 ACSR	7.35Y	122.5	0.00	2.53	0.92	1	7	2	96	0.00	0.0	8.045	0.093	7	2	2	2
PL.4492	PL.3125	A	#1/0 ACSR	7.35Y	122.5	0.00	2.53	0.65	0	5	1	98	0.00	0.0	8.181	0.229	0	0	0	1
PL.4494	PL.4492	A	#1/0 ACSR	7.35Y	122.5	0.00	2.53	0.65	0	5	1	98	0.00	0.0	8.350	0.169	5	1	1	1
PL.4493	PL.4492	A	#1/0 ACSR	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	8.245	0.063	0	0	0	0
PL.2766	PL.3124	A	#4 ACSR	7.35Y	122.5	0.00	2.51	0.36	0	3	1	95	0.00	0.0	7.949	0.104	3	1	1	1
PL.3118	PL.3347	ABC	#1/0 ACSR	7.37Y	122.8	0.01	2.15	10.64	5	226	63	96	0.01	0.0	6.307	0.038	0	0	0	71
PL.3114	PL.3118	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.15	2.11	1	45	13	96	0.00	0.0	6.383	0.076	9	3	2	10
PL.3115	PL.3114	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.51	1	32	9	96	0.00	0.0	6.425	0.042	0	0	0	7
PL.2834	PL.3115	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.83	0	18	5	96	0.00	0.0	6.536	0.111	0	0	0	3
PL.2835	PL.2834	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.38	0	8	2	97	0.00	0.0	6.579	0.043	0	0	0	1
PL.3106	PL.2835	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.38	0	8	2	97	0.00	0.0	6.594	0.015	0	0	0	1
PL.3107	PL.3106	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.00	0	0	0	100	0.00	0.0	6.746	0.151	0	0	0	0
PL.2967	PL.3107	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.00	0	0	0	100	0.00	0.0	6.870	0.125	0	0	0	0
PL.3607	PL.2967	ABC	#1/0 ACSR	7.37Y	122.8	0.00	2.16	0.00	0	0	0	100	0.00	0.0	6.952	0.082	0	0	0	0
PD.438-A	PL.3607	ABC	Open	7.37Y	122.8	0.00	2.16	0.00	0	0	0	100	0.00	0.0	6.952	0.082	0	0	0	0
PL.3578	PL.3106	C	#2 ACSR	7.37Y	122.8	0.00	2.16	1.13	1	8	2	97	0.00	0.0	6.599	0.005	0	0	0	1
PD.424	PL.3578	C	40QA	7.37Y	122.8	0.00	2.16	1.13	3	8	2	97	0.00	0.0	6.599	0.005	0	0	0	1
PL.3579	PD.424	C	#2 ACSR	7.37Y	122.8	0.00	2.16	1.13	1	8	2	97	0.00	0.0	6.645	0.046	8	2	1	1
PL.2940	PL.2834	A	6 A (CWC)	7.37Y	122.8	0.00	2.16	1.37	1	10	3	96	0.00	0.0	6.541	0.005	0	0	0	2
PD.410	PL.2940	A	15T	7.37Y	122.8	0.00	2.16	1.37	0	10	3	96	0.00	0.0	6.541	0.005	0	0	0	2
PL.2941	PD.410	A	6 A (CWC)	7.37Y	122.8	0.01	2.16	1.37	1	10	3	96	0.00	0.0	6.659	0.118	5	1	1	2
PL.3352	PL.2941	A	6 A (CWC)	7.37Y	122.8	0.00	2.16	0.68	0	5	1	98	0.00	0.0	6.746	0.087	5	1	1	1
PL.2762	PL.3115	C	#4 ACSR	7.37Y	122.8	0.00	2.16	2.03	2	14	4	96	0.00	0.0	6.430	0.005	0	0	0	4
PD.409	PL.2762	C	40QA	7.37Y	122.8	0.00	2.16	2.03	5	14	4	96	0.00	0.0	6.430	0.005	0	0	0	4
PL.3110	PD.409	C	#4 ACSR	7.37Y	122.8	0.00	2.16	0.72	1	5	1	98	0.00	0.0	6.445	0.015	0	0	0	1
PL.2763	PL.3110	C	#4 ACSR	7.37Y	122.8	0.00	2.16	0.72	1	5	1	98	0.00	0.0	6.492	0.047	5	1	1	1
PL.3353	PD.409	C	#4 ACSR	7.37Y	122.8	0.00	2.16	1.31	1	9	3	95	0.00	0.0	6.510	0.080	5	1	1	3
PL.3354	PL.3353	C	#4 ACSR	7.37Y	122.8	0.00	2.16	0.59	0	4	1	97	0.00	0.0	6.523	0.013	4	1	2	2
PL.2761	PL.3114	A	#2 ACSR	7.37Y	122.8	0.00	2.15	0.48	0	3	1	95	0.00	0.0	6.441	0.057	3	1	1	1
PL.2942	PL.3118	A	6 A (CWC)	7.37Y	122.8	0.01	2.16	25.57	18	181	51	96	0.01	0.0	6.312	0.005	0	0	0	61
PD.411	PL.2942	A	30T	7.37Y	122.8	0.00	2.16	25.57	0	181	51	96	0.00	0.0	6.312	0.005	0	0	0	61

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2943	PD.411	A	6 A (CWC)	7.37Y	122.8	0.05	2.21	25.57	18	181	51	96	0.07	0.0	6.353	0.042	2	0	4	61
PL.2760	PL.2943	A	#4 ACSR	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	6.409	0.056	0	0	1	1
PL.3116	PL.2943	A	6 A (CWC)	7.36Y	122.7	0.06	2.26	25.33	18	180	50	96	0.08	0.0	6.405	0.052	6	2	3	56
PL.2794	PL.3116	A	6 A (CWC)	7.36Y	122.7	0.07	2.34	24.51	18	174	49	96	0.10	0.1	6.472	0.066	0	0	0	53
PL.2795	PL.2794	A	6 A (CWC)	7.36Y	122.7	0.00	2.34	2.17	2	15	4	97	0.00	0.0	6.515	0.043	6	2	1	4
PL.2796	PL.2795	A	#4 ACSR	7.36Y	122.7	0.00	2.34	1.33	1	9	3	95	0.00	0.0	6.531	0.016	9	3	3	3
PL.3108	PL.2794	A	6 A (CWC)	7.36Y	122.6	0.07	2.40	22.34	16	158	44	96	0.08	0.0	6.536	0.064	0	0	1	49
PL.3109	PL.3108	A	6 A (CWC)	7.35Y	122.5	0.09	2.49	21.06	15	149	42	96	0.10	0.1	6.628	0.092	3	1	1	46
PL.3105	PL.3109	A	#4 ACSR	7.35Y	122.5	0.00	2.49	1.91	1	13	4	96	0.00	0.0	6.657	0.029	2	1	1	4
PL.2799	PL.3105	A	#4 ACSR	7.35Y	122.5	0.00	2.49	0.35	0	2	1	89	0.00	0.0	6.693	0.037	2	1	1	1
PL.3355	PL.3105	A	#4 ACSR	7.35Y	122.5	0.00	2.50	1.24	1	9	2	98	0.00	0.0	6.695	0.039	9	2	2	2
PL.3356	PL.3355	A	#4 ACSR	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	6.759	0.063	0	0	0	0
PL.3241	PL.3109	A	6 A (CWC)	7.35Y	122.4	0.08	2.57	18.75	13	133	37	96	0.08	0.1	6.718	0.091	2	1	1	41
PL.3242	PL.3241	A	6 A (CWC)	7.34Y	122.4	0.04	2.61	18.40	13	130	36	96	0.04	0.0	6.766	0.048	5	1	1	40
PL.2800	PL.3242	A	6 A (CWC)	7.34Y	122.4	0.00	2.61	2.21	2	16	4	97	0.00	0.0	6.820	0.054	16	4	5	5
PL.3104	PL.3242	A	6 A (CWC)	7.34Y	122.3	0.06	2.67	15.50	11	110	31	96	0.04	0.0	6.861	0.095	31	9	3	34
PL.3102	PL.3104	A	#4 ACSR	7.34Y	122.3	0.02	2.69	11.11	9	79	22	96	0.01	0.0	6.910	0.049	3	1	1	31
PL.3100	PL.3102	A	#4 ACSR	7.34Y	122.3	0.04	2.73	10.63	8	75	21	96	0.02	0.0	6.994	0.083	4	1	1	29
PL.3101	PL.3100	A	#4 ACSR	7.34Y	122.3	0.02	2.75	9.41	7	66	19	96	0.01	0.0	7.035	0.041	0	0	0	24
PL.2802	PL.3101	A	#4 ACSR	7.33Y	122.2	0.05	2.79	9.19	7	65	18	96	0.02	0.0	7.148	0.113	0	0	0	23
PL.10180	PL.2802	A	#4 ACSR	7.33Y	122.2	0.03	2.83	9.19	7	65	18	96	0.02	0.0	7.235	0.087	6	2	1	23
PL.10181	PL.10180	A	#4 ACSR	7.33Y	122.2	0.01	2.84	8.32	6	59	16	97	0.00	0.0	7.263	0.028	2	1	1	22
PL.2806	PL.10181	A	#4 ACSR	7.33Y	122.2	0.01	2.85	7.99	6	56	16	96	0.01	0.0	7.298	0.035	0	0	0	21
PL.3098	PL.2806	A	6 A (CWC)	7.33Y	122.1	0.01	2.86	3.44	2	24	7	96	0.00	0.0	7.407	0.109	8	2	4	7
PL.3099	PL.3098	A	6 A (CWC)	7.33Y	122.1	0.00	2.87	1.09	1	8	2	97	0.00	0.0	7.504	0.097	8	2	1	1
PL.2966	PL.3099	A	6 A (CWC)	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	7.635	0.131	0	0	0	0
PL.3392	PL.2966	A	6 A (CWC)	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	7.682	0.047	0	0	0	0
PD.359-A	PL.3392	A	Open	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	7.682	0.047	0	0	0	0
PL.2809	PL.3098	A	#2 ACSR	7.33Y	122.1	0.00	2.86	0.00	0	0	0	100	0.00	0.0	7.465	0.058	0	0	1	1
PL.2808	PL.3098	A	#4 ACSR	7.33Y	122.1	0.00	2.87	1.22	1	9	2	98	0.00	0.0	7.460	0.053	9	2	1	1
PL.2807	PL.2806	A	6 A (CWC)	7.33Y	122.1	0.01	2.86	4.56	3	32	9	96	0.00	0.0	7.347	0.049	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2961	PL.2807	A	6 A (CWC)	7.33Y	122.1	0.02	2.88	4.56	3	32	9	96	0.00	0.0	7.438	0.091	0	0	0	14
PL.2962	PL.2961	A	6 A (CWC)	7.33Y	122.1	0.02	2.89	4.56	3	32	9	96	0.00	0.0	7.511	0.074	0	0	0	14
PL.2963	PL.2962	A	6 A (CWC)	7.32Y	122.1	0.02	2.92	4.56	3	32	9	96	0.01	0.0	7.629	0.117	0	0	0	14
PL.3096	PL.2963	A	6 A (CWC)	7.32Y	122.1	0.01	2.93	3.59	3	25	7	96	0.00	0.0	7.689	0.060	9	3	5	11
PL.2811	PL.3096	A	#4 ACSR	7.32Y	122.1	0.00	2.93	0.97	1	7	2	96	0.00	0.0	7.759	0.070	7	2	1	1
PL.3097	PL.3096	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	1.30	1	9	3	95	0.00	0.0	7.807	0.118	6	2	3	5
PL.3239	PL.3097	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.38	0	3	1	95	0.00	0.0	7.945	0.138	2	1	1	2
PL.3240	PL.3239	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.06	0	0	0	100	0.00	0.0	8.081	0.136	0	0	0	1
PL.2813	PL.3240	A	#1/0 ACSR	7.32Y	122.1	0.00	2.93	0.06	0	0	0	100	0.00	0.0	8.173	0.092	0	0	1	1
PL.10199	PL.3240	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.129	0.048	0	0	0	0
PL.3275	PL.10199	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.230	0.101	0	0	0	0
PL.3276	PL.3275	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.362	0.132	0	0	0	0
PL.2964	PL.3276	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.499	0.137	0	0	0	0
PL.2965	PL.2964	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.553	0.055	0	0	0	0
PL.4477	PL.2965	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	0.00	0	0	0	100	0.00	0.0	8.650	0.096	0	0	0	0
PL.2810	PL.2963	A	#4 ACSR	7.32Y	122.1	0.00	2.92	0.97	1	7	2	96	0.00	0.0	7.681	0.052	7	2	3	3
PL.2833	PL.3101	A	#4 ACSR	7.34Y	122.3	0.00	2.75	0.22	0	2	0	100	0.00	0.0	7.062	0.027	0	0	0	1
PL.2803	PL.2833	A	#4 ACSR	7.34Y	122.3	0.00	2.75	0.22	0	2	0	100	0.00	0.0	7.099	0.037	2	0	1	1
PL.2801	PL.3100	A	#4 ACSR	7.34Y	122.3	0.00	2.73	0.71	1	5	1	98	0.00	0.0	7.148	0.154	0	0	0	4
PL.2804	PL.2801	A	#1/0 ACSR	7.34Y	122.3	0.00	2.73	0.00	0	0	0	100	0.00	0.0	7.246	0.098	0	0	1	1
PL.2832	PL.2801	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.71	1	5	1	98	0.00	0.0	7.202	0.054	0	0	0	3
PL.2805	PL.2832	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	7.221	0.019	0	0	0	0
PL.3244	PL.2832	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.71	1	5	1	98	0.00	0.0	7.316	0.114	1	0	1	3
PL.3245	PL.3244	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.57	0	4	1	97	0.00	0.0	7.344	0.028	4	1	1	2
PL.3243	PL.3245	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	7.394	0.050	0	0	1	1
PL.3246	PL.3243	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	7.452	0.058	0	0	0	0
PL.3247	PL.3246	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	7.572	0.120	0	0	0	0
PL.2895	PL.3247	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	7.645	0.074	0	0	0	0
PL.3103	PL.3102	A	#4 ACSR	7.34Y	122.3	0.00	2.69	0.03	0	0	0	100	0.00	0.0	6.948	0.038	0	0	1	1
PL.2797	PL.3108	A	#4 ACSR	7.36Y	122.6	0.00	2.40	1.27	1	9	3	95	0.00	0.0	6.551	0.016	9	3	2	2
PL.2798	PL.2797	A	#2 ACSR	7.36Y	122.6	0.00	2.40	0.00	0	0	0	100	0.00	0.0	6.589	0.037	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3576	PL.3347	C	#4 ACSR	7.37Y	122.9	0.00	2.14	0.50	0	4	1	97	0.00	0.0	6.274	0.005	0	0	0	1
PD.423	PL.3576	C	40QA	7.37Y	122.9	0.00	2.14	0.50	1	4	1	97	0.00	0.0	6.274	0.005	0	0	0	1
PL.3577	PD.423	C	#4 ACSR	7.37Y	122.9	0.00	2.14	0.50	0	4	1	97	0.00	0.0	6.302	0.028	4	1	1	1
PL.3476	PL.3230	C	#4 ACSR	7.37Y	122.9	0.00	2.11	0.64	0	5	1	98	0.00	0.0	6.110	0.005	0	0	0	2
PD.400	PL.3476	C	40QA	7.37Y	122.9	0.00	2.11	0.64	2	5	1	98	0.00	0.0	6.110	0.005	0	0	0	2
PL.3477	PD.400	C	#4 ACSR	7.37Y	122.9	0.00	2.11	0.64	0	5	1	98	0.00	0.0	6.123	0.014	0	0	1	2
PL.3228	PL.3477	C	#4 ACSR	7.37Y	122.9	0.00	2.11	0.61	0	4	1	97	0.00	0.0	6.168	0.045	4	1	1	1
PL.3478	PL.3117	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	5.623	0.005	0	0	0	1
PD.401	PL.3478	C	40QA	7.38Y	123.0	0.00	1.99	0.32	1	2	1	89	0.00	0.0	5.623	0.005	0	0	0	1
PL.3479	PD.401	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	5.704	0.081	0	0	0	1
PL.3057	PL.3479	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	5.798	0.094	0	0	0	1
PL.2886	PL.3057	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	5.942	0.144	0	0	0	1
PL.2887	PL.2886	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	6.015	0.073	0	0	0	1
PL.25703	PL.2887	C	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	6.084	0.069	0	0	0	1
PD.3629	PL.25703	C	25T	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	6.084	0.069	0	0	0	1
PL.25704	PD.3629	C	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.32	0	2	1	89	0.00	0.0	6.176	0.092	2	1	1	1
PL.3232	PL.25704	C	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.00	0	0	0	100	0.00	0.0	6.202	0.026	0	0	0	0
PL.3472	PL.3222	C	#1/0 ACSR	7.39Y	123.2	0.00	1.79	0.48	0	3	1	95	0.00	0.0	4.865	0.005	0	0	0	2
PD.399	PL.3472	C	40QA	7.39Y	123.2	0.00	1.79	0.48	1	3	1	95	0.00	0.0	4.865	0.005	0	0	0	2
PL.3473	PD.399	C	#1/0 ACSR	7.39Y	123.2	0.00	1.79	0.48	0	3	1	95	0.00	0.0	4.915	0.049	3	1	2	2
PL.4862	PL.3614	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.43	1	10	3	96	0.00	0.0	3.832	0.003	0	0	0	4
PD.893	PL.4862	C	50QA	7.42Y	123.7	0.00	1.33	1.43	3	10	3	96	0.00	0.0	3.832	0.003	0	0	0	4
PL.4863	PD.893	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.43	1	10	3	96	0.00	0.0	3.933	0.101	10	3	4	4
PL.2828	PL.3614	B	#4 ACSR	7.42Y	123.7	0.00	1.32	0.25	0	2	1	89	0.00	0.0	3.861	0.033	2	1	1	1
CP.7	PL.3613	ABC	Cap (297)	7.43Y	123.8	0.00	1.24	0.00	0	0	0	100	0.00	0.0	3.778	0.033	0	0	0	0
PL.3414	PL.2670	A	#4 ACSR	7.36Y	122.7	0.00	2.31	0.00	0	0	0	100	0.00	0.0	2.998	0.005	0	0	0	0
PD.370	PL.3414	A	40QA	7.36Y	122.7	0.00	2.31	0.00	0	0	0	100	0.00	0.0	2.998	0.005	0	0	0	0
PL.3415	PD.370	A	#4 ACSR	7.36Y	122.7	0.00	2.31	0.00	0	0	0	100	0.00	0.0	3.073	0.074	0	0	0	0
PL.3400	PL.3050	C	#4 ACSR	7.41Y	123.6	0.00	1.43	0.73	1	5	1	98	0.00	0.0	1.864	0.005	0	0	0	1
PD.364	PL.3400	C	40QA	7.41Y	123.6	0.00	1.43	0.73	2	5	1	98	0.00	0.0	1.864	0.005	0	0	0	1
PL.3401	PD.364	C	#4 ACSR	7.41Y	123.6	0.00	1.44	0.73	1	5	1	98	0.00	0.0	1.897	0.033	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3566	PL.2595	C	#4 ACSR	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.587	0.005	0	0	0	0
PD.418	PL.3566	C	40QA	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.587	0.005	0	0	0	0
PL.3567	PD.418	C	#4 ACSR	7.42Y	123.7	0.00	1.26	0.00	0	0	0	100	0.00	0.0	1.683	0.096	0	0	0	0
PL.3406	PL.2595	C	#4 ACSR	7.42Y	123.7	0.00	1.26	0.87	1	6	2	95	0.00	0.0	1.587	0.005	0	0	0	1
PD.367	PL.3406	C	40QA	7.42Y	123.7	0.00	1.26	0.87	2	6	2	95	0.00	0.0	1.587	0.005	0	0	0	1
PL.3407	PD.367	C	#4 ACSR	7.42Y	123.7	0.00	1.26	0.87	1	6	2	95	0.00	0.0	1.660	0.073	6	2	1	1
PL.3398	PL.3091	A	#2 ACSR	7.44Y	123.9	0.00	1.06	7.39	4	53	15	96	0.00	0.0	1.301	0.005	0	0	0	10
PD.363	PL.3398	A	20T	7.44Y	123.9	0.00	1.06	7.39	0	53	15	96	0.00	0.0	1.301	0.005	0	0	0	10
PL.3399	PD.363	A	#2 ACSR	7.44Y	123.9	0.00	1.07	7.39	4	53	15	96	0.00	0.0	1.320	0.019	14	4	3	10
PL.2584	PL.3399	A	#2 ACSR	7.44Y	123.9	0.01	1.07	5.41	3	39	11	96	0.00	0.0	1.383	0.064	17	5	2	7
PL.2586	PL.2584	A	#2 ACSR	7.44Y	123.9	0.00	1.08	3.07	2	22	6	96	0.00	0.0	1.430	0.047	0	0	0	5
PL.2587	PL.2586	A	#2 ACSR	7.44Y	123.9	0.00	1.08	2.31	1	17	5	96	0.00	0.0	1.462	0.032	17	5	4	4
PL.2588	PL.2586	A	#4 ACSR	7.44Y	123.9	0.00	1.08	0.76	1	5	2	93	0.00	0.0	1.526	0.096	0	0	0	1
PL.2590	PL.2588	A	#4 ACSR	7.43Y	123.9	0.00	1.08	0.76	1	5	2	93	0.00	0.0	1.551	0.024	0	0	0	1
PL.2591	PL.2590	A	#4 ACSR	7.43Y	123.9	0.00	1.08	0.76	1	5	2	93	0.00	0.0	1.592	0.041	5	2	1	1
PL.2593	PL.2591	A	#2 ACSR	7.43Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	1.744	0.152	0	0	0	0
PL.2582	PL.2865	ABC	336 MCM AC	7.45Y	124.1	0.00	0.91	15.89	3	342	96	96	0.01	0.0	1.114	0.031	11	3	1	89
PL.2691	PL.2582	ABC	#4/0 ACSR	7.44Y	124.1	0.01	0.93	15.39	5	331	93	96	0.02	0.0	1.180	0.066	0	0	0	88
PL.3603	PL.2691	ABC	336 MCM AC	7.44Y	124.1	0.01	0.93	15.39	3	331	93	96	0.01	0.0	1.226	0.046	0	0	0	88
PD.436	PL.3603	ABC	70L	7.44Y	124.1	0.00	0.93	15.39	22	331	93	96	0.00	0.0	1.226	0.046	0	0	0	88
PL.3604	PD.436	ABC	336 MCM AC	7.44Y	124.1	0.01	0.94	15.39	3	331	93	96	0.01	0.0	1.285	0.059	0	0	0	88
PL.3202	PL.3604	ABC	336 MCM AC	7.44Y	124.0	0.01	0.95	14.83	3	319	90	96	0.02	0.0	1.401	0.117	10	3	3	85
PL.3203	PL.3202	ABC	336 MCM AC	7.44Y	124.0	0.00	0.95	14.36	3	309	87	96	0.01	0.0	1.443	0.042	2	1	2	82
PL.3201	PL.3203	ABC	336 MCM AC	7.44Y	124.0	0.01	0.97	14.28	3	307	86	96	0.02	0.0	1.571	0.128	0	0	0	80
PL.3086	PL.3201	ABC	336 MCM AC	7.44Y	124.0	0.01	0.98	14.28	3	307	86	96	0.01	0.0	1.656	0.085	4	1	1	80
PL.3088	PL.3086	ABC	336 MCM AC	7.44Y	124.0	0.01	0.99	14.00	3	301	84	96	0.02	0.0	1.759	0.103	0	0	0	78
PL.2692	PL.3088	B	#2 ACSR	7.44Y	124.0	0.01	0.99	1.57	1	11	3	96	0.00	0.0	1.861	0.102	0	0	0	2
PL.2693	PL.2692	B	#1/0 ACSR	7.44Y	124.0	0.00	0.99	1.57	1	11	3	96	0.00	0.0	1.865	0.005	0	0	0	2
PD.394	PL.2693	B	40QA	7.44Y	124.0	0.00	0.99	1.57	4	11	3	96	0.00	0.0	1.865	0.005	0	0	0	2
PL.3089	PD.394	B	#2 ACSR	7.44Y	124.0	0.00	0.99	1.01	1	7	2	96	0.00	0.0	1.871	0.006	0	0	0	1
PL.2700	PL.3089	B	#2 ACSR	7.44Y	124.0	0.00	0.99	1.01	1	7	2	96	0.00	0.0	1.892	0.021	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2818	PD.394	B	#1/0 ACSR	7.44Y	124.0	0.00	0.99	0.57	0	4	1	97	0.00	0.0	1.945	0.080	4	1	1	1
PL.2817	PL.3088	ABC	336 MCM AC	7.44Y	124.0	0.01	0.99	13.47	3	289	81	96	0.01	0.0	1.824	0.065	0	0	0	76
PL.3460	PL.2817	A	#4 ACSR	7.44Y	124.0	0.00	0.99	0.00	0	0	0	100	0.00	0.0	1.828	0.004	0	0	0	0
PD.392	PL.3460	A	40QA	7.44Y	124.0	0.00	0.99	0.00	0	0	0	100	0.00	0.0	1.828	0.004	0	0	0	0
PL.3461	PD.392	A	#4 ACSR	7.44Y	124.0	0.00	0.99	0.00	0	0	0	100	0.00	0.0	1.842	0.014	0	0	0	0
PL.2819	PL.2817	ABC	336 MCM AC	7.44Y	124.0	0.01	1.01	13.47	3	289	81	96	0.02	0.0	1.932	0.109	0	0	0	76
PL.2820	PL.2819	ABC	336 MCM AC	7.44Y	124.0	0.01	1.02	13.44	3	289	81	96	0.02	0.0	2.056	0.124	0	0	0	75
PL.2867	PL.2820	ABC	336 MCM AC	7.44Y	124.0	0.01	1.03	13.44	3	289	81	96	0.02	0.0	2.158	0.102	0	0	0	75
PL.2868	PL.2867	ABC	336 MCM AC	7.44Y	124.0	0.01	1.04	13.44	3	289	81	96	0.02	0.0	2.288	0.130	0	0	0	75
PL.3595	PL.2868	A	#4 ACSR	7.44Y	124.0	0.00	1.04	25.71	20	184	52	96	0.00	0.0	2.291	0.003	0	0	0	55
PD.432	PL.3595	A	50H	7.44Y	124.0	0.00	1.04	25.71	51	184	52	96	0.00	0.0	2.291	0.003	0	0	0	55
PL.3596	PD.432	A	#4 ACSR	7.43Y	123.9	0.04	1.08	25.71	20	184	52	96	0.06	0.0	2.327	0.036	9	2	2	55
PL.2694	PL.3596	A	#2 ACSR	7.43Y	123.9	0.04	1.12	24.51	14	175	49	96	0.05	0.0	2.377	0.050	0	0	1	53
PL.3080	PL.2694	A	#2 ACSR	7.43Y	123.8	0.06	1.19	24.45	14	175	49	96	0.08	0.0	2.460	0.083	0	0	1	52
PL.3258	PL.3080	A	#2 ACSR	7.43Y	123.8	0.00	1.19	1.59	1	11	3	96	0.00	0.0	2.486	0.027	10	3	1	2
PL.3259	PL.3258	A	#2 ACSR	7.43Y	123.8	0.00	1.19	0.17	0	1	0	100	0.00	0.0	2.506	0.020	1	0	1	1
PL.3081	PL.3080	A	#2 ACSR	7.43Y	123.8	0.05	1.24	22.86	13	164	46	96	0.06	0.0	2.532	0.073	14	4	2	49
PL.3256	PL.3081	A	#2 ACSR	7.43Y	123.8	0.00	1.24	2.44	1	17	5	96	0.00	0.0	2.569	0.037	13	4	3	4
PL.3257	PL.3256	A	#2 ACSR	7.43Y	123.8	0.00	1.24	0.62	0	4	1	97	0.00	0.0	2.665	0.096	4	1	1	1
PL.25726	PL.3081	A	#1/0 ACSR	7.42Y	123.7	0.02	1.25	18.48	8	132	37	96	0.01	0.0	2.569	0.037	0	0	0	43
PL.25727	PL.25726	A	#1/0 ACSR	7.42Y	123.7	0.03	1.28	17.92	8	128	36	96	0.02	0.0	2.632	0.062	0	0	0	42
PL.3083	PL.25727	A	#2 ACSR	7.42Y	123.7	0.05	1.33	17.92	10	128	36	96	0.04	0.0	2.715	0.083	4	1	1	42
PL.2702	PL.3083	A	#2 ACSR	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	2.771	0.056	0	0	0	0
PL.33104	PL.3083	A	#2 ACSR	7.42Y	123.6	0.04	1.37	17.41	10	124	35	96	0.04	0.0	2.793	0.078	0	0	0	41
PL.33105	PL.33104	A	#2 ACSR	7.42Y	123.6	0.02	1.39	17.41	10	124	35	96	0.02	0.0	2.826	0.033	0	0	2	41
PL.3255	PL.33105	A	#2 ACSR	7.41Y	123.6	0.04	1.43	17.39	10	124	35	96	0.04	0.0	2.906	0.080	0	0	0	39
PL.3260	PL.3255	A	#2 ACSR	7.41Y	123.5	0.07	1.50	15.67	9	112	31	96	0.05	0.0	3.044	0.139	7	2	1	33
PL.3261	PL.3260	A	#2 ACSR	7.41Y	123.5	0.04	1.54	14.66	8	105	29	96	0.03	0.0	3.128	0.084	0	0	0	32
PL.2821	PL.3261	A	#2 ACSR	7.40Y	123.4	0.06	1.59	13.84	8	99	28	96	0.04	0.0	3.258	0.130	0	0	0	31
PL.3084	PL.2821	A	#2 ACSR	7.40Y	123.4	0.03	1.62	13.84	8	99	28	96	0.02	0.0	3.325	0.067	6	2	3	31
PL.2705	PL.3084	A	#2 ACSR	7.40Y	123.4	0.00	1.62	0.00	0	0	0	100	0.00	0.0	3.368	0.043	0	0	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3085	PL.3084	A	#2 ACSR	7.40Y	123.4	0.02	1.64	13.00	7	93	26	96	0.01	0.0	3.385	0.060	16	4	3	26
PL.2708	PL.3085	A	6 A (CWC)	7.40Y	123.3	0.05	1.69	10.74	8	77	21	96	0.03	0.0	3.485	0.101	0	0	0	23
PL.2706	PL.2708	A	6 A (CWC)	7.40Y	123.3	0.00	1.69	0.09	0	1	0	100	0.00	0.0	3.514	0.029	1	0	1	1
PL.2822	PL.2708	A	6 A (CWC)	7.39Y	123.2	0.08	1.77	10.66	8	76	21	96	0.04	0.1	3.655	0.169	7	2	2	22
PL.3268	PL.2822	A	6 A (CWC)	7.39Y	123.2	0.00	1.77	3.17	2	23	6	97	0.00	0.0	3.695	0.040	23	6	4	5
PL.3269	PL.3268	A	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.00	0	0	0	100	0.00	0.0	3.867	0.172	0	0	1	1
PL.3267	PL.2822	A	6 A (CWC)	7.39Y	123.2	0.03	1.80	6.49	5	46	13	96	0.01	0.0	3.744	0.089	1	0	1	15
PL.3270	PL.3267	A	6 A (CWC)	7.39Y	123.2	0.01	1.81	6.35	5	45	13	96	0.00	0.0	3.797	0.053	7	2	1	14
PL.3271	PL.3270	A	6 A (CWC)	7.39Y	123.2	0.01	1.82	5.35	4	38	11	96	0.00	0.0	3.849	0.053	10	3	3	13
PL.3266	PL.3271	A	6 A (CWC)	7.39Y	123.2	0.02	1.84	3.92	3	28	8	96	0.00	0.0	3.939	0.090	2	1	1	10
PL.3265	PL.3266	A	6 A (CWC)	7.39Y	123.2	0.01	1.84	3.66	3	26	7	97	0.00	0.0	3.978	0.039	0	0	1	9
PL.3262	PL.3265	A	6 A (CWC)	7.39Y	123.1	0.01	1.85	3.66	3	26	7	97	0.00	0.0	4.025	0.047	10	3	2	8
PL.3263	PL.3262	A	6 A (CWC)	7.39Y	123.1	0.00	1.85	2.22	2	16	4	97	0.00	0.0	4.055	0.030	1	0	2	6
PL.3264	PL.3263	A	6 A (CWC)	7.39Y	123.1	0.01	1.86	2.05	1	15	4	97	0.00	0.0	4.156	0.101	0	0	0	4
PL.2870	PL.3264	A	6 A (CWC)	7.39Y	123.1	0.01	1.88	2.05	1	15	4	97	0.00	0.0	4.288	0.132	0	0	0	4
PL.3272	PL.2870	A	6 A (CWC)	7.39Y	123.1	0.01	1.88	2.05	1	15	4	97	0.00	0.0	4.380	0.092	9	3	3	4
PL.3273	PL.3272	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.72	1	5	1	98	0.00	0.0	4.435	0.055	5	1	1	1
PL.4476	PL.3273	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	4.443	0.008	0	0	0	0
PL.2704	PL.3261	A	#4 ACSR	7.41Y	123.5	0.00	1.54	0.82	1	6	2	95	0.00	0.0	3.208	0.080	6	2	1	1
PL.10200	PL.3255	A	#2 ACSR	7.41Y	123.6	0.00	1.43	1.72	1	12	3	97	0.00	0.0	2.959	0.054	0	0	0	6
PL.3251	PL.10200	A	#2 ACSR	7.41Y	123.6	0.00	1.44	1.72	1	12	3	97	0.00	0.0	3.034	0.075	2	1	1	6
PL.3252	PL.3251	A	#2 ACSR	7.41Y	123.6	0.00	1.44	1.37	1	10	3	96	0.00	0.0	3.170	0.136	5	1	1	5
PL.3253	PL.3252	A	#2 ACSR	7.41Y	123.6	0.00	1.44	0.74	0	5	1	98	0.00	0.0	3.275	0.105	0	0	0	4
PL.3250	PL.3253	A	#2 ACSR	7.41Y	123.6	0.00	1.44	0.74	0	5	1	98	0.00	0.0	3.364	0.089	4	1	2	4
PL.3248	PL.3250	A	#4 ACSR	7.41Y	123.6	0.00	1.44	0.14	0	1	0	100	0.00	0.0	3.395	0.031	1	0	2	2
PL.3249	PL.3248	A	#4 ACSR	7.41Y	123.6	0.00	1.44	0.00	0	0	0	100	0.00	0.0	3.433	0.038	0	0	0	0
PL.25725	PL.25726	A	#1/0 ACSR	7.42Y	123.7	0.00	1.25	0.56	0	4	1	97	0.00	0.0	2.601	0.032	4	1	1	1
PL.3568	PL.2868	C	#2 ACSR	7.44Y	124.0	0.00	1.04	14.61	8	105	29	96	0.00	0.0	2.293	0.005	0	0	0	20
PD.419	PL.3568	C	20T	7.44Y	124.0	0.00	1.04	14.61	0	105	29	96	0.00	0.0	2.293	0.005	0	0	0	20
PL.3569	PD.419	C	#2 ACSR	7.44Y	123.9	0.01	1.05	14.61	8	105	29	96	0.01	0.0	2.316	0.023	8	2	1	20
PL.2707	PL.3569	C	#4 ACSR	7.44Y	123.9	0.02	1.07	13.43	10	96	27	96	0.01	0.0	2.350	0.034	5	1	1	19

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3205	PL.2707	C	#4 ACSR	7.43Y	123.9	0.02	1.09	12.72	10	91	25	96	0.01	0.0	2.383	0.033	0	0	0	18
PL.3208	PL.3205	C	#4 ACSR	7.43Y	123.9	0.02	1.11	10.61	8	76	21	96	0.01	0.0	2.428	0.045	5	2	1	16
PL.3209	PL.3208	C	#4 ACSR	7.43Y	123.9	0.01	1.13	9.85	8	71	20	96	0.01	0.0	2.458	0.030	0	0	0	15
PL.3206	PL.3209	C	#4 ACSR	7.43Y	123.9	0.00	1.13	0.75	1	5	2	93	0.00	0.0	2.482	0.024	0	0	1	2
PL.3207	PL.3206	C	#4 ACSR	7.43Y	123.9	0.00	1.13	0.75	1	5	2	93	0.00	0.0	2.548	0.066	5	2	1	1
PL.3388	PL.3209	C	#4 ACSR	7.43Y	123.9	0.01	1.14	9.10	7	65	18	96	0.01	0.0	2.500	0.042	21	6	3	13
PL.3389	PL.3388	C	#4 ACSR	7.43Y	123.8	0.01	1.15	6.10	5	44	12	96	0.00	0.0	2.544	0.044	5	2	2	10
PL.3204	PL.3389	C	#4 ACSR	7.43Y	123.8	0.01	1.16	5.34	4	38	11	96	0.00	0.0	2.603	0.059	13	4	4	8
PL.3211	PL.3204	C	#4 ACSR	7.43Y	123.8	0.01	1.18	3.58	3	26	7	97	0.00	0.0	2.708	0.105	14	4	2	4
PL.3212	PL.3211	C	#4 ACSR	7.43Y	123.8	0.00	1.18	1.55	1	11	3	96	0.00	0.0	2.732	0.024	5	1	1	2
PL.3210	PL.3212	C	#4 ACSR	7.43Y	123.8	0.00	1.18	0.86	1	6	2	95	0.00	0.0	2.779	0.047	6	2	1	1
PL.10179	PL.3205	C	#1/0 ACSR	7.43Y	123.9	0.00	1.09	2.11	1	15	4	97	0.00	0.0	2.416	0.033	15	4	2	2
PL.3466	PL.2819	C	#2 ACSR	7.44Y	124.0	0.00	1.01	0.10	0	1	0	100	0.00	0.0	1.937	0.005	0	0	0	1
PD.396	PL.3466	C	40QA	7.44Y	124.0	0.00	1.01	0.10	0	1	0	100	0.00	0.0	1.937	0.005	0	0	0	1
PL.3467	PD.396	C	#2 ACSR	7.44Y	124.0	0.00	1.01	0.10	0	1	0	100	0.00	0.0	1.963	0.026	1	0	1	1
PL.3462	PL.3086	C	#4 ACSR	7.44Y	124.0	0.00	0.98	0.29	0	2	1	89	0.00	0.0	1.661	0.005	0	0	0	1
PD.393	PL.3462	C	40QA	7.44Y	124.0	0.00	0.98	0.29	1	2	1	89	0.00	0.0	1.661	0.005	0	0	0	1
PL.3463	PD.393	C	#4 ACSR	7.44Y	124.0	0.00	0.98	0.29	0	2	1	89	0.00	0.0	1.736	0.075	2	1	1	1
PL.3464	PL.3604	C	#2 ACSR	7.44Y	124.1	0.00	0.94	1.70	1	12	3	97	0.00	0.0	1.289	0.005	0	0	0	3
PD.395	PL.3464	C	40QA	7.44Y	124.1	0.00	0.94	1.70	4	12	3	97	0.00	0.0	1.289	0.005	0	0	0	3
PL.3465	PD.395	C	#2 ACSR	7.44Y	124.1	0.00	0.94	1.70	1	12	3	97	0.00	0.0	1.309	0.020	12	3	3	3
PL.3562	PL.2581	A	#2 ACSR	7.47Y	124.4	0.00	0.56	1.24	1	9	2	98	0.00	0.0	0.661	0.005	0	0	0	1
PD.416	PL.3562	A	40QA	7.47Y	124.4	0.00	0.56	1.24	3	9	2	98	0.00	0.0	0.661	0.005	0	0	0	1
PL.3563	PD.416	A	#2 ACSR	7.47Y	124.4	0.00	0.56	1.24	1	9	2	98	0.00	0.0	0.680	0.019	9	2	1	1
PL.3422	PL.2581	C	#2 ACSR	7.47Y	124.4	0.00	0.56	0.96	1	7	2	96	0.00	0.0	0.661	0.005	0	0	0	2
PD.374	PL.3422	C	40QA	7.47Y	124.4	0.00	0.56	0.96	2	7	2	96	0.00	0.0	0.661	0.005	0	0	0	2
PL.3423	PD.374	C	#2 ACSR	7.47Y	124.4	0.00	0.56	0.96	1	7	2	96	0.00	0.0	0.679	0.018	7	2	2	2
PL.2576	PL.2863	C	#2 ACSR	7.48Y	124.6	0.00	0.36	4.00	2	29	8	96	0.00	0.0	0.440	0.020	0	0	0	4
PL.3418	PL.2576	C	#2 ACSR	7.48Y	124.6	0.00	0.36	4.00	2	29	8	96	0.00	0.0	0.444	0.005	0	0	0	4
PD.372	PL.3418	C	40QA	7.48Y	124.6	0.00	0.36	4.00	10	29	8	96	0.00	0.0	0.444	0.005	0	0	0	4
PL.3419	PD.372	C	#2 ACSR	7.48Y	124.6	0.00	0.36	4.00	2	29	8	96	0.00	0.0	0.459	0.015	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2578	PL.3419	C	#4 ACSR	7.48Y	124.6	0.00	0.37	3.11	2	22	6	96	0.00	0.0	0.478	0.019	22	6	3	3
PL.2577	PL.3419	C	#2 ACSR	7.48Y	124.6	0.00	0.37	0.88	1	6	2	95	0.00	0.0	0.495	0.036	6	2	1	1
PL.1257	Goose Rock	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.007	0.007	0	0	0	4
PL.7163	PL.1257	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.009	0.002	0	0	0	4
----- Feeder No. 5 (Clay Ind Park F5) Beginning with Device PD.1530 -----																				
PD.1530	PL.7163	ABC	480VWE	7.50Y	125.0	0.00	0.00	2.71	0	60	10	99	0.00	0.0	0.009	0.002	0	0	0	4
PL.7164	PD.1530	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.020	0.011	0	0	0	4
PL.1299	PL.7164	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.281	0.261	0	0	0	4
PL.1290	PL.1299	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.473	0.192	0	0	0	4
PL.1291	PL.1290	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.640	0.167	0	0	0	4
PL.1231	PL.1291	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.71	1	60	10	99	0.00	0.0	0.834	0.194	0	0	0	4
PL.1230	PL.1231	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.71	1	60	10	99	0.00	0.0	1.491	0.657	0	0	0	4
PL.1343	PL.1230	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.71	1	60	10	99	0.00	0.0	1.858	0.367	0	0	0	4
PL.1344	PL.1343	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.71	1	60	10	99	0.00	0.0	2.048	0.189	0	0	0	4
PL.1229	PL.1344	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.71	1	60	10	99	0.00	0.0	2.369	0.321	0	0	0	4
PL.1245	PL.1229	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	2.28	0	51	8	99	0.00	0.0	2.577	0.208	0	0	0	3
PL.1240	PL.1245	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	2.28	0	51	8	99	0.00	0.0	2.756	0.179	0	0	0	3
PL.1227	PL.1240	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	1.58	0	35	3	100	0.00	0.0	2.802	0.046	0	0	0	2
PL.1347	PL.1227	ABC	350 MCM AL	7.50Y	125.0	0.00	0.02	1.58	0	35	3	100	0.00	0.0	2.805	0.003	0	0	0	2
PD.185-A	PL.1347	ABC	Closed	7.50Y	125.0	0.00	0.02	1.59	0	35	3	100	0.00	0.0	2.805	0.003	0	0	0	2
PD.185-B	PD.185-A	ABC	Closed	7.50Y	125.0	0.00	0.02	1.59	0	35	3	100	0.00	0.0	2.805	0.003	0	0	0	2
PL.1348	PD.185-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.02	1.59	0	35	3	100	0.00	0.0	3.330	0.524	0	0	0	2
PD.154-A	PL.1348	ABC	Closed	7.50Y	125.0	0.00	0.02	1.67	0	35	12	95	0.00	0.0	3.330	0.524	0	0	0	2
PD.154-B	PD.154-A	ABC	Closed	7.50Y	125.0	0.00	0.02	1.67	0	35	12	95	0.00	0.0	3.330	0.524	0	0	0	2
PL.1225	PD.154-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.03	1.58	0	33	12	94	0.00	0.0	3.481	0.152	0	0	0	1
PD.153-A	PL.1225	ABC	Closed	7.50Y	125.0	0.00	0.03	1.62	0	33	14	92	0.00	0.0	3.481	0.152	0	0	0	1
PD.153-B	PD.153-A	ABC	Closed	7.50Y	125.0	0.00	0.03	1.62	0	33	14	92	0.00	0.0	3.481	0.152	0	0	0	1
PL.1247	PD.153-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.03	1.62	1	33	14	92	0.00	0.0	3.565	0.084	0	0	0	1
PL.1248	PL.1247	ABC	350 MCM AL	7.50Y	125.0	0.00	0.03	1.64	1	33	16	90	0.00	0.0	3.586	0.021	33	16	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

12/17/2009 13:32 Page 98

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.1226	PD.154-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.02	0.10	0	2	1	89	0.00	0.0	3.353	0.023	2	1	1	1
PL.1345	PL.1240	ABC	#2 ACSR	7.50Y	125.0	0.00	0.02	0.71	0	15	4	97	0.00	0.0	2.816	0.060	0	0	0	1
PD.184	PL.1345	ABC	100QA	7.50Y	125.0	0.00	0.02	0.71	1	15	4	97	0.00	0.0	2.816	0.060	0	0	0	1
PL.1346	PD.184	ABC	#2 ACSR	7.50Y	125.0	0.00	0.02	0.71	0	15	4	97	0.00	0.0	2.839	0.022	15	4	1	1
PL.63	PL.1229	B	8 A (CWC)	7.50Y	125.0	0.00	0.02	1.28	1	9	3	95	0.00	0.0	2.406	0.037	9	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	10647	0	0	0	0	0	288		0.00	10935	Lowest Voltage =	116.88	on Element PL.2227
KVAR	3073	0	0	-18	0	0	541			3596	Max Accm VoltD =	8.12	on Element PL.2227
											Max Elem VoltD =	0.40	on Element PL.1393