

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
Greenbriar		ABC	SRC-Greenb	7.50Y	125.0	0.00	0.00	487.00	0	10406	3433	95	0.00	0.0	0.000	0.000	0	0	0	1628
PL.4927	Greenbriar	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	13.57	3	290	94	95	0.00	0.0	0.008	0.008	0	0	0	32
PL.7530	PL.4927	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	13.57	3	290	94	95	0.00	0.0	0.010	0.002	0	0	0	32
----- Feeder No. 4 (Fox Hollow F4) Beginning with Device PD.1909 -----																				
PD.1909	PL.7530	ABC	480VWE	7.50Y	125.0	0.00	0.00	13.57	0	290	94	95	0.00	0.0	0.010	0.002	0	0	0	32
PL.7531	PD.1909	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	13.57	3	290	94	95	0.01	0.0	0.095	0.086	0	0	1	32
PL.4908	PL.7531	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	13.55	3	290	94	95	0.00	0.0	0.103	0.007	0	0	0	31
PL.4897	PL.4908	ABC	336 MCM AC	7.50Y	125.0	0.01	0.02	13.55	3	290	94	95	0.02	0.0	0.214	0.111	0	0	0	31
PL.4896	PL.4897	ABC	336 MCM AC	7.50Y	125.0	0.01	0.04	13.55	3	290	94	95	0.02	0.0	0.333	0.119	0	0	0	31
PL.4882	PL.4896	A	#4 ACSR	7.50Y	125.0	0.00	0.04	0.63	0	5	1	98	0.00	0.0	0.465	0.132	5	1	1	1
PL.4911	PL.4896	ABC	336 MCM AC	7.50Y	125.0	0.00	0.04	13.34	3	285	93	95	0.01	0.0	0.370	0.037	7	1	1	30
PL.4912	PL.4911	ABC	336 MCM AC	7.50Y	125.0	0.01	0.04	13.03	3	278	92	95	0.01	0.0	0.424	0.054	0	0	0	29
PL.4890	PL.4912	ABC	336 MCM AC	7.50Y	124.9	0.01	0.05	12.75	2	272	90	95	0.01	0.0	0.496	0.073	0	0	0	27
PL.4482	PL.4890	C	#2 ACSR	7.50Y	124.9	0.00	0.05	9.40	5	69	14	98	0.00	0.0	0.500	0.003	0	0	0	15
PD.912	PL.4482	C	65T	7.50Y	124.9	0.00	0.05	9.40	0	69	14	98	0.00	0.0	0.500	0.003	0	0	0	15
PL.4483	PD.912	C	#2 ACSR	7.50Y	124.9	0.02	0.07	9.40	5	69	14	98	0.01	0.0	0.558	0.058	3	1	2	15
PL.4910	PL.4483	C	#2 ACSR	7.50Y	124.9	0.01	0.08	8.95	5	66	13	98	0.00	0.0	0.595	0.037	4	1	2	13
PL.4909	PL.4910	C	#2 ACSR	7.49Y	124.9	0.02	0.10	8.44	5	62	13	98	0.01	0.0	0.675	0.080	5	1	2	11
PL.4884	PL.4909	C	#4 ACSR	7.49Y	124.9	0.00	0.10	3.00	2	22	5	98	0.00	0.0	0.712	0.036	0	0	0	4
PL.4885	PL.4884	C	#4 ACSR	7.49Y	124.9	0.00	0.10	0.00	0	0	0	100	0.00	0.0	0.724	0.012	0	0	0	0
PL.4891	PL.4884	C	#4 ACSR	7.49Y	124.9	0.00	0.10	3.00	2	22	5	98	0.00	0.0	0.722	0.011	22	5	4	4
PL.4883	PL.4909	C	#2 ACSR	7.49Y	124.9	0.00	0.10	4.73	3	35	7	98	0.00	0.0	0.697	0.022	0	0	0	5
PL.4484	PL.4883	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	3.08	2	23	4	99	0.00	0.0	0.700	0.004	0	0	0	4
PD.913	PL.4484	C	65T	7.49Y	124.9	0.00	0.10	3.08	0	23	4	99	0.00	0.0	0.700	0.004	0	0	0	4
PL.4485	PD.913	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	3.08	2	23	4	99	0.00	0.0	0.713	0.013	12	3	2	4
P PL.4889	PL.4485	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	-0.02	0	0	0	100	0.00	0.0	0.743	0.030	0	0	0	0 P
PL.4892	PL.4485	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	1.38	1	10	2	98	0.00	0.0	0.742	0.028	10	2	2	2
PL.4486	PL.4883	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	1.65	1	12	2	99	0.00	0.0	0.700	0.003	0	0	0	1
PD.914	PL.4486	C	65T	7.49Y	124.9	0.00	0.10	1.65	0	12	2	99	0.00	0.0	0.700	0.003	0	0	0	1
PL.4487	PD.914	C	1/0 AL URD	7.49Y	124.9	0.00	0.10	1.65	1	12	2	99	0.00	0.0	0.739	0.039	12	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4901	PL.4890	ABC	336 MCM AC	7.50Y	124.9	0.01	0.06	9.65	2	203	76	94	0.01	0.0	0.618	0.121	0	0	0	12
PL.4902	PL.4901	ABC	336 MCM AC	7.50Y	124.9	0.01	0.07	9.59	2	202	76	94	0.01	0.0	0.705	0.088	0	0	0	11
PL.4893	PL.4902	ABC	336 MCM AC	7.50Y	124.9	0.00	0.07	3.66	1	81	17	98	0.00	0.0	0.866	0.161	0	0	0	9
PL.4895	PL.4893	ABC	336 MCM AC	7.50Y	124.9	0.00	0.07	2.07	0	46	10	98	0.00	0.0	0.894	0.027	0	0	0	8
PL.4906	PL.4895	B	#4 ACSR	7.49Y	124.9	0.04	0.11	6.22	5	46	10	98	0.01	0.0	1.036	0.143	4	1	2	8
PL.4907	PL.4906	B	#4 ACSR	7.49Y	124.9	0.01	0.12	5.67	4	42	9	98	0.00	0.0	1.071	0.035	0	0	0	6
PL.4904	PL.4907	B	#4 ACSR	7.49Y	124.9	0.00	0.12	3.61	3	26	6	97	0.00	0.0	1.110	0.039	12	3	1	4
PL.4905	PL.4904	B	#4 ACSR	7.49Y	124.9	0.00	0.13	1.98	2	15	3	98	0.00	0.0	1.151	0.041	6	1	1	3
PL.4903	PL.4905	B	#4 ACSR	7.49Y	124.9	0.00	0.13	1.10	1	8	2	97	0.00	0.0	1.181	0.030	8	2	2	2
PL.4888	PL.4907	B	#2 ACSR	7.49Y	124.9	0.00	0.12	2.05	1	15	3	98	0.00	0.0	1.104	0.033	15	3	2	2
PL.4913	PL.4893	C	#4 ACSR	7.50Y	124.9	0.00	0.08	4.75	4	35	7	98	0.00	0.0	0.890	0.024	0	0	0	1
PL.4490	PL.4913	C	#4 ACSR	7.50Y	124.9	0.00	0.08	4.75	4	35	7	98	0.00	0.0	0.893	0.004	0	0	0	1
PD.916	PL.4490	C	65T	7.50Y	124.9	0.00	0.08	4.75	0	35	7	98	0.00	0.0	0.893	0.004	0	0	0	1
PL.4491	PD.916	C	#4 ACSR	7.49Y	124.9	0.02	0.10	4.75	4	35	7	98	0.00	0.0	0.984	0.090	0	0	0	1
PL.4898	PL.4491	C	#4 ACSR	7.49Y	124.9	0.02	0.12	4.75	4	35	7	98	0.00	0.0	1.073	0.090	0	0	0	1
PL.4899	PL.4898	C	#4 ACSR	7.49Y	124.9	0.01	0.13	4.75	4	35	7	98	0.00	0.0	1.179	0.106	35	7	1	1
PL.4887	PL.4902	ABC	#4/0 ACSR	7.50Y	124.9	0.01	0.08	5.99	2	121	59	90	0.01	0.0	0.823	0.118	0	0	0	2
PL.4488	PL.4887	C	#2 ACSR	7.50Y	124.9	0.00	0.08	0.01	0	0	0	100	0.00	0.0	0.826	0.004	0	0	0	1
PD.915	PL.4488	C	65T	7.50Y	124.9	0.00	0.08	0.01	0	0	0	100	0.00	0.0	0.826	0.004	0	0	0	1
PL.4489	PD.915	C	#2 ACSR	7.50Y	124.9	0.00	0.08	0.01	0	0	0	100	0.00	0.0	0.958	0.132	0	0	1	1
PL.4894	PL.4887	ABC	#4/0 ACSR	7.50Y	124.9	0.00	0.08	5.99	2	121	59	90	0.00	0.0	0.893	0.071	121	59	1	1
PL.4886	PL.4901	ABC	#2 ACSR	7.50Y	124.9	0.00	0.06	0.06	0	1	1	71	0.00	0.0	0.635	0.017	1	1	1	1
PL.4480	PL.4912	ABC	#2 ACSR	7.50Y	125.0	0.00	0.04	0.28	0	6	1	99	0.00	0.0	0.427	0.003	0	0	0	2
PD.911	PL.4480	ABC	65T	7.50Y	125.0	0.00	0.04	0.28	0	6	1	99	0.00	0.0	0.427	0.003	0	0	0	2
PL.4481	PD.911	ABC	#2 ACSR	7.50Y	125.0	0.00	0.04	0.28	0	6	1	99	0.00	0.0	0.461	0.034	0	0	1	2
PL.4900	PL.4481	ABC	#2 ACSR	7.50Y	125.0	0.00	0.04	0.26	0	6	1	99	0.00	0.0	0.463	0.002	6	1	1	1
PL.4925	Greenbriar	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	98.85	19	1999	974	90	0.06	0.0	0.008	0.008	0	0	0	2
PL.7524	PL.4925	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	98.85	19	1999	974	90	0.01	0.0	0.009	0.002	0	0	0	2

----- Feeder No. 1 (Fed Prison F1) Beginning with Device PD.1906 -----

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1906	PL.7524	ABC	480VWE	7.50Y	125.0	0.00	0.01	98.85	0	1999	974	90	0.00	0.0	0.009	0.002	0	0	0	2
PL.7525	PD.1906	ABC	336 MCM AC	7.50Y	125.0	0.01	0.02	98.85	19	1999	974	90	0.06	0.0	0.017	0.008	0	0	0	2
PL.4881	PL.7525	ABC	336 MCM AC	7.50Y	125.0	0.01	0.03	98.85	19	1999	974	90	0.11	0.0	0.031	0.014	0	0	0	2
PL.4878	PL.4881	ABC	336 MCM AC	7.49Y	124.8	0.13	0.16	98.85	19	1999	974	90	1.20	0.1	0.177	0.146	0	0	0	2
PL.4876	PL.4878	ABC	336 MCM AC	7.49Y	124.8	0.07	0.23	98.85	19	1998	971	90	0.63	0.0	0.254	0.077	0	0	0	2
PL.4879	PL.4876	ABC	336 MCM AC	7.48Y	124.7	0.11	0.33	98.85	19	1997	969	90	1.01	0.1	0.377	0.123	0	0	0	2
PL.4478	PL.4879	ABC	350 MCM AL	7.48Y	124.7	0.00	0.33	0.54	0	11	5	91	0.00	0.0	0.377	0.001	0	0	0	1
PD.910	PL.4478	ABC	65T	7.48Y	124.7	0.00	0.33	0.54	0	11	5	91	0.00	0.0	0.377	0.001	0	0	0	1
PL.4479	PD.910	ABC	350 MCM AL	7.48Y	124.7	0.00	0.33	0.54	0	11	5	91	0.00	0.0	0.379	0.002	11	5	1	1
PL.4880	PL.4879	ABC	336 MCM AC	7.48Y	124.7	0.01	0.34	98.31	19	1985	962	90	0.05	0.0	0.383	0.006	0	0	0	1
PL.72522	PL.4880	ABC	336 MCM AC	7.48Y	124.7	0.00	0.34	98.31	19	1985	962	90	0.00	0.0	0.385	0.002	1985	962	1	1
CP.112	PL.4880	ABC	Cap (300)	7.48Y	124.7	0.00	0.34	0.00	0	0	0	100	0.00	0.0	0.383	0.002	0	0	0	0
PL.7120	Greenbriar	ABC	336 MCM AC	7.50Y	125.0	0.02	0.02	277.91	54	6016	1703	96	0.63	0.0	0.010	0.010	0	0	0	1220
PL.7526	PL.7120	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	277.91	54	6016	1702	96	0.13	0.0	0.012	0.002	0	0	0	1220

----- Feeder No. 2 (Island Creek F2) Beginning with Device PD.1907 -----

PD.1907	PL.7526	ABC	480VWE	7.50Y	125.0	0.00	0.02	277.91	0	6016	1701	96	0.00	0.0	0.012	0.002	0	0	0	1220
PL.7527	PD.1907	ABC	336 MCM AC	7.48Y	124.6	0.38	0.40	277.91	54	6016	1701	96	11.77	0.2	0.193	0.181	1	0	1	1220
PL.7184	PL.7527	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.92	0	7	1	99	0.00	0.0	0.194	0.001	0	0	0	1
PD.1538	PL.7184	C	65T	7.48Y	124.6	0.00	0.40	0.92	0	7	1	99	0.00	0.0	0.194	0.001	0	0	0	1
PL.7185	PD.1538	C	#1/0 ACSR	7.48Y	124.6	0.00	0.40	0.92	0	7	1	99	0.00	0.0	0.215	0.022	7	1	1	1
PL.6024	PL.7527	ABC	336 MCM AC	7.47Y	124.5	0.15	0.55	277.56	53	5996	1672	96	4.63	0.1	0.264	0.071	0	0	0	1218
PL.7182	PL.6024	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	2.83	2	57	28	90	0.00	0.0	0.264	0.000	0	0	0	1
PD.1537	PL.7182	ABC	65T	7.47Y	124.5	0.00	0.55	2.83	0	57	28	90	0.00	0.0	0.264	0.000	0	0	0	1
PL.7183	PD.1537	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	2.83	2	57	28	90	0.00	0.0	0.266	0.002	57	28	1	1
PL.21315	PL.7183	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	0.269	0.003	0	0	0	0
PL.21316	PL.21315	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	0.408	0.139	0	0	0	0
PL.21317	PL.21316	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	0.456	0.049	0	0	0	0
PL.21318	PL.21315	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	0.296	0.028	0	0	0	0
PL.21319	PL.21318	ABC	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	0.357	0.061	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6277	PL.6024	ABC	336 MCM AC	7.46Y	124.4	0.10	0.65	274.78	53	5935	1634	96	3.22	0.1	0.315	0.051	0	0	1	1217
PL.6278	PL.6277	ABC	336 MCM AC	7.46Y	124.3	0.09	0.74	274.78	53	5932	1626	96	2.68	0.0	0.357	0.042	0	0	0	1216
PL.6282	PL.6278	ABC	336 MCM AC	7.45Y	124.2	0.08	0.81	274.78	53	5929	1620	96	2.37	0.0	0.394	0.037	2	0	2	1216
PL.6283	PL.6282	ABC	336 MCM AC	7.45Y	124.1	0.06	0.88	274.70	53	5925	1614	96	2.02	0.0	0.426	0.032	0	0	0	1214
PL.6019	PL.6283	ABC	336 MCM AC	7.44Y	124.0	0.09	0.96	252.16	49	5459	1393	97	2.51	0.0	0.473	0.047	4	1	4	1207
PL.6629	PL.6019	A	#2 ACSR	7.44Y	124.0	0.00	0.96	3.25	2	24	5	98	0.00	0.0	0.477	0.005	0	0	0	4
PD.1345	PL.6629	A	65T	7.44Y	124.0	0.00	0.96	3.25	0	24	5	98	0.00	0.0	0.477	0.005	0	0	0	4
PL.6630	PD.1345	A	#2 ACSR	7.44Y	124.0	0.00	0.97	3.25	2	24	5	98	0.00	0.0	0.544	0.066	18	4	2	4
PL.5312	PL.6630	A	#2 ACSR	7.44Y	124.0	0.00	0.97	0.79	0	6	1	99	0.00	0.0	0.573	0.030	5	1	1	2
PL.5313	PL.5312	A	#1/0 ACSR	7.44Y	124.0	0.00	0.97	0.17	0	1	0	100	0.00	0.0	0.634	0.060	1	0	1	1
PL.6020	PL.6019	ABC	336 MCM AC	7.43Y	123.9	0.15	1.11	250.90	48	5429	1381	97	4.31	0.1	0.554	0.081	3	1	2	1199
PL.6621	PL.6020	A	6 A (CWC)	7.43Y	123.9	0.00	1.11	3.10	2	23	5	98	0.00	0.0	0.559	0.005	0	0	0	8
PD.1342	PL.6621	A	65T	7.43Y	123.9	0.00	1.11	3.10	0	23	5	98	0.00	0.0	0.559	0.005	0	0	0	8
PL.6622	PD.1342	A	6 A (CWC)	7.43Y	123.9	0.00	1.11	3.10	2	23	5	98	0.00	0.0	0.596	0.038	13	3	5	8
PL.6281	PL.6622	A	6 A (CWC)	7.43Y	123.9	0.00	1.11	1.26	1	9	2	98	0.00	0.0	0.654	0.057	9	2	3	3
PL.6838	PL.6020	ABC	336 MCM AC	7.43Y	123.9	0.02	1.13	249.71	48	5399	1365	97	0.69	0.0	0.567	0.013	0	0	0	1189
PL.7176	PL.6838	ABC	336 MCM AC	7.43Y	123.9	0.01	1.14	249.71	48	5398	1364	97	0.18	0.0	0.571	0.004	0	0	0	1189
PL.7177	PL.7176	ABC	336 MCM AC	7.43Y	123.8	0.08	1.22	249.71	48	5398	1363	97	2.45	0.0	0.617	0.047	0	0	0	1189
PL.6017	PL.7177	ABC	336 MCM AC	7.41Y	123.5	0.27	1.49	249.39	48	5388	1356	97	7.79	0.1	0.766	0.149	0	0	0	1185
PL.6018	PL.6017	ABC	336 MCM AC	7.41Y	123.5	0.01	1.50	249.39	48	5381	1338	97	0.30	0.0	0.772	0.006	10	2	3	1185
PL.6014	PL.6018	ABC	336 MCM AC	7.41Y	123.5	0.03	1.53	247.88	48	5348	1330	97	0.99	0.0	0.791	0.019	0	0	0	1178
PL.6824	PL.6014	C	6 A (CWC)	7.41Y	123.5	0.00	1.54	30.58	22	222	47	98	0.01	0.0	0.793	0.003	0	0	0	33
PD.1454	PL.6824	C	70L	7.41Y	123.5	0.00	1.54	30.58	44	222	47	98	0.00	0.0	0.793	0.003	0	0	0	33
PL.6825	PD.1454	C	6 A (CWC)	7.40Y	123.4	0.06	1.60	30.58	22	222	47	98	0.10	0.0	0.838	0.045	11	2	5	33
PL.6284	PL.6825	C	6 A (CWC)	7.40Y	123.3	0.12	1.71	29.08	21	211	44	98	0.18	0.1	0.929	0.091	10	2	2	28
PL.6285	PL.6284	C	6 A (CWC)	7.39Y	123.1	0.18	1.89	27.76	20	201	42	98	0.27	0.1	1.074	0.145	0	0	0	26
PL.5325	PL.6285	C	#2 ACSR	7.39Y	123.1	0.00	1.89	1.35	1	10	2	98	0.00	0.0	1.095	0.021	10	2	1	1
PL.5732	PL.6285	C	6 A (CWC)	7.37Y	122.9	0.21	2.10	26.41	19	191	40	98	0.30	0.2	1.257	0.183	12	2	1	25
PL.6287	PL.5732	C	6 A (CWC)	7.37Y	122.8	0.07	2.17	24.79	18	179	37	98	0.08	0.0	1.327	0.069	44	9	2	24
PL.6288	PL.6287	C	6 A (CWC)	7.37Y	122.8	0.07	2.24	18.67	13	135	28	98	0.07	0.1	1.412	0.086	1	0	1	22
PL.6289	PL.6288	C	6 A (CWC)	7.36Y	122.7	0.06	2.30	18.57	13	134	28	98	0.06	0.0	1.487	0.075	6	1	3	21

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6290	PL.6289	C	6 A (CWC)	7.36Y	122.7	0.02	2.32	17.71	13	128	27	98	0.02	0.0	1.511	0.023	13	3	2	18
PL.5326	PL.6290	C	6 A (CWC)	7.36Y	122.7	0.00	2.32	1.47	1	11	2	98	0.00	0.0	1.594	0.084	11	2	2	2
PL.6631	PL.6290	C	6 A (CWC)	7.36Y	122.7	0.00	2.32	14.48	10	104	22	98	0.00	0.0	1.515	0.005	0	0	0	14
PD.1346	PL.6631	C	30T	7.36Y	122.7	0.00	2.32	14.48	0	104	22	98	0.00	0.0	1.515	0.005	0	0	0	14
PL.6632	PD.1346	C	6 A (CWC)	7.36Y	122.6	0.05	2.37	14.48	10	104	22	98	0.04	0.0	1.590	0.075	5	1	2	14
PL.6291	PL.6632	C	6 A (CWC)	7.36Y	122.6	0.04	2.41	13.82	10	100	21	98	0.03	0.0	1.656	0.066	0	0	0	12
PL.5327	PL.6291	C	#2 ACSR	7.35Y	122.6	0.02	2.43	13.82	8	100	21	98	0.01	0.0	1.701	0.045	0	0	0	12
PL.5730	PL.5327	C	#2 ACSR	7.35Y	122.5	0.03	2.46	6.38	4	46	10	98	0.01	0.0	1.866	0.165	0	0	0	9
PL.5731	PL.5730	C	#2 ACSR	7.35Y	122.5	0.01	2.47	5.03	3	36	8	98	0.00	0.0	1.933	0.067	0	0	0	7
PL.6294	PL.5731	C	#2 ACSR	7.35Y	122.5	0.00	2.48	4.03	2	29	6	98	0.00	0.0	1.972	0.039	10	2	1	5
PL.6295	PL.6294	C	#2 ACSR	7.35Y	122.5	0.00	2.48	2.58	1	19	4	98	0.00	0.0	1.989	0.017	0	0	0	4
PL.6292	PL.6295	C	#1/0 ACSR	7.35Y	122.5	0.00	2.48	1.62	1	12	2	99	0.00	0.0	2.061	0.072	12	2	2	3
PL.6293	PL.6292	C	#1/0 ACSR	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	2.117	0.056	0	0	1	1
PL.5333	PL.6295	C	6 A (CWC)	7.35Y	122.5	0.00	2.48	0.96	1	7	1	99	0.00	0.0	2.081	0.093	7	1	1	1
PL.5331	PL.5731	C	#2 ACSR	7.35Y	122.5	0.00	2.47	1.01	1	7	2	96	0.00	0.0	1.979	0.046	1	0	1	2
PL.5332	PL.5331	C	#2 ACSR	7.35Y	122.5	0.00	2.48	0.93	1	7	1	99	0.00	0.0	2.015	0.036	7	1	1	1
PL.5330	PL.5730	C	#4 ACSR	7.35Y	122.5	0.00	2.46	1.35	1	10	2	98	0.00	0.0	1.899	0.033	10	2	2	2
PL.5328	PL.5327	C	#1/0 ACSR	7.35Y	122.6	0.00	2.43	1.45	1	10	2	98	0.00	0.0	1.742	0.041	10	2	1	1
PL.5329	PL.5327	C	#2 ACSR	7.35Y	122.6	0.01	2.44	5.98	3	43	9	98	0.00	0.0	1.779	0.078	14	3	1	2
PL.6717	PL.5329	C	1/0 AL URD	7.35Y	122.6	0.00	2.44	4.06	2	29	6	98	0.00	0.0	1.783	0.005	0	0	0	1
PD.1395	PL.6717	C	30T	7.35Y	122.6	0.00	2.44	4.06	0	29	6	98	0.00	0.0	1.783	0.005	0	0	0	1
PL.6718	PD.1395	C	1/0 AL URD	7.35Y	122.6	0.01	2.45	4.06	2	29	6	98	0.00	0.0	1.867	0.084	29	6	1	1
PL.5729	PL.6014	ABC	336 MCM AC	7.40Y	123.3	0.20	1.73	237.70	46	5125	1281	97	5.58	0.1	0.908	0.117	13	3	3	1145
PL.5336	PL.5729	ABC	336 MCM AC	7.39Y	123.2	0.11	1.84	237.11	46	5106	1266	97	3.02	0.1	0.972	0.064	7	1	6	1142
PL.6719	PL.5336	B	#2 ACSR	7.39Y	123.2	0.00	1.84	0.60	0	4	1	97	0.00	0.0	0.977	0.005	0	0	0	1
PD.1396	PL.6719	B	65T	7.39Y	123.2	0.00	1.84	0.60	0	4	1	97	0.00	0.0	0.977	0.005	0	0	0	1
PL.6720	PD.1396	B	#2 ACSR	7.39Y	123.2	0.00	1.84	0.60	0	4	1	97	0.00	0.0	1.007	0.030	4	1	1	1
PL.6006	PL.5336	ABC	336 MCM AC	7.38Y	123.1	0.11	1.95	233.12	45	5017	1240	97	2.94	0.1	1.036	0.064	4	1	2	1115
PL.5337	PL.6006	ABC	#4/0 ACSR	7.38Y	122.9	0.10	2.05	231.26	68	4973	1225	97	3.10	0.1	1.080	0.043	3	1	1	1107
PL.5338	PL.5337	ABC	#4/0 ACSR	7.37Y	122.8	0.19	2.24	231.11	68	4967	1219	97	5.75	0.1	1.161	0.081	23	5	4	1106
PL.6721	PL.5338	A	#4 ACSR	7.37Y	122.8	0.00	2.24	3.27	3	24	5	98	0.00	0.0	1.165	0.005	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1397	PL.6721	A	65T	7.37Y	122.8	0.00	2.24	3.27	0	24	5	98	0.00	0.0	1.165	0.005	0	0	0	3
PL.6722	PD.1397	A	#4 ACSR	7.36Y	122.7	0.01	2.26	3.27	3	24	5	98	0.00	0.0	1.239	0.073	0	0	0	3
PL.5345	PL.6722	A	#2 ACSR	7.36Y	122.7	0.00	2.26	2.56	1	18	4	98	0.00	0.0	1.254	0.015	18	4	2	2
PL.5346	PL.6722	A	#2 ACSR	7.36Y	122.7	0.00	2.26	0.71	0	5	1	98	0.00	0.0	1.274	0.036	5	1	1	1
PL.5347	PL.6722	A	#4 ACSR	7.36Y	122.7	0.00	2.26	0.00	0	0	0	100	0.00	0.0	1.277	0.038	0	0	0	0
PL.6266	PL.5338	ABC	#4/0 ACSR	7.36Y	122.6	0.16	2.40	226.35	67	4858	1187	97	4.56	0.1	1.228	0.067	26	6	6	1089
PL.6267	PL.6266	ABC	#4/0 ACSR	7.35Y	122.5	0.13	2.53	225.12	66	4827	1174	97	3.70	0.1	1.282	0.055	15	3	3	1083
PL.6617	PL.6267	C	#4 ACSR	7.35Y	122.5	0.00	2.53	1.27	1	9	2	98	0.00	0.0	1.287	0.005	0	0	0	3
PD.1340	PL.6617	C	65T	7.35Y	122.5	0.00	2.53	1.27	0	9	2	98	0.00	0.0	1.287	0.005	0	0	0	3
PL.6618	PD.1340	C	#4 ACSR	7.35Y	122.5	0.00	2.53	1.27	1	9	2	98	0.00	0.0	1.359	0.072	9	2	3	3
PL.6275	PL.6267	ABC	#4/0 ACSR	7.34Y	122.4	0.07	2.59	224.03	66	4800	1162	97	1.91	0.0	1.311	0.029	15	3	4	1077
PL.6276	PL.6275	ABC	#4/0 ACSR	7.33Y	122.2	0.19	2.78	223.34	66	4783	1156	97	5.57	0.1	1.395	0.084	0	0	0	1073
PL.6615	PL.6276	C	6 A (CWC)	7.33Y	122.2	0.00	2.78	10.25	7	74	15	98	0.00	0.0	1.399	0.005	0	0	0	16
PD.1339	PL.6615	C	65T	7.33Y	122.2	0.00	2.78	10.25	0	74	15	98	0.00	0.0	1.399	0.005	0	0	0	16
PL.6616	PD.1339	C	6 A (CWC)	7.33Y	122.2	0.02	2.80	10.25	7	74	15	98	0.01	0.0	1.443	0.044	19	4	5	16
PL.6268	PL.6616	C	6 A (CWC)	7.33Y	122.2	0.01	2.81	7.57	5	54	11	98	0.00	0.0	1.471	0.028	6	1	2	11
PL.5349	PL.6268	C	#4 ACSR	7.33Y	122.2	0.00	2.81	1.21	1	9	2	98	0.00	0.0	1.510	0.039	9	2	2	2
PL.5350	PL.6268	C	6 A (CWC)	7.33Y	122.2	0.01	2.82	5.58	4	40	8	98	0.00	0.0	1.523	0.052	18	4	4	7
PL.6269	PL.5350	C	#2 ACSR	7.33Y	122.2	0.00	2.82	3.13	2	22	5	98	0.00	0.0	1.557	0.034	10	2	1	3
PL.6270	PL.6269	C	#2 ACSR	7.33Y	122.2	0.00	2.82	1.74	1	13	3	97	0.00	0.0	1.585	0.028	7	1	1	2
PL.6271	PL.6270	C	#2 ACSR	7.33Y	122.2	0.00	2.83	0.76	0	5	1	98	0.00	0.0	1.618	0.034	5	1	1	1
PL.6274	PL.6276	A	#4 ACSR	7.33Y	122.2	0.00	2.78	4.11	3	29	6	98	0.00	0.0	1.400	0.005	14	3	1	6
PL.6613	PL.6274	A	#4 ACSR	7.33Y	122.2	0.00	2.78	2.23	2	16	3	98	0.00	0.0	1.405	0.005	0	0	0	5
PD.1338	PL.6613	A	65T	7.33Y	122.2	0.00	2.78	2.23	0	16	3	98	0.00	0.0	1.405	0.005	0	0	0	5
PL.6614	PD.1338	A	#4 ACSR	7.33Y	122.2	0.01	2.79	2.23	2	16	3	98	0.00	0.0	1.462	0.057	2	0	2	5
PL.5348	PL.6614	A	#4 ACSR	7.33Y	122.2	0.00	2.79	1.97	2	14	3	98	0.00	0.0	1.497	0.036	14	3	3	3
PL.5734	PL.6276	ABC	#4/0 ACSR	7.33Y	122.2	0.05	2.83	218.56	64	4675	1125	97	1.29	0.0	1.415	0.020	0	0	1	1051
PL.6272	PL.5734	ABC	#4/0 ACSR	7.32Y	122.1	0.09	2.92	218.54	64	4673	1122	97	2.63	0.1	1.456	0.041	8	2	1	1050
PL.6273	PL.6272	ABC	#4/0 ACSR	7.32Y	122.1	0.02	2.94	218.19	64	4663	1116	97	0.55	0.0	1.465	0.009	3	1	1	1049
PL.5351	PL.6273	ABC	#4/0 ACSR	7.31Y	121.8	0.22	3.16	218.03	64	4659	1114	97	6.29	0.1	1.564	0.099	2	0	1	1048
PL.7189	PL.5351	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.36	1	10	2	98	0.00	0.0	1.567	0.003	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1540	PL.7189	C	65T	7.31Y	121.8	0.00	3.16	1.36	0	10	2	98	0.00	0.0	1.567	0.003	0	0	0	2
PL.7190	PD.1540	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.36	1	10	2	98	0.00	0.0	1.569	0.001	0	0	0	2
PL.5735	PL.7190	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	0.31	0	2	0	100	0.00	0.0	1.600	0.031	2	0	1	1
PL.6001	PL.7190	C	1/0 AL URD	7.31Y	121.8	0.00	3.16	1.05	1	8	1	99	0.00	0.0	1.576	0.008	0	0	0	1
PL.5353	PL.6001	C	1/0 AL URD	7.31Y	121.8	0.00	3.16	1.05	1	8	1	99	0.00	0.0	1.614	0.038	8	2	1	1
PL.5354	PL.5351	ABC	336 MCM AC	7.30Y	121.7	0.19	3.35	217.50	42	4641	1101	97	4.86	0.1	1.686	0.122	3	1	1	1045
PL.6609	PL.5354	C	#2 ACSR	7.30Y	121.6	0.00	3.35	24.64	14	176	37	98	0.00	0.0	1.691	0.005	0	0	0	23
PD.1335	PL.6609	C	65T	7.30Y	121.6	0.00	3.35	24.64	0	176	37	98	0.00	0.0	1.691	0.005	0	0	0	23
PL.6610	PD.1335	C	#2 ACSR	7.30Y	121.6	0.01	3.36	24.64	14	176	37	98	0.01	0.0	1.702	0.012	4	1	1	23
PL.6265	PL.6610	C	#2 ACSR	7.30Y	121.6	0.04	3.40	24.13	14	172	36	98	0.05	0.0	1.755	0.052	3	1	1	22
PL.5358	PL.6265	C	#2 ACSR	7.30Y	121.6	0.01	3.41	23.68	14	169	35	98	0.01	0.0	1.766	0.012	11	2	1	21
PL.5999	PL.5358	C	#1/0 ACSR	7.29Y	121.6	0.01	3.42	22.12	10	158	33	98	0.01	0.0	1.790	0.024	10	2	1	20
PL.6787	PL.5999	C	1/0 AL URD	7.29Y	121.6	0.00	3.42	1.72	1	12	3	97	0.00	0.0	1.795	0.005	0	0	0	1
PD.1431	PL.6787	C	40T	7.29Y	121.6	0.00	3.42	1.72	0	12	3	97	0.00	0.0	1.795	0.005	0	0	0	1
PL.6788	PD.1431	C	1/0 AL URD	7.29Y	121.6	0.00	3.42	1.72	1	12	3	97	0.00	0.0	1.808	0.013	12	3	1	1
PL.6000	PL.5999	C	#2 ACSR	7.29Y	121.5	0.04	3.46	18.97	11	135	28	98	0.04	0.0	1.868	0.078	17	4	3	18
PL.6250	PL.6000	C	#1/0 ACSR	7.29Y	121.5	0.01	3.47	8.85	4	63	13	98	0.00	0.0	1.911	0.044	7	2	1	8
PL.6251	PL.6250	C	#1/0 ACSR	7.29Y	121.5	0.01	3.47	7.84	3	56	12	98	0.00	0.0	1.959	0.047	17	3	2	7
PL.5993	PL.6251	C	#1/0 ACSR	7.29Y	121.5	0.01	3.48	4.29	2	31	6	98	0.00	0.0	2.013	0.054	0	0	0	4
PL.5736	PL.5993	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	2.28	1	16	3	98	0.00	0.0	2.059	0.046	0	0	0	3
PL.5737	PL.5736	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	1.54	1	11	2	98	0.00	0.0	2.077	0.019	10	2	1	2
PL.10157	PL.5737	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.07	0	1	0	100	0.00	0.0	2.163	0.086	1	0	1	1
PL.5356	PL.5736	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.75	0	5	1	98	0.00	0.0	2.137	0.079	5	1	1	1
PL.5357	PL.5993	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	2.01	1	14	3	98	0.00	0.0	2.067	0.054	14	3	1	1
PL.5355	PL.6251	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	1.23	1	9	2	98	0.00	0.0	2.000	0.041	9	2	1	1
PL.6258	PL.6000	C	#1/0 ACSR	7.29Y	121.5	0.01	3.47	7.72	3	55	12	98	0.00	0.0	1.930	0.063	23	5	3	7
PL.6259	PL.6258	C	#1/0 ACSR	7.29Y	121.5	0.00	3.47	4.47	2	32	7	98	0.00	0.0	1.986	0.056	16	3	2	4
PL.10196	PL.6259	C	#1/0 ACSR	7.29Y	121.5	0.01	3.48	2.17	1	15	3	98	0.00	0.0	2.104	0.118	0	0	0	2
PL.10195	PL.10196	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.73	0	5	1	98	0.00	0.0	2.145	0.041	0	0	0	1
PL.10198	PL.10195	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.73	0	5	1	98	0.00	0.0	2.185	0.040	5	1	1	1
PL.10197	PL.10198	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	1.43	1	10	2	98	0.00	0.0	2.143	0.040	10	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33047	PL.10197	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.177	0.034	0	0	0	0
PL.33048	PL.33047	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.210	0.033	0	0	0	0
PL.33049	PL.33048	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.246	0.036	0	0	0	0
PL.33051	PL.33049	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.276	0.030	0	0	0	0
PL.33052	PL.33051	C	#1/0 ACSR	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.276	0.000	0	0	0	0
PL.6607	PL.5354	ABC	336 MCM AC	7.30Y	121.6	0.01	3.35	207.02	40	4412	1043	97	0.16	0.0	1.691	0.004	0	0	0	1010
PL.6608	PL.6607	ABC	336 MCM AC	7.29Y	121.6	0.07	3.42	207.02	40	4411	1042	97	1.66	0.0	1.737	0.046	0	0	0	1010
PL.6256	PL.6608	ABC	#4/0 ACSR	7.29Y	121.5	0.12	3.54	206.85	61	4406	1038	97	3.15	0.1	1.792	0.055	2	0	1	1009
PL.6257	PL.6256	ABC	#4/0 ACSR	7.27Y	121.2	0.27	3.80	206.74	61	4401	1032	97	7.21	0.2	1.919	0.127	14	3	3	1008
PL.7191	PL.6257	C	6 A (CWC)	7.27Y	121.2	0.00	3.80	7.96	6	57	12	98	0.00	0.0	1.922	0.003	0	0	0	17
PD.1541	PL.7191	C	65T	7.27Y	121.2	0.00	3.80	7.96	0	57	12	98	0.00	0.0	1.922	0.003	0	0	0	17
PL.7192	PD.1541	C	6 A (CWC)	7.27Y	121.2	0.00	3.81	7.96	6	57	12	98	0.00	0.0	1.923	0.002	0	0	0	17
PL.5738	PL.7192	C	6 A (CWC)	7.27Y	121.2	0.00	3.81	0.33	0	2	0	100	0.00	0.0	1.969	0.045	2	0	1	1
PL.6009	PL.7192	C	6 A (CWC)	7.27Y	121.2	0.00	3.81	7.63	5	54	11	98	0.00	0.0	1.931	0.007	0	0	0	16
PL.5360	PL.6009	C	6 A (CWC)	7.27Y	121.2	0.02	3.83	7.63	5	54	11	98	0.01	0.0	2.000	0.069	13	3	3	16
PL.5362	PL.5360	C	6 A (CWC)	7.27Y	121.2	0.02	3.85	5.75	4	41	9	98	0.00	0.0	2.084	0.084	14	3	3	13
PL.6254	PL.5362	C	#2 ACSR	7.27Y	121.1	0.00	3.85	2.10	1	15	3	98	0.00	0.0	2.150	0.066	2	0	2	6
PL.6255	PL.6254	C	#2 ACSR	7.27Y	121.1	0.00	3.85	1.85	1	13	3	97	0.00	0.0	2.194	0.044	4	1	2	4
PL.6253	PL.6255	C	#2 ACSR	7.27Y	121.1	0.00	3.85	1.26	1	9	2	98	0.00	0.0	2.248	0.054	9	2	2	2
PL.5363	PL.5362	C	#4 ACSR	7.27Y	121.2	0.00	3.85	0.74	1	5	1	98	0.00	0.0	2.143	0.059	5	1	3	3
PL.5364	PL.5362	C	6 A (CWC)	7.27Y	121.2	0.00	3.85	0.92	1	7	1	99	0.00	0.0	2.127	0.043	7	1	1	1
PL.6725	PL.6257	A	#2 ACSR	7.27Y	121.2	0.00	3.80	1.08	1	8	2	97	0.00	0.0	1.923	0.005	0	0	0	2
PD.1399	PL.6725	A	65T	7.27Y	121.2	0.00	3.80	1.08	0	8	2	97	0.00	0.0	1.923	0.005	0	0	0	2
PL.6726	PD.1399	A	#2 ACSR	7.27Y	121.2	0.00	3.80	1.08	1	8	2	97	0.00	0.0	1.970	0.047	8	2	2	2
PL.5361	PL.6257	ABC	#4/0 ACSR	7.26Y	121.0	0.22	4.02	203.06	60	4315	1003	97	5.88	0.1	2.026	0.107	10	2	1	986
PL.6011	PL.5361	ABC	#4/0 ACSR	7.25Y	120.8	0.19	4.22	202.59	60	4299	990	97	5.14	0.1	2.119	0.094	4	1	1	985
PL.6248	PL.6011	ABC	#4/0 ACSR	7.24Y	120.7	0.11	4.32	201.90	59	4279	978	97	2.86	0.1	2.172	0.053	14	3	6	982
PL.6249	PL.6248	ABC	#4/0 ACSR	7.23Y	120.6	0.11	4.43	201.22	59	4262	970	98	2.95	0.1	2.227	0.055	0	0	0	976
PL.5370	PL.6249	ABC	#4/0 ACSR	7.23Y	120.5	0.08	4.51	86.97	26	1844	401	98	0.91	0.0	2.317	0.091	1	0	1	388
PL.6401	PL.5370	ABC	#4/0 ACSR	7.23Y	120.4	0.05	4.56	86.92	26	1842	399	98	0.53	0.0	2.370	0.052	0	0	0	387
PL.6727	PL.6401	A	#1/0 ACSR	7.23Y	120.4	0.00	4.56	12.80	6	90	19	98	0.00	0.0	2.374	0.005	0	0	0	17

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1400	PL.6727	A	65T	7.23Y	120.4	0.00	4.56	12.80	0	90	19	98	0.00	0.0	2.374	0.005	0	0	0	17
PL.6728	PD.1400	A	#1/0 ACSR	7.22Y	120.4	0.07	4.63	12.80	6	90	19	98	0.04	0.0	2.621	0.247	0	0	0	17
PL.5373	PL.6728	A	#1/0 ACSR	7.22Y	120.4	0.00	4.63	1.02	0	7	2	96	0.00	0.0	2.703	0.081	7	2	1	1
PL.5374	PL.6728	A	#1/0 ACSR	7.22Y	120.4	0.01	4.64	11.78	5	83	18	98	0.00	0.0	2.654	0.033	0	0	0	16
PL.5375	PL.5374	A	#1/0 ACSR	7.22Y	120.4	0.00	4.64	0.75	0	5	1	98	0.00	0.0	2.707	0.052	0	0	0	3
PL.5377	PL.5375	A	#1/0 ACSR	7.22Y	120.4	0.00	4.64	0.17	0	1	0	100	0.00	0.0	2.850	0.143	1	0	1	1
PL.5378	PL.5375	A	#4 ACSR	7.22Y	120.4	0.00	4.64	0.58	0	4	1	97	0.00	0.0	2.723	0.016	4	1	2	2
PL.5739	PL.5374	A	#1/0 ACSR	7.22Y	120.4	0.01	4.65	11.03	5	78	16	98	0.00	0.0	2.691	0.036	4	1	1	13
PL.5376	PL.5739	A	#1/0 ACSR	7.22Y	120.4	0.00	4.65	0.92	0	7	1	99	0.00	0.0	2.738	0.047	7	1	1	1
PL.6398	PL.5739	A	#1/0 ACSR	7.22Y	120.3	0.01	4.66	9.51	4	67	14	98	0.01	0.0	2.747	0.056	2	1	1	11
PL.6399	PL.6398	A	#1/0 ACSR	7.22Y	120.3	0.02	4.68	9.16	4	65	14	98	0.01	0.0	2.836	0.090	8	2	1	10
PL.6397	PL.6399	A	#1/0 ACSR	7.22Y	120.3	0.01	4.68	8.01	3	57	12	98	0.00	0.0	2.872	0.036	7	1	1	9
PL.6395	PL.6397	A	#1/0 ACSR	7.22Y	120.3	0.01	4.69	7.08	3	50	11	98	0.00	0.0	2.917	0.045	11	2	2	8
PL.6396	PL.6395	A	#1/0 ACSR	7.22Y	120.3	0.01	4.69	5.51	2	39	8	98	0.00	0.0	2.972	0.055	7	2	1	6
PL.6394	PL.6396	A	#1/0 ACSR	7.22Y	120.3	0.00	4.70	4.44	2	31	7	98	0.00	0.0	3.014	0.042	7	1	1	5
PL.6393	PL.6394	A	#1/0 ACSR	7.22Y	120.3	0.00	4.70	3.48	2	25	5	98	0.00	0.0	3.058	0.044	18	4	3	4
PL.6392	PL.6393	A	#1/0 ACSR	7.22Y	120.3	0.00	4.70	0.98	0	7	1	99	0.00	0.0	3.113	0.055	7	1	1	1
PL.6828	PL.6401	ABC	#4/0 ACSR	7.22Y	120.4	0.04	4.60	82.36	24	1745	378	98	0.44	0.0	2.418	0.049	0	0	0	368
PL.7193	PL.6828	ABC	#4/0 ACSR	7.22Y	120.4	0.00	4.60	82.36	24	1745	377	98	0.03	0.0	2.422	0.003	0	0	0	368
C PD.1542	PL.7193	ABC	70L	7.22Y	120.4	0.00	4.60	82.36	118	1745	377	98	0.00	0.0	2.422	0.003	0	0	0	368 C
PL.7194	PD.1542	ABC	#4/0 ACSR	7.22Y	120.3	0.08	4.68	82.36	24	1745	377	98	0.88	0.1	2.519	0.097	0	0	0	368
PL.5994	PL.7194	ABC	#1/0 ACSR	7.22Y	120.3	0.02	4.70	16.90	7	358	75	98	0.06	0.0	2.596	0.077	0	0	1	77
PL.6729	PL.5994	C	#4 ACSR	7.22Y	120.3	0.00	4.71	16.44	13	116	24	98	0.00	0.0	2.600	0.004	0	0	0	21
PD.1401	PL.6729	C	30T	7.22Y	120.3	0.00	4.71	16.44	0	116	24	98	0.00	0.0	2.600	0.004	0	0	0	21
PL.6730	PD.1401	C	#4 ACSR	7.21Y	120.2	0.05	4.76	16.44	13	116	24	98	0.04	0.0	2.671	0.071	11	2	1	21
PL.6389	PL.6730	C	#4 ACSR	7.21Y	120.2	0.03	4.78	14.90	11	105	22	98	0.02	0.0	2.717	0.046	6	1	2	20
PL.5379	PL.6389	C	#4 ACSR	7.21Y	120.2	0.02	4.81	13.01	10	92	19	98	0.02	0.0	2.763	0.046	16	3	5	17
PL.6384	PL.5379	C	#4 ACSR	7.21Y	120.2	0.02	4.83	10.68	8	75	16	98	0.01	0.0	2.804	0.041	9	2	1	12
PL.6385	PL.6384	C	#4 ACSR	7.21Y	120.2	0.01	4.83	9.41	7	66	14	98	0.00	0.0	2.819	0.015	9	2	1	11
PL.6386	PL.6385	C	#4 ACSR	7.21Y	120.2	0.00	4.84	4.23	3	30	6	98	0.00	0.0	2.859	0.040	21	4	3	4
PL.6387	PL.6386	C	#4 ACSR	7.21Y	120.2	0.00	4.84	1.28	1	9	2	98	0.00	0.0	2.880	0.021	9	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6388	PL.6387	C	#4 ACSR	7.21Y	120.2	0.00	4.84	0.00	0	0	0	100	0.00	0.0	2.900	0.020	0	0	0	0
PL.6382	PL.6385	C	#4 ACSR	7.21Y	120.2	0.01	4.84	3.87	3	27	6	98	0.00	0.0	2.865	0.046	10	2	2	6
PL.6383	PL.6382	C	#4 ACSR	7.21Y	120.2	0.00	4.84	2.43	2	17	4	97	0.00	0.0	2.892	0.027	14	3	3	4
PL.6381	PL.6383	C	#4 ACSR	7.21Y	120.2	0.00	4.84	0.44	0	3	1	95	0.00	0.0	2.912	0.020	3	1	1	1
PL.5987	PL.6389	C	#4 ACSR	7.21Y	120.2	0.00	4.79	1.09	1	8	2	97	0.00	0.0	2.779	0.061	8	2	1	1
PL.5995	PL.5994	ABC	#1/0 ACSR	7.22Y	120.3	0.02	4.72	11.42	5	242	51	98	0.03	0.0	2.678	0.082	0	0	0	55
PL.7195	PL.5995	ABC	#1/0 ACSR	7.22Y	120.3	0.00	4.72	11.42	5	242	51	98	0.00	0.0	2.682	0.003	0	0	0	55
PD.1543	PL.7195	ABC	35H	7.22Y	120.3	0.00	4.72	11.42	33	242	51	98	0.00	0.0	2.682	0.003	0	0	0	55
PL.7196	PD.1543	ABC	#1/0 ACSR	7.22Y	120.3	0.01	4.73	11.42	5	242	51	98	0.01	0.0	2.724	0.043	2	0	2	55
PL.5382	PL.7196	A	#2 ACSR	7.22Y	120.3	0.00	4.73	4.75	3	34	7	98	0.00	0.0	2.729	0.005	0	0	0	8
PD.1402	PL.5382	A	10T	7.22Y	120.3	0.00	4.73	4.75	0	34	7	98	0.00	0.0	2.729	0.005	0	0	0	8
PL.5991	PD.1402	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	3.15	2	22	5	98	0.00	0.0	2.741	0.012	0	0	0	6
PL.5380	PL.5991	A	6 A (CWC)	7.22Y	120.3	0.00	4.74	3.15	2	22	5	98	0.00	0.0	2.765	0.024	0	0	0	6
PL.5381	PL.5380	A	#4 ACSR	7.22Y	120.3	0.00	4.74	2.17	2	15	3	98	0.00	0.0	2.815	0.050	5	1	2	5
PL.6691	PL.5381	A	#4 ACSR	7.22Y	120.3	0.00	4.74	1.51	1	11	2	98	0.00	0.0	2.819	0.005	0	0	0	3
PD.1379	PL.6691	A	10T	7.22Y	120.3	0.00	4.74	1.51	0	11	2	98	0.00	0.0	2.819	0.005	0	0	0	3
PL.6692	PD.1379	A	#4 ACSR	7.22Y	120.3	0.00	4.74	1.51	1	11	2	98	0.00	0.0	2.865	0.046	5	1	1	3
PL.6374	PL.6692	A	#4 ACSR	7.22Y	120.3	0.00	4.74	0.74	1	5	1	98	0.00	0.0	2.928	0.063	1	0	1	2
PL.5402	PL.6374	A	#4 ACSR	7.22Y	120.3	0.00	4.75	0.53	0	4	1	97	0.00	0.0	3.034	0.106	0	0	0	1
PL.5403	PL.5402	A	#4 ACSR	7.22Y	120.3	0.00	4.75	0.53	0	4	1	97	0.00	0.0	3.047	0.014	4	1	1	1
PL.5740	PL.5380	A	6 A (CWC)	7.22Y	120.3	0.00	4.74	0.98	1	7	1	99	0.00	0.0	2.798	0.033	7	1	1	1
PL.6390	PD.1402	A	#2 ACSR	7.22Y	120.3	0.00	4.73	1.60	1	11	2	98	0.00	0.0	2.789	0.059	3	1	1	2
PL.6391	PL.6390	A	#2 ACSR	7.22Y	120.3	0.00	4.73	1.22	1	9	2	98	0.00	0.0	2.809	0.020	9	2	1	1
PL.5985	PL.7196	ABC	#1/0 ACSR	7.22Y	120.3	0.01	4.74	9.75	4	207	44	98	0.02	0.0	2.807	0.083	13	3	3	45
PL.5986	PL.5985	ABC	#1/0 ACSR	7.21Y	120.2	0.02	4.76	9.01	4	191	40	98	0.02	0.0	2.904	0.097	0	0	0	41
PL.6687	PL.5986	C	#2 ACSR	7.21Y	120.2	0.00	4.76	1.31	1	9	2	98	0.00	0.0	2.909	0.005	0	0	0	2
PD.1377	PL.6687	C	10T	7.21Y	120.2	0.00	4.76	1.31	0	9	2	98	0.00	0.0	2.909	0.005	0	0	0	2
PL.6688	PD.1377	C	#2 ACSR	7.21Y	120.2	0.00	4.76	1.31	1	9	2	98	0.00	0.0	2.948	0.039	9	2	2	2
PL.5741	PL.5986	ABC	#1/0 ACSR	7.21Y	120.2	0.02	4.77	7.92	3	168	35	98	0.02	0.0	3.018	0.113	0	0	0	37
PL.5742	PL.5741	ABC	#1/0 ACSR	7.21Y	120.2	0.00	4.78	1.91	1	40	8	98	0.00	0.0	3.071	0.053	0	0	1	14
PL.6372	PL.5742	ABC	#1/0 ACSR	7.21Y	120.2	0.00	4.78	1.66	1	35	7	98	0.00	0.0	3.148	0.077	1	0	2	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6373	PL.6372	ABC	#1/0 ACSR	7.21Y	120.2	0.00	4.78	1.60	1	34	7	98	0.00	0.0	3.209	0.060	0	0	0	10
PL.6683	PL.6373	B	6 A (CWC)	7.21Y	120.2	0.00	4.78	4.81	3	34	7	98	0.00	0.0	3.213	0.005	0	0	0	10
PD.1375	PL.6683	B	10T	7.21Y	120.2	0.00	4.78	4.81	0	34	7	98	0.00	0.0	3.213	0.005	0	0	0	10
PL.6684	PD.1375	B	6 A (CWC)	7.21Y	120.1	0.07	4.85	4.81	3	34	7	98	0.02	0.1	3.554	0.341	0	0	0	10
PL.6370	PL.6684	B	#4 ACSR	7.21Y	120.1	0.01	4.87	2.88	2	20	4	98	0.00	0.0	3.669	0.115	1	0	1	6
PL.6371	PL.6370	B	#4 ACSR	7.21Y	120.1	0.01	4.88	2.71	2	19	4	98	0.00	0.0	3.754	0.085	0	0	0	5
PL.6369	PL.6371	B	#4 ACSR	7.21Y	120.1	0.01	4.89	2.71	2	19	4	98	0.00	0.0	3.832	0.078	1	0	1	5
PL.5392	PL.6369	B	#4 ACSR	7.21Y	120.1	0.01	4.89	2.56	2	18	4	98	0.00	0.0	3.892	0.060	0	0	0	4
PL.5396	PL.5392	B	#4 ACSR	7.21Y	120.1	0.01	4.90	1.88	1	13	3	97	0.00	0.0	3.964	0.072	4	1	1	2
PL.5397	PL.5396	B	#4 ACSR	7.21Y	120.1	0.00	4.90	1.31	1	9	2	98	0.00	0.0	4.050	0.086	9	2	1	1
PL.5394	PL.5392	B	#4 ACSR	7.21Y	120.1	0.00	4.89	0.00	0	0	0	100	0.00	0.0	3.908	0.016	0	0	0	0
PL.5395	PL.5392	B	#4 ACSR	7.21Y	120.1	0.00	4.89	0.69	1	5	1	98	0.00	0.0	3.914	0.022	5	1	2	2
PL.5393	PL.6369	B	#4 ACSR	7.21Y	120.1	0.00	4.89	0.00	0	0	0	100	0.00	0.0	3.877	0.045	0	0	0	0
PL.5391	PL.6684	B	6 A (CWC)	7.21Y	120.1	0.01	4.87	1.93	1	14	3	98	0.00	0.0	3.740	0.186	6	1	2	4
PL.5398	PL.5391	B	#1/0 ACSR	7.21Y	120.1	0.00	4.87	1.13	0	8	2	97	0.00	0.0	3.773	0.033	0	0	0	2
PL.6366	PL.5398	B	#1/0 ACSR	7.21Y	120.1	0.00	4.87	1.13	0	8	2	97	0.00	0.0	3.787	0.013	1	0	1	2
PL.6367	PL.6366	B	#1/0 ACSR	7.21Y	120.1	0.00	4.87	0.94	0	7	1	99	0.00	0.0	3.827	0.040	7	1	1	1
PL.6735	PL.6373	A	#4 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.213	0.004	0	0	0	0
PD.1405	PL.6735	A	10T	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.213	0.004	0	0	0	0
PL.6736	PD.1405	A	#4 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.268	0.055	0	0	0	0
PL.33053	PL.6736	A	#1/0 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.302	0.034	0	0	0	0
PL.33054	PL.33053	A	#1/0 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.353	0.052	0	0	0	0
PL.33055	PL.33054	A	#1/0 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.400	0.047	0	0	0	0
PL.33056	PL.33055	A	#1/0 ACSR	7.21Y	120.2	0.00	4.78	0.00	0	0	0	100	0.00	0.0	3.434	0.034	0	0	0	0
PL.6685	PL.5742	C	#4 ACSR	7.21Y	120.2	0.00	4.78	0.68	1	5	1	98	0.00	0.0	3.076	0.005	0	0	0	1
PD.1376	PL.6685	C	10T	7.21Y	120.2	0.00	4.78	0.68	0	5	1	98	0.00	0.0	3.076	0.005	0	0	0	1
PL.6686	PD.1376	C	#4 ACSR	7.21Y	120.2	0.00	4.78	0.68	1	5	1	98	0.00	0.0	3.117	0.041	5	1	1	1
PL.6733	PL.5741	C	6 A (CWC)	7.21Y	120.2	0.00	4.78	18.05	13	127	27	98	0.00	0.0	3.022	0.005	0	0	0	23
PD.1404	PL.6733	C	25T	7.21Y	120.2	0.00	4.78	18.05	0	127	27	98	0.00	0.0	3.022	0.005	0	0	0	23
PL.6734	PD.1404	C	6 A (CWC)	7.21Y	120.2	0.05	4.82	18.05	13	127	27	98	0.04	0.0	3.083	0.061	10	2	2	23
PL.6380	PL.6734	C	6 A (CWC)	7.21Y	120.2	0.01	4.84	16.63	12	117	25	98	0.01	0.0	3.101	0.018	5	1	1	21

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6379	PL.6380	C	6 A (CWC)	7.21Y	120.1	0.03	4.87	15.89	11	112	24	98	0.03	0.0	3.146	0.045	0	0	0	20
PL.6377	PL.6379	C	#1/0 ACSR	7.21Y	120.1	0.00	4.87	2.33	1	16	3	98	0.00	0.0	3.183	0.037	8	2	1	2
PL.6378	PL.6377	C	#1/0 ACSR	7.21Y	120.1	0.00	4.87	1.17	1	8	2	97	0.00	0.0	3.252	0.069	8	2	1	1
PL.5744	PL.6379	C	6 A (CWC)	7.20Y	120.1	0.06	4.93	13.55	10	96	20	98	0.04	0.0	3.241	0.095	7	2	1	18
PL.6375	PL.5744	C	6 A (CWC)	7.20Y	120.1	0.00	4.93	11.73	8	83	17	98	0.00	0.0	3.249	0.008	4	1	1	16
PL.6376	PL.6375	C	6 A (CWC)	7.20Y	120.0	0.03	4.96	11.22	8	79	17	98	0.02	0.0	3.317	0.068	17	4	2	15
PL.5384	PL.6376	C	6 A (CWC)	7.20Y	120.0	0.01	4.97	4.41	3	31	7	98	0.00	0.0	3.391	0.073	11	2	3	9
PL.5386	PL.5384	C	6 A (CWC)	7.20Y	120.0	0.01	4.98	2.91	2	20	4	98	0.00	0.0	3.463	0.072	11	2	3	6
PL.5388	PL.5386	C	#2 ACSR	7.20Y	120.0	0.00	4.98	0.77	0	5	1	98	0.00	0.0	3.498	0.036	5	1	2	2
PL.5387	PL.5386	C	#2 ACSR	7.20Y	120.0	0.00	4.98	0.64	0	4	1	97	0.00	0.0	3.492	0.029	4	1	1	1
PL.5385	PL.6376	C	#4 ACSR	7.20Y	120.0	0.01	4.97	4.34	3	31	6	98	0.00	0.0	3.377	0.060	7	2	1	4
PL.5983	PL.5385	C	#4 ACSR	7.20Y	120.0	0.01	4.98	3.30	3	23	5	98	0.00	0.0	3.443	0.066	5	1	1	3
PL.5389	PL.5983	C	#1/0 ACSR	7.20Y	120.0	0.00	4.98	1.38	1	10	2	98	0.00	0.0	3.537	0.093	10	2	1	1
PL.5984	PL.5983	C	#4 ACSR	7.20Y	120.0	0.00	4.98	1.15	1	8	2	97	0.00	0.0	3.516	0.072	0	0	0	1
PL.5390	PL.5984	C	#2 ACSR	7.20Y	120.0	0.00	4.98	1.15	1	8	2	97	0.00	0.0	3.565	0.049	8	2	1	1
PL.5743	PL.5744	C	6 A (CWC)	7.20Y	120.1	0.00	4.93	0.78	1	6	1	99	0.00	0.0	3.280	0.039	0	0	0	1
PL.5383	PL.5743	C	#4 ACSR	7.20Y	120.1	0.00	4.93	0.78	1	6	1	99	0.00	0.0	3.315	0.035	6	1	1	1
PL.6731	PL.5986	A	6 A (CWC)	7.21Y	120.2	0.00	4.76	1.95	1	14	3	98	0.00	0.0	2.909	0.005	0	0	0	2
PD.1403	PL.6731	A	10T	7.21Y	120.2	0.00	4.76	1.95	0	14	3	98	0.00	0.0	2.909	0.005	0	0	0	2
PL.6732	PD.1403	A	6 A (CWC)	7.21Y	120.2	0.00	4.76	1.95	1	14	3	98	0.00	0.0	2.978	0.069	14	3	2	2
PL.6689	PL.5985	C	#4 ACSR	7.22Y	120.3	0.00	4.74	0.40	0	3	1	95	0.00	0.0	2.812	0.005	0	0	0	1
PD.1378	PL.6689	C	10T	7.22Y	120.3	0.00	4.74	0.40	0	3	1	95	0.00	0.0	2.812	0.005	0	0	0	1
PL.6690	PD.1378	C	#4 ACSR	7.22Y	120.3	0.00	4.74	0.40	0	3	1	95	0.00	0.0	2.852	0.041	3	1	1	1
PL.6364	PL.7194	ABC	#4/0 ACSR	7.22Y	120.3	0.05	4.73	65.47	19	1386	300	98	0.46	0.0	2.600	0.081	1	0	1	291
PL.6365	PL.6364	ABC	#4/0 ACSR	7.21Y	120.2	0.02	4.75	65.42	19	1384	299	98	0.16	0.0	2.629	0.029	27	6	6	290
PL.5553	PL.6365	ABC	#4/0 ACSR	7.21Y	120.2	0.05	4.80	63.72	19	1348	291	98	0.42	0.0	2.707	0.078	4	1	1	280
PL.6363	PL.5553	ABC	#4/0 ACSR	7.21Y	120.2	0.04	4.84	63.51	19	1343	290	98	0.36	0.0	2.773	0.067	7	1	1	279
PL.5551	PL.6363	ABC	#4/0 ACSR	7.21Y	120.1	0.02	4.86	61.84	18	1308	282	98	0.15	0.0	2.802	0.029	0	0	1	274
PL.5552	PL.5551	ABC	#4/0 ACSR	7.21Y	120.1	0.03	4.89	61.84	18	1307	281	98	0.23	0.0	2.847	0.045	1	0	1	273
PL.5549	PL.5552	ABC	#4/0 ACSR	7.20Y	120.1	0.04	4.93	61.29	18	1296	278	98	0.33	0.0	2.913	0.066	18	4	3	268
PL.5550	PL.5549	ABC	#4/0 ACSR	7.20Y	120.0	0.03	4.96	60.42	18	1277	274	98	0.27	0.0	2.969	0.056	17	4	3	265

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6005	PL.5550	ABC	#4/0 ACSR	7.20Y	120.0	0.05	5.01	58.79	17	1242	266	98	0.39	0.0	3.054	0.085	0	0	0	257
PL.5544	PL.6005	ABC	#4/0 ACSR	7.20Y	119.9	0.05	5.06	58.79	17	1242	266	98	0.38	0.0	3.136	0.082	6	1	2	257
PL.5545	PL.5544	ABC	#4/0 ACSR	7.19Y	119.9	0.03	5.09	58.49	17	1235	264	98	0.21	0.0	3.183	0.047	0	0	0	255
PL.5746	PL.5545	ABC	#4/0 ACSR	7.19Y	119.9	0.04	5.13	58.35	17	1232	263	98	0.32	0.0	3.253	0.071	0	0	0	254
PL.6673	PL.5746	A	6 A (CWC)	7.19Y	119.9	0.00	5.13	1.45	1	10	2	98	0.00	0.0	3.258	0.005	0	0	0	4
PD.1369	PL.6673	A	30T	7.19Y	119.9	0.00	5.13	1.45	0	10	2	98	0.00	0.0	3.258	0.005	0	0	0	4
PL.6674	PD.1369	A	6 A (CWC)	7.19Y	119.9	0.00	5.13	1.45	1	10	2	98	0.00	0.0	3.324	0.066	10	2	4	4
PL.5998	PL.5746	ABC	#4/0 ACSR	7.19Y	119.8	0.03	5.15	57.87	17	1221	260	98	0.20	0.0	3.298	0.045	11	2	1	250
PL.6513	PL.5998	ABC	#4/0 ACSR	7.19Y	119.8	0.02	5.17	56.87	17	1200	255	98	0.13	0.0	3.330	0.031	9	2	1	248
PL.6514	PL.6513	ABC	#4/0 ACSR	7.19Y	119.8	0.03	5.20	56.45	17	1191	253	98	0.24	0.0	3.386	0.056	0	0	0	247
PL.5748	PL.6514	ABC	#4/0 ACSR	7.19Y	119.8	0.03	5.24	54.63	16	1152	245	98	0.23	0.0	3.444	0.058	0	0	0	239
PL.7254	PL.5748	ABC	#4/0 ACSR	7.18Y	119.7	0.03	5.26	54.29	16	1145	243	98	0.21	0.0	3.498	0.053	0	0	0	238
PL.7253	PL.7254	C	#1/0 ACSR	7.18Y	119.7	0.00	5.26	0.59	0	4	1	97	0.00	0.0	3.545	0.047	4	1	1	1
PL.7255	PL.7254	ABC	#4/0 ACSR	7.18Y	119.7	0.03	5.29	54.10	16	1141	241	98	0.22	0.0	3.554	0.057	6	1	1	237
PL.5542	PL.7255	ABC	#4/0 ACSR	7.18Y	119.7	0.03	5.33	53.83	16	1135	240	98	0.24	0.0	3.617	0.063	1	0	2	236
PL.5543	PL.5542	ABC	#4/0 ACSR	7.18Y	119.7	0.01	5.34	53.78	16	1134	239	98	0.08	0.0	3.639	0.022	12	2	1	234
PL.5541	PL.5543	ABC	#4/0 ACSR	7.18Y	119.7	0.01	5.35	53.23	16	1122	237	98	0.05	0.0	3.653	0.014	0	0	0	233
PL.6669	PL.5541	B	#4 ACSR	7.18Y	119.7	0.00	5.35	8.40	6	59	12	98	0.00	0.0	3.658	0.005	0	0	0	12
PD.1366	PL.6669	B	30T	7.18Y	119.7	0.00	5.35	8.40	0	59	12	98	0.00	0.0	3.658	0.005	0	0	0	12
PL.6670	PD.1366	B	#4 ACSR	7.18Y	119.6	0.02	5.37	8.40	6	59	12	98	0.01	0.0	3.713	0.055	0	0	0	12
PL.5410	PL.6670	B	#4 ACSR	7.18Y	119.6	0.00	5.37	0.44	0	3	1	95	0.00	0.0	3.727	0.015	3	1	1	1
PL.5537	PL.6670	B	#4 ACSR	7.18Y	119.6	0.00	5.37	2.16	2	15	3	98	0.00	0.0	3.769	0.056	4	1	1	3
PL.5538	PL.5537	B	#4 ACSR	7.18Y	119.6	0.00	5.38	1.61	1	11	2	98	0.00	0.0	3.798	0.029	7	1	1	2
PL.5535	PL.5538	B	#4 ACSR	7.18Y	119.6	0.00	5.38	0.65	1	5	1	98	0.00	0.0	3.828	0.030	5	1	1	1
PL.5539	PL.6670	B	#4 ACSR	7.18Y	119.6	0.01	5.38	5.79	4	41	9	98	0.00	0.0	3.744	0.031	9	2	3	8
PL.5540	PL.5539	B	#4 ACSR	7.18Y	119.6	0.01	5.39	4.54	3	32	7	98	0.00	0.0	3.804	0.060	6	1	1	5
PL.5536	PL.5540	B	#4 ACSR	7.18Y	119.6	0.01	5.40	3.68	3	26	5	98	0.00	0.0	3.870	0.066	7	1	1	4
PL.5534	PL.5536	B	#4 ACSR	7.18Y	119.6	0.00	5.40	2.68	2	19	4	98	0.00	0.0	3.900	0.029	6	1	1	3
PL.5533	PL.5534	B	#4 ACSR	7.18Y	119.6	0.00	5.40	1.78	1	13	3	97	0.00	0.0	3.935	0.036	0	0	0	2
PL.5531	PL.5533	B	#4 ACSR	7.18Y	119.6	0.00	5.40	1.78	1	13	3	97	0.00	0.0	3.962	0.027	9	2	1	2
PL.5532	PL.5531	B	#4 ACSR	7.18Y	119.6	0.00	5.40	0.48	0	3	1	95	0.00	0.0	4.039	0.077	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5988	PL.5541	ABC	#4/0 ACSR	7.18Y	119.6	0.02	5.37	50.43	15	1063	224	98	0.13	0.0	3.692	0.039	3	1	1	221
PL.6667	PL.5988	B	1/0 AL URD	7.18Y	119.6	0.00	5.37	12.60	7	89	18	98	0.00	0.0	3.697	0.005	0	0	0	14
PD.1365	PL.6667	B	30T	7.18Y	119.6	0.00	5.37	12.60	0	89	18	98	0.00	0.0	3.697	0.005	0	0	0	14
PL.6668	PD.1365	B	1/0 AL URD	7.18Y	119.6	0.01	5.37	12.60	7	89	18	98	0.00	0.0	3.710	0.013	6	1	1	14
PL.6532	PL.6668	B	1/0 AL URD	7.18Y	119.6	0.01	5.38	11.70	7	82	16	98	0.00	0.0	3.735	0.025	22	5	4	13
PL.6531	PL.6532	B	1/0 AL URD	7.18Y	119.6	0.01	5.39	8.52	5	60	12	98	0.00	0.0	3.764	0.029	0	0	0	9
PL.5411	PL.6531	B	1/0 AL URD	7.18Y	119.6	0.01	5.40	8.52	5	60	12	98	0.00	0.0	3.788	0.024	0	0	0	9
PL.5425	PL.5411	B	1/0 AL URD	7.18Y	119.6	0.01	5.40	8.53	5	60	12	98	0.00	0.0	3.823	0.034	13	3	2	9
PL.6529	PL.5425	B	1/0 AL URD	7.18Y	119.6	0.01	5.41	6.63	4	47	9	98	0.00	0.0	3.864	0.042	3	1	1	7
PL.6530	PL.6529	B	1/0 AL URD	7.17Y	119.6	0.01	5.42	6.23	4	44	9	98	0.00	0.0	3.927	0.062	0	0	0	6
P PL.7200	PL.6530	B	1/0 AL URD	7.17Y	119.6	0.00	5.42	-0.00	0	0	0	100	0.00	0.0	3.931	0.005	0	0	0	0 P
PL.6661	PL.6530	B	1/0 AL URD	7.17Y	119.6	0.00	5.43	6.24	4	44	9	98	0.00	0.0	3.931	0.005	0	0	0	6
PD.1361	PL.6661	B	20T	7.17Y	119.6	0.00	5.43	6.24	0	44	9	98	0.00	0.0	3.931	0.005	0	0	0	6
PL.6662	PD.1361	B	1/0 AL URD	7.17Y	119.6	0.00	5.43	6.24	4	44	9	98	0.00	0.0	3.936	0.005	0	0	0	6
PL.5413	PL.6662	B	#1/0 ACSR	7.17Y	119.6	0.00	5.43	6.24	3	44	9	98	0.00	0.0	3.970	0.034	0	0	0	6
PL.5423	PL.5413	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	6.24	3	44	9	98	0.00	0.0	4.008	0.038	9	2	1	6
PL.5422	PL.5423	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	3.96	2	28	6	98	0.00	0.0	4.048	0.040	5	1	1	4
PL.5415	PL.5422	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	3.23	1	23	5	98	0.00	0.0	4.081	0.032	7	1	1	3
PL.5416	PL.5415	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	1.02	0	7	2	96	0.00	0.0	4.110	0.030	7	2	1	1
PL.5417	PL.5415	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	1.26	1	9	2	98	0.00	0.0	4.113	0.032	9	2	1	1
PL.5418	PL.5415	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	0.00	0	0	0	100	0.00	0.0	4.118	0.037	0	0	0	0
PL.5414	PL.5423	B	#1/0 ACSR	7.17Y	119.6	0.00	5.44	0.98	0	7	1	99	0.00	0.0	4.040	0.032	7	1	1	1
PL.5529	PL.5988	ABC	#4/0 ACSR	7.18Y	119.6	0.02	5.38	46.08	14	971	206	98	0.11	0.0	3.730	0.038	6	1	1	206
PL.5530	PL.5529	ABC	#4/0 ACSR	7.18Y	119.6	0.02	5.40	45.78	13	964	204	98	0.10	0.0	3.767	0.037	0	0	0	205
PL.5527	PL.5530	ABC	#4/0 ACSR	7.17Y	119.6	0.02	5.42	45.39	13	956	203	98	0.12	0.0	3.813	0.046	8	2	2	202
PL.5528	PL.5527	ABC	#4/0 ACSR	7.17Y	119.5	0.05	5.47	45.01	13	948	201	98	0.28	0.0	3.917	0.104	9	2	5	200
PL.5524	PL.5528	ABC	#4/0 ACSR	7.17Y	119.5	0.01	5.48	44.56	13	938	198	98	0.06	0.0	3.941	0.024	0	0	0	195
PL.6344	PL.5524	ABC	#4/0 ACSR	7.17Y	119.5	0.01	5.48	17.18	5	362	77	98	0.01	0.0	3.976	0.035	15	3	2	68
PL.6345	PL.6344	ABC	#4/0 ACSR	7.17Y	119.5	0.01	5.49	16.46	5	346	73	98	0.02	0.0	4.026	0.050	9	2	2	66
PL.5420	PL.6345	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.51	16.04	7	337	71	98	0.05	0.0	4.094	0.068	0	0	0	64
PL.5750	PL.5420	ABC	#1/0 ACSR	7.17Y	119.4	0.04	5.55	13.63	6	287	61	98	0.08	0.0	4.264	0.171	0	0	0	58

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6657	PL.5750	A	#1/0 ACSR	7.17Y	119.4	0.00	5.55	0.50	0	4	1	97	0.00	0.0	4.269	0.005	0	0	0	1
PD.1359	PL.6657	A	30T	7.17Y	119.4	0.00	5.55	0.50	0	4	1	97	0.00	0.0	4.269	0.005	0	0	0	1
PL.6658	PD.1359	A	#1/0 ACSR	7.17Y	119.4	0.00	5.55	0.50	0	4	1	97	0.00	0.0	4.297	0.028	4	1	1	1
PL.7257	PL.5750	ABC	#1/0 ACSR	7.17Y	119.4	0.02	5.57	13.46	6	283	60	98	0.03	0.0	4.330	0.066	7	2	1	57
PL.7258	PL.7257	ABC	#1/0 ACSR	7.16Y	119.4	0.04	5.61	13.11	6	276	58	98	0.08	0.0	4.505	0.175	8	2	1	56
PL.5751	PL.7258	ABC	#1/0 ACSR	7.16Y	119.4	0.04	5.64	12.12	5	255	54	98	0.07	0.0	4.679	0.174	2	0	1	53
PL.6343	PL.5751	ABC	#1/0 ACSR	7.16Y	119.3	0.03	5.67	12.05	5	253	54	98	0.05	0.0	4.822	0.143	4	1	1	52
PL.6341	PL.6343	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.68	11.84	5	249	53	98	0.02	0.0	4.879	0.058	0	0	0	51
PL.6655	PL.6341	A	#1/0 ACSR	7.16Y	119.3	0.00	5.68	0.72	0	5	1	98	0.00	0.0	4.884	0.004	0	0	0	1
PD.1358	PL.6655	A	30T	7.16Y	119.3	0.00	5.68	0.72	0	5	1	98	0.00	0.0	4.884	0.004	0	0	0	1
PL.6656	PD.1358	A	#1/0 ACSR	7.16Y	119.3	0.00	5.69	0.72	0	5	1	98	0.00	0.0	4.936	0.052	5	1	1	1
PL.6339	PL.6341	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.69	11.60	5	244	51	98	0.01	0.0	4.920	0.041	5	1	2	50
PL.6340	PL.6339	ABC	#1/0 ACSR	7.16Y	119.3	0.03	5.72	11.36	5	239	50	98	0.05	0.0	5.061	0.141	0	0	0	48
PL.33045	PL.6340	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.74	11.36	5	239	50	98	0.03	0.0	5.152	0.091	5	1	3	48
PL.33046	PL.33045	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.75	11.11	5	233	49	98	0.02	0.0	5.206	0.054	0	0	0	45
PL.6759	PL.33046	B	6 A (CWC)	7.15Y	119.2	0.01	5.75	25.08	18	176	37	98	0.01	0.0	5.211	0.005	0	0	0	33
PD.1417	PL.6759	B	30T	7.15Y	119.2	0.00	5.75	25.08	0	176	37	98	0.00	0.0	5.211	0.005	0	0	0	33
PL.6760	PD.1417	B	6 A (CWC)	7.15Y	119.2	0.05	5.81	25.08	18	176	37	98	0.07	0.0	5.256	0.046	2	0	2	33
PL.6332	PL.6760	B	6 A (CWC)	7.15Y	119.1	0.10	5.90	23.79	17	166	35	98	0.12	0.1	5.353	0.097	13	3	2	29
PL.6333	PL.6332	B	6 A (CWC)	7.14Y	119.0	0.09	5.99	21.92	16	153	32	98	0.11	0.1	5.444	0.091	0	0	0	27
PL.6326	PL.6333	B	6 A (CWC)	7.14Y	119.0	0.03	6.02	14.14	10	99	21	98	0.02	0.0	5.495	0.051	18	4	4	20
PL.6327	PL.6326	B	6 A (CWC)	7.14Y	118.9	0.04	6.06	11.56	8	81	17	98	0.02	0.0	5.564	0.069	0	0	0	16
PL.5466	PL.6327	B	6 A (CWC)	7.14Y	118.9	0.00	6.06	2.01	1	14	3	98	0.00	0.0	5.594	0.030	8	2	2	3
PL.5468	PL.5466	B	#1/0 ACSR	7.14Y	118.9	0.00	6.06	0.81	0	6	1	99	0.00	0.0	5.669	0.075	6	1	1	1
PL.5467	PL.6327	B	6 A (CWC)	7.14Y	118.9	0.00	6.06	0.68	0	5	1	98	0.00	0.0	5.632	0.067	5	1	1	1
PL.6007	PL.6327	B	6 A (CWC)	7.13Y	118.9	0.03	6.09	8.87	6	62	13	98	0.01	0.0	5.648	0.084	7	2	1	12
PL.6324	PL.6007	B	#1/0 ACSR	7.13Y	118.9	0.01	6.10	7.84	3	55	12	98	0.00	0.0	5.722	0.074	2	0	2	11
PL.6325	PL.6324	B	#1/0 ACSR	7.13Y	118.9	0.01	6.11	7.52	3	52	11	98	0.00	0.0	5.790	0.068	0	0	0	9
PL.5469	PL.6325	B	#2 ACSR	7.13Y	118.9	0.00	6.12	2.25	1	16	3	98	0.00	0.0	5.813	0.023	9	2	2	3
PL.7256	PL.5469	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	0.94	0	7	1	99	0.00	0.0	5.882	0.069	7	1	1	1
PL.5753	PL.6325	B	#1/0 ACSR	7.13Y	118.9	0.01	6.12	3.70	2	26	5	98	0.00	0.0	5.864	0.074	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.5471	PL.5753	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	3.33	1	23	5	98	0.00	0.0	5.904	0.040	9	2	1	2
PL.5472	PL.5471	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	1.98	1	14	3	98	0.00	0.0	5.953	0.050	14	3	1	1
PL.5754	PL.5753	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	0.37	0	3	1	95	0.00	0.0	5.926	0.062	3	1	1	1
PL.5962	PL.5754	B	6 A (CWC)	7.13Y	118.9	0.00	6.12	0.00	0	0	0	100	0.00	0.0	5.931	0.005	0	0	0	0
PD.1441-A	PL.5962	B	Open	7.13Y	118.9	0.00	6.12	0.00	0	0	0	100	0.00	0.0	5.931	0.005	0	0	0	0
PL.25732	PL.6325	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	1.57	1	11	2	98	0.00	0.0	5.843	0.053	6	1	1	3
PL.25733	PL.25732	B	#1/0 ACSR	7.13Y	118.9	0.00	6.12	0.71	0	5	1	98	0.00	0.0	5.896	0.052	5	1	2	2
PL.6330	PL.6333	B	#2 ACSR	7.14Y	119.0	0.00	6.00	2.84	2	20	4	98	0.00	0.0	5.486	0.043	14	3	2	3
PL.6331	PL.6330	B	#2 ACSR	7.14Y	119.0	0.00	6.00	0.80	0	6	1	99	0.00	0.0	5.528	0.042	6	1	1	1
PL.6328	PL.6333	B	#4 ACSR	7.14Y	119.0	0.01	6.00	4.94	4	35	7	98	0.00	0.0	5.486	0.043	25	5	3	4
PL.6329	PL.6328	B	#4 ACSR	7.14Y	119.0	0.00	6.00	1.38	1	10	2	98	0.00	0.0	5.539	0.052	10	2	1	1
PL.5465	PL.6760	B	#4 ACSR	7.15Y	119.2	0.00	5.81	1.00	1	7	1	99	0.00	0.0	5.294	0.037	7	1	2	2
PL.6651	PL.33046	C	#1/0 ACSR	7.16Y	119.3	0.00	5.75	0.62	0	4	1	97	0.00	0.0	5.234	0.028	0	0	0	1
PD.1356	PL.6651	C	30T	7.16Y	119.3	0.00	5.75	0.62	0	4	1	97	0.00	0.0	5.234	0.028	0	0	0	1
PL.6652	PD.1356	C	#1/0 ACSR	7.15Y	119.2	0.00	5.75	0.62	0	4	1	97	0.00	0.0	5.346	0.112	4	1	1	1
PL.6761	PL.33046	A	#1/0 ACSR	7.16Y	119.3	0.00	5.75	7.63	3	53	11	98	0.00	0.0	5.210	0.004	0	0	0	11
PD.1418	PL.6761	A	30T	7.16Y	119.3	0.00	5.75	7.63	0	53	11	98	0.00	0.0	5.210	0.004	0	0	0	11
PL.6762	PD.1418	A	#1/0 ACSR	7.15Y	119.2	0.01	5.76	7.63	3	53	11	98	0.00	0.0	5.249	0.039	9	2	1	11
PL.6337	PL.6762	A	6 A (CWC)	7.15Y	119.2	0.01	5.76	6.38	5	45	9	98	0.00	0.0	5.276	0.026	5	1	1	10
PL.6338	PL.6337	A	6 A (CWC)	7.15Y	119.2	0.01	5.77	5.73	4	40	8	98	0.00	0.0	5.305	0.029	2	0	1	9
PL.6336	PL.6338	A	6 A (CWC)	7.15Y	119.2	0.01	5.78	5.39	4	38	8	98	0.00	0.0	5.358	0.053	0	0	1	8
PL.6334	PL.6336	A	6 A (CWC)	7.15Y	119.2	0.00	5.79	4.44	3	31	7	98	0.00	0.0	5.375	0.017	7	1	1	6
PL.6335	PL.6334	A	6 A (CWC)	7.15Y	119.2	0.01	5.79	3.50	2	24	5	98	0.00	0.0	5.429	0.054	14	3	2	5
PL.5457	PL.6335	A	#4 ACSR	7.15Y	119.2	0.00	5.79	0.00	0	0	0	100	0.00	0.0	5.494	0.065	0	0	0	0
PL.5458	PL.6335	A	#1/0 ACSR	7.15Y	119.2	0.00	5.79	0.52	0	4	1	97	0.00	0.0	5.491	0.062	4	1	2	2
PL.5459	PL.6335	A	#2 ACSR	7.15Y	119.2	0.00	5.79	0.95	1	7	1	99	0.00	0.0	5.497	0.068	7	1	1	1
PL.5479	PL.6336	A	#1/0 ACSR	7.15Y	119.2	0.00	5.78	0.89	0	6	1	99	0.00	0.0	5.405	0.047	6	1	1	1
PL.6653	PL.6340	A	#2 ACSR	7.16Y	119.3	0.00	5.72	0.00	0	0	0	100	0.00	0.0	5.066	0.005	0	0	0	0
PD.1357	PL.6653	A	30T	7.16Y	119.3	0.00	5.72	0.00	0	0	0	100	0.00	0.0	5.066	0.005	0	0	0	0
PL.6654	PD.1357	A	#2 ACSR	7.16Y	119.3	0.00	5.72	0.00	0	0	0	100	0.00	0.0	5.093	0.027	0	0	0	0
PL.6757	PL.7258	C	#1/0 ACSR	7.16Y	119.4	0.00	5.61	1.84	1	13	3	97	0.00	0.0	4.510	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1416	PL.6757	C	30T	7.16Y	119.4	0.00	5.61	1.84	0	13	3	97	0.00	0.0	4.510	0.005	0	0	0	2
PL.6758	PD.1416	C	#1/0 ACSR	7.16Y	119.4	0.00	5.61	1.84	1	13	3	97	0.00	0.0	4.599	0.089	13	3	2	2
PL.5419	PL.5420	A	#1/0 ACSR	7.17Y	119.5	0.01	5.52	7.22	3	51	11	98	0.00	0.0	4.132	0.038	3	1	1	6
PL.6743	PL.5419	A	6 A (CWC)	7.17Y	119.5	0.00	5.52	6.83	5	48	10	98	0.00	0.0	4.136	0.005	0	0	0	5
PD.1409	PL.6743	A	30T	7.17Y	119.5	0.00	5.52	6.83	0	48	10	98	0.00	0.0	4.136	0.005	0	0	0	5
PL.6744	PD.1409	A	6 A (CWC)	7.17Y	119.5	0.01	5.53	6.83	5	48	10	98	0.00	0.0	4.168	0.031	17	4	2	5
PL.5526	PL.6744	A	6 A (CWC)	7.17Y	119.5	0.01	5.54	4.35	3	31	6	98	0.00	0.0	4.243	0.075	13	3	1	3
PL.5525	PL.5526	A	6 A (CWC)	7.17Y	119.5	0.00	5.54	2.48	2	17	4	97	0.00	0.0	4.295	0.052	11	2	1	2
PL.5428	PL.5525	A	#4 ACSR	7.17Y	119.5	0.00	5.54	0.96	1	7	1	99	0.00	0.0	4.331	0.036	7	1	1	1
PL.5421	PL.5524	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.50	27.39	12	576	122	98	0.10	0.0	3.989	0.048	0	0	0	127
PL.5756	PL.5421	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.52	26.71	12	562	119	98	0.08	0.0	4.029	0.040	0	0	0	124
PL.6747	PL.5756	A	#1/0 ACSR	7.17Y	119.5	0.00	5.52	19.72	9	138	29	98	0.00	0.0	4.034	0.005	0	0	0	30
PD.1411	PL.6747	A	30T	7.17Y	119.5	0.00	5.52	19.72	0	138	29	98	0.00	0.0	4.034	0.005	0	0	0	30
PL.6748	PD.1411	A	#1/0 ACSR	7.17Y	119.5	0.01	5.53	19.72	9	138	29	98	0.01	0.0	4.053	0.020	0	0	1	30
PL.5431	PL.6748	A	#1/0 ACSR	7.17Y	119.5	0.01	5.55	19.72	9	138	29	98	0.01	0.0	4.087	0.034	0	0	0	29
PL.5522	PL.5431	A	#1/0 ACSR	7.17Y	119.4	0.00	5.55	4.52	2	32	7	98	0.00	0.0	4.138	0.052	6	1	1	5
PL.5523	PL.5522	A	#1/0 ACSR	7.17Y	119.4	0.00	5.55	3.68	2	26	5	98	0.00	0.0	4.175	0.037	19	4	3	4
PL.5521	PL.5523	A	#1/0 ACSR	7.17Y	119.4	0.00	5.55	1.02	0	7	1	99	0.00	0.0	4.381	0.206	7	1	1	1
PL.5429	PL.5431	A	#1/0 ACSR	7.17Y	119.5	0.00	5.55	0.00	0	0	0	100	0.00	0.0	4.105	0.018	0	0	0	0
PL.5989	PL.5431	A	#1/0 ACSR	7.17Y	119.4	0.02	5.56	15.20	7	107	22	98	0.01	0.0	4.148	0.062	14	3	3	24
PL.5430	PL.5989	A	#2 ACSR	7.17Y	119.4	0.00	5.57	1.19	1	8	2	97	0.00	0.0	4.179	0.030	8	2	2	2
PL.5990	PL.5989	A	#1/0 ACSR	7.17Y	119.4	0.01	5.58	11.99	5	84	18	98	0.01	0.0	4.207	0.059	10	2	2	19
PL.6362	PL.5990	A	6 A (CWC)	7.16Y	119.4	0.02	5.60	10.58	8	74	16	98	0.01	0.0	4.260	0.053	7	1	1	17
PL.5517	PL.6362	A	6 A (CWC)	7.16Y	119.4	0.01	5.62	9.57	7	67	14	98	0.01	0.0	4.300	0.039	31	7	7	16
PL.6361	PL.5517	A	6 A (CWC)	7.16Y	119.4	0.01	5.62	5.11	4	36	8	98	0.00	0.0	4.331	0.031	0	0	2	9
PL.6313	PL.6361	A	6 A (CWC)	7.16Y	119.4	0.02	5.64	5.11	4	36	8	98	0.00	0.0	4.406	0.074	4	1	1	6
PL.6312	PL.6313	A	6 A (CWC)	7.16Y	119.4	0.00	5.64	4.54	3	32	7	98	0.00	0.0	4.415	0.009	0	0	0	5
PL.5434	PL.6312	A	#2 ACSR	7.16Y	119.4	0.00	5.65	2.88	2	20	4	98	0.00	0.0	4.474	0.059	10	2	1	3
PL.5435	PL.5434	A	#1/0 ACSR	7.16Y	119.4	0.00	5.65	1.44	1	10	2	98	0.00	0.0	4.568	0.094	10	2	2	2
PL.5433	PL.6312	A	#4 ACSR	7.16Y	119.4	0.00	5.64	0.83	1	6	1	99	0.00	0.0	4.436	0.021	6	1	1	1
PL.21295	PL.6312	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	0.83	0	6	1	99	0.00	0.0	4.483	0.068	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.65719	PL.6361	A	#1/0 ACSR	7.16Y	119.4	0.00	5.62	0.00	0	0	0	100	0.00	0.0	4.395	0.063	0	0	0	1
PL.65720	PL.65719	A	#1/0 ACSR	7.16Y	119.4	0.00	5.62	0.00	0	0	0	100	0.00	0.0	4.433	0.039	0	0	1	1
PL.5757	PL.5756	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.54	19.58	9	412	87	98	0.05	0.0	4.077	0.048	0	0	0	92
PL.6645	PL.5757	A	#1/0 ACSR	7.17Y	119.5	0.00	5.54	2.22	1	16	3	98	0.00	0.0	4.082	0.005	0	0	0	3
PD.1354	PL.6645	A	15T	7.17Y	119.5	0.00	5.54	2.22	0	16	3	98	0.00	0.0	4.082	0.005	0	0	0	3
PL.6646	PD.1354	A	#1/0 ACSR	7.17Y	119.5	0.00	5.54	2.22	1	16	3	98	0.00	0.0	4.099	0.017	16	3	3	3
PL.6647	PL.5757	ABC	#1/0 ACSR	7.17Y	119.5	0.00	5.54	18.84	8	396	84	98	0.00	0.0	4.082	0.004	0	0	0	89
PL.6648	PL.6647	ABC	#1/0 ACSR	7.17Y	119.4	0.04	5.58	18.84	8	396	84	98	0.12	0.0	4.212	0.131	0	0	0	89
PL.6643	PL.6648	A	#1/0 ACSR	7.17Y	119.4	0.00	5.58	0.23	0	2	0	100	0.00	0.0	4.217	0.005	0	0	0	1
PD.1353	PL.6643	A	30T	7.17Y	119.4	0.00	5.58	0.23	0	2	0	100	0.00	0.0	4.217	0.005	0	0	0	1
PL.6644	PD.1353	A	#1/0 ACSR	7.17Y	119.4	0.00	5.58	0.23	0	2	0	100	0.00	0.0	4.245	0.028	2	0	1	1
PL.5758	PL.6648	ABC	#1/0 ACSR	7.16Y	119.4	0.05	5.63	17.53	8	369	78	98	0.13	0.0	4.367	0.154	0	0	0	84
PL.5759	PL.5758	ABC	#1/0 ACSR	7.16Y	119.4	0.02	5.65	15.73	7	331	70	98	0.05	0.0	4.446	0.079	0	0	0	76
PL.5760	PL.5759	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.67	15.33	7	322	68	98	0.05	0.0	4.531	0.086	0	0	0	75
PL.6637	PL.5760	C	#1/0 ACSR	7.16Y	119.3	0.00	5.67	1.68	1	12	2	99	0.00	0.0	4.536	0.005	0	0	0	3
PD.1350	PL.6637	C	30T	7.16Y	119.3	0.00	5.67	1.68	0	12	2	99	0.00	0.0	4.536	0.005	0	0	0	3
PL.6638	PD.1350	C	#1/0 ACSR	7.16Y	119.3	0.00	5.67	1.68	1	12	2	99	0.00	0.0	4.557	0.021	12	2	3	3
PL.6306	PL.5760	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.69	14.77	6	310	65	98	0.03	0.0	4.583	0.051	14	3	1	72
PL.6307	PL.6306	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.70	14.10	6	296	62	98	0.03	0.0	4.640	0.058	0	0	0	71
PL.6751	PL.6307	C	#1/0 ACSR	7.16Y	119.3	0.00	5.70	1.04	0	7	2	96	0.00	0.0	4.645	0.005	0	0	0	1
PD.1413	PL.6751	C	30T	7.16Y	119.3	0.00	5.70	1.04	0	7	2	96	0.00	0.0	4.645	0.005	0	0	0	1
PL.6752	PD.1413	C	#1/0 ACSR	7.16Y	119.3	0.00	5.70	1.04	0	7	2	96	0.00	0.0	4.686	0.041	7	2	1	1
PL.5761	PL.6307	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.72	13.62	6	286	60	98	0.03	0.0	4.706	0.066	0	0	0	69
PL.6304	PL.5761	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.73	11.90	5	250	53	98	0.02	0.0	4.761	0.055	11	2	3	64
PL.6305	PL.6304	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.74	11.38	5	239	50	98	0.02	0.0	4.828	0.067	9	2	1	61
PL.6303	PL.6305	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.75	10.97	5	230	49	98	0.01	0.0	4.863	0.034	5	1	1	60
PL.6302	PL.6303	ABC	#1/0 ACSR	7.15Y	119.2	0.01	5.76	10.72	5	225	47	98	0.02	0.0	4.917	0.054	11	2	3	59
PL.5440	PL.6302	C	#4 ACSR	7.15Y	119.2	0.02	5.78	18.09	14	127	27	98	0.02	0.0	4.945	0.028	0	0	0	38
PL.6826	PL.5440	C	#4 ACSR	7.15Y	119.2	0.00	5.78	18.09	14	127	27	98	0.00	0.0	4.947	0.003	0	0	0	38
PD.1455	PL.6826	C	50H	7.15Y	119.2	0.00	5.78	18.09	36	127	27	98	0.00	0.0	4.947	0.003	0	0	0	38
PL.6827	PD.1455	C	#4 ACSR	7.13Y	118.8	0.42	6.20	18.09	14	127	27	98	0.42	0.3	5.485	0.537	0	0	1	38

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.6360	PL.6827	C	#4 ACSR	7.12Y	118.7	0.11	6.32	18.05	14	126	26	98	0.11	0.1	5.629	0.144	0	0	0	37
PL.5450	PL.6360	C	#4 ACSR	7.12Y	118.7	0.00	6.32	0.49	0	3	1	95	0.00	0.0	5.744	0.115	3	1	1	1
PL.6357	PL.6360	C	#4 ACSR	7.12Y	118.7	0.03	6.35	17.56	14	122	26	98	0.03	0.0	5.667	0.038	10	2	1	36
PL.6358	PL.6357	C	#4 ACSR	7.12Y	118.6	0.03	6.37	16.08	12	112	23	98	0.02	0.0	5.705	0.039	13	3	2	35
PL.5977	PL.6358	C	#1/0 ACSR	7.12Y	118.6	0.00	6.37	1.08	0	8	2	97	0.00	0.0	5.773	0.067	0	0	0	3
PL.5451	PL.5977	C	#4 ACSR	7.12Y	118.6	0.00	6.38	0.48	0	3	1	95	0.00	0.0	5.904	0.131	3	1	1	1
PL.6355	PL.5977	C	#1/0 ACSR	7.12Y	118.6	0.00	6.37	0.60	0	4	1	97	0.00	0.0	5.796	0.024	2	0	1	2
PL.6356	PL.6355	C	#1/0 ACSR	7.12Y	118.6	0.00	6.37	0.26	0	2	0	100	0.00	0.0	5.859	0.063	2	0	1	1
PL.5978	PL.6358	C	#4 ACSR	7.11Y	118.6	0.05	6.42	13.10	10	91	19	98	0.03	0.0	5.791	0.086	8	2	3	30
PL.6353	PL.5978	C	#4 ACSR	7.11Y	118.6	0.00	6.42	0.41	0	3	0	100	0.00	0.0	5.907	0.116	0	0	1	3
PL.6354	PL.6353	C	#4 ACSR	7.11Y	118.6	0.00	6.42	0.34	0	2	0	100	0.00	0.0	5.940	0.034	1	0	1	2
PL.6659	PL.6354	C	1/0 AL URD	7.11Y	118.6	0.00	6.42	0.22	0	2	0	100	0.00	0.0	5.945	0.005	0	0	0	1
PD.1360	PL.6659	C	20T	7.11Y	118.6	0.00	6.42	0.22	0	2	0	100	0.00	0.0	5.945	0.005	0	0	0	1
PL.6660	PD.1360	C	1/0 AL URD	7.11Y	118.6	0.00	6.42	0.22	0	2	0	100	0.00	0.0	6.010	0.065	2	0	1	1
PL.5976	PL.5978	C	#4 ACSR	7.10Y	118.4	0.20	6.62	11.55	9	80	17	98	0.13	0.2	6.191	0.400	0	0	0	24
PL.6351	PL.5976	C	#4 ACSR	7.10Y	118.4	0.02	6.64	4.62	4	32	7	98	0.00	0.0	6.282	0.092	3	1	2	10
PL.6352	PL.6351	C	#4 ACSR	7.10Y	118.3	0.01	6.65	4.19	3	29	6	98	0.00	0.0	6.344	0.062	0	0	0	8
PL.5452	PL.6352	C	#4 ACSR	7.10Y	118.3	0.00	6.65	1.08	1	7	2	96	0.00	0.0	6.420	0.075	7	2	1	1
PL.6349	PL.6352	C	#4 ACSR	7.10Y	118.3	0.01	6.66	3.11	2	22	5	98	0.00	0.0	6.445	0.100	2	0	1	7
PL.6350	PL.6349	C	#4 ACSR	7.10Y	118.3	0.00	6.67	2.84	2	20	4	98	0.00	0.0	6.477	0.032	1	0	1	6
PL.6348	PL.6350	C	#4 ACSR	7.10Y	118.3	0.01	6.68	2.68	2	19	4	98	0.00	0.0	6.554	0.077	5	1	2	5
PL.6347	PL.6348	C	#4 ACSR	7.10Y	118.3	0.00	6.68	2.01	2	14	3	98	0.00	0.0	6.600	0.046	0	0	0	3
PL.6346	PL.6347	C	#4 ACSR	7.10Y	118.3	0.00	6.68	2.01	2	14	3	98	0.00	0.0	6.628	0.029	0	0	0	3
PL.5765	PL.6346	C	#4 ACSR	7.10Y	118.3	0.00	6.68	0.94	1	7	1	99	0.00	0.0	6.656	0.028	7	1	2	2
PL.5453	PL.6346	C	#1/0 ACSR	7.10Y	118.3	0.00	6.68	1.07	0	7	2	96	0.00	0.0	6.704	0.075	7	2	1	1
PL.5764	PL.5976	C	#4 ACSR	7.10Y	118.3	0.04	6.66	6.93	5	48	10	98	0.02	0.0	6.325	0.135	0	0	1	14
PL.6753	PL.5764	C	#4 ACSR	7.10Y	118.3	0.00	6.66	1.70	1	12	2	99	0.00	0.0	6.330	0.005	0	0	0	3
PD.1414	PL.6753	C	20T	7.10Y	118.3	0.00	6.66	1.70	0	12	2	99	0.00	0.0	6.330	0.005	0	0	0	3
PL.6754	PD.1414	C	#4 ACSR	7.10Y	118.3	0.03	6.70	1.70	1	12	2	99	0.00	0.0	6.824	0.494	1	0	1	3
PL.5974	PL.6754	C	#4 ACSR	7.10Y	118.3	0.01	6.70	1.51	1	10	2	98	0.00	0.0	6.937	0.113	0	0	0	1
PL.5449	PL.5974	C	#2 ACSR	7.10Y	118.3	0.00	6.70	0.00	0	0	0	100	0.00	0.0	6.972	0.035	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5463	PL.5974	C	#4 ACSR	7.10Y	118.3	0.01	6.71	1.51	1	10	2	98	0.00	0.0	7.133	0.196	10	2	1	1
PL.5975	PL.6754	C	#4 ACSR	7.10Y	118.3	0.00	6.70	0.00	0	0	0	100	0.00	0.0	6.914	0.090	0	0	1	1
PL.6755	PL.5764	C	#4 ACSR	7.10Y	118.3	0.00	6.66	5.23	4	36	8	98	0.00	0.0	6.330	0.005	0	0	0	10
PD.1415	PL.6755	C	20T	7.10Y	118.3	0.00	6.66	5.23	0	36	8	98	0.00	0.0	6.330	0.005	0	0	0	10
PL.6756	PD.1415	C	#4 ACSR	7.10Y	118.3	0.07	6.74	5.23	4	36	8	98	0.02	0.1	6.647	0.317	0	0	1	10
PL.6323	PL.6756	C	#4 ACSR	7.09Y	118.2	0.04	6.77	5.17	4	36	8	98	0.01	0.0	6.813	0.166	0	0	1	9
PL.6318	PL.6323	C	#4 ACSR	7.09Y	118.2	0.01	6.78	5.12	4	36	7	98	0.00	0.0	6.853	0.041	9	2	1	6
PL.6319	PL.6318	C	#4 ACSR	7.09Y	118.2	0.01	6.79	3.84	3	27	6	98	0.00	0.0	6.887	0.034	0	0	0	5
PL.5455	PL.6319	C	#4 ACSR	7.09Y	118.2	0.05	6.83	3.84	3	27	6	98	0.01	0.0	7.227	0.339	10	2	2	5
PL.6316	PL.5455	C	#4 ACSR	7.09Y	118.2	0.00	6.83	1.44	1	10	2	98	0.00	0.0	7.248	0.022	0	0	0	1
PL.6649	PL.6316	C	#1/0 ACSR	7.09Y	118.2	0.00	6.83	1.44	1	10	2	98	0.00	0.0	7.253	0.005	0	0	0	1
PD.1355	PL.6649	C	12T	7.09Y	118.2	0.00	6.83	1.44	0	10	2	98	0.00	0.0	7.253	0.005	0	0	0	1
PL.6650	PD.1355	C	#1/0 ACSR	7.09Y	118.2	0.00	6.83	1.44	1	10	2	98	0.00	0.0	7.278	0.025	10	2	1	1
PL.6317	PL.5455	C	#4 ACSR	7.09Y	118.2	0.00	6.84	0.94	1	7	1	99	0.00	0.0	7.306	0.079	0	0	1	2
PL.6315	PL.6317	C	#4 ACSR	7.09Y	118.2	0.00	6.84	0.94	1	7	1	99	0.00	0.0	7.391	0.086	7	1	1	1
PL.5454	PL.6323	C	6 A (CWC)	7.09Y	118.2	0.00	6.77	0.01	0	0	0	100	0.00	0.0	6.918	0.106	0	0	1	2
PL.6320	PL.5454	C	6 A (CWC)	7.09Y	118.2	0.00	6.77	0.00	0	0	0	100	0.00	0.0	7.009	0.090	0	0	0	1
PL.6321	PL.6320	C	6 A (CWC)	7.09Y	118.2	0.00	6.77	0.00	0	0	0	100	0.00	0.0	7.077	0.069	0	0	1	1
PL.28279	PL.5764	C	#1/0 ACSR	7.10Y	118.3	0.00	6.66	0.00	0	0	0	100	0.00	0.0	6.376	0.051	0	0	0	0
PL.5441	PL.6302	A	6 A (CWC)	7.15Y	119.2	0.01	5.77	12.50	9	88	18	98	0.01	0.0	4.942	0.026	0	0	0	18
PL.6813	PL.5441	A	6 A (CWC)	7.15Y	119.2	0.00	5.77	12.50	9	87	18	98	0.00	0.0	4.945	0.003	0	0	0	18
PD.1446	PL.6813	A	35H	7.15Y	119.2	0.00	5.77	12.50	36	87	18	98	0.00	0.0	4.945	0.003	0	0	0	18
PL.6814	PD.1446	A	6 A (CWC)	7.15Y	119.2	0.04	5.81	12.50	9	87	18	98	0.02	0.0	5.013	0.068	9	2	1	18
PL.6301	PL.6814	A	6 A (CWC)	7.15Y	119.2	0.02	5.82	11.26	8	79	17	98	0.01	0.0	5.050	0.037	12	3	2	17
PL.6300	PL.6301	A	6 A (CWC)	7.15Y	119.1	0.04	5.86	9.50	7	67	14	98	0.02	0.0	5.142	0.092	13	3	3	15
PL.6299	PL.6300	A	6 A (CWC)	7.14Y	119.0	0.11	5.97	7.68	5	54	11	98	0.04	0.1	5.454	0.312	1	0	1	12
PL.5980	PL.6299	A	6 A (CWC)	7.14Y	118.9	0.09	6.05	6.74	5	47	10	98	0.03	0.1	5.741	0.287	0	0	0	7
PL.5763	PL.5980	A	6 A (CWC)	7.13Y	118.9	0.04	6.09	5.66	4	40	8	98	0.01	0.0	5.917	0.176	11	2	2	5
PL.5443	PL.5763	A	6 A (CWC)	7.13Y	118.9	0.02	6.11	3.95	3	28	6	98	0.00	0.0	6.031	0.115	0	0	0	2
PL.5448	PL.5443	A	6 A (CWC)	7.13Y	118.9	0.00	6.11	1.81	1	13	3	97	0.00	0.0	6.055	0.024	0	0	0	1
PL.5447	PL.5448	A	6 A (CWC)	7.13Y	118.9	0.00	6.11	1.81	1	13	3	97	0.00	0.0	6.083	0.028	13	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5446	PL.5443	A	6 A (CWC)	7.13Y	118.9	0.02	6.13	2.14	2	15	3	98	0.00	0.0	6.225	0.194	0	0	0	1
PL.6297	PL.5446	A	6 A (CWC)	7.13Y	118.9	0.01	6.14	2.14	2	15	3	98	0.00	0.0	6.341	0.116	15	3	1	1
PL.5462	PL.5763	A	6 A (CWC)	7.13Y	118.9	0.00	6.09	0.09	0	1	0	100	0.00	0.0	6.036	0.119	1	0	1	1
PL.5444	PL.5980	A	#2 ACSR	7.14Y	118.9	0.00	6.05	0.02	0	0	0	100	0.00	0.0	5.823	0.082	0	0	1	1
PL.5456	PL.5980	A	#1/0 ACSR	7.14Y	118.9	0.00	6.05	1.05	0	7	2	96	0.00	0.0	5.795	0.055	7	2	1	1
PL.6298	PL.6299	A	#4 ACSR	7.14Y	119.0	0.00	5.97	0.77	1	5	1	98	0.00	0.0	5.492	0.038	0	0	1	4
PL.6633	PL.6298	A	#4 ACSR	7.14Y	119.0	0.00	5.97	0.73	1	5	1	98	0.00	0.0	5.496	0.005	0	0	0	3
PD.1347	PL.6633	A	10T	7.14Y	119.0	0.00	5.97	0.73	0	5	1	98	0.00	0.0	5.496	0.005	0	0	0	3
PL.6634	PD.1347	A	#4 ACSR	7.14Y	119.0	0.01	5.97	0.73	1	5	1	98	0.00	0.0	5.910	0.414	5	1	3	3
PL.7201	PL.5761	C	#1/0 ACSR	7.16Y	119.3	0.00	5.72	5.16	2	36	8	98	0.00	0.0	4.708	0.002	0	0	0	5
PD.1545	PL.7201	C	30T	7.16Y	119.3	0.00	5.72	5.16	0	36	8	98	0.00	0.0	4.708	0.002	0	0	0	5
PL.7202	PD.1545	C	#1/0 ACSR	7.16Y	119.3	0.00	5.72	5.16	2	36	8	98	0.00	0.0	4.711	0.003	0	0	0	5
PL.5762	PL.7202	C	#1/0 ACSR	7.16Y	119.3	0.00	5.72	2.29	1	16	3	98	0.00	0.0	4.728	0.017	16	3	2	2
PL.5981	PL.7202	C	#1/0 ACSR	7.16Y	119.3	0.00	5.72	2.87	1	20	4	98	0.00	0.0	4.715	0.004	0	0	0	3
PL.5437	PL.5981	C	#1/0 ACSR	7.16Y	119.3	0.00	5.72	2.87	1	20	4	98	0.00	0.0	4.740	0.025	0	0	0	3
PL.5438	PL.5437	C	6 A (CWC)	7.16Y	119.3	0.01	5.72	2.87	2	20	4	98	0.00	0.0	4.819	0.079	20	4	3	3
PL.6635	PL.6307	C	#1/0 ACSR	7.16Y	119.3	0.00	5.70	0.38	0	3	1	95	0.00	0.0	4.645	0.005	0	0	0	1
PD.1349	PL.6635	C	30T	7.16Y	119.3	0.00	5.70	0.38	0	3	1	95	0.00	0.0	4.645	0.005	0	0	0	1
PL.6636	PD.1349	C	#1/0 ACSR	7.16Y	119.3	0.00	5.70	0.38	0	3	1	95	0.00	0.0	4.666	0.021	3	1	1	1
PL.6639	PL.5759	C	#1/0 ACSR	7.16Y	119.4	0.00	5.65	1.19	1	8	2	97	0.00	0.0	4.450	0.005	0	0	0	1
PD.1351	PL.6639	C	30T	7.16Y	119.4	0.00	5.65	1.19	0	8	2	97	0.00	0.0	4.450	0.005	0	0	0	1
PL.6640	PD.1351	C	#1/0 ACSR	7.16Y	119.3	0.00	5.65	1.19	1	8	2	97	0.00	0.0	4.475	0.025	8	2	1	1
PL.6641	PL.5758	A	#1/0 ACSR	7.16Y	119.4	0.00	5.63	5.41	2	38	8	98	0.00	0.0	4.371	0.005	0	0	0	8
PD.1352	PL.6641	A	30T	7.16Y	119.4	0.00	5.63	5.41	0	38	8	98	0.00	0.0	4.371	0.005	0	0	0	8
PL.6642	PD.1352	A	#1/0 ACSR	7.16Y	119.4	0.00	5.63	5.41	2	38	8	98	0.00	0.0	4.376	0.004	9	2	2	8
PL.6311	PL.6642	A	#1/0 ACSR	7.16Y	119.4	0.00	5.63	4.12	2	29	6	98	0.00	0.0	4.432	0.057	5	1	1	6
PL.6310	PL.6311	A	#1/0 ACSR	7.16Y	119.4	0.01	5.64	3.34	1	23	5	98	0.00	0.0	4.549	0.117	9	2	1	5
PL.5436	PL.6310	A	#4 ACSR	7.16Y	119.4	0.00	5.64	0.85	1	6	1	99	0.00	0.0	4.596	0.046	6	1	1	1
PL.6308	PL.6310	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	1.20	1	8	2	97	0.00	0.0	4.599	0.050	0	0	2	3
PL.6309	PL.6308	A	#1/0 ACSR	7.16Y	119.4	0.00	5.64	1.17	1	8	2	97	0.00	0.0	4.643	0.044	8	2	1	1
PL.6749	PL.6648	C	#1/0 ACSR	7.17Y	119.4	0.00	5.58	3.70	2	26	5	98	0.00	0.0	4.218	0.005	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1412	PL.6749	C	30T	7.17Y	119.4	0.00	5.58	3.70	0	26	5	98	0.00	0.0	4.218	0.005	0	0	0	4
PL.6750	PD.1412	C	#1/0 ACSR	7.16Y	119.4	0.00	5.58	3.70	2	26	5	98	0.00	0.0	4.274	0.056	26	5	4	4
PL.6663	PL.5756	A	#4 ACSR	7.17Y	119.5	0.00	5.52	1.67	1	12	2	99	0.00	0.0	4.034	0.005	0	0	0	2
PD.1362	PL.6663	A	30T	7.17Y	119.5	0.00	5.52	1.67	0	12	2	99	0.00	0.0	4.034	0.005	0	0	0	2
PL.6664	PD.1362	A	#4 ACSR	7.17Y	119.5	0.00	5.52	1.67	1	12	2	99	0.00	0.0	4.062	0.029	0	0	1	2
PL.5520	PL.6664	A	#4 ACSR	7.17Y	119.5	0.00	5.52	1.62	1	11	2	98	0.00	0.0	4.091	0.029	11	2	1	1
PL.6745	PL.5421	C	#1/0 ACSR	7.17Y	119.5	0.00	5.50	2.02	1	14	3	98	0.00	0.0	3.994	0.005	0	0	0	2
PD.1410	PL.6745	C	30T	7.17Y	119.5	0.00	5.50	2.02	0	14	3	98	0.00	0.0	3.994	0.005	0	0	0	2
PL.6746	PD.1410	C	#1/0 ACSR	7.17Y	119.5	0.00	5.50	2.02	1	14	3	98	0.00	0.0	4.018	0.024	14	3	2	2
PL.6665	PL.5421	A	#4 ACSR	7.17Y	119.5	0.00	5.50	0.00	0	0	0	100	0.00	0.0	3.994	0.005	0	0	0	1
PD.1363	PL.6665	A	30T	7.17Y	119.5	0.00	5.50	0.00	0	0	0	100	0.00	0.0	3.994	0.005	0	0	0	1
PL.6666	PD.1363	A	#4 ACSR	7.17Y	119.5	0.00	5.50	0.00	0	0	0	100	0.00	0.0	4.017	0.023	0	0	1	1
PL.5427	PL.5530	B	1/0 AL URD	7.18Y	119.6	0.00	5.40	1.17	1	8	1	99	0.00	0.0	3.772	0.005	0	0	0	3
PD.1364	PL.5427	B	30T	7.18Y	119.6	0.00	5.40	1.17	0	8	1	99	0.00	0.0	3.772	0.005	0	0	0	3
PL.5823	PD.1364	B	1/0 AL URD	7.18Y	119.6	0.00	5.40	1.17	1	8	1	99	0.00	0.0	3.781	0.009	7	1	1	3
PL.5424	PL.5823	B	1/0 AL URD	7.18Y	119.6	0.00	5.40	0.21	0	1	0	100	0.00	0.0	3.836	0.055	1	0	2	2
PL.5426	PL.5424	B	1/0 AL URD	7.18Y	119.6	-0.00	5.40	-0.07	0	0	0	100	0.00	0.0	3.960	0.123	0	0	0	0
P PL.7199	PL.5426	B	1/0 AL URD	7.18Y	119.6	0.00	5.40	0.00	0	0	0	100	0.00	0.0	3.961	0.001	0	0	0	0 P
PL.6671	PL.5748	A	#1/0 ACSR	7.19Y	119.8	0.00	5.24	1.01	0	7	1	99	0.00	0.0	3.449	0.005	0	0	0	1
PD.1367	PL.6671	A	30T	7.19Y	119.8	0.00	5.24	1.01	0	7	1	99	0.00	0.0	3.449	0.005	0	0	0	1
PL.6672	PD.1367	A	#1/0 ACSR	7.19Y	119.8	0.00	5.24	1.01	0	7	1	99	0.00	0.0	3.495	0.046	7	1	1	1
PL.7197	PL.6514	A	#4 ACSR	7.19Y	119.8	0.00	5.20	5.45	4	38	8	98	0.00	0.0	3.388	0.002	0	0	0	8
PD.1544	PL.7197	A	30T	7.19Y	119.8	0.00	5.20	5.45	0	38	8	98	0.00	0.0	3.388	0.002	0	0	0	8
PL.7198	PD.1544	A	#4 ACSR	7.19Y	119.8	0.00	5.21	5.45	4	38	8	98	0.00	0.0	3.391	0.002	0	0	0	8
PL.5747	PL.7198	A	#4 ACSR	7.19Y	119.8	0.00	5.21	2.26	2	16	3	98	0.00	0.0	3.470	0.079	16	3	5	5
PL.5996	PL.7198	A	#4 ACSR	7.19Y	119.8	0.00	5.21	3.19	2	22	5	98	0.00	0.0	3.394	0.003	0	0	0	3
PL.5408	PL.5996	A	#4 ACSR	7.19Y	119.8	0.00	5.21	3.19	2	22	5	98	0.00	0.0	3.441	0.047	22	5	3	3
PL.6741	PL.5998	B	#1/0 ACSR	7.19Y	119.8	0.00	5.15	1.42	1	10	2	98	0.00	0.0	3.303	0.005	0	0	0	1
PD.1408	PL.6741	B	30T	7.19Y	119.8	0.00	5.15	1.42	0	10	2	98	0.00	0.0	3.303	0.005	0	0	0	1
PL.6742	PD.1408	B	#1/0 ACSR	7.19Y	119.8	0.00	5.16	1.42	1	10	2	98	0.00	0.0	3.324	0.021	10	2	1	1
PL.6675	PL.5545	A	6 A (CWC)	7.19Y	119.9	0.00	5.09	0.42	0	3	1	95	0.00	0.0	3.187	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1370	PL.6675	A	30T	7.19Y	119.9	0.00	5.09	0.42	0	3	1	95	0.00	0.0	3.187	0.005	0	0	0	1
PL.6676	PD.1370	A	6 A (CWC)	7.19Y	119.9	0.00	5.09	0.42	0	3	1	95	0.00	0.0	3.205	0.018	3	1	1	1
PL.5405	PL.5550	A	#4 ACSR	7.20Y	120.0	0.00	4.96	2.45	2	17	4	97	0.00	0.0	2.974	0.005	0	0	0	5
PD.1371	PL.5405	A	30T	7.20Y	120.0	0.00	4.96	2.45	0	17	4	97	0.00	0.0	2.974	0.005	0	0	0	5
PL.6003	PD.1371	A	6 A (CWC)	7.20Y	120.0	0.00	4.96	0.77	1	5	1	98	0.00	0.0	2.978	0.004	0	0	0	1
PL.5404	PL.6003	A	6 A (CWC)	7.20Y	120.0	0.00	4.96	0.77	1	5	1	98	0.00	0.0	3.028	0.050	5	1	1	1
PL.5745	PD.1371	A	#4 ACSR	7.20Y	120.0	0.00	4.97	1.67	1	12	2	99	0.00	0.0	3.021	0.047	0	0	0	4
PL.5547	PL.5745	A	#4 ACSR	7.20Y	120.0	0.00	4.97	1.67	1	12	2	99	0.00	0.0	3.058	0.037	4	1	2	4
PL.5548	PL.5547	A	#4 ACSR	7.20Y	120.0	0.00	4.97	1.13	1	8	2	97	0.00	0.0	3.103	0.045	0	0	1	2
PL.5546	PL.5548	A	#4 ACSR	7.20Y	120.0	0.00	4.97	1.11	1	8	2	97	0.00	0.0	3.156	0.053	8	2	1	1
PL.6677	PL.5552	B	#4 ACSR	7.21Y	120.1	0.00	4.89	1.05	1	7	2	96	0.00	0.0	2.852	0.005	0	0	0	2
PD.1372	PL.6677	B	30T	7.21Y	120.1	0.00	4.89	1.05	0	7	2	96	0.00	0.0	2.852	0.005	0	0	0	2
PL.6678	PD.1372	B	#4 ACSR	7.21Y	120.1	0.00	4.89	1.05	1	7	2	96	0.00	0.0	2.913	0.061	7	2	2	2
PL.6739	PL.5552	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.41	0	3	1	95	0.00	0.0	2.852	0.005	0	0	0	2
PD.1407	PL.6739	C	30T	7.21Y	120.1	0.00	4.89	0.41	0	3	1	95	0.00	0.0	2.852	0.005	0	0	0	2
PL.6740	PD.1407	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.41	0	3	1	95	0.00	0.0	2.932	0.080	0	0	1	2
PL.5400	PL.6740	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.34	0	2	1	89	0.00	0.0	3.227	0.296	2	1	1	1
PL.6679	PL.6363	C	#1/0 ACSR	7.21Y	120.2	0.00	4.84	3.98	2	28	6	98	0.00	0.0	2.778	0.005	0	0	0	4
PD.1373	PL.6679	C	30T	7.21Y	120.2	0.00	4.84	3.98	0	28	6	98	0.00	0.0	2.778	0.005	0	0	0	4
PL.6680	PD.1373	C	#1/0 ACSR	7.21Y	120.2	0.00	4.85	3.98	2	28	6	98	0.00	0.0	2.802	0.024	28	6	4	4
PL.6681	PL.6365	C	6 A (CWC)	7.21Y	120.2	0.00	4.75	0.63	0	4	1	97	0.00	0.0	2.633	0.005	0	0	0	3
PD.1374	PL.6681	C	30T	7.21Y	120.2	0.00	4.75	0.63	0	4	1	97	0.00	0.0	2.633	0.005	0	0	0	3
PL.6682	PD.1374	C	6 A (CWC)	7.21Y	120.2	0.00	4.75	0.63	0	4	1	97	0.00	0.0	2.685	0.051	0	0	1	3
PL.5399	PL.6682	C	6 A (CWC)	7.21Y	120.2	0.00	4.75	0.62	0	4	1	97	0.00	0.0	2.734	0.049	4	1	2	2
PL.6737	PL.6365	A	1/0 AL URD	7.21Y	120.2	0.00	4.75	0.65	0	5	1	98	0.00	0.0	2.633	0.004	0	0	0	1
PD.1406	PL.6737	A	30T	7.21Y	120.2	0.00	4.75	0.65	0	5	1	98	0.00	0.0	2.633	0.004	0	0	0	1
PL.6738	PD.1406	A	1/0 AL URD	7.21Y	120.2	0.00	4.75	0.65	0	5	1	98	0.00	0.0	2.661	0.028	5	1	1	1
PL.6693	PL.6401	C	#2 ACSR	7.23Y	120.4	0.00	4.56	0.87	0	6	1	99	0.00	0.0	2.374	0.005	0	0	0	2
PD.1380	PL.6693	C	65T	7.23Y	120.4	0.00	4.56	0.87	0	6	1	99	0.00	0.0	2.374	0.005	0	0	0	2
PL.6694	PD.1380	C	#2 ACSR	7.23Y	120.4	0.00	4.56	0.87	0	6	1	99	0.00	0.0	2.431	0.057	6	1	1	2
PL.5372	PL.6694	C	#4 ACSR	7.23Y	120.4	0.00	4.56	0.09	0	1	0	100	0.00	0.0	2.486	0.054	1	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5371	PL.6249	ABC	#4/0 ACSR	7.23Y	120.5	0.05	4.49	114.26	34	2415	564	97	0.77	0.0	2.271	0.044	0	0	0	588
PL.6243	PL.5371	ABC	#4/0 ACSR	7.23Y	120.4	0.08	4.57	111.64	33	2358	551	97	1.17	0.0	2.342	0.071	14	3	3	578
PL.6244	PL.6243	ABC	#4/0 ACSR	7.22Y	120.4	0.06	4.62	110.96	33	2343	546	97	0.86	0.0	2.394	0.053	1	0	1	575
PL.6245	PL.6244	ABC	#4/0 ACSR	7.22Y	120.3	0.08	4.70	110.90	33	2340	544	97	1.11	0.0	2.462	0.068	10	2	3	574
PL.6240	PL.6245	ABC	#4/0 ACSR	7.22Y	120.3	0.04	4.74	110.42	32	2329	540	97	0.61	0.0	2.500	0.038	0	0	0	571
PL.5766	PL.6240	ABC	#4/0 ACSR	7.21Y	120.2	0.06	4.80	110.17	32	2323	538	97	0.80	0.0	2.549	0.050	0	0	0	570
PL.6599	PL.5766	C	6 A (CWC)	7.21Y	120.2	0.00	4.80	4.12	3	29	6	98	0.00	0.0	2.554	0.005	0	0	0	7
PD.1330	PL.6599	C	65T	7.21Y	120.2	0.00	4.80	4.12	0	29	6	98	0.00	0.0	2.554	0.005	0	0	0	7
PL.6600	PD.1330	C	6 A (CWC)	7.21Y	120.2	0.01	4.81	4.12	3	29	6	98	0.00	0.0	2.600	0.046	6	1	3	7
PL.5474	PL.6600	C	6 A (CWC)	7.21Y	120.2	0.00	4.81	3.30	2	23	5	98	0.00	0.0	2.613	0.013	0	0	0	4
PL.6241	PL.5474	C	6 A (CWC)	7.21Y	120.2	0.00	4.81	2.58	2	18	4	98	0.00	0.0	2.653	0.040	8	2	1	3
PL.6242	PL.6241	C	6 A (CWC)	7.21Y	120.2	0.00	4.81	1.49	1	10	2	98	0.00	0.0	2.672	0.019	10	2	2	2
PL.5475	PL.6242	C	6 A (CWC)	7.21Y	120.2	0.00	4.81	0.73	1	5	1	98	0.00	0.0	2.669	0.056	5	1	1	1
PL.5767	PL.5475	ABC	#4/0 ACSR	7.21Y	120.1	0.06	4.86	108.80	32	2293	530	97	0.83	0.0	2.602	0.053	3	1	1	563
PL.6021	PL.5767	ABC	#4/0 ACSR	7.21Y	120.1	0.02	4.87	108.53	32	2287	528	97	0.23	0.0	2.617	0.015	18	4	1	561
PL.6430	PL.6021	ABC	#1/0 ACSR	7.21Y	120.1	0.03	4.90	16.43	7	348	74	98	0.07	0.0	2.718	0.101	1	0	1	96
PL.6431	PL.6430	ABC	#1/0 ACSR	7.21Y	120.1	0.01	4.91	16.37	7	346	73	98	0.02	0.0	2.745	0.027	0	0	1	95
PL.6832	PL.6431	ABC	#1/0 ACSR	7.20Y	120.1	0.01	4.92	16.37	7	346	73	98	0.03	0.0	2.782	0.037	0	0	0	94
PL.7203	PL.6832	ABC	#1/0 ACSR	7.20Y	120.1	0.00	4.92	16.37	7	346	73	98	0.00	0.0	2.784	0.002	0	0	0	94
PD.1546	PL.7203	ABC	50L	7.20Y	120.1	0.00	4.92	16.37	33	346	73	98	0.00	0.0	2.784	0.002	0	0	0	94
PL.7204	PD.1546	ABC	#1/0 ACSR	7.20Y	120.1	0.01	4.93	16.37	7	346	73	98	0.03	0.0	2.829	0.045	3	1	1	94
PL.6428	PL.7204	ABC	#1/0 ACSR	7.20Y	120.0	0.03	4.96	15.81	7	334	71	98	0.07	0.0	2.932	0.103	8	2	1	90
PL.6429	PL.6428	ABC	#1/0 ACSR	7.20Y	120.0	0.01	4.97	15.43	7	326	69	98	0.02	0.0	2.972	0.039	10	2	2	89
PL.6427	PL.6429	ABC	#1/0 ACSR	7.20Y	120.0	0.01	4.98	14.97	7	317	67	98	0.03	0.0	3.020	0.049	0	0	1	87
PL.6426	PL.6427	ABC	#1/0 ACSR	7.20Y	120.0	0.04	5.03	14.97	7	317	67	98	0.09	0.0	3.178	0.158	5	1	2	86
PL.6425	PL.6426	ABC	#1/0 ACSR	7.20Y	120.0	0.01	5.04	14.72	6	311	66	98	0.03	0.0	3.234	0.056	1	0	1	84
PL.6424	PL.6425	ABC	#1/0 ACSR	7.20Y	119.9	0.02	5.06	14.69	6	310	65	98	0.04	0.0	3.305	0.071	0	0	0	83
PL.6038	PL.6424	ABC	#1/0 ACSR	7.20Y	119.9	0.02	5.08	14.21	6	300	63	98	0.05	0.0	3.396	0.091	8	2	1	82
PL.6703	PL.6038	B	#2 ACSR	7.20Y	119.9	0.00	5.08	0.84	0	6	1	99	0.00	0.0	3.401	0.005	0	0	0	1
PD.1385	PL.6703	B	20T	7.20Y	119.9	0.00	5.08	0.84	0	6	1	99	0.00	0.0	3.401	0.005	0	0	0	1
PL.6704	PD.1385	B	#2 ACSR	7.20Y	119.9	0.00	5.08	0.84	0	6	1	99	0.00	0.0	3.425	0.024	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6039	PL.6038	ABC	#1/0 ACSR	7.19Y	119.9	0.02	5.10	13.53	6	286	60	98	0.04	0.0	3.470	0.074	0	0	0	80
PL.6421	PL.6039	ABC	#1/0 ACSR	7.19Y	119.9	0.02	5.11	12.39	5	262	55	98	0.03	0.0	3.550	0.079	1	0	1	75
PL.6422	PL.6421	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.12	12.36	5	261	55	98	0.02	0.0	3.591	0.041	10	2	2	74
PL.6420	PL.6422	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.14	11.89	5	251	53	98	0.03	0.0	3.662	0.071	16	3	2	72
PL.6051	PL.6420	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.15	10.58	5	223	47	98	0.02	0.0	3.726	0.064	10	2	2	66
PL.6417	PL.6051	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.15	9.42	4	199	42	98	0.01	0.0	3.751	0.025	8	2	1	61
PL.6418	PL.6417	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.16	9.05	4	191	40	98	0.01	0.0	3.801	0.051	6	1	2	60
PL.6416	PL.6418	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.17	8.75	4	185	39	98	0.01	0.0	3.835	0.034	1	0	1	58
PL.6415	PL.6416	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.18	8.69	4	184	39	98	0.01	0.0	3.897	0.062	2	0	1	57
PL.6414	PL.6415	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.19	8.62	4	182	38	98	0.01	0.0	3.970	0.073	0	0	1	56
PL.5516	PL.6414	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.20	8.27	4	174	37	98	0.02	0.0	4.059	0.089	10	2	7	54
PL.6070	PL.5516	ABC	#1/0 ACSR	7.19Y	119.8	0.02	5.22	6.90	3	146	31	98	0.02	0.0	4.204	0.145	7	2	6	45
PL.6695	PL.6070	C	6 A (CWC)	7.19Y	119.8	0.00	5.22	8.00	6	56	12	98	0.00	0.0	4.208	0.005	0	0	0	18
PD.1381	PL.6695	C	20T	7.19Y	119.8	0.00	5.22	8.00	0	56	12	98	0.00	0.0	4.208	0.005	0	0	0	18
PL.6696	PD.1381	C	6 A (CWC)	7.18Y	119.7	0.04	5.26	8.00	6	56	12	98	0.02	0.0	4.324	0.116	8	2	2	18
PL.6083	PL.6696	C	#2 ACSR	7.18Y	119.7	0.01	5.26	6.92	4	49	10	98	0.00	0.0	4.367	0.043	2	0	2	16
PL.6408	PL.6083	C	#4 ACSR	7.18Y	119.7	0.01	5.28	5.23	4	37	8	98	0.00	0.0	4.419	0.052	1	0	1	10
PL.6409	PL.6408	C	#4 ACSR	7.18Y	119.7	0.01	5.28	5.09	4	36	8	98	0.00	0.0	4.447	0.028	7	1	1	9
PL.6407	PL.6409	C	#4 ACSR	7.18Y	119.7	0.01	5.29	4.16	3	29	6	98	0.00	0.0	4.486	0.038	0	0	0	8
PL.5770	PL.6407	C	#4 ACSR	7.18Y	119.7	0.00	5.29	3.07	2	22	5	98	0.00	0.0	4.511	0.025	12	3	3	5
PL.5486	PL.5770	C	6 A (CWC)	7.18Y	119.7	0.00	5.30	1.37	1	10	2	98	0.00	0.0	4.588	0.076	0	0	1	2
PL.5488	PL.5486	C	#2 ACSR	7.18Y	119.7	0.00	5.30	1.37	1	10	2	98	0.00	0.0	4.639	0.052	10	2	1	1
PL.6405	PL.6407	C	#4 ACSR	7.18Y	119.7	0.00	5.29	1.09	1	8	2	97	0.00	0.0	4.513	0.027	1	0	2	3
PL.6406	PL.6405	C	#4 ACSR	7.18Y	119.7	0.00	5.29	0.99	1	7	1	99	0.00	0.0	4.540	0.027	0	0	0	1
PL.5487	PL.6406	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	0.99	1	7	1	99	0.00	0.0	4.566	0.026	7	1	1	1
PL.6403	PL.6083	C	#2 ACSR	7.18Y	119.7	0.00	5.27	1.41	1	10	2	98	0.00	0.0	4.428	0.061	6	1	2	4
PL.6404	PL.6403	C	#2 ACSR	7.18Y	119.7	0.00	5.27	0.63	0	4	1	97	0.00	0.0	4.509	0.080	4	1	2	2
PL.6402	PL.6404	C	#2 ACSR	7.18Y	119.7	0.00	5.27	0.00	0	0	0	100	0.00	0.0	4.532	0.024	0	0	0	0
PL.6769	PL.6070	A	6 A (CWC)	7.19Y	119.8	0.00	5.22	11.65	8	82	17	98	0.00	0.0	4.209	0.005	0	0	0	21
PD.1422	PL.6769	A	20T	7.19Y	119.8	0.00	5.22	11.65	0	82	17	98	0.00	0.0	4.209	0.005	0	0	0	21
PL.6770	PD.1422	A	6 A (CWC)	7.19Y	119.8	0.02	5.24	11.65	8	82	17	98	0.01	0.0	4.250	0.041	7	1	1	21

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6412	PL.6770	A	#4 ACSR	7.19Y	119.8	0.01	5.25	2.42	2	17	4	97	0.00	0.0	4.327	0.078	4	1	1	2
PL.6413	PL.6412	A	#4 ACSR	7.18Y	119.7	0.00	5.25	1.91	1	13	3	97	0.00	0.0	4.434	0.107	13	3	1	1
PL.5508	PL.6770	A	6 A (CWC)	7.18Y	119.7	0.03	5.27	8.27	6	58	12	98	0.01	0.0	4.343	0.093	6	1	2	18
PL.5492	PL.5508	A	#4 ACSR	7.18Y	119.7	0.00	5.27	0.00	0	0	0	100	0.00	0.0	4.385	0.042	0	0	0	0
PL.5484	PL.5508	A	6 A (CWC)	7.18Y	119.7	0.00	5.27	0.53	0	4	1	97	0.00	0.0	4.399	0.057	4	1	1	1
PL.5509	PL.5508	A	6 A (CWC)	7.18Y	119.7	0.03	5.30	6.91	5	49	10	98	0.01	0.0	4.439	0.096	6	1	2	15
PL.5482	PL.5509	A	#1/0 ACSR	7.18Y	119.7	0.00	5.30	2.37	1	17	3	98	0.00	0.0	4.464	0.025	17	3	5	5
PL.5485	PL.5509	A	6 A (CWC)	7.18Y	119.7	0.01	5.31	1.35	1	9	2	98	0.00	0.0	4.565	0.127	3	1	1	6
PL.5494	PL.5485	A	#4 ACSR	7.18Y	119.7	0.01	5.31	0.96	1	7	1	99	0.00	0.0	4.721	0.156	0	0	0	5
PL.5483	PL.5494	A	6 A (CWC)	7.18Y	119.7	0.00	5.31	0.00	0	0	0	100	0.00	0.0	4.789	0.067	0	0	0	0
PL.5769	PL.5494	A	#4 ACSR	7.18Y	119.7	0.00	5.31	0.96	1	7	1	99	0.00	0.0	4.783	0.062	7	1	5	5
PL.5493	PL.5509	A	#4 ACSR	7.18Y	119.7	0.00	5.30	2.34	2	16	3	98	0.00	0.0	4.485	0.047	8	2	1	2
PL.6410	PL.5493	A	6 A (CWC)	7.18Y	119.7	0.00	5.30	1.13	1	8	2	97	0.00	0.0	4.514	0.029	8	2	1	1
PL.6411	PL.6410	A	6 A (CWC)	7.18Y	119.7	0.00	5.30	0.00	0	0	0	100	0.00	0.0	4.552	0.038	0	0	0	0
PL.6697	PL.5516	C	#2 ACSR	7.19Y	119.8	0.00	5.20	2.66	2	19	4	98	0.00	0.0	4.064	0.005	0	0	0	2
PD.1382	PL.6697	C	20T	7.19Y	119.8	0.00	5.20	2.66	0	19	4	98	0.00	0.0	4.064	0.005	0	0	0	2
PL.6698	PD.1382	C	#2 ACSR	7.19Y	119.8	0.00	5.20	2.66	2	19	4	98	0.00	0.0	4.104	0.040	0	0	0	2
PL.5768	PL.6698	C	#2 ACSR	7.19Y	119.8	0.00	5.20	0.59	0	4	1	97	0.00	0.0	4.140	0.036	4	1	1	1
PL.5481	PL.6698	C	#1/0 ACSR	7.19Y	119.8	0.00	5.20	2.07	1	15	3	98	0.00	0.0	4.163	0.060	15	3	1	1
PL.6699	PL.6414	A	#4 ACSR	7.19Y	119.8	0.00	5.19	1.04	1	7	2	96	0.00	0.0	3.975	0.005	0	0	0	1
PD.1383	PL.6699	A	20T	7.19Y	119.8	0.00	5.19	1.04	0	7	2	96	0.00	0.0	3.975	0.005	0	0	0	1
PL.6700	PD.1383	A	#4 ACSR	7.19Y	119.8	0.00	5.19	1.04	1	7	2	96	0.00	0.0	4.043	0.069	7	2	1	1
PL.6767	PL.6051	A	#4 ACSR	7.19Y	119.9	0.00	5.15	2.14	2	15	3	98	0.00	0.0	3.731	0.005	0	0	0	3
PD.1421	PL.6767	A	20T	7.19Y	119.9	0.00	5.15	2.14	0	15	3	98	0.00	0.0	3.731	0.005	0	0	0	3
PL.6768	PD.1421	A	#4 ACSR	7.19Y	119.8	0.00	5.15	2.14	2	15	3	98	0.00	0.0	3.793	0.063	5	1	1	3
PL.6054	PL.6768	A	#4 ACSR	7.19Y	119.8	0.00	5.15	0.54	0	4	1	97	0.00	0.0	3.843	0.049	4	1	1	1
PL.5478	PL.6768	A	#4 ACSR	7.19Y	119.8	0.00	5.16	0.81	1	6	1	99	0.00	0.0	3.834	0.041	6	1	1	1
PL.6765	PL.6420	C	#4 ACSR	7.19Y	119.9	0.00	5.14	1.69	1	12	2	99	0.00	0.0	3.667	0.005	0	0	0	4
PD.1420	PL.6765	C	20T	7.19Y	119.9	0.00	5.14	1.69	0	12	2	99	0.00	0.0	3.667	0.005	0	0	0	4
PL.6766	PD.1420	C	#4 ACSR	7.19Y	119.9	0.01	5.14	1.69	1	12	2	99	0.00	0.0	3.787	0.120	5	1	2	4
PL.6419	PL.6766	C	#4 ACSR	7.19Y	119.9	0.00	5.15	0.91	1	6	1	99	0.00	0.0	3.820	0.033	6	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6763	PL.6039	A	6 A (CWC)	7.19Y	119.9	0.00	5.10	1.55	1	11	2	98	0.00	0.0	3.475	0.005	0	0	0	3
PD.1419	PL.6763	A	20T	7.19Y	119.9	0.00	5.10	1.55	0	11	2	98	0.00	0.0	3.475	0.005	0	0	0	3
PL.6764	PD.1419	A	6 A (CWC)	7.19Y	119.9	0.00	5.10	1.55	1	11	2	98	0.00	0.0	3.569	0.094	11	2	2	3
PL.6423	PL.6764	A	6 A (CWC)	7.19Y	119.9	0.00	5.10	0.00	0	0	0	100	0.00	0.0	3.601	0.032	0	0	0	1
PL.5477	PL.6423	A	#4 ACSR	7.19Y	119.9	0.00	5.10	0.00	0	0	0	100	0.00	0.0	3.656	0.055	0	0	1	1
PL.6701	PL.6039	C	6 A (CWC)	7.19Y	119.9	0.00	5.10	1.88	1	13	3	97	0.00	0.0	3.475	0.005	0	0	0	2
PD.1384	PL.6701	C	20T	7.19Y	119.9	0.00	5.10	1.88	0	13	3	97	0.00	0.0	3.475	0.005	0	0	0	2
PL.6702	PD.1384	C	6 A (CWC)	7.19Y	119.9	0.00	5.10	1.88	1	13	3	97	0.00	0.0	3.499	0.024	13	3	2	2
PL.6705	PL.6424	C	#2 ACSR	7.20Y	119.9	0.00	5.06	1.43	1	10	2	98	0.00	0.0	3.310	0.005	0	0	0	1
PD.1386	PL.6705	C	20T	7.20Y	119.9	0.00	5.06	1.43	0	10	2	98	0.00	0.0	3.310	0.005	0	0	0	1
PL.6706	PD.1386	C	#2 ACSR	7.20Y	119.9	0.00	5.06	1.43	1	10	2	98	0.00	0.0	3.346	0.036	10	2	1	1
PL.6707	PL.7204	A	#4 ACSR	7.20Y	120.1	0.00	4.93	1.19	1	8	2	97	0.00	0.0	2.834	0.005	0	0	0	3
PD.1387	PL.6707	A	20T	7.20Y	120.1	0.00	4.93	1.19	0	8	2	97	0.00	0.0	2.834	0.005	0	0	0	3
PL.6708	PD.1387	A	#4 ACSR	7.20Y	120.1	0.00	4.94	1.19	1	8	2	97	0.00	0.0	2.886	0.052	8	2	3	3
PL.5476	PL.6021	ABC	6 A (CWC)	7.21Y	120.1	0.00	4.87	0.78	1	16	3	98	0.00	0.0	2.671	0.054	16	3	5	5
PL.6022	PL.6021	ABC	#4/0 ACSR	7.21Y	120.1	0.02	4.89	90.49	27	1905	447	97	0.25	0.0	2.640	0.023	7	1	1	459
PL.6237	PL.6022	ABC	#4/0 ACSR	7.20Y	120.0	0.07	4.96	90.16	27	1898	445	97	0.83	0.0	2.717	0.077	9	2	2	458
PL.6238	PL.6237	ABC	#4/0 ACSR	7.20Y	119.9	0.10	5.06	89.74	26	1888	441	97	1.17	0.1	2.825	0.108	0	0	0	456
PL.6235	PL.6238	ABC	#4/0 ACSR	7.19Y	119.9	0.08	5.15	89.43	26	1880	438	97	1.00	0.1	2.919	0.093	1	0	1	454
PL.6236	PL.6235	ABC	#4/0 ACSR	7.19Y	119.8	0.10	5.24	89.37	26	1878	436	97	1.13	0.1	3.025	0.106	16	3	3	453
PL.7206	PL.6236	A	#2 ACSR	7.19Y	119.8	0.00	5.24	0.00	0	0	0	100	0.00	0.0	3.030	0.005	0	0	0	0
PL.6591	PL.6236	C	#4 ACSR	7.19Y	119.8	0.00	5.24	1.55	1	11	2	98	0.00	0.0	3.030	0.005	0	0	0	2
PD.1326	PL.6591	C	65T	7.19Y	119.8	0.00	5.24	1.55	0	11	2	98	0.00	0.0	3.030	0.005	0	0	0	2
PL.6592	PD.1326	C	#4 ACSR	7.19Y	119.8	0.00	5.25	1.55	1	11	2	98	0.00	0.0	3.057	0.028	11	2	2	2
PL.6028	PL.6236	ABC	#4/0 ACSR	7.18Y	119.7	0.05	5.29	88.08	26	1850	428	97	0.54	0.0	3.077	0.052	0	0	0	448
PL.6593	PL.6028	C	#2 ACSR	7.18Y	119.7	0.00	5.29	2.66	2	19	4	98	0.00	0.0	3.082	0.004	0	0	0	4
PD.1327	PL.6593	C	65T	7.18Y	119.7	0.00	5.29	2.66	0	19	4	98	0.00	0.0	3.082	0.004	0	0	0	4
PL.6594	PD.1327	C	#2 ACSR	7.18Y	119.7	0.00	5.29	2.66	2	19	4	98	0.00	0.0	3.108	0.026	8	2	2	4
PL.6218	PL.6594	C	#2 ACSR	7.18Y	119.7	0.00	5.29	1.46	1	10	2	98	0.00	0.0	3.141	0.033	10	2	2	2
PL.5771	PL.6028	ABC	#4/0 ACSR	7.18Y	119.6	0.09	5.38	87.19	26	1831	423	97	1.03	0.1	3.179	0.101	0	0	0	444
PL.6771	PL.5771	A	6 A (CWC)	7.18Y	119.6	0.00	5.38	1.56	1	11	2	98	0.00	0.0	3.184	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1423	PL.6771	A	65T	7.18Y	119.6	0.00	5.38	1.56	0	11	2	98	0.00	0.0	3.184	0.005	0	0	0	2
PL.6772	PD.1423	A	6 A (CWC)	7.18Y	119.6	0.00	5.38	1.56	1	11	2	98	0.00	0.0	3.232	0.048	11	2	2	2
PL.6589	PL.5771	C	6 A (CWC)	7.18Y	119.6	0.00	5.38	0.57	0	4	1	97	0.00	0.0	3.183	0.005	0	0	0	1
PD.1325	PL.6589	C	65T	7.18Y	119.6	0.00	5.38	0.57	0	4	1	97	0.00	0.0	3.183	0.005	0	0	0	1
PL.6590	PD.1325	C	6 A (CWC)	7.18Y	119.6	0.00	5.38	0.57	0	4	1	97	0.00	0.0	3.207	0.023	4	1	1	1
PL.6032	PL.5771	ABC	#4/0 ACSR	7.17Y	119.6	0.07	5.45	86.48	25	1815	418	97	0.74	0.0	3.253	0.074	3	1	1	441
PL.6587	PL.6032	C	#4 ACSR	7.17Y	119.6	0.00	5.45	2.92	2	21	4	98	0.00	0.0	3.258	0.005	0	0	0	4
PD.1324	PL.6587	C	65T	7.17Y	119.6	0.00	5.45	2.92	0	21	4	98	0.00	0.0	3.258	0.005	0	0	0	4
PL.6588	PD.1324	C	#4 ACSR	7.17Y	119.6	0.00	5.45	2.92	2	21	4	98	0.00	0.0	3.286	0.028	21	4	4	4
PL.6033	PL.6032	ABC	#4/0 ACSR	7.17Y	119.6	0.00	5.45	85.38	25	1791	412	97	0.03	0.0	3.256	0.003	0	0	0	436
PL.5489	PL.6033	ABC	#4/0 ACSR	7.17Y	119.5	0.08	5.53	85.38	25	1791	412	97	0.88	0.0	3.347	0.090	0	0	0	436
PL.6585	PL.5489	A	#4 ACSR	7.17Y	119.5	0.00	5.53	0.07	0	1	0	100	0.00	0.0	3.351	0.005	0	0	0	1
PD.1323	PL.6585	A	65T	7.17Y	119.5	0.00	5.53	0.07	0	1	0	100	0.00	0.0	3.351	0.005	0	0	0	1
PL.6586	PD.1323	A	#4 ACSR	7.17Y	119.5	0.00	5.53	0.07	0	1	0	100	0.00	0.0	3.392	0.041	1	0	1	1
PL.6217	PL.6586	A	#4 ACSR	7.17Y	119.5	0.00	5.53	0.00	0	0	0	100	0.00	0.0	3.455	0.063	0	0	0	0
PL.5772	PL.5489	ABC	#4/0 ACSR	7.16Y	119.4	0.08	5.60	85.35	25	1789	410	97	0.86	0.0	3.435	0.088	7	1	1	435
PL.5497	PL.5772	A	6 A (CWC)	7.16Y	119.4	0.00	5.61	22.95	16	161	34	98	0.00	0.0	3.438	0.003	0	0	0	38
PD.1452	PL.5497	A	50L	7.16Y	119.4	0.00	5.61	22.95	46	161	34	98	0.00	0.0	3.438	0.003	0	0	0	38
PL.6034	PD.1452	A	6 A (CWC)	7.16Y	119.4	0.00	5.61	0.04	0	0	0	100	0.00	0.0	3.442	0.004	0	0	0	1
PL.5491	PL.6034	A	6 A (CWC)	7.16Y	119.4	0.00	5.61	0.04	0	0	0	100	0.00	0.0	3.527	0.085	0	0	1	1
PL.6192	PD.1452	A	6 A (CWC)	7.16Y	119.3	0.08	5.69	22.91	16	161	34	98	0.10	0.1	3.523	0.085	10	2	2	37
PL.6193	PL.6192	A	6 A (CWC)	7.16Y	119.3	0.05	5.74	21.46	15	150	32	98	0.06	0.0	3.573	0.051	0	0	0	35
PL.6188	PL.6193	A	6 A (CWC)	7.15Y	119.2	0.06	5.79	21.46	15	150	32	98	0.06	0.0	3.632	0.059	6	1	2	35
PL.5499	PL.6188	A	#2 ACSR	7.15Y	119.2	0.00	5.79	0.49	0	3	1	95	0.00	0.0	3.691	0.059	3	1	1	1
PL.6189	PL.6188	A	6 A (CWC)	7.15Y	119.2	0.02	5.81	9.93	7	70	15	98	0.01	0.0	3.668	0.036	3	1	1	18
PL.6190	PL.6189	A	6 A (CWC)	7.15Y	119.2	0.02	5.83	9.44	7	66	14	98	0.01	0.0	3.718	0.050	3	1	1	17
PL.6191	PL.6190	A	6 A (CWC)	7.15Y	119.2	0.01	5.84	9.07	6	63	13	98	0.01	0.0	3.747	0.029	0	0	0	16
PL.6179	PL.6191	A	6 A (CWC)	7.15Y	119.1	0.01	5.86	7.41	5	52	11	98	0.01	0.0	3.793	0.046	10	2	2	10
PL.6180	PL.6179	A	6 A (CWC)	7.15Y	119.1	0.02	5.88	6.00	4	42	9	98	0.01	0.0	3.883	0.090	0	0	1	8
PL.6181	PL.6180	A	6 A (CWC)	7.15Y	119.1	0.02	5.90	5.96	4	42	9	98	0.01	0.0	3.958	0.076	12	3	2	7
PL.6182	PL.6181	A	#1/0 ACSR	7.15Y	119.1	0.00	5.90	2.77	1	19	4	98	0.00	0.0	3.999	0.041	10	2	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PL.6183	PL.6182	A	#1/0 ACSR	7.15Y	119.1	0.00	5.90	1.31	1	9	2	98	0.00	0.0	4.036	0.037	9	2	1	1
PL.6050	PL.6181	A	6 A (CWC)	7.15Y	119.1	0.00	5.90	1.49	1	10	2	98	0.00	0.0	4.026	0.068	10	2	2	2
PL.5501	PL.6191	A	6 A (CWC)	7.15Y	119.2	0.00	5.85	1.66	1	12	2	99	0.00	0.0	3.836	0.089	12	2	4	6
PL.5502	PL.5501	A	#4 ACSR	7.15Y	119.2	0.00	5.85	0.00	0	0	0	100	0.00	0.0	3.874	0.037	0	0	2	2
PL.6186	PL.6188	A	6 A (CWC)	7.15Y	119.2	0.05	5.85	10.12	7	71	15	98	0.03	0.0	3.745	0.113	0	0	0	14
PL.6187	PL.6186	A	6 A (CWC)	7.15Y	119.1	0.02	5.87	10.12	7	71	15	98	0.01	0.0	3.789	0.044	0	0	0	14
PL.5500	PL.6187	A	#2 ACSR	7.15Y	119.1	0.00	5.87	0.59	0	4	1	97	0.00	0.0	3.825	0.036	4	1	1	1
PL.6184	PL.6187	A	6 A (CWC)	7.14Y	119.1	0.06	5.92	9.53	7	67	14	98	0.03	0.0	3.935	0.146	6	1	2	13
PL.6185	PL.6184	A	6 A (CWC)	7.14Y	119.0	0.03	5.95	8.62	6	60	13	98	0.01	0.0	4.005	0.070	6	1	2	11
PL.6176	PL.6185	A	6 A (CWC)	7.14Y	119.0	0.05	6.00	7.73	6	54	11	98	0.02	0.0	4.136	0.131	0	0	0	9
PL.6177	PL.6176	A	6 A (CWC)	7.14Y	119.0	0.02	6.02	7.73	6	54	11	98	0.01	0.0	4.206	0.069	10	2	1	9
PL.6178	PL.6177	A	6 A (CWC)	7.14Y	119.0	0.02	6.03	6.27	4	44	9	98	0.01	0.0	4.259	0.054	0	0	0	8
PL.5503	PL.6178	A	#4 ACSR	7.14Y	119.0	0.00	6.03	0.13	0	1	0	100	0.00	0.0	4.366	0.107	0	0	0	1
PL.5844	PL.5503	A	#4 ACSR	7.14Y	119.0	0.00	6.03	0.13	0	1	0	100	0.00	0.0	4.484	0.118	1	0	1	1
PL.5773	PL.6178	A	6 A (CWC)	7.14Y	118.9	0.03	6.06	6.15	4	43	9	98	0.01	0.0	4.358	0.099	0	0	0	7
PL.5845	PL.5773	A	6 A (CWC)	7.13Y	118.9	0.03	6.09	6.15	4	43	9	98	0.01	0.0	4.461	0.102	0	0	0	7
PL.6027	PL.5845	A	6 A (CWC)	7.13Y	118.9	0.02	6.11	6.15	4	43	9	98	0.01	0.0	4.533	0.072	0	0	0	7
PL.6029	PL.6027	A	6 A (CWC)	7.13Y	118.9	0.01	6.12	5.43	4	38	8	98	0.00	0.0	4.593	0.060	3	1	1	6
PL.6164	PL.6029	A	6 A (CWC)	7.13Y	118.9	0.01	6.13	4.11	3	29	6	98	0.00	0.0	4.666	0.073	8	2	1	3
PL.6165	PL.6164	A	6 A (CWC)	7.13Y	118.9	0.01	6.14	2.93	2	20	4	98	0.00	0.0	4.725	0.059	0	0	0	2
PL.5273	PL.6165	A	#1/0 ACSR	7.13Y	118.9	0.00	6.14	1.62	1	11	2	98	0.00	0.0	4.791	0.065	11	2	1	1
PL.6030	PL.6165	A	6 A (CWC)	7.13Y	118.9	0.00	6.14	1.32	1	9	2	98	0.00	0.0	4.755	0.029	9	2	1	1
PL.5272	PL.6029	A	#2 ACSR	7.13Y	118.9	0.00	6.12	0.93	1	6	1	99	0.00	0.0	4.642	0.049	6	1	2	2
PL.5270	PL.6027	A	#4 ACSR	7.13Y	118.9	0.00	6.11	0.71	1	5	1	98	0.00	0.0	4.558	0.025	5	1	1	1
PL.5271	PL.5845	A	#4 ACSR	7.13Y	118.9	0.00	6.09	0.00	0	0	0	100	0.00	0.0	4.497	0.036	0	0	0	0
PL.5498	PL.5772	ABC	#4/0 ACSR	7.15Y	119.1	0.27	5.87	77.39	23	1621	373	97	2.77	0.2	3.781	0.346	0	0	0	396
PL.6575	PL.5498	A	#4 ACSR	7.15Y	119.1	0.00	5.87	1.03	1	7	2	96	0.00	0.0	3.786	0.005	0	0	0	1
PD.1318	PL.6575	A	65T	7.15Y	119.1	0.00	5.87	1.03	0	7	2	96	0.00	0.0	3.786	0.005	0	0	0	1
PL.6576	PD.1318	A	#4 ACSR	7.15Y	119.1	0.00	5.88	1.03	1	7	2	96	0.00	0.0	3.843	0.058	7	2	1	1
PL.5774	PL.5498	ABC	#4/0 ACSR	7.14Y	119.1	0.07	5.95	77.05	23	1611	367	98	0.76	0.0	3.876	0.095	0	0	0	395
PL.6577	PL.5774	C	#4 ACSR	7.14Y	119.1	0.00	5.95	1.17	1	8	2	97	0.00	0.0	3.881	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PD.1319	PL.6577	C	65T	7.14Y	119.1	0.00	5.95	1.17	0	8	2	97	0.00	0.0	3.881	0.005	0	0	0	2
PL.6578	PD.1319	C	#4 ACSR	7.14Y	119.1	0.00	5.95	1.17	1	8	2	97	0.00	0.0	3.938	0.057	8	2	2	2
PL.5775	PL.5774	ABC	#4/0 ACSR	7.13Y	118.9	0.14	6.09	76.66	23	1602	364	98	1.45	0.1	4.062	0.185	0	0	1	393
PL.6201	PL.5775	ABC	#4/0 ACSR	7.13Y	118.8	0.08	6.17	76.65	23	1600	361	98	0.79	0.0	4.162	0.101	0	0	0	392
PL.5274	PL.6201	ABC	#4/0 ACSR	7.13Y	118.8	0.06	6.23	68.36	20	1424	332	97	0.55	0.0	4.251	0.089	5	1	2	353
PL.6811	PL.5274	A	#4 ACSR	7.13Y	118.8	0.01	6.24	54.11	42	377	81	98	0.02	0.0	4.253	0.003	0	0	0	63
C PD.1445	PL.6811	A	50L	7.13Y	118.8	0.00	6.24	54.11	108	377	81	98	0.00	0.0	4.253	0.003	0	0	0	63 C
PL.6812	PD.1445	A	#4 ACSR	7.10Y	118.3	0.49	6.72	54.11	42	377	81	98	1.44	0.4	4.458	0.205	0	0	0	63
PL.5275	PL.6812	A	#1/0 ACSR	7.10Y	118.3	0.00	6.72	1.54	1	11	2	98	0.00	0.0	4.485	0.027	11	2	1	1
PL.6202	PL.6812	A	6 A (CWC)	7.10Y	118.3	0.00	6.73	1.15	1	8	2	97	0.00	0.0	4.555	0.096	0	0	0	2
PL.6203	PL.6202	A	6 A (CWC)	7.10Y	118.3	0.00	6.73	1.15	1	8	2	97	0.00	0.0	4.603	0.048	8	2	2	2
L PL.5276	PL.6812	A	#4 ACSR	7.03Y	117.1	1.19	7.91	51.42	40	357	77	98	3.35	0.9	4.986	0.528	0	0	0	60 L
L PL.5278	PL.5276	A	6 A (CWC)	7.02Y	117.1	0.01	7.92	1.21	1	8	2	97	0.00	0.0	5.097	0.111	0	0	0	2 L
L PL.5280	PL.5278	A	6 A (CWC)	7.02Y	117.1	0.00	7.92	0.54	0	4	1	97	0.00	0.0	5.186	0.089	0	0	0	1 L
L PL.5281	PL.5280	A	#1/0 ACSR	7.02Y	117.1	0.00	7.92	0.54	0	4	1	97	0.00	0.0	5.223	0.037	4	1	1	1 L
L PL.6094	PL.5278	A	6 A (CWC)	7.02Y	117.1	0.00	7.92	0.67	0	5	1	98	0.00	0.0	5.171	0.073	5	1	1	1 L
L PL.6095	PL.5276	A	#4 ACSR	7.01Y	116.8	0.31	8.22	50.21	39	345	73	98	0.85	0.2	5.128	0.142	4	1	3	58 L
L PL.5277	PL.6095	A	6 A (CWC)	7.01Y	116.8	0.00	8.22	0.00	0	0	0	100	0.00	0.0	5.264	0.136	0	0	0	0 L
L PL.6096	PL.6095	A	#4 ACSR	6.99Y	116.6	0.20	8.42	49.68	38	341	72	98	0.54	0.2	5.219	0.091	0	0	0	55 L
L PL.5279	PL.6096	A	#4 ACSR	6.99Y	116.6	0.00	8.42	3.54	3	24	5	98	0.00	0.0	5.230	0.010	0	0	0	2 L
L PL.6573	PL.5279	A	1/0 AL URD	6.99Y	116.6	0.00	8.42	3.54	2	24	5	98	0.00	0.0	5.234	0.005	0	0	0	2 L
L PD.1317	PL.6573	A	20T	6.99Y	116.6	0.00	8.42	3.54	0	24	5	98	0.00	0.0	5.234	0.005	0	0	0	2 L
L PL.6574	PD.1317	A	1/0 AL URD	6.99Y	116.6	0.00	8.42	3.54	2	24	5	98	0.00	0.0	5.277	0.043	24	5	2	2 L
L PL.6092	PL.6096	A	#4 ACSR	6.98Y	116.3	0.29	8.71	46.14	35	316	66	98	0.72	0.2	5.362	0.142	2	0	1	53 L
L PL.6227	PL.6092	A	#1/0 ACSR	6.98Y	116.3	0.02	8.73	13.53	6	92	19	98	0.02	0.0	5.446	0.085	4	1	1	21 L
L PL.6228	PL.6227	A	#1/0 ACSR	6.98Y	116.3	0.01	8.74	12.97	6	89	19	98	0.01	0.0	5.480	0.033	0	0	0	20 L
L PL.5283	PL.6228	A	#4 ACSR	6.97Y	116.2	0.02	8.76	11.31	9	77	16	98	0.01	0.0	5.515	0.036	3	1	2	19 L
L PL.5287	PL.5283	A	#1/0 ACSR	6.97Y	116.2	0.01	8.77	10.88	5	74	16	98	0.01	0.0	5.558	0.042	0	0	0	17 L
L PL.6209	PL.5287	A	#2 ACSR	6.97Y	116.2	0.00	8.77	2.40	1	16	3	98	0.00	0.0	5.591	0.033	4	1	1	4 L
L PL.6210	PL.6209	A	#2 ACSR	6.97Y	116.2	0.00	8.77	1.84	1	13	3	97	0.00	0.0	5.632	0.042	0	0	0	3 L
L PL.5288	PL.6210	A	#2 ACSR	6.97Y	116.2	0.00	8.77	0.75	0	5	1	98	0.00	0.0	5.759	0.127	5	1	1	1 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.6207	PL.6210	A	#1/0 ACSR	6.97Y	116.2	0.00	8.77	1.10	0	7	2	96	0.00	0.0	5.672	0.040	3	1	1	2 L
L PL.6208	PL.6207	A	#1/0 ACSR	6.97Y	116.2	0.00	8.77	0.68	0	5	1	98	0.00	0.0	5.728	0.056	5	1	1	1 L
L PL.5284	PL.5287	A	#4 ACSR	6.97Y	116.2	0.02	8.79	8.47	7	58	12	98	0.01	0.0	5.616	0.059	14	3	3	13 L
L PL.5915	PL.5284	A	#4 ACSR	6.97Y	116.2	0.01	8.79	6.41	5	44	9	98	0.00	0.0	5.641	0.025	0	0	0	10 L
L PL.5285	PL.5915	A	#2 ACSR	6.97Y	116.2	0.00	8.79	0.00	0	0	0	100	0.00	0.0	5.666	0.025	0	0	3	3 L
L PL.6211	PL.5915	A	#1/0 ACSR	6.97Y	116.2	0.00	8.80	6.41	3	44	9	98	0.00	0.0	5.669	0.028	5	1	1	7 L
L PL.6212	PL.6211	A	#1/0 ACSR	6.97Y	116.2	0.01	8.81	5.61	2	38	8	98	0.00	0.0	5.769	0.100	4	1	1	6 L
L PL.5286	PL.6212	A	#2 ACSR	6.97Y	116.2	0.00	8.81	1.61	1	11	2	98	0.00	0.0	5.869	0.099	3	1	1	2 L
L PL.5289	PL.5286	A	#2 ACSR	6.97Y	116.2	0.00	8.82	1.22	1	8	2	97	0.00	0.0	5.960	0.092	0	0	0	1 L
L PL.5290	PL.5289	A	#1/0 ACSR	6.97Y	116.2	0.00	8.82	1.22	1	8	2	97	0.00	0.0	6.122	0.161	8	2	1	1 L
L PL.6213	PL.6212	A	#1/0 ACSR	6.97Y	116.2	0.00	8.81	3.42	1	23	5	98	0.00	0.0	5.803	0.033	19	4	2	3 L
L PL.6214	PL.6213	A	#1/0 ACSR	6.97Y	116.2	0.00	8.81	0.61	0	4	1	97	0.00	0.0	5.830	0.028	4	1	1	1 L
L PL.5777	PL.6228	A	#1/0 ACSR	6.98Y	116.3	0.00	8.74	1.66	1	11	2	98	0.00	0.0	5.508	0.029	11	2	1	1 L
L PL.6091	PL.6092	A	#4 ACSR	6.98Y	116.3	0.04	8.75	32.30	25	221	46	98	0.07	0.0	5.391	0.029	6	1	1	31 L
L PL.6089	PL.6091	A	#4 ACSR	6.97Y	116.2	0.09	8.84	31.39	24	214	45	98	0.16	0.1	5.461	0.070	13	3	2	30 L
L PL.6090	PL.6089	A	#4 ACSR	6.97Y	116.1	0.04	8.88	22.47	17	153	32	98	0.04	0.0	5.498	0.036	0	0	0	21 L
L PL.5291	PL.6090	A	#1/0 ACSR	6.97Y	116.1	0.00	8.88	1.64	1	11	2	98	0.00	0.0	5.510	0.013	11	2	1	1 L
L PL.6229	PL.6090	A	#4 ACSR	6.96Y	116.1	0.05	8.92	20.83	16	142	30	98	0.05	0.0	5.551	0.053	6	1	2	20 L
L PL.6230	PL.6229	A	#4 ACSR	6.96Y	116.0	0.03	8.95	19.96	15	136	28	98	0.03	0.0	5.581	0.031	4	1	1	18 L
L PL.5292	PL.6230	A	#4 ACSR	6.96Y	116.0	0.00	8.95	3.84	3	26	5	98	0.00	0.0	5.602	0.021	0	0	0	2 L
L PL.6597	PL.5292	A	1/0 AL URD	6.96Y	116.0	0.00	8.95	2.46	1	17	3	98	0.00	0.0	5.607	0.005	0	0	0	1 L
L PD.1329	PL.6597	A	20T	6.96Y	116.0	0.00	8.95	2.46	0	17	3	98	0.00	0.0	5.607	0.005	0	0	0	1 L
L PL.6598	PD.1329	A	1/0 AL URD	6.96Y	116.0	0.00	8.96	2.46	1	17	3	98	0.00	0.0	5.634	0.027	17	4	1	1 L
L PL.5300	PL.5292	A	#4 ACSR	6.96Y	116.0	0.00	8.96	1.38	1	9	2	98	0.00	0.0	5.649	0.047	9	2	1	1 L
L PL.5293	PL.6230	A	#4 ACSR	6.96Y	116.0	0.03	8.98	15.51	12	106	22	98	0.02	0.0	5.623	0.042	0	0	0	15 L
L PL.6087	PL.5293	A	#4 ACSR	6.96Y	116.0	0.02	9.00	13.35	10	91	19	98	0.02	0.0	5.665	0.042	13	3	1	14 L
L PL.5294	PL.6087	A	#2 ACSR	6.96Y	116.0	0.00	9.00	1.21	1	8	2	97	0.00	0.0	5.737	0.073	8	2	1	1 L
L PL.6088	PL.6087	A	#4 ACSR	6.96Y	116.0	0.03	9.03	10.28	8	70	15	98	0.02	0.0	5.735	0.070	8	2	1	12 L
L PL.5295	PL.6088	A	#4 ACSR	6.96Y	116.0	0.02	9.05	9.14	7	62	13	98	0.01	0.0	5.778	0.043	0	0	0	11 L
L PL.5296	PL.5295	A	#2 ACSR	6.96Y	116.0	0.00	9.05	0.50	0	3	1	95	0.00	0.0	5.816	0.037	3	1	2	2 L
L PL.5297	PL.5295	A	#4 ACSR	6.96Y	115.9	0.01	9.06	8.64	7	59	12	98	0.01	0.0	5.812	0.033	0	0	0	9 L

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
L PL.6084	PL.5297	A	#4 ACSR	6.96Y	115.9	0.01	9.08	6.48	5	44	9	98	0.00	0.0	5.860	0.048	0	0	0	7 L
L PL.5298	PL.6084	A	#4 ACSR	6.96Y	115.9	0.00	9.08	2.01	2	14	3	98	0.00	0.0	5.882	0.022	14	3	1	1 L
L PL.6233	PL.6084	A	#4 ACSR	6.96Y	115.9	0.01	9.08	4.47	3	30	6	98	0.00	0.0	5.893	0.033	6	1	2	6 L
L PL.6234	PL.6233	A	#4 ACSR	6.95Y	115.9	0.01	9.09	3.52	3	24	5	98	0.00	0.0	5.933	0.040	0	0	0	4 L
L PL.6221	PL.6234	A	#4 ACSR	6.95Y	115.9	0.00	9.09	1.09	1	7	2	96	0.00	0.0	5.953	0.020	7	2	2	2 L
L PL.6222	PL.6221	A	#4 ACSR	6.95Y	115.9	0.00	9.09	0.00	0	0	0	100	0.00	0.0	5.999	0.046	0	0	0	0 L
L PL.5299	PL.6234	A	#4 ACSR	6.95Y	115.9	0.00	9.09	2.43	2	17	3	98	0.00	0.0	5.961	0.027	17	3	2	2 L
L PL.6231	PL.5297	A	#4 ACSR	6.96Y	115.9	0.01	9.07	2.15	2	15	3	98	0.00	0.0	5.925	0.114	8	2	1	2 L
L PL.6232	PL.6231	A	#4 ACSR	6.96Y	115.9	0.00	9.07	0.92	1	6	1	99	0.00	0.0	5.956	0.030	6	1	1	1 L
L PL.6595	PL.5293	A	1/0 AL URD	6.96Y	116.0	0.00	8.98	2.15	1	15	3	98	0.00	0.0	5.627	0.005	0	0	0	1 L
L PD.1328	PL.6595	A	20T	6.96Y	116.0	0.00	8.98	2.15	0	15	3	98	0.00	0.0	5.627	0.005	0	0	0	1 L
L PL.6596	PD.1328	A	1/0 AL URD	6.96Y	116.0	0.00	8.98	2.15	1	15	3	98	0.00	0.0	5.698	0.071	15	3	1	1 L
L PL.6223	PL.6089	A	6 A (CWC)	6.97Y	116.1	0.01	8.85	7.04	5	48	10	98	0.00	0.0	5.506	0.045	7	2	2	7 L
L PL.6224	PL.6223	A	6 A (CWC)	6.97Y	116.1	0.01	8.86	5.95	4	41	9	98	0.00	0.0	5.542	0.036	0	0	0	5 L
L PL.5778	PL.6224	A	6 A (CWC)	6.97Y	116.1	0.00	8.87	2.47	2	17	4	97	0.00	0.0	5.572	0.030	17	4	3	3 L
L PL.6225	PL.6224	A	#4 ACSR	6.97Y	116.1	0.01	8.88	3.48	3	24	5	98	0.00	0.0	5.656	0.114	12	2	1	2 L
L PL.6226	PL.6225	A	#4 ACSR	6.97Y	116.1	0.00	8.88	1.77	1	12	3	97	0.00	0.0	5.717	0.061	12	3	1	1 L
PL.5602	PL.5274	ABC	#4/0 ACSR	7.12Y	118.7	0.12	6.35	50.07	15	1041	249	97	0.77	0.1	4.479	0.229	0	0	0	288
PL.5601	PL.5602	ABC	336 MCM AC	7.12Y	118.6	0.04	6.39	50.07	10	1040	248	97	0.26	0.0	4.603	0.123	0	0	0	288
PL.5588	PL.5601	ABC	336 MCM AC	7.11Y	118.5	0.07	6.46	45.65	9	948	227	97	0.38	0.0	4.822	0.219	6	1	3	272
PL.6098	PL.5588	ABC	336 MCM AC	7.11Y	118.5	0.04	6.51	45.25	9	939	225	97	0.24	0.0	4.960	0.138	0	0	0	268
PL.5603	PL.6098	ABC	336 MCM AC	7.11Y	118.5	0.00	6.51	14.69	3	302	83	96	0.00	0.0	4.970	0.010	0	0	0	64
PL.5604	PL.5603	ABC	#1/0 ACSR	7.11Y	118.5	0.00	6.51	4.21	2	82	37	91	0.00	0.0	5.023	0.053	0	0	0	5
PL.6793	PL.5604	ABC	6 A (CWC)	7.11Y	118.5	0.02	6.53	4.21	3	82	37	91	0.01	0.0	5.135	0.112	0	0	0	5
PD.1435	PL.6793	ABC	65T	7.11Y	118.5	0.00	6.53	4.21	0	82	37	91	0.00	0.0	5.135	0.112	0	0	0	5
PL.6794	PD.1435	ABC	6 A (CWC)	7.11Y	118.5	0.01	6.54	4.21	3	82	37	91	0.01	0.0	5.205	0.070	10	2	3	5
PL.6172	PL.6794	ABC	6 A (CWC)	7.11Y	118.5	0.00	6.54	3.74	3	72	35	90	0.00	0.0	5.228	0.023	0	0	0	2
PL.5783	PL.6172	ABC	6 A (CWC)	7.11Y	118.5	0.00	6.54	0.00	0	0	0	100	0.00	0.0	5.289	0.061	0	0	0	0
PL.5605	PL.6172	ABC	6 A (CWC)	7.11Y	118.5	0.00	6.55	3.74	3	72	35	90	0.00	0.0	5.250	0.021	72	35	2	2
PL.5718	PL.5605	ABC	6 A (CWC)	7.11Y	118.5	0.00	6.55	0.00	0	0	0	100	0.00	0.0	5.253	0.003	0	0	0	0
PL.5782	PL.5603	ABC	336 MCM AC	7.11Y	118.5	0.02	6.53	10.56	2	220	47	98	0.03	0.0	5.293	0.323	6	1	1	59

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5519	PL.5782	ABC	336 MCM AC	7.11Y	118.5	0.00	6.53	10.29	2	215	45	98	0.01	0.0	5.358	0.065	0	0	0	58
PL.6169	PL.5519	ABC	336 MCM AC	7.11Y	118.5	0.00	6.54	10.29	2	215	45	98	0.00	0.0	5.398	0.040	0	0	0	58
PL.6775	PL.6169	C	#4 ACSR	7.11Y	118.5	0.00	6.54	0.90	1	6	1	99	0.00	0.0	5.403	0.005	0	0	0	1
PD.1425	PL.6775	C	65T	7.11Y	118.5	0.00	6.54	0.90	0	6	1	99	0.00	0.0	5.403	0.005	0	0	0	1
PL.6776	PD.1425	C	#4 ACSR	7.11Y	118.5	0.00	6.54	0.90	1	6	1	99	0.00	0.0	5.459	0.056	6	1	1	1
PL.6167	PL.6169	ABC	336 MCM AC	7.11Y	118.5	0.00	6.54	9.99	2	208	44	98	0.00	0.0	5.436	0.038	5	1	1	57
PL.6168	PL.6167	ABC	336 MCM AC	7.11Y	118.5	0.00	6.54	9.73	2	203	43	98	0.00	0.0	5.486	0.050	0	0	1	56
PL.6166	PL.6168	ABC	336 MCM AC	7.11Y	118.5	0.01	6.55	9.73	2	203	43	98	0.01	0.0	5.566	0.080	0	0	0	55
PL.6561	PL.6166	C	#1/0 ACSR	7.11Y	118.5	0.00	6.55	0.48	0	3	1	95	0.00	0.0	5.571	0.005	0	0	0	1
PD.1310	PL.6561	C	65T	7.11Y	118.5	0.00	6.55	0.48	0	3	1	95	0.00	0.0	5.571	0.005	0	0	0	1
PL.6562	PD.1310	C	#1/0 ACSR	7.11Y	118.5	0.00	6.55	0.48	0	3	1	95	0.00	0.0	5.616	0.045	3	1	1	1
PL.6836	PL.6166	ABC	336 MCM AC	7.11Y	118.4	0.00	6.55	9.57	2	200	42	98	0.00	0.0	5.625	0.059	0	0	0	54
PL.7218	PL.6836	ABC	336 MCM AC	7.11Y	118.4	0.00	6.55	9.57	2	200	42	98	0.00	0.0	5.626	0.002	0	0	0	54
PD.1557	PL.7218	ABC	70L	7.11Y	118.4	0.00	6.55	9.57	14	200	42	98	0.00	0.0	5.626	0.002	0	0	0	54
PL.7219	PD.1557	ABC	336 MCM AC	7.11Y	118.4	0.01	6.56	9.57	2	200	42	98	0.01	0.0	5.739	0.113	0	0	0	54
PL.6844	PL.7219	ABC	336 MCM AC	7.11Y	118.4	0.00	6.56	9.25	2	193	41	98	0.00	0.0	5.758	0.019	0	0	0	52
PL.7222	PL.6844	ABC	336 MCM AC	7.11Y	118.4	0.00	6.56	9.25	2	193	41	98	0.00	0.0	5.760	0.002	0	0	0	52
RG.10	PL.7222	ABC	76.2 KVA	7.48Y	124.7	-6.23	0.33	9.25	9	193	41	98	percent Boost= 5.00 Tap= 8.0						52	
PL.7223	RG.10	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	8.79	2	193	41	98	0.00	0.0	5.816	0.056	0	0	0	52
PL.6557	PL.7223	C	#1/0 ACSR	7.48Y	124.7	0.00	0.33	0.39	0	3	1	95	0.00	0.0	5.821	0.005	0	0	0	1
PD.1308	PL.6557	C	30T	7.48Y	124.7	0.00	0.33	0.39	0	3	1	95	0.00	0.0	5.821	0.005	0	0	0	1
PL.6558	PD.1308	C	#1/0 ACSR	7.48Y	124.7	0.00	0.33	0.39	0	3	1	95	0.00	0.0	5.832	0.011	3	1	1	1
PL.6099	PL.7223	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	8.65	2	190	40	98	0.00	0.0	5.863	0.046	7	2	2	51
PL.6162	PL.6099	ABC	336 MCM AC	7.48Y	124.7	0.01	0.34	7.46	1	164	34	98	0.00	0.0	5.964	0.101	2	0	1	42
PL.6163	PL.6162	ABC	336 MCM AC	7.48Y	124.7	0.00	0.34	7.35	1	161	34	98	0.00	0.0	6.004	0.040	4	1	2	41
PL.6148	PL.6163	ABC	336 MCM AC	7.48Y	124.7	0.01	0.35	7.18	1	158	33	98	0.00	0.0	6.113	0.108	2	1	2	39
PL.6147	PL.6148	ABC	336 MCM AC	7.48Y	124.7	0.00	0.35	7.07	1	155	33	98	0.00	0.0	6.183	0.071	0	0	0	37
PL.5785	PL.6147	ABC	336 MCM AC	7.48Y	124.6	0.00	0.35	6.99	1	153	32	98	0.00	0.0	6.220	0.037	0	0	0	36
PL.6543	PL.5785	A	#2 ACSR	7.48Y	124.6	0.00	0.35	1.41	1	10	2	98	0.00	0.0	6.225	0.005	0	0	0	2
PD.1301	PL.6543	A	30T	7.48Y	124.6	0.00	0.35	1.41	0	10	2	98	0.00	0.0	6.225	0.005	0	0	0	2
PL.6544	PD.1301	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	1.41	1	10	2	98	0.00	0.0	6.272	0.047	3	1	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6142	PL.6544	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	1.01	0	7	2	96	0.00	0.0	6.317	0.045	7	2	1	1
PL.5786	PL.5785	ABC	336 MCM AC	7.48Y	124.6	0.00	0.35	6.52	1	143	30	98	0.00	0.0	6.281	0.060	0	0	0	34
PL.6143	PL.5786	ABC	336 MCM AC	7.48Y	124.6	0.00	0.36	5.77	1	127	27	98	0.00	0.0	6.404	0.124	1	0	1	30
PL.6144	PL.6143	ABC	336 MCM AC	7.48Y	124.6	0.01	0.36	5.70	1	125	26	98	0.00	0.0	6.562	0.158	4	1	1	29
PL.6114	PL.6144	ABC	336 MCM AC	7.48Y	124.6	0.01	0.37	5.53	1	121	26	98	0.00	0.0	6.711	0.149	0	0	0	28
PL.5614	PL.6114	ABC	6 A (CWC)	7.48Y	124.6	0.04	0.41	5.53	4	121	26	98	0.04	0.0	6.903	0.191	0	0	0	28
PL.6141	PL.5614	ABC	6 A (CWC)	7.47Y	124.6	0.03	0.45	5.53	4	121	26	98	0.03	0.0	7.066	0.163	5	1	3	28
PL.6116	PL.6141	ABC	6 A (CWC)	7.47Y	124.5	0.04	0.48	4.68	3	103	22	98	0.03	0.0	7.282	0.216	16	3	3	23
PL.6139	PL.6116	ABC	6 A (CWC)	7.47Y	124.5	0.03	0.51	3.97	3	87	18	98	0.02	0.0	7.479	0.197	0	0	0	20
PL.5617	PL.6139	ABC	6 A (CWC)	7.47Y	124.5	0.01	0.53	2.61	2	57	12	98	0.01	0.0	7.606	0.126	0	0	0	16
PL.5788	PL.5617	ABC	6 A (CWC)	7.47Y	124.4	0.03	0.56	2.61	2	57	12	98	0.01	0.0	7.946	0.340	6	1	1	16
PL.6131	PL.5788	ABC	6 A (CWC)	7.47Y	124.4	0.01	0.57	2.33	2	51	11	98	0.01	0.0	8.118	0.172	7	1	5	15
PL.6129	PL.6131	ABC	6 A (CWC)	7.46Y	124.4	0.05	0.62	2.03	1	45	9	98	0.02	0.0	8.744	0.626	0	0	0	10
PL.5620	PL.6129	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	2.03	1	45	9	98	0.00	0.0	8.780	0.037	0	0	0	10
PL.6120	PL.5620	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.53	0	12	2	99	0.00	0.0	8.892	0.111	4	1	1	3
PL.6121	PL.6120	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.33	0	7	1	99	0.00	0.0	8.914	0.022	6	1	1	2
PL.6132	PL.6121	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.04	0	1	0	100	0.00	0.0	8.951	0.037	1	0	1	1
PL.6133	PL.6132	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.00	0	0	0	100	0.00	0.0	9.026	0.075	0	0	0	0
PL.6801	PL.6133	ABC	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.00	0	0	0	100	0.00	0.0	9.141	0.116	0	0	0	0
PD.9537-A	PL.6801	ABC	Open	7.46Y	124.4	0.00	0.63	0.00	0	0	0	100	0.00	0.0	9.141	0.116	0	0	0	0
PL.6535	PL.5620	B	6 A (CWC)	7.46Y	124.4	0.01	0.63	4.51	3	33	7	98	0.00	0.0	8.815	0.035	0	0	0	7
PD.1297	PL.6535	B	30T	7.46Y	124.4	0.00	0.63	4.51	0	33	7	98	0.00	0.0	8.815	0.035	0	0	0	7
PL.6536	PD.1297	B	6 A (CWC)	7.46Y	124.4	0.00	0.64	4.51	3	33	7	98	0.00	0.0	8.837	0.021	8	2	2	7
PL.6134	PL.6536	B	6 A (CWC)	7.46Y	124.4	0.01	0.65	3.37	2	25	5	98	0.00	0.0	8.923	0.086	0	0	0	5
PL.5621	PL.6134	B	#4 ACSR	7.46Y	124.4	0.00	0.65	0.00	0	0	0	100	0.00	0.0	9.019	0.096	0	0	0	0
PL.6135	PL.6134	B	6 A (CWC)	7.46Y	124.3	0.02	0.66	3.37	2	25	5	98	0.00	0.0	9.043	0.120	8	2	1	5
PL.6136	PL.6135	B	6 A (CWC)	7.46Y	124.3	0.01	0.67	2.30	2	17	4	97	0.00	0.0	9.185	0.141	12	2	2	4
PL.6137	PL.6136	B	6 A (CWC)	7.46Y	124.3	0.00	0.68	0.68	0	5	1	98	0.00	0.0	9.298	0.113	5	1	2	2
PL.6537	PL.5617	C	#2 ACSR	7.47Y	124.5	0.00	0.53	0.00	0	0	0	100	0.00	0.0	7.610	0.005	0	0	0	0
PD.1298	PL.6537	C	30T	7.47Y	124.5	0.00	0.53	0.00	0	0	0	100	0.00	0.0	7.610	0.005	0	0	0	0
PL.6538	PD.1298	C	#2 ACSR	7.47Y	124.5	0.00	0.53	0.00	0	0	0	100	0.00	0.0	7.645	0.034	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.7224	PL.6139	C	#4 ACSR	7.47Y	124.5	0.00	0.51	1.71	1	13	3	97	0.00	0.0	7.482	0.003	0	0	0	2
PD.1558	PL.7224	C	30T	7.47Y	124.5	0.00	0.51	1.71	0	13	3	97	0.00	0.0	7.482	0.003	0	0	0	2
PL.7225	PD.1558	C	#4 ACSR	7.47Y	124.5	0.00	0.51	1.71	1	13	3	97	0.00	0.0	7.484	0.002	0	0	0	2
PL.5787	PL.7225	C	#4 ACSR	7.47Y	124.5	0.00	0.51	0.62	0	5	1	98	0.00	0.0	7.521	0.037	5	1	1	1
PL.6117	PL.7225	C	#4 ACSR	7.47Y	124.5	0.00	0.51	1.09	1	8	2	97	0.00	0.0	7.488	0.004	0	0	0	1
PL.5618	PL.6117	C	#4 ACSR	7.47Y	124.5	0.00	0.51	1.09	1	8	2	97	0.00	0.0	7.537	0.049	8	2	1	1
PL.6779	PL.6139	A	#4 ACSR	7.47Y	124.5	0.00	0.51	2.39	2	17	4	97	0.00	0.0	7.484	0.005	0	0	0	2
PD.1427	PL.6779	A	30T	7.47Y	124.5	0.00	0.51	2.39	0	17	4	97	0.00	0.0	7.484	0.005	0	0	0	2
PL.6780	PD.1427	A	#4 ACSR	7.47Y	124.5	0.02	0.54	2.39	2	17	4	97	0.00	0.0	7.950	0.466	17	4	2	2
PL.5615	PL.6141	C	6 A (CWC)	7.47Y	124.5	0.01	0.45	1.87	1	14	3	98	0.00	0.0	7.170	0.104	7	1	1	2
PL.6777	PL.5615	C	6 A (CWC)	7.47Y	124.5	0.00	0.45	0.97	1	7	1	99	0.00	0.0	7.175	0.005	0	0	0	1
PD.1426	PL.6777	C	30T	7.47Y	124.5	0.00	0.45	0.97	0	7	1	99	0.00	0.0	7.175	0.005	0	0	0	1
PL.6778	PD.1426	C	6 A (CWC)	7.47Y	124.5	0.00	0.46	0.97	1	7	1	99	0.00	0.0	7.235	0.060	0	0	0	1
PL.5616	PL.6778	C	#4 ACSR	7.47Y	124.5	0.00	0.46	0.97	1	7	1	99	0.00	0.0	7.316	0.081	7	1	1	1
PL.6539	PL.6144	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	6.567	0.005	0	0	0	0
PD.1299	PL.6539	A	30T	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	6.567	0.005	0	0	0	0
PL.6540	PD.1299	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.00	0	0	0	100	0.00	0.0	6.626	0.059	0	0	0	0
PL.6545	PL.5786	C	#1/0 ACSR	7.48Y	124.6	0.00	0.35	2.25	1	16	3	98	0.00	0.0	6.285	0.005	0	0	0	4
PD.1302	PL.6545	C	30T	7.48Y	124.6	0.00	0.35	2.25	0	16	3	98	0.00	0.0	6.285	0.005	0	0	0	4
PL.6546	PD.1302	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	2.25	1	16	3	98	0.00	0.0	6.304	0.019	4	1	2	4
PL.6145	PL.6546	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	1.69	1	12	3	97	0.00	0.0	6.344	0.040	7	1	1	2
PL.6146	PL.6145	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.73	0	5	1	98	0.00	0.0	6.504	0.160	5	1	1	1
PL.6541	PL.6147	C	#1/0 ACSR	7.48Y	124.7	0.00	0.35	0.24	0	2	0	100	0.00	0.0	6.188	0.005	0	0	0	1
PD.1300	PL.6541	C	30T	7.48Y	124.7	0.00	0.35	0.24	0	2	0	100	0.00	0.0	6.188	0.005	0	0	0	1
PL.6542	PD.1300	C	#1/0 ACSR	7.48Y	124.7	0.00	0.35	0.24	0	2	0	100	0.00	0.0	6.219	0.031	2	0	1	1
PL.6555	PL.6099	A	6 A (CWC)	7.48Y	124.7	0.00	0.33	2.60	2	19	4	98	0.00	0.0	5.867	0.005	0	0	0	7
PD.1307	PL.6555	A	20T	7.48Y	124.7	0.00	0.33	2.60	0	19	4	98	0.00	0.0	5.867	0.005	0	0	0	7
PL.6556	PD.1307	A	6 A (CWC)	7.48Y	124.7	0.01	0.34	2.60	2	19	4	98	0.00	0.0	5.919	0.052	0	0	0	7
PL.5609	PL.6556	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	1.15	1	8	2	97	0.00	0.0	5.954	0.034	0	0	0	2
PL.5612	PL.5609	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.81	0	6	1	99	0.00	0.0	5.986	0.033	6	1	1	1
PL.5613	PL.5609	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.34	0	3	1	95	0.00	0.0	5.984	0.030	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5610	PL.6556	A	6 A (CWC)	7.48Y	124.6	0.02	0.36	1.26	1	9	2	98	0.00	0.0	6.218	0.299	0	0	0	2
PL.5784	PL.5610	A	6 A (CWC)	7.48Y	124.6	0.00	0.36	0.26	0	2	0	100	0.00	0.0	6.253	0.034	2	0	1	1
PL.5709	PL.5610	A	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.99	0	7	2	96	0.00	0.0	6.259	0.041	7	2	1	1
PL.5608	PL.6556	A	#4 ACSR	7.48Y	124.7	0.00	0.34	0.19	0	1	0	100	0.00	0.0	5.956	0.037	1	0	3	3
PL.6715	PL.7219	B	#4 ACSR	7.11Y	118.4	0.00	6.56	0.97	1	7	1	99	0.00	0.0	5.744	0.005	0	0	0	2
PD.1393	PL.6715	B	30T	7.11Y	118.4	0.00	6.56	0.97	0	7	1	99	0.00	0.0	5.744	0.005	0	0	0	2
PL.6716	PD.1393	B	#4 ACSR	7.11Y	118.4	0.01	6.57	0.97	1	7	1	99	0.00	0.0	5.873	0.129	0	0	0	2
PL.5606	PL.6716	B	#4 ACSR	7.11Y	118.4	0.00	6.57	0.51	0	4	1	97	0.00	0.0	5.953	0.080	4	1	1	1
PL.5607	PL.6716	B	#4 ACSR	7.11Y	118.4	0.00	6.57	0.46	0	3	1	95	0.00	0.0	5.950	0.078	3	1	1	1
PL.5781	PL.6098	ABC	336 MCM AC	7.11Y	118.5	0.01	6.52	30.57	6	637	141	98	0.04	0.0	5.009	0.049	0	0	0	204
PL.7226	PL.5781	ABC	336 MCM AC	7.11Y	118.5	0.00	6.52	30.57	6	637	141	98	0.00	0.0	5.012	0.003	0	0	0	204
PD.1559	PL.7226	ABC	100L	7.11Y	118.5	0.00	6.52	30.57	31	637	141	98	0.00	0.0	5.012	0.003	0	0	0	204
PL.7227	PD.1559	ABC	336 MCM AC	7.11Y	118.5	0.01	6.53	30.57	6	637	141	98	0.04	0.0	5.058	0.046	0	0	0	204
PL.5789	PL.7227	ABC	336 MCM AC	7.11Y	118.4	0.05	6.58	28.99	6	604	134	98	0.19	0.0	5.331	0.273	0	0	0	197
PL.6565	PL.5789	B	6 A (CWC)	7.11Y	118.4	0.00	6.58	0.22	0	2	0	100	0.00	0.0	5.336	0.005	0	0	0	2
PD.1312	PL.6565	B	40T	7.11Y	118.4	0.00	6.58	0.22	0	2	0	100	0.00	0.0	5.336	0.005	0	0	0	2
PL.6566	PD.1312	B	6 A (CWC)	7.11Y	118.4	0.00	6.58	0.22	0	2	0	100	0.00	0.0	5.370	0.035	1	0	1	2
PL.5626	PL.6566	B	#4 ACSR	7.11Y	118.4	0.00	6.58	0.01	0	0	0	100	0.00	0.0	5.500	0.129	0	0	1	1
PL.5790	PL.5789	ABC	336 MCM AC	7.10Y	118.4	0.05	6.63	28.92	6	602	133	98	0.16	0.0	5.563	0.232	0	0	0	195
PL.6563	PL.5790	A	#4 ACSR	7.10Y	118.4	0.00	6.63	0.25	0	2	0	100	0.00	0.0	5.568	0.005	0	0	0	1
PD.1311	PL.6563	A	40T	7.10Y	118.4	0.00	6.63	0.25	0	2	0	100	0.00	0.0	5.568	0.005	0	0	0	1
PL.6564	PD.1311	A	#4 ACSR	7.10Y	118.4	0.00	6.63	0.25	0	2	0	100	0.00	0.0	5.590	0.022	2	0	1	1
PL.5791	PL.5790	ABC	336 MCM AC	7.10Y	118.3	0.08	6.70	28.84	6	600	132	98	0.26	0.0	5.941	0.378	0	0	0	194
PL.6559	PL.5791	C	#2 ACSR	7.10Y	118.3	0.00	6.70	2.07	1	14	3	98	0.00	0.0	5.945	0.004	0	0	0	4
PD.1309	PL.6559	C	40T	7.10Y	118.3	0.00	6.70	2.07	0	14	3	98	0.00	0.0	5.945	0.004	0	0	0	4
PL.6560	PD.1309	C	#2 ACSR	7.10Y	118.3	0.01	6.71	2.07	1	14	3	98	0.00	0.0	6.097	0.152	5	1	1	4
PL.5627	PL.6560	C	#2 ACSR	7.10Y	118.3	0.00	6.71	0.32	0	2	0	100	0.00	0.0	6.145	0.047	2	0	1	1
PL.6174	PL.6560	C	#2 ACSR	7.10Y	118.3	0.00	6.71	1.09	1	8	2	97	0.00	0.0	6.166	0.069	8	2	1	2
PL.6175	PL.6174	C	#2 ACSR	7.10Y	118.3	0.00	6.71	0.00	0	0	0	100	0.00	0.0	6.236	0.070	0	0	1	1
PL.5792	PL.5791	ABC	336 MCM AC	7.10Y	118.3	0.01	6.72	28.15	5	585	129	98	0.04	0.0	6.004	0.063	0	0	1	190
PL.6551	PL.5792	B	#1/0 ACSR	7.10Y	118.3	0.00	6.72	1.14	0	8	2	97	0.00	0.0	6.008	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1305	PL.6551	B	40T	7.10Y	118.3	0.00	6.72	1.14	0	8	2	97	0.00	0.0	6.008	0.005	0	0	0	2
PL.6552	PD.1305	B	#1/0 ACSR	7.10Y	118.3	0.00	6.72	1.14	0	8	2	97	0.00	0.0	6.035	0.027	8	2	2	2
PL.5628	PL.5792	ABC	336 MCM AC	7.09Y	118.2	0.05	6.76	27.77	5	578	127	98	0.16	0.0	6.251	0.248	0	0	0	187
PL.7228	PL.5628	ABC	336 MCM AC	7.09Y	118.2	0.00	6.76	27.77	5	577	126	98	0.00	0.0	6.251	0.000	0	0	0	187
RG.11	PL.7228	ABC	76.2 KVA	7.47Y	124.5	-6.22	0.54	27.77	28	577	126	98	percent Boost= 5.00 Tap= 8.0						187	
PL.7229	RG.11	ABC	336 MCM AC	7.47Y	124.4	0.02	0.56	26.38	5	577	126	98	0.08	0.0	6.384	0.133	0	0	0	187
PL.5793	PL.7229	ABC	336 MCM AC	7.46Y	124.4	0.04	0.60	19.98	4	437	97	98	0.09	0.0	6.647	0.262	2	0	1	128
PL.6161	PL.5793	ABC	336 MCM AC	7.46Y	124.4	0.02	0.62	19.88	4	435	96	98	0.04	0.0	6.759	0.112	1	0	1	127
PL.6159	PL.6161	ABC	336 MCM AC	7.46Y	124.4	0.02	0.63	19.84	4	434	96	98	0.04	0.0	6.875	0.116	0	0	0	126
PL.5801	PL.6159	ABC	336 MCM AC	7.46Y	124.3	0.03	0.66	19.26	4	421	93	98	0.06	0.0	7.071	0.196	4	1	2	119
PL.6156	PL.5801	ABC	336 MCM AC	7.46Y	124.3	0.01	0.66	19.06	4	417	92	98	0.01	0.0	7.118	0.048	0	0	0	117
PL.6157	PL.6156	ABC	336 MCM AC	7.46Y	124.3	0.03	0.69	19.06	4	417	92	98	0.07	0.0	7.342	0.224	0	0	0	117
PL.6840	PL.6157	ABC	336 MCM AC	7.46Y	124.3	0.01	0.70	17.78	3	388	86	98	0.01	0.0	7.386	0.043	0	0	0	110
PL.7232	PL.6840	ABC	336 MCM AC	7.46Y	124.3	0.00	0.70	17.78	3	388	86	98	0.00	0.0	7.389	0.003	0	0	0	110
PL.7233	PL.7232	ABC	336 MCM AC	7.46Y	124.3	0.02	0.72	17.78	3	388	86	98	0.04	0.0	7.552	0.163	0	0	0	110
PL.5803	PL.7233	ABC	336 MCM AC	7.46Y	124.3	0.02	0.74	17.64	3	385	85	98	0.05	0.0	7.747	0.195	1	0	1	109
PL.6154	PL.5803	ABC	336 MCM AC	7.45Y	124.2	0.02	0.76	17.62	3	385	85	98	0.03	0.0	7.873	0.126	0	0	0	108
PL.6547	PL.6154	B	#1/0 ACSR	7.45Y	124.2	0.00	0.76	0.21	0	2	0	100	0.00	0.0	7.896	0.023	0	0	0	2
PD.1303	PL.6547	B	40T	7.45Y	124.2	0.00	0.76	0.21	0	2	0	100	0.00	0.0	7.896	0.023	0	0	0	2
PL.6548	PD.1303	B	#1/0 ACSR	7.45Y	124.2	0.00	0.76	0.21	0	2	0	100	0.00	0.0	7.922	0.025	2	0	2	2
PL.6102	PL.6154	ABC	336 MCM AC	7.45Y	124.2	0.02	0.78	17.55	3	383	84	98	0.03	0.0	8.007	0.134	0	0	0	106
PL.6103	PL.6102	ABC	336 MCM AC	7.45Y	124.2	0.00	0.78	17.55	3	383	84	98	0.00	0.0	8.010	0.003	0	0	0	106
PL.5659	PL.6103	B	6 A (CWC)	7.45Y	124.2	0.00	0.78	1.93	1	14	3	98	0.00	0.0	8.012	0.002	0	0	0	4
PD.1449	PL.5659	B	35L	7.45Y	124.2	0.00	0.78	1.93	6	14	3	98	0.00	0.0	8.012	0.002	0	0	0	4
PL.5820	PD.1449	B	6 A (CWC)	7.45Y	124.2	0.00	0.78	1.04	1	8	2	97	0.00	0.0	8.014	0.002	0	0	0	3
PL.5804	PL.5820	B	6 A (CWC)	7.45Y	124.2	0.01	0.78	1.04	1	8	2	97	0.00	0.0	8.193	0.178	2	0	1	3
PL.6152	PL.5804	B	6 A (CWC)	7.45Y	124.2	0.01	0.80	0.83	1	6	1	99	0.00	0.0	8.571	0.378	0	0	0	2
PL.5805	PL.6152	B	6 A (CWC)	7.45Y	124.2	0.00	0.80	0.33	0	2	1	89	0.00	0.0	8.827	0.256	0	0	0	1
PL.5664	PL.5805	B	#2 ACSR	7.45Y	124.2	0.00	0.80	0.33	0	2	1	89	0.00	0.0	8.879	0.052	2	1	1	1
PL.5662	PL.6152	B	#1/0 ACSR	7.45Y	124.2	0.00	0.80	0.50	0	4	1	97	0.00	0.0	8.669	0.098	4	1	1	1
PL.6100	PD.1449	B	6 A (CWC)	7.45Y	124.2	0.00	0.78	0.89	1	7	1	99	0.00	0.0	8.015	0.002	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5660	PL.6100	B	6 A (CWC)	7.45Y	124.2	0.00	0.78	0.89	1	7	1	99	0.00	0.0	8.076	0.061	7	1	1	1
PL.6104	PL.6103	ABC	336 MCM AC	7.45Y	124.2	0.01	0.79	16.91	3	369	81	98	0.02	0.0	8.101	0.091	1	0	1	102
PL.6783	PL.6104	C	6 A (CWC)	7.45Y	124.2	0.00	0.79	0.37	0	3	1	95	0.00	0.0	8.105	0.005	0	0	0	1
PD.1429	PL.6783	C	40T	7.45Y	124.2	0.00	0.79	0.37	0	3	1	95	0.00	0.0	8.105	0.005	0	0	0	1
PL.6784	PD.1429	C	6 A (CWC)	7.45Y	124.2	0.00	0.79	0.37	0	3	1	95	0.00	0.0	8.151	0.046	3	1	1	1
PL.6105	PL.6104	ABC	336 MCM AC	7.45Y	124.2	0.01	0.79	16.73	3	365	80	98	0.01	0.0	8.149	0.049	0	0	0	100
PL.6807	PL.6105	A	#1/0 ACSR	7.45Y	124.2	0.01	0.80	7.70	3	56	12	98	0.00	0.0	8.203	0.054	0	0	0	28
PL.7238	PL.6807	A	#1/0 ACSR	7.45Y	124.2	0.00	0.80	7.70	3	56	12	98	0.00	0.0	8.207	0.003	0	0	0	28
PD.1562	PL.7238	A	70L	7.45Y	124.2	0.00	0.80	7.70	11	56	12	98	0.00	0.0	8.207	0.003	0	0	0	28
PL.7239	PD.1562	A	#1/0 ACSR	7.45Y	124.2	0.03	0.83	7.70	3	56	12	98	0.01	0.0	8.375	0.169	2	0	1	28
PL.65717	PL.7239	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.56	0	4	1	97	0.00	0.0	8.463	0.088	0	0	0	2
PL.65718	PL.65717	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.56	0	4	1	97	0.00	0.0	8.625	0.162	3	1	1	2
PL.5667	PL.65718	A	#1/0 ACSR	7.45Y	124.2	0.00	0.83	0.11	0	1	0	100	0.00	0.0	8.717	0.091	1	0	1	1
PL.5665	PL.7239	A	#1/0 ACSR	7.45Y	124.2	0.00	0.83	6.89	3	50	11	98	0.00	0.0	8.383	0.008	0	0	0	25
PL.6126	PL.5665	A	#4 ACSR	7.45Y	124.2	0.02	0.85	6.89	5	50	11	98	0.01	0.0	8.441	0.058	2	0	1	25
PL.6127	PL.6126	A	#4 ACSR	7.45Y	124.1	0.02	0.87	6.61	5	48	10	98	0.01	0.0	8.516	0.075	3	1	2	24
PL.6125	PL.6127	A	#4 ACSR	7.44Y	124.1	0.06	0.93	6.24	5	45	10	98	0.02	0.0	8.735	0.219	0	0	0	22
PL.6123	PL.6125	A	#4 ACSR	7.44Y	124.1	0.02	0.95	6.24	5	45	10	98	0.01	0.0	8.812	0.078	1	0	2	22
PL.6124	PL.6123	A	#4 ACSR	7.44Y	124.0	0.06	1.01	6.07	5	44	9	98	0.02	0.0	9.036	0.223	0	0	0	20
PL.5806	PL.6124	A	#4 ACSR	7.44Y	124.0	0.04	1.04	5.31	4	39	8	98	0.01	0.0	9.189	0.153	0	0	0	18
PL.5807	PL.5806	A	#4 ACSR	7.44Y	123.9	0.02	1.07	5.29	4	39	8	98	0.01	0.0	9.279	0.090	0	0	0	17
PL.5808	PL.5807	A	#4 ACSR	7.43Y	123.8	0.15	1.21	5.29	4	39	8	98	0.04	0.1	9.907	0.629	0	0	0	17
PL.5809	PL.5808	A	#4 ACSR	7.42Y	123.7	0.05	1.26	5.29	4	38	8	98	0.01	0.0	10.122	0.215	3	1	1	17
PL.6503	PL.5809	A	#4 ACSR	7.42Y	123.7	0.01	1.27	4.93	4	36	8	98	0.00	0.0	10.178	0.056	0	0	0	16
PL.6119	PL.6503	A	#4 ACSR	7.42Y	123.7	0.03	1.30	4.54	3	33	7	98	0.01	0.0	10.325	0.147	6	1	2	14
PL.5671	PL.6119	A	#1/0 ACSR	7.42Y	123.7	0.00	1.30	1.70	1	12	3	97	0.00	0.0	10.450	0.125	12	3	2	2
PL.6500	PL.6119	A	#4 ACSR	7.42Y	123.7	0.00	1.30	2.08	2	15	3	98	0.00	0.0	10.357	0.032	9	2	2	10
PL.6501	PL.6500	A	#4 ACSR	7.42Y	123.7	0.00	1.30	0.85	1	6	1	99	0.00	0.0	10.441	0.084	2	0	2	8
PL.6499	PL.6501	A	#4 ACSR	7.42Y	123.7	0.01	1.31	0.54	0	4	1	97	0.00	0.0	10.839	0.397	0	0	1	6
PL.6498	PL.6499	A	#4 ACSR	7.42Y	123.7	0.00	1.31	0.54	0	4	1	97	0.00	0.0	10.953	0.114	1	0	1	5
PL.6496	PL.6498	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.36	0	3	1	95	0.00	0.0	11.099	0.146	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5672	PL.6496	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.11	0	1	0	100	0.00	0.0	11.151	0.052	1	0	1	1
PL.5673	PL.6496	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.14	0	1	0	100	0.00	0.0	11.171	0.072	0	0	1	2
PL.5674	PL.5673	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.08	0	1	0	100	0.00	0.0	11.310	0.139	0	0	0	1
PL.5675	PL.5674	A	#1/0 ACSR	7.42Y	123.7	0.00	1.32	0.08	0	1	0	100	0.00	0.0	11.359	0.049	1	0	1	1
PL.6494	PL.6496	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.12	0	1	0	100	0.00	0.0	11.172	0.073	0	0	0	1
PL.6495	PL.6494	A	#4 ACSR	7.42Y	123.7	0.00	1.32	0.12	0	1	0	100	0.00	0.0	11.466	0.294	1	0	1	1
PL.6504	PL.6503	A	#4 ACSR	7.42Y	123.7	0.00	1.27	0.39	0	3	1	95	0.00	0.0	10.191	0.013	2	0	1	2
PL.6505	PL.6504	A	#4 ACSR	7.42Y	123.7	0.00	1.27	0.16	0	1	0	100	0.00	0.0	10.889	0.698	1	0	1	1
PL.5669	PL.5807	A	#4 ACSR	7.44Y	123.9	0.00	1.07	0.00	0	0	0	100	0.00	0.0	9.340	0.062	0	0	0	0
PL.5668	PL.5806	A	#4 ACSR	7.44Y	124.0	0.00	1.04	0.01	0	0	0	100	0.00	0.0	9.240	0.051	0	0	1	1
PL.6507	PL.6124	A	#2 ACSR	7.44Y	124.0	0.00	1.01	0.76	0	6	1	99	0.00	0.0	9.071	0.035	0	0	0	2
PL.6508	PL.6507	A	#2 ACSR	7.44Y	124.0	0.00	1.01	0.76	0	6	1	99	0.00	0.0	9.090	0.019	2	0	1	2
PL.6506	PL.6508	A	#2 ACSR	7.44Y	124.0	0.00	1.01	0.50	0	4	1	97	0.00	0.0	9.149	0.058	4	1	1	1
PL.5661	PL.6105	B	#1/0 ACSR	7.45Y	124.2	0.01	0.80	42.51	18	309	69	98	0.02	0.0	8.159	0.010	0	0	0	72
PL.7234	PL.5661	B	#1/0 ACSR	7.45Y	124.2	0.00	0.80	42.51	18	309	69	98	0.01	0.0	8.162	0.003	0	0	0	72
PD.1561	PL.7234	B	70L	7.45Y	124.2	0.00	0.80	42.51	61	309	69	98	0.00	0.0	8.162	0.003	0	0	0	72
PL.7235	PD.1561	B	#1/0 ACSR	7.45Y	124.1	0.06	0.87	42.51	18	309	69	98	0.13	0.0	8.229	0.068	0	0	0	72
PL.7236	PL.7235	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	42.51	18	309	68	98	0.01	0.0	8.233	0.003	0	0	0	72
RG.12	PL.7236	B	76.2 KVA	7.45Y	124.1	0.00	0.87	42.51	43	309	68	98	percent Boost= 0.00 Tap= 0.0						72	
PL.7237	RG.12	B	#1/0 ACSR	7.44Y	124.1	0.05	0.92	42.51	18	309	68	98	0.11	0.0	8.289	0.056	0	0	0	72
PL.5676	PL.7237	B	6 A (CWC)	7.42Y	123.7	0.42	1.35	42.51	30	309	68	98	0.96	0.3	8.514	0.225	12	2	1	72
PL.6493	PL.5676	B	6 A (CWC)	7.41Y	123.6	0.08	1.43	40.92	29	296	65	98	0.19	0.1	8.561	0.046	4	1	1	71
PL.6491	PL.6493	B	6 A (CWC)	7.41Y	123.5	0.07	1.50	40.31	29	292	64	98	0.15	0.1	8.600	0.039	7	1	3	70
PL.6490	PL.6491	B	6 A (CWC)	7.40Y	123.3	0.21	1.71	39.41	28	285	63	98	0.45	0.2	8.719	0.119	2	0	4	67
PL.6489	PL.6490	B	6 A (CWC)	7.38Y	123.0	0.25	1.96	39.18	28	283	62	98	0.53	0.2	8.861	0.142	0	0	0	63
PL.5677	PL.6489	B	#4 ACSR	7.38Y	123.0	0.00	1.96	0.27	0	2	0	100	0.00	0.0	8.878	0.017	2	0	1	1
PL.5810	PL.6489	B	6 A (CWC)	7.37Y	122.8	0.26	2.23	38.91	28	281	61	98	0.55	0.2	9.012	0.151	0	0	0	62
PL.5811	PL.5810	B	6 A (CWC)	7.34Y	122.4	0.37	2.59	36.59	26	263	57	98	0.72	0.3	9.234	0.223	0	0	0	58
PL.5680	PL.5811	B	6 A (CWC)	7.34Y	122.4	0.00	2.59	0.00	0	0	0	100	0.00	0.0	9.299	0.064	0	0	0	0
PL.6486	PL.5811	B	6 A (CWC)	7.33Y	122.2	0.18	2.77	36.59	26	263	57	98	0.35	0.1	9.343	0.108	6	1	1	58
PL.6487	PL.6486	B	6 A (CWC)	7.33Y	122.1	0.14	2.91	35.69	25	256	55	98	0.27	0.1	9.433	0.090	7	2	1	57

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6485	PL.6487	B	6 A (CWC)	7.31Y	121.8	0.32	3.23	34.69	25	248	54	98	0.60	0.2	9.637	0.204	0	0	0	56
PL.10176	PL.6485	B	6 A (CWC)	7.29Y	121.6	0.22	3.45	33.84	24	242	52	98	0.40	0.2	9.782	0.145	4	1	1	55
PL.10177	PL.10176	B	6 A (CWC)	7.29Y	121.5	0.06	3.51	33.31	24	238	51	98	0.10	0.0	9.822	0.040	11	2	2	54
PL.10174	PL.10177	B	6 A (CWC)	7.29Y	121.5	0.01	3.51	1.08	1	8	2	97	0.00	0.0	9.980	0.158	5	1	1	2
PL.10175	PL.10174	B	6 A (CWC)	7.29Y	121.5	0.00	3.51	0.34	0	2	1	89	0.00	0.0	10.045	0.065	2	1	1	1
PL.6109	PL.10177	B	6 A (CWC)	7.28Y	121.3	0.21	3.72	30.64	22	218	47	98	0.35	0.2	9.978	0.156	2	0	1	50
PL.6111	PL.6109	B	6 A (CWC)	7.27Y	121.1	0.17	3.89	29.71	21	211	45	98	0.27	0.1	10.103	0.124	0	0	0	48
PL.5684	PL.6111	B	6 A (CWC)	7.27Y	121.1	0.00	3.89	1.43	1	10	2	98	0.00	0.0	10.177	0.074	3	1	1	4
PL.5685	PL.5684	B	#4 ACSR	7.27Y	121.1	0.01	3.90	1.07	1	8	2	97	0.00	0.0	10.428	0.251	0	0	0	3
PL.5686	PL.5685	B	#1/0 ACSR	7.27Y	121.1	0.00	3.90	0.43	0	3	1	95	0.00	0.0	10.476	0.049	3	1	1	1
PL.6479	PL.5685	B	#4 ACSR	7.27Y	121.1	0.00	3.90	0.65	0	5	1	98	0.00	0.0	10.466	0.038	1	0	1	2
PL.6480	PL.6479	B	#4 ACSR	7.27Y	121.1	0.00	3.90	0.55	0	4	1	97	0.00	0.0	10.590	0.124	4	1	1	1
PL.5814	PL.6111	B	6 A (CWC)	7.26Y	121.0	0.12	4.01	28.28	20	201	43	98	0.18	0.1	10.197	0.094	0	0	0	44
PL.5815	PL.5814	B	6 A (CWC)	7.24Y	120.7	0.26	4.27	27.55	20	196	42	98	0.38	0.2	10.412	0.215	10	2	1	42
PL.6478	PL.5815	B	6 A (CWC)	7.23Y	120.4	0.32	4.58	26.14	19	185	40	98	0.44	0.2	10.694	0.282	14	3	2	41
PL.6785	PL.6478	B	6 A (CWC)	7.22Y	120.4	0.00	4.59	23.98	17	169	36	98	0.01	0.0	10.699	0.005	0	0	0	38
PD.1430	PL.6785	B	30T	7.22Y	120.4	0.00	4.59	23.98	0	169	36	98	0.00	0.0	10.699	0.005	0	0	0	38
PL.6786	PD.1430	B	6 A (CWC)	7.22Y	120.4	0.06	4.65	23.98	17	169	36	98	0.08	0.0	10.757	0.058	4	1	2	38
PL.6476	PL.6786	B	6 A (CWC)	7.21Y	120.2	0.12	4.77	23.45	17	166	35	98	0.16	0.1	10.874	0.117	0	0	0	36
PL.6475	PL.6476	B	6 A (CWC)	7.21Y	120.2	0.04	4.81	23.45	17	165	35	98	0.05	0.0	10.913	0.040	14	3	2	36
PL.6474	PL.6475	B	6 A (CWC)	7.21Y	120.1	0.07	4.89	21.50	15	152	32	98	0.09	0.1	10.993	0.080	9	2	2	34
PL.6473	PL.6474	B	6 A (CWC)	7.20Y	120.1	0.04	4.92	20.28	14	143	30	98	0.04	0.0	11.033	0.040	0	0	1	32
PL.6472	PL.6473	B	6 A (CWC)	7.19Y	119.9	0.18	5.11	20.28	14	143	30	98	0.20	0.1	11.239	0.206	9	2	2	31
PL.6113	PL.6472	B	6 A (CWC)	7.19Y	119.8	0.07	5.18	18.33	13	129	27	98	0.07	0.1	11.324	0.085	0	0	0	26
PL.5972	PL.6113	B	6 A (CWC)	7.18Y	119.6	0.23	5.41	18.33	13	129	27	98	0.23	0.2	11.615	0.290	8	2	2	26
PL.6471	PL.5972	B	6 A (CWC)	7.17Y	119.5	0.07	5.47	17.19	12	121	25	98	0.06	0.1	11.703	0.088	0	0	0	24
PL.6815	PL.6471	B	6 A (CWC)	7.17Y	119.5	0.00	5.48	11.15	8	78	17	98	0.00	0.0	11.705	0.003	0	0	0	17
PD.1447	PL.6815	B	25H	7.17Y	119.5	0.00	5.48	11.15	45	78	17	98	0.00	0.0	11.705	0.003	0	0	0	17
PL.6816	PD.1447	B	6 A (CWC)	7.16Y	119.4	0.12	5.60	11.15	8	78	17	98	0.07	0.1	11.951	0.245	0	0	0	17
PL.6469	PL.6816	B	6 A (CWC)	7.16Y	119.4	0.05	5.65	11.15	8	78	16	98	0.03	0.0	12.059	0.108	11	2	2	17
PL.5692	PL.6469	B	#1/0 ACSR	7.16Y	119.4	0.00	5.65	0.80	0	6	1	99	0.00	0.0	12.119	0.060	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PL.6115	PL.6469	B	6 A (CWC)	7.16Y	119.3	0.08	5.73	8.77	6	61	13	98	0.04	0.1	12.272	0.213	4	1	1	14
PL.6467	PL.6115	B	6 A (CWC)	7.15Y	119.2	0.03	5.76	8.24	6	58	12	98	0.01	0.0	12.360	0.089	5	1	2	13
PL.6465	PL.6467	B	6 A (CWC)	7.15Y	119.2	0.04	5.80	7.56	5	53	11	98	0.02	0.0	12.485	0.124	0	0	0	11
PL.6464	PL.6465	B	6 A (CWC)	7.15Y	119.2	0.02	5.83	7.56	5	53	11	98	0.01	0.0	12.552	0.067	0	0	0	11
PL.5818	PL.6464	B	6 A (CWC)	7.15Y	119.1	0.04	5.87	6.17	4	43	9	98	0.01	0.0	12.712	0.160	0	0	0	9
PL.5819	PL.5818	B	6 A (CWC)	7.14Y	119.1	0.08	5.95	4.68	3	33	7	98	0.02	0.1	13.076	0.364	0	0	1	6
PL.5699	PL.5819	B	6 A (CWC)	7.14Y	119.1	0.00	5.95	0.76	1	5	1	98	0.00	0.0	13.208	0.132	5	1	1	1
PL.28281	PL.5699	B	#1/0 ACSR	7.14Y	119.1	0.00	5.95	0.00	0	0	0	100	0.00	0.0	13.247	0.038	0	0	0	0
PL.5697	PL.5819	B	6 A (CWC)	7.14Y	119.0	0.04	5.99	3.85	3	27	6	98	0.01	0.0	13.307	0.231	0	0	0	4
PL.5707	PL.5697	B	#4 ACSR	7.14Y	119.0	0.03	6.01	3.85	3	27	6	98	0.01	0.0	13.475	0.168	0	0	0	4
PL.6460	PL.5707	B	#4 ACSR	7.14Y	119.0	0.01	6.03	2.59	2	18	4	98	0.00	0.0	13.574	0.099	0	0	0	3
PL.6461	PL.6460	B	#4 ACSR	7.14Y	119.0	0.01	6.03	2.59	2	18	4	98	0.00	0.0	13.663	0.088	9	2	1	3
PL.6459	PL.6461	B	#4 ACSR	7.14Y	119.0	0.01	6.05	1.25	1	9	2	98	0.00	0.0	13.885	0.222	0	0	1	2
PL.5698	PL.6459	B	#4 ACSR	7.14Y	119.0	0.00	6.05	1.24	1	9	2	98	0.00	0.0	14.048	0.164	9	2	1	1
PL.5706	PL.5707	B	#4 ACSR	7.14Y	119.0	0.00	6.02	1.26	1	9	2	98	0.00	0.0	13.546	0.071	9	2	1	1
PL.5694	PL.5818	B	6 A (CWC)	7.15Y	119.1	0.00	5.88	1.50	1	10	2	98	0.00	0.0	12.795	0.084	3	1	2	3
PL.5695	PL.5694	B	#4 ACSR	7.15Y	119.1	0.00	5.88	1.05	1	7	2	96	0.00	0.0	12.871	0.075	7	2	1	1
PL.5693	PL.6464	B	#2 ACSR	7.15Y	119.2	0.00	5.83	1.39	1	10	2	98	0.00	0.0	12.579	0.027	10	2	2	2
PL.6511	PL.6471	B	6 A (CWC)	7.17Y	119.5	0.02	5.50	6.04	4	42	9	98	0.01	0.0	11.794	0.091	1	0	1	7
PL.6512	PL.6511	B	6 A (CWC)	7.17Y	119.5	0.01	5.51	5.85	4	41	9	98	0.00	0.0	11.836	0.042	19	4	2	6
PL.6510	PL.6512	B	6 A (CWC)	7.17Y	119.5	0.01	5.52	3.07	2	22	5	98	0.00	0.0	11.926	0.090	0	0	0	4
PL.6509	PL.6510	B	6 A (CWC)	7.17Y	119.5	0.01	5.53	3.07	2	22	5	98	0.00	0.0	11.999	0.073	0	0	0	4
PL.5700	PL.6509	B	#4 ACSR	7.17Y	119.5	0.01	5.54	0.72	1	5	1	98	0.00	0.0	12.255	0.256	0	0	0	1
PL.5701	PL.5700	B	6 A (CWC)	7.17Y	119.5	0.01	5.55	0.72	1	5	1	98	0.00	0.0	12.488	0.233	0	0	0	1
PL.5702	PL.5701	B	#4 ACSR	7.17Y	119.5	0.00	5.55	0.72	1	5	1	98	0.00	0.0	12.520	0.032	0	0	0	1
PL.64872	PL.5702	B	#4 ACSR	7.17Y	119.5	0.00	5.55	0.00	0	0	0	100	0.00	0.0	12.523	0.003	0	0	0	0
PL.5703	PL.5702	B	6 A (CWC)	7.17Y	119.5	0.00	5.55	0.72	1	5	1	98	0.00	0.0	12.669	0.149	5	1	1	1
PL.5817	PL.6509	B	6 A (CWC)	7.17Y	119.5	0.01	5.54	2.35	2	16	3	98	0.00	0.0	12.064	0.065	7	2	1	3
PL.5705	PL.5817	B	#1/0 ACSR	7.17Y	119.5	0.00	5.54	1.32	1	9	2	98	0.00	0.0	12.194	0.129	9	2	2	2
PL.6711	PL.6472	B	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.70	0	5	1	98	0.00	0.0	11.244	0.005	0	0	0	3
PD.1391	PL.6711	B	30T	7.19Y	119.9	0.00	5.11	0.70	0	5	1	98	0.00	0.0	11.244	0.005	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6712	PD.1391	B	6 A (CWC)	7.19Y	119.9	0.01	5.12	0.70	0	5	1	98	0.00	0.0	11.693	0.449	0	0	0	3
PL.5690	PL.6712	B	#4 ACSR	7.19Y	119.9	0.00	5.12	0.30	0	2	0	100	0.00	0.0	11.742	0.049	2	0	1	1
PL.5691	PL.6712	B	#4 ACSR	7.19Y	119.9	0.01	5.12	0.40	0	3	1	95	0.00	0.0	12.128	0.435	2	0	1	2
PL.6463	PL.5691	B	#4 ACSR	7.19Y	119.9	0.00	5.13	0.16	0	1	0	100	0.00	0.0	12.189	0.061	1	0	1	1
PL.5689	PL.6712	B	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.00	0	0	0	100	0.00	0.0	12.210	0.517	0	0	0	0
PL.33057	PL.6478	B	6 A (CWC)	7.23Y	120.4	0.00	4.58	0.16	0	1	0	100	0.00	0.0	10.727	0.033	0	0	0	1
PL.33058	PL.33057	B	6 A (CWC)	7.22Y	120.4	0.00	4.59	0.16	0	1	0	100	0.00	0.0	11.049	0.321	0	0	0	1
PL.5816	PL.33058	B	6 A (CWC)	7.22Y	120.4	0.00	4.59	0.00	0	0	0	100	0.00	0.0	11.078	0.029	0	0	0	0
PL.5688	PL.33058	B	#2 ACSR	7.22Y	120.4	0.00	4.59	0.16	0	1	0	100	0.00	0.0	11.121	0.073	1	0	1	1
PL.6483	PL.5814	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	0.73	1	5	1	98	0.00	0.0	10.216	0.019	0	0	0	2
PL.6484	PL.6483	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	0.73	1	5	1	98	0.00	0.0	10.405	0.190	4	1	1	2
PL.6482	PL.6484	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	0.18	0	1	0	100	0.00	0.0	10.459	0.054	1	0	1	1
PL.5683	PL.6109	B	#4 ACSR	7.28Y	121.3	0.00	3.72	0.65	0	5	1	98	0.00	0.0	10.037	0.059	5	1	1	1
PL.5681	PL.6485	B	#4 ACSR	7.31Y	121.8	0.00	3.23	0.85	1	6	1	99	0.00	0.0	9.692	0.055	6	1	1	1
PL.6488	PL.5810	B	#1/0 ACSR	7.37Y	122.8	0.00	2.23	2.33	1	17	4	97	0.00	0.0	9.049	0.037	2	0	1	4
PL.6713	PL.6488	B	#1/0 ACSR	7.37Y	122.8	0.00	2.23	2.06	1	15	3	98	0.00	0.0	9.053	0.004	0	0	0	3
PD.1392	PL.6713	B	30T	7.37Y	122.8	0.00	2.23	2.06	0	15	3	98	0.00	0.0	9.053	0.004	0	0	0	3
PL.6714	PD.1392	B	#1/0 ACSR	7.37Y	122.8	0.02	2.24	2.06	1	15	3	98	0.00	0.0	9.390	0.337	0	0	0	3
PL.5812	PL.6714	B	#1/0 ACSR	7.37Y	122.8	0.00	2.24	1.08	0	8	2	97	0.00	0.0	9.415	0.024	8	2	2	2
PL.5679	PL.6714	B	#1/0 ACSR	7.37Y	122.8	0.00	2.25	0.98	0	7	1	99	0.00	0.0	9.600	0.210	7	1	1	1
PL.6549	PL.7233	A	#1/0 ACSR	7.46Y	124.3	0.00	0.72	0.41	0	3	1	95	0.00	0.0	7.557	0.005	0	0	0	1
PD.1304	PL.6549	A	40T	7.46Y	124.3	0.00	0.72	0.41	0	3	1	95	0.00	0.0	7.557	0.005	0	0	0	1
PL.6550	PD.1304	A	#1/0 ACSR	7.46Y	124.3	0.00	0.72	0.41	0	3	1	95	0.00	0.0	7.628	0.071	3	1	1	1
CP.12	PL.7232	ABC	Cap (300)	7.46Y	124.3	0.00	0.70	0.00	0	0	0	100	0.00	0.0	7.389	0.071	0	0	0	0
PL.5656	PL.6157	B	#1/0 ACSR	7.46Y	124.3	0.00	0.70	3.83	2	28	6	98	0.00	0.0	7.368	0.026	0	0	0	7
PL.6818	PL.5656	B	6 A (CWC)	7.46Y	124.3	0.00	0.70	3.83	3	28	6	98	0.00	0.0	7.371	0.003	0	0	0	7
PD.1450	PL.6818	B	35L	7.46Y	124.3	0.00	0.70	3.83	11	28	6	98	0.00	0.0	7.371	0.003	0	0	0	7
PL.6819	PD.1450	B	6 A (CWC)	7.46Y	124.3	0.00	0.70	3.83	3	28	6	98	0.00	0.0	7.398	0.027	0	0	0	7
PL.10183	PL.6819	B	6 A (CWC)	7.46Y	124.3	0.01	0.71	2.84	2	21	4	98	0.00	0.0	7.509	0.111	3	1	1	5
PL.10184	PL.10183	B	6 A (CWC)	7.46Y	124.3	0.01	0.73	2.45	2	18	4	98	0.00	0.0	7.636	0.127	0	0	0	4
PL.6457	PL.10184	B	6 A (CWC)	7.46Y	124.3	0.01	0.73	2.45	2	18	4	98	0.00	0.0	7.689	0.053	5	1	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.6455	PL.6457	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	1.82	1	13	3	97	0.00	0.0	7.747	0.059	2	0	1	3
PL.5657	PL.6455	B	#4 ACSR	7.45Y	124.2	0.02	0.75	1.51	1	11	2	98	0.00	0.0	8.144	0.397	8	2	1	2
PL.5658	PL.5657	B	#2 ACSR	7.45Y	124.2	0.00	0.76	0.46	0	3	1	95	0.00	0.0	8.184	0.040	3	1	1	1
PL.7251	PL.6819	B	#1/0 ACSR	7.46Y	124.3	0.00	0.70	0.99	0	7	2	96	0.00	0.0	7.466	0.068	7	2	2	2
PL.6553	PL.6159	C	#4 ACSR	7.46Y	124.4	0.00	0.63	0.88	1	6	1	99	0.00	0.0	6.880	0.005	0	0	0	3
PD.1306	PL.6553	C	40T	7.46Y	124.4	0.00	0.63	0.88	0	6	1	99	0.00	0.0	6.880	0.005	0	0	0	3
PL.6554	PD.1306	C	#4 ACSR	7.46Y	124.4	0.00	0.63	0.88	1	6	1	99	0.00	0.0	6.909	0.029	6	1	2	3
PL.5655	PL.6554	C	#4 ACSR	7.46Y	124.4	0.00	0.63	0.03	0	0	0	100	0.00	0.0	7.137	0.229	0	0	1	1
PL.6781	PL.6159	A	#2 ACSR	7.46Y	124.4	0.00	0.63	0.88	1	6	1	99	0.00	0.0	6.880	0.005	0	0	0	4
PD.1428	PL.6781	A	40T	7.46Y	124.4	0.00	0.63	0.88	0	6	1	99	0.00	0.0	6.880	0.005	0	0	0	4
PL.6782	PD.1428	A	#2 ACSR	7.46Y	124.4	0.00	0.63	0.88	1	6	1	99	0.00	0.0	6.927	0.047	3	1	2	4
PL.6158	PL.6782	A	#2 ACSR	7.46Y	124.4	0.00	0.64	0.51	0	4	1	97	0.00	0.0	7.125	0.198	0	0	0	2
PL.5802	PL.6158	A	#2 ACSR	7.46Y	124.4	0.00	0.64	0.17	0	1	0	100	0.00	0.0	7.166	0.041	1	0	1	1
PL.5654	PL.6158	A	#1/0 ACSR	7.46Y	124.4	0.00	0.64	0.34	0	2	1	89	0.00	0.0	7.299	0.174	2	1	1	1
PL.5629	PL.7229	B	6 A (CWC)	7.46Y	124.4	0.07	0.64	19.22	14	140	30	98	0.08	0.1	6.469	0.085	0	0	0	59
PL.7230	PL.5629	B	6 A (CWC)	7.46Y	124.4	0.00	0.64	19.22	14	140	30	98	0.00	0.0	6.472	0.003	0	0	0	59
PD.1560	PL.7230	B	35L	7.46Y	124.4	0.00	0.64	19.22	55	140	30	98	0.00	0.0	6.472	0.003	0	0	0	59
PL.7231	PD.1560	B	6 A (CWC)	7.45Y	124.2	0.18	0.82	19.22	14	140	30	98	0.19	0.1	6.680	0.207	0	0	0	59
PL.6709	PL.7231	B	6 A (CWC)	7.45Y	124.2	0.00	0.82	6.06	4	44	9	98	0.00	0.0	6.684	0.005	0	0	0	15
PD.1389	PL.6709	B	40T	7.45Y	124.2	0.00	0.82	6.06	0	44	9	98	0.00	0.0	6.684	0.005	0	0	0	15
PL.6710	PD.1389	B	6 A (CWC)	7.45Y	124.2	0.01	0.83	6.06	4	44	9	98	0.00	0.0	6.737	0.052	2	0	2	15
PL.6445	PL.6710	B	6 A (CWC)	7.45Y	124.2	0.01	0.85	5.76	4	42	9	98	0.00	0.0	6.787	0.050	2	1	2	13
PL.6446	PL.6445	B	6 A (CWC)	7.45Y	124.1	0.06	0.91	5.42	4	39	8	98	0.02	0.0	7.040	0.253	1	0	1	11
PL.6444	PL.6446	B	6 A (CWC)	7.44Y	124.1	0.01	0.92	5.31	4	39	8	98	0.00	0.0	7.105	0.065	4	1	2	10
PL.6442	PL.6444	B	6 A (CWC)	7.44Y	124.1	0.00	0.93	4.82	3	35	7	98	0.00	0.0	7.127	0.022	0	0	0	8
PL.5638	PL.6442	B	6 A (CWC)	7.44Y	124.1	0.01	0.94	4.82	3	35	7	98	0.00	0.0	7.173	0.046	0	0	0	8
PL.5640	PL.5638	B	#1/0 ACSR	7.44Y	124.1	0.00	0.94	1.01	0	7	2	96	0.00	0.0	7.289	0.116	7	2	2	2
PL.6440	PL.5638	B	#1/0 ACSR	7.44Y	124.1	0.00	0.94	3.81	2	28	6	98	0.00	0.0	7.209	0.036	8	2	1	6
PL.6441	PL.6440	B	#1/0 ACSR	7.44Y	124.1	0.01	0.95	2.73	1	20	4	98	0.00	0.0	7.387	0.177	9	2	3	5
PL.5639	PL.6441	B	#2 ACSR	7.44Y	124.1	0.00	0.95	0.78	0	6	1	99	0.00	0.0	7.442	0.056	6	1	1	1
PL.6026	PL.6441	B	#1/0 ACSR	7.44Y	124.1	0.00	0.95	0.65	0	5	1	98	0.00	0.0	7.434	0.047	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5631	PL.7231	B	6 A (CWC)	7.45Y	124.1	0.04	0.86	13.16	9	96	20	98	0.03	0.0	6.744	0.065	0	0	0	44
PL.5632	PL.5631	B	6 A (CWC)	7.45Y	124.1	0.00	0.86	0.37	0	3	1	95	0.00	0.0	6.803	0.059	3	1	2	2
PL.5633	PL.5631	B	6 A (CWC)	7.45Y	124.1	0.01	0.87	12.79	9	93	20	98	0.01	0.0	6.769	0.025	0	0	0	42
PL.5635	PL.5633	B	#4 ACSR	7.44Y	124.1	0.06	0.94	10.81	8	79	17	98	0.04	0.0	6.904	0.135	0	0	0	30
PL.5636	PL.5635	B	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.03	0	0	0	100	0.00	0.0	6.948	0.044	0	0	1	1
PL.5796	PL.5635	B	#4 ACSR	7.44Y	124.0	0.05	0.99	10.79	8	79	17	98	0.03	0.0	7.022	0.117	3	1	1	29
PL.6438	PL.5796	B	6 A (CWC)	7.44Y	124.0	0.03	1.02	10.38	7	76	16	98	0.01	0.0	7.083	0.062	8	2	2	28
PL.6439	PL.6438	B	6 A (CWC)	7.44Y	124.0	0.01	1.03	9.34	7	68	14	98	0.00	0.0	7.107	0.024	16	3	3	26
PL.6437	PL.6439	B	6 A (CWC)	7.44Y	124.0	0.01	1.04	7.09	5	52	11	98	0.00	0.0	7.149	0.041	5	1	1	23
PL.6436	PL.6437	B	6 A (CWC)	7.44Y	123.9	0.02	1.06	6.35	5	46	10	98	0.01	0.0	7.212	0.063	0	0	0	22
PL.5641	PL.6436	B	#1/0 ACSR	7.44Y	123.9	0.00	1.06	2.02	1	15	3	98	0.00	0.0	7.234	0.023	7	1	1	2
PL.5642	PL.5641	B	#1/0 ACSR	7.44Y	123.9	0.00	1.06	1.09	0	8	2	97	0.00	0.0	7.336	0.102	8	2	1	1
PL.6031	PL.6436	B	6 A (CWC)	7.43Y	123.9	0.04	1.10	4.34	3	32	7	98	0.01	0.0	7.426	0.215	0	0	0	20
PL.5797	PL.6031	B	6 A (CWC)	7.43Y	123.9	0.01	1.10	1.16	1	8	2	97	0.00	0.0	7.541	0.115	0	0	0	7
PL.5647	PL.5797	B	6 A (CWC)	7.43Y	123.9	0.00	1.11	0.98	1	7	2	96	0.00	0.0	7.609	0.068	0	0	0	6
PL.5649	PL.5647	B	#2 ACSR	7.43Y	123.9	0.00	1.11	0.30	0	2	0	100	0.00	0.0	7.652	0.043	2	0	1	1
PL.5798	PL.5647	B	6 A (CWC)	7.43Y	123.9	0.00	1.11	0.68	0	5	1	98	0.00	0.0	7.706	0.097	0	0	0	5
PL.5799	PL.5798	B	6 A (CWC)	7.43Y	123.9	0.00	1.11	0.00	0	0	0	100	0.00	0.0	8.003	0.297	0	0	0	0
PD.1442-B	PL.5799	B	Open	7.43Y	123.9	0.00	1.11	0.00	0	0	0	100	0.00	0.0	8.003	0.297	0	0	0	0
PL.7252	PL.5798	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	0.39	0	3	1	95	0.00	0.0	7.769	0.063	3	1	1	1
PL.5650	PL.5798	B	6 A (CWC)	7.43Y	123.9	0.00	1.11	0.29	0	2	0	100	0.00	0.0	7.819	0.113	1	0	1	4
PL.6432	PL.5650	B	#2 ACSR	7.43Y	123.9	0.00	1.11	0.17	0	1	0	100	0.00	0.0	7.886	0.068	0	0	0	3
PL.6433	PL.6432	B	#2 ACSR	7.43Y	123.9	0.00	1.11	0.17	0	1	0	100	0.00	0.0	7.946	0.059	0	0	0	3
PL.5652	PL.6433	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	0.13	0	1	0	100	0.00	0.0	8.114	0.169	1	0	1	1
PL.5800	PL.6433	B	#2 ACSR	7.43Y	123.9	0.00	1.11	0.04	0	0	0	100	0.00	0.0	8.003	0.058	0	0	2	2
PL.5651	PL.5650	B	#2 ACSR	7.43Y	123.9	0.00	1.11	0.00	0	0	0	100	0.00	0.0	7.861	0.042	0	0	0	0
PL.5648	PL.5797	B	6 A (CWC)	7.43Y	123.9	0.00	1.10	0.18	0	1	0	100	0.00	0.0	7.625	0.084	1	0	1	1
PL.5643	PL.6031	B	6 A (CWC)	7.43Y	123.9	0.01	1.10	3.18	2	23	5	98	0.00	0.0	7.463	0.037	1	0	2	13
PL.6434	PL.5643	B	6 A (CWC)	7.43Y	123.9	0.01	1.11	3.04	2	22	5	98	0.00	0.0	7.524	0.061	5	1	1	11
PL.6435	PL.6434	B	6 A (CWC)	7.43Y	123.9	0.01	1.12	2.41	2	18	4	98	0.00	0.0	7.636	0.112	3	1	4	10
PL.5645	PL.6435	B	#4 ACSR	7.43Y	123.9	0.00	1.12	1.99	2	14	3	98	0.00	0.0	7.651	0.015	0	0	0	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5644	PL.5645	B	6 A (CWC)	7.43Y	123.9	0.01	1.13	1.99	1	14	3	98	0.00	0.0	7.726	0.075	1	0	2	6
PL.5646	PL.5644	B	#4 ACSR	7.43Y	123.9	0.00	1.13	1.78	1	13	3	97	0.00	0.0	7.799	0.074	6	1	1	4
PL.5710	PL.5646	B	#4 ACSR	7.43Y	123.9	0.00	1.13	0.05	0	0	0	100	0.00	0.0	7.834	0.035	0	0	1	1
PL.6517	PL.5646	B	#2 ACSR	7.43Y	123.9	0.00	1.13	0.93	1	7	1	99	0.00	0.0	7.845	0.046	0	0	1	2
PL.6518	PL.6517	B	#2 ACSR	7.43Y	123.9	0.00	1.14	0.92	1	7	1	99	0.00	0.0	7.944	0.099	7	1	1	1
PL.5634	PL.5633	B	6 A (CWC)	7.45Y	124.1	0.00	0.87	1.19	1	9	2	98	0.00	0.0	6.788	0.019	0	0	0	10
PL.5795	PL.5634	B	6 A (CWC)	7.45Y	124.1	0.00	0.87	0.78	1	6	1	99	0.00	0.0	6.798	0.010	6	1	2	2
PL.6453	PL.5634	B	6 A (CWC)	7.45Y	124.1	0.00	0.87	0.42	0	3	1	95	0.00	0.0	6.851	0.063	0	0	1	8
PL.6454	PL.6453	B	6 A (CWC)	7.45Y	124.1	0.00	0.87	0.41	0	3	1	95	0.00	0.0	6.920	0.069	0	0	0	7
PL.5637	PL.6454	B	6 A (CWC)	7.45Y	124.1	0.00	0.88	0.41	0	3	1	95	0.00	0.0	7.013	0.092	3	1	1	1
PL.6451	PL.6454	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	6.970	0.049	0	0	2	6
PL.6452	PL.6451	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	7.029	0.059	0	0	0	4
PL.6449	PL.6452	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	7.120	0.091	0	0	1	2
PL.6450	PL.6449	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	7.201	0.081	0	0	1	1
PL.6447	PL.6452	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	7.085	0.056	0	0	1	2
PL.6448	PL.6447	B	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	7.138	0.053	0	0	1	1
PL.5794	PL.5633	B	6 A (CWC)	7.45Y	124.1	0.00	0.87	0.79	1	6	1	99	0.00	0.0	6.790	0.020	6	1	2	2
PL.5630	PL.5629	B	6 A (CWC)	7.46Y	124.4	0.00	0.64	0.00	0	0	0	100	0.00	0.0	6.524	0.055	0	0	0	0
PL.6569	PL.7227	B	#4 ACSR	7.11Y	118.5	0.00	6.53	4.73	4	33	7	98	0.00	0.0	5.063	0.005	0	0	0	7
PD.1314	PL.6569	B	40T	7.11Y	118.5	0.00	6.53	4.73	0	33	7	98	0.00	0.0	5.063	0.005	0	0	0	7
PL.6570	PD.1314	B	#4 ACSR	7.11Y	118.5	0.00	6.53	4.73	4	33	7	98	0.00	0.0	5.072	0.009	6	1	1	7
PL.6173	PL.6570	B	#4 ACSR	7.11Y	118.5	0.01	6.54	3.90	3	27	6	98	0.00	0.0	5.135	0.063	3	1	2	6
PL.5623	PL.6173	B	#2 ACSR	7.11Y	118.5	0.00	6.54	2.67	2	19	4	98	0.00	0.0	5.188	0.053	19	4	2	2
PL.5624	PL.6173	B	#2 ACSR	7.11Y	118.5	0.00	6.54	0.74	0	5	1	98	0.00	0.0	5.180	0.046	5	1	1	2
PL.5625	PL.5624	B	#2 ACSR	7.11Y	118.5	0.00	6.54	0.08	0	1	0	100	0.00	0.0	5.229	0.048	1	0	1	1
PL.6567	PL.5588	C	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.33	0	2	0	100	0.00	0.0	4.826	0.005	0	0	0	1
PD.1313	PL.6567	C	65T	7.11Y	118.5	0.00	6.46	0.33	0	2	0	100	0.00	0.0	4.826	0.005	0	0	0	1
PL.6568	PD.1313	C	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.33	0	2	0	100	0.00	0.0	5.015	0.188	2	0	1	1
PL.6171	PL.6568	C	6 A (CWC)	7.11Y	118.5	0.00	6.46	0.00	0	0	0	100	0.00	0.0	5.050	0.036	0	0	0	0
PL.5589	PL.5601	B	#1/0 ACSR	7.11Y	118.6	0.04	6.43	13.27	6	92	20	98	0.02	0.0	4.730	0.127	0	0	0	16
PL.6809	PL.5589	B	6 A (CWC)	7.11Y	118.5	0.03	6.46	12.50	9	87	18	98	0.02	0.0	4.788	0.059	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1444	PL.6809	B	50L	7.11Y	118.5	0.00	6.46	12.50	25	87	18	98	0.00	0.0	4.788	0.059	0	0	0	14
PL.6810	PD.1444	B	6 A (CWC)	7.11Y	118.5	0.03	6.49	12.50	9	87	18	98	0.02	0.0	4.849	0.060	0	0	0	14
PL.5779	PL.6810	B	6 A (CWC)	7.11Y	118.5	0.04	6.53	12.50	9	87	18	98	0.02	0.0	4.912	0.063	0	0	0	14
PL.6198	PL.5779	B	6 A (CWC)	7.11Y	118.4	0.02	6.55	12.50	9	87	18	98	0.02	0.0	4.952	0.040	0	0	0	14
PL.6199	PL.6198	B	6 A (CWC)	7.10Y	118.4	0.04	6.60	12.50	9	87	18	98	0.03	0.0	5.037	0.085	11	2	1	14
PL.6196	PL.6199	B	6 A (CWC)	7.10Y	118.4	0.01	6.61	10.90	8	76	16	98	0.00	0.0	5.055	0.018	8	2	1	13
PL.6197	PL.6196	B	6 A (CWC)	7.10Y	118.3	0.06	6.67	9.80	7	68	14	98	0.03	0.0	5.199	0.144	1	0	1	12
PL.6195	PL.6197	B	6 A (CWC)	7.09Y	118.2	0.15	6.81	9.63	7	67	14	98	0.08	0.1	5.534	0.336	0	0	0	11
L PL.5592	PL.6195	B	6 A (CWC)	7.08Y	118.0	0.22	7.03	9.63	7	67	14	98	0.11	0.2	6.039	0.504	0	0	0	11 L
L PL.5594	PL.5592	B	6 A (CWC)	7.07Y	117.9	0.07	7.10	6.40	5	44	9	98	0.02	0.0	6.296	0.258	8	2	2	7 L
L PL.5599	PL.5594	B	#4 ACSR	7.07Y	117.9	0.00	7.10	2.56	2	18	4	98	0.00	0.0	6.357	0.061	18	4	3	3 L
L PL.5600	PL.5594	B	#4 ACSR	7.07Y	117.9	0.00	7.10	2.70	2	19	4	98	0.00	0.0	6.368	0.072	19	4	2	2 L
L PL.5593	PL.5592	B	6 A (CWC)	7.08Y	117.9	0.03	7.07	3.23	2	22	5	98	0.01	0.0	6.276	0.238	0	0	0	4 L
L PL.6149	PL.5593	B	6 A (CWC)	7.08Y	117.9	0.00	7.07	0.18	0	1	0	100	0.00	0.0	6.340	0.063	1	0	1	2 L
L PL.6150	PL.6149	B	6 A (CWC)	7.08Y	117.9	0.00	7.07	0.07	0	0	0	100	0.00	0.0	6.433	0.093	0	0	1	1 L
L PL.5596	PL.5593	B	#1/0 ACSR	7.08Y	117.9	0.00	7.07	3.05	1	21	4	98	0.00	0.0	6.321	0.044	0	0	0	2 L
L PL.5597	PL.5596	B	#1/0 ACSR	7.08Y	117.9	0.00	7.07	1.66	1	12	2	99	0.00	0.0	6.431	0.110	12	2	1	1 L
L PL.5780	PL.5596	B	#1/0 ACSR	7.08Y	117.9	0.00	7.07	1.38	1	10	2	98	0.00	0.0	6.415	0.094	10	2	1	1 L
PL.5591	PL.6810	B	#4 ACSR	7.11Y	118.5	0.00	6.49	0.00	0	0	0	100	0.00	0.0	5.011	0.163	0	0	0	0
PL.5590	PL.5589	B	#4 ACSR	7.11Y	118.6	0.00	6.43	0.77	1	5	1	98	0.00	0.0	4.749	0.019	5	1	2	2
PL.6791	PL.6201	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.17	8.31	4	176	28	99	0.00	0.0	4.167	0.005	0	0	0	39
PD.1434	PL.6791	ABC	65T	7.13Y	118.8	0.00	6.17	8.31	0	176	28	99	0.00	0.0	4.167	0.005	0	0	0	39
PL.6792	PD.1434	ABC	#1/0 ACSR	7.13Y	118.8	0.01	6.18	8.31	4	176	28	99	0.02	0.0	4.257	0.090	0	0	1	39
PL.6204	PL.6792	ABC	#1/0 ACSR	7.13Y	118.8	0.01	6.19	7.71	3	163	25	99	0.01	0.0	4.327	0.070	0	0	0	36
PL.6205	PL.6204	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.20	7.71	3	163	25	99	0.01	0.0	4.363	0.036	6	1	1	36
PL.6206	PL.6205	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.20	7.40	3	157	24	99	0.00	0.0	4.395	0.032	0	0	0	35
PL.6080	PL.6206	ABC	#1/0 ACSR	7.13Y	118.8	0.01	6.21	7.40	3	157	24	99	0.01	0.0	4.439	0.044	2	0	1	35
PL.6571	PL.6080	C	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.96	0	7	1	99	0.00	0.0	4.443	0.004	0	0	0	1
PD.1315	PL.6571	C	40T	7.13Y	118.8	0.00	6.21	0.96	0	7	1	99	0.00	0.0	4.443	0.004	0	0	0	1
PL.6572	PD.1315	C	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.96	0	7	1	99	0.00	0.0	4.486	0.043	7	1	1	1
PL.6773	PL.6080	A	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.78	0	5	1	98	0.00	0.0	4.443	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1424	PL.6773	A	40T	7.13Y	118.8	0.00	6.21	0.78	0	5	1	98	0.00	0.0	4.443	0.005	0	0	0	2
PL.6774	PD.1424	A	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.78	0	5	1	98	0.00	0.0	4.469	0.025	5	1	2	2
PL.6215	PL.6080	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.21	6.72	3	142	21	99	0.00	0.0	4.474	0.035	16	3	2	31
PL.6216	PL.6215	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.21	5.93	3	126	17	99	0.00	0.0	4.501	0.027	0	0	0	29
PL.6581	PL.6216	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	11.34	7	80	14	99	0.00	0.0	4.505	0.005	0	0	0	21
PD.1321	PL.6581	C	40T	7.13Y	118.8	0.00	6.21	11.34	0	80	14	99	0.00	0.0	4.505	0.005	0	0	0	21
PL.6582	PD.1321	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	11.34	7	80	14	99	0.00	0.0	4.510	0.004	0	0	0	21
PL.6075	PL.6582	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	11.34	7	80	14	99	0.00	0.0	4.511	0.002	0	0	0	21
PL.5719	PL.6075	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	11.34	7	80	14	99	0.00	0.0	4.517	0.006	0	0	0	21
PL.6073	PL.5719	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	11.34	7	80	14	99	0.00	0.0	4.525	0.008	0	0	0	21
PL.5720	PL.6073	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	11.34	7	80	14	99	0.00	0.0	4.535	0.010	0	0	0	21
PL.5514	PL.5720	C	1/0 AL URD	7.13Y	118.8	0.00	6.23	11.34	7	80	14	99	0.00	0.0	4.549	0.014	0	0	0	21
PL.5721	PL.5514	C	1/0 AL URD	7.13Y	118.8	0.00	6.23	11.34	7	80	14	99	0.00	0.0	4.552	0.003	0	0	0	21
PL.5510	PL.5721	C	1/0 AL URD	7.13Y	118.8	0.00	6.23	11.34	7	80	14	99	0.00	0.0	4.555	0.003	0	0	0	21
PL.5722	PL.5510	C	1/0 AL URD	7.13Y	118.8	0.00	6.23	11.35	7	80	14	99	0.00	0.0	4.557	0.002	6	1	1	21
PL.5579	PL.5722	C	1/0 AL URD	7.13Y	118.8	0.00	6.23	10.47	6	73	13	98	0.00	0.0	4.562	0.005	0	0	0	20
PL.5580	PL.5579	C	1/0 AL URD	7.13Y	118.8	0.00	6.24	10.48	6	73	13	98	0.00	0.0	4.570	0.008	0	0	0	20
PL.5581	PL.5580	C	1/0 AL URD	7.13Y	118.8	0.00	6.24	10.48	6	73	13	98	0.00	0.0	4.572	0.002	0	0	0	20
PL.6068	PL.5581	C	1/0 AL URD	7.13Y	118.8	0.00	6.24	10.48	6	73	13	98	0.00	0.0	4.580	0.009	0	0	0	20
PL.6065	PL.6068	C	1/0 AL URD	7.13Y	118.8	0.00	6.24	10.48	6	73	13	98	0.00	0.0	4.596	0.015	0	0	0	20
PL.6066	PL.6065	C	1/0 AL URD	7.13Y	118.8	0.00	6.24	0.47	0	3	1	95	0.00	0.0	4.600	0.004	0	0	0	1
PL.6579	PL.6066	C	#1/0 ACSR	7.13Y	118.8	0.00	6.24	0.47	0	3	1	95	0.00	0.0	4.604	0.005	0	0	0	1
PD.1320	PL.6579	C	25T	7.13Y	118.8	0.00	6.24	0.47	0	3	1	95	0.00	0.0	4.604	0.005	0	0	0	1
PL.6580	PD.1320	C	#1/0 ACSR	7.13Y	118.8	0.00	6.24	0.47	0	3	1	95	0.00	0.0	4.648	0.044	3	1	1	1
PL.5305	PL.6065	C	1/0 AL URD	7.12Y	118.7	0.01	6.26	10.01	6	70	13	98	0.01	0.0	4.638	0.042	0	0	0	19
PL.6063	PL.5305	C	1/0 AL URD	7.12Y	118.7	0.00	6.26	10.01	6	70	13	98	0.00	0.0	4.647	0.009	0	0	0	19
PL.6064	PL.6063	C	1/0 AL URD	7.12Y	118.7	0.00	6.26	10.01	6	70	13	98	0.00	0.0	4.648	0.001	0	0	0	19
PL.6521	PL.6064	C	1/0 AL URD	7.12Y	118.7	0.00	6.26	10.01	6	70	13	98	0.00	0.0	4.655	0.007	21	4	5	19
PL.6522	PL.6521	C	1/0 AL URD	7.12Y	118.7	0.00	6.26	6.99	4	49	8	99	0.00	0.0	4.659	0.004	0	0	0	14
PL.6061	PL.6522	C	1/0 AL URD	7.12Y	118.7	0.00	6.26	6.99	4	49	8	99	0.00	0.0	4.665	0.006	0	0	0	14
PL.5306	PL.6061	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	8	99	0.00	0.0	4.672	0.007	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5307	PL.5306	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	8	99	0.00	0.0	4.684	0.012	0	0	0	14
PL.5308	PL.5307	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	9	98	0.00	0.0	4.689	0.005	0	0	0	14
PL.6057	PL.5308	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	9	98	0.00	0.0	4.696	0.007	0	0	0	14
PL.6058	PL.6057	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	9	98	0.00	0.0	4.697	0.001	0	0	0	14
PL.6523	PL.6058	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	6.99	4	49	9	98	0.00	0.0	4.701	0.004	11	2	4	14
PL.6524	PL.6523	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	5.44	3	38	6	99	0.00	0.0	4.707	0.006	0	0	0	10
PL.6055	PL.6524	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	5.44	3	38	6	99	0.00	0.0	4.719	0.012	0	0	0	10
PL.6056	PL.6055	C	1/0 AL URD	7.12Y	118.7	0.00	6.27	5.44	3	38	6	99	0.00	0.0	4.720	0.001	0	0	0	10
PL.6525	PL.6056	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	5.44	3	38	6	99	0.00	0.0	4.726	0.005	14	3	4	10
PL.6526	PL.6525	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	3.49	2	25	4	99	0.00	0.0	4.734	0.008	0	0	0	6
PL.6052	PL.6526	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	3.49	2	25	4	99	0.00	0.0	4.770	0.037	0	0	0	6
PL.6053	PL.6052	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	3.49	2	25	4	99	0.00	0.0	4.772	0.001	0	0	0	6
PL.6527	PL.6053	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	3.49	2	25	4	99	0.00	0.0	4.792	0.020	8	2	1	6
PL.6528	PL.6527	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	2.35	1	17	2	99	0.00	0.0	4.799	0.008	0	0	0	5
PL.5566	PL.6528	C	1/0 AL URD	7.12Y	118.7	0.00	6.28	2.35	1	17	2	99	0.00	0.0	4.809	0.010	0	0	0	5
PL.5567	PL.5566	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	2.35	1	17	2	99	0.00	0.0	4.835	0.026	0	0	0	5
PL.6046	PL.5567	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	2.36	1	17	2	99	0.00	0.0	4.877	0.042	0	0	0	5
PL.6047	PL.6046	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	2.36	1	17	2	99	0.00	0.0	4.879	0.001	0	0	0	5
PL.6042	PL.6047	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	2.36	1	17	2	99	0.00	0.0	4.885	0.007	0	0	0	5
PL.6043	PL.6042	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	2.36	1	17	2	99	0.00	0.0	4.890	0.005	0	0	0	5
PL.5723	PL.6043	C	1/0 AL URD	7.12Y	118.7	0.00	6.29	0.37	0	3	1	95	0.00	0.0	4.894	0.004	3	1	1	1
PL.5568	PL.6043	C	1/0 AL URD	7.12Y	118.7	0.01	6.30	1.99	1	14	2	99	0.00	0.0	5.020	0.130	0	0	0	4
PL.5573	PL.5568	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	0.06	0	0	0	100	0.00	0.0	5.022	0.002	0	0	1	1
PL.5574	PL.5568	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	1.94	1	14	2	99	0.00	0.0	5.030	0.010	0	0	0	3
PL.5575	PL.5574	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	1.94	1	14	2	99	0.00	0.0	5.064	0.034	0	0	0	3
PL.6036	PL.5575	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	1.95	1	14	2	99	0.00	0.0	5.105	0.041	0	0	0	3
PL.6037	PL.6036	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	1.95	1	14	3	98	0.00	0.0	5.106	0.001	0	0	0	3
PL.5576	PL.6037	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	1.95	1	14	3	98	0.00	0.0	5.116	0.010	11	2	2	3
PL.5577	PL.5576	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	0.41	0	3	0	100	0.00	0.0	5.126	0.011	0	0	0	1
PL.6040	PL.5577	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	0.41	0	3	0	100	0.00	0.0	5.159	0.032	0	0	0	1
PL.6041	PL.6040	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	0.42	0	3	1	95	0.00	0.0	5.160	0.002	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.5578	PL.6041	C	1/0 AL URD	7.12Y	118.7	0.00	6.30	0.42	0	3	1	95	0.00	0.0	5.167	0.007	3	1	1	1
PL.6077	PL.6216	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.21	2.16	1	46	3	100	0.00	0.0	4.528	0.027	10	2	1	8
PL.6078	PL.6077	ABC	#1/0 ACSR	7.13Y	118.8	0.00	6.21	1.41	1	30	2	100	0.00	0.0	4.605	0.077	0	0	0	6
PL.5583	PL.6078	ABC	#3/0 ACSR	7.13Y	118.8	0.00	6.21	1.03	0	22	0	100	0.00	0.0	4.611	0.006	0	0	0	4
PL.6799	PL.5583	ABC	1/0 AL URD	7.13Y	118.8	0.00	6.21	1.03	1	22	0	100	0.00	0.0	4.616	0.005	0	0	0	4
PD.1438	PL.6799	ABC	40T	7.13Y	118.8	0.00	6.21	1.03	0	22	0	100	0.00	0.0	4.616	0.005	0	0	0	4
PL.6800	PD.1438	ABC	1/0 AL URD	7.13Y	118.8	0.00	6.22	1.03	1	22	0	100	0.00	0.0	4.677	0.061	0	0	0	4
PL.5584	PL.6800	A	1/0 AL URD	7.13Y	118.8	0.00	6.22	1.25	1	9	2	98	0.00	0.0	4.702	0.025	9	2	2	2
PL.6085	PL.6800	ABC	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.62	0	13	-1	-100	0.00	0.0	4.814	0.137	0	0	0	2
PL.5587	PL.6085	ABC	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.47	0	10	0	100	0.00	0.0	4.926	0.112	0	0	0	1
PL.5585	PL.5587	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	1.43	1	10	2	98	0.00	0.0	5.027	0.101	10	2	1	1
PL.6086	PL.6085	ABC	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.15	0	3	0	100	0.00	0.0	4.880	0.066	0	0	0	1
PL.5586	PL.6086	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.46	0	3	1	95	0.00	0.0	4.906	0.027	3	1	1	1
PL.5582	PL.6078	C	#2/0 ACSR	7.13Y	118.8	0.00	6.21	1.17	0	8	2	97	0.00	0.0	4.610	0.005	0	0	0	2
PD.1316	PL.5582	C	40T	7.13Y	118.8	0.00	6.21	1.17	0	8	2	97	0.00	0.0	4.610	0.005	0	0	0	2
PL.5822	PD.1316	C	#2/0 ACSR	7.13Y	118.8	0.00	6.21	1.17	0	8	2	97	0.00	0.0	4.677	0.067	7	2	1	2
PL.6220	PL.5822	C	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.10	0	1	0	100	0.00	0.0	4.808	0.131	1	0	1	1
PL.28280	PL.6220	C	#1/0 ACSR	7.13Y	118.8	0.00	6.21	0.00	0	0	0	100	0.00	0.0	4.880	0.073	0	0	0	0
PL.6583	PL.6077	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.532	0.005	0	0	0	1
PD.1322	PL.6583	C	40T	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.532	0.005	0	0	0	1
PL.6584	PD.1322	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.543	0.011	0	0	0	1
PL.6071	PL.6584	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.556	0.013	0	0	0	1
PL.6072	PL.6071	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.557	0.001	0	0	0	1
PL.5303	PL.6072	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	-1	-99	0.00	0.0	4.573	0.017	0	0	0	1
PL.5512	PL.5303	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.582	0.009	0	0	0	1
PL.5513	PL.5512	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.587	0.005	0	0	0	1
PL.5507	PL.5513	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.597	0.009	0	0	0	1
PL.5504	PL.5507	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.607	0.010	0	0	0	1
PL.6067	PL.5504	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.608	0.001	0	0	0	1
PL.5304	PL.6067	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.615	0.007	0	0	0	1
PL.5714	PL.5304	C	1/0 AL URD	7.13Y	118.8	0.00	6.21	0.84	0	6	0	100	0.00	0.0	4.620	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5715	PL.5714	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	0	100	0.00	0.0	4.670	0.050	0	0	0	1
PL.5716	PL.5715	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.83	0	6	0	100	0.00	0.0	4.706	0.036	0	0	0	1
PL.6059	PL.5716	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.83	0	6	0	100	0.00	0.0	4.723	0.017	0	0	0	1
PL.6060	PL.6059	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.83	0	6	0	100	0.00	0.0	4.725	0.002	0	0	0	1
PL.5717	PL.6060	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.83	0	6	0	100	0.00	0.0	4.758	0.034	0	0	0	1
PL.5569	PL.5717	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.83	0	6	0	100	0.00	0.0	4.780	0.021	0	0	0	1
PL.5570	PL.5569	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	0	100	0.00	0.0	4.822	0.043	0	0	0	1
PL.6048	PL.5570	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	0	100	0.00	0.0	4.859	0.037	0	0	0	1
PL.6049	PL.6048	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	1	99	0.00	0.0	4.861	0.001	0	0	0	1
PL.6044	PL.6049	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	1	99	0.00	0.0	4.884	0.023	0	0	0	1
PL.6045	PL.6044	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	1	99	0.00	0.0	4.884	0.001	0	0	0	1
PL.5571	PL.6045	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	1	99	0.00	0.0	4.957	0.072	0	0	0	1
PL.5572	PL.5571	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	0.84	0	6	1	99	0.00	0.0	4.961	0.004	6	1	1	1
PL.5724	PL.5572	C	1/0 AL URD	7.13Y	118.8	-0.00	6.22	-0.04	0	0	0	100	0.00	0.0	4.983	0.023	0	0	0	0
PL.5725	PL.5724	C	1/0 AL URD	7.13Y	118.8	-0.00	6.22	-0.03	0	0	0	100	0.00	0.0	5.032	0.049	0	0	0	0
PL.5726	PL.5725	C	1/0 AL URD	7.13Y	118.8	0.00	6.22	-0.00	0	0	0	100	0.00	0.0	5.040	0.008	0	0	0	0
PL.5301	PL.6792	A	#4 ACSR	7.13Y	118.8	0.00	6.18	1.74	1	12	3	97	0.00	0.0	4.261	0.005	0	0	0	2
PD.1388	PL.5301	A	40T	7.13Y	118.8	0.00	6.18	1.74	0	12	3	97	0.00	0.0	4.261	0.005	0	0	0	2
PL.5776	PD.1388	A	#4 ACSR	7.13Y	118.8	0.00	6.18	0.67	1	5	1	98	0.00	0.0	4.294	0.033	5	1	1	1
PL.6081	PD.1388	A	#4 ACSR	7.13Y	118.8	0.00	6.18	1.07	1	7	2	96	0.00	0.0	4.272	0.011	0	0	0	1
PL.5302	PL.6081	A	#4 ACSR	7.13Y	118.8	0.00	6.18	1.07	1	7	2	96	0.00	0.0	4.357	0.085	7	2	1	1
PL.6519	PL.6238	ABC	#4 ACSR	7.20Y	119.9	0.00	5.06	0.31	0	6	2	95	0.00	0.0	2.872	0.047	2	1	1	2
PL.6520	PL.6519	ABC	#4 ACSR	7.20Y	119.9	0.00	5.06	0.23	0	5	1	98	0.00	0.0	2.932	0.060	5	1	1	1
PL.5495	PL.6520	C	#4 ACSR	7.20Y	119.9	0.00	5.06	0.00	0	0	0	100	0.00	0.0	2.953	0.021	0	0	0	0
PL.5496	PL.5495	C	#4 ACSR	7.20Y	119.9	0.00	5.06	0.00	0	0	0	100	0.00	0.0	3.011	0.057	0	0	0	0
PL.6601	PL.5767	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.31	0	2	0	100	0.00	0.0	2.607	0.005	0	0	0	1
PD.1331	PL.6601	C	65T	7.21Y	120.1	0.00	4.86	0.31	0	2	0	100	0.00	0.0	2.607	0.005	0	0	0	1
PL.6602	PD.1331	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.31	0	2	0	100	0.00	0.0	2.636	0.029	2	0	1	1
PL.6603	PL.6240	A	#1/0 ACSR	7.22Y	120.3	0.00	4.74	0.74	0	5	1	98	0.00	0.0	2.504	0.005	0	0	0	1
PD.1332	PL.6603	A	65T	7.22Y	120.3	0.00	4.74	0.74	0	5	1	98	0.00	0.0	2.504	0.005	0	0	0	1
PL.6604	PD.1332	A	#1/0 ACSR	7.22Y	120.3	0.00	4.74	0.74	0	5	1	98	0.00	0.0	2.541	0.036	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6605	PL.5371	C	#4 ACSR	7.23Y	120.5	0.00	4.49	7.85	6	56	12	98	0.00	0.0	2.276	0.005	0	0	0	10
PD.1333	PL.6605	C	65T	7.23Y	120.5	0.00	4.49	7.85	0	56	12	98	0.00	0.0	2.276	0.005	0	0	0	10
PL.6606	PD.1333	C	#4 ACSR	7.23Y	120.5	0.01	4.50	7.85	6	56	12	98	0.01	0.0	2.320	0.044	9	2	1	10
PL.5473	PL.6606	C	6 A (CWC)	7.23Y	120.5	0.00	4.50	3.12	2	22	5	98	0.00	0.0	2.359	0.039	22	5	4	4
PL.6246	PL.6606	C	6 A (CWC)	7.23Y	120.5	0.00	4.50	0.35	0	2	1	89	0.00	0.0	2.367	0.048	0	0	1	2
PL.6247	PL.6246	C	6 A (CWC)	7.23Y	120.5	0.00	4.50	0.35	0	2	1	89	0.00	0.0	2.387	0.020	2	1	1	1
PL.6013	PL.6606	C	#4 ACSR	7.23Y	120.5	0.00	4.51	1.83	1	13	3	97	0.00	0.0	2.370	0.050	0	0	0	2
PL.5480	PL.6013	C	#1/0 ACSR	7.23Y	120.5	0.00	4.51	1.83	1	13	3	97	0.00	0.0	2.386	0.016	13	3	2	2
PL.5369	PL.6606	C	#4 ACSR	7.23Y	120.5	0.00	4.50	1.32	1	9	2	98	0.00	0.0	2.362	0.043	9	2	1	1
PL.5367	PL.6011	A	#4 ACSR	7.25Y	120.8	0.00	4.22	1.44	1	10	2	98	0.00	0.0	2.161	0.042	4	1	1	2
PL.5368	PL.5367	A	#4 ACSR	7.25Y	120.8	0.00	4.22	0.82	1	6	1	99	0.00	0.0	2.221	0.060	6	1	1	1
PL.6611	PL.6608	C	#2 ACSR	7.29Y	121.6	0.00	3.42	0.51	0	4	1	97	0.00	0.0	1.741	0.005	0	0	0	1
PD.1336	PL.6611	C	65T	7.29Y	121.6	0.00	3.42	0.51	0	4	1	97	0.00	0.0	1.741	0.005	0	0	0	1
PL.6612	PD.1336	C	#2 ACSR	7.29Y	121.6	0.00	3.42	0.51	0	4	1	97	0.00	0.0	1.891	0.150	4	1	1	1
PL.6723	PL.5354	C	6 A (CWC)	7.30Y	121.7	0.00	3.35	6.39	5	46	10	98	0.00	0.0	1.691	0.005	0	0	0	11
PD.1398	PL.6723	C	65T	7.30Y	121.7	0.00	3.35	6.39	0	46	10	98	0.00	0.0	1.691	0.005	0	0	0	11
PL.6724	PD.1398	C	6 A (CWC)	7.30Y	121.6	0.02	3.37	6.39	5	46	10	98	0.01	0.0	1.779	0.089	2	0	1	11
PL.6012	PL.6724	C	6 A (CWC)	7.30Y	121.6	0.01	3.38	4.72	3	34	7	98	0.00	0.0	1.818	0.039	0	0	0	8
PL.5365	PL.6012	C	#2 ACSR	7.30Y	121.6	0.00	3.38	0.48	0	3	1	95	0.00	0.0	1.872	0.053	3	1	1	1
PL.5366	PL.6012	C	#2 ACSR	7.30Y	121.6	0.00	3.38	1.25	1	9	2	98	0.00	0.0	1.848	0.030	9	2	1	1
PL.6260	PL.6012	C	#2 ACSR	7.30Y	121.6	0.00	3.39	3.00	2	21	4	98	0.00	0.0	1.873	0.055	18	4	4	6
PL.6263	PL.6260	C	#2 ACSR	7.30Y	121.6	0.00	3.39	0.54	0	4	1	97	0.00	0.0	1.918	0.045	4	1	2	2
PL.6264	PL.6263	C	#2 ACSR	7.30Y	121.6	0.00	3.39	0.00	0	0	0	100	0.00	0.0	2.011	0.093	0	0	0	0
PL.6261	PL.6724	C	#2 ACSR	7.30Y	121.6	0.00	3.37	1.43	1	10	2	98	0.00	0.0	1.797	0.017	6	1	1	2
PL.6262	PL.6261	C	#2 ACSR	7.30Y	121.6	0.00	3.37	0.56	0	4	1	97	0.00	0.0	1.843	0.047	4	1	1	1
PL.5343	PL.5338	A	#2 ACSR	7.36Y	122.7	0.01	2.25	7.79	4	56	12	98	0.00	0.0	1.199	0.038	2	0	1	10
PL.5344	PL.5343	A	#2 ACSR	7.36Y	122.7	0.00	2.26	4.45	3	32	7	98	0.00	0.0	1.248	0.049	32	7	4	4
PL.6619	PL.5343	A	#2 ACSR	7.36Y	122.7	0.00	2.25	3.02	2	22	5	98	0.00	0.0	1.204	0.005	0	0	0	5
PD.1341	PL.6619	A	40T	7.36Y	122.7	0.00	2.25	3.02	0	22	5	98	0.00	0.0	1.204	0.005	0	0	0	5
PL.6620	PD.1341	A	#2 ACSR	7.36Y	122.7	0.00	2.25	3.02	2	22	5	98	0.00	0.0	1.212	0.008	22	5	5	5
PL.6314	PL.6006	ABC	336 MCM AC	7.38Y	123.1	0.00	1.95	1.70	0	37	8	98	0.00	0.0	1.120	0.084	37	8	6	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6803	PL.6314	ABC	336 MCM AC	7.38Y	123.1	0.00	1.95	0.00	0	0	0	100	0.00	0.0	1.161	0.040	0	0	0	0
PD.1440-A	PL.6803	ABC	Open	7.38Y	123.1	0.00	1.95	0.00	0	0	0	100	0.00	0.0	1.161	0.040	0	0	0	0
PL.6822	PL.5336	B	6 A (CWC)	7.39Y	123.2	0.00	1.84	10.40	7	75	16	98	0.00	0.0	0.975	0.003	0	0	0	20
PD.1453	PL.6822	B	70L	7.39Y	123.2	0.00	1.84	10.40	15	75	16	98	0.00	0.0	0.975	0.003	0	0	0	20
PL.6823	PD.1453	B	6 A (CWC)	7.39Y	123.1	0.04	1.88	10.40	7	75	16	98	0.02	0.0	1.065	0.091	8	2	4	20
PL.5340	PL.6823	B	#2 ACSR	7.39Y	123.1	0.01	1.89	7.11	4	51	11	98	0.00	0.0	1.106	0.041	0	0	0	13
PL.5322	PL.5340	B	6 A (CWC)	7.39Y	123.1	0.02	1.91	6.12	4	44	9	98	0.01	0.0	1.172	0.067	7	2	3	10
PL.5321	PL.5322	B	#4 ACSR	7.39Y	123.1	0.00	1.91	2.51	2	18	4	98	0.00	0.0	1.230	0.058	18	4	4	4
PL.5320	PL.5322	B	6 A (CWC)	7.39Y	123.1	0.01	1.91	2.59	2	19	4	98	0.00	0.0	1.233	0.061	10	2	2	3
PL.5319	PL.5320	B	6 A (CWC)	7.39Y	123.1	0.00	1.91	1.26	1	9	2	98	0.00	0.0	1.253	0.020	0	0	0	1
PL.5318	PL.5319	B	#4 ACSR	7.39Y	123.1	0.00	1.92	1.26	1	9	2	98	0.00	0.0	1.275	0.021	0	0	0	1
PL.5317	PL.5318	B	#2 ACSR	7.38Y	123.1	0.00	1.92	1.26	1	9	2	98	0.00	0.0	1.317	0.043	9	2	1	1
PL.5733	PL.5340	B	#2 ACSR	7.39Y	123.1	0.00	1.89	0.99	1	7	1	99	0.00	0.0	1.153	0.047	2	0	2	3
PL.5341	PL.5733	B	#2 ACSR	7.39Y	123.1	0.00	1.89	0.70	0	5	1	98	0.00	0.0	1.170	0.017	0	0	0	1
PL.5342	PL.5341	B	#2 ACSR	7.39Y	123.1	0.00	1.89	0.70	0	5	1	98	0.00	0.0	1.209	0.039	5	1	1	1
PL.5339	PL.6823	B	6 A (CWC)	7.39Y	123.1	0.00	1.89	2.17	2	16	3	98	0.00	0.0	1.159	0.094	16	3	3	3
PL.5324	PL.6018	A	#4 ACSR	7.41Y	123.5	0.00	1.50	3.14	2	23	5	98	0.00	0.0	0.777	0.006	0	0	0	4
PD.1394	PL.5324	A	20T	7.41Y	123.5	0.00	1.50	3.14	0	23	5	98	0.00	0.0	0.777	0.006	0	0	0	4
PL.5728	PD.1394	A	#4 ACSR	7.41Y	123.5	0.00	1.50	3.14	2	23	5	98	0.00	0.0	0.841	0.063	23	5	4	4
PL.6015	PD.1394	A	#2 ACSR	7.41Y	123.5	0.00	1.50	0.00	0	0	0	100	0.00	0.0	0.781	0.003	0	0	0	0
PL.5323	PL.6015	A	#2 ACSR	7.41Y	123.5	0.00	1.50	0.00	0	0	0	100	0.00	0.0	0.848	0.068	0	0	0	0
PL.6279	PL.7177	ABC	#4 ACSR	7.43Y	123.8	0.00	1.22	0.32	0	7	1	99	0.00	0.0	0.650	0.033	2	0	1	4
PL.6280	PL.6279	ABC	#4 ACSR	7.43Y	123.8	0.00	1.22	0.24	0	5	1	98	0.00	0.0	0.827	0.177	5	1	3	3
PL.5315	PL.6280	ABC	#4 ACSR	7.43Y	123.8	0.00	1.22	0.00	0	0	0	100	0.00	0.0	0.870	0.043	0	0	0	0
CP.11	PL.7176	ABC	Cap (300)	7.43Y	123.9	0.00	1.14	0.00	0	0	0	100	0.00	0.0	0.571	0.043	0	0	0	0
PL.7187	PL.6283	ABC	#1/0 ACSR	7.45Y	124.1	0.00	0.88	22.91	10	464	217	91	0.00	0.0	0.428	0.002	0	0	0	7
PD.1539	PL.7187	ABC	65T	7.45Y	124.1	0.00	0.88	22.91	0	464	217	91	0.00	0.0	0.428	0.002	0	0	0	7
PL.7188	PD.1539	ABC	#1/0 ACSR	7.45Y	124.1	0.04	0.92	22.91	10	464	217	91	0.12	0.0	0.515	0.088	2	0	1	7
PL.6023	PL.7188	ABC	#1/0 ACSR	7.44Y	124.1	0.02	0.94	22.41	10	452	214	90	0.07	0.0	0.567	0.052	0	0	0	4
PL.5311	PL.6023	ABC	#1/0 ACSR	7.44Y	124.1	0.01	0.95	22.12	10	445	215	90	0.02	0.0	0.618	0.050	432	209	1	2
PL.5713	PL.5311	ABC	#1/0 ACSR	7.44Y	124.1	0.00	0.95	0.63	0	13	5	93	0.00	0.0	0.619	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.7172	PL.5713	ABC	1/0 AL URD	7.44Y	124.1	0.00	0.95	0.63	0	13	5	93	0.00	0.0	0.622	0.003	0	0	0	1
PD.1533	PL.7172	ABC	65T	7.44Y	124.1	0.00	0.95	0.63	0	13	5	93	0.00	0.0	0.622	0.003	0	0	0	1
PL.7173	PD.1533	ABC	1/0 AL URD	7.44Y	124.1	0.00	0.95	0.63	0	13	5	93	0.00	0.0	0.704	0.081	13	6	1	1
PL.5727	PL.6023	ABC	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.32	0	7	0	100	0.00	0.0	0.570	0.003	0	0	0	2
PL.7174	PL.5727	ABC	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.32	0	7	0	100	0.00	0.0	0.573	0.003	0	0	0	2
PD.1534	PL.7174	ABC	65T	7.44Y	124.1	0.00	0.94	0.32	0	7	0	100	0.00	0.0	0.573	0.003	0	0	0	2
PL.7175	PD.1534	ABC	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.32	0	7	0	100	0.00	0.0	0.602	0.029	0	0	0	2
PL.5406	PL.7175	A	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.75	0	6	1	99	0.00	0.0	0.689	0.087	6	1	1	1
PL.5407	PL.7175	ABC	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.08	0	2	-1	-89	0.00	0.0	0.723	0.121	2	1	1	1
PL.6627	PL.7188	A	#2 ACSR	7.45Y	124.1	0.00	0.92	1.24	1	9	2	98	0.00	0.0	0.520	0.005	0	0	0	2
PD.1344	PL.6627	A	65T	7.45Y	124.1	0.00	0.92	1.24	0	9	2	98	0.00	0.0	0.520	0.005	0	0	0	2
PL.6628	PD.1344	A	#2 ACSR	7.44Y	124.1	0.00	0.92	1.24	1	9	2	98	0.00	0.0	0.580	0.060	2	0	1	2
PL.5314	PL.6628	A	#2 ACSR	7.44Y	124.1	0.00	0.92	0.95	1	7	1	99	0.00	0.0	0.631	0.051	7	1	1	1
PL.7169	PL.6278	ABC	336 MCM AC	7.46Y	124.3	0.00	0.74	0.00	0	0	0	100	0.00	0.0	0.357	0.000	0	0	0	0
PL.7122	Greenbriar	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	97.83	19	2099	662	95	0.07	0.0	0.009	0.009	0	0	0	374
PL.7528	PL.7122	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	97.83	19	2099	662	95	0.02	0.0	0.012	0.002	0	0	0	374
----- Feeder No. 3 (Manchester F3) Beginning with Device PD.1908 -----																				
PD.1908	PL.7528	ABC	480VWE	7.50Y	125.0	0.00	0.01	97.83	0	2099	661	95	0.00	0.0	0.012	0.002	0	0	0	374
PL.7529	PD.1908	ABC	336 MCM AC	7.50Y	125.0	0.01	0.02	97.83	19	2099	661	95	0.08	0.0	0.021	0.009	0	0	0	374
PL.7091	PL.7529	A	#4 ACSR	7.50Y	125.0	0.00	0.02	3.98	3	29	6	98	0.00	0.0	0.025	0.005	0	0	0	11
PD.1466	PL.7091	A	65T	7.50Y	125.0	0.00	0.02	3.98	0	29	6	98	0.00	0.0	0.025	0.005	0	0	0	11
PL.7092	PD.1466	A	#4 ACSR	7.50Y	125.0	0.01	0.03	3.98	3	29	6	98	0.00	0.0	0.102	0.077	0	0	0	11
PL.6847	PL.7092	A	#4 ACSR	7.50Y	125.0	0.00	0.03	2.21	2	16	3	98	0.00	0.0	0.184	0.081	16	3	3	3
PL.6972	PL.7092	A	#4 ACSR	7.50Y	125.0	0.00	0.03	1.77	1	13	3	97	0.00	0.0	0.148	0.046	0	0	0	8
PL.7002	PL.6972	A	6 A (CWC)	7.50Y	125.0	0.00	0.04	1.77	1	13	3	97	0.00	0.0	0.174	0.025	0	0	2	8
PL.7003	PL.7002	A	6 A (CWC)	7.50Y	125.0	0.00	0.04	1.77	1	13	3	97	0.00	0.0	0.235	0.061	13	3	2	6
PL.6970	PL.7003	A	6 A (CWC)	7.50Y	125.0	0.00	0.04	0.06	0	0	0	100	0.00	0.0	0.275	0.041	0	0	4	4
PL.6848	PL.7529	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	0.34	0	7	2	96	0.00	0.0	0.037	0.016	2	1	4	6
PL.6849	PL.6848	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.02	0.23	0	5	1	98	0.00	0.0	0.079	0.041	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5562	PL.6849	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.02	0.23	0	5	1	98	0.00	0.0	0.142	0.063	0	0	1	2
PL.5563	PL.5562	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.02	0.22	0	5	1	98	0.00	0.0	0.166	0.024	5	1	1	1
PL.5564	PL.5563	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.02	0.00	0	0	0	100	0.00	0.0	0.170	0.003	0	0	0	0
PL.6971	PL.7529	ABC	336 MCM AC	7.50Y	124.9	0.05	0.07	96.17	19	2063	654	95	0.54	0.0	0.091	0.070	0	0	0	357
PL.7186	PL.6971	ABC	336 MCM AC	7.48Y	124.7	0.20	0.27	96.17	19	2062	652	95	2.08	0.1	0.358	0.267	0	0	0	357
PL.6850	PL.7186	ABC	336 MCM AC	7.48Y	124.7	0.02	0.28	96.17	19	2060	647	95	0.18	0.0	0.381	0.023	0	0	0	357
PL.7004	PL.6850	ABC	336 MCM AC	7.48Y	124.7	0.03	0.31	96.17	19	2060	647	95	0.28	0.0	0.417	0.036	1	0	1	357
PL.7005	PL.7004	ABC	336 MCM AC	7.48Y	124.7	0.01	0.32	96.11	19	2058	646	95	0.10	0.0	0.429	0.012	0	0	0	356
PL.5952	PL.7005	ABC	1/0 AL URD	7.48Y	124.7	0.00	0.32	8.79	5	180	81	91	0.00	0.0	0.434	0.005	0	0	0	3
PD.1496	PL.5952	ABC	65T	7.48Y	124.7	0.00	0.32	8.79	0	180	81	91	0.00	0.0	0.434	0.005	0	0	0	3
PL.5953	PD.1496	ABC	1/0 AL URD	7.48Y	124.7	0.01	0.33	8.79	5	180	81	91	0.02	0.0	0.506	0.073	0	0	0	3
PL.6851	PL.5953	ABC	1/0 AL URD	7.48Y	124.7	0.00	0.33	0.73	0	15	7	91	0.00	0.0	0.548	0.041	15	7	1	1
PL.6852	PL.5953	ABC	1/0 AL URD	7.48Y	124.7	0.00	0.34	8.07	5	165	75	91	0.00	0.0	0.531	0.024	150	72	1	2
PL.6869	PL.6852	A	1/0 AL URD	7.48Y	124.7	0.00	0.34	2.06	1	15	3	98	0.00	0.0	0.574	0.044	15	3	1	1
PL.6974	PL.7005	ABC	336 MCM AC	7.48Y	124.6	0.06	0.38	87.40	17	1878	565	96	0.58	0.0	0.519	0.090	2	0	1	353
PL.6975	PL.6974	ABC	336 MCM AC	7.47Y	124.6	0.05	0.43	86.96	17	1868	562	96	0.46	0.0	0.591	0.072	0	0	0	351
PL.7103	PL.6975	C	#4 ACSR	7.47Y	124.6	0.00	0.43	3.93	3	29	6	98	0.00	0.0	0.596	0.005	0	0	0	10
PD.1472	PL.7103	C	65T	7.47Y	124.6	0.00	0.43	3.93	0	29	6	98	0.00	0.0	0.596	0.005	0	0	0	10
PL.7104	PD.1472	C	#4 ACSR	7.47Y	124.6	0.00	0.43	3.93	3	29	6	98	0.00	0.0	0.609	0.013	12	2	5	10
PL.7001	PL.7104	C	#4 ACSR	7.47Y	124.6	0.00	0.43	2.32	2	17	4	97	0.00	0.0	0.656	0.047	17	4	5	5
PL.6976	PL.6975	ABC	336 MCM AC	7.47Y	124.5	0.03	0.46	85.66	17	1839	554	96	0.28	0.0	0.637	0.046	6	1	4	341
PL.6853	PL.6976	ABC	336 MCM AC	7.47Y	124.5	0.02	0.48	85.38	16	1833	552	96	0.23	0.0	0.675	0.038	3	1	1	337
PL.5565	PL.6853	ABC	336 MCM AC	7.47Y	124.5	0.01	0.49	84.60	16	1815	548	96	0.11	0.0	0.693	0.018	4	1	3	331
PL.6993	PL.5565	ABC	336 MCM AC	7.47Y	124.5	0.04	0.53	84.42	16	1811	547	96	0.34	0.0	0.750	0.057	0	0	0	328
PL.6997	PL.6993	ABC	336 MCM AC	7.47Y	124.4	0.05	0.58	83.70	16	1795	543	96	0.44	0.0	0.825	0.075	12	2	1	320
PL.6998	PL.6997	ABC	336 MCM AC	7.46Y	124.4	0.05	0.63	83.16	16	1783	540	96	0.45	0.0	0.902	0.078	14	3	2	319
PL.6999	PL.6998	ABC	336 MCM AC	7.46Y	124.3	0.08	0.71	82.51	16	1768	536	96	0.77	0.0	1.037	0.135	6	1	6	317
PL.7243	PL.6999	C	#4 ACSR	7.46Y	124.3	0.00	0.71	1.19	1	9	2	98	0.00	0.0	1.039	0.002	0	0	0	2
PD.1564	PL.7243	C	65T	7.46Y	124.3	0.00	0.71	1.19	0	9	2	98	0.00	0.0	1.039	0.002	0	0	0	2
PL.7244	PD.1564	C	#4 ACSR	7.46Y	124.3	0.00	0.71	1.19	1	9	2	98	0.00	0.0	1.042	0.002	0	0	0	2
PL.6981	PL.7244	C	#1/0 ACSR	7.46Y	124.3	0.00	0.71	0.29	0	2	0	100	0.00	0.0	1.047	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.6856	PL.6981	C	#1/0 ACSR	7.46Y	124.3	0.00	0.71	0.29	0	2	0	100	0.00	0.0	1.089	0.043	2	0	1	1
PL.6980	PL.7244	C	#4 ACSR	7.46Y	124.3	0.00	0.71	0.90	1	7	1	99	0.00	0.0	1.089	0.047	7	1	1	1
PL.5928	PL.6999	A	6 A (CWC)	7.46Y	124.3	0.00	0.71	1.02	1	7	2	96	0.00	0.0	1.042	0.005	0	0	0	2
PD.1483	PL.5928	A	65T	7.46Y	124.3	0.00	0.71	1.02	0	7	2	96	0.00	0.0	1.042	0.005	0	0	0	2
PL.5929	PD.1483	A	6 A (CWC)	7.46Y	124.3	0.00	0.71	1.02	1	7	2	96	0.00	0.0	1.099	0.057	3	1	1	2
PL.6994	PL.5929	A	6 A (CWC)	7.46Y	124.3	0.00	0.72	0.60	0	4	1	97	0.00	0.0	1.128	0.030	4	1	1	1
PL.7079	PL.6999	ABC	336 MCM AC	7.46Y	124.3	0.03	0.75	81.49	16	1745	529	96	0.29	0.0	1.089	0.052	0	0	0	307
PL.7080	PL.7079	ABC	336 MCM AC	7.45Y	124.2	0.02	0.77	81.49	16	1744	528	96	0.20	0.0	1.125	0.036	0	0	0	307
PL.7093	PL.7080	C	#4 ACSR	7.45Y	124.2	0.00	0.77	0.02	0	0	0	100	0.00	0.0	1.140	0.014	0	0	0	1
PD.1467	PL.7093	C	65T	7.45Y	124.2	0.00	0.77	0.02	0	0	0	100	0.00	0.0	1.140	0.014	0	0	0	1
PL.7094	PD.1467	C	#4 ACSR	7.45Y	124.2	0.00	0.77	0.02	0	0	0	100	0.00	0.0	1.205	0.065	0	0	1	1
PL.6857	PL.7080	ABC	336 MCM AC	7.45Y	124.2	0.05	0.81	81.48	16	1744	528	96	0.41	0.0	1.200	0.075	31	7	3	306
PL.7245	PL.6857	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	1.50	1	11	2	98	0.00	0.0	1.201	0.001	0	0	0	3
PD.1565	PL.7245	A	65T	7.45Y	124.2	0.00	0.81	1.50	0	11	2	98	0.00	0.0	1.201	0.001	0	0	0	3
PL.7246	PD.1565	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	1.50	1	11	2	98	0.00	0.0	1.205	0.003	0	0	0	3
PL.6986	PL.7246	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	0.47	0	3	1	95	0.00	0.0	1.227	0.022	0	0	0	1
PL.6858	PL.6986	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	0.47	0	3	1	95	0.00	0.0	1.242	0.015	3	1	1	1
PL.6983	PL.7246	A	6 A (CWC)	7.45Y	124.2	0.00	0.81	1.02	1	7	2	96	0.00	0.0	1.219	0.014	0	0	0	2
PL.6872	PL.6983	A	6 A (CWC)	7.45Y	124.2	0.00	0.82	1.02	1	7	2	96	0.00	0.0	1.269	0.050	7	2	2	2
PL.6918	PL.6857	ABC	336 MCM AC	7.45Y	124.1	0.04	0.85	79.56	15	1701	518	96	0.33	0.0	1.262	0.062	0	0	0	300
PL.6917	PL.6918	ABC	336 MCM AC	7.45Y	124.1	0.03	0.88	79.56	15	1701	517	96	0.28	0.0	1.315	0.053	0	0	0	300
PL.7097	PL.6917	B	#4 ACSR	7.45Y	124.1	0.00	0.88	0.48	0	4	1	97	0.00	0.0	1.320	0.005	0	0	0	1
PD.1469	PL.7097	B	65T	7.45Y	124.1	0.00	0.88	0.48	0	4	1	97	0.00	0.0	1.320	0.005	0	0	0	1
PL.7098	PD.1469	B	#4 ACSR	7.45Y	124.1	0.00	0.88	0.48	0	4	1	97	0.00	0.0	1.336	0.016	4	1	1	1
PL.6919	PL.6917	ABC	336 MCM AC	7.45Y	124.1	0.02	0.90	79.40	15	1697	516	96	0.14	0.0	1.341	0.026	1	0	4	299
PL.5930	PL.6919	C	#4 ACSR	7.45Y	124.1	0.00	0.90	1.00	1	7	2	96	0.00	0.0	1.346	0.005	0	0	0	3
PD.1485	PL.5930	C	65T	7.45Y	124.1	0.00	0.90	1.00	0	7	2	96	0.00	0.0	1.346	0.005	0	0	0	3
PL.5931	PD.1485	C	#4 ACSR	7.45Y	124.1	0.00	0.90	1.00	1	7	2	96	0.00	0.0	1.380	0.034	2	0	1	3
PL.7000	PL.5931	C	#4 ACSR	7.45Y	124.1	0.00	0.90	0.78	1	6	1	99	0.00	0.0	1.394	0.014	0	0	0	2
PL.6987	PL.7000	C	#4 ACSR	7.45Y	124.1	0.00	0.90	0.30	0	2	0	100	0.00	0.0	1.475	0.081	2	0	1	1
PL.6860	PL.7000	C	#4 ACSR	7.45Y	124.1	0.00	0.90	0.48	0	3	1	95	0.00	0.0	1.436	0.043	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5557	PL.6919	ABC	336 MCM AC	7.44Y	124.1	0.02	0.92	77.99	15	1666	509	96	0.21	0.0	1.383	0.042	1	0	1	288
PL.5558	PL.5557	ABC	336 MCM AC	7.44Y	124.0	0.03	0.96	77.92	15	1664	508	96	0.30	0.0	1.441	0.058	4	1	2	287
PL.5559	PL.5558	ABC	336 MCM AC	7.44Y	124.0	0.03	0.99	77.73	15	1660	507	96	0.25	0.0	1.489	0.048	0	0	1	285
PL.6859	PL.5559	ABC	336 MCM AC	7.44Y	124.0	0.02	1.01	77.71	15	1659	506	96	0.16	0.0	1.521	0.032	26	5	4	284
PL.7089	PL.6859	C	#1/0 ACSR	7.44Y	124.0	0.00	1.01	0.92	0	7	1	99	0.00	0.0	1.526	0.005	0	0	0	4
PD.1465	PL.7089	C	65T	7.44Y	124.0	0.00	1.01	0.92	0	7	1	99	0.00	0.0	1.526	0.005	0	0	0	4
PL.7090	PD.1465	C	#1/0 ACSR	7.44Y	124.0	0.00	1.01	0.92	0	7	1	99	0.00	0.0	1.560	0.034	1	0	1	4
PL.6861	PL.7090	C	#1/0 ACSR	7.44Y	124.0	0.00	1.01	0.72	0	5	1	98	0.00	0.0	1.598	0.038	5	1	3	3
PL.5560	PL.6859	ABC	336 MCM AC	7.44Y	123.9	0.07	1.08	76.22	15	1626	499	96	0.59	0.0	1.643	0.122	4	1	2	276
PL.5561	PL.5560	ABC	336 MCM AC	7.43Y	123.8	0.09	1.16	76.02	15	1621	496	96	0.72	0.0	1.790	0.148	5	1	2	274
PL.5554	PL.5561	ABC	336 MCM AC	7.43Y	123.8	0.01	1.18	75.79	15	1616	494	96	0.10	0.0	1.811	0.020	0	0	0	272
PL.6862	PL.5554	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	17.62	3	354	170	90	0.00	0.0	1.825	0.014	0	0	0	1
PL.64958	PL.6862	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	17.62	3	354	170	90	0.00	0.0	1.825	0.000	0	0	0	1
PD.9572-A	PL.64958	ABC	Closed	7.43Y	123.8	0.00	1.18	17.62	0	354	170	90	0.00	0.0	1.825	0.000	0	0	0	1
PD.9572-B	PD.9572-A	ABC	Closed	7.43Y	123.8	0.00	1.18	17.62	0	354	170	90	0.00	0.0	1.825	0.000	0	0	0	1
PL.6873	PD.9572-B	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	17.62	3	354	170	90	0.00	0.0	1.827	0.002	0	0	0	1
PD.1504	PL.6873	ABC	280L	7.43Y	123.8	0.00	1.18	17.62	0	354	170	90	0.00	0.0	1.827	0.002	0	0	0	1
PL.6961	PD.1504	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	17.62	3	354	170	90	0.00	0.0	1.827	0.001	0	0	0	1
PL.5954	PL.6961	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.18	17.62	10	354	170	90	0.00	0.0	1.829	0.001	0	0	0	1
PD.1497	PL.5954	ABC	65T	7.43Y	123.8	0.00	1.18	17.62	0	354	170	90	0.00	0.0	1.829	0.001	0	0	0	1
PL.5955	PD.1497	ABC	1/0 AL URD	7.43Y	123.8	0.01	1.19	17.62	10	354	170	90	0.03	0.0	1.852	0.024	0	0	0	1
PL.64960	PL.5955	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	17.63	10	354	171	90	0.00	0.0	1.853	0.001	0	0	0	1
PD.1499-A	PL.64960	ABC	Closed	7.43Y	123.8	0.00	1.19	17.63	0	354	171	90	0.00	0.0	1.853	0.001	0	0	0	1
PD.1499-B	PD.1499-A	ABC	Closed	7.43Y	123.8	0.00	1.19	17.63	0	354	171	90	0.00	0.0	1.853	0.001	0	0	0	1
PL.6875	PD.1499-B	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	17.63	10	354	171	90	0.00	0.0	1.856	0.003	0	0	0	1
PL.64962	PL.6875	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	17.63	10	354	171	90	0.00	0.0	1.857	0.001	354	171	1	1
P PL.64964	PL.64962	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.01	0	0	0	100	0.00	0.0	1.862	0.006	0	0	0	0 P
P PL.64967	PL.64964	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.01	0	0	0	100	0.00	0.0	1.878	0.016	0	0	0	0 P
P PL.64963	PL.64962	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.02	0	0	0	100	0.00	0.0	1.864	0.007	0	0	0	0 P
P PL.64966	PL.64963	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.01	0	0	0	100	0.00	0.0	1.879	0.016	0	0	0	0 P
PL.64965	PL.64963	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.01	0	0	0	100	0.00	0.0	1.879	0.015	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																					
-Base Voltage:120.0-																					
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru	

P	PL.64968	PL.64965	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.880	0.002	0	0	0	0	P
	PD.9991-A	PL.64968	ABC	Open	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.880	0.002	0	0	0	0	
P	PL.5269	PL.5955	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	-0.01	0	0	100	0.00	0.0	1.874	0.021	0	0	0	0	P
	PD.897	PL.5269	ABC	65T	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.874	0.021	0	0	0	0	
P	PL.5268	PD.897	ABC	1/0 AL URD	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.875	0.001	0	0	0	0	P
	PL.5267	PL.5268	ABC	#2 ACSR	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.876	0.001	0	0	0	0	
	PD.896	PL.5267	ABC	280L	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.876	0.001	0	0	0	0	
	PL.5266	PD.896	ABC	#2 ACSR	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.878	0.002	0	0	0	0	
	PD.9573-B	PL.5266	ABC	Open	7.43Y	123.8	0.00	1.19	0.00	0	0	100	0.00	0.0	1.878	0.002	0	0	0	0	
	PL.5555	PL.5554	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	58.43	11	1261	323	97	0.03	0.0	1.820	0.009	0	0	0	271
	PL.7066	PL.5555	ABC	336 MCM AC	7.43Y	123.8	0.03	1.21	58.43	11	1261	323	97	0.19	0.0	1.885	0.065	14	3	3	271
	PL.7067	PL.7066	ABC	336 MCM AC	7.43Y	123.8	0.01	1.22	57.80	11	1248	320	97	0.09	0.0	1.919	0.034	54	11	9	268
	PL.7068	PL.7067	ABC	336 MCM AC	7.43Y	123.8	0.01	1.24	55.31	11	1193	308	97	0.09	0.0	1.955	0.037	3	1	2	259
	PL.7069	PL.7068	ABC	336 MCM AC	7.42Y	123.7	0.02	1.26	55.20	11	1191	308	97	0.15	0.0	2.014	0.059	10	2	2	257
	PL.7070	PL.7069	ABC	336 MCM AC	7.42Y	123.7	0.01	1.26	54.75	11	1181	305	97	0.04	0.0	2.028	0.014	3	1	6	255
	PL.7071	PL.7070	ABC	336 MCM AC	7.42Y	123.7	0.00	1.27	54.63	11	1178	305	97	0.02	0.0	2.037	0.008	0	0	0	249
	PL.7072	PL.7071	ABC	336 MCM AC	7.42Y	123.7	0.02	1.29	54.36	10	1172	303	97	0.13	0.0	2.090	0.054	18	4	12	245
	PL.7073	PL.7072	ABC	336 MCM AC	7.42Y	123.7	0.01	1.30	53.56	10	1155	299	97	0.08	0.0	2.125	0.035	33	7	11	233
	PL.5944	PL.7073	C	#1/0 ACSR	7.42Y	123.7	0.00	1.30	6.02	3	44	9	98	0.00	0.0	2.128	0.003	0	0	0	7
	PD.1492	PL.5944	C	65T	7.42Y	123.7	0.00	1.30	6.02	0	44	9	98	0.00	0.0	2.128	0.003	0	0	0	7
	PL.5945	PD.1492	C	#1/0 ACSR	7.42Y	123.7	0.00	1.30	6.02	3	44	9	98	0.00	0.0	2.141	0.013	0	0	0	7
	PL.6988	PL.5945	C	6 A (CWC)	7.42Y	123.7	0.03	1.33	6.02	4	44	9	98	0.01	0.0	2.253	0.112	0	0	0	7
	PL.7020	PL.6988	C	6 A (CWC)	7.42Y	123.7	0.01	1.34	2.79	2	20	4	98	0.00	0.0	2.330	0.077	9	2	2	3
	PL.7021	PL.7020	C	6 A (CWC)	7.42Y	123.7	0.00	1.34	1.52	1	11	2	98	0.00	0.0	2.356	0.026	11	2	1	1
	PL.6989	PL.6988	C	6 A (CWC)	7.42Y	123.7	0.01	1.34	3.23	2	23	5	98	0.00	0.0	2.314	0.061	10	2	2	4
	PL.7018	PL.6989	C	#2 ACSR	7.42Y	123.7	0.00	1.34	1.92	1	14	3	98	0.00	0.0	2.371	0.057	7	1	1	2
	PL.7019	PL.7018	C	#2 ACSR	7.42Y	123.7	0.00	1.35	0.97	1	7	1	99	0.00	0.0	2.423	0.052	7	1	1	1
	PL.6920	PL.7073	ABC	336 MCM AC	7.42Y	123.7	0.02	1.32	50.02	10	1077	283	97	0.10	0.0	2.173	0.048	6	1	2	215
	PL.6921	PL.6920	ABC	336 MCM AC	7.42Y	123.7	0.02	1.34	48.55	9	1045	276	97	0.09	0.0	2.219	0.046	35	7	9	206
	PL.7118	PL.6921	ABC	336 MCM AC	7.42Y	123.6	0.05	1.39	46.32	9	997	264	97	0.28	0.0	2.376	0.157	0	0	0	195
	PL.7143	PL.7118	ABC	336 MCM AC	7.42Y	123.6	0.00	1.39	46.32	9	996	264	97	0.01	0.0	2.379	0.003	0	0	0	195

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts
-Base Voltage:120.0-

Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.1515	PL.7143	ABC	70L	7.42Y	123.6	0.00	1.39	46.32	66	996	264	97	0.00	0.0	2.379	0.003	0	0	0	195
PL.7144	PD.1515	ABC	336 MCM AC	7.42Y	123.6	0.02	1.41	46.32	9	996	264	97	0.08	0.0	2.426	0.047	25	5	5	195
PL.6922	PL.7144	ABC	336 MCM AC	7.41Y	123.6	0.02	1.42	45.17	9	971	258	97	0.10	0.0	2.483	0.057	12	3	2	190
PL.6923	PL.6922	ABC	336 MCM AC	7.41Y	123.6	0.02	1.44	44.16	9	949	253	97	0.10	0.0	2.543	0.060	12	2	3	187
PL.7074	PL.6923	ABC	336 MCM AC	7.41Y	123.5	0.02	1.46	41.77	8	897	242	97	0.09	0.0	2.606	0.063	0	0	1	174
PL.7081	PL.7074	ABC	336 MCM AC	7.41Y	123.5	0.01	1.47	41.75	8	896	242	97	0.04	0.0	2.636	0.030	3	2	1	173
PL.7082	PL.7081	ABC	336 MCM AC	7.41Y	123.5	0.01	1.48	41.58	8	893	240	97	0.05	0.0	2.668	0.032	4	1	5	172
PL.7076	PL.7082	ABC	336 MCM AC	7.41Y	123.5	0.01	1.49	41.40	8	889	239	97	0.06	0.0	2.709	0.041	2	0	1	167
PL.7075	PL.7076	ABC	336 MCM AC	7.41Y	123.5	0.02	1.51	41.32	8	887	239	97	0.08	0.0	2.766	0.057	0	0	0	166
PL.5932	PL.7075	A	#1/0 ACSR	7.41Y	123.5	0.00	1.51	0.91	0	7	1	99	0.00	0.0	2.773	0.007	0	0	0	2
PD.1486	PL.5932	A	30T	7.41Y	123.5	0.00	1.51	0.91	0	7	1	99	0.00	0.0	2.773	0.007	0	0	0	2
PL.5933	PD.1486	A	#1/0 ACSR	7.41Y	123.5	0.00	1.51	0.91	0	7	1	99	0.00	0.0	2.816	0.043	0	0	0	2
PL.6991	PL.5933	A	#4 ACSR	7.41Y	123.5	0.00	1.52	0.91	1	7	1	99	0.00	0.0	2.866	0.050	0	0	0	2
PL.6992	PL.6991	A	#4 ACSR	7.41Y	123.5	0.00	1.52	0.15	0	1	0	100	0.00	0.0	2.882	0.016	1	0	1	1
PL.6868	PL.6991	A	#4 ACSR	7.41Y	123.5	0.00	1.52	0.76	1	5	1	98	0.00	0.0	2.932	0.066	5	1	1	1
PL.7077	PL.7075	ABC	336 MCM AC	7.41Y	123.5	0.02	1.53	41.02	8	880	237	97	0.08	0.0	2.822	0.055	7	1	1	164
PL.7078	PL.7077	ABC	336 MCM AC	7.41Y	123.4	0.03	1.55	40.72	8	874	235	97	0.12	0.0	2.908	0.087	0	0	0	163
PL.6941	PL.7078	ABC	336 MCM AC	7.41Y	123.4	0.02	1.58	40.72	8	874	235	97	0.11	0.0	2.984	0.075	0	0	0	163
PL.6942	PL.6941	ABC	336 MCM AC	7.40Y	123.4	0.01	1.59	40.72	8	874	235	97	0.06	0.0	3.024	0.040	20	4	4	163
PL.7116	PL.6942	B	#2 ACSR	7.40Y	123.4	0.00	1.59	24.72	14	179	38	98	0.00	0.0	3.028	0.005	0	0	0	41
PD.1503	PL.7116	B	35H	7.40Y	123.4	0.00	1.59	24.72	71	179	38	98	0.00	0.0	3.028	0.005	0	0	0	41
PL.7117	PD.1503	B	#2 ACSR	7.40Y	123.4	0.04	1.63	24.72	14	179	38	98	0.05	0.0	3.089	0.060	36	7	10	41
PL.7013	PL.7117	B	6 A (CWC)	7.40Y	123.3	0.03	1.67	19.82	14	144	30	98	0.04	0.0	3.127	0.038	2	0	2	31
PL.7014	PL.7013	B	6 A (CWC)	7.40Y	123.3	0.04	1.71	19.51	14	141	30	98	0.05	0.0	3.182	0.055	20	4	3	29
PL.7008	PL.7014	B	#4 ACSR	7.40Y	123.3	0.00	1.71	3.17	2	23	5	98	0.00	0.0	3.196	0.014	8	2	1	3
PL.7009	PL.7008	B	#4 ACSR	7.40Y	123.3	0.00	1.71	2.05	2	15	3	98	0.00	0.0	3.217	0.021	15	3	2	2
PL.7010	PL.7014	B	6 A (CWC)	7.39Y	123.2	0.05	1.76	13.53	10	98	21	98	0.03	0.0	3.263	0.081	5	1	1	23
PL.7011	PL.7010	B	6 A (CWC)	7.39Y	123.2	0.03	1.79	12.77	9	92	19	98	0.02	0.0	3.311	0.049	11	2	2	22
PL.7012	PL.7011	B	6 A (CWC)	7.39Y	123.2	0.03	1.82	11.23	8	81	17	98	0.02	0.0	3.383	0.072	14	3	4	20
PL.7015	PL.7012	B	6 A (CWC)	7.39Y	123.2	0.02	1.84	9.33	7	68	14	98	0.01	0.0	3.445	0.062	7	1	1	16
PL.7016	PL.7015	B	6 A (CWC)	7.39Y	123.1	0.02	1.86	8.35	6	60	13	98	0.01	0.0	3.497	0.051	14	3	4	15

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Table with columns: Element Name, Parent Name, Cnf, Type/Conductor, Pri, Base Volt, Element Drop, Accum Drop, Thru Amps, % Cap, Thru KW, KVAR, % PF, kW Loss, % Loss, mi From Src, Length (mi), Element (KW, KVAR), Cons On, Cons Thru. Includes units displayed in volts and base voltage of 120.0.

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.7128	PD.1507-B	ABC	336 MCM AC	7.40Y	123.3	0.03	1.74	27.51	5	585	173	96	0.08	0.0	3.699	0.125	0	0	0	105
PL.7247	PL.7128	ABC	336 MCM AC	7.40Y	123.3	0.00	1.74	27.51	5	585	173	96	0.00	0.0	3.701	0.003	0	0	0	105
PD.1566-A	PL.7247	ABC	Closed	7.40Y	123.3	0.00	1.74	27.51	0	585	173	96	0.00	0.0	3.701	0.003	0	0	0	105
PD.1566-B	PD.1566-A	ABC	Closed	7.40Y	123.3	0.00	1.74	27.51	0	585	173	96	0.00	0.0	3.701	0.003	0	0	0	105
PL.7248	PD.1566-B	ABC	336 MCM AC	7.39Y	123.2	0.01	1.76	27.51	5	585	173	96	0.04	0.0	3.762	0.061	0	0	0	105
PL.6870	PL.7248	ABC	6 A (CWC)	7.39Y	123.1	0.13	1.89	27.42	20	583	173	96	0.62	0.1	3.886	0.124	0	0	0	104
PL.6927	PL.6870	ABC	6 A (CWC)	7.38Y	123.0	0.09	1.98	27.12	19	576	171	96	0.42	0.1	3.972	0.085	0	0	0	103
PL.6928	PL.6927	ABC	6 A (CWC)	7.37Y	122.8	0.17	2.15	26.83	19	569	169	96	0.77	0.1	4.133	0.162	0	0	0	100
PL.7111	PL.6928	C	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.41	1	10	2	98	0.00	0.0	4.138	0.005	0	0	0	1
PD.1476	PL.7111	C	30T	7.37Y	122.8	0.00	2.15	1.41	0	10	2	98	0.00	0.0	4.138	0.005	0	0	0	1
PL.7112	PD.1476	C	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.41	1	10	2	98	0.00	0.0	4.143	0.005	10	2	1	1
PL.6929	PL.6928	ABC	6 A (CWC)	7.36Y	122.7	0.10	2.25	26.36	19	558	167	96	0.44	0.1	4.231	0.097	7	2	1	99
PL.6884	PL.6929	C	#4 ACSR	7.36Y	122.7	0.00	2.25	1.50	1	11	2	98	0.00	0.0	4.279	0.048	11	2	2	2
PL.6930	PL.6929	ABC	6 A (CWC)	7.36Y	122.6	0.10	2.35	25.52	18	540	163	96	0.43	0.1	4.331	0.100	4	1	2	96
PL.6931	PL.6930	ABC	6 A (CWC)	7.35Y	122.6	0.07	2.42	25.36	18	536	162	96	0.29	0.1	4.400	0.069	11	2	2	94
PL.6932	PL.6931	ABC	6 A (CWC)	7.35Y	122.5	0.07	2.49	24.85	18	525	160	96	0.29	0.1	4.473	0.073	7	2	2	91
PL.5918	PL.6932	C	#2 ACSR	7.35Y	122.5	0.00	2.49	0.87	0	6	1	99	0.00	0.0	4.477	0.005	0	0	0	1
PD.1478	PL.5918	C	30T	7.35Y	122.5	0.00	2.49	0.87	0	6	1	99	0.00	0.0	4.477	0.005	0	0	0	1
PL.5919	PD.1478	C	#2 ACSR	7.35Y	122.5	0.00	2.49	0.87	0	6	1	99	0.00	0.0	4.519	0.042	6	1	1	1
PL.7031	PL.6932	ABC	6 A (CWC)	7.35Y	122.5	0.06	2.55	24.22	17	511	157	96	0.23	0.0	4.533	0.060	14	3	2	88
PL.7032	PL.7031	ABC	6 A (CWC)	7.34Y	122.4	0.05	2.59	23.59	17	497	154	96	0.19	0.0	4.586	0.053	11	2	1	86
PL.6885	PL.7032	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	1.41	1	10	2	98	0.00	0.0	4.615	0.030	10	2	3	3
PL.6933	PL.7032	ABC	6 A (CWC)	7.34Y	122.4	0.05	2.65	22.23	16	467	147	95	0.20	0.0	4.648	0.062	11	2	3	81
PL.6887	PL.6933	ABC	6 A (CWC)	7.34Y	122.3	0.02	2.67	21.70	15	455	145	95	0.08	0.0	4.675	0.027	19	4	3	78
PL.5920	PL.6887	A	6 A (CWC)	7.34Y	122.3	0.00	2.67	3.98	3	29	6	98	0.00	0.0	4.680	0.005	0	0	0	4
PD.1479	PL.5920	A	30T	7.34Y	122.3	0.00	2.67	3.98	0	29	6	98	0.00	0.0	4.680	0.005	0	0	0	4
PL.5921	PD.1479	A	6 A (CWC)	7.34Y	122.3	0.02	2.69	3.98	3	29	6	98	0.00	0.0	4.802	0.122	3	1	1	4
PL.7034	PL.5921	A	6 A (CWC)	7.34Y	122.3	0.01	2.70	3.57	3	26	5	98	0.00	0.0	4.844	0.042	5	1	2	3
PL.7035	PL.7034	A	6 A (CWC)	7.34Y	122.3	0.01	2.70	2.84	2	20	4	98	0.00	0.0	4.929	0.085	20	4	1	1
PL.7036	PL.6887	ABC	6 A (CWC)	7.34Y	122.3	0.06	2.73	19.50	14	408	135	95	0.19	0.0	4.753	0.078	23	5	6	71
PL.7037	PL.7036	ABC	6 A (CWC)	7.33Y	122.2	0.07	2.80	18.42	13	384	130	95	0.21	0.1	4.846	0.094	11	2	2	65

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.7033	PL.7037	ABC	6 A (CWC)	7.33Y	122.1	0.06	2.86	17.89	13	372	127	95	0.19	0.1	4.936	0.090	0	0	0	63
PL.6890	PL.7033	ABC	6 A (CWC)	7.33Y	122.1	0.00	2.86	8.41	6	180	42	97	0.01	0.0	4.950	0.013	0	0	0	51
PL.6892	PL.6890	A	#4 ACSR	7.33Y	122.1	0.00	2.87	2.52	2	18	4	98	0.00	0.0	4.971	0.022	18	4	8	8
PL.6977	PL.6890	ABC	6 A (CWC)	7.33Y	122.1	0.02	2.89	7.57	5	162	38	97	0.03	0.0	5.030	0.080	6	1	2	43
PL.7114	PL.6977	A	6 A (CWC)	7.33Y	122.1	0.00	2.89	18.85	13	135	29	98	0.00	0.0	5.033	0.003	0	0	0	39
PD.1502	PL.7114	A	35H	7.33Y	122.1	0.00	2.89	18.85	54	135	29	98	0.00	0.0	5.033	0.003	0	0	0	39
PL.7115	PD.1502	A	6 A (CWC)	7.32Y	122.1	0.06	2.95	18.85	13	135	29	98	0.06	0.0	5.102	0.070	0	0	0	39
PL.7038	PL.7115	A	6 A (CWC)	7.32Y	121.9	0.10	3.05	18.85	13	135	29	98	0.11	0.1	5.225	0.123	0	0	1	39
PL.7048	PL.7038	A	#4 ACSR	7.32Y	121.9	0.00	3.05	1.34	1	10	2	98	0.00	0.0	5.254	0.029	7	2	1	2
PL.7049	PL.7048	A	#2 ACSR	7.32Y	121.9	0.00	3.05	0.33	0	2	1	89	0.00	0.0	5.294	0.040	2	1	1	1
PL.7046	PL.7038	A	6 A (CWC)	7.31Y	121.9	0.05	3.10	17.49	12	125	27	98	0.04	0.0	5.285	0.060	0	0	1	36
PL.7047	PL.7046	A	6 A (CWC)	7.31Y	121.9	0.04	3.14	17.47	12	125	26	98	0.04	0.0	5.333	0.048	0	0	0	35
PL.7045	PL.7047	A	6 A (CWC)	7.31Y	121.8	0.08	3.22	17.47	12	125	26	98	0.08	0.1	5.440	0.107	0	0	0	35
PL.6896	PL.7045	A	#4 ACSR	7.31Y	121.8	0.00	3.22	1.14	1	8	2	97	0.00	0.0	5.508	0.068	8	2	3	3
PL.6898	PL.6896	A	#4 ACSR	7.31Y	121.8	0.00	3.22	0.00	0	0	0	100	0.00	0.0	5.599	0.091	0	0	0	0
PL.6973	PL.7045	A	6 A (CWC)	7.30Y	121.7	0.09	3.31	15.79	11	113	24	98	0.07	0.1	5.564	0.124	5	1	1	31
PL.7041	PL.6973	A	6 A (CWC)	7.30Y	121.7	0.04	3.35	13.95	10	100	21	98	0.03	0.0	5.631	0.067	1	0	1	28
PL.7042	PL.7041	A	6 A (CWC)	7.30Y	121.6	0.05	3.39	13.77	10	98	21	98	0.03	0.0	5.708	0.077	5	1	1	27
PL.7043	PL.7042	A	6 A (CWC)	7.30Y	121.6	0.02	3.42	13.04	9	93	20	98	0.02	0.0	5.744	0.037	0	0	0	26
PL.7044	PL.7043	A	6 A (CWC)	7.29Y	121.5	0.05	3.46	11.46	8	82	17	98	0.03	0.0	5.836	0.092	7	1	1	24
PL.7050	PL.7044	A	6 A (CWC)	7.29Y	121.5	0.03	3.49	10.51	8	75	16	98	0.02	0.0	5.909	0.072	10	2	2	23
PL.7051	PL.7050	A	6 A (CWC)	7.29Y	121.4	0.07	3.56	9.14	7	65	14	98	0.03	0.1	6.078	0.170	0	0	0	21
PL.6901	PL.7051	A	#4 ACSR	7.27Y	121.2	0.21	3.78	8.82	7	63	13	98	0.10	0.2	6.634	0.555	0	0	0	19
PL.6967	PL.6901	A	#4 ACSR	7.26Y	121.1	0.14	3.92	7.70	6	55	12	98	0.06	0.1	7.057	0.423	0	0	0	18
PL.6963	PL.6967	A	#4 ACSR	7.26Y	121.0	0.04	3.96	7.51	6	53	11	98	0.02	0.0	7.181	0.124	0	0	0	17
PL.7062	PL.6963	A	#4 ACSR	7.26Y	121.0	0.02	3.98	3.86	3	27	6	98	0.00	0.0	7.314	0.133	5	1	1	7
PL.7063	PL.7062	A	#4 ACSR	7.26Y	121.0	0.01	3.99	3.14	2	22	5	98	0.00	0.0	7.373	0.059	0	0	0	6
PL.6910	PL.7063	A	#4 ACSR	7.26Y	121.0	0.00	3.99	2.33	2	17	3	98	0.00	0.0	7.414	0.041	17	3	4	4
PL.6916	PL.7063	A	#4 ACSR	7.26Y	121.0	0.00	3.99	0.23	0	2	0	100	0.00	0.0	7.440	0.067	2	0	1	1
PL.6962	PL.7063	A	#4 ACSR	7.26Y	121.0	0.00	3.99	0.58	0	4	1	97	0.00	0.0	7.468	0.095	4	1	1	1
PL.6912	PL.6962	A	#2 ACSR	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	7.721	0.253	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.6914	PL.6912	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	7.930	0.208	0	0	0	0
PL.6905	PL.6963	A	#4 ACSR	7.26Y	121.0	0.00	3.96	1.02	1	7	2	96	0.00	0.0	7.221	0.040	7	2	2	2
PL.7064	PL.6963	A	#4 ACSR	7.26Y	121.0	0.01	3.97	2.62	2	19	4	98	0.00	0.0	7.295	0.114	8	2	3	8
PL.7065	PL.7064	A	#4 ACSR	7.26Y	121.0	0.03	4.00	1.46	1	10	2	98	0.00	0.0	7.737	0.442	0	0	0	5
PL.7060	PL.7065	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.63	0	4	1	97	0.00	0.0	7.840	0.102	3	1	1	4
PL.7061	PL.7060	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.20	0	1	0	100	0.00	0.0	8.101	0.262	0	0	0	3
PL.6969	PL.7061	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.20	0	1	0	100	0.00	0.0	8.200	0.099	0	0	0	3
PL.6908	PL.6969	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.20	0	1	0	100	0.00	0.0	8.278	0.078	1	0	2	3
PL.6909	PL.6908	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.00	0	0	0	100	0.00	0.0	8.521	0.243	0	0	1	1
PL.6965	PL.7065	A	#4 ACSR	7.26Y	121.0	0.00	4.00	0.83	1	6	1	99	0.00	0.0	7.820	0.082	6	1	1	1
PL.6906	PL.6967	A	#4 ACSR	7.26Y	121.1	0.00	3.92	0.20	0	1	0	100	0.00	0.0	7.121	0.064	1	0	1	1
PL.6903	PL.6901	A	#1/0 ACSR	7.27Y	121.2	0.00	3.78	1.11	0	8	2	97	0.00	0.0	6.674	0.041	8	2	1	1
PL.7058	PL.7051	A	6 A (CWC)	7.29Y	121.4	0.00	3.56	0.33	0	2	0	100	0.00	0.0	6.179	0.101	2	0	1	2
PL.7059	PL.7058	A	6 A (CWC)	7.29Y	121.4	0.00	3.56	0.03	0	0	0	100	0.00	0.0	6.293	0.114	0	0	1	1
PL.6900	PL.7043	A	#4 ACSR	7.29Y	121.6	0.03	3.44	1.58	1	11	2	98	0.00	0.0	6.146	0.401	0	0	0	2
PL.7056	PL.6900	A	#4 ACSR	7.29Y	121.6	0.00	3.45	1.58	1	11	2	98	0.00	0.0	6.201	0.055	6	1	1	2
PL.7057	PL.7056	A	#4 ACSR	7.29Y	121.6	0.00	3.45	0.80	1	6	1	99	0.00	0.0	6.256	0.055	6	1	1	1
PL.7039	PL.6973	A	6 A (CWC)	7.30Y	121.7	0.01	3.31	1.15	1	8	2	97	0.00	0.0	5.697	0.133	0	0	0	2
PL.7040	PL.7039	A	6 A (CWC)	7.30Y	121.7	0.00	3.32	1.15	1	8	2	97	0.00	0.0	5.797	0.100	6	1	1	2
PL.6899	PL.7040	A	#4 ACSR	7.30Y	121.7	0.00	3.32	0.34	0	2	1	89	0.00	0.0	6.080	0.283	0	0	0	1
PL.7030	PL.6899	A	#4 ACSR	7.30Y	121.7	0.00	3.32	0.34	0	2	1	89	0.00	0.0	6.134	0.054	2	1	1	1
PL.6897	PL.7045	A	#4 ACSR	7.31Y	121.8	0.00	3.22	0.54	0	4	1	97	0.00	0.0	5.514	0.074	4	1	1	1
PL.6978	PL.6977	ABC	6 A (CWC)	7.33Y	122.1	0.00	2.89	1.04	1	21	8	93	0.00	0.0	5.043	0.013	0	0	0	2
PL.6893	PL.6978	B	#4 ACSR	7.33Y	122.1	0.00	2.89	1.04	1	7	2	96	0.00	0.0	5.100	0.057	7	2	1	1
PL.5956	PL.6978	ABC	1/0 AL URD	7.33Y	122.1	0.00	2.89	0.69	0	14	6	92	0.00	0.0	5.048	0.005	0	0	0	1
PD.1498	PL.5956	ABC	30T	7.33Y	122.1	0.00	2.89	0.70	0	14	6	92	0.00	0.0	5.048	0.005	0	0	0	1
PL.5957	PD.1498	ABC	1/0 AL URD	7.33Y	122.1	0.00	2.89	0.70	0	14	6	92	0.00	0.0	5.082	0.035	14	7	1	1
PL.6891	PL.7033	ABC	6 A (CWC)	7.33Y	122.1	0.03	2.89	9.56	7	192	86	91	0.05	0.0	5.026	0.090	9	2	2	12
PL.6894	PL.6891	ABC	6 A (CWC)	7.33Y	122.1	0.02	2.92	9.17	7	183	84	91	0.03	0.0	5.088	0.062	1	0	1	10
PL.7109	PL.6894	A	6 A (CWC)	7.33Y	122.1	0.00	2.92	2.11	2	15	3	98	0.00	0.0	5.093	0.005	0	0	0	8
PD.1475	PL.7109	A	30T	7.33Y	122.1	0.00	2.92	2.11	0	15	3	98	0.00	0.0	5.093	0.005	0	0	0	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.7110	PD.1475	A	6 A (CWC)	7.32Y	122.1	0.00	2.92	2.11	2	15	3	98	0.00	0.0	5.140	0.047	2	1	2	8
PL.7054	PL.7110	A	6 A (CWC)	7.32Y	122.1	0.00	2.92	1.77	1	13	2	99	0.00	0.0	5.156	0.016	0	0	0	6
PL.7055	PL.7054	A	6 A (CWC)	7.32Y	122.1	0.00	2.92	0.81	1	6	1	99	0.00	0.0	5.245	0.088	2	0	1	3
PL.6895	PL.7055	A	#2 ACSR	7.32Y	122.1	0.00	2.92	0.55	0	4	1	97	0.00	0.0	5.275	0.031	4	1	2	2
PL.32694	PL.7054	A	#1/0 ACSR	7.32Y	122.1	0.00	2.92	0.96	0	7	1	99	0.00	0.0	5.180	0.024	6	1	2	3
PL.65706	PL.32694	A	1/0 AL URD	7.32Y	122.1	0.00	2.92	0.11	0	1	0	100	0.00	0.0	5.215	0.035	0	0	0	1
PL.65707	PL.65706	A	1/0 AL URD	7.32Y	122.1	0.00	2.92	0.10	0	1	0	100	0.00	0.0	5.249	0.034	0	0	0	1
PL.65708	PL.65707	A	1/0 AL URD	7.32Y	122.1	0.00	2.92	0.10	0	1	0	100	0.00	0.0	5.277	0.028	1	0	1	1
PL.7052	PL.6894	ABC	6 A (CWC)	7.32Y	122.1	0.03	2.95	8.46	6	167	81	90	0.05	0.0	5.189	0.101	0	0	0	1
PL.7053	PL.7052	ABC	6 A (CWC)	7.32Y	122.0	0.01	2.96	8.46	6	167	81	90	0.01	0.0	5.231	0.042	167	81	1	1
PL.6886	PL.7032	A	#4 ACSR	7.34Y	122.4	0.00	2.60	1.17	1	8	2	97	0.00	0.0	4.622	0.037	8	2	1	1
PL.5916	PL.6931	C	#4 ACSR	7.35Y	122.6	0.00	2.42	0.01	0	0	0	100	0.00	0.0	4.405	0.005	0	0	0	1
PD.1477	PL.5916	C	30T	7.35Y	122.6	0.00	2.42	0.01	0	0	0	100	0.00	0.0	4.405	0.005	0	0	0	1
PL.5917	PD.1477	C	#4 ACSR	7.35Y	122.6	0.00	2.42	0.01	0	0	0	100	0.00	0.0	4.681	0.276	0	0	1	1
PL.7025	PL.6927	C	#4 ACSR	7.38Y	123.0	0.00	1.98	0.89	1	6	1	99	0.00	0.0	4.001	0.029	0	0	1	3
PL.7026	PL.7025	C	#4 ACSR	7.38Y	123.0	0.00	1.98	0.89	1	6	1	99	0.00	0.0	4.025	0.024	6	1	2	2
PL.6871	PL.6870	C	6 A (CWC)	7.39Y	123.1	0.00	1.89	0.90	1	7	1	99	0.00	0.0	3.947	0.061	7	1	1	1
PL.5936	PL.7248	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	0.28	0	2	0	100	0.00	0.0	3.767	0.005	0	0	0	1
PD.1489	PL.5936	C	30T	7.39Y	123.2	0.00	1.76	0.28	0	2	0	100	0.00	0.0	3.767	0.005	0	0	0	1
PL.5937	PD.1489	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	0.28	0	2	0	100	0.00	0.0	3.777	0.011	0	0	0	1
PL.7023	PL.5937	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	0.28	0	2	0	100	0.00	0.0	3.808	0.031	2	0	1	1
PL.7024	PL.7023	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	0.00	0	0	0	100	0.00	0.0	3.853	0.045	0	0	0	0
PL.7129	PL.6945	C	#2 ACSR	7.40Y	123.3	0.00	1.72	6.86	4	50	10	98	0.00	0.0	3.572	0.002	0	0	0	8
PD.1508	PL.7129	C	30T	7.40Y	123.3	0.00	1.72	6.86	0	50	10	98	0.00	0.0	3.572	0.002	0	0	0	8
PL.7130	PD.1508	C	#2 ACSR	7.40Y	123.3	0.00	1.72	6.86	4	50	10	98	0.00	0.0	3.582	0.009	10	2	2	8
PL.6880	PL.7130	C	6 A (CWC)	7.40Y	123.3	0.00	1.72	0.45	0	3	1	95	0.00	0.0	3.614	0.032	3	1	1	1
PL.28008	PL.7130	C	#4 ACSR	7.40Y	123.3	0.01	1.73	4.96	4	36	8	98	0.00	0.0	3.623	0.042	0	0	0	5
PL.28009	PL.28008	C	#4 ACSR	7.40Y	123.3	0.01	1.74	4.96	4	36	8	98	0.00	0.0	3.687	0.064	7	1	1	5
PL.6883	PL.28009	C	#4 ACSR	7.40Y	123.3	0.00	1.74	1.06	1	8	2	97	0.00	0.0	3.749	0.062	8	2	2	2
PL.7027	PL.28009	C	#4 ACSR	7.39Y	123.2	0.01	1.75	2.93	2	21	4	98	0.00	0.0	3.791	0.104	8	2	1	2
PL.7028	PL.7027	C	#4 ACSR	7.39Y	123.2	0.00	1.75	1.82	1	13	3	97	0.00	0.0	3.867	0.076	13	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.7139	PL.6923	A	#1/0 ACSR	7.41Y	123.6	0.00	1.44	5.58	2	40	9	98	0.00	0.0	2.548	0.005	0	0	0	10
PD.1513	PL.7139	A	30T	7.41Y	123.6	0.00	1.44	5.58	0	40	9	98	0.00	0.0	2.548	0.005	0	0	0	10
PL.7140	PD.1513	A	#1/0 ACSR	7.41Y	123.5	0.01	1.45	5.58	2	40	9	98	0.00	0.0	2.601	0.053	13	3	2	10
PL.6865	PL.7140	A	#4 ACSR	7.41Y	123.5	0.01	1.46	3.75	3	27	6	98	0.00	0.0	2.662	0.061	17	4	2	8
PL.6866	PL.6865	A	#2 ACSR	7.41Y	123.5	0.00	1.46	1.43	1	10	2	98	0.00	0.0	2.722	0.060	10	2	6	6
PL.7141	PL.6922	A	6 A (CWC)	7.41Y	123.6	0.00	1.42	1.35	1	10	2	98	0.00	0.0	2.488	0.005	0	0	0	1
PD.1514	PL.7141	A	30T	7.41Y	123.6	0.00	1.42	1.35	0	10	2	98	0.00	0.0	2.488	0.005	0	0	0	1
PL.7142	PD.1514	A	6 A (CWC)	7.41Y	123.6	0.00	1.43	1.35	1	10	2	98	0.00	0.0	2.544	0.057	10	2	1	1
PL.6864	PL.6921	ABC	#1/0 ACSR	7.42Y	123.7	0.00	1.34	0.62	0	13	4	96	0.00	0.0	2.221	0.002	5	2	1	2
PL.7107	PL.6864	B	#1/0 ACSR	7.42Y	123.7	0.00	1.34	1.16	1	8	2	97	0.00	0.0	2.226	0.005	0	0	0	1
PD.1474	PL.7107	B	65T	7.42Y	123.7	0.00	1.34	1.16	0	8	2	97	0.00	0.0	2.226	0.005	0	0	0	1
PL.7108	PD.1474	B	#1/0 ACSR	7.42Y	123.7	0.00	1.34	1.16	1	8	2	97	0.00	0.0	2.258	0.032	8	2	1	1
PL.5946	PL.6920	A	#4 ACSR	7.42Y	123.7	0.00	1.32	3.67	3	27	6	98	0.00	0.0	2.179	0.007	0	0	0	7
PD.1493	PL.5946	A	65T	7.42Y	123.7	0.00	1.32	3.67	0	27	6	98	0.00	0.0	2.179	0.007	0	0	0	7
PL.5947	PD.1493	A	#4 ACSR	7.42Y	123.7	0.00	1.32	3.67	3	27	6	98	0.00	0.0	2.197	0.017	27	6	7	7
PL.5927	PL.7071	A	#1/0 ACSR	7.42Y	123.7	0.00	1.27	0.79	0	6	1	99	0.00	0.0	2.058	0.021	2	0	1	4
PL.6863	PL.5927	A	#1/0 ACSR	7.42Y	123.7	0.00	1.27	0.51	0	4	1	97	0.00	0.0	2.078	0.020	4	1	3	3
PL.7125	PL.5555	ABC	336 MCM AC	7.43Y	123.8	0.00	1.18	0.00	0	0	0	100	0.00	0.0	1.820	0.000	0	0	0	0
PD.1506-A	PL.7125	ABC	Open	7.43Y	123.8	0.00	1.18	0.00	0	0	0	100	0.00	0.0	1.820	0.000	0	0	0	0
PL.7099	PL.6919	A	6 A (CWC)	7.45Y	124.1	0.00	0.90	3.19	2	23	5	98	0.00	0.0	1.346	0.005	0	0	0	4
PD.1470	PL.7099	A	65T	7.45Y	124.1	0.00	0.90	3.19	0	23	5	98	0.00	0.0	1.346	0.005	0	0	0	4
PL.7100	PD.1470	A	6 A (CWC)	7.45Y	124.1	0.00	0.90	3.19	2	23	5	98	0.00	0.0	1.376	0.030	1	0	1	4
PL.6995	PL.7100	A	#1/0 ACSR	7.45Y	124.1	0.00	0.91	3.03	1	22	5	98	0.00	0.0	1.424	0.048	16	3	2	3
PL.6996	PL.6995	A	#1/0 ACSR	7.45Y	124.1	0.00	0.91	0.90	0	7	1	99	0.00	0.0	1.469	0.044	7	1	1	1
PL.5934	PL.6918	C	#2 ACSR	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	1.267	0.005	0	0	0	0
PD.1487	PL.5934	C	65T	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	1.267	0.005	0	0	0	0
PL.5935	PD.1487	C	#2 ACSR	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	1.307	0.040	0	0	0	0
PL.7095	PL.6993	B	6 A (CWC)	7.47Y	124.5	0.00	0.53	2.15	2	16	3	98	0.00	0.0	0.755	0.005	0	0	0	8
PD.1468	PL.7095	B	65T	7.47Y	124.5	0.00	0.53	2.15	0	16	3	98	0.00	0.0	0.755	0.005	0	0	0	8
PL.7096	PD.1468	B	6 A (CWC)	7.47Y	124.5	0.00	0.53	2.15	2	16	3	98	0.00	0.0	0.803	0.048	16	3	8	8
PL.6854	PL.6853	ABC	6 A (CWC)	7.47Y	124.5	0.00	0.48	0.64	0	14	3	98	0.00	0.0	0.730	0.055	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Greenbriar

Database: C:\MILSOFT\DATA\2010-2013 WP EXISTING CONDITIONS.WM\
Title: 2010-2013 CWP - Jackson Energy Cooperative - McKee, Kentucky
Case: 2009 Existing Conditions

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.6855	PL.6854	ABC	6 A (CWC)	7.47Y	124.5	0.00	0.48	0.64	0	14	3	98	0.00	0.0	0.731	0.002	4	1	3	5
PL.7101	PL.6855	B	#4 ACSR	7.47Y	124.5	0.00	0.48	1.43	1	10	2	98	0.00	0.0	0.736	0.005	0	0	0	2
PD.1471	PL.7101	B	65T	7.47Y	124.5	0.00	0.48	1.43	0	10	2	98	0.00	0.0	0.736	0.005	0	0	0	2
PL.7102	PD.1471	B	#4 ACSR	7.47Y	124.5	0.00	0.49	1.43	1	10	2	98	0.00	0.0	0.841	0.105	10	2	2	2
PL.7105	PL.6974	B	6 A (CWC)	7.48Y	124.6	0.00	0.38	1.03	1	8	2	97	0.00	0.0	0.524	0.005	0	0	0	1
PD.1473	PL.7105	B	65T	7.48Y	124.6	0.00	0.38	1.03	0	8	2	97	0.00	0.0	0.524	0.005	0	0	0	1
PL.7106	PD.1473	B	6 A (CWC)	7.48Y	124.6	0.00	0.38	1.03	1	8	2	97	0.00	0.0	0.552	0.028	8	2	1	1
PL.7168	PL.7186	ABC	336 MCM AC	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	0.359	0.002	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	10199	0	0	0	0	0	207		0.00	10406	Lowest Voltage =	115.91	on Element PL.5299
KVAR	3076	0	0	-20	0	0	378			3433	Max Accm VoltD =	9.09	on Element PL.5299
											Max Elem VoltD =	1.19	on Element PL.5276