

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Bush		ABC	SRC-Bush	7.50Y	125.0	0.00	0.00	450.92	0	9693	2996	96	0.00	0.0	0.000	0.000	0	0	0	1436
PL.52863	Bush	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	101.11	19	2183	640	96	0.00	0.0	0.001	0.001	0	0	0	305
PL.52867	PL.52863	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	101.11	19	2183	640	96	0.00	0.0	0.002	0.001	0	0	0	305
----- Feeder No. 3 (Lick Fork F3) Beginning with Device PD.8055 -----																				
PD.8055	PL.52867	ABC	480VWE	7.50Y	125.0	0.00	0.00	101.11	0	2183	640	96	0.00	0.0	0.002	0.001	0	0	0	305
PL.33530	PD.8055	ABC	397 SPACER	7.50Y	125.0	0.01	0.01	101.11	19	2183	640	96	0.03	0.0	0.021	0.019	0	0	0	305
PL.34391	PL.33530	ABC	#3/0 ACSR	7.50Y	125.0	0.00	0.01	101.11	34	2183	640	96	0.01	0.0	0.022	0.001	0	0	0	305
PL.55153	PL.34391	ABC	#3/0 ACSR	7.50Y	125.0	0.04	0.05	101.11	34	2183	640	96	0.50	0.0	0.051	0.029	28	8	10	305
PL.55264	PL.55153	ABC	#3/0 ACSR	7.49Y	124.9	0.10	0.14	99.82	33	2154	632	96	1.27	0.1	0.128	0.076	11	3	4	295
PL.55263	PL.55264	ABC	#3/0 ACSR	7.48Y	124.7	0.12	0.27	99.31	33	2142	627	96	1.61	0.1	0.225	0.098	9	2	1	291
PL.55386	PL.55263	C	#2 ACSR	7.48Y	124.7	0.00	0.27	1.89	1	14	4	96	0.00	0.0	0.228	0.003	0	0	0	1
PD.8198	PL.55386	C	30QA	7.48Y	124.7	0.00	0.27	1.89	6	14	4	96	0.00	0.0	0.228	0.003	0	0	0	1
PL.55161	PD.8198	C	#2 ACSR	7.48Y	124.7	0.00	0.27	1.89	1	14	4	96	0.00	0.0	0.244	0.016	0	0	0	1
PL.55385	PL.55161	C	#2 ACSR	7.48Y	124.7	0.00	0.27	1.89	1	14	4	96	0.00	0.0	0.326	0.081	14	4	1	1
PL.55135	PL.55263	ABC	#3/0 ACSR	7.48Y	124.6	0.15	0.42	98.28	33	2118	618	96	1.93	0.1	0.344	0.119	0	0	0	289
PL.33550	PL.55135	ABC	#3/0 ACSR	7.47Y	124.6	0.01	0.43	96.28	32	2073	604	96	0.18	0.0	0.356	0.011	0	0	0	282
PL.33551	PL.33550	ABC	#3/0 ACSR	7.47Y	124.6	0.00	0.43	96.28	32	2073	604	96	0.02	0.0	0.357	0.001	0	0	0	282
PL.33209	PL.33551	ABC	#3/0 ACSR	7.47Y	124.4	0.14	0.57	96.28	32	2073	604	96	1.73	0.1	0.468	0.111	9	2	1	282
PL.33210	PL.33209	C	6 A (CWC)	7.47Y	124.4	0.00	0.57	7.78	6	56	15	97	0.00	0.0	0.469	0.000	0	0	0	6
PD.4957	PL.33210	C	75QA	7.47Y	124.4	0.00	0.57	7.78	10	56	15	97	0.00	0.0	0.469	0.000	0	0	0	6
PL.33211	PD.4957	C	6 A (CWC)	7.47Y	124.4	0.00	0.57	7.78	6	56	15	97	0.00	0.0	0.469	0.000	0	0	0	6
PL.62738	PL.33211	C	6 A (CWC)	7.47Y	124.4	0.01	0.58	5.23	4	38	10	97	0.00	0.0	0.523	0.054	0	0	0	4
PL.55128	PL.62738	C	6 A (CWC)	7.46Y	124.4	0.01	0.59	5.23	4	38	10	97	0.00	0.0	0.562	0.039	13	3	2	4
PL.64853	PL.55128	C	6 A (CWC)	7.46Y	124.4	0.00	0.59	3.48	2	25	7	96	0.00	0.0	0.619	0.057	25	7	2	2
PL.55129	PL.33211	C	#4 ACSR	7.47Y	124.4	0.01	0.57	2.55	2	18	5	96	0.00	0.0	0.592	0.123	18	5	2	2
PL.55130	PL.33209	ABC	#3/0 ACSR	7.46Y	124.4	0.03	0.60	93.27	31	2006	583	96	0.43	0.0	0.498	0.029	7	2	1	275
PL.55131	PL.55130	ABC	#3/0 ACSR	7.46Y	124.3	0.07	0.68	92.97	31	1999	581	96	0.89	0.0	0.560	0.062	22	6	3	274
PL.55133	PL.55131	C	#4 ACSR	7.46Y	124.3	0.00	0.68	3.30	3	24	6	97	0.00	0.0	0.564	0.004	0	0	0	3
PD.8173	PL.55133	C	75QA	7.46Y	124.3	0.00	0.68	3.30	4	24	6	97	0.00	0.0	0.564	0.004	0	0	0	3
PL.55292	PD.8173	C	#4 ACSR	7.46Y	124.3	0.00	0.68	3.30	3	24	6	97	0.00	0.0	0.610	0.046	18	5	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55293	PL.55292	C	#4 ACSR	7.46Y	124.3	0.00	0.68	0.74	1	5	1	98	0.00	0.0	0.758	0.148	5	1	1	1
PL.55132	PL.55131	ABC	#3/0 ACSR	7.44Y	124.1	0.26	0.93	90.85	30	1952	567	96	3.09	0.2	0.783	0.223	0	0	0	268
PL.33496	PL.55132	B	6 A (CWC)	7.44Y	124.0	0.04	0.97	11.99	9	86	23	97	0.03	0.0	0.859	0.077	0	0	0	11
PL.33591	PL.33496	B	6 A (CWC)	7.44Y	124.0	0.00	0.98	11.99	9	86	23	97	0.00	0.0	0.861	0.001	0	0	0	11
PD.5016	PL.33591	B	35L	7.44Y	124.0	0.00	0.98	11.99	34	86	23	97	0.00	0.0	0.861	0.001	0	0	0	11
PL.33212	PD.5016	B	6 A (CWC)	7.44Y	124.0	0.06	1.03	11.99	9	86	23	97	0.04	0.0	0.966	0.106	0	0	0	11
PL.33213	PL.33212	B	6 A (CWC)	7.44Y	123.9	0.02	1.06	9.71	7	70	19	97	0.01	0.0	1.022	0.055	0	0	0	10
PL.55364	PL.33213	B	6 A (CWC)	7.43Y	123.9	0.05	1.11	4.32	3	31	8	97	0.01	0.0	1.352	0.330	13	4	3	6
PL.55365	PL.55364	B	6 A (CWC)	7.43Y	123.9	0.04	1.14	2.45	2	18	5	96	0.00	0.0	1.671	0.319	0	0	0	3
PL.33291	PL.55365	B	#4 ACSR	7.43Y	123.9	0.00	1.15	0.77	1	6	2	95	0.00	0.0	1.806	0.135	6	2	1	1
PL.55100	PL.55365	B	6 A (CWC)	7.43Y	123.9	0.00	1.15	1.67	1	12	3	97	0.00	0.0	1.716	0.045	12	3	1	2
PL.55101	PL.55100	B	6 A (CWC)	7.43Y	123.9	0.00	1.15	0.00	0	0	0	100	0.00	0.0	1.909	0.193	0	0	1	1
PL.57768	PL.33213	B	#4 ACSR	7.44Y	123.9	0.01	1.07	5.39	4	39	10	97	0.00	0.0	1.099	0.077	20	5	2	4
PL.57769	PL.57768	B	#1/0 ACSR	7.44Y	123.9	0.01	1.08	2.61	1	19	5	97	0.00	0.0	1.241	0.143	0	0	0	2
PL.54815	PL.57769	B	#1/0 ACSR	7.43Y	123.9	0.01	1.09	2.61	1	19	5	97	0.00	0.0	1.331	0.090	0	0	0	2
PL.55322	PL.54815	B	#1/0 ACSR	7.43Y	123.9	0.00	1.09	2.61	1	19	5	97	0.00	0.0	1.385	0.054	0	0	0	2
PL.55323	PL.55322	B	1/0 AL URD	7.43Y	123.9	0.00	1.09	2.61	2	19	5	97	0.00	0.0	1.442	0.057	19	5	2	2
PL.57963	PL.55323	B	1/0 AL URD	7.43Y	123.9	0.00	1.09	0.00	0	0	0	100	0.00	0.0	1.499	0.057	0	0	0	0
PL.54816	PL.57769	B	#1/0 ACSR	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	1.321	0.080	0	0	0	0
PL.55321	PL.33212	B	6 A (CWC)	7.44Y	124.0	0.01	1.04	2.28	2	16	4	97	0.00	0.0	1.086	0.119	16	4	1	1
PL.55362	PL.55132	ABC	#3/0 ACSR	7.44Y	124.0	0.10	1.04	86.86	29	1863	540	96	1.19	0.1	0.878	0.095	23	6	3	257
PL.55363	PL.55362	ABC	#3/0 ACSR	7.43Y	123.9	0.08	1.12	85.80	29	1839	532	96	0.89	0.0	0.950	0.073	16	4	2	254
PL.55358	PL.55363	ABC	#3/0 ACSR	7.43Y	123.8	0.13	1.24	83.21	28	1782	515	96	1.37	0.1	1.069	0.118	8	2	1	247
PL.55354	PL.55358	ABC	#3/0 ACSR	7.42Y	123.7	0.06	1.31	82.83	28	1773	511	96	0.71	0.0	1.130	0.062	9	2	1	246
PL.55353	PL.55354	ABC	#3/0 ACSR	7.41Y	123.6	0.13	1.44	81.87	27	1752	505	96	1.46	0.1	1.260	0.130	0	0	0	243
PL.55348	PL.55353	ABC	#3/0 ACSR	7.41Y	123.5	0.07	1.51	81.41	27	1740	500	96	0.71	0.0	1.324	0.064	0	0	0	242
PL.55347	PL.55348	C	6 A (CWC)	7.41Y	123.5	0.00	1.51	0.00	0	0	0	100	0.00	0.0	1.325	0.001	0	0	0	0
PD.4989	PL.55347	C	75QA	7.41Y	123.5	0.00	1.51	0.00	0	0	0	100	0.00	0.0	1.325	0.001	0	0	0	0
PL.55351	PD.4989	C	6 A (CWC)	7.41Y	123.5	0.00	1.51	0.00	0	0	0	100	0.00	0.0	1.432	0.107	0	0	0	0
PL.55352	PL.55351	C	6 A (CWC)	7.41Y	123.5	0.00	1.51	0.00	0	0	0	100	0.00	0.0	1.519	0.087	0	0	0	0
PL.54821	PL.55348	ABC	#3/0 ACSR	7.39Y	123.2	0.25	1.75	81.41	27	1740	499	96	2.65	0.2	1.563	0.239	4	1	4	242

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.54822	PL.54821	ABC	#3/0 ACSR	7.39Y	123.2	0.03	1.79	81.21	27	1733	494	96	0.35	0.0	1.594	0.032	0	0	0	238
PL.55238	PL.54822	ABC	#3/0 ACSR	7.38Y	123.1	0.16	1.94	81.15	27	1731	493	96	1.70	0.1	1.748	0.154	3	1	3	237
PL.55236	PL.55238	ABC	6 A (CWC)	7.38Y	123.0	0.01	1.95	2.86	2	61	17	96	0.00	0.0	1.826	0.078	0	0	0	11
PL.55221	PL.55236	B	#2 ACSR	7.38Y	123.0	0.00	1.95	1.04	1	7	2	96	0.00	0.0	1.877	0.051	7	2	1	1
PL.33594	PL.55236	B	6 A (CWC)	7.38Y	123.0	0.02	1.97	7.55	5	54	15	96	0.01	0.0	1.874	0.048	0	0	0	10
PL.33527	PL.33594	B	6 A (CWC)	7.38Y	123.0	0.01	1.98	7.55	5	54	15	96	0.00	0.0	1.892	0.019	0	0	0	10
PL.33528	PL.33527	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	7.55	5	54	15	96	0.00	0.0	1.893	0.001	0	0	0	10
PD.5018	PL.33528	B	50L	7.38Y	123.0	0.00	1.98	7.55	15	54	15	96	0.00	0.0	1.893	0.001	0	0	0	10
PL.33537	PD.5018	B	6 A (CWC)	7.38Y	123.0	0.02	2.00	7.55	5	54	15	96	0.01	0.0	1.963	0.069	10	3	2	10
PL.55345	PL.33537	B	6 A (CWC)	7.38Y	123.0	0.01	2.01	6.08	4	43	12	96	0.00	0.0	2.010	0.047	9	2	1	8
PL.55346	PL.55345	B	6 A (CWC)	7.38Y	123.0	0.01	2.02	4.88	3	35	9	97	0.00	0.0	2.047	0.037	0	0	0	7
PL.55344	PL.55346	B	#4 ACSR	7.38Y	123.0	0.00	2.02	1.30	1	9	2	98	0.00	0.0	2.121	0.073	9	2	1	1
PL.55342	PL.55346	B	6 A (CWC)	7.38Y	123.0	0.02	2.04	3.58	3	26	7	97	0.00	0.0	2.154	0.107	1	0	1	6
PL.55343	PL.55342	B	6 A (CWC)	7.38Y	123.0	0.01	2.04	2.24	2	16	4	97	0.00	0.0	2.222	0.068	7	2	1	4
PL.55316	PL.55343	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	1.23	1	9	2	98	0.00	0.0	2.275	0.053	7	2	2	3
PL.55317	PL.55316	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.30	0	2	1	89	0.00	0.0	2.366	0.091	2	1	1	1
PL.55341	PL.55342	B	#4 ACSR	7.38Y	123.0	0.00	2.04	1.21	1	9	2	98	0.00	0.0	2.224	0.070	9	2	1	1
PL.55220	PL.55236	ABC	#4 ACSR	7.38Y	123.0	0.00	1.95	0.00	0	0	0	100	0.00	0.0	1.876	0.051	0	0	0	0
PL.55237	PL.55238	ABC	336 MCM AC	7.38Y	123.0	0.01	1.95	18.70	4	400	108	97	0.02	0.0	1.811	0.063	0	0	0	62
PL.55231	PL.55237	B	#4 ACSR	7.38Y	123.0	0.00	1.96	10.24	8	73	20	96	0.00	0.0	1.815	0.004	0	0	0	7
PD.8177	PL.55231	B	75QA	7.38Y	123.0	0.00	1.96	10.24	14	73	20	96	0.00	0.0	1.815	0.004	0	0	0	7
PL.55230	PD.8177	B	#4 ACSR	7.38Y	123.0	0.01	1.96	10.24	8	73	20	96	0.00	0.0	1.831	0.016	13	4	1	7
PL.55232	PL.55230	B	#4 ACSR	7.38Y	123.0	0.01	1.97	8.38	6	60	16	97	0.00	0.0	1.866	0.035	12	3	2	6
PL.55229	PL.55232	B	#4 ACSR	7.38Y	123.0	0.01	1.98	6.63	5	47	13	96	0.00	0.0	1.906	0.040	26	7	2	4
PL.55228	PL.55229	B	#4 ACSR	7.38Y	123.0	0.00	1.98	2.94	2	21	6	96	0.00	0.0	1.941	0.035	21	6	2	2
PL.55233	PL.55237	ABC	336 MCM AC	7.38Y	123.0	0.00	1.95	15.28	3	327	89	96	0.00	0.0	1.815	0.003	0	0	0	55
PD.8178	PL.55233	ABC	50L	7.38Y	123.0	0.00	1.95	15.28	31	327	89	96	0.00	0.0	1.815	0.003	0	0	0	55
PL.55234	PD.8178	ABC	336 MCM AC	7.38Y	123.0	0.01	1.96	15.28	3	327	89	96	0.01	0.0	1.884	0.069	1	0	1	55
PL.55235	PL.55234	B	6 A (CWC)	7.38Y	123.0	0.00	1.97	2.46	2	18	5	96	0.00	0.0	1.941	0.057	9	3	2	5
PL.33651	PL.55235	B	6 A (CWC)	7.38Y	123.0	0.00	1.97	1.16	1	8	2	97	0.00	0.0	1.980	0.039	8	2	3	3
PL.62763	PL.55234	ABC	336 MCM AC	7.38Y	123.0	0.02	1.98	14.43	3	308	84	96	0.03	0.0	2.059	0.175	0	0	0	49

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33592	PL.62763	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	1.59	1	11	3	96	0.00	0.0	2.129	0.070	3	1	1	3
PL.33650	PL.33592	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	0.00	0	0	0	100	0.00	0.0	2.179	0.050	0	0	0	0
PL.33512	PL.33592	B	#4 ACSR	7.38Y	123.0	0.00	1.99	1.17	1	8	2	97	0.00	0.0	2.167	0.038	8	2	2	2
PL.62764	PL.62763	B	1/0 AL URD	7.38Y	123.0	0.00	1.98	0.00	0	0	0	100	0.00	0.0	2.092	0.033	0	0	0	0
PL.33203	PL.62763	ABC	336 MCM AC	7.38Y	123.0	0.01	1.99	13.90	3	297	81	96	0.02	0.0	2.161	0.102	0	0	0	46
PL.62686	PL.33203	B	6 A (CWC)	7.38Y	123.0	0.01	2.00	3.46	2	25	7	96	0.00	0.0	2.214	0.053	0	0	0	4
PL.62687	PL.62686	B	6 A (CWC)	7.38Y	123.0	0.00	2.00	3.46	2	25	7	96	0.00	0.0	2.246	0.032	6	2	1	4
PL.62688	PL.62687	B	6 A (CWC)	7.38Y	123.0	0.00	2.01	2.62	2	19	5	97	0.00	0.0	2.273	0.026	6	2	1	3
PL.55059	PL.62688	B	6 A (CWC)	7.38Y	123.0	0.01	2.01	1.74	1	12	3	97	0.00	0.0	2.353	0.081	0	0	1	2
PL.34394	PL.55059	B	6 A (CWC)	7.38Y	123.0	0.00	2.02	1.74	1	12	3	97	0.00	0.0	2.427	0.074	12	3	1	1
PL.33532	PL.33203	ABC	336 MCM AC	7.38Y	123.0	0.01	2.00	12.75	2	272	74	96	0.02	0.0	2.306	0.145	0	0	0	42
PL.33466	PL.33532	B	6 A (CWC)	7.38Y	123.0	0.01	2.01	2.75	2	20	5	97	0.00	0.0	2.380	0.074	0	0	0	3
PL.33467	PL.33466	B	6 A (CWC)	7.38Y	123.0	0.02	2.03	2.10	1	15	4	97	0.00	0.0	2.566	0.186	4	1	1	2
PL.33619	PL.33467	B	6 A (CWC)	7.38Y	123.0	0.01	2.04	1.60	1	11	3	96	0.00	0.0	2.756	0.190	11	3	1	1
PL.55058	PL.33466	B	#4 ACSR	7.38Y	123.0	0.00	2.01	0.65	0	5	1	98	0.00	0.0	2.460	0.079	5	1	1	1
PL.54984	PL.33532	ABC	336 MCM AC	7.38Y	123.0	0.01	2.01	11.83	2	253	69	96	0.01	0.0	2.364	0.059	5	1	3	39
PL.54985	PL.54984	ABC	336 MCM AC	7.38Y	123.0	0.02	2.03	11.62	2	248	67	97	0.02	0.0	2.563	0.199	0	0	0	36
PL.34400	PL.54985	ABC	336 MCM AC	7.38Y	123.0	0.01	2.03	11.62	2	248	67	97	0.01	0.0	2.630	0.067	8	2	1	36
PL.33833	PL.34400	ABC	336 MCM AC	7.38Y	123.0	0.01	2.05	11.24	2	240	65	97	0.02	0.0	2.789	0.159	5	1	1	35
PL.57871	PL.33833	ABC	336 MCM AC	7.38Y	122.9	0.01	2.06	11.00	2	235	64	96	0.01	0.0	2.911	0.122	0	0	0	34
PL.57872	PL.57871	ABC	336 MCM AC	7.38Y	122.9	0.01	2.06	11.00	2	235	64	96	0.01	0.0	3.021	0.109	8	2	1	34
PL.54978	PL.57872	ABC	336 MCM AC	7.38Y	122.9	0.00	2.07	10.62	2	227	61	97	0.00	0.0	3.045	0.025	5	1	2	33
PL.54977	PL.54978	ABC	336 MCM AC	7.38Y	122.9	0.00	2.07	10.38	2	222	60	97	0.01	0.0	3.110	0.065	0	0	0	31
PL.53767	PL.54977	B	#4 ACSR	7.37Y	122.9	0.02	2.09	5.00	4	36	10	96	0.00	0.0	3.204	0.094	17	5	3	5
PL.53865	PL.53767	B	#1/0 ACSR	7.37Y	122.9	0.01	2.09	2.64	1	19	5	97	0.00	0.0	3.321	0.117	6	2	1	2
PL.53866	PL.53865	B	#1/0 ACSR	7.37Y	122.9	0.00	2.09	1.77	1	13	3	97	0.00	0.0	3.415	0.094	13	3	1	1
PL.33308	PL.54977	ABC	336 MCM AC	7.37Y	122.9	0.02	2.09	8.71	2	186	50	97	0.02	0.0	3.361	0.250	9	2	2	26
PL.33309	PL.33308	ABC	336 MCM AC	7.37Y	122.9	0.00	2.09	8.30	2	177	48	97	0.00	0.0	3.418	0.057	8	2	1	24
PL.33606	PL.33309	ABC	336 MCM AC	7.37Y	122.9	0.01	2.10	5.98	1	128	35	96	0.01	0.0	3.750	0.332	0	0	0	14
PL.33607	PL.33606	ABC	336 MCM AC	7.37Y	122.9	0.01	2.11	5.98	1	128	35	96	0.00	0.0	3.867	0.117	3	1	1	14
PL.33784	PL.33607	ABC	336 MCM AC	7.37Y	122.9	0.00	2.11	5.28	1	113	30	97	0.00	0.0	3.949	0.083	0	0	0	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33786	PL.33784	B	6 A (CWC)	7.37Y	122.9	0.00	2.12	1.94	1	14	4	96	0.00	0.0	3.996	0.046	12	3	1	2
PL.34396	PL.33786	B	6 A (CWC)	7.37Y	122.9	0.00	2.12	0.27	0	2	1	89	0.00	0.0	4.024	0.028	2	1	1	1
PL.33785	PL.33784	ABC	336 MCM AC	7.37Y	122.9	0.00	2.11	4.63	1	99	27	96	0.00	0.0	4.010	0.061	0	0	0	10
PL.62746	PL.33785	ABC	336 MCM AC	7.37Y	122.9	0.00	2.12	1.96	0	42	11	97	0.00	0.0	4.094	0.084	20	6	2	4
PL.62692	PL.62746	ABC	336 MCM AC	7.37Y	122.9	0.00	2.12	1.00	0	21	6	96	0.00	0.0	4.131	0.037	0	0	0	2
PL.59535	PL.62692	ABC	336 MCM AC	7.37Y	122.9	0.00	2.12	0.00	0	0	0	100	0.00	0.0	4.161	0.030	0	0	0	0
PD.8794-A	PL.59535	ABC	Open	7.37Y	122.9	0.00	2.12	0.00	0	0	0	100	0.00	0.0	4.161	0.030	0	0	0	0
PL.62690	PL.62692	B	#1/0 ACSR	7.37Y	122.9	0.00	2.12	2.99	1	21	6	96	0.00	0.0	4.171	0.040	9	2	1	2
PL.62691	PL.62690	B	#1/0 ACSR	7.37Y	122.9	0.00	2.12	1.79	1	13	3	97	0.00	0.0	4.228	0.057	13	3	1	1
PL.34397	PL.33785	B	6 A (CWC)	7.37Y	122.9	0.03	2.14	8.03	6	57	15	97	0.01	0.0	4.090	0.080	10	3	1	6
PL.55000	PL.34397	B	6 A (CWC)	7.37Y	122.8	0.01	2.15	6.56	5	47	13	96	0.00	0.0	4.127	0.037	0	0	0	5
PL.55049	PL.55000	B	#2 ACSR	7.37Y	122.8	0.00	2.15	0.00	0	0	0	100	0.00	0.0	4.204	0.077	0	0	0	0
PL.55050	PL.55000	B	6 A (CWC)	7.37Y	122.8	0.01	2.16	6.56	5	47	13	96	0.00	0.0	4.165	0.038	0	0	0	5
PL.55120	PL.55050	B	#1/0 ACSR	7.37Y	122.8	0.00	2.17	1.96	1	14	4	96	0.00	0.0	4.199	0.034	0	0	0	1
PL.55121	PL.55120	B	#1/0 ACSR	7.37Y	122.8	0.00	2.17	1.96	1	14	4	96	0.00	0.0	4.311	0.111	14	4	1	1
PL.55122	PL.55120	B	#1/0 ACSR	7.37Y	122.8	0.00	2.17	0.00	0	0	0	100	0.00	0.0	4.307	0.108	0	0	0	0
PL.55051	PL.55050	B	6 A (CWC)	7.37Y	122.8	0.02	2.18	4.60	3	33	9	96	0.00	0.0	4.277	0.112	23	6	2	4
PL.55001	PL.55051	B	6 A (CWC)	7.37Y	122.8	0.00	2.18	1.30	1	9	3	95	0.00	0.0	4.353	0.076	0	0	0	2
PL.54999	PL.55001	B	6 A (CWC)	7.37Y	122.8	0.00	2.19	1.30	1	9	3	95	0.00	0.0	4.433	0.080	9	3	2	2
PL.64866	PL.33607	B	#4 ACSR	7.37Y	122.9	0.00	2.11	1.70	1	12	3	97	0.00	0.0	3.937	0.071	12	3	1	1
PL.33465	PL.33309	B	6 A (CWC)	7.37Y	122.9	0.01	2.10	5.80	4	41	11	97	0.00	0.0	3.467	0.049	0	0	0	9
PL.34401	PL.33465	B	#2 ACSR	7.37Y	122.9	0.00	2.10	0.19	0	1	0	100	0.00	0.0	3.515	0.048	0	0	0	4
PL.33495	PL.34401	B	#2 ACSR	7.37Y	122.9	0.00	2.10	0.00	0	0	0	100	0.00	0.0	3.544	0.029	0	0	1	1
PL.33647	PL.34401	B	#2 ACSR	7.37Y	122.9	0.00	2.10	0.19	0	1	0	100	0.00	0.0	3.675	0.160	0	0	1	3
PL.55041	PL.33647	B	#2 ACSR	7.37Y	122.9	0.00	2.11	0.19	0	1	0	100	0.00	0.0	4.003	0.328	1	0	1	2
PL.55042	PL.55041	B	#2 ACSR	7.37Y	122.9	0.00	2.11	0.07	0	0	0	100	0.00	0.0	4.085	0.082	0	0	1	1
PL.34402	PL.33465	B	6 A (CWC)	7.37Y	122.9	0.01	2.11	5.61	4	40	11	96	0.00	0.0	3.487	0.020	0	0	0	5
PL.64858	PL.34402	B	#2 ACSR	7.37Y	122.9	0.00	2.11	1.01	1	7	2	96	0.00	0.0	3.529	0.042	7	2	1	1
PL.33831	PL.34402	B	6 A (CWC)	7.37Y	122.9	0.03	2.14	4.60	3	33	9	96	0.01	0.0	3.636	0.149	0	0	1	4
PL.33832	PL.33831	B	#2 ACSR	7.37Y	122.9	0.01	2.15	4.55	3	32	9	96	0.00	0.0	3.706	0.070	8	2	1	3
PL.55043	PL.33832	B	#2 ACSR	7.37Y	122.8	0.01	2.15	3.38	2	24	6	97	0.00	0.0	3.781	0.075	15	4	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55044	PL.55043	B	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.26	1	9	2	98	0.00	0.0	3.801	0.020	0	0	0	1
PL.55045	PL.55044	B	1/0 AL URD	7.37Y	122.8	0.00	2.16	1.26	1	9	2	98	0.00	0.0	3.898	0.098	9	2	1	1
PL.57952	PL.57871	B	6 A (CWC)	7.38Y	122.9	0.00	2.06	0.00	0	0	0	100	0.00	0.0	3.089	0.177	0	0	0	0
PL.33285	PL.54985	B	6 A (CWC)	7.38Y	123.0	0.00	2.03	0.00	0	0	0	100	0.00	0.0	2.637	0.073	0	0	0	0
PL.55239	PL.55238	ABC	336 MCM AC	7.38Y	123.0	0.04	1.98	59.47	11	1266	365	96	0.24	0.0	1.829	0.080	0	0	0	161
PL.55225	PL.55239	ABC	336 MCM AC	7.38Y	123.0	0.02	2.00	59.27	11	1261	363	96	0.11	0.0	1.865	0.036	0	0	0	160
PL.55226	PL.55225	A	#4 ACSR	7.38Y	123.0	0.00	2.00	0.93	1	7	2	96	0.00	0.0	1.869	0.004	0	0	0	1
PD.8176	PL.55226	A	75QA	7.38Y	123.0	0.00	2.00	0.93	1	7	2	96	0.00	0.0	1.869	0.004	0	0	0	1
PL.55227	PD.8176	A	#4 ACSR	7.38Y	123.0	0.00	2.00	0.93	1	7	2	96	0.00	0.0	1.903	0.034	7	2	1	1
PL.55224	PL.55225	ABC	336 MCM AC	7.38Y	123.0	0.03	2.03	58.96	11	1255	361	96	0.21	0.0	1.939	0.074	24	7	3	159
PL.33652	PL.55224	ABC	336 MCM AC	7.38Y	122.9	0.05	2.08	57.84	11	1230	354	96	0.32	0.0	2.052	0.113	8	2	3	156
PL.33653	PL.33652	C	6 A (CWC)	7.38Y	122.9	0.00	2.08	1.56	1	11	3	96	0.00	0.0	2.053	0.001	0	0	0	2
PD.4982	PL.33653	C	75QA	7.38Y	122.9	0.00	2.08	1.56	2	11	3	96	0.00	0.0	2.053	0.001	0	0	0	2
PL.33654	PD.4982	C	6 A (CWC)	7.38Y	122.9	0.00	2.08	1.56	1	11	3	96	0.00	0.0	2.121	0.069	8	2	1	2
PL.33655	PL.33654	C	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.39	0	3	1	95	0.00	0.0	2.140	0.019	3	1	1	1
PL.33620	PL.33652	ABC	336 MCM AC	7.37Y	122.9	0.04	2.12	56.93	11	1211	348	96	0.25	0.0	2.145	0.093	0	0	0	151
PL.33662	PL.33620	A	#4 ACSR	7.37Y	122.9	0.00	2.12	3.80	3	27	7	97	0.00	0.0	2.146	0.000	0	0	0	4
PD.4983	PL.33662	A	75QA	7.37Y	122.9	0.00	2.12	3.80	5	27	7	97	0.00	0.0	2.146	0.000	0	0	0	4
PL.33389	PD.4983	A	#4 ACSR	7.37Y	122.9	0.01	2.12	3.80	3	27	7	97	0.00	0.0	2.185	0.040	6	2	2	4
PL.59084	PL.33389	A	#4 ACSR	7.37Y	122.9	0.01	2.13	2.92	2	21	6	96	0.00	0.0	2.298	0.112	21	6	2	2
PL.62758	PL.33620	C	#1/0 ACSR	7.37Y	122.9	0.00	2.12	2.91	1	21	6	96	0.00	0.0	2.200	0.055	0	0	0	2
PL.62759	PL.62758	C	#1/0 ACSR	7.37Y	122.9	0.00	2.12	2.91	1	21	6	96	0.00	0.0	2.226	0.026	21	6	2	2
PL.33390	PL.33620	A	6 A (CWC)	7.37Y	122.9	0.00	2.12	1.44	1	10	3	96	0.00	0.0	2.146	0.000	0	0	0	1
PD.4977	PL.33390	A	75QA	7.37Y	122.9	0.00	2.12	1.44	2	10	3	96	0.00	0.0	2.146	0.000	0	0	0	1
PL.33391	PD.4977	A	6 A (CWC)	7.37Y	122.9	0.00	2.12	1.44	1	10	3	96	0.00	0.0	2.213	0.067	10	3	1	1
PL.33656	PL.33620	ABC	336 MCM AC	7.37Y	122.9	0.03	2.15	54.22	10	1152	332	96	0.19	0.0	2.221	0.076	5	1	1	144
PL.33304	PL.33656	ABC	336 MCM AC	7.37Y	122.8	0.02	2.17	53.99	10	1147	330	96	0.15	0.0	2.282	0.061	0	0	0	143
PL.33312	PL.33304	C	#4 ACSR	7.37Y	122.8	0.00	2.17	1.72	1	12	3	97	0.00	0.0	2.283	0.001	0	0	0	1
PD.5004	PL.33312	C	75QA	7.37Y	122.8	0.00	2.17	1.72	2	12	3	97	0.00	0.0	2.283	0.001	0	0	0	1
PL.33313	PD.5004	C	#4 ACSR	7.37Y	122.8	0.00	2.18	1.72	1	12	3	97	0.00	0.0	2.340	0.058	12	3	1	1
PL.33311	PL.33304	ABC	336 MCM AC	7.37Y	122.8	0.04	2.21	53.42	10	1135	326	96	0.23	0.0	2.377	0.094	0	0	0	142

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33263	PL.33311	ABC	336 MCM AC	7.36Y	122.7	0.04	2.25	49.39	10	1049	303	96	0.21	0.0	2.481	0.104	0	0	0	121
PL.55245	PL.33263	C	6 A (CWC)	7.36Y	122.7	0.00	2.25	15.75	11	112	30	97	0.00	0.0	2.486	0.006	0	0	0	10
PD.8179	PL.55245	C	30T	7.36Y	122.7	0.00	2.25	15.75	0	112	30	97	0.00	0.0	2.486	0.006	0	0	0	10
PL.55244	PD.8179	C	6 A (CWC)	7.36Y	122.7	0.04	2.30	15.75	11	112	30	97	0.03	0.0	2.553	0.067	19	5	1	10
PL.55246	PL.55244	C	#1/0 ACSR	7.36Y	122.7	0.00	2.30	1.41	1	10	3	96	0.00	0.0	2.608	0.055	10	3	1	1
PL.57717	PL.55244	C	6 A (CWC)	7.36Y	122.7	0.02	2.32	11.71	8	83	22	97	0.01	0.0	2.592	0.039	0	0	0	8
PL.57718	PL.57717	C	6 A (CWC)	7.36Y	122.7	0.02	2.34	7.75	6	55	15	96	0.01	0.0	2.649	0.057	7	2	1	6
PL.55242	PL.57718	C	#4 ACSR	7.36Y	122.7	0.01	2.34	2.11	2	15	4	97	0.00	0.0	2.775	0.126	15	4	1	1
PL.55243	PL.57718	C	6 A (CWC)	7.36Y	122.7	0.01	2.35	4.60	3	33	9	96	0.00	0.0	2.692	0.043	0	0	0	4
PL.33400	PL.55243	C	6 A (CWC)	7.36Y	122.6	0.00	2.35	1.18	1	8	2	97	0.00	0.0	2.798	0.106	8	2	1	1
PL.55247	PL.55243	C	#4 ACSR	7.36Y	122.6	0.00	2.35	3.41	3	24	7	96	0.00	0.0	2.752	0.060	24	7	2	3
PL.55248	PL.55247	C	#4 ACSR	7.36Y	122.6	0.00	2.35	0.00	0	0	0	100	0.00	0.0	2.798	0.046	0	0	1	1
PL.57719	PL.57717	C	6 A (CWC)	7.36Y	122.7	0.01	2.33	3.96	3	28	8	96	0.00	0.0	2.697	0.105	23	6	1	2
PL.57716	PL.57719	C	6 A (CWC)	7.36Y	122.7	0.00	2.33	0.78	1	6	1	99	0.00	0.0	2.733	0.036	6	1	1	1
PL.66210	PL.57716	C	#1/0 ACSR	7.36Y	122.7	0.00	2.33	0.00	0	0	0	100	0.00	0.0	2.786	0.053	0	0	0	0
PL.66211	PL.66210	C	#1/0 ACSR	7.36Y	122.7	0.00	2.33	0.00	0	0	0	100	0.00	0.0	2.832	0.046	0	0	0	0
PL.66212	PL.66211	C	#1/0 ACSR	7.36Y	122.7	0.00	2.33	0.00	0	0	0	100	0.00	0.0	2.896	0.064	0	0	0	0
PL.66213	PL.66212	C	1/0 AL URD	7.36Y	122.7	0.00	2.33	0.00	0	0	0	100	0.00	0.0	2.936	0.040	0	0	0	0
PL.33172	PL.33263	ABC	336 MCM AC	7.36Y	122.7	0.08	2.33	44.14	9	937	272	96	0.39	0.0	2.720	0.240	0	0	0	111
PL.33173	PL.33172	ABC	336 MCM AC	7.36Y	122.7	0.02	2.35	41.89	8	888	258	96	0.09	0.0	2.782	0.062	0	0	0	104
PL.33498	PL.33173	ABC	336 MCM AC	7.36Y	122.6	0.04	2.39	30.69	6	653	180	96	0.15	0.0	2.967	0.185	0	0	0	79
PL.55110	PL.33498	C	6 A (CWC)	7.34Y	122.3	0.28	2.67	84.93	61	602	166	96	1.24	0.2	3.038	0.071	4	1	1	72
PL.55111	PL.55110	C	6 A (CWC)	7.34Y	122.3	0.00	2.67	84.42	60	597	165	96	0.01	0.0	3.039	0.000	0	0	0	71
PD.4942	PL.55111	C	140L	7.34Y	122.3	0.00	2.67	84.42	60	597	165	96	0.00	0.0	3.039	0.000	0	0	0	71
PL.55078	PD.4942	C	6 A (CWC)	7.33Y	122.1	0.25	2.92	84.42	60	597	165	96	1.09	0.2	3.103	0.065	18	5	4	71
PL.55079	PL.55078	C	#4 ACSR	7.32Y	122.1	0.01	2.93	2.61	2	18	5	96	0.00	0.0	3.206	0.102	4	1	1	2
PL.33403	PL.55079	C	#4 ACSR	7.32Y	122.1	0.00	2.93	2.03	2	14	4	96	0.00	0.0	3.256	0.050	14	4	1	1
PL.55077	PL.55078	C	6 A (CWC)	7.32Y	121.9	0.15	3.07	79.31	57	560	154	96	0.64	0.1	3.146	0.042	4	1	1	65
PL.55054	PL.55077	C	6 A (CWC)	7.30Y	121.7	0.25	3.31	73.41	52	518	142	96	0.96	0.2	3.219	0.073	2	1	1	57
PL.55055	PL.55054	C	6 A (CWC)	7.29Y	121.5	0.23	3.54	73.15	52	515	141	96	0.88	0.2	3.287	0.068	0	0	0	56
PL.55052	PL.55055	C	#4 ACSR	7.29Y	121.5	0.00	3.54	2.98	2	21	6	96	0.00	0.0	3.340	0.053	21	6	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33407	PL.55055	C	6 A (CWC)	7.27Y	121.1	0.34	3.88	70.17	50	493	135	96	1.27	0.3	3.394	0.108	6	2	1	54
PL.61215	PL.33407	C	6 A (CWC)	7.26Y	120.9	0.17	4.05	62.30	44	437	119	96	0.55	0.1	3.453	0.059	0	0	0	50
PL.62780	PL.61215	C	6 A (CWC)	7.26Y	120.9	0.00	4.05	62.30	44	436	119	96	0.00	0.0	3.453	0.000	10	3	1	50
PL.62781	PL.62780	C	6 A (CWC)	7.24Y	120.7	0.29	4.34	60.85	43	426	116	96	0.92	0.2	3.559	0.106	14	4	2	49
PL.53899	PL.62781	C	#1/0 ACSR	7.24Y	120.6	0.07	4.41	45.29	20	316	86	96	0.14	0.0	3.622	0.063	0	0	0	36
PL.61248	PL.53899	C	#1/0 ACSR	7.24Y	120.6	0.00	4.41	0.00	0	0	0	100	0.00	0.0	3.649	0.027	0	0	0	0
PL.51856	PL.53899	C	#1/0 ACSR	7.23Y	120.5	0.05	4.46	45.29	20	316	86	96	0.11	0.0	3.671	0.049	15	4	1	36
PL.51855	PL.51856	C	#1/0 ACSR	7.23Y	120.5	0.07	4.53	43.11	19	301	82	96	0.14	0.0	3.741	0.069	0	0	0	35
PL.51963	PL.51855	C	#1/0 ACSR	7.23Y	120.5	0.00	4.53	1.04	0	7	2	96	0.00	0.0	3.759	0.018	0	0	0	1
PL.53636	PL.51963	C	#4 ACSR	7.23Y	120.5	0.00	4.53	1.04	1	7	2	96	0.00	0.0	3.896	0.137	7	2	1	1
PL.53974	PL.51855	C	#1/0 ACSR	7.22Y	120.4	0.08	4.61	42.07	18	293	80	96	0.17	0.1	3.827	0.086	0	0	0	34
PL.51964	PL.53974	C	#1/0 ACSR	7.21Y	120.2	0.19	4.80	40.88	18	285	77	97	0.36	0.1	4.024	0.197	0	0	0	32
PL.51967	PL.51964	C	#1/0 ACSR	7.21Y	120.2	0.02	4.82	39.03	17	272	74	96	0.04	0.0	4.047	0.023	0	0	0	31
PL.51732	PL.51967	C	#1/0 ACSR	7.21Y	120.2	0.03	4.84	36.32	16	253	68	97	0.04	0.0	4.077	0.030	10	3	1	29
PL.51734	PL.51732	C	#1/0 ACSR	7.21Y	120.1	0.04	4.88	14.98	7	104	28	97	0.03	0.0	4.207	0.130	8	2	2	13
PL.55084	PL.51734	C	#4 ACSR	7.21Y	120.1	0.01	4.89	12.39	10	86	23	97	0.01	0.0	4.228	0.020	9	2	1	9
PL.55086	PL.55084	C	#4 ACSR	7.21Y	120.1	0.02	4.91	11.13	9	77	21	96	0.01	0.0	4.262	0.034	8	2	1	8
PL.55085	PL.55086	C	#4 ACSR	7.20Y	120.1	0.01	4.92	10.04	8	70	19	97	0.00	0.0	4.281	0.019	0	0	0	7
PD.7995	PL.55085	C	50QA	7.20Y	120.1	0.00	4.92	10.04	20	70	19	97	0.00	0.0	4.281	0.019	0	0	0	7
PL.51958	PD.7995	C	#4 ACSR	7.20Y	120.1	0.00	4.92	10.04	8	70	19	97	0.00	0.0	4.281	0.000	0	0	1	7
PL.55087	PL.51958	C	6 A (CWC)	7.20Y	120.1	0.00	4.92	1.43	1	10	3	96	0.00	0.0	4.324	0.042	10	3	1	1
PL.55083	PL.55087	C	6 A (CWC)	7.20Y	120.1	0.00	4.92	0.00	0	0	0	100	0.00	0.0	4.374	0.050	0	0	0	0
PD.7956-B	PL.55083	C	Open	7.20Y	120.1	0.00	4.92	0.00	0	0	0	100	0.00	0.0	4.374	0.050	0	0	0	0
PL.51957	PL.51958	C	6 A (CWC)	7.20Y	120.1	0.03	4.95	2.61	2	18	5	96	0.00	0.0	4.499	0.217	0	0	0	1
PL.55088	PL.51957	C	#4 ACSR	7.20Y	120.0	0.01	4.95	2.61	2	18	5	96	0.00	0.0	4.619	0.120	18	5	1	1
PL.51959	PL.51957	C	6 A (CWC)	7.20Y	120.1	0.00	4.95	0.00	0	0	0	100	0.00	0.0	4.706	0.208	0	0	0	0
PL.55089	PL.51958	C	#2 ACSR	7.20Y	120.1	0.00	4.92	5.99	3	42	11	97	0.00	0.0	4.309	0.027	8	2	1	4
PL.55090	PL.55089	C	#2 ACSR	7.20Y	120.1	0.01	4.93	4.87	3	34	9	97	0.00	0.0	4.367	0.058	11	3	1	3
PL.54991	PL.55090	C	#2 ACSR	7.20Y	120.1	0.00	4.93	3.32	2	23	6	97	0.00	0.0	4.396	0.030	23	6	2	2
PL.51864	PL.51734	C	#4 ACSR	7.21Y	120.1	0.00	4.88	1.43	1	10	3	96	0.00	0.0	4.209	0.001	0	0	0	2
PD.7939	PL.51864	C	40QA	7.21Y	120.1	0.00	4.88	1.43	4	10	3	96	0.00	0.0	4.209	0.001	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.51863	PD.7939	C	#4 ACSR	7.21Y	120.1	0.00	4.89	1.43	1	10	3	96	0.00	0.0	4.255	0.046	10	3	1	2
PL.54990	PL.51863	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.00	0	0	0	100	0.00	0.0	4.355	0.100	0	0	1	1
PL.51735	PL.51732	C	#4 ACSR	7.21Y	120.2	0.00	4.84	19.96	15	139	38	96	0.00	0.0	4.077	0.000	0	0	0	15
PD.7938	PL.51735	C	30T	7.21Y	120.2	0.00	4.84	19.96	0	139	38	96	0.00	0.0	4.077	0.000	0	0	0	15
PL.51857	PD.7938	C	#4 ACSR	7.21Y	120.2	0.00	4.84	19.96	15	139	38	96	0.00	0.0	4.078	0.000	0	0	0	15
PL.51861	PL.51857	C	#2 ACSR	7.21Y	120.2	0.00	4.84	0.92	1	6	2	95	0.00	0.0	4.113	0.036	6	2	1	1
PL.61199	PL.51857	C	#4 ACSR	7.21Y	120.1	0.02	4.86	19.03	15	132	36	96	0.02	0.0	4.097	0.020	20	5	2	14
PL.61198	PL.61199	C	#4 ACSR	7.21Y	120.1	0.03	4.89	16.15	12	112	30	97	0.03	0.0	4.144	0.046	0	0	0	12
PL.51858	PL.61198	C	#4 ACSR	7.21Y	120.1	0.01	4.90	7.15	6	50	13	97	0.00	0.0	4.196	0.053	43	12	4	5
PL.51859	PL.51858	C	#4 ACSR	7.21Y	120.1	0.00	4.90	0.95	1	7	2	96	0.00	0.0	4.241	0.044	7	2	1	1
PL.57537	PL.61198	C	#4 ACSR	7.21Y	120.1	0.01	4.90	9.00	7	63	17	97	0.01	0.0	4.177	0.034	9	3	1	7
PL.57536	PL.57537	C	#4 ACSR	7.20Y	120.1	0.02	4.92	7.65	6	53	14	97	0.01	0.0	4.242	0.065	0	0	0	6
PL.51862	PL.57536	C	#2 ACSR	7.20Y	120.1	0.00	4.93	2.14	1	15	4	97	0.00	0.0	4.262	0.020	15	4	2	2
PL.55080	PL.57536	C	#4 ACSR	7.20Y	120.1	0.01	4.94	5.51	4	38	10	97	0.00	0.0	4.298	0.056	9	2	1	4
PL.55082	PL.55080	C	#1/0 ACSR	7.20Y	120.1	0.00	4.94	1.58	1	11	3	96	0.00	0.0	4.362	0.063	11	3	1	1
PL.55081	PL.55080	C	#4 ACSR	7.20Y	120.1	0.00	4.94	2.69	2	19	5	97	0.00	0.0	4.329	0.031	19	5	2	2
PL.51733	PL.51967	C	#4 ACSR	7.21Y	120.2	0.00	4.82	2.72	2	19	5	97	0.00	0.0	4.047	0.000	0	0	0	2
PD.7263	PL.51733	C	50QA	7.21Y	120.2	0.00	4.82	2.72	5	19	5	97	0.00	0.0	4.047	0.000	0	0	0	2
PL.46203	PD.7263	C	#1/0 ACSR	7.21Y	120.2	0.01	4.82	2.72	1	19	5	97	0.00	0.0	4.150	0.103	0	0	0	2
PL.46204	PL.46203	C	#4 ACSR	7.21Y	120.2	0.00	4.82	1.51	1	11	3	96	0.00	0.0	4.203	0.053	11	3	1	1
PL.51860	PL.46203	C	#4 ACSR	7.21Y	120.2	0.00	4.82	1.20	1	8	2	97	0.00	0.0	4.203	0.053	8	2	1	1
PL.51968	PL.51964	C	#4 ACSR	7.21Y	120.2	0.00	4.80	1.85	1	13	3	97	0.00	0.0	4.060	0.036	13	3	1	1
PL.51965	PL.53974	C	#1/0 ACSR	7.22Y	120.4	0.00	4.61	0.57	0	4	1	97	0.00	0.0	3.843	0.016	4	1	1	1
PL.51966	PL.53974	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.62	0	4	1	97	0.00	0.0	3.919	0.092	4	1	1	1
PL.53898	PL.62781	C	6 A (CWC)	7.24Y	120.6	0.06	4.40	13.51	10	94	26	96	0.05	0.0	3.667	0.108	6	2	2	11
PL.53735	PL.53898	C	6 A (CWC)	7.24Y	120.6	0.01	4.41	12.63	9	88	24	96	0.00	0.0	3.681	0.014	41	11	3	9
PL.53751	PL.53735	C	6 A (CWC)	7.23Y	120.6	0.02	4.44	6.80	5	48	13	97	0.01	0.0	3.761	0.080	0	0	0	6
PL.53869	PL.53751	C	6 A (CWC)	7.23Y	120.5	0.02	4.45	5.03	4	35	9	97	0.00	0.0	3.837	0.076	9	2	1	5
PL.57550	PL.53869	C	6 A (CWC)	7.23Y	120.5	0.01	4.46	3.44	2	24	6	97	0.00	0.0	3.934	0.097	5	1	1	3
PL.57552	PL.57550	C	#1/0 ACSR	7.23Y	120.5	0.00	4.47	2.69	1	19	5	97	0.00	0.0	3.964	0.030	0	0	0	2
PL.53846	PL.57552	C	#1/0 ACSR	7.23Y	120.5	0.00	4.47	1.52	1	11	3	96	0.00	0.0	4.014	0.050	11	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53891	PL.57552	C	#1/0 ACSR	7.23Y	120.5	0.00	4.47	1.17	1	8	2	97	0.00	0.0	4.046	0.082	8	2	1	1
PL.53890	PL.53891	C	#1/0 ACSR	7.23Y	120.5	0.00	4.47	0.00	0	0	0	100	0.00	0.0	4.152	0.106	0	0	0	0
PL.57551	PL.57550	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	0.00	0	0	0	100	0.00	0.0	3.967	0.033	0	0	0	0
PL.53868	PL.53869	C	#2 ACSR	7.23Y	120.5	0.00	4.45	0.31	0	2	1	89	0.00	0.0	3.882	0.046	2	1	1	1
PL.53752	PL.53751	C	#1/0 ACSR	7.23Y	120.6	0.00	4.44	1.77	1	12	3	97	0.00	0.0	3.801	0.040	12	3	1	1
PL.33408	PL.33407	C	6 A (CWC)	7.27Y	121.1	0.02	3.90	6.99	5	49	13	97	0.01	0.0	3.442	0.048	0	0	0	3
PL.33625	PL.33408	C	#2 ACSR	7.27Y	121.1	0.00	3.90	0.60	0	4	1	97	0.00	0.0	3.475	0.032	4	1	1	1
PL.64334	PL.33408	C	6 A (CWC)	7.27Y	121.1	0.01	3.91	6.39	5	45	12	97	0.00	0.0	3.465	0.023	0	0	0	2
PL.64335	PL.64334	C	6 A (CWC)	7.27Y	121.1	0.00	3.91	6.39	5	45	12	97	0.00	0.0	3.465	0.000	45	12	2	2
PL.55053	PL.55077	C	6 A (CWC)	7.32Y	121.9	0.01	3.08	5.26	4	37	10	97	0.00	0.0	3.177	0.031	0	0	1	7
PL.33406	PL.55053	C	6 A (CWC)	7.32Y	121.9	0.01	3.08	5.26	4	37	10	97	0.00	0.0	3.216	0.039	28	8	2	6
PL.62739	PL.33406	C	#1/0 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	3.247	0.031	0	0	1	1
PL.53830	PL.33406	C	6 A (CWC)	7.31Y	121.9	0.00	3.08	1.26	1	9	2	98	0.00	0.0	3.299	0.083	9	2	3	3
PL.33404	PL.33498	ABC	336 MCM AC	7.36Y	122.6	0.00	2.39	2.38	0	51	14	96	0.00	0.0	3.022	0.055	15	4	2	7
PL.33405	PL.33404	ABC	336 MCM AC	7.36Y	122.6	0.00	2.39	1.69	0	36	10	96	0.00	0.0	3.095	0.073	15	4	2	5
PL.64859	PL.33405	ABC	336 MCM AC	7.36Y	122.6	0.00	2.39	0.97	0	21	6	96	0.00	0.0	3.172	0.077	0	0	0	3
PL.33163	PL.64859	A	#4 ACSR	7.36Y	122.6	0.00	2.40	1.09	1	8	2	97	0.00	0.0	3.350	0.178	8	2	1	1
PL.64860	PL.64859	ABC	336 MCM AC	7.36Y	122.6	0.00	2.39	0.61	0	13	4	96	0.00	0.0	3.234	0.062	13	4	2	2
PL.64861	PL.64860	ABC	336 MCM AC	7.36Y	122.6	0.00	2.39	0.00	0	0	0	100	0.00	0.0	3.276	0.042	0	0	0	0
PD.4951-B	PL.64861	ABC	Open	7.36Y	122.6	0.00	2.39	0.00	0	0	0	100	0.00	0.0	3.276	0.042	0	0	0	0
PL.33254	PL.33173	ABC	#4 ACSR	7.36Y	122.6	0.02	2.37	11.21	9	235	77	95	0.03	0.0	2.821	0.038	10	3	1	25
PL.33402	PL.33254	B	#4 ACSR	7.35Y	122.6	0.05	2.42	22.58	17	160	43	97	0.06	0.0	2.875	0.054	15	4	2	23
PL.57987	PL.33402	B	#4 ACSR	7.35Y	122.6	0.00	2.42	17.10	13	121	33	96	0.00	0.0	2.879	0.004	0	0	0	18
PD.8399	PL.57987	B	60QA	7.35Y	122.6	0.00	2.42	17.10	29	121	33	96	0.00	0.0	2.879	0.004	0	0	0	18
PL.59072	PD.8399	B	#4 ACSR	7.35Y	122.6	0.02	2.44	17.10	13	121	33	96	0.02	0.0	2.908	0.029	2	0	1	18
PL.59070	PL.59072	B	#4 ACSR	7.35Y	122.6	0.01	2.45	5.20	4	37	10	97	0.00	0.0	2.952	0.045	37	10	4	4
PL.59071	PL.59072	B	#4 ACSR	7.35Y	122.5	0.02	2.46	11.66	9	83	22	97	0.01	0.0	2.949	0.041	6	2	1	13
PL.55109	PL.59071	B	#4 ACSR	7.35Y	122.5	0.00	2.46	1.03	1	7	2	96	0.00	0.0	3.003	0.054	7	2	1	1
PL.55103	PL.59071	B	#2 ACSR	7.35Y	122.5	0.01	2.47	4.87	3	35	9	97	0.00	0.0	3.010	0.061	8	2	1	4
PL.54997	PL.55103	B	#2 ACSR	7.35Y	122.5	0.00	2.47	3.72	2	26	7	97	0.00	0.0	3.019	0.009	0	0	1	3
PL.54998	PL.54997	B	#2 ACSR	7.35Y	122.5	0.00	2.47	3.71	2	26	7	97	0.00	0.0	3.034	0.014	13	3	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.54996	PL.54998	B	#2 ACSR	7.35Y	122.5	0.00	2.47	1.91	1	14	4	96	0.00	0.0	3.049	0.015	14	4	1	1
PL.55107	PL.59071	B	#4 ACSR	7.35Y	122.5	0.01	2.47	4.89	4	35	9	97	0.00	0.0	2.993	0.044	12	3	2	7
PL.55108	PL.55107	B	#4 ACSR	7.35Y	122.5	0.01	2.48	3.13	2	22	6	96	0.00	0.0	3.038	0.045	0	0	0	5
PL.55106	PL.55108	B	#1/0 ACSR	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.049	0.011	0	0	0	0
PL.53838	PL.55106	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.069	0.021	0	0	0	0
PL.53839	PL.53838	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.109	0.039	0	0	0	0
PL.53840	PL.53839	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.136	0.027	0	0	0	0
PL.53841	PL.53840	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.193	0.057	0	0	0	0
PL.53842	PL.53841	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.239	0.046	0	0	0	0
PL.53843	PL.53842	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.294	0.055	0	0	0	0
PL.53844	PL.53843	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.320	0.026	0	0	0	0
PL.53845	PL.53844	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.351	0.031	0	0	0	0
PL.53837	PL.55106	B	1/0 AL URD	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.101	0.052	0	0	0	0
PL.55105	PL.55108	B	#4 ACSR	7.35Y	122.5	0.00	2.48	0.00	0	0	0	100	0.00	0.0	3.084	0.046	0	0	0	0
PL.55104	PL.55108	B	#4 ACSR	7.35Y	122.5	0.00	2.48	3.13	2	22	6	96	0.00	0.0	3.068	0.029	22	6	5	5
PL.57985	PL.33402	B	#4 ACSR	7.35Y	122.6	0.00	2.42	3.42	3	24	7	96	0.00	0.0	2.909	0.034	11	3	1	3
PL.57986	PL.57985	B	#4 ACSR	7.35Y	122.6	0.00	2.42	1.85	1	13	4	96	0.00	0.0	2.954	0.045	13	4	2	2
PL.64865	PL.33254	ABC	#4 ACSR	7.36Y	122.6	0.00	2.37	3.27	3	65	31	90	0.00	0.0	2.842	0.021	65	31	1	1
PL.33180	PL.33172	C	#4 ACSR	7.36Y	122.7	0.00	2.33	6.77	5	48	13	97	0.00	0.0	2.721	0.001	0	0	0	7
PD.4954	PL.33180	C	60QA	7.36Y	122.7	0.00	2.33	6.77	11	48	13	97	0.00	0.0	2.721	0.001	0	0	0	7
PL.33593	PD.4954	C	#4 ACSR	7.36Y	122.7	0.01	2.34	6.77	5	48	13	97	0.00	0.0	2.754	0.033	5	1	2	7
PL.33401	PL.33593	C	#4 ACSR	7.36Y	122.7	0.01	2.35	6.07	5	43	12	96	0.00	0.0	2.783	0.028	10	3	2	5
PL.53867	PL.33401	C	#4 ACSR	7.36Y	122.6	0.00	2.35	4.73	4	34	9	97	0.00	0.0	2.818	0.035	34	9	3	3
PL.33392	PL.33311	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	2.377	0.000	0	0	0	2
PD.4898	PL.33392	C	75QA	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	2.377	0.000	0	0	0	2
PL.33393	PD.4898	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	2.397	0.020	0	0	2	2
PL.33503	PL.33311	A	6 A (CWC)	7.37Y	122.8	0.00	2.21	12.08	9	86	23	97	0.00	0.0	2.377	0.000	0	0	0	19
PD.4941	PL.33503	A	50L	7.37Y	122.8	0.00	2.21	12.08	24	86	23	97	0.00	0.0	2.377	0.000	0	0	0	19
PL.33394	PD.4941	A	6 A (CWC)	7.37Y	122.8	0.03	2.24	12.08	9	86	23	97	0.02	0.0	2.436	0.059	5	1	1	19
PL.33504	PL.33394	A	6 A (CWC)	7.36Y	122.7	0.03	2.27	11.42	8	81	22	97	0.02	0.0	2.496	0.060	1	0	2	18
PL.33457	PL.33504	A	6 A (CWC)	7.36Y	122.7	0.00	2.28	0.51	0	4	1	97	0.00	0.0	2.615	0.119	4	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33505	PL.33504	A	6 A (CWC)	7.36Y	122.6	0.08	2.36	10.78	8	77	21	96	0.05	0.1	2.675	0.180	7	2	1	14
PL.33398	PL.33505	A	6 A (CWC)	7.36Y	122.6	0.01	2.37	5.23	4	37	10	97	0.00	0.0	2.720	0.045	32	9	3	9
PL.55162	PL.33398	A	6 A (CWC)	7.36Y	122.6	0.00	2.37	0.75	1	5	1	98	0.00	0.0	2.850	0.130	0	0	1	6
PL.55163	PL.55162	A	6 A (CWC)	7.36Y	122.6	0.00	2.37	0.74	1	5	1	98	0.00	0.0	3.004	0.153	1	0	1	5
PL.55155	PL.55163	A	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.63	0	4	1	97	0.00	0.0	3.093	0.089	0	0	0	4
PL.55156	PL.55155	A	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.58	0	4	1	97	0.00	0.0	3.131	0.038	4	1	1	1
PL.33399	PL.55155	A	#4 ACSR	7.36Y	122.6	0.00	2.38	0.04	0	0	0	100	0.00	0.0	3.138	0.045	0	0	0	3
PL.55157	PL.33399	A	#4 ACSR	7.36Y	122.6	0.00	2.38	0.04	0	0	0	100	0.00	0.0	3.241	0.103	0	0	3	3
PL.33395	PL.33505	A	6 A (CWC)	7.36Y	122.6	0.01	2.37	3.12	2	22	6	96	0.00	0.0	2.741	0.065	8	2	1	3
PL.33396	PL.33395	A	6 A (CWC)	7.36Y	122.6	0.01	2.38	1.98	1	14	4	96	0.00	0.0	2.849	0.109	4	1	1	2
PL.33397	PL.33396	A	6 A (CWC)	7.36Y	122.6	0.00	2.38	1.45	1	10	3	96	0.00	0.0	2.916	0.067	10	3	1	1
PL.33589	PL.33505	A	6 A (CWC)	7.36Y	122.6	0.00	2.36	1.45	1	10	3	96	0.00	0.0	2.764	0.089	10	3	1	1
PL.55222	PL.55239	B	#1/0 ACSR	7.38Y	123.0	0.00	1.98	0.60	0	4	1	97	0.00	0.0	1.832	0.003	0	0	0	1
PD.8175	PL.55222	B	10QA	7.38Y	123.0	0.00	1.98	0.60	0	4	1	97	0.00	0.0	1.832	0.003	0	0	0	1
PL.55223	PD.8175	B	#1/0 ACSR	7.38Y	123.0	0.00	1.98	0.60	0	4	1	97	0.00	0.0	1.857	0.025	4	1	1	1
PL.54817	PL.54822	ABC	#4 ACSR	7.39Y	123.2	0.00	1.79	0.06	0	1	0	100	0.00	0.0	1.597	0.002	0	0	0	1
PD.8196	PL.54817	ABC	25QA	7.39Y	123.2	0.00	1.79	0.06	0	1	0	100	0.00	0.0	1.597	0.002	0	0	0	1
PL.54818	PD.8196	ABC	#4 ACSR	7.39Y	123.2	0.00	1.79	0.06	0	1	0	100	0.00	0.0	1.654	0.057	0	0	0	1
PL.54819	PL.54818	ABC	#4 ACSR	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	1.677	0.023	0	0	0	0
PL.54820	PL.54818	A	#2 ACSR	7.39Y	123.2	0.00	1.79	0.17	0	1	0	100	0.00	0.0	1.655	0.001	0	0	0	1
PD.5003	PL.54820	A	75QA	7.39Y	123.2	0.00	1.79	0.17	0	1	0	100	0.00	0.0	1.655	0.001	0	0	0	1
PL.33649	PD.5003	A	#2 ACSR	7.39Y	123.2	0.00	1.79	0.17	0	1	0	100	0.00	0.0	1.693	0.039	1	0	1	1
PL.55349	PL.55353	C	#1/0 ACSR	7.41Y	123.6	0.00	1.44	1.38	1	10	3	96	0.00	0.0	1.263	0.003	0	0	0	1
PD.8191	PL.55349	C	20QA	7.41Y	123.6	0.00	1.44	1.38	7	10	3	96	0.00	0.0	1.263	0.003	0	0	0	1
PL.55350	PD.8191	C	#1/0 ACSR	7.41Y	123.6	0.00	1.44	1.38	1	10	3	96	0.00	0.0	1.273	0.010	10	3	1	1
PL.55355	PL.55354	C	6 A (CWC)	7.42Y	123.7	0.00	1.31	1.64	1	12	3	97	0.00	0.0	1.134	0.003	0	0	0	2
PD.8192	PL.55355	C	75QA	7.42Y	123.7	0.00	1.31	1.64	2	12	3	97	0.00	0.0	1.134	0.003	0	0	0	2
PL.55356	PD.8192	C	6 A (CWC)	7.42Y	123.7	0.00	1.31	1.64	1	12	3	97	0.00	0.0	1.176	0.042	5	1	1	2
PL.55357	PL.55356	C	6 A (CWC)	7.42Y	123.7	0.00	1.31	0.87	1	6	2	95	0.00	0.0	1.204	0.028	6	2	1	1
PL.55360	PL.55363	C	6 A (CWC)	7.43Y	123.9	0.00	1.12	5.59	4	40	11	96	0.00	0.0	0.954	0.004	0	0	0	5
PD.8193	PL.55360	C	75QA	7.43Y	123.9	0.00	1.12	5.59	7	40	11	96	0.00	0.0	0.954	0.004	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55361	PD.8193	C	6 A (CWC)	7.43Y	123.9	0.01	1.13	5.59	4	40	11	96	0.00	0.0	1.023	0.069	24	7	3	5
PL.55359	PL.55361	C	6 A (CWC)	7.43Y	123.9	0.00	1.13	2.20	2	16	4	97	0.00	0.0	1.086	0.063	16	4	2	2
CP.49	PL.33551	ABC	Cap (300)	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	0.357	0.063	0	0	0	0
PL.54824	PL.55135	C	6 A (CWC)	7.48Y	124.6	0.00	0.42	6.00	4	43	12	96	0.00	0.0	0.349	0.004	0	0	0	7
PD.8197	PL.54824	C	75QA	7.48Y	124.6	0.00	0.42	6.00	8	43	12	96	0.00	0.0	0.349	0.004	0	0	0	7
PL.54825	PD.8197	C	6 A (CWC)	7.47Y	124.6	0.01	0.43	6.00	4	43	12	96	0.00	0.0	0.403	0.054	5	1	1	7
PL.55384	PL.54825	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	3.38	1	24	7	96	0.00	0.0	0.422	0.019	5	1	1	3
PL.55367	PL.55384	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	2.72	1	20	5	97	0.00	0.0	0.456	0.034	20	5	2	2
PL.64873	PL.54825	C	6 A (CWC)	7.47Y	124.6	0.01	0.44	1.98	1	14	4	96	0.00	0.0	0.473	0.070	0	0	1	3
PL.64874	PL.64873	C	6 A (CWC)	7.47Y	124.6	0.00	0.44	1.98	1	14	4	96	0.00	0.0	0.539	0.066	14	4	2	2
PL.52864	Bush	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	79.42	15	1718	492	96	0.00	0.0	0.002	0.002	0	0	0	269
PL.52865	PL.52864	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	79.42	15	1718	492	96	0.00	0.0	0.005	0.003	0	0	0	269

----- Feeder No. 1 (Marydale F1) Beginning with Device PD.8053 -----

PD.8053	PL.52865	ABC	480VWE	7.50Y	125.0	0.00	0.00	79.42	0	1718	492	96	0.00	0.0	0.005	0.003	0	0	0	269
PL.33355	PD.8053	ABC	397 SPACER	7.50Y	125.0	0.02	0.02	79.42	15	1718	492	96	0.07	0.0	0.089	0.084	51	14	1	269
PL.33356	PL.33355	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	77.08	15	1667	478	96	0.00	0.0	0.095	0.006	10	3	1	268
PL.33357	PL.33356	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	76.61	15	1657	475	96	0.00	0.0	0.097	0.002	0	0	0	267
PL.33621	PL.33357	ABC	#3/0 ACSR	7.49Y	124.8	0.13	0.16	76.61	26	1657	475	96	1.34	0.1	0.234	0.137	13	3	2	267
PL.33595	PL.33621	ABC	#3/0 ACSR	7.49Y	124.8	0.06	0.21	76.02	25	1643	469	96	0.57	0.0	0.292	0.058	0	0	0	265
PL.33360	PL.33595	ABC	#3/0 ACSR	7.48Y	124.7	0.07	0.28	76.00	25	1641	468	96	0.69	0.0	0.364	0.072	14	4	1	264
PL.33361	PL.33360	ABC	#3/0 ACSR	7.48Y	124.7	0.02	0.30	75.36	25	1627	464	96	0.23	0.0	0.389	0.024	3	1	1	263
PL.55249	PL.33361	ABC	#3/0 ACSR	7.48Y	124.6	0.08	0.38	75.20	25	1623	462	96	0.77	0.0	0.470	0.081	0	0	0	262
PL.55250	PL.55249	ABC	#3/0 ACSR	7.47Y	124.5	0.11	0.49	74.98	25	1618	460	96	1.09	0.1	0.587	0.117	24	6	2	261
PL.55061	PL.55250	ABC	#3/0 ACSR	7.46Y	124.4	0.09	0.59	73.89	25	1593	452	96	0.92	0.1	0.687	0.100	0	0	0	259
PL.33363	PL.55061	C	#4 ACSR	7.46Y	124.4	0.00	0.59	3.47	3	25	7	96	0.00	0.0	0.689	0.002	0	0	0	3
PD.4933	PL.33363	C	40QA	7.46Y	124.4	0.00	0.59	3.47	9	25	7	96	0.00	0.0	0.689	0.002	0	0	0	3
PL.55116	PD.4933	C	#4 ACSR	7.46Y	124.4	0.01	0.59	3.47	3	25	7	96	0.00	0.0	0.748	0.059	11	3	1	3
PL.55117	PL.55116	C	#4 ACSR	7.46Y	124.4	0.01	0.60	1.91	1	14	4	96	0.00	0.0	0.831	0.083	3	1	1	2
PL.55060	PL.55117	C	#4 ACSR	7.46Y	124.4	0.00	0.60	1.48	1	11	3	96	0.00	0.0	0.905	0.074	11	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33362	PL.55061	ABC	#3/0 ACSR	7.46Y	124.4	0.04	0.62	72.73	24	1567	444	96	0.35	0.0	0.727	0.040	37	10	4	256
PL.33459	PL.33362	ABC	#1/0 ACSR	7.45Y	124.2	0.16	0.78	69.58	30	1499	425	96	1.60	0.1	0.851	0.124	0	0	0	242
PL.33236	PL.33459	A	6 A (CWC)	7.45Y	124.2	0.00	0.78	9.09	6	65	18	96	0.00	0.0	0.855	0.003	0	0	0	10
PD.4934	PL.33236	A	40QA	7.45Y	124.2	0.00	0.78	9.09	23	65	18	96	0.00	0.0	0.855	0.003	0	0	0	10
PL.33237	PD.4934	A	6 A (CWC)	7.45Y	124.1	0.10	0.89	9.09	6	65	18	96	0.05	0.1	1.107	0.253	0	0	0	10
PL.64864	PL.33237	A	#4 ACSR	7.45Y	124.1	0.00	0.89	1.29	1	9	3	95	0.00	0.0	1.195	0.088	9	3	1	1
PL.33238	PL.33237	A	6 A (CWC)	7.44Y	124.1	0.03	0.92	7.79	6	56	15	97	0.01	0.0	1.204	0.097	0	0	0	9
PL.54983	PL.33238	A	#4 ACSR	7.44Y	124.1	0.00	0.92	1.18	1	9	2	98	0.00	0.0	1.243	0.039	9	2	1	1
PL.33239	PL.33238	A	6 A (CWC)	7.44Y	124.1	0.01	0.93	6.61	5	47	13	96	0.00	0.0	1.246	0.042	0	0	0	8
PL.33240	PL.33239	A	6 A (CWC)	7.44Y	124.1	0.01	0.94	6.61	5	47	13	96	0.00	0.0	1.285	0.038	10	3	1	8
PL.54980	PL.33240	A	6 A (CWC)	7.44Y	124.1	0.01	0.95	3.07	2	22	6	96	0.00	0.0	1.342	0.057	8	2	1	4
PL.54981	PL.54980	A	6 A (CWC)	7.44Y	124.0	0.00	0.95	1.77	1	13	3	97	0.00	0.0	1.379	0.037	0	0	0	1
PL.33241	PL.54981	A	6 A (CWC)	7.44Y	124.0	0.01	0.96	1.77	1	13	3	97	0.00	0.0	1.520	0.141	13	3	1	1
PL.54979	PL.54980	A	#4 ACSR	7.44Y	124.1	0.00	0.95	0.18	0	1	0	100	0.00	0.0	1.412	0.070	1	0	2	2
PL.33534	PL.33240	A	#4 ACSR	7.44Y	124.1	0.00	0.94	2.21	2	16	4	97	0.00	0.0	1.322	0.038	16	4	3	3
PL.33242	PL.33459	ABC	#1/0 ACSR	7.45Y	124.1	0.09	0.87	66.55	29	1432	406	96	0.92	0.1	0.929	0.078	0	0	0	232
PL.33243	PL.33242	ABC	#1/0 ACSR	7.45Y	124.1	0.03	0.90	66.55	29	1431	405	96	0.31	0.0	0.955	0.026	2	0	1	232
PL.33244	PL.33243	ABC	#1/0 ACSR	7.44Y	124.0	0.11	1.01	66.47	29	1429	404	96	1.07	0.1	1.046	0.091	0	0	0	231
PL.54787	PL.33244	ABC	#1/0 ACSR	7.43Y	123.9	0.09	1.10	64.19	28	1378	390	96	0.81	0.1	1.120	0.074	1	0	1	222
PL.54790	PL.54787	ABC	#1/0 ACSR	7.43Y	123.8	0.12	1.22	63.87	28	1371	387	96	1.10	0.1	1.222	0.102	6	2	1	220
PL.62765	PL.54790	ABC	#1/0 ACSR	7.42Y	123.7	0.04	1.26	63.20	27	1355	382	96	0.40	0.0	1.259	0.038	13	3	1	218
PL.62766	PL.62765	ABC	#1/0 ACSR	7.42Y	123.7	0.05	1.31	62.62	27	1342	379	96	0.46	0.0	1.303	0.044	5	1	1	217
PL.54793	PL.62766	ABC	#1/0 ACSR	7.41Y	123.6	0.12	1.42	62.37	27	1337	377	96	1.06	0.1	1.406	0.103	9	2	3	216
PL.54797	PL.54793	ABC	#1/0 ACSR	7.41Y	123.5	0.03	1.45	61.97	27	1327	373	96	0.25	0.0	1.430	0.024	10	3	1	213
PL.54796	PL.54797	C	#4 ACSR	7.41Y	123.5	0.00	1.45	1.67	1	12	3	97	0.00	0.0	1.435	0.004	0	0	0	1
PD.8171	PL.54796	C	40QA	7.41Y	123.5	0.00	1.45	1.67	4	12	3	97	0.00	0.0	1.435	0.004	0	0	0	1
PL.54794	PD.8171	C	#4 ACSR	7.41Y	123.5	0.00	1.45	1.67	1	12	3	97	0.00	0.0	1.478	0.043	12	3	1	1
PL.54795	PL.54797	ABC	#1/0 ACSR	7.40Y	123.3	0.28	1.73	60.28	26	1290	363	96	2.45	0.2	1.683	0.253	0	0	0	208
PL.55070	PL.54795	ABC	#1/0 ACSR	7.39Y	123.2	0.06	1.79	60.05	26	1283	360	96	0.52	0.0	1.738	0.055	12	3	1	206
PL.55071	PL.55070	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.82	59.51	26	1271	356	96	0.28	0.0	1.768	0.030	19	5	2	205
PL.33538	PL.55071	ABC	#1/0 ACSR	7.38Y	123.0	0.17	1.99	55.29	24	1180	331	96	1.36	0.1	1.936	0.168	10	3	2	194

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33685	PL.33538	ABC	#1/0 ACSR	7.37Y	122.8	0.26	2.25	53.73	23	1146	321	96	2.09	0.2	2.207	0.271	0	0	0	189
PL.33132	PL.33685	C	#4 ACSR	7.37Y	122.8	0.00	2.25	1.34	1	10	3	96	0.00	0.0	2.208	0.001	0	0	0	2
PD.4993	PL.33132	C	40QA	7.37Y	122.8	0.00	2.25	1.34	3	10	3	96	0.00	0.0	2.208	0.001	0	0	0	2
PL.55009	PD.4993	C	#4 ACSR	7.36Y	122.7	0.01	2.26	1.34	1	10	3	96	0.00	0.0	2.425	0.217	10	3	2	2
PL.55010	PL.55009	C	#4 ACSR	7.36Y	122.7	0.00	2.26	0.00	0	0	0	100	0.00	0.0	2.542	0.116	0	0	0	0
PL.33427	PL.33685	C	#4 ACSR	7.36Y	122.7	0.00	2.25	0.80	1	6	2	95	0.00	0.0	2.301	0.094	1	0	1	2
PL.33779	PL.33427	C	#4 ACSR	7.36Y	122.7	0.00	2.25	0.70	1	5	1	98	0.00	0.0	2.388	0.088	0	0	0	1
PL.33780	PL.33779	C	#4 ACSR	7.36Y	122.7	0.00	2.26	0.70	1	5	1	98	0.00	0.0	2.497	0.109	5	1	1	1
PL.33202	PL.33779	C	#4 ACSR	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	2.467	0.078	0	0	0	0
PL.33770	PL.33685	ABC	#1/0 ACSR	7.36Y	122.6	0.10	2.35	53.02	23	1128	315	96	0.81	0.1	2.315	0.108	2	1	1	185
PL.53820	PL.33770	ABC	#1/0 ACSR	7.35Y	122.6	0.09	2.44	52.91	23	1125	314	96	0.68	0.1	2.406	0.091	0	0	0	184
PL.53821	PL.53820	ABC	#1/0 ACSR	7.34Y	122.4	0.21	2.65	52.24	23	1110	309	96	1.60	0.1	2.627	0.221	8	2	1	183
PL.53916	PL.53821	ABC	#1/0 ACSR	7.33Y	122.2	0.15	2.80	51.66	22	1096	304	96	1.17	0.1	2.793	0.165	0	0	0	181
PL.53917	PL.53916	A	#4 ACSR	7.33Y	122.2	0.00	2.80	1.29	1	9	2	98	0.00	0.0	2.793	0.001	0	0	0	1
PD.4914	PL.53917	A	40QA	7.33Y	122.2	0.00	2.80	1.29	3	9	2	98	0.00	0.0	2.793	0.001	0	0	0	1
PL.33287	PD.4914	A	#4 ACSR	7.33Y	122.2	0.00	2.80	1.29	1	9	2	98	0.00	0.0	2.891	0.098	9	2	1	1
PL.53918	PL.53916	ABC	#1/0 ACSR	7.32Y	122.1	0.13	2.93	51.23	22	1086	301	96	1.01	0.1	2.937	0.144	0	0	0	180
PL.33609	PL.53918	ABC	#1/0 ACSR	7.32Y	122.0	0.08	3.01	51.02	22	1081	298	96	0.60	0.1	3.024	0.087	0	0	0	178
PL.33610	PL.33609	ABC	#1/0 ACSR	7.32Y	121.9	0.04	3.05	50.82	22	1076	297	96	0.29	0.0	3.067	0.043	0	0	0	176
PL.33774	PL.33610	ABC	#1/0 ACSR	7.31Y	121.9	0.08	3.13	46.99	20	994	274	96	0.53	0.1	3.158	0.091	0	0	0	166
PL.33783	PL.33774	ABC	#1/0 ACSR	7.30Y	121.7	0.17	3.30	46.34	20	980	270	96	1.18	0.1	3.365	0.207	6	2	1	164
PL.63848	PL.33783	ABC	#1/0 ACSR	7.30Y	121.6	0.11	3.41	46.06	20	973	268	96	0.74	0.1	3.497	0.132	0	0	0	163
PL.63849	PL.63848	ABC	#1/0 ACSR	7.30Y	121.6	0.00	3.41	46.06	20	972	267	96	0.00	0.0	3.497	0.000	1	0	1	163
PL.33419	PL.63849	C	6 A (CWC)	7.30Y	121.6	0.00	3.41	5.98	4	42	11	97	0.00	0.0	3.498	0.001	0	0	0	10
PD.4987	PL.33419	C	40QA	7.30Y	121.6	0.00	3.41	5.98	15	42	11	97	0.00	0.0	3.498	0.001	0	0	0	10
PL.33789	PD.4987	C	6 A (CWC)	7.29Y	121.5	0.05	3.46	5.98	4	42	11	97	0.02	0.0	3.679	0.182	0	0	0	10
PL.53668	PL.33789	C	#2 ACSR	7.29Y	121.5	0.01	3.47	5.10	3	36	10	96	0.00	0.0	3.733	0.053	19	5	5	7
PL.53870	PL.53668	C	#2 ACSR	7.29Y	121.5	0.00	3.47	2.46	1	17	5	96	0.00	0.0	3.774	0.041	7	2	1	2
PL.53871	PL.53870	C	#1/0 ACSR	7.29Y	121.5	0.00	3.47	1.44	1	10	3	96	0.00	0.0	3.827	0.053	10	3	1	1
PL.53816	PL.33789	C	6 A (CWC)	7.29Y	121.5	0.00	3.47	0.87	1	6	2	95	0.00	0.0	3.739	0.060	0	0	1	3
PL.53817	PL.53816	C	6 A (CWC)	7.29Y	121.5	0.01	3.47	0.87	1	6	2	95	0.00	0.0	3.942	0.202	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.34398	PL.53817	C	6 A (CWC)	7.29Y	121.5	0.00	3.48	0.24	0	2	0	100	0.00	0.0	4.129	0.188	0	0	0	1
PL.33314	PL.34398	C	#2 ACSR	7.29Y	121.5	0.00	3.48	0.24	0	2	0	100	0.00	0.0	4.186	0.057	2	0	1	1
PL.34399	PL.34398	C	6 A (CWC)	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	4.379	0.250	0	0	0	0
PL.33284	PL.53817	C	#4 ACSR	7.29Y	121.5	0.00	3.48	0.64	0	4	1	97	0.00	0.0	4.196	0.255	4	1	1	1
PL.33787	PL.63849	ABC	#1/0 ACSR	7.29Y	121.5	0.04	3.45	44.03	19	929	255	96	0.26	0.0	3.547	0.050	0	0	0	152
PL.57356	PL.33787	C	6 A (CWC)	7.29Y	121.5	0.00	3.45	2.12	2	15	4	97	0.00	0.0	3.565	0.018	15	4	1	1
PL.53913	PL.33787	ABC	#1/0 ACSR	7.29Y	121.5	0.06	3.51	43.33	19	914	251	96	0.38	0.0	3.623	0.076	0	0	0	151
PL.53914	PL.53913	ABC	#1/0 ACSR	7.29Y	121.5	0.02	3.53	43.33	19	914	251	96	0.13	0.0	3.649	0.026	15	4	2	151
PL.53667	PL.53914	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.55	42.62	19	899	246	96	0.14	0.0	3.678	0.029	0	0	0	149
PL.33788	PL.53667	C	6 A (CWC)	7.29Y	121.4	0.00	3.55	0.02	0	0	0	100	0.00	0.0	3.679	0.001	0	0	0	1
PD.4936	PL.33788	C	30QA	7.29Y	121.4	0.00	3.55	0.02	0	0	0	100	0.00	0.0	3.679	0.001	0	0	0	1
PL.53805	PD.4936	C	6 A (CWC)	7.29Y	121.4	0.00	3.55	0.02	0	0	0	100	0.00	0.0	3.695	0.016	0	0	1	1
PL.33776	PL.53667	ABC	#1/0 ACSR	7.28Y	121.4	0.06	3.62	42.62	19	898	246	96	0.41	0.0	3.763	0.085	4	1	5	148
PL.33190	PL.33776	A	#4 ACSR	7.28Y	121.4	0.00	3.62	9.70	7	68	18	97	0.00	0.0	3.763	0.000	0	0	0	8
PD.4974	PL.33190	A	40QA	7.28Y	121.4	0.00	3.62	9.70	24	68	18	97	0.00	0.0	3.763	0.000	0	0	0	8
PL.54368	PD.4974	A	#4 ACSR	7.28Y	121.4	0.02	3.64	9.70	7	68	18	97	0.01	0.0	3.809	0.045	14	4	1	8
PL.54369	PL.54368	A	#4 ACSR	7.28Y	121.4	0.00	3.64	5.31	4	37	10	97	0.00	0.0	3.821	0.013	0	0	0	5
PL.53906	PL.54369	A	#4 ACSR	7.28Y	121.4	0.01	3.65	3.89	3	27	7	97	0.00	0.0	3.873	0.052	0	0	0	4
PL.53905	PL.53906	A	#4 ACSR	7.28Y	121.3	0.01	3.66	3.89	3	27	7	97	0.00	0.0	3.930	0.056	0	0	0	4
PL.33127	PL.53905	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.34	0	2	1	89	0.00	0.0	3.980	0.051	2	1	1	1
PL.33497	PL.53905	A	#2 ACSR	7.28Y	121.3	0.00	3.66	2.27	1	16	4	97	0.00	0.0	3.952	0.023	16	4	2	2
PL.33791	PL.53905	A	#2 ACSR	7.28Y	121.3	0.00	3.66	1.28	1	9	2	98	0.00	0.0	3.989	0.060	0	0	0	1
PL.33792	PL.33791	A	#2 ACSR	7.28Y	121.3	0.00	3.66	1.28	1	9	2	98	0.00	0.0	4.024	0.034	9	2	1	1
PL.33208	PL.54369	A	#4 ACSR	7.28Y	121.4	0.00	3.64	1.42	1	10	3	96	0.00	0.0	3.847	0.026	10	3	1	1
PL.54370	PL.54368	A	#4 ACSR	7.28Y	121.4	0.00	3.64	2.38	2	17	5	96	0.00	0.0	3.853	0.045	7	2	1	2
PL.33790	PL.54370	A	#4 ACSR	7.28Y	121.4	0.00	3.64	1.45	1	10	3	96	0.00	0.0	3.930	0.077	10	3	1	1
PL.33262	PL.33776	ABC	#1/0 ACSR	7.28Y	121.4	0.03	3.65	39.19	17	826	226	96	0.18	0.0	3.806	0.043	0	0	0	135
PL.33644	PL.33262	ABC	#1/0 ACSR	7.28Y	121.3	0.00	3.65	39.19	17	826	226	96	0.00	0.0	3.807	0.000	0	0	0	135
RG.36	PL.33644	ABC	167Kkva	7.47Y	124.5	-3.11	0.54	39.19	18	826	226	96	percent Boost= 2.50 Tap= 4.0				0	0	0	135
PL.33128	RG.36	ABC	#1/0 ACSR	7.47Y	124.4	0.04	0.58	38.21	17	826	226	96	0.22	0.0	3.862	0.056	0	0	0	135
PL.33129	PL.33128	ABC	#1/0 ACSR	7.46Y	124.3	0.09	0.67	38.19	17	825	226	96	0.53	0.1	4.000	0.137	0	0	0	134

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58404	PL.33129	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	7.26	5	52	14	97	0.00	0.0	4.002	0.003	0	0	0	11
PD.8579	PL.58404	B	40T	7.46Y	124.3	0.00	0.67	7.26	0	52	14	97	0.00	0.0	4.002	0.003	0	0	0	11
PL.58405	PD.8579	B	6 A (CWC)	7.46Y	124.3	0.05	0.72	7.26	5	52	14	97	0.02	0.0	4.159	0.156	4	1	1	11
PL.58403	PL.58405	B	6 A (CWC)	7.45Y	124.2	0.03	0.75	6.65	5	48	13	97	0.01	0.0	4.255	0.096	0	0	0	10
PL.33794	PL.58403	B	6 A (CWC)	7.45Y	124.2	0.02	0.77	5.10	4	37	10	97	0.01	0.0	4.356	0.101	0	0	0	8
PL.33799	PL.33794	B	6 A (CWC)	7.45Y	124.2	0.01	0.79	3.13	2	23	6	97	0.00	0.0	4.439	0.083	4	1	2	6
PL.33506	PL.33799	B	6 A (CWC)	7.45Y	124.2	0.00	0.79	0.42	0	3	1	95	0.00	0.0	4.529	0.090	3	1	1	1
PL.33800	PL.33799	B	6 A (CWC)	7.45Y	124.2	0.02	0.80	2.12	2	15	4	97	0.00	0.0	4.615	0.176	0	0	0	3
PL.33290	PL.33800	B	6 A (CWC)	7.45Y	124.2	0.00	0.80	0.00	0	0	0	100	0.00	0.0	4.655	0.040	0	0	1	1
PL.53919	PL.33800	B	6 A (CWC)	7.45Y	124.2	0.02	0.83	2.12	2	15	4	97	0.00	0.0	4.944	0.329	7	2	1	2
PL.53920	PL.53919	B	#1/0 ACSR	7.45Y	124.2	0.00	0.83	1.13	0	8	2	97	0.00	0.0	5.005	0.061	8	2	1	1
PL.33519	PL.33794	B	#1/0 ACSR	7.45Y	124.2	0.00	0.78	1.96	1	14	4	96	0.00	0.0	4.378	0.022	0	0	0	2
PL.33585	PL.33519	B	#1/0 ACSR	7.45Y	124.2	0.00	0.78	1.96	1	14	4	96	0.00	0.0	4.413	0.035	10	3	1	2
PL.33288	PL.33288	B	#1/0 ACSR	7.45Y	124.2	0.00	0.78	0.60	0	4	1	97	0.00	0.0	4.454	0.041	0	0	0	1
PL.53911	PL.33288	B	#1/0 ACSR	7.45Y	124.2	0.00	0.78	0.00	0	0	0	100	0.00	0.0	4.495	0.042	0	0	0	0
PL.33793	PL.33288	B	#1/0 ACSR	7.45Y	124.2	0.00	0.78	0.60	0	4	1	97	0.00	0.0	4.490	0.037	4	1	1	1
PL.33795	PL.58403	B	#1/0 ACSR	7.45Y	124.2	0.00	0.75	1.55	1	11	3	96	0.00	0.0	4.278	0.024	11	3	1	2
PL.33796	PL.33795	B	#1/0 ACSR	7.45Y	124.2	0.00	0.75	0.03	0	0	0	100	0.00	0.0	4.299	0.020	0	0	1	1
PL.53897	PL.33129	ABC	#1/0 ACSR	7.46Y	124.3	0.05	0.72	35.76	16	772	211	96	0.26	0.0	4.078	0.078	9	2	2	123
PL.53896	PL.53897	ABC	#1/0 ACSR	7.45Y	124.2	0.04	0.76	35.35	15	763	209	96	0.19	0.0	4.135	0.057	0	0	0	121
PL.53669	PL.53896	ABC	#1/0 ACSR	7.45Y	124.2	0.06	0.81	34.93	15	754	206	96	0.29	0.0	4.223	0.088	0	0	0	120
PL.33797	PL.53669	ABC	#1/0 ACSR	7.45Y	124.1	0.05	0.86	34.64	15	747	204	96	0.26	0.0	4.304	0.081	0	0	0	118
PL.33463	PL.33797	ABC	#1/0 ACSR	7.45Y	124.1	0.00	0.87	34.64	15	747	204	96	0.01	0.0	4.309	0.004	0	0	0	118
PL.53944	PL.33463	ABC	#1/0 ACSR	7.45Y	124.1	0.04	0.91	34.64	15	747	204	96	0.20	0.0	4.371	0.062	10	3	1	118
PL.53945	PL.53944	ABC	#1/0 ACSR	7.44Y	124.0	0.08	0.99	34.18	15	737	201	96	0.42	0.1	4.507	0.136	0	0	0	117
PL.33801	PL.53945	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	0.72	1	5	1	98	0.00	0.0	4.509	0.002	0	0	0	1
PD.4998	PL.33801	C	40QA	7.44Y	124.0	0.00	0.99	0.72	2	5	1	98	0.00	0.0	4.509	0.002	0	0	0	1
PL.33802	PD.4998	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	0.72	1	5	1	98	0.00	0.0	4.638	0.129	5	1	1	1
PL.33305	PL.53945	ABC	#1/0 ACSR	7.44Y	123.9	0.06	1.05	33.94	15	731	199	96	0.31	0.0	4.608	0.101	5	1	1	116
PL.33632	PL.33305	ABC	#1/0 ACSR	7.43Y	123.9	0.05	1.10	33.70	15	726	197	97	0.24	0.0	4.688	0.080	0	0	0	115
PL.33804	PL.33632	A	6 A (CWC)	7.43Y	123.9	0.00	1.10	20.72	15	149	40	97	0.00	0.0	4.691	0.003	0	0	0	21

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5013	PL.33804	A	35L	7.43Y	123.9	0.00	1.10	20.72	59	149	40	97	0.00	0.0	4.691	0.003	0	0	0	21
PL.33138	PD.5013	A	6 A (CWC)	7.42Y	123.6	0.29	1.40	20.72	15	149	40	97	0.32	0.2	5.002	0.311	0	0	0	21
PL.33206	PL.33138	A	#2 ACSR	7.42Y	123.6	0.00	1.40	1.06	1	8	2	97	0.00	0.0	5.059	0.057	8	2	1	1
PL.33139	PL.33138	A	6 A (CWC)	7.41Y	123.5	0.06	1.45	19.67	14	141	38	97	0.06	0.0	5.065	0.063	8	2	1	20
PL.33140	PL.33139	A	6 A (CWC)	7.41Y	123.4	0.12	1.57	9.25	7	66	18	96	0.06	0.1	5.353	0.288	0	0	0	11
PL.33627	PL.33140	A	6 A (CWC)	7.40Y	123.4	0.02	1.59	3.24	2	23	6	97	0.00	0.0	5.470	0.116	0	0	0	4
PL.33207	PL.33627	A	#4 ACSR	7.40Y	123.4	0.00	1.59	1.18	1	8	2	97	0.00	0.0	5.514	0.044	8	2	1	1
PL.59090	PL.33627	A	6 A (CWC)	7.40Y	123.4	0.01	1.60	2.07	1	15	4	97	0.00	0.0	5.565	0.095	0	0	0	3
PL.59092	PL.59090	A	6 A (CWC)	7.40Y	123.4	0.01	1.61	1.49	1	11	3	96	0.00	0.0	5.720	0.155	7	2	1	2
PL.59093	PL.59092	A	6 A (CWC)	7.40Y	123.4	0.00	1.61	0.52	0	4	1	97	0.00	0.0	5.753	0.034	4	1	1	1
PL.59091	PL.59090	A	#1/0 ACSR	7.40Y	123.4	0.00	1.60	0.58	0	4	1	97	0.00	0.0	5.605	0.040	0	0	0	1
PL.53800	PL.59091	A	#1/0 ACSR	7.40Y	123.4	0.00	1.60	0.58	0	4	1	97	0.00	0.0	5.641	0.036	4	1	1	1
PL.33836	PL.33140	A	6 A (CWC)	7.40Y	123.4	0.02	1.59	6.00	4	43	12	96	0.01	0.0	5.411	0.057	0	0	0	7
PL.33837	PL.33836	A	#4 ACSR	7.40Y	123.4	0.00	1.59	1.29	1	9	2	98	0.00	0.0	5.487	0.076	5	1	1	2
PL.33626	PL.33837	A	#4 ACSR	7.40Y	123.4	0.00	1.59	0.60	0	4	1	97	0.00	0.0	5.540	0.053	4	1	1	1
PL.33539	PL.33836	A	6 A (CWC)	7.40Y	123.4	0.02	1.61	4.72	3	34	9	97	0.01	0.0	5.511	0.100	0	0	1	5
PL.66220	PL.33539	A	6 A (CWC)	7.40Y	123.4	0.01	1.62	4.72	3	34	9	97	0.00	0.0	5.578	0.067	12	3	1	4
PL.66219	PL.66220	A	6 A (CWC)	7.40Y	123.4	0.01	1.63	2.98	2	21	6	96	0.00	0.0	5.622	0.045	0	0	0	3
PL.64862	PL.66219	A	6 A (CWC)	7.40Y	123.4	0.00	1.63	0.00	0	0	0	100	0.00	0.0	5.681	0.059	0	0	0	0
PL.33431	PL.66219	A	6 A (CWC)	7.40Y	123.4	0.01	1.64	2.98	2	21	6	96	0.00	0.0	5.723	0.100	0	0	0	3
PL.33253	PL.33431	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	1.38	1	10	3	96	0.00	0.0	5.770	0.048	10	3	1	1
PL.62747	PL.33431	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.06	0	0	0	100	0.00	0.0	5.823	0.100	0	0	0	1
PL.62748	PL.62747	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	6.117	0.294	0	0	0	0
PL.33432	PL.62748	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	6.258	0.141	0	0	0	0
PL.33491	PL.33432	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	6.618	0.361	0	0	0	0
PL.33492	PL.33491	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	6.729	0.111	0	0	0	0
PL.64863	PL.62748	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	6.318	0.202	0	0	0	0
PL.62749	PL.62747	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.06	0	0	0	100	0.00	0.0	5.894	0.071	0	0	1	1
PL.33622	PL.33431	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	1.54	1	11	3	96	0.00	0.0	5.798	0.075	11	3	1	1
PL.33623	PL.33622	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	5.831	0.033	0	0	0	0
PL.64752	PL.33623	A	#1/0 ACSR	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	5.861	0.030	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.64753	PL.64752	A	#1/0 ACSR	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	5.922	0.061	0	0	0	0
PL.33834	PL.33139	A	6 A (CWC)	7.41Y	123.5	0.01	1.46	4.61	3	33	9	96	0.00	0.0	5.126	0.061	0	0	0	4
PL.53894	PL.33834	A	#2 ACSR	7.41Y	123.5	0.00	1.47	3.63	2	26	7	97	0.00	0.0	5.154	0.028	12	3	1	3
PL.53895	PL.53894	A	#2 ACSR	7.41Y	123.5	0.00	1.47	1.98	1	14	4	96	0.00	0.0	5.192	0.038	8	2	1	2
PL.53810	PL.53895	A	#2 ACSR	7.41Y	123.5	0.00	1.47	0.93	1	7	2	96	0.00	0.0	5.226	0.034	7	2	1	1
PL.33143	PL.33834	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.99	1	7	2	96	0.00	0.0	5.144	0.018	7	2	1	1
PL.33835	PL.33139	A	6 A (CWC)	7.41Y	123.5	0.01	1.47	4.67	3	33	9	96	0.00	0.0	5.150	0.084	11	3	1	4
PL.33306	PL.33835	A	6 A (CWC)	7.41Y	123.5	0.02	1.48	3.07	2	22	6	96	0.00	0.0	5.289	0.139	10	3	1	3
PL.33307	PL.33306	A	6 A (CWC)	7.41Y	123.5	0.01	1.49	1.69	1	12	3	97	0.00	0.0	5.438	0.149	6	2	1	2
PL.33310	PL.33307	A	6 A (CWC)	7.41Y	123.5	0.00	1.49	0.83	1	6	2	95	0.00	0.0	5.473	0.036	6	2	1	1
PL.61245	PL.33632	ABC	#1/0 ACSR	7.43Y	123.9	0.04	1.14	24.93	11	537	146	96	0.16	0.0	4.785	0.097	0	0	1	90
PL.61246	PL.61245	ABC	#1/0 ACSR	7.43Y	123.8	0.04	1.18	24.93	11	536	146	96	0.14	0.0	4.869	0.083	0	0	0	89
PL.63966	PL.61246	ABC	#1/0 ACSR	7.43Y	123.8	0.00	1.18	24.26	11	522	142	96	0.00	0.0	4.869	0.000	8	2	1	87
PL.63967	PL.63966	ABC	#1/0 ACSR	7.43Y	123.8	0.05	1.23	23.90	10	514	140	96	0.18	0.0	4.988	0.119	12	3	3	86
PL.33540	PL.63967	C	#4 ACSR	7.43Y	123.8	0.00	1.23	1.09	1	8	2	97	0.00	0.0	4.988	0.001	0	0	0	1
PD.4897	PL.33540	C	40QA	7.43Y	123.8	0.00	1.23	1.09	3	8	2	97	0.00	0.0	4.988	0.001	0	0	0	1
PL.33541	PD.4897	C	#4 ACSR	7.43Y	123.8	0.00	1.23	1.09	1	8	2	97	0.00	0.0	5.066	0.078	8	2	1	1
PL.59086	PL.63967	ABC	#1/0 ACSR	7.42Y	123.7	0.05	1.28	22.99	10	494	134	97	0.18	0.0	5.114	0.126	0	0	0	82
PL.59087	PL.59086	ABC	#1/0 ACSR	7.42Y	123.7	0.03	1.31	22.99	10	494	134	97	0.09	0.0	5.180	0.066	0	0	0	82
PL.59085	PL.59087	C	6 A (CWC)	7.42Y	123.7	0.00	1.31	0.26	0	2	1	89	0.00	0.0	5.181	0.001	0	0	0	1
PD.4986	PL.59085	C	40QA	7.42Y	123.7	0.00	1.31	0.26	1	2	1	89	0.00	0.0	5.181	0.001	0	0	0	1
PL.33883	PD.4986	C	6 A (CWC)	7.42Y	123.7	0.00	1.31	0.26	0	2	1	89	0.00	0.0	5.267	0.086	2	1	1	1
PL.62743	PL.59087	ABC	#1/0 ACSR	7.42Y	123.6	0.07	1.38	22.90	10	492	133	97	0.24	0.0	5.354	0.174	0	0	0	81
PL.33881	PL.62743	ABC	#1/0 ACSR	7.42Y	123.6	0.03	1.41	22.90	10	492	133	97	0.11	0.0	5.429	0.075	0	0	0	81
PL.33879	PL.33881	A	6 A (CWC)	7.42Y	123.6	0.00	1.41	22.88	16	164	44	97	0.00	0.0	5.430	0.001	0	0	0	26
PD.4999	PL.33879	A	40QA	7.42Y	123.6	0.00	1.41	22.88	57	164	44	97	0.00	0.0	5.430	0.001	0	0	0	26
PL.53876	PD.4999	A	6 A (CWC)	7.41Y	123.4	0.15	1.57	22.88	16	164	44	97	0.18	0.1	5.580	0.150	9	2	2	26
PL.62744	PL.53876	A	#2 ACSR	7.41Y	123.4	0.00	1.57	1.48	1	11	3	96	0.00	0.0	5.601	0.020	11	3	1	1
PL.62745	PL.62744	A	#2 ACSR	7.41Y	123.4	0.00	1.57	0.00	0	0	0	100	0.00	0.0	5.619	0.018	0	0	0	0
PL.53872	PL.53876	A	6 A (CWC)	7.40Y	123.4	0.02	1.58	8.40	6	60	16	97	0.01	0.0	5.633	0.053	17	5	3	8
PL.53874	PL.53872	A	#4 ACSR	7.40Y	123.4	0.00	1.59	3.54	3	25	7	96	0.00	0.0	5.682	0.049	25	7	3	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53873	PL.53872	A	6 A (CWC)	7.40Y	123.4	0.00	1.59	2.43	2	17	5	96	0.00	0.0	5.701	0.068	17	5	2	2
PL.53875	PL.53876	A	6 A (CWC)	7.41Y	123.4	0.01	1.57	11.74	8	84	23	96	0.01	0.0	5.595	0.015	0	0	0	15
PL.53900	PL.53875	A	6 A (CWC)	7.40Y	123.4	0.05	1.62	11.74	8	84	23	96	0.03	0.0	5.682	0.087	0	0	0	15
PL.53883	PL.53900	A	#4 ACSR	7.40Y	123.4	0.03	1.65	8.15	6	58	16	96	0.01	0.0	5.776	0.094	20	5	5	10
PL.53884	PL.53883	A	#4 ACSR	7.40Y	123.4	0.00	1.65	0.00	0	0	0	100	0.00	0.0	5.818	0.042	0	0	0	0
PL.53882	PL.53883	A	#4 ACSR	7.40Y	123.3	0.00	1.65	3.31	3	24	6	97	0.00	0.0	5.834	0.058	24	6	2	2
PL.53885	PL.53883	A	#4 ACSR	7.40Y	123.3	0.00	1.65	2.05	2	15	4	97	0.00	0.0	5.814	0.038	8	2	1	3
PL.33882	PL.53885	A	#4 ACSR	7.40Y	123.3	0.00	1.65	0.93	1	7	2	96	0.00	0.0	5.929	0.115	7	2	2	2
PL.33283	PL.53900	A	6 A (CWC)	7.40Y	123.4	0.00	1.62	3.58	3	26	7	97	0.00	0.0	5.697	0.015	7	2	3	5
PL.33225	PL.33283	A	6 A (CWC)	7.40Y	123.4	0.00	1.63	2.57	2	18	5	96	0.00	0.0	5.739	0.042	11	3	1	2
PL.53901	PL.33225	A	6 A (CWC)	7.40Y	123.4	0.00	1.63	0.97	1	7	2	96	0.00	0.0	5.809	0.070	7	2	1	1
PL.33880	PL.33881	C	6 A (CWC)	7.42Y	123.6	0.00	1.41	4.48	3	32	9	96	0.00	0.0	5.429	0.001	0	0	0	5
PD.4940	PL.33880	C	40QA	7.42Y	123.6	0.00	1.41	4.48	11	32	9	96	0.00	0.0	5.429	0.001	0	0	0	5
PL.33114	PD.4940	C	6 A (CWC)	7.41Y	123.5	0.05	1.46	4.48	3	32	9	96	0.01	0.0	5.664	0.234	2	1	2	5
PL.33115	PL.33114	C	6 A (CWC)	7.41Y	123.5	0.01	1.47	4.21	3	30	8	97	0.00	0.0	5.746	0.082	30	8	3	3
PL.61689	PL.33881	ABC	#1/0 ACSR	7.41Y	123.6	0.03	1.44	13.78	6	296	80	97	0.05	0.0	5.530	0.101	0	0	0	50
PL.61691	PL.61689	A	#1/0 ACSR	7.41Y	123.6	0.00	1.44	2.67	1	19	5	97	0.00	0.0	5.532	0.002	0	0	0	3
PD.9151	PL.61691	A	40QA	7.41Y	123.6	0.00	1.44	2.67	7	19	5	97	0.00	0.0	5.532	0.002	0	0	0	3
PL.61688	PD.9151	A	#1/0 ACSR	7.41Y	123.6	0.00	1.44	2.67	1	19	5	97	0.00	0.0	5.554	0.022	0	0	0	3
PL.61242	PL.61688	A	#1/0 ACSR	7.41Y	123.6	0.00	1.44	2.57	1	18	5	96	0.00	0.0	5.574	0.021	18	5	2	2
PL.61243	PL.61688	A	#1/0 ACSR	7.41Y	123.6	0.00	1.44	0.10	0	1	0	100	0.00	0.0	5.600	0.047	1	0	1	1
PL.61690	PL.61689	ABC	#1/0 ACSR	7.41Y	123.5	0.01	1.45	12.89	6	277	75	97	0.02	0.0	5.583	0.053	0	0	1	47
PL.55178	PL.61690	ABC	#1/0 ACSR	7.41Y	123.5	0.01	1.46	12.87	6	276	75	97	0.02	0.0	5.625	0.042	0	0	0	46
PL.55177	PL.55178	C	#4 ACSR	7.41Y	123.5	0.00	1.46	2.79	2	20	5	97	0.00	0.0	5.626	0.001	0	0	0	2
PD.5008	PL.55177	C	40QA	7.41Y	123.5	0.00	1.46	2.79	7	20	5	97	0.00	0.0	5.626	0.001	0	0	0	2
PL.34188	PD.5008	C	#4 ACSR	7.41Y	123.5	0.00	1.46	2.79	2	20	5	97	0.00	0.0	5.660	0.034	20	5	2	2
PL.55176	PL.55178	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.48	11.94	5	256	69	97	0.04	0.0	5.721	0.096	3	1	1	44
PL.53881	PL.55176	ABC	#1/0 ACSR	7.41Y	123.5	0.01	1.49	11.51	5	247	67	97	0.01	0.0	5.749	0.028	5	1	1	42
PL.53879	PL.53881	B	6 A (CWC)	7.41Y	123.4	0.08	1.57	21.37	15	153	41	97	0.09	0.1	5.833	0.083	0	0	0	26
PD.7916	PL.53879	B	25T	7.41Y	123.4	0.00	1.57	21.37	0	153	41	97	0.00	0.0	5.833	0.083	0	0	0	26
PL.53951	PD.7916	B	6 A (CWC)	7.41Y	123.4	0.00	1.57	21.37	15	153	41	97	0.00	0.0	5.835	0.002	0	0	0	26

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53671	PL.53951	B	#4 ACSR	7.41Y	123.4	0.00	1.57	1.62	1	12	3	97	0.00	0.0	5.916	0.081	12	3	1	1
PL.53952	PL.53951	B	#1/0 ACSR	7.41Y	123.4	0.00	1.57	1.77	1	13	3	97	0.00	0.0	5.863	0.028	0	0	1	2
PL.53801	PL.53952	B	#1/0 ACSR	7.41Y	123.4	0.00	1.57	1.77	1	13	3	97	0.00	0.0	5.917	0.054	13	3	1	1
PL.53672	PL.53951	B	6 A (CWC)	7.40Y	123.3	0.08	1.65	17.98	13	129	35	97	0.08	0.1	5.937	0.102	9	2	1	23
PL.33252	PL.53672	B	#2 ACSR	7.40Y	123.3	0.00	1.65	0.91	1	6	2	95	0.00	0.0	6.010	0.073	6	2	1	1
PL.33461	PL.53672	B	6 A (CWC)	7.40Y	123.3	0.00	1.65	1.99	1	14	4	96	0.00	0.0	5.987	0.050	14	4	2	2
PL.53903	PL.53672	B	6 A (CWC)	7.40Y	123.3	0.03	1.68	13.82	10	99	27	96	0.02	0.0	5.990	0.054	0	0	0	19
PL.53904	PL.53903	B	6 A (CWC)	7.40Y	123.3	0.02	1.70	13.82	10	99	27	96	0.01	0.0	6.016	0.026	0	0	0	19
PL.33453	PL.53904	B	6 A (CWC)	7.40Y	123.3	0.03	1.73	3.87	3	28	7	97	0.01	0.0	6.173	0.156	0	0	0	4
PL.33454	PL.33453	B	6 A (CWC)	7.40Y	123.3	0.01	1.74	3.87	3	28	7	97	0.00	0.0	6.250	0.077	0	0	0	4
PL.33429	PL.33454	B	6 A (CWC)	7.40Y	123.3	0.00	1.74	1.27	1	9	2	98	0.00	0.0	6.280	0.030	7	2	1	2
PL.66218	PL.33429	B	#1/0 ACSR	7.40Y	123.3	0.00	1.74	0.34	0	2	1	89	0.00	0.0	6.311	0.031	2	1	1	1
PL.33249	PL.33454	B	6 A (CWC)	7.39Y	123.2	0.01	1.75	2.60	2	19	5	97	0.00	0.0	6.320	0.069	0	0	0	2
PL.72956	PL.33249	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	1.31	1	9	3	95	0.00	0.0	6.373	0.053	0	0	0	1
PL.72957	PL.72956	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	1.31	1	9	3	95	0.00	0.0	6.373	0.000	9	3	1	1
PL.72958	PL.72957	B	#1/0 ACSR	7.39Y	123.2	0.00	1.75	0.00	0	0	0	100	0.00	0.0	6.407	0.034	0	0	0	0
PL.72959	PL.72958	B	#1/0 ACSR	7.39Y	123.2	0.00	1.75	0.00	0	0	0	100	0.00	0.0	6.474	0.067	0	0	0	0
PL.33449	PL.33249	B	#4 ACSR	7.39Y	123.2	0.00	1.75	1.29	1	9	2	98	0.00	0.0	6.370	0.050	9	2	1	1
PL.34206	PL.53904	B	#4 ACSR	7.40Y	123.3	0.02	1.72	9.95	8	71	19	97	0.01	0.0	6.062	0.046	6	2	1	15
PL.33112	PL.34206	B	#4 ACSR	7.39Y	123.2	0.03	1.75	9.09	7	65	18	96	0.02	0.0	6.140	0.078	0	0	1	14
PL.33452	PL.33112	B	6 A (CWC)	7.39Y	123.2	0.01	1.76	6.00	4	43	12	96	0.00	0.0	6.172	0.032	0	0	0	7
PL.33482	PL.33452	B	6 A (CWC)	7.39Y	123.2	0.01	1.77	4.88	3	35	9	97	0.00	0.0	6.211	0.039	5	1	1	5
PL.33118	PL.33482	B	6 A (CWC)	7.39Y	123.2	0.02	1.79	4.17	3	30	8	97	0.01	0.0	6.342	0.130	0	0	0	4
PL.33119	PL.33118	B	6 A (CWC)	7.39Y	123.2	0.00	1.80	3.20	2	23	6	97	0.00	0.0	6.355	0.014	10	3	1	3
PL.33247	PL.33119	B	6 A (CWC)	7.39Y	123.2	0.00	1.80	1.78	1	13	3	97	0.00	0.0	6.472	0.117	12	3	1	2
PL.33248	PL.33247	B	6 A (CWC)	7.39Y	123.2	0.00	1.80	0.04	0	0	0	100	0.00	0.0	6.504	0.032	0	0	1	1
PL.53909	PL.33118	B	#4 ACSR	7.39Y	123.2	0.01	1.80	0.97	1	7	2	96	0.00	0.0	6.657	0.316	7	2	1	1
PL.53910	PL.53909	B	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.00	0	0	0	100	0.00	0.0	6.702	0.044	0	0	0	0
PL.33116	PL.33452	B	#4 ACSR	7.39Y	123.2	0.00	1.76	1.12	1	8	2	97	0.00	0.0	6.241	0.069	8	2	1	2
PL.33117	PL.33116	B	#4 ACSR	7.39Y	123.2	0.00	1.76	0.00	0	0	0	100	0.00	0.0	6.260	0.019	0	0	1	1
PL.59075	PL.33112	B	#4 ACSR	7.39Y	123.2	0.00	1.75	3.08	2	22	6	96	0.00	0.0	6.154	0.014	2	0	1	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59076	PL.59075	B	#4 ACSR	7.39Y	123.2	0.00	1.76	2.16	2	15	4	97	0.00	0.0	6.175	0.021	7	2	1	3
PL.57894	PL.59076	B	#4 ACSR	7.39Y	123.2	0.00	1.76	0.59	0	4	1	97	0.00	0.0	6.221	0.046	4	1	1	1
PL.57893	PL.59076	B	#4 ACSR	7.39Y	123.2	0.00	1.76	0.63	0	5	1	98	0.00	0.0	6.356	0.181	5	1	1	1
PL.59074	PL.59075	B	#4 ACSR	7.39Y	123.2	0.00	1.75	0.71	1	5	1	98	0.00	0.0	6.204	0.050	4	1	1	2
PL.33277	PL.59074	B	#4 ACSR	7.39Y	123.2	0.00	1.75	0.18	0	1	0	100	0.00	0.0	6.225	0.021	1	0	1	1
PL.53880	PL.53881	ABC	#1/0 ACSR	7.41Y	123.5	0.01	1.49	4.14	2	89	24	97	0.00	0.0	5.824	0.075	18	5	4	15
PL.53902	PL.53880	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.49	3.31	1	71	19	97	0.00	0.0	5.879	0.055	0	0	0	11
PL.33483	PL.53902	A	#2 ACSR	7.41Y	123.5	0.00	1.50	1.67	1	12	3	97	0.00	0.0	5.898	0.019	12	3	4	4
PL.34187	PL.53902	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.50	2.42	1	52	14	97	0.00	0.0	5.952	0.073	13	4	2	6
PL.34186	PL.34187	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.50	1.79	1	39	10	97	0.00	0.0	6.016	0.064	39	10	4	4
PL.58877	PL.34186	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.50	0.00	0	0	0	100	0.00	0.0	6.078	0.063	0	0	0	0
PD.8482-A	PL.58877	ABC	Open	7.41Y	123.5	0.00	1.50	0.00	0	0	0	100	0.00	0.0	6.078	0.063	0	0	0	0
PL.53907	PL.53902	A	#2 ACSR	7.41Y	123.5	0.00	1.49	1.02	1	7	2	96	0.00	0.0	5.901	0.022	7	2	1	1
PL.53887	PL.55176	A	#1/0 ACSR	7.41Y	123.5	0.00	1.48	0.93	0	7	2	96	0.00	0.0	5.724	0.003	0	0	0	1
PD.7930	PL.53887	A	10QA	7.41Y	123.5	0.00	1.48	0.93	0	7	2	96	0.00	0.0	5.724	0.003	0	0	0	1
PL.53889	PD.7930	A	#1/0 ACSR	7.41Y	123.5	0.00	1.48	0.93	0	7	2	96	0.00	0.0	5.732	0.009	0	0	0	1
PL.53888	PL.53889	A	#1/0 ACSR	7.41Y	123.5	0.00	1.48	0.93	0	7	2	96	0.00	0.0	5.763	0.031	7	2	1	1
PL.61244	PL.61246	A	#4 ACSR	7.43Y	123.8	0.00	1.18	2.00	2	14	4	96	0.00	0.0	4.870	0.001	0	0	0	2
PD.5001	PL.61244	A	12T	7.43Y	123.8	0.00	1.18	2.00	0	14	4	96	0.00	0.0	4.870	0.001	0	0	0	2
PL.33113	PD.5001	A	#4 ACSR	7.43Y	123.8	0.00	1.18	2.00	2	14	4	96	0.00	0.0	4.915	0.046	14	4	2	2
PL.33803	PL.33632	A	#2 ACSR	7.43Y	123.9	0.00	1.10	5.59	3	40	11	96	0.00	0.0	4.691	0.003	0	0	0	4
PD.4937	PL.33803	A	20T	7.43Y	123.9	0.00	1.10	5.59	0	40	11	96	0.00	0.0	4.691	0.003	0	0	0	4
PL.53946	PD.4937	A	#2 ACSR	7.43Y	123.9	0.01	1.11	5.59	3	40	11	96	0.00	0.0	4.727	0.036	0	0	0	4
PL.72960	PL.53946	A	#1/0 ACSR	7.43Y	123.9	0.01	1.11	5.59	2	40	11	96	0.00	0.0	4.792	0.065	0	0	0	4
PL.72961	PL.72960	A	#1/0 ACSR	7.43Y	123.9	0.01	1.12	5.59	2	40	11	96	0.00	0.0	4.842	0.051	0	0	0	4
PL.62768	PL.72961	A	#1/0 ACSR	7.43Y	123.9	0.01	1.13	3.18	1	23	6	97	0.00	0.0	4.979	0.137	18	5	1	2
PL.53825	PL.62768	A	#1/0 ACSR	7.43Y	123.9	0.00	1.13	0.71	0	5	1	98	0.00	0.0	5.040	0.061	5	1	1	1
PL.62769	PL.72961	A	#1/0 ACSR	7.43Y	123.9	0.00	1.12	2.41	1	17	5	96	0.00	0.0	4.907	0.065	0	0	0	2
PL.62770	PL.62769	A	#1/0 ACSR	7.43Y	123.9	0.00	1.13	2.41	1	17	5	96	0.00	0.0	4.986	0.079	10	3	1	2
PL.62771	PL.62770	A	#1/0 ACSR	7.43Y	123.9	0.00	1.13	1.03	0	7	2	96	0.00	0.0	5.054	0.068	7	2	1	1
CP.50	PL.33463	ABC	Cap (300)	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	4.309	0.068	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33798	PL.53669	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	0.87	0	6	2	95	0.00	0.0	4.228	0.004	0	0	0	2
PD.4985	PL.33798	A	10QA	7.45Y	124.2	0.00	0.81	0.87	0	6	2	95	0.00	0.0	4.228	0.004	0	0	0	2
PL.53802	PD.4985	A	#1/0 ACSR	7.45Y	124.2	0.00	0.82	0.87	0	6	2	95	0.00	0.0	4.339	0.112	0	0	1	2
PL.53803	PL.53802	A	#1/0 ACSR	7.45Y	124.2	0.00	0.82	0.87	0	6	2	95	0.00	0.0	4.464	0.124	6	2	1	1
PL.53670	PL.53896	C	#1/0 ACSR	7.45Y	124.2	0.00	0.76	1.24	1	9	2	98	0.00	0.0	4.139	0.004	0	0	0	1
PD.8112	PL.53670	C	20QA	7.45Y	124.2	0.00	0.76	1.24	6	9	2	98	0.00	0.0	4.139	0.004	0	0	0	1
PL.53824	PD.8112	C	#1/0 ACSR	7.45Y	124.2	0.00	0.76	1.24	1	9	2	98	0.00	0.0	4.185	0.047	9	2	1	1
PL.33130	PL.33128	C	6 A (CWC)	7.47Y	124.4	0.00	0.58	0.08	0	1	0	100	0.00	0.0	3.864	0.002	0	0	0	1
PD.4938	PL.33130	C	40QA	7.47Y	124.4	0.00	0.58	0.08	0	1	0	100	0.00	0.0	3.864	0.002	0	0	0	1
PL.33131	PD.4938	C	6 A (CWC)	7.47Y	124.4	0.00	0.58	0.08	0	1	0	100	0.00	0.0	3.969	0.105	1	0	1	1
PL.33133	PL.33774	A	#4 ACSR	7.31Y	121.9	0.00	3.13	1.95	2	14	4	96	0.00	0.0	3.161	0.003	0	0	0	2
PD.4997	PL.33133	A	40QA	7.31Y	121.9	0.00	3.13	1.95	5	14	4	96	0.00	0.0	3.161	0.003	0	0	0	2
PL.33134	PD.4997	A	#4 ACSR	7.31Y	121.9	0.00	3.13	1.95	2	14	4	96	0.00	0.0	3.184	0.023	9	2	1	2
PL.33778	PL.33134	A	#4 ACSR	7.31Y	121.9	0.00	3.13	0.65	1	5	1	98	0.00	0.0	3.260	0.076	5	1	1	1
PL.33775	PL.33610	C	6 A (CWC)	7.32Y	121.9	0.00	3.05	11.49	8	81	22	97	0.00	0.0	3.068	0.001	0	0	0	10
PD.4905	PL.33775	C	40QA	7.32Y	121.9	0.00	3.05	11.49	29	81	22	97	0.00	0.0	3.068	0.001	0	0	0	10
PL.33777	PD.4905	C	6 A (CWC)	7.32Y	121.9	0.01	3.07	11.49	8	81	22	97	0.01	0.0	3.098	0.030	19	5	2	10
PL.33781	PL.33777	C	6 A (CWC)	7.31Y	121.9	0.04	3.11	8.82	6	62	17	96	0.02	0.0	3.203	0.105	8	2	1	8
PL.33782	PL.33781	C	6 A (CWC)	7.31Y	121.9	0.02	3.12	6.75	5	48	13	97	0.01	0.0	3.252	0.049	0	0	0	6
PL.33499	PL.33782	C	6 A (CWC)	7.31Y	121.9	0.00	3.13	1.07	1	8	2	97	0.00	0.0	3.355	0.102	8	2	2	2
PL.53807	PL.33782	C	6 A (CWC)	7.31Y	121.9	0.02	3.14	5.69	4	40	11	96	0.01	0.0	3.345	0.093	10	3	1	4
PL.53808	PL.53807	C	6 A (CWC)	7.31Y	121.8	0.02	3.17	3.09	2	22	6	96	0.00	0.0	3.531	0.185	7	2	1	2
PL.34395	PL.53808	C	6 A (CWC)	7.31Y	121.8	0.00	3.17	2.04	1	14	4	96	0.00	0.0	3.577	0.046	14	4	1	1
PL.53809	PL.53807	C	#1/0 ACSR	7.31Y	121.9	0.00	3.15	1.21	1	9	2	98	0.00	0.0	3.494	0.149	9	2	1	1
PL.64854	PL.33781	C	6 A (CWC)	7.31Y	121.9	0.00	3.11	0.87	1	6	2	95	0.00	0.0	3.353	0.150	6	2	1	1
PL.33611	PL.33609	A	#4 ACSR	7.32Y	122.0	0.00	3.01	0.61	0	4	1	97	0.00	0.0	3.025	0.001	0	0	0	2
PD.4904	PL.33611	A	40QA	7.32Y	122.0	0.00	3.01	0.61	2	4	1	97	0.00	0.0	3.025	0.001	0	0	0	2
PL.64339	PD.4904	A	#4 ACSR	7.32Y	122.0	0.00	3.02	0.61	0	4	1	97	0.00	0.0	3.062	0.037	0	0	0	2
PL.64340	PL.64339	A	#4 ACSR	7.32Y	122.0	0.00	3.02	0.41	0	3	1	95	0.00	0.0	3.103	0.041	3	1	1	1
PL.64341	PL.64339	A	#2 ACSR	7.32Y	122.0	0.00	3.02	0.20	0	1	0	100	0.00	0.0	3.098	0.036	0	0	0	1
PL.64342	PL.64341	A	#1/0 ACSR	7.32Y	122.0	0.00	3.02	0.20	0	1	0	100	0.00	0.0	3.133	0.035	1	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33772	PL.53918	A	#4 ACSR	7.32Y	122.1	0.00	2.93	0.61	0	4	1	97	0.00	0.0	2.938	0.001	0	0	0	2
PD.4901	PL.33772	A	40QA	7.32Y	122.1	0.00	2.93	0.61	2	4	1	97	0.00	0.0	2.938	0.001	0	0	0	2
PL.33773	PD.4901	A	#4 ACSR	7.32Y	122.1	0.00	2.94	0.61	0	4	1	97	0.00	0.0	3.003	0.065	4	1	2	2
PL.33771	PL.53821	A	6 A (CWC)	7.34Y	122.4	0.00	2.65	0.64	0	5	1	98	0.00	0.0	2.629	0.001	0	0	0	1
PD.4903	PL.33771	A	40QA	7.34Y	122.4	0.00	2.65	0.64	2	5	1	98	0.00	0.0	2.629	0.001	0	0	0	1
PL.53823	PD.4903	A	6 A (CWC)	7.34Y	122.4	0.00	2.65	0.64	0	5	1	98	0.00	0.0	2.705	0.077	5	1	1	1
PL.53822	PL.53820	C	#1/0 ACSR	7.35Y	122.6	0.00	2.44	2.01	1	14	4	96	0.00	0.0	2.421	0.015	14	4	1	1
PL.61196	PL.33538	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	1.39	1	10	3	96	0.00	0.0	1.939	0.003	0	0	0	1
PD.9103	PL.61196	C	15T	7.38Y	123.0	0.00	1.99	1.39	0	10	3	96	0.00	0.0	1.939	0.003	0	0	0	1
PL.61197	PD.9103	C	#1/0 ACSR	7.38Y	123.0	0.00	1.99	1.39	1	10	3	96	0.00	0.0	1.981	0.041	10	3	1	1
PL.33686	PL.33538	C	6 A (CWC)	7.38Y	123.0	0.00	1.99	1.91	1	14	4	96	0.00	0.0	1.991	0.055	10	3	1	2
PL.33769	PL.33686	C	6 A (CWC)	7.38Y	123.0	0.00	1.99	0.54	0	4	1	97	0.00	0.0	2.081	0.090	4	1	1	1
PL.33507	PL.55071	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	9.98	7	71	19	97	0.00	0.0	1.768	0.001	0	0	0	9
PD.4902	PL.33507	C	40QA	7.39Y	123.2	0.00	1.82	9.98	25	71	19	97	0.00	0.0	1.768	0.001	0	0	0	9
PL.55069	PD.4902	C	6 A (CWC)	7.39Y	123.2	0.02	1.84	9.98	7	71	19	97	0.01	0.0	1.817	0.049	11	3	1	9
PL.55379	PL.55069	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	8.43	4	60	16	97	0.00	0.0	1.825	0.008	8	2	1	8
PL.55380	PL.55379	C	#1/0 ACSR	7.39Y	123.1	0.02	1.86	7.33	3	52	14	97	0.01	0.0	1.944	0.119	9	2	1	7
PL.55381	PL.55380	C	#1/0 ACSR	7.39Y	123.1	0.00	1.86	1.28	1	9	2	98	0.00	0.0	2.033	0.089	9	2	1	1
PL.55382	PL.55380	C	#1/0 ACSR	7.39Y	123.1	0.00	1.86	4.83	2	34	9	97	0.00	0.0	1.980	0.036	8	2	1	5
PL.55383	PL.55382	C	#1/0 ACSR	7.39Y	123.1	0.01	1.87	3.65	2	26	7	97	0.00	0.0	2.064	0.084	13	4	2	4
PL.57164	PL.55383	C	#1/0 ACSR	7.39Y	123.1	0.00	1.87	0.91	0	6	2	95	0.00	0.0	2.156	0.092	6	2	1	1
PL.54808	PL.55383	C	#1/0 ACSR	7.39Y	123.1	0.00	1.87	0.89	0	6	2	95	0.00	0.0	2.098	0.034	6	2	1	1
PL.33188	PL.54795	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	0.68	0	5	1	98	0.00	0.0	1.687	0.004	0	0	0	2
PD.4935	PL.33188	C	40QA	7.40Y	123.3	0.00	1.73	0.68	2	5	1	98	0.00	0.0	1.687	0.004	0	0	0	2
PL.33246	PD.4935	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	0.68	0	5	1	98	0.00	0.0	1.804	0.116	5	1	2	2
PL.54798	PL.54797	C	6 A (CWC)	7.41Y	123.5	0.00	1.45	2.01	1	14	4	96	0.00	0.0	1.435	0.004	0	0	0	3
PD.8172	PL.54798	C	40QA	7.41Y	123.5	0.00	1.45	2.01	5	14	4	96	0.00	0.0	1.435	0.004	0	0	0	3
PL.54799	PD.8172	C	6 A (CWC)	7.41Y	123.5	0.01	1.46	2.01	1	14	4	96	0.00	0.0	1.529	0.095	3	1	1	3
PL.54800	PL.54799	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	1.56	1	11	3	96	0.00	0.0	1.581	0.052	0	0	0	2
PL.33245	PL.54800	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	0.57	0	4	1	97	0.00	0.0	1.646	0.064	4	1	1	1
PL.33258	PL.54800	C	6 A (CWC)	7.41Y	123.5	0.00	1.47	0.99	1	7	2	96	0.00	0.0	1.635	0.054	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.54791	PL.54790	A	#2 ACSR	7.43Y	123.8	0.00	1.22	1.13	1	8	2	97	0.00	0.0	1.225	0.003	0	0	0	1
PD.8170	PL.54791	A	40QA	7.43Y	123.8	0.00	1.22	1.13	3	8	2	97	0.00	0.0	1.225	0.003	0	0	0	1
PL.54792	PD.8170	A	#2 ACSR	7.43Y	123.8	0.00	1.22	1.13	1	8	2	97	0.00	0.0	1.285	0.060	8	2	1	1
PL.54788	PL.54787	C	#4 ACSR	7.43Y	123.9	0.00	1.10	0.74	1	5	1	98	0.00	0.0	1.124	0.003	0	0	0	1
PD.8169	PL.54788	C	40QA	7.43Y	123.9	0.00	1.10	0.74	2	5	1	98	0.00	0.0	1.124	0.003	0	0	0	1
PL.54789	PD.8169	C	#4 ACSR	7.43Y	123.9	0.00	1.10	0.74	1	5	1	98	0.00	0.0	1.214	0.091	5	1	1	1
PL.33282	PL.33244	B	6 A (CWC)	7.44Y	124.0	0.00	1.02	6.85	5	49	13	97	0.00	0.0	1.049	0.003	0	0	0	9
PD.4984	PL.33282	B	40QA	7.44Y	124.0	0.00	1.02	6.85	17	49	13	97	0.00	0.0	1.049	0.003	0	0	0	9
PL.64051	PD.4984	B	6 A (CWC)	7.44Y	124.0	0.03	1.05	6.85	5	49	13	97	0.01	0.0	1.160	0.110	8	2	2	9
PL.64054	PL.64051	B	#4 ACSR	7.44Y	123.9	0.02	1.06	3.16	2	23	6	97	0.00	0.0	1.269	0.109	0	0	0	5
PL.57608	PL.64054	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	2.38	1	17	5	96	0.00	0.0	1.331	0.063	5	1	1	4
PL.57609	PL.57608	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	1.410	0.079	0	0	1	3
PL.62772	PL.57609	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	1.413	0.003	0	0	0	2
PD.9436	PL.62772	B	25T	7.44Y	123.9	0.00	1.07	1.74	0	12	3	97	0.00	0.0	1.413	0.003	0	0	0	2
PL.62773	PD.9436	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	1.476	0.063	0	0	0	2
PL.62774	PL.62773	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	1.514	0.038	0	0	0	2
PL.62775	PL.62774	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	1.571	0.057	12	3	1	2
PL.62776	PL.62775	B	#1/0 ACSR	7.44Y	123.9	0.00	1.07	0.01	0	0	0	100	0.00	0.0	1.727	0.156	0	0	1	1
PL.54786	PL.64054	B	#4 ACSR	7.44Y	123.9	0.00	1.06	0.78	1	6	2	95	0.00	0.0	1.336	0.067	6	2	1	1
PL.64052	PL.64051	B	#1/0 ACSR	7.44Y	124.0	0.00	1.05	0.78	0	6	2	95	0.00	0.0	1.282	0.122	6	2	1	1
PL.64053	PL.64051	B	#1/0 ACSR	7.44Y	124.0	0.00	1.05	1.80	1	13	3	97	0.00	0.0	1.217	0.058	13	3	1	1
PL.33418	PL.33362	A	6 A (CWC)	7.46Y	124.4	0.00	0.62	4.34	3	31	8	97	0.00	0.0	0.728	0.001	0	0	0	10
PD.4900	PL.33418	A	40QA	7.46Y	124.4	0.00	0.62	4.34	11	31	8	97	0.00	0.0	0.728	0.001	0	0	0	10
PL.61200	PD.4900	A	6 A (CWC)	7.46Y	124.4	0.02	0.65	4.34	3	31	8	97	0.01	0.0	0.844	0.116	0	0	0	10
PL.61201	PL.61200	A	6 A (CWC)	7.46Y	124.3	0.01	0.65	3.49	2	25	7	96	0.00	0.0	0.902	0.058	6	2	2	9
PL.55056	PL.61201	A	6 A (CWC)	7.46Y	124.3	0.01	0.67	2.64	2	19	5	97	0.00	0.0	1.012	0.111	0	0	0	7
PL.55064	PL.55056	A	6 A (CWC)	7.46Y	124.3	0.01	0.68	2.64	2	19	5	97	0.00	0.0	1.116	0.104	0	0	1	7
PL.55067	PL.55064	A	6 A (CWC)	7.46Y	124.3	0.00	0.68	2.64	2	19	5	97	0.00	0.0	1.151	0.035	8	2	2	6
PL.55068	PL.55067	A	6 A (CWC)	7.46Y	124.3	0.01	0.69	1.59	1	11	3	96	0.00	0.0	1.272	0.121	0	0	0	4
PL.55066	PL.55068	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.84	1	6	2	95	0.00	0.0	1.327	0.055	0	0	1	2
PL.55057	PL.55066	A	6 A (CWC)	7.46Y	124.3	0.00	0.70	0.84	1	6	2	95	0.00	0.0	1.372	0.045	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PL.55065	PL.55068	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.75	1	5	1	98	0.00	0.0	1.362	0.089	5	1	2	2
PL.55063	PL.55064	A	6 A (CWC)	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	1.286	0.170	0	0	0	0
PL.61202	PL.61200	A	#1/0 ACSR	7.46Y	124.4	0.00	0.65	0.85	0	6	2	95	0.00	0.0	0.848	0.003	0	0	0	1
PD.9104	PL.61202	A	15T	7.46Y	124.4	0.00	0.65	0.85	0	6	2	95	0.00	0.0	0.848	0.003	0	0	0	1
PL.61203	PD.9104	A	#1/0 ACSR	7.46Y	124.4	0.00	0.65	0.85	0	6	2	95	0.00	0.0	0.872	0.024	6	2	1	1
PL.55251	PL.55249	B	#1/0 ACSR	7.48Y	124.6	0.00	0.38	0.65	0	5	1	98	0.00	0.0	0.474	0.004	0	0	0	1
PD.8180	PL.55251	B	10QA	7.48Y	124.6	0.00	0.38	0.65	0	5	1	98	0.00	0.0	0.474	0.004	0	0	0	1
PL.55252	PD.8180	B	#1/0 ACSR	7.48Y	124.6	0.00	0.38	0.65	0	5	1	98	0.00	0.0	0.526	0.052	5	1	1	1
PL.33358	PL.33595	B	#4 ACSR	7.49Y	124.8	0.00	0.21	0.08	0	1	0	100	0.00	0.0	0.293	0.001	0	0	0	1
PD.4899	PL.33358	B	40QA	7.49Y	124.8	0.00	0.21	0.08	0	1	0	100	0.00	0.0	0.293	0.001	0	0	0	1
PL.33359	PD.4899	B	#4 ACSR	7.49Y	124.8	0.00	0.21	0.08	0	1	0	100	0.00	0.0	0.367	0.074	1	0	1	1
PL.52862	Bush	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	270.44	52	5792	1863	95	0.01	0.0	0.001	0.001	0	0	0	862
PL.52866	PL.52862	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	270.44	52	5792	1863	95	0.01	0.0	0.002	0.001	0	0	0	862
----- Feeder No. 2 (Blackwater F2) Beginning with Device PD.8054 -----																				
PD.8054	PL.52866	ABC	480VWE	7.50Y	125.0	0.00	0.00	270.44	0	5792	1863	95	0.00	0.0	0.002	0.001	0	0	0	862
PL.33548	PD.8054	ABC	397 SPACER	7.50Y	125.0	0.03	0.03	270.44	52	5792	1863	95	0.27	0.0	0.030	0.028	0	0	0	862
PL.55154	PL.33548	C	#2 ACSR	7.50Y	125.0	0.00	0.03	1.41	1	10	3	96	0.00	0.0	0.048	0.018	10	3	2	2
PL.33549	PL.33548	ABC	397 SPACER	7.49Y	124.8	0.15	0.17	269.97	52	5782	1857	95	1.57	0.0	0.193	0.163	4	1	1	860
PL.33515	PL.33549	ABC	336 MCM AC	7.47Y	124.5	0.32	0.50	268.06	52	5739	1828	95	9.45	0.2	0.349	0.156	0	0	0	856
PL.62402	PL.33515	ABC	336 MCM AC	7.47Y	124.4	0.07	0.57	267.59	52	5719	1803	95	1.95	0.0	0.381	0.032	0	0	0	855
PL.62401	PL.62402	ABC	336 MCM AC	7.44Y	124.0	0.42	0.99	266.02	51	5683	1789	95	12.17	0.2	0.586	0.205	15	4	1	850
PL.55603	PL.62401	A	6 A (CWC)	7.44Y	124.0	0.00	0.99	1.54	1	11	3	96	0.00	0.0	0.590	0.004	0	0	0	1
PD.8214	PL.55603	A	75QA	7.44Y	124.0	0.00	0.99	1.54	2	11	3	96	0.00	0.0	0.590	0.004	0	0	0	1
PL.62697	PD.8214	A	6 A (CWC)	7.44Y	124.0	0.00	0.99	1.54	1	11	3	96	0.00	0.0	0.682	0.092	11	3	1	1
PL.62696	PL.62697	A	1/0 AL URD	7.44Y	124.0	0.00	0.99	0.00	0	0	0	100	0.00	0.0	0.739	0.057	0	0	0	0
PL.55186	PL.62401	ABC	336 MCM AC	7.44Y	124.0	0.06	1.05	264.80	51	5645	1753	96	1.70	0.0	0.615	0.029	0	0	0	848
PL.55578	PL.55186	C	#1/0 ACSR	7.44Y	124.0	0.00	1.05	3.45	1	24	10	92	0.00	0.0	0.618	0.003	0	0	0	2
PD.8208	PL.55578	C	75QA	7.44Y	124.0	0.00	1.05	3.45	5	24	10	92	0.00	0.0	0.618	0.003	0	0	0	2
PL.55579	PD.8208	C	#1/0 ACSR	7.44Y	124.0	0.00	1.05	3.45	1	24	10	92	0.00	0.0	0.642	0.024	24	10	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55581	PL.55186	ABC	336 MCM AC	7.43Y	123.8	0.13	1.17	263.65	51	5619	1740	96	3.66	0.1	0.677	0.063	9	2	3	846
PL.55580	PL.55581	ABC	336 MCM AC	7.42Y	123.7	0.16	1.33	263.25	51	5607	1729	96	4.53	0.1	0.755	0.078	0	0	0	843
PL.55582	PL.55580	A	#4 ACSR	7.42Y	123.7	0.00	1.33	2.80	2	20	5	97	0.00	0.0	0.758	0.003	0	0	0	2
PD.8209	PL.55582	A	75QA	7.42Y	123.7	0.00	1.33	2.80	4	20	5	97	0.00	0.0	0.758	0.003	0	0	0	2
PL.55583	PD.8209	A	#4 ACSR	7.42Y	123.7	0.00	1.33	2.80	2	20	5	97	0.00	0.0	0.817	0.060	20	5	2	2
PL.55584	PL.55580	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.03	1	7	2	96	0.00	0.0	0.758	0.003	0	0	0	2
PD.8210	PL.55584	C	75QA	7.42Y	123.7	0.00	1.33	1.03	1	7	2	96	0.00	0.0	0.758	0.003	0	0	0	2
PL.55585	PD.8210	C	#4 ACSR	7.42Y	123.7	0.00	1.33	1.03	1	7	2	96	0.00	0.0	0.818	0.060	3	1	1	2
PL.55586	PL.55585	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.56	0	4	1	97	0.00	0.0	0.909	0.091	4	1	1	1
PL.63850	PL.55580	ABC	336 MCM AC	7.41Y	123.4	0.22	1.55	261.97	50	5575	1711	96	6.44	0.1	0.866	0.111	0	0	0	839
PL.63854	PL.63850	ABC	336 MCM AC	7.41Y	123.4	0.01	1.56	261.97	50	5569	1696	96	0.19	0.0	0.870	0.003	0	0	0	839
PL.63858	PL.63854	ABC	336 MCM AC	7.40Y	123.4	0.09	1.65	243.69	47	5185	1560	96	2.37	0.0	0.917	0.047	0	0	0	808
PL.63855	PL.63858	ABC	#3/0 ACSR	7.39Y	123.2	0.19	1.84	154.05	51	3269	1008	96	3.86	0.1	1.014	0.097	13	3	2	529
PL.63856	PL.63855	ABC	#3/0 ACSR	7.38Y	123.0	0.14	1.98	153.45	51	3252	999	96	2.73	0.1	1.083	0.069	0	0	0	527
PL.33648	PL.63856	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	3.20	2	23	6	97	0.00	0.0	1.084	0.000	0	0	0	4
PD.5012	PL.33648	B	25T	7.38Y	123.0	0.00	1.98	3.20	0	23	6	97	0.00	0.0	1.084	0.000	0	0	0	4
PL.53418	PD.5012	B	6 A (CWC)	7.38Y	123.0	0.01	1.98	3.20	2	23	6	97	0.00	0.0	1.137	0.053	6	2	1	4
PL.53417	PL.53418	B	6 A (CWC)	7.38Y	123.0	0.00	1.99	2.31	2	16	4	97	0.00	0.0	1.175	0.039	1	0	1	3
PL.53589	PL.53417	B	6 A (CWC)	7.38Y	123.0	0.00	1.99	2.24	2	16	4	97	0.00	0.0	1.228	0.053	16	4	2	2
PL.52710	PL.63856	ABC	#3/0 ACSR	7.37Y	122.8	0.19	2.17	152.15	51	3221	987	96	3.75	0.1	1.180	0.097	17	5	4	521
PL.52709	PL.52710	ABC	#3/0 ACSR	7.36Y	122.7	0.09	2.25	151.35	50	3201	977	96	1.69	0.1	1.224	0.044	0	0	0	517
PL.53419	PL.52709	ABC	#3/0 ACSR	7.36Y	122.7	0.07	2.33	151.35	50	3199	975	96	1.46	0.0	1.262	0.038	17	5	3	517
PL.55553	PL.53419	C	#4 ACSR	7.36Y	122.7	0.00	2.33	7.64	6	54	15	96	0.00	0.0	1.266	0.003	0	0	0	8
PD.8201	PL.55553	C	50QA	7.36Y	122.7	0.00	2.33	7.64	15	54	15	96	0.00	0.0	1.266	0.003	0	0	0	8
PL.55554	PD.8201	C	#4 ACSR	7.36Y	122.7	0.02	2.35	7.64	6	54	15	96	0.01	0.0	1.326	0.060	6	2	4	8
PL.55555	PL.55554	C	#4 ACSR	7.36Y	122.6	0.00	2.35	6.79	5	48	13	97	0.00	0.0	1.342	0.016	18	5	2	4
PL.55552	PL.55555	C	#4 ACSR	7.36Y	122.6	0.00	2.35	4.24	3	30	8	97	0.00	0.0	1.381	0.038	30	8	2	2
PL.55550	PL.53419	ABC	#3/0 ACSR	7.35Y	122.6	0.11	2.44	147.99	49	3126	953	96	2.19	0.1	1.322	0.060	26	7	7	506
PL.55556	PL.55550	ABC	#3/0 ACSR	7.35Y	122.5	0.09	2.53	146.11	49	3084	939	96	1.73	0.1	1.371	0.048	13	4	4	498
PL.55557	PL.55556	ABC	#3/0 ACSR	7.34Y	122.3	0.12	2.65	145.48	48	3068	933	96	2.33	0.1	1.436	0.066	0	0	0	494
PL.53587	PL.55557	C	#1/0 ACSR	7.34Y	122.3	0.00	2.65	0.54	0	4	1	97	0.00	0.0	1.439	0.003	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.7911	PL.53587	C	20QA	7.34Y	122.3	0.00	2.65	0.54	3	4	1	97	0.00	0.0	1.439	0.003	0	0	0	1
PL.53588	PD.7911	C	#1/0 ACSR	7.34Y	122.3	0.00	2.65	0.54	0	4	1	97	0.00	0.0	1.503	0.064	4	1	1	1
PL.55185	PL.55557	ABC	#3/0 ACSR	7.33Y	122.2	0.12	2.77	144.45	48	3044	924	96	2.27	0.1	1.501	0.065	0	0	0	488
PL.55420	PL.55185	A	#4 ACSR	7.33Y	122.2	0.00	2.77	4.17	3	29	8	96	0.00	0.0	1.504	0.003	0	0	0	9
PD.8205	PL.55420	A	50QA	7.33Y	122.2	0.00	2.77	4.17	8	29	8	96	0.00	0.0	1.504	0.003	0	0	0	9
PL.55417	PD.8205	A	#4 ACSR	7.33Y	122.2	0.01	2.78	4.17	3	29	8	96	0.00	0.0	1.552	0.048	5	1	2	9
PL.55418	PL.55417	A	#4 ACSR	7.33Y	122.2	0.00	2.78	1.25	1	9	2	98	0.00	0.0	1.593	0.041	9	2	2	2
PL.55419	PL.55417	A	#4 ACSR	7.33Y	122.2	0.00	2.78	2.18	2	15	4	97	0.00	0.0	1.572	0.020	15	4	5	5
PL.55184	PL.55185	ABC	#3/0 ACSR	7.33Y	122.1	0.12	2.90	143.06	48	3012	912	96	2.28	0.1	1.567	0.066	5	1	1	479
PL.53179	PL.55184	ABC	#3/0 ACSR	7.31Y	121.8	0.31	3.21	142.44	47	2997	905	96	5.84	0.2	1.739	0.171	0	0	0	475
PL.33458	PL.53179	ABC	#3/0 ACSR	7.30Y	121.6	0.16	3.37	142.06	47	2983	895	96	2.98	0.1	1.827	0.088	7	2	1	473
PL.33298	PL.33458	ABC	#3/0 ACSR	7.29Y	121.5	0.11	3.48	141.75	47	2973	889	96	2.05	0.1	1.887	0.061	10	3	3	472
PL.33299	PL.33298	ABC	#3/0 ACSR	7.28Y	121.3	0.20	3.68	141.30	47	2962	883	96	3.73	0.1	1.999	0.111	0	0	0	469
PL.33301	PL.33299	A	#2 ACSR	7.28Y	121.3	0.00	3.68	1.71	1	12	3	97	0.00	0.0	2.053	0.054	0	0	0	2
PL.33302	PL.33301	A	#2 ACSR	7.28Y	121.3	0.00	3.68	0.48	0	3	1	95	0.00	0.0	2.133	0.080	3	1	1	1
PL.33456	PL.33301	A	#2 ACSR	7.28Y	121.3	0.00	3.68	1.22	1	9	2	98	0.00	0.0	2.082	0.029	9	2	1	1
PL.55566	PL.33299	B	#2 ACSR	7.28Y	121.3	0.00	3.68	7.67	4	54	15	96	0.00	0.0	2.002	0.004	0	0	0	8
PD.8204	PL.55566	B	50QA	7.28Y	121.3	0.00	3.68	7.67	15	54	15	96	0.00	0.0	2.002	0.004	0	0	0	8
PL.55564	PD.8204	B	#2 ACSR	7.28Y	121.3	0.01	3.69	7.67	4	54	15	96	0.00	0.0	2.042	0.040	17	5	2	8
PL.62777	PL.55564	B	#1/0 ACSR	7.28Y	121.3	0.00	3.69	0.52	0	4	1	97	0.00	0.0	2.042	0.000	0	0	0	2
PL.62778	PL.62777	B	#1/0 ACSR	7.28Y	121.3	0.00	3.69	0.52	0	4	1	97	0.00	0.0	2.046	0.004	0	0	0	2
PL.62779	PL.62778	B	#1/0 ACSR	7.28Y	121.3	0.00	3.69	0.52	0	4	1	97	0.00	0.0	2.062	0.016	4	1	2	2
PL.55567	PL.55564	B	#2 ACSR	7.28Y	121.3	0.00	3.69	1.46	1	10	3	96	0.00	0.0	2.072	0.030	10	3	1	1
PL.55565	PL.55564	B	#2 ACSR	7.28Y	121.3	0.00	3.69	3.26	2	23	6	97	0.00	0.0	2.064	0.022	7	2	1	3
PL.53768	PL.55565	B	#2 ACSR	7.28Y	121.3	0.00	3.69	2.29	1	16	4	97	0.00	0.0	2.093	0.029	9	2	1	2
PL.53769	PL.53768	B	#2 ACSR	7.28Y	121.3	0.00	3.69	0.99	1	7	2	96	0.00	0.0	2.123	0.030	7	2	1	1
PL.33838	PL.33299	ABC	#3/0 ACSR	7.27Y	121.2	0.08	3.76	138.17	46	2892	860	96	1.51	0.1	2.046	0.047	0	0	0	459
PL.57567	PL.33838	C	#1/0 ACSR	7.27Y	121.2	0.01	3.77	5.94	3	42	11	97	0.00	0.0	2.092	0.046	11	3	1	6
PL.57568	PL.57567	C	#1/0 ACSR	7.27Y	121.2	0.01	3.78	4.40	2	31	8	97	0.00	0.0	2.153	0.061	0	0	0	5
PL.53185	PL.57568	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	1.16	1	8	2	97	0.00	0.0	2.184	0.030	8	2	1	1
PL.53184	PL.57568	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	3.23	1	23	6	97	0.00	0.0	2.221	0.068	1	0	2	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53183	PL.53184	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	1.45	1	10	3	96	0.00	0.0	2.300	0.078	10	3	1	1
PL.53182	PL.53184	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	1.58	1	11	3	96	0.00	0.0	2.274	0.053	11	3	1	1
PL.59077	PL.33838	ABC	#2 ACSR	7.27Y	121.2	0.00	3.77	0.92	1	18	9	89	0.00	0.0	2.075	0.029	0	0	0	1
PD.8670	PL.59077	ABC	40QA	7.27Y	121.2	0.00	3.77	0.92	2	18	9	89	0.00	0.0	2.075	0.029	0	0	0	1
PL.59078	PD.8670	ABC	#2 ACSR	7.27Y	121.2	0.00	3.77	0.92	1	18	9	89	0.00	0.0	2.079	0.004	18	9	1	1
PL.55187	PL.33838	ABC	#3/0 ACSR	7.27Y	121.1	0.10	3.86	135.28	45	2831	838	96	1.69	0.1	2.101	0.055	0	0	0	452
PL.55189	PL.55187	ABC	#3/0 ACSR	7.25Y	120.8	0.32	4.18	132.49	44	2770	819	96	5.48	0.2	2.287	0.186	12	3	2	441
PL.55190	PL.55189	ABC	#3/0 ACSR	7.25Y	120.8	0.06	4.23	131.94	44	2753	808	96	1.02	0.0	2.322	0.035	0	0	0	439
PL.59081	PL.55190	ABC	#3/0 ACSR	7.24Y	120.7	0.06	4.30	131.32	44	2739	803	96	1.08	0.0	2.360	0.037	15	4	3	438
PL.59082	PL.59081	C	#4 ACSR	7.24Y	120.7	0.00	4.30	9.23	7	65	17	97	0.00	0.0	2.363	0.003	0	0	0	15
PD.8212	PL.59082	C	50QA	7.24Y	120.7	0.00	4.30	9.23	18	65	17	97	0.00	0.0	2.363	0.003	0	0	0	15
PL.55601	PD.8212	C	#4 ACSR	7.24Y	120.7	0.04	4.33	9.23	7	65	17	97	0.02	0.0	2.459	0.097	10	3	2	15
PL.55602	PL.55601	C	#4 ACSR	7.24Y	120.6	0.02	4.35	7.81	6	55	15	96	0.01	0.0	2.513	0.053	13	3	1	13
PL.33572	PL.55602	C	#4 ACSR	7.24Y	120.6	0.01	4.36	6.01	5	42	11	97	0.00	0.0	2.555	0.043	2	1	2	12
PL.64875	PL.33572	C	#4 ACSR	7.24Y	120.6	0.01	4.37	5.68	4	40	11	96	0.00	0.0	2.616	0.060	15	4	1	10
PL.64876	PL.64875	C	#4 ACSR	7.24Y	120.6	0.00	4.37	3.58	3	25	7	96	0.00	0.0	2.616	0.000	9	2	5	9
PL.55600	PL.64876	C	#4 ACSR	7.24Y	120.6	0.00	4.38	1.24	1	9	2	98	0.00	0.0	2.691	0.076	9	2	2	2
PL.33574	PL.64876	C	#4 ACSR	7.24Y	120.6	0.00	4.38	1.08	1	8	2	97	0.00	0.0	2.677	0.061	8	2	2	2
PL.59083	PL.59081	ABC	#3/0 ACSR	7.24Y	120.6	0.09	4.39	127.55	43	2659	780	96	1.52	0.1	2.415	0.056	0	0	0	420
PL.55595	PL.59083	ABC	#3/0 ACSR	7.23Y	120.5	0.08	4.47	126.65	42	2639	773	96	1.36	0.1	2.466	0.051	2	1	2	418
PL.55596	PL.55595	ABC	#3/0 ACSR	7.22Y	120.4	0.15	4.62	126.56	42	2635	771	96	2.54	0.1	2.561	0.094	5	1	1	416
PL.33346	PL.55596	ABC	#3/0 ACSR	7.22Y	120.3	0.07	4.69	126.33	42	2628	766	96	1.17	0.0	2.604	0.044	0	0	0	415
PD.4949-A	PL.33346	ABC	Closed	7.22Y	120.3	0.00	4.69	126.33	0	2627	764	96	0.00	0.0	2.604	0.044	0	0	0	415
PD.4949-B	PD.4949-A	ABC	Closed	7.22Y	120.3	0.00	4.69	126.33	0	2627	764	96	0.00	0.0	2.604	0.044	0	0	0	415
PL.33347	PD.4949-B	ABC	#3/0 ACSR	7.22Y	120.3	0.02	4.71	126.33	42	2627	764	96	0.36	0.0	2.618	0.013	0	0	0	415
PL.33489	PL.33347	B	6 A (CWC)	7.22Y	120.3	0.00	4.71	2.94	2	21	6	96	0.00	0.0	2.618	0.000	0	0	0	2
PD.4896	PL.33489	B	50QA	7.22Y	120.3	0.00	4.71	2.94	6	21	6	96	0.00	0.0	2.618	0.000	0	0	0	2
PL.33351	PD.4896	B	6 A (CWC)	7.22Y	120.3	0.00	4.72	2.94	2	21	6	96	0.00	0.0	2.661	0.043	9	3	1	2
PL.33352	PL.33351	B	6 A (CWC)	7.22Y	120.3	0.00	4.72	1.60	1	11	3	96	0.00	0.0	2.678	0.017	11	3	1	1
PL.33194	PL.33347	C	#2 ACSR	7.22Y	120.3	0.00	4.71	0.81	0	6	2	95	0.00	0.0	2.692	0.074	6	2	1	1
PL.33348	PL.33347	ABC	#3/0 ACSR	7.21Y	120.1	0.14	4.86	125.08	42	2600	756	96	2.36	0.1	2.708	0.090	18	5	2	412

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33353	PL.33348	ABC	#3/0 ACSR	7.20Y	120.0	0.09	4.95	124.20	41	2580	748	96	1.54	0.1	2.767	0.060	7	2	1	410
PL.34177	PL.33353	ABC	#3/0 ACSR	7.19Y	119.8	0.23	5.18	123.12	41	2556	740	96	3.77	0.1	2.915	0.148	0	0	0	406
PL.34178	PL.34177	ABC	#3/0 ACSR	7.18Y	119.7	0.10	5.28	123.12	41	2552	734	96	1.56	0.1	2.977	0.061	0	0	0	406
PL.34181	PL.34178	ABC	#3/0 ACSR	7.18Y	119.6	0.10	5.38	122.10	41	2529	726	96	1.62	0.1	3.042	0.065	9	3	3	401
PL.34185	PL.34181	ABC	#3/0 ACSR	7.17Y	119.5	0.13	5.51	121.65	41	2518	721	96	2.10	0.1	3.126	0.085	5	1	1	397
PL.34184	PL.34185	ABC	#3/0 ACSR	7.16Y	119.4	0.09	5.60	121.40	40	2511	717	96	1.51	0.1	3.188	0.061	8	2	2	396
PL.33616	PL.34184	ABC	#3/0 ACSR	7.16Y	119.3	0.10	5.70	120.99	40	2501	712	96	1.61	0.1	3.253	0.065	0	0	0	394
PL.53947	PL.33616	ABC	#3/0 ACSR	7.15Y	119.2	0.07	5.78	120.99	40	2499	710	96	1.14	0.0	3.299	0.046	3	1	2	394
PL.53949	PL.53947	ABC	#1/0 ACSR	7.15Y	119.2	0.01	5.78	24.07	10	498	136	96	0.03	0.0	3.318	0.019	0	0	0	77
PD.8101	PL.53949	ABC	50L	7.15Y	119.2	0.00	5.78	24.07	48	498	136	96	0.00	0.0	3.318	0.019	0	0	0	77
PL.53452	PD.8101	ABC	#1/0 ACSR	7.15Y	119.2	0.05	5.83	24.07	10	498	136	96	0.17	0.0	3.430	0.111	0	0	0	77
PL.53453	PL.53452	A	6 A (CWC)	7.15Y	119.2	0.00	5.83	1.19	1	8	2	97	0.00	0.0	3.434	0.004	0	0	0	2
PD.8102	PL.53453	A	20T	7.15Y	119.2	0.00	5.83	1.19	0	8	2	97	0.00	0.0	3.434	0.004	0	0	0	2
PL.53451	PD.8102	A	6 A (CWC)	7.15Y	119.2	0.00	5.83	1.19	1	8	2	97	0.00	0.0	3.482	0.048	4	1	1	2
PL.53450	PL.53451	A	#4 ACSR	7.15Y	119.2	0.00	5.84	0.66	1	5	1	98	0.00	0.0	3.567	0.085	5	1	1	1
PL.53454	PL.53452	ABC	#1/0 ACSR	7.15Y	119.2	0.01	5.84	23.67	10	490	133	97	0.04	0.0	3.458	0.028	0	0	0	75
PL.53455	PL.53454	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	0.37	0	3	1	95	0.00	0.0	3.461	0.003	0	0	0	1
PD.8103	PL.53455	A	10QA	7.15Y	119.2	0.00	5.84	0.37	0	3	1	95	0.00	0.0	3.461	0.003	0	0	0	1
PL.53456	PD.8103	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	0.37	0	3	1	95	0.00	0.0	3.541	0.080	3	1	1	1
PL.53457	PL.53454	ABC	#1/0 ACSR	7.14Y	119.1	0.09	5.93	23.55	10	487	132	97	0.31	0.1	3.671	0.212	1	0	1	74
PL.53458	PL.53457	ABC	#1/0 ACSR	7.14Y	119.0	0.02	5.96	23.48	10	486	132	97	0.08	0.0	3.723	0.052	0	0	0	73
PL.53463	PL.53458	ABC	#1/0 ACSR	7.14Y	119.0	0.02	5.98	23.48	10	486	132	97	0.08	0.0	3.778	0.056	0	0	0	73
PL.53464	PL.53463	A	6 A (CWC)	7.14Y	119.0	0.00	5.98	1.43	1	10	3	96	0.00	0.0	3.782	0.004	0	0	0	1
PD.8104	PL.53464	A	10QA	7.14Y	119.0	0.00	5.98	1.43	0	10	3	96	0.00	0.0	3.782	0.004	0	0	0	1
PL.53460	PD.8104	A	6 A (CWC)	7.14Y	119.0	0.00	5.98	1.43	1	10	3	96	0.00	0.0	3.812	0.029	0	0	0	1
PL.53459	PL.53460	A	#2 ACSR	7.14Y	119.0	0.00	5.98	1.43	1	10	3	96	0.00	0.0	3.832	0.020	10	3	1	1
PL.53461	PL.53460	A	6 A (CWC)	7.14Y	119.0	0.00	5.98	0.00	0	0	0	100	0.00	0.0	3.893	0.081	0	0	0	0
PL.53465	PL.53463	C	6 A (CWC)	7.14Y	119.0	0.00	5.98	1.94	1	13	4	96	0.00	0.0	3.782	0.004	0	0	0	2
PD.8105	PL.53465	C	10QA	7.14Y	119.0	0.00	5.98	1.94	0	13	4	96	0.00	0.0	3.782	0.004	0	0	0	2
PL.53467	PD.8105	C	6 A (CWC)	7.14Y	119.0	0.01	5.99	1.94	1	13	4	96	0.00	0.0	3.852	0.070	3	1	1	2
PL.53466	PL.53467	C	6 A (CWC)	7.14Y	119.0	0.00	5.99	0.00	0	0	0	100	0.00	0.0	3.981	0.129	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53462	PL.53466	C	#4 ACSR	7.14Y	119.0	0.00	5.99	0.00	0	0	0	100	0.00	0.0	4.046	0.065	0	0	0	0
PL.33216	PL.53466	C	6 A (CWC)	7.14Y	119.0	0.00	5.99	0.00	0	0	0	100	0.00	0.0	4.221	0.240	0	0	0	0
PL.53468	PL.53467	C	#1/0 ACSR	7.14Y	119.0	0.00	5.99	1.54	1	11	3	96	0.00	0.0	3.904	0.052	11	3	1	1
PL.53469	PL.53463	ABC	#1/0 ACSR	7.14Y	119.0	0.02	5.99	22.36	10	462	125	97	0.05	0.0	3.816	0.038	0	0	0	70
PL.53470	PL.53469	ABC	#1/0 ACSR	7.14Y	119.0	0.04	6.03	21.95	10	454	123	97	0.12	0.0	3.912	0.095	2	0	1	69
PL.53473	PL.53470	ABC	#1/0 ACSR	7.14Y	118.9	0.02	6.05	21.86	10	452	122	97	0.06	0.0	3.963	0.051	14	4	2	68
PL.53476	PL.53473	ABC	#1/0 ACSR	7.13Y	118.9	0.06	6.11	20.48	9	423	115	96	0.19	0.0	4.130	0.167	0	0	0	63
PL.53482	PL.53476	ABC	#1/0 ACSR	7.13Y	118.9	0.02	6.13	20.28	9	419	113	97	0.05	0.0	4.175	0.045	15	4	3	62
PL.53483	PL.53482	C	6 A (CWC)	7.13Y	118.9	0.00	6.13	3.09	2	21	6	96	0.00	0.0	4.179	0.003	0	0	0	2
PD.8109	PL.53483	C	10QA	7.13Y	118.9	0.00	6.13	3.09	0	21	6	96	0.00	0.0	4.179	0.003	0	0	0	2
PL.53480	PD.8109	C	6 A (CWC)	7.13Y	118.9	0.00	6.13	3.09	2	21	6	96	0.00	0.0	4.206	0.028	6	2	1	2
PL.53479	PL.53480	C	6 A (CWC)	7.13Y	118.9	0.00	6.13	2.19	2	15	4	97	0.00	0.0	4.227	0.021	15	4	1	1
PL.53484	PL.53482	A	6 A (CWC)	7.13Y	118.9	0.00	6.13	9.37	7	65	17	97	0.00	0.0	4.180	0.004	0	0	0	7
PD.8110	PL.53484	A	30QA	7.13Y	118.9	0.00	6.13	9.37	31	65	17	97	0.00	0.0	4.180	0.004	0	0	0	7
PL.53485	PD.8110	A	6 A (CWC)	7.13Y	118.9	0.01	6.14	9.37	7	65	17	97	0.00	0.0	4.212	0.032	27	7	3	7
PL.53511	PL.53485	A	#4 ACSR	7.13Y	118.9	0.01	6.15	2.87	2	20	5	97	0.00	0.0	4.261	0.049	3	1	1	3
PL.53512	PL.53511	A	#4 ACSR	7.13Y	118.8	0.00	6.15	2.45	2	17	5	96	0.00	0.0	4.304	0.043	8	2	1	2
PL.53513	PL.53512	A	#4 ACSR	7.13Y	118.8	0.00	6.15	1.24	1	9	2	98	0.00	0.0	4.356	0.052	9	2	1	1
PL.53481	PL.53485	A	6 A (CWC)	7.13Y	118.9	0.00	6.15	2.58	2	18	5	96	0.00	0.0	4.264	0.053	18	5	1	1
PL.53493	PL.53482	ABC	#1/0 ACSR	7.13Y	118.8	0.02	6.15	15.40	7	318	86	97	0.05	0.0	4.255	0.079	5	1	2	50
PL.53495	PL.53493	A	6 A (CWC)	7.13Y	118.8	0.01	6.16	23.22	17	160	43	97	0.01	0.0	4.260	0.005	0	0	0	25
PD.7907	PL.53495	A	40QA	7.13Y	118.8	0.00	6.16	23.22	58	160	43	97	0.00	0.0	4.260	0.005	0	0	0	25
PL.53496	PD.7907	A	6 A (CWC)	7.13Y	118.8	0.04	6.20	23.22	17	160	43	97	0.05	0.0	4.300	0.040	0	0	0	25
PL.53501	PL.53496	A	6 A (CWC)	7.12Y	118.7	0.11	6.31	21.93	16	151	41	97	0.12	0.1	4.407	0.106	2	1	1	24
PL.53499	PL.53501	A	#4 ACSR	7.12Y	118.7	0.00	6.31	1.30	1	9	2	98	0.00	0.0	4.407	0.000	0	0	0	1
PD.4976	PL.53499	A	40QA	7.12Y	118.7	0.00	6.31	1.30	3	9	2	98	0.00	0.0	4.407	0.000	0	0	0	1
PL.53510	PD.4976	A	#4 ACSR	7.12Y	118.7	0.00	6.31	1.30	1	9	2	98	0.00	0.0	4.478	0.071	9	2	1	1
PL.55811	PL.53501	A	6 A (CWC)	7.12Y	118.6	0.10	6.41	17.06	12	117	32	96	0.09	0.1	4.550	0.143	16	4	2	18
PL.55809	PL.55811	A	6 A (CWC)	7.12Y	118.6	0.00	6.41	1.80	1	12	3	97	0.00	0.0	4.646	0.096	12	3	1	1
PL.55810	PL.55811	A	#2 ACSR	7.12Y	118.6	0.00	6.41	1.74	1	12	3	97	0.00	0.0	4.590	0.040	12	3	1	1
PL.55812	PL.55811	A	6 A (CWC)	7.12Y	118.6	0.00	6.41	3.14	2	22	6	96	0.00	0.0	4.595	0.045	17	5	2	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PL.55661	PL.55812	A	6 A (CWC)	7.11Y	118.6	0.01	6.42	0.72	1	5	1	98	0.00	0.0	4.765	0.170	0	0	0	2
PL.55604	PL.55661	A	6 A (CWC)	7.11Y	118.6	0.00	6.42	0.41	0	3	1	95	0.00	0.0	4.770	0.005	0	0	0	1
PD.8217	PL.55604	A	20T	7.11Y	118.6	0.00	6.42	0.41	0	3	1	95	0.00	0.0	4.770	0.005	0	0	0	1
PL.55605	PD.8217	A	6 A (CWC)	7.11Y	118.6	0.00	6.42	0.41	0	3	1	95	0.00	0.0	4.997	0.228	0	0	0	1
PL.55398	PL.55605	A	6 A (CWC)	7.11Y	118.6	0.01	6.43	0.41	0	3	1	95	0.00	0.0	5.423	0.426	0	0	0	1
PL.33136	PL.55398	A	#4 ACSR	7.11Y	118.6	0.00	6.43	0.41	0	3	1	95	0.00	0.0	5.616	0.193	3	1	1	1
PL.33588	PL.55398	A	6 A (CWC)	7.11Y	118.6	0.00	6.43	0.00	0	0	0	100	0.00	0.0	5.772	0.349	0	0	0	0
PL.33617	PL.33588	A	6 A (CWC)	7.11Y	118.6	0.00	6.43	0.00	0	0	0	100	0.00	0.0	6.558	0.785	0	0	0	0
PL.55197	PL.55605	A	#1/0 ACSR	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	5.321	0.323	0	0	0	0
PL.55393	PL.55197	A	#1/0 ACSR	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	5.421	0.100	0	0	0	0
PL.55394	PL.55393	A	#1/0 ACSR	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	6.095	0.674	0	0	0	0
PL.55396	PL.55661	A	6 A (CWC)	7.11Y	118.6	0.00	6.42	0.31	0	2	1	89	0.00	0.0	4.836	0.071	2	1	1	1
PL.55397	PL.55396	A	6 A (CWC)	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	4.840	0.005	0	0	0	0
PD.8216	PL.55397	A	10QA	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	4.840	0.005	0	0	0	0
PL.55395	PD.8216	A	6 A (CWC)	7.11Y	118.6	0.00	6.42	0.00	0	0	0	100	0.00	0.0	4.925	0.084	0	0	0	0
PL.61235	PL.55811	A	6 A (CWC)	7.12Y	118.6	0.00	6.41	8.09	6	56	15	97	0.00	0.0	4.556	0.006	0	0	0	10
PD.9110	PL.61235	A	10QA	7.12Y	118.6	0.00	6.41	8.09	0	56	15	97	0.00	0.0	4.556	0.006	0	0	0	10
PL.61238	PD.9110	A	6 A (CWC)	7.11Y	118.6	0.02	6.44	8.09	6	56	15	97	0.01	0.0	4.628	0.072	12	3	1	10
PL.61239	PL.61238	A	6 A (CWC)	7.11Y	118.6	0.01	6.45	6.27	4	43	12	96	0.00	0.0	4.675	0.047	0	0	0	9
PL.61237	PL.61239	A	6 A (CWC)	7.11Y	118.5	0.01	6.46	3.77	3	26	7	97	0.00	0.0	4.756	0.081	4	1	2	6
PL.33508	PL.61237	A	6 A (CWC)	7.11Y	118.5	0.01	6.47	3.21	2	22	6	96	0.00	0.0	4.807	0.051	11	3	1	4
PL.33509	PL.33508	A	6 A (CWC)	7.11Y	118.5	0.01	6.48	1.56	1	11	3	96	0.00	0.0	4.957	0.150	2	1	1	3
PL.33123	PL.33509	A	#1/0 ACSR	7.11Y	118.5	0.00	6.48	0.93	0	6	2	95	0.00	0.0	5.045	0.087	6	2	1	1
PL.55198	PL.33509	A	6 A (CWC)	7.11Y	118.5	0.00	6.48	0.28	0	2	1	89	0.00	0.0	5.112	0.155	2	1	1	1
PL.61236	PL.61239	A	#4 ACSR	7.11Y	118.5	0.00	6.45	2.50	2	17	5	96	0.00	0.0	4.736	0.061	12	3	2	3
PL.53502	PL.61236	A	#4 ACSR	7.11Y	118.5	0.00	6.46	0.77	1	5	1	98	0.00	0.0	4.819	0.083	5	1	1	1
PL.53500	PL.53501	A	#2 ACSR	7.12Y	118.7	0.01	6.32	3.25	2	22	6	96	0.00	0.0	4.539	0.132	0	0	0	4
PL.53498	PL.53500	A	#2 ACSR	7.12Y	118.7	0.00	6.32	0.84	0	6	2	95	0.00	0.0	4.571	0.032	6	2	1	1
PL.53497	PL.53500	A	#2 ACSR	7.12Y	118.7	0.01	6.33	2.41	1	17	4	97	0.00	0.0	4.624	0.085	0	0	0	3
PL.33107	PL.53497	A	#2 ACSR	7.12Y	118.7	0.00	6.33	2.41	1	17	4	97	0.00	0.0	4.666	0.043	2	1	1	3
PL.64847	PL.33107	A	#2 ACSR	7.12Y	118.7	0.00	6.33	0.92	1	6	2	95	0.00	0.0	4.730	0.063	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.61224	PL.33107	A	#1/0 ACSR	7.12Y	118.7	0.00	6.33	1.17	1	8	2	97	0.00	0.0	4.670	0.003	0	0	0	1
PD.9107	PL.61224	A	10T	7.12Y	118.7	0.00	6.33	1.17	0	8	2	97	0.00	0.0	4.670	0.003	0	0	0	1
PL.61225	PD.9107	A	#1/0 ACSR	7.12Y	118.7	0.00	6.33	1.17	1	8	2	97	0.00	0.0	4.762	0.092	8	2	1	1
PL.33448	PL.53497	A	#2 ACSR	7.12Y	118.7	0.00	6.33	0.00	0	0	0	100	0.00	0.0	4.684	0.061	0	0	0	0
PL.53492	PL.53496	A	#4 ACSR	7.13Y	118.8	0.00	6.20	1.29	1	9	2	98	0.00	0.0	4.399	0.098	9	2	1	1
PL.53494	PL.53493	C	#4 ACSR	7.13Y	118.8	0.00	6.16	22.29	17	153	41	97	0.00	0.0	4.258	0.003	0	0	0	23
PD.8111	PL.53494	C	40QA	7.13Y	118.8	0.00	6.16	22.29	56	153	41	97	0.00	0.0	4.258	0.003	0	0	0	23
PL.53491	PD.8111	C	#4 ACSR	7.13Y	118.8	0.03	6.18	22.29	17	153	41	97	0.03	0.0	4.288	0.030	12	3	3	23
PL.53490	PL.53491	C	#4 ACSR	7.13Y	118.8	0.05	6.23	20.62	16	142	38	97	0.05	0.0	4.338	0.050	4	1	1	20
PL.53488	PL.53490	C	#4 ACSR	7.12Y	118.7	0.03	6.26	17.81	14	123	33	97	0.03	0.0	4.385	0.046	23	6	2	18
PL.53486	PL.53488	C	#4 ACSR	7.12Y	118.7	0.03	6.30	14.43	11	99	27	96	0.02	0.0	4.441	0.057	18	5	3	16
PL.53487	PL.53486	C	#4 ACSR	7.12Y	118.7	0.00	6.30	2.67	2	18	5	96	0.00	0.0	4.493	0.052	18	5	2	2
PL.53508	PL.53486	C	#1/0 ACSR	7.12Y	118.7	0.00	6.30	9.19	4	63	17	97	0.00	0.0	4.461	0.020	13	4	1	11
PL.53509	PL.53508	C	#1/0 ACSR	7.12Y	118.7	0.01	6.31	7.27	3	50	14	96	0.00	0.0	4.551	0.090	9	3	1	10
PL.53505	PL.53509	C	#1/0 ACSR	7.12Y	118.7	0.01	6.32	5.91	3	41	11	97	0.00	0.0	4.593	0.042	5	1	1	9
PL.53506	PL.53505	C	6 A (CWC)	7.12Y	118.7	0.01	6.33	1.38	1	9	3	95	0.00	0.0	4.728	0.135	0	0	0	2
PL.53503	PL.53506	C	6 A (CWC)	7.12Y	118.7	0.01	6.33	1.38	1	9	3	95	0.00	0.0	4.840	0.111	0	0	0	2
PL.53504	PL.53503	C	6 A (CWC)	7.12Y	118.7	0.00	6.34	1.38	1	9	3	95	0.00	0.0	4.987	0.147	9	3	2	2
PL.53507	PL.53505	C	6 A (CWC)	7.12Y	118.7	0.02	6.34	3.79	3	26	7	97	0.00	0.0	4.735	0.141	0	0	1	6
PL.33165	PL.53507	C	#4 ACSR	7.12Y	118.7	0.00	6.34	0.62	0	4	1	97	0.00	0.0	4.805	0.070	4	1	1	1
PL.53540	PL.53507	C	6 A (CWC)	7.12Y	118.7	0.00	6.35	3.11	2	21	6	96	0.00	0.0	4.765	0.030	0	0	0	4
PL.53541	PL.53540	C	6 A (CWC)	7.12Y	118.7	0.00	6.35	0.67	0	5	1	98	0.00	0.0	4.837	0.072	5	1	1	1
PL.53539	PL.53540	C	#2 ACSR	7.12Y	118.7	0.00	6.35	2.44	1	17	5	96	0.00	0.0	4.792	0.027	17	5	3	3
PL.53489	PL.53490	C	#4 ACSR	7.13Y	118.8	0.00	6.23	2.18	2	15	4	97	0.00	0.0	4.401	0.063	15	4	1	1
PL.53477	PL.53476	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.58	0	4	1	97	0.00	0.0	4.133	0.003	0	0	0	1
PD.8108	PL.53477	C	10QA	7.13Y	118.9	0.00	6.11	0.58	0	4	1	97	0.00	0.0	4.133	0.003	0	0	0	1
PL.53478	PD.8108	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.58	0	4	1	97	0.00	0.0	4.172	0.040	4	1	1	1
PL.53475	PL.53478	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.00	0	0	0	100	0.00	0.0	4.251	0.079	0	0	0	0
PL.53474	PL.53473	C	#4 ACSR	7.14Y	118.9	0.00	6.05	2.10	2	14	4	96	0.00	0.0	3.966	0.003	0	0	0	3
PD.8107	PL.53474	C	10QA	7.14Y	118.9	0.00	6.05	2.10	0	14	4	96	0.00	0.0	3.966	0.003	0	0	0	3
PL.53514	PD.8107	C	#4 ACSR	7.14Y	118.9	0.00	6.06	2.10	2	14	4	96	0.00	0.0	4.048	0.082	14	4	3	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53471	PL.53469	A	#1/0 ACSR	7.14Y	119.0	0.00	5.99	1.22	1	8	2	97	0.00	0.0	3.819	0.003	0	0	0	1
PD.8106	PL.53471	A	10QA	7.14Y	119.0	0.00	5.99	1.22	0	8	2	97	0.00	0.0	3.819	0.003	0	0	0	1
PL.53472	PD.8106	A	#1/0 ACSR	7.14Y	119.0	0.00	6.00	1.22	1	8	2	97	0.00	0.0	3.847	0.028	8	2	1	1
PL.53948	PL.53947	ABC	#3/0 ACSR	7.15Y	119.2	0.04	5.82	96.79	32	1997	572	96	0.54	0.0	3.334	0.034	5	1	2	315
PL.53447	PL.53948	ABC	#3/0 ACSR	7.15Y	119.1	0.07	5.89	96.54	32	1991	570	96	0.96	0.0	3.395	0.061	5	1	2	313
PL.53449	PL.53447	C	6 A (CWC)	7.15Y	119.1	0.00	5.89	0.64	0	4	1	97	0.00	0.0	3.399	0.004	0	0	0	2
PD.8100	PL.53449	C	20QA	7.15Y	119.1	0.00	5.89	0.64	3	4	1	97	0.00	0.0	3.399	0.004	0	0	0	2
PL.53922	PD.8100	C	6 A (CWC)	7.15Y	119.1	0.00	5.89	0.64	0	4	1	97	0.00	0.0	3.420	0.021	3	1	1	2
PL.53921	PL.53922	C	6 A (CWC)	7.15Y	119.1	0.00	5.89	0.27	0	2	0	100	0.00	0.0	3.452	0.032	2	0	1	1
PL.53826	PL.53921	C	6 A (CWC)	7.15Y	119.1	0.00	5.89	0.00	0	0	0	100	0.00	0.0	3.547	0.095	0	0	0	0
PL.53448	PL.53447	ABC	#3/0 ACSR	7.14Y	119.1	0.03	5.93	96.08	32	1981	566	96	0.42	0.0	3.422	0.027	25	7	1	309
PL.33469	PL.53448	ABC	#3/0 ACSR	7.14Y	119.0	0.07	5.99	94.89	32	1956	559	96	0.85	0.0	3.478	0.056	8	2	1	308
PL.33316	PL.33469	ABC	#3/0 ACSR	7.14Y	119.0	0.06	6.05	94.25	31	1942	554	96	0.70	0.0	3.525	0.047	1	0	1	305
PL.33317	PL.33316	ABC	#3/0 ACSR	7.13Y	118.9	0.05	6.10	94.20	31	1940	552	96	0.60	0.0	3.565	0.040	3	1	2	304
PL.34207	PL.33317	ABC	#3/0 ACSR	7.13Y	118.8	0.07	6.17	94.04	31	1936	551	96	0.88	0.0	3.624	0.059	0	0	0	302
PL.57882	PL.34207	C	#4 ACSR	7.13Y	118.8	0.00	6.17	0.00	0	0	0	100	0.00	0.0	3.678	0.054	0	0	0	0
PL.34208	PL.34207	A	6 A (CWC)	7.13Y	118.8	0.00	6.17	0.67	0	5	1	98	0.00	0.0	3.625	0.001	0	0	0	1
PD.4908	PL.34208	A	50QA	7.13Y	118.8	0.00	6.17	0.67	1	5	1	98	0.00	0.0	3.625	0.001	0	0	0	1
PL.64849	PD.4908	A	6 A (CWC)	7.13Y	118.8	0.00	6.17	0.67	0	5	1	98	0.00	0.0	3.698	0.073	0	0	0	1
PL.53915	PL.64849	A	6 A (CWC)	7.13Y	118.8	0.00	6.17	0.67	0	5	1	98	0.00	0.0	3.787	0.089	5	1	1	1
PL.33462	PL.34207	ABC	#3/0 ACSR	7.12Y	118.7	0.10	6.27	92.08	31	1894	538	96	1.26	0.1	3.713	0.089	5	1	1	294
PL.33420	PL.33462	A	6 A (CWC)	7.12Y	118.7	0.00	6.27	3.59	3	25	7	96	0.00	0.0	3.714	0.001	0	0	0	6
PD.4909	PL.33420	A	50QA	7.12Y	118.7	0.00	6.27	3.59	7	25	7	96	0.00	0.0	3.714	0.001	0	0	0	6
PL.64848	PD.4909	A	6 A (CWC)	7.12Y	118.7	0.03	6.30	3.59	3	25	7	96	0.00	0.0	3.886	0.172	4	1	1	6
PL.53987	PL.64848	A	6 A (CWC)	7.12Y	118.7	0.01	6.30	2.96	2	20	6	96	0.00	0.0	3.936	0.050	0	0	1	5
PL.53986	PL.53987	A	6 A (CWC)	7.12Y	118.7	0.00	6.31	2.96	2	20	5	97	0.00	0.0	4.004	0.068	20	5	4	4
PL.33256	PL.64848	A	#2 ACSR	7.12Y	118.7	0.00	6.30	0.00	0	0	0	100	0.00	0.0	3.923	0.038	0	0	0	0
PL.53950	PL.33462	ABC	#3/0 ACSR	7.12Y	118.7	0.08	6.35	89.92	30	1849	525	96	0.93	0.1	3.781	0.068	0	0	0	284
PL.53664	PL.53950	ABC	#3/0 ACSR	7.11Y	118.6	0.09	6.44	89.46	30	1838	521	96	1.09	0.1	3.862	0.081	0	0	0	280
PL.34209	PL.53664	ABC	#3/0 ACSR	7.11Y	118.5	0.02	6.46	85.24	28	1750	496	96	0.27	0.0	3.884	0.022	0	0	0	264
PL.34212	PL.34209	A	#4 ACSR	7.11Y	118.5	0.00	6.46	1.74	1	12	3	97	0.00	0.0	3.885	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.4911	PL.34212	A	50QA	7.11Y	118.5	0.00	6.46	1.74	3	12	3	97	0.00	0.0	3.885	0.001	0	0	0	1
PL.34213	PD.4911	A	#4 ACSR	7.11Y	118.5	0.00	6.47	1.74	1	12	3	97	0.00	0.0	3.924	0.039	12	3	1	1
PL.53829	PL.34209	ABC	#3/0 ACSR	7.10Y	118.4	0.13	6.59	84.46	28	1734	491	96	1.46	0.1	4.007	0.122	9	2	1	262
PL.53827	PL.53829	A	#4 ACSR	7.10Y	118.4	0.00	6.60	18.95	15	130	35	97	0.00	0.0	4.007	0.000	0	0	0	16
PD.4926	PL.53827	A	50QA	7.10Y	118.4	0.00	6.60	18.95	38	130	35	97	0.00	0.0	4.007	0.000	0	0	0	16
PL.33510	PD.4926	A	#4 ACSR	7.10Y	118.4	0.04	6.63	18.95	15	130	35	97	0.04	0.0	4.058	0.051	23	6	3	16
PL.33511	PL.33510	A	#4 ACSR	7.10Y	118.3	0.02	6.65	15.63	12	107	29	97	0.01	0.0	4.083	0.024	0	0	0	13
PL.53989	PL.33511	A	#4 ACSR	7.10Y	118.3	0.04	6.69	13.83	11	95	26	96	0.03	0.0	4.148	0.065	16	4	1	9
PL.53990	PL.53989	A	#4 ACSR	7.10Y	118.3	0.01	6.70	11.51	9	79	21	97	0.00	0.0	4.163	0.016	12	3	1	8
PL.53991	PL.53990	A	#4 ACSR	7.10Y	118.3	0.01	6.71	9.72	7	67	18	97	0.01	0.0	4.197	0.034	19	5	1	7
PL.53988	PL.53991	A	#4 ACSR	7.10Y	118.3	0.00	6.71	1.26	1	9	2	98	0.00	0.0	4.235	0.037	9	2	2	2
PL.53992	PL.53991	A	#4 ACSR	7.10Y	118.3	0.02	6.72	5.66	4	39	10	97	0.00	0.0	4.263	0.065	6	2	1	4
PL.57880	PL.53992	A	#4 ACSR	7.10Y	118.3	0.00	6.73	4.80	4	33	9	96	0.00	0.0	4.289	0.027	33	9	3	3
PL.33125	PL.33511	A	#4 ACSR	7.10Y	118.3	0.00	6.65	1.81	1	12	3	97	0.00	0.0	4.119	0.036	12	3	4	4
PL.53828	PL.53829	ABC	#3/0 ACSR	7.10Y	118.3	0.07	6.66	77.70	26	1593	451	96	0.69	0.0	4.075	0.068	4	1	2	245
REG28	PL.53828	ABC	114.3 KVA	7.52Y	125.4	-7.05	-0.39	77.50	52	1588	449	96	percent Boost= 5.62		Tap= 9.0					243
PL.33455	REG28	ABC	#3/0 ACSR	7.52Y	125.3	0.08	-0.32	73.14	24	1588	449	96	0.73	0.0	4.156	0.081	0	0	0	243
PL.34299	PL.33455	C	6 A (CWC)	7.52Y	125.3	0.00	-0.32	8.89	6	65	17	97	0.00	0.0	4.157	0.001	0	0	0	15
PD.5009	PL.34299	C	50QA	7.52Y	125.3	0.00	-0.32	8.89	18	65	17	97	0.00	0.0	4.157	0.001	0	0	0	15
PL.61211	PD.5009	C	6 A (CWC)	7.52Y	125.3	0.01	-0.31	8.89	6	65	17	97	0.00	0.0	4.174	0.017	0	0	0	15
PL.61213	PL.61211	C	6 A (CWC)	7.52Y	125.3	0.01	-0.30	8.89	6	65	17	97	0.01	0.0	4.204	0.029	8	2	1	15
PL.61214	PL.61213	C	6 A (CWC)	7.51Y	125.2	0.08	-0.22	7.82	6	57	15	97	0.03	0.1	4.416	0.212	0	0	0	14
PL.61212	PL.61214	C	6 A (CWC)	7.51Y	125.2	0.01	-0.21	7.82	6	57	15	97	0.01	0.0	4.458	0.042	0	0	0	14
PL.53963	PL.61212	C	6 A (CWC)	7.51Y	125.2	0.01	-0.19	7.82	6	57	15	97	0.00	0.0	4.492	0.034	3	1	1	14
PL.53964	PL.53963	C	6 A (CWC)	7.51Y	125.2	0.02	-0.18	7.38	5	53	14	97	0.01	0.0	4.538	0.046	3	1	1	13
PL.53961	PL.53964	C	6 A (CWC)	7.51Y	125.2	0.00	-0.18	1.03	1	8	2	97	0.00	0.0	4.592	0.053	8	2	1	1
PL.53962	PL.53964	C	6 A (CWC)	7.51Y	125.2	0.02	-0.16	5.96	4	43	12	96	0.01	0.0	4.626	0.087	0	0	0	11
PL.53994	PL.53962	C	#4 ACSR	7.51Y	125.1	0.02	-0.14	3.97	3	29	8	96	0.00	0.0	4.720	0.095	5	1	1	8
PL.53996	PL.53994	C	#4 ACSR	7.51Y	125.1	0.00	-0.14	1.55	1	11	3	96	0.00	0.0	4.762	0.042	2	1	1	2
PL.53997	PL.53996	C	#1/0 ACSR	7.51Y	125.1	0.00	-0.14	1.23	1	9	2	98	0.00	0.0	4.800	0.038	9	2	1	1
PL.53995	PL.53994	C	#4 ACSR	7.51Y	125.1	0.01	-0.13	1.72	1	12	3	97	0.00	0.0	4.825	0.105	6	2	1	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.63970	PL.53995	C	#4 ACSR	7.51Y	125.1	0.00	-0.13	0.91	1	7	2	96	0.00	0.0	4.931	0.106	3	1	1	4
PL.63968	PL.63970	C	#4 ACSR	7.51Y	125.1	0.00	-0.13	0.51	0	4	1	97	0.00	0.0	4.957	0.026	4	1	2	3
PL.63969	PL.63968	C	#4 ACSR	7.51Y	125.1	0.00	-0.13	0.01	0	0	0	100	0.00	0.0	5.028	0.070	0	0	1	1
PL.34303	PL.53962	C	#4 ACSR	7.51Y	125.1	0.01	-0.15	1.96	2	14	4	96	0.00	0.0	4.703	0.077	0	0	0	2
PL.54001	PL.34303	C	#4 ACSR	7.51Y	125.1	0.00	-0.15	1.20	1	9	2	98	0.00	0.0	4.722	0.020	9	2	1	1
PL.53998	PL.34303	C	#4 ACSR	7.51Y	125.1	0.00	-0.15	0.76	1	6	1	99	0.00	0.0	4.758	0.055	0	0	0	1
PL.53999	PL.53998	C	#4 ACSR	7.51Y	125.1	0.00	-0.15	0.76	1	6	1	99	0.00	0.0	4.792	0.034	6	1	1	1
PL.54000	PL.53999	C	#4 ACSR	7.51Y	125.1	0.00	-0.15	0.00	0	0	0	100	0.00	0.0	4.974	0.182	0	0	0	0
PL.33624	PL.53962	C	#4 ACSR	7.51Y	125.2	0.00	-0.16	0.03	0	0	0	100	0.00	0.0	4.691	0.065	0	0	1	1
PL.53969	PL.33455	ABC	#3/0 ACSR	7.51Y	125.2	0.10	-0.22	65.84	22	1429	405	96	0.87	0.1	4.276	0.120	11	3	1	215
PL.53970	PL.53969	C	#1/0 ACSR	7.51Y	125.2	0.00	-0.22	0.00	0	0	0	100	0.00	0.0	4.280	0.004	0	0	0	0
PD.8117	PL.53970	C	10QA	7.51Y	125.2	0.00	-0.22	0.00	0	0	0	100	0.00	0.0	4.280	0.004	0	0	0	0
PL.53971	PD.8117	C	#1/0 ACSR	7.51Y	125.2	0.00	-0.22	0.00	0	0	0	100	0.00	0.0	4.303	0.024	0	0	0	0
PL.64330	PL.53969	ABC	#3/0 ACSR	7.51Y	125.2	0.06	-0.16	65.34	22	1417	401	96	0.50	0.0	4.345	0.069	4	1	1	214
PL.64333	PL.64330	ABC	#3/0 ACSR	7.51Y	125.2	0.00	-0.16	65.16	22	1413	399	96	0.00	0.0	4.346	0.000	4	1	2	213
PL.64331	PL.64333	C	#4 ACSR	7.51Y	125.2	0.00	-0.16	2.47	2	18	5	96	0.00	0.0	4.347	0.002	0	0	0	2
PD.4956	PL.64331	C	50QA	7.51Y	125.2	0.00	-0.16	2.47	5	18	5	96	0.00	0.0	4.347	0.002	0	0	0	2
PL.33260	PD.4956	C	#4 ACSR	7.51Y	125.2	0.01	-0.15	2.47	2	18	5	96	0.00	0.0	4.431	0.084	9	2	1	2
PL.62762	PL.33260	C	1/0 AL URD	7.51Y	125.2	0.00	-0.15	1.29	1	9	3	95	0.00	0.0	4.457	0.027	9	3	1	1
PL.64332	PL.64333	ABC	#3/0 ACSR	7.51Y	125.1	0.07	-0.09	64.14	21	1391	393	96	0.62	0.0	4.435	0.089	0	0	0	209
PL.64852	PL.64332	ABC	#3/0 ACSR	7.50Y	125.0	0.06	-0.03	64.14	21	1390	392	96	0.48	0.0	4.504	0.069	7	2	2	209
PL.34305	PL.64852	ABC	#3/0 ACSR	7.50Y	124.9	0.10	0.07	63.82	21	1382	389	96	0.86	0.1	4.631	0.127	10	3	1	207
PL.34306	PL.34305	ABC	#3/0 ACSR	7.49Y	124.9	0.06	0.13	63.36	21	1372	386	96	0.53	0.0	4.709	0.078	0	0	0	206
PL.56640	PL.34306	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.96	1	7	2	96	0.00	0.0	4.713	0.004	0	0	0	1
PD.8325	PL.56640	A	25T	7.49Y	124.9	0.00	0.13	0.96	0	7	2	96	0.00	0.0	4.713	0.004	0	0	0	1
PL.61190	PD.8325	A	#4 ACSR	7.49Y	124.9	0.00	0.14	0.96	1	7	2	96	0.00	0.0	4.749	0.036	7	2	1	1
PL.61191	PL.61190	A	#4 ACSR	7.49Y	124.9	0.00	0.14	0.00	0	0	0	100	0.00	0.0	4.935	0.186	0	0	0	0
PL.34307	PL.34306	ABC	#3/0 ACSR	7.49Y	124.8	0.05	0.19	63.04	21	1364	383	96	0.46	0.0	4.777	0.068	4	1	1	205
PL.34308	PL.34307	ABC	#3/0 ACSR	7.49Y	124.8	0.05	0.24	62.85	21	1360	381	96	0.40	0.0	4.838	0.060	18	5	3	204
PL.53912	PL.34308	ABC	#3/0 ACSR	7.48Y	124.7	0.05	0.29	59.34	20	1283	360	96	0.42	0.0	4.910	0.072	7	2	1	194
PL.53965	PL.53912	ABC	#3/0 ACSR	7.48Y	124.7	0.03	0.32	59.01	20	1276	357	96	0.24	0.0	4.951	0.042	0	0	0	193

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53967	PL.53965	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	2.58	1	19	5	97	0.00	0.0	4.955	0.004	0	0	0	1
PD.8116	PL.53967	C	20QA	7.48Y	124.7	0.00	0.32	2.58	13	19	5	97	0.00	0.0	4.955	0.004	0	0	0	1
PL.53968	PD.8116	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	2.58	1	19	5	97	0.00	0.0	4.972	0.017	19	5	1	1
PL.53966	PL.53965	ABC	#3/0 ACSR	7.48Y	124.6	0.04	0.36	58.15	19	1257	352	96	0.30	0.0	5.005	0.053	0	0	0	192
PD.5014	PL.53966	ABC	100L	7.48Y	124.6	0.00	0.36	58.15	58	1256	352	96	0.00	0.0	5.005	0.053	0	0	0	192
PL.33807	PD.5014	ABC	#3/0 ACSR	7.48Y	124.6	0.00	0.36	58.15	19	1256	352	96	0.00	0.0	5.005	0.000	0	0	0	192
PL.58445	PL.33807	ABC	#3/0 ACSR	7.48Y	124.6	0.05	0.41	58.15	19	1256	352	96	0.37	0.0	5.071	0.066	0	0	0	192
PL.58447	PL.58445	C	#4 ACSR	7.48Y	124.6	0.00	0.41	2.25	2	16	4	97	0.00	0.0	5.071	0.001	0	0	0	4
PD.8593	PL.58447	C	40QA	7.48Y	124.6	0.00	0.41	2.25	6	16	4	97	0.00	0.0	5.071	0.001	0	0	0	4
PL.58444	PD.8593	C	#4 ACSR	7.48Y	124.6	0.00	0.41	1.48	1	11	3	96	0.00	0.0	5.153	0.082	11	3	1	1
PL.58443	PD.8593	C	6 A (CWC)	7.48Y	124.6	0.01	0.41	0.77	1	6	1	99	0.00	0.0	5.231	0.160	0	0	2	3
PL.33150	PL.58443	C	6 A (CWC)	7.47Y	124.6	0.01	0.42	0.73	1	5	1	98	0.00	0.0	5.563	0.331	5	1	1	1
PL.58446	PL.58445	ABC	#3/0 ACSR	7.46Y	124.4	0.20	0.61	57.40	19	1240	347	96	1.54	0.1	5.349	0.278	0	0	0	188
PL.33423	PL.58446	ABC	#3/0 ACSR	7.46Y	124.3	0.08	0.69	54.22	18	1169	326	96	0.55	0.0	5.460	0.112	0	0	0	176
PL.33424	PL.33423	ABC	#3/0 ACSR	7.45Y	124.2	0.08	0.77	54.22	18	1169	325	96	0.59	0.1	5.580	0.120	4	1	2	176
PL.53958	PL.33424	ABC	#3/0 ACSR	7.44Y	123.9	0.31	1.07	54.01	18	1164	323	96	2.20	0.2	6.028	0.448	0	0	0	174
PL.54005	PL.53958	ABC	#3/0 ACSR	7.42Y	123.7	0.22	1.29	53.43	18	1149	316	96	1.54	0.1	6.350	0.321	2	0	2	172
PL.54006	PL.54005	ABC	#3/0 ACSR	7.42Y	123.7	0.03	1.32	51.71	17	1111	304	96	0.20	0.0	6.395	0.045	1	0	1	167
PL.54003	PL.54006	ABC	#3/0 ACSR	7.42Y	123.6	0.04	1.36	50.96	17	1094	300	96	0.27	0.0	6.456	0.061	1	0	1	165
PL.33174	PL.54003	ABC	#3/0 ACSR	7.41Y	123.6	0.07	1.43	50.91	17	1093	299	96	0.46	0.0	6.562	0.106	0	0	2	164
PL.34142	PL.33174	ABC	#3/0 ACSR	7.41Y	123.5	0.07	1.50	50.91	17	1092	298	96	0.47	0.0	6.671	0.109	2	0	2	162
PL.33909	PL.34142	ABC	#3/0 ACSR	7.40Y	123.4	0.12	1.62	50.45	17	1082	295	96	0.80	0.1	6.858	0.187	0	0	0	159
PL.33590	PL.33909	ABC	#1/0 ACSR	7.40Y	123.4	0.03	1.64	13.54	6	290	79	96	0.05	0.0	6.965	0.107	0	0	0	48
PL.33912	PL.33590	ABC	#1/0 ACSR	7.40Y	123.4	0.00	1.64	13.54	6	290	79	96	0.00	0.0	6.965	0.000	0	0	0	48
PD.5015	PL.33912	ABC	35L	7.40Y	123.4	0.00	1.64	13.54	39	290	79	96	0.00	0.0	6.965	0.000	0	0	0	48
PL.33913	PD.5015	ABC	#1/0 ACSR	7.40Y	123.3	0.08	1.73	13.54	6	290	79	96	0.17	0.1	7.310	0.344	0	0	0	48
PL.33957	PL.33913	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	5.71	2	41	11	97	0.00	0.0	7.311	0.001	0	0	0	4
PD.5000	PL.33957	C	40QA	7.40Y	123.3	0.00	1.73	5.71	14	41	11	97	0.00	0.0	7.311	0.001	0	0	0	4
PL.33476	PD.5000	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	5.71	2	41	11	97	0.00	0.0	7.339	0.029	15	4	1	4
PL.33257	PL.33476	C	#2 ACSR	7.40Y	123.3	0.00	1.73	1.29	1	9	2	98	0.00	0.0	7.374	0.034	9	2	1	1
PL.54009	PL.33476	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	2.30	1	16	4	97	0.00	0.0	7.405	0.066	16	4	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.54010	PL.54009	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	7.533	0.128	0	0	0	0
PL.54011	PL.54010	C	#2 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	7.636	0.102	0	0	0	0
PL.54012	PL.54011	C	#2 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	7.729	0.094	0	0	0	0
PL.33477	PL.33913	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.76	11.64	5	249	68	96	0.05	0.0	7.465	0.155	16	4	2	44
PL.33479	PL.33477	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	1.91	1	14	4	96	0.00	0.0	7.466	0.001	0	0	0	1
PD.4929	PL.33479	C	20QA	7.39Y	123.2	0.00	1.76	1.91	10	14	4	96	0.00	0.0	7.466	0.001	0	0	0	1
PL.33958	PD.4929	C	#1/0 ACSR	7.39Y	123.2	0.00	1.76	1.91	1	14	4	96	0.00	0.0	7.523	0.057	14	4	1	1
PL.33478	PL.33477	ABC	#1/0 ACSR	7.39Y	123.2	0.04	1.79	10.23	4	219	59	97	0.06	0.0	7.670	0.205	0	0	0	41
PL.55995	PL.33478	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.82	10.23	4	219	59	97	0.04	0.0	7.800	0.130	3	1	1	41
PL.61205	PL.55995	ABC	#1/0 ACSR	7.39Y	123.2	0.01	1.83	10.10	4	216	59	96	0.02	0.0	7.865	0.065	0	0	0	40
PL.61206	PL.61205	ABC	#1/0 ACSR	7.39Y	123.2	0.01	1.84	9.70	4	208	56	97	0.02	0.0	7.947	0.082	0	0	0	39
PL.33179	PL.61206	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	0.38	0	3	1	95	0.00	0.0	7.948	0.001	0	0	0	2
PD.4931	PL.33179	C	40QA	7.39Y	123.2	0.00	1.84	0.38	1	3	1	95	0.00	0.0	7.948	0.001	0	0	0	2
PL.33959	PD.4931	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	0.38	0	3	1	95	0.00	0.0	7.991	0.043	3	1	2	2
PL.33960	PL.33959	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	0.00	0	0	0	100	0.00	0.0	8.113	0.123	0	0	0	0
PL.34000	PL.33960	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	0.00	0	0	0	100	0.00	0.0	8.224	0.111	0	0	0	0
PL.34001	PL.34000	C	#1/0 ACSR	7.39Y	123.2	0.00	1.84	0.00	0	0	0	100	0.00	0.0	8.268	0.044	0	0	0	0
PL.33178	PL.61206	ABC	#1/0 ACSR	7.39Y	123.1	0.01	1.86	9.57	4	205	55	97	0.02	0.0	8.030	0.083	0	0	0	37
PL.34314	PL.33178	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.87	9.57	4	205	55	97	0.02	0.0	8.127	0.097	18	5	2	37
PL.55656	PL.34314	ABC	#1/0 ACSR	7.39Y	123.1	0.01	1.89	8.75	4	187	51	96	0.01	0.0	8.198	0.071	1	0	2	35
PL.55658	PL.55656	ABC	#1/0 ACSR	7.39Y	123.1	0.01	1.89	8.37	4	179	48	97	0.01	0.0	8.251	0.052	23	6	3	31
PL.55203	PL.55658	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.90	7.28	3	156	42	97	0.01	0.0	8.288	0.037	0	0	0	28
PL.55653	PL.55203	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.91	7.28	3	156	42	97	0.02	0.0	8.403	0.115	1	0	1	28
PL.55654	PL.55653	C	6 A (CWC)	7.39Y	123.1	0.00	1.91	6.35	5	45	12	97	0.00	0.0	8.408	0.004	0	0	0	5
PD.8220	PL.55654	C	40QA	7.39Y	123.1	0.00	1.91	6.35	16	45	12	97	0.00	0.0	8.408	0.004	0	0	0	5
PL.56790	PD.8220	C	6 A (CWC)	7.38Y	123.0	0.05	1.96	6.35	5	45	12	97	0.02	0.0	8.577	0.170	0	0	0	5
PL.56791	PL.56790	C	#4 ACSR	7.38Y	123.0	0.00	1.96	0.60	0	4	1	97	0.00	0.0	8.675	0.098	4	1	1	1
PL.56794	PL.56790	C	6 A (CWC)	7.38Y	123.0	0.01	1.97	5.75	4	41	11	97	0.00	0.0	8.620	0.043	20	5	3	4
PL.56795	PL.56794	C	6 A (CWC)	7.38Y	123.0	0.00	1.98	3.00	2	21	6	96	0.00	0.0	8.685	0.066	21	6	1	1
PL.56796	PL.56794	C	6 A (CWC)	7.38Y	123.0	0.00	1.97	0.00	0	0	0	100	0.00	0.0	8.740	0.120	0	0	0	0
PL.56792	PL.56796	C	6 A (CWC)	7.38Y	123.0	0.00	1.97	0.00	0	0	0	100	0.00	0.0	8.817	0.078	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55655	PL.55653	A	#2 ACSR	7.39Y	123.1	0.00	1.91	0.00	0	0	0	100	0.00	0.0	8.409	0.006	0	0	0	3
PD.8221	PL.55655	A	60QA	7.39Y	123.1	0.00	1.91	0.00	0	0	0	100	0.00	0.0	8.409	0.006	0	0	0	3
PL.55652	PD.8221	A	#2 ACSR	7.39Y	123.1	0.00	1.91	0.00	0	0	0	100	0.00	0.0	8.472	0.063	0	0	3	3
PL.65750	PL.55653	A	#1/0 ACSR	7.39Y	123.1	0.00	1.91	15.33	7	109	30	96	0.00	0.0	8.407	0.004	0	0	0	19
PD.9588	PL.65750	A	30T	7.39Y	123.1	0.00	1.91	15.33	0	109	30	96	0.00	0.0	8.407	0.004	0	0	0	19
PL.65751	PD.9588	A	#1/0 ACSR	7.38Y	123.1	0.02	1.93	15.33	7	109	30	96	0.01	0.0	8.460	0.053	0	0	0	19
PL.55678	PL.65751	A	6 A (CWC)	7.38Y	123.1	0.00	1.93	0.28	0	2	1	89	0.00	0.0	8.510	0.050	2	1	1	1
PL.55681	PL.65751	A	#1/0 ACSR	7.38Y	123.1	0.02	1.95	15.06	7	107	29	97	0.01	0.0	8.505	0.045	0	0	0	18
PL.55682	PL.55681	A	#1/0 ACSR	7.38Y	123.0	0.01	1.96	15.06	7	107	29	97	0.01	0.0	8.547	0.043	0	0	0	18
PL.55679	PL.55682	A	#1/0 ACSR	7.38Y	123.0	0.04	2.00	11.28	5	80	22	96	0.02	0.0	8.685	0.138	0	0	1	13
PL.55663	PL.55679	A	6 A (CWC)	7.38Y	123.0	0.03	2.02	5.44	4	39	10	97	0.01	0.0	8.787	0.102	0	0	0	7
PL.55662	PL.55663	A	6 A (CWC)	7.38Y	123.0	0.01	2.04	5.44	4	39	10	97	0.00	0.0	8.846	0.058	16	4	1	7
PL.55666	PL.55662	A	6 A (CWC)	7.38Y	123.0	0.01	2.04	1.96	1	14	4	96	0.00	0.0	8.965	0.120	8	2	1	4
PL.55667	PL.55666	A	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.61	0	4	1	97	0.00	0.0	9.021	0.056	4	1	1	1
PL.55683	PL.55666	A	#2 ACSR	7.38Y	123.0	0.00	2.04	0.24	0	2	0	100	0.00	0.0	9.026	0.060	2	0	2	2
PL.55664	PL.55662	A	6 A (CWC)	7.38Y	123.0	0.01	2.04	1.18	1	8	2	97	0.00	0.0	9.039	0.194	8	2	1	2
PL.55665	PL.55664	A	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	9.074	0.034	0	0	1	1
PL.55669	PL.55679	A	#1/0 ACSR	7.38Y	123.0	0.00	2.00	5.84	3	42	11	97	0.00	0.0	8.716	0.031	0	0	0	5
PL.55668	PL.55669	A	6 A (CWC)	7.38Y	123.0	0.00	2.01	1.87	1	13	4	96	0.00	0.0	8.767	0.052	13	4	1	1
PL.55670	PL.55669	A	#1/0 ACSR	7.38Y	123.0	0.01	2.01	3.97	2	28	8	96	0.00	0.0	8.818	0.102	0	0	0	4
PL.55671	PL.55670	A	#1/0 ACSR	7.38Y	123.0	0.00	2.02	3.97	2	28	8	96	0.00	0.0	8.869	0.052	16	4	3	4
PL.55672	PL.55671	A	#1/0 ACSR	7.38Y	123.0	0.01	2.02	1.67	1	12	3	97	0.00	0.0	9.051	0.182	0	0	0	1
PL.55673	PL.55672	A	#1/0 ACSR	7.38Y	123.0	0.00	2.03	1.67	1	12	3	97	0.00	0.0	9.304	0.253	12	3	1	1
PL.55680	PL.55682	A	6 A (CWC)	7.38Y	123.0	0.01	1.97	2.89	2	21	6	96	0.00	0.0	8.619	0.072	7	2	1	4
PL.55674	PL.55680	A	6 A (CWC)	7.38Y	123.0	0.00	1.97	1.94	1	14	4	96	0.00	0.0	8.667	0.048	3	1	1	3
PL.55675	PL.55674	A	6 A (CWC)	7.38Y	123.0	0.00	1.98	1.54	1	11	3	96	0.00	0.0	8.717	0.049	11	3	2	2
PL.55677	PL.55682	A	#4 ACSR	7.38Y	123.0	0.00	1.96	0.88	1	6	2	95	0.00	0.0	8.604	0.057	6	2	1	1
PL.55204	PL.55203	A	#4 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.291	0.003	0	0	0	0
PD.8219	PL.55204	A	20QA	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.291	0.003	0	0	0	0
PL.59073	PD.8219	A	#4 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.342	0.050	0	0	0	0
PL.55205	PL.55203	C	#1/0 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.292	0.004	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.8218	PL.55205	C	20QA	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.292	0.004	0	0	0	0
PL.55202	PD.8218	C	#1/0 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	8.335	0.043	0	0	0	0
PL.55657	PL.55656	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.97	1	7	2	96	0.00	0.0	8.204	0.006	0	0	0	2
PD.8222	PL.55657	A	25QA	7.39Y	123.1	0.00	1.89	0.97	4	7	2	96	0.00	0.0	8.204	0.006	0	0	0	2
PL.55659	PD.8222	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.97	1	7	2	96	0.00	0.0	8.249	0.045	7	2	1	2
PL.55660	PL.55659	A	#2 ACSR	7.39Y	123.1	0.00	1.89	0.04	0	0	0	100	0.00	0.0	8.324	0.074	0	0	1	1
PL.61207	PL.61205	B	#1/0 ACSR	7.39Y	123.2	0.00	1.83	1.20	1	9	2	98	0.00	0.0	7.868	0.004	0	0	0	1
PD.9105	PL.61207	B	12T	7.39Y	123.2	0.00	1.83	1.20	0	9	2	98	0.00	0.0	7.868	0.004	0	0	0	1
PL.61208	PD.9105	B	#1/0 ACSR	7.39Y	123.2	0.00	1.83	1.20	1	9	2	98	0.00	0.0	7.925	0.056	9	2	1	1
PL.55996	PL.55995	A	#1/0 ACSR	7.39Y	123.2	0.00	1.82	0.00	0	0	0	100	0.00	0.0	7.803	0.003	0	0	0	0
PD.8305	PL.55996	A	20QA	7.39Y	123.2	0.00	1.82	0.00	0	0	0	100	0.00	0.0	7.803	0.003	0	0	0	0
PL.55994	PD.8305	A	#1/0 ACSR	7.39Y	123.2	0.00	1.82	0.00	0	0	0	100	0.00	0.0	7.824	0.020	0	0	0	0
PL.33189	PL.33909	ABC	6 A (CWC)	7.38Y	123.0	0.37	1.99	36.91	26	791	215	96	2.32	0.3	7.116	0.257	0	0	0	111
PL.33228	PL.33189	ABC	6 A (CWC)	7.38Y	123.0	0.00	1.99	36.91	26	789	214	97	0.01	0.0	7.117	0.001	0	0	0	111
PL.33943	PL.33228	ABC	6 A (CWC)	7.38Y	123.0	0.01	2.00	36.91	26	789	214	97	0.08	0.0	7.125	0.008	0	0	0	111
PL.33641	PL.33943	ABC	6 A (CWC)	7.38Y	123.0	0.03	2.04	36.85	26	787	214	96	0.21	0.0	7.149	0.024	3	1	1	110
PL.64402	PL.33641	ABC	6 A (CWC)	7.37Y	122.9	0.09	2.13	36.72	26	784	213	97	0.57	0.1	7.212	0.063	0	0	0	109
PL.64403	PL.64402	ABC	6 A (CWC)	7.37Y	122.9	0.01	2.13	2.20	2	47	13	96	0.00	0.0	7.294	0.082	25	7	3	10
PL.33642	PL.64403	ABC	6 A (CWC)	7.37Y	122.9	0.00	2.13	1.01	1	22	6	96	0.00	0.0	7.350	0.056	5	1	4	7
PL.33946	PL.33642	ABC	6 A (CWC)	7.37Y	122.9	0.00	2.13	0.77	1	16	4	97	0.00	0.0	7.431	0.082	16	4	3	3
PL.64405	PL.64402	ABC	6 A (CWC)	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.491	0.279	0	0	0	0
PL.64406	PL.64405	ABC	6 A (CWC)	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.495	0.005	0	0	0	0
PD.9537-B	PL.64406	ABC	Open	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.495	0.005	0	0	0	0
PL.64404	PL.64402	ABC	6 A (CWC)	7.36Y	122.7	0.17	2.30	34.52	25	737	200	97	1.02	0.1	7.341	0.129	2	1	1	99
PL.33947	PL.64404	ABC	6 A (CWC)	7.35Y	122.6	0.12	2.43	34.41	25	733	199	97	0.73	0.1	7.434	0.093	0	0	0	98
PL.33161	PL.33947	ABC	6 A (CWC)	7.35Y	122.6	0.00	2.43	34.41	25	733	199	97	0.00	0.0	7.434	0.000	0	0	0	98
PD.5017	PL.33161	ABC	50L	7.35Y	122.6	0.00	2.43	34.41	69	733	199	97	0.00	0.0	7.434	0.000	0	0	0	98
PL.33643	PD.5017	ABC	6 A (CWC)	7.35Y	122.5	0.07	2.49	34.41	25	733	199	97	0.40	0.1	7.485	0.051	7	2	2	98
PL.33948	PL.33643	ABC	6 A (CWC)	7.34Y	122.3	0.16	2.65	34.08	24	725	197	97	0.90	0.1	7.602	0.117	3	1	1	96
PL.33949	PL.33948	A	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	7.602	0.000	0	0	0	0
PD.4916	PL.33949	A	40QA	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	7.602	0.000	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33950	PD.4916	A	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	7.638	0.036	0	0	0	0
PL.33232	PL.33948	ABC	6 A (CWC)	7.33Y	122.2	0.13	2.78	33.95	24	722	195	97	0.74	0.1	7.700	0.098	5	1	2	95
PL.33233	PL.33232	ABC	6 A (CWC)	7.33Y	122.2	0.01	2.79	33.06	24	702	190	97	0.06	0.0	7.708	0.008	0	0	0	91
PL.33234	PL.33233	ABC	6 A (CWC)	7.32Y	122.1	0.15	2.94	33.06	24	702	190	97	0.81	0.1	7.820	0.112	0	0	0	91
PL.54039	PL.33234	ABC	6 A (CWC)	7.31Y	121.9	0.21	3.15	27.17	19	576	156	97	0.96	0.2	8.019	0.198	4	1	1	75
PL.54040	PL.54039	ABC	6 A (CWC)	7.31Y	121.8	0.04	3.18	27.00	19	572	155	97	0.16	0.0	8.052	0.034	0	0	0	74
PL.54041	PL.54040	ABC	6 A (CWC)	7.31Y	121.8	0.05	3.23	27.00	19	571	155	97	0.21	0.0	8.096	0.043	0	0	1	74
PL.33269	PL.54041	ABC	6 A (CWC)	7.30Y	121.7	0.03	3.25	26.98	19	571	154	97	0.11	0.0	8.120	0.025	27	7	4	73
PL.33229	PL.33269	ABC	6 A (CWC)	7.30Y	121.7	0.07	3.32	25.70	18	544	147	97	0.28	0.1	8.188	0.068	28	8	4	69
PL.33270	PL.33229	C	6 A (CWC)	7.30Y	121.7	0.00	3.32	2.60	2	18	5	96	0.00	0.0	8.189	0.001	0	0	0	2
PD.4932	PL.33270	C	40QA	7.30Y	121.7	0.00	3.32	2.60	6	18	5	96	0.00	0.0	8.189	0.001	0	0	0	2
PL.54022	PD.4932	C	397 SPACER	7.30Y	121.7	0.00	3.32	2.60	0	18	5	96	0.00	0.0	8.277	0.089	18	5	2	2
PL.54023	PL.54022	C	6 A (CWC)	7.30Y	121.7	0.00	3.32	0.00	0	0	0	100	0.00	0.0	8.331	0.054	0	0	0	0
PL.54021	PL.33229	ABC	6 A (CWC)	7.30Y	121.6	0.09	3.41	23.50	17	497	134	97	0.33	0.1	8.287	0.099	56	15	6	63
PL.61247	PL.54021	B	#1/0 ACSR	7.30Y	121.6	0.00	3.41	1.44	1	10	3	96	0.00	0.0	8.330	0.043	10	3	1	1
PL.54042	PL.54021	ABC	6 A (CWC)	7.29Y	121.5	0.05	3.45	20.38	15	431	116	97	0.16	0.0	8.347	0.059	7	2	1	56
PL.54044	PL.54042	C	#2 ACSR	7.29Y	121.5	0.00	3.46	2.79	2	20	5	97	0.00	0.0	8.372	0.025	20	5	1	1
PL.54043	PL.54042	ABC	6 A (CWC)	7.29Y	121.5	0.05	3.51	16.29	12	344	93	97	0.14	0.0	8.431	0.084	35	10	4	49
PL.33273	PL.54043	ABC	6 A (CWC)	7.29Y	121.5	0.03	3.53	14.61	10	309	83	97	0.07	0.0	8.480	0.049	24	6	5	45
PL.33633	PL.33273	ABC	6 A (CWC)	7.29Y	121.4	0.05	3.58	13.49	10	285	77	97	0.10	0.0	8.571	0.091	34	9	3	40
PL.33274	PL.33633	ABC	6 A (CWC)	7.28Y	121.4	0.02	3.60	11.48	8	242	65	97	0.04	0.0	8.616	0.045	7	2	1	36
PL.33191	PL.33274	A	6 A (CWC)	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	8.616	0.000	0	0	0	0
PD.4919	PL.33191	A	40QA	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	8.616	0.000	0	0	0	0
PL.33192	PD.4919	A	6 A (CWC)	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	8.663	0.047	0	0	0	0
PL.33261	PL.33274	ABC	6 A (CWC)	7.28Y	121.4	0.03	3.63	9.90	7	209	56	97	0.05	0.0	8.695	0.079	0	0	0	31
PL.33577	PL.33261	ABC	6 A (CWC)	7.28Y	121.4	0.01	3.64	9.07	6	191	52	96	0.01	0.0	8.725	0.030	32	9	6	29
PL.33578	PL.33577	ABC	6 A (CWC)	7.28Y	121.3	0.03	3.67	7.56	5	159	43	97	0.04	0.0	8.838	0.113	18	5	2	23
PL.33579	PL.33578	C	#4 ACSR	7.28Y	121.3	0.00	3.67	1.65	1	12	3	97	0.00	0.0	8.838	0.000	0	0	0	2
PD.4994	PL.33579	C	40QA	7.28Y	121.3	0.00	3.67	1.65	4	12	3	97	0.00	0.0	8.838	0.000	0	0	0	2
PL.33175	PD.4994	C	#4 ACSR	7.28Y	121.3	0.00	3.67	1.65	1	12	3	97	0.00	0.0	8.900	0.062	1	0	1	2
PL.33177	PL.33175	C	#4 ACSR	7.28Y	121.3	0.00	3.67	1.49	1	10	3	96	0.00	0.0	8.923	0.023	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33580	PL.33578	ABC	6 A (CWC)	7.28Y	121.3	0.02	3.69	6.16	4	130	35	97	0.02	0.0	8.931	0.093	13	3	1	19
PL.33584	PL.33580	ABC	6 A (CWC)	7.28Y	121.3	0.01	3.70	5.19	4	109	30	96	0.01	0.0	8.994	0.063	1	0	1	16
PL.33303	PL.33584	ABC	6 A (CWC)	7.28Y	121.3	0.02	3.72	5.15	4	108	29	97	0.02	0.0	9.102	0.108	15	4	1	15
PL.33581	PL.33303	ABC	6 A (CWC)	7.28Y	121.3	0.01	3.74	4.45	3	94	25	97	0.01	0.0	9.179	0.077	0	0	0	14
PL.33259	PL.33581	C	6 A (CWC)	7.28Y	121.3	0.00	3.74	3.00	2	21	6	96	0.00	0.0	9.180	0.001	0	0	0	2
PD.4995	PL.33259	C	40QA	7.28Y	121.3	0.00	3.74	3.00	8	21	6	96	0.00	0.0	9.180	0.001	0	0	0	2
PL.54019	PD.4995	C	6 A (CWC)	7.28Y	121.3	0.00	3.74	3.00	2	21	6	96	0.00	0.0	9.226	0.046	12	3	1	2
PL.54020	PL.54019	C	6 A (CWC)	7.28Y	121.3	0.00	3.74	1.30	1	9	2	98	0.00	0.0	9.270	0.045	9	2	1	1
PL.33294	PL.33581	ABC	6 A (CWC)	7.27Y	121.2	0.03	3.76	3.45	2	73	20	96	0.01	0.0	9.367	0.188	0	0	1	12
PL.33464	PL.33294	C	#2 ACSR	7.27Y	121.2	0.00	3.77	2.83	2	20	5	97	0.00	0.0	9.462	0.095	20	5	1	1
PL.33295	PL.33294	ABC	6 A (CWC)	7.27Y	121.2	0.01	3.77	2.51	2	53	14	97	0.00	0.0	9.428	0.061	12	3	3	10
PL.33296	PL.33295	ABC	6 A (CWC)	7.27Y	121.2	0.00	3.77	1.92	1	40	11	96	0.00	0.0	9.462	0.034	4	1	1	7
PL.54033	PL.33296	ABC	6 A (CWC)	7.27Y	121.2	0.00	3.77	1.75	1	37	10	97	0.00	0.0	9.515	0.053	0	0	0	6
PL.54035	PL.54033	C	#1/0 ACSR	7.27Y	121.2	0.00	3.77	0.80	0	6	2	95	0.00	0.0	9.518	0.003	0	0	0	1
PD.8118	PL.54035	C	10QA	7.27Y	121.2	0.00	3.77	0.80	0	6	2	95	0.00	0.0	9.518	0.003	0	0	0	1
PL.54036	PD.8118	C	#1/0 ACSR	7.27Y	121.2	0.00	3.77	0.80	0	6	2	95	0.00	0.0	9.555	0.037	6	2	1	1
PL.54034	PL.54033	ABC	6 A (CWC)	7.27Y	121.2	0.00	3.78	1.48	1	31	8	97	0.00	0.0	9.572	0.057	0	0	0	5
PL.33297	PL.54034	C	6 A (CWC)	7.27Y	121.2	0.00	3.78	4.45	3	31	8	97	0.00	0.0	9.575	0.003	0	0	0	5
PD.5010	PL.33297	C	40QA	7.27Y	121.2	0.00	3.78	4.45	11	31	8	97	0.00	0.0	9.575	0.003	0	0	0	5
PL.54029	PD.5010	C	6 A (CWC)	7.27Y	121.2	0.00	3.78	4.45	3	31	8	97	0.00	0.0	9.580	0.005	0	0	0	5
PL.54031	PL.54029	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	2.32	1	16	4	97	0.00	0.0	9.610	0.030	4	1	1	2
PL.54032	PL.54031	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	1.74	1	12	3	97	0.00	0.0	9.642	0.032	12	3	1	1
PL.54030	PL.54029	C	6 A (CWC)	7.27Y	121.2	0.01	3.79	2.13	2	15	4	97	0.00	0.0	9.687	0.107	0	0	0	3
PL.54028	PL.54030	C	6 A (CWC)	7.27Y	121.2	0.00	3.79	2.13	2	15	4	97	0.00	0.0	9.765	0.078	15	4	3	3
PL.33583	PL.33580	C	6 A (CWC)	7.28Y	121.3	0.00	3.69	1.06	1	7	2	96	0.00	0.0	8.931	0.000	0	0	0	2
PD.4920	PL.33583	C	40QA	7.28Y	121.3	0.00	3.69	1.06	3	7	2	96	0.00	0.0	8.931	0.000	0	0	0	2
PL.54018	PD.4920	C	6 A (CWC)	7.28Y	121.3	0.00	3.69	1.06	1	7	2	96	0.00	0.0	8.975	0.044	7	2	2	2
PL.33582	PL.33580	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	0.00	0	0	0	100	0.00	0.0	8.931	0.000	0	0	0	0
PD.4981	PL.33582	A	40QA	7.28Y	121.3	0.00	3.69	0.00	0	0	0	100	0.00	0.0	8.931	0.000	0	0	0	0
PL.54017	PD.4981	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	0.00	0	0	0	100	0.00	0.0	8.997	0.066	0	0	0	0
PL.33279	PL.33261	C	#2 ACSR	7.28Y	121.4	0.00	3.63	2.47	1	17	5	96	0.00	0.0	8.719	0.025	17	5	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33575	PL.33274	A	#4 ACSR	7.28Y	121.4	0.01	3.61	3.82	3	27	7	97	0.00	0.0	8.685	0.069	12	3	2	4
PL.33576	PL.33575	A	#4 ACSR	7.28Y	121.4	0.00	3.61	2.05	2	14	4	96	0.00	0.0	8.703	0.019	14	4	2	2
PL.33271	PL.33633	A	6 A (CWC)	7.29Y	121.4	0.00	3.58	1.24	1	9	2	98	0.00	0.0	8.572	0.000	0	0	0	1
PD.4980	PL.33271	A	40QA	7.29Y	121.4	0.00	3.58	1.24	3	9	2	98	0.00	0.0	8.572	0.000	0	0	0	1
PL.33272	PD.4980	A	6 A (CWC)	7.29Y	121.4	0.00	3.58	1.24	1	9	2	98	0.00	0.0	8.635	0.063	9	2	1	1
PL.54045	PL.54042	A	#1/0 ACSR	7.29Y	121.5	0.00	3.45	1.30	1	9	2	98	0.00	0.0	8.348	0.001	0	0	0	1
PD.4918	PL.54045	A	25QA	7.29Y	121.5	0.00	3.45	1.30	5	9	2	98	0.00	0.0	8.348	0.001	0	0	0	1
PL.54038	PD.4918	A	#1/0 ACSR	7.29Y	121.5	0.00	3.46	1.30	1	9	2	98	0.00	0.0	8.389	0.042	9	2	1	1
PL.63846	PL.54042	C	#1/0 ACSR	7.29Y	121.5	0.00	3.46	7.17	3	51	14	96	0.00	0.0	8.379	0.032	21	6	2	4
PL.63847	PL.63846	C	#1/0 ACSR	7.29Y	121.5	0.00	3.46	4.17	2	29	8	96	0.00	0.0	8.404	0.025	17	5	1	2
PL.54037	PL.63847	C	#1/0 ACSR	7.29Y	121.5	0.00	3.46	1.77	1	12	3	97	0.00	0.0	8.437	0.033	12	3	1	1
PL.33951	PL.33234	C	6 A (CWC)	7.32Y	122.1	0.00	2.94	17.67	13	125	34	96	0.00	0.0	7.821	0.000	0	0	0	16
PD.4930	PL.33951	C	40QA	7.32Y	122.1	0.00	2.94	17.67	44	125	34	96	0.00	0.0	7.821	0.000	0	0	0	16
PL.33952	PD.4930	C	6 A (CWC)	7.32Y	122.0	0.06	2.99	17.67	13	125	34	96	0.05	0.0	7.894	0.074	17	5	2	16
PL.33953	PL.33952	C	6 A (CWC)	7.32Y	121.9	0.08	3.07	14.44	10	102	28	96	0.06	0.1	8.009	0.115	0	0	0	13
PL.33954	PL.33953	C	6 A (CWC)	7.31Y	121.9	0.03	3.10	12.67	9	89	24	97	0.02	0.0	8.066	0.057	8	2	1	12
PL.33955	PL.33954	C	6 A (CWC)	7.31Y	121.8	0.07	3.17	11.53	8	81	22	97	0.04	0.1	8.205	0.139	0	0	0	11
PL.54026	PL.33955	C	6 A (CWC)	7.31Y	121.8	0.03	3.20	10.84	8	76	21	96	0.02	0.0	8.269	0.064	9	2	1	10
PL.54027	PL.54026	C	6 A (CWC)	7.31Y	121.8	0.02	3.23	8.52	6	60	16	97	0.01	0.0	8.329	0.060	0	0	0	8
PL.33956	PL.54027	C	6 A (CWC)	7.30Y	121.7	0.03	3.26	8.52	6	60	16	97	0.01	0.0	8.422	0.092	13	4	1	8
PL.33265	PL.33956	C	6 A (CWC)	7.30Y	121.7	0.04	3.29	6.66	5	47	13	96	0.01	0.0	8.542	0.120	2	0	1	7
PL.33266	PL.33265	C	6 A (CWC)	7.30Y	121.7	0.03	3.32	6.42	5	45	12	97	0.01	0.0	8.648	0.106	10	3	2	6
PL.33267	PL.33266	C	6 A (CWC)	7.30Y	121.7	0.02	3.34	5.05	4	36	10	96	0.00	0.0	8.750	0.102	10	3	1	4
PL.33268	PL.33267	C	#4/0 ACSR	7.30Y	121.7	0.00	3.34	2.44	1	17	5	96	0.00	0.0	8.799	0.049	7	2	1	2
PL.62742	PL.33268	C	#1/0 ACSR	7.30Y	121.7	0.00	3.34	1.40	1	10	3	96	0.00	0.0	8.850	0.051	10	3	1	1
PL.33167	PL.33267	C	#2 ACSR	7.30Y	121.7	0.00	3.34	1.21	1	9	2	98	0.00	0.0	8.807	0.056	9	2	1	1
PL.33639	PL.54027	C	#2 ACSR	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	8.375	0.046	0	0	0	0
PL.54025	PL.54026	C	#1/0 ACSR	7.31Y	121.8	0.00	3.20	1.10	0	8	2	97	0.00	0.0	8.330	0.061	8	2	1	1
PL.54024	PL.33955	C	#2 ACSR	7.31Y	121.8	0.00	3.17	0.70	0	5	1	98	0.00	0.0	8.298	0.093	5	1	1	1
PL.33230	PL.33954	C	#1/0 ACSR	7.31Y	121.9	0.00	3.10	0.00	0	0	0	100	0.00	0.0	8.130	0.064	0	0	0	0
PL.33169	PL.33953	C	#4 ACSR	7.32Y	121.9	0.00	3.07	1.77	1	13	3	97	0.00	0.0	8.073	0.064	13	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33147	PL.33952	C	6 A (CWC)	7.32Y	122.0	0.00	2.99	0.76	1	5	1	98	0.00	0.0	7.985	0.090	5	1	1	1
PL.33235	PL.33233	A	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.00	0	0	0	100	0.00	0.0	7.708	0.000	0	0	0	0
PD.4917	PL.33235	A	40QA	7.33Y	122.2	0.00	2.79	0.00	0	0	0	100	0.00	0.0	7.708	0.000	0	0	0	0
PL.33250	PD.4917	A	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.00	0	0	0	100	0.00	0.0	7.747	0.038	0	0	0	0
PL.33460	PL.33232	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	1.92	1	14	4	96	0.00	0.0	7.778	0.079	14	4	2	2
PL.33160	PL.33641	A	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	7.170	0.022	0	0	0	0
PL.33944	PL.33943	C	6 A (CWC)	7.38Y	123.0	0.00	2.00	0.19	0	1	0	100	0.00	0.0	7.125	0.000	0	0	0	1
PD.4915	PL.33944	C	40QA	7.38Y	123.0	0.00	2.00	0.19	0	1	0	100	0.00	0.0	7.125	0.000	0	0	0	1
PL.33945	PD.4915	C	6 A (CWC)	7.38Y	123.0	0.00	2.00	0.19	0	1	0	100	0.00	0.0	7.192	0.067	1	0	1	1
CP.51	PL.33228	ABC	Cap (300)	7.38Y	123.0	0.00	1.99	0.00	0	0	0	100	0.00	0.0	7.117	0.067	0	0	0	0
PL.33122	PL.33909	A	#2 ACSR	7.40Y	123.4	0.00	1.62	0.00	0	0	0	100	0.00	0.0	6.927	0.068	0	0	0	0
PL.33910	PL.34142	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.14	1	8	2	97	0.00	0.0	6.671	0.000	0	0	0	1
PD.4928	PL.33910	C	40QA	7.41Y	123.5	0.00	1.50	1.14	3	8	2	97	0.00	0.0	6.671	0.000	0	0	0	1
PL.33911	PD.4928	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.14	1	8	2	97	0.00	0.0	6.747	0.076	8	2	1	1
PL.54002	PL.54006	C	#4 ACSR	7.42Y	123.7	0.00	1.32	2.11	2	15	4	97	0.00	0.0	6.395	0.000	0	0	0	1
PD.4927	PL.54002	C	40QA	7.42Y	123.7	0.00	1.32	2.11	5	15	4	97	0.00	0.0	6.395	0.000	0	0	0	1
PL.54004	PD.4927	C	#4 ACSR	7.42Y	123.7	0.00	1.32	2.11	2	15	4	97	0.00	0.0	6.446	0.051	15	4	1	1
PL.54007	PL.54005	C	#4 ACSR	7.42Y	123.7	0.01	1.30	4.90	4	35	9	97	0.00	0.0	6.405	0.055	23	6	2	3
PL.54008	PL.54007	C	#2 ACSR	7.42Y	123.7	0.00	1.30	1.65	1	12	3	97	0.00	0.0	6.458	0.053	12	3	1	1
PL.53959	PL.53958	C	#4 ACSR	7.44Y	123.9	0.00	1.07	1.74	1	12	3	97	0.00	0.0	6.033	0.005	0	0	0	2
PD.8115	PL.53959	C	10QA	7.44Y	123.9	0.00	1.07	1.74	0	12	3	97	0.00	0.0	6.033	0.005	0	0	0	2
PL.53960	PD.8115	C	#4 ACSR	7.44Y	123.9	0.00	1.08	1.74	1	12	3	97	0.00	0.0	6.126	0.093	12	3	2	2
PL.57486	PL.58446	B	6 A (CWC)	7.46Y	124.4	0.00	0.61	9.56	7	69	19	96	0.00	0.0	5.353	0.005	0	0	0	12
PD.8370	PL.57486	B	20T	7.46Y	124.4	0.00	0.61	9.56	0	69	19	96	0.00	0.0	5.353	0.005	0	0	0	12
PL.57487	PD.8370	B	6 A (CWC)	7.46Y	124.3	0.06	0.68	9.56	7	69	19	96	0.03	0.0	5.519	0.166	15	4	3	12
PL.57485	PL.57487	B	6 A (CWC)	7.46Y	124.3	0.03	0.71	7.53	5	54	15	96	0.01	0.0	5.612	0.093	0	0	0	9
PL.33810	PL.57485	B	6 A (CWC)	7.45Y	124.2	0.06	0.77	6.40	5	46	12	97	0.02	0.0	5.829	0.217	0	0	0	8
PL.34143	PL.33810	B	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.08	0	1	0	100	0.00	0.0	6.118	0.289	0	0	0	1
PL.34144	PL.34143	B	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.08	0	1	0	100	0.00	0.0	6.357	0.239	1	0	1	1
PL.34145	PL.34144	B	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.00	0	0	0	100	0.00	0.0	6.837	0.480	0	0	0	0
PL.61241	PL.33810	B	6 A (CWC)	7.45Y	124.2	0.02	0.79	6.32	5	45	12	97	0.00	0.0	5.894	0.064	14	4	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.61240	PL.61241	B	6 A (CWC)	7.45Y	124.2	0.01	0.80	4.35	3	31	8	97	0.00	0.0	5.937	0.043	14	4	1	5
PL.53985	PL.61240	B	6 A (CWC)	7.45Y	124.2	0.01	0.80	2.46	2	18	5	96	0.00	0.0	6.002	0.065	2	0	1	4
PL.33251	PL.53985	B	#1/0 ACSR	7.45Y	124.2	0.00	0.80	1.47	1	11	3	96	0.00	0.0	6.047	0.045	11	3	1	1
PL.33226	PL.53985	B	6 A (CWC)	7.45Y	124.2	0.01	0.81	0.74	1	5	1	98	0.00	0.0	6.273	0.272	3	1	1	2
PL.33227	PL.33226	B	6 A (CWC)	7.45Y	124.2	0.00	0.81	0.28	0	2	1	89	0.00	0.0	6.342	0.069	2	1	1	1
PL.33808	PL.57485	B	#2 ACSR	7.46Y	124.3	0.01	0.72	1.13	1	8	2	97	0.00	0.0	5.773	0.161	0	0	0	1
PL.33809	PL.33808	B	#2 ACSR	7.46Y	124.3	0.00	0.72	1.13	1	8	2	97	0.00	0.0	5.829	0.056	8	2	1	1
PL.34309	PL.34308	A	#4 ACSR	7.49Y	124.8	0.00	0.24	8.09	6	58	16	96	0.00	0.0	4.838	0.001	0	0	0	7
PD.4912	PL.34309	A	40QA	7.49Y	124.8	0.00	0.24	8.09	20	58	16	96	0.00	0.0	4.838	0.001	0	0	0	7
PL.34310	PD.4912	A	#4 ACSR	7.48Y	124.7	0.02	0.26	8.09	6	58	16	96	0.01	0.0	4.913	0.075	25	7	2	7
PL.34311	PL.34310	A	#4 ACSR	7.48Y	124.7	0.01	0.27	4.67	4	34	9	97	0.00	0.0	4.965	0.051	13	4	2	5
PL.54013	PL.34311	A	#4 ACSR	7.48Y	124.7	0.01	0.27	2.82	2	20	5	97	0.00	0.0	5.055	0.091	20	5	3	3
PL.34302	PL.64332	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	0.00	0	0	0	100	0.00	0.0	4.435	0.000	0	0	0	0
PD.4955	PL.34302	C	50QA	7.51Y	125.1	0.00	-0.09	0.00	0	0	0	100	0.00	0.0	4.435	0.000	0	0	0	0
PL.34304	PD.4955	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	0.00	0	0	0	100	0.00	0.0	4.514	0.079	0	0	0	0
PL.61228	PL.33455	B	6 A (CWC)	7.52Y	125.3	0.00	-0.32	12.99	9	94	26	96	0.00	0.0	4.157	0.001	0	0	0	13
PD.9108	PL.61228	B	50QA	7.52Y	125.3	0.00	-0.32	12.99	26	94	26	96	0.00	0.0	4.157	0.001	0	0	0	13
PL.61226	PD.9108	B	6 A (CWC)	7.51Y	125.2	0.12	-0.20	12.99	9	94	26	96	0.08	0.1	4.379	0.222	17	5	2	13
PL.61227	PL.61226	B	6 A (CWC)	7.51Y	125.2	0.00	-0.19	0.85	1	6	2	95	0.00	0.0	4.430	0.051	6	2	2	2
PL.61229	PL.61226	B	6 A (CWC)	7.51Y	125.1	0.06	-0.14	9.75	7	71	19	97	0.03	0.0	4.513	0.135	2	1	1	9
PL.34300	PL.61229	B	6 A (CWC)	7.51Y	125.1	0.02	-0.12	9.49	7	69	19	96	0.01	0.0	4.561	0.047	0	0	0	8
PL.34301	PL.34300	B	6 A (CWC)	7.51Y	125.1	0.02	-0.09	9.49	7	69	19	96	0.01	0.0	4.615	0.054	10	3	2	8
PL.55200	PL.34301	B	6 A (CWC)	7.50Y	125.0	0.05	-0.05	8.15	6	59	16	97	0.02	0.0	4.759	0.144	13	3	2	6
PL.55201	PL.55200	B	6 A (CWC)	7.50Y	125.0	0.01	-0.04	6.39	5	46	13	96	0.00	0.0	4.810	0.051	46	13	4	4
PL.55199	PL.55201	B	6 A (CWC)	7.50Y	125.0	0.00	-0.04	0.00	0	0	0	100	0.00	0.0	4.863	0.053	0	0	0	0
PL.33634	PL.34300	B	#4 ACSR	7.51Y	125.1	0.00	-0.12	0.00	0	0	0	100	0.00	0.0	4.618	0.057	0	0	0	0
PL.34210	PL.34209	C	#4 ACSR	7.11Y	118.5	0.00	6.46	0.58	0	4	1	97	0.00	0.0	3.885	0.000	0	0	0	1
PD.4925	PL.34210	C	50QA	7.11Y	118.5	0.00	6.46	0.58	1	4	1	97	0.00	0.0	3.885	0.000	0	0	0	1
PL.34211	PD.4925	C	#4 ACSR	7.11Y	118.5	0.00	6.47	0.58	0	4	1	97	0.00	0.0	3.938	0.053	4	1	1	1
PL.64850	PL.53664	A	#4 ACSR	7.11Y	118.6	0.00	6.44	12.68	10	87	24	96	0.00	0.0	3.864	0.001	0	0	0	16
PD.4910	PL.64850	A	50QA	7.11Y	118.6	0.00	6.44	12.68	25	87	24	96	0.00	0.0	3.864	0.001	0	0	0	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.53893	PD.4910	A	#4 ACSR	7.11Y	118.6	0.01	6.45	12.68	10	87	24	96	0.00	0.0	3.874	0.010	3	1	3	16
PL.53892	PL.53893	A	#4 ACSR	7.11Y	118.5	0.04	6.49	12.20	9	84	23	96	0.03	0.0	3.958	0.084	3	1	2	13
PL.33422	PL.53892	A	#4 ACSR	7.11Y	118.5	0.03	6.53	11.81	9	81	22	97	0.02	0.0	4.021	0.064	0	0	0	11
PL.33426	PL.33422	A	#4 ACSR	7.11Y	118.5	0.00	6.53	1.29	1	9	2	98	0.00	0.0	4.045	0.024	9	2	2	2
PL.53886	PL.33422	A	#4 ACSR	7.11Y	118.5	0.01	6.53	3.47	3	24	6	97	0.00	0.0	4.112	0.091	24	6	3	3
PL.33421	PL.33422	A	#4 ACSR	7.11Y	118.5	0.02	6.54	7.06	5	48	13	97	0.01	0.0	4.084	0.063	0	0	0	6
PL.53972	PL.33421	A	#4 ACSR	7.11Y	118.5	0.00	6.55	6.21	5	43	12	96	0.00	0.0	4.110	0.025	29	8	3	5
PL.53993	PL.53972	A	#4 ACSR	7.11Y	118.4	0.00	6.55	1.97	2	14	4	96	0.00	0.0	4.207	0.097	14	4	2	2
PL.53973	PL.53972	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.00	0	0	0	100	0.00	0.0	4.132	0.023	0	0	0	0
PL.33586	PL.33421	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.85	1	6	2	95	0.00	0.0	4.141	0.057	0	0	0	1
PL.33587	PL.33586	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.85	1	6	2	95	0.00	0.0	4.226	0.085	6	2	1	1
PL.33255	PL.33587	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.00	0	0	0	100	0.00	0.0	4.289	0.063	0	0	0	0
PL.62693	PL.33587	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.00	0	0	0	100	0.00	0.0	4.264	0.037	0	0	0	0
PL.62694	PL.62693	A	#4 ACSR	7.11Y	118.5	0.00	6.55	0.00	0	0	0	100	0.00	0.0	4.325	0.061	0	0	0	0
PL.53665	PL.53950	B	#2 ACSR	7.12Y	118.7	0.00	6.35	0.47	0	3	1	95	0.00	0.0	3.784	0.002	0	0	0	2
PD.8113	PL.53665	B	15QA	7.12Y	118.7	0.00	6.35	0.47	0	3	1	95	0.00	0.0	3.784	0.002	0	0	0	2
PL.53878	PD.8113	B	#2 ACSR	7.12Y	118.7	0.00	6.35	0.47	0	3	1	95	0.00	0.0	3.791	0.008	2	1	1	2
PL.53877	PL.53878	B	#2 ACSR	7.12Y	118.7	0.00	6.35	0.19	0	1	0	100	0.00	0.0	3.816	0.025	1	0	1	1
PL.53666	PL.53950	B	#1/0 ACSR	7.12Y	118.7	0.00	6.35	0.91	0	6	2	95	0.00	0.0	3.784	0.003	0	0	0	2
PD.8114	PL.53666	B	15QA	7.12Y	118.7	0.00	6.35	0.91	0	6	2	95	0.00	0.0	3.784	0.003	0	0	0	2
PL.56756	PD.8114	B	#1/0 ACSR	7.12Y	118.7	0.00	6.35	0.91	0	6	2	95	0.00	0.0	3.832	0.047	6	2	2	2
PL.33518	PL.33462	A	6 A (CWC)	7.12Y	118.7	0.00	6.27	2.12	2	15	4	97	0.00	0.0	3.758	0.045	15	4	3	3
PL.33214	PL.34207	C	6 A (CWC)	7.13Y	118.8	0.00	6.17	5.22	4	36	10	96	0.00	0.0	3.625	0.001	0	0	0	7
PD.4907	PL.33214	C	50QA	7.13Y	118.8	0.00	6.17	5.22	10	36	10	96	0.00	0.0	3.625	0.001	0	0	0	7
PL.33215	PD.4907	C	6 A (CWC)	7.13Y	118.8	0.00	6.17	5.22	4	36	10	96	0.00	0.0	3.640	0.015	16	4	3	7
PL.64870	PL.33215	C	6 A (CWC)	7.13Y	118.8	0.01	6.18	2.83	2	19	5	97	0.00	0.0	3.759	0.119	8	2	1	4
PL.33106	PL.64870	C	6 A (CWC)	7.13Y	118.8	0.00	6.18	1.65	1	11	3	96	0.00	0.0	3.800	0.041	8	2	1	3
PL.57881	PL.33106	C	6 A (CWC)	7.13Y	118.8	0.00	6.19	0.52	0	4	1	97	0.00	0.0	3.846	0.046	4	1	2	2
PL.33475	PL.33469	C	6 A (CWC)	7.14Y	119.0	0.00	5.99	0.82	1	6	2	95	0.00	0.0	3.478	0.000	0	0	0	2
PD.4906	PL.33475	C	50QA	7.14Y	119.0	0.00	5.99	0.82	2	6	2	95	0.00	0.0	3.478	0.000	0	0	0	2
PL.33315	PD.4906	C	6 A (CWC)	7.14Y	119.0	0.00	5.99	0.82	1	6	2	95	0.00	0.0	3.511	0.033	6	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.58878	PL.34184	ABC	#1/0 ACSR	7.16Y	119.4	0.00	5.60	0.00	0	0	0	100	0.00	0.0	3.196	0.008	0	0	0	0
PD.8482-B	PL.58878	ABC	Open	7.16Y	119.4	0.00	5.60	0.00	0	0	0	100	0.00	0.0	3.196	0.008	0	0	0	0
PL.34182	PL.34181	A	6 A (CWC)	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.042	0.001	0	0	0	1
PD.4975	PL.34182	A	50QA	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.042	0.001	0	0	0	1
PL.34183	PD.4975	A	6 A (CWC)	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.139	0.097	0	0	1	1
PL.33204	PL.34178	A	#4 ACSR	7.18Y	119.7	0.00	5.28	3.05	2	21	6	96	0.00	0.0	2.977	0.000	0	0	0	5
PD.4895	PL.33204	A	50QA	7.18Y	119.7	0.00	5.28	3.05	6	21	6	96	0.00	0.0	2.977	0.000	0	0	0	5
PL.33205	PD.4895	A	#4 ACSR	7.18Y	119.7	0.00	5.28	3.05	2	21	6	96	0.00	0.0	3.007	0.030	14	4	2	5
PL.34179	PL.33205	A	6 A (CWC)	7.18Y	119.7	0.00	5.28	0.96	1	7	2	96	0.00	0.0	3.065	0.057	4	1	2	3
PL.34180	PL.34179	A	6 A (CWC)	7.18Y	119.7	0.00	5.28	0.34	0	2	1	89	0.00	0.0	3.155	0.091	2	1	1	1
PL.34175	PL.33353	B	6 A (CWC)	7.20Y	120.0	0.00	4.95	2.18	2	15	4	97	0.00	0.0	2.768	0.001	0	0	0	3
PD.4939	PL.34175	B	50QA	7.20Y	120.0	0.00	4.95	2.18	4	15	4	97	0.00	0.0	2.768	0.001	0	0	0	3
PL.34176	PD.4939	B	6 A (CWC)	7.20Y	120.0	0.00	4.95	2.18	2	15	4	97	0.00	0.0	2.776	0.008	5	1	1	3
PL.33349	PL.34176	B	6 A (CWC)	7.20Y	120.0	0.01	4.96	1.50	1	10	3	96	0.00	0.0	2.885	0.109	6	2	1	2
PL.33350	PL.33349	B	6 A (CWC)	7.20Y	120.0	0.00	4.96	0.61	0	4	1	97	0.00	0.0	2.940	0.055	4	1	1	1
PL.55598	PL.59083	C	#4 ACSR	7.24Y	120.6	0.00	4.39	2.70	2	19	5	97	0.00	0.0	2.418	0.003	0	0	0	2
PD.8213	PL.55598	C	50QA	7.24Y	120.6	0.00	4.39	2.70	5	19	5	97	0.00	0.0	2.418	0.003	0	0	0	2
PL.55599	PD.8213	C	#4 ACSR	7.24Y	120.6	0.00	4.39	2.70	2	19	5	97	0.00	0.0	2.436	0.018	2	0	1	2
PL.62782	PL.55599	C	#1/0 ACSR	7.24Y	120.6	0.00	4.39	2.45	1	17	5	96	0.00	0.0	2.436	0.000	0	0	0	1
PL.62783	PL.62782	C	#1/0 ACSR	7.24Y	120.6	0.00	4.39	2.45	1	17	5	96	0.00	0.0	2.470	0.034	17	5	1	1
PL.55191	PL.55190	A	#4 ACSR	7.25Y	120.8	0.00	4.23	1.84	1	13	3	97	0.00	0.0	2.326	0.004	0	0	0	1
PD.8211	PL.55191	A	20T	7.25Y	120.8	0.00	4.23	1.84	0	13	3	97	0.00	0.0	2.326	0.004	0	0	0	1
PL.55597	PD.8211	A	#4 ACSR	7.25Y	120.8	0.00	4.24	1.84	1	13	3	97	0.00	0.0	2.384	0.058	13	3	1	1
PL.55188	PL.55187	B	6 A (CWC)	7.27Y	121.1	0.00	3.86	8.38	6	59	16	97	0.00	0.0	2.101	0.000	0	0	0	11
PD.4991	PL.55188	B	50QA	7.27Y	121.1	0.00	3.86	8.38	17	59	16	97	0.00	0.0	2.101	0.000	0	0	0	11
PL.33839	PD.4991	B	6 A (CWC)	7.27Y	121.1	0.01	3.87	8.38	6	59	16	97	0.00	0.0	2.118	0.016	0	0	0	11
PL.33546	PL.33839	B	#4 ACSR	7.27Y	121.1	0.00	3.87	0.58	0	4	1	97	0.00	0.0	2.154	0.037	0	0	0	1
PL.33547	PL.33546	B	#4 ACSR	7.27Y	121.1	0.00	3.87	0.58	0	4	1	97	0.00	0.0	2.177	0.023	4	1	1	1
PL.53770	PL.33839	B	6 A (CWC)	7.27Y	121.1	0.01	3.88	7.80	6	55	15	96	0.00	0.0	2.147	0.029	2	0	1	10
PL.53771	PL.53770	B	6 A (CWC)	7.27Y	121.1	0.01	3.89	7.55	5	53	14	97	0.00	0.0	2.179	0.033	0	0	0	9
PL.55588	PL.53771	B	6 A (CWC)	7.27Y	121.1	0.00	3.89	7.55	5	53	14	97	0.00	0.0	2.194	0.015	2	1	1	9

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55590	PL.55588	B	6 A (CWC)	7.27Y	121.1	0.02	3.91	7.21	5	51	14	96	0.01	0.0	2.253	0.059	0	0	0	7
PL.55592	PL.55590	B	#1/0 ACSR	7.27Y	121.1	0.00	3.91	1.48	1	10	3	96	0.00	0.0	2.270	0.017	10	3	1	1
PL.55591	PL.55590	B	6 A (CWC)	7.26Y	121.1	0.02	3.93	5.73	4	40	11	96	0.01	0.0	2.337	0.085	8	2	1	6
PL.55589	PL.55591	B	6 A (CWC)	7.26Y	121.1	0.01	3.94	4.54	3	32	9	96	0.00	0.0	2.391	0.053	0	0	0	5
PL.53818	PL.55589	B	#2 ACSR	7.26Y	121.1	0.00	3.94	2.82	2	20	5	97	0.00	0.0	2.425	0.034	20	5	2	2
PL.53819	PL.53818	B	#2 ACSR	7.26Y	121.1	0.00	3.94	0.00	0	0	0	100	0.00	0.0	2.449	0.024	0	0	0	0
PL.33570	PL.55589	B	6 A (CWC)	7.26Y	121.0	0.01	3.95	1.73	1	12	3	97	0.00	0.0	2.535	0.145	0	0	0	3
PL.53804	PL.33570	B	#1/0 ACSR	7.26Y	121.0	0.00	3.95	0.90	0	6	2	95	0.00	0.0	2.575	0.040	6	2	2	2
PL.33571	PL.33570	B	6 A (CWC)	7.26Y	121.0	0.00	3.95	0.00	0	0	0	100	0.00	0.0	2.590	0.054	0	0	0	0
PL.53814	PL.33570	B	6 A (CWC)	7.26Y	121.0	0.00	3.95	0.00	0	0	0	100	0.00	0.0	2.595	0.060	0	0	0	0
PL.53815	PL.53814	B	6 A (CWC)	7.26Y	121.0	0.00	3.95	0.00	0	0	0	100	0.00	0.0	2.631	0.035	0	0	0	0
PL.53908	PL.33570	B	#2 ACSR	7.26Y	121.0	0.00	3.95	0.83	0	6	2	95	0.00	0.0	2.561	0.026	6	2	1	1
PL.55587	PL.55588	B	6 A (CWC)	7.27Y	121.1	0.00	3.89	0.01	0	0	0	100	0.00	0.0	2.237	0.043	0	0	1	1
PL.33300	PL.53179	C	#4 ACSR	7.31Y	121.8	0.00	3.21	1.15	1	8	2	97	0.00	0.0	1.739	0.001	0	0	0	2
PD.4958	PL.33300	C	50QA	7.31Y	121.8	0.00	3.21	1.15	2	8	2	97	0.00	0.0	1.739	0.001	0	0	0	2
PL.53180	PD.4958	C	#4 ACSR	7.31Y	121.8	0.00	3.21	1.15	1	8	2	97	0.00	0.0	1.819	0.080	8	2	1	2
PL.53181	PL.53180	C	#4 ACSR	7.31Y	121.8	0.00	3.21	0.07	0	1	0	100	0.00	0.0	1.879	0.059	1	0	1	1
PL.55561	PL.55184	A	6 A (CWC)	7.33Y	122.1	0.00	2.90	1.22	1	9	2	98	0.00	0.0	1.570	0.003	0	0	0	3
PD.8203	PL.55561	A	50QA	7.33Y	122.1	0.00	2.90	1.22	2	9	2	98	0.00	0.0	1.570	0.003	0	0	0	3
PL.55562	PD.8203	A	6 A (CWC)	7.33Y	122.1	0.01	2.90	1.22	1	9	2	98	0.00	0.0	1.664	0.093	0	0	0	3
PL.55563	PL.55562	A	6 A (CWC)	7.33Y	122.1	0.00	2.90	1.22	1	9	2	98	0.00	0.0	1.716	0.053	9	2	1	3
PL.53178	PL.55563	A	6 A (CWC)	7.33Y	122.1	0.00	2.90	0.01	0	0	0	100	0.00	0.0	1.747	0.031	0	0	0	2
PL.53177	PL.53178	A	6 A (CWC)	7.33Y	122.1	0.00	2.90	0.01	0	0	0	100	0.00	0.0	1.791	0.044	0	0	1	1
PL.61204	PL.53178	A	#1/0 ACSR	7.33Y	122.1	0.00	2.90	0.00	0	0	0	100	0.00	0.0	1.903	0.156	0	0	1	1
PL.55559	PL.55557	C	#4 ACSR	7.34Y	122.3	0.00	2.65	2.54	2	18	5	96	0.00	0.0	1.441	0.005	0	0	0	5
PD.8202	PL.55559	C	50QA	7.34Y	122.3	0.00	2.65	2.54	5	18	5	96	0.00	0.0	1.441	0.005	0	0	0	5
PL.55560	PD.8202	C	#4 ACSR	7.34Y	122.3	0.01	2.66	2.54	2	18	5	96	0.00	0.0	1.508	0.067	10	3	3	5
PL.55558	PL.55560	C	#4 ACSR	7.34Y	122.3	0.00	2.66	1.18	1	8	2	97	0.00	0.0	1.561	0.053	8	2	2	2
PL.55551	PL.55550	C	#4 ACSR	7.35Y	122.6	0.00	2.44	1.99	2	14	4	96	0.00	0.0	1.326	0.003	0	0	0	1
PD.8200	PL.55551	C	50QA	7.35Y	122.6	0.00	2.44	1.99	4	14	4	96	0.00	0.0	1.326	0.003	0	0	0	1
PL.55549	PD.8200	C	#4 ACSR	7.35Y	122.6	0.00	2.44	1.99	2	14	4	96	0.00	0.0	1.377	0.052	14	4	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33635	PL.63856	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	0.71	1	5	1	98	0.00	0.0	1.255	0.172	5	1	2	2
PL.63857	PL.63858	ABC	#3/0 ACSR	7.40Y	123.3	0.04	1.69	89.65	30	1914	547	96	0.46	0.0	0.951	0.034	0	0	0	279
PL.63851	PL.63857	ABC	#3/0 ACSR	7.38Y	123.0	0.30	1.99	89.65	30	1914	546	96	3.55	0.2	1.215	0.264	3	1	1	279
PL.34315	PL.63851	ABC	#3/0 ACSR	7.38Y	123.0	0.05	2.03	89.51	30	1907	540	96	0.56	0.0	1.257	0.042	3	1	1	278
PL.34319	PL.34315	ABC	#3/0 ACSR	7.37Y	122.8	0.13	2.17	89.39	30	1904	539	96	1.59	0.1	1.375	0.119	0	0	0	277
PL.34316	PL.34319	ABC	#3/0 ACSR	7.37Y	122.8	0.07	2.23	88.07	29	1874	529	96	0.78	0.0	1.435	0.060	0	0	0	269
PL.34317	PL.34316	ABC	#3/0 ACSR	7.36Y	122.6	0.13	2.37	88.07	29	1873	528	96	1.57	0.1	1.556	0.121	0	0	0	269
PL.34318	PL.34317	ABC	#3/0 ACSR	7.35Y	122.6	0.06	2.43	87.81	29	1866	524	96	0.71	0.0	1.611	0.055	0	0	0	268
PL.33324	PL.34318	C	#4 ACSR	7.35Y	122.6	0.00	2.43	1.36	1	10	3	96	0.00	0.0	1.611	0.001	0	0	0	2
PD.4959	PL.33324	C	75QA	7.35Y	122.6	0.00	2.43	1.36	2	10	3	96	0.00	0.0	1.611	0.001	0	0	0	2
PL.53174	PD.4959	C	#4 ACSR	7.35Y	122.6	0.00	2.43	1.36	1	10	3	96	0.00	0.0	1.684	0.073	0	0	0	2
PL.53175	PL.53174	C	#4 ACSR	7.35Y	122.6	0.00	2.44	1.36	1	10	3	96	0.00	0.0	1.720	0.036	10	3	2	2
PL.33815	PL.34318	ABC	#3/0 ACSR	7.35Y	122.5	0.08	2.51	87.35	29	1856	520	96	0.92	0.0	1.683	0.072	0	0	0	266
PL.33325	PL.33815	ABC	#3/0 ACSR	7.35Y	122.5	0.00	2.51	87.35	29	1855	519	96	0.01	0.0	1.684	0.001	0	0	0	266
PD.4943	PL.33325	ABC	140L	7.35Y	122.5	0.00	2.51	87.35	62	1855	519	96	0.00	0.0	1.684	0.001	0	0	0	266
PL.61192	PD.4943	ABC	#3/0 ACSR	7.35Y	122.4	0.06	2.57	87.35	29	1855	519	96	0.65	0.0	1.735	0.051	0	0	0	266
PL.61193	PL.61192	ABC	#3/0 ACSR	7.34Y	122.3	0.16	2.72	87.24	29	1852	517	96	1.82	0.1	1.877	0.143	0	0	0	265
RG.37	PL.61193	ABC	114.3 KVA	7.48Y	124.6	-2.34	0.39	87.24	58	1850	515	96	percent Boost= 1.88 Tap= 3.0						265	
PL.33451	RG.37	ABC	#3/0 ACSR	7.48Y	124.6	0.00	0.39	85.61	29	1850	515	96	0.00	0.0	1.877	0.000	0	0	0	265
PL.59100	PL.33451	ABC	#3/0 ACSR	7.47Y	124.5	0.15	0.53	85.61	29	1850	515	96	1.65	0.1	2.013	0.136	32	9	3	265
PL.59101	PL.59100	ABC	#3/0 ACSR	7.47Y	124.4	0.03	0.56	65.96	22	1424	396	96	0.27	0.0	2.050	0.037	14	4	1	205
PL.33446	PL.59101	ABC	#3/0 ACSR	7.46Y	124.4	0.04	0.60	65.31	22	1409	391	96	0.31	0.0	2.093	0.043	0	0	0	204
PL.33326	PL.33446	ABC	#3/0 ACSR	7.46Y	124.4	0.00	0.60	65.31	22	1409	391	96	0.02	0.0	2.096	0.003	0	0	0	204
PL.33327	PL.33326	ABC	#3/0 ACSR	7.46Y	124.4	0.01	0.61	65.31	22	1409	391	96	0.05	0.0	2.104	0.008	1	0	1	204
PL.33328	PL.33327	ABC	#3/0 ACSR	7.46Y	124.3	0.07	0.67	65.27	22	1408	391	96	0.59	0.0	2.186	0.082	0	0	0	203
PL.34334	PL.33328	B	6 A (CWC)	7.46Y	124.3	0.00	0.68	10.53	8	76	21	96	0.00	0.0	2.189	0.003	0	0	0	11
PD.4945	PL.34334	B	50L	7.46Y	124.3	0.00	0.68	10.53	21	76	21	96	0.00	0.0	2.189	0.003	0	0	0	11
PL.34335	PD.4945	B	6 A (CWC)	7.46Y	124.3	0.01	0.69	10.53	8	76	21	96	0.01	0.0	2.216	0.027	10	3	1	11
PL.33151	PL.34335	B	6 A (CWC)	7.46Y	124.3	0.01	0.69	9.21	7	66	18	96	0.00	0.0	2.228	0.012	0	0	0	10
PD.4950-A	PL.33151	B	Closed	7.46Y	124.3	0.00	0.69	9.21	0	66	18	96	0.00	0.0	2.228	0.012	0	0	0	10
PD.4950-B	PD.4950-A	B	Closed	7.46Y	124.3	0.00	0.69	9.21	0	66	18	96	0.00	0.0	2.228	0.012	0	0	0	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.34173	PD.4950-B	B	6 A (CWC)	7.45Y	124.1	0.22	0.92	9.21	7	66	18	96	0.11	0.2	2.754	0.526	0	0	0	10
PL.34033	PL.34173	B	6 A (CWC)	7.44Y	124.0	0.06	0.97	8.73	6	63	17	97	0.03	0.0	2.895	0.141	0	0	0	9
PL.34034	PL.34033	B	#4 ACSR	7.44Y	124.0	0.00	0.97	0.01	0	0	0	100	0.00	0.0	3.108	0.213	0	0	0	1
PL.33332	PL.34034	B	#4 ACSR	7.44Y	124.0	0.00	0.97	0.01	0	0	0	100	0.00	0.0	3.198	0.090	0	0	1	1
PL.34032	PL.34033	B	6 A (CWC)	7.44Y	123.9	0.09	1.06	8.71	6	63	17	97	0.04	0.1	3.114	0.219	0	0	0	8
PL.55544	PL.34032	B	6 A (CWC)	7.44Y	123.9	0.02	1.07	5.42	4	39	11	96	0.00	0.0	3.175	0.062	0	0	0	4
PL.55543	PL.55544	B	6 A (CWC)	7.44Y	123.9	0.01	1.08	5.42	4	39	11	96	0.00	0.0	3.210	0.034	0	0	0	4
PL.33428	PL.55543	B	6 A (CWC)	7.44Y	123.9	0.00	1.08	1.14	1	8	2	97	0.00	0.0	3.242	0.032	8	2	1	1
PL.64435	PL.55543	B	6 A (CWC)	7.43Y	123.9	0.03	1.11	4.29	3	31	8	97	0.01	0.0	3.341	0.132	0	0	0	3
PL.64436	PL.64435	B	6 A (CWC)	7.43Y	123.9	0.00	1.11	1.10	1	8	2	97	0.00	0.0	3.367	0.025	8	2	1	1
PL.64437	PL.64435	B	#1/0 ACSR	7.43Y	123.9	0.01	1.11	3.19	1	23	6	97	0.00	0.0	3.410	0.068	0	0	0	2
PL.64438	PL.64437	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	1.49	1	11	3	96	0.00	0.0	3.467	0.057	11	3	1	1
PL.64439	PL.64437	B	#1/0 ACSR	7.43Y	123.9	0.00	1.11	1.69	1	12	3	97	0.00	0.0	3.509	0.099	12	3	1	1
PL.33516	PL.34032	B	6 A (CWC)	7.44Y	123.9	0.01	1.07	3.29	2	24	6	97	0.00	0.0	3.198	0.084	14	4	2	4
PL.33184	PL.33516	B	#4 ACSR	7.44Y	123.9	0.00	1.07	1.30	1	9	3	95	0.00	0.0	3.238	0.040	9	2	1	2
PL.33185	PL.33184	B	#4 ACSR	7.44Y	123.9	0.00	1.07	0.02	0	0	0	100	0.00	0.0	3.285	0.047	0	0	1	1
PL.33417	PL.33516	B	6 A (CWC)	7.44Y	123.9	0.00	1.07	0.00	0	0	0	100	0.00	0.0	3.206	0.008	0	0	0	0
PD.4952-A	PL.33417	B	Open	7.44Y	123.9	0.00	1.07	0.00	0	0	0	100	0.00	0.0	3.206	0.008	0	0	0	0
PL.34174	PL.34173	B	6 A (CWC)	7.45Y	124.1	0.00	0.92	0.49	0	4	1	97	0.00	0.0	2.859	0.104	4	1	1	1
PL.33861	PL.34174	B	6 A (CWC)	7.45Y	124.1	0.00	0.92	0.00	0	0	0	100	0.00	0.0	3.071	0.212	0	0	0	0
PL.34336	PL.33328	ABC	#3/0 ACSR	7.46Y	124.3	0.07	0.75	61.76	21	1332	369	96	0.62	0.0	2.282	0.096	0	0	0	192
PL.53422	PL.34336	ABC	#3/0 ACSR	7.45Y	124.2	0.08	0.83	61.22	20	1320	365	96	0.63	0.0	2.381	0.100	5	1	1	191
PL.53423	PL.53422	ABC	#3/0 ACSR	7.45Y	124.1	0.06	0.88	61.01	20	1314	363	96	0.46	0.0	2.455	0.074	5	1	1	190
PL.33560	PL.53423	ABC	#3/0 ACSR	7.44Y	124.0	0.08	0.96	60.79	20	1309	361	96	0.63	0.0	2.557	0.101	8	2	1	189
PL.33142	PL.33560	A	6 A (CWC)	7.44Y	124.0	0.00	0.96	1.00	1	7	2	96	0.00	0.0	2.557	0.001	0	0	0	2
PD.4968	PL.33142	A	50QA	7.44Y	124.0	0.00	0.96	1.00	2	7	2	96	0.00	0.0	2.557	0.001	0	0	0	2
PL.53420	PD.4968	A	6 A (CWC)	7.44Y	124.0	0.00	0.96	1.00	1	7	2	96	0.00	0.0	2.639	0.081	7	2	1	2
PL.53421	PL.53420	A	#2 ACSR	7.44Y	124.0	0.00	0.96	0.03	0	0	0	100	0.00	0.0	2.721	0.082	0	0	1	1
PL.33157	PL.33560	ABC	#3/0 ACSR	7.44Y	124.0	0.04	1.00	60.09	20	1293	356	96	0.30	0.0	2.606	0.049	0	0	0	186
PL.33561	PL.33157	ABC	#3/0 ACSR	7.43Y	123.9	0.09	1.09	60.08	20	1293	356	96	0.76	0.1	2.731	0.126	3	1	1	185
PL.53530	PL.33561	ABC	#3/0 ACSR	7.43Y	123.8	0.07	1.16	59.94	20	1289	354	96	0.56	0.0	2.824	0.093	7	2	2	184

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.53531	PL.53530	ABC	#3/0 ACSR	7.43Y	123.8	0.08	1.24	59.60	20	1281	351	96	0.62	0.0	2.929	0.104	2	0	1	182
PL.33562	PL.53531	ABC	#3/0 ACSR	7.42Y	123.7	0.05	1.29	59.53	20	1279	350	96	0.36	0.0	2.990	0.061	0	0	0	181
PL.33563	PL.33562	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.10	0	1	0	100	0.00	0.0	2.993	0.003	0	0	0	2
PD.5005	PL.33563	C	50QA	7.42Y	123.7	0.00	1.29	0.10	0	1	0	100	0.00	0.0	2.993	0.003	0	0	0	2
PL.33564	PD.5005	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.10	0	1	0	100	0.00	0.0	3.211	0.219	1	0	2	2
PL.33166	PL.33562	ABC	#4 ACSR	7.42Y	123.7	0.03	1.32	21.92	17	471	128	96	0.13	0.0	3.031	0.041	0	0	0	63
PL.33645	PL.33166	ABC	#4 ACSR	7.42Y	123.7	0.00	1.32	21.92	17	471	128	96	0.00	0.0	3.031	0.000	0	0	0	63
PD.4946	PL.33645	ABC	35L	7.42Y	123.7	0.00	1.32	21.92	63	471	128	96	0.00	0.0	3.031	0.000	0	0	0	63
PL.33565	PD.4946	ABC	#4 ACSR	7.42Y	123.6	0.06	1.38	21.92	17	471	128	96	0.23	0.0	3.105	0.074	0	0	0	63
PL.33566	PL.33565	ABC	#4 ACSR	7.41Y	123.6	0.05	1.44	21.92	17	471	128	96	0.20	0.0	3.169	0.064	0	0	0	63
PL.33567	PL.33566	ABC	#4 ACSR	7.41Y	123.5	0.05	1.49	21.48	17	461	125	97	0.20	0.0	3.237	0.068	10	3	1	61
PL.33433	PL.33567	A	6 A (CWC)	7.41Y	123.5	0.00	1.49	7.46	5	53	14	97	0.00	0.0	3.242	0.005	0	0	0	5
PD.4961	PL.33433	A	40QA	7.41Y	123.5	0.00	1.49	7.46	19	53	14	97	0.00	0.0	3.242	0.005	0	0	0	5
PL.33646	PD.4961	A	6 A (CWC)	7.41Y	123.5	0.03	1.52	7.46	5	53	14	97	0.01	0.0	3.336	0.095	0	0	0	5
PL.62740	PL.33646	A	#4/0 ACSR	7.41Y	123.5	0.00	1.52	2.13	1	15	4	97	0.00	0.0	3.370	0.034	9	2	1	2
PL.62741	PL.62740	A	#4/0 ACSR	7.41Y	123.5	0.00	1.52	0.92	0	7	2	96	0.00	0.0	3.424	0.054	7	2	1	1
PL.33884	PL.33646	A	6 A (CWC)	7.41Y	123.5	0.01	1.54	5.33	4	38	10	97	0.00	0.0	3.410	0.074	15	4	1	3
PL.61222	PL.33884	A	6 A (CWC)	7.41Y	123.5	0.01	1.55	3.25	2	23	6	97	0.00	0.0	3.483	0.073	12	3	1	2
PL.61223	PL.61222	A	6 A (CWC)	7.41Y	123.5	0.00	1.55	1.57	1	11	3	96	0.00	0.0	3.507	0.023	11	3	1	1
PL.53583	PL.33567	ABC	#4 ACSR	7.39Y	123.2	0.30	1.79	18.54	14	398	108	97	0.93	0.2	3.657	0.420	0	0	0	55
PL.53584	PL.53583	ABC	#4 ACSR	7.39Y	123.1	0.11	1.90	18.07	14	387	105	97	0.35	0.1	3.823	0.166	0	0	0	54
PL.55574	PL.53584	B	#4 ACSR	7.39Y	123.1	0.00	1.90	2.75	2	20	5	97	0.00	0.0	3.826	0.003	0	0	0	3
PD.8207	PL.55574	B	40QA	7.39Y	123.1	0.00	1.90	2.75	7	20	5	97	0.00	0.0	3.826	0.003	0	0	0	3
PL.55575	PD.8207	B	#4 ACSR	7.39Y	123.1	0.00	1.90	2.75	2	20	5	97	0.00	0.0	3.842	0.016	1	0	1	3
PL.55573	PL.55575	B	#4 ACSR	7.38Y	123.1	0.03	1.93	2.62	2	19	5	97	0.00	0.0	4.117	0.275	0	0	0	2
PL.53580	PL.55573	B	#4 ACSR	7.38Y	123.1	0.00	1.93	0.90	1	6	2	95	0.00	0.0	4.150	0.033	6	2	1	1
PL.55576	PL.55573	B	#4 ACSR	7.38Y	123.1	0.01	1.95	1.72	1	12	3	97	0.00	0.0	4.284	0.167	0	0	0	1
PL.55577	PL.55576	B	#4 ACSR	7.38Y	123.0	0.01	1.95	1.72	1	12	3	97	0.00	0.0	4.417	0.132	12	3	1	1
PL.55570	PL.53584	ABC	#4 ACSR	7.38Y	123.1	0.02	1.92	17.15	13	367	99	97	0.07	0.0	3.859	0.036	1	0	1	51
PL.55571	PL.55570	B	#4 ACSR	7.38Y	123.1	0.00	1.92	3.62	3	26	7	97	0.00	0.0	3.862	0.003	0	0	0	2
PD.8206	PL.55571	B	40QA	7.38Y	123.1	0.00	1.92	3.62	9	26	7	97	0.00	0.0	3.862	0.003	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55568	PD.8206	B	#4 ACSR	7.38Y	123.1	0.00	1.93	3.62	3	26	7	97	0.00	0.0	3.902	0.040	17	5	1	2
PL.55569	PL.55568	B	#4 ACSR	7.38Y	123.1	0.00	1.93	1.23	1	9	2	98	0.00	0.0	3.974	0.071	9	2	1	1
PL.55572	PL.55570	ABC	#4 ACSR	7.38Y	123.0	0.07	2.00	15.91	12	340	92	97	0.20	0.1	3.980	0.121	0	0	0	48
PL.62517	PL.55572	C	#1/0 ACSR	7.38Y	123.0	0.00	2.00	1.21	1	9	2	98	0.00	0.0	3.984	0.003	0	0	0	2
PD.9374	PL.62517	C	25T	7.38Y	123.0	0.00	2.00	1.21	0	9	2	98	0.00	0.0	3.984	0.003	0	0	0	2
PL.62518	PD.9374	C	#1/0 ACSR	7.38Y	123.0	0.00	2.00	1.21	1	9	2	98	0.00	0.0	4.072	0.089	0	0	1	2
PL.57863	PL.62518	C	#1/0 ACSR	7.38Y	123.0	0.00	2.00	1.21	1	9	2	98	0.00	0.0	4.117	0.044	9	2	1	1
PL.53581	PL.55572	ABC	#4 ACSR	7.38Y	123.0	0.05	2.04	15.51	12	331	90	96	0.12	0.0	4.058	0.077	0	0	0	46
PL.33434	PL.53581	ABC	#4 ACSR	7.37Y	122.9	0.07	2.11	15.40	12	329	89	97	0.19	0.1	4.179	0.122	0	0	0	45
PL.55253	PL.33434	B	#4 ACSR	7.37Y	122.9	0.00	2.11	0.88	1	6	2	95	0.00	0.0	4.183	0.004	0	0	0	2
PD.8181	PL.55253	B	40QA	7.37Y	122.9	0.00	2.11	0.88	2	6	2	95	0.00	0.0	4.183	0.004	0	0	0	2
PL.55254	PD.8181	B	#4 ACSR	7.37Y	122.9	0.00	2.11	0.88	1	6	2	95	0.00	0.0	4.234	0.051	6	2	2	2
PL.55256	PL.33434	ABC	#4 ACSR	7.37Y	122.9	0.03	2.14	15.11	12	323	87	97	0.08	0.0	4.236	0.057	0	0	0	43
PL.55257	PL.55256	C	#1/0 ACSR	7.37Y	122.9	0.00	2.14	0.45	0	3	1	95	0.00	0.0	4.241	0.004	0	0	0	1
PD.8182	PL.55257	C	20QA	7.37Y	122.9	0.00	2.14	0.45	2	3	1	95	0.00	0.0	4.241	0.004	0	0	0	1
PL.55258	PD.8182	C	#1/0 ACSR	7.37Y	122.9	0.00	2.15	0.45	0	3	1	95	0.00	0.0	4.263	0.022	3	1	1	1
PL.55255	PL.55256	ABC	#4 ACSR	7.37Y	122.8	0.05	2.20	14.96	12	319	86	97	0.14	0.0	4.330	0.094	0	0	0	42
PL.55260	PL.55255	B	#4 ACSR	7.37Y	122.8	0.00	2.20	1.27	1	9	2	98	0.00	0.0	4.334	0.004	0	0	0	2
PD.8183	PL.55260	B	20T	7.37Y	122.8	0.00	2.20	1.27	0	9	2	98	0.00	0.0	4.334	0.004	0	0	0	2
PL.55261	PD.8183	B	#4 ACSR	7.37Y	122.8	0.00	2.20	1.27	1	9	2	98	0.00	0.0	4.361	0.027	7	2	1	2
PL.55259	PL.55261	B	#4 ACSR	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	4.394	0.033	0	0	0	0
PL.55262	PL.55261	B	#4 ACSR	7.37Y	122.8	0.00	2.20	0.34	0	2	1	89	0.00	0.0	4.535	0.174	2	1	1	1
PL.64337	PL.55255	ABC	#4 ACSR	7.36Y	122.7	0.10	2.30	14.53	11	310	84	97	0.24	0.1	4.509	0.179	6	2	1	40
PL.64338	PL.64337	ABC	#4 ACSR	7.36Y	122.7	0.00	2.30	14.24	11	304	82	97	0.00	0.0	4.509	0.000	0	0	0	39
PL.64336	PL.64338	ABC	#4 ACSR	7.35Y	122.6	0.14	2.44	14.24	11	304	82	97	0.34	0.1	4.767	0.258	0	0	0	39
PL.33141	PL.64336	ABC	#4 ACSR	7.34Y	122.4	0.16	2.60	14.24	11	303	82	97	0.39	0.1	5.065	0.297	0	0	0	39
PL.55274	PL.33141	A	#4 ACSR	7.34Y	122.4	0.00	2.60	1.41	1	10	3	96	0.00	0.0	5.068	0.004	0	0	0	1
PD.8186	PL.55274	A	40QA	7.34Y	122.4	0.00	2.60	1.41	4	10	3	96	0.00	0.0	5.068	0.004	0	0	0	1
PL.55275	PD.8186	A	#4 ACSR	7.34Y	122.4	0.00	2.60	1.41	1	10	3	96	0.00	0.0	5.101	0.033	10	3	1	1
PL.55278	PL.33141	B	6 A (CWC)	7.34Y	122.4	0.00	2.60	30.88	22	219	59	97	0.01	0.0	5.068	0.003	0	0	0	26
PD.8187	PL.55278	B	50QA	7.34Y	122.4	0.00	2.60	30.88	62	219	59	97	0.00	0.0	5.068	0.003	0	0	0	26

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55276	PD.8187	B	6 A (CWC)	7.34Y	122.4	0.04	2.64	30.88	22	219	59	97	0.07	0.0	5.099	0.031	6	2	1	26
PL.55277	PL.55276	B	6 A (CWC)	7.34Y	122.3	0.05	2.69	30.02	21	213	58	96	0.07	0.0	5.133	0.034	0	0	0	25
PL.33450	PL.55277	B	6 A (CWC)	7.34Y	122.3	0.00	2.69	1.35	1	10	3	96	0.00	0.0	5.167	0.035	10	3	1	1
PL.33542	PL.55277	B	6 A (CWC)	7.33Y	122.2	0.06	2.75	28.67	20	203	55	97	0.09	0.0	5.181	0.048	15	4	1	24
PL.55141	PL.33542	B	6 A (CWC)	7.33Y	122.2	0.04	2.79	12.80	9	91	25	96	0.03	0.0	5.253	0.073	7	2	1	14
PL.62760	PL.55141	B	6 A (CWC)	7.33Y	122.2	0.01	2.81	9.19	7	65	18	96	0.01	0.0	5.291	0.038	8	2	1	11
PL.62761	PL.62760	B	6 A (CWC)	7.33Y	122.1	0.05	2.85	8.06	6	57	15	97	0.02	0.0	5.418	0.127	0	0	0	10
PL.55145	PL.62761	B	#1/0 ACSR	7.33Y	122.1	0.00	2.86	2.78	1	20	5	97	0.00	0.0	5.463	0.045	0	0	0	3
PL.55146	PL.55145	B	#1/0 ACSR	7.33Y	122.1	0.00	2.86	1.00	0	7	2	96	0.00	0.0	5.498	0.035	7	2	1	1
PL.55147	PL.55145	B	#1/0 ACSR	7.33Y	122.1	0.00	2.86	1.79	1	13	3	97	0.00	0.0	5.480	0.017	13	3	2	2
PL.55144	PL.62761	B	6 A (CWC)	7.33Y	122.1	0.02	2.87	5.28	4	37	10	97	0.00	0.0	5.503	0.084	12	3	2	7
PL.55288	PL.55144	B	6 A (CWC)	7.33Y	122.1	0.02	2.89	3.53	3	25	7	96	0.00	0.0	5.624	0.121	3	1	1	5
PL.55289	PL.55288	B	6 A (CWC)	7.33Y	122.1	0.01	2.90	3.16	2	22	6	96	0.00	0.0	5.748	0.124	8	2	2	4
PL.55291	PL.55289	B	6 A (CWC)	7.33Y	122.1	0.00	2.91	1.53	1	11	3	96	0.00	0.0	5.879	0.131	11	3	1	1
PL.55290	PL.55289	B	#1/0 ACSR	7.33Y	122.1	0.00	2.90	0.49	0	3	1	95	0.00	0.0	5.823	0.075	3	1	1	1
PL.55287	PL.55288	B	6 A (CWC)	7.33Y	122.1	0.00	2.89	0.00	0	0	0	100	0.00	0.0	5.819	0.195	0	0	0	0
PL.55142	PL.55141	B	6 A (CWC)	7.33Y	122.2	0.01	2.80	2.55	2	18	5	96	0.00	0.0	5.308	0.055	8	2	1	2
PL.55143	PL.55142	B	6 A (CWC)	7.33Y	122.2	0.00	2.80	1.48	1	10	3	96	0.00	0.0	5.398	0.090	10	3	1	1
PL.55279	PL.33542	B	6 A (CWC)	7.33Y	122.2	0.03	2.79	13.73	10	97	26	97	0.02	0.0	5.241	0.060	15	4	2	9
PL.55280	PL.55279	B	6 A (CWC)	7.33Y	122.2	0.04	2.82	11.68	8	83	22	97	0.02	0.0	5.308	0.067	0	0	0	7
PL.55282	PL.55280	B	6 A (CWC)	7.33Y	122.2	0.02	2.84	11.68	8	83	22	97	0.01	0.0	5.352	0.044	15	4	1	7
PL.55281	PL.55282	B	#1/0 ACSR	7.33Y	122.2	0.00	2.84	0.89	0	6	2	95	0.00	0.0	5.416	0.064	6	2	1	1
PL.55283	PL.55282	B	6 A (CWC)	7.33Y	122.1	0.05	2.89	8.64	6	61	17	96	0.02	0.0	5.468	0.116	0	0	0	5
PL.55284	PL.55283	B	6 A (CWC)	7.33Y	122.1	0.03	2.91	8.64	6	61	17	96	0.01	0.0	5.535	0.068	0	0	0	5
PL.55286	PL.55284	B	6 A (CWC)	7.32Y	122.1	0.01	2.92	6.88	5	49	13	97	0.00	0.0	5.571	0.035	14	4	1	4
PL.64587	PL.55286	B	6 A (CWC)	7.32Y	122.1	0.01	2.94	4.94	4	35	9	97	0.00	0.0	5.638	0.067	5	1	1	3
PL.64588	PL.64587	B	6 A (CWC)	7.32Y	122.0	0.01	2.95	4.20	3	30	8	97	0.00	0.0	5.726	0.088	8	2	1	2
PL.63965	PL.64588	B	#1/0 ACSR	7.32Y	122.0	0.00	2.96	3.09	1	22	6	96	0.00	0.0	5.791	0.066	22	6	1	1
PL.55285	PL.55284	B	#2 ACSR	7.33Y	122.1	0.00	2.92	1.76	1	12	3	97	0.00	0.0	5.563	0.028	12	3	1	1
PL.34386	PL.33141	ABC	#4 ACSR	7.34Y	122.4	0.02	2.62	3.47	3	74	20	97	0.01	0.0	5.222	0.158	0	0	0	12
PL.33186	PL.34386	ABC	#4 ACSR	7.34Y	122.4	0.01	2.62	3.01	2	64	17	97	0.00	0.0	5.281	0.059	0	0	1	11

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.34387	PL.33186	ABC	#4 ACSR	7.34Y	122.4	0.02	2.65	3.00	2	64	17	97	0.01	0.0	5.477	0.196	0	0	0	10
PL.64855	PL.34387	ABC	#4 ACSR	7.34Y	122.3	0.01	2.65	2.02	2	43	12	96	0.00	0.0	5.560	0.082	0	0	0	7
PL.64857	PL.64855	B	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	5.562	0.003	0	0	0	0
PD.4988	PL.64857	B	40QA	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	5.562	0.003	0	0	0	0
PL.55269	PD.4988	B	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	5.618	0.056	0	0	0	0
PL.64856	PL.64855	ABC	#4 ACSR	7.34Y	122.3	0.01	2.66	2.02	2	43	12	96	0.00	0.0	5.688	0.128	0	0	0	7
PL.45005	PL.64856	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.753	0.065	0	0	0	0
PL.45147	PL.45005	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.825	0.072	0	0	0	0
PL.45004	PL.45147	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.894	0.070	0	0	0	0
PL.45003	PL.45004	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.925	0.031	0	0	0	0
PL.45002	PL.45003	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.962	0.037	0	0	0	0
PL.44954	PL.45002	ABC	#4 ACSR	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.996	0.034	0	0	0	0
PD.4953-B	PL.44954	ABC	Open	7.34Y	122.3	0.00	2.66	0.00	0	0	0	100	0.00	0.0	5.996	0.034	0	0	0	0
PL.55266	PL.64856	B	6 A (CWC)	7.34Y	122.3	0.00	2.66	3.27	2	23	6	97	0.00	0.0	5.691	0.003	0	0	0	2
PD.8184	PL.55266	B	40QA	7.34Y	122.3	0.00	2.66	3.27	8	23	6	97	0.00	0.0	5.691	0.003	0	0	0	2
PL.55268	PD.8184	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	3.27	2	23	6	97	0.00	0.0	5.726	0.035	13	3	1	2
PL.55267	PL.55268	B	6 A (CWC)	7.34Y	122.3	0.01	2.67	1.45	1	10	3	96	0.00	0.0	5.887	0.161	10	3	1	1
PL.34389	PL.64856	B	6 A (CWC)	7.34Y	122.3	0.01	2.67	2.78	2	20	5	97	0.00	0.0	5.737	0.049	5	1	1	5
PL.34390	PL.34389	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.73	1	5	1	98	0.00	0.0	5.817	0.081	0	0	0	1
PL.55265	PL.34390	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.73	1	5	1	98	0.00	0.0	5.890	0.072	5	1	1	1
PL.33536	PL.34389	B	#4 ACSR	7.34Y	122.3	0.00	2.67	1.39	1	10	3	96	0.00	0.0	5.786	0.049	10	3	3	3
PL.34388	PL.34387	B	6 A (CWC)	7.34Y	122.4	0.00	2.65	2.95	2	21	6	96	0.00	0.0	5.482	0.004	0	0	0	3
PD.4963	PL.34388	B	40QA	7.34Y	122.4	0.00	2.65	2.95	7	21	6	96	0.00	0.0	5.482	0.004	0	0	0	3
PL.55270	PD.4963	B	6 A (CWC)	7.34Y	122.4	0.00	2.65	2.95	2	21	6	96	0.00	0.0	5.511	0.030	13	3	1	3
PL.55271	PL.55270	B	6 A (CWC)	7.34Y	122.3	0.00	2.65	1.14	1	8	2	97	0.00	0.0	5.572	0.061	8	2	2	2
PL.55272	PL.34386	B	6 A (CWC)	7.34Y	122.4	0.00	2.62	1.39	1	10	3	96	0.00	0.0	5.226	0.004	0	0	0	1
PD.8185	PL.55272	B	40QA	7.34Y	122.4	0.00	2.62	1.39	3	10	3	96	0.00	0.0	5.226	0.004	0	0	0	1
PL.55273	PD.8185	B	6 A (CWC)	7.34Y	122.4	0.00	2.62	1.39	1	10	3	96	0.00	0.0	5.271	0.045	10	3	1	1
PL.33468	PL.64336	B	6 A (CWC)	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	4.819	0.051	0	0	0	0
PD.4952-B	PL.33468	B	Open	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	4.819	0.051	0	0	0	0
PL.33435	PL.53581	B	#4 ACSR	7.38Y	123.0	0.00	2.04	0.32	0	2	1	89	0.00	0.0	4.059	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.4962	PL.33435	B	40QA	7.38Y	123.0	0.00	2.04	0.32	1	2	1	89	0.00	0.0	4.059	0.001	0	0	0	1
PL.33333	PD.4962	B	#4 ACSR	7.38Y	123.0	0.00	2.04	0.32	0	2	1	89	0.00	0.0	4.123	0.064	2	1	1	1
PL.53585	PL.53583	C	#1/0 ACSR	7.39Y	123.2	0.00	1.79	1.43	1	10	3	96	0.00	0.0	3.660	0.003	0	0	0	1
PD.7910	PL.53585	C	20QA	7.39Y	123.2	0.00	1.79	1.43	7	10	3	96	0.00	0.0	3.660	0.003	0	0	0	1
PL.53586	PD.7910	C	#1/0 ACSR	7.39Y	123.2	0.00	1.79	1.43	1	10	3	96	0.00	0.0	3.677	0.017	10	3	1	1
PL.33568	PL.33566	A	#4 ACSR	7.41Y	123.6	0.00	1.44	1.31	1	9	3	95	0.00	0.0	3.170	0.001	0	0	0	2
PD.4960	PL.33568	A	40QA	7.41Y	123.6	0.00	1.44	1.31	3	9	3	95	0.00	0.0	3.170	0.001	0	0	0	2
PL.33569	PD.4960	A	#4 ACSR	7.41Y	123.6	0.00	1.44	1.31	1	9	3	95	0.00	0.0	3.202	0.033	9	3	2	2
PL.33500	PL.33562	ABC	#3/0 ACSR	7.42Y	123.6	0.07	1.36	37.58	13	807	221	96	0.36	0.0	3.144	0.154	3	1	1	116
PL.33181	PL.33500	ABC	#3/0 ACSR	7.42Y	123.6	0.02	1.38	37.44	12	804	220	96	0.11	0.0	3.190	0.046	0	0	0	115
PL.33501	PL.33181	ABC	#3/0 ACSR	7.42Y	123.6	0.02	1.40	36.84	12	791	216	96	0.11	0.0	3.238	0.047	12	3	2	114
PL.34061	PL.33501	ABC	#3/0 ACSR	7.41Y	123.5	0.05	1.46	36.30	12	779	213	96	0.26	0.0	3.356	0.119	0	0	0	112
PL.34060	PL.34061	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	1.77	1	13	3	97	0.00	0.0	3.357	0.001	0	0	0	1
PD.4923	PL.34060	C	50QA	7.41Y	123.5	0.00	1.46	1.77	4	13	3	97	0.00	0.0	3.357	0.001	0	0	0	1
PL.53521	PD.4923	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	1.77	1	13	3	97	0.00	0.0	3.429	0.072	13	3	1	1
PL.53522	PL.53521	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	3.529	0.100	0	0	0	0
PL.33182	PL.34061	ABC	#3/0 ACSR	7.41Y	123.5	0.05	1.50	35.71	12	766	209	96	0.22	0.0	3.457	0.101	2	0	3	111
PL.34062	PL.33182	ABC	#3/0 ACSR	7.41Y	123.5	0.01	1.51	34.85	12	747	204	96	0.04	0.0	3.476	0.019	0	0	0	106
PL.34063	PL.34062	ABC	#3/0 ACSR	7.41Y	123.5	0.02	1.53	34.85	12	747	204	96	0.08	0.0	3.516	0.040	0	0	0	106
PL.34064	PL.34063	A	#4 ACSR	7.41Y	123.5	0.00	1.53	5.07	4	36	10	96	0.00	0.0	3.516	0.000	0	0	0	6
PD.5006	PL.34064	A	50QA	7.41Y	123.5	0.00	1.53	5.07	10	36	10	96	0.00	0.0	3.516	0.000	0	0	0	6
PL.53534	PD.5006	A	#4 ACSR	7.41Y	123.5	0.02	1.55	5.07	4	36	10	96	0.00	0.0	3.607	0.091	12	3	1	6
PL.53535	PL.53534	A	#4 ACSR	7.41Y	123.5	0.00	1.55	3.41	3	24	7	96	0.00	0.0	3.623	0.016	0	0	0	5
PL.53600	PL.53535	A	#1/0 ACSR	7.41Y	123.5	0.00	1.55	1.36	1	10	3	96	0.00	0.0	3.666	0.043	4	1	1	3
PL.53601	PL.53600	A	#1/0 ACSR	7.41Y	123.5	0.00	1.55	0.79	0	6	2	95	0.00	0.0	3.727	0.061	0	0	0	2
PL.53603	PL.53601	A	#1/0 ACSR	7.41Y	123.5	0.00	1.55	0.00	0	0	0	100	0.00	0.0	3.825	0.098	0	0	0	0
PL.53602	PL.53601	A	#1/0 ACSR	7.41Y	123.4	0.00	1.55	0.79	0	6	2	95	0.00	0.0	3.766	0.039	3	1	1	2
PL.53599	PL.53602	A	#1/0 ACSR	7.41Y	123.4	0.00	1.55	0.38	0	3	1	95	0.00	0.0	3.850	0.084	3	1	1	1
PL.53536	PL.53535	A	#1/0 ACSR	7.41Y	123.5	0.00	1.55	0.47	0	3	1	95	0.00	0.0	3.661	0.038	3	1	1	1
PL.53598	PL.53535	A	#4 ACSR	7.41Y	123.4	0.01	1.55	1.59	1	11	3	96	0.00	0.0	3.782	0.159	11	3	1	1
PL.34065	PL.34063	ABC	#3/0 ACSR	7.41Y	123.4	0.03	1.56	33.16	11	711	194	96	0.14	0.0	3.594	0.078	2	1	2	100

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.34221	PL.34065	C	#4 ACSR	7.41Y	123.4	0.00	1.56	1.73	1	12	3	97	0.00	0.0	3.594	0.000	0	0	0	3
PD.4924	PL.34221	C	20T	7.41Y	123.4	0.00	1.56	1.73	0	12	3	97	0.00	0.0	3.594	0.000	0	0	0	3
PL.33484	PD.4924	C	#4 ACSR	7.41Y	123.4	0.00	1.57	1.73	1	12	3	97	0.00	0.0	3.670	0.075	5	1	2	3
PL.34222	PL.33484	C	#4 ACSR	7.41Y	123.4	0.00	1.57	1.00	1	7	2	96	0.00	0.0	3.693	0.023	7	2	1	1
PL.34220	PL.34065	ABC	#3/0 ACSR	7.40Y	123.4	0.05	1.61	32.49	11	697	190	96	0.20	0.0	3.705	0.111	0	0	0	95
PL.33170	PL.34220	C	6 A (CWC)	7.40Y	123.4	0.01	1.61	11.40	8	81	22	97	0.00	0.0	3.718	0.013	0	0	0	11
PL.34223	PL.33170	C	6 A (CWC)	7.40Y	123.4	0.00	1.61	11.40	8	81	22	97	0.00	0.0	3.720	0.002	0	0	0	11
PD.4947	PL.34223	C	35L	7.40Y	123.4	0.00	1.61	11.40	33	81	22	97	0.00	0.0	3.720	0.002	0	0	0	11
PL.34163	PD.4947	C	6 A (CWC)	7.39Y	123.2	0.21	1.82	11.40	8	81	22	97	0.12	0.2	4.114	0.394	0	0	0	11
PL.33980	PL.34163	C	6 A (CWC)	7.39Y	123.2	0.03	1.85	7.99	6	57	15	97	0.01	0.0	4.190	0.076	0	0	0	9
PL.34164	PL.33980	C	6 A (CWC)	7.39Y	123.1	0.03	1.88	7.99	6	57	15	97	0.01	0.0	4.277	0.088	0	0	0	9
PL.64869	PL.34164	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	4.398	0.120	0	0	0	0
PL.34165	PL.34164	C	6 A (CWC)	7.38Y	123.1	0.05	1.93	7.99	6	57	15	97	0.02	0.0	4.424	0.146	0	0	0	9
PL.34166	PL.34165	C	6 A (CWC)	7.38Y	123.0	0.04	1.98	6.46	5	46	12	97	0.02	0.0	4.574	0.151	0	0	0	7
PL.33200	PL.34166	C	6 A (CWC)	7.38Y	123.0	0.02	1.99	5.78	4	41	11	97	0.01	0.0	4.643	0.068	0	0	0	6
PL.33126	PL.33200	C	6 A (CWC)	7.38Y	123.0	0.00	2.00	1.15	1	8	2	97	0.00	0.0	4.699	0.056	8	2	1	1
PL.33201	PL.33200	C	6 A (CWC)	7.38Y	123.0	0.01	2.01	4.63	3	33	9	96	0.00	0.0	4.713	0.070	2	1	1	5
PL.64851	PL.33201	C	#4 ACSR	7.38Y	123.0	0.01	2.02	3.40	3	24	7	96	0.00	0.0	4.763	0.050	8	2	1	3
PL.34169	PL.64851	C	#4 ACSR	7.38Y	123.0	0.00	2.02	2.34	2	17	5	96	0.00	0.0	4.812	0.048	9	2	1	2
PL.34170	PL.34169	C	#4 ACSR	7.38Y	123.0	0.00	2.02	1.06	1	8	2	97	0.00	0.0	4.858	0.047	8	2	1	1
PL.66217	PL.34170	C	#1/0 ACSR	7.38Y	123.0	0.00	2.02	0.00	0	0	0	100	0.00	0.0	4.911	0.053	0	0	0	0
PL.34171	PL.33201	C	6 A (CWC)	7.38Y	123.0	0.00	2.01	0.97	1	7	2	96	0.00	0.0	4.825	0.112	0	0	0	1
PL.34172	PL.34171	C	6 A (CWC)	7.38Y	123.0	0.00	2.02	0.97	1	7	2	96	0.00	0.0	5.027	0.202	7	2	1	1
PL.62966	PL.34172	C	6 A (CWC)	7.38Y	123.0	0.00	2.02	0.00	0	0	0	100	0.00	0.0	5.140	0.113	0	0	0	0
PD.9401-A	PL.62966	C	Open	7.38Y	123.0	0.00	2.02	0.00	0	0	0	100	0.00	0.0	5.140	0.113	0	0	0	0
PL.34167	PL.34166	C	#2 ACSR	7.38Y	123.0	0.00	1.98	0.68	0	5	1	98	0.00	0.0	4.735	0.161	0	0	0	1
PL.34168	PL.34167	C	#2 ACSR	7.38Y	123.0	0.00	1.98	0.68	0	5	1	98	0.00	0.0	4.934	0.199	5	1	1	1
PL.64868	PL.34165	C	6 A (CWC)	7.38Y	123.1	0.00	1.94	1.53	1	11	3	96	0.00	0.0	4.521	0.097	11	3	2	2
PL.33146	PL.33980	C	6 A (CWC)	7.39Y	123.2	0.00	1.85	0.00	0	0	0	100	0.00	0.0	4.253	0.063	0	0	0	0
PL.33278	PL.34163	C	#4 ACSR	7.39Y	123.2	0.00	1.82	3.41	3	24	7	96	0.00	0.0	4.141	0.028	24	7	2	2
PL.33164	PL.34163	C	#4 ACSR	7.39Y	123.2	0.00	1.82	0.00	0	0	0	100	0.00	0.0	4.184	0.071	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33193	PL.34220	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.63	28.69	12	615	167	97	0.09	0.0	3.745	0.040	0	0	0	84
PL.33974	PL.33193	ABC	#1/0 ACSR	7.40Y	123.4	0.00	1.63	28.69	12	615	167	97	0.00	0.0	3.745	0.001	0	0	0	84
PD.4948	PL.33974	ABC	50L	7.40Y	123.4	0.00	1.63	28.69	57	615	167	97	0.00	0.0	3.745	0.001	0	0	0	84
PL.33975	PD.4948	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.65	28.69	12	615	167	97	0.08	0.0	3.782	0.037	0	0	0	84
PL.53524	PL.33975	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.69	28.69	12	615	167	97	0.17	0.0	3.862	0.079	0	0	0	84
PL.53525	PL.53524	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.73	27.97	12	599	163	96	0.17	0.0	3.944	0.082	12	3	1	82
PL.33149	PL.53525	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	1.44	1	10	3	96	0.00	0.0	3.996	0.052	10	3	3	3
PL.33485	PL.53525	C	#4 ACSR	7.40Y	123.3	0.00	1.73	1.82	1	13	4	96	0.00	0.0	3.945	0.001	0	0	0	1
PD.4966	PL.33485	C	25QA	7.40Y	123.3	0.00	1.73	1.82	7	13	4	96	0.00	0.0	3.945	0.001	0	0	0	1
PL.62750	PD.4966	C	#4 ACSR	7.40Y	123.3	0.00	1.73	1.82	1	13	4	96	0.00	0.0	3.977	0.033	0	0	0	1
PL.62752	PL.62750	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	1.82	1	13	4	96	0.00	0.0	3.980	0.003	0	0	0	1
PD.9398	PL.62752	C	10T	7.40Y	123.3	0.00	1.73	1.82	0	13	4	96	0.00	0.0	3.980	0.003	0	0	0	1
PL.62753	PD.9398	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	1.82	1	13	4	96	0.00	0.0	4.036	0.056	0	0	0	1
PL.62754	PL.62753	C	#1/0 ACSR	7.40Y	123.3	0.00	1.74	1.82	1	13	4	96	0.00	0.0	4.104	0.068	0	0	0	1
PL.62755	PL.62754	C	#1/0 ACSR	7.40Y	123.3	0.00	1.74	1.82	1	13	4	96	0.00	0.0	4.174	0.070	0	0	0	1
PL.62756	PL.62755	C	#1/0 ACSR	7.40Y	123.3	0.00	1.74	1.82	1	13	4	96	0.00	0.0	4.219	0.045	0	0	0	1
PL.62757	PL.62756	C	#1/0 ACSR	7.40Y	123.3	0.00	1.74	1.82	1	13	4	96	0.00	0.0	4.280	0.060	13	4	1	1
PL.62751	PL.62750	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	4.030	0.053	0	0	0	0
PL.33976	PL.53525	ABC	#1/0 ACSR	7.39Y	123.2	0.04	1.76	26.34	11	564	153	97	0.14	0.0	4.020	0.076	24	6	2	77
PL.33486	PL.33976	ABC	#1/0 ACSR	7.39Y	123.2	0.05	1.81	17.49	8	374	102	96	0.12	0.0	4.167	0.147	13	3	1	56
PL.33470	PL.33486	ABC	#1/0 ACSR	7.39Y	123.2	0.04	1.84	16.90	7	362	98	97	0.09	0.0	4.283	0.117	0	0	0	55
PL.33471	PL.33470	ABC	#1/0 ACSR	7.39Y	123.1	0.01	1.85	16.90	7	362	98	97	0.02	0.0	4.314	0.031	9	2	1	55
PL.33472	PL.33471	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.87	16.49	7	353	96	96	0.05	0.0	4.386	0.072	0	0	0	54
PL.33940	PL.33472	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	1.65	1	12	3	97	0.00	0.0	4.387	0.001	0	0	0	2
PD.4913	PL.33940	C	25QA	7.39Y	123.1	0.00	1.87	1.65	7	12	3	97	0.00	0.0	4.387	0.001	0	0	0	2
PL.33473	PD.4913	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	1.65	1	12	3	97	0.00	0.0	4.451	0.064	6	2	1	2
PL.33162	PL.33473	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.82	1	6	2	95	0.00	0.0	4.491	0.040	6	2	1	1
PL.33474	PL.33473	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	4.493	0.042	0	0	0	0
PL.33514	PL.33472	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.90	15.94	7	341	93	96	0.06	0.0	4.468	0.082	0	0	0	52
PL.33941	PL.33514	C	6 A (CWC)	7.39Y	123.1	0.00	1.90	1.31	1	9	3	95	0.00	0.0	4.469	0.001	0	0	0	1
PD.4978	PL.33941	C	25QA	7.39Y	123.1	0.00	1.90	1.31	5	9	3	95	0.00	0.0	4.469	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33942	PD.4978	C	6 A (CWC)	7.39Y	123.1	0.00	1.90	1.31	1	9	3	95	0.00	0.0	4.518	0.049	0	0	0	1
PL.53171	PL.33942	C	6 A (CWC)	7.39Y	123.1	0.00	1.90	1.31	1	9	3	95	0.00	0.0	4.582	0.064	9	3	1	1
PL.53424	PL.33942	C	#4 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	4.580	0.062	0	0	0	0
PL.53425	PL.53424	C	#4 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	4.627	0.048	0	0	0	0
PL.33636	PL.33514	ABC	#1/0 ACSR	7.38Y	123.0	0.06	1.95	15.50	7	331	90	96	0.13	0.0	4.668	0.200	0	0	0	51
PL.33480	PL.33636	C	#4 ACSR	7.38Y	123.0	0.00	1.95	2.28	2	16	4	97	0.00	0.0	4.671	0.003	0	0	0	2
PD.4990	PL.33480	C	25QA	7.38Y	123.0	0.00	1.95	2.28	9	16	4	97	0.00	0.0	4.671	0.003	0	0	0	2
PL.33481	PD.4990	C	#4 ACSR	7.38Y	123.0	0.01	1.97	2.28	2	16	4	97	0.00	0.0	4.828	0.158	7	2	1	2
PL.33638	PL.33481	C	#4 ACSR	7.38Y	123.0	0.00	1.97	1.33	1	9	3	95	0.00	0.0	4.894	0.065	9	3	1	1
PL.33637	PL.33636	ABC	#1/0 ACSR	7.38Y	123.0	0.02	1.98	14.74	6	315	85	97	0.05	0.0	4.749	0.081	0	0	0	49
PL.34133	PL.33637	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	8.44	6	60	16	97	0.00	0.0	4.753	0.004	0	0	0	7
PD.4971	PL.34133	B	25QA	7.38Y	123.0	0.00	1.98	8.44	34	60	16	97	0.00	0.0	4.753	0.004	0	0	0	7
PL.33535	PD.4971	B	6 A (CWC)	7.38Y	123.0	0.02	2.00	8.44	6	60	16	97	0.01	0.0	4.813	0.060	6	2	1	7
PL.34089	PL.33535	B	6 A (CWC)	7.38Y	123.0	0.04	2.03	7.55	5	54	15	96	0.01	0.0	4.915	0.101	0	0	0	6
PL.34090	PL.34089	B	6 A (CWC)	7.38Y	122.9	0.02	2.06	6.39	5	45	12	97	0.01	0.0	4.996	0.082	0	0	0	5
PL.53533	PL.34090	B	#1/0 ACSR	7.38Y	122.9	0.00	2.06	1.45	1	10	3	96	0.00	0.0	5.056	0.060	10	3	1	1
PL.53582	PL.34090	B	6 A (CWC)	7.38Y	122.9	0.02	2.08	2.65	2	19	5	97	0.00	0.0	5.199	0.202	0	0	0	3
PL.55422	PL.53582	B	6 A (CWC)	7.37Y	122.9	0.01	2.09	2.65	2	19	5	97	0.00	0.0	5.329	0.130	8	2	1	3
PL.55423	PL.55422	B	6 A (CWC)	7.37Y	122.9	0.00	2.10	0.50	0	4	1	97	0.00	0.0	5.391	0.062	4	1	1	1
PL.55426	PL.55423	B	6 A (CWC)	7.37Y	122.9	0.00	2.10	0.00	0	0	0	100	0.00	0.0	5.553	0.163	0	0	0	0
PL.55424	PL.55422	B	#4 ACSR	7.37Y	122.9	0.00	2.10	1.05	1	7	2	96	0.00	0.0	5.385	0.057	7	2	1	1
PL.55425	PL.55424	B	#4 ACSR	7.37Y	122.9	0.00	2.10	0.00	0	0	0	100	0.00	0.0	5.440	0.054	0	0	0	0
PL.53532	PL.34090	B	#1/0 ACSR	7.38Y	122.9	0.00	2.06	2.28	1	16	4	97	0.00	0.0	5.013	0.017	16	4	1	1
PL.55421	PL.34089	B	6 A (CWC)	7.38Y	123.0	0.00	2.03	1.17	1	8	2	97	0.00	0.0	4.961	0.047	8	2	1	1
PL.64867	PL.33637	ABC	#1/0 ACSR	7.38Y	123.0	0.02	2.00	11.93	5	255	69	97	0.04	0.0	4.862	0.113	0	0	0	42
PL.34134	PL.64867	C	6 A (CWC)	7.38Y	123.0	0.00	2.00	13.94	10	99	27	96	0.00	0.0	4.865	0.003	0	0	0	14
PD.4970	PL.34134	C	25QA	7.38Y	123.0	0.00	2.00	13.94	56	99	27	96	0.00	0.0	4.865	0.003	0	0	0	14
PL.34135	PD.4970	C	6 A (CWC)	7.38Y	123.0	0.04	2.05	13.94	10	99	27	96	0.03	0.0	4.935	0.069	0	0	0	14
PL.53176	PL.34135	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	1.23	1	9	2	98	0.00	0.0	5.019	0.085	9	2	1	1
PL.53590	PL.53176	C	#1/0 ACSR	7.38Y	123.0	0.00	2.05	0.00	0	0	0	100	0.00	0.0	5.073	0.054	0	0	0	0
PL.34136	PL.34135	C	6 A (CWC)	7.36Y	122.6	0.32	2.36	12.71	9	90	25	96	0.21	0.2	5.479	0.544	0	0	0	13

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33612	PL.34136	C	6 A (CWC)	7.36Y	122.6	0.02	2.38	3.96	3	28	8	96	0.00	0.0	5.570	0.091	0	0	0	5
PL.33613	PL.33612	C	6 A (CWC)	7.36Y	122.6	0.02	2.40	3.96	3	28	8	96	0.00	0.0	5.671	0.101	0	0	0	5
PL.53597	PL.33613	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.00	0	0	0	100	0.00	0.0	5.699	0.028	0	0	1	1
PL.33614	PL.33613	C	6 A (CWC)	7.36Y	122.6	0.01	2.41	1.97	1	14	4	96	0.00	0.0	5.807	0.136	0	0	0	2
PL.34015	PL.33614	C	6 A (CWC)	7.36Y	122.6	0.00	2.41	1.97	1	14	4	96	0.00	0.0	5.860	0.054	0	0	0	2
PL.34016	PL.34015	C	6 A (CWC)	7.35Y	122.6	0.01	2.42	1.47	1	10	3	96	0.00	0.0	6.071	0.210	10	3	1	1
PL.33289	PL.34015	C	6 A (CWC)	7.36Y	122.6	0.00	2.41	0.50	0	4	1	97	0.00	0.0	5.887	0.026	4	1	1	1
PL.53595	PL.33613	C	#1/0 ACSR	7.36Y	122.6	0.00	2.40	1.99	1	14	4	96	0.00	0.0	5.697	0.026	1	0	1	2
PL.53596	PL.53595	C	#1/0 ACSR	7.36Y	122.6	0.00	2.40	1.88	1	13	4	96	0.00	0.0	5.722	0.025	13	4	1	1
PL.33171	PL.33612	C	6 A (CWC)	7.36Y	122.6	0.00	2.38	0.00	0	0	0	100	0.00	0.0	5.620	0.050	0	0	0	0
PL.34139	PL.34136	C	6 A (CWC)	7.36Y	122.6	0.03	2.39	8.75	6	62	17	96	0.01	0.0	5.561	0.082	6	2	1	8
PL.34140	PL.34139	C	6 A (CWC)	7.35Y	122.6	0.03	2.42	7.93	6	56	15	97	0.01	0.0	5.631	0.069	0	0	0	7
PL.33264	PL.34140	C	#2 ACSR	7.35Y	122.6	0.00	2.42	1.52	1	11	3	96	0.00	0.0	5.729	0.099	11	3	1	1
PL.34012	PL.34140	C	6 A (CWC)	7.35Y	122.5	0.06	2.47	6.41	5	46	12	97	0.02	0.0	5.825	0.194	0	0	0	6
PL.55593	PL.34012	C	6 A (CWC)	7.35Y	122.5	0.02	2.50	6.41	5	46	12	97	0.01	0.0	5.913	0.088	7	2	1	6
PL.55594	PL.55593	C	6 A (CWC)	7.35Y	122.5	0.04	2.54	5.38	4	38	10	97	0.01	0.0	6.095	0.182	0	0	0	5
PL.34017	PL.55594	C	6 A (CWC)	7.35Y	122.4	0.03	2.57	3.57	3	25	7	96	0.00	0.0	6.254	0.158	0	0	0	2
PL.34018	PL.34017	C	6 A (CWC)	7.35Y	122.4	0.01	2.58	3.57	3	25	7	96	0.00	0.0	6.309	0.055	0	0	0	2
PL.34019	PL.34018	C	6 A (CWC)	7.34Y	122.4	0.01	2.59	3.57	3	25	7	96	0.00	0.0	6.362	0.052	0	0	0	2
PL.34021	PL.34019	C	6 A (CWC)	7.34Y	122.4	0.00	2.59	0.00	0	0	0	100	0.00	0.0	6.405	0.043	0	0	0	0
PL.34022	PL.34021	C	6 A (CWC)	7.34Y	122.4	0.00	2.59	0.00	0	0	0	100	0.00	0.0	6.449	0.044	0	0	0	0
PL.33608	PL.34019	C	#4 ACSR	7.34Y	122.4	0.00	2.59	0.00	0	0	0	100	0.00	0.0	6.534	0.173	0	0	0	0
PL.55392	PL.34019	C	#4 ACSR	7.34Y	122.4	0.01	2.59	3.57	3	25	7	96	0.00	0.0	6.456	0.094	25	7	2	2
PL.34013	PL.55594	C	#4 ACSR	7.35Y	122.5	0.00	2.55	1.82	1	13	3	97	0.00	0.0	6.116	0.021	3	1	1	3
PL.34014	PL.34013	C	#4 ACSR	7.35Y	122.5	0.00	2.55	1.35	1	10	3	96	0.00	0.0	6.149	0.033	10	3	2	2
PL.53173	PL.64867	B	6 A (CWC)	7.38Y	122.9	0.07	2.07	21.85	16	156	42	97	0.08	0.1	4.937	0.075	16	4	3	28
PL.53172	PL.53173	B	6 A (CWC)	7.37Y	122.9	0.07	2.14	19.61	14	140	38	97	0.07	0.1	5.017	0.080	0	0	0	25
PL.33640	PL.53172	B	#2 ACSR	7.37Y	122.9	0.00	2.14	1.26	1	9	2	98	0.00	0.0	5.050	0.033	9	2	1	1
PL.34137	PL.53172	B	6 A (CWC)	7.37Y	122.8	0.05	2.19	18.35	13	131	35	97	0.05	0.0	5.079	0.062	0	0	0	24
PL.53517	PL.34137	B	6 A (CWC)	7.37Y	122.8	0.01	2.20	4.04	3	29	8	96	0.00	0.0	5.155	0.076	14	4	1	2
PL.62956	PL.53517	B	#1/0 ACSR	7.37Y	122.8	0.00	2.21	2.04	1	15	4	97	0.00	0.0	5.212	0.058	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62955	PL.62956	B	#1/0 ACSR	7.37Y	122.8	0.00	2.21	2.04	1	15	4	97	0.00	0.0	5.269	0.057	15	4	1	1
PL.53518	PL.34137	B	6 A (CWC)	7.37Y	122.8	0.03	2.22	14.31	10	102	28	96	0.02	0.0	5.121	0.042	6	2	2	22
PL.53520	PL.53518	B	#1/0 ACSR	7.37Y	122.8	0.00	2.22	0.00	0	0	0	100	0.00	0.0	5.150	0.029	0	0	0	0
PL.72962	PL.53518	B	6 A (CWC)	7.37Y	122.8	0.00	2.22	13.44	10	96	26	97	0.00	0.0	5.121	0.000	0	0	0	20
PL.72963	PL.72962	B	6 A (CWC)	7.36Y	122.6	0.15	2.37	13.44	10	96	26	97	0.10	0.1	5.374	0.253	10	3	1	20
PL.34138	PL.72963	B	6 A (CWC)	7.36Y	122.6	0.04	2.41	12.08	9	86	23	97	0.02	0.0	5.443	0.070	0	0	0	19
PL.66215	PL.34138	B	6 A (CWC)	7.35Y	122.6	0.02	2.43	10.96	8	78	21	97	0.01	0.0	5.493	0.049	0	0	0	18
PL.66214	PL.66215	B	#1/0 ACSR	7.35Y	122.6	0.00	2.43	0.93	0	7	2	96	0.00	0.0	5.537	0.045	7	2	1	1
PL.66216	PL.66215	B	6 A (CWC)	7.35Y	122.5	0.05	2.48	10.03	7	71	19	97	0.02	0.0	5.593	0.101	0	0	0	17
PL.34011	PL.66216	B	6 A (CWC)	7.35Y	122.4	0.09	2.57	10.03	7	71	19	97	0.05	0.1	5.797	0.204	0	0	0	17
PL.34020	PL.34011	B	6 A (CWC)	7.34Y	122.4	0.01	2.58	4.79	3	34	9	97	0.00	0.0	5.858	0.060	0	0	0	9
PL.33176	PL.34020	B	6 A (CWC)	7.34Y	122.4	0.02	2.60	3.88	3	28	7	97	0.00	0.0	5.965	0.107	0	0	0	7
PL.33502	PL.33176	B	6 A (CWC)	7.34Y	122.4	0.01	2.61	2.54	2	18	5	96	0.00	0.0	6.048	0.083	4	1	1	5
PL.57236	PL.33502	B	6 A (CWC)	7.34Y	122.4	0.00	2.61	1.99	1	14	4	96	0.00	0.0	6.071	0.023	0	0	0	4
PL.57237	PL.57236	B	6 A (CWC)	7.34Y	122.4	0.00	2.62	1.99	1	14	4	96	0.00	0.0	6.124	0.053	4	1	1	3
PL.57238	PL.57237	B	6 A (CWC)	7.34Y	122.4	0.00	2.62	1.44	1	10	3	96	0.00	0.0	6.214	0.090	10	3	2	2
PL.57235	PL.57236	B	6 A (CWC)	7.34Y	122.4	0.00	2.61	0.00	0	0	0	100	0.00	0.0	6.133	0.062	0	0	1	1
PL.33513	PL.33176	B	6 A (CWC)	7.34Y	122.4	0.00	2.61	1.35	1	10	3	96	0.00	0.0	6.056	0.091	10	3	2	2
PL.33135	PL.34020	B	6 A (CWC)	7.34Y	122.4	0.00	2.58	0.91	1	6	2	95	0.00	0.0	5.903	0.045	6	2	2	2
PL.59098	PL.34011	B	#2 ACSR	7.35Y	122.4	0.01	2.58	5.24	3	37	10	97	0.00	0.0	5.862	0.065	10	3	1	8
PL.59097	PL.59098	B	#2 ACSR	7.35Y	122.4	0.00	2.58	1.43	1	10	3	96	0.00	0.0	5.921	0.059	10	3	1	1
PL.59099	PL.59098	B	#2 ACSR	7.35Y	122.4	0.00	2.58	2.46	1	17	5	96	0.00	0.0	5.915	0.052	17	5	6	6
PL.33531	PL.34138	B	6 A (CWC)	7.36Y	122.6	0.00	2.41	1.12	1	8	2	97	0.00	0.0	5.517	0.073	8	2	1	1
PL.33977	PL.33976	A	6 A (CWC)	7.39Y	123.2	0.00	1.76	23.23	17	166	45	97	0.00	0.0	4.020	0.001	0	0	0	19
PD.4964	PL.33977	A	40QA	7.39Y	123.2	0.00	1.76	23.23	58	166	45	97	0.00	0.0	4.020	0.001	0	0	0	19
PL.33487	PD.4964	A	6 A (CWC)	7.39Y	123.1	0.14	1.90	23.23	17	166	45	97	0.17	0.1	4.148	0.127	0	0	0	19
PL.53523	PL.33487	A	6 A (CWC)	7.39Y	123.1	0.01	1.90	2.21	2	16	4	97	0.00	0.0	4.266	0.118	16	4	1	1
PL.33488	PL.33487	A	6 A (CWC)	7.38Y	123.0	0.11	2.01	21.02	15	150	41	96	0.12	0.1	4.260	0.112	0	0	0	18
PL.33978	PL.33488	A	6 A (CWC)	7.38Y	123.0	0.02	2.03	6.65	5	47	13	96	0.01	0.0	4.339	0.080	0	0	0	4
PL.33292	PL.33978	A	#2 ACSR	7.38Y	123.0	0.00	2.03	1.84	1	13	4	96	0.00	0.0	4.364	0.025	13	4	1	1
PL.33979	PL.33978	A	6 A (CWC)	7.38Y	123.0	0.01	2.04	4.80	3	34	9	97	0.00	0.0	4.399	0.060	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																	KW	KVAR	Cons On	Cons Thru
PL.53537	PL.33979	A	6 A (CWC)	7.38Y	123.0	0.00	2.05	2.88	2	21	6	96	0.00	0.0	4.440	0.041	12	3	1	2
PL.53538	PL.53537	A	6 A (CWC)	7.38Y	123.0	0.00	2.05	1.15	1	8	2	97	0.00	0.0	4.501	0.061	8	2	1	1
PL.33124	PL.33979	A	#1/0 ACSR	7.38Y	123.0	0.00	2.05	1.92	1	14	4	96	0.00	0.0	4.508	0.109	14	4	1	1
PL.33280	PL.33488	A	6 A (CWC)	7.37Y	122.9	0.09	2.09	14.37	10	102	28	96	0.07	0.1	4.390	0.130	0	0	0	14
PL.33318	PL.33280	A	#4 ACSR	7.37Y	122.9	0.00	2.09	0.61	0	4	1	97	0.00	0.0	4.532	0.142	4	1	1	1
PL.33281	PL.33280	A	6 A (CWC)	7.37Y	122.8	0.08	2.18	13.76	10	98	26	97	0.06	0.1	4.543	0.153	24	7	2	13
PL.33932	PL.33281	A	6 A (CWC)	7.37Y	122.8	0.03	2.20	7.03	5	50	14	96	0.01	0.0	4.630	0.087	0	0	0	9
PL.33517	PL.33932	A	#4 ACSR	7.37Y	122.8	0.00	2.20	0.00	0	0	0	100	0.00	0.0	4.665	0.035	0	0	0	0
PL.33933	PL.33932	A	6 A (CWC)	7.37Y	122.8	0.02	2.22	7.03	5	50	14	96	0.01	0.0	4.694	0.063	7	2	2	9
PL.33425	PL.33933	A	#4 ACSR	7.37Y	122.8	0.00	2.23	1.41	1	10	3	96	0.00	0.0	4.777	0.083	10	3	1	1
PL.33934	PL.33933	A	6 A (CWC)	7.37Y	122.8	0.01	2.23	3.62	3	26	7	97	0.00	0.0	4.755	0.061	17	5	2	5
PL.33935	PL.33934	A	6 A (CWC)	7.37Y	122.8	0.00	2.23	1.27	1	9	2	98	0.00	0.0	4.816	0.061	5	1	2	3
PL.33936	PL.33935	A	6 A (CWC)	7.37Y	122.8	0.00	2.23	0.63	0	4	1	97	0.00	0.0	4.888	0.072	4	1	1	1
PL.33938	PL.33936	A	#4 ACSR	7.37Y	122.8	0.00	2.23	0.00	0	0	0	100	0.00	0.0	4.929	0.041	0	0	0	0
PL.33939	PL.33938	A	#4 ACSR	7.37Y	122.8	0.00	2.23	0.00	0	0	0	100	0.00	0.0	4.969	0.041	0	0	0	0
PL.33937	PL.33936	A	6 A (CWC)	7.37Y	122.8	0.00	2.23	0.00	0	0	0	100	0.00	0.0	4.971	0.083	0	0	0	0
PL.33319	PL.33933	A	#4 ACSR	7.37Y	122.8	0.00	2.22	0.97	1	7	2	96	0.00	0.0	4.756	0.063	7	2	1	1
PL.62695	PL.33281	A	6 A (CWC)	7.37Y	122.8	0.01	2.18	3.32	2	24	6	97	0.00	0.0	4.590	0.047	11	3	1	2
PL.62395	PL.62695	A	#1/0 ACSR	7.37Y	122.8	0.00	2.18	1.77	1	13	3	97	0.00	0.0	4.592	0.002	0	0	0	1
PD.9518	PL.62395	A	25T	7.37Y	122.8	0.00	2.18	1.77	0	13	3	97	0.00	0.0	4.592	0.002	0	0	0	1
PL.62396	PD.9518	A	#1/0 ACSR	7.37Y	122.8	0.00	2.18	1.77	1	13	3	97	0.00	0.0	4.647	0.055	0	0	0	1
PL.62397	PL.62396	A	#1/0 ACSR	7.37Y	122.8	0.00	2.19	1.77	1	13	3	97	0.00	0.0	4.698	0.051	0	0	0	1
PL.62398	PL.62397	A	#1/0 ACSR	7.37Y	122.8	0.00	2.19	1.77	1	13	3	97	0.00	0.0	4.732	0.034	0	0	0	1
PL.62399	PL.62398	A	1/0 AL URD	7.37Y	122.8	0.00	2.19	1.77	1	13	3	97	0.00	0.0	4.778	0.046	13	3	1	1
PL.62394	PL.62695	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	4.618	0.028	0	0	0	0
PL.33931	PL.62394	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	4.702	0.084	0	0	0	0
PL.33187	PL.33281	A	#4 ACSR	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	4.587	0.045	0	0	0	0
PL.53528	PL.53524	A	#1/0 ACSR	7.40Y	123.3	0.00	1.69	0.57	0	4	1	97	0.00	0.0	3.866	0.004	0	0	0	1
PD.7909	PL.53528	A	10QA	7.40Y	123.3	0.00	1.69	0.57	0	4	1	97	0.00	0.0	3.866	0.004	0	0	0	1
PL.53529	PD.7909	A	#1/0 ACSR	7.40Y	123.3	0.00	1.69	0.57	0	4	1	97	0.00	0.0	3.894	0.028	4	1	1	1
PL.53526	PL.53524	A	6 A (CWC)	7.40Y	123.3	0.00	1.69	1.59	1	11	3	96	0.00	0.0	3.867	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PD.7908	PL.53526	A	10QA	7.40Y	123.3	0.00	1.69	1.59	0	11	3	96	0.00	0.0	3.867	0.005	0	0	0	1
PL.53527	PD.7908	A	6 A (CWC)	7.40Y	123.3	0.00	1.69	1.59	1	11	3	96	0.00	0.0	3.943	0.076	11	3	1	1
PL.33183	PL.33182	A	6 A (CWC)	7.41Y	123.5	0.00	1.50	2.35	2	17	5	96	0.00	0.0	3.463	0.006	0	0	0	2
PD.4965	PL.33183	A	50QA	7.41Y	123.5	0.00	1.50	2.35	5	17	5	96	0.00	0.0	3.463	0.006	0	0	0	2
PL.53515	PD.4965	A	6 A (CWC)	7.41Y	123.5	0.01	1.51	2.35	2	17	5	96	0.00	0.0	3.537	0.074	8	2	1	2
PL.53516	PL.53515	A	#1/0 ACSR	7.41Y	123.5	0.00	1.51	1.17	1	8	2	97	0.00	0.0	3.566	0.029	8	2	1	1
PL.33137	PL.33181	A	#4 ACSR	7.42Y	123.6	0.00	1.38	1.80	1	13	3	97	0.00	0.0	3.241	0.051	13	3	1	1
PL.33158	PL.33157	A	#4 ACSR	7.44Y	124.0	0.00	1.00	0.01	0	0	0	100	0.00	0.0	2.607	0.002	0	0	0	1
PD.4969	PL.33158	A	50QA	7.44Y	124.0	0.00	1.00	0.01	0	0	0	100	0.00	0.0	2.607	0.002	0	0	0	1
PL.33159	PD.4969	A	#4 ACSR	7.44Y	124.0	0.00	1.00	0.01	0	0	0	100	0.00	0.0	2.670	0.063	0	0	1	1
PL.34337	PL.34336	A	#2 ACSR	7.46Y	124.3	0.00	0.75	1.62	1	12	3	97	0.00	0.0	2.283	0.002	0	0	0	1
PD.4967	PL.34337	A	50QA	7.46Y	124.3	0.00	0.75	1.62	3	12	3	97	0.00	0.0	2.283	0.002	0	0	0	1
PL.55183	PD.4967	A	#2 ACSR	7.45Y	124.2	0.00	0.75	1.62	1	12	3	97	0.00	0.0	2.396	0.113	12	3	1	1
CP.52	PL.33326	ABC	Cap (300)	7.46Y	124.4	0.00	0.60	0.00	0	0	0	100	0.00	0.0	2.096	0.113	0	0	0	0
PL.59102	PL.59100	C	6 A (CWC)	7.46Y	124.3	0.15	0.68	54.45	39	392	108	96	0.44	0.1	2.074	0.061	0	0	0	57
PL.33447	PL.59102	C	6 A (CWC)	7.46Y	124.3	0.00	0.69	54.45	39	392	108	96	0.01	0.0	2.075	0.002	0	0	0	57
PD.4944	PL.33447	C	100L	7.46Y	124.3	0.00	0.69	54.45	54	392	108	96	0.00	0.0	2.075	0.002	0	0	0	57
PL.33152	PD.4944	C	6 A (CWC)	7.44Y	124.0	0.31	1.00	54.45	39	392	108	96	0.90	0.2	2.200	0.124	0	0	0	57
PL.33168	PL.33152	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.83	0	6	2	95	0.00	0.0	2.238	0.038	6	2	1	1
PL.33153	PL.33152	C	6 A (CWC)	7.43Y	123.9	0.14	1.13	53.62	38	385	105	96	0.39	0.1	2.256	0.056	0	0	0	56
PL.33329	PL.33153	C	#4 ACSR	7.43Y	123.9	0.00	1.13	2.08	2	15	4	97	0.00	0.0	2.257	0.001	0	0	0	1
PD.5007	PL.33329	C	40QA	7.43Y	123.9	0.00	1.13	2.08	5	15	4	97	0.00	0.0	2.257	0.001	0	0	0	1
PL.33275	PD.5007	C	#4 ACSR	7.43Y	123.9	0.00	1.14	2.08	2	15	4	97	0.00	0.0	2.307	0.050	15	4	1	1
PL.33154	PL.33153	C	6 A (CWC)	7.42Y	123.7	0.13	1.26	51.54	37	369	101	96	0.34	0.1	2.309	0.054	5	1	1	55
PL.33155	PL.33154	C	#4 ACSR	7.42Y	123.7	0.00	1.26	1.23	1	9	2	98	0.00	0.0	2.310	0.001	0	0	0	1
PD.4973	PL.33155	C	6T	7.42Y	123.7	0.00	1.26	1.23	0	9	2	98	0.00	0.0	2.310	0.001	0	0	0	1
PL.33156	PD.4973	C	#4 ACSR	7.42Y	123.7	0.00	1.26	1.23	1	9	2	98	0.00	0.0	2.337	0.027	9	2	1	1
PL.61216	PL.33154	C	6 A (CWC)	7.40Y	123.3	0.39	1.65	46.84	33	335	92	96	0.98	0.3	2.492	0.183	0	0	0	51
PL.61218	PL.61216	C	#1/0 ACSR	7.40Y	123.3	0.00	1.65	0.00	0	0	0	100	0.00	0.0	2.543	0.051	0	0	0	0
PL.61217	PL.61216	C	6 A (CWC)	7.38Y	123.1	0.27	1.92	46.84	33	334	91	96	0.67	0.2	2.618	0.126	0	0	0	51
PL.33276	PL.61217	C	6 A (CWC)	7.35Y	122.6	0.51	2.43	44.65	32	318	87	96	1.21	0.4	2.868	0.250	0	0	0	50

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33816	PL.33276	C	6 A (CWC)	7.35Y	122.6	0.00	2.43	9.61	7	68	18	97	0.00	0.0	2.870	0.002	0	0	0	10
PD.4992	PL.33816	C	40T	7.35Y	122.6	0.00	2.43	9.61	0	68	18	97	0.00	0.0	2.870	0.002	0	0	0	10
PL.34047	PD.4992	C	6 A (CWC)	7.35Y	122.5	0.06	2.49	9.61	7	68	18	97	0.03	0.0	3.008	0.139	0	0	0	10
PL.34048	PL.34047	C	6 A (CWC)	7.35Y	122.5	0.02	2.51	8.49	6	60	16	97	0.01	0.0	3.065	0.057	0	0	0	9
PL.59088	PL.34048	C	#1/0 ACSR	7.35Y	122.5	0.00	2.52	1.36	1	10	3	96	0.00	0.0	3.069	0.004	0	0	0	1
PD.8671	PL.59088	C	15T	7.35Y	122.5	0.00	2.52	1.36	0	10	3	96	0.00	0.0	3.069	0.004	0	0	0	1
PL.59089	PD.8671	C	#1/0 ACSR	7.35Y	122.5	0.00	2.52	1.36	1	10	3	96	0.00	0.0	3.149	0.081	10	3	1	1
PL.34329	PL.34048	C	6 A (CWC)	7.35Y	122.5	0.01	2.53	5.72	4	41	11	97	0.00	0.0	3.114	0.049	9	3	2	7
PL.34330	PL.34329	C	6 A (CWC)	7.35Y	122.5	0.02	2.54	4.38	3	31	8	97	0.00	0.0	3.204	0.090	8	2	1	5
PL.33148	PL.34330	C	#4 ACSR	7.35Y	122.5	0.00	2.54	1.43	1	10	3	96	0.00	0.0	3.257	0.054	10	3	1	1
PL.34049	PL.34330	C	6 A (CWC)	7.35Y	122.5	0.00	2.55	1.83	1	13	4	96	0.00	0.0	3.299	0.095	13	4	3	3
PL.33195	PL.34048	C	#2 ACSR	7.35Y	122.5	0.00	2.52	1.41	1	10	3	96	0.00	0.0	3.122	0.057	10	3	1	1
PL.33615	PL.34047	C	6 A (CWC)	7.35Y	122.5	0.01	2.50	1.13	1	8	2	97	0.00	0.0	3.220	0.212	0	0	0	1
PL.33618	PL.33615	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	1.13	1	8	2	97	0.00	0.0	3.247	0.027	0	0	0	1
PL.55173	PL.33618	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	1.13	1	8	2	97	0.00	0.0	3.310	0.063	0	0	0	1
PL.55175	PL.55173	C	#2 ACSR	7.35Y	122.5	0.00	2.51	0.00	0	0	0	100	0.00	0.0	3.340	0.030	0	0	0	0
PL.55174	PL.55173	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	1.13	1	8	2	97	0.00	0.0	3.408	0.098	8	2	1	1
PL.55172	PL.55174	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	0.00	0	0	0	100	0.00	0.0	3.483	0.075	0	0	0	0
PL.33817	PL.33276	C	6 A (CWC)	7.35Y	122.6	0.00	2.43	5.64	4	40	11	96	0.00	0.0	2.870	0.002	0	0	0	9
PD.4979	PL.33817	C	40T	7.35Y	122.6	0.00	2.43	5.64	0	40	11	96	0.00	0.0	2.870	0.002	0	0	0	9
PL.33544	PD.4979	C	6 A (CWC)	7.35Y	122.5	0.03	2.46	5.64	4	40	11	96	0.01	0.0	2.999	0.129	0	0	0	9
PL.33545	PL.33544	C	6 A (CWC)	7.35Y	122.5	0.00	2.47	5.54	4	39	11	96	0.00	0.0	3.022	0.023	14	4	1	8
PL.34046	PL.33545	C	6 A (CWC)	7.35Y	122.5	0.03	2.50	3.51	3	25	7	96	0.01	0.0	3.203	0.182	0	0	0	7
PL.34331	PL.34046	C	6 A (CWC)	7.35Y	122.5	0.01	2.50	3.51	3	25	7	96	0.00	0.0	3.237	0.034	0	0	0	7
PL.33196	PL.34331	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	0.48	0	3	1	95	0.00	0.0	3.297	0.060	0	0	0	2
PL.33197	PL.33196	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	0.00	0	0	0	100	0.00	0.0	3.327	0.030	0	0	0	0
PL.33198	PL.33196	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	0.48	0	3	1	95	0.00	0.0	3.538	0.242	2	1	1	2
PL.33199	PL.33198	C	6 A (CWC)	7.35Y	122.5	0.00	2.51	0.13	0	1	0	100	0.00	0.0	3.599	0.061	1	0	1	1
PL.34332	PL.34331	C	#4 ACSR	7.35Y	122.5	0.02	2.52	3.04	2	22	6	96	0.00	0.0	3.401	0.164	11	3	2	5
PL.33293	PL.34332	C	#4 ACSR	7.35Y	122.5	0.00	2.52	0.91	1	6	2	95	0.00	0.0	3.451	0.050	6	2	1	1
PL.34333	PL.34332	C	#4 ACSR	7.35Y	122.5	0.00	2.52	0.53	0	4	1	97	0.00	0.0	3.447	0.046	4	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33144	PL.33544	C	#2 ACSR	7.35Y	122.5	0.00	2.46	0.09	0	1	0	100	0.00	0.0	3.046	0.047	1	0	1	1
PL.57413	PL.33276	C	6 A (CWC)	7.35Y	122.6	0.01	2.44	29.40	21	209	57	96	0.01	0.0	2.873	0.005	0	0	0	31
PD.8283	PL.57413	C	25T	7.35Y	122.6	0.00	2.44	29.40	0	209	57	96	0.00	0.0	2.873	0.005	0	0	0	31
PL.57411	PD.8283	C	6 A (CWC)	7.35Y	122.4	0.13	2.57	29.40	21	209	57	96	0.20	0.1	2.976	0.102	18	5	2	31
PL.57412	PL.57411	C	6 A (CWC)	7.34Y	122.3	0.11	2.68	26.87	19	190	52	96	0.15	0.1	3.065	0.089	12	3	2	29
PL.55167	PL.57412	C	6 A (CWC)	7.33Y	122.2	0.11	2.78	25.21	18	179	48	97	0.14	0.1	3.158	0.093	0	0	0	27
PL.55181	PL.55167	C	6 A (CWC)	7.33Y	122.2	0.03	2.82	17.24	12	122	33	97	0.03	0.0	3.201	0.044	0	0	0	18
PL.55182	PL.55181	C	6 A (CWC)	7.33Y	122.1	0.08	2.90	17.24	12	122	33	97	0.08	0.1	3.305	0.104	0	0	0	18
PL.55170	PL.55182	C	6 A (CWC)	7.33Y	122.1	0.02	2.92	16.33	12	115	31	97	0.01	0.0	3.330	0.024	10	3	1	17
PL.55171	PL.55170	C	6 A (CWC)	7.32Y	121.9	0.14	3.06	14.91	11	105	29	96	0.11	0.1	3.541	0.212	0	0	0	16
PL.53591	PL.55171	C	6 A (CWC)	7.31Y	121.9	0.07	3.13	11.51	8	81	22	97	0.04	0.1	3.675	0.133	0	0	0	13
PL.53592	PL.53591	C	6 A (CWC)	7.31Y	121.8	0.04	3.17	7.75	6	55	15	96	0.02	0.0	3.790	0.115	3	1	1	7
PL.33369	PL.53592	C	6 A (CWC)	7.31Y	121.8	0.03	3.20	7.30	5	52	14	97	0.01	0.0	3.890	0.100	0	0	0	6
PL.55387	PL.33369	C	#4 ACSR	7.31Y	121.8	0.00	3.21	1.07	1	8	2	97	0.00	0.0	3.939	0.049	8	2	1	1
PL.55164	PL.33369	C	6 A (CWC)	7.30Y	121.7	0.05	3.25	3.58	3	25	7	96	0.01	0.0	4.202	0.312	0	0	0	3
PL.55165	PL.55164	C	6 A (CWC)	7.30Y	121.7	0.00	3.26	3.58	3	25	7	96	0.00	0.0	4.233	0.031	10	3	1	3
PL.55388	PL.55165	C	6 A (CWC)	7.30Y	121.7	0.00	3.26	1.30	1	9	2	98	0.00	0.0	4.270	0.037	9	2	1	1
PL.64440	PL.55165	C	#1/0 ACSR	7.30Y	121.7	0.00	3.26	0.92	0	7	2	96	0.00	0.0	4.262	0.029	0	0	0	1
PL.64441	PL.64440	C	#1/0 ACSR	7.30Y	121.7	0.00	3.26	0.92	0	7	2	96	0.00	0.0	4.310	0.047	0	0	0	1
PL.64442	PL.64441	C	#1/0 ACSR	7.30Y	121.7	0.00	3.26	0.92	0	7	2	96	0.00	0.0	4.384	0.074	7	2	1	1
PL.62784	PL.33369	C	6 A (CWC)	7.31Y	121.8	0.00	3.21	2.66	2	19	5	97	0.00	0.0	3.939	0.049	19	5	2	2
PL.53593	PL.53591	C	6 A (CWC)	7.31Y	121.9	0.01	3.14	3.76	3	27	7	97	0.00	0.0	3.718	0.043	0	0	0	6
PL.53594	PL.53593	C	6 A (CWC)	7.31Y	121.9	0.01	3.15	3.76	3	27	7	97	0.00	0.0	3.784	0.066	4	1	1	6
PL.55195	PL.53594	C	6 A (CWC)	7.31Y	121.8	0.01	3.16	2.95	2	21	6	96	0.00	0.0	3.832	0.048	0	0	0	4
PL.55194	PL.55195	C	6 A (CWC)	7.31Y	121.8	0.00	3.16	1.11	1	8	2	97	0.00	0.0	3.862	0.030	7	2	1	2
PL.33286	PL.55194	C	6 A (CWC)	7.31Y	121.8	0.00	3.16	0.13	0	1	0	100	0.00	0.0	3.891	0.029	1	0	1	1
PL.55196	PL.55195	C	6 A (CWC)	7.31Y	121.8	0.01	3.16	1.84	1	13	4	96	0.00	0.0	3.909	0.077	0	0	0	2
PL.55192	PL.55196	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.84	1	13	4	96	0.00	0.0	3.914	0.005	0	0	0	2
PD.8215	PL.55192	C	20QA	7.31Y	121.8	0.00	3.16	1.84	9	13	4	96	0.00	0.0	3.914	0.005	0	0	0	2
PL.55193	PD.8215	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.84	1	13	4	96	0.00	0.0	4.032	0.118	13	4	2	2
PL.57902	PL.53594	C	#4 ACSR	7.31Y	121.9	0.00	3.15	0.24	0	2	0	100	0.00	0.0	3.864	0.080	2	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.33818	PL.55171	C	6 A (CWC)	7.32Y	121.9	0.01	3.07	3.40	2	24	6	97	0.00	0.0	3.598	0.057	0	0	0	3
PL.59079	PL.33818	C	#2 ACSR	7.32Y	121.9	0.00	3.07	0.95	1	7	2	96	0.00	0.0	3.689	0.091	7	2	1	1
PL.59080	PL.59079	C	#2 ACSR	7.32Y	121.9	0.00	3.07	0.00	0	0	0	100	0.00	0.0	3.811	0.122	0	0	0	0
PL.61209	PL.33818	C	#1/0 ACSR	7.32Y	121.9	0.00	3.07	1.42	1	10	3	96	0.00	0.0	3.601	0.004	0	0	0	1
PD.9106	PL.61209	C	15T	7.32Y	121.9	0.00	3.07	1.42	0	10	3	96	0.00	0.0	3.601	0.004	0	0	0	1
PL.61210	PD.9106	C	#1/0 ACSR	7.32Y	121.9	0.00	3.07	1.42	1	10	3	96	0.00	0.0	3.649	0.048	10	3	1	1
PL.55166	PL.33818	C	6 A (CWC)	7.32Y	121.9	0.00	3.07	1.03	1	7	2	96	0.00	0.0	3.669	0.071	7	2	1	1
PL.55389	PL.55170	C	#4 ACSR	7.33Y	122.1	0.00	2.92	0.00	0	0	0	100	0.00	0.0	3.426	0.096	0	0	0	0
PL.55169	PL.55182	C	#4 ACSR	7.33Y	122.1	0.00	2.90	0.90	1	6	2	95	0.00	0.0	3.355	0.050	6	2	1	1
PL.55390	PL.55167	C	#4 ACSR	7.33Y	122.2	0.01	2.79	4.32	3	31	8	97	0.00	0.0	3.203	0.046	9	2	1	3
PL.55391	PL.55390	C	#4 ACSR	7.33Y	122.2	0.00	2.79	3.08	2	22	6	96	0.00	0.0	3.258	0.055	22	6	2	2
PL.55168	PL.55167	C	#4 ACSR	7.33Y	122.2	0.01	2.79	3.66	3	26	7	97	0.00	0.0	3.200	0.043	3	1	1	6
PL.55179	PL.55168	C	#4 ACSR	7.33Y	122.2	0.01	2.79	3.23	2	23	6	97	0.00	0.0	3.252	0.052	14	4	2	5
PL.55180	PL.55179	C	#1/0 ACSR	7.33Y	122.2	0.00	2.80	1.30	1	9	2	98	0.00	0.0	3.274	0.022	9	2	3	3
PL.55547	PL.61217	C	#4 ACSR	7.38Y	123.1	0.00	1.92	2.19	2	16	4	97	0.00	0.0	2.621	0.003	0	0	0	1
PD.8199	PL.55547	C	40QA	7.38Y	123.1	0.00	1.92	2.19	5	16	4	97	0.00	0.0	2.621	0.003	0	0	0	1
PL.55548	PD.8199	C	#4 ACSR	7.38Y	123.1	0.00	1.92	2.19	2	16	4	97	0.00	0.0	2.659	0.038	16	4	1	1
PL.33231	PL.61217	C	#4 ACSR	7.38Y	123.1	0.00	1.92	0.00	0	0	0	100	0.00	0.0	2.633	0.015	0	0	0	0
PL.33533	PL.33154	C	#4 ACSR	7.42Y	123.7	0.01	1.26	2.75	2	20	5	97	0.00	0.0	2.376	0.066	14	4	1	2
PL.61234	PL.33533	C	#1/0 ACSR	7.42Y	123.7	0.00	1.27	0.80	0	6	2	95	0.00	0.0	2.436	0.061	6	2	1	1
PL.61194	PL.61192	B	#1/0 ACSR	7.35Y	122.4	0.00	2.57	0.34	0	2	1	89	0.00	0.0	1.738	0.004	0	0	0	1
PD.9102	PL.61194	B	10T	7.35Y	122.4	0.00	2.57	0.34	0	2	1	89	0.00	0.0	1.738	0.004	0	0	0	1
PL.61195	PD.9102	B	#1/0 ACSR	7.35Y	122.4	0.00	2.57	0.34	0	2	1	89	0.00	0.0	1.769	0.030	2	1	1	1
PL.33145	PL.34317	C	6 A (CWC)	7.36Y	122.6	0.00	2.37	0.79	1	6	2	95	0.00	0.0	1.616	0.060	6	2	1	1
PL.33813	PL.34319	A	6 A (CWC)	7.37Y	122.8	0.00	2.17	3.96	3	28	8	96	0.00	0.0	1.375	0.000	0	0	0	8
PD.4972	PL.33813	A	75QA	7.37Y	122.8	0.00	2.17	3.96	5	28	8	96	0.00	0.0	1.375	0.000	0	0	0	8
PL.33814	PD.4972	A	6 A (CWC)	7.37Y	122.8	0.01	2.17	3.96	3	28	8	96	0.00	0.0	1.435	0.060	22	6	2	8
PL.34320	PL.33814	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.89	1	6	2	95	0.00	0.0	1.465	0.030	2	0	1	6
PL.33811	PL.34320	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.66	0	5	1	98	0.00	0.0	1.492	0.027	5	1	5	5
PL.33812	PL.33811	A	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	1.524	0.032	0	0	0	0
PL.63859	PL.63854	C	#1/0 ACSR	7.41Y	123.4	0.00	1.56	54.88	24	383	135	94	0.01	0.0	0.873	0.003	0	0	0	31

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.9491	PL.63859	C	50T	7.41Y	123.4	0.00	1.56	54.88	0	383	135	94	0.00	0.0	0.873	0.003	0	0	0	31
PL.63860	PD.9491	C	#1/0 ACSR	7.40Y	123.3	0.11	1.68	54.88	24	383	135	94	0.27	0.1	0.959	0.086	12	3	2	31
PL.63852	PL.63860	C	6 A (CWC)	7.40Y	123.3	0.00	1.68	4.75	3	34	9	97	0.00	0.0	1.000	0.041	34	9	1	1
PL.63853	PL.63860	C	6 A (CWC)	7.40Y	123.3	0.05	1.73	48.41	35	337	122	94	0.13	0.0	0.982	0.023	0	0	0	28
PL.61220	PL.63853	C	6 A (CWC)	7.39Y	123.2	0.09	1.82	26.84	19	192	52	97	0.13	0.1	1.059	0.076	11	3	1	27
PL.61221	PL.61220	C	6 A (CWC)	7.38Y	123.1	0.10	1.92	25.27	18	180	49	96	0.13	0.1	1.145	0.086	0	0	0	26
PL.59103	PL.61221	C	6 A (CWC)	7.38Y	123.1	0.00	1.92	0.96	1	7	2	96	0.00	0.0	1.218	0.073	7	2	2	2
PL.33321	PL.61221	C	6 A (CWC)	7.38Y	123.1	0.00	1.92	1.82	1	13	4	96	0.00	0.0	1.208	0.063	3	1	1	3
PL.33322	PL.33321	C	6 A (CWC)	7.38Y	123.1	0.01	1.93	1.34	1	10	3	96	0.00	0.0	1.353	0.145	0	0	0	2
PL.33323	PL.33322	C	6 A (CWC)	7.38Y	123.1	0.00	1.94	1.34	1	10	3	96	0.00	0.0	1.445	0.092	10	3	2	2
PL.61420	PL.61221	C	6 A (CWC)	7.38Y	122.9	0.15	2.07	22.49	16	160	43	97	0.18	0.1	1.297	0.152	10	3	1	21
PL.61421	PL.61420	C	6 A (CWC)	7.38Y	122.9	0.01	2.08	1.22	1	9	2	98	0.00	0.0	1.400	0.103	2	1	1	2
PL.33628	PL.61421	C	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.94	1	7	2	96	0.00	0.0	1.418	0.017	7	2	1	1
PL.61419	PL.61420	C	6 A (CWC)	7.37Y	122.9	0.05	2.12	19.87	14	141	38	97	0.05	0.0	1.359	0.062	17	4	1	18
PL.61422	PL.61419	C	6 A (CWC)	7.37Y	122.8	0.04	2.16	17.54	13	125	34	96	0.03	0.0	1.404	0.046	0	0	0	17
PL.61416	PL.61422	C	6 A (CWC)	7.37Y	122.8	0.01	2.17	1.19	1	9	2	98	0.00	0.0	1.648	0.243	9	2	1	1
PL.61417	PL.61422	C	6 A (CWC)	7.37Y	122.8	0.08	2.24	14.22	10	101	27	97	0.06	0.1	1.531	0.127	7	2	2	13
PL.61183	PL.61417	C	6 A (CWC)	7.36Y	122.7	0.04	2.28	13.21	9	94	25	97	0.03	0.0	1.592	0.061	0	0	0	11
PL.61182	PL.61183	C	#2 ACSR	7.36Y	122.7	0.02	2.29	7.48	4	53	14	97	0.01	0.0	1.668	0.076	11	3	1	4
PL.53806	PL.61182	C	#1/0 ACSR	7.36Y	122.7	0.02	2.31	5.91	3	42	11	97	0.00	0.0	1.812	0.144	20	5	1	3
PL.59094	PL.53806	C	#1/0 ACSR	7.36Y	122.7	0.00	2.31	3.16	1	22	6	96	0.00	0.0	1.850	0.039	0	0	0	2
PL.59095	PL.59094	C	#1/0 ACSR	7.36Y	122.7	0.00	2.31	2.21	1	16	4	97	0.00	0.0	1.899	0.048	16	4	1	1
PL.59096	PL.59094	C	#1/0 ACSR	7.36Y	122.7	0.00	2.31	0.95	0	7	2	96	0.00	0.0	1.930	0.080	7	2	1	1
PL.62689	PL.61183	C	6 A (CWC)	7.36Y	122.7	0.04	2.31	5.73	4	41	11	97	0.01	0.0	1.749	0.157	8	2	1	7
PL.61185	PL.62689	C	6 A (CWC)	7.36Y	122.7	0.00	2.32	1.58	1	11	3	96	0.00	0.0	1.825	0.075	11	3	2	3
PL.61184	PL.61185	C	6 A (CWC)	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	1.993	0.168	0	0	1	1
PL.61187	PL.62689	C	#1/0 ACSR	7.36Y	122.7	0.00	2.31	3.07	1	22	6	96	0.00	0.0	1.752	0.003	0	0	0	3
PD.9101	PL.61187	C	10T	7.36Y	122.7	0.00	2.31	3.07	0	22	6	96	0.00	0.0	1.752	0.003	0	0	0	3
PL.61188	PD.9101	C	#1/0 ACSR	7.36Y	122.7	0.01	2.32	3.07	1	22	6	96	0.00	0.0	1.902	0.149	10	3	2	3
PL.61186	PL.61188	C	1/0 AL URD	7.36Y	122.7	0.00	2.32	1.67	1	12	3	97	0.00	0.0	1.959	0.057	12	3	1	1
PL.61418	PL.61422	C	6 A (CWC)	7.37Y	122.8	0.00	2.16	2.13	2	15	4	97	0.00	0.0	1.408	0.003	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.4996	PL.61418	C	25T	7.37Y	122.8	0.00	2.16	2.13	0	15	4	97	0.00	0.0	1.408	0.003	0	0	0	3
PL.33629	PD.4996	C	6 A (CWC)	7.37Y	122.8	0.01	2.17	2.13	2	15	4	97	0.00	0.0	1.580	0.172	5	1	1	3
PL.33630	PL.33629	C	6 A (CWC)	7.37Y	122.8	0.01	2.18	1.40	1	10	3	96	0.00	0.0	1.671	0.091	2	0	1	2
PL.33631	PL.33630	C	6 A (CWC)	7.37Y	122.8	0.00	2.18	1.17	1	8	2	97	0.00	0.0	1.741	0.070	8	2	1	1
PL.61219	PL.63853	C	6 A (CWC)	7.39Y	123.2	0.05	1.78	21.78	16	145	70	90	0.06	0.0	1.035	0.053	0	0	0	1
PL.33543	PL.61219	C	6 A (CWC)	7.39Y	123.2	0.01	1.79	21.78	16	145	70	90	0.01	0.0	1.050	0.015	145	70	1	1
PL.62400	PL.62402	A	#4 ACSR	7.47Y	124.4	0.00	0.57	3.26	3	23	6	97	0.00	0.0	0.382	0.000	0	0	0	3
PD.4922	PL.62400	A	75QA	7.47Y	124.4	0.00	0.57	3.26	4	23	6	97	0.00	0.0	0.382	0.000	0	0	0	3
PL.33320	PD.4922	A	#4 ACSR	7.47Y	124.4	0.00	0.57	3.26	3	23	6	97	0.00	0.0	0.418	0.037	13	4	2	3
PL.61189	PL.33320	A	#1/0 ACSR	7.47Y	124.4	0.00	0.57	1.39	1	10	3	96	0.00	0.0	0.441	0.023	10	3	1	1
PL.62733	PL.62402	B	#1/0 ACSR	7.47Y	124.4	0.00	0.57	1.43	1	10	3	96	0.00	0.0	0.384	0.003	0	0	0	2
PD.9519	PL.62733	B	25T	7.47Y	124.4	0.00	0.57	1.43	0	10	3	96	0.00	0.0	0.384	0.003	0	0	0	2
PL.62734	PD.9519	B	#1/0 ACSR	7.47Y	124.4	0.00	0.57	1.43	1	10	3	96	0.00	0.0	0.403	0.019	9	2	1	2
PL.62735	PL.62734	B	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.19	0	1	0	100	0.00	0.0	0.460	0.057	0	0	0	1
PL.62736	PL.62735	B	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.19	0	1	0	100	0.00	0.0	0.517	0.057	0	0	0	1
PL.62737	PL.62736	B	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.19	0	1	0	100	0.00	0.0	0.574	0.057	1	0	1	1
PL.33493	PL.33515	A	#4 ACSR	7.47Y	124.5	0.00	0.50	1.43	1	10	3	96	0.00	0.0	0.350	0.000	0	0	0	1
PD.5011	PL.33493	A	75QA	7.47Y	124.5	0.00	0.50	1.43	2	10	3	96	0.00	0.0	0.350	0.000	0	0	0	1
PL.33494	PD.5011	A	#4 ACSR	7.47Y	124.5	0.00	0.50	1.43	1	10	3	96	0.00	0.0	0.365	0.016	10	3	1	1
PL.34392	PL.33549	C	#4 ACSR	7.49Y	124.8	0.00	0.17	5.20	4	38	10	97	0.00	0.0	0.194	0.001	0	0	0	3
PD.4921	PL.34392	C	75QA	7.49Y	124.8	0.00	0.17	5.20	7	38	10	97	0.00	0.0	0.194	0.001	0	0	0	3
PL.34393	PD.4921	C	#4 ACSR	7.49Y	124.8	0.01	0.18	5.20	4	38	10	97	0.00	0.0	0.233	0.039	27	7	2	3
PL.64050	PL.34393	C	#1/0 ACSR	7.49Y	124.8	0.00	0.18	1.48	1	11	3	96	0.00	0.0	0.294	0.061	11	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	9428	0	0	0	0	0	265		0.00	9693	Lowest Voltage =	118.27	on Element PL.57880
KVAR	2599	0	0	0	0	0	397			2996	Max Accm VoltD =	6.73	on Element PL.57880
											Max Elem VoltD =	0.51	on Element PL.33276

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Bush

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

12/15/2009 12:20 Page 68

Units Displayed In Volts
-Base Voltage:120.0-

Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																Cons	Cons	On	Thru	
