

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Goose Rock		ABC	SRC-Goose	7.50Y	125.0	0.00	0.00	542.64	0	11595	3825	95	0.00	0.0	0.000	0.000	0	0	0	2558
PL.1255	Goose Rock	ABC	1/0 AL URD	7.50Y	125.0	0.01	0.01	59.29	35	1282	369	96	0.09	0.0	0.007	0.007	0	0	0	273
PL.7157	PL.1255	ABC	1/0 AL URD	7.50Y	125.0	0.00	0.01	59.29	35	1282	369	96	0.03	0.0	0.009	0.002	0	0	0	273
----- Feeder No. 2 (Big Creek F2) Beginning with Device PD.1527 -----																				
PD.1527	PL.7157	ABC	480VWE	7.50Y	125.0	0.00	0.01	59.29	0	1282	369	96	0.00	0.0	0.009	0.002	0	0	0	273
PL.7158	PD.1527	ABC	1/0 AL URD	7.50Y	125.0	0.01	0.02	59.29	35	1282	369	96	0.13	0.0	0.020	0.011	0	0	0	273
PL.1388	PL.7158	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	59.29	11	1282	369	96	0.00	0.0	0.023	0.002	0	0	0	273
PD.204-A	PL.1388	ABC	Closed	7.50Y	125.0	0.00	0.02	59.29	0	1282	369	96	0.00	0.0	0.023	0.002	0	0	0	273
PD.204-B	PD.204-A	ABC	Closed	7.50Y	125.0	0.00	0.02	59.29	0	1282	369	96	0.00	0.0	0.023	0.002	0	0	0	273
PL.1389	PD.204-B	ABC	397 SPACER	7.50Y	125.0	0.02	0.04	59.29	11	1282	369	96	0.04	0.0	0.106	0.083	0	0	0	273
PL.47	PL.1389	ABC	397 SPACER	7.50Y	125.0	0.01	0.05	58.97	11	1275	366	96	0.02	0.0	0.150	0.044	12	3	3	270
PL.90	PL.47	ABC	397 SPACER	7.50Y	124.9	0.01	0.06	58.41	11	1263	363	96	0.02	0.0	0.196	0.046	0	0	1	267
PL.91	PL.90	ABC	397 SPACER	7.50Y	124.9	0.01	0.06	58.41	11	1263	363	96	0.01	0.0	0.227	0.031	30	8	4	266
PL.1298	PL.91	ABC	397 SPACER	7.50Y	124.9	0.01	0.07	57.05	11	1233	354	96	0.02	0.0	0.281	0.055	0	0	4	262
PL.92	PL.1298	ABC	397 SPACER	7.50Y	124.9	0.00	0.08	57.05	11	1233	354	96	0.01	0.0	0.304	0.023	9	3	1	258
PL.1297	PL.92	ABC	397 SPACER	7.49Y	124.9	0.01	0.09	56.61	11	1224	351	96	0.02	0.0	0.358	0.054	0	0	0	257
PL.48	PL.1297	ABC	397 SPACER	7.49Y	124.9	0.01	0.09	56.13	11	1213	348	96	0.01	0.0	0.388	0.030	7	2	1	253
PL.1296	PL.48	ABC	397 SPACER	7.49Y	124.9	0.01	0.10	55.79	11	1206	346	96	0.02	0.0	0.446	0.058	8	2	2	252
PL.94	PL.1296	ABC	397 SPACER	7.49Y	124.9	0.00	0.11	55.42	11	1198	343	96	0.01	0.0	0.474	0.027	13	4	2	250
PL.1295	PL.94	ABC	397 SPACER	7.49Y	124.9	0.01	0.11	54.82	11	1185	340	96	0.02	0.0	0.521	0.047	4	1	2	248
PL.95	PL.1295	ABC	397 SPACER	7.49Y	124.9	0.01	0.12	54.63	11	1181	338	96	0.01	0.0	0.553	0.032	36	10	1	246
PL.1294	PL.95	ABC	397 SPACER	7.49Y	124.9	0.01	0.13	52.96	10	1144	328	96	0.02	0.0	0.602	0.049	0	0	0	245
PL.96	PL.1294	ABC	397 SPACER	7.49Y	124.9	0.01	0.13	52.96	10	1144	328	96	0.01	0.0	0.640	0.039	20	5	7	245
PL.97	PL.96	ABC	397 SPACER	7.49Y	124.9	0.01	0.14	52.05	10	1125	322	96	0.02	0.0	0.691	0.051	0	0	0	238
PL.1308	PL.97	C	#4 ACSR	7.49Y	124.9	0.00	0.14	1.07	1	8	2	97	0.00	0.0	0.695	0.004	0	0	0	1
PD.167	PL.1308	C	65QA	7.49Y	124.9	0.00	0.14	1.07	0	8	2	97	0.00	0.0	0.695	0.004	0	0	0	1
PL.1309	PD.167	C	#4 ACSR	7.49Y	124.9	0.00	0.14	1.07	1	8	2	97	0.00	0.0	0.707	0.011	8	2	1	1
PL.1306	PL.97	A	#4 ACSR	7.49Y	124.9	0.00	0.14	3.58	3	26	7	97	0.00	0.0	0.694	0.003	0	0	0	6
PD.166	PL.1306	A	65QA	7.49Y	124.9	0.00	0.14	3.58	0	26	7	97	0.00	0.0	0.694	0.003	0	0	0	6
PL.1307	PD.166	A	#4 ACSR	7.49Y	124.9	0.01	0.15	3.58	3	26	7	97	0.00	0.0	0.776	0.082	19	5	4	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.5	PL.1307	A	#4 ACSR	7.49Y	124.8	0.00	0.15	0.99	1	7	2	96	0.00	0.0	0.878	0.102	7	2	2	2
PL.1293	PL.97	ABC	397 SPACER	7.49Y	124.9	0.01	0.15	50.50	10	1091	313	96	0.02	0.0	0.743	0.052	0	0	0	231
PL.1312	PL.1293	B	6 A (CWC)	7.49Y	124.9	0.00	0.15	1.81	1	13	4	96	0.00	0.0	0.745	0.003	0	0	0	3
PD.169	PL.1312	B	65QA	7.49Y	124.9	0.00	0.15	1.81	0	13	4	96	0.00	0.0	0.745	0.003	0	0	0	3
PL.1313	PD.169	B	6 A (CWC)	7.49Y	124.8	0.00	0.15	1.81	1	13	4	96	0.00	0.0	0.808	0.063	13	4	3	3
PL.1310	PL.1293	B	6 A (CWC)	7.49Y	124.9	0.00	0.15	1.29	1	9	3	95	0.00	0.0	0.747	0.004	0	0	0	1
PD.168	PL.1310	B	65QA	7.49Y	124.9	0.00	0.15	1.29	0	9	3	95	0.00	0.0	0.747	0.004	0	0	0	1
PL.1311	PD.168	B	6 A (CWC)	7.49Y	124.9	0.00	0.15	1.29	1	9	3	95	0.00	0.0	0.759	0.012	9	3	1	1
PL.1292	PL.1293	ABC	397 SPACER	7.49Y	124.8	0.01	0.16	49.47	10	1069	307	96	0.03	0.0	0.834	0.091	0	0	0	227
PL.1280	PL.1292	B	#4 ACSR	7.49Y	124.8	0.00	0.16	2.81	2	20	6	96	0.00	0.0	0.837	0.003	0	0	0	4
PD.158	PL.1280	B	40QA	7.49Y	124.8	0.00	0.16	2.81	7	20	6	96	0.00	0.0	0.837	0.003	0	0	0	4
PL.1281	PD.158	B	#4 ACSR	7.49Y	124.8	0.00	0.16	2.81	2	20	6	96	0.00	0.0	0.859	0.022	20	6	4	4
PL.1314	PL.1292	ABC	397 SPACER	7.49Y	124.8	0.01	0.17	48.53	9	1048	301	96	0.02	0.0	0.902	0.068	0	0	0	223
PL.1315	PL.1314	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.48	1	11	3	96	0.00	0.0	0.904	0.003	0	0	0	1
PD.170	PL.1315	B	65QA	7.49Y	124.8	0.00	0.17	1.48	0	11	3	96	0.00	0.0	0.904	0.003	0	0	0	1
PL.1316	PD.170	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.48	1	11	3	96	0.00	0.0	0.924	0.020	11	3	1	1
PL.517	PL.1314	ABC	397 SPACER	7.49Y	124.8	0.01	0.18	47.49	9	1026	294	96	0.02	0.0	0.974	0.072	6	2	1	218
PL.98	PL.517	ABC	397 SPACER	7.49Y	124.8	0.00	0.19	47.21	9	1020	292	96	0.01	0.0	0.993	0.019	0	0	0	217
PL.50	PL.98	ABC	397 SPACER	7.49Y	124.8	0.01	0.19	45.90	9	991	284	96	0.01	0.0	1.047	0.054	4	1	2	211
PL.51	PL.50	ABC	397 SPACER	7.49Y	124.8	0.01	0.20	45.73	9	988	283	96	0.01	0.0	1.085	0.039	14	4	3	209
PL.1321	PL.51	B	#2 ACSR	7.49Y	124.8	0.00	0.20	3.07	2	22	6	96	0.00	0.0	1.089	0.004	0	0	0	4
PD.173	PL.1321	B	40QA	7.49Y	124.8	0.00	0.20	3.07	8	22	6	96	0.00	0.0	1.089	0.004	0	0	0	4
PL.1322	PD.173	B	#2 ACSR	7.49Y	124.8	0.00	0.20	3.07	2	22	6	96	0.00	0.0	1.098	0.009	22	6	4	4
PL.52	PL.51	ABC	397 SPACER	7.49Y	124.8	0.00	0.20	44.05	8	951	273	96	0.01	0.0	1.107	0.021	17	5	3	202
PL.53	PL.52	ABC	397 SPACER	7.49Y	124.8	0.01	0.21	43.26	8	934	268	96	0.01	0.0	1.163	0.056	17	5	2	199
PL.54	PL.53	ABC	397 SPACER	7.49Y	124.8	0.00	0.21	42.22	8	912	262	96	0.01	0.0	1.186	0.023	0	0	0	196
PL.514	PL.54	ABC	397 SPACER	7.49Y	124.8	0.01	0.22	41.69	8	900	258	96	0.02	0.0	1.257	0.071	7	2	2	194
PL.1327	PL.514	A	#2 HdCu -	7.49Y	124.8	0.00	0.22	7.14	3	51	14	96	0.00	0.0	1.261	0.004	0	0	0	9
PD.176	PL.1327	A	65QA	7.49Y	124.8	0.00	0.22	7.14	0	51	14	96	0.00	0.0	1.261	0.004	0	0	0	9
PL.1328	PD.176	A	#2 HdCu -	7.49Y	124.8	0.00	0.22	7.14	3	51	14	96	0.00	0.0	1.265	0.004	0	0	0	9
PL.951	PL.1328	A	#2 HdCu -	7.49Y	124.8	0.00	0.23	5.10	2	37	10	97	0.00	0.0	1.302	0.037	9	2	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.511	PL.951	A	#2 HdCu -	7.49Y	124.8	0.00	0.23	3.90	2	28	8	96	0.00	0.0	1.329	0.027	28	8	5	5
PL.296	PL.1328	A	#2 ACSR	7.49Y	124.8	0.00	0.22	2.04	1	15	4	97	0.00	0.0	1.284	0.020	0	0	0	2
PL.6	PL.296	A	#2 ACSR	7.49Y	124.8	0.00	0.23	2.04	1	15	4	97	0.00	0.0	1.301	0.017	0	0	0	2
PL.55	PL.6	A	#1/0 ACSR	7.49Y	124.8	0.00	0.23	2.04	1	15	4	97	0.00	0.0	1.346	0.045	15	4	2	2
PL.1032	PL.514	ABC	397 SPACER	7.49Y	124.8	0.00	0.23	38.97	7	841	242	96	0.01	0.0	1.295	0.037	0	0	0	183
PL.1329	PL.1032	ABC	#2 HdCu -	7.49Y	124.8	0.00	0.23	12.04	5	258	80	96	0.00	0.0	1.299	0.004	0	0	0	51
PD.177	PL.1329	ABC	150QA	7.49Y	124.8	0.00	0.23	12.04	0	258	80	96	0.00	0.0	1.299	0.004	0	0	0	51
PL.1330	PD.177	ABC	#2 HdCu -	7.49Y	124.8	0.01	0.23	12.04	5	258	80	96	0.01	0.0	1.328	0.029	1	0	1	51
PL.510	PL.1330	ABC	#2 HdCu -	7.49Y	124.8	0.01	0.24	11.98	5	257	79	96	0.01	0.0	1.361	0.033	12	3	3	50
PL.509	PL.510	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.25	11.44	5	245	76	96	0.02	0.0	1.413	0.052	15	4	6	47
PL.508	PL.509	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.26	10.74	4	230	72	95	0.02	0.0	1.481	0.068	14	4	5	41
PL.506	PL.508	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.27	9.70	4	208	66	95	0.01	0.0	1.531	0.050	24	7	7	35
PL.507	PL.506	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.28	8.58	4	183	59	95	0.01	0.0	1.609	0.078	13	4	2	28
PL.1139	PL.507	A	6 A (CWC)	7.48Y	124.7	0.00	0.28	0.25	0	2	1	89	0.00	0.0	1.614	0.005	0	0	0	3
PD.98	PL.1139	A	40QA	7.48Y	124.7	0.00	0.28	0.25	1	2	1	89	0.00	0.0	1.614	0.005	0	0	0	3
PL.1140	PD.98	A	6 A (CWC)	7.48Y	124.7	0.00	0.28	0.25	0	2	1	89	0.00	0.0	1.626	0.012	2	1	3	3
PL.57	PL.507	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.29	7.89	3	168	55	95	0.00	0.0	1.638	0.028	0	0	0	23
PL.467	PL.57	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.29	7.89	3	168	55	95	0.00	0.0	1.666	0.028	23	6	2	23
PL.468	PL.467	ABC	#2 HdCu -	7.48Y	124.7	0.00	0.29	6.83	3	146	49	95	0.00	0.0	1.703	0.037	16	4	2	21
PL.292	PL.468	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.30	5.45	2	116	40	95	0.01	0.0	1.787	0.085	11	3	3	17
PL.1183	PL.292	B	#4 ACSR	7.48Y	124.7	0.00	0.30	1.98	2	14	4	96	0.00	0.0	1.794	0.006	0	0	0	2
PD.120	PL.1183	B	65QA	7.48Y	124.7	0.00	0.30	1.98	0	14	4	96	0.00	0.0	1.794	0.006	0	0	0	2
PL.1184	PD.120	B	#4 ACSR	7.48Y	124.7	0.00	0.31	1.98	2	14	4	96	0.00	0.0	1.841	0.047	14	4	2	2
PL.293	PL.292	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.31	4.27	2	90	33	94	0.00	0.0	1.897	0.109	8	2	1	12
PL.289	PL.293	ABC	#2 HdCu -	7.48Y	124.7	0.01	0.32	3.57	1	75	29	93	0.00	0.0	2.029	0.132	0	0	0	9
PL.1335	PL.289	ABC	#4 ACSR	7.48Y	124.7	0.00	0.32	3.57	3	75	29	93	0.00	0.0	2.032	0.003	0	0	0	9
PD.180	PL.1335	ABC	100QA	7.48Y	124.7	0.00	0.32	3.57	4	75	29	93	0.00	0.0	2.032	0.003	0	0	0	9
PL.1336	PD.180	ABC	#4 ACSR	7.48Y	124.7	0.01	0.33	3.57	3	75	29	93	0.01	0.0	2.115	0.083	6	2	2	9
PL.66	PL.1336	ABC	#4 ACSR	7.48Y	124.7	0.00	0.33	1.98	2	40	19	90	0.00	0.0	2.122	0.007	40	19	1	1
PL.1339	PL.1336	A	#4 ACSR	7.48Y	124.7	0.00	0.33	1.48	1	11	3	96	0.00	0.0	2.118	0.003	0	0	0	3
PD.182	PL.1339	A	15T	7.48Y	124.7	0.00	0.33	1.48	0	11	3	96	0.00	0.0	2.118	0.003	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1340	PD.182	A	#4 ACSR	7.48Y	124.7	0.01	0.34	1.48	1	11	3	96	0.00	0.0	2.217	0.099	0	0	0	3
PL.67	PL.1340	A	#4 ACSR	7.48Y	124.7	0.00	0.34	0.95	1	7	2	96	0.00	0.0	2.253	0.036	7	2	1	1
PL.69	PL.1340	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.54	0	4	1	97	0.00	0.0	2.263	0.046	0	0	0	2
PL.68	PL.69	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.00	0	0	0	100	0.00	0.0	2.277	0.014	0	0	0	0
PL.70	PL.69	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.54	0	4	1	97	0.00	0.0	2.343	0.081	4	1	2	2
PL.1337	PL.1336	A	#4 ACSR	7.48Y	124.7	0.00	0.33	2.44	2	18	5	96	0.00	0.0	2.118	0.003	0	0	0	3
PD.181	PL.1337	A	65QA	7.48Y	124.7	0.00	0.33	2.44	0	18	5	96	0.00	0.0	2.118	0.003	0	0	0	3
PL.1338	PD.181	A	#4 ACSR	7.48Y	124.7	0.00	0.33	2.44	2	18	5	96	0.00	0.0	2.167	0.049	11	3	2	3
PL.918	PL.1338	A	#4 ACSR	7.48Y	124.7	0.00	0.34	0.91	1	7	2	96	0.00	0.0	2.207	0.040	7	2	1	1
PL.1333	PL.293	A	#4 ACSR	7.48Y	124.7	0.00	0.31	1.06	1	8	2	97	0.00	0.0	1.900	0.003	0	0	0	2
PD.179	PL.1333	A	40QA	7.48Y	124.7	0.00	0.31	1.06	3	8	2	97	0.00	0.0	1.900	0.003	0	0	0	2
PL.1334	PD.179	A	#4 ACSR	7.48Y	124.7	0.00	0.31	1.06	1	8	2	97	0.00	0.0	1.902	0.002	0	0	0	2
PL.99	PL.1334	A	#4 ACSR	7.48Y	124.7	0.00	0.31	0.00	0	0	0	100	0.00	0.0	1.942	0.040	0	0	1	1
PL.286	PL.1334	A	#1/0 ACSR	7.48Y	124.7	0.00	0.31	1.06	0	8	2	97	0.00	0.0	1.907	0.005	0	0	0	1
PL.65	PL.286	A	#1/0 ACSR	7.48Y	124.7	0.00	0.31	1.06	0	8	2	97	0.00	0.0	1.931	0.024	8	2	1	1
PL.1331	PL.468	A	#4 ACSR	7.48Y	124.7	0.00	0.30	1.89	1	14	4	96	0.00	0.0	1.706	0.003	0	0	0	2
PD.178	PL.1331	A	65QA	7.48Y	124.7	0.00	0.30	1.89	0	14	4	96	0.00	0.0	1.706	0.003	0	0	0	2
PL.1332	PD.178	A	6 A (CWC)	7.48Y	124.7	0.00	0.30	1.89	1	14	4	96	0.00	0.0	1.761	0.055	0	0	0	2
PL.466	PL.1332	A	#4 ACSR	7.48Y	124.7	0.00	0.30	1.89	1	14	4	96	0.00	0.0	1.784	0.023	14	4	2	2
PL.916	PL.508	C	#1/0 ACSR	7.48Y	124.7	0.00	0.26	1.14	0	8	2	97	0.00	0.0	1.524	0.043	8	2	1	1
PL.512	PL.1032	ABC	397 SPACER	7.49Y	124.8	0.01	0.24	26.93	5	583	162	96	0.01	0.0	1.397	0.102	0	0	0	132
PL.568	PL.512	A	#4 ACSR	7.48Y	124.7	0.03	0.27	25.02	19	181	50	96	0.04	0.0	1.427	0.030	0	0	0	41
PL.1261	PL.568	A	#4 ACSR	7.48Y	124.7	0.00	0.27	25.02	19	180	50	96	0.00	0.0	1.430	0.003	0	0	0	41
PD.144	PL.1261	A	50L	7.48Y	124.7	0.00	0.27	25.02	50	180	50	96	0.00	0.0	1.430	0.003	0	0	0	41
PL.1262	PD.144	A	#4 ACSR	7.48Y	124.7	0.03	0.30	25.02	19	180	50	96	0.04	0.0	1.460	0.030	19	5	6	41
PL.82	PL.1262	A	#4 ACSR	7.48Y	124.6	0.07	0.37	22.36	17	161	45	96	0.08	0.0	1.530	0.070	14	4	3	35
PL.81	PL.82	A	#4 ACSR	7.48Y	124.6	0.04	0.41	17.49	13	126	35	96	0.04	0.0	1.584	0.053	14	4	5	27
PL.921	PL.81	A	#4 ACSR	7.48Y	124.6	0.00	0.41	5.14	4	37	10	97	0.00	0.0	1.597	0.013	0	0	0	9
PL.922	PL.921	A	#4 ACSR	7.47Y	124.6	0.00	0.42	5.14	4	37	10	97	0.00	0.0	1.624	0.026	22	6	4	9
PL.79	PL.922	A	#4 ACSR	7.47Y	124.6	0.00	0.42	0.90	1	7	2	96	0.00	0.0	1.654	0.031	0	0	0	3
PL.78	PL.79	A	#4 ACSR	7.47Y	124.6	0.00	0.42	0.90	1	7	2	96	0.00	0.0	1.708	0.054	6	2	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.77	PL.78	A	#4 ACSR	7.47Y	124.6	0.00	0.42	0.01	0	0	0	100	0.00	0.0	1.763	0.056	0	0	1	1
PL.83	PL.922	A	#4 ACSR	7.47Y	124.6	0.00	0.42	1.12	1	8	2	97	0.00	0.0	1.627	0.003	0	0	0	2
PL.80	PL.83	A	#4 ACSR	7.47Y	124.6	0.00	0.42	1.12	1	8	2	97	0.00	0.0	1.691	0.064	8	2	2	2
PL.570	PL.81	A	#4 ACSR	7.47Y	124.6	0.02	0.43	10.47	8	75	21	96	0.01	0.0	1.625	0.041	0	0	0	13
PL.571	PL.570	A	#4 ACSR	7.47Y	124.6	0.02	0.45	10.47	8	75	21	96	0.01	0.0	1.668	0.044	15	4	2	13
PL.76	PL.571	A	#4 ACSR	7.47Y	124.5	0.02	0.47	8.43	6	61	17	96	0.01	0.0	1.727	0.058	7	2	1	11
PL.294	PL.76	A	#4 ACSR	7.47Y	124.5	0.02	0.49	7.46	6	54	15	96	0.01	0.0	1.789	0.062	0	0	0	10
PL.295	PL.294	A	#4 ACSR	7.47Y	124.5	0.03	0.51	7.46	6	54	15	96	0.01	0.0	1.869	0.081	5	2	1	10
PL.89	PL.295	A	#4 ACSR	7.47Y	124.5	0.00	0.52	1.42	1	10	3	96	0.00	0.0	1.901	0.032	10	3	1	1
PL.87	PL.295	A	#4 ACSR	7.47Y	124.5	0.02	0.53	4.13	3	30	8	97	0.00	0.0	1.964	0.095	0	0	1	7
PL.574	PL.87	A	#4 ACSR	7.47Y	124.5	0.01	0.54	4.13	3	30	8	97	0.00	0.0	2.043	0.079	17	5	2	6
PL.575	PL.574	A	#4 ACSR	7.47Y	124.5	0.00	0.55	1.79	1	13	4	96	0.00	0.0	2.096	0.053	6	2	1	4
PL.576	PL.575	A	#4 ACSR	7.47Y	124.5	0.00	0.55	0.96	1	7	2	96	0.00	0.0	2.107	0.011	5	1	2	3
PL.86	PL.576	A	#4 ACSR	7.47Y	124.5	0.00	0.55	0.23	0	2	0	100	0.00	0.0	2.169	0.062	0	0	0	1
PL.578	PL.86	A	#4 ACSR	7.47Y	124.5	0.00	0.55	0.23	0	2	0	100	0.00	0.0	2.236	0.067	0	0	0	1
PL.579	PL.578	A	#4 ACSR	7.47Y	124.5	0.00	0.55	0.23	0	2	0	100	0.00	0.0	2.308	0.072	0	0	0	1
PL.577	PL.579	A	#4 ACSR	7.47Y	124.5	0.00	0.55	0.23	0	2	0	100	0.00	0.0	2.359	0.051	2	0	1	1
PL.88	PL.295	A	#4 ACSR	7.47Y	124.5	0.00	0.52	1.16	1	8	2	97	0.00	0.0	1.923	0.054	8	2	1	1
PL.85	PL.82	A	8 A (CWC)	7.48Y	124.6	0.01	0.38	2.93	3	21	6	96	0.00	0.0	1.562	0.032	5	1	1	5
PL.84	PL.85	A	8 A (CWC)	7.48Y	124.6	0.00	0.38	2.22	2	16	4	97	0.00	0.0	1.595	0.033	5	1	2	4
PL.572	PL.84	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	1.58	1	11	3	96	0.00	0.0	1.602	0.007	0	0	0	2
PL.573	PL.572	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	1.58	1	11	3	96	0.00	0.0	1.626	0.024	11	3	2	2
PL.502	PL.512	ABC	397 SPACER	7.49Y	124.8	0.01	0.24	18.59	4	402	112	96	0.00	0.0	1.493	0.096	0	0	0	91
PL.504	PL.502	ABC	397 SPACER	7.49Y	124.8	0.01	0.25	18.53	4	401	112	96	0.01	0.0	1.624	0.131	0	0	0	90
PL.1143	PL.504	A	#4 ACSR	7.49Y	124.8	0.00	0.25	0.00	0	0	0	100	0.00	0.0	1.628	0.004	0	0	0	0
PD.100	PL.1143	A	40QA	7.49Y	124.8	0.00	0.25	0.00	0	0	0	100	0.00	0.0	1.628	0.004	0	0	0	0
PL.1144	PD.100	A	#4 ACSR	7.49Y	124.8	0.00	0.25	0.00	0	0	0	100	0.00	0.0	1.635	0.007	0	0	0	0
PL.499	PL.504	ABC	397 SPACER	7.48Y	124.7	0.01	0.26	18.53	4	401	112	96	0.01	0.0	1.789	0.165	0	0	0	90
PL.494	PL.499	ABC	397 SPACER	7.48Y	124.7	0.01	0.27	18.53	4	401	111	96	0.01	0.0	2.048	0.260	7	2	1	90
PL.487	PL.494	ABC	397 SPACER	7.48Y	124.7	0.00	0.28	18.20	4	394	109	96	0.00	0.0	2.117	0.068	0	0	0	89
PL.485	PL.487	ABC	397 SPACER	7.48Y	124.7	0.01	0.28	18.20	4	394	109	96	0.00	0.0	2.225	0.108	8	2	1	89

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.100	PL.485	ABC	397 SPACER	7.48Y	124.7	0.00	0.28	17.85	3	386	107	96	0.00	0.0	2.241	0.016	5	1	1	88
PL.482	PL.100	ABC	397 SPACER	7.48Y	124.7	0.00	0.29	17.13	3	371	103	96	0.00	0.0	2.312	0.072	8	2	1	84
PL.480	PL.482	ABC	397 SPACER	7.48Y	124.7	0.00	0.29	16.75	3	362	101	96	0.00	0.0	2.371	0.059	0	0	0	83
PL.478	PL.480	ABC	336 MCM AC	7.48Y	124.7	0.01	0.29	16.75	3	362	101	96	0.01	0.0	2.416	0.045	0	0	0	83
PL.1349	PL.478	ABC	336 MCM AC	7.48Y	124.7	0.01	0.30	16.75	3	362	101	96	0.01	0.0	2.460	0.045	0	0	0	83
PL.58	PL.1349	ABC	336 MCM AC	7.48Y	124.7	0.00	0.30	15.46	3	334	93	96	0.01	0.0	2.487	0.027	0	0	0	78
PL.1352	PL.58	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	2.37	1	17	5	96	0.00	0.0	2.490	0.003	0	0	0	3
PD.187	PL.1352	C	65QA	7.48Y	124.7	0.00	0.30	2.37	0	17	5	96	0.00	0.0	2.490	0.003	0	0	0	3
PL.1353	PD.187	C	#1/0 ACSR	7.48Y	124.7	0.02	0.32	2.37	1	17	5	96	0.00	0.0	2.863	0.373	0	0	0	3
PL.17	PL.1353	C	#4 ACSR	7.48Y	124.7	0.00	0.33	1.87	1	13	4	96	0.00	0.0	2.904	0.041	13	4	2	2
PL.18	PL.1353	C	#4 ACSR	7.48Y	124.7	0.00	0.32	0.51	0	4	1	97	0.00	0.0	2.948	0.084	4	1	1	1
PL.1148	PL.58	ABC	336 MCM AC	7.48Y	124.7	0.01	0.31	14.66	3	317	88	96	0.02	0.0	2.595	0.108	0	0	0	75
PL.59	PL.1148	ABC	336 MCM AC	7.48Y	124.7	0.00	0.32	14.60	3	316	88	96	0.01	0.0	2.623	0.029	0	0	0	74
PL.472	PL.59	ABC	336 MCM AC	7.48Y	124.7	0.01	0.33	14.49	3	313	87	96	0.01	0.0	2.705	0.082	0	0	0	73
PL.1358	PL.472	A	#1/0 ACSR	7.48Y	124.7	0.00	0.33	0.43	0	3	1	95	0.00	0.0	2.709	0.003	0	0	0	2
PD.190	PL.1358	A	40QA	7.48Y	124.7	0.00	0.33	0.43	1	3	1	95	0.00	0.0	2.709	0.003	0	0	0	2
PL.1359	PD.190	A	#1/0 ACSR	7.48Y	124.7	0.00	0.33	0.43	0	3	1	95	0.00	0.0	2.721	0.012	3	1	2	2
PL.439	PL.472	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	14.35	3	310	86	96	0.00	0.0	2.733	0.027	1	0	1	71
PL.440	PL.439	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	14.31	3	309	86	96	0.00	0.0	2.759	0.027	0	0	0	70
PL.13	PL.440	ABC	336 MCM AC	7.48Y	124.7	0.00	0.34	13.72	3	297	82	96	0.01	0.0	2.805	0.046	0	0	0	68
PL.19	PL.13	A	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.83	0	6	2	95	0.00	0.0	2.831	0.026	6	2	1	1
PL.441	PL.13	ABC	336 MCM AC	7.48Y	124.7	0.01	0.35	13.45	3	291	81	96	0.02	0.0	2.916	0.111	0	0	0	67
PL.444	PL.441	ABC	336 MCM AC	7.48Y	124.6	0.00	0.35	13.45	3	291	81	96	0.00	0.0	2.940	0.024	3	1	1	67
PL.445	PL.444	ABC	336 MCM AC	7.48Y	124.6	0.01	0.36	13.33	3	288	80	96	0.01	0.0	2.994	0.054	0	0	0	66
PL.447	PL.445	ABC	336 MCM AC	7.48Y	124.6	0.01	0.36	13.03	3	282	78	96	0.01	0.0	3.074	0.080	6	2	1	63
PL.449	PL.447	ABC	336 MCM AC	7.48Y	124.6	0.01	0.37	12.78	2	276	77	96	0.01	0.0	3.178	0.103	0	0	0	62
PL.15	PL.449	ABC	336 MCM AC	7.48Y	124.6	0.01	0.38	12.65	2	273	76	96	0.01	0.0	3.236	0.058	0	0	0	60
PL.453	PL.15	ABC	336 MCM AC	7.48Y	124.6	0.01	0.38	12.65	2	273	76	96	0.01	0.0	3.290	0.054	3	1	2	60
PL.454	PL.453	ABC	336 MCM AC	7.48Y	124.6	0.00	0.39	12.49	2	270	75	96	0.01	0.0	3.342	0.053	0	0	0	58
PL.455	PL.454	ABC	336 MCM AC	7.48Y	124.6	0.01	0.40	11.93	2	258	71	96	0.01	0.0	3.433	0.090	0	0	0	56
PL.1161	PL.455	A	#1/0 ACSR	7.48Y	124.6	0.00	0.40	1.72	1	12	3	97	0.00	0.0	3.437	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PD.109	PL.1161	A	40QA	7.48Y	124.6	0.00	0.40	1.72	4	12	3	97	0.00	0.0	3.437	0.005	0	0	0	2
PL.1162	PD.109	A	#1/0 ACSR	7.48Y	124.6	0.00	0.40	1.72	1	12	3	97	0.00	0.0	3.447	0.010	12	3	2	2
PL.458	PL.455	ABC	336 MCM AC	7.48Y	124.6	0.01	0.41	11.36	2	246	68	96	0.01	0.0	3.547	0.115	0	0	0	54
PL.1165	PL.458	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.33	0	2	1	89	0.00	0.0	3.552	0.005	0	0	0	1
PD.111	PL.1165	A	40QA	7.48Y	124.6	0.00	0.41	0.33	1	2	1	89	0.00	0.0	3.552	0.005	0	0	0	1
PL.1166	PD.111	A	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.33	0	2	1	89	0.00	0.0	3.588	0.037	2	1	1	1
PL.436	PL.458	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	9.24	2	200	55	96	0.00	0.0	3.599	0.052	5	1	1	44
PL.437	PL.436	ABC	336 MCM AC	7.47Y	124.6	0.01	0.42	9.00	2	194	54	96	0.01	0.0	3.708	0.108	0	0	0	43
PL.246	PL.437	ABC	336 MCM AC	7.47Y	124.6	0.00	0.42	9.00	2	194	54	96	0.00	0.0	3.762	0.054	0	0	0	43
PL.1021	PL.246	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	2.38	1	17	5	96	0.00	0.0	3.766	0.005	0	0	0	4
PD.36	PL.1021	C	40QA	7.47Y	124.6	0.00	0.42	2.38	6	17	5	96	0.00	0.0	3.766	0.005	0	0	0	4
PL.1022	PD.36	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	2.38	1	17	5	96	0.00	0.0	3.786	0.020	17	5	4	4
PL.16	PL.246	ABC	336 MCM AC	7.47Y	124.6	0.00	0.42	8.20	2	177	49	96	0.00	0.0	3.816	0.054	0	0	0	39
PL.1171	PL.16	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.53	0	4	1	97	0.00	0.0	3.821	0.005	0	0	0	2
PD.114	PL.1171	C	40QA	7.47Y	124.6	0.00	0.42	0.53	1	4	1	97	0.00	0.0	3.821	0.005	0	0	0	2
PL.1172	PD.114	C	#1/0 ACSR	7.47Y	124.6	0.00	0.42	0.53	0	4	1	97	0.00	0.0	3.837	0.016	4	1	2	2
PL.433	PL.16	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	8.03	2	173	48	96	0.00	0.0	3.865	0.049	6	2	1	37
PL.434	PL.433	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	7.76	1	168	46	96	0.00	0.0	3.904	0.038	8	2	1	36
PL.431	PL.434	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	3.30	1	71	20	96	0.00	0.0	3.919	0.016	0	0	0	14
PL.10586	PL.431	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	3.30	1	71	20	96	0.00	0.0	3.969	0.050	5	1	1	14
PL.10587	PL.10586	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	3.09	1	67	18	97	0.00	0.0	4.021	0.051	7	2	1	13
PL.10585	PL.10587	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	2.77	1	60	17	96	0.00	0.0	4.060	0.039	0	0	0	12
PL.412	PL.10585	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	1.36	0	29	8	96	0.00	0.0	4.155	0.095	1	0	1	8
PL.416	PL.412	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	1.31	0	28	8	96	0.00	0.0	4.199	0.043	0	0	0	7
PL.417	PL.416	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.48	0	10	3	96	0.00	0.0	4.347	0.148	0	0	0	3
PL.421	PL.417	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.20	0	4	1	97	0.00	0.0	4.493	0.146	0	0	0	2
PL.65780	PL.421	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.09	0	2	1	89	0.00	0.0	4.548	0.055	0	0	0	1
PL.65781	PL.65780	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.09	0	2	1	89	0.00	0.0	4.700	0.152	2	1	1	1
PL.1371	PL.65781	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.747	0.046	0	0	0	0
PL.1372	PL.1371	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.749	0.003	0	0	0	0
PD.147-A	PL.1372	ABC	Open	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.749	0.003	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1017	PL.421	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	0.33	0	2	1	89	0.00	0.0	4.498	0.005	0	0	0	1
PD.34	PL.1017	A	40QA	7.47Y	124.6	0.00	0.43	0.33	1	2	1	89	0.00	0.0	4.498	0.005	0	0	0	1
PL.1018	PD.34	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	0.33	0	2	1	89	0.00	0.0	4.506	0.008	2	1	1	1
PL.1369	PL.417	C	6 A (CWC)	7.47Y	124.6	0.00	0.43	0.83	1	6	2	95	0.00	0.0	4.350	0.003	0	0	0	1
PD.195	PL.1369	C	40QA	7.47Y	124.6	0.00	0.43	0.83	2	6	2	95	0.00	0.0	4.350	0.003	0	0	0	1
PL.1370	PD.195	C	6 A (CWC)	7.47Y	124.6	0.00	0.44	0.83	1	6	2	95	0.00	0.0	4.402	0.052	6	2	1	1
PL.1173	PL.416	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.203	0.005	0	0	0	0
PD.115	PL.1173	C	40QA	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.203	0.005	0	0	0	0
PL.1174	PD.115	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	4.212	0.009	0	0	0	0
PL.1175	PL.416	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	2.50	1	18	5	96	0.00	0.0	4.203	0.005	0	0	0	4
PD.116	PL.1175	A	40QA	7.47Y	124.6	0.00	0.43	2.50	6	18	5	96	0.00	0.0	4.203	0.005	0	0	0	4
PL.1176	PD.116	A	#1/0 ACSR	7.47Y	124.6	0.00	0.44	2.50	1	18	5	96	0.00	0.0	4.226	0.022	4	1	1	4
PL.413	PL.1176	A	#4 ACSR	7.47Y	124.6	0.00	0.44	2.01	2	14	4	96	0.00	0.0	4.254	0.028	8	2	2	3
PL.414	PL.413	A	#4 ACSR	7.47Y	124.6	0.00	0.44	0.85	1	6	2	95	0.00	0.0	4.286	0.032	6	2	1	1
PL.1167	PL.10585	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	1.08	0	8	2	97	0.00	0.0	4.065	0.005	0	0	0	3
PD.112	PL.1167	A	25T	7.47Y	124.6	0.00	0.43	1.08	0	8	2	97	0.00	0.0	4.065	0.005	0	0	0	3
PL.1168	PD.112	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	1.08	0	8	2	97	0.00	0.0	4.082	0.017	8	2	3	3
PL.1169	PL.10585	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	3.16	1	23	6	97	0.00	0.0	4.065	0.005	0	0	0	1
PD.113	PL.1169	C	40QA	7.47Y	124.6	0.00	0.43	3.16	8	23	6	97	0.00	0.0	4.065	0.005	0	0	0	1
PL.1170	PD.113	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	3.16	1	23	6	97	0.00	0.0	4.082	0.017	0	0	0	1
PL.20	PL.1170	C	#1/0 ACSR	7.47Y	124.6	0.00	0.44	3.16	1	23	6	97	0.00	0.0	4.125	0.043	23	6	1	1
PL.1019	PL.434	B	#1/0 ACSR	7.47Y	124.6	0.00	0.43	12.24	5	88	24	96	0.00	0.0	3.908	0.005	0	0	0	21
PD.35	PL.1019	B	30T	7.47Y	124.6	0.00	0.43	12.24	0	88	24	96	0.00	0.0	3.908	0.005	0	0	0	21
PL.1020	PD.35	B	#1/0 ACSR	7.47Y	124.5	0.02	0.45	12.24	5	88	24	96	0.01	0.0	3.982	0.073	10	3	2	21
PL.430	PL.1020	B	#1/0 ACSR	7.47Y	124.5	0.02	0.47	10.82	5	78	22	96	0.01	0.0	4.085	0.104	10	3	1	19
PL.73	PL.430	B	8 A (CWC)	7.47Y	124.5	0.06	0.54	9.38	9	68	19	96	0.03	0.0	4.186	0.101	0	0	1	18
PL.428	PL.73	B	#4 ACSR	7.47Y	124.4	0.01	0.55	9.38	7	68	19	96	0.01	0.0	4.222	0.036	8	2	3	17
PL.566	PL.428	B	#4 ACSR	7.46Y	124.4	0.04	0.59	8.26	6	59	16	97	0.02	0.0	4.343	0.121	3	1	2	14
PL.565	PL.566	B	#4 ACSR	7.46Y	124.4	0.01	0.61	7.84	6	56	16	96	0.01	0.0	4.383	0.040	5	1	2	12
PL.74	PL.565	B	#4 ACSR	7.46Y	124.4	0.00	0.61	0.64	0	5	1	98	0.00	0.0	4.405	0.022	5	1	2	2
PL.563	PL.565	B	#4 ACSR	7.46Y	124.4	0.02	0.63	6.52	5	47	13	96	0.01	0.0	4.466	0.083	9	3	1	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.919	PL.563	B	#4 ACSR	7.46Y	124.4	0.01	0.64	5.26	4	38	10	97	0.00	0.0	4.507	0.041	0	0	0	7
PL.564	PL.919	B	#4 ACSR	7.46Y	124.4	0.01	0.65	5.26	4	38	10	97	0.00	0.0	4.545	0.038	6	2	1	7
PL.562	PL.564	B	#4 ACSR	7.46Y	124.3	0.02	0.66	4.41	3	32	9	96	0.00	0.0	4.637	0.091	7	2	2	6
PL.561	PL.562	B	#4 ACSR	7.46Y	124.3	0.01	0.68	3.44	3	25	7	96	0.00	0.0	4.713	0.077	0	0	0	4
PL.557	PL.561	B	#4 ACSR	7.46Y	124.3	0.01	0.68	2.86	2	21	6	96	0.00	0.0	4.851	0.137	21	6	3	3
PL.559	PL.561	B	#1/0 ACSR	7.46Y	124.3	0.00	0.68	0.58	0	4	1	97	0.00	0.0	4.760	0.046	4	1	1	1
PL.1163	PL.458	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	6.02	3	43	12	96	0.00	0.0	3.552	0.005	0	0	0	9
PD.110	PL.1163	C	40QA	7.48Y	124.6	0.00	0.41	6.02	15	43	12	96	0.00	0.0	3.552	0.005	0	0	0	9
PL.1164	PD.110	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	6.02	3	43	12	96	0.00	0.0	3.568	0.017	0	0	0	9
PL.465	PL.1164	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	6.02	3	43	12	96	0.00	0.0	3.602	0.034	17	5	4	9
PL.464	PL.465	C	6 A (CWC)	7.47Y	124.6	0.01	0.42	3.67	3	26	7	97	0.00	0.0	3.645	0.043	6	2	1	5
PL.914	PL.464	C	6 A (CWC)	7.47Y	124.6	0.01	0.42	2.77	2	20	6	96	0.00	0.0	3.694	0.049	7	2	2	4
PL.463	PL.914	C	6 A (CWC)	7.47Y	124.6	0.00	0.43	1.83	1	13	4	96	0.00	0.0	3.756	0.062	9	3	1	2
PL.462	PL.463	C	6 A (CWC)	7.47Y	124.6	0.00	0.43	0.54	0	4	1	97	0.00	0.0	3.810	0.054	0	0	0	1
PL.461	PL.462	C	6 A (CWC)	7.47Y	124.6	0.00	0.43	0.54	0	4	1	97	0.00	0.0	3.833	0.023	4	1	1	1
PL.460	PL.461	C	6 A (CWC)	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	3.929	0.096	0	0	0	0
PL.1159	PL.454	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	1.68	1	12	3	97	0.00	0.0	3.347	0.005	0	0	0	2
PD.108	PL.1159	A	40QA	7.48Y	124.6	0.00	0.39	1.68	4	12	3	97	0.00	0.0	3.347	0.005	0	0	0	2
PL.1160	PD.108	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	1.68	1	12	3	97	0.00	0.0	3.375	0.028	12	3	2	2
PL.911	PL.1160	A	#2 ACSR	7.48Y	124.6	0.00	0.39	0.00	0	0	0	100	0.00	0.0	3.401	0.026	0	0	0	0
PL.912	PL.911	A	#2 ACSR	7.48Y	124.6	0.00	0.39	0.00	0	0	0	100	0.00	0.0	3.417	0.016	0	0	0	0
PL.1157	PL.15	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	0.00	0	0	0	100	0.00	0.0	3.240	0.005	0	0	0	0
PD.107	PL.1157	A	40QA	7.48Y	124.6	0.00	0.38	0.00	0	0	0	100	0.00	0.0	3.240	0.005	0	0	0	0
PL.1158	PD.107	A	#1/0 ACSR	7.48Y	124.6	0.00	0.38	0.00	0	0	0	100	0.00	0.0	3.251	0.010	0	0	0	0
PL.1155	PL.449	A	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	3.182	0.005	0	0	0	0
PD.106	PL.1155	A	40QA	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	3.182	0.005	0	0	0	0
PL.1156	PD.106	A	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	3.199	0.017	0	0	0	0
PL.1153	PL.449	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.38	0	3	1	95	0.00	0.0	3.182	0.005	0	0	0	2
PD.105	PL.1153	C	40QA	7.48Y	124.6	0.00	0.37	0.38	1	3	1	95	0.00	0.0	3.182	0.005	0	0	0	2
PL.1154	PD.105	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.38	0	3	1	95	0.00	0.0	3.210	0.028	3	1	2	2
PL.1367	PL.445	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.88	0	6	2	95	0.00	0.0	2.997	0.003	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.194	PL.1367	C	40QA	7.48Y	124.6	0.00	0.36	0.88	2	6	2	95	0.00	0.0	2.997	0.003	0	0	0	3
PL.1368	PD.194	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.88	0	6	2	95	0.00	0.0	3.028	0.031	4	1	2	3
PL.450	PL.1368	C	#1/0 ACSR	7.48Y	124.6	0.00	0.36	0.38	0	3	1	95	0.00	0.0	3.082	0.053	3	1	1	1
PL.1365	PL.441	C	336 MCM AC	7.48Y	124.7	0.00	0.35	0.00	0	0	0	100	0.00	0.0	2.918	0.001	0	0	0	0
PL.1360	PL.440	C	#1/0 ACSR	7.48Y	124.7	0.00	0.33	1.75	1	13	3	97	0.00	0.0	2.763	0.003	0	0	0	2
PD.191	PL.1360	C	40QA	7.48Y	124.7	0.00	0.33	1.75	4	13	3	97	0.00	0.0	2.763	0.003	0	0	0	2
PL.1361	PD.191	C	#1/0 ACSR	7.48Y	124.7	0.00	0.33	1.75	1	13	3	97	0.00	0.0	2.781	0.018	13	3	2	2
PL.1356	PL.59	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.33	0	2	1	89	0.00	0.0	2.627	0.003	0	0	0	1
PD.189	PL.1356	C	40QA	7.48Y	124.7	0.00	0.32	0.33	1	2	1	89	0.00	0.0	2.627	0.003	0	0	0	1
PL.1357	PD.189	C	#1/0 ACSR	7.48Y	124.7	0.00	0.32	0.33	0	2	1	89	0.00	0.0	2.641	0.015	2	1	1	1
PL.1354	PL.1148	C	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.19	0	1	0	100	0.00	0.0	2.598	0.003	0	0	0	1
PD.188	PL.1354	C	40QA	7.48Y	124.7	0.00	0.31	0.19	0	1	0	100	0.00	0.0	2.598	0.003	0	0	0	1
PL.1355	PD.188	C	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.19	0	1	0	100	0.00	0.0	2.631	0.033	1	0	1	1
PL.72	PL.1349	C	#1/0 ACSR	7.48Y	124.7	0.00	0.30	3.90	2	28	8	96	0.00	0.0	2.470	0.010	7	2	2	5
PL.1350	PL.72	C	8 A (CWC)	7.48Y	124.7	0.00	0.30	2.97	3	21	6	96	0.00	0.0	2.473	0.003	0	0	0	3
PD.186	PL.1350	C	25T	7.48Y	124.7	0.00	0.30	2.97	0	21	6	96	0.00	0.0	2.473	0.003	0	0	0	3
PL.1351	PD.186	C	8 A (CWC)	7.48Y	124.7	0.01	0.31	2.97	3	21	6	96	0.00	0.0	2.515	0.042	0	0	0	3
PL.547	PL.1351	C	8 A (CWC)	7.48Y	124.7	0.01	0.32	2.01	2	14	4	96	0.00	0.0	2.620	0.105	9	2	1	2
PL.544	PL.547	C	#4 ACSR	7.48Y	124.7	0.01	0.32	0.81	1	6	2	95	0.00	0.0	2.916	0.296	6	2	1	1
PL.549	PL.1351	C	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.96	0	7	2	96	0.00	0.0	2.570	0.055	7	2	1	1
PL.1282	PL.100	A	#4 ACSR	7.48Y	124.7	0.00	0.28	1.52	1	11	3	96	0.00	0.0	2.244	0.003	0	0	0	3
PD.159	PL.1282	A	65QA	7.48Y	124.7	0.00	0.28	1.52	0	11	3	96	0.00	0.0	2.244	0.003	0	0	0	3
PL.1283	PD.159	A	#4 ACSR	7.48Y	124.7	0.00	0.28	1.52	1	11	3	96	0.00	0.0	2.246	0.002	0	0	0	3
PL.101	PL.1283	A	#4 ACSR	7.48Y	124.7	0.00	0.28	0.00	0	0	0	100	0.00	0.0	2.262	0.016	0	0	0	0
PL.285	PL.1283	A	8 A (CWC)	7.48Y	124.7	0.00	0.28	1.52	2	11	3	96	0.00	0.0	2.265	0.019	0	0	0	3
PL.553	PL.285	A	8 A (CWC)	7.48Y	124.7	0.00	0.29	1.52	2	11	3	96	0.00	0.0	2.288	0.023	10	3	2	3
PL.554	PL.553	A	8 A (CWC)	7.48Y	124.7	0.00	0.29	0.17	0	1	0	100	0.00	0.0	2.329	0.041	0	0	0	1
PL.552	PL.554	A	8 A (CWC)	7.48Y	124.7	0.00	0.29	0.17	0	1	0	100	0.00	0.0	2.369	0.041	0	0	0	1
PL.551	PL.552	A	8 A (CWC)	7.48Y	124.7	0.00	0.29	0.17	0	1	0	100	0.00	0.0	2.408	0.039	1	0	1	1
PL.1341	PL.502	B	#4 ACSR	7.49Y	124.8	0.00	0.24	0.20	0	1	0	100	0.00	0.0	1.495	0.003	0	0	0	1
PD.183	PL.1341	B	40QA	7.49Y	124.8	0.00	0.24	0.20	1	1	0	100	0.00	0.0	1.495	0.003	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1342	PD.183	B	#4 ACSR	7.49Y	124.8	0.00	0.24	0.20	0	1	0	100	0.00	0.0	1.511	0.015	1	0	1	1
PL.1325	PL.54	A	#2 ACSR	7.49Y	124.8	0.00	0.21	1.60	1	12	3	97	0.00	0.0	1.190	0.004	0	0	0	2
PD.175	PL.1325	A	40QA	7.49Y	124.8	0.00	0.21	1.60	4	12	3	97	0.00	0.0	1.190	0.004	0	0	0	2
PL.1326	PD.175	A	#2 ACSR	7.49Y	124.8	0.00	0.21	1.60	1	12	3	97	0.00	0.0	1.211	0.021	12	3	2	2
PL.1323	PL.53	B	#2 ACSR	7.49Y	124.8	0.00	0.21	0.72	0	5	1	98	0.00	0.0	1.166	0.003	0	0	0	1
PD.174	PL.1323	B	40QA	7.49Y	124.8	0.00	0.21	0.72	2	5	1	98	0.00	0.0	1.166	0.003	0	0	0	1
PL.1324	PD.174	B	#2 ACSR	7.49Y	124.8	0.00	0.21	0.72	0	5	1	98	0.00	0.0	1.199	0.033	5	1	1	1
PL.1319	PL.98	B	#4 ACSR	7.49Y	124.8	0.00	0.19	3.93	3	28	8	96	0.00	0.0	0.997	0.004	0	0	0	6
PD.172	PL.1319	B	40QA	7.49Y	124.8	0.00	0.19	3.93	10	28	8	96	0.00	0.0	0.997	0.004	0	0	0	6
PL.1320	PD.172	B	#4 ACSR	7.49Y	124.8	0.00	0.19	3.93	3	28	8	96	0.00	0.0	1.004	0.007	6	2	2	6
PL.516	PL.1320	B	#4 ACSR	7.49Y	124.8	0.00	0.19	3.10	2	22	6	96	0.00	0.0	1.020	0.016	16	4	3	4
PL.4	PL.516	B	#4 ACSR	7.49Y	124.8	0.00	0.19	0.87	1	6	2	95	0.00	0.0	1.107	0.087	6	2	1	1
PL.1317	PL.1314	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.66	1	12	3	97	0.00	0.0	0.906	0.004	0	0	0	4
PD.171	PL.1317	B	65QA	7.49Y	124.8	0.00	0.17	1.66	0	12	3	97	0.00	0.0	0.906	0.004	0	0	0	4
PL.1318	PD.171	B	6 A (CWC)	7.49Y	124.8	0.00	0.17	1.66	1	12	3	97	0.00	0.0	0.926	0.020	12	3	4	4
PL.1300	PL.1297	B	#2 ACSR	7.49Y	124.9	0.00	0.09	1.45	1	10	3	96	0.00	0.0	0.361	0.003	0	0	0	4
PD.163	PL.1300	B	65T	7.49Y	124.9	0.00	0.09	1.45	0	10	3	96	0.00	0.0	0.361	0.003	0	0	0	4
PL.1301	PD.163	B	#2 ACSR	7.49Y	124.9	0.00	0.09	1.45	1	10	3	96	0.00	0.0	0.364	0.003	0	0	0	4
PL.299	PL.1301	B	#4 ACSR	7.49Y	124.9	0.00	0.09	0.99	1	7	2	96	0.00	0.0	0.381	0.018	0	0	0	3
PL.1	PL.299	B	#4 ACSR	7.49Y	124.9	0.00	0.09	0.99	1	7	2	96	0.00	0.0	0.395	0.014	7	2	3	3
PL.93	PL.1301	B	#2 ACSR	7.49Y	124.9	0.00	0.09	0.47	0	3	1	95	0.00	0.0	0.379	0.015	3	1	1	1
PL.1287	PL.1389	B	6 A (CWC)	7.50Y	125.0	0.00	0.04	0.95	1	7	2	96	0.00	0.0	0.109	0.003	0	0	0	3
PD.161	PL.1287	B	65QA	7.50Y	125.0	0.00	0.04	0.95	0	7	2	96	0.00	0.0	0.109	0.003	0	0	0	3
PL.1288	PD.161	B	#2 ACSR	7.50Y	125.0	0.00	0.04	0.95	1	7	2	96	0.00	0.0	0.131	0.023	7	2	3	3
PL.1852	Goose Rock	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	276.39	53	5867	2062	94	0.36	0.0	0.006	0.006	0	0	0	1228
PL.7155	PL.1852	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	276.39	53	5867	2061	94	0.08	0.0	0.007	0.001	0	0	0	1228

----- Feeder No. 1 (Garrad F1) Beginning with Device PD.1526 -----

PD.1526	PL.7155	ABC	480VWE	7.50Y	125.0	0.00	0.02	276.39	0	5866	2061	94	0.00	0.0	0.007	0.001	0	0	0	1228
PL.7156	PD.1526	ABC	336 MCM AC	7.49Y	124.9	0.09	0.11	276.39	53	5866	2061	94	2.74	0.0	0.049	0.043	11	3	1	1228

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1390	PL.7156	ABC	336 MCM AC	7.47Y	124.6	0.33	0.44	275.90	53	5853	2052	94	9.54	0.2	0.198	0.149	0	0	0	1227
PL.2476	PL.1390	A	#4 ACSR	7.47Y	124.6	0.00	0.44	1.08	1	8	2	97	0.00	0.0	0.203	0.005	0	0	0	4
PD.309	PL.2476	A	40QA	7.47Y	124.6	0.00	0.44	1.08	3	8	2	97	0.00	0.0	0.203	0.005	0	0	0	4
PL.2477	PD.309	A	#4 ACSR	7.47Y	124.6	0.00	0.44	1.08	1	8	2	97	0.00	0.0	0.289	0.086	6	2	2	4
PL.1392	PL.2477	A	#1/0 ACSR	7.47Y	124.6	0.00	0.44	0.20	0	1	0	100	0.00	0.0	0.331	0.042	1	0	2	2
PL.1393	PL.1390	ABC	336 MCM AC	7.45Y	124.1	0.42	0.86	275.54	53	5836	2027	94	12.23	0.2	0.389	0.191	0	0	0	1223
PL.1395	PL.1393	ABC	336 MCM AC	7.43Y	123.9	0.27	1.13	259.13	50	5469	1901	94	7.36	0.1	0.520	0.130	0	0	0	1131
PL.5262	PL.1395	C	#1/0 ACSR	7.43Y	123.9	0.00	1.13	1.17	1	8	2	97	0.00	0.0	0.523	0.004	0	0	0	2
PD.894	PL.5262	C	40QA	7.43Y	123.9	0.00	1.13	1.17	3	8	2	97	0.00	0.0	0.523	0.004	0	0	0	2
PL.5263	PD.894	C	#1/0 ACSR	7.43Y	123.9	0.00	1.13	1.17	1	8	2	97	0.00	0.0	0.540	0.017	8	2	2	2
PL.5264	PL.1395	B	#1/0 ACSR	7.43Y	123.9	0.00	1.13	9.68	4	69	19	96	0.00	0.0	0.523	0.003	0	0	0	14
PD.895	PL.5264	B	70L	7.43Y	123.9	0.00	1.13	9.68	14	69	19	96	0.00	0.0	0.523	0.003	0	0	0	14
PL.5265	PD.895	B	#1/0 ACSR	7.43Y	123.8	0.03	1.16	9.68	4	69	19	96	0.01	0.0	0.667	0.144	6	2	1	14
PL.1584	PL.5265	B	6 A (CWC)	7.43Y	123.8	0.01	1.18	8.82	6	63	17	97	0.01	0.0	0.702	0.035	0	0	0	13
PL.1401	PL.1584	B	#1/0 ACSR	7.43Y	123.8	0.00	1.18	1.86	1	13	4	96	0.00	0.0	0.749	0.047	2	1	1	2
PL.1402	PL.1401	B	#1/0 ACSR	7.43Y	123.8	0.00	1.18	1.56	1	11	3	96	0.00	0.0	0.794	0.044	11	3	1	1
PL.1585	PL.1584	B	6 A (CWC)	7.43Y	123.8	0.02	1.20	6.97	5	50	14	96	0.01	0.0	0.779	0.077	2	1	2	11
PL.1403	PL.1585	B	6 A (CWC)	7.42Y	123.7	0.06	1.26	6.69	5	48	13	97	0.02	0.0	0.968	0.189	0	0	0	9
PL.1406	PL.1403	B	#2 ACSR	7.42Y	123.7	0.00	1.26	1.46	1	10	3	96	0.00	0.0	1.094	0.126	10	3	1	1
PL.1405	PL.1403	B	8 A (CWC)	7.42Y	123.7	0.09	1.34	5.23	5	37	10	97	0.03	0.1	1.213	0.245	0	0	0	8
PL.1410	PL.1405	B	8 A (CWC)	7.42Y	123.6	0.03	1.37	5.23	5	37	10	97	0.01	0.0	1.290	0.077	0	0	0	8
PL.1411	PL.1410	B	8 A (CWC)	7.42Y	123.6	0.05	1.42	5.23	5	37	10	97	0.01	0.0	1.460	0.170	16	5	2	8
PL.1413	PL.1411	B	#2 ACSR	7.42Y	123.6	0.00	1.42	0.75	0	5	1	98	0.00	0.0	1.488	0.028	5	1	1	2
PL.1418	PL.1413	B	#2 ACSR	7.42Y	123.6	0.00	1.42	0.07	0	0	0	100	0.00	0.0	1.647	0.159	0	0	1	1
PL.1414	PL.1411	B	#4 ACSR	7.41Y	123.6	0.00	1.42	2.18	2	16	4	97	0.00	0.0	1.501	0.041	0	0	0	4
PL.1416	PL.1414	B	#4 ACSR	7.41Y	123.6	0.00	1.42	1.02	1	7	2	96	0.00	0.0	1.662	0.161	7	2	2	2
PL.1415	PL.1414	B	#4 ACSR	7.41Y	123.6	0.00	1.42	1.16	1	8	2	97	0.00	0.0	1.523	0.022	8	2	2	2
PL.1399	PL.1395	ABC	336 MCM AC	7.43Y	123.8	0.07	1.20	255.53	49	5384	1862	95	1.78	0.0	0.552	0.032	0	0	0	1115
PL.1459	PL.1399	ABC	336 MCM AC	7.42Y	123.6	0.16	1.36	254.57	49	5362	1852	95	4.40	0.1	0.633	0.081	0	0	0	1112
PL.2412	PL.1459	C	#1/0 ACSR	7.42Y	123.6	0.00	1.36	0.77	0	5	2	93	0.00	0.0	0.637	0.005	0	0	0	1
PD.276	PL.2412	C	40QA	7.42Y	123.6	0.00	1.36	0.77	2	5	2	93	0.00	0.0	0.637	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2413	PD.276	C	#1/0 ACSR	7.42Y	123.6	0.00	1.36	0.77	0	5	2	93	0.00	0.0	0.643	0.005	0	0	0	1
PL.1464	PL.2413	C	#1/0 ACSR	7.42Y	123.6	0.00	1.36	0.77	0	5	2	93	0.00	0.0	0.684	0.041	0	0	0	1
PL.1472	PL.1464	C	#2 ACSR	7.42Y	123.6	0.00	1.36	0.77	0	5	2	93	0.00	0.0	0.756	0.072	0	0	0	1
PL.1473	PL.1472	C	#2 ACSR	7.42Y	123.6	0.00	1.36	0.77	0	5	2	93	0.00	0.0	0.796	0.040	5	2	1	1
PL.1465	PL.1459	ABC	336 MCM AC	7.42Y	123.6	0.05	1.41	254.31	49	5352	1841	95	1.37	0.0	0.658	0.025	0	0	0	1111
PL.1466	PL.1465	ABC	336 MCM AC	7.41Y	123.5	0.06	1.47	254.25	49	5349	1837	95	1.69	0.0	0.689	0.031	0	0	0	1110
PL.1496	PL.1466	ABC	336 MCM AC	7.39Y	123.2	0.31	1.79	249.49	48	5246	1805	95	8.30	0.2	0.847	0.158	0	0	0	1082
PL.1580	PL.1496	ABC	336 MCM AC	7.37Y	122.8	0.37	2.15	249.49	48	5237	1785	95	9.66	0.2	1.031	0.184	0	0	0	1082
PL.1581	PL.1580	ABC	336 MCM AC	7.36Y	122.7	0.19	2.34	248.85	48	5214	1759	95	4.96	0.1	1.126	0.095	0	0	0	1080
PL.2480	PL.1581	C	#4 ACSR	7.36Y	122.7	0.00	2.34	1.30	1	9	3	95	0.00	0.0	1.131	0.005	0	0	0	3
PD.311	PL.2480	C	50QA	7.36Y	122.7	0.00	2.34	1.30	3	9	3	95	0.00	0.0	1.131	0.005	0	0	0	3
PL.2481	PD.311	C	#4 ACSR	7.36Y	122.7	0.00	2.34	1.30	1	9	3	95	0.00	0.0	1.143	0.012	0	0	0	3
PL.1499	PL.2481	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	1.30	1	9	3	95	0.00	0.0	1.179	0.037	6	2	1	3
PL.2138	PL.1499	C	#4 ACSR	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.249	0.069	0	0	0	0
PL.2139	PL.2138	C	#4 ACSR	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.329	0.080	0	0	0	0
PL.1505	PL.1499	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	0.40	0	3	1	95	0.00	0.0	1.255	0.075	3	1	2	2
PL.1506	PL.1505	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.294	0.040	0	0	0	0
PL.1498	PL.1581	ABC	336 MCM AC	7.35Y	122.6	0.08	2.42	248.42	48	5200	1745	95	2.12	0.0	1.167	0.041	0	0	0	1077
PL.1501	PL.1498	ABC	336 MCM AC	7.34Y	122.3	0.26	2.69	248.42	48	5198	1740	95	7.01	0.1	1.302	0.135	0	0	0	1077
PL.2140	PL.1501	ABC	336 MCM AC	7.33Y	122.1	0.21	2.90	248.42	48	5191	1724	95	5.69	0.1	1.412	0.109	0	0	0	1077
PL.2141	PL.2140	ABC	336 MCM AC	7.32Y	122.0	0.05	2.95	248.42	48	5185	1710	95	1.42	0.0	1.439	0.027	5	1	1	1077
PL.1507	PL.2141	ABC	336 MCM AC	7.32Y	121.9	0.11	3.06	247.13	48	5156	1699	95	2.83	0.1	1.494	0.055	0	0	0	1069
PL.1509	PL.1507	ABC	336 MCM AC	7.31Y	121.9	0.07	3.13	247.13	48	5153	1693	95	1.87	0.0	1.530	0.036	0	0	0	1069
PL.1510	PL.1509	ABC	336 MCM AC	7.31Y	121.8	0.06	3.19	247.13	48	5152	1688	95	1.66	0.0	1.563	0.032	0	0	0	1069
PL.1511	PL.1510	ABC	336 MCM AC	7.30Y	121.7	0.07	3.26	239.93	46	5002	1630	95	1.78	0.0	1.599	0.037	0	0	0	1053
PL.1522	PL.1511	ABC	336 MCM AC	7.29Y	121.5	0.19	3.45	239.08	46	4982	1621	95	4.92	0.1	1.702	0.102	9	2	1	1051
PL.1528	PL.1522	ABC	336 MCM AC	7.29Y	121.5	0.07	3.53	237.68	46	4947	1601	95	1.91	0.0	1.742	0.040	0	0	0	1045
PL.2292	PL.1528	A	#1/0 ACSR	7.29Y	121.5	0.00	3.53	1.38	1	10	3	96	0.00	0.0	1.746	0.005	0	0	0	3
PD.219	PL.2292	A	40QA	7.29Y	121.5	0.00	3.53	1.38	3	10	3	96	0.00	0.0	1.746	0.005	0	0	0	3
PL.2293	PD.219	A	#1/0 ACSR	7.29Y	121.5	0.00	3.53	1.38	1	10	3	96	0.00	0.0	1.757	0.010	10	3	3	3
PL.1529	PL.1528	ABC	336 MCM AC	7.28Y	121.4	0.08	3.60	237.22	46	4936	1594	95	1.94	0.0	1.783	0.041	0	0	0	1042

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1539	PL.1529	ABC	336 MCM AC	7.27Y	121.2	0.18	3.79	236.73	46	4924	1587	95	4.65	0.1	1.881	0.098	0	0	0	1040
PL.1542	PL.1539	ABC	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.50	1	31	9	96	0.00	0.0	1.911	0.030	0	0	0	4
PL.1543	PL.1542	ABC	#1/0 ACSR	7.27Y	121.2	0.00	3.79	0.99	0	21	6	96	0.00	0.0	1.929	0.018	21	6	1	1
PL.2328	PL.1542	C	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.50	1	11	3	96	0.00	0.0	1.915	0.005	0	0	0	3
PD.236	PL.2328	C	40QA	7.27Y	121.2	0.00	3.79	1.50	4	11	3	96	0.00	0.0	1.915	0.005	0	0	0	3
PL.2329	PD.236	C	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.50	1	11	3	96	0.00	0.0	1.953	0.037	11	3	3	3
PL.1541	PL.1539	ABC	336 MCM AC	7.27Y	121.1	0.07	3.85	235.24	45	4887	1567	95	1.68	0.0	1.917	0.036	0	0	0	1036
PL.1544	PL.1541	ABC	336 MCM AC	7.26Y	120.9	0.22	4.07	234.78	45	4876	1561	95	5.52	0.1	2.036	0.119	0	0	0	1035
PL.1547	PL.1544	ABC	336 MCM AC	7.24Y	120.7	0.18	4.25	234.78	45	4870	1548	95	4.62	0.1	2.136	0.100	0	0	0	1035
PL.1549	PL.1547	ABC	336 MCM AC	7.24Y	120.7	0.09	4.34	234.18	45	4853	1534	95	2.22	0.0	2.184	0.048	0	0	0	1033
PL.2334	PL.1549	C	#1/0 ACSR	7.24Y	120.7	0.00	4.34	0.72	0	5	1	98	0.00	0.0	2.189	0.005	0	0	0	1
PD.239	PL.2334	C	40QA	7.24Y	120.7	0.00	4.34	0.72	2	5	1	98	0.00	0.0	2.189	0.005	0	0	0	1
PL.2335	PD.239	C	#1/0 ACSR	7.24Y	120.7	0.00	4.34	0.72	0	5	1	98	0.00	0.0	2.226	0.037	5	1	1	1
PL.1550	PL.1549	ABC	336 MCM AC	7.23Y	120.5	0.17	4.51	233.94	45	4846	1527	95	4.39	0.1	2.279	0.095	0	0	0	1032
PL.1552	PL.1550	ABC	336 MCM AC	7.21Y	120.2	0.25	4.76	230.02	44	4760	1494	95	6.27	0.1	2.420	0.141	0	0	0	1021
PL.1564	PL.1552	ABC	336 MCM AC	7.20Y	120.0	0.22	4.98	230.02	44	4754	1479	95	5.62	0.1	2.546	0.126	0	0	0	1021
PL.1568	PL.1564	ABC	336 MCM AC	7.19Y	119.8	0.18	5.16	229.49	44	4737	1463	96	4.46	0.1	2.647	0.101	0	0	0	1018
PL.2322	PL.1568	A	8 A (CWC)	7.19Y	119.8	0.00	5.16	0.65	1	4	1	97	0.00	0.0	2.651	0.004	0	0	0	5
PD.233	PL.2322	A	40QA	7.19Y	119.8	0.00	5.16	0.65	2	4	1	97	0.00	0.0	2.651	0.004	0	0	0	5
PL.2323	PD.233	A	8 A (CWC)	7.19Y	119.8	0.00	5.17	0.65	1	4	1	97	0.00	0.0	2.758	0.107	0	0	0	5
PL.1574	PL.2323	A	#4 ACSR	7.19Y	119.8	0.00	5.17	0.65	0	4	1	97	0.00	0.0	2.854	0.096	0	0	0	5
PL.1578	PL.1574	A	#2 ACSR	7.19Y	119.8	0.00	5.17	0.65	0	4	1	97	0.00	0.0	2.891	0.037	4	1	5	5
PL.2320	PL.1568	ABC	336 MCM AC	7.19Y	119.8	0.01	5.17	229.27	44	4728	1452	96	0.20	0.0	2.651	0.004	0	0	0	1013
PL.2321	PL.2320	ABC	336 MCM AC	7.18Y	119.6	0.24	5.40	229.27	44	4728	1451	96	5.93	0.1	2.785	0.134	0	0	0	1013
PL.1579	PL.2321	ABC	336 MCM AC	7.16Y	119.3	0.29	5.70	229.27	44	4722	1437	96	7.38	0.2	2.952	0.167	0	0	0	1013
PL.2490	PL.1579	C	#4 ACSR	7.16Y	119.3	0.00	5.70	1.36	1	9	3	95	0.00	0.0	2.956	0.005	0	0	0	1
PD.316	PL.2490	C	15T	7.16Y	119.3	0.00	5.70	1.36	0	9	3	95	0.00	0.0	2.956	0.005	0	0	0	1
PL.2491	PD.316	C	#4 ACSR	7.16Y	119.3	0.00	5.70	1.36	1	9	3	95	0.00	0.0	2.980	0.024	9	3	1	1
PL.1593	PL.1579	ABC	336 MCM AC	7.14Y	119.0	0.28	5.98	228.28	44	4694	1414	96	7.12	0.2	3.114	0.162	0	0	0	1011
PL.2338	PL.1593	C	#2 ACSR	7.14Y	119.0	0.00	5.98	0.69	0	5	1	98	0.00	0.0	3.118	0.005	0	0	0	1
PD.241	PL.2338	C	40QA	7.14Y	119.0	0.00	5.98	0.69	2	5	1	98	0.00	0.0	3.118	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2339	PD.241	C	#2 ACSR	7.14Y	119.0	0.00	5.98	0.69	0	5	1	98	0.00	0.0	3.130	0.012	5	1	1	1
PL.2492	PL.1593	A	#2 ACSR	7.14Y	119.0	0.00	5.98	5.32	3	37	10	97	0.00	0.0	3.118	0.004	0	0	0	5
PD.317	PL.2492	A	40QA	7.14Y	119.0	0.00	5.98	5.32	13	37	10	97	0.00	0.0	3.118	0.004	0	0	0	5
PL.2493	PD.317	A	#2 ACSR	7.14Y	119.0	0.01	5.98	5.32	3	37	10	97	0.00	0.0	3.152	0.034	9	2	1	5
PL.1599	PL.2493	A	#2 ACSR	7.14Y	119.0	0.00	5.99	2.25	1	15	4	97	0.00	0.0	3.197	0.044	15	4	2	2
PL.1598	PL.2493	A	#2 ACSR	7.14Y	119.0	0.00	5.99	1.77	1	12	3	97	0.00	0.0	3.176	0.024	12	3	2	2
PL.2131	PL.1593	ABC	336 MCM AC	7.14Y	118.9	0.10	6.08	226.28	44	4645	1386	96	2.54	0.1	3.173	0.059	0	0	0	1005
PL.2132	PL.2131	ABC	336 MCM AC	7.13Y	118.8	0.13	6.21	224.76	43	4611	1372	96	3.22	0.1	3.248	0.076	1	0	1	998
PL.1603	PL.2132	ABC	336 MCM AC	7.13Y	118.8	0.03	6.24	150.62	29	3085	926	96	0.57	0.0	3.278	0.030	2	1	3	622
PL.1775	PL.1603	ABC	336 MCM AC	7.12Y	118.6	0.11	6.35	150.50	29	3082	924	96	1.79	0.1	3.372	0.094	14	4	1	619
PL.2182	PL.1775	ABC	336 MCM AC	7.12Y	118.6	0.05	6.40	149.83	29	3066	916	96	0.81	0.0	3.415	0.043	0	0	0	618
PL.2266	PL.2182	ABC	336 MCM AC	7.11Y	118.6	0.02	6.42	146.14	28	2989	893	96	0.33	0.0	3.433	0.018	0	0	0	602
PL.2562	PL.2266	ABC	336 MCM AC	7.11Y	118.6	0.00	6.42	146.14	28	2989	892	96	0.05	0.0	3.436	0.003	0	0	0	602
PD.354	PL.2562	ABC	4804C	7.11Y	118.6	0.00	6.42	146.14	0	2989	892	96	0.00	0.0	3.436	0.003	0	0	0	602
PL.2563	PD.354	ABC	336 MCM AC	7.11Y	118.5	0.03	6.45	146.14	28	2989	892	96	0.48	0.0	3.463	0.027	0	0	0	602
PL.2009	PL.2563	ABC	336 MCM AC	7.11Y	118.5	0.00	6.45	146.14	28	2988	891	96	0.02	0.0	3.464	0.001	0	0	0	602
RG.2	PL.2009	ABC	167Kkva	7.49Y	124.8	-6.24	0.22	146.14	67	2988	891	96	percent Boost= 5.00 Tap= 8.0						602	
PL.2008	RG.2	ABC	336 MCM AC	7.49Y	124.8	0.00	0.22	138.83	27	2988	891	96	0.02	0.0	3.466	0.001	0	0	0	602
PL.2179	PL.2008	ABC	336 MCM AC	7.49Y	124.8	0.03	0.24	138.83	27	2988	891	96	0.42	0.0	3.492	0.026	0	0	1	602
PL.2180	PL.2179	ABC	336 MCM AC	7.48Y	124.7	0.06	0.31	138.82	27	2988	890	96	0.95	0.0	3.550	0.059	0	0	0	601
PL.2318	PL.2180	C	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.44	0	3	1	95	0.00	0.0	3.555	0.005	0	0	0	1
PD.232	PL.2318	C	40QA	7.48Y	124.7	0.00	0.31	0.44	1	3	1	95	0.00	0.0	3.555	0.005	0	0	0	1
PL.2319	PD.232	C	#1/0 ACSR	7.48Y	124.7	0.00	0.31	0.44	0	3	1	95	0.00	0.0	3.576	0.021	3	1	1	1
PL.2130	PL.2180	ABC	336 MCM AC	7.48Y	124.6	0.06	0.37	138.67	27	2983	887	96	0.94	0.0	3.608	0.058	0	0	0	600
PL.2128	PL.2130	ABC	336 MCM AC	7.48Y	124.6	0.03	0.40	138.67	27	2983	884	96	0.45	0.0	3.636	0.028	0	0	0	600
PL.2129	PL.2128	ABC	336 MCM AC	7.47Y	124.6	0.02	0.42	109.97	21	2362	710	96	0.26	0.0	3.662	0.026	0	0	0	476
PL.2316	PL.2129	C	#4 ACSR	7.47Y	124.6	0.00	0.42	5.07	4	37	10	97	0.00	0.0	3.667	0.005	0	0	0	8
PD.231	PL.2316	C	20T	7.47Y	124.6	0.00	0.42	5.07	0	37	10	97	0.00	0.0	3.667	0.005	0	0	0	8
PL.2317	PD.231	C	#4 ACSR	7.47Y	124.6	0.01	0.43	5.07	4	37	10	97	0.00	0.0	3.734	0.067	11	3	1	8
PL.1984	PL.2317	C	6 A (CWC)	7.47Y	124.6	0.01	0.44	3.53	3	25	7	96	0.00	0.0	3.780	0.046	3	1	2	7
PL.1985	PL.1984	C	6 A (CWC)	7.47Y	124.6	0.00	0.44	1.55	1	11	3	96	0.00	0.0	3.841	0.061	5	1	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1987	PL.1985	C	6 A (CWC)	7.47Y	124.6	0.00	0.44	0.79	1	6	2	95	0.00	0.0	3.878	0.037	6	2	2	2
PL.1986	PL.1984	C	#4 ACSR	7.47Y	124.6	0.00	0.44	1.58	1	11	3	96	0.00	0.0	3.819	0.039	11	3	2	2
PL.2177	PL.2129	ABC	336 MCM AC	7.47Y	124.6	0.03	0.45	108.28	21	2325	700	96	0.32	0.0	3.695	0.033	1	0	1	468
PL.2178	PL.2177	ABC	336 MCM AC	7.47Y	124.5	0.02	0.46	108.23	21	2324	698	96	0.21	0.0	3.716	0.022	0	0	0	467
PL.2125	PL.2178	ABC	336 MCM AC	7.47Y	124.5	0.02	0.49	107.99	21	2319	696	96	0.28	0.0	3.745	0.029	0	0	0	466
PL.2173	PL.2125	ABC	336 MCM AC	7.47Y	124.4	0.07	0.56	107.35	21	2305	691	96	0.84	0.0	3.832	0.087	3	1	1	464
PL.2174	PL.2173	ABC	336 MCM AC	7.47Y	124.4	0.02	0.58	107.23	21	2301	688	96	0.25	0.0	3.858	0.026	0	0	0	463
PL.2171	PL.2174	ABC	336 MCM AC	7.46Y	124.4	0.07	0.65	106.21	20	2279	682	96	0.80	0.0	3.942	0.084	0	0	0	460
PL.2172	PL.2171	ABC	336 MCM AC	7.46Y	124.3	0.02	0.67	106.21	20	2278	680	96	0.27	0.0	3.971	0.029	8	2	5	460
PL.2170	PL.2172	ABC	336 MCM AC	7.45Y	124.2	0.09	0.76	105.83	20	2270	677	96	1.06	0.0	4.083	0.112	0	0	0	455
PL.2312	PL.2170	C	#2 ACSR	7.45Y	124.2	0.00	0.76	3.42	2	25	7	96	0.00	0.0	4.088	0.005	0	0	0	3
PD.229	PL.2312	C	20T	7.45Y	124.2	0.00	0.76	3.42	0	25	7	96	0.00	0.0	4.088	0.005	0	0	0	3
PL.2313	PD.229	C	#2 ACSR	7.45Y	124.2	0.00	0.76	3.42	2	25	7	96	0.00	0.0	4.136	0.048	25	7	3	3
PL.2122	PL.2170	ABC	336 MCM AC	7.45Y	124.2	0.04	0.80	104.69	20	2244	668	96	0.49	0.0	4.136	0.053	0	0	0	452
PL.2308	PL.2122	C	#2 ACSR	7.45Y	124.2	0.00	0.80	1.52	1	11	3	96	0.00	0.0	4.141	0.005	0	0	0	3
PD.227	PL.2308	C	40QA	7.45Y	124.2	0.00	0.80	1.52	4	11	3	96	0.00	0.0	4.141	0.005	0	0	0	3
PL.2309	PD.227	C	#2 ACSR	7.45Y	124.2	0.00	0.80	1.52	1	11	3	96	0.00	0.0	4.169	0.028	11	3	3	3
PL.1793	PL.2309	C	#2 ACSR	7.45Y	124.2	0.00	0.80	0.00	0	0	0	100	0.00	0.0	4.197	0.028	0	0	0	0
PL.2120	PL.2122	ABC	336 MCM AC	7.45Y	124.2	0.02	0.83	104.19	20	2233	664	96	0.26	0.0	4.165	0.029	0	0	0	449
PL.2175	PL.2120	ABC	336 MCM AC	7.44Y	124.0	0.13	0.96	103.84	20	2225	661	96	1.54	0.1	4.335	0.170	3	1	2	448
PL.2176	PL.2175	ABC	336 MCM AC	7.44Y	124.0	0.04	1.00	103.71	20	2220	657	96	0.49	0.0	4.389	0.054	0	0	0	446
PL.2546	PL.2176	ABC	1/0 AL URD	7.44Y	124.0	0.00	1.00	7.23	4	147	65	91	0.00	0.0	4.394	0.005	0	0	0	4
PD.344	PL.2546	ABC	40QA	7.44Y	124.0	0.00	1.00	7.23	18	147	65	91	0.00	0.0	4.394	0.005	0	0	0	4
PL.2547	PD.344	ABC	1/0 AL URD	7.44Y	124.0	0.00	1.01	7.23	4	147	65	91	0.00	0.0	4.412	0.018	0	0	0	4
PL.1795	PL.2547	ABC	1/0 AL URD	7.44Y	124.0	0.01	1.01	6.97	4	142	64	91	0.01	0.0	4.453	0.042	0	0	0	3
PL.1804	PL.1795	ABC	1/0 AL URD	7.44Y	124.0	0.01	1.02	6.97	4	142	64	91	0.00	0.0	4.518	0.065	118	57	1	3
PL.1796	PL.1804	ABC	1/0 AL URD	7.44Y	124.0	0.00	1.02	1.12	1	24	7	96	0.00	0.0	4.558	0.039	0	0	0	2
PL.1797	PL.1796	A	1/0 AL URD	7.44Y	124.0	0.00	1.02	3.34	2	24	7	96	0.00	0.0	4.560	0.002	24	7	1	1
PL.1798	PL.1796	ABC	1/0 AL URD	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	4.588	0.030	0	0	0	1
PL.1799	PL.1798	A	1/0 AL URD	7.44Y	124.0	0.00	1.02	0.01	0	0	0	100	0.00	0.0	4.590	0.002	0	0	1	1
PL.1794	PL.2547	A	1/0 AL URD	7.44Y	124.0	0.00	1.01	0.78	0	6	2	95	0.00	0.0	4.414	0.002	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2112	PL.2176	ABC	336 MCM AC	7.44Y	124.0	0.04	1.04	96.55	19	2072	590	96	0.41	0.0	4.441	0.052	3	1	2	442
PL.1802	PL.2112	A	1/0 AL URD	7.44Y	124.0	0.00	1.04	4.07	2	29	8	96	0.00	0.0	4.445	0.005	0	0	0	7
PD.214	PL.1802	A	40QA	7.44Y	124.0	0.00	1.04	4.07	10	29	8	96	0.00	0.0	4.445	0.005	0	0	0	7
PL.2007	PD.214	A	1/0 AL URD	7.44Y	124.0	0.00	1.04	4.07	2	29	8	96	0.00	0.0	4.457	0.012	0	0	0	7
PL.1801	PL.2007	A	1/0 AL URD	7.44Y	124.0	0.00	1.04	4.07	2	29	8	96	0.00	0.0	4.487	0.030	29	8	4	7
PL.1800	PL.1801	A	1/0 AL URD	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	4.513	0.026	0	0	3	3
PL.2113	PL.2112	ABC	336 MCM AC	7.43Y	123.9	0.08	1.12	95.07	18	2040	580	96	0.86	0.0	4.554	0.114	0	0	0	433
PL.2109	PL.2113	ABC	336 MCM AC	7.43Y	123.8	0.06	1.18	95.07	18	2039	578	96	0.68	0.0	4.644	0.090	0	0	0	433
PL.2278	PL.2109	B	#4 ACSR	7.43Y	123.8	0.00	1.18	1.64	1	12	3	97	0.00	0.0	4.649	0.005	0	0	0	1
PD.211	PL.2278	B	40QA	7.43Y	123.8	0.00	1.18	1.64	4	12	3	97	0.00	0.0	4.649	0.005	0	0	0	1
PL.2279	PD.211	B	#4 ACSR	7.43Y	123.8	0.00	1.19	1.64	1	12	3	97	0.00	0.0	4.675	0.027	12	3	1	1
PL.2110	PL.2109	ABC	336 MCM AC	7.42Y	123.7	0.08	1.26	94.52	18	2027	574	96	0.85	0.0	4.756	0.112	0	0	0	432
PL.2099	PL.2110	ABC	336 MCM AC	7.42Y	123.7	0.04	1.30	91.64	18	1964	554	96	0.41	0.0	4.815	0.058	2	1	1	417
PL.2282	PL.2099	A	#4 ACSR	7.42Y	123.7	0.00	1.30	3.13	2	22	6	96	0.00	0.0	4.819	0.005	0	0	0	11
PD.213	PL.2282	A	40QA	7.42Y	123.7	0.00	1.30	3.13	8	22	6	96	0.00	0.0	4.819	0.005	0	0	0	11
PL.2283	PD.213	A	#4 ACSR	7.42Y	123.7	0.00	1.31	3.13	2	22	6	96	0.00	0.0	4.846	0.027	22	6	11	11
PL.1588	PL.2099	ABC	336 MCM AC	7.42Y	123.7	0.02	1.32	90.51	17	1940	547	96	0.15	0.0	4.837	0.022	5	1	2	405
PL.1589	PL.1588	ABC	336 MCM AC	7.42Y	123.7	0.01	1.33	90.29	17	1935	545	96	0.14	0.0	4.857	0.020	0	0	0	403
PL.2095	PL.1589	ABC	336 MCM AC	7.42Y	123.6	0.03	1.37	90.29	17	1935	545	96	0.35	0.0	4.908	0.051	0	0	0	403
PL.2468	PL.2095	C	#4 ACSR	7.42Y	123.6	0.00	1.37	0.35	0	2	1	89	0.00	0.0	4.912	0.005	0	0	0	4
PD.305	PL.2468	C	40QA	7.42Y	123.6	0.00	1.37	0.35	1	2	1	89	0.00	0.0	4.912	0.005	0	0	0	4
PL.2469	PD.305	C	#4 ACSR	7.42Y	123.6	0.00	1.37	0.35	0	2	1	89	0.00	0.0	4.920	0.008	2	1	4	4
PL.2096	PL.2095	ABC	336 MCM AC	7.42Y	123.6	0.02	1.39	90.17	17	1932	543	96	0.25	0.0	4.945	0.037	0	0	0	399
PL.2360	PL.2096	C	#4 ACSR	7.42Y	123.6	0.00	1.39	1.50	1	11	3	96	0.00	0.0	4.949	0.005	0	0	0	1
PD.253	PL.2360	C	40QA	7.42Y	123.6	0.00	1.39	1.50	4	11	3	96	0.00	0.0	4.949	0.005	0	0	0	1
PL.2361	PD.253	C	#4 ACSR	7.42Y	123.6	0.00	1.39	1.50	1	11	3	96	0.00	0.0	4.978	0.029	0	0	0	1
PL.1849	PL.2361	C	#4 ACSR	7.42Y	123.6	0.00	1.39	1.50	1	11	3	96	0.00	0.0	5.008	0.030	11	3	1	1
PL.2187	PL.2096	ABC	336 MCM AC	7.42Y	123.6	0.02	1.41	89.67	17	1921	540	96	0.20	0.0	4.974	0.029	9	2	1	398
PL.2188	PL.2187	ABC	336 MCM AC	7.41Y	123.6	0.03	1.44	89.27	17	1912	537	96	0.34	0.0	5.024	0.050	0	0	0	397
PL.2094	PL.2188	ABC	336 MCM AC	7.41Y	123.5	0.02	1.46	41.53	8	890	248	96	0.08	0.0	5.081	0.057	0	0	0	182
PL.2362	PL.2094	C	#2 ACSR	7.41Y	123.5	0.00	1.46	1.18	1	8	2	97	0.00	0.0	5.086	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.254	PL.2362	C	40QA	7.41Y	123.5	0.00	1.46	1.18	3	8	2	97	0.00	0.0	5.086	0.005	0	0	0	1
PL.2363	PD.254	C	#2 ACSR	7.41Y	123.5	0.00	1.46	1.18	1	8	2	97	0.00	0.0	5.096	0.010	8	2	1	1
PL.2189	PL.2094	ABC	336 MCM AC	7.41Y	123.5	0.01	1.48	41.14	8	881	245	96	0.07	0.0	5.129	0.047	0	0	0	181
PL.2190	PL.2189	ABC	336 MCM AC	7.41Y	123.5	0.01	1.49	41.14	8	881	245	96	0.05	0.0	5.162	0.034	0	0	0	181
PL.2364	PL.2190	C	#4 ACSR	7.41Y	123.5	0.00	1.49	3.53	3	25	7	96	0.00	0.0	5.167	0.005	0	0	0	11
PD.255	PL.2364	C	40QA	7.41Y	123.5	0.00	1.49	3.53	9	25	7	96	0.00	0.0	5.167	0.005	0	0	0	11
PL.2365	PD.255	C	#4 ACSR	7.41Y	123.5	0.00	1.49	3.53	3	25	7	96	0.00	0.0	5.183	0.016	4	1	4	11
PL.1924	PL.2365	C	#4 ACSR	7.41Y	123.5	0.00	1.49	2.95	2	21	6	96	0.00	0.0	5.230	0.047	21	6	7	7
PL.2093	PL.2190	ABC	336 MCM AC	7.41Y	123.5	0.01	1.50	39.96	8	856	238	96	0.05	0.0	5.202	0.040	0	0	0	170
PL.2092	PL.2093	ABC	336 MCM AC	7.41Y	123.5	0.01	1.51	39.20	8	840	234	96	0.04	0.0	5.234	0.032	2	1	1	165
PL.1928	PL.2092	ABC	336 MCM AC	7.41Y	123.5	0.03	1.54	38.16	7	817	227	96	0.13	0.0	5.345	0.111	8	2	3	161
PL.2372	PL.1928	ABC	336 MCM AC	7.41Y	123.4	0.02	1.55	37.77	7	809	225	96	0.06	0.0	5.399	0.054	10	3	1	158
PL.2191	PL.2372	ABC	336 MCM AC	7.41Y	123.4	0.02	1.58	36.76	7	787	219	96	0.09	0.0	5.480	0.081	7	2	2	155
PL.2192	PL.2191	ABC	336 MCM AC	7.41Y	123.4	0.00	1.58	36.44	7	780	216	96	0.02	0.0	5.498	0.018	0	0	0	153
PL.2374	PL.2192	A	#4 ACSR	7.41Y	123.4	0.00	1.58	2.94	2	21	6	96	0.00	0.0	5.502	0.005	0	0	0	3
PD.259	PL.2374	A	40QA	7.41Y	123.4	0.00	1.58	2.94	7	21	6	96	0.00	0.0	5.502	0.005	0	0	0	3
PL.2375	PD.259	A	#4 ACSR	7.41Y	123.4	0.00	1.58	2.94	2	21	6	96	0.00	0.0	5.532	0.029	21	6	3	3
PL.2377	PL.2192	ABC	336 MCM AC	7.40Y	123.4	0.02	1.60	35.46	7	759	211	96	0.08	0.0	5.576	0.079	0	0	0	150
PL.2382	PL.2377	A	#4 ACSR	7.40Y	123.4	0.00	1.60	13.77	11	98	27	96	0.00	0.0	5.581	0.005	0	0	0	23
PD.262	PL.2382	A	40QA	7.40Y	123.4	0.00	1.60	13.77	34	98	27	96	0.00	0.0	5.581	0.005	0	0	0	23
PL.2383	PD.262	A	#4 ACSR	7.40Y	123.4	0.01	1.61	13.77	11	98	27	96	0.01	0.0	5.595	0.014	8	2	3	23
PL.1931	PL.2383	A	6 A (CWC)	7.40Y	123.4	0.00	1.61	1.51	1	11	3	96	0.00	0.0	5.616	0.020	2	1	1	3
PL.1932	PL.1931	A	#4 ACSR	7.40Y	123.4	0.00	1.61	1.20	1	9	2	98	0.00	0.0	5.644	0.029	8	2	1	2
PL.1933	PL.1932	A	#4 ACSR	7.40Y	123.4	0.00	1.61	0.11	0	1	0	100	0.00	0.0	5.664	0.020	1	0	1	1
PL.1930	PL.2383	A	#4 ACSR	7.40Y	123.4	0.01	1.63	11.14	9	79	22	96	0.01	0.0	5.627	0.032	14	4	1	17
PL.1938	PL.1930	A	#4 ACSR	7.40Y	123.4	0.01	1.64	9.14	7	65	18	96	0.01	0.0	5.659	0.032	0	0	0	16
PL.1939	PL.1938	A	#4 ACSR	7.40Y	123.3	0.02	1.66	9.05	7	65	18	96	0.01	0.0	5.713	0.054	0	0	0	15
PL.1941	PL.1939	A	#4 ACSR	7.40Y	123.3	0.02	1.68	9.05	7	65	18	96	0.01	0.0	5.766	0.053	14	4	3	15
PL.1942	PL.1941	A	6 A (CWC)	7.40Y	123.3	0.00	1.68	2.92	2	21	6	96	0.00	0.0	5.792	0.026	10	3	1	5
PL.1945	PL.1942	A	6 A (CWC)	7.40Y	123.3	0.00	1.69	1.55	1	11	3	96	0.00	0.0	5.843	0.051	11	3	4	4
PL.1943	PL.1941	A	#4 ACSR	7.40Y	123.3	0.01	1.69	2.91	2	21	6	96	0.00	0.0	5.829	0.063	7	2	5	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1946	PL.1943	A	#4 ACSR	7.40Y	123.3	0.00	1.69	1.99	2	14	4	96	0.00	0.0	5.876	0.047	14	4	1	1
PL.1944	PL.1941	A	6 A (CWC)	7.40Y	123.3	0.00	1.68	1.28	1	9	3	95	0.00	0.0	5.805	0.039	9	3	1	1
PL.1940	PL.1938	A	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.09	0	1	0	100	0.00	0.0	5.712	0.053	1	0	1	1
PL.2087	PL.2377	ABC	336 MCM AC	7.40Y	123.4	0.01	1.61	30.87	6	661	183	96	0.04	0.0	5.620	0.044	2	1	1	127
PL.2085	PL.2087	ABC	336 MCM AC	7.40Y	123.4	0.01	1.62	26.47	5	567	157	96	0.03	0.0	5.678	0.057	0	0	0	110
PL.2197	PL.2085	ABC	336 MCM AC	7.40Y	123.4	0.02	1.65	23.70	5	507	141	96	0.06	0.0	5.809	0.131	2	1	1	103
PL.2198	PL.2197	ABC	336 MCM AC	7.40Y	123.4	0.00	1.65	23.59	5	505	140	96	0.01	0.0	5.830	0.021	0	0	0	102
PL.2388	PL.2198	A	#2 ACSR	7.40Y	123.4	0.00	1.65	4.45	3	32	9	96	0.00	0.0	5.835	0.004	0	0	0	8
PD.265	PL.2388	A	15T	7.40Y	123.4	0.00	1.65	4.45	0	32	9	96	0.00	0.0	5.835	0.004	0	0	0	8
PL.2389	PD.265	A	#2 ACSR	7.40Y	123.3	0.00	1.65	4.45	3	32	9	96	0.00	0.0	5.844	0.009	4	1	3	8
PL.1954	PL.2389	A	#2 ACSR	7.40Y	123.3	0.00	1.65	3.93	2	28	8	96	0.00	0.0	5.863	0.019	0	0	0	5
PL.1955	PL.1954	A	#2 ACSR	7.40Y	123.3	0.01	1.66	3.93	2	28	8	96	0.00	0.0	5.918	0.054	2	1	2	5
PL.1956	PL.1955	A	#2 ACSR	7.40Y	123.3	0.01	1.67	3.58	2	26	7	97	0.00	0.0	5.965	0.047	0	0	0	3
PL.1957	PL.1956	A	#2 ACSR	7.40Y	123.3	0.01	1.67	3.58	2	26	7	97	0.00	0.0	6.034	0.070	18	5	2	3
PL.1958	PL.1957	A	#1/0 ACSR	7.40Y	123.3	0.00	1.67	1.08	0	8	2	97	0.00	0.0	6.123	0.089	0	0	0	1
PL.1959	PL.1958	A	#1/0 ACSR	7.40Y	123.3	0.00	1.67	1.08	0	8	2	97	0.00	0.0	6.156	0.033	8	2	1	1
PL.1953	PL.2198	ABC	336 MCM AC	7.40Y	123.3	0.01	1.65	22.10	4	473	131	96	0.01	0.0	5.862	0.032	0	0	0	94
PL.1962	PL.1953	C	#4 ACSR	7.40Y	123.3	0.00	1.66	1.14	1	8	2	97	0.00	0.0	5.887	0.025	8	2	1	1
PL.2570	PL.1953	ABC	336 MCM AC	7.40Y	123.3	0.01	1.66	21.72	4	465	129	96	0.02	0.0	5.915	0.052	0	0	0	93
PL.2571	PL.2570	ABC	336 MCM AC	7.40Y	123.3	0.01	1.67	21.72	4	465	129	96	0.01	0.0	5.949	0.035	7	2	1	93
PL.2202	PL.2571	ABC	336 MCM AC	7.40Y	123.3	0.00	1.67	21.41	4	458	127	96	0.00	0.0	5.960	0.011	14	4	4	92
PL.10163	PL.2202	C	#4 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	5.962	0.002	0	0	0	0
PL.2203	PL.2202	ABC	336 MCM AC	7.40Y	123.3	0.01	1.68	20.76	4	444	123	96	0.02	0.0	6.010	0.050	0	0	1	88
PL.2392	PL.2203	ABC	336 MCM AC	7.40Y	123.3	0.01	1.69	20.76	4	444	123	96	0.02	0.0	6.071	0.061	0	0	0	87
PL.2393	PL.2392	ABC	336 MCM AC	7.40Y	123.3	0.00	1.69	20.76	4	444	123	96	0.00	0.0	6.076	0.004	0	0	0	87
PL.2390	PL.2393	C	#4 ACSR	7.40Y	123.3	0.00	1.69	2.30	2	16	5	95	0.00	0.0	6.080	0.005	0	0	0	2
PD.266	PL.2390	C	20T	7.40Y	123.3	0.00	1.69	2.30	0	16	5	95	0.00	0.0	6.080	0.005	0	0	0	2
PL.2391	PD.266	C	#4 ACSR	7.40Y	123.3	0.00	1.69	2.30	2	16	5	95	0.00	0.0	6.122	0.042	16	5	2	2
PL.2530	PL.2393	A	#4 ACSR	7.40Y	123.3	0.00	1.69	3.49	3	25	7	96	0.00	0.0	6.080	0.005	0	0	0	3
PD.336	PL.2530	A	20QA	7.40Y	123.3	0.00	1.69	3.49	17	25	7	96	0.00	0.0	6.080	0.005	0	0	0	3
PL.2531	PD.336	A	#4 ACSR	7.40Y	123.3	0.00	1.69	3.49	3	25	7	96	0.00	0.0	6.095	0.015	8	2	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2204	PL.2531	A	#2 ACSR	7.40Y	123.3	0.00	1.69	2.36	1	17	5	96	0.00	0.0	6.112	0.016	9	2	1	2
PL.2205	PL.2204	A	#2 ACSR	7.40Y	123.3	0.00	1.69	1.16	1	8	2	97	0.00	0.0	6.146	0.034	8	2	1	1
PL.2083	PL.2393	ABC	336 MCM AC	7.40Y	123.3	0.01	1.69	18.83	4	403	112	96	0.01	0.0	6.117	0.042	8	2	2	82
PL.2532	PL.2083	C	#4 ACSR	7.40Y	123.3	0.00	1.69	2.22	2	16	4	97	0.00	0.0	6.122	0.005	0	0	0	3
PD.337	PL.2532	C	20QA	7.40Y	123.3	0.00	1.69	2.22	11	16	4	97	0.00	0.0	6.122	0.005	0	0	0	3
PL.2533	PD.337	C	#4 ACSR	7.40Y	123.3	0.00	1.70	2.22	2	16	4	97	0.00	0.0	6.157	0.034	16	4	3	3
PL.2084	PL.2083	ABC	336 MCM AC	7.40Y	123.3	0.01	1.70	17.70	3	379	105	96	0.01	0.0	6.158	0.041	5	1	2	77
PL.2082	PL.2084	ABC	336 MCM AC	7.40Y	123.3	0.01	1.71	17.43	3	373	103	96	0.01	0.0	6.208	0.049	10	3	2	73
PL.1965	PL.2082	B	#4 ACSR	7.39Y	123.2	0.05	1.75	20.27	16	145	40	96	0.05	0.0	6.258	0.050	0	0	0	25
PL.2206	PL.1965	B	#4 ACSR	7.39Y	123.2	0.00	1.76	5.89	5	42	12	96	0.00	0.0	6.286	0.028	31	9	5	6
PL.2207	PL.2206	B	#4 ACSR	7.39Y	123.2	0.00	1.76	1.49	1	11	3	96	0.00	0.0	6.307	0.021	11	3	1	1
PL.1966	PL.1965	B	#4 ACSR	7.39Y	123.2	0.02	1.78	14.38	11	102	28	96	0.02	0.0	6.296	0.038	0	0	1	19
PL.2560	PL.1966	B	6 A (CWC)	7.39Y	123.2	0.00	1.78	14.38	10	102	28	96	0.00	0.0	6.299	0.003	0	0	0	18
PD.353	PL.2560	B	35H	7.39Y	123.2	0.00	1.78	14.38	41	102	28	96	0.00	0.0	6.299	0.003	0	0	0	18
PL.2561	PD.353	B	6 A (CWC)	7.39Y	123.2	0.04	1.82	14.38	10	102	28	96	0.03	0.0	6.363	0.064	13	4	2	18
PL.2208	PL.2561	B	6 A (CWC)	7.39Y	123.1	0.04	1.85	12.56	9	89	25	96	0.02	0.0	6.430	0.066	12	3	2	16
PL.2081	PL.2208	B	6 A (CWC)	7.39Y	123.1	0.04	1.89	10.83	8	77	21	96	0.02	0.0	6.516	0.086	2	1	1	14
PL.1967	PL.2081	B	#4 ACSR	7.39Y	123.1	0.00	1.90	0.45	0	3	1	95	0.00	0.0	6.594	0.079	3	1	1	1
PL.2209	PL.2081	B	6 A (CWC)	7.38Y	123.1	0.03	1.93	10.12	7	72	20	96	0.02	0.0	6.595	0.079	11	3	2	12
PL.2210	PL.2209	B	6 A (CWC)	7.38Y	123.0	0.03	1.96	8.61	6	61	17	96	0.01	0.0	6.668	0.073	2	0	1	10
PL.2211	PL.2210	B	6 A (CWC)	7.38Y	123.0	0.02	1.98	8.36	6	59	16	97	0.01	0.0	6.739	0.071	10	3	1	9
PL.1968	PL.2211	B	6 A (CWC)	7.38Y	123.0	0.00	1.98	1.84	1	13	4	96	0.00	0.0	6.777	0.039	13	4	2	2
PL.2078	PL.2211	B	6 A (CWC)	7.38Y	123.0	0.05	2.03	5.06	4	36	10	96	0.01	0.0	6.965	0.227	10	3	1	6
PL.2215	PL.2078	B	6 A (CWC)	7.38Y	122.9	0.03	2.06	3.69	3	26	7	97	0.01	0.0	7.143	0.178	0	0	0	5
PL.2216	PL.2215	B	6 A (CWC)	7.37Y	122.9	0.03	2.09	3.69	3	26	7	97	0.01	0.0	7.340	0.197	0	0	0	5
PL.1969	PL.2216	B	6 A (CWC)	7.37Y	122.9	0.01	2.10	2.62	2	19	5	97	0.00	0.0	7.397	0.057	7	2	1	3
PL.1971	PL.1969	B	#4 ACSR	7.37Y	122.9	0.00	2.10	1.59	1	11	3	96	0.00	0.0	7.420	0.023	11	3	2	2
PL.1970	PL.2216	B	6 A (CWC)	7.37Y	122.9	0.00	2.09	1.07	1	8	2	97	0.00	0.0	7.377	0.036	8	2	2	2
PL.1964	PL.2082	ABC	336 MCM AC	7.40Y	123.3	0.01	1.71	10.19	2	218	60	96	0.01	0.0	6.292	0.084	14	4	2	46
PL.2080	PL.1964	ABC	336 MCM AC	7.40Y	123.3	0.01	1.72	9.53	2	204	56	96	0.01	0.0	6.374	0.082	0	0	0	44
PL.2534	PL.2080	C	#4 ACSR	7.40Y	123.3	0.00	1.72	1.02	1	7	2	96	0.00	0.0	6.379	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.338	PL.2534	C	40QA	7.40Y	123.3	0.00	1.72	1.02	3	7	2	96	0.00	0.0	6.379	0.005	0	0	0	1
PL.2535	PD.338	C	#4 ACSR	7.40Y	123.3	0.00	1.72	1.02	1	7	2	96	0.00	0.0	6.384	0.005	7	2	1	1
PL.2077	PL.2080	ABC	336 MCM AC	7.40Y	123.3	0.00	1.72	8.91	2	190	53	96	0.00	0.0	6.431	0.057	0	0	0	41
PL.2076	PL.2077	ABC	336 MCM AC	7.40Y	123.3	0.00	1.72	8.15	2	174	48	96	0.00	0.0	6.477	0.047	2	1	1	39
PL.2075	PL.2076	ABC	336 MCM AC	7.40Y	123.3	0.00	1.73	7.09	1	152	42	96	0.00	0.0	6.568	0.091	13	4	3	32
PL.2470	PL.2075	A	#4 ACSR	7.40Y	123.3	0.00	1.73	3.54	3	25	7	96	0.00	0.0	6.573	0.005	0	0	0	5
PD.306	PL.2470	A	20QA	7.40Y	123.3	0.00	1.73	3.54	18	25	7	96	0.00	0.0	6.573	0.005	0	0	0	5
PL.2471	PD.306	A	#4 ACSR	7.40Y	123.3	0.00	1.73	3.54	3	25	7	96	0.00	0.0	6.597	0.024	25	7	5	5
PL.2212	PL.2075	ABC	336 MCM AC	7.40Y	123.3	0.00	1.73	5.30	1	113	31	96	0.00	0.0	6.626	0.058	0	0	0	24
PL.2213	PL.2212	ABC	336 MCM AC	7.40Y	123.3	0.00	1.73	5.30	1	113	31	96	0.00	0.0	6.676	0.050	15	4	4	24
PL.2548	PL.2213	ABC	336 MCM AC	7.40Y	123.3	0.00	1.73	4.61	1	99	27	96	0.00	0.0	6.703	0.027	0	0	0	20
PD.345-A	PL.2548	ABC	Closed	7.40Y	123.3	0.00	1.73	4.61	0	99	27	96	0.00	0.0	6.703	0.027	0	0	0	20
PD.345-B	PD.345-A	ABC	Closed	7.40Y	123.3	0.00	1.73	4.61	0	99	27	96	0.00	0.0	6.703	0.027	0	0	0	20
PL.4873	PD.345-B	ABC	336 MCM AC	7.40Y	123.3	0.01	1.74	4.61	1	99	27	96	0.01	0.0	7.014	0.310	0	0	0	20
PL.4874	PL.4873	ABC	336 MCM AC	7.39Y	123.2	0.01	1.76	4.61	1	99	27	96	0.01	0.0	7.373	0.359	0	0	0	20
PL.4872	PL.4874	ABC	336 MCM AC	7.39Y	123.2	0.01	1.77	4.61	1	99	27	96	0.01	0.0	7.778	0.404	0	0	0	20
PD.346-A	PL.4872	ABC	Closed	7.39Y	123.2	0.00	1.77	4.61	0	99	27	96	0.00	0.0	7.778	0.404	0	0	0	20
PD.346-B	PD.346-A	ABC	Closed	7.39Y	123.2	0.00	1.77	4.61	0	99	27	96	0.00	0.0	7.778	0.404	0	0	0	20
PL.2551	PD.346-B	ABC	336 MCM AC	7.39Y	123.2	0.00	1.77	4.61	1	99	27	96	0.00	0.0	7.896	0.119	0	0	0	20
PL.1974	PL.2551	C	#2 ACSR	7.39Y	123.2	0.00	1.77	0.72	0	5	1	98	0.00	0.0	7.915	0.019	5	1	1	1
PL.2068	PL.2551	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	4.37	1	93	26	96	0.00	0.0	7.947	0.050	6	2	2	19
PL.2400	PL.2068	C	#4 ACSR	7.39Y	123.2	0.00	1.78	2.55	2	18	5	96	0.00	0.0	7.951	0.005	0	0	0	2
PD.270	PL.2400	C	20QA	7.39Y	123.2	0.00	1.78	2.55	13	18	5	96	0.00	0.0	7.951	0.005	0	0	0	2
PL.2401	PD.270	C	#4 ACSR	7.39Y	123.2	0.00	1.78	2.55	2	18	5	96	0.00	0.0	8.015	0.064	18	5	2	2
PL.2066	PL.2068	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	3.22	1	69	19	96	0.00	0.0	8.154	0.208	4	1	1	15
PL.2217	PL.2066	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	3.02	1	65	18	96	0.00	0.0	8.200	0.046	3	1	1	14
PL.2218	PL.2217	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	2.89	1	62	17	96	0.00	0.0	8.230	0.031	0	0	0	13
PL.2402	PL.2218	C	#4 ACSR	7.39Y	123.2	0.00	1.78	0.95	1	7	2	96	0.00	0.0	8.235	0.005	0	0	0	4
PD.271	PL.2402	C	20QA	7.39Y	123.2	0.00	1.78	0.95	5	7	2	96	0.00	0.0	8.235	0.005	0	0	0	4
PL.2403	PD.271	C	#4 ACSR	7.39Y	123.2	0.00	1.78	0.95	1	7	2	96	0.00	0.0	8.314	0.079	7	2	4	4
PL.2062	PL.2218	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	2.57	0	55	15	96	0.00	0.0	8.283	0.052	0	0	0	9

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2404	PL.2062	A	#4 ACSR	7.39Y	123.2	0.00	1.78	1.85	1	13	4	96	0.00	0.0	8.288	0.005	0	0	0	4
PD.272	PL.2404	A	20QA	7.39Y	123.2	0.00	1.78	1.85	9	13	4	96	0.00	0.0	8.288	0.005	0	0	0	4
PL.2405	PD.272	A	#4 ACSR	7.39Y	123.2	0.00	1.78	1.85	1	13	4	96	0.00	0.0	8.302	0.014	4	1	1	4
PL.2219	PL.2405	A	#4 ACSR	7.39Y	123.2	0.00	1.79	1.28	1	9	3	95	0.00	0.0	8.325	0.023	9	3	3	3
PL.2061	PL.2062	ABC	336 MCM AC	7.39Y	123.2	0.00	1.78	1.95	0	42	12	96	0.00	0.0	8.365	0.082	0	0	0	5
PL.2060	PL.2061	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.44	0	9	3	95	0.00	0.0	8.519	0.155	0	0	0	1
PL.2059	PL.2060	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	9.062	0.543	0	0	0	0
PL.4865	PL.2059	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	9.449	0.387	0	0	0	0
PL.4867	PL.4865	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	9.999	0.551	0	0	0	0
PL.4866	PL.4867	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.393	0.394	0	0	0	0
PL.7126	PL.4866	ABC	336 MCM AC	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.396	0.003	0	0	0	0
PD.1506-B	PL.7126	ABC	Open	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.396	0.003	0	0	0	0
PL.1980	PL.4866	ABC	#2 ACSR	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.410	0.017	0	0	0	0
PL.64959	PL.1980	ABC	#2 ACSR	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.410	0.000	0	0	0	0
PD.9573-A	PL.64959	ABC	Open	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	10.410	0.000	0	0	0	0
PL.4868	PL.2060	A	#2 ACSR	7.39Y	123.2	0.00	1.79	1.31	1	9	3	95	0.00	0.0	8.523	0.003	0	0	0	1
PD.898	PL.4868	A	20QA	7.39Y	123.2	0.00	1.79	1.31	7	9	3	95	0.00	0.0	8.523	0.003	0	0	0	1
PL.4869	PD.898	A	#2 ACSR	7.39Y	123.2	0.00	1.79	1.31	1	9	3	95	0.00	0.0	8.548	0.025	9	3	1	1
PL.4870	PL.2061	A	#4 ACSR	7.39Y	123.2	0.00	1.79	4.56	4	32	9	96	0.00	0.0	8.368	0.003	0	0	0	4
PD.899	PL.4870	A	20QA	7.39Y	123.2	0.00	1.79	4.56	23	32	9	96	0.00	0.0	8.368	0.003	0	0	0	4
PL.4871	PD.899	A	#4 ACSR	7.39Y	123.2	0.00	1.79	4.56	4	32	9	96	0.00	0.0	8.400	0.032	32	9	4	4
PL.1975	PL.4871	A	#4 ACSR	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	8.407	0.006	0	0	0	0
PL.2472	PL.2066	A	#4 ACSR	7.39Y	123.2	0.00	1.78	0.00	0	0	0	100	0.00	0.0	8.159	0.005	0	0	0	0
PD.307	PL.2472	A	20QA	7.39Y	123.2	0.00	1.78	0.00	0	0	0	100	0.00	0.0	8.159	0.005	0	0	0	0
PL.2473	PD.307	A	#4 ACSR	7.39Y	123.2	0.00	1.78	0.00	0	0	0	100	0.00	0.0	8.213	0.054	0	0	0	0
PL.2398	PL.2076	A	#4 ACSR	7.40Y	123.3	0.00	1.72	2.90	2	21	6	96	0.00	0.0	6.482	0.005	0	0	0	6
PD.269	PL.2398	A	20QA	7.40Y	123.3	0.00	1.72	2.90	14	21	6	96	0.00	0.0	6.482	0.005	0	0	0	6
PL.2399	PD.269	A	#4 ACSR	7.40Y	123.3	0.00	1.73	2.90	2	21	6	96	0.00	0.0	6.538	0.056	21	6	6	6
PL.2540	PL.2077	C	#2 ACSR	7.40Y	123.3	0.00	1.72	2.26	1	16	4	97	0.00	0.0	6.435	0.005	0	0	0	2
PD.340	PL.2540	C	20QA	7.40Y	123.3	0.00	1.72	2.26	11	16	4	97	0.00	0.0	6.435	0.005	0	0	0	2
PL.2541	PD.340	C	#2 ACSR	7.40Y	123.3	0.00	1.72	2.26	1	16	4	97	0.00	0.0	6.461	0.026	6	2	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1972	PL.2541	C	#2 ACSR	7.40Y	123.3	0.00	1.72	1.45	1	10	3	96	0.00	0.0	6.477	0.015	10	3	1	1
PL.2396	PL.2077	A	#2 ACSR	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	6.435	0.005	0	0	0	0
PD.268	PL.2396	A	20QA	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	6.435	0.005	0	0	0	0
PL.2397	PD.268	A	#2 ACSR	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	6.454	0.019	0	0	0	0
PL.2538	PL.2080	A	#4 ACSR	7.40Y	123.3	0.00	1.72	0.87	1	6	2	95	0.00	0.0	6.379	0.005	0	0	0	2
PD.339	PL.2538	A	40QA	7.40Y	123.3	0.00	1.72	0.87	2	6	2	95	0.00	0.0	6.379	0.005	0	0	0	2
PL.2539	PD.339	A	#4 ACSR	7.40Y	123.3	0.00	1.72	0.87	1	6	2	95	0.00	0.0	6.394	0.015	6	2	2	2
PL.2394	PL.2084	A	#4 ACSR	7.40Y	123.3	0.00	1.70	0.09	0	1	0	100	0.00	0.0	6.163	0.005	0	0	0	2
PD.267	PL.2394	A	20QA	7.40Y	123.3	0.00	1.70	0.09	0	1	0	100	0.00	0.0	6.163	0.005	0	0	0	2
PL.2395	PD.267	A	#4 ACSR	7.40Y	123.3	0.00	1.70	0.09	0	1	0	100	0.00	0.0	6.198	0.035	1	0	2	2
CP.5	PL.2570	ABC	Cap (300)	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	5.915	0.035	0	0	0	0
PL.1947	PL.2085	B	#2 ACSR	7.40Y	123.4	0.01	1.63	8.30	5	59	16	97	0.00	0.0	5.704	0.026	0	0	0	7
PL.2386	PL.1947	B	#2 ACSR	7.40Y	123.4	0.00	1.63	8.30	5	59	16	97	0.00	0.0	5.709	0.005	0	0	0	7
PD.264	PL.2386	B	15T	7.40Y	123.4	0.00	1.63	8.30	0	59	16	97	0.00	0.0	5.709	0.005	0	0	0	7
PL.2387	PD.264	B	#2 ACSR	7.40Y	123.4	0.01	1.64	8.30	5	59	16	97	0.01	0.0	5.758	0.049	0	0	0	7
PL.1948	PL.2387	B	#2 ACSR	7.40Y	123.3	0.01	1.66	8.30	5	59	16	97	0.01	0.0	5.804	0.047	0	0	0	7
PL.1949	PL.1948	B	#4 ACSR	7.40Y	123.3	0.01	1.67	8.30	6	59	16	97	0.01	0.0	5.847	0.042	12	3	2	7
PL.1950	PL.1949	B	#4 ACSR	7.40Y	123.3	0.02	1.69	6.57	5	47	13	96	0.01	0.0	5.904	0.057	5	1	1	5
PL.1951	PL.1950	B	#4 ACSR	7.40Y	123.3	0.00	1.69	5.87	5	42	12	96	0.00	0.0	5.932	0.028	33	9	3	4
PL.1952	PL.1951	B	#2 ACSR	7.40Y	123.3	0.00	1.69	1.22	1	9	2	98	0.00	0.0	5.973	0.041	9	2	1	1
PL.2528	PL.2087	A	#4 ACSR	7.40Y	123.4	0.00	1.61	12.60	10	90	25	96	0.00	0.0	5.625	0.005	0	0	0	15
PD.335	PL.2528	A	30T	7.40Y	123.4	0.00	1.61	12.60	0	90	25	96	0.00	0.0	5.625	0.005	0	0	0	15
PL.2529	PD.335	A	#4 ACSR	7.40Y	123.4	0.02	1.63	12.60	10	90	25	96	0.01	0.0	5.659	0.034	0	0	0	15
PL.1934	PL.2529	A	#4 ACSR	7.40Y	123.3	0.04	1.67	12.07	9	86	24	96	0.02	0.0	5.726	0.066	0	0	0	12
PL.1937	PL.1934	A	#4 ACSR	7.40Y	123.3	0.00	1.67	0.39	0	3	1	95	0.00	0.0	5.765	0.039	3	1	1	1
PL.1935	PL.1934	A	#4 ACSR	7.40Y	123.3	0.03	1.70	10.35	8	74	20	97	0.02	0.0	5.796	0.071	12	3	1	9
PL.2199	PL.1935	A	#4 ACSR	7.40Y	123.3	0.01	1.71	8.64	7	62	17	96	0.00	0.0	5.827	0.030	15	4	2	8
PL.2200	PL.2199	A	#4 ACSR	7.40Y	123.3	0.01	1.72	6.51	5	46	13	96	0.00	0.0	5.855	0.029	8	2	1	6
PL.2201	PL.2200	A	#4 ACSR	7.40Y	123.3	0.00	1.72	5.32	4	38	10	97	0.00	0.0	5.883	0.028	27	7	3	5
PL.1961	PL.2201	A	#4 ACSR	7.40Y	123.3	0.00	1.72	1.52	1	11	3	96	0.00	0.0	5.931	0.048	0	0	0	2
PL.1963	PL.1961	A	#4 ACSR	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	5.954	0.023	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2195	PL.1961	A	#4 ACSR	7.40Y	123.3	0.00	1.73	1.52	1	11	3	96	0.00	0.0	5.958	0.027	4	1	1	2
PL.2196	PL.2195	A	#4 ACSR	7.40Y	123.3	0.00	1.73	0.91	1	6	2	95	0.00	0.0	5.975	0.016	6	2	1	1
PL.10162	PL.2201	A	#4 ACSR	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	5.931	0.048	0	0	0	0
PL.1936	PL.1934	A	#4 ACSR	7.40Y	123.3	0.00	1.67	1.33	1	10	3	96	0.00	0.0	5.795	0.069	10	3	2	2
PL.2193	PL.2529	A	#4 ACSR	7.40Y	123.4	0.00	1.63	0.52	0	4	1	97	0.00	0.0	5.686	0.026	3	1	1	3
PL.2194	PL.2193	A	#4 ACSR	7.40Y	123.4	0.00	1.63	0.14	0	1	0	100	0.00	0.0	5.716	0.030	1	0	2	2
PL.2384	PL.2087	A	#4 ACSR	7.40Y	123.4	0.00	1.61	0.28	0	2	1	89	0.00	0.0	5.625	0.005	0	0	0	1
PD.263	PL.2384	A	40QA	7.40Y	123.4	0.00	1.61	0.28	1	2	1	89	0.00	0.0	5.625	0.005	0	0	0	1
PL.2385	PD.263	A	#4 ACSR	7.40Y	123.4	0.00	1.61	0.28	0	2	1	89	0.00	0.0	5.658	0.033	0	0	0	1
PL.1929	PL.2385	A	#4 ACSR	7.40Y	123.4	0.00	1.61	0.28	0	2	1	89	0.00	0.0	5.691	0.033	2	1	1	1
PL.2370	PL.2372	C	#4 ACSR	7.41Y	123.4	0.00	1.55	1.66	1	12	3	97	0.00	0.0	5.403	0.005	0	0	0	2
PD.258	PL.2370	C	40QA	7.41Y	123.4	0.00	1.55	1.66	4	12	3	97	0.00	0.0	5.403	0.005	0	0	0	2
PL.2371	PD.258	C	#4 ACSR	7.41Y	123.4	0.00	1.55	1.66	1	12	3	97	0.00	0.0	5.414	0.011	12	3	2	2
PL.2358	PL.2092	C	#4 ACSR	7.41Y	123.5	0.00	1.51	2.82	2	20	6	96	0.00	0.0	5.239	0.005	0	0	0	3
PD.252	PL.2358	C	40QA	7.41Y	123.5	0.00	1.51	2.82	7	20	6	96	0.00	0.0	5.239	0.005	0	0	0	3
PL.2359	PD.252	C	#4 ACSR	7.41Y	123.5	0.00	1.51	2.82	2	20	6	96	0.00	0.0	5.265	0.026	20	6	3	3
PL.2366	PL.2093	A	#4 ACSR	7.41Y	123.5	0.00	1.50	2.28	2	16	4	97	0.00	0.0	5.207	0.005	0	0	0	5
PD.256	PL.2366	A	40QA	7.41Y	123.5	0.00	1.50	2.28	6	16	4	97	0.00	0.0	5.207	0.005	0	0	0	5
PL.2367	PD.256	A	#4 ACSR	7.41Y	123.5	0.00	1.50	2.28	2	16	4	97	0.00	0.0	5.233	0.027	9	3	4	5
PL.1925	PL.2367	A	#2 ACSR	7.41Y	123.5	0.00	1.50	0.98	1	7	2	96	0.00	0.0	5.245	0.012	0	0	0	1
PL.1926	PL.1925	A	#2 ACSR	7.41Y	123.5	0.00	1.50	0.98	1	7	2	96	0.00	0.0	5.258	0.012	0	0	0	1
PL.1927	PL.1926	A	#2 ACSR	7.41Y	123.5	0.00	1.50	0.98	1	7	2	96	0.00	0.0	5.301	0.043	7	2	1	1
PL.1850	PL.2188	ABC	#1/0 ACSR	7.41Y	123.5	0.04	1.48	47.74	21	1022	288	96	0.25	0.0	5.067	0.043	46	13	10	215
PL.1851	PL.1850	ABC	#1/0 ACSR	7.41Y	123.5	0.04	1.52	45.61	20	976	275	96	0.25	0.0	5.113	0.046	11	3	3	205
PL.1854	PL.1851	ABC	#1/0 ACSR	7.41Y	123.4	0.05	1.56	45.08	20	964	272	96	0.31	0.0	5.170	0.057	0	0	0	202
PL.1855	PL.1854	ABC	8 A (CWC)	7.40Y	123.4	0.03	1.59	25.47	25	544	155	96	0.14	0.0	5.190	0.020	0	0	0	99
PL.1857	PL.1855	ABC	8 A (CWC)	7.40Y	123.3	0.08	1.68	25.47	25	544	155	96	0.37	0.1	5.245	0.055	7	2	1	99
PL.1861	PL.1857	ABC	8 A (CWC)	7.40Y	123.3	0.06	1.74	25.16	25	537	153	96	0.25	0.0	5.283	0.038	14	4	1	98
PL.2356	PL.1861	C	#2 ACSR	7.40Y	123.3	0.00	1.74	5.84	3	42	12	96	0.00	0.0	5.288	0.004	0	0	0	7
PD.251	PL.2356	C	40QA	7.40Y	123.3	0.00	1.74	5.84	15	42	12	96	0.00	0.0	5.288	0.004	0	0	0	7
PL.2357	PD.251	C	#2 ACSR	7.40Y	123.3	0.00	1.74	5.84	3	42	12	96	0.00	0.0	5.312	0.024	5	1	1	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2186	PL.2357	C	#2 ACSR	7.40Y	123.3	0.01	1.75	5.08	3	36	10	96	0.00	0.0	5.365	0.053	0	0	0	6
PL.4512	PL.2186	C	#4 ACSR	7.39Y	123.2	0.00	1.75	2.29	2	16	5	95	0.00	0.0	5.380	0.015	6	2	1	2
PL.4513	PL.4512	C	#4 ACSR	7.39Y	123.2	0.00	1.75	1.40	1	10	3	96	0.00	0.0	5.403	0.022	10	3	1	1
PL.2090	PL.2186	C	#2 ACSR	7.39Y	123.2	0.00	1.75	2.79	2	20	5	97	0.00	0.0	5.401	0.035	0	0	0	4
PL.1864	PL.2090	C	#4 ACSR	7.39Y	123.2	0.00	1.76	2.79	2	20	5	97	0.00	0.0	5.448	0.047	20	5	4	4
PL.1862	PL.1861	ABC	#2 ACSR	7.39Y	123.2	0.04	1.77	22.57	13	481	138	96	0.14	0.0	5.352	0.069	5	1	2	90
PL.1889	PL.1862	ABC	#2 ACSR	7.39Y	123.2	0.03	1.81	22.33	13	476	137	96	0.12	0.0	5.413	0.061	24	12	1	88
PL.1890	PL.1889	ABC	#2 ACSR	7.39Y	123.2	0.02	1.83	21.16	12	452	125	96	0.08	0.0	5.458	0.045	1	0	2	87
PL.1892	PL.1890	A	#2 ACSR	7.39Y	123.2	0.00	1.83	3.79	2	27	7	97	0.00	0.0	5.463	0.005	0	0	0	5
PD.333	PL.1892	A	40QA	7.39Y	123.2	0.00	1.83	3.79	9	27	7	97	0.00	0.0	5.463	0.005	0	0	0	5
PL.2006	PD.333	A	#2 ACSR	7.39Y	123.2	0.01	1.84	3.79	2	27	7	97	0.00	0.0	5.514	0.051	7	2	3	5
PL.1893	PL.2006	A	#4 ACSR	7.39Y	123.2	0.00	1.84	2.74	2	19	5	97	0.00	0.0	5.563	0.050	8	2	1	2
PL.1894	PL.1893	A	#4 ACSR	7.39Y	123.2	0.00	1.85	1.60	1	11	3	96	0.00	0.0	5.630	0.067	11	3	1	1
PL.2368	PL.1890	C	6 A (CWC)	7.39Y	123.2	0.00	1.84	13.30	9	95	26	96	0.00	0.0	5.463	0.005	0	0	0	16
PD.257	PL.2368	C	40QA	7.39Y	123.2	0.00	1.84	13.30	33	95	26	96	0.00	0.0	5.463	0.005	0	0	0	16
PL.2369	PD.257	C	6 A (CWC)	7.39Y	123.1	0.03	1.86	13.30	9	95	26	96	0.02	0.0	5.506	0.043	5	1	1	16
PL.1895	PL.2369	C	6 A (CWC)	7.39Y	123.1	0.05	1.91	12.60	9	90	25	96	0.03	0.0	5.589	0.083	0	0	0	15
PL.1896	PL.1895	C	#4 ACSR	7.38Y	123.1	0.01	1.92	7.62	6	54	15	96	0.00	0.0	5.623	0.034	7	2	1	9
PL.1902	PL.1896	C	#4 ACSR	7.38Y	123.1	0.01	1.93	6.62	5	47	13	96	0.00	0.0	5.662	0.039	9	2	2	8
PL.1903	PL.1902	C	#2 ACSR	7.38Y	123.1	0.00	1.93	1.20	1	9	2	98	0.00	0.0	5.736	0.074	9	2	2	2
PL.1904	PL.1902	C	#4 ACSR	7.38Y	123.1	0.01	1.94	4.18	3	30	8	97	0.00	0.0	5.704	0.041	8	2	1	4
PL.1905	PL.1904	C	#2 ACSR	7.38Y	123.1	0.00	1.94	2.32	1	17	5	96	0.00	0.0	5.768	0.065	9	2	1	2
PL.1907	PL.1905	C	#2 ACSR	7.38Y	123.1	0.00	1.94	1.08	1	8	2	97	0.00	0.0	5.829	0.061	8	2	1	1
PL.1906	PL.1904	C	#2 ACSR	7.38Y	123.1	0.00	1.94	0.69	0	5	1	98	0.00	0.0	5.810	0.107	5	1	1	1
PL.1897	PL.1895	C	#2 ACSR	7.39Y	123.1	0.00	1.91	4.98	3	35	10	96	0.00	0.0	5.622	0.033	13	3	2	6
PL.1898	PL.1897	C	#2 ACSR	7.39Y	123.1	0.00	1.92	3.21	2	23	6	97	0.00	0.0	5.647	0.025	0	0	1	4
PL.1899	PL.1898	C	#2 ACSR	7.38Y	123.1	0.01	1.93	3.21	2	23	6	97	0.00	0.0	5.742	0.096	0	0	0	3
PL.1901	PL.1899	C	#2 ACSR	7.38Y	123.1	0.00	1.93	1.50	1	11	3	96	0.00	0.0	5.765	0.023	11	3	1	1
PL.1900	PL.1899	C	#2 ACSR	7.38Y	123.1	0.00	1.93	1.71	1	12	3	97	0.00	0.0	5.779	0.037	12	3	2	2
PL.1891	PL.1890	ABC	#2 ACSR	7.39Y	123.1	0.02	1.85	15.42	9	330	91	96	0.05	0.0	5.512	0.054	12	3	2	64
PL.1908	PL.1891	ABC	#2 ACSR	7.39Y	123.1	0.02	1.87	9.70	6	207	57	96	0.03	0.0	5.600	0.088	26	7	5	44

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2380	PL.1908	A	6 A (CWC)	7.39Y	123.1	0.00	1.87	1.22	1	9	2	98	0.00	0.0	5.605	0.005	0	0	0	2
PD.261	PL.2380	A	10T	7.39Y	123.1	0.00	1.87	1.22	0	9	2	98	0.00	0.0	5.605	0.005	0	0	0	2
PL.2381	PD.261	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	1.22	1	9	2	98	0.00	0.0	5.703	0.098	9	2	2	2
PL.1913	PL.1908	ABC	#2 ACSR	7.39Y	123.1	0.01	1.89	8.07	5	172	48	96	0.02	0.0	5.668	0.068	9	3	4	37
PL.1914	PL.1913	ABC	#2 ACSR	7.39Y	123.1	0.00	1.89	7.63	4	163	45	96	0.01	0.0	5.696	0.028	34	9	6	33
PL.1915	PL.1914	ABC	#2 ACSR	7.39Y	123.1	0.01	1.90	6.04	3	129	36	96	0.01	0.0	5.769	0.072	28	8	5	27
PL.1916	PL.1915	ABC	#2 ACSR	7.39Y	123.1	0.01	1.91	4.73	3	101	28	96	0.00	0.0	5.820	0.051	14	4	2	22
PL.1917	PL.1916	ABC	#2 ACSR	7.39Y	123.1	0.00	1.91	4.06	2	87	24	96	0.00	0.0	5.873	0.053	24	7	5	20
PL.2526	PL.1917	C	#2 ACSR	7.39Y	123.1	0.00	1.91	8.85	5	63	17	97	0.00	0.0	5.878	0.005	0	0	0	15
PD.334	PL.2526	C	40QA	7.39Y	123.1	0.00	1.91	8.85	22	63	17	97	0.00	0.0	5.878	0.005	0	0	0	15
PL.2527	PD.334	C	#2 ACSR	7.38Y	123.1	0.01	1.93	8.85	5	63	17	97	0.01	0.0	5.936	0.058	20	6	4	15
PL.1918	PL.2527	C	#2 ACSR	7.38Y	123.1	0.01	1.93	4.26	2	30	8	97	0.00	0.0	6.013	0.077	14	4	5	9
PL.1922	PL.1918	C	#4 ACSR	7.38Y	123.1	0.00	1.94	0.27	0	2	1	89	0.00	0.0	6.078	0.065	2	1	1	1
PL.1923	PL.1918	C	#1/0 ACSR	7.38Y	123.1	0.00	1.94	2.06	1	15	4	97	0.00	0.0	6.083	0.069	15	4	3	3
PL.1919	PL.2527	C	#2 ACSR	7.38Y	123.1	0.00	1.93	1.72	1	12	3	97	0.00	0.0	5.951	0.015	9	3	1	2
PL.1920	PL.1919	C	#2 ACSR	7.38Y	123.1	0.00	1.93	0.44	0	3	1	95	0.00	0.0	5.982	0.031	0	0	0	1
PL.1921	PL.1920	C	#2 ACSR	7.38Y	123.1	0.00	1.93	0.44	0	3	1	95	0.00	0.0	6.003	0.021	3	1	1	1
PL.2378	PL.1891	C	#4 ACSR	7.39Y	123.1	0.00	1.85	8.57	7	61	17	96	0.00	0.0	5.516	0.005	0	0	0	9
PD.260	PL.2378	C	40QA	7.39Y	123.1	0.00	1.85	8.57	21	61	17	96	0.00	0.0	5.516	0.005	0	0	0	9
PL.2379	PD.260	C	#4 ACSR	7.39Y	123.1	0.01	1.87	8.57	7	61	17	96	0.01	0.0	5.548	0.032	0	0	0	9
PL.1911	PL.2379	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	3.09	2	22	6	96	0.00	0.0	5.603	0.055	22	6	4	4
PL.1910	PL.2379	C	#4 ACSR	7.39Y	123.1	0.00	1.87	5.48	4	39	11	96	0.00	0.0	5.564	0.016	32	9	4	5
PL.1912	PL.1910	C	#4 ACSR	7.39Y	123.1	0.00	1.87	0.98	1	7	2	96	0.00	0.0	5.579	0.015	7	2	1	1
PL.1909	PL.1891	C	#4 ACSR	7.39Y	123.1	0.01	1.86	6.90	5	49	14	96	0.00	0.0	5.554	0.043	49	14	9	9
PL.2274	PL.1861	C	#4 ACSR	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	5.288	0.005	0	0	0	0
PL.1856	PL.1854	ABC	#2 ACSR	7.41Y	123.4	0.01	1.57	19.61	11	420	116	96	0.02	0.0	5.185	0.015	6	2	3	103
PL.1858	PL.1856	ABC	#2 ACSR	7.40Y	123.4	0.01	1.59	19.34	11	414	115	96	0.04	0.0	5.214	0.029	5	1	1	100
PL.1859	PL.1858	ABC	#2 ACSR	7.40Y	123.4	0.01	1.59	19.10	11	409	113	96	0.02	0.0	5.228	0.014	0	0	0	99
PL.1860	PL.1859	ABC	#2 ACSR	7.40Y	123.4	0.06	1.65	19.10	11	409	113	96	0.17	0.0	5.347	0.119	10	3	1	99
PL.1866	PL.1860	ABC	#2 ACSR	7.40Y	123.3	0.01	1.66	18.64	11	399	110	96	0.03	0.0	5.371	0.024	0	0	0	98
PL.1867	PL.1866	ABC	#2 ACSR	7.40Y	123.3	0.00	1.66	18.64	11	399	110	96	0.00	0.0	5.373	0.003	45	12	13	98

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1868	PL.1867	ABC	#2 ACSR	7.40Y	123.3	0.01	1.67	16.56	9	354	98	96	0.03	0.0	5.403	0.029	0	0	0	85
PL.1869	PL.1868	ABC	#2 ACSR	7.40Y	123.3	0.01	1.68	15.84	9	339	94	96	0.03	0.0	5.432	0.029	9	2	7	79
PL.1871	PL.1869	ABC	#2 ACSR	7.40Y	123.3	0.02	1.71	15.41	9	330	91	96	0.06	0.0	5.498	0.067	30	8	6	72
PL.2558	PL.1871	A	6 A (CWC)	7.40Y	123.3	0.00	1.71	25.01	18	178	49	96	0.00	0.0	5.501	0.003	0	0	0	31
PD.352	PL.2558	A	70L	7.40Y	123.3	0.00	1.71	25.01	36	178	49	96	0.00	0.0	5.501	0.003	0	0	0	31
PL.2559	PD.352	A	6 A (CWC)	7.39Y	123.2	0.09	1.80	25.01	18	178	49	96	0.12	0.1	5.582	0.081	5	1	1	31
PL.1872	PL.2559	A	8 A (CWC)	7.39Y	123.1	0.08	1.89	24.37	24	174	48	96	0.11	0.1	5.637	0.055	19	5	4	30
PL.1989	PL.1872	A	6 A (CWC)	7.38Y	123.1	0.05	1.94	6.49	5	46	13	96	0.02	0.0	5.807	0.170	0	0	0	6
PL.1990	PL.1989	A	6 A (CWC)	7.38Y	123.0	0.04	1.98	6.49	5	46	13	96	0.02	0.0	5.954	0.148	0	0	0	6
PL.1992	PL.1990	A	6 A (CWC)	7.38Y	123.0	0.01	2.00	2.27	2	16	4	97	0.00	0.0	6.073	0.118	0	0	0	2
PL.1998	PL.1992	A	6 A (CWC)	7.38Y	123.0	0.01	2.00	2.27	2	16	4	97	0.00	0.0	6.149	0.077	0	0	0	2
PL.2000	PL.1998	A	6 A (CWC)	7.38Y	123.0	0.01	2.01	2.27	2	16	4	97	0.00	0.0	6.270	0.121	16	4	2	2
PL.2271	PL.2000	A	6 A (CWC)	7.38Y	123.0	0.00	2.01	0.00	0	0	0	100	0.00	0.0	6.275	0.005	0	0	0	0
PL.1993	PL.1990	A	6 A (CWC)	7.38Y	123.0	0.02	2.00	4.22	3	30	8	97	0.00	0.0	6.069	0.115	9	2	1	4
PL.1995	PL.1993	A	6 A (CWC)	7.38Y	123.0	0.00	2.00	2.99	2	21	6	96	0.00	0.0	6.089	0.020	0	0	0	3
PL.2262	PL.1995	A	6 A (CWC)	7.38Y	123.0	0.01	2.01	2.99	2	21	6	96	0.00	0.0	6.184	0.095	21	6	3	3
PL.2263	PL.2262	A	6 A (CWC)	7.38Y	123.0	0.00	2.01	0.00	0	0	0	100	0.00	0.0	6.214	0.030	0	0	0	0
PL.1873	PL.1872	A	8 A (CWC)	7.38Y	123.1	0.03	1.92	15.23	15	108	30	96	0.03	0.0	5.672	0.035	7	2	1	20
PL.1875	PL.1873	A	8 A (CWC)	7.38Y	123.1	0.02	1.95	8.58	9	61	17	96	0.01	0.0	5.713	0.041	6	2	2	11
PL.1586	PL.1875	A	8 A (CWC)	7.38Y	123.0	0.01	1.96	7.74	8	55	15	96	0.00	0.0	5.734	0.020	8	2	2	9
PL.1587	PL.1586	A	8 A (CWC)	7.38Y	123.0	0.02	1.97	6.59	7	47	13	96	0.00	0.0	5.783	0.050	29	8	4	7
PL.1877	PL.1587	A	6 A (CWC)	7.38Y	123.0	0.00	1.97	2.49	2	18	5	96	0.00	0.0	5.839	0.056	12	3	2	3
PL.1878	PL.1877	A	#2 ACSR	7.38Y	123.0	0.00	1.97	0.77	0	6	2	95	0.00	0.0	5.866	0.027	6	2	1	1
PL.1876	PL.1873	A	6 A (CWC)	7.38Y	123.1	0.01	1.93	5.65	4	40	11	96	0.00	0.0	5.723	0.051	40	11	8	8
PL.2552	PL.1871	C	6 A (CWC)	7.40Y	123.3	0.00	1.71	16.96	12	121	33	96	0.00	0.0	5.501	0.003	0	0	0	35
PD.348	PL.2552	C	35H	7.40Y	123.3	0.00	1.71	16.96	48	121	33	96	0.00	0.0	5.501	0.003	0	0	0	35
PL.2553	PD.348	C	6 A (CWC)	7.40Y	123.3	0.03	1.74	16.96	12	121	33	96	0.03	0.0	5.544	0.044	19	5	4	35
PL.1879	PL.2553	C	6 A (CWC)	7.39Y	123.2	0.03	1.77	14.31	10	102	28	96	0.02	0.0	5.586	0.041	3	1	4	31
PL.1880	PL.1879	C	6 A (CWC)	7.39Y	123.2	0.01	1.78	13.88	10	99	27	96	0.01	0.0	5.607	0.022	0	0	0	27
PL.1881	PL.1880	C	6 A (CWC)	7.39Y	123.2	0.04	1.82	13.88	10	99	27	96	0.03	0.0	5.663	0.056	2	1	1	27
PL.1883	PL.1881	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	2.84	2	20	6	96	0.00	0.0	5.694	0.031	0	0	1	13

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1884	PL.1883	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	0.09	0	1	0	100	0.00	0.0	5.784	0.090	1	0	3	3
PL.1885	PL.1883	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	2.72	2	19	5	97	0.00	0.0	5.713	0.018	0	0	0	9
PL.1886	PL.1885	C	#4 ACSR	7.39Y	123.2	0.00	1.83	2.72	2	19	5	97	0.00	0.0	5.737	0.024	19	5	9	9
PL.1882	PL.1881	C	6 A (CWC)	7.39Y	123.2	0.01	1.83	10.71	8	76	21	96	0.00	0.0	5.685	0.021	35	10	5	13
PL.1887	PL.1882	C	#4 ACSR	7.39Y	123.2	0.01	1.83	5.84	4	42	11	97	0.00	0.0	5.714	0.029	0	0	0	8
PL.1888	PL.1887	C	#4 ACSR	7.39Y	123.2	0.00	1.84	5.84	4	42	11	97	0.00	0.0	5.740	0.026	42	11	8	8
PL.1870	PL.1868	C	8 A (CWC)	7.40Y	123.3	0.00	1.68	2.16	2	15	4	97	0.00	0.0	5.452	0.050	15	4	6	6
PL.2280	PL.2110	C	#4 ACSR	7.42Y	123.7	0.00	1.26	8.64	7	62	17	96	0.00	0.0	4.761	0.005	0	0	0	15
PD.212	PL.2280	C	40QA	7.42Y	123.7	0.00	1.26	8.64	22	62	17	96	0.00	0.0	4.761	0.005	0	0	0	15
PL.2281	PD.212	C	#4 ACSR	7.42Y	123.7	0.01	1.27	8.64	7	62	17	96	0.00	0.0	4.784	0.023	25	7	6	15
PL.1803	PL.2281	C	#4 ACSR	7.42Y	123.7	0.02	1.29	5.10	4	37	10	97	0.01	0.0	4.876	0.092	0	0	0	9
PL.2097	PL.1803	C	#4 ACSR	7.42Y	123.7	0.01	1.30	3.58	3	26	7	97	0.00	0.0	4.925	0.048	0	0	0	8
PL.2098	PL.2097	C	#4 ACSR	7.42Y	123.7	0.01	1.31	3.58	3	26	7	97	0.00	0.0	4.984	0.059	0	0	0	8
PL.1841	PL.2098	C	#4 ACSR	7.42Y	123.7	0.00	1.31	1.49	1	11	3	96	0.00	0.0	5.047	0.063	11	3	1	1
PL.1840	PL.2098	C	#4 ACSR	7.42Y	123.7	0.00	1.31	2.09	2	15	4	97	0.00	0.0	5.026	0.043	0	0	0	7
PL.1842	PL.1840	C	#4 ACSR	7.42Y	123.7	0.01	1.32	2.09	2	15	4	97	0.00	0.0	5.082	0.056	0	0	0	7
PL.1590	PL.1842	C	#2 ACSR	7.42Y	123.7	0.00	1.32	2.09	1	15	4	97	0.00	0.0	5.129	0.047	7	2	1	7
PL.1591	PL.1590	C	#2 ACSR	7.42Y	123.7	0.00	1.32	1.04	1	7	2	96	0.00	0.0	5.209	0.080	0	0	0	6
PL.2026	PL.1591	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.04	1	7	2	96	0.00	0.0	5.331	0.121	0	0	0	6
PL.2027	PL.2026	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.04	1	7	2	96	0.00	0.0	5.380	0.049	0	0	0	6
PL.1843	PL.2027	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.04	1	7	2	96	0.00	0.0	5.418	0.038	0	0	0	6
PL.1844	PL.1843	C	#2 ACSR	7.42Y	123.7	0.00	1.33	1.04	1	7	2	96	0.00	0.0	5.444	0.026	0	0	0	6
PL.1845	PL.1844	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.32	0	2	1	89	0.00	0.0	5.475	0.030	2	1	5	5
PL.1847	PL.1845	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	5.503	0.028	0	0	0	0
PL.1846	PL.1844	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.72	1	5	1	98	0.00	0.0	5.477	0.033	5	1	1	1
PL.1848	PL.1846	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	5.544	0.067	0	0	0	0
PL.1838	PL.2097	C	#2 ACSR	7.42Y	123.7	0.00	1.30	0.00	0	0	0	100	0.00	0.0	4.947	0.023	0	0	0	0
PL.2284	PL.1803	C	#4 ACSR	7.42Y	123.7	0.00	1.29	1.53	1	11	3	96	0.00	0.0	4.881	0.005	0	0	0	1
PD.215	PL.2284	C	40QA	7.42Y	123.7	0.00	1.29	1.53	4	11	3	96	0.00	0.0	4.881	0.005	0	0	0	1
PL.2285	PD.215	C	#4 ACSR	7.42Y	123.7	0.00	1.29	1.53	1	11	3	96	0.00	0.0	4.897	0.016	0	0	0	1
PL.1839	PL.2285	C	#4 ACSR	7.42Y	123.7	0.00	1.30	1.53	1	11	3	96	0.00	0.0	4.927	0.030	11	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2310	PL.2120	C	#2 ACSR	7.45Y	124.2	0.00	0.83	1.04	1	7	2	96	0.00	0.0	4.169	0.005	0	0	0	1
PD.228	PL.2310	C	40QA	7.45Y	124.2	0.00	0.83	1.04	3	7	2	96	0.00	0.0	4.169	0.005	0	0	0	1
PL.2311	PD.228	C	#1/0 ACSR	7.45Y	124.2	0.00	0.83	1.04	0	7	2	96	0.00	0.0	4.206	0.037	7	2	1	1
PL.2306	PL.2174	C	#4 ACSR	7.47Y	124.4	0.00	0.58	3.05	2	22	6	96	0.00	0.0	3.862	0.005	0	0	0	3
PD.226	PL.2306	C	40QA	7.47Y	124.4	0.00	0.58	3.05	8	22	6	96	0.00	0.0	3.862	0.005	0	0	0	3
PL.2307	PD.226	C	#4 ACSR	7.47Y	124.4	0.00	0.58	3.05	2	22	6	96	0.00	0.0	3.875	0.012	22	6	3	3
PL.2314	PL.2125	A	#2 ACSR	7.47Y	124.5	0.00	0.49	1.90	1	14	4	96	0.00	0.0	3.750	0.005	0	0	0	2
PD.230	PL.2314	A	40QA	7.47Y	124.5	0.00	0.49	1.90	5	14	4	96	0.00	0.0	3.750	0.005	0	0	0	2
PL.2315	PD.230	A	#2 ACSR	7.47Y	124.5	0.00	0.49	1.90	1	14	4	96	0.00	0.0	3.775	0.025	14	4	2	2
PL.1791	PL.2178	ABC	#2 ACSR	7.47Y	124.5	0.00	0.46	0.24	0	5	2	93	0.00	0.0	3.720	0.004	5	2	1	1
PL.1788	PL.2128	ABC	#1/0 ACSR	7.48Y	124.6	0.02	0.42	28.70	12	620	173	96	0.08	0.0	3.675	0.039	0	0	0	124
PL.2566	PL.1788	ABC	#1/0 ACSR	7.47Y	124.6	0.00	0.42	28.70	12	620	173	96	0.01	0.0	3.677	0.003	0	0	0	124
PD.356	PL.2566	ABC	50L	7.47Y	124.6	0.00	0.42	28.70	57	620	173	96	0.00	0.0	3.677	0.003	0	0	0	124
PL.2567	PD.356	ABC	#1/0 ACSR	7.47Y	124.5	0.03	0.45	28.70	12	620	173	96	0.14	0.0	3.741	0.064	0	0	0	124
PL.1789	PL.2567	ABC	#1/0 ACSR	7.47Y	124.5	0.04	0.49	28.70	12	620	173	96	0.18	0.0	3.824	0.083	0	0	0	124
PL.2025	PL.1789	ABC	#1/0 ACSR	7.47Y	124.4	0.06	0.55	28.70	12	620	173	96	0.25	0.0	3.937	0.113	7	2	1	124
PL.1790	PL.2025	ABC	#1/0 ACSR	7.47Y	124.4	0.01	0.56	28.39	12	613	171	96	0.03	0.0	3.951	0.014	0	0	0	123
PL.2304	PL.1790	C	#2 ACSR	7.47Y	124.4	0.00	0.56	0.30	0	2	1	89	0.00	0.0	3.955	0.004	0	0	0	2
PD.225	PL.2304	C	40QA	7.47Y	124.4	0.00	0.56	0.30	1	2	1	89	0.00	0.0	3.955	0.004	0	0	0	2
PL.2305	PD.225	C	#2 ACSR	7.47Y	124.4	0.00	0.56	0.30	0	2	1	89	0.00	0.0	4.046	0.091	2	1	2	2
PL.2168	PL.1790	ABC	#1/0 ACSR	7.47Y	124.4	0.02	0.58	28.29	12	610	170	96	0.08	0.0	3.989	0.038	0	0	0	121
PL.2169	PL.2168	ABC	#1/0 ACSR	7.46Y	124.4	0.04	0.61	28.29	12	610	170	96	0.15	0.0	4.058	0.069	0	0	0	121
PL.2024	PL.2169	ABC	#1/0 ACSR	7.46Y	124.3	0.05	0.67	28.29	12	610	170	96	0.22	0.0	4.162	0.104	0	0	0	121
PL.2023	PL.2024	ABC	#1/0 ACSR	7.46Y	124.3	0.03	0.70	28.29	12	610	170	96	0.13	0.0	4.221	0.060	0	0	0	121
PL.66256	PL.2023	ABC	#1/0 ACSR	7.46Y	124.3	0.05	0.75	28.29	12	610	169	96	0.20	0.0	4.317	0.096	0	0	0	121
PL.66257	PL.66256	ABC	#1/0 ACSR	7.45Y	124.2	0.02	0.77	28.29	12	610	169	96	0.10	0.0	4.365	0.048	0	0	0	121
PL.2021	PL.66257	ABC	#1/0 ACSR	7.45Y	124.2	0.06	0.83	28.29	12	610	169	96	0.23	0.0	4.473	0.109	0	0	0	121
PL.2158	PL.2021	ABC	#1/0 ACSR	7.45Y	124.1	0.04	0.86	28.29	12	609	169	96	0.15	0.0	4.546	0.073	16	4	2	121
PL.2159	PL.2158	ABC	#1/0 ACSR	7.45Y	124.1	0.02	0.89	27.55	12	593	164	96	0.10	0.0	4.597	0.050	10	3	2	119
PL.2296	PL.2159	C	#2 ACSR	7.45Y	124.1	0.00	0.89	2.21	1	16	4	97	0.00	0.0	4.601	0.004	0	0	0	2
PD.221	PL.2296	C	40QA	7.45Y	124.1	0.00	0.89	2.21	6	16	4	97	0.00	0.0	4.601	0.004	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2297	PD.221	C	#2 ACSR	7.45Y	124.1	0.00	0.89	2.21	1	16	4	97	0.00	0.0	4.603	0.002	16	4	2	2
PL.2136	PL.2159	ABC	#1/0 ACSR	7.44Y	124.1	0.03	0.92	26.33	11	567	157	96	0.12	0.0	4.667	0.070	24	7	7	115
PL.2524	PL.2136	A	8 A (CWC)	7.44Y	124.1	0.01	0.93	21.64	22	155	43	96	0.01	0.0	4.671	0.005	0	0	0	30
PD.332	PL.2524	A	15T	7.44Y	124.1	0.00	0.93	21.64	0	155	43	96	0.00	0.0	4.671	0.005	0	0	0	30
PL.2525	PD.332	A	8 A (CWC)	7.44Y	124.0	0.11	1.03	21.64	22	155	43	96	0.13	0.1	4.744	0.073	0	0	0	30
PL.1807	PL.2525	A	8 A (CWC)	7.43Y	123.8	0.18	1.21	21.64	22	155	43	96	0.22	0.1	4.868	0.123	0	0	0	30
PL.2134	PL.1807	A	8 A (CWC)	7.42Y	123.7	0.11	1.32	21.64	22	155	43	96	0.13	0.1	4.945	0.077	11	3	2	30
PL.1808	PL.2134	A	#4 ACSR	7.42Y	123.7	0.00	1.32	1.81	1	13	4	96	0.00	0.0	4.963	0.018	13	4	1	1
PL.2160	PL.2134	A	8 A (CWC)	7.42Y	123.6	0.07	1.39	18.35	18	131	36	96	0.07	0.1	5.007	0.062	11	3	2	27
PL.2161	PL.2160	A	8 A (CWC)	7.41Y	123.6	0.05	1.44	16.83	17	120	33	96	0.04	0.0	5.049	0.042	0	0	0	25
PL.2162	PL.2161	A	8 A (CWC)	7.41Y	123.5	0.02	1.46	16.83	17	120	33	96	0.02	0.0	5.071	0.022	3	1	1	25
PL.2163	PL.2162	A	8 A (CWC)	7.41Y	123.4	0.10	1.56	16.44	16	117	32	96	0.09	0.1	5.169	0.098	11	3	3	24
PL.1809	PL.2163	A	8 A (CWC)	7.40Y	123.4	0.03	1.60	10.19	10	73	20	96	0.02	0.0	5.218	0.049	7	2	1	12
PL.2166	PL.1809	A	#4 ACSR	7.40Y	123.4	0.00	1.60	3.57	3	25	7	96	0.00	0.0	5.249	0.030	11	3	1	2
PL.2167	PL.2166	A	#4 ACSR	7.40Y	123.4	0.00	1.60	1.98	2	14	4	96	0.00	0.0	5.273	0.025	14	4	1	1
PL.1811	PL.1809	A	8 A (CWC)	7.40Y	123.4	0.01	1.61	2.25	2	16	4	97	0.00	0.0	5.287	0.069	4	1	1	4
PL.1813	PL.1811	A	#2 ACSR	7.40Y	123.4	0.00	1.61	1.72	1	12	3	97	0.00	0.0	5.338	0.051	12	3	3	3
PL.65779	PL.1811	A	#1/0 ACSR	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	5.358	0.071	0	0	0	0
PL.1812	PL.1809	A	#4 ACSR	7.40Y	123.4	0.00	1.60	3.45	3	25	7	96	0.00	0.0	5.248	0.030	0	0	0	5
PL.1836	PL.1812	A	8 A (CWC)	7.40Y	123.4	0.03	1.64	3.45	3	25	7	96	0.01	0.0	5.398	0.150	0	0	0	5
PL.1814	PL.1836	A	8 A (CWC)	7.40Y	123.3	0.02	1.66	3.45	3	25	7	96	0.00	0.0	5.499	0.101	0	0	0	5
PL.1815	PL.1814	A	8 A (CWC)	7.40Y	123.3	0.01	1.66	1.94	2	14	4	96	0.00	0.0	5.538	0.039	0	0	0	3
PL.1818	PL.1815	A	#4 ACSR	7.40Y	123.3	0.00	1.66	0.97	1	7	2	96	0.00	0.0	5.559	0.021	7	2	1	1
PL.1817	PL.1815	A	#4 ACSR	7.40Y	123.3	0.00	1.67	0.97	1	7	2	96	0.00	0.0	5.587	0.049	7	2	1	2
PL.1819	PL.1817	A	#4 ACSR	7.40Y	123.3	0.00	1.67	0.01	0	0	0	100	0.00	0.0	5.623	0.036	0	0	0	1
PL.1820	PL.1819	A	#4 ACSR	7.40Y	123.3	0.00	1.67	0.01	0	0	0	100	0.00	0.0	5.675	0.052	0	0	1	1
PL.1816	PL.1814	A	#4 ACSR	7.40Y	123.3	0.00	1.66	1.50	1	11	3	96	0.00	0.0	5.535	0.036	11	3	2	2
PL.2135	PL.2163	A	#4 ACSR	7.41Y	123.4	0.00	1.57	4.66	4	33	9	96	0.00	0.0	5.189	0.020	20	5	4	9
PL.1810	PL.2135	A	#1/0 ACSR	7.41Y	123.4	0.00	1.57	1.49	1	11	3	96	0.00	0.0	5.231	0.042	11	3	1	1
PL.2164	PL.2135	A	#4 ACSR	7.41Y	123.4	0.00	1.57	0.41	0	3	1	95	0.00	0.0	5.235	0.045	1	0	3	4
PL.2165	PL.2164	A	#4 ACSR	7.41Y	123.4	0.00	1.57	0.21	0	2	0	100	0.00	0.0	5.285	0.051	2	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1806	PL.2136	ABC	#1/0 ACSR	7.44Y	124.1	0.02	0.94	16.60	7	357	99	96	0.05	0.0	4.740	0.073	13	4	3	73
PL.2300	PL.1806	BC	#1/0 ACSR	7.44Y	124.0	0.02	0.96	19.80	9	284	79	96	0.04	0.0	4.786	0.047	0	0	0	56
PD.223	PL.2300	BC	25T	7.44Y	124.0	0.00	0.96	19.80	0	284	79	96	0.00	0.0	4.786	0.047	0	0	0	56
PL.2301	PD.223	BC	#1/0 ACSR	7.44Y	124.0	0.01	0.97	19.80	9	284	79	96	0.02	0.0	4.821	0.034	26	7	4	56
PL.2150	PL.2301	BC	#1/0 ACSR	7.44Y	124.0	0.03	1.00	17.96	8	258	71	96	0.05	0.0	4.900	0.079	17	5	7	52
PL.2137	PL.2150	C	#1/0 ACSR	7.44Y	124.0	0.00	1.01	8.67	4	62	17	96	0.00	0.0	4.919	0.019	0	0	1	11
PL.1826	PL.2137	C	#1/0 ACSR	7.44Y	124.0	0.01	1.02	8.67	4	62	17	96	0.00	0.0	4.968	0.049	22	6	3	10
PL.2143	PL.1826	C	#1/0 ACSR	7.44Y	124.0	0.01	1.02	5.61	2	40	11	96	0.00	0.0	5.054	0.086	21	6	3	7
PL.2144	PL.2143	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	2.71	1	19	5	97	0.00	0.0	5.090	0.036	0	0	0	4
PL.1592	PL.2144	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	2.71	1	19	5	97	0.00	0.0	5.133	0.044	7	2	2	4
PL.1834	PL.1592	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	1.67	1	12	3	97	0.00	0.0	5.151	0.017	0	0	0	2
PL.1835	PL.1834	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	1.67	1	12	3	97	0.00	0.0	5.192	0.041	12	3	2	2
PL.1825	PL.2150	B	#1/0 ACSR	7.44Y	124.0	0.02	1.03	24.84	11	178	49	96	0.03	0.0	4.940	0.040	15	4	2	34
PL.2148	PL.1825	B	#1/0 ACSR	7.44Y	124.0	0.02	1.04	22.76	10	163	45	96	0.02	0.0	4.975	0.036	33	9	7	32
PL.2149	PL.2148	B	#1/0 ACSR	7.44Y	123.9	0.02	1.06	18.11	8	130	36	96	0.02	0.0	5.021	0.046	9	2	1	25
PL.2145	PL.2149	B	#1/0 ACSR	7.44Y	123.9	0.01	1.08	16.91	7	121	33	96	0.01	0.0	5.058	0.036	15	4	2	24
PL.1827	PL.2145	B	#1/0 ACSR	7.43Y	123.9	0.01	1.09	5.99	3	43	12	96	0.00	0.0	5.160	0.102	18	5	4	11
PL.1830	PL.1827	B	#1/0 ACSR	7.43Y	123.9	0.00	1.09	3.05	1	22	6	96	0.00	0.0	5.211	0.051	10	3	2	6
PL.1832	PL.1830	B	#1/0 ACSR	7.43Y	123.9	0.00	1.09	1.70	1	12	3	97	0.00	0.0	5.250	0.040	7	2	1	3
PL.1833	PL.1832	B	8 A (CWC)	7.43Y	123.9	0.00	1.09	0.74	1	5	1	98	0.00	0.0	5.296	0.046	5	1	2	2
PL.21313	PL.1830	B	#1/0 ACSR	7.43Y	123.9	0.00	1.09	0.01	0	0	0	100	0.00	0.0	5.232	0.022	0	0	0	1
PL.21314	PL.21313	B	#1/0 ACSR	7.43Y	123.9	0.00	1.09	0.01	0	0	0	100	0.00	0.0	5.302	0.070	0	0	1	1
PL.1831	PL.1827	B	#4 ACSR	7.43Y	123.9	0.00	1.09	0.48	0	3	1	95	0.00	0.0	5.230	0.071	3	1	1	1
PL.1829	PL.2145	B	#4 ACSR	7.44Y	123.9	0.00	1.08	5.33	4	38	11	96	0.00	0.0	5.084	0.027	38	11	6	6
PL.2146	PL.2145	B	#2 ACSR	7.44Y	123.9	0.00	1.08	3.06	2	22	6	96	0.00	0.0	5.088	0.030	20	5	3	4
PL.2147	PL.2146	B	#2 ACSR	7.44Y	123.9	0.00	1.08	0.33	0	2	1	89	0.00	0.0	5.117	0.029	2	1	1	1
PL.1828	PL.2145	B	#2 ACSR	7.44Y	123.9	0.00	1.08	0.51	0	4	1	97	0.00	0.0	5.074	0.016	4	1	1	1
PL.28010	PL.2145	B	#1/0 ACSR	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	5.087	0.029	0	0	0	0
PL.2151	PL.1806	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	1.54	1	11	3	96	0.00	0.0	4.763	0.024	4	1	3	4
PL.2152	PL.2151	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	1.01	0	7	2	96	0.00	0.0	4.799	0.036	7	2	1	1
PL.2298	PL.1806	C	8 A (CWC)	7.44Y	124.1	0.00	0.94	6.82	7	49	14	96	0.00	0.0	4.744	0.005	0	0	0	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.222	PL.2298	C	40QA	7.44Y	124.1	0.00	0.94	6.82	17	49	14	96	0.00	0.0	4.744	0.005	0	0	0	10
PL.2299	PD.222	C	8 A (CWC)	7.44Y	124.0	0.02	0.96	6.82	7	49	14	96	0.01	0.0	4.796	0.052	24	7	3	10
PL.1821	PL.2299	C	8 A (CWC)	7.44Y	124.0	0.02	0.98	3.45	3	25	7	96	0.00	0.0	4.878	0.082	5	1	1	7
PL.1822	PL.1821	C	8 A (CWC)	7.44Y	124.0	0.01	0.99	2.76	3	20	5	97	0.00	0.0	4.924	0.046	3	1	1	6
PL.1823	PL.1822	C	8 A (CWC)	7.44Y	124.0	0.01	1.00	2.30	2	17	5	96	0.00	0.0	5.023	0.100	8	2	2	5
PL.2153	PL.1823	C	8 A (CWC)	7.44Y	124.0	0.00	1.00	0.66	1	5	1	98	0.00	0.0	5.067	0.043	2	1	1	2
PL.2154	PL.2153	C	8 A (CWC)	7.44Y	124.0	0.00	1.00	0.39	0	3	1	95	0.00	0.0	5.118	0.051	0	0	0	1
PL.1837	PL.2154	C	6 A (CWC)	7.44Y	124.0	0.00	1.00	0.39	0	3	1	95	0.00	0.0	5.169	0.051	3	1	1	1
PL.1824	PL.1823	C	8 A (CWC)	7.44Y	124.0	0.00	1.00	0.50	0	4	1	97	0.00	0.0	5.071	0.048	4	1	1	1
PL.2302	PL.2136	A	#4 ACSR	7.44Y	124.1	0.00	0.92	4.25	3	30	8	97	0.00	0.0	4.671	0.005	0	0	0	5
PD.224	PL.2302	A	40QA	7.44Y	124.1	0.00	0.92	4.25	11	30	8	97	0.00	0.0	4.671	0.005	0	0	0	5
PL.2303	PD.224	A	#4 ACSR	7.44Y	124.1	0.01	0.93	4.25	3	30	8	97	0.00	0.0	4.705	0.034	0	0	0	5
PL.2155	PL.2303	A	#4 ACSR	7.44Y	124.1	0.01	0.93	4.25	3	30	8	97	0.00	0.0	4.757	0.052	18	5	2	5
PL.2156	PL.2155	A	#4 ACSR	7.44Y	124.1	0.00	0.94	1.77	1	13	4	96	0.00	0.0	4.814	0.057	4	1	2	3
PL.2157	PL.2156	A	#4 ACSR	7.44Y	124.1	0.00	0.94	1.29	1	9	3	95	0.00	0.0	4.833	0.018	9	3	1	1
PL.1776	PL.2182	C	#2 ACSR	7.12Y	118.6	0.01	6.41	11.07	6	76	21	96	0.01	0.0	3.464	0.049	32	9	5	16
PL.2522	PL.1776	C	8 A (CWC)	7.12Y	118.6	0.00	6.42	6.46	6	44	12	96	0.00	0.0	3.469	0.005	0	0	0	11
PD.331	PL.2522	C	40QA	7.12Y	118.6	0.00	6.42	6.46	16	44	12	96	0.00	0.0	3.469	0.005	0	0	0	11
PL.2523	PD.331	C	8 A (CWC)	7.11Y	118.6	0.02	6.44	6.46	6	44	12	96	0.01	0.0	3.533	0.064	13	4	2	11
PL.1777	PL.2523	C	8 A (CWC)	7.11Y	118.5	0.03	6.47	4.61	5	32	9	96	0.01	0.0	3.640	0.107	0	0	0	9
PL.2183	PL.1777	C	8 A (CWC)	7.11Y	118.5	0.02	6.49	4.61	5	32	9	96	0.00	0.0	3.710	0.070	5	1	2	9
PL.2184	PL.2183	C	8 A (CWC)	7.11Y	118.5	0.02	6.52	3.92	4	27	7	97	0.01	0.0	3.811	0.100	4	1	1	7
PL.1779	PL.2184	C	8 A (CWC)	7.11Y	118.5	0.02	6.54	3.34	3	23	6	97	0.00	0.0	3.911	0.100	0	0	0	6
PL.1781	PL.1779	C	6 A (CWC)	7.11Y	118.4	0.01	6.55	3.34	2	23	6	97	0.00	0.0	3.990	0.080	0	0	0	6
PL.1783	PL.1781	C	6 A (CWC)	7.11Y	118.4	0.01	6.56	3.34	2	23	6	97	0.00	0.0	4.069	0.079	0	0	1	6
PL.1784	PL.1783	C	8 A (CWC)	7.11Y	118.4	0.00	6.56	0.43	0	3	1	95	0.00	0.0	4.124	0.055	2	1	1	2
PL.1787	PL.1784	C	#2 ACSR	7.11Y	118.4	0.00	6.56	0.16	0	1	0	100	0.00	0.0	4.156	0.032	0	0	0	1
PL.1981	PL.1787	C	#2 ACSR	7.11Y	118.4	0.00	6.56	0.16	0	1	0	100	0.00	0.0	4.250	0.094	1	0	1	1
PL.1785	PL.1783	C	#4 ACSR	7.11Y	118.4	0.00	6.57	2.87	2	20	5	97	0.00	0.0	4.104	0.035	11	3	2	3
PL.1786	PL.1785	C	#4 ACSR	7.11Y	118.4	0.00	6.57	1.21	1	8	2	97	0.00	0.0	4.145	0.041	8	2	1	1
PL.1602	PL.2132	ABC	336 MCM AC	7.12Y	118.7	0.05	6.26	74.08	14	1522	438	96	0.45	0.0	3.346	0.098	0	0	0	375

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4468	PL.1602	ABC	336 MCM AC	7.12Y	118.7	0.00	6.27	74.08	14	1522	437	96	0.02	0.0	3.350	0.003	0	0	0	375
PD.901	PL.4468	ABC	100L	7.12Y	118.7	0.00	6.27	74.08	74	1522	437	96	0.00	0.0	3.350	0.003	0	0	0	375
PL.4469	PD.901	ABC	336 MCM AC	7.12Y	118.7	0.01	6.28	74.08	14	1522	437	96	0.12	0.0	3.376	0.026	0	0	0	375
PL.2127	PL.4469	ABC	336 MCM AC	7.12Y	118.7	0.03	6.31	73.90	14	1518	436	96	0.25	0.0	3.429	0.053	0	0	0	374
PL.2126	PL.2127	ABC	336 MCM AC	7.12Y	118.6	0.08	6.39	73.28	14	1505	432	96	0.69	0.0	3.582	0.154	0	0	0	372
PL.2124	PL.2126	ABC	336 MCM AC	7.11Y	118.5	0.08	6.48	72.39	14	1486	425	96	0.67	0.0	3.734	0.152	0	0	0	369
PL.2123	PL.2124	ABC	336 MCM AC	7.11Y	118.5	0.01	6.49	72.29	14	1483	423	96	0.12	0.0	3.762	0.027	0	0	0	368
PL.2121	PL.2123	ABC	336 MCM AC	7.11Y	118.4	0.08	6.57	71.65	14	1470	419	96	0.63	0.0	3.908	0.146	0	0	0	365
PL.2013	PL.2121	ABC	336 MCM AC	7.10Y	118.4	0.06	6.63	71.65	14	1469	417	96	0.50	0.0	4.024	0.116	0	0	0	365
PL.2352	PL.2013	C	#4 ACSR	7.10Y	118.4	0.00	6.63	1.21	1	8	2	97	0.00	0.0	4.028	0.005	0	0	0	5
PD.249	PL.2352	C	40QA	7.10Y	118.4	0.00	6.63	1.21	3	8	2	97	0.00	0.0	4.028	0.005	0	0	0	5
PL.2353	PD.249	C	#4 ACSR	7.10Y	118.4	0.00	6.63	1.21	1	8	2	97	0.00	0.0	4.048	0.020	8	2	5	5
PL.2116	PL.2013	ABC	336 MCM AC	7.10Y	118.3	0.02	6.65	71.25	14	1461	414	96	0.16	0.0	4.061	0.038	0	0	0	360
PL.2354	PL.2116	A	#2 ACSR	7.10Y	118.3	0.00	6.65	5.96	3	41	11	97	0.00	0.0	4.066	0.005	0	0	0	6
PD.250	PL.2354	A	40QA	7.10Y	118.3	0.00	6.65	5.96	15	41	11	97	0.00	0.0	4.066	0.005	0	0	0	6
PL.2355	PD.250	A	#2 ACSR	7.10Y	118.3	0.00	6.66	5.96	3	41	11	97	0.00	0.0	4.085	0.019	6	2	2	6
PL.1607	PL.2355	A	8 A (CWC)	7.10Y	118.3	0.01	6.67	5.13	5	35	10	96	0.00	0.0	4.137	0.052	21	6	2	4
PL.1609	PL.1607	A	#4 ACSR	7.10Y	118.3	0.00	6.67	2.13	2	15	4	97	0.00	0.0	4.196	0.059	15	4	2	2
PL.2258	PL.2116	ABC	336 MCM AC	7.10Y	118.3	0.03	6.68	69.26	13	1420	402	96	0.21	0.0	4.112	0.051	0	0	0	354
REG54	PL.2258	ABC	114.3 KVA	7.52Y	125.4	-7.05	-0.37	69.26	46	1419	402	96	percent Boost= 5.62 Tap= 9.0				0	0	0	354
PL.2259	REG54	ABC	336 MCM AC	7.52Y	125.3	0.05	-0.33	65.37	13	1419	402	96	0.34	0.0	4.207	0.095	6	2	1	354
PL.2256	PL.2259	ABC	336 MCM AC	7.52Y	125.3	0.02	-0.31	51.03	10	1107	315	96	0.12	0.0	4.262	0.055	2	0	1	290
PL.2257	PL.2256	ABC	336 MCM AC	7.52Y	125.3	0.02	-0.29	50.95	10	1106	314	96	0.11	0.0	4.311	0.049	9	3	1	289
PL.2117	PL.2257	ABC	336 MCM AC	7.51Y	125.2	0.07	-0.22	50.46	10	1095	311	96	0.38	0.0	4.492	0.180	6	2	1	287
PL.2114	PL.2117	ABC	336 MCM AC	7.51Y	125.2	0.02	-0.20	49.83	10	1081	306	96	0.11	0.0	4.544	0.052	0	0	0	283
PL.2111	PL.2114	ABC	336 MCM AC	7.51Y	125.2	0.04	-0.16	49.52	10	1074	304	96	0.23	0.0	4.654	0.110	0	0	0	280
PL.2498	PL.2111	C	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.98	1	7	2	96	0.00	0.0	4.659	0.005	0	0	0	3
PD.320	PL.2498	C	40QA	7.51Y	125.2	0.00	-0.16	0.98	2	7	2	96	0.00	0.0	4.659	0.005	0	0	0	3
PL.2499	PD.320	C	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.98	1	7	2	96	0.00	0.0	4.678	0.020	0	0	0	3
PL.2108	PL.2499	C	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.15	0	1	0	100	0.00	0.0	4.704	0.026	1	0	1	1
PL.1651	PL.2499	C	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.82	0	6	2	95	0.00	0.0	4.705	0.027	6	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2456	PL.2111	A	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.65	0	5	1	98	0.00	0.0	4.659	0.005	0	0	0	1
PD.298	PL.2456	A	40QA	7.51Y	125.2	0.00	-0.16	0.65	2	5	1	98	0.00	0.0	4.659	0.005	0	0	0	1
PL.2457	PD.298	A	#2 ACSR	7.51Y	125.2	0.00	-0.16	0.65	0	5	1	98	0.00	0.0	4.678	0.020	5	1	1	1
PL.2105	PL.2111	ABC	336 MCM AC	7.51Y	125.1	0.07	-0.09	48.98	9	1062	300	96	0.37	0.0	4.835	0.181	0	0	0	276
PL.2254	PL.2105	ABC	336 MCM AC	7.50Y	125.1	0.04	-0.05	48.62	9	1054	297	96	0.23	0.0	4.948	0.113	0	0	0	269
PL.2255	PL.2254	ABC	336 MCM AC	7.50Y	125.0	0.02	-0.03	48.62	9	1054	297	96	0.11	0.0	5.005	0.057	0	0	0	269
PL.2106	PL.2255	ABC	336 MCM AC	7.50Y	125.0	0.03	-0.00	48.13	9	1043	293	96	0.17	0.0	5.089	0.085	1	0	1	266
PL.2466	PL.2106	A	#4 ACSR	7.50Y	125.0	0.00	-0.00	1.13	1	8	2	97	0.00	0.0	5.094	0.005	0	0	0	3
PD.304	PL.2466	A	40QA	7.50Y	125.0	0.00	-0.00	1.13	3	8	2	97	0.00	0.0	5.094	0.005	0	0	0	3
PL.2467	PD.304	A	#4 ACSR	7.50Y	125.0	0.00	-0.00	1.13	1	8	2	97	0.00	0.0	5.117	0.023	8	2	3	3
PL.2107	PL.2106	ABC	336 MCM AC	7.50Y	125.0	0.04	0.03	47.71	9	1033	290	96	0.19	0.0	5.189	0.099	0	0	0	262
PL.2104	PL.2107	ABC	336 MCM AC	7.50Y	124.9	0.02	0.05	38.12	7	825	232	96	0.08	0.0	5.250	0.061	0	0	0	205
PL.2414	PL.2104	A	#4 ACSR	7.50Y	124.9	0.00	0.05	2.91	2	21	6	96	0.00	0.0	5.255	0.005	0	0	0	2
PD.277	PL.2414	A	40QA	7.50Y	124.9	0.00	0.05	2.91	7	21	6	96	0.00	0.0	5.255	0.005	0	0	0	2
PL.2415	PD.277	A	#4 ACSR	7.50Y	124.9	0.00	0.05	2.91	2	21	6	96	0.00	0.0	5.268	0.013	21	6	2	2
PL.2103	PL.2104	ABC	336 MCM AC	7.50Y	124.9	0.02	0.07	36.00	7	779	220	96	0.07	0.0	5.314	0.064	0	0	0	200
PL.2502	PL.2103	C	#4 ACSR	7.50Y	124.9	0.00	0.07	1.16	1	8	2	97	0.00	0.0	5.318	0.005	0	0	0	2
PD.322	PL.2502	C	40QA	7.50Y	124.9	0.00	0.07	1.16	3	8	2	97	0.00	0.0	5.318	0.005	0	0	0	2
PL.2503	PD.322	C	#4 ACSR	7.50Y	124.9	0.00	0.07	1.16	1	8	2	97	0.00	0.0	5.338	0.020	8	2	2	2
PL.2102	PL.2103	ABC	336 MCM AC	7.50Y	124.9	0.01	0.08	35.16	7	761	214	96	0.06	0.0	5.369	0.056	2	1	1	196
PL.2504	PL.2102	C	#4 ACSR	7.50Y	124.9	0.00	0.08	0.66	1	5	1	98	0.00	0.0	5.374	0.004	0	0	0	1
PD.323	PL.2504	C	40QA	7.50Y	124.9	0.00	0.08	0.66	2	5	1	98	0.00	0.0	5.374	0.004	0	0	0	1
PL.2505	PD.323	C	#4 ACSR	7.50Y	124.9	0.00	0.08	0.66	1	5	1	98	0.00	0.0	5.377	0.004	5	1	1	1
PL.2267	PL.2102	ABC	336 MCM AC	7.49Y	124.9	0.02	0.10	34.86	7	754	212	96	0.06	0.0	5.433	0.064	27	10	6	194
PL.2268	PL.2267	ABC	336 MCM AC	7.49Y	124.9	0.01	0.11	33.57	6	727	202	96	0.03	0.0	5.467	0.033	11	3	3	188
PL.2225	PL.2268	ABC	336 MCM AC	7.49Y	124.9	0.01	0.11	33.05	6	716	199	96	0.02	0.0	5.491	0.024	3	1	2	185
PL.2226	PL.2225	ABC	336 MCM AC	7.49Y	124.9	0.02	0.13	32.90	6	712	198	96	0.08	0.0	5.573	0.083	7	2	3	183
PL.2420	PL.2226	C	#4 ACSR	7.49Y	124.9	0.00	0.14	14.68	11	106	29	96	0.00	0.0	5.578	0.004	0	0	0	24
PD.280	PL.2420	C	40QA	7.49Y	124.9	0.00	0.14	14.68	37	106	29	96	0.00	0.0	5.578	0.004	0	0	0	24
PL.2421	PD.280	C	#4 ACSR	7.49Y	124.8	0.04	0.18	14.68	11	106	29	96	0.03	0.0	5.641	0.064	12	3	2	24
PL.1688	PL.2421	C	8 A (CWC)	7.49Y	124.8	0.05	0.22	13.05	13	94	26	96	0.03	0.0	5.704	0.062	28	8	9	22

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1689	PL.1688	C	8 A (CWC)	7.49Y	124.8	0.03	0.25	9.15	9	66	18	96	0.01	0.0	5.754	0.050	16	4	3	13
PL.1690	PL.1689	C	8 A (CWC)	7.48Y	124.7	0.02	0.27	6.01	6	43	12	96	0.01	0.0	5.842	0.088	26	7	5	9
PL.1692	PL.1690	C	8 A (CWC)	7.48Y	124.7	0.01	0.28	2.32	2	17	5	96	0.00	0.0	5.923	0.080	4	1	1	3
PL.1693	PL.1692	C	#2 ACSR	7.48Y	124.7	0.00	0.29	0.87	0	6	2	95	0.00	0.0	5.997	0.075	6	2	1	1
PL.1694	PL.1692	C	#4 ACSR	7.48Y	124.7	0.00	0.28	0.87	1	6	2	95	0.00	0.0	5.928	0.006	6	2	1	1
PL.65819	PL.1690	C	#1/0 ACSR	7.48Y	124.7	0.00	0.27	0.12	0	1	0	100	0.00	0.0	5.861	0.019	1	0	1	1
PL.1691	PL.1689	C	#4 ACSR	7.49Y	124.8	0.00	0.25	0.89	1	6	2	95	0.00	0.0	5.774	0.020	6	2	1	1
PL.2508	PL.2226	ABC	336 MCM AC	7.49Y	124.9	0.00	0.13	25.31	5	548	153	96	0.00	0.0	5.578	0.004	0	0	0	141
PL.2509	PL.2508	ABC	336 MCM AC	7.49Y	124.9	0.01	0.14	25.31	5	548	153	96	0.02	0.0	5.609	0.031	21	6	3	141
PL.2229	PL.2509	ABC	336 MCM AC	7.49Y	124.9	0.01	0.15	24.32	5	527	147	96	0.02	0.0	5.655	0.046	6	2	2	138
PL.2418	PL.2229	A	#4 ACSR	7.49Y	124.9	0.00	0.15	1.15	1	8	2	97	0.00	0.0	5.659	0.005	0	0	0	5
PD.279	PL.2418	A	40QA	7.49Y	124.9	0.00	0.15	1.15	3	8	2	97	0.00	0.0	5.659	0.005	0	0	0	5
PL.2419	PD.279	A	#4 ACSR	7.49Y	124.9	0.00	0.15	1.15	1	8	2	97	0.00	0.0	5.665	0.006	8	2	5	5
PL.2232	PL.2229	ABC	336 MCM AC	7.49Y	124.8	0.01	0.16	23.68	5	513	143	96	0.02	0.0	5.700	0.045	1	0	2	131
PL.2233	PL.2232	ABC	336 MCM AC	7.49Y	124.8	0.02	0.18	23.62	5	511	142	96	0.06	0.0	5.824	0.124	0	0	0	129
PL.2014	PL.2233	ABC	336 MCM AC	7.49Y	124.8	0.03	0.21	23.62	5	511	142	96	0.08	0.0	5.988	0.164	0	0	0	129
PL.2422	PL.2014	A	#4 ACSR	7.49Y	124.8	0.00	0.21	0.00	0	0	0	100	0.00	0.0	5.993	0.005	0	0	0	0
PD.281	PL.2422	A	40QA	7.49Y	124.8	0.00	0.21	0.00	0	0	0	100	0.00	0.0	5.993	0.005	0	0	0	0
PL.2423	PD.281	A	#1/0 ACSR	7.49Y	124.8	0.00	0.21	0.00	0	0	0	100	0.00	0.0	6.034	0.041	0	0	0	0
PL.2089	PL.2014	ABC	336 MCM AC	7.49Y	124.8	0.02	0.23	23.62	5	511	142	96	0.06	0.0	6.122	0.134	0	0	0	129
PL.2424	PL.2089	A	#4 ACSR	7.49Y	124.8	0.00	0.23	1.14	1	8	2	97	0.00	0.0	6.127	0.005	0	0	0	3
PD.282	PL.2424	A	40QA	7.49Y	124.8	0.00	0.23	1.14	3	8	2	97	0.00	0.0	6.127	0.005	0	0	0	3
PL.2425	PD.282	A	#4 ACSR	7.49Y	124.8	0.00	0.23	1.14	1	8	2	97	0.00	0.0	6.153	0.026	0	0	1	3
PL.1699	PL.2425	A	#4 ACSR	7.49Y	124.8	0.01	0.24	1.12	1	8	2	97	0.00	0.0	6.313	0.161	0	0	0	2
PL.1701	PL.1699	A	#4 ACSR	7.49Y	124.8	0.01	0.25	1.12	1	8	2	97	0.00	0.0	6.417	0.103	0	0	0	2
PL.1702	PL.1701	A	#4 ACSR	7.49Y	124.8	0.00	0.25	1.12	1	8	2	97	0.00	0.0	6.478	0.061	0	0	0	2
PL.1703	PL.1702	A	#4 ACSR	7.49Y	124.8	0.00	0.25	0.01	0	0	0	100	0.00	0.0	6.528	0.050	0	0	0	1
PL.1705	PL.1703	A	#2 ACSR	7.49Y	124.8	0.00	0.25	0.01	0	0	0	100	0.00	0.0	6.547	0.019	0	0	0	1
PL.1706	PL.1705	A	#4 ACSR	7.49Y	124.8	0.00	0.25	0.01	0	0	0	100	0.00	0.0	6.600	0.053	0	0	1	1
PL.1704	PL.1702	A	#4 ACSR	7.49Y	124.8	0.00	0.25	1.11	1	8	2	97	0.00	0.0	6.538	0.060	8	2	1	1
PL.2086	PL.2089	ABC	336 MCM AC	7.49Y	124.8	0.01	0.25	23.24	4	503	140	96	0.04	0.0	6.207	0.085	0	0	0	126

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2234	PL.2086	ABC	336 MCM AC	7.49Y	124.8	0.00	0.25	22.27	4	482	134	96	0.01	0.0	6.234	0.027	0	0	0	122
PL.2235	PL.2234	ABC	336 MCM AC	7.48Y	124.7	0.01	0.26	22.27	4	482	134	96	0.02	0.0	6.281	0.046	6	2	2	122
PL.65772	PL.2235	ABC	336 MCM AC	7.48Y	124.7	0.01	0.26	22.00	4	476	132	96	0.01	0.0	6.316	0.035	0	0	0	120
PL.65773	PL.65772	ABC	336 MCM AC	7.48Y	124.7	0.00	0.27	22.00	4	476	132	96	0.01	0.0	6.332	0.016	8	2	1	120
PL.2238	PL.65773	ABC	336 MCM AC	7.48Y	124.7	0.01	0.28	21.64	4	468	130	96	0.02	0.0	6.394	0.062	4	1	3	119
PL.2236	PL.2238	ABC	336 MCM AC	7.48Y	124.7	0.02	0.29	21.44	4	464	129	96	0.04	0.0	6.504	0.110	0	0	0	116
PL.2239	PL.2236	ABC	336 MCM AC	7.48Y	124.7	0.01	0.30	21.27	4	460	128	96	0.02	0.0	6.560	0.056	16	4	3	114
PL.2240	PL.2239	ABC	336 MCM AC	7.48Y	124.7	0.01	0.31	20.53	4	444	123	96	0.01	0.0	6.601	0.041	9	3	5	111
PL.2241	PL.2240	ABC	336 MCM AC	7.48Y	124.7	0.02	0.32	20.10	4	435	121	96	0.04	0.0	6.706	0.105	3	1	1	106
PL.2074	PL.2241	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	19.01	4	411	114	96	0.01	0.0	6.741	0.034	0	0	0	102
PL.2564	PL.2074	ABC	336 MCM AC	7.48Y	124.7	0.00	0.33	19.01	4	411	114	96	0.01	0.0	6.770	0.029	0	0	0	102
PD.355	PL.2564	ABC	50L	7.48Y	124.7	0.00	0.33	19.01	38	411	114	96	0.00	0.0	6.770	0.029	0	0	0	102
PL.2565	PD.355	ABC	336 MCM AC	7.48Y	124.7	0.00	0.34	19.01	4	411	114	96	0.01	0.0	6.800	0.030	0	0	0	102
PL.2512	PL.2565	C	#4 ACSR	7.48Y	124.7	0.00	0.34	11.18	9	81	22	97	0.00	0.0	6.805	0.004	0	0	0	17
PD.326	PL.2512	C	25T	7.48Y	124.7	0.00	0.34	11.18	0	81	22	97	0.00	0.0	6.805	0.004	0	0	0	17
PL.2513	PD.326	C	#4 ACSR	7.48Y	124.6	0.02	0.36	11.18	9	81	22	97	0.01	0.0	6.849	0.044	20	5	3	17
PL.1710	PL.2513	C	#4 ACSR	7.48Y	124.6	0.06	0.42	8.43	6	61	17	96	0.03	0.0	7.001	0.152	0	0	0	14
PL.1715	PL.1710	C	#4 ACSR	7.47Y	124.5	0.06	0.47	8.43	6	61	17	96	0.02	0.0	7.159	0.158	7	2	2	14
PL.1718	PL.1715	C	8 A (CWC)	7.47Y	124.5	0.05	0.52	7.48	7	54	15	96	0.02	0.0	7.259	0.100	8	2	3	12
PL.1721	PL.1718	C	#4 ACSR	7.47Y	124.5	0.02	0.54	6.38	5	46	13	96	0.01	0.0	7.324	0.065	0	0	0	9
PL.1720	PL.1721	C	#4 ACSR	7.47Y	124.4	0.02	0.55	6.38	5	46	13	96	0.00	0.0	7.388	0.063	14	4	3	9
PL.1723	PL.1720	C	#4 ACSR	7.47Y	124.4	0.01	0.56	4.49	3	32	9	96	0.00	0.0	7.422	0.034	6	2	1	6
PL.1724	PL.1723	C	#4 ACSR	7.47Y	124.4	0.01	0.56	3.71	3	27	7	97	0.00	0.0	7.455	0.033	0	0	0	5
PL.1725	PL.1724	C	#4 ACSR	7.47Y	124.4	0.00	0.57	3.71	3	27	7	97	0.00	0.0	7.476	0.022	0	0	0	5
PL.2514	PL.1725	C	#4 ACSR	7.47Y	124.4	0.00	0.57	2.29	2	16	5	95	0.00	0.0	7.481	0.005	0	0	0	3
PD.327	PL.2514	C	15T	7.47Y	124.4	0.00	0.57	2.29	0	16	5	95	0.00	0.0	7.481	0.005	0	0	0	3
PL.2515	PD.327	C	#4 ACSR	7.47Y	124.4	0.01	0.58	2.29	2	16	5	95	0.00	0.0	7.556	0.075	0	0	0	3
PL.1727	PL.2515	C	#4 ACSR	7.47Y	124.4	0.00	0.58	0.52	0	4	1	97	0.00	0.0	7.573	0.017	4	1	1	1
PL.1728	PL.2515	C	#4 ACSR	7.46Y	124.4	0.01	0.58	1.77	1	13	4	96	0.00	0.0	7.672	0.116	0	0	0	2
PL.1730	PL.1728	C	#4 ACSR	7.46Y	124.4	0.00	0.58	0.00	0	0	0	100	0.00	0.0	7.706	0.034	0	0	0	0
PL.1731	PL.1730	C	#4 ACSR	7.46Y	124.4	0.01	0.59	1.77	1	13	4	96	0.00	0.0	7.795	0.123	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1732	PL.1731	C	#4 ACSR	7.46Y	124.4	0.01	0.61	1.77	1	13	4	96	0.00	0.0	7.935	0.140	0	0	0	2
PL.1734	PL.1732	C	#4 ACSR	7.46Y	124.4	0.00	0.61	1.33	1	10	3	96	0.00	0.0	7.989	0.054	10	3	1	1
PL.1736	PL.1732	C	#2 ACSR	7.46Y	124.4	0.00	0.61	0.44	0	3	1	95	0.00	0.0	8.038	0.103	0	0	0	1
PL.1737	PL.1736	C	#2 ACSR	7.46Y	124.4	0.00	0.61	0.44	0	3	1	95	0.00	0.0	8.181	0.143	0	0	0	1
PL.1738	PL.1737	C	#1/0 ACSR	7.46Y	124.4	0.00	0.61	0.44	0	3	1	95	0.00	0.0	8.267	0.086	3	1	1	1
PL.1726	PL.1725	C	#4 ACSR	7.47Y	124.4	0.00	0.57	1.42	1	10	3	96	0.00	0.0	7.492	0.016	10	3	2	2
PL.2073	PL.2565	ABC	336 MCM AC	7.48Y	124.7	0.01	0.34	15.28	3	330	92	96	0.01	0.0	6.863	0.063	0	0	0	85
PL.2072	PL.2073	ABC	336 MCM AC	7.48Y	124.6	0.02	0.36	14.68	3	318	88	96	0.03	0.0	7.018	0.155	0	0	0	82
PL.65775	PL.2072	ABC	336 MCM AC	7.48Y	124.6	0.01	0.37	14.68	3	318	88	96	0.01	0.0	7.091	0.072	0	0	0	82
PL.65777	PL.65775	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	7.136	0.046	0	0	0	0
PD.9594	PL.65777	C	15T	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	7.136	0.046	0	0	0	0
PL.65778	PD.9594	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	7.274	0.138	0	0	0	0
PL.65776	PL.65775	ABC	336 MCM AC	7.48Y	124.6	0.01	0.37	14.68	3	318	88	96	0.01	0.0	7.147	0.056	0	0	0	82
PL.2435	PL.65776	ABC	336 MCM AC	7.48Y	124.6	0.00	0.38	14.68	3	317	88	96	0.00	0.0	7.151	0.004	0	0	0	82
PL.2242	PL.2435	ABC	336 MCM AC	7.48Y	124.6	0.01	0.38	14.34	3	310	86	96	0.01	0.0	7.214	0.064	2	1	1	79
PL.2243	PL.2242	ABC	336 MCM AC	7.48Y	124.6	0.00	0.39	14.23	3	308	85	96	0.01	0.0	7.261	0.046	0	0	2	78
PL.1740	PL.2243	ABC	336 MCM AC	7.48Y	124.6	0.01	0.39	14.23	3	308	85	96	0.01	0.0	7.318	0.057	0	0	1	76
PL.2070	PL.1740	ABC	336 MCM AC	7.48Y	124.6	0.00	0.40	14.23	3	308	85	96	0.01	0.0	7.362	0.044	22	6	6	75
PL.2071	PL.2070	ABC	336 MCM AC	7.48Y	124.6	0.01	0.40	9.43	2	204	56	96	0.01	0.0	7.440	0.078	34	9	5	54
PL.2440	PL.2071	A	8 A (CWC)	7.48Y	124.6	0.00	0.40	5.79	6	42	12	96	0.00	0.0	7.445	0.005	0	0	0	10
PD.289	PL.2440	A	25T	7.48Y	124.6	0.00	0.40	5.79	0	42	12	96	0.00	0.0	7.445	0.005	0	0	0	10
PL.2441	PD.289	A	8 A (CWC)	7.48Y	124.6	0.00	0.41	5.79	6	42	12	96	0.00	0.0	7.453	0.009	0	0	0	10
PL.1754	PL.2441	A	8 A (CWC)	7.48Y	124.6	0.01	0.41	5.79	6	42	12	96	0.00	0.0	7.473	0.019	15	4	5	10
PL.1755	PL.1754	A	8 A (CWC)	7.47Y	124.6	0.01	0.42	3.71	4	27	7	97	0.00	0.0	7.499	0.027	10	3	2	5
PL.1756	PL.1755	A	#2 ACSR	7.47Y	124.6	0.00	0.42	2.27	1	16	5	95	0.00	0.0	7.529	0.030	16	5	3	3
PL.2069	PL.2071	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	5.93	1	128	35	96	0.00	0.0	7.523	0.083	0	0	0	39
PL.2244	PL.2069	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	5.24	1	113	31	96	0.00	0.0	7.568	0.045	1	0	1	34
PL.2245	PL.2244	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	5.18	1	112	31	96	0.00	0.0	7.612	0.044	5	1	2	33
PL.2516	PL.2245	C	#4 ACSR	7.48Y	124.6	0.00	0.41	0.31	0	2	1	89	0.00	0.0	7.617	0.004	0	0	0	1
PD.328	PL.2516	C	25T	7.48Y	124.6	0.00	0.41	0.31	0	2	1	89	0.00	0.0	7.617	0.004	0	0	0	1
PL.2517	PD.328	C	#4 ACSR	7.48Y	124.6	0.00	0.41	0.31	0	2	1	89	0.00	0.0	7.654	0.038	2	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1757	PL.2245	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	4.84	1	105	29	96	0.00	0.0	7.682	0.070	4	1	3	30
PL.1758	PL.1757	ABC	336 MCM AC	7.48Y	124.6	0.00	0.41	4.65	1	101	28	96	0.00	0.0	7.733	0.051	0	0	0	27
PL.1759	PL.1758	ABC	336 MCM AC	7.48Y	124.6	0.00	0.42	4.65	1	100	28	96	0.00	0.0	7.795	0.062	0	0	0	27
PL.2520	PL.1759	C	#4 ACSR	7.48Y	124.6	0.00	0.42	0.36	0	3	1	95	0.00	0.0	7.799	0.005	0	0	0	1
PD.330	PL.2520	C	25T	7.48Y	124.6	0.00	0.42	0.36	0	3	1	95	0.00	0.0	7.799	0.005	0	0	0	1
PL.2521	PD.330	C	#4 ACSR	7.48Y	124.6	0.00	0.42	0.36	0	3	1	95	0.00	0.0	7.845	0.045	3	1	1	1
PL.1761	PL.1759	ABC	336 MCM AC	7.47Y	124.6	0.00	0.42	4.53	1	98	27	96	0.00	0.0	7.870	0.075	0	0	0	26
PL.1762	PL.1761	ABC	336 MCM AC	7.47Y	124.6	0.00	0.42	4.53	1	98	27	96	0.00	0.0	7.967	0.097	0	0	0	26
PL.1764	PL.1762	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	4.53	1	98	27	96	0.00	0.0	8.072	0.105	0	0	1	26
PL.1768	PL.1764	ABC	336 MCM AC	7.47Y	124.6	0.01	0.43	4.53	1	98	27	96	0.00	0.0	8.244	0.172	0	0	0	25
PL.1769	PL.1768	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	4.29	1	93	26	96	0.00	0.0	8.293	0.049	0	0	0	23
PL.1770	PL.1769	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	2.16	0	47	13	96	0.00	0.0	8.367	0.074	0	0	0	13
PL.2064	PL.1770	ABC	336 MCM AC	7.47Y	124.6	0.00	0.43	1.59	0	34	9	97	0.00	0.0	8.420	0.053	0	0	0	10
PL.2065	PL.2064	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	8.529	0.110	0	0	0	6
PL.2016	PL.2065	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	8.628	0.099	0	0	0	6
PL.2017	PL.2016	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	8.725	0.097	0	0	0	6
PL.2018	PL.2017	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	8.827	0.102	0	0	0	6
PL.2019	PL.2018	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	8.909	0.082	0	0	0	6
PL.2020	PL.2019	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	9.022	0.112	0	0	0	6
PL.2249	PL.2020	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	1.08	0	23	6	97	0.00	0.0	9.147	0.126	5	1	1	6
PL.2250	PL.2249	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.84	0	18	5	96	0.00	0.0	9.218	0.071	0	0	0	5
PL.2058	PL.2250	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.35	0	8	2	97	0.00	0.0	9.274	0.057	0	0	0	4
PL.2251	PL.2058	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.27	0	6	2	95	0.00	0.0	9.338	0.063	0	0	0	2
PL.2252	PL.2251	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.27	0	6	2	95	0.00	0.0	9.520	0.182	2	1	1	2
PL.2253	PL.2252	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.18	0	4	1	97	0.00	0.0	9.626	0.106	0	0	0	1
PL.2264	PL.2253	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.18	0	4	1	97	0.00	0.0	9.740	0.114	4	1	1	1
PL.2265	PL.2264	ABC	336 MCM AC	7.47Y	124.6	0.00	0.44	0.00	0	0	0	100	0.00	0.0	9.800	0.061	0	0	0	0
PD.205-A	PL.2265	ABC	Open	7.47Y	124.6	0.00	0.44	0.00	0	0	0	100	0.00	0.0	9.800	0.061	0	0	0	0
PL.2452	PL.2058	C	#4 ACSR	7.47Y	124.6	0.00	0.44	0.26	0	2	1	89	0.00	0.0	9.279	0.005	0	0	0	2
PD.295	PL.2452	C	20T	7.47Y	124.6	0.00	0.44	0.26	0	2	1	89	0.00	0.0	9.279	0.005	0	0	0	2
PL.2453	PD.295	C	#4 ACSR	7.47Y	124.6	0.00	0.44	0.26	0	2	1	89	0.00	0.0	9.299	0.020	2	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2450	PL.2250	A	#2 ACSR	7.47Y	124.6	0.00	0.44	1.47	1	11	3	96	0.00	0.0	9.222	0.005	0	0	0	1
PD.294	PL.2450	A	20T	7.47Y	124.6	0.00	0.44	1.47	0	11	3	96	0.00	0.0	9.222	0.005	0	0	0	1
PL.2451	PD.294	A	#2 ACSR	7.47Y	124.6	0.00	0.44	1.47	1	11	3	96	0.00	0.0	9.242	0.020	11	3	1	1
PL.2448	PL.2064	C	#2 ACSR	7.47Y	124.6	0.00	0.43	1.54	1	11	3	96	0.00	0.0	8.425	0.005	0	0	0	4
PD.293	PL.2448	C	20T	7.47Y	124.6	0.00	0.43	1.54	0	11	3	96	0.00	0.0	8.425	0.005	0	0	0	4
PL.2449	PD.293	C	#2 ACSR	7.47Y	124.6	0.00	0.44	1.54	1	11	3	96	0.00	0.0	8.443	0.018	11	3	4	4
PL.2446	PL.1770	A	#2 ACSR	7.47Y	124.6	0.00	0.43	1.72	1	12	3	97	0.00	0.0	8.371	0.004	0	0	0	3
PD.292	PL.2446	A	20T	7.47Y	124.6	0.00	0.43	1.72	0	12	3	97	0.00	0.0	8.371	0.004	0	0	0	3
PL.2447	PD.292	A	#2 ACSR	7.47Y	124.6	0.00	0.43	1.72	1	12	3	97	0.00	0.0	8.384	0.013	2	1	1	3
PL.4519	PL.2447	A	#1/0 ACSR	7.47Y	124.6	0.00	0.44	1.41	1	10	3	96	0.00	0.0	8.408	0.024	10	3	2	2
PL.2444	PL.1769	A	#2 ACSR	7.47Y	124.6	0.00	0.43	6.38	4	46	13	96	0.00	0.0	8.298	0.005	0	0	0	10
PD.291	PL.2444	A	20T	7.47Y	124.6	0.00	0.43	6.38	0	46	13	96	0.00	0.0	8.298	0.005	0	0	0	10
PL.2445	PD.291	A	#2 ACSR	7.47Y	124.6	0.00	0.44	6.38	4	46	13	96	0.00	0.0	8.320	0.023	15	4	3	10
PL.2246	PL.2445	A	#2 ACSR	7.47Y	124.6	0.00	0.44	4.24	2	31	8	97	0.00	0.0	8.354	0.034	3	1	1	7
PL.2247	PL.2246	A	8 A (CWC)	7.47Y	124.6	0.00	0.45	3.86	4	28	8	96	0.00	0.0	8.373	0.018	2	0	1	6
PL.2248	PL.2247	A	8 A (CWC)	7.47Y	124.5	0.01	0.45	3.63	4	26	7	97	0.00	0.0	8.410	0.038	6	2	1	5
PL.1772	PL.2248	A	#4 ACSR	7.47Y	124.5	0.00	0.46	1.41	1	10	3	96	0.00	0.0	8.466	0.055	10	3	1	1
PL.1771	PL.2248	A	8 A (CWC)	7.47Y	124.5	0.01	0.46	1.43	1	10	3	96	0.00	0.0	8.516	0.106	0	0	0	3
PL.1774	PL.1771	A	8 A (CWC)	7.47Y	124.5	0.00	0.47	1.43	1	10	3	96	0.00	0.0	8.549	0.033	10	3	3	3
PL.2442	PL.1768	A	#2 ACSR	7.47Y	124.6	0.00	0.43	0.72	0	5	1	98	0.00	0.0	8.249	0.005	0	0	0	2
PD.290	PL.2442	A	25T	7.47Y	124.6	0.00	0.43	0.72	0	5	1	98	0.00	0.0	8.249	0.005	0	0	0	2
PL.2443	PD.290	A	#2 ACSR	7.47Y	124.6	0.00	0.43	0.72	0	5	1	98	0.00	0.0	8.275	0.026	5	1	2	2
PL.2438	PL.2069	A	#2 ACSR	7.48Y	124.6	0.00	0.41	2.07	1	15	4	97	0.00	0.0	7.527	0.005	0	0	0	5
PD.288	PL.2438	A	25T	7.48Y	124.6	0.00	0.41	2.07	0	15	4	97	0.00	0.0	7.527	0.005	0	0	0	5
PL.2439	PD.288	A	#2 ACSR	7.48Y	124.6	0.00	0.41	2.07	1	15	4	97	0.00	0.0	7.534	0.007	15	4	5	5
PL.2436	PL.2070	A	#4 ACSR	7.48Y	124.6	0.00	0.40	11.41	9	82	23	96	0.00	0.0	7.366	0.005	0	0	0	15
PD.287	PL.2436	A	25T	7.48Y	124.6	0.00	0.40	11.41	0	82	23	96	0.00	0.0	7.366	0.005	0	0	0	15
PL.2437	PD.287	A	#4 ACSR	7.47Y	124.6	0.02	0.42	11.41	9	82	23	96	0.01	0.0	7.412	0.046	25	7	5	15
PL.1741	PL.2437	A	#4 ACSR	7.47Y	124.6	0.02	0.44	7.88	6	57	16	96	0.01	0.0	7.476	0.064	13	3	2	10
PL.1742	PL.1741	A	#4 ACSR	7.47Y	124.5	0.02	0.46	6.14	5	44	12	96	0.01	0.0	7.567	0.091	4	1	1	8
PL.1743	PL.1742	A	#4 ACSR	7.47Y	124.5	0.02	0.48	5.53	4	40	11	96	0.01	0.0	7.661	0.094	5	1	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1744	PL.1743	A	#4 ACSR	7.47Y	124.5	0.01	0.50	4.80	4	35	10	96	0.00	0.0	7.726	0.065	8	2	1	5
PL.1746	PL.1744	A	#4 ACSR	7.47Y	124.5	0.01	0.50	3.66	3	26	7	97	0.00	0.0	7.758	0.033	2	1	1	4
PL.1747	PL.1746	A	#4 ACSR	7.47Y	124.5	0.01	0.51	2.92	2	21	6	96	0.00	0.0	7.833	0.075	0	0	0	2
PL.1751	PL.1747	A	#4 ACSR	7.47Y	124.5	0.01	0.52	1.33	1	10	3	96	0.00	0.0	7.930	0.097	0	0	0	1
PL.1752	PL.1751	A	#4 ACSR	7.47Y	124.5	0.00	0.52	1.33	1	10	3	96	0.00	0.0	7.989	0.059	10	3	1	1
PL.1750	PL.1747	A	#4 ACSR	7.47Y	124.5	0.00	0.51	1.60	1	11	3	96	0.00	0.0	7.873	0.039	11	3	1	1
PL.1748	PL.1746	A	#4 ACSR	7.47Y	124.5	0.00	0.50	0.40	0	3	1	95	0.00	0.0	7.819	0.061	3	1	1	1
PL.2432	PL.2435	C	#4 ACSR	7.48Y	124.6	0.00	0.38	1.04	1	7	2	96	0.00	0.0	7.155	0.005	0	0	0	3
PD.286	PL.2432	C	25T	7.48Y	124.6	0.00	0.38	1.04	0	7	2	96	0.00	0.0	7.155	0.005	0	0	0	3
PL.2433	PD.286	C	#4 ACSR	7.48Y	124.6	0.00	0.38	1.04	1	7	2	96	0.00	0.0	7.211	0.056	7	2	3	3
PL.2430	PL.2073	C	#4 ACSR	7.48Y	124.7	0.00	0.34	1.79	1	13	4	96	0.00	0.0	6.868	0.004	0	0	0	3
PD.285	PL.2430	C	25T	7.48Y	124.7	0.00	0.34	1.79	0	13	4	96	0.00	0.0	6.868	0.004	0	0	0	3
PL.2431	PD.285	C	#4 ACSR	7.48Y	124.7	0.00	0.35	1.79	1	13	4	96	0.00	0.0	6.899	0.031	4	1	2	3
PL.1711	PL.2431	C	#4 ACSR	7.48Y	124.7	0.00	0.35	1.30	1	9	3	95	0.00	0.0	6.947	0.048	9	3	1	1
PL.2510	PL.2241	C	#4 ACSR	7.48Y	124.7	0.00	0.32	2.91	2	21	6	96	0.00	0.0	6.711	0.005	0	0	0	3
PD.325	PL.2510	C	40QA	7.48Y	124.7	0.00	0.32	2.91	7	21	6	96	0.00	0.0	6.711	0.005	0	0	0	3
PL.2511	PD.325	C	#4 ACSR	7.48Y	124.7	0.00	0.33	2.91	2	21	6	96	0.00	0.0	6.732	0.021	0	0	0	3
PL.1708	PL.2511	C	#4 ACSR	7.48Y	124.7	0.00	0.33	2.91	2	21	6	96	0.00	0.0	6.773	0.040	21	6	3	3
PL.1709	PL.1708	C	#4 ACSR	7.48Y	124.7	0.00	0.33	0.00	0	0	0	100	0.00	0.0	6.811	0.038	0	0	0	0
PL.2428	PL.2236	C	#4 ACSR	7.48Y	124.7	0.00	0.29	0.53	0	4	1	97	0.00	0.0	6.508	0.005	0	0	0	2
PD.284	PL.2428	C	40QA	7.48Y	124.7	0.00	0.29	0.53	1	4	1	97	0.00	0.0	6.508	0.005	0	0	0	2
PL.2429	PD.284	C	#4 ACSR	7.48Y	124.7	0.00	0.29	0.53	0	4	1	97	0.00	0.0	6.529	0.021	4	1	2	2
PL.1707	PL.2086	C	#4 ACSR	7.49Y	124.8	0.00	0.25	2.89	2	21	6	96	0.00	0.0	6.231	0.024	0	0	0	4
PD.283	PL.1707	C	15T	7.49Y	124.8	0.00	0.25	2.89	0	21	6	96	0.00	0.0	6.231	0.024	0	0	0	4
PL.2426	PD.283	C	8 A (CWC)	7.49Y	124.8	0.00	0.25	2.89	3	21	6	96	0.00	0.0	6.233	0.003	9	3	2	4
PL.2427	PL.2426	C	8 A (CWC)	7.48Y	124.7	0.00	0.25	1.62	2	12	3	97	0.00	0.0	6.278	0.044	12	3	2	2
PL.2506	PL.2226	A	#4 ACSR	7.49Y	124.9	0.00	0.13	7.15	5	52	14	97	0.00	0.0	5.578	0.005	0	0	0	15
PD.324	PL.2506	A	40QA	7.49Y	124.9	0.00	0.13	7.15	18	52	14	97	0.00	0.0	5.578	0.005	0	0	0	15
PL.2507	PD.324	A	#4 ACSR	7.49Y	124.9	0.00	0.14	7.15	5	52	14	97	0.00	0.0	5.594	0.016	14	4	3	15
PL.2230	PL.2507	A	8 A (CWC)	7.49Y	124.8	0.01	0.15	5.25	5	38	10	97	0.00	0.0	5.638	0.044	15	4	5	12
PL.2231	PL.2230	A	8 A (CWC)	7.49Y	124.8	0.01	0.16	3.13	3	23	6	97	0.00	0.0	5.672	0.034	6	2	2	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.1695	PL.2231	A	8 A (CWC)	7.49Y	124.8	0.00	0.16	2.36	2	17	5	96	0.00	0.0	5.703	0.031	5	1	2	5
PL.1696	PL.1695	A	8 A (CWC)	7.49Y	124.8	0.00	0.16	1.70	2	12	3	97	0.00	0.0	5.731	0.028	8	2	1	3
PL.1697	PL.1696	A	8 A (CWC)	7.49Y	124.8	0.00	0.17	0.54	1	4	1	97	0.00	0.0	5.769	0.037	0	0	0	2
PL.1698	PL.1697	A	8 A (CWC)	7.49Y	124.8	0.00	0.17	0.54	1	4	1	97	0.00	0.0	5.810	0.042	4	1	2	2
PL.2416	PL.2103	A	#4 ACSR	7.50Y	124.9	0.00	0.07	1.35	1	10	3	96	0.00	0.0	5.318	0.005	0	0	0	2
PD.278	PL.2416	A	40QA	7.50Y	124.9	0.00	0.07	1.35	3	10	3	96	0.00	0.0	5.318	0.005	0	0	0	2
PL.2417	PD.278	A	#4 ACSR	7.50Y	124.9	0.00	0.07	1.35	1	10	3	96	0.00	0.0	5.339	0.021	10	3	2	2
PL.2500	PL.2104	C	#4 ACSR	7.50Y	124.9	0.00	0.05	3.46	3	25	7	96	0.00	0.0	5.255	0.005	0	0	0	3
PD.321	PL.2500	C	40QA	7.50Y	124.9	0.00	0.05	3.46	9	25	7	96	0.00	0.0	5.255	0.005	0	0	0	3
PL.2501	PD.321	C	#4 ACSR	7.50Y	124.9	0.00	0.05	3.46	3	25	7	96	0.00	0.0	5.274	0.020	25	7	3	3
PL.2464	PL.2107	A	#4 ACSR	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	5.193	0.005	0	0	0	0
PD.303	PL.2464	A	40QA	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	5.193	0.005	0	0	0	0
PL.2465	PD.303	A	#4 ACSR	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	5.204	0.011	0	0	0	0
PL.1655	PL.2107	B	8 A (CWC)	7.49Y	124.9	0.11	0.14	28.76	29	208	58	96	0.17	0.1	5.246	0.057	10	3	4	57
PL.2556	PL.1655	B	8 A (CWC)	7.49Y	124.9	0.00	0.15	27.33	27	197	55	96	0.01	0.0	5.249	0.003	0	0	0	53
PD.351	PL.2556	B	50L	7.49Y	124.9	0.00	0.15	27.33	55	197	55	96	0.00	0.0	5.249	0.003	0	0	0	53
PL.2557	PD.351	B	8 A (CWC)	7.48Y	124.7	0.13	0.28	27.33	27	197	55	96	0.20	0.1	5.323	0.075	11	3	3	53
PL.1657	PL.2557	B	#4 ACSR	7.48Y	124.7	0.00	0.28	1.82	1	13	4	96	0.00	0.0	5.343	0.020	13	4	2	2
PL.1656	PL.2557	B	8 A (CWC)	7.48Y	124.6	0.13	0.41	23.96	24	173	48	96	0.17	0.1	5.412	0.088	21	6	5	48
PL.1658	PL.1656	B	8 A (CWC)	7.46Y	124.4	0.22	0.63	21.04	21	152	42	96	0.26	0.2	5.569	0.158	5	1	1	43
PL.1660	PL.1658	B	8 A (CWC)	7.46Y	124.3	0.11	0.74	20.39	20	147	41	96	0.13	0.1	5.654	0.085	8	2	3	42
PL.2260	PL.1660	B	8 A (CWC)	7.45Y	124.2	0.08	0.83	19.24	19	138	38	96	0.09	0.1	5.720	0.066	0	0	1	39
PL.2261	PL.2260	B	8 A (CWC)	7.45Y	124.1	0.06	0.88	19.24	19	138	38	96	0.06	0.0	5.766	0.046	10	3	4	38
PL.1661	PL.2261	B	8 A (CWC)	7.44Y	124.1	0.05	0.94	17.81	18	128	35	96	0.05	0.0	5.811	0.045	4	1	2	34
PL.1663	PL.1661	B	8 A (CWC)	7.44Y	124.0	0.04	0.98	15.86	16	114	31	96	0.04	0.0	5.850	0.039	0	0	1	30
PL.1664	PL.1663	B	8 A (CWC)	7.44Y	124.0	0.02	0.99	15.86	16	114	31	96	0.01	0.0	5.867	0.017	13	3	3	29
PL.1665	PL.1664	B	#4 ACSR	7.44Y	124.0	0.04	1.04	14.11	11	101	28	96	0.03	0.0	5.942	0.075	13	4	3	26
PL.1667	PL.1665	B	#4 ACSR	7.44Y	123.9	0.02	1.06	12.11	9	87	24	96	0.01	0.0	5.976	0.035	0	0	1	21
PL.1669	PL.1667	B	#4 ACSR	7.44Y	123.9	0.02	1.08	12.10	9	87	24	96	0.01	0.0	6.010	0.034	1	0	1	20
PL.1670	PL.1669	B	#4 ACSR	7.43Y	123.9	0.02	1.09	11.96	9	86	24	96	0.01	0.0	6.040	0.030	7	2	2	19
PL.1671	PL.1670	B	8 A (CWC)	7.43Y	123.8	0.09	1.18	11.05	11	79	22	96	0.06	0.1	6.164	0.124	0	0	1	17

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1673	PL.1671	B	#4 ACSR	7.43Y	123.8	0.00	1.18	0.43	0	3	1	95	0.00	0.0	6.211	0.047	3	1	1	1
PL.1674	PL.1671	B	8 A (CWC)	7.43Y	123.8	0.05	1.23	10.62	11	76	21	96	0.03	0.0	6.233	0.069	0	0	0	15
PL.1675	PL.1674	B	8 A (CWC)	7.42Y	123.7	0.04	1.27	10.62	11	76	21	96	0.03	0.0	6.294	0.061	0	0	0	15
PL.1676	PL.1675	B	8 A (CWC)	7.42Y	123.7	0.06	1.34	10.62	11	76	21	96	0.03	0.0	6.391	0.097	15	4	3	15
PL.1677	PL.1676	B	8 A (CWC)	7.42Y	123.6	0.04	1.38	8.51	9	61	17	96	0.02	0.0	6.468	0.076	13	4	2	12
PL.1678	PL.1677	B	8 A (CWC)	7.42Y	123.6	0.03	1.40	6.67	7	48	13	97	0.01	0.0	6.528	0.060	5	1	1	10
PL.1679	PL.1678	B	8 A (CWC)	7.41Y	123.6	0.03	1.43	6.04	6	43	12	96	0.01	0.0	6.611	0.083	3	1	1	9
PL.1680	PL.1679	B	#4 ACSR	7.41Y	123.6	0.00	1.44	2.71	2	19	5	97	0.00	0.0	6.644	0.033	11	3	2	3
PL.1681	PL.1680	B	#2 ACSR	7.41Y	123.6	0.00	1.44	1.13	1	8	2	97	0.00	0.0	6.670	0.026	0	0	0	1
PL.1682	PL.1681	B	#2 ACSR	7.41Y	123.6	0.00	1.44	1.13	1	8	2	97	0.00	0.0	6.734	0.064	8	2	1	1
PL.1683	PL.1679	B	#2 ACSR	7.41Y	123.6	0.00	1.43	0.00	0	0	0	100	0.00	0.0	6.675	0.064	0	0	0	1
PL.1685	PL.1683	B	#2 ACSR	7.41Y	123.6	0.00	1.43	0.00	0	0	0	100	0.00	0.0	6.730	0.055	0	0	1	1
PL.1684	PL.1679	B	8 A (CWC)	7.41Y	123.5	0.02	1.45	2.96	3	21	6	96	0.00	0.0	6.705	0.095	0	0	0	4
PL.2133	PL.1684	B	8 A (CWC)	7.41Y	123.5	0.01	1.46	2.96	3	21	6	96	0.00	0.0	6.731	0.026	0	0	0	4
PL.1687	PL.2133	B	#4 ACSR	7.41Y	123.5	0.00	1.46	0.71	1	5	1	98	0.00	0.0	6.759	0.028	0	0	0	1
PL.1686	PL.1687	B	#4 ACSR	7.41Y	123.5	0.00	1.46	0.71	1	5	1	98	0.00	0.0	6.801	0.042	5	1	1	1
PL.2227	PL.2133	B	8 A (CWC)	7.41Y	123.5	0.01	1.46	2.24	2	16	4	97	0.00	0.0	6.819	0.088	16	4	3	3
PL.2228	PL.2227	B	#2 ACSR	7.41Y	123.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	6.869	0.050	0	0	0	0
PL.1668	PL.1665	B	#4 ACSR	7.44Y	124.0	0.00	1.04	0.19	0	1	0	100	0.00	0.0	5.974	0.032	1	0	2	2
PL.1662	PL.1661	B	#4 ACSR	7.44Y	124.1	0.00	0.94	1.46	1	10	3	96	0.00	0.0	5.825	0.014	10	3	2	2
PL.2454	PL.2255	C	#2 ACSR	7.50Y	125.0	0.00	-0.03	1.48	1	11	3	96	0.00	0.0	5.009	0.005	0	0	0	3
PD.296	PL.2454	C	40QA	7.50Y	125.0	0.00	-0.03	1.48	4	11	3	96	0.00	0.0	5.009	0.005	0	0	0	3
PL.2455	PD.296	C	#2 ACSR	7.50Y	125.0	0.00	-0.03	1.48	1	11	3	96	0.00	0.0	5.045	0.036	11	3	3	3
PL.65771	PL.2254	C	#1/0 ACSR	7.50Y	125.1	0.00	-0.05	0.00	0	0	0	100	0.00	0.0	4.978	0.030	0	0	0	0
PL.1646	PL.2105	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	1.07	1	8	2	97	0.00	0.0	4.839	0.005	0	0	0	7
PD.297	PL.1646	C	20T	7.51Y	125.1	0.00	-0.09	1.07	0	8	2	97	0.00	0.0	4.839	0.005	0	0	0	7
PL.10178	PD.297	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	0.07	0	1	0	100	0.00	0.0	4.850	0.010	0	0	0	3
PL.21698	PL.10178	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	0.07	0	1	0	100	0.00	0.0	4.862	0.013	0	0	0	3
PL.21699	PL.21698	C	#4 ACSR	7.51Y	125.1	0.00	-0.09	0.07	0	1	0	100	0.00	0.0	4.952	0.089	0	0	1	3
PL.1650	PL.21699	C	#2 ACSR	7.51Y	125.1	0.00	-0.09	0.03	0	0	0	100	0.00	0.0	4.989	0.038	0	0	1	2
PL.1654	PL.1650	C	#2 ACSR	7.51Y	125.1	0.00	-0.09	0.03	0	0	0	100	0.00	0.0	5.089	0.100	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2100	PD.297	C	#2 ACSR	7.51Y	125.1	0.00	-0.09	1.00	1	7	2	96	0.00	0.0	4.853	0.013	0	0	0	4
PL.1653	PL.2100	C	#2 ACSR	7.51Y	125.1	0.00	-0.09	1.00	1	7	2	96	0.00	0.0	4.862	0.009	1	0	1	4
PL.1652	PL.1653	C	#2 ACSR	7.51Y	125.1	0.00	-0.09	0.83	0	6	2	95	0.00	0.0	4.908	0.046	6	2	3	3
PL.2458	PL.2114	C	#4 ACSR	7.51Y	125.2	0.00	-0.20	0.92	1	7	2	96	0.00	0.0	4.548	0.005	0	0	0	3
PD.299	PL.2458	C	40QA	7.51Y	125.2	0.00	-0.20	0.92	2	7	2	96	0.00	0.0	4.548	0.005	0	0	0	3
PL.2459	PD.299	C	#4 ACSR	7.51Y	125.2	0.00	-0.20	0.92	1	7	2	96	0.00	0.0	4.588	0.039	7	2	3	3
PL.2460	PL.2117	C	#4 ACSR	7.51Y	125.2	0.00	-0.22	1.03	1	7	2	96	0.00	0.0	4.496	0.004	0	0	0	3
PD.300	PL.2460	C	15T	7.51Y	125.2	0.00	-0.22	1.03	0	7	2	96	0.00	0.0	4.496	0.004	0	0	0	3
PL.2461	PD.300	C	#4 ACSR	7.51Y	125.2	0.00	-0.22	1.03	1	7	2	96	0.00	0.0	4.519	0.023	7	2	3	3
PL.2462	PL.2257	C	#4 ACSR	7.52Y	125.3	0.00	-0.29	0.24	0	2	0	100	0.00	0.0	4.316	0.004	0	0	0	1
PD.301	PL.2462	C	40QA	7.52Y	125.3	0.00	-0.29	0.24	1	2	0	100	0.00	0.0	4.316	0.004	0	0	0	1
PL.2463	PD.301	C	#4 ACSR	7.52Y	125.3	0.00	-0.29	0.24	0	2	0	100	0.00	0.0	4.324	0.008	2	0	1	1
PL.1611	PL.2259	A	#4 ACSR	7.52Y	125.3	0.03	-0.30	42.16	32	306	85	96	0.06	0.0	4.222	0.014	7	2	1	63
PL.1613	PL.1611	A	#4 ACSR	7.52Y	125.3	0.01	-0.29	41.21	32	299	83	96	0.02	0.0	4.226	0.005	0	0	0	62
PD.302	PL.1613	A	30T	7.52Y	125.3	0.00	-0.29	41.21	0	299	83	96	0.00	0.0	4.226	0.005	0	0	0	62
PL.2005	PD.302	A	#4 ACSR	7.51Y	125.2	0.12	-0.17	39.80	31	288	80	96	0.25	0.1	4.295	0.069	20	6	3	58
PL.1616	PL.2005	A	#4 ACSR	7.51Y	125.1	0.09	-0.09	32.21	25	233	65	96	0.15	0.1	4.357	0.062	1	0	1	51
PL.1620	PL.1616	A	#2 ACSR	7.51Y	125.1	0.00	-0.09	2.59	1	19	5	97	0.00	0.0	4.370	0.013	19	5	2	2
PL.1612	PL.1616	A	#4 ACSR	7.51Y	125.1	0.00	-0.08	1.10	1	8	2	97	0.00	0.0	4.406	0.049	8	2	3	3
PL.1621	PL.1616	A	#4 ACSR	7.50Y	125.1	0.03	-0.06	28.31	22	205	57	96	0.05	0.0	4.382	0.025	5	1	1	45
PL.1622	PL.1621	A	#4 ACSR	7.50Y	125.0	0.04	-0.02	27.67	21	200	55	96	0.06	0.0	4.414	0.033	4	1	1	44
PL.1623	PL.1622	A	#4 ACSR	7.50Y	125.0	0.05	0.04	27.18	21	197	54	96	0.08	0.0	4.460	0.046	10	3	3	43
PL.1624	PL.1623	A	#4 ACSR	7.50Y	125.0	0.01	0.05	5.67	4	41	11	97	0.00	0.0	4.504	0.043	12	3	4	12
PL.1644	PL.1624	A	#4 ACSR	7.50Y	124.9	0.01	0.05	3.97	3	29	8	96	0.00	0.0	4.547	0.044	11	3	4	8
PL.1645	PL.1644	A	#4 ACSR	7.50Y	124.9	0.00	0.06	2.46	2	18	5	96	0.00	0.0	4.568	0.021	18	5	4	4
PL.1625	PL.1623	A	#4 ACSR	7.50Y	125.0	0.00	0.04	2.59	2	19	5	97	0.00	0.0	4.518	0.058	19	5	3	3
PL.1626	PL.1623	A	#4 ACSR	7.49Y	124.9	0.06	0.10	17.59	14	127	35	96	0.06	0.0	4.535	0.075	0	0	0	25
PL.1628	PL.1626	A	#4 ACSR	7.49Y	124.9	0.00	0.10	0.59	0	4	1	97	0.00	0.0	4.570	0.034	4	1	2	2
PL.1627	PL.1626	A	#4 ACSR	7.49Y	124.9	0.01	0.11	17.01	13	123	34	96	0.01	0.0	4.552	0.017	0	0	0	23
PL.1629	PL.1627	A	#4 ACSR	7.49Y	124.9	0.03	0.14	17.01	13	123	34	96	0.02	0.0	4.589	0.037	11	3	3	23
PL.1630	PL.1629	A	#4 ACSR	7.49Y	124.8	0.03	0.17	14.92	11	108	30	96	0.02	0.0	4.635	0.046	0	0	0	19

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.1632	PL.1630	A	#4 ACSR	7.49Y	124.8	0.02	0.19	14.92	11	108	30	96	0.02	0.0	4.670	0.036	8	2	2	19
PL.1633	PL.1632	A	#4 ACSR	7.49Y	124.8	0.03	0.22	13.86	11	100	28	96	0.02	0.0	4.720	0.050	3	1	1	17
PL.1634	PL.1633	A	#4 ACSR	7.49Y	124.8	0.02	0.24	13.39	10	97	27	96	0.01	0.0	4.757	0.037	5	1	4	16
PL.1635	PL.1634	A	#4 ACSR	7.48Y	124.7	0.03	0.27	12.66	10	91	25	96	0.02	0.0	4.808	0.051	11	3	1	12
PL.1636	PL.1635	A	#4 ACSR	7.48Y	124.7	0.01	0.28	11.14	9	80	22	96	0.01	0.0	4.836	0.028	26	7	3	11
PL.1637	PL.1636	A	#4 ACSR	7.48Y	124.7	0.02	0.30	7.52	6	54	15	96	0.01	0.0	4.887	0.051	9	2	2	8
PL.1638	PL.1637	A	#4 ACSR	7.48Y	124.7	0.02	0.31	6.31	5	45	13	96	0.01	0.0	4.944	0.057	0	0	0	6
PL.1639	PL.1638	A	#4 ACSR	7.48Y	124.7	0.00	0.32	4.31	3	31	9	96	0.00	0.0	4.978	0.034	20	5	2	4
PL.1641	PL.1639	A	#4 ACSR	7.48Y	124.7	0.00	0.32	1.59	1	12	3	97	0.00	0.0	5.029	0.052	9	3	1	2
PL.1642	PL.1641	A	#4 ACSR	7.48Y	124.7	0.00	0.32	0.28	0	2	1	89	0.00	0.0	5.064	0.034	2	1	1	1
PL.1643	PL.1642	A	#4 ACSR	7.48Y	124.7	0.00	0.32	0.00	0	0	0	100	0.00	0.0	5.121	0.057	0	0	0	0
PL.1640	PL.1638	A	#4 ACSR	7.48Y	124.7	0.00	0.31	2.00	2	14	4	96	0.00	0.0	4.989	0.046	14	4	2	2
PL.1631	PL.1629	A	#4 ACSR	7.49Y	124.9	0.00	0.14	0.55	0	4	1	97	0.00	0.0	4.667	0.078	4	1	1	1
PL.1617	PL.2005	A	#4 ACSR	7.51Y	125.2	0.01	-0.16	4.79	4	35	10	96	0.00	0.0	4.375	0.080	16	4	2	4
PL.1619	PL.1617	A	#4 ACSR	7.51Y	125.2	0.00	-0.16	1.39	1	10	3	96	0.00	0.0	4.416	0.041	10	3	1	1
PL.1618	PL.1617	A	#4 ACSR	7.51Y	125.2	0.00	-0.16	1.19	1	9	2	98	0.00	0.0	4.394	0.019	9	2	1	1
PL.2118	PD.302	A	#4 ACSR	7.52Y	125.3	0.00	-0.29	1.42	1	10	3	96	0.00	0.0	4.232	0.006	0	0	0	4
PL.1614	PL.2118	A	#4 ACSR	7.52Y	125.3	0.00	-0.29	1.42	1	10	3	96	0.00	0.0	4.260	0.028	7	2	3	4
PL.1615	PL.1614	A	#4 ACSR	7.52Y	125.3	0.00	-0.29	0.38	0	3	1	95	0.00	0.0	4.287	0.027	3	1	1	1
PL.2350	PL.2123	C	#4 ACSR	7.11Y	118.5	0.00	6.49	1.92	1	13	4	96	0.00	0.0	3.766	0.005	0	0	0	3
PD.248	PL.2350	C	40QA	7.11Y	118.5	0.00	6.49	1.92	5	13	4	96	0.00	0.0	3.766	0.005	0	0	0	3
PL.2351	PD.248	C	#4 ACSR	7.11Y	118.5	0.00	6.49	1.92	1	13	4	96	0.00	0.0	3.807	0.041	13	4	3	3
PL.2348	PL.2124	A	#2 ACSR	7.11Y	118.5	0.00	6.48	0.30	0	2	1	89	0.00	0.0	3.739	0.005	0	0	0	1
PD.247	PL.2348	A	40QA	7.11Y	118.5	0.00	6.48	0.30	1	2	1	89	0.00	0.0	3.739	0.005	0	0	0	1
PL.2349	PD.247	A	#2 ACSR	7.11Y	118.5	0.00	6.48	0.30	0	2	1	89	0.00	0.0	3.752	0.013	2	1	1	1
PL.2496	PL.2126	C	#2 ACSR	7.12Y	118.6	0.00	6.39	1.81	1	12	3	97	0.00	0.0	3.587	0.005	0	0	0	1
PD.319	PL.2496	C	40QA	7.12Y	118.6	0.00	6.39	1.81	5	12	3	97	0.00	0.0	3.587	0.005	0	0	0	1
PL.2497	PD.319	C	#2 ACSR	7.12Y	118.6	0.01	6.40	1.81	1	12	3	97	0.00	0.0	3.683	0.096	0	0	0	1
PL.1608	PL.2497	C	#2 ACSR	7.12Y	118.6	0.00	6.40	1.81	1	12	3	97	0.00	0.0	3.740	0.057	12	3	1	1
PL.2346	PL.2126	A	#2 ACSR	7.12Y	118.6	0.00	6.39	0.86	0	6	2	95	0.00	0.0	3.587	0.005	0	0	0	2
PD.246	PL.2346	A	40QA	7.12Y	118.6	0.00	6.39	0.86	2	6	2	95	0.00	0.0	3.587	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2347	PD.246	A	#2 ACSR	7.12Y	118.6	0.00	6.39	0.86	0	6	2	95	0.00	0.0	3.598	0.011	6	2	2	2
PL.1606	PL.2127	A	#4 ACSR	7.12Y	118.7	0.00	6.31	1.87	1	13	4	96	0.00	0.0	3.433	0.005	0	0	0	2
PD.245	PL.1606	A	40QA	7.12Y	118.7	0.00	6.31	1.87	5	13	4	96	0.00	0.0	3.433	0.005	0	0	0	2
PL.2010	PD.245	A	#4 ACSR	7.12Y	118.7	0.00	6.31	1.87	1	13	4	96	0.00	0.0	3.442	0.008	13	4	2	2
PL.2344	PL.4469	C	#4 ACSR	7.12Y	118.7	0.00	6.28	0.53	0	4	1	97	0.00	0.0	3.380	0.005	0	0	0	1
PD.244	PL.2344	C	40QA	7.12Y	118.7	0.00	6.28	0.53	1	4	1	97	0.00	0.0	3.380	0.005	0	0	0	1
PL.2345	PD.244	C	#4 ACSR	7.12Y	118.7	0.00	6.28	0.53	0	4	1	97	0.00	0.0	3.404	0.024	4	1	1	1
PL.2342	PL.2131	C	#2 ACSR	7.14Y	118.9	0.00	6.08	1.66	1	11	3	96	0.00	0.0	3.177	0.005	0	0	0	2
PD.243	PL.2342	C	40QA	7.14Y	118.9	0.00	6.08	1.66	4	11	3	96	0.00	0.0	3.177	0.005	0	0	0	2
PL.2343	PD.243	C	#2 ACSR	7.14Y	118.9	0.00	6.08	1.66	1	11	3	96	0.00	0.0	3.213	0.035	6	2	1	2
PL.1605	PL.2343	C	#2 ACSR	7.14Y	118.9	0.00	6.08	0.72	0	5	1	98	0.00	0.0	3.258	0.045	5	1	1	1
PL.2494	PL.2131	A	#4 ACSR	7.14Y	118.9	0.00	6.08	2.89	2	20	5	97	0.00	0.0	3.177	0.004	0	0	0	5
PD.318	PL.2494	A	15T	7.14Y	118.9	0.00	6.08	2.89	0	20	5	97	0.00	0.0	3.177	0.004	0	0	0	5
PL.2495	PD.318	A	#4 ACSR	7.14Y	118.9	0.00	6.08	2.89	2	20	5	97	0.00	0.0	3.196	0.019	20	5	5	5
PL.2340	PL.1579	B	#1/0 ACSR	7.16Y	119.3	0.00	5.70	1.61	1	11	3	96	0.00	0.0	2.956	0.004	0	0	0	1
PD.242	PL.2340	B	40QA	7.16Y	119.3	0.00	5.70	1.61	4	11	3	96	0.00	0.0	2.956	0.004	0	0	0	1
PL.2341	PD.242	B	#1/0 ACSR	7.16Y	119.3	0.00	5.70	1.61	1	11	3	96	0.00	0.0	2.968	0.012	0	0	0	1
PL.2185	PL.2341	B	#1/0 ACSR	7.16Y	119.3	0.00	5.70	1.61	1	11	3	96	0.00	0.0	2.993	0.025	11	3	1	1
PL.2324	PL.1564	C	#1/0 ACSR	7.20Y	120.0	0.00	4.98	1.61	1	11	3	96	0.00	0.0	2.551	0.005	0	0	0	3
PD.234	PL.2324	C	40QA	7.20Y	120.0	0.00	4.98	1.61	4	11	3	96	0.00	0.0	2.551	0.005	0	0	0	3
PL.2325	PD.234	C	#1/0 ACSR	7.20Y	120.0	0.00	4.98	1.61	1	11	3	96	0.00	0.0	2.592	0.041	2	1	1	3
PL.1569	PL.2325	C	#1/0 ACSR	7.20Y	120.0	0.00	4.99	1.33	1	9	3	95	0.00	0.0	2.615	0.024	9	3	2	2
PL.2336	PL.1550	C	#1/0 ACSR	7.23Y	120.5	0.00	4.51	11.77	5	82	23	96	0.00	0.0	2.284	0.005	0	0	0	11
PD.240	PL.2336	C	40QA	7.23Y	120.5	0.00	4.51	11.77	29	82	23	96	0.00	0.0	2.284	0.005	0	0	0	11
PL.2337	PD.240	C	#1/0 ACSR	7.23Y	120.5	0.01	4.52	11.77	5	82	23	96	0.01	0.0	2.330	0.047	12	3	1	11
PL.1553	PL.2337	C	#1/0 ACSR	7.23Y	120.5	0.01	4.53	10.09	4	70	19	97	0.00	0.0	2.358	0.028	2	1	1	10
PL.1554	PL.1553	C	#1/0 ACSR	7.23Y	120.5	0.01	4.54	5.68	2	40	11	96	0.00	0.0	2.465	0.107	30	8	2	3
PL.1558	PL.1554	C	6 A (CWC)	7.23Y	120.5	0.00	4.54	1.35	1	9	3	95	0.00	0.0	2.548	0.083	9	3	1	1
PL.1555	PL.1553	C	#4 ACSR	7.23Y	120.5	0.00	4.53	4.09	3	28	8	96	0.00	0.0	2.385	0.027	5	1	3	6
PL.1559	PL.1555	C	#1/0 ACSR	7.23Y	120.5	0.00	4.54	3.43	1	24	7	96	0.00	0.0	2.443	0.058	0	0	0	3
PL.1560	PL.1559	C	#1/0 ACSR	7.23Y	120.5	0.00	4.54	3.43	1	24	7	96	0.00	0.0	2.527	0.084	18	5	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1561	PL.1560	C	#1/0 ACSR	7.23Y	120.5	0.00	4.54	0.87	0	6	2	95	0.00	0.0	2.570	0.043	6	2	1	1
PL.2332	PL.1547	A	#1/0 ACSR	7.24Y	120.7	0.00	4.25	1.78	1	12	3	97	0.00	0.0	2.140	0.005	0	0	0	2
PD.238	PL.2332	A	40QA	7.24Y	120.7	0.00	4.25	1.78	4	12	3	97	0.00	0.0	2.140	0.005	0	0	0	2
PL.2333	PD.238	A	#1/0 ACSR	7.24Y	120.7	0.00	4.25	1.78	1	12	3	97	0.00	0.0	2.149	0.008	12	3	2	2
PL.2330	PL.1541	A	#1/0 ACSR	7.27Y	121.1	0.00	3.85	1.39	1	10	3	96	0.00	0.0	1.922	0.004	0	0	0	1
PD.237	PL.2330	A	40QA	7.27Y	121.1	0.00	3.85	1.39	3	10	3	96	0.00	0.0	1.922	0.004	0	0	0	1
PL.2331	PD.237	A	#1/0 ACSR	7.27Y	121.1	0.00	3.85	1.39	1	10	3	96	0.00	0.0	1.956	0.034	10	3	1	1
PL.4466	PL.1529	A	#1/0 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	1.786	0.004	0	0	0	0
PD.1295	PL.4466	A	40QA	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	1.786	0.004	0	0	0	0
PL.4467	PD.1295	A	#1/0 ACSR	7.28Y	121.4	0.00	3.60	0.00	0	0	0	100	0.00	0.0	1.809	0.023	0	0	0	0
PL.4464	PL.1529	C	#1/0 ACSR	7.28Y	121.4	0.00	3.60	1.47	1	10	3	96	0.00	0.0	1.786	0.003	0	0	0	2
PD.1294	PL.4464	C	40QA	7.28Y	121.4	0.00	3.60	1.47	4	10	3	96	0.00	0.0	1.786	0.003	0	0	0	2
PL.4465	PD.1294	C	#1/0 ACSR	7.28Y	121.4	0.00	3.60	1.47	1	10	3	96	0.00	0.0	1.820	0.034	10	3	2	2
PL.2484	PL.1522	C	6 A (CWC)	7.29Y	121.5	0.00	3.45	2.95	2	21	6	96	0.00	0.0	1.706	0.005	0	0	0	5
PD.313	PL.2484	C	40QA	7.29Y	121.5	0.00	3.45	2.95	7	21	6	96	0.00	0.0	1.706	0.005	0	0	0	5
PL.2485	PD.313	C	6 A (CWC)	7.29Y	121.5	0.02	3.47	2.95	2	21	6	96	0.00	0.0	1.819	0.113	0	0	0	5
PL.2011	PL.2485	C	6 A (CWC)	7.29Y	121.5	0.01	3.48	2.95	2	21	6	96	0.00	0.0	1.935	0.115	2	1	1	5
PL.1537	PL.2011	C	6 A (CWC)	7.29Y	121.5	0.01	3.49	2.68	2	19	5	97	0.00	0.0	2.030	0.095	6	2	1	4
PL.1538	PL.1537	C	6 A (CWC)	7.29Y	121.5	0.00	3.50	1.77	1	12	3	97	0.00	0.0	2.118	0.088	12	3	3	3
PL.2290	PL.1511	A	#1/0 ACSR	7.30Y	121.7	0.00	3.26	2.56	1	18	5	96	0.00	0.0	1.604	0.005	0	0	0	2
PD.218	PL.2290	A	40QA	7.30Y	121.7	0.00	3.26	2.56	6	18	5	96	0.00	0.0	1.604	0.005	0	0	0	2
PL.2291	PD.218	A	#1/0 ACSR	7.30Y	121.7	0.00	3.26	2.56	1	18	5	96	0.00	0.0	1.626	0.022	10	3	1	2
PL.1521	PL.2291	A	#4 ACSR	7.30Y	121.7	0.00	3.26	1.21	1	8	2	97	0.00	0.0	1.676	0.050	8	2	1	1
PL.2544	PL.1510	ABC	#1/0 ACSR	7.31Y	121.8	0.00	3.19	5.78	3	118	46	93	0.00	0.0	1.567	0.005	0	0	0	9
PD.343	PL.2544	ABC	25T	7.31Y	121.8	0.00	3.19	5.78	0	118	46	93	0.00	0.0	1.567	0.005	0	0	0	9
PL.2545	PD.343	ABC	#1/0 ACSR	7.31Y	121.8	0.00	3.20	5.78	3	118	46	93	0.00	0.0	1.596	0.028	0	0	0	9
PL.1523	PL.2545	C	#4 ACSR	7.31Y	121.8	0.00	3.20	3.22	2	23	6	97	0.00	0.0	1.629	0.034	23	6	3	3
PL.1525	PL.1525	ABC	8 A (CWC)	7.31Y	121.8	0.01	3.20	4.71	5	95	40	92	0.01	0.0	1.624	0.029	18	5	2	6
PL.1524	PL.1525	ABC	8 A (CWC)	7.31Y	121.8	0.02	3.22	3.85	4	77	35	91	0.01	0.0	1.702	0.078	8	2	1	4
PL.1530	PL.1524	ABC	8 A (CWC)	7.31Y	121.8	0.00	3.22	3.49	3	69	33	90	0.00	0.0	1.721	0.019	0	0	0	3
PL.1531	PL.1530	ABC	8 A (CWC)	7.31Y	121.8	0.00	3.23	3.35	3	66	32	90	0.00	0.0	1.741	0.020	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1533	PL.1531	ABC	8 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	1.765	0.023	0	0	0	0
PL.1534	PL.1531	ABC	#1/0 ACSR	7.31Y	121.8	0.00	3.23	3.35	1	66	32	90	0.00	0.0	1.788	0.047	2	0	1	2
PL.1535	PL.1534	ABC	#1/0 ACSR	7.31Y	121.8	0.00	3.23	3.27	1	65	31	90	0.00	0.0	1.817	0.029	0	0	0	1
PL.1536	PL.1535	ABC	#1/0 ACSR	7.31Y	121.8	0.00	3.23	3.27	1	65	31	90	0.00	0.0	1.841	0.024	65	31	1	1
PL.2294	PL.1530	C	#1/0 ACSR	7.31Y	121.8	0.00	3.22	0.43	0	3	1	95	0.00	0.0	1.726	0.005	0	0	0	1
PD.220	PL.2294	C	40QA	7.31Y	121.8	0.00	3.22	0.43	1	3	1	95	0.00	0.0	1.726	0.005	0	0	0	1
PL.2295	PD.220	C	#1/0 ACSR	7.31Y	121.8	0.00	3.22	0.43	0	3	1	95	0.00	0.0	1.752	0.027	0	0	0	1
PL.1532	PL.2295	C	#1/0 ACSR	7.31Y	121.8	0.00	3.23	0.43	0	3	1	95	0.00	0.0	1.782	0.029	3	1	1	1
PL.2482	PL.1510	A	#1/0 ACSR	7.31Y	121.8	0.00	3.19	4.29	2	30	8	97	0.00	0.0	1.567	0.005	0	0	0	7
PD.312	PL.2482	A	25T	7.31Y	121.8	0.00	3.19	4.29	0	30	8	97	0.00	0.0	1.567	0.005	0	0	0	7
PL.2483	PD.312	A	#1/0 ACSR	7.31Y	121.8	0.00	3.20	4.29	2	30	8	97	0.00	0.0	1.606	0.039	0	0	0	7
PL.1512	PL.2483	A	8 A (CWC)	7.31Y	121.8	0.03	3.23	4.29	4	30	8	97	0.01	0.0	1.704	0.098	0	0	0	7
PL.1513	PL.1512	A	8 A (CWC)	7.30Y	121.7	0.03	3.25	4.29	4	30	8	97	0.01	0.0	1.797	0.092	0	0	1	7
PL.1514	PL.1513	A	#4 ACSR	7.30Y	121.7	0.01	3.26	4.25	3	30	8	97	0.00	0.0	1.838	0.042	15	4	1	6
PL.1515	PL.1514	A	#4 ACSR	7.30Y	121.7	0.00	3.26	2.16	2	15	4	97	0.00	0.0	1.874	0.036	0	0	0	5
PL.1516	PL.1515	A	#2 ACSR	7.30Y	121.7	0.00	3.26	0.82	0	6	2	95	0.00	0.0	1.911	0.036	0	0	0	1
PL.1517	PL.1516	A	#2 ACSR	7.30Y	121.7	0.00	3.26	0.82	0	6	2	95	0.00	0.0	1.978	0.068	6	2	1	1
PL.1518	PL.1517	A	#4 ACSR	7.30Y	121.7	0.00	3.26	1.34	1	9	3	95	0.00	0.0	1.911	0.036	3	1	2	4
PL.1519	PL.1518	A	#2 ACSR	7.30Y	121.7	0.00	3.27	0.95	1	7	2	96	0.00	0.0	1.981	0.071	0	0	0	2
PL.1520	PL.1519	A	#2 ACSR	7.30Y	121.7	0.00	3.27	0.95	1	7	2	96	0.00	0.0	2.011	0.030	7	2	2	2
PL.2288	PL.2141	C	#1/0 ACSR	7.32Y	122.0	0.00	2.95	3.12	1	22	6	96	0.00	0.0	1.444	0.005	0	0	0	7
PD.217	PL.2288	C	40QA	7.32Y	122.0	0.00	2.95	3.12	8	22	6	96	0.00	0.0	1.444	0.005	0	0	0	7
PL.2289	PD.217	C	#1/0 ACSR	7.32Y	122.0	0.00	2.95	3.12	1	22	6	96	0.00	0.0	1.458	0.014	6	2	3	7
PL.2142	PL.2289	C	#1/0 ACSR	7.32Y	122.0	0.00	2.95	2.33	1	16	5	95	0.00	0.0	1.464	0.006	0	0	0	4
PL.1508	PL.2142	C	8 A (CWC)	7.32Y	122.0	0.00	2.96	2.33	2	16	5	95	0.00	0.0	1.509	0.045	16	5	4	4
PL.2286	PL.1581	A	#4 ACSR	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.131	0.005	0	0	0	0
PD.216	PL.2286	A	50QA	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.131	0.005	0	0	0	0
PL.2287	PD.216	A	#4 ACSR	7.36Y	122.7	0.00	2.34	0.00	0	0	0	100	0.00	0.0	1.163	0.032	0	0	0	0
PL.2488	PL.1580	C	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.94	1	14	4	96	0.00	0.0	1.036	0.005	0	0	0	2
PD.315	PL.2488	C	40QA	7.37Y	122.8	0.00	2.15	1.94	5	14	4	96	0.00	0.0	1.036	0.005	0	0	0	2
PL.2489	PD.315	C	#1/0 ACSR	7.37Y	122.8	0.00	2.15	1.94	1	14	4	96	0.00	0.0	1.068	0.031	14	4	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1467	PL.1466	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.47	4.77	2	102	28	96	0.00	0.0	0.693	0.005	0	0	0	28
PD.341	PL.1467	ABC	50QA	7.41Y	123.5	0.00	1.47	4.77	10	102	28	96	0.00	0.0	0.693	0.005	0	0	0	28
PL.2003	PD.341	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.47	4.77	2	102	28	96	0.00	0.0	0.703	0.010	1	0	1	28
PL.1469	PL.2003	A	#1/0 ACSR	7.41Y	123.5	0.02	1.49	14.16	6	101	28	96	0.01	0.0	0.757	0.053	0	0	0	27
PL.1471	PL.1469	A	#4 ACSR	7.41Y	123.5	0.00	1.49	1.69	1	12	3	97	0.00	0.0	0.777	0.021	12	3	2	2
PL.1474	PL.1469	A	#1/0 ACSR	7.41Y	123.5	0.04	1.53	12.47	5	89	25	96	0.02	0.0	0.895	0.138	12	3	5	25
PL.1475	PL.1474	A	#1/0 ACSR	7.41Y	123.5	0.01	1.54	10.80	5	77	21	96	0.00	0.0	0.933	0.038	0	0	0	20
PL.1476	PL.1475	A	#1/0 ACSR	7.41Y	123.4	0.01	1.55	10.80	5	77	21	96	0.01	0.0	0.983	0.050	4	1	1	20
PL.1477	PL.1476	A	#1/0 ACSR	7.40Y	123.4	0.04	1.59	10.19	4	73	20	96	0.02	0.0	1.138	0.154	1	0	1	19
PL.1479	PL.1477	A	#1/0 ACSR	7.40Y	123.4	0.01	1.60	10.01	4	71	20	96	0.01	0.0	1.184	0.046	0	0	0	18
PL.1480	PL.1479	A	#1/0 ACSR	7.40Y	123.4	0.01	1.62	10.01	4	71	20	96	0.01	0.0	1.239	0.055	0	0	0	18
PL.1482	PL.1480	A	8 A (CWC)	7.40Y	123.4	0.00	1.62	10.01	10	71	20	96	0.00	0.0	1.241	0.002	0	0	0	18
PL.1483	PL.1482	A	6 A (CWC)	7.40Y	123.3	0.05	1.66	10.01	7	71	20	96	0.02	0.0	1.345	0.103	4	1	2	18
PL.1484	PL.1483	A	6 A (CWC)	7.40Y	123.3	0.03	1.69	9.42	7	67	19	96	0.01	0.0	1.422	0.077	13	4	3	16
PL.1485	PL.1484	A	6 A (CWC)	7.40Y	123.3	0.03	1.73	7.56	5	54	15	96	0.01	0.0	1.525	0.104	3	1	1	13
PL.1486	PL.1485	A	6 A (CWC)	7.39Y	123.2	0.03	1.76	7.16	5	51	14	96	0.01	0.0	1.628	0.103	0	0	0	12
PL.1487	PL.1486	A	6 A (CWC)	7.39Y	123.2	0.04	1.80	7.16	5	51	14	96	0.02	0.0	1.766	0.139	7	2	1	12
PL.1489	PL.1487	A	8 A (CWC)	7.39Y	123.2	0.02	1.83	5.21	5	37	10	97	0.01	0.0	1.843	0.077	10	3	3	10
PL.1490	PL.1489	A	8 A (CWC)	7.39Y	123.1	0.03	1.86	3.80	4	27	7	97	0.01	0.0	1.955	0.112	0	0	0	7
PL.1493	PL.1490	A	8 A (CWC)	7.39Y	123.1	0.00	1.86	2.54	3	18	5	96	0.00	0.0	2.006	0.051	18	5	3	3
PL.1492	PL.1490	A	#4 ACSR	7.39Y	123.1	0.00	1.86	1.26	1	9	2	98	0.00	0.0	2.003	0.048	9	2	4	4
PL.10156	PL.1487	A	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.94	0	7	2	96	0.00	0.0	1.794	0.028	7	2	1	1
PL.1481	PL.1480	A	#4 ACSR	7.40Y	123.4	0.00	1.62	0.00	0	0	0	100	0.00	0.0	1.281	0.042	0	0	0	0
PL.2478	PL.1465	B	#1/0 ACSR	7.42Y	123.6	0.00	1.41	0.18	0	1	0	100	0.00	0.0	0.662	0.005	0	0	0	1
PD.310	PL.2478	B	40QA	7.42Y	123.6	0.00	1.41	0.18	0	1	0	100	0.00	0.0	0.662	0.005	0	0	0	1
PL.2479	PD.310	B	#1/0 ACSR	7.42Y	123.6	0.00	1.41	0.18	0	1	0	100	0.00	0.0	0.675	0.012	1	0	1	1
PL.2410	PL.1399	C	#2 ACSR	7.43Y	123.8	0.00	1.20	2.89	2	21	6	96	0.00	0.0	0.557	0.005	0	0	0	3
PD.275	PL.2410	C	30T	7.43Y	123.8	0.00	1.20	2.89	0	21	6	96	0.00	0.0	0.557	0.005	0	0	0	3
PL.2411	PD.275	C	#2 ACSR	7.43Y	123.8	0.00	1.20	2.89	2	21	6	96	0.00	0.0	0.573	0.017	10	3	2	3
PL.1460	PL.2411	C	#2 ACSR	7.43Y	123.8	0.00	1.20	1.44	1	10	3	96	0.00	0.0	0.617	0.044	0	0	0	1
PL.1461	PL.1460	C	#4 ACSR	7.43Y	123.8	0.00	1.20	1.44	1	10	3	96	0.00	0.0	0.664	0.047	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1583	PL.1393	ABC	336 MCM AC	7.45Y	124.1	0.00	0.86	16.44	3	354	98	96	0.00	0.0	0.405	0.015	0	0	0	92
PL.2554	PL.1583	ABC	#1/0 ACSR	7.45Y	124.1	0.00	0.86	16.44	7	354	98	96	0.00	0.0	0.407	0.003	0	0	0	92
PD.350	PL.2554	ABC	70L	7.45Y	124.1	0.00	0.86	16.44	23	354	98	96	0.00	0.0	0.407	0.003	0	0	0	92
PL.2555	PD.350	ABC	#1/0 ACSR	7.45Y	124.1	0.01	0.88	16.44	7	354	98	96	0.03	0.0	0.453	0.046	18	5	5	92
PL.1421	PL.2555	ABC	#1/0 ACSR	7.45Y	124.1	0.01	0.89	14.83	6	319	88	96	0.03	0.0	0.507	0.054	0	0	1	84
PL.1425	PL.1421	ABC	#1/0 ACSR	7.45Y	124.1	0.01	0.90	14.81	6	319	88	96	0.02	0.0	0.546	0.039	37	10	5	83
PL.1426	PL.1425	ABC	#1/0 ACSR	7.45Y	124.1	0.01	0.91	13.07	6	281	78	96	0.02	0.0	0.599	0.052	6	2	3	78
PL.1429	PL.1426	B	8 A (CWC)	7.45Y	124.1	0.00	0.91	0.86	1	6	2	95	0.00	0.0	0.641	0.042	4	1	1	2
PL.1433	PL.1429	B	8 A (CWC)	7.45Y	124.1	0.00	0.91	0.29	0	2	1	89	0.00	0.0	0.676	0.035	2	1	1	1
PL.1434	PL.1433	B	8 A (CWC)	7.45Y	124.1	0.00	0.91	0.00	0	0	0	100	0.00	0.0	0.741	0.065	0	0	0	0
PL.1428	PL.1426	B	8 A (CWC)	7.45Y	124.1	0.00	0.91	1.35	1	10	3	96	0.00	0.0	0.647	0.048	10	3	1	1
PL.1432	PL.1428	B	8 A (CWC)	7.45Y	124.1	0.00	0.91	0.00	0	0	0	100	0.00	0.0	0.649	0.002	0	0	0	0
PL.1427	PL.1426	ABC	#1/0 ACSR	7.44Y	124.1	0.01	0.92	12.04	5	259	72	96	0.01	0.0	0.624	0.025	4	1	3	72
PL.1430	PL.1427	ABC	#1/0 ACSR	7.44Y	124.1	0.01	0.93	11.84	5	255	70	96	0.03	0.0	0.694	0.071	14	4	6	69
PL.1438	PL.1430	ABC	#1/0 ACSR	7.44Y	124.1	0.01	0.94	10.41	5	224	62	96	0.02	0.0	0.754	0.060	2	0	1	60
PL.1439	PL.1438	ABC	#1/0 ACSR	7.44Y	124.0	0.01	0.95	10.33	4	222	62	96	0.02	0.0	0.814	0.060	30	8	6	59
PL.1440	PL.1439	ABC	#1/0 ACSR	7.44Y	124.0	0.01	0.96	8.54	4	184	51	96	0.01	0.0	0.884	0.070	11	3	3	52
PL.4514	PL.1440	B	8 A (CWC)	7.44Y	124.0	0.01	0.97	4.13	4	30	8	97	0.00	0.0	0.915	0.031	11	3	1	12
PL.4515	PL.4514	B	8 A (CWC)	7.44Y	124.0	0.02	0.99	2.59	3	19	5	97	0.00	0.0	1.045	0.130	0	0	0	11
PL.1445	PL.4515	B	8 A (CWC)	7.44Y	124.0	0.00	1.00	0.73	1	5	1	98	0.00	0.0	1.139	0.094	0	0	0	2
PL.1448	PL.1445	B	8 A (CWC)	7.44Y	124.0	0.00	1.00	0.73	1	5	1	98	0.00	0.0	1.192	0.053	5	1	2	2
PL.1446	PL.4515	B	#4 ACSR	7.44Y	124.0	0.00	1.00	1.86	1	13	4	96	0.00	0.0	1.089	0.044	8	2	7	9
PL.1447	PL.1446	B	#4 ACSR	7.44Y	124.0	0.00	1.00	0.71	1	5	1	98	0.00	0.0	1.142	0.053	5	1	2	2
PL.1449	PL.1447	B	#4 ACSR	7.44Y	124.0	0.00	1.00	0.00	0	0	0	100	0.00	0.0	1.217	0.076	0	0	0	0
PL.1443	PL.1440	B	#1/0 ACSR	7.44Y	124.0	0.01	0.98	19.97	9	143	40	96	0.01	0.0	0.913	0.028	8	2	1	37
PL.2220	PL.1443	B	#1/0 ACSR	7.44Y	124.0	0.01	0.99	18.87	8	135	37	96	0.01	0.0	0.945	0.032	9	3	2	36
PL.2221	PL.2220	B	#1/0 ACSR	7.44Y	124.0	0.02	1.01	17.57	8	126	35	96	0.02	0.0	0.990	0.045	5	1	1	34
PL.1451	PL.2221	B	#1/0 ACSR	7.44Y	124.0	0.01	1.02	16.94	7	121	34	96	0.01	0.0	1.013	0.022	28	8	4	33
PL.1452	PL.1451	B	#2 ACSR	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	1.064	0.051	0	0	1	1
PL.1453	PL.1451	B	#1/0 ACSR	7.44Y	124.0	0.01	1.03	12.97	6	93	26	96	0.01	0.0	1.058	0.045	41	11	12	28
PL.1454	PL.1453	B	#1/0 ACSR	7.44Y	124.0	0.01	1.04	7.31	3	52	14	97	0.00	0.0	1.119	0.061	27	7	7	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.1455	PL.1454	B	#1/0 ACSR	7.44Y	124.0	0.00	1.04	2.02	1	14	4	96	0.00	0.0	1.147	0.028	8	2	3	7
PL.2222	PL.1455	B	#2 ACSR 6/	7.44Y	124.0	0.00	1.04	0.86	0	6	2	95	0.00	0.0	1.208	0.062	0	0	1	4
PL.2223	PL.2222	B	#1/0 ACSR	7.44Y	124.0	0.00	1.04	0.86	0	6	2	95	0.00	0.0	1.293	0.084	6	2	2	3
PL.2224	PL.2223	B	#1/0 ACSR	7.44Y	124.0	0.00	1.04	0.02	0	0	0	100	0.00	0.0	1.379	0.086	0	0	0	1
PL.1458	PL.2224	B	#1/0 ACSR	7.44Y	124.0	0.00	1.04	0.02	0	0	0	100	0.00	0.0	1.491	0.112	0	0	1	1
PL.1456	PL.1454	B	#4 ACSR	7.44Y	124.0	0.00	1.04	1.55	1	11	3	96	0.00	0.0	1.140	0.021	11	3	2	2
PL.1457	PL.1456	B	#4 ACSR	7.44Y	124.0	0.00	1.04	0.00	0	0	0	100	0.00	0.0	1.185	0.045	0	0	0	0
PL.1441	PL.1439	B	8 A (CWC)	7.44Y	124.0	0.00	0.96	1.16	1	8	2	97	0.00	0.0	0.857	0.043	8	2	1	1
PL.1436	PL.1430	B	#4 ACSR	7.44Y	124.1	0.00	0.93	2.35	2	17	5	96	0.00	0.0	0.722	0.027	0	0	0	3
PL.1435	PL.1436	B	#4 ACSR	7.44Y	124.1	0.00	0.94	2.35	2	17	5	96	0.00	0.0	0.750	0.028	4	1	1	3
PL.1437	PL.1435	B	#4 ACSR	7.44Y	124.1	0.00	0.94	1.79	1	13	4	96	0.00	0.0	0.816	0.066	13	4	2	2
PL.1420	PL.2555	B	#4 ACSR	7.45Y	124.1	0.00	0.88	2.35	2	17	5	96	0.00	0.0	0.466	0.013	0	0	0	3
PL.1422	PL.1420	B	#4 ACSR	7.45Y	124.1	0.01	0.88	2.35	2	17	5	96	0.00	0.0	0.539	0.073	0	0	1	3
PL.1423	PL.1422	B	#1/0 ACSR	7.45Y	124.1	0.00	0.89	1.04	0	7	2	96	0.00	0.0	0.594	0.055	7	2	1	1
PL.1424	PL.1422	B	#2 ACSR	7.45Y	124.1	0.00	0.89	1.30	1	9	3	95	0.00	0.0	0.570	0.031	9	3	1	1
PL.3087	Goose Rock	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.00	85.03	25	1820	591	95	0.05	0.0	0.005	0.005	0	0	0	387
PL.7161	PL.3087	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.01	85.03	25	1820	591	95	0.01	0.0	0.006	0.001	0	0	0	387

----- Feeder No. 4 (Schoolhouse F4) Beginning with Device PD.1529 -----

PD.1529	PL.7161	ABC	480VWE	7.50Y	125.0	0.00	0.01	85.03	0	1820	591	95	0.00	0.0	0.006	0.001	0	0	0	387
PL.7162	PD.1529	ABC	#4/0 ACSR	7.50Y	125.0	0.00	0.01	85.03	25	1820	591	95	0.05	0.0	0.011	0.005	0	0	0	387
PL.3992	PL.7162	ABC	#4/0 ACSR	7.49Y	124.9	0.09	0.10	85.03	25	1820	591	95	0.95	0.1	0.110	0.099	0	0	0	387
PL.3490	PL.3992	C	6 A (CWC)	7.49Y	124.9	0.00	0.10	0.41	0	3	1	95	0.00	0.0	0.115	0.005	0	0	0	1
PD.460	PL.3490	C	40QA	7.49Y	124.9	0.00	0.10	0.41	1	3	1	95	0.00	0.0	0.115	0.005	0	0	0	1
PL.3491	PD.460	C	6 A (CWC)	7.49Y	124.9	0.00	0.10	0.41	0	3	1	95	0.00	0.0	0.151	0.037	3	1	1	1
PL.3780	PL.3992	ABC	#4/0 ACSR	7.49Y	124.8	0.07	0.18	84.90	25	1816	588	95	0.75	0.0	0.189	0.078	0	0	0	386
PL.3781	PL.3780	ABC	#4/0 ACSR	7.48Y	124.7	0.08	0.26	84.67	25	1810	586	95	0.83	0.0	0.275	0.087	0	0	0	383
PL.3617	PL.3781	ABC	#4/0 ACSR	7.48Y	124.7	0.09	0.34	74.87	22	1609	487	96	0.80	0.0	0.383	0.107	10	3	1	382
PL.3619	PL.3617	ABC	#4/0 ACSR	7.47Y	124.6	0.08	0.43	74.41	22	1598	483	96	0.76	0.0	0.486	0.103	0	0	0	381
PL.2958	PL.3619	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	3.51	2	25	7	96	0.00	0.0	0.491	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.458	PL.2958	A	40QA	7.47Y	124.6	0.00	0.43	3.51	9	25	7	96	0.00	0.0	0.491	0.005	0	0	0	2
PL.2959	PD.458	A	#1/0 ACSR	7.47Y	124.6	0.00	0.43	3.51	2	25	7	96	0.00	0.0	0.520	0.029	25	7	2	2
PL.3620	PL.3619	ABC	#4/0 ACSR	7.47Y	124.5	0.05	0.48	73.24	22	1572	475	96	0.49	0.0	0.555	0.069	9	2	4	379
PL.3621	PL.3620	ABC	#4/0 ACSR	7.47Y	124.5	0.02	0.50	72.60	21	1558	470	96	0.18	0.0	0.580	0.026	0	0	1	374
PL.3622	PL.3621	ABC	#4/0 ACSR	7.46Y	124.4	0.13	0.64	72.58	21	1557	470	96	1.19	0.1	0.750	0.169	0	0	0	373
PL.3537	PL.3622	ABC	#4/0 ACSR	7.45Y	124.2	0.14	0.78	72.58	21	1556	467	96	1.27	0.1	0.931	0.181	3	1	1	373
PL.3928	PL.3537	ABC	#4/0 ACSR	7.45Y	124.1	0.13	0.91	72.42	21	1551	464	96	1.21	0.1	1.103	0.172	0	0	0	372
PL.2954	PL.3928	C	#4 ACSR	7.45Y	124.1	0.00	0.91	1.19	1	9	2	98	0.00	0.0	1.108	0.005	0	0	0	1
PD.456	PL.2954	C	40QA	7.45Y	124.1	0.00	0.91	1.19	3	9	2	98	0.00	0.0	1.108	0.005	0	0	0	1
PL.32693	PD.456	C	#2 ACSR	7.45Y	124.1	0.00	0.91	1.19	1	9	2	98	0.00	0.0	1.168	0.060	9	2	1	1
PL.3514	PL.3928	ABC	#4/0 ACSR	7.44Y	124.0	0.14	1.05	72.03	21	1542	460	96	1.22	0.1	1.279	0.176	0	0	0	371
PL.3538	PL.3514	ABC	#4/0 ACSR	7.43Y	123.9	0.04	1.09	72.03	21	1540	458	96	0.36	0.0	1.331	0.052	7	2	1	371
PL.3624	PL.3538	ABC	#4/0 ACSR	7.43Y	123.9	0.05	1.14	70.76	21	1513	450	96	0.47	0.0	1.402	0.071	11	3	1	366
PL.3925	PL.3624	ABC	#4/0 ACSR	7.43Y	123.8	0.06	1.20	70.25	21	1501	446	96	0.48	0.0	1.475	0.073	3	1	1	365
PL.3926	PL.3925	ABC	#4/0 ACSR	7.42Y	123.7	0.08	1.28	70.09	21	1497	444	96	0.74	0.0	1.588	0.112	4	1	1	364
PL.3924	PL.3926	ABC	#4/0 ACSR	7.42Y	123.7	0.06	1.34	69.92	21	1493	442	96	0.51	0.0	1.666	0.079	9	3	1	363
PL.3919	PL.3924	ABC	#4/0 ACSR	7.42Y	123.6	0.07	1.41	69.48	20	1483	438	96	0.57	0.0	1.755	0.089	8	2	2	362
PL.3628	PL.3919	ABC	#4/0 ACSR	7.41Y	123.5	0.12	1.53	68.72	20	1466	433	96	1.04	0.1	1.920	0.165	1	0	1	359
PL.3923	PL.3628	ABC	#4/0 ACSR	7.41Y	123.4	0.05	1.58	68.68	20	1464	431	96	0.41	0.0	1.985	0.065	0	0	0	358
PL.3920	PL.3923	ABC	#4/0 ACSR	7.40Y	123.4	0.04	1.62	68.20	20	1454	427	96	0.30	0.0	2.033	0.048	5	1	1	356
PL.3921	PL.3920	ABC	#4/0 ACSR	7.40Y	123.3	0.04	1.65	67.96	20	1448	425	96	0.33	0.0	2.087	0.054	6	2	1	355
PL.3918	PL.3921	ABC	#4/0 ACSR	7.40Y	123.3	0.05	1.70	67.68	20	1442	423	96	0.42	0.0	2.156	0.069	0	0	0	354
PL.3630	PL.3918	ABC	#1/0 ACSR	7.39Y	123.2	0.10	1.80	67.48	29	1437	421	96	0.99	0.1	2.238	0.082	17	5	2	353
PL.3916	PL.3630	ABC	#1/0 ACSR	7.39Y	123.1	0.08	1.89	66.70	29	1419	415	96	0.82	0.1	2.308	0.070	15	4	3	351
PL.3917	PL.3916	ABC	#4/0 ACSR	7.38Y	123.0	0.06	1.95	66.00	19	1404	410	96	0.53	0.0	2.398	0.090	0	0	0	348
PL.4011	PL.3917	C	#4 ACSR	7.38Y	123.0	0.00	1.95	0.73	1	5	1	98	0.00	0.0	2.403	0.005	0	0	0	3
PD.451	PL.4011	C	40QA	7.38Y	123.0	0.00	1.95	0.73	2	5	1	98	0.00	0.0	2.403	0.005	0	0	0	3
PL.4012	PD.451	C	#4 ACSR	7.38Y	123.0	0.00	1.96	0.73	1	5	1	98	0.00	0.0	2.481	0.078	1	0	1	3
PL.3631	PL.4012	C	#4 ACSR	7.38Y	123.0	0.00	1.96	0.62	0	4	1	97	0.00	0.0	2.558	0.077	4	1	2	2
PL.3515	PL.3917	ABC	#4/0 ACSR	7.38Y	123.0	0.08	2.03	65.76	19	1398	408	96	0.63	0.0	2.508	0.110	5	1	1	345
PL.3915	PL.3515	ABC	#4/0 ACSR	7.37Y	122.9	0.11	2.14	65.52	19	1392	406	96	0.93	0.1	2.670	0.162	0	0	0	344

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.4009	PL.3915	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.92	1	7	2	96	0.00	0.0	2.674	0.004	0	0	0	1
PD.450	PL.4009	A	40QA	7.37Y	122.9	0.00	2.14	0.92	2	7	2	96	0.00	0.0	2.674	0.004	0	0	0	1
PL.4010	PD.450	A	#4 ACSR	7.37Y	122.9	0.00	2.15	0.92	1	7	2	96	0.00	0.0	2.714	0.040	7	2	1	1
PL.3885	PL.3915	ABC	#4/0 ACSR	7.37Y	122.8	0.07	2.21	65.22	19	1385	402	96	0.54	0.0	2.765	0.095	8	2	1	343
PL.3886	PL.3885	ABC	#4/0 ACSR	7.36Y	122.7	0.04	2.25	64.82	19	1376	399	96	0.33	0.0	2.824	0.059	0	0	0	342
PL.3887	PL.3886	ABC	#4/0 ACSR	7.36Y	122.7	0.03	2.28	64.82	19	1376	398	96	0.23	0.0	2.866	0.042	23	6	3	342
PL.3888	PL.3887	ABC	#4/0 ACSR	7.36Y	122.7	0.06	2.34	63.74	19	1352	392	96	0.45	0.0	2.950	0.083	9	3	2	339
PL.3889	PL.3888	ABC	#4/0 ACSR	7.36Y	122.6	0.07	2.40	63.30	19	1343	388	96	0.51	0.0	3.046	0.096	0	0	0	337
PL.3999	PL.3889	A	#2 ACSR	7.36Y	122.6	0.00	2.40	1.10	1	8	2	97	0.00	0.0	3.050	0.005	0	0	0	2
PD.445	PL.3999	A	40QA	7.36Y	122.6	0.00	2.40	1.10	3	8	2	97	0.00	0.0	3.050	0.005	0	0	0	2
PL.4000	PD.445	A	#2 ACSR	7.36Y	122.6	0.00	2.40	1.10	1	8	2	97	0.00	0.0	3.066	0.016	8	2	2	2
PL.3854	PL.3889	ABC	#4/0 ACSR	7.35Y	122.5	0.05	2.46	62.93	19	1334	385	96	0.43	0.0	3.128	0.082	16	4	5	335
PL.3997	PL.3854	A	#4 ACSR	7.35Y	122.5	0.00	2.46	2.71	2	19	5	97	0.00	0.0	3.132	0.005	0	0	0	4
PD.444	PL.3997	A	40QA	7.35Y	122.5	0.00	2.46	2.71	7	19	5	97	0.00	0.0	3.132	0.005	0	0	0	4
PL.3998	PD.444	A	#4 ACSR	7.35Y	122.5	0.00	2.46	2.71	2	19	5	97	0.00	0.0	3.195	0.063	19	5	4	4
PL.3880	PL.3854	ABC	#4/0 ACSR	7.35Y	122.5	0.05	2.51	61.29	18	1299	375	96	0.40	0.0	3.206	0.079	0	0	0	326
PL.3882	PL.3880	ABC	#4/0 ACSR	7.35Y	122.5	0.03	2.54	61.29	18	1299	374	96	0.24	0.0	3.256	0.049	12	3	2	326
PL.3883	PL.3882	ABC	#4/0 ACSR	7.35Y	122.4	0.03	2.57	60.74	18	1287	370	96	0.22	0.0	3.299	0.044	8	2	1	324
PL.3884	PL.3883	ABC	#4/0 ACSR	7.34Y	122.4	0.04	2.61	60.36	18	1278	368	96	0.28	0.0	3.356	0.057	0	0	0	323
PL.3881	PL.3884	ABC	#4/0 ACSR	7.34Y	122.4	0.03	2.63	60.36	18	1278	367	96	0.21	0.0	3.398	0.042	2	1	2	323
PL.3633	PL.3881	ABC	#4/0 ACSR	7.34Y	122.3	0.04	2.67	60.27	18	1276	366	96	0.31	0.0	3.461	0.063	0	0	0	321
PL.3993	PL.3633	B	#1/0 ACSR	7.34Y	122.3	0.00	2.67	5.61	2	40	11	96	0.00	0.0	3.466	0.005	0	0	0	12
PD.441	PL.3993	B	40QA	7.34Y	122.3	0.00	2.67	5.61	14	40	11	96	0.00	0.0	3.466	0.005	0	0	0	12
PL.3994	PD.441	B	#1/0 ACSR	7.34Y	122.3	0.00	2.68	5.61	2	40	11	96	0.00	0.0	3.490	0.024	8	2	2	12
PL.3909	PL.3994	B	#1/0 ACSR	7.34Y	122.3	0.01	2.69	4.45	2	31	9	96	0.00	0.0	3.590	0.100	0	0	0	10
PL.3634	PL.3909	B	#2 ACSR	7.34Y	122.3	0.00	2.69	1.17	1	8	2	97	0.00	0.0	3.647	0.057	0	0	0	1
PL.3827	PL.3634	B	#2 ACSR	7.34Y	122.3	0.00	2.69	1.17	1	8	2	97	0.00	0.0	3.774	0.126	8	2	1	1
PL.3516	PL.3909	B	#1/0 ACSR	7.34Y	122.3	0.01	2.69	3.28	1	23	6	97	0.00	0.0	3.674	0.084	0	0	0	9
PL.3910	PL.3516	B	#1/0 ACSR	7.34Y	122.3	0.01	2.70	3.28	1	23	6	97	0.00	0.0	3.802	0.127	16	5	5	9
PL.3911	PL.3910	B	#1/0 ACSR	7.34Y	122.3	0.00	2.70	0.96	0	7	2	96	0.00	0.0	3.853	0.051	7	2	4	4
PL.3912	PL.3911	B	#1/0 ACSR	7.34Y	122.3	0.00	2.70	0.00	0	0	0	100	0.00	0.0	3.932	0.080	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3913	PL.3912	B	#1/0 ACSR	7.34Y	122.3	0.00	2.70	0.00	0	0	0	100	0.00	0.0	4.093	0.161	0	0	0	0
PL.3850	PL.3633	ABC	#4/0 ACSR	7.34Y	122.3	0.05	2.72	58.40	17	1236	355	96	0.33	0.0	3.535	0.073	4	1	4	309
PL.3995	PL.3850	C	#2 ACSR	7.34Y	122.3	0.00	2.72	0.52	0	4	1	97	0.00	0.0	3.539	0.005	0	0	0	1
PD.442	PL.3995	C	40QA	7.34Y	122.3	0.00	2.72	0.52	1	4	1	97	0.00	0.0	3.539	0.005	0	0	0	1
PL.3996	PD.442	C	#2 ACSR	7.34Y	122.3	0.00	2.72	0.52	0	4	1	97	0.00	0.0	3.555	0.016	4	1	1	1
PL.3907	PL.3850	ABC	#4/0 ACSR	7.34Y	122.3	0.03	2.75	58.02	17	1228	352	96	0.18	0.0	3.576	0.041	10	3	4	304
PL.3908	PL.3907	ABC	#4/0 ACSR	7.33Y	122.2	0.02	2.77	57.56	17	1218	349	96	0.17	0.0	3.615	0.039	0	0	0	300
PL.3824	PL.3908	ABC	#4/0 ACSR	7.33Y	122.2	0.00	2.77	57.56	17	1217	349	96	0.01	0.0	3.617	0.001	0	0	0	300
RG.5	PL.3824	ABC	114.3 KVA	7.47Y	124.6	-2.34	0.44	57.56	38	1217	349	96	percent Boost= 1.88		Tap= 3.0					300
PL.3825	RG.5	ABC	#4/0 ACSR	7.47Y	124.6	0.00	0.44	56.48	17	1217	349	96	0.01	0.0	3.618	0.001	0	0	0	300
PL.3849	PL.3825	ABC	#4/0 ACSR	7.47Y	124.5	0.02	0.46	56.48	17	1217	349	96	0.16	0.0	3.657	0.039	24	7	3	300
PL.4028	PL.3849	C	#2 ACSR	7.47Y	124.5	0.00	0.46	2.25	1	16	4	97	0.00	0.0	3.661	0.005	0	0	0	7
PD.482	PL.4028	C	40QA	7.47Y	124.5	0.00	0.46	2.25	6	16	4	97	0.00	0.0	3.661	0.005	0	0	0	7
PL.4029	PD.482	C	#2 ACSR	7.47Y	124.5	0.00	0.46	2.25	1	16	4	97	0.00	0.0	3.720	0.058	16	4	7	7
PL.4007	PL.3849	A	#4 ACSR	7.47Y	124.5	0.00	0.46	2.19	2	16	4	97	0.00	0.0	3.661	0.005	0	0	0	3
PD.449	PL.4007	A	40QA	7.47Y	124.5	0.00	0.46	2.19	5	16	4	97	0.00	0.0	3.661	0.005	0	0	0	3
PL.4008	PD.449	A	#4 ACSR	7.47Y	124.5	0.00	0.46	2.19	2	16	4	97	0.00	0.0	3.698	0.037	16	4	3	3
PL.4048	PL.3849	ABC	#4/0 ACSR	7.47Y	124.5	0.02	0.48	53.89	16	1161	333	96	0.15	0.0	3.694	0.038	0	0	0	287
PD.492	PL.4048	ABC	100L	7.47Y	124.5	0.00	0.48	53.89	54	1161	333	96	0.00	0.0	3.694	0.038	0	0	0	287
PL.4049	PD.492	ABC	#4/0 ACSR	7.47Y	124.5	0.02	0.51	53.89	16	1161	333	96	0.17	0.0	3.738	0.043	10	3	2	287
PL.4005	PL.4049	A	#2 ACSR	7.47Y	124.5	0.00	0.51	0.32	0	2	1	89	0.00	0.0	3.742	0.005	0	0	0	1
PD.448	PL.4005	A	40QA	7.47Y	124.5	0.00	0.51	0.32	1	2	1	89	0.00	0.0	3.742	0.005	0	0	0	1
PL.4006	PD.448	A	#2 ACSR	7.47Y	124.5	0.00	0.51	0.32	0	2	1	89	0.00	0.0	3.798	0.056	2	1	1	1
PL.4026	PL.4049	ABC	#4/0 ACSR	7.47Y	124.4	0.06	0.56	53.30	16	1148	329	96	0.38	0.0	3.838	0.101	0	0	0	284
PL.4027	PL.4026	ABC	#4/0 ACSR	7.47Y	124.4	0.00	0.57	53.30	16	1148	328	96	0.02	0.0	3.843	0.004	14	4	4	284
PL.4042	PL.4027	C	#1/0 ACSR	7.47Y	124.4	0.00	0.57	27.64	12	199	56	96	0.00	0.0	3.845	0.003	0	0	0	51
PD.489	PL.4042	C	50L	7.47Y	124.4	0.00	0.57	27.64	55	199	56	96	0.00	0.0	3.845	0.003	0	0	0	51
PL.4043	PD.489	C	#1/0 ACSR	7.46Y	124.4	0.03	0.59	27.64	12	199	56	96	0.03	0.0	3.887	0.042	0	0	0	51
PL.3517	PL.4043	C	#1/0 ACSR	7.46Y	124.3	0.06	0.66	26.68	12	192	54	96	0.08	0.0	3.987	0.100	0	0	0	49
PL.3539	PL.3517	C	#1/0 ACSR	7.46Y	124.3	0.09	0.75	26.68	12	192	54	96	0.11	0.1	4.131	0.144	0	0	0	49
PL.3637	PL.3539	C	#2 ACSR	7.46Y	124.3	0.00	0.75	0.40	0	3	1	95	0.00	0.0	4.165	0.034	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3636	PL.3539	C	#1/0 ACSR	7.45Y	124.2	0.05	0.79	26.28	11	189	53	96	0.06	0.0	4.206	0.075	3	1	2	48
PL.3640	PL.3636	C	#1/0 ACSR	7.45Y	124.2	0.04	0.83	25.44	11	183	51	96	0.05	0.0	4.280	0.074	4	1	1	43
PL.3641	PL.3640	C	#1/0 ACSR	7.45Y	124.1	0.04	0.87	24.84	11	178	50	96	0.04	0.0	4.345	0.065	0	0	0	42
PL.3878	PL.3641	C	#1/0 ACSR	7.45Y	124.1	0.01	0.88	8.30	4	60	16	97	0.00	0.0	4.415	0.071	15	4	3	10
PL.3879	PL.3878	C	#1/0 ACSR	7.45Y	124.1	0.01	0.89	6.20	3	44	12	96	0.00	0.0	4.487	0.071	6	2	1	7
PL.4517	PL.3879	C	#2 ACSR	7.45Y	124.1	0.01	0.90	5.39	3	39	11	96	0.00	0.0	4.551	0.064	0	0	0	6
PL.4518	PL.4517	C	#2 ACSR	7.45Y	124.1	0.01	0.91	4.31	2	31	9	96	0.00	0.0	4.639	0.088	15	4	2	5
PL.3865	PL.4518	C	#2 ACSR	7.45Y	124.1	0.00	0.92	2.20	1	16	4	97	0.00	0.0	4.692	0.053	9	2	2	3
PL.3863	PL.3865	C	#2 ACSR	7.45Y	124.1	0.00	0.92	0.95	1	7	2	96	0.00	0.0	4.740	0.048	7	2	1	1
PL.4516	PL.4517	C	#1/0 ACSR	7.45Y	124.1	0.00	0.91	1.08	0	8	2	97	0.00	0.0	4.879	0.328	8	2	1	1
PL.3642	PL.3641	C	#1/0 ACSR	7.44Y	124.1	0.06	0.93	16.54	7	119	33	96	0.04	0.0	4.491	0.147	0	0	0	32
PL.3541	PL.3642	C	#1/0 ACSR	7.44Y	124.0	0.04	0.97	16.54	7	119	33	96	0.03	0.0	4.604	0.113	0	0	0	32
PL.3542	PL.3541	C	#1/0 ACSR	7.44Y	124.0	0.05	1.02	16.54	7	119	33	96	0.04	0.0	4.740	0.136	0	0	0	32
PL.3644	PL.3542	C	#2 ACSR	7.44Y	124.0	0.00	1.02	0.12	0	1	0	100	0.00	0.0	4.840	0.101	0	0	0	2
PL.3661	PL.3644	C	#2 ACSR	7.44Y	124.0	0.00	1.02	0.11	0	1	0	100	0.00	0.0	4.958	0.117	0	0	0	1
PL.3544	PL.3661	C	#2 ACSR	7.44Y	124.0	0.00	1.02	0.11	0	1	0	100	0.00	0.0	5.102	0.144	0	0	0	1
PL.3545	PL.3544	C	#2 ACSR	7.44Y	124.0	0.00	1.02	0.11	0	1	0	100	0.00	0.0	5.188	0.086	0	0	0	1
PL.3830	PL.3545	C	#2 ACSR	7.44Y	124.0	0.00	1.03	0.11	0	1	0	100	0.00	0.0	5.358	0.170	0	0	0	1
PL.4521	PL.3830	C	#2 ACSR	7.44Y	124.0	0.00	1.03	0.11	0	1	0	100	0.00	0.0	5.504	0.146	0	0	0	1
PL.4522	PL.4521	C	#2 ACSR	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	5.522	0.019	0	0	0	0
PL.4520	PL.4521	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	0.11	0	1	0	100	0.00	0.0	5.600	0.096	1	0	1	1
PL.3662	PL.3644	C	#1/0 ACSR	7.44Y	124.0	0.00	1.02	0.01	0	0	0	100	0.00	0.0	4.892	0.052	0	0	1	1
PL.3871	PL.3542	C	#1/0 ACSR	7.44Y	124.0	0.02	1.04	16.36	7	117	33	96	0.01	0.0	4.782	0.043	1	0	1	29
PL.3872	PL.3871	C	#1/0 ACSR	7.44Y	123.9	0.04	1.08	16.17	7	116	32	96	0.03	0.0	4.885	0.103	0	0	0	28
PL.3548	PL.3872	C	#1/0 ACSR	7.43Y	123.9	0.05	1.12	16.17	7	116	32	96	0.04	0.0	5.012	0.127	0	0	0	28
PL.3549	PL.3548	C	#1/0 ACSR	7.43Y	123.8	0.04	1.17	16.17	7	116	32	96	0.03	0.0	5.128	0.116	0	0	0	28
PL.3550	PL.3549	C	#1/0 ACSR	7.43Y	123.8	0.05	1.22	16.17	7	116	32	96	0.04	0.0	5.258	0.130	0	0	0	28
PL.3873	PL.3550	C	#1/0 ACSR	7.43Y	123.8	0.02	1.24	16.17	7	116	32	96	0.02	0.0	5.327	0.069	10	3	1	28
PL.3874	PL.3873	C	#1/0 ACSR	7.42Y	123.7	0.01	1.25	14.81	6	106	29	96	0.01	0.0	5.360	0.032	1	0	1	27
PL.3875	PL.3874	C	#1/0 ACSR	7.42Y	123.7	0.05	1.31	14.72	6	105	29	96	0.04	0.0	5.514	0.155	2	1	1	26
PL.3876	PL.3875	C	#1/0 ACSR	7.42Y	123.7	0.01	1.31	14.44	6	103	29	96	0.01	0.0	5.541	0.026	0	0	0	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3877	PL.3876	C	#1/0 ACSR	7.42Y	123.7	0.03	1.35	14.44	6	103	29	96	0.02	0.0	5.640	0.099	2	1	1	25
PL.3855	PL.3877	C	#1/0 ACSR	7.42Y	123.6	0.03	1.38	14.13	6	101	28	96	0.02	0.0	5.737	0.097	0	0	0	23
PL.3782	PL.3855	C	#1/0 ACSR	7.41Y	123.6	0.04	1.42	14.13	6	101	28	96	0.03	0.0	5.859	0.122	0	0	0	23
PL.3783	PL.3782	C	#1/0 ACSR	7.41Y	123.5	0.05	1.46	14.13	6	101	28	96	0.03	0.0	6.003	0.144	8	2	2	23
PL.3647	PL.3783	C	#1/0 ACSR	7.41Y	123.5	0.03	1.49	12.00	5	86	24	96	0.02	0.0	6.112	0.109	0	0	0	20
PL.3649	PL.3647	C	#4 ACSR	7.41Y	123.5	0.00	1.50	2.24	2	16	4	97	0.00	0.0	6.140	0.028	5	2	3	8
PL.3650	PL.3649	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.48	1	11	3	96	0.00	0.0	6.181	0.041	2	0	1	5
PL.3858	PL.3650	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.24	1	9	2	98	0.00	0.0	6.271	0.090	0	0	0	4
PL.3859	PL.3858	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.24	1	9	2	98	0.00	0.0	6.276	0.005	4	1	1	4
PL.3658	PL.3859	C	#1/0 ACSR	7.41Y	123.5	0.00	1.50	0.61	0	4	1	97	0.00	0.0	6.281	0.005	0	0	0	3
PD.443	PL.3658	C	40QA	7.41Y	123.5	0.00	1.50	0.61	2	4	1	97	0.00	0.0	6.281	0.005	0	0	0	3
PL.3518	PD.443	C	#1/0 ACSR	7.41Y	123.5	0.00	1.50	0.00	0	0	0	100	0.00	0.0	6.326	0.046	0	0	0	0
PL.3860	PD.443	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.61	0	4	1	97	0.00	0.0	6.290	0.010	0	0	0	3
PL.3657	PL.3860	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.61	0	4	1	97	0.00	0.0	6.370	0.080	0	0	0	3
PL.3655	PL.3657	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.61	0	4	1	97	0.00	0.0	6.511	0.140	0	0	0	3
PL.3784	PL.3655	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.61	0	4	1	97	0.00	0.0	6.574	0.064	0	0	0	3
PL.3666	PL.3784	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.00	0	0	0	100	0.00	0.0	6.616	0.041	0	0	1	1
PL.3519	PL.3784	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.61	0	4	1	97	0.00	0.0	6.731	0.157	0	0	0	2
PL.3785	PL.3519	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.61	0	4	1	97	0.00	0.0	6.835	0.104	0	0	0	2
PL.3828	PL.3785	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.61	0	4	1	97	0.00	0.0	6.941	0.106	0	0	0	2
PL.3786	PL.3828	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.61	0	4	1	97	0.00	0.0	7.026	0.086	3	1	1	2
PL.3656	PL.3786	C	#4 ACSR	7.41Y	123.5	0.00	1.53	0.18	0	1	0	100	0.00	0.0	7.179	0.153	0	0	0	1
PL.3659	PL.3656	C	#4 ACSR	7.41Y	123.5	0.00	1.53	0.18	0	1	0	100	0.00	0.0	7.243	0.064	1	0	1	1
PL.3929	PL.3647	C	#1/0 ACSR	7.41Y	123.5	0.01	1.51	9.76	4	70	19	97	0.01	0.0	6.174	0.062	0	0	0	12
PL.3930	PL.3929	C	#1/0 ACSR	7.41Y	123.5	0.01	1.52	9.76	4	70	19	97	0.01	0.0	6.222	0.049	0	0	0	12
PL.3651	PL.3930	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.35	0	2	1	89	0.00	0.0	6.261	0.038	2	1	1	1
PL.3867	PL.3930	C	#1/0 ACSR	7.41Y	123.5	0.02	1.54	9.41	4	67	19	96	0.01	0.0	6.300	0.078	9	2	2	11
PL.3868	PL.3867	C	#1/0 ACSR	7.41Y	123.5	0.01	1.54	8.17	4	58	16	96	0.00	0.0	6.334	0.034	10	3	2	9
PL.3866	PL.3868	C	#1/0 ACSR	7.41Y	123.4	0.01	1.55	6.71	3	48	13	97	0.00	0.0	6.405	0.071	0	0	0	7
PL.3869	PL.3866	C	#1/0 ACSR	7.41Y	123.4	0.01	1.56	5.65	2	40	11	96	0.00	0.0	6.461	0.056	19	5	2	6
PL.3870	PL.3869	C	#1/0 ACSR	7.41Y	123.4	0.00	1.56	3.02	1	22	6	96	0.00	0.0	6.550	0.089	10	3	2	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3653	PL.3870	C	#4 ACSR	7.41Y	123.4	0.00	1.56	1.03	1	7	2	96	0.00	0.0	6.577	0.027	7	2	1	1
PL.3667	PL.3870	C	#4 ACSR	7.41Y	123.4	0.00	1.56	0.60	0	4	1	97	0.00	0.0	6.650	0.100	4	1	1	1
PL.3652	PL.3866	C	#1/0 ACSR	7.41Y	123.4	0.00	1.55	1.06	0	8	2	97	0.00	0.0	6.433	0.028	8	2	1	1
PL.3648	PL.3783	C	#2 ACSR	7.41Y	123.5	0.00	1.47	0.95	1	7	2	96	0.00	0.0	6.071	0.068	7	2	1	1
PL.3645	PL.3877	C	#4 ACSR	7.42Y	123.7	0.00	1.35	0.01	0	0	0	100	0.00	0.0	5.699	0.059	0	0	1	1
PL.3643	PL.3542	C	#2 ACSR	7.44Y	124.0	0.00	1.02	0.06	0	0	0	100	0.00	0.0	4.800	0.060	0	0	1	1
PL.3638	PL.3636	C	#2 ACSR	7.45Y	124.2	0.00	0.79	0.20	0	1	0	100	0.00	0.0	4.255	0.049	1	0	1	1
PL.3639	PL.3636	C	#2 ACSR	7.45Y	124.2	0.00	0.79	0.18	0	1	0	100	0.00	0.0	4.255	0.049	1	0	2	2
PL.28283	PL.4043	C	#1/0 ACSR	7.46Y	124.4	0.00	0.59	0.95	0	7	2	96	0.00	0.0	3.909	0.022	0	0	1	2
PL.28284	PL.28283	C	#1/0 ACSR	7.46Y	124.4	0.00	0.60	0.90	0	6	2	95	0.00	0.0	3.969	0.060	6	2	1	1
PL.4024	PL.4027	C	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.59	0	4	1	97	0.00	0.0	3.847	0.005	0	0	0	1
PD.481	PL.4024	C	50H	7.47Y	124.4	0.00	0.57	0.59	1	4	1	97	0.00	0.0	3.847	0.005	0	0	0	1
PL.4025	PD.481	C	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.59	0	4	1	97	0.00	0.0	3.864	0.016	4	1	1	1
PL.3905	PL.4027	ABC	#4/0 ACSR	7.46Y	124.4	0.03	0.60	43.25	13	931	268	96	0.16	0.0	3.907	0.064	3	1	1	228
PL.3906	PL.3905	ABC	#3/0 ACSR	7.46Y	124.3	0.08	0.68	43.13	14	928	267	96	0.47	0.1	4.057	0.150	0	0	0	227
PL.3832	PL.3906	ABC	#4/0 ACSR	7.46Y	124.3	0.05	0.72	43.13	13	928	266	96	0.26	0.0	4.160	0.103	0	0	0	227
PL.3788	PL.3832	ABC	#4/0 ACSR	7.45Y	124.2	0.08	0.81	43.13	13	928	265	96	0.44	0.0	4.337	0.177	0	0	0	227
PL.3790	PL.3788	ABC	#4/0 ACSR	7.45Y	124.1	0.08	0.88	43.13	13	927	265	96	0.42	0.0	4.505	0.168	0	0	0	227
PL.3833	PL.3790	ABC	#4/0 ACSR	7.44Y	124.1	0.05	0.94	43.13	13	927	264	96	0.29	0.0	4.623	0.118	0	0	0	227
PL.3520	PL.3833	ABC	#4/0 ACSR	7.44Y	124.0	0.08	1.02	42.96	13	923	262	96	0.44	0.0	4.800	0.177	0	0	0	225
PL.3791	PL.3520	ABC	#4/0 ACSR	7.43Y	123.9	0.09	1.10	42.96	13	922	262	96	0.46	0.0	4.987	0.187	0	0	0	225
PL.3779	PL.3791	ABC	#4/0 ACSR	7.43Y	123.8	0.10	1.21	42.96	13	922	261	96	0.55	0.1	5.212	0.225	0	0	0	225
PL.4003	PL.3779	C	#2 ACSR	7.43Y	123.8	0.00	1.21	0.34	0	2	1	89	0.00	0.0	5.216	0.005	0	0	0	2
PD.447	PL.4003	C	40QA	7.43Y	123.8	0.00	1.21	0.34	1	2	1	89	0.00	0.0	5.216	0.005	0	0	0	2
PL.4004	PD.447	C	#2 ACSR	7.43Y	123.8	0.00	1.21	0.34	0	2	1	89	0.00	0.0	5.239	0.022	2	1	2	2
PL.4040	PL.3779	B	6 A (CWC)	7.42Y	123.6	0.16	1.37	32.59	23	233	65	96	0.28	0.1	5.321	0.110	0	0	0	62
PD.488	PL.4040	B	70L	7.42Y	123.6	0.00	1.37	32.59	47	233	65	96	0.00	0.0	5.321	0.110	0	0	0	62
PL.4041	PD.488	B	6 A (CWC)	7.40Y	123.4	0.24	1.61	32.59	23	233	65	96	0.42	0.2	5.483	0.162	0	0	0	62
PL.3890	PL.4041	B	6 A (CWC)	7.40Y	123.3	0.06	1.67	32.59	23	232	65	96	0.10	0.0	5.522	0.040	3	1	1	62
PL.3891	PL.3890	B	6 A (CWC)	7.39Y	123.2	0.11	1.78	32.14	23	229	64	96	0.18	0.1	5.594	0.072	0	0	0	61
PL.3892	PL.3891	B	6 A (CWC)	7.39Y	123.2	0.03	1.80	32.14	23	229	64	96	0.04	0.0	5.612	0.018	7	2	2	61

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3664	PL.3892	B	6 A (CWC)	7.39Y	123.2	0.00	1.80	1.79	1	13	4	96	0.00	0.0	5.664	0.052	13	4	2	2
PL.3665	PL.3892	B	6 A (CWC)	7.38Y	123.0	0.22	2.02	29.37	21	209	58	96	0.34	0.2	5.772	0.160	0	0	0	57
PL.3893	PL.3665	B	6 A (CWC)	7.38Y	123.0	0.01	2.03	4.92	4	35	10	96	0.00	0.0	5.815	0.043	6	2	1	9
PL.3894	PL.3893	B	6 A (CWC)	7.38Y	123.0	0.02	2.04	4.04	3	29	8	96	0.00	0.0	5.910	0.096	0	0	0	8
PL.3671	PL.3894	B	6 A (CWC)	7.38Y	122.9	0.01	2.05	3.64	3	26	7	97	0.00	0.0	5.976	0.066	19	5	5	7
PL.3673	PL.3671	B	#1/0 ACSR	7.38Y	122.9	0.00	2.05	0.93	0	7	2	96	0.00	0.0	6.002	0.026	7	2	2	2
PL.3672	PL.3894	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.40	0	3	1	95	0.00	0.0	5.981	0.070	3	1	1	1
PL.3670	PL.3665	B	6 A (CWC)	7.37Y	122.8	0.15	2.17	24.45	17	174	48	96	0.20	0.1	5.907	0.135	0	0	0	48
PL.3674	PL.3670	B	6 A (CWC)	7.37Y	122.8	0.02	2.19	4.50	3	32	9	96	0.00	0.0	5.994	0.087	5	1	1	9
PL.3675	PL.3674	B	6 A (CWC)	7.37Y	122.8	0.00	2.19	0.52	0	4	1	97	0.00	0.0	6.002	0.008	0	0	0	1
PL.3677	PL.3675	B	6 A (CWC)	7.37Y	122.8	0.00	2.19	0.52	0	4	1	97	0.00	0.0	6.064	0.062	4	1	1	1
PL.3676	PL.3674	B	#2 ACSR	7.37Y	122.8	0.00	2.19	3.27	2	23	6	97	0.00	0.0	6.019	0.024	17	5	5	7
PL.3678	PL.3676	B	#1/0 ACSR	7.37Y	122.8	0.00	2.19	0.91	0	6	2	95	0.00	0.0	6.068	0.049	6	2	2	2
PL.3679	PL.3670	B	6 A (CWC)	7.36Y	122.7	0.10	2.27	19.95	14	142	39	96	0.11	0.1	6.022	0.115	0	0	0	39
PL.3901	PL.3679	B	6 A (CWC)	7.36Y	122.6	0.11	2.38	19.95	14	142	39	96	0.11	0.1	6.142	0.120	2	1	1	39
PL.3902	PL.3901	B	6 A (CWC)	7.36Y	122.6	0.02	2.40	19.65	14	139	39	96	0.02	0.0	6.167	0.024	1	0	1	38
PL.3680	PL.3902	B	6 A (CWC)	7.35Y	122.6	0.03	2.43	6.51	5	46	13	96	0.01	0.0	6.283	0.116	20	5	4	14
PL.3704	PL.3680	B	#2 ACSR	7.35Y	122.6	0.00	2.43	0.86	0	6	2	95	0.00	0.0	6.306	0.022	6	2	4	4
PL.3705	PL.3680	B	#4 ACSR	7.35Y	122.6	0.00	2.43	1.08	1	8	2	97	0.00	0.0	6.360	0.077	8	2	3	3
PL.3706	PL.3705	B	#4 ACSR	7.35Y	122.6	0.00	2.43	0.00	0	0	0	100	0.00	0.0	6.396	0.037	0	0	0	0
PL.3903	PL.3680	B	6 A (CWC)	7.35Y	122.6	0.00	2.44	1.77	1	13	3	97	0.00	0.0	6.343	0.060	5	1	1	3
PL.3904	PL.3903	B	6 A (CWC)	7.35Y	122.6	0.00	2.44	1.02	1	7	2	96	0.00	0.0	6.378	0.035	0	0	0	2
PL.3707	PL.3904	B	6 A (CWC)	7.35Y	122.6	0.00	2.44	0.68	0	5	1	98	0.00	0.0	6.516	0.138	5	1	1	1
PL.3708	PL.3904	B	#2 ACSR	7.35Y	122.6	0.00	2.44	0.34	0	2	1	89	0.00	0.0	6.407	0.029	2	1	1	1
PL.3846	PL.3902	B	6 A (CWC)	7.35Y	122.6	0.04	2.44	12.97	9	92	25	97	0.03	0.0	6.235	0.068	5	1	2	23
PL.3682	PL.3846	B	#4 ACSR	7.35Y	122.6	0.00	2.45	1.05	1	7	2	96	0.00	0.0	6.289	0.054	2	1	2	3
PL.3683	PL.3682	B	#4 ACSR	7.35Y	122.6	0.00	2.45	0.70	1	5	1	98	0.00	0.0	6.332	0.043	5	1	1	1
PL.3681	PL.3846	B	6 A (CWC)	7.35Y	122.5	0.04	2.49	11.21	8	79	22	96	0.02	0.0	6.324	0.089	9	3	3	18
PL.3685	PL.3681	B	6 A (CWC)	7.35Y	122.5	0.04	2.53	9.89	7	70	19	97	0.02	0.0	6.410	0.085	0	0	0	15
PL.3686	PL.3685	B	6 A (CWC)	7.35Y	122.5	0.01	2.53	9.89	7	70	19	97	0.00	0.0	6.429	0.019	0	0	0	15
PL.3899	PL.3686	B	6 A (CWC)	7.35Y	122.5	0.00	2.54	2.27	2	16	4	97	0.00	0.0	6.468	0.039	0	0	1	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3900	PL.3899	B	6 A (CWC)	7.35Y	122.4	0.01	2.55	2.20	2	16	4	97	0.00	0.0	6.606	0.138	0	0	0	4
PL.3898	PL.3900	B	6 A (CWC)	7.35Y	122.4	0.01	2.56	2.20	2	16	4	97	0.00	0.0	6.709	0.103	7	2	2	4
PL.3897	PL.3898	B	6 A (CWC)	7.35Y	122.4	0.00	2.56	1.26	1	9	2	98	0.00	0.0	6.810	0.101	7	2	1	2
PL.3710	PL.3897	B	#4 ACSR	7.35Y	122.4	0.00	2.56	0.29	0	2	1	89	0.00	0.0	6.864	0.054	2	1	1	1
PL.3687	PL.3686	B	#2 ACSR	7.35Y	122.4	0.03	2.56	7.62	4	54	15	96	0.01	0.0	6.535	0.106	0	0	0	10
PL.3709	PL.3687	B	6 A (CWC)	7.34Y	122.4	0.06	2.62	7.62	5	54	15	96	0.02	0.0	6.695	0.161	0	0	0	10
PL.3689	PL.3709	B	6 A (CWC)	7.34Y	122.4	0.01	2.63	2.54	2	18	5	96	0.00	0.0	6.786	0.090	0	0	0	4
PL.3694	PL.3689	B	6 A (CWC)	7.34Y	122.4	0.02	2.64	2.54	2	18	5	96	0.00	0.0	6.936	0.150	0	0	0	4
PL.3793	PL.3694	B	6 A (CWC)	7.34Y	122.3	0.01	2.65	2.54	2	18	5	96	0.00	0.0	7.007	0.071	0	0	0	4
PL.3695	PL.3793	B	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	7.048	0.042	0	0	0	0
PL.2273	PL.3695	B	6 A (CWC)	7.34Y	122.3	0.00	2.65	0.00	0	0	0	100	0.00	0.0	7.053	0.005	0	0	0	0
PL.3703	PL.3793	B	6 A (CWC)	7.34Y	122.3	0.01	2.67	2.54	2	18	5	96	0.00	0.0	7.120	0.114	0	0	0	4
PL.3701	PL.3703	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	1.99	1	14	4	96	0.00	0.0	7.174	0.054	11	3	1	3
PL.3699	PL.3701	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.49	0	3	1	95	0.00	0.0	7.206	0.033	0	0	0	2
PL.3697	PL.3699	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.19	0	1	0	100	0.00	0.0	7.259	0.052	1	0	1	1
PL.3700	PL.3699	B	#4 ACSR	7.34Y	122.3	0.00	2.67	0.30	0	2	1	89	0.00	0.0	7.219	0.013	0	0	0	1
PL.3698	PL.3700	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.30	0	2	1	89	0.00	0.0	7.253	0.034	2	1	1	1
PL.3702	PL.3703	B	#4 ACSR	7.34Y	122.3	0.00	2.67	0.56	0	4	1	97	0.00	0.0	7.188	0.067	4	1	1	1
PL.3690	PL.3709	B	#1/0 ACSR	7.34Y	122.4	0.01	2.62	5.07	2	36	10	96	0.00	0.0	6.766	0.070	0	0	0	6
PL.3522	PL.3690	B	#1/0 ACSR	7.34Y	122.4	0.00	2.63	2.72	1	19	5	97	0.00	0.0	6.835	0.069	10	3	1	3
PL.3711	PL.3522	B	#4 ACSR	7.34Y	122.4	0.00	2.63	1.30	1	9	3	95	0.00	0.0	6.872	0.037	3	1	1	2
PL.3693	PL.3711	B	#4 ACSR	7.34Y	122.4	0.00	2.63	0.83	1	6	2	95	0.00	0.0	6.884	0.012	6	2	1	1
PL.3691	PL.3690	B	#4 ACSR	7.34Y	122.4	0.00	2.63	2.35	2	17	5	96	0.00	0.0	6.830	0.064	17	5	3	3
PL.3684	PL.3681	B	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.00	0	0	0	100	0.00	0.0	6.441	0.117	0	0	0	0
PL.3835	PL.3684	B	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.00	0	0	0	100	0.00	0.0	6.501	0.059	0	0	0	0
PL.3669	PL.3779	ABC	#4/0 ACSR	7.43Y	123.8	0.02	1.22	31.98	9	686	194	96	0.06	0.0	5.256	0.045	16	4	4	161
PL.3713	PL.3669	A	6 A (CWC)	7.43Y	123.8	0.00	1.22	0.46	0	3	1	95	0.00	0.0	5.309	0.053	0	0	0	2
PL.4020	PL.3713	A	6 A (CWC)	7.43Y	123.8	0.00	1.22	0.46	0	3	1	95	0.00	0.0	5.314	0.005	0	0	0	2
PD.479	PL.4020	A	40QA	7.43Y	123.8	0.00	1.22	0.46	1	3	1	95	0.00	0.0	5.314	0.005	0	0	0	2
PL.4021	PD.479	A	6 A (CWC)	7.43Y	123.8	0.00	1.22	0.46	0	3	1	95	0.00	0.0	5.356	0.042	3	1	2	2
PL.4022	PL.3669	A	6 A (CWC)	7.43Y	123.8	0.00	1.22	2.66	2	19	5	97	0.00	0.0	5.261	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.480	PL.4022	A	40QA	7.43Y	123.8	0.00	1.22	2.66	7	19	5	97	0.00	0.0	5.261	0.005	0	0	0	2
PL.4023	PD.480	A	6 A (CWC)	7.43Y	123.8	0.00	1.23	2.66	2	19	5	97	0.00	0.0	5.289	0.028	19	5	2	2
PL.3714	PL.3669	ABC	#4/0 ACSR	7.42Y	123.7	0.03	1.26	30.20	9	647	184	96	0.12	0.0	5.358	0.101	13	4	2	153
PL.3847	PL.3714	ABC	#4/0 ACSR	7.42Y	123.7	0.04	1.29	29.57	9	634	180	96	0.13	0.0	5.472	0.115	10	3	1	151
PL.3848	PL.3847	ABC	#4/0 ACSR	7.42Y	123.7	0.03	1.32	28.89	8	619	175	96	0.09	0.0	5.556	0.083	0	0	0	149
PL.3523	PL.3848	ABC	#4/0 ACSR	7.42Y	123.6	0.06	1.38	27.28	8	584	166	96	0.20	0.0	5.757	0.201	0	0	0	143
PL.3794	PL.3523	ABC	#4/0 ACSR	7.42Y	123.6	0.04	1.42	27.28	8	584	165	96	0.14	0.0	5.899	0.142	0	0	0	143
PL.3721	PL.3794	ABC	#4/0 ACSR	7.41Y	123.5	0.05	1.47	27.27	8	584	165	96	0.17	0.0	6.068	0.169	0	0	0	142
PL.4014	PL.3721	A	6 A (CWC)	7.41Y	123.5	0.00	1.47	0.20	0	1	0	100	0.00	0.0	6.073	0.005	0	0	0	1
PD.476	PL.4014	A	40QA	7.41Y	123.5	0.00	1.47	0.20	0	1	0	100	0.00	0.0	6.073	0.005	0	0	0	1
PL.4015	PD.476	A	6 A (CWC)	7.41Y	123.5	0.00	1.47	0.20	0	1	0	100	0.00	0.0	6.110	0.037	1	0	1	1
PL.3722	PL.3721	ABC	#4/0 ACSR	7.41Y	123.5	0.06	1.53	27.20	8	582	164	96	0.21	0.0	6.278	0.210	0	0	0	141
PL.3723	PL.3722	ABC	#4/0 ACSR	7.40Y	123.4	0.07	1.59	26.99	8	577	163	96	0.23	0.0	6.516	0.238	0	0	0	140
PL.3726	PL.3723	ABC	#4/0 ACSR	7.40Y	123.4	0.04	1.63	24.84	7	531	150	96	0.12	0.0	6.668	0.151	0	0	0	129
PL.4047	PL.3726	ABC	#4/0 ACSR	7.40Y	123.4	0.01	1.64	24.84	7	531	149	96	0.02	0.0	6.697	0.030	8	2	2	129
PL.3851	PL.4047	ABC	#4/0 ACSR	7.40Y	123.3	0.03	1.67	24.49	7	523	147	96	0.09	0.0	6.816	0.119	8	2	1	127
PL.3852	PL.3851	ABC	#4/0 ACSR	7.40Y	123.3	0.03	1.70	23.91	7	511	144	96	0.08	0.0	6.923	0.107	3	1	1	122
PL.3796	PL.3852	ABC	#1/0 ACSR	7.39Y	123.2	0.11	1.81	23.78	10	508	143	96	0.40	0.1	7.187	0.264	0	0	0	121
PL.3510	PL.3796	C	6 A (CWC)	7.39Y	123.2	0.00	1.81	0.49	0	3	1	95	0.00	0.0	7.192	0.005	0	0	0	3
PD.471	PL.3510	C	40QA	7.39Y	123.2	0.00	1.81	0.49	1	3	1	95	0.00	0.0	7.192	0.005	0	0	0	3
PL.3511	PD.471	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	0.49	0	3	1	95	0.00	0.0	7.282	0.091	3	1	3	3
PL.10580	PL.3796	ABC	#1/0 ACSR	7.39Y	123.1	0.05	1.86	23.62	10	504	141	96	0.16	0.0	7.294	0.107	0	0	0	118
PD.1910	PL.10580	ABC	70L	7.39Y	123.1	0.00	1.86	23.62	34	504	141	96	0.00	0.0	7.294	0.107	0	0	0	118
PL.10581	PD.1910	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.86	23.62	10	504	141	96	0.00	0.0	7.296	0.002	0	0	0	118
PL.4032	PL.10581	B	6 A (CWC)	7.39Y	123.1	0.00	1.86	0.78	1	6	2	95	0.00	0.0	7.300	0.004	0	0	0	1
PD.484	PL.4032	B	40QA	7.39Y	123.1	0.00	1.86	0.78	2	6	2	95	0.00	0.0	7.300	0.004	0	0	0	1
PL.4033	PD.484	B	6 A (CWC)	7.39Y	123.1	0.00	1.86	0.78	1	6	2	95	0.00	0.0	7.342	0.042	6	2	1	1
PL.3733	PL.4033	B	#4/0 ACSR	7.39Y	123.1	0.00	1.86	0.00	0	0	0	100	0.00	0.0	7.424	0.082	0	0	0	0
PL.4034	PL.10581	B	6 A (CWC)	7.39Y	123.1	0.00	1.86	0.63	0	5	1	98	0.00	0.0	7.300	0.005	0	0	0	3
PD.485	PL.4034	B	15T	7.39Y	123.1	0.00	1.86	0.63	0	5	1	98	0.00	0.0	7.300	0.005	0	0	0	3
PL.4035	PD.485	B	6 A (CWC)	7.39Y	123.1	0.00	1.86	0.63	0	5	1	98	0.00	0.0	7.405	0.105	5	1	3	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3732	PL.10581	ABC	#1/0 ACSR	7.39Y	123.1	0.05	1.91	23.15	10	494	138	96	0.16	0.0	7.405	0.110	0	0	0	114
PL.3525	PL.3732	ABC	#1/0 ACSR	7.38Y	123.1	0.04	1.95	21.72	9	463	130	96	0.13	0.0	7.512	0.106	1	0	1	107
PL.3735	PL.3525	ABC	#1/0 ACSR	7.38Y	123.0	0.07	2.02	21.65	9	462	129	96	0.23	0.1	7.699	0.188	0	0	0	106
PL.3983	PL.3735	ABC	#1/0 ACSR	7.38Y	122.9	0.05	2.08	21.65	9	462	129	96	0.17	0.0	7.837	0.138	3	1	5	106
PL.3985	PL.3983	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.10	21.53	9	459	128	96	0.08	0.0	7.905	0.068	2	0	1	101
PL.3986	PL.3985	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.13	21.46	9	457	128	96	0.10	0.0	7.989	0.085	8	2	2	100
PL.3984	PL.3986	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.16	21.08	9	449	125	96	0.07	0.0	8.046	0.057	0	0	0	98
PL.3506	PL.3984	A	#2 ACSR	7.37Y	122.8	0.00	2.16	0.90	1	6	2	95	0.00	0.0	8.051	0.004	0	0	0	1
PD.469	PL.3506	A	15T	7.37Y	122.8	0.00	2.16	0.90	0	6	2	95	0.00	0.0	8.051	0.004	0	0	0	1
PL.3507	PD.469	A	#2 ACSR	7.37Y	122.8	0.00	2.16	0.90	1	6	2	95	0.00	0.0	8.078	0.027	6	2	1	1
PL.3526	PL.3984	ABC	#1/0 ACSR	7.37Y	122.8	0.07	2.23	20.78	9	443	124	96	0.22	0.0	8.237	0.191	9	3	1	97
PL.3980	PL.3526	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.25	20.34	9	433	121	96	0.07	0.0	8.299	0.062	0	0	0	96
PL.3981	PL.3980	ABC	#1/0 ACSR	7.36Y	122.7	0.03	2.28	20.08	9	427	119	96	0.09	0.0	8.388	0.089	10	3	3	95
PL.3982	PL.3981	ABC	#1/0 ACSR	7.36Y	122.7	0.02	2.30	19.59	9	417	116	96	0.06	0.0	8.450	0.062	10	3	2	92
PL.4050	PL.3982	ABC	#1/0 ACSR	7.36Y	122.7	0.01	2.32	19.14	8	407	113	96	0.04	0.0	8.486	0.036	0	0	0	90
PL.4051	PL.4050	ABC	#1/0 ACSR	7.36Y	122.7	0.03	2.35	19.14	8	407	113	96	0.09	0.0	8.577	0.091	0	0	0	90
PL.3502	PL.4051	C	#2 ACSR	7.36Y	122.7	0.00	2.35	6.53	4	46	13	96	0.00	0.0	8.581	0.004	0	0	0	9
PD.467	PL.3502	C	40QA	7.36Y	122.7	0.00	2.35	6.53	16	46	13	96	0.00	0.0	8.581	0.004	0	0	0	9
PL.3503	PD.467	C	#2 ACSR	7.36Y	122.6	0.00	2.35	6.53	4	46	13	96	0.00	0.0	8.594	0.013	0	0	0	9
PL.3736	PL.3503	C	#2 ACSR	7.36Y	122.6	0.00	2.35	6.53	4	46	13	96	0.00	0.0	8.630	0.036	46	13	9	9
PL.3527	PL.4051	ABC	#1/0 ACSR	7.36Y	122.6	0.04	2.38	16.96	7	361	101	96	0.09	0.0	8.700	0.123	0	0	0	81
PL.3528	PL.3527	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.40	9.58	4	204	56	96	0.02	0.0	8.785	0.085	0	0	0	42
PL.3533	PL.3528	ABC	#1/0 ACSR	7.35Y	122.6	0.03	2.43	8.44	4	179	50	96	0.04	0.0	8.980	0.195	0	0	0	38
PL.3816	PL.3533	ABC	#1/0 ACSR	7.35Y	122.5	0.02	2.45	8.44	4	179	50	96	0.03	0.0	9.133	0.153	0	0	0	38
PL.3754	PL.3816	ABC	#1/0 ACSR	7.35Y	122.5	0.04	2.49	8.44	4	179	50	96	0.04	0.0	9.363	0.230	0	0	0	38
PL.3534	PL.3754	ABC	#1/0 ACSR	7.35Y	122.5	0.02	2.51	8.20	4	174	48	96	0.02	0.0	9.490	0.127	0	0	0	36
PL.3949	PL.3534	ABC	#3/0 ACSR	7.35Y	122.5	0.00	2.51	2.59	1	55	15	96	0.00	0.0	9.569	0.079	0	0	0	16
PL.3950	PL.3949	ABC	#3/0 ACSR	7.35Y	122.5	0.01	2.51	2.59	1	55	15	96	0.00	0.0	9.751	0.182	0	0	0	16
PL.3845	PL.3950	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.52	2.59	1	55	15	96	0.00	0.0	9.890	0.140	0	0	0	16
PL.3823	PL.3845	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.53	2.59	1	55	15	96	0.00	0.0	10.023	0.133	0	0	0	16
PL.3494	PL.3823	B	6 A (CWC)	7.35Y	122.4	0.03	2.56	7.78	6	55	15	96	0.01	0.0	10.120	0.096	0	0	0	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.463	PL.3494	B	40QA	7.35Y	122.4	0.00	2.56	7.78	19	55	15	96	0.00	0.0	10.120	0.096	0	0	0	16
PL.3495	PD.463	B	6 A (CWC)	7.34Y	122.4	0.06	2.62	7.78	6	55	15	96	0.03	0.0	10.297	0.177	0	0	0	16
PL.3757	PL.3495	B	6 A (CWC)	7.34Y	122.4	0.00	2.63	2.06	1	15	4	97	0.00	0.0	10.360	0.063	7	2	2	3
PL.3760	PL.3757	B	6 A (CWC)	7.34Y	122.4	0.00	2.63	1.03	1	7	2	96	0.00	0.0	10.458	0.098	7	2	1	1
PL.32697	PL.3495	B	6 A (CWC)	7.34Y	122.4	0.02	2.65	5.71	4	40	11	96	0.01	0.0	10.394	0.097	3	1	1	13
PL.32696	PL.32697	B	6 A (CWC)	7.34Y	122.3	0.01	2.65	5.24	4	37	10	97	0.00	0.0	10.415	0.022	2	0	1	12
PL.3938	PL.32696	B	6 A (CWC)	7.34Y	122.3	0.02	2.68	5.03	4	36	10	96	0.01	0.0	10.518	0.102	4	1	4	11
PL.3936	PL.3938	B	6 A (CWC)	7.34Y	122.3	0.01	2.69	4.51	3	32	9	96	0.00	0.0	10.573	0.055	3	1	2	7
PL.3935	PL.3936	B	6 A (CWC)	7.34Y	122.3	0.01	2.70	4.08	3	29	8	96	0.00	0.0	10.631	0.058	0	0	0	5
PL.3933	PL.3935	B	6 A (CWC)	7.34Y	122.3	0.01	2.70	3.49	2	25	7	96	0.00	0.0	10.680	0.049	6	2	1	4
PL.3934	PL.3933	B	6 A (CWC)	7.34Y	122.3	0.01	2.71	2.62	2	19	5	97	0.00	0.0	10.795	0.115	11	3	1	3
PL.3932	PL.3934	B	6 A (CWC)	7.34Y	122.3	0.00	2.72	1.05	1	7	2	96	0.00	0.0	10.882	0.087	1	0	1	2
PL.3775	PL.3932	B	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	10.944	0.062	0	0	0	0
PL.3774	PL.3932	B	#2 ACSR	7.34Y	122.3	0.00	2.72	0.85	0	6	2	95	0.00	0.0	10.973	0.091	0	0	0	1
PL.3536	PL.3774	B	#2 ACSR	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	11.095	0.122	0	0	0	0
PL.3776	PL.3774	B	#4 ACSR	7.34Y	122.3	0.00	2.72	0.85	1	6	2	95	0.00	0.0	10.993	0.020	6	2	1	1
PL.3773	PL.3935	B	6 A (CWC)	7.34Y	122.3	0.00	2.70	0.59	0	4	1	97	0.00	0.0	10.701	0.070	4	1	1	1
PL.3764	PL.3534	B	6 A (CWC)	7.35Y	122.5	0.04	2.54	16.83	12	119	33	96	0.03	0.0	9.539	0.049	14	4	3	20
PL.3766	PL.3764	B	6 A (CWC)	7.35Y	122.5	0.00	2.54	14.89	11	105	29	96	0.00	0.0	9.544	0.005	0	0	0	17
PD.462	PL.3766	B	20T	7.35Y	122.5	0.00	2.54	14.89	0	105	29	96	0.00	0.0	9.544	0.005	0	0	0	17
PL.3856	PD.462	B	6 A (CWC)	7.35Y	122.5	0.00	2.55	0.97	1	7	2	96	0.00	0.0	9.559	0.015	0	0	0	1
PL.3765	PL.3856	B	6 A (CWC)	7.35Y	122.5	0.00	2.55	0.97	1	7	2	96	0.00	0.0	9.570	0.010	7	2	1	1
PL.3535	PD.462	B	6 A (CWC)	7.35Y	122.4	0.03	2.58	13.92	10	99	27	96	0.02	0.0	9.597	0.053	8	2	1	16
PL.3767	PL.3535	B	6 A (CWC)	7.34Y	122.4	0.02	2.60	12.79	9	91	25	96	0.02	0.0	9.643	0.046	16	4	2	15
PL.3941	PL.3767	B	6 A (CWC)	7.34Y	122.4	0.03	2.64	9.40	7	67	18	97	0.02	0.0	9.722	0.079	0	0	1	12
PL.3947	PL.3941	B	6 A (CWC)	7.34Y	122.4	0.01	2.65	9.36	7	66	18	96	0.01	0.0	9.750	0.028	9	3	1	11
PL.3948	PL.3947	B	6 A (CWC)	7.34Y	122.3	0.01	2.66	8.03	6	57	16	96	0.00	0.0	9.790	0.040	19	5	2	10
PL.3770	PL.3948	B	6 A (CWC)	7.34Y	122.3	0.02	2.68	4.48	3	32	9	96	0.01	0.0	9.902	0.112	0	0	0	6
PL.3771	PL.3770	B	#4 ACSR	7.34Y	122.3	0.00	2.68	0.68	1	5	1	98	0.00	0.0	9.937	0.035	5	1	1	1
PL.3944	PL.3770	B	6 A (CWC)	7.34Y	122.3	0.01	2.69	3.80	3	27	7	97	0.00	0.0	9.967	0.064	3	1	1	5
PL.3945	PL.3944	B	6 A (CWC)	7.34Y	122.3	0.00	2.70	3.35	2	24	7	96	0.00	0.0	10.008	0.041	12	3	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3946	PL.3945	B	6 A (CWC)	7.34Y	122.3	0.00	2.70	1.71	1	12	3	97	0.00	0.0	10.085	0.077	6	2	1	3
PL.3942	PL.3946	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	0.93	1	7	2	96	0.00	0.0	10.171	0.086	2	0	1	2
PL.3943	PL.3942	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	0.69	0	5	1	98	0.00	0.0	10.319	0.148	0	0	0	1
PL.3821	PL.3943	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	0.69	0	5	1	98	0.00	0.0	10.442	0.123	5	1	1	1
PL.3769	PL.3948	B	#2 ACSR	7.34Y	122.3	0.00	2.66	0.85	0	6	2	95	0.00	0.0	9.830	0.039	1	0	1	2
PL.3772	PL.3769	B	#1/0 ACSR	7.34Y	122.3	0.00	2.66	0.70	0	5	1	98	0.00	0.0	9.976	0.147	0	0	0	1
PL.3818	PL.3772	B	#1/0 ACSR	7.34Y	122.3	0.00	2.66	0.70	0	5	1	98	0.00	0.0	10.095	0.119	0	0	0	1
PL.3819	PL.3818	B	#1/0 ACSR	7.34Y	122.3	0.00	2.66	0.70	0	5	1	98	0.00	0.0	10.180	0.084	5	1	1	1
PL.3768	PL.3767	B	#4 ACSR	7.34Y	122.4	0.00	2.60	1.10	1	8	2	97	0.00	0.0	9.684	0.041	8	2	1	1
PL.3496	PL.3754	A	#2 ACSR	7.35Y	122.5	0.00	2.49	0.70	0	5	1	98	0.00	0.0	9.368	0.005	0	0	0	2
PD.464	PL.3496	A	40QA	7.35Y	122.5	0.00	2.49	0.70	2	5	1	98	0.00	0.0	9.368	0.005	0	0	0	2
PL.3497	PD.464	A	#2 ACSR	7.35Y	122.5	0.00	2.49	0.70	0	5	1	98	0.00	0.0	9.408	0.040	5	1	2	2
PL.3500	PL.3528	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	3.43	2	24	7	96	0.00	0.0	8.790	0.005	0	0	0	4
PD.466	PL.3500	C	40QA	7.36Y	122.6	0.00	2.40	3.43	9	24	7	96	0.00	0.0	8.790	0.005	0	0	0	4
PL.3501	PD.466	C	6 A (CWC)	7.36Y	122.6	0.01	2.40	3.43	2	24	7	96	0.00	0.0	8.858	0.069	24	7	4	4
PL.4044	PL.3527	A	#1/0 ACSR	7.36Y	122.6	0.00	2.39	22.15	10	157	44	96	0.00	0.0	8.702	0.003	0	0	0	39
PL.10582	PL.4044	A	#1/0 ACSR	7.36Y	122.6	0.01	2.40	22.15	10	157	44	96	0.01	0.0	8.721	0.019	0	0	0	39
PD.1911	PL.10582	A	100CodeSMo	7.36Y	122.6	0.00	2.40	22.15	0	157	44	96	0.00	0.0	8.721	0.019	0	0	0	39
PL.10583	PD.1911	A	#1/0 ACSR	7.35Y	122.5	0.10	2.49	22.15	10	157	44	96	0.10	0.1	8.910	0.189	0	0	0	39
PL.3953	PL.10583	A	#1/0 ACSR	7.35Y	122.4	0.06	2.55	22.15	10	157	44	96	0.06	0.0	9.031	0.121	4	1	2	39
PL.3738	PL.3953	A	#1/0 ACSR	7.34Y	122.3	0.11	2.67	21.55	9	152	43	96	0.11	0.1	9.257	0.226	0	0	0	37
PL.3803	PL.3738	A	#1/0 ACSR	7.33Y	122.2	0.11	2.77	21.55	9	152	42	96	0.11	0.1	9.469	0.212	0	0	0	37
PL.3971	PL.3803	A	#1/0 ACSR	7.33Y	122.2	0.04	2.81	21.55	9	152	42	96	0.04	0.0	9.553	0.084	4	1	1	37
PL.3972	PL.3971	A	#1/0 ACSR	7.33Y	122.1	0.04	2.86	20.99	9	148	41	96	0.04	0.0	9.640	0.087	0	0	0	36
PL.3966	PL.3972	A	#1/0 ACSR	7.33Y	122.1	0.01	2.87	5.65	2	40	11	96	0.00	0.0	9.726	0.086	3	1	1	8
PL.3967	PL.3966	A	#1/0 ACSR	7.33Y	122.1	0.01	2.88	5.21	2	37	10	97	0.00	0.0	9.820	0.094	0	0	0	7
PL.3965	PL.3967	A	#1/0 ACSR	7.33Y	122.1	0.01	2.89	5.21	2	37	10	97	0.00	0.0	9.928	0.108	2	1	1	7
PL.3964	PL.3965	A	#1/0 ACSR	7.33Y	122.1	0.01	2.90	4.91	2	35	10	96	0.00	0.0	10.019	0.090	2	0	1	6
PL.3739	PL.3964	A	#4 ACSR	7.33Y	122.1	0.00	2.90	0.31	0	2	1	89	0.00	0.0	10.073	0.054	2	1	1	1
PL.3962	PL.3964	A	#1/0 ACSR	7.33Y	122.1	0.01	2.91	4.36	2	31	9	96	0.00	0.0	10.114	0.096	0	0	0	4
PL.3963	PL.3962	A	#1/0 ACSR	7.33Y	122.1	0.01	2.92	4.36	2	31	9	96	0.00	0.0	10.164	0.050	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3741	PL.3963	A	6 A (CWC)	7.33Y	122.1	0.00	2.92	0.18	0	1	0	100	0.00	0.0	10.197	0.033	0	0	0	2
PL.3742	PL.3741	A	6 A (CWC)	7.33Y	122.1	0.00	2.92	0.18	0	1	0	100	0.00	0.0	10.234	0.037	1	0	2	2
PL.3740	PL.3963	A	#1/0 ACSR	7.32Y	122.1	0.01	2.93	4.17	2	29	8	96	0.00	0.0	10.315	0.151	0	0	0	2
PL.3498	PL.3740	A	#1/0 ACSR	7.32Y	122.1	0.00	2.93	3.90	2	28	8	96	0.00	0.0	10.320	0.005	0	0	0	1
PD.465	PL.3498	A	40QA	7.32Y	122.1	0.00	2.93	3.90	10	28	8	96	0.00	0.0	10.320	0.005	0	0	0	1
PL.3743	PD.465	A	#1/0 ACSR	7.32Y	122.1	0.02	2.95	3.90	2	28	8	96	0.00	0.0	10.502	0.182	0	0	0	1
PL.3805	PL.3743	A	#1/0 ACSR	7.32Y	122.0	0.01	2.96	3.90	2	28	8	96	0.00	0.0	10.621	0.119	0	0	0	1
PL.3806	PL.3805	A	#1/0 ACSR	7.32Y	122.0	0.01	2.97	3.90	2	28	8	96	0.00	0.0	10.743	0.122	0	0	0	1
PL.3807	PL.3806	A	#1/0 ACSR	7.32Y	122.0	0.01	2.97	3.90	2	28	8	96	0.00	0.0	10.865	0.122	28	8	1	1
PL.3529	PL.3740	A	#1/0 ACSR	7.32Y	122.1	0.00	2.93	0.27	0	2	1	89	0.00	0.0	10.480	0.165	2	1	1	1
PL.3968	PL.3972	A	#1/0 ACSR	7.33Y	122.1	0.02	2.87	15.34	7	108	30	96	0.01	0.0	9.688	0.048	4	1	3	28
PL.3969	PL.3968	A	#1/0 ACSR	7.33Y	122.1	0.02	2.90	14.75	6	104	29	96	0.02	0.0	9.757	0.069	5	1	2	25
PL.3960	PL.3969	A	#1/0 ACSR	7.32Y	122.0	0.06	2.96	14.05	6	99	28	96	0.04	0.0	9.946	0.190	0	0	0	23
PL.3961	PL.3960	A	#1/0 ACSR	7.32Y	122.0	0.05	3.01	14.05	6	99	28	96	0.03	0.0	10.097	0.151	0	0	0	23
PL.3744	PL.3961	A	#4 ACSR	7.32Y	122.0	0.00	3.01	1.38	1	10	3	96	0.00	0.0	10.137	0.039	10	3	1	1
PL.3530	PL.3961	A	#1/0 ACSR	7.32Y	122.0	0.04	3.04	12.67	6	89	25	96	0.02	0.0	10.227	0.130	4	1	2	22
PL.3745	PL.3530	A	#1/0 ACSR	7.32Y	121.9	0.03	3.07	12.10	5	85	24	96	0.01	0.0	10.318	0.091	0	0	0	20
PL.3492	PL.3745	A	6 A (CWC)	7.32Y	121.9	0.00	3.07	9.42	7	66	18	96	0.00	0.0	10.323	0.004	0	0	0	15
PD.461	PL.3492	A	25T	7.32Y	121.9	0.00	3.07	9.42	0	66	18	96	0.00	0.0	10.323	0.004	0	0	0	15
PL.3493	PD.461	A	6 A (CWC)	7.31Y	121.9	0.03	3.10	9.42	7	66	18	96	0.02	0.0	10.397	0.074	0	0	0	15
PL.3748	PL.3493	A	6 A (CWC)	7.31Y	121.8	0.07	3.18	9.42	7	66	18	96	0.04	0.1	10.584	0.188	10	3	3	15
PL.3749	PL.3748	A	#4 ACSR	7.31Y	121.8	0.00	3.18	0.44	0	3	1	95	0.00	0.0	10.661	0.077	3	1	1	1
PL.3750	PL.3748	A	#4 ACSR	7.31Y	121.8	0.05	3.23	7.53	6	53	15	96	0.02	0.0	10.738	0.154	0	0	0	11
PL.3808	PL.3750	A	#4 ACSR	7.30Y	121.7	0.05	3.28	7.53	6	53	15	96	0.02	0.0	10.895	0.157	0	0	0	11
PL.3809	PL.3808	A	#4 ACSR	7.30Y	121.7	0.05	3.33	7.53	6	53	15	96	0.02	0.0	11.034	0.139	0	0	0	11
PL.3958	PL.3809	A	#4 ACSR	7.30Y	121.6	0.05	3.38	7.53	6	53	15	96	0.02	0.0	11.195	0.160	3	1	1	11
PL.3959	PL.3958	A	#4 ACSR	7.29Y	121.6	0.06	3.44	7.08	5	50	14	96	0.02	0.0	11.388	0.193	0	0	0	10
PL.3751	PL.3959	A	#4 ACSR	7.29Y	121.6	0.00	3.44	0.30	0	2	1	89	0.00	0.0	11.427	0.039	2	1	1	1
PL.3531	PL.3959	A	#4 ACSR	7.29Y	121.5	0.04	3.48	6.78	5	48	13	97	0.01	0.0	11.508	0.120	0	0	0	9
PL.3954	PL.3531	A	#4 ACSR	7.29Y	121.5	0.03	3.51	6.78	5	48	13	97	0.01	0.0	11.610	0.102	4	1	2	9
PL.3955	PL.3954	A	#4 ACSR	7.29Y	121.5	0.03	3.54	6.17	5	43	12	96	0.01	0.0	11.752	0.142	13	4	1	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3956	PL.3955	A	#4 ACSR	7.29Y	121.4	0.01	3.55	4.31	3	30	8	97	0.00	0.0	11.816	0.063	12	3	4	6
PL.3957	PL.3956	A	#4 ACSR	7.29Y	121.4	0.01	3.56	2.62	2	18	5	96	0.00	0.0	11.866	0.050	0	0	0	2
PL.3753	PL.3957	A	#4 ACSR	7.29Y	121.4	0.00	3.56	1.60	1	11	3	96	0.00	0.0	12.005	0.139	11	3	1	1
PL.3532	PL.3957	A	#4 ACSR	7.29Y	121.4	0.00	3.56	0.00	0	0	0	100	0.00	0.0	11.897	0.031	0	0	0	0
PL.3752	PL.3957	A	#4 ACSR	7.29Y	121.4	0.00	3.56	1.02	1	7	2	96	0.00	0.0	11.919	0.053	7	2	1	1
PL.4036	PL.3745	A	6 A (CWC)	7.32Y	121.9	0.00	3.07	2.68	2	19	5	97	0.00	0.0	10.323	0.005	0	0	0	5
PD.486	PL.4036	A	15T	7.32Y	121.9	0.00	3.07	2.68	0	19	5	97	0.00	0.0	10.323	0.005	0	0	0	5
PL.4037	PD.486	A	6 A (CWC)	7.32Y	121.9	0.01	3.08	2.68	2	19	5	97	0.00	0.0	10.416	0.093	7	2	1	5
PL.3940	PL.4037	A	6 A (CWC)	7.31Y	121.9	0.01	3.09	1.76	1	12	3	97	0.00	0.0	10.533	0.117	8	2	1	4
PL.3939	PL.3940	A	6 A (CWC)	7.31Y	121.9	0.01	3.09	0.65	0	5	1	98	0.00	0.0	10.713	0.180	0	0	0	3
PL.3842	PL.3939	A	6 A (CWC)	7.31Y	121.9	0.01	3.10	0.65	0	5	1	98	0.00	0.0	10.896	0.183	0	0	0	3
PL.3812	PL.3842	A	6 A (CWC)	7.31Y	121.9	0.00	3.10	0.65	0	5	1	98	0.00	0.0	11.008	0.112	0	0	0	3
PL.3843	PL.3812	A	6 A (CWC)	7.31Y	121.9	0.00	3.10	0.65	0	5	1	98	0.00	0.0	11.116	0.107	0	0	0	3
PL.3813	PL.3843	A	6 A (CWC)	7.31Y	121.9	0.00	3.11	0.65	0	5	1	98	0.00	0.0	11.235	0.119	2	1	1	3
PL.3746	PL.3813	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.35	0	2	1	89	0.00	0.0	11.353	0.118	0	0	0	2
PL.3814	PL.3746	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.35	0	2	1	89	0.00	0.0	11.515	0.162	0	0	1	2
PL.3747	PL.3814	A	#2 ACSR	7.31Y	121.9	0.00	3.11	0.35	0	2	1	89	0.00	0.0	11.683	0.168	2	1	1	1
CP.8	PL.4050	ABC	Cap (300)	7.36Y	122.7	0.00	2.32	0.00	0	0	0	100	0.00	0.0	8.486	0.168	0	0	0	0
PL.3504	PL.3980	A	6 A (CWC)	7.37Y	122.8	0.00	2.25	0.77	1	5	2	93	0.00	0.0	8.304	0.005	0	0	0	1
PD.468	PL.3504	A	40QA	7.37Y	122.8	0.00	2.25	0.77	2	5	2	93	0.00	0.0	8.304	0.005	0	0	0	1
PL.3505	PD.468	A	6 A (CWC)	7.36Y	122.7	0.00	2.25	0.77	1	5	2	93	0.00	0.0	8.358	0.054	5	2	1	1
PL.3734	PL.3732	C	6 A (CWC)	7.38Y	123.1	0.01	1.92	4.27	3	30	8	97	0.00	0.0	7.462	0.057	1	0	1	7
PL.3508	PL.3734	C	6 A (CWC)	7.38Y	123.1	0.00	1.92	4.13	3	29	8	96	0.00	0.0	7.466	0.005	0	0	0	6
PD.470	PL.3508	C	20T	7.38Y	123.1	0.00	1.92	4.13	0	29	8	96	0.00	0.0	7.466	0.005	0	0	0	6
PL.3509	PD.470	C	6 A (CWC)	7.38Y	123.1	0.02	1.93	4.13	3	29	8	96	0.00	0.0	7.553	0.087	0	0	0	6
PL.3987	PL.3509	C	#4 ACSR	7.38Y	123.0	0.02	1.95	4.13	3	29	8	96	0.00	0.0	7.664	0.110	0	0	0	6
PL.3988	PL.3987	C	#4 ACSR	7.38Y	123.0	0.03	1.98	4.13	3	29	8	96	0.01	0.0	7.815	0.151	0	0	0	6
PL.3797	PL.3988	C	#4 ACSR	7.38Y	123.0	0.03	2.01	4.13	3	29	8	96	0.01	0.0	7.965	0.150	0	0	0	6
PL.3836	PL.3797	C	#4 ACSR	7.38Y	123.0	0.03	2.04	4.13	3	29	8	96	0.01	0.0	8.144	0.178	0	0	0	6
PL.3799	PL.3836	C	#4 ACSR	7.38Y	122.9	0.03	2.07	4.13	3	29	8	96	0.01	0.0	8.284	0.141	0	0	0	6
PL.3975	PL.3799	C	6 A (CWC)	7.37Y	122.9	0.02	2.08	4.13	3	29	8	96	0.00	0.0	8.388	0.103	12	3	2	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3976	PL.3975	C	6 A (CWC)	7.37Y	122.9	0.01	2.10	2.38	2	17	5	96	0.00	0.0	8.487	0.099	0	0	0	4
PL.3837	PL.3976	C	6 A (CWC)	7.37Y	122.9	0.01	2.11	2.38	2	17	5	96	0.00	0.0	8.674	0.187	16	4	3	4
PL.10578	PL.3837	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	8.722	0.048	0	0	0	1
PL.10579	PL.10578	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	8.771	0.049	0	0	0	1
PL.3838	PL.10579	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	8.881	0.110	0	0	0	1
PL.3800	PL.3838	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	9.022	0.140	0	0	0	1
PL.3801	PL.3800	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	9.150	0.129	0	0	0	1
PL.3802	PL.3801	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	9.294	0.143	0	0	0	1
PL.3977	PL.3802	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.16	0	1	0	100	0.00	0.0	9.387	0.093	1	0	1	1
PL.3978	PL.3977	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.00	0	0	0	100	0.00	0.0	9.439	0.052	0	0	0	0
PL.3512	PL.3851	C	#4 ACSR	7.40Y	123.3	0.00	1.67	0.64	0	5	1	98	0.00	0.0	6.821	0.005	0	0	0	4
PD.472	PL.3512	C	40QA	7.40Y	123.3	0.00	1.67	0.64	2	5	1	98	0.00	0.0	6.821	0.005	0	0	0	4
PL.3513	PD.472	C	#4 ACSR	7.40Y	123.3	0.00	1.67	0.64	0	5	1	98	0.00	0.0	6.846	0.026	5	1	2	4
PL.3730	PL.3513	C	#4 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	6.907	0.060	0	0	2	2
PL.3728	PL.3723	A	6 A (CWC)	7.40Y	123.4	0.01	1.60	2.13	2	15	4	97	0.00	0.0	6.570	0.054	0	0	0	5
PL.3551	PL.3728	A	6 A (CWC)	7.40Y	123.4	0.00	1.60	2.13	2	15	4	97	0.00	0.0	6.575	0.004	0	0	0	5
PD.473	PL.3551	A	40QA	7.40Y	123.4	0.00	1.60	2.13	5	15	4	97	0.00	0.0	6.575	0.004	0	0	0	5
PL.3552	PD.473	A	6 A (CWC)	7.40Y	123.4	0.00	1.60	2.13	2	15	4	97	0.00	0.0	6.589	0.014	1	0	2	5
PL.3991	PL.3552	A	6 A (CWC)	7.40Y	123.4	0.01	1.61	1.97	1	14	4	96	0.00	0.0	6.725	0.137	4	1	1	3
PL.3989	PL.3991	A	6 A (CWC)	7.40Y	123.4	0.00	1.61	1.38	1	10	3	96	0.00	0.0	6.754	0.029	0	0	0	2
PL.3990	PL.3989	A	6 A (CWC)	7.40Y	123.4	0.00	1.62	1.38	1	10	3	96	0.00	0.0	6.828	0.074	10	3	2	2
PL.3727	PL.3723	A	#4 ACSR	7.40Y	123.4	0.01	1.60	4.31	3	31	9	96	0.00	0.0	6.594	0.078	24	7	5	6
PL.3553	PL.3727	A	#4 ACSR	7.40Y	123.4	0.00	1.60	0.94	1	7	2	96	0.00	0.0	6.598	0.005	0	0	0	1
PD.474	PL.3553	A	40QA	7.40Y	123.4	0.00	1.60	0.94	2	7	2	96	0.00	0.0	6.598	0.005	0	0	0	1
PL.3554	PD.474	A	#4 ACSR	7.40Y	123.4	0.00	1.61	0.94	1	7	2	96	0.00	0.0	6.644	0.045	7	2	1	1
PL.3555	PL.3722	A	6 A (CWC)	7.41Y	123.5	0.00	1.53	0.63	0	5	1	98	0.00	0.0	6.283	0.004	0	0	0	1
PD.475	PL.3555	A	40QA	7.41Y	123.5	0.00	1.53	0.63	2	5	1	98	0.00	0.0	6.283	0.004	0	0	0	1
PL.3729	PD.475	A	6 A (CWC)	7.41Y	123.5	0.00	1.53	0.63	0	5	1	98	0.00	0.0	6.384	0.101	5	1	1	1
PL.4030	PL.3794	C	#4 ACSR	7.42Y	123.6	0.00	1.42	0.03	0	0	0	100	0.00	0.0	5.904	0.005	0	0	0	1
PD.483	PL.4030	C	15T	7.42Y	123.6	0.00	1.42	0.03	0	0	0	100	0.00	0.0	5.904	0.005	0	0	0	1
PL.4031	PD.483	C	#4 ACSR	7.42Y	123.6	0.00	1.42	0.03	0	0	0	100	0.00	0.0	5.964	0.060	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.4016	PL.3848	C	#4 ACSR	7.42Y	123.7	0.00	1.32	4.84	4	35	10	96	0.00	0.0	5.560	0.005	0	0	0	6
PD.477	PL.4016	C	40QA	7.42Y	123.7	0.00	1.32	4.84	12	35	10	96	0.00	0.0	5.560	0.005	0	0	0	6
PL.4017	PD.477	C	#4 ACSR	7.42Y	123.7	0.01	1.33	4.84	4	35	10	96	0.00	0.0	5.612	0.052	6	2	1	6
PL.3715	PL.4017	C	#4 ACSR	7.42Y	123.7	0.01	1.33	3.96	3	28	8	96	0.00	0.0	5.651	0.039	0	0	0	5
PL.3717	PL.3715	C	#2 ACSR	7.42Y	123.7	0.00	1.34	1.47	1	11	3	96	0.00	0.0	5.708	0.057	0	0	0	1
PL.3718	PL.3717	C	#2 ACSR	7.42Y	123.7	0.00	1.34	1.47	1	11	3	96	0.00	0.0	5.745	0.037	11	3	1	1
PL.3716	PL.3715	C	#4 ACSR	7.42Y	123.7	0.00	1.34	2.49	2	18	5	96	0.00	0.0	5.719	0.068	18	5	4	4
PL.4018	PL.3847	C	6 A (CWC)	7.42Y	123.7	0.00	1.29	0.68	0	5	1	98	0.00	0.0	5.477	0.005	0	0	0	1
PD.478	PL.4018	C	40QA	7.42Y	123.7	0.00	1.29	0.68	2	5	1	98	0.00	0.0	5.477	0.005	0	0	0	1
PL.4019	PD.478	C	6 A (CWC)	7.42Y	123.7	0.00	1.29	0.68	0	5	1	98	0.00	0.0	5.510	0.033	5	1	1	1
PL.4001	PL.3833	C	6 A (CWC)	7.44Y	124.1	0.00	0.94	0.51	0	4	1	97	0.00	0.0	4.627	0.005	0	0	0	2
PD.446	PL.4001	C	40QA	7.44Y	124.1	0.00	0.94	0.51	1	4	1	97	0.00	0.0	4.627	0.005	0	0	0	2
PL.3712	PD.446	C	6 A (CWC)	7.44Y	124.1	0.00	0.94	0.51	0	4	1	97	0.00	0.0	4.761	0.134	4	1	2	2
PL.2946	PL.3918	C	#4 ACSR	7.40Y	123.3	0.00	1.70	0.62	0	4	1	97	0.00	0.0	2.161	0.005	0	0	0	1
PD.452	PL.2946	C	40QA	7.40Y	123.3	0.00	1.70	0.62	2	4	1	97	0.00	0.0	2.161	0.005	0	0	0	1
PL.2947	PD.452	C	#4 ACSR	7.40Y	123.3	0.00	1.71	0.62	0	4	1	97	0.00	0.0	2.207	0.047	4	1	1	1
PL.2948	PL.3923	A	#4 ACSR	7.41Y	123.4	0.00	1.58	1.44	1	10	3	96	0.00	0.0	1.990	0.005	0	0	0	2
PD.453	PL.2948	A	40QA	7.41Y	123.4	0.00	1.58	1.44	4	10	3	96	0.00	0.0	1.990	0.005	0	0	0	2
PL.2949	PD.453	A	#4 ACSR	7.41Y	123.4	0.00	1.58	1.44	1	10	3	96	0.00	0.0	2.063	0.073	10	3	2	2
PL.2950	PL.3919	C	#4 ACSR	7.42Y	123.6	0.00	1.41	1.18	1	8	2	97	0.00	0.0	1.760	0.005	0	0	0	1
PD.454	PL.2950	C	40QA	7.42Y	123.6	0.00	1.41	1.18	3	8	2	97	0.00	0.0	1.760	0.005	0	0	0	1
PL.2951	PD.454	C	#4 ACSR	7.42Y	123.6	0.00	1.41	1.18	1	8	2	97	0.00	0.0	1.807	0.048	0	0	0	1
PL.3629	PL.2951	C	#4 ACSR	7.42Y	123.6	0.00	1.41	1.18	1	8	2	97	0.00	0.0	1.837	0.030	8	2	1	1
PL.2952	PL.3538	C	6 A (CWC)	7.43Y	123.9	0.00	1.09	2.86	2	21	6	96	0.00	0.0	1.335	0.005	0	0	0	4
PD.455	PL.2952	C	40QA	7.43Y	123.9	0.00	1.09	2.86	7	21	6	96	0.00	0.0	1.335	0.005	0	0	0	4
PL.2953	PD.455	C	6 A (CWC)	7.43Y	123.9	0.00	1.09	2.86	2	21	6	96	0.00	0.0	1.355	0.020	4	1	1	4
PL.3625	PL.2953	C	6 A (CWC)	7.43Y	123.9	0.00	1.10	2.36	2	17	5	96	0.00	0.0	1.402	0.047	7	2	2	3
PL.3626	PL.3625	C	#2 ACSR	7.43Y	123.9	0.00	1.10	1.43	1	10	3	96	0.00	0.0	1.423	0.021	10	3	1	1
PL.3488	PL.3620	C	#1/0 ACSR	7.47Y	124.5	0.00	0.48	0.72	0	5	1	98	0.00	0.0	0.572	0.017	0	0	0	1
PD.459	PL.3488	C	40QA	7.47Y	124.5	0.00	0.48	0.72	2	5	1	98	0.00	0.0	0.572	0.017	0	0	0	1
PL.3489	PD.459	C	#1/0 ACSR	7.47Y	124.5	0.00	0.48	0.72	0	5	1	98	0.00	0.0	0.622	0.050	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3618	PL.3781	ABC	#1/0 ACSR	7.48Y	124.7	0.01	0.27	9.91	4	200	97	90	0.01	0.0	0.332	0.056	0	0	0	1
PL.4038	PL.3618	ABC	4/0 AL URD	7.48Y	124.7	0.00	0.27	9.91	4	200	97	90	0.00	0.0	0.336	0.005	0	0	0	1
PD.487	PL.4038	ABC	65T	7.48Y	124.7	0.00	0.27	9.91	0	200	97	90	0.00	0.0	0.336	0.005	0	0	0	1
PL.4039	PD.487	ABC	4/0 AL URD	7.48Y	124.7	0.00	0.27	9.91	4	200	97	90	0.00	0.0	0.379	0.043	200	97	1	1
PL.2956	PL.3780	C	6 A (CWC)	7.49Y	124.8	0.00	0.18	0.67	0	5	1	98	0.00	0.0	0.193	0.004	0	0	0	3
PD.457	PL.2956	C	40QA	7.49Y	124.8	0.00	0.18	0.67	2	5	1	98	0.00	0.0	0.193	0.004	0	0	0	3
PL.2957	PD.457	C	6 A (CWC)	7.49Y	124.8	0.00	0.18	0.67	0	5	1	98	0.00	0.0	0.242	0.048	5	1	3	3
PL.4053	Goose Rock	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	119.12	23	2564	779	96	0.06	0.0	0.005	0.005	0	0	0	666
PL.7159	PL.4053	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	119.12	23	2564	779	96	0.01	0.0	0.006	0.001	0	0	0	666
----- Feeder No. 3 (Brightshade F3) Beginning with Device PD.1528 -----																				
PD.1528	PL.7159	ABC	480VWE	7.50Y	125.0	0.00	0.01	119.12	0	2564	779	96	0.00	0.0	0.006	0.001	0	0	0	666
PL.7160	PD.1528	ABC	336 MCM AC	7.50Y	125.0	0.03	0.03	119.12	23	2564	779	96	0.34	0.0	0.034	0.028	0	0	0	666
PL.2860	PL.7160	ABC	336 MCM AC	7.49Y	124.9	0.10	0.13	119.12	23	2564	778	96	1.34	0.1	0.147	0.112	0	0	0	666
PL.2861	PL.2860	ABC	336 MCM AC	7.49Y	124.8	0.09	0.23	119.12	23	2563	775	96	1.21	0.0	0.248	0.101	0	0	0	666
PL.2862	PL.2861	ABC	336 MCM AC	7.48Y	124.7	0.06	0.29	119.12	23	2561	772	96	0.85	0.0	0.319	0.071	0	0	0	666
PL.2863	PL.2862	ABC	336 MCM AC	7.48Y	124.6	0.09	0.38	119.12	23	2561	770	96	1.21	0.0	0.420	0.101	0	0	0	666
PL.2575	PL.2863	C	#2 ACSR	7.48Y	124.6	0.00	0.38	2.96	2	21	6	96	0.00	0.0	0.443	0.023	0	0	1	4
PL.3420	PL.2575	C	#2 ACSR	7.48Y	124.6	0.00	0.38	2.96	2	21	6	96	0.00	0.0	0.447	0.005	0	0	0	3
PD.373	PL.3420	C	40QA	7.48Y	124.6	0.00	0.38	2.96	7	21	6	96	0.00	0.0	0.447	0.005	0	0	0	3
PL.3421	PD.373	C	#2 ACSR	7.48Y	124.6	0.01	0.39	2.96	2	21	6	96	0.00	0.0	0.601	0.154	21	6	3	3
PL.65760	PL.3421	C	#1/0 ACSR	7.48Y	124.6	0.00	0.39	0.00	0	0	0	100	0.00	0.0	0.709	0.108	0	0	0	0
PL.2579	PL.2863	ABC	336 MCM AC	7.47Y	124.5	0.16	0.54	116.72	22	2508	753	96	2.08	0.1	0.601	0.181	0	0	0	658
PL.2581	PL.2579	ABC	336 MCM AC	7.46Y	124.4	0.05	0.59	116.72	22	2505	748	96	0.63	0.0	0.656	0.054	0	0	0	658
PL.3169	PL.2581	ABC	336 MCM AC	7.46Y	124.3	0.10	0.69	115.94	22	2488	742	96	1.22	0.0	0.764	0.108	1	0	2	655
PL.3170	PL.3169	ABC	336 MCM AC	7.45Y	124.2	0.09	0.77	115.88	22	2486	739	96	1.13	0.0	0.864	0.100	0	0	0	653
PL.2864	PL.3170	ABC	336 MCM AC	7.45Y	124.1	0.08	0.86	115.88	22	2484	736	96	1.08	0.0	0.959	0.095	0	0	0	653
PL.2865	PL.2864	ABC	336 MCM AC	7.44Y	124.0	0.11	0.97	115.88	22	2483	734	96	1.41	0.1	1.084	0.124	0	0	0	653
PL.3590	PL.2865	ABC	336 MCM AC	7.44Y	124.0	0.03	0.99	99.01	19	2119	629	96	0.28	0.0	1.118	0.034	0	0	0	564
PD.429-A	PL.3590	ABC	Closed	7.44Y	124.0	0.00	0.99	99.01	0	2119	629	96	0.00	0.0	1.118	0.034	0	0	0	564

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.429-B	PD.429-A	ABC	Closed	7.44Y	124.0	0.00	0.99	99.01	0	2119	629	96	0.00	0.0	1.118	0.034	0	0	0	564
PL.3591	PD.429-B	ABC	336 MCM AC	7.44Y	123.9	0.06	1.05	99.01	19	2119	629	96	0.62	0.0	1.193	0.076	0	0	0	564
PL.3424	PL.3591	C	#4 ACSR	7.44Y	123.9	0.00	1.05	0.37	0	3	1	95	0.00	0.0	1.198	0.005	0	0	0	1
PD.375	PL.3424	C	40QA	7.44Y	123.9	0.00	1.05	0.37	1	3	1	95	0.00	0.0	1.198	0.005	0	0	0	1
PL.3425	PD.375	C	#4 ACSR	7.44Y	123.9	0.00	1.05	0.37	0	3	1	95	0.00	0.0	1.223	0.025	3	1	1	1
PL.3091	PL.3591	ABC	336 MCM AC	7.43Y	123.9	0.08	1.13	98.89	19	2116	626	96	0.84	0.0	1.296	0.103	5	1	1	563
PL.3092	PL.3091	ABC	336 MCM AC	7.43Y	123.9	0.02	1.15	96.05	19	2054	608	96	0.19	0.0	1.321	0.025	0	0	0	552
PL.2585	PL.3092	ABC	336 MCM AC	7.43Y	123.8	0.03	1.17	96.05	19	2053	607	96	0.30	0.0	1.360	0.039	4	1	1	552
PL.3408	PL.2585	C	#4 ACSR	7.43Y	123.8	0.00	1.17	1.22	1	9	2	98	0.00	0.0	1.364	0.005	0	0	0	1
PD.368	PL.3408	C	15T	7.43Y	123.8	0.00	1.17	1.22	0	9	2	98	0.00	0.0	1.364	0.005	0	0	0	1
PL.3409	PD.368	C	#4 ACSR	7.43Y	123.8	0.00	1.17	1.22	1	9	2	98	0.00	0.0	1.380	0.016	9	2	1	1
PL.3411	PL.2585	ABC	336 MCM AC	7.43Y	123.8	0.07	1.24	95.47	18	2041	603	96	0.71	0.0	1.453	0.093	9	3	2	550
PL.3564	PL.3411	A	#2 ACSR	7.43Y	123.8	0.00	1.24	0.80	0	6	2	95	0.00	0.0	1.457	0.004	0	0	0	2
PD.417	PL.3564	A	40QA	7.43Y	123.8	0.00	1.24	0.80	2	6	2	95	0.00	0.0	1.457	0.004	0	0	0	2
PL.3565	PD.417	A	#2 ACSR	7.43Y	123.8	0.00	1.24	0.80	0	6	2	95	0.00	0.0	1.478	0.020	6	2	2	2
PL.2594	PL.3411	ABC	336 MCM AC	7.42Y	123.7	0.05	1.29	94.77	18	2025	597	96	0.51	0.0	1.521	0.068	24	7	4	546
PL.2595	PL.2594	ABC	336 MCM AC	7.42Y	123.7	0.04	1.33	93.64	18	2000	589	96	0.45	0.0	1.582	0.061	0	0	0	542
PL.3094	PL.2595	ABC	336 MCM AC	7.42Y	123.6	0.07	1.40	93.33	18	1993	586	96	0.69	0.0	1.676	0.094	1	0	1	541
PL.3404	PL.3094	A	#2 ACSR	7.42Y	123.6	0.00	1.40	9.96	6	71	20	96	0.00	0.0	1.680	0.005	0	0	0	16
PD.366	PL.3404	A	40QA	7.42Y	123.6	0.00	1.40	9.96	25	71	20	96	0.00	0.0	1.680	0.005	0	0	0	16
PL.3405	PD.366	A	#2 ACSR	7.42Y	123.6	0.01	1.41	9.96	6	71	20	96	0.01	0.0	1.714	0.033	0	0	0	16
PL.2596	PL.3405	A	#2 ACSR	7.41Y	123.6	0.02	1.43	9.96	6	71	20	96	0.01	0.0	1.770	0.056	0	0	0	16
PL.2597	PL.2596	A	6 A (CWC)	7.41Y	123.5	0.03	1.46	9.96	7	71	20	96	0.01	0.0	1.830	0.060	0	0	0	16
PL.2598	PL.2597	A	6 A (CWC)	7.41Y	123.5	0.05	1.50	9.96	7	71	20	96	0.03	0.0	1.935	0.106	0	0	0	16
PL.2599	PL.2598	A	#4 ACSR	7.41Y	123.5	0.01	1.51	6.15	5	44	12	96	0.00	0.0	1.968	0.033	3	1	1	10
PL.2604	PL.2599	A	#4 ACSR	7.41Y	123.5	0.01	1.52	5.78	4	41	11	97	0.00	0.0	2.006	0.038	9	2	1	9
PL.2605	PL.2604	A	#4 ACSR	7.41Y	123.5	0.01	1.53	4.55	3	32	9	96	0.00	0.0	2.068	0.062	5	1	1	8
PL.2606	PL.2605	A	#4 ACSR	7.41Y	123.5	0.00	1.53	1.02	1	7	2	96	0.00	0.0	2.121	0.052	7	2	1	1
PL.2607	PL.2605	A	#4 ACSR	7.41Y	123.5	0.01	1.54	2.80	2	20	6	96	0.00	0.0	2.148	0.080	0	0	1	6
PL.2608	PL.2607	A	#4 ACSR	7.41Y	123.4	0.01	1.55	2.80	2	20	6	96	0.00	0.0	2.229	0.081	7	2	1	5
PL.2609	PL.2608	A	#4 ACSR	7.41Y	123.4	0.00	1.55	0.00	0	0	0	100	0.00	0.0	2.287	0.058	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2610	PL.2608	A	#2 ACSR	7.41Y	123.4	0.00	1.55	1.78	1	13	4	96	0.00	0.0	2.245	0.016	0	0	0	4
PL.2611	PL.2610	A	#2 ACSR	7.41Y	123.4	0.00	1.55	0.00	0	0	0	100	0.00	0.0	2.316	0.070	0	0	1	1
PL.3402	PL.2610	A	#2 ACSR	7.41Y	123.4	0.00	1.55	1.78	1	13	4	96	0.00	0.0	2.250	0.005	0	0	0	3
PD.365	PL.3402	A	40QA	7.41Y	123.4	0.00	1.55	1.78	4	13	4	96	0.00	0.0	2.250	0.005	0	0	0	3
PL.3403	PD.365	A	#2 ACSR	7.41Y	123.4	0.00	1.55	1.78	1	13	4	96	0.00	0.0	2.263	0.013	13	4	3	3
PL.2600	PL.2598	A	#4 ACSR	7.41Y	123.5	0.01	1.51	3.81	3	27	8	96	0.00	0.0	1.996	0.061	5	1	2	6
PL.2601	PL.2600	A	#4 ACSR	7.41Y	123.5	0.00	1.52	3.08	2	22	6	96	0.00	0.0	2.030	0.034	0	0	0	4
PL.2603	PL.2601	A	#4 ACSR	7.41Y	123.5	0.00	1.52	2.06	2	15	4	97	0.00	0.0	2.072	0.042	15	4	2	2
PL.2602	PL.2601	A	#4 ACSR	7.41Y	123.5	0.00	1.52	1.03	1	7	2	96	0.00	0.0	2.082	0.052	7	2	2	2
PL.3095	PL.3094	ABC	336 MCM AC	7.41Y	123.5	0.06	1.46	89.97	17	1920	565	96	0.64	0.0	1.769	0.094	0	0	0	524
PL.3050	PL.3095	ABC	336 MCM AC	7.41Y	123.5	0.06	1.52	89.97	17	1920	563	96	0.61	0.0	1.859	0.090	0	0	0	524
PL.3166	PL.3050	ABC	336 MCM AC	7.41Y	123.4	0.04	1.56	89.71	17	1914	560	96	0.38	0.0	1.916	0.057	6	2	1	523
PL.3167	PL.3166	ABC	336 MCM AC	7.40Y	123.4	0.06	1.62	89.45	17	1908	558	96	0.61	0.0	2.006	0.090	0	0	0	522
PL.3416	PL.3167	C	#1/0 ACSR	7.40Y	123.4	0.00	1.62	1.03	0	7	2	96	0.00	0.0	2.010	0.005	0	0	0	3
PD.371	PL.3416	C	40QA	7.40Y	123.4	0.00	1.62	1.03	3	7	2	96	0.00	0.0	2.010	0.005	0	0	0	3
PL.3417	PD.371	C	#1/0 ACSR	7.40Y	123.4	0.00	1.62	1.03	0	7	2	96	0.00	0.0	2.034	0.023	0	0	0	3
PL.2612	PL.3417	C	#2 ACSR	7.40Y	123.4	0.00	1.62	1.03	1	7	2	96	0.00	0.0	2.087	0.053	7	2	3	3
PL.2871	PL.3167	ABC	336 MCM AC	7.40Y	123.3	0.12	1.74	89.11	17	1900	555	96	1.18	0.1	2.182	0.176	0	0	0	519
PL.3162	PL.2871	ABC	336 MCM AC	7.39Y	123.2	0.07	1.81	89.11	17	1898	552	96	0.71	0.0	2.289	0.106	3	1	2	519
PL.3163	PL.3162	ABC	336 MCM AC	7.39Y	123.1	0.08	1.89	88.97	17	1895	549	96	0.80	0.0	2.408	0.120	0	0	0	517
PL.3158	PL.3163	ABC	336 MCM AC	7.38Y	123.0	0.06	1.95	88.97	17	1894	547	96	0.61	0.0	2.500	0.091	0	0	0	517
PL.3159	PL.3158	ABC	336 MCM AC	7.38Y	123.0	0.02	1.97	88.97	17	1893	546	96	0.17	0.0	2.526	0.026	0	0	0	517
PL.3412	PL.3159	A	#2 ACSR	7.38Y	123.0	0.00	1.97	0.42	0	3	1	95	0.00	0.0	2.530	0.005	0	0	0	1
PD.369	PL.3412	A	40QA	7.38Y	123.0	0.00	1.97	0.42	1	3	1	95	0.00	0.0	2.530	0.005	0	0	0	1
PL.3413	PD.369	A	#2 ACSR	7.38Y	123.0	0.00	1.97	0.42	0	3	1	95	0.00	0.0	2.548	0.018	3	1	1	1
PL.3160	PL.3159	ABC	336 MCM AC	7.38Y	123.0	0.03	2.01	88.82	17	1890	545	96	0.35	0.0	2.578	0.052	0	0	0	516
PL.3161	PL.3160	ABC	336 MCM AC	7.38Y	122.9	0.07	2.08	88.82	17	1890	544	96	0.71	0.0	2.685	0.107	0	0	0	516
PL.2872	PL.3161	ABC	336 MCM AC	7.37Y	122.8	0.11	2.19	88.82	17	1889	542	96	1.08	0.1	2.848	0.163	14	4	4	516
PL.3592	PL.2872	B	#2 ACSR	7.37Y	122.8	0.00	2.19	46.40	27	329	93	96	0.01	0.0	2.851	0.003	0	0	0	97
PD.430	PL.3592	B	70L	7.37Y	122.8	0.00	2.19	46.40	66	329	93	96	0.00	0.0	2.851	0.003	0	0	0	97
PL.3593	PD.430	B	#2 ACSR	7.36Y	122.6	0.21	2.40	46.40	27	329	93	96	0.50	0.2	2.994	0.143	0	0	0	97

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2615	PL.3593	B	#2 ACSR	7.35Y	122.4	0.16	2.56	45.07	26	319	90	96	0.37	0.1	3.107	0.113	4	1	1	95
PL.2617	PL.2615	B	#2 ACSR	7.34Y	122.3	0.11	2.67	44.52	25	315	89	96	0.25	0.1	3.184	0.077	0	0	0	94
PL.2618	PL.2617	B	#2 ACSR	7.34Y	122.3	0.05	2.72	44.52	25	315	88	96	0.11	0.0	3.220	0.036	0	0	0	94
PL.3156	PL.2618	B	#2 ACSR	7.33Y	122.2	0.04	2.76	44.52	25	314	88	96	0.10	0.0	3.251	0.031	0	0	0	94
PL.3157	PL.3156	B	#2 ACSR	7.33Y	122.1	0.10	2.87	44.52	25	314	88	96	0.23	0.1	3.324	0.073	0	0	0	94
PL.3155	PL.3157	B	#2 ACSR	7.32Y	122.0	0.09	2.95	44.52	25	314	88	96	0.20	0.1	3.386	0.062	0	0	0	94
PL.3153	PL.3155	B	#2 ACSR	7.31Y	121.9	0.16	3.11	44.52	25	314	88	96	0.36	0.1	3.499	0.113	4	1	2	94
PL.3154	PL.3153	B	#2 ACSR	7.31Y	121.8	0.05	3.16	43.91	25	309	86	96	0.12	0.0	3.538	0.039	7	2	2	92
PL.2621	PL.3154	B	#4 ACSR	7.31Y	121.8	0.00	3.17	1.01	1	7	2	96	0.00	0.0	3.603	0.064	2	1	1	3
PL.2622	PL.2621	B	#2 ACSR	7.31Y	121.8	0.00	3.17	0.67	0	5	1	98	0.00	0.0	3.628	0.025	5	1	2	2
PL.3119	PL.3154	B	#2 ACSR	7.31Y	121.8	0.06	3.23	41.85	24	295	82	96	0.14	0.0	3.587	0.049	5	1	2	87
PL.3120	PL.3119	B	#2 ACSR	7.30Y	121.7	0.10	3.32	40.12	23	282	79	96	0.20	0.1	3.664	0.077	2	1	1	84
PL.2624	PL.3120	B	#4 ACSR	7.30Y	121.7	0.01	3.34	4.16	3	29	8	96	0.00	0.0	3.749	0.085	16	5	2	3
PL.2623	PL.2624	B	#2 ACSR	7.30Y	121.7	0.00	3.34	1.83	1	13	4	96	0.00	0.0	3.793	0.044	13	4	1	1
PL.3121	PL.3120	B	#2 ACSR	7.29Y	121.5	0.15	3.48	35.63	20	251	70	96	0.28	0.1	3.801	0.137	0	0	0	80
PL.2874	PL.3121	B	#2 ACSR	7.28Y	121.4	0.15	3.63	35.63	20	250	70	96	0.27	0.1	3.937	0.135	5	1	2	80
PL.3152	PL.2874	B	#2 ACSR	7.28Y	121.3	0.08	3.71	34.91	20	245	68	96	0.15	0.1	4.014	0.077	12	3	2	78
PL.3122	PL.3152	B	#2 ACSR	7.27Y	121.2	0.06	3.77	30.74	18	216	60	96	0.09	0.0	4.074	0.060	3	1	2	69
PL.2626	PL.3122	B	#2 ACSR	7.27Y	121.2	0.07	3.84	30.25	17	212	59	96	0.11	0.1	4.148	0.074	4	1	4	67
PL.2630	PL.2626	B	#4 ACSR	7.27Y	121.2	0.00	3.84	1.73	1	12	3	97	0.00	0.0	4.173	0.026	12	3	1	1
PL.2632	PL.2626	B	#2 ACSR	7.26Y	121.0	0.15	3.99	27.93	16	196	54	96	0.21	0.1	4.319	0.171	8	2	4	62
PL.2634	PL.2632	B	#2 ACSR	7.26Y	120.9	0.07	4.06	26.84	15	188	52	96	0.10	0.1	4.406	0.087	1	0	1	58
PL.2635	PL.2634	B	#2 ACSR	7.26Y	120.9	0.02	4.08	26.75	15	187	52	96	0.02	0.0	4.425	0.019	9	2	1	57
PL.2636	PL.2635	B	#2 ACSR	7.26Y	120.9	0.01	4.08	25.51	15	178	49	96	0.01	0.0	4.432	0.007	0	0	1	56
PL.2637	PL.2636	B	#2 ACSR	7.25Y	120.9	0.03	4.11	23.62	13	165	46	96	0.04	0.0	4.472	0.040	1	0	2	54
PL.2639	PL.2637	B	#2 ACSR	7.25Y	120.8	0.04	4.16	18.75	11	131	36	96	0.04	0.0	4.551	0.079	11	3	4	46
PL.2642	PL.2639	B	#2 ACSR	7.25Y	120.8	0.00	4.16	0.49	0	3	1	95	0.00	0.0	4.634	0.084	3	1	2	2
PL.2645	PL.2642	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.00	0	0	0	100	0.00	0.0	4.741	0.107	0	0	0	0
PL.2646	PL.2645	B	#4 ACSR	7.25Y	120.8	0.00	4.16	0.00	0	0	0	100	0.00	0.0	4.806	0.065	0	0	0	0
PL.2643	PL.2639	B	#2 ACSR	7.25Y	120.8	0.07	4.23	16.76	10	117	32	96	0.06	0.1	4.708	0.157	24	7	4	40
PL.2648	PL.2643	B	#2 ACSR	7.24Y	120.7	0.08	4.31	13.27	8	93	26	96	0.05	0.1	4.893	0.185	3	1	3	36

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3394	PL.2648	B	#4 ACSR	7.24Y	120.7	0.00	4.31	2.81	2	20	5	97	0.00	0.0	4.897	0.005	0	0	0	8
PD.360	PL.3394	B	20T	7.24Y	120.7	0.00	4.31	2.81	0	20	5	97	0.00	0.0	4.897	0.005	0	0	0	8
PL.3395	PD.360	B	#4 ACSR	7.24Y	120.7	0.02	4.32	2.81	2	20	5	97	0.00	0.0	5.022	0.124	0	0	0	8
PL.2878	PL.3395	B	#4 ACSR	7.24Y	120.7	0.01	4.34	2.81	2	20	5	97	0.00	0.0	5.134	0.113	0	0	0	8
PL.2651	PL.2878	B	#4 ACSR	7.24Y	120.6	0.02	4.35	2.81	2	20	5	97	0.00	0.0	5.291	0.157	3	1	1	8
PL.2652	PL.2651	B	#4 ACSR	7.24Y	120.6	0.01	4.37	2.38	2	17	5	96	0.00	0.0	5.407	0.116	0	0	0	7
PL.2653	PL.2652	B	#4 ACSR	7.24Y	120.6	0.01	4.38	2.38	2	17	5	96	0.00	0.0	5.519	0.113	5	1	1	7
PL.2654	PL.2653	B	#4 ACSR	7.24Y	120.6	0.01	4.39	1.65	1	12	3	97	0.00	0.0	5.679	0.160	0	0	0	6
PL.2879	PL.2654	B	#4 ACSR	7.24Y	120.6	0.01	4.40	1.65	1	12	3	97	0.00	0.0	5.773	0.093	0	0	0	6
PL.3052	PL.2879	B	#4 ACSR	7.24Y	120.6	0.01	4.40	1.65	1	12	3	97	0.00	0.0	5.880	0.107	0	0	0	6
PL.2880	PL.3052	B	#4 ACSR	7.24Y	120.6	0.01	4.41	1.65	1	12	3	97	0.00	0.0	5.992	0.112	0	0	0	6
PL.3053	PL.2880	B	#4 ACSR	7.23Y	120.6	0.01	4.42	1.65	1	12	3	97	0.00	0.0	6.080	0.088	0	0	0	6
PL.2881	PL.3053	B	#4 ACSR	7.23Y	120.6	0.01	4.43	1.65	1	12	3	97	0.00	0.0	6.176	0.097	0	0	0	6
PL.3054	PL.2881	B	#4 ACSR	7.23Y	120.6	0.01	4.43	1.65	1	12	3	97	0.00	0.0	6.255	0.079	0	0	0	6
PL.2882	PL.3054	B	#4 ACSR	7.23Y	120.6	0.01	4.44	1.65	1	12	3	97	0.00	0.0	6.352	0.097	0	0	0	6
PL.3055	PL.2882	B	#4 ACSR	7.23Y	120.6	0.01	4.45	1.65	1	12	3	97	0.00	0.0	6.457	0.105	0	0	0	6
PL.2883	PL.3055	B	#4 ACSR	7.23Y	120.5	0.01	4.45	1.65	1	12	3	97	0.00	0.0	6.532	0.075	0	0	0	6
PL.3056	PL.2883	B	#4 ACSR	7.23Y	120.5	0.01	4.46	1.65	1	12	3	97	0.00	0.0	6.632	0.100	0	0	0	6
PL.2655	PL.3056	B	#4 ACSR	7.23Y	120.5	0.00	4.46	1.65	1	12	3	97	0.00	0.0	6.679	0.047	0	0	0	6
PL.2656	PL.2655	B	#4 ACSR	7.23Y	120.5	0.01	4.47	1.44	1	10	3	96	0.00	0.0	6.847	0.169	0	0	0	3
PL.2696	PL.2656	B	#4 ACSR	7.23Y	120.5	0.01	4.48	1.44	1	10	3	96	0.00	0.0	6.927	0.080	0	0	0	3
PL.2698	PL.2696	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.67	1	5	1	98	0.00	0.0	6.996	0.069	5	1	1	1
PL.3386	PL.2696	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.77	1	5	1	98	0.00	0.0	7.096	0.169	3	1	1	2
PL.3387	PL.3386	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.32	0	2	1	89	0.00	0.0	7.259	0.163	0	0	0	1
PL.3135	PL.3387	B	#4 ACSR	7.23Y	120.5	0.00	4.49	0.32	0	2	1	89	0.00	0.0	7.332	0.072	0	0	0	1
PL.3136	PL.3135	B	#4 ACSR	7.23Y	120.5	0.00	4.49	0.32	0	2	1	89	0.00	0.0	7.351	0.019	2	1	1	1
PL.2825	PL.2655	B	#4 ACSR	7.23Y	120.5	0.00	4.46	0.21	0	1	0	100	0.00	0.0	6.758	0.080	0	0	0	3
PL.2658	PL.2825	B	#4 ACSR	7.23Y	120.5	0.00	4.46	0.21	0	1	0	100	0.00	0.0	6.922	0.164	0	0	0	3
PL.2657	PL.2658	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.21	0	1	0	100	0.00	0.0	7.007	0.085	0	0	0	3
PL.3171	PL.2657	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.21	0	1	0	100	0.00	0.0	7.090	0.083	1	0	1	3
PL.3172	PL.3171	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.05	0	0	0	100	0.00	0.0	7.188	0.098	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2660	PL.3172	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.05	0	0	0	100	0.00	0.0	7.277	0.089	0	0	0	2
PL.3143	PL.2660	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.05	0	0	0	100	0.00	0.0	7.334	0.057	0	0	1	2
PL.3144	PL.3143	B	#4 ACSR	7.23Y	120.5	0.00	4.47	0.05	0	0	0	100	0.00	0.0	7.363	0.029	0	0	1	1
PL.2659	PL.2825	B	#2 ACSR	7.23Y	120.5	0.00	4.46	0.00	0	0	0	100	0.00	0.0	6.791	0.032	0	0	0	0
PL.10154	PL.2648	B	#2 ACSR	7.24Y	120.7	0.00	4.31	10.00	6	70	19	97	0.00	0.0	4.896	0.003	0	0	0	25
PD.1878	PL.10154	B	20T	7.24Y	120.7	0.00	4.31	10.00	0	70	19	97	0.00	0.0	4.896	0.003	0	0	0	25
PL.10155	PD.1878	B	#2 ACSR	7.24Y	120.7	0.04	4.35	10.00	6	70	19	97	0.02	0.0	5.032	0.136	0	0	0	25
PL.2875	PL.10155	B	#2 ACSR	7.24Y	120.6	0.03	4.38	10.00	6	70	19	97	0.02	0.0	5.140	0.107	0	0	0	25
PL.2661	PL.2875	B	#2 ACSR	7.24Y	120.6	0.02	4.40	10.00	6	70	19	97	0.01	0.0	5.199	0.060	0	0	0	25
PL.3127	PL.2661	B	#2 ACSR	7.24Y	120.6	0.01	4.42	8.92	5	62	17	96	0.01	0.0	5.247	0.047	0	0	0	23
PL.2663	PL.3127	B	#4 ACSR	7.24Y	120.6	0.00	4.42	0.58	0	4	1	97	0.00	0.0	5.278	0.032	4	1	1	1
PL.2664	PL.3127	B	#4 ACSR	7.24Y	120.6	0.00	4.42	0.57	0	4	1	97	0.00	0.0	5.315	0.069	4	1	3	3
PL.3128	PL.3127	B	#2 ACSR	7.23Y	120.5	0.04	4.45	7.77	4	54	15	96	0.01	0.0	5.393	0.146	0	0	0	19
PL.3149	PL.3128	B	#2 ACSR	7.23Y	120.5	0.02	4.47	7.77	4	54	15	96	0.01	0.0	5.462	0.069	3	1	1	19
PL.3150	PL.3149	B	#2 ACSR	7.23Y	120.5	0.01	4.48	7.38	4	51	14	96	0.00	0.0	5.517	0.055	7	2	1	18
PL.3129	PL.3150	B	#2 ACSR	7.23Y	120.5	0.01	4.49	6.34	4	44	12	96	0.00	0.0	5.581	0.064	0	0	0	16
PL.2824	PL.3129	B	#2 ACSR	7.23Y	120.5	0.00	4.49	0.76	0	5	1	98	0.00	0.0	5.651	0.071	0	0	0	1
PL.2667	PL.2824	B	#4 ACSR	7.23Y	120.5	0.00	4.49	0.76	1	5	1	98	0.00	0.0	5.667	0.015	5	1	1	1
PL.2666	PL.3129	B	#2 ACSR	7.23Y	120.5	0.01	4.50	5.58	3	39	11	96	0.00	0.0	5.641	0.061	28	8	7	15
PL.2668	PL.2666	B	#2 ACSR	7.23Y	120.5	0.00	4.50	1.60	1	11	3	96	0.00	0.0	5.699	0.057	3	1	1	8
PL.2669	PL.2668	B	#2 ACSR	7.23Y	120.5	0.00	4.50	1.22	1	9	2	98	0.00	0.0	5.750	0.052	2	1	3	7
PL.3147	PL.2669	B	#2 ACSR	7.23Y	120.5	0.00	4.51	0.90	1	6	2	95	0.00	0.0	5.873	0.123	0	0	1	4
PL.3148	PL.3147	B	#2 ACSR	7.23Y	120.5	0.00	4.51	0.85	0	6	2	95	0.00	0.0	5.995	0.122	0	0	0	3
PL.2876	PL.3148	B	#2 ACSR	7.23Y	120.5	0.00	4.51	0.85	0	6	2	95	0.00	0.0	6.105	0.109	0	0	0	3
PL.3051	PL.2876	B	#2 ACSR	7.23Y	120.5	0.00	4.52	0.85	0	6	2	95	0.00	0.0	6.245	0.141	2	1	1	3
PL.3146	PL.3051	B	#2 ACSR	7.23Y	120.5	0.00	4.52	0.51	0	4	1	97	0.00	0.0	6.344	0.099	4	1	2	2
PL.2665	PL.3150	B	#2 ACSR	7.23Y	120.5	0.00	4.48	0.05	0	0	0	100	0.00	0.0	5.551	0.034	0	0	1	1
PL.2662	PL.2661	B	#2 ACSR	7.24Y	120.6	0.00	4.40	1.08	1	8	2	97	0.00	0.0	5.230	0.030	8	2	2	2
PL.2640	PL.2637	B	#2 ACSR	7.25Y	120.9	0.00	4.11	4.28	2	30	8	97	0.00	0.0	4.508	0.036	30	8	4	4
PL.2641	PL.2637	B	#4 ACSR	7.25Y	120.9	0.00	4.11	0.43	0	3	1	95	0.00	0.0	4.517	0.045	3	1	2	2
PL.2638	PL.2636	B	#4 ACSR	7.25Y	120.9	0.00	4.08	1.85	1	13	4	96	0.00	0.0	4.498	0.066	13	4	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2631	PL.2626	B	#4 ACSR	7.27Y	121.2	0.00	3.84	0.00	0	0	0	100	0.00	0.0	4.201	0.054	0	0	0	0
PL.2625	PL.3152	B	#4 ACSR	7.28Y	121.3	0.01	3.72	2.51	2	18	5	96	0.00	0.0	4.108	0.095	5	1	2	7
PL.2627	PL.2625	B	#4 ACSR	7.28Y	121.3	0.00	3.72	1.86	1	13	4	96	0.00	0.0	4.136	0.028	7	2	2	5
PL.2628	PL.2627	B	#4 ACSR	7.28Y	121.3	0.00	3.72	0.80	1	6	2	95	0.00	0.0	4.199	0.063	1	0	1	3
PL.2629	PL.2628	B	#2 ACSR	7.28Y	121.3	0.00	3.72	0.68	0	5	1	98	0.00	0.0	4.233	0.034	5	1	2	2
PL.2620	PL.3119	B	#4 ACSR	7.31Y	121.8	0.00	3.23	1.07	1	8	2	97	0.00	0.0	3.613	0.026	8	2	1	1
PL.2616	PL.3593	B	#4 ACSR	7.36Y	122.6	0.00	2.40	1.33	1	9	3	95	0.00	0.0	3.078	0.084	9	3	2	2
PL.2614	PL.2872	ABC	#2 ACSR	7.36Y	122.7	0.08	2.27	72.70	42	1545	443	96	0.94	0.1	2.891	0.044	1	0	1	415
PL.2670	PL.2614	ABC	#2 ACSR	7.35Y	122.5	0.19	2.45	72.67	42	1543	442	96	2.20	0.1	2.994	0.102	11	3	1	414
PL.3164	PL.2670	ABC	#2 ACSR	7.35Y	122.5	0.05	2.50	72.17	41	1531	438	96	0.55	0.0	3.019	0.026	6	2	1	413
PL.3165	PL.3164	ABC	#2 ACSR	7.34Y	122.4	0.11	2.61	71.91	41	1524	436	96	1.25	0.1	3.079	0.059	21	6	4	412
PL.2671	PL.3165	ABC	#2 ACSR	7.34Y	122.3	0.07	2.68	70.90	41	1502	430	96	0.76	0.1	3.116	0.037	0	0	0	408
PL.3426	PL.2671	A	#4 ACSR	7.34Y	122.3	0.00	2.68	0.57	0	4	1	97	0.00	0.0	3.120	0.005	0	0	0	1
PD.376	PL.3426	A	40QA	7.34Y	122.3	0.00	2.68	0.57	1	4	1	97	0.00	0.0	3.120	0.005	0	0	0	1
PL.3427	PD.376	A	#4 ACSR	7.34Y	122.3	0.00	2.68	0.57	0	4	1	97	0.00	0.0	3.208	0.087	4	1	1	1
PL.2826	PL.2671	ABC	#2 ACSR	7.33Y	122.2	0.13	2.80	70.70	40	1497	428	96	1.46	0.1	3.188	0.072	13	4	1	407
PL.3428	PL.2826	A	#1/0 ACSR	7.33Y	122.2	0.00	2.80	4.82	2	34	9	97	0.00	0.0	3.192	0.005	0	0	0	14
PD.377	PL.3428	A	15T	7.33Y	122.2	0.00	2.80	4.82	0	34	9	97	0.00	0.0	3.192	0.005	0	0	0	14
PL.3429	PD.377	A	#1/0 ACSR	7.33Y	122.2	0.01	2.81	4.82	2	34	9	97	0.00	0.0	3.253	0.061	14	4	4	14
PL.2674	PL.3429	A	#4 ACSR	7.33Y	122.2	0.01	2.81	2.87	2	20	6	96	0.00	0.0	3.304	0.050	7	2	7	10
PL.2675	PL.2674	A	#4 ACSR	7.33Y	122.2	0.01	2.82	1.90	1	13	4	96	0.00	0.0	3.366	0.063	0	0	0	3
PL.2676	PL.2675	A	#4 ACSR	7.33Y	122.2	0.00	2.82	1.01	1	7	2	96	0.00	0.0	3.432	0.066	7	2	1	1
PL.2677	PL.2675	A	#4 ACSR	7.33Y	122.2	0.00	2.82	0.89	1	6	2	95	0.00	0.0	3.408	0.042	6	2	2	2
PL.2672	PL.2826	ABC	#2 ACSR	7.33Y	122.1	0.09	2.89	68.50	39	1449	414	96	1.02	0.1	3.241	0.053	0	0	0	392
PL.2673	PL.2672	ABC	#2 ACSR	7.33Y	122.1	0.00	2.90	68.50	39	1448	414	96	0.02	0.0	3.242	0.001	0	0	0	392
RG.4	PL.2673	ABC	114.3 KVA	7.47Y	124.4	-2.33	0.56	68.50	46	1448	414	96	percent Boost= 1.88 Tap= 3.0				0	0	0	392
PL.3046	RG.4	ABC	#2 ACSR	7.47Y	124.4	0.00	0.57	67.22	38	1448	414	96	0.02	0.0	3.243	0.001	0	0	0	392
PL.3047	PL.3046	ABC	#2 ACSR	7.46Y	124.3	0.10	0.66	67.22	38	1448	414	96	1.04	0.1	3.299	0.056	0	0	0	392
PL.3430	PL.3047	C	#1/0 ACSR	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	3.304	0.005	0	0	0	0
PD.378	PL.3430	C	40QA	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	3.304	0.005	0	0	0	0
PL.3431	PD.378	C	#1/0 ACSR	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	3.350	0.047	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3432	PL.3047	ABC	#2 ACSR	7.46Y	124.3	0.01	0.67	67.22	38	1446	413	96	0.08	0.0	3.304	0.004	0	0	0	392
PL.3433	PL.3432	ABC	#2 ACSR	7.45Y	124.1	0.19	0.85	67.22	38	1446	413	96	2.02	0.1	3.413	0.109	0	0	0	392
PL.2679	PL.3433	ABC	#2 ACSR	7.44Y	124.0	0.18	1.03	67.22	38	1444	412	96	1.91	0.1	3.516	0.103	0	0	0	392
PL.2885	PL.2679	ABC	#2 ACSR	7.43Y	123.8	0.19	1.22	67.22	38	1442	411	96	2.09	0.1	3.629	0.113	0	0	0	392
PL.3396	PL.2885	C	6 A (CWC)	7.43Y	123.8	0.00	1.22	1.50	1	11	3	96	0.00	0.0	3.634	0.005	0	0	0	3
PD.361	PL.3396	C	40QA	7.43Y	123.8	0.00	1.22	1.50	4	11	3	96	0.00	0.0	3.634	0.005	0	0	0	3
PL.3397	PD.361	C	6 A (CWC)	7.43Y	123.8	0.00	1.23	1.50	1	11	3	96	0.00	0.0	3.726	0.092	11	3	3	3
PL.2827	PL.2885	ABC	#2 ACSR	7.42Y	123.6	0.13	1.35	66.72	38	1430	407	96	1.39	0.1	3.705	0.076	0	0	0	389
PL.3613	PL.2827	ABC	#2 ACSR	7.41Y	123.5	0.12	1.47	66.72	38	1428	406	96	1.33	0.1	3.778	0.073	0	0	0	389
PL.3614	PL.3613	ABC	#2 ACSR	7.41Y	123.4	0.09	1.56	66.72	38	1427	405	96	0.92	0.1	3.829	0.051	0	0	0	389
PL.2682	PL.3614	ABC	#2 ACSR	7.40Y	123.3	0.12	1.68	66.12	38	1413	401	96	1.27	0.1	3.900	0.071	9	2	2	384
PL.2683	PL.2682	ABC	#2 ACSR	7.39Y	123.2	0.08	1.76	65.72	38	1403	398	96	0.85	0.1	3.948	0.048	0	0	0	382
PL.2685	PL.2683	ABC	#2 ACSR	7.39Y	123.2	0.08	1.84	46.86	27	1000	285	96	0.62	0.1	4.018	0.069	0	0	0	255
PL.2686	PL.2685	ABC	#2 ACSR	7.38Y	123.0	0.11	1.95	46.86	27	999	285	96	0.85	0.1	4.113	0.095	0	0	0	255
PL.2843	PL.2686	ABC	#2 ACSR	7.38Y	122.9	0.10	2.06	46.57	27	992	283	96	0.78	0.1	4.200	0.087	0	0	0	254
PL.3605	PL.2843	ABC	#2 ACSR	7.37Y	122.8	0.10	2.16	46.57	27	991	282	96	0.75	0.1	4.285	0.085	0	0	0	254
PD.437	PL.3605	ABC	70L	7.37Y	122.8	0.00	2.16	46.57	67	991	282	96	0.00	0.0	4.285	0.085	0	0	0	254
PL.3606	PD.437	ABC	#2 ACSR	7.37Y	122.8	0.01	2.17	46.57	27	991	282	96	0.11	0.0	4.297	0.012	6	2	2	254
PL.3213	PL.3606	ABC	#2 ACSR	7.36Y	122.7	0.11	2.28	46.28	26	984	280	96	0.83	0.1	4.392	0.095	9	3	2	252
PL.3189	PL.3213	ABC	#2 ACSR	7.36Y	122.6	0.11	2.39	45.84	26	974	277	96	0.81	0.1	4.486	0.094	0	0	0	250
PL.3191	PL.3189	ABC	#2 ACSR	7.35Y	122.6	0.04	2.43	45.84	26	973	277	96	0.30	0.0	4.520	0.035	0	0	0	250
PL.3192	PL.3191	ABC	#2 ACSR	7.35Y	122.5	0.09	2.52	45.84	26	973	276	96	0.64	0.1	4.595	0.074	4	1	2	250
PL.3190	PL.3192	ABC	#2 ACSR	7.34Y	122.4	0.10	2.62	45.63	26	968	275	96	0.76	0.1	4.683	0.089	0	0	0	248
PL.2844	PL.3190	ABC	#2 ACSR	7.34Y	122.3	0.09	2.71	45.00	26	954	271	96	0.63	0.1	4.760	0.076	0	0	0	244
PL.3458	PL.2844	A	6 A (CWC)	7.34Y	122.3	0.00	2.71	9.35	7	66	18	96	0.00	0.0	4.764	0.005	0	0	0	10
PD.391	PL.3458	A	40QA	7.34Y	122.3	0.00	2.71	9.35	23	66	18	96	0.00	0.0	4.764	0.005	0	0	0	10
PL.3459	PD.391	A	6 A (CWC)	7.34Y	122.3	0.02	2.73	9.35	7	66	18	96	0.01	0.0	4.816	0.052	0	0	0	10
PL.3193	PL.3459	A	6 A (CWC)	7.34Y	122.3	0.01	2.74	9.35	7	66	18	96	0.01	0.0	4.850	0.034	16	4	1	10
PL.3194	PL.3193	A	6 A (CWC)	7.33Y	122.2	0.01	2.76	7.09	5	50	14	96	0.00	0.0	4.892	0.041	11	3	1	9
PL.3195	PL.3194	A	6 A (CWC)	7.33Y	122.2	0.01	2.77	5.50	4	39	11	96	0.00	0.0	4.942	0.050	0	0	0	8
PL.3196	PL.3195	A	6 A (CWC)	7.33Y	122.2	0.00	2.77	5.50	4	39	11	96	0.00	0.0	4.959	0.017	6	2	1	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3197	PL.3196	A	6 A (CWC)	7.33Y	122.2	0.01	2.78	4.67	3	33	9	96	0.00	0.0	5.027	0.068	21	6	4	7
PL.3198	PL.3197	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	1.74	1	12	3	97	0.00	0.0	5.045	0.019	0	0	0	3
PL.2687	PL.3198	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.95	1	7	2	96	0.00	0.0	5.077	0.032	7	2	1	1
PL.3199	PL.3198	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.80	1	6	2	95	0.00	0.0	5.090	0.044	0	0	0	2
PL.3200	PL.3199	A	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.80	1	6	2	95	0.00	0.0	5.158	0.068	6	2	2	2
PL.2845	PL.2844	ABC	#2 ACSR	7.33Y	122.2	0.11	2.81	41.89	24	887	252	96	0.74	0.1	4.862	0.103	0	0	0	234
PL.2688	PL.2845	ABC	#2 ACSR	7.33Y	122.1	0.08	2.90	41.89	24	886	252	96	0.57	0.1	4.941	0.079	1	0	3	234
PL.2689	PL.2688	C	#4 ACSR	7.33Y	122.1	0.00	2.90	2.55	2	18	5	96	0.00	0.0	4.985	0.044	12	3	3	4
PL.2690	PL.2689	C	#4 ACSR	7.33Y	122.1	0.00	2.90	0.88	1	6	2	95	0.00	0.0	5.019	0.034	6	2	1	1
PL.3214	PL.2688	ABC	#2 ACSR	7.32Y	122.0	0.09	2.99	40.98	23	866	246	96	0.59	0.1	5.027	0.086	1	0	1	227
PL.3215	PL.3214	ABC	#2 ACSR	7.32Y	121.9	0.06	3.05	40.94	23	865	246	96	0.43	0.0	5.090	0.062	0	0	0	226
PL.3470	PL.3215	A	#4 ACSR	7.32Y	121.9	0.00	3.05	0.90	1	6	2	95	0.00	0.0	5.094	0.005	0	0	0	1
PD.398	PL.3470	A	40QA	7.32Y	121.9	0.00	3.05	0.90	2	6	2	95	0.00	0.0	5.094	0.005	0	0	0	1
PL.3471	PD.398	A	#4 ACSR	7.32Y	121.9	0.00	3.05	0.90	1	6	2	95	0.00	0.0	5.130	0.036	6	2	1	1
PL.3216	PL.3215	ABC	#2 ACSR	7.31Y	121.8	0.13	3.18	40.64	23	858	244	96	0.85	0.1	5.216	0.126	8	2	1	225
PL.3217	PL.3216	ABC	#2 ACSR	7.30Y	121.7	0.10	3.28	40.24	23	849	241	96	0.62	0.1	5.309	0.094	0	0	0	224
PL.2996	PL.3217	ABC	#2 ACSR	7.30Y	121.6	0.07	3.35	40.24	23	848	240	96	0.48	0.1	5.381	0.072	0	0	0	224
PL.3067	PL.2996	ABC	#2 ACSR	7.29Y	121.5	0.14	3.49	40.24	23	848	240	96	0.88	0.1	5.515	0.133	0	0	0	224
PL.2997	PL.3067	ABC	#2 ACSR	7.28Y	121.4	0.16	3.65	40.24	23	847	240	96	1.07	0.1	5.676	0.161	0	0	0	224
PL.2998	PL.2997	ABC	#2 ACSR	7.27Y	121.2	0.11	3.76	40.24	23	846	239	96	0.74	0.1	5.787	0.111	0	0	0	224
PL.2712	PL.2998	ABC	#2 ACSR	7.27Y	121.1	0.11	3.88	40.24	23	845	239	96	0.74	0.1	5.899	0.111	0	0	0	224
PL.3570	PL.2712	C	6 A (CWC)	7.27Y	121.1	0.00	3.88	1.96	1	14	4	96	0.00	0.0	5.903	0.005	0	0	0	2
PD.420	PL.3570	C	40QA	7.27Y	121.1	0.00	3.88	1.96	5	14	4	96	0.00	0.0	5.903	0.005	0	0	0	2
PL.3571	PD.420	C	6 A (CWC)	7.27Y	121.1	0.00	3.88	1.96	1	14	4	96	0.00	0.0	5.961	0.058	14	4	2	2
PL.2919	PL.2712	ABC	#2 ACSR	7.27Y	121.1	0.04	3.91	39.59	23	831	234	96	0.24	0.0	5.936	0.038	0	0	2	222
PL.3611	PL.2919	ABC	#2 ACSR	7.26Y	121.0	0.07	3.99	39.59	23	830	234	96	0.48	0.1	6.010	0.074	0	0	0	220
PL.3612	PL.3611	ABC	#2 ACSR	7.25Y	120.9	0.10	4.09	39.59	23	830	234	96	0.66	0.1	6.113	0.103	0	0	0	220
PL.3130	PL.3612	ABC	#2 ACSR	7.25Y	120.8	0.09	4.18	39.42	23	826	233	96	0.58	0.1	6.205	0.092	9	2	2	217
PL.3572	PL.3130	C	6 A (CWC)	7.25Y	120.8	0.00	4.18	4.83	3	34	9	97	0.00	0.0	6.210	0.005	0	0	0	5
PD.421	PL.3572	C	40QA	7.25Y	120.8	0.00	4.18	4.83	12	34	9	97	0.00	0.0	6.210	0.005	0	0	0	5
PL.3573	PD.421	C	6 A (CWC)	7.25Y	120.8	0.01	4.19	4.83	3	34	9	97	0.00	0.0	6.268	0.058	34	9	5	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3444	PL.3130	B	6 A (CWC)	7.25Y	120.8	0.01	4.19	12.00	9	84	23	96	0.01	0.0	6.224	0.019	0	0	0	27
PD.384	PL.3444	B	25T	7.25Y	120.8	0.00	4.19	12.00	0	84	23	96	0.00	0.0	6.224	0.019	0	0	0	27
PL.3445	PD.384	B	6 A (CWC)	7.25Y	120.8	0.03	4.22	12.00	9	84	23	96	0.02	0.0	6.277	0.053	3	1	2	27
PL.2925	PL.3445	B	6 A (CWC)	7.25Y	120.8	0.01	4.23	11.63	8	81	22	97	0.00	0.0	6.289	0.012	9	2	2	25
PL.2924	PL.2925	B	6 A (CWC)	7.24Y	120.7	0.05	4.28	10.42	7	73	20	96	0.03	0.0	6.406	0.117	9	2	1	23
PL.2714	PL.2924	B	6 A (CWC)	7.24Y	120.7	0.04	4.32	9.15	7	64	18	96	0.02	0.0	6.493	0.087	0	0	0	22
PL.2715	PL.2714	B	#4 ACSR	7.24Y	120.7	0.00	4.32	0.32	0	2	1	89	0.00	0.0	6.539	0.046	2	1	1	1
PL.2926	PL.2714	B	6 A (CWC)	7.24Y	120.6	0.04	4.35	8.83	6	62	17	96	0.02	0.0	6.589	0.096	10	3	2	21
PL.2927	PL.2926	B	6 A (CWC)	7.24Y	120.6	0.02	4.37	7.35	5	51	14	96	0.01	0.0	6.648	0.059	8	2	1	19
PL.2928	PL.2927	B	6 A (CWC)	7.24Y	120.6	0.01	4.38	6.26	4	44	12	96	0.00	0.0	6.690	0.043	10	3	3	18
PL.2922	PL.2928	B	#4 ACSR	7.24Y	120.6	0.01	4.39	4.85	4	34	9	97	0.00	0.0	6.727	0.036	12	3	1	15
PL.2923	PL.2922	B	#4 ACSR	7.24Y	120.6	0.01	4.40	3.13	2	22	6	96	0.00	0.0	6.831	0.104	2	1	1	14
PL.2911	PL.2923	B	#4 ACSR	7.24Y	120.6	0.01	4.41	2.82	2	20	5	97	0.00	0.0	6.904	0.073	0	0	0	13
PL.2912	PL.2911	B	#4 ACSR	7.23Y	120.6	0.02	4.43	2.82	2	20	5	97	0.00	0.0	7.024	0.120	0	0	0	13
PL.2913	PL.2912	B	#4 ACSR	7.23Y	120.6	0.01	4.44	2.82	2	20	5	97	0.00	0.0	7.100	0.076	0	0	0	13
PL.2914	PL.2913	B	#4 ACSR	7.23Y	120.5	0.02	4.45	2.82	2	20	5	97	0.00	0.0	7.240	0.141	0	0	0	13
PL.2846	PL.2914	B	#4 ACSR	7.23Y	120.5	0.01	4.46	1.75	1	12	3	97	0.00	0.0	7.317	0.076	0	0	0	7
PL.2716	PL.2846	B	#4 ACSR	7.23Y	120.5	0.01	4.47	1.75	1	12	3	97	0.00	0.0	7.448	0.131	0	0	0	7
PL.3068	PL.2716	B	#4 ACSR	7.23Y	120.5	0.01	4.48	1.75	1	12	3	97	0.00	0.0	7.535	0.087	0	0	0	7
PL.3002	PL.3068	B	#4 ACSR	7.23Y	120.5	0.01	4.49	1.75	1	12	3	97	0.00	0.0	7.672	0.137	0	0	0	7
PL.3140	PL.3002	B	#4 ACSR	7.23Y	120.5	0.01	4.50	1.75	1	12	3	97	0.00	0.0	7.783	0.111	0	0	0	7
PL.2718	PL.3140	B	#4 ACSR	7.23Y	120.5	0.00	4.50	1.00	1	7	2	96	0.00	0.0	7.860	0.077	0	0	0	4
PL.2717	PL.2718	B	#4 ACSR	7.23Y	120.5	0.00	4.50	1.00	1	7	2	96	0.00	0.0	7.953	0.093	0	0	0	4
PL.3069	PL.2717	B	#4 ACSR	7.23Y	120.5	0.01	4.51	1.00	1	7	2	96	0.00	0.0	8.068	0.115	0	0	0	4
PL.3003	PL.3069	B	#4 ACSR	7.23Y	120.5	0.01	4.51	1.00	1	7	2	96	0.00	0.0	8.197	0.130	0	0	0	4
PL.3070	PL.3003	B	#4 ACSR	7.23Y	120.5	0.00	4.52	1.00	1	7	2	96	0.00	0.0	8.301	0.104	0	0	0	4
PL.3004	PL.3070	B	#4 ACSR	7.23Y	120.5	0.01	4.53	1.00	1	7	2	96	0.00	0.0	8.450	0.149	0	0	0	4
PL.3005	PL.3004	B	#4 ACSR	7.23Y	120.5	0.00	4.53	1.00	1	7	2	96	0.00	0.0	8.527	0.077	0	0	0	4
PL.3071	PL.3005	B	#4 ACSR	7.23Y	120.5	0.00	4.53	1.00	1	7	2	96	0.00	0.0	8.625	0.098	0	0	0	4
PL.3006	PL.3071	B	#4 ACSR	7.23Y	120.5	0.00	4.54	1.00	1	7	2	96	0.00	0.0	8.732	0.107	0	0	0	4
PL.3177	PL.3006	B	#4 ACSR	7.23Y	120.5	0.01	4.55	1.00	1	7	2	96	0.00	0.0	8.901	0.169	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3178	PL.3177	B	#4 ACSR	7.23Y	120.5	0.00	4.55	1.00	1	7	2	96	0.00	0.0	8.996	0.095	0	0	0	4
PL.3072	PL.3178	B	#4 ACSR	7.23Y	120.4	0.00	4.55	1.00	1	7	2	96	0.00	0.0	9.086	0.091	0	0	0	4
PL.2719	PL.3072	B	#4 ACSR	7.23Y	120.4	0.01	4.56	1.00	1	7	2	96	0.00	0.0	9.245	0.158	0	0	0	4
PL.3007	PL.2719	B	#4 ACSR	7.23Y	120.4	0.01	4.57	1.00	1	7	2	96	0.00	0.0	9.361	0.116	0	0	0	4
PL.3175	PL.3007	B	#4 ACSR	7.23Y	120.4	0.00	4.57	1.00	1	7	2	96	0.00	0.0	9.415	0.054	4	1	1	4
PL.3176	PL.3175	B	#4 ACSR	7.23Y	120.4	0.00	4.57	0.40	0	3	1	95	0.00	0.0	9.505	0.090	0	0	0	3
PL.3073	PL.3176	B	#4 ACSR	7.23Y	120.4	0.00	4.57	0.40	0	3	1	95	0.00	0.0	9.593	0.089	0	0	0	3
PL.3008	PL.3073	B	#4 ACSR	7.23Y	120.4	0.00	4.57	0.40	0	3	1	95	0.00	0.0	9.754	0.160	0	0	0	3
PL.3173	PL.3008	B	#4 ACSR	7.23Y	120.4	0.00	4.58	0.34	0	2	1	89	0.00	0.0	9.889	0.135	2	0	1	2
PL.3174	PL.3173	B	#4 ACSR	7.23Y	120.4	0.00	4.58	0.12	0	1	0	100	0.00	0.0	10.018	0.129	0	0	0	1
PL.3009	PL.3174	B	#4 ACSR	7.23Y	120.4	0.00	4.58	0.12	0	1	0	100	0.00	0.0	10.171	0.153	1	0	1	1
PL.2720	PL.3008	B	#4 ACSR	7.23Y	120.4	0.00	4.57	0.06	0	0	0	100	0.00	0.0	9.805	0.051	0	0	1	1
PL.3141	PL.3140	B	#4 ACSR	7.23Y	120.5	0.00	4.50	0.74	1	5	1	98	0.00	0.0	7.810	0.027	5	1	3	3
PL.3440	PL.2914	B	#4 ACSR	7.23Y	120.5	0.00	4.45	1.07	1	7	2	96	0.00	0.0	7.245	0.005	0	0	0	6
PD.382	PL.3440	B	10T	7.23Y	120.5	0.00	4.45	1.07	0	7	2	96	0.00	0.0	7.245	0.005	0	0	0	6
PL.3441	PD.382	B	#4 ACSR	7.23Y	120.5	0.01	4.46	1.07	1	7	2	96	0.00	0.0	7.359	0.114	0	0	0	6
PL.2999	PL.3441	B	#4 ACSR	7.23Y	120.5	0.01	4.47	1.07	1	7	2	96	0.00	0.0	7.496	0.137	0	0	0	6
PL.3000	PL.2999	B	#4 ACSR	7.23Y	120.5	0.01	4.47	1.07	1	7	2	96	0.00	0.0	7.609	0.113	0	0	0	6
PL.3001	PL.3000	B	#4 ACSR	7.23Y	120.5	0.00	4.48	1.07	1	7	2	96	0.00	0.0	7.714	0.105	0	0	0	6
PL.2915	PL.3001	B	#4 ACSR	7.23Y	120.5	0.00	4.48	1.07	1	7	2	96	0.00	0.0	7.797	0.083	2	1	2	6
PL.2917	PL.2915	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.74	1	5	1	98	0.00	0.0	7.928	0.132	3	1	2	4
PL.2918	PL.2917	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.27	0	2	1	89	0.00	0.0	8.006	0.078	0	0	0	2
PL.2916	PL.2918	B	#4 ACSR	7.23Y	120.5	0.00	4.48	0.27	0	2	1	89	0.00	0.0	8.095	0.089	2	1	2	2
PL.3131	PL.3130	ABC	#2 ACSR	7.24Y	120.7	0.09	4.27	33.39	19	699	197	96	0.49	0.1	6.312	0.107	0	0	0	183
PL.3442	PL.3131	B	#2 ACSR	7.24Y	120.7	0.00	4.27	4.60	3	32	9	96	0.00	0.0	6.317	0.005	0	0	0	6
PD.383	PL.3442	B	40QA	7.24Y	120.7	0.00	4.27	4.60	11	32	9	96	0.00	0.0	6.317	0.005	0	0	0	6
PL.3443	PD.383	B	#2 ACSR	7.24Y	120.7	0.01	4.28	4.60	3	32	9	96	0.00	0.0	6.361	0.044	0	0	0	6
PL.2920	PL.3443	B	#2 ACSR	7.24Y	120.7	0.00	4.28	4.60	3	32	9	96	0.00	0.0	6.394	0.033	3	1	2	6
PL.2921	PL.2920	B	#2 ACSR	7.24Y	120.7	0.01	4.29	4.15	2	29	8	96	0.00	0.0	6.485	0.091	11	3	1	4
PL.2725	PL.2921	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.525	0.039	0	0	1	1
PL.33079	PL.2725	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.583	0.058	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.33080	PL.33079	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.656	0.073	0	0	0	0
PL.33081	PL.33080	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.704	0.048	0	0	0	0
PL.33083	PL.33081	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.706	0.001	0	0	0	0
PD.4894	PL.33083	B	10T	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.706	0.001	0	0	0	0
PL.33084	PD.4894	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.751	0.046	0	0	0	0
PL.33085	PL.33084	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.803	0.052	0	0	0	0
PL.33086	PL.33085	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.854	0.050	0	0	0	0
PL.33087	PL.33086	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.896	0.042	0	0	0	0
PL.33088	PL.33087	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.935	0.039	0	0	0	0
PL.33089	PL.33088	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	6.978	0.043	0	0	0	0
PL.33090	PL.33089	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.044	0.067	0	0	0	0
PL.33091	PL.33090	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.099	0.055	0	0	0	0
PL.33092	PL.33091	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.138	0.039	0	0	0	0
PL.33093	PL.33092	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.194	0.056	0	0	0	0
PL.33094	PL.33093	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.254	0.060	0	0	0	0
PL.33095	PL.33094	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.335	0.080	0	0	0	0
PL.33096	PL.33095	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.379	0.045	0	0	0	0
PL.33097	PL.33096	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.426	0.047	0	0	0	0
PL.33098	PL.33097	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.469	0.042	0	0	0	0
PL.33099	PL.33098	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.492	0.023	0	0	0	0
PL.33100	PL.33099	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.522	0.030	0	0	0	0
PL.33101	PL.33100	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.582	0.060	0	0	0	0
PL.33102	PL.33101	B	#1/0 ACSR	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.627	0.045	0	0	0	0
PL.33103	PL.33102	B	1/0 AL URD	7.24Y	120.7	0.00	4.29	0.00	0	0	0	100	0.00	0.0	7.672	0.045	0	0	0	0
PL.2724	PL.2921	B	#2 ACSR	7.24Y	120.7	0.00	4.30	2.55	1	18	5	96	0.00	0.0	6.511	0.026	18	5	2	2
PL.2847	PL.3131	ABC	#2 ACSR	7.24Y	120.7	0.07	4.34	31.86	18	666	188	96	0.34	0.1	6.396	0.084	7	2	1	177
PL.2721	PL.2847	ABC	#2 ACSR	7.23Y	120.6	0.08	4.42	31.41	18	656	186	96	0.42	0.1	6.501	0.105	0	0	0	175
PL.3010	PL.2721	ABC	#2 ACSR	7.23Y	120.5	0.08	4.51	31.41	18	656	185	96	0.42	0.1	6.606	0.105	0	0	0	175
PL.2723	PL.3010	C	6 A (CWC)	7.23Y	120.5	0.01	4.52	4.04	3	28	8	96	0.00	0.0	6.724	0.118	28	8	4	4
PL.3448	PL.2723	C	#4 ACSR	7.23Y	120.5	0.00	4.52	0.00	0	0	0	100	0.00	0.0	6.728	0.005	0	0	0	0
PD.386	PL.3448	C	40QA	7.23Y	120.5	0.00	4.52	0.00	0	0	0	100	0.00	0.0	6.728	0.005	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3449	PD.386	C	#4 ACSR	7.23Y	120.5	0.00	4.52	0.00	0	0	0	100	0.00	0.0	6.763	0.035	0	0	0	0
PL.2931	PL.3010	ABC	#2 ACSR	7.23Y	120.4	0.06	4.56	30.06	17	627	177	96	0.27	0.0	6.679	0.073	5	1	1	171
PL.2932	PL.2931	ABC	#2 ACSR	7.22Y	120.4	0.07	4.63	29.81	17	622	176	96	0.32	0.1	6.767	0.088	0	0	0	170
PL.3074	PL.2932	ABC	#2 ACSR	7.22Y	120.3	0.08	4.71	29.81	17	622	176	96	0.40	0.1	6.876	0.109	0	0	0	170
PL.2929	PL.3074	ABC	#2 ACSR	7.21Y	120.2	0.08	4.79	29.81	17	621	175	96	0.37	0.1	6.978	0.101	0	0	0	170
PL.2930	PL.2929	ABC	#2 ACSR	7.21Y	120.1	0.08	4.86	29.81	17	621	175	96	0.36	0.1	7.078	0.100	0	0	0	170
PL.3075	PL.2930	ABC	#2 ACSR	7.20Y	120.1	0.06	4.92	29.81	17	621	175	96	0.29	0.0	7.156	0.079	0	0	0	170
PL.3011	PL.3075	ABC	#2 ACSR	7.20Y	120.0	0.07	4.99	29.81	17	620	175	96	0.33	0.1	7.248	0.091	0	0	0	170
PL.3012	PL.3011	ABC	#2 ACSR	7.20Y	120.0	0.06	5.05	29.81	17	620	175	96	0.28	0.0	7.324	0.076	3	1	2	170
PL.3187	PL.3012	ABC	#2 ACSR	7.19Y	119.9	0.05	5.10	29.67	17	617	174	96	0.23	0.0	7.389	0.065	2	1	1	168
PL.3188	PL.3187	ABC	#2 ACSR	7.19Y	119.8	0.07	5.17	29.58	17	615	173	96	0.35	0.1	7.485	0.097	0	0	0	167
PL.3133	PL.3188	ABC	#2 ACSR	7.19Y	119.8	0.07	5.24	29.58	17	614	173	96	0.35	0.1	7.583	0.097	0	0	1	167
PL.3390	PL.3133	C	6 A (CWC)	7.19Y	119.8	0.00	5.24	0.00	0	0	0	100	0.00	0.0	7.587	0.005	0	0	0	0
PL.3134	PL.3133	ABC	#2 ACSR	7.18Y	119.7	0.08	5.33	29.57	17	614	173	96	0.40	0.1	7.694	0.112	0	0	0	166
PL.2726	PL.3134	ABC	#1/0 ACSR	7.18Y	119.6	0.06	5.38	29.57	13	613	172	96	0.25	0.0	7.803	0.109	0	0	0	166
PL.2727	PL.2726	C	6 A (CWC)	7.17Y	119.5	0.12	5.50	33.52	24	232	65	96	0.21	0.1	7.881	0.078	10	3	2	59
PL.3615	PL.2727	C	6 A (CWC)	7.16Y	119.4	0.11	5.61	32.05	23	221	62	96	0.19	0.1	7.957	0.076	0	0	0	57
RG.3	PL.3615	C	76.2 KVA	7.44Y	124.0	-4.65	0.96	32.05	32	221	62	96	percent Boost= 0.00 Tap= 0.0							57
PL.3616	RG.3	C	6 A (CWC)	7.44Y	124.0	0.09	1.05	30.85	22	221	62	96	0.14	0.1	8.019	0.063	0	0	0	57
PD.431	PL.3616	C	50L	7.44Y	124.0	0.00	1.05	30.85	62	221	62	96	0.00	0.0	8.019	0.063	0	0	0	57
PL.3594	PD.431	C	6 A (CWC)	7.42Y	123.7	0.24	1.28	30.85	22	221	62	96	0.39	0.2	8.186	0.167	0	0	0	57
PL.2729	PL.3594	C	#4 ACSR	7.42Y	123.7	0.00	1.29	0.35	0	3	1	95	0.00	0.0	8.267	0.081	3	1	2	2
PL.3138	PL.3594	C	6 A (CWC)	7.41Y	123.5	0.19	1.47	30.49	22	218	61	96	0.31	0.1	8.322	0.136	0	0	0	55
PL.3139	PL.3138	C	6 A (CWC)	7.41Y	123.5	0.06	1.53	30.12	22	215	60	96	0.09	0.0	8.363	0.041	0	0	0	54
PL.3182	PL.3139	C	6 A (CWC)	7.40Y	123.3	0.18	1.71	30.12	22	215	60	96	0.29	0.1	8.496	0.133	4	1	1	54
PL.3183	PL.3182	C	6 A (CWC)	7.39Y	123.2	0.13	1.85	29.60	21	211	59	96	0.21	0.1	8.595	0.100	0	0	0	53
PL.3306	PL.3183	C	6 A (CWC)	7.38Y	123.0	0.12	1.96	29.60	21	211	59	96	0.18	0.1	8.681	0.085	0	0	1	53
PL.3307	PL.3306	C	6 A (CWC)	7.38Y	123.0	0.08	2.04	29.60	21	210	59	96	0.12	0.1	8.740	0.059	8	2	1	52
PL.3305	PL.3307	C	6 A (CWC)	7.37Y	122.8	0.12	2.16	28.43	20	202	57	96	0.18	0.1	8.832	0.091	0	0	0	51
PL.3013	PL.3305	C	6 A (CWC)	7.36Y	122.7	0.13	2.29	28.43	20	202	56	96	0.20	0.1	8.931	0.099	0	0	0	51
PL.3132	PL.3013	C	6 A (CWC)	7.35Y	122.5	0.19	2.48	27.96	20	198	55	96	0.28	0.1	9.088	0.157	18	5	6	49

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3319	PL.3132	C	6 A (CWC)	7.35Y	122.4	0.10	2.58	24.09	17	171	48	96	0.12	0.1	9.180	0.093	10	3	3	41
PL.3320	PL.3319	C	6 A (CWC)	7.34Y	122.4	0.05	2.63	22.70	16	161	45	96	0.06	0.0	9.232	0.052	6	2	2	38
PL.3321	PL.3320	C	6 A (CWC)	7.34Y	122.3	0.03	2.67	21.90	16	155	43	96	0.04	0.0	9.265	0.033	7	2	1	36
PL.3318	PL.3321	C	6 A (CWC)	7.34Y	122.3	0.06	2.73	20.92	15	148	41	96	0.07	0.0	9.333	0.068	0	0	0	35
PL.3324	PL.3318	C	6 A (CWC)	7.33Y	122.2	0.07	2.80	20.92	15	148	41	96	0.07	0.1	9.405	0.071	4	1	1	35
PL.3325	PL.3324	C	6 A (CWC)	7.33Y	122.2	0.05	2.85	20.33	15	144	40	96	0.05	0.0	9.459	0.054	0	0	0	34
PL.3326	PL.3325	C	6 A (CWC)	7.33Y	122.1	0.05	2.90	20.33	15	144	40	96	0.05	0.0	9.515	0.057	6	2	1	34
PL.3323	PL.3326	C	6 A (CWC)	7.32Y	122.0	0.08	2.98	19.45	14	137	38	96	0.08	0.1	9.606	0.091	8	2	2	33
PL.3322	PL.3323	C	6 A (CWC)	7.32Y	121.9	0.07	3.05	18.29	13	129	36	96	0.07	0.1	9.693	0.087	0	0	0	31
PL.3076	PL.3322	C	6 A (CWC)	7.31Y	121.8	0.10	3.16	18.29	13	129	36	96	0.10	0.1	9.815	0.123	0	0	0	31
PL.3014	PL.3076	C	6 A (CWC)	7.31Y	121.8	0.08	3.23	18.29	13	129	36	96	0.08	0.1	9.910	0.095	0	0	0	31
PL.3336	PL.3014	C	6 A (CWC)	7.30Y	121.7	0.07	3.30	18.29	13	129	36	96	0.07	0.1	9.994	0.084	2	1	1	31
PL.3337	PL.3336	C	6 A (CWC)	7.30Y	121.6	0.05	3.36	18.00	13	127	35	96	0.05	0.0	10.058	0.064	0	0	0	30
PL.3334	PL.3337	C	6 A (CWC)	7.29Y	121.6	0.09	3.45	18.00	13	127	35	96	0.08	0.1	10.168	0.109	5	2	1	30
PL.3335	PL.3334	C	6 A (CWC)	7.29Y	121.5	0.07	3.52	17.23	12	121	34	96	0.07	0.1	10.260	0.092	0	0	0	29
PL.3137	PL.3335	C	6 A (CWC)	7.29Y	121.4	0.04	3.55	17.23	12	121	34	96	0.03	0.0	10.306	0.047	4	1	1	29
PL.2747	PL.3137	C	6 A (CWC)	7.29Y	121.4	0.00	3.56	0.93	1	7	2	96	0.00	0.0	10.409	0.103	0	0	0	1
PL.3015	PL.2747	C	6 A (CWC)	7.29Y	121.4	0.01	3.56	0.93	1	7	2	96	0.00	0.0	10.529	0.120	0	0	0	1
PL.3016	PL.3015	C	6 A (CWC)	7.29Y	121.4	0.00	3.57	0.93	1	7	2	96	0.00	0.0	10.644	0.115	7	2	1	1
PL.3328	PL.3137	C	6 A (CWC)	7.28Y	121.4	0.05	3.60	15.69	11	110	31	96	0.04	0.0	10.374	0.067	9	2	1	27
PL.3329	PL.3328	C	6 A (CWC)	7.28Y	121.4	0.04	3.64	14.44	10	101	28	96	0.03	0.0	10.445	0.072	14	4	3	26
PL.3327	PL.3329	C	6 A (CWC)	7.28Y	121.3	0.04	3.68	12.46	9	87	24	96	0.02	0.0	10.511	0.066	11	3	1	23
PL.3330	PL.3327	C	6 A (CWC)	7.28Y	121.3	0.02	3.70	10.89	8	76	21	96	0.01	0.0	10.562	0.051	8	2	4	22
PL.3331	PL.3330	C	6 A (CWC)	7.27Y	121.2	0.05	3.75	9.69	7	68	19	96	0.03	0.0	10.674	0.112	0	0	0	18
PL.2748	PL.3331	C	6 A (CWC)	7.27Y	121.2	0.00	3.75	0.00	0	0	0	100	0.00	0.0	10.741	0.067	0	0	1	1
PL.2749	PL.3331	C	6 A (CWC)	7.27Y	121.2	0.04	3.80	9.68	7	68	19	96	0.02	0.0	10.774	0.101	0	0	0	17
PL.2750	PL.2749	C	6 A (CWC)	7.27Y	121.2	0.00	3.80	0.82	1	6	2	95	0.00	0.0	10.833	0.059	2	1	1	2
PL.2938	PL.2750	C	#1/0 ACSR	7.27Y	121.2	0.00	3.80	0.54	0	4	1	97	0.00	0.0	10.838	0.005	0	0	0	1
PD.408	PL.2938	C	40QA	7.27Y	121.2	0.00	3.80	0.54	1	4	1	97	0.00	0.0	10.838	0.005	0	0	0	1
PL.2939	PD.408	C	#1/0 ACSR	7.27Y	121.2	0.00	3.80	0.54	0	4	1	97	0.00	0.0	11.000	0.163	0	0	0	1
PL.3017	PL.2939	C	#1/0 ACSR	7.27Y	121.2	0.00	3.80	0.54	0	4	1	97	0.00	0.0	11.159	0.159	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3018	PL.3017	C	#1/0 ACSR	7.27Y	121.2	0.00	3.81	0.54	0	4	1	97	0.00	0.0	11.314	0.156	0	0	0	1
PL.3077	PL.3018	C	#1/0 ACSR	7.27Y	121.2	0.00	3.81	0.54	0	4	1	97	0.00	0.0	11.396	0.082	0	0	0	1
PL.3019	PL.3077	C	#1/0 ACSR	7.27Y	121.2	0.00	3.81	0.54	0	4	1	97	0.00	0.0	11.500	0.104	4	1	1	1
PL.2848	PL.2749	C	6 A (CWC)	7.27Y	121.2	0.05	3.84	8.87	6	62	17	96	0.02	0.0	10.887	0.113	0	0	0	15
PL.3332	PL.2848	C	#4 ACSR	7.27Y	121.2	0.00	3.85	1.56	1	11	3	96	0.00	0.0	10.967	0.080	8	2	2	3
PL.3333	PL.3332	C	#4 ACSR	7.27Y	121.2	0.00	3.85	0.36	0	3	1	95	0.00	0.0	11.013	0.046	0	0	0	1
PL.2752	PL.3333	C	#4 ACSR	7.27Y	121.2	0.00	3.85	0.36	0	3	1	95	0.00	0.0	11.054	0.041	3	1	1	1
PL.2751	PL.2848	C	#1/0 ACSR	7.27Y	121.1	0.02	3.86	7.31	3	51	14	96	0.01	0.0	10.976	0.089	0	0	0	12
PL.3020	PL.2751	C	#1/0 ACSR	7.27Y	121.1	0.02	3.88	7.31	3	51	14	96	0.01	0.0	11.098	0.122	0	0	0	12
PL.3021	PL.3020	C	#1/0 ACSR	7.27Y	121.1	0.02	3.90	7.31	3	51	14	96	0.01	0.0	11.229	0.131	0	0	0	12
PL.3022	PL.3021	C	#1/0 ACSR	7.26Y	121.1	0.03	3.93	7.31	3	51	14	96	0.01	0.0	11.378	0.149	0	0	0	12
PL.3023	PL.3022	C	#1/0 ACSR	7.26Y	121.1	0.02	3.95	7.31	3	51	14	96	0.01	0.0	11.491	0.113	0	0	0	12
PL.3024	PL.3023	C	#1/0 ACSR	7.26Y	121.0	0.03	3.97	7.31	3	51	14	96	0.01	0.0	11.643	0.152	0	0	0	12
PL.3025	PL.3024	C	#1/0 ACSR	7.26Y	121.0	0.02	3.99	7.31	3	51	14	96	0.01	0.0	11.775	0.133	0	0	0	12
PL.3026	PL.3025	C	#1/0 ACSR	7.26Y	121.0	0.02	4.02	7.31	3	51	14	96	0.01	0.0	11.918	0.143	0	0	0	12
PL.3027	PL.3026	C	#1/0 ACSR	7.26Y	121.0	0.01	4.03	7.31	3	51	14	96	0.00	0.0	12.004	0.086	8	2	2	12
PL.2753	PL.3027	C	#4 ACSR	7.26Y	121.0	0.02	4.05	6.22	5	43	12	96	0.01	0.0	12.065	0.061	0	0	0	10
PL.2849	PL.2753	C	#4 ACSR	7.26Y	120.9	0.02	4.07	4.07	3	28	8	96	0.00	0.0	12.158	0.093	0	0	0	7
PL.3338	PL.2849	C	#4 ACSR	7.26Y	120.9	0.01	4.08	4.07	3	28	8	96	0.00	0.0	12.239	0.080	4	1	1	7
PL.3339	PL.3338	C	#4 ACSR	7.25Y	120.9	0.01	4.09	3.45	3	24	7	96	0.00	0.0	12.373	0.134	22	6	3	6
PL.3340	PL.3339	C	#4 ACSR	7.25Y	120.9	0.00	4.09	0.34	0	2	1	89	0.00	0.0	12.480	0.107	0	0	0	3
PL.2755	PL.3340	C	#4 ACSR	7.25Y	120.9	0.00	4.09	0.34	0	2	1	89	0.00	0.0	12.637	0.157	0	0	0	3
PL.3028	PL.2755	C	#4 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.693	0.057	0	0	0	3
PL.2756	PL.3028	C	#4 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.732	0.039	0	0	0	3
PL.2757	PL.2756	C	#2 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.817	0.084	0	0	0	3
PL.3029	PL.2757	C	#2 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.900	0.084	0	0	0	3
PL.3341	PL.3029	C	#2 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.942	0.042	0	0	1	3
PL.3342	PL.3341	C	#2 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	12.992	0.050	0	0	1	2
PL.2758	PL.3342	C	#2 ACSR	7.25Y	120.9	0.00	4.10	0.34	0	2	1	89	0.00	0.0	13.033	0.041	2	1	1	1
PL.2754	PL.2753	C	#2 ACSR	7.26Y	120.9	0.00	4.05	2.15	1	15	4	97	0.00	0.0	12.099	0.034	15	4	3	3
PL.2746	PL.3132	C	6 A (CWC)	7.35Y	122.5	0.00	2.48	1.34	1	9	3	95	0.00	0.0	9.168	0.080	9	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2745	PL.3013	C	#2 ACSR	7.36Y	122.7	0.00	2.29	0.46	0	3	1	95	0.00	0.0	8.975	0.044	3	1	2	2
PL.2744	PL.3138	C	#2 ACSR	7.41Y	123.5	0.00	1.48	0.37	0	3	1	95	0.00	0.0	8.352	0.030	3	1	1	1
PL.3609	PL.2726	ABC	#1/0 ACSR	7.18Y	119.6	0.03	5.41	18.40	8	382	107	96	0.07	0.0	7.881	0.077	0	0	0	107
PD.439	PL.3609	ABC	35L	7.18Y	119.6	0.00	5.41	18.40	53	381	107	96	0.00	0.0	7.881	0.077	0	0	0	107
PL.3610	PD.439	ABC	#1/0 ACSR	7.17Y	119.5	0.05	5.46	18.40	8	381	107	96	0.14	0.0	8.035	0.155	0	0	1	107
PL.2933	PL.3610	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.48	18.40	8	381	106	96	0.05	0.0	8.089	0.053	0	0	0	106
PL.2850	PL.2933	ABC	#1/0 ACSR	7.17Y	119.5	0.03	5.51	18.40	8	381	106	96	0.09	0.0	8.189	0.100	0	0	0	104
PL.3452	PL.2850	C	#4 ACSR	7.17Y	119.5	0.00	5.51	0.00	0	0	0	100	0.00	0.0	8.194	0.005	0	0	0	0
PD.388	PL.3452	C	40QA	7.17Y	119.5	0.00	5.51	0.00	0	0	0	100	0.00	0.0	8.194	0.005	0	0	0	0
PL.3453	PD.388	C	#4 ACSR	7.17Y	119.5	0.00	5.51	0.00	0	0	0	100	0.00	0.0	8.236	0.042	0	0	0	0
PL.3180	PL.2850	ABC	#1/0 ACSR	7.17Y	119.5	0.03	5.55	18.40	8	381	106	96	0.09	0.0	8.293	0.104	17	5	2	104
PL.3181	PL.3180	ABC	#1/0 ACSR	7.17Y	119.4	0.02	5.56	17.57	8	364	101	96	0.05	0.0	8.349	0.056	0	0	0	102
PL.3454	PL.3181	C	#4 ACSR	7.17Y	119.4	0.00	5.56	0.89	1	6	2	95	0.00	0.0	8.354	0.005	0	0	0	1
PD.389	PL.3454	C	40QA	7.17Y	119.4	0.00	5.56	0.89	2	6	2	95	0.00	0.0	8.354	0.005	0	0	0	1
PL.3455	PD.389	C	#4 ACSR	7.17Y	119.4	0.00	5.56	0.89	1	6	2	95	0.00	0.0	8.372	0.018	6	2	1	1
PL.2851	PL.3181	ABC	#1/0 ACSR	7.16Y	119.4	0.03	5.59	17.27	8	358	100	96	0.07	0.0	8.436	0.087	0	0	0	101
PL.3030	PL.2851	ABC	#1/0 ACSR	7.16Y	119.4	0.03	5.63	17.27	8	358	100	96	0.09	0.0	8.547	0.111	0	0	0	101
PL.3031	PL.3030	ABC	#1/0 ACSR	7.16Y	119.3	0.03	5.66	17.27	8	357	100	96	0.09	0.0	8.658	0.111	0	0	0	101
PL.3032	PL.3031	ABC	#1/0 ACSR	7.16Y	119.3	0.03	5.69	17.27	8	357	99	96	0.08	0.0	8.763	0.105	0	0	0	101
PL.3574	PL.3032	C	#4 ACSR	7.16Y	119.3	0.00	5.69	6.93	5	48	13	97	0.00	0.0	8.767	0.004	0	0	0	22
PD.422	PL.3574	C	40QA	7.16Y	119.3	0.00	5.69	6.93	17	48	13	97	0.00	0.0	8.767	0.004	0	0	0	22
PL.3575	PD.422	C	#4 ACSR	7.16Y	119.3	0.00	5.70	6.93	5	48	13	97	0.00	0.0	8.780	0.013	1	0	1	22
PL.2728	PL.3575	C	#4 ACSR	7.16Y	119.3	0.01	5.71	6.83	5	47	13	96	0.00	0.0	8.809	0.029	6	2	1	21
PL.2730	PL.2728	C	#4 ACSR	7.16Y	119.3	0.01	5.71	5.90	5	41	11	97	0.00	0.0	8.830	0.021	0	0	0	20
PL.3184	PL.2730	C	#4 ACSR	7.16Y	119.3	0.00	5.72	5.90	5	41	11	97	0.00	0.0	8.845	0.015	0	0	1	20
PL.3185	PL.3184	C	#4 ACSR	7.16Y	119.3	0.01	5.73	5.90	5	41	11	97	0.00	0.0	8.894	0.050	1	0	2	19
PL.3186	PL.3185	C	#4 ACSR	7.15Y	119.2	0.03	5.76	5.69	4	39	11	96	0.01	0.0	9.023	0.129	0	0	0	17
PL.3078	PL.3186	C	#4 ACSR	7.15Y	119.2	0.02	5.78	5.69	4	39	11	96	0.01	0.0	9.096	0.073	0	0	0	17
PL.3033	PL.3078	C	#4 ACSR	7.15Y	119.2	0.02	5.80	5.69	4	39	11	96	0.01	0.0	9.190	0.094	0	0	0	17
PL.3314	PL.3033	C	#4 ACSR	7.15Y	119.2	0.02	5.83	5.69	4	39	11	96	0.01	0.0	9.293	0.103	3	1	1	17
PL.3315	PL.3314	C	#4 ACSR	7.15Y	119.2	0.01	5.84	5.19	4	36	10	96	0.00	0.0	9.351	0.058	3	1	1	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3313	PL.3315	C	#4 ACSR	7.15Y	119.1	0.03	5.88	4.82	4	33	9	96	0.01	0.0	9.521	0.170	5	1	1	15
PL.3311	PL.3313	C	#4 ACSR	7.15Y	119.1	0.01	5.88	3.59	3	25	7	96	0.00	0.0	9.577	0.056	0	0	1	10
PL.3312	PL.3311	C	#4 ACSR	7.15Y	119.1	0.01	5.90	3.59	3	25	7	96	0.00	0.0	9.653	0.076	3	1	1	9
PL.3308	PL.3312	C	#4 ACSR	7.15Y	119.1	0.00	5.90	3.21	2	22	6	96	0.00	0.0	9.668	0.015	2	1	2	8
PL.3309	PL.3308	C	#4 ACSR	7.15Y	119.1	0.00	5.90	2.92	2	20	6	96	0.00	0.0	9.717	0.049	13	4	5	6
PL.3310	PL.3309	C	#4 ACSR	7.15Y	119.1	0.00	5.90	1.00	1	7	2	96	0.00	0.0	9.758	0.041	7	2	1	1
PL.2731	PL.3313	C	#4 ACSR	7.15Y	119.1	0.00	5.88	0.27	0	2	1	89	0.00	0.0	9.593	0.072	2	1	2	2
PL.3316	PL.3313	C	#4 ACSR	7.15Y	119.1	0.00	5.88	0.29	0	2	1	89	0.00	0.0	9.563	0.042	2	1	1	2
PL.3317	PL.3316	C	#4 ACSR	7.15Y	119.1	0.00	5.88	0.03	0	0	0	100	0.00	0.0	9.596	0.033	0	0	1	1
PL.2852	PL.3032	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.72	14.96	7	309	86	96	0.05	0.0	8.851	0.088	0	0	0	79
PL.3034	PL.2852	ABC	#1/0 ACSR	7.15Y	119.2	0.04	5.75	14.96	7	309	86	96	0.08	0.0	8.990	0.139	0	0	0	79
PL.2853	PL.3034	ABC	#1/0 ACSR	7.15Y	119.2	0.02	5.78	14.80	6	306	85	96	0.05	0.0	9.069	0.079	0	0	0	78
PL.2900	PL.2853	C	#2 ACSR 6/	7.15Y	119.2	0.00	5.78	2.07	1	14	4	96	0.00	0.0	9.079	0.010	8	2	1	2
PL.2901	PL.2900	C	#2 ACSR 6/	7.15Y	119.2	0.00	5.78	0.95	1	7	2	96	0.00	0.0	9.114	0.035	7	2	1	1
PL.3434	PL.2853	A	#4 ACSR	7.15Y	119.2	0.00	5.78	6.15	5	42	12	96	0.00	0.0	9.074	0.005	0	0	0	8
PD.379	PL.3434	A	40QA	7.15Y	119.2	0.00	5.78	6.15	15	42	12	96	0.00	0.0	9.074	0.005	0	0	0	8
PL.3435	PD.379	A	#4 ACSR	7.15Y	119.2	0.01	5.79	6.15	5	42	12	96	0.00	0.0	9.112	0.038	0	0	0	8
PL.2904	PL.3435	A	#4 ACSR	7.15Y	119.2	0.01	5.79	3.08	2	21	6	96	0.00	0.0	9.172	0.061	1	0	1	4
PL.2909	PL.2904	A	#4 ACSR	7.15Y	119.2	0.00	5.80	2.93	2	20	6	96	0.00	0.0	9.246	0.073	20	6	3	3
PL.2910	PL.2909	A	#4 ACSR	7.15Y	119.2	0.00	5.80	0.00	0	0	0	100	0.00	0.0	9.291	0.045	0	0	0	0
PL.2734	PL.3435	A	#4 ACSR	7.15Y	119.2	0.01	5.79	3.06	2	21	6	96	0.00	0.0	9.160	0.048	2	0	1	4
PL.2733	PL.2734	A	#4 ACSR	7.15Y	119.2	0.00	5.79	1.09	1	8	2	97	0.00	0.0	9.174	0.014	8	2	1	1
PL.2732	PL.2734	A	#4 ACSR	7.15Y	119.2	0.00	5.80	1.74	1	12	3	97	0.00	0.0	9.209	0.049	12	3	2	2
PL.2902	PL.2853	ABC	#1/0 ACSR	7.15Y	119.2	0.02	5.79	12.06	5	249	69	96	0.03	0.0	9.139	0.070	2	1	1	68
PL.2903	PL.2902	ABC	#1/0 ACSR	7.15Y	119.2	0.01	5.80	11.94	5	247	69	96	0.03	0.0	9.206	0.067	0	0	0	67
PL.3035	PL.2903	ABC	#1/0 ACSR	7.15Y	119.2	0.01	5.82	11.94	5	247	69	96	0.02	0.0	9.272	0.066	0	0	0	67
PL.2907	PL.3035	ABC	#1/0 ACSR	7.15Y	119.2	0.03	5.85	11.94	5	247	69	96	0.05	0.0	9.412	0.140	0	0	0	67
PL.2908	PL.2907	ABC	#1/0 ACSR	7.15Y	119.1	0.01	5.86	11.94	5	247	69	96	0.02	0.0	9.469	0.057	5	1	3	67
PL.2906	PL.2908	ABC	#1/0 ACSR	7.15Y	119.1	0.02	5.88	11.73	5	242	67	96	0.03	0.0	9.546	0.077	6	2	1	64
PL.2905	PL.2906	ABC	#1/0 ACSR	7.15Y	119.1	0.02	5.90	11.46	5	237	66	96	0.03	0.0	9.645	0.099	0	0	0	63
PL.3036	PL.2905	ABC	#1/0 ACSR	7.15Y	119.1	0.02	5.92	11.46	5	237	66	96	0.03	0.0	9.729	0.084	0	0	0	63

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3037	PL.3036	ABC	#1/0 ACSR	7.14Y	119.1	0.02	5.94	11.46	5	237	66	96	0.04	0.0	9.833	0.104	0	0	0	63
PL.3038	PL.3037	ABC	#1/0 ACSR	7.14Y	119.1	0.01	5.94	11.46	5	237	66	96	0.01	0.0	9.859	0.026	0	0	0	63
PL.2854	PL.3038	ABC	#1/0 ACSR	7.14Y	119.0	0.02	5.96	11.12	5	230	64	96	0.03	0.0	9.960	0.101	0	0	0	59
PL.2735	PL.2854	A	#1/0 ACSR	7.14Y	119.0	0.00	5.96	1.23	1	8	2	97	0.00	0.0	9.997	0.037	8	2	1	1
PL.2855	PL.2854	ABC	#1/0 ACSR	7.14Y	119.0	0.02	5.98	10.71	5	221	61	96	0.03	0.0	10.058	0.098	0	0	0	58
PL.3039	PL.2855	ABC	#1/0 ACSR	7.14Y	119.0	0.02	6.00	10.71	5	221	61	96	0.03	0.0	10.142	0.084	0	0	0	58
PL.3040	PL.3039	ABC	#1/0 ACSR	7.14Y	119.0	0.02	6.02	10.71	5	221	61	96	0.03	0.0	10.233	0.090	0	0	0	58
PL.3142	PL.3040	ABC	#1/0 ACSR	7.14Y	119.0	0.02	6.03	10.71	5	221	61	96	0.03	0.0	10.326	0.093	4	1	1	58
PL.3295	PL.3142	ABC	#1/0 ACSR	7.14Y	118.9	0.02	6.05	10.00	4	206	57	96	0.03	0.0	10.439	0.113	2	1	1	52
PL.3296	PL.3295	ABC	#1/0 ACSR	7.14Y	118.9	0.01	6.06	9.89	4	204	57	96	0.01	0.0	10.489	0.049	0	0	0	51
PL.2936	PL.3296	C	#2 ACSR	7.14Y	118.9	0.00	6.06	1.18	1	8	2	97	0.00	0.0	10.493	0.005	0	0	0	1
PD.407	PL.2936	C	40QA	7.14Y	118.9	0.00	6.06	1.18	3	8	2	97	0.00	0.0	10.493	0.005	0	0	0	1
PL.2937	PD.407	C	#2 ACSR	7.14Y	118.9	0.00	6.06	1.18	1	8	2	97	0.00	0.0	10.534	0.041	8	2	1	1
PL.2856	PL.3296	ABC	#1/0 ACSR	7.14Y	118.9	0.01	6.07	9.50	4	196	54	96	0.02	0.0	10.552	0.063	0	0	0	50
PL.3486	PL.2856	A	#1/0 ACSR	7.14Y	118.9	0.00	6.07	8.10	4	56	15	97	0.00	0.0	10.556	0.005	0	0	0	16
PD.405	PL.3486	A	40QA	7.14Y	118.9	0.00	6.07	8.10	20	56	15	97	0.00	0.0	10.556	0.005	0	0	0	16
PL.3487	PD.405	A	#1/0 ACSR	7.14Y	118.9	0.00	6.08	8.10	4	56	15	97	0.00	0.0	10.575	0.019	0	0	0	16
PL.3297	PL.3487	A	#1/0 ACSR	7.13Y	118.9	0.01	6.09	8.10	4	56	15	97	0.00	0.0	10.633	0.057	0	0	0	16
PL.3280	PL.3297	A	#1/0 ACSR	7.13Y	118.9	0.02	6.11	8.10	4	56	15	97	0.01	0.0	10.747	0.115	0	0	0	16
PL.3281	PL.3280	A	#1/0 ACSR	7.13Y	118.9	0.01	6.12	8.10	4	56	15	97	0.00	0.0	10.833	0.086	16	4	3	16
PL.3282	PL.3281	A	#1/0 ACSR	7.13Y	118.9	0.02	6.14	5.82	3	40	11	96	0.00	0.0	10.946	0.113	0	0	2	13
PL.2896	PL.3282	A	#1/0 ACSR	7.13Y	118.9	0.01	6.15	5.75	2	40	11	96	0.00	0.0	11.025	0.078	18	5	6	11
PL.2897	PL.2896	A	#1/0 ACSR	7.13Y	118.8	0.00	6.15	3.20	1	22	6	96	0.00	0.0	11.083	0.058	0	0	1	5
PL.2898	PL.2897	A	#1/0 ACSR	7.13Y	118.8	0.01	6.16	2.02	1	14	4	96	0.00	0.0	11.233	0.151	2	1	1	3
PL.2899	PL.2898	A	#1/0 ACSR	7.13Y	118.8	0.00	6.16	1.75	1	12	3	97	0.00	0.0	11.257	0.024	0	0	0	2
PL.2858	PL.2899	A	#1/0 ACSR	7.13Y	118.8	0.00	6.16	0.88	0	6	2	95	0.00	0.0	11.290	0.033	6	2	1	1
PL.2736	PL.2899	A	#4 ACSR	7.13Y	118.8	0.00	6.16	0.87	1	6	2	95	0.00	0.0	11.285	0.028	6	2	1	1
PL.2737	PL.2897	A	#2 ACSR	7.13Y	118.8	0.00	6.15	1.12	1	8	2	97	0.00	0.0	11.114	0.032	8	2	1	1
PL.2857	PL.2856	ABC	#1/0 ACSR	7.14Y	118.9	0.01	6.08	6.80	3	140	39	96	0.01	0.0	10.595	0.043	0	0	0	34
PL.2934	PL.2857	A	#2 ACSR	7.14Y	118.9	0.00	6.08	1.51	1	10	3	96	0.00	0.0	10.599	0.005	0	0	0	2
PD.406	PL.2934	A	40QA	7.14Y	118.9	0.00	6.08	1.51	4	10	3	96	0.00	0.0	10.599	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2935	PD.406	A	#2 ACSR	7.14Y	118.9	0.00	6.08	1.51	1	10	3	96	0.00	0.0	10.621	0.022	10	3	2	2
PL.2859	PL.2857	ABC	#1/0 ACSR	7.14Y	118.9	0.00	6.08	6.29	3	130	36	96	0.00	0.0	10.638	0.044	0	0	0	32
PL.3484	PL.2859	A	#4 ACSR	7.13Y	118.9	0.00	6.09	18.88	15	130	36	96	0.00	0.0	10.643	0.005	0	0	0	32
PD.404	PL.3484	A	25T	7.13Y	118.9	0.00	6.09	18.88	0	130	36	96	0.00	0.0	10.643	0.005	0	0	0	32
PL.3485	PD.404	A	#4 ACSR	7.13Y	118.9	0.04	6.13	18.88	15	130	36	96	0.04	0.0	10.691	0.048	11	3	3	32
PL.3279	PL.3485	A	#4 ACSR	7.13Y	118.8	0.12	6.25	17.30	13	119	33	96	0.11	0.1	10.853	0.162	7	2	2	29
PL.3278	PL.3279	A	#4 ACSR	7.12Y	118.7	0.04	6.28	16.31	13	112	31	96	0.03	0.0	10.904	0.052	4	1	2	27
PL.3277	PL.3278	A	#4 ACSR	7.12Y	118.6	0.11	6.39	15.71	12	108	30	96	0.09	0.1	11.059	0.155	0	0	0	25
PL.3293	PL.3277	A	#4 ACSR	7.11Y	118.5	0.06	6.45	15.71	12	108	30	96	0.05	0.0	11.144	0.084	5	1	1	25
PL.3294	PL.3293	A	#4 ACSR	7.11Y	118.5	0.07	6.52	15.00	12	103	28	96	0.06	0.1	11.254	0.110	0	0	0	24
PL.2738	PL.3294	A	#4 ACSR	7.10Y	118.4	0.06	6.58	15.00	12	103	28	96	0.05	0.0	11.345	0.091	0	0	0	24
PL.3290	PL.2738	A	#4 ACSR	7.10Y	118.4	0.06	6.65	15.00	12	103	28	96	0.05	0.0	11.446	0.102	11	3	1	24
PL.3291	PL.3290	A	#4 ACSR	7.10Y	118.3	0.03	6.68	13.38	10	92	25	97	0.02	0.0	11.492	0.046	4	1	2	23
PL.3292	PL.3291	A	#4 ACSR	7.10Y	118.3	0.06	6.74	12.77	10	87	24	96	0.04	0.0	11.597	0.104	0	0	0	21
PL.3041	PL.3292	A	#4 ACSR	7.09Y	118.2	0.06	6.79	12.77	10	87	24	96	0.04	0.0	11.699	0.102	0	0	0	21
PL.2740	PL.3041	A	#2 ACSR	7.09Y	118.2	0.00	6.80	2.12	1	14	4	96	0.00	0.0	11.765	0.066	14	4	2	2
PL.2739	PL.3041	A	#4 ACSR	7.09Y	118.2	0.05	6.84	10.65	8	73	20	96	0.03	0.0	11.804	0.105	11	3	2	19
PL.3288	PL.2739	A	#4 ACSR	7.09Y	118.2	0.00	6.84	1.80	1	12	3	97	0.00	0.0	11.879	0.075	11	3	2	3
PL.3289	PL.3288	A	#4 ACSR	7.09Y	118.2	0.00	6.84	0.26	0	2	0	100	0.00	0.0	11.949	0.071	2	0	1	1
PL.3285	PL.3289	A	#4 ACSR	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	12.100	0.150	0	0	0	0
PL.3042	PL.3285	A	#4 ACSR	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	12.206	0.106	0	0	0	0
PL.3079	PL.3042	A	#4 ACSR	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	12.286	0.080	0	0	0	0
PL.3043	PL.3079	A	#4 ACSR	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	12.345	0.059	0	0	0	0
PL.3286	PL.2739	A	#4 ACSR	7.09Y	118.1	0.02	6.86	7.31	6	50	14	96	0.01	0.0	11.862	0.058	1	0	2	14
PL.3287	PL.3286	A	#4 ACSR	7.09Y	118.1	0.01	6.87	7.12	5	49	13	97	0.01	0.0	11.917	0.055	14	4	1	12
PL.3283	PL.3287	A	#4 ACSR	7.09Y	118.1	0.01	6.88	5.03	4	34	9	97	0.00	0.0	11.967	0.050	9	3	3	11
PL.3284	PL.3283	A	#4 ACSR	7.09Y	118.1	0.01	6.89	3.70	3	25	7	96	0.00	0.0	12.006	0.039	6	2	1	8
PL.3301	PL.3284	A	#4 ACSR	7.09Y	118.1	0.02	6.91	2.83	2	19	5	97	0.00	0.0	12.147	0.141	0	0	0	7
PL.3302	PL.3301	A	#4 ACSR	7.08Y	118.1	0.02	6.92	2.83	2	19	5	97	0.00	0.0	12.281	0.134	0	0	0	7
PL.3044	PL.3302	A	#4 ACSR	7.08Y	118.1	0.01	6.93	2.83	2	19	5	97	0.00	0.0	12.355	0.074	0	0	0	7
PL.2741	PL.3044	A	#4 ACSR	7.08Y	118.1	0.00	6.94	1.40	1	10	3	96	0.00	0.0	12.422	0.067	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3298	PL.2741	A	#4 ACSR	7.08Y	118.1	0.01	6.94	1.40	1	10	3	96	0.00	0.0	12.537	0.115	1	0	2	5
PL.3299	PL.3298	A	#4 ACSR	7.08Y	118.1	0.00	6.95	1.30	1	9	2	98	0.00	0.0	12.613	0.076	0	0	0	3
PL.3300	PL.3299	A	#4 ACSR	7.08Y	118.0	0.01	6.96	1.30	1	9	2	98	0.00	0.0	12.744	0.130	0	0	0	3
PL.3303	PL.3300	A	#4 ACSR	7.08Y	118.0	0.00	6.96	1.30	1	9	2	98	0.00	0.0	12.891	0.147	9	2	3	3
PL.3304	PL.3303	A	#4 ACSR	7.08Y	118.0	0.00	6.96	0.00	0	0	0	100	0.00	0.0	13.019	0.128	0	0	0	0
PL.2743	PL.3304	A	#4 ACSR	7.08Y	118.0	0.00	6.96	0.00	0	0	0	100	0.00	0.0	13.077	0.058	0	0	0	0
PL.2742	PL.3044	A	#4 ACSR	7.08Y	118.1	0.00	6.93	1.43	1	10	3	96	0.00	0.0	12.405	0.050	10	3	2	2
PL.3482	PL.3142	A	#2 ACSR	7.14Y	119.0	0.00	6.03	1.56	1	11	3	96	0.00	0.0	10.330	0.005	0	0	0	5
PD.403	PL.3482	A	40QA	7.14Y	119.0	0.00	6.03	1.56	4	11	3	96	0.00	0.0	10.330	0.005	0	0	0	5
PL.3483	PD.403	A	#2 ACSR	7.14Y	119.0	0.00	6.03	1.56	1	11	3	96	0.00	0.0	10.358	0.028	11	3	5	5
PL.3438	PL.3038	A	#4 ACSR	7.14Y	119.1	0.00	5.94	1.01	1	7	2	96	0.00	0.0	9.864	0.005	0	0	0	4
PD.381	PL.3438	A	40QA	7.14Y	119.1	0.00	5.94	1.01	3	7	2	96	0.00	0.0	9.864	0.005	0	0	0	4
PL.3439	PD.381	A	#4 ACSR	7.14Y	119.1	0.00	5.94	1.01	1	7	2	96	0.00	0.0	9.918	0.054	7	2	4	4
PL.3436	PL.3034	C	#2 ACSR	7.15Y	119.2	0.00	5.75	0.47	0	3	1	95	0.00	0.0	8.994	0.005	0	0	0	1
PD.380	PL.3436	C	40QA	7.15Y	119.2	0.00	5.75	0.47	1	3	1	95	0.00	0.0	8.994	0.005	0	0	0	1
PL.3437	PD.380	C	#2 ACSR	7.15Y	119.2	0.00	5.75	0.47	0	3	1	95	0.00	0.0	9.011	0.016	3	1	1	1
PL.3450	PL.2933	C	#4 ACSR	7.17Y	119.5	0.00	5.48	0.00	0	0	0	100	0.00	0.0	8.094	0.005	0	0	0	2
PD.387	PL.3450	C	40QA	7.17Y	119.5	0.00	5.48	0.00	0	0	0	100	0.00	0.0	8.094	0.005	0	0	0	2
PL.3451	PD.387	C	#4 ACSR	7.17Y	119.5	0.00	5.48	0.00	0	0	0	100	0.00	0.0	8.105	0.012	0	0	1	2
PL.3179	PL.3451	C	#4 ACSR	7.17Y	119.5	0.00	5.48	0.00	0	0	0	100	0.00	0.0	8.177	0.072	0	0	1	1
PL.2722	PL.2847	A	#1/0 ACSR	7.24Y	120.7	0.00	4.34	0.34	0	2	1	89	0.00	0.0	6.430	0.035	2	1	1	1
PL.3446	PL.3612	A	6 A (CWC)	7.25Y	120.9	0.00	4.09	0.50	0	3	1	95	0.00	0.0	6.118	0.005	0	0	0	3
PD.385	PL.3446	A	15T	7.25Y	120.9	0.00	4.09	0.50	0	3	1	95	0.00	0.0	6.118	0.005	0	0	0	3
PL.3447	PD.385	A	6 A (CWC)	7.25Y	120.9	0.00	4.09	0.50	0	3	1	95	0.00	0.0	6.210	0.092	1	0	1	3
PL.2709	PL.3447	A	#4 ACSR	7.25Y	120.9	0.00	4.09	0.36	0	3	1	95	0.00	0.0	6.250	0.040	3	1	2	2
PL.2710	PL.3447	A	6 A (CWC)	7.25Y	120.9	0.00	4.09	0.00	0	0	0	100	0.00	0.0	6.247	0.037	0	0	0	0
CP.6	PL.3611	ABC	Cap (300)	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	6.010	0.037	0	0	0	0
PL.3456	PL.3190	A	#4 ACSR	7.34Y	122.4	0.00	2.62	1.88	1	13	4	96	0.00	0.0	4.688	0.005	0	0	0	4
PD.390	PL.3456	A	10T	7.34Y	122.4	0.00	2.62	1.88	0	13	4	96	0.00	0.0	4.688	0.005	0	0	0	4
PL.3457	PD.390	A	#4 ACSR	7.34Y	122.4	0.00	2.62	1.88	1	13	4	96	0.00	0.0	4.738	0.050	13	4	4	4
PL.3468	PL.2686	A	6 A (CWC)	7.38Y	123.0	0.00	1.95	0.84	1	6	2	95	0.00	0.0	4.117	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.397	PL.3468	A	40QA	7.38Y	123.0	0.00	1.95	0.84	2	6	2	95	0.00	0.0	4.117	0.005	0	0	0	1
PL.3469	PD.397	A	6 A (CWC)	7.38Y	123.0	0.00	1.96	0.84	1	6	2	95	0.00	0.0	4.175	0.058	6	2	1	1
PL.2684	PL.2683	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.79	18.86	8	403	113	96	0.08	0.0	4.037	0.089	1	0	3	127
PL.3218	PL.2684	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.81	18.81	8	402	112	96	0.07	0.0	4.112	0.075	0	0	1	124
PL.3601	PL.3218	ABC	#1/0 ACSR	7.39Y	123.2	0.00	1.82	18.79	8	401	112	96	0.00	0.0	4.117	0.005	0	0	0	123
PD.435	PL.3601	ABC	70L	7.39Y	123.2	0.00	1.82	18.79	27	401	112	96	0.00	0.0	4.117	0.005	0	0	0	123
PL.3602	PD.435	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.84	18.79	8	401	112	96	0.08	0.0	4.201	0.084	3	1	1	123
PL.3219	PL.3602	ABC	#1/0 ACSR	7.39Y	123.1	0.03	1.87	18.64	8	398	111	96	0.08	0.0	4.290	0.088	2	0	1	122
PL.3220	PL.3219	ABC	#1/0 ACSR	7.39Y	123.1	0.03	1.90	18.56	8	396	111	96	0.07	0.0	4.371	0.082	18	5	4	121
PL.3221	PL.3220	ABC	#1/0 ACSR	7.38Y	123.1	0.02	1.92	17.71	8	378	106	96	0.05	0.0	4.435	0.064	8	2	4	117
PL.3225	PL.3221	ABC	#1/0 ACSR	7.38Y	123.1	0.01	1.93	17.32	8	370	103	96	0.03	0.0	4.468	0.032	6	2	1	113
PL.3226	PL.3225	ABC	#1/0 ACSR	7.38Y	123.1	0.02	1.95	17.06	7	364	102	96	0.04	0.0	4.517	0.049	0	0	1	112
PL.3227	PL.3226	ABC	#1/0 ACSR	7.38Y	123.0	0.03	1.97	17.06	7	364	102	96	0.07	0.0	4.603	0.086	0	0	0	111
PL.3223	PL.3227	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.00	17.06	7	364	102	96	0.07	0.0	4.690	0.088	6	2	1	111
PL.3224	PL.3223	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.03	16.79	7	358	100	96	0.07	0.0	4.779	0.089	3	1	1	110
PL.3222	PL.3224	ABC	#1/0 ACSR	7.38Y	122.9	0.02	2.05	16.63	7	355	99	96	0.06	0.0	4.861	0.082	4	1	2	109
PL.3474	PL.3222	ABC	#1/0 ACSR	7.38Y	122.9	0.00	2.05	16.30	7	347	97	96	0.00	0.0	4.865	0.005	0	0	0	105
PL.3475	PL.3474	ABC	#1/0 ACSR	7.38Y	122.9	0.03	2.08	16.30	7	347	97	96	0.06	0.0	4.955	0.090	2	0	1	105
PL.3237	PL.3475	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.11	16.22	7	346	96	96	0.08	0.0	5.065	0.110	2	1	1	104
PL.3238	PL.3237	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.14	16.12	7	343	96	96	0.08	0.0	5.176	0.111	8	2	2	103
PL.3236	PL.3238	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.16	15.75	7	336	93	96	0.04	0.0	5.236	0.060	11	3	2	101
PL.3234	PL.3236	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.18	15.25	7	325	90	96	0.05	0.0	5.317	0.081	2	1	1	99
PL.3235	PL.3234	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.20	15.14	7	322	90	96	0.05	0.0	5.397	0.080	5	1	1	98
PL.3233	PL.3235	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.22	14.90	6	317	88	96	0.04	0.0	5.471	0.074	2	1	1	97
PL.3480	PL.3233	A	#2 ACSR	7.37Y	122.8	0.00	2.22	0.55	0	4	1	97	0.00	0.0	5.476	0.005	0	0	0	1
PD.402	PL.3480	A	40QA	7.37Y	122.8	0.00	2.22	0.55	1	4	1	97	0.00	0.0	5.476	0.005	0	0	0	1
PL.3481	PD.402	A	#2 ACSR	7.37Y	122.8	0.00	2.22	0.55	0	4	1	97	0.00	0.0	5.492	0.016	4	1	1	1
PL.3117	PL.3233	ABC	#1/0 ACSR	7.36Y	122.7	0.04	2.26	14.62	6	311	87	96	0.08	0.0	5.618	0.147	0	0	0	95
PL.2829	PL.3117	ABC	#1/0 ACSR	7.36Y	122.7	0.03	2.29	14.50	6	309	86	96	0.06	0.0	5.722	0.104	0	0	0	94
PL.3058	PL.2829	ABC	#1/0 ACSR	7.36Y	122.7	0.02	2.31	14.50	6	309	86	96	0.04	0.0	5.793	0.071	0	0	0	94
PL.2888	PL.3058	ABC	#1/0 ACSR	7.36Y	122.7	0.02	2.33	14.50	6	309	86	96	0.05	0.0	5.881	0.089	0	0	0	94

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3229	PL.2888	ABC	#1/0 ACSR	7.36Y	122.6	0.04	2.37	14.50	6	309	86	96	0.07	0.0	6.016	0.135	6	2	1	94
PL.3230	PL.3229	ABC	#1/0 ACSR	7.36Y	122.6	0.02	2.39	14.24	6	303	84	96	0.05	0.0	6.105	0.089	0	0	0	93
PL.3346	PL.3230	ABC	#1/0 ACSR	7.36Y	122.6	0.02	2.41	14.02	6	298	83	96	0.03	0.0	6.172	0.067	4	1	1	91
PL.3347	PL.3346	ABC	#1/0 ACSR	7.35Y	122.6	0.02	2.43	13.84	6	294	82	96	0.05	0.0	6.269	0.097	4	1	3	90
PL.3597	PL.3347	A	#4 ACSR	7.35Y	122.6	0.00	2.43	6.51	5	46	13	96	0.00	0.0	6.272	0.003	0	0	0	15
PD.433	PL.3597	A	35H	7.35Y	122.6	0.00	2.43	6.51	19	46	13	96	0.00	0.0	6.272	0.003	0	0	0	15
PL.3598	PD.433	A	#4 ACSR	7.35Y	122.6	0.02	2.45	6.51	5	46	13	96	0.01	0.0	6.338	0.066	4	1	1	15
PL.3345	PL.3598	A	#4 ACSR	7.35Y	122.5	0.02	2.47	6.00	5	43	12	96	0.01	0.0	6.416	0.078	0	0	0	14
PL.2764	PL.3345	A	6 A (CWC)	7.35Y	122.5	0.00	2.47	0.00	0	0	0	100	0.00	0.0	6.541	0.125	0	0	0	0
PL.3343	PL.3345	A	#4 ACSR	7.35Y	122.5	0.01	2.48	6.00	5	43	12	96	0.00	0.0	6.471	0.055	0	0	0	14
PL.3344	PL.3343	A	#4 ACSR	7.35Y	122.5	0.04	2.53	6.00	5	43	12	96	0.01	0.0	6.634	0.163	0	0	0	14
PL.2759	PL.3344	A	#4 ACSR	7.35Y	122.4	0.03	2.56	6.00	5	43	12	96	0.01	0.0	6.753	0.120	0	0	0	14
PL.3065	PL.2759	A	#4 ACSR	7.35Y	122.4	0.02	2.58	6.00	5	43	12	96	0.01	0.0	6.824	0.070	0	0	0	14
PL.2889	PL.3065	A	#4 ACSR	7.34Y	122.4	0.04	2.62	6.00	5	43	12	96	0.01	0.0	6.991	0.167	0	0	0	14
PL.2890	PL.2889	A	#4 ACSR	7.34Y	122.3	0.04	2.66	6.00	5	42	12	96	0.01	0.0	7.125	0.135	0	0	0	14
PL.2891	PL.2890	A	#4 ACSR	7.34Y	122.3	0.03	2.69	6.00	5	42	12	96	0.01	0.0	7.225	0.100	0	0	0	14
PL.3348	PL.2891	A	#4 ACSR	7.34Y	122.3	0.01	2.69	6.00	5	42	12	96	0.00	0.0	7.256	0.031	7	2	2	14
PL.3349	PL.3348	A	#4 ACSR	7.34Y	122.3	0.03	2.73	5.06	4	36	10	96	0.01	0.0	7.393	0.137	0	0	0	12
PL.2892	PL.3349	A	#4 ACSR	7.33Y	122.2	0.03	2.76	5.06	4	36	10	96	0.01	0.0	7.535	0.142	0	0	0	12
PL.3123	PL.2892	A	#4 ACSR	7.33Y	122.2	0.03	2.79	5.06	4	36	10	96	0.01	0.0	7.660	0.125	0	0	0	12
PL.3124	PL.3123	A	#4 ACSR	7.33Y	122.2	0.03	2.82	5.06	4	36	10	96	0.01	0.0	7.845	0.185	11	3	3	12
PL.3125	PL.3124	A	#4 ACSR	7.33Y	122.2	0.01	2.83	3.04	2	22	6	96	0.00	0.0	7.952	0.107	4	1	1	8
PL.2767	PL.3125	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.80	1	6	2	95	0.00	0.0	8.079	0.128	0	0	0	4
PL.2830	PL.2767	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.31	0	2	1	89	0.00	0.0	8.139	0.060	0	0	0	3
PL.2831	PL.2830	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.00	0	0	0	100	0.00	0.0	8.174	0.035	0	0	0	0
PL.2769	PL.2830	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.31	0	2	1	89	0.00	0.0	8.226	0.086	0	0	0	3
PL.3350	PL.2769	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.31	0	2	1	89	0.00	0.0	8.320	0.095	1	0	1	3
PL.3351	PL.3350	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.15	0	1	0	100	0.00	0.0	8.481	0.161	0	0	0	2
PL.2893	PL.3351	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.15	0	1	0	100	0.00	0.0	8.586	0.105	0	0	0	2
PL.3066	PL.2893	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.15	0	1	0	100	0.00	0.0	8.656	0.070	0	0	0	2
PL.2894	PL.3066	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.15	0	1	0	100	0.00	0.0	8.729	0.073	1	0	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

12/15/2009 14:57 Page 89

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2768	PL.2767	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.49	0	3	1	95	0.00	0.0	8.124	0.045	3	1	1	1
PL.3126	PL.3125	A	#4 ACSR	7.33Y	122.2	0.00	2.84	0.98	1	7	2	96	0.00	0.0	8.045	0.093	7	2	2	2
PL.4492	PL.3125	A	#1/0 ACSR	7.33Y	122.2	0.00	2.84	0.69	0	5	1	98	0.00	0.0	8.181	0.229	0	0	0	1
PL.4494	PL.4492	A	#1/0 ACSR	7.33Y	122.2	0.00	2.84	0.69	0	5	1	98	0.00	0.0	8.350	0.169	5	1	1	1
PL.4493	PL.4492	A	#1/0 ACSR	7.33Y	122.2	0.00	2.84	0.00	0	0	0	100	0.00	0.0	8.245	0.063	0	0	0	0
PL.2766	PL.3124	A	#4 ACSR	7.33Y	122.2	0.00	2.82	0.39	0	3	1	95	0.00	0.0	7.949	0.104	3	1	1	1
PL.3118	PL.3347	ABC	#1/0 ACSR	7.35Y	122.6	0.01	2.44	11.31	5	241	67	96	0.01	0.0	6.307	0.038	0	0	0	71
PL.3114	PL.3118	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	2.25	1	48	13	97	0.00	0.0	6.383	0.076	10	3	2	10
PL.3115	PL.3114	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	1.61	1	34	9	97	0.00	0.0	6.425	0.042	0	0	0	7
PL.2834	PL.3115	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.89	0	19	5	97	0.00	0.0	6.536	0.111	0	0	0	3
PL.2835	PL.2834	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.40	0	9	2	98	0.00	0.0	6.579	0.043	0	0	0	1
PL.3106	PL.2835	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.40	0	9	2	98	0.00	0.0	6.594	0.015	0	0	0	1
PL.3107	PL.3106	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	6.746	0.151	0	0	0	0
PL.2967	PL.3107	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	6.870	0.125	0	0	0	0
PL.3607	PL.2967	ABC	#1/0 ACSR	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	6.952	0.082	0	0	0	0
PD.438-A	PL.3607	ABC	Open	7.35Y	122.6	0.00	2.44	0.00	0	0	0	100	0.00	0.0	6.952	0.082	0	0	0	0
PL.3578	PL.3106	C	#2 ACSR	7.35Y	122.6	0.00	2.44	1.21	1	9	2	98	0.00	0.0	6.599	0.005	0	0	0	1
PD.424	PL.3578	C	40QA	7.35Y	122.6	0.00	2.44	1.21	3	9	2	98	0.00	0.0	6.599	0.005	0	0	0	1
PL.3579	PD.424	C	#2 ACSR	7.35Y	122.6	0.00	2.44	1.21	1	9	2	98	0.00	0.0	6.645	0.046	9	2	1	1
PL.2940	PL.2834	A	6 A (CWC)	7.35Y	122.6	0.00	2.44	1.46	1	10	3	96	0.00	0.0	6.541	0.005	0	0	0	2
PD.410	PL.2940	A	15T	7.35Y	122.6	0.00	2.44	1.46	0	10	3	96	0.00	0.0	6.541	0.005	0	0	0	2
PL.2941	PD.410	A	6 A (CWC)	7.35Y	122.6	0.01	2.45	1.46	1	10	3	96	0.00	0.0	6.659	0.118	5	1	1	2
PL.3352	PL.2941	A	6 A (CWC)	7.35Y	122.5	0.00	2.45	0.72	1	5	1	98	0.00	0.0	6.746	0.087	5	1	1	1
PL.2762	PL.3115	C	#4 ACSR	7.35Y	122.6	0.00	2.44	2.16	2	15	4	97	0.00	0.0	6.430	0.005	0	0	0	4
PD.409	PL.2762	C	40QA	7.35Y	122.6	0.00	2.44	2.16	5	15	4	97	0.00	0.0	6.430	0.005	0	0	0	4
PL.3110	PD.409	C	#4 ACSR	7.35Y	122.6	0.00	2.44	0.76	1	5	1	98	0.00	0.0	6.445	0.015	0	0	0	1
PL.2763	PL.3110	C	#4 ACSR	7.35Y	122.6	0.00	2.44	0.76	1	5	1	98	0.00	0.0	6.492	0.047	5	1	1	1
PL.3353	PD.409	C	#4 ACSR	7.35Y	122.6	0.00	2.45	1.39	1	10	3	96	0.00	0.0	6.510	0.080	5	2	1	3
PL.3354	PL.3353	C	#4 ACSR	7.35Y	122.6	0.00	2.45	0.63	0	4	1	97	0.00	0.0	6.523	0.013	4	1	2	2
PL.2761	PL.3114	A	#2 ACSR	7.35Y	122.6	0.00	2.44	0.51	0	4	1	97	0.00	0.0	6.441	0.057	4	1	1	1
PL.2942	PL.3118	A	6 A (CWC)	7.35Y	122.6	0.01	2.44	27.20	19	193	54	96	0.01	0.0	6.312	0.005	0	0	0	61

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.411	PL.2942	A	30T	7.35Y	122.6	0.00	2.44	27.20	0	193	54	96	0.00	0.0	6.312	0.005	0	0	0	61
PL.2943	PD.411	A	6 A (CWC)	7.35Y	122.5	0.05	2.50	27.20	19	193	54	96	0.07	0.0	6.353	0.042	2	1	4	61
PL.2760	PL.2943	A	#4 ACSR	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	6.409	0.056	0	0	1	1
PL.3116	PL.2943	A	6 A (CWC)	7.35Y	122.4	0.06	2.56	26.94	19	191	53	96	0.09	0.0	6.405	0.052	6	2	3	56
PL.2794	PL.3116	A	6 A (CWC)	7.34Y	122.4	0.08	2.64	26.08	19	185	51	96	0.11	0.1	6.472	0.066	0	0	0	53
PL.2795	PL.2794	A	6 A (CWC)	7.34Y	122.4	0.00	2.64	2.31	2	16	5	95	0.00	0.0	6.515	0.043	6	2	1	4
PL.2796	PL.2795	A	#4 ACSR	7.34Y	122.4	0.00	2.64	1.42	1	10	3	96	0.00	0.0	6.531	0.016	10	3	3	3
PL.3108	PL.2794	A	6 A (CWC)	7.34Y	122.3	0.07	2.71	23.76	17	168	47	96	0.09	0.1	6.536	0.064	0	0	1	49
PL.3109	PL.3108	A	6 A (CWC)	7.33Y	122.2	0.09	2.80	22.41	16	158	44	96	0.11	0.1	6.628	0.092	3	1	1	46
PL.3105	PL.3109	A	#4 ACSR	7.33Y	122.2	0.00	2.80	2.03	2	14	4	96	0.00	0.0	6.657	0.029	2	1	1	4
PL.2799	PL.3105	A	#4 ACSR	7.33Y	122.2	0.00	2.80	0.37	0	3	1	95	0.00	0.0	6.693	0.037	3	1	1	1
PL.3355	PL.3105	A	#4 ACSR	7.33Y	122.2	0.00	2.80	1.32	1	9	3	95	0.00	0.0	6.695	0.039	9	3	2	2
PL.3356	PL.3355	A	#4 ACSR	7.33Y	122.2	0.00	2.80	0.00	0	0	0	100	0.00	0.0	6.759	0.063	0	0	0	0
PL.3241	PL.3109	A	6 A (CWC)	7.33Y	122.1	0.08	2.88	19.95	14	141	39	96	0.09	0.1	6.718	0.091	3	1	1	41
PL.3242	PL.3241	A	6 A (CWC)	7.32Y	122.1	0.04	2.92	19.57	14	138	38	96	0.04	0.0	6.766	0.048	5	1	1	40
PL.2800	PL.3242	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	2.35	2	17	5	96	0.00	0.0	6.820	0.054	17	5	5	5
PL.3104	PL.3242	A	6 A (CWC)	7.32Y	122.0	0.06	2.99	16.49	12	116	32	96	0.05	0.0	6.861	0.095	33	9	3	34
PL.3102	PL.3104	A	#4 ACSR	7.32Y	122.0	0.03	3.01	11.82	9	83	23	96	0.02	0.0	6.910	0.049	3	1	1	31
PL.3100	PL.3102	A	#4 ACSR	7.32Y	121.9	0.04	3.05	11.31	9	80	22	96	0.02	0.0	6.994	0.083	4	1	1	29
PL.3101	PL.3100	A	#4 ACSR	7.32Y	121.9	0.02	3.07	10.01	8	71	20	96	0.01	0.0	7.035	0.041	0	0	0	24
PL.2802	PL.3101	A	#4 ACSR	7.31Y	121.9	0.05	3.12	9.77	8	69	19	96	0.03	0.0	7.148	0.113	0	0	0	23
PL.10180	PL.2802	A	#4 ACSR	7.31Y	121.8	0.04	3.16	9.77	8	69	19	96	0.02	0.0	7.235	0.087	6	2	1	23
PL.10181	PL.10180	A	#4 ACSR	7.31Y	121.8	0.01	3.17	8.85	7	62	17	96	0.01	0.0	7.263	0.028	2	1	1	22
PL.2806	PL.10181	A	#4 ACSR	7.31Y	121.8	0.01	3.18	8.50	7	60	17	96	0.01	0.0	7.298	0.035	0	0	0	21
PL.3098	PL.2806	A	6 A (CWC)	7.31Y	121.8	0.02	3.20	3.65	3	26	7	97	0.00	0.0	7.407	0.109	8	2	4	7
PL.3099	PL.3098	A	6 A (CWC)	7.31Y	121.8	0.00	3.20	1.16	1	8	2	97	0.00	0.0	7.504	0.097	8	2	1	1
PL.2966	PL.3099	A	6 A (CWC)	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	7.635	0.131	0	0	0	0
PL.3392	PL.2966	A	6 A (CWC)	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	7.682	0.047	0	0	0	0
PD.359-A	PL.3392	A	Open	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	7.682	0.047	0	0	0	0
PL.2809	PL.3098	A	#2 ACSR	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	7.465	0.058	0	0	1	1
PL.2808	PL.3098	A	#4 ACSR	7.31Y	121.8	0.00	3.20	1.29	1	9	3	95	0.00	0.0	7.460	0.053	9	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2807	PL.2806	A	6 A (CWC)	7.31Y	121.8	0.01	3.19	4.85	3	34	9	97	0.00	0.0	7.347	0.049	0	0	0	14
PL.2961	PL.2807	A	6 A (CWC)	7.31Y	121.8	0.02	3.21	4.85	3	34	9	97	0.01	0.0	7.438	0.091	0	0	0	14
PL.2962	PL.2961	A	6 A (CWC)	7.31Y	121.8	0.02	3.23	4.85	3	34	9	97	0.00	0.0	7.511	0.074	0	0	0	14
PL.2963	PL.2962	A	6 A (CWC)	7.30Y	121.7	0.03	3.25	4.85	3	34	9	97	0.01	0.0	7.629	0.117	0	0	0	14
PL.3096	PL.2963	A	6 A (CWC)	7.30Y	121.7	0.01	3.26	3.82	3	27	7	97	0.00	0.0	7.689	0.060	10	3	5	11
PL.2811	PL.3096	A	#4 ACSR	7.30Y	121.7	0.00	3.26	1.03	1	7	2	96	0.00	0.0	7.759	0.070	7	2	1	1
PL.3097	PL.3096	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	1.38	1	10	3	96	0.00	0.0	7.807	0.118	7	2	3	5
PL.3239	PL.3097	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.41	0	3	1	95	0.00	0.0	7.945	0.138	2	1	1	2
PL.3240	PL.3239	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.06	0	0	0	100	0.00	0.0	8.081	0.136	0	0	0	1
PL.2813	PL.3240	A	#1/0 ACSR	7.30Y	121.7	0.00	3.27	0.06	0	0	0	100	0.00	0.0	8.173	0.092	0	0	1	1
PL.10199	PL.3240	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.129	0.048	0	0	0	0
PL.3275	PL.10199	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.230	0.101	0	0	0	0
PL.3276	PL.3275	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.362	0.132	0	0	0	0
PL.2964	PL.3276	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.499	0.137	0	0	0	0
PL.2965	PL.2964	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.553	0.055	0	0	0	0
PL.4477	PL.2965	A	6 A (CWC)	7.30Y	121.7	0.00	3.27	0.00	0	0	0	100	0.00	0.0	8.650	0.096	0	0	0	0
PL.2810	PL.2963	A	#4 ACSR	7.30Y	121.7	0.00	3.25	1.03	1	7	2	96	0.00	0.0	7.681	0.052	7	2	3	3
PL.2833	PL.3101	A	#4 ACSR	7.32Y	121.9	0.00	3.07	0.24	0	2	0	100	0.00	0.0	7.062	0.027	0	0	0	1
PL.2803	PL.2833	A	#4 ACSR	7.32Y	121.9	0.00	3.07	0.24	0	2	0	100	0.00	0.0	7.099	0.037	2	0	1	1
PL.2801	PL.3100	A	#4 ACSR	7.32Y	121.9	0.01	3.06	0.76	1	5	1	98	0.00	0.0	7.148	0.154	0	0	0	4
PL.2804	PL.2801	A	#1/0 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.246	0.098	0	0	1	1
PL.2832	PL.2801	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.76	1	5	1	98	0.00	0.0	7.202	0.054	0	0	0	3
PL.2805	PL.2832	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.221	0.019	0	0	0	0
PL.3244	PL.2832	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.76	1	5	1	98	0.00	0.0	7.316	0.114	1	0	1	3
PL.3245	PL.3244	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.60	0	4	1	97	0.00	0.0	7.344	0.028	4	1	1	2
PL.3243	PL.3245	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.394	0.050	0	0	1	1
PL.3246	PL.3243	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.452	0.058	0	0	0	0
PL.3247	PL.3246	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.572	0.120	0	0	0	0
PL.2895	PL.3247	A	#4 ACSR	7.32Y	121.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	7.645	0.074	0	0	0	0
PL.3103	PL.3102	A	#4 ACSR	7.32Y	122.0	0.00	3.01	0.03	0	0	0	100	0.00	0.0	6.948	0.038	0	0	1	1
PL.2797	PL.3108	A	#4 ACSR	7.34Y	122.3	0.00	2.71	1.35	1	10	3	96	0.00	0.0	6.551	0.016	10	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.2798	PL.2797	A	#2 ACSR	7.34Y	122.3	0.00	2.71	0.00	0	0	0	100	0.00	0.0	6.589	0.037	0	0	0	0
PL.3576	PL.3347	C	#4 ACSR	7.35Y	122.6	0.00	2.43	0.53	0	4	1	97	0.00	0.0	6.274	0.005	0	0	0	1
PD.423	PL.3576	C	40QA	7.35Y	122.6	0.00	2.43	0.53	1	4	1	97	0.00	0.0	6.274	0.005	0	0	0	1
PL.3577	PD.423	C	#4 ACSR	7.35Y	122.6	0.00	2.43	0.53	0	4	1	97	0.00	0.0	6.302	0.028	4	1	1	1
PL.3476	PL.3230	C	#4 ACSR	7.36Y	122.6	0.00	2.39	0.68	1	5	1	98	0.00	0.0	6.110	0.005	0	0	0	2
PD.400	PL.3476	C	40QA	7.36Y	122.6	0.00	2.39	0.68	2	5	1	98	0.00	0.0	6.110	0.005	0	0	0	2
PL.3477	PD.400	C	#4 ACSR	7.36Y	122.6	0.00	2.39	0.68	1	5	1	98	0.00	0.0	6.123	0.014	0	0	1	2
PL.3228	PL.3477	C	#4 ACSR	7.36Y	122.6	0.00	2.39	0.65	1	5	1	98	0.00	0.0	6.168	0.045	5	1	1	1
PL.3478	PL.3117	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	5.623	0.005	0	0	0	1
PD.401	PL.3478	C	40QA	7.36Y	122.7	0.00	2.26	0.34	1	2	1	89	0.00	0.0	5.623	0.005	0	0	0	1
PL.3479	PD.401	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	5.704	0.081	0	0	0	1
PL.3057	PL.3479	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	5.798	0.094	0	0	0	1
PL.2886	PL.3057	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	5.942	0.144	0	0	0	1
PL.2887	PL.2886	C	#1/0 ACSR	7.36Y	122.7	0.00	2.27	0.34	0	2	1	89	0.00	0.0	6.015	0.073	0	0	0	1
PL.25703	PL.2887	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	0.34	0	2	1	89	0.00	0.0	6.084	0.069	0	0	0	1
PD.3629	PL.25703	C	25T	7.36Y	122.7	0.00	2.27	0.34	0	2	1	89	0.00	0.0	6.084	0.069	0	0	0	1
PL.25704	PD.3629	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	0.34	0	2	1	89	0.00	0.0	6.176	0.092	2	1	1	1
PL.3232	PL.25704	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	0.00	0	0	0	100	0.00	0.0	6.202	0.026	0	0	0	0
PL.3472	PL.3222	C	#1/0 ACSR	7.38Y	122.9	0.00	2.05	0.51	0	4	1	97	0.00	0.0	4.865	0.005	0	0	0	2
PD.399	PL.3472	C	40QA	7.38Y	122.9	0.00	2.05	0.51	1	4	1	97	0.00	0.0	4.865	0.005	0	0	0	2
PL.3473	PD.399	C	#1/0 ACSR	7.38Y	122.9	0.00	2.05	0.51	0	4	1	97	0.00	0.0	4.915	0.049	4	1	2	2
PL.4862	PL.3614	C	#4 ACSR	7.41Y	123.4	0.00	1.56	1.52	1	11	3	96	0.00	0.0	3.832	0.003	0	0	0	4
PD.893	PL.4862	C	50QA	7.41Y	123.4	0.00	1.56	1.52	3	11	3	96	0.00	0.0	3.832	0.003	0	0	0	4
PL.4863	PD.893	C	#4 ACSR	7.41Y	123.4	0.00	1.56	1.52	1	11	3	96	0.00	0.0	3.933	0.101	11	3	4	4
PL.2828	PL.3614	B	#4 ACSR	7.41Y	123.4	0.00	1.56	0.27	0	2	1	89	0.00	0.0	3.861	0.033	2	1	1	1
CP.7	PL.3613	ABC	Cap (297)	7.41Y	123.5	0.00	1.47	0.00	0	0	0	100	0.00	0.0	3.778	0.033	0	0	0	0
PL.3414	PL.2670	A	#4 ACSR	7.35Y	122.5	0.00	2.45	0.00	0	0	0	100	0.00	0.0	2.998	0.005	0	0	0	0
PD.370	PL.3414	A	40QA	7.35Y	122.5	0.00	2.45	0.00	0	0	0	100	0.00	0.0	2.998	0.005	0	0	0	0
PL.3415	PD.370	A	#4 ACSR	7.35Y	122.5	0.00	2.45	0.00	0	0	0	100	0.00	0.0	3.073	0.074	0	0	0	0
PL.3400	PL.3050	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.77	1	6	2	95	0.00	0.0	1.864	0.005	0	0	0	1
PD.364	PL.3400	C	40QA	7.41Y	123.5	0.00	1.52	0.77	2	6	2	95	0.00	0.0	1.864	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.3401	PD.364	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.77	1	6	2	95	0.00	0.0	1.897	0.033	6	2	1	1
PL.3566	PL.2595	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	1.587	0.005	0	0	0	0
PD.418	PL.3566	C	40QA	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	1.587	0.005	0	0	0	0
PL.3567	PD.418	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.00	0	0	0	100	0.00	0.0	1.683	0.096	0	0	0	0
PL.3406	PL.2595	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.92	1	7	2	96	0.00	0.0	1.587	0.005	0	0	0	1
PD.367	PL.3406	C	40QA	7.42Y	123.7	0.00	1.33	0.92	2	7	2	96	0.00	0.0	1.587	0.005	0	0	0	1
PL.3407	PD.367	C	#4 ACSR	7.42Y	123.7	0.00	1.33	0.92	1	7	2	96	0.00	0.0	1.660	0.073	7	2	1	1
PL.3398	PL.3091	A	#2 ACSR	7.43Y	123.9	0.00	1.13	7.85	4	56	16	96	0.00	0.0	1.301	0.005	0	0	0	10
PD.363	PL.3398	A	20T	7.43Y	123.9	0.00	1.13	7.85	0	56	16	96	0.00	0.0	1.301	0.005	0	0	0	10
PL.3399	PD.363	A	#2 ACSR	7.43Y	123.9	0.00	1.13	7.85	4	56	16	96	0.00	0.0	1.320	0.019	15	4	3	10
PL.2584	PL.3399	A	#2 ACSR	7.43Y	123.9	0.01	1.14	5.74	3	41	11	97	0.00	0.0	1.383	0.064	18	5	2	7
PL.2586	PL.2584	A	#2 ACSR	7.43Y	123.9	0.00	1.15	3.26	2	23	6	97	0.00	0.0	1.430	0.047	0	0	0	5
PL.2587	PL.2586	A	#2 ACSR	7.43Y	123.9	0.00	1.15	2.45	1	18	5	96	0.00	0.0	1.462	0.032	18	5	4	4
PL.2588	PL.2586	A	#4 ACSR	7.43Y	123.9	0.00	1.15	0.80	1	6	2	95	0.00	0.0	1.526	0.096	0	0	0	1
PL.2590	PL.2588	A	#4 ACSR	7.43Y	123.8	0.00	1.15	0.80	1	6	2	95	0.00	0.0	1.551	0.024	0	0	0	1
PL.2591	PL.2590	A	#4 ACSR	7.43Y	123.8	0.00	1.15	0.80	1	6	2	95	0.00	0.0	1.592	0.041	6	2	1	1
PL.2593	PL.2591	A	#2 ACSR	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	1.744	0.152	0	0	0	0
PL.2582	PL.2865	ABC	336 MCM AC	7.44Y	124.0	0.00	0.97	16.87	3	363	101	96	0.01	0.0	1.114	0.031	11	3	1	89
PL.2691	PL.2582	ABC	#4/0 ACSR	7.44Y	124.0	0.01	0.98	16.34	5	351	98	96	0.02	0.0	1.180	0.066	0	0	0	88
PL.3603	PL.2691	ABC	336 MCM AC	7.44Y	124.0	0.01	0.99	16.34	3	351	98	96	0.01	0.0	1.226	0.046	0	0	0	88
PD.436	PL.3603	ABC	70L	7.44Y	124.0	0.00	0.99	16.34	23	351	98	96	0.00	0.0	1.226	0.046	0	0	0	88
PL.3604	PD.436	ABC	336 MCM AC	7.44Y	124.0	0.01	1.00	16.34	3	351	98	96	0.01	0.0	1.285	0.059	0	0	0	88
PL.3202	PL.3604	ABC	336 MCM AC	7.44Y	124.0	0.01	1.01	15.74	3	338	94	96	0.02	0.0	1.401	0.117	11	3	3	85
PL.3203	PL.3202	ABC	336 MCM AC	7.44Y	124.0	0.00	1.01	15.25	3	328	91	96	0.01	0.0	1.443	0.042	2	1	2	82
PL.3201	PL.3203	ABC	336 MCM AC	7.44Y	124.0	0.01	1.03	15.16	3	326	91	96	0.02	0.0	1.571	0.128	0	0	0	80
PL.3086	PL.3201	ABC	336 MCM AC	7.44Y	124.0	0.01	1.04	15.16	3	326	91	96	0.02	0.0	1.656	0.085	4	1	1	80
PL.3088	PL.3086	ABC	336 MCM AC	7.44Y	124.0	0.01	1.05	14.86	3	319	89	96	0.02	0.0	1.759	0.103	0	0	0	78
PL.2692	PL.3088	B	#2 ACSR	7.44Y	123.9	0.01	1.05	1.67	1	12	3	97	0.00	0.0	1.861	0.102	0	0	0	2
PL.2693	PL.2692	B	#1/0 ACSR	7.44Y	123.9	0.00	1.05	1.67	1	12	3	97	0.00	0.0	1.865	0.005	0	0	0	2
PD.394	PL.2693	B	40QA	7.44Y	123.9	0.00	1.05	1.67	4	12	3	97	0.00	0.0	1.865	0.005	0	0	0	2
PL.3089	PD.394	B	#2 ACSR	7.44Y	123.9	0.00	1.06	1.07	1	8	2	97	0.00	0.0	1.871	0.006	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2700	PL.3089	B	#2 ACSR	7.44Y	123.9	0.00	1.06	1.07	1	8	2	97	0.00	0.0	1.892	0.021	8	2	1	1
PL.2818	PD.394	B	#1/0 ACSR	7.44Y	123.9	0.00	1.06	0.60	0	4	1	97	0.00	0.0	1.945	0.080	4	1	1	1
PL.2817	PL.3088	ABC	336 MCM AC	7.44Y	123.9	0.01	1.06	14.30	3	307	86	96	0.01	0.0	1.824	0.065	0	0	0	76
PL.3460	PL.2817	A	#4 ACSR	7.44Y	123.9	0.00	1.06	0.00	0	0	0	100	0.00	0.0	1.828	0.004	0	0	0	0
PD.392	PL.3460	A	40QA	7.44Y	123.9	0.00	1.06	0.00	0	0	0	100	0.00	0.0	1.828	0.004	0	0	0	0
PL.3461	PD.392	A	#4 ACSR	7.44Y	123.9	0.00	1.06	0.00	0	0	0	100	0.00	0.0	1.842	0.014	0	0	0	0
PL.2819	PL.2817	ABC	336 MCM AC	7.44Y	123.9	0.01	1.07	14.30	3	307	85	96	0.02	0.0	1.932	0.109	0	0	0	76
PL.2820	PL.2819	ABC	336 MCM AC	7.44Y	123.9	0.01	1.08	14.27	3	307	85	96	0.02	0.0	2.056	0.124	0	0	0	75
PL.2867	PL.2820	ABC	336 MCM AC	7.43Y	123.9	0.01	1.09	14.27	3	307	85	96	0.02	0.0	2.158	0.102	0	0	0	75
PL.2868	PL.2867	ABC	336 MCM AC	7.43Y	123.9	0.01	1.11	14.27	3	307	85	96	0.02	0.0	2.288	0.130	0	0	0	75
PL.3595	PL.2868	A	#4 ACSR	7.43Y	123.9	0.00	1.11	27.30	21	195	54	96	0.00	0.0	2.291	0.003	0	0	0	55
PD.432	PL.3595	A	50H	7.43Y	123.9	0.00	1.11	27.30	55	195	54	96	0.00	0.0	2.291	0.003	0	0	0	55
PL.3596	PD.432	A	#4 ACSR	7.43Y	123.8	0.04	1.15	27.30	21	195	54	96	0.06	0.0	2.327	0.036	9	3	2	55
PL.2694	PL.3596	A	#2 ACSR	7.43Y	123.8	0.04	1.19	26.02	15	186	52	96	0.05	0.0	2.377	0.050	0	0	1	53
PL.3080	PL.2694	A	#2 ACSR	7.42Y	123.7	0.07	1.26	25.96	15	186	52	96	0.09	0.0	2.460	0.083	0	0	1	52
PL.3258	PL.3080	A	#2 ACSR	7.42Y	123.7	0.00	1.26	1.69	1	12	3	97	0.00	0.0	2.486	0.027	11	3	1	2
PL.3259	PL.3258	A	#2 ACSR	7.42Y	123.7	0.00	1.26	0.18	0	1	0	100	0.00	0.0	2.506	0.020	1	0	1	1
PL.3081	PL.3080	A	#2 ACSR	7.42Y	123.7	0.05	1.31	24.27	14	174	48	96	0.06	0.0	2.532	0.073	15	4	2	49
PL.3256	PL.3081	A	#2 ACSR	7.42Y	123.7	0.00	1.32	2.59	1	19	5	97	0.00	0.0	2.569	0.037	14	4	3	4
PL.3257	PL.3256	A	#2 ACSR	7.42Y	123.7	0.00	1.32	0.66	0	5	1	98	0.00	0.0	2.665	0.096	5	1	1	1
PL.25726	PL.3081	A	#1/0 ACSR	7.42Y	123.7	0.02	1.33	19.63	9	140	39	96	0.02	0.0	2.569	0.037	0	0	0	43
PL.25727	PL.25726	A	#1/0 ACSR	7.42Y	123.6	0.03	1.36	19.03	8	136	38	96	0.02	0.0	2.632	0.062	0	0	0	42
PL.3083	PL.25727	A	#2 ACSR	7.42Y	123.6	0.05	1.41	19.03	11	136	38	96	0.05	0.0	2.715	0.083	4	1	1	42
PL.2702	PL.3083	A	#2 ACSR	7.42Y	123.6	0.00	1.41	0.00	0	0	0	100	0.00	0.0	2.771	0.056	0	0	0	0
PL.33104	PL.3083	A	#2 ACSR	7.41Y	123.5	0.05	1.45	18.49	11	132	37	96	0.04	0.0	2.793	0.078	0	0	0	41
PL.33105	PL.33104	A	#2 ACSR	7.41Y	123.5	0.02	1.47	18.49	11	132	37	96	0.02	0.0	2.826	0.033	0	0	2	41
PL.3255	PL.33105	A	#2 ACSR	7.41Y	123.5	0.05	1.52	18.47	11	132	37	96	0.04	0.0	2.906	0.080	0	0	0	39
PL.3260	PL.3255	A	#2 ACSR	7.40Y	123.4	0.07	1.59	16.64	10	119	33	96	0.06	0.0	3.044	0.139	8	2	1	33
PL.3261	PL.3260	A	#2 ACSR	7.40Y	123.4	0.04	1.63	15.56	9	111	31	96	0.03	0.0	3.128	0.084	0	0	0	32
PL.2821	PL.3261	A	#2 ACSR	7.40Y	123.3	0.06	1.69	14.69	8	105	29	96	0.05	0.0	3.258	0.130	0	0	0	31
PL.3084	PL.2821	A	#2 ACSR	7.40Y	123.3	0.03	1.72	14.69	8	105	29	96	0.02	0.0	3.325	0.067	6	2	3	31

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.2705	PL.3084	A	#2 ACSR	7.40Y	123.3	0.00	1.72	0.00	0	0	0	100	0.00	0.0	3.368	0.043	0	0	2	2
PL.3085	PL.3084	A	#2 ACSR	7.40Y	123.3	0.02	1.74	13.80	8	98	27	96	0.02	0.0	3.385	0.060	17	5	3	26
PL.2708	PL.3085	A	6 A (CWC)	7.39Y	123.2	0.05	1.80	11.41	8	81	23	96	0.03	0.0	3.485	0.101	0	0	0	23
PL.2706	PL.2708	A	6 A (CWC)	7.39Y	123.2	0.00	1.80	0.09	0	1	0	100	0.00	0.0	3.514	0.029	1	0	1	1
PL.2822	PL.2708	A	6 A (CWC)	7.39Y	123.1	0.08	1.88	11.32	8	81	22	97	0.05	0.1	3.655	0.169	8	2	2	22
PL.3268	PL.2822	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	3.37	2	24	7	96	0.00	0.0	3.695	0.040	24	7	4	5
PL.3269	PL.3268	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	3.867	0.172	0	0	1	1
PL.3267	PL.2822	A	6 A (CWC)	7.39Y	123.1	0.03	1.91	6.89	5	49	14	96	0.01	0.0	3.744	0.089	1	0	1	15
PL.3270	PL.3267	A	6 A (CWC)	7.38Y	123.1	0.02	1.92	6.74	5	48	13	97	0.01	0.0	3.797	0.053	8	2	1	14
PL.3271	PL.3270	A	6 A (CWC)	7.38Y	123.1	0.01	1.93	5.68	4	40	11	96	0.00	0.0	3.849	0.053	11	3	3	13
PL.3266	PL.3271	A	6 A (CWC)	7.38Y	123.0	0.02	1.95	4.16	3	30	8	97	0.00	0.0	3.939	0.090	2	1	1	10
PL.3265	PL.3266	A	6 A (CWC)	7.38Y	123.0	0.01	1.96	3.89	3	28	8	96	0.00	0.0	3.978	0.039	0	0	1	9
PL.3262	PL.3265	A	6 A (CWC)	7.38Y	123.0	0.01	1.96	3.89	3	28	8	96	0.00	0.0	4.025	0.047	11	3	2	8
PL.3263	PL.3262	A	6 A (CWC)	7.38Y	123.0	0.00	1.97	2.36	2	17	5	96	0.00	0.0	4.055	0.030	1	0	2	6
PL.3264	PL.3263	A	6 A (CWC)	7.38Y	123.0	0.01	1.98	2.18	2	15	4	97	0.00	0.0	4.156	0.101	0	0	0	4
PL.2870	PL.3264	A	6 A (CWC)	7.38Y	123.0	0.01	1.99	2.18	2	15	4	97	0.00	0.0	4.288	0.132	0	0	0	4
PL.3272	PL.2870	A	6 A (CWC)	7.38Y	123.0	0.01	2.00	2.18	2	15	4	97	0.00	0.0	4.380	0.092	10	3	3	4
PL.3273	PL.3272	A	6 A (CWC)	7.38Y	123.0	0.00	2.00	0.76	1	5	2	93	0.00	0.0	4.435	0.055	5	2	1	1
PL.4476	PL.3273	A	6 A (CWC)	7.38Y	123.0	0.00	2.00	0.00	0	0	0	100	0.00	0.0	4.443	0.008	0	0	0	0
PL.2704	PL.3261	A	#4 ACSR	7.40Y	123.4	0.00	1.63	0.87	1	6	2	95	0.00	0.0	3.208	0.080	6	2	1	1
PL.10200	PL.3255	A	#2 ACSR	7.41Y	123.5	0.00	1.52	1.83	1	13	4	96	0.00	0.0	2.959	0.054	0	0	0	6
PL.3251	PL.10200	A	#2 ACSR	7.41Y	123.5	0.00	1.53	1.83	1	13	4	96	0.00	0.0	3.034	0.075	3	1	1	6
PL.3252	PL.3251	A	#2 ACSR	7.41Y	123.5	0.00	1.53	1.46	1	10	3	96	0.00	0.0	3.170	0.136	5	1	1	5
PL.3253	PL.3252	A	#2 ACSR	7.41Y	123.5	0.00	1.53	0.78	0	6	2	95	0.00	0.0	3.275	0.105	0	0	0	4
PL.3250	PL.3253	A	#2 ACSR	7.41Y	123.5	0.00	1.53	0.78	0	6	2	95	0.00	0.0	3.364	0.089	5	1	2	4
PL.3248	PL.3250	A	#4 ACSR	7.41Y	123.5	0.00	1.53	0.15	0	1	0	100	0.00	0.0	3.395	0.031	1	0	2	2
PL.3249	PL.3248	A	#4 ACSR	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	3.433	0.038	0	0	0	0
PL.25725	PL.25726	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.59	0	4	1	97	0.00	0.0	2.601	0.032	4	1	1	1
PL.3568	PL.2868	C	#2 ACSR	7.43Y	123.9	0.00	1.11	15.51	9	111	31	96	0.00	0.0	2.293	0.005	0	0	0	20
PD.419	PL.3568	C	20T	7.43Y	123.9	0.00	1.11	15.51	0	111	31	96	0.00	0.0	2.293	0.005	0	0	0	20
PL.3569	PD.419	C	#2 ACSR	7.43Y	123.9	0.01	1.12	15.51	9	111	31	96	0.01	0.0	2.316	0.023	9	2	1	20

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	-----Element----- Length (mi)	KW	KVAR	Cons On	Cons Thru

PL.2707	PL.3569	C	#4 ACSR	7.43Y	123.9	0.02	1.14	14.26	11	102	28	96	0.02	0.0	2.350	0.034	5	1	1	19
PL.3205	PL.2707	C	#4 ACSR	7.43Y	123.8	0.02	1.16	13.50	10	97	27	96	0.01	0.0	2.383	0.033	0	0	0	18
PL.3208	PL.3205	C	#4 ACSR	7.43Y	123.8	0.02	1.18	11.26	9	81	22	97	0.01	0.0	2.428	0.045	6	2	1	16
PL.3209	PL.3208	C	#4 ACSR	7.43Y	123.8	0.01	1.20	10.46	8	75	21	96	0.01	0.0	2.458	0.030	0	0	0	15
PL.3206	PL.3209	C	#4 ACSR	7.43Y	123.8	0.00	1.20	0.80	1	6	2	95	0.00	0.0	2.482	0.024	0	0	1	2
PL.3207	PL.3206	C	#4 ACSR	7.43Y	123.8	0.00	1.20	0.80	1	6	2	95	0.00	0.0	2.548	0.066	6	2	1	1
PL.3388	PL.3209	C	#4 ACSR	7.43Y	123.8	0.02	1.21	9.66	7	69	19	96	0.01	0.0	2.500	0.042	23	6	3	13
PL.3389	PL.3388	C	#4 ACSR	7.43Y	123.8	0.01	1.22	6.48	5	46	13	96	0.00	0.0	2.544	0.044	6	2	2	10
PL.3204	PL.3389	C	#4 ACSR	7.43Y	123.8	0.01	1.23	5.67	4	41	11	97	0.00	0.0	2.603	0.059	13	4	4	8
PL.3211	PL.3204	C	#4 ACSR	7.43Y	123.8	0.01	1.25	3.80	3	27	8	96	0.00	0.0	2.708	0.105	15	4	2	4
PL.3212	PL.3211	C	#4 ACSR	7.43Y	123.8	0.00	1.25	1.65	1	12	3	97	0.00	0.0	2.732	0.024	5	1	1	2
PL.3210	PL.3212	C	#4 ACSR	7.43Y	123.8	0.00	1.25	0.92	1	7	2	96	0.00	0.0	2.779	0.047	7	2	1	1
PL.10179	PL.3205	C	#1/0 ACSR	7.43Y	123.8	0.00	1.16	2.24	1	16	4	97	0.00	0.0	2.416	0.033	16	4	2	2
PL.3466	PL.2819	C	#2 ACSR	7.44Y	123.9	0.00	1.07	0.10	0	1	0	100	0.00	0.0	1.937	0.005	0	0	0	1
PD.396	PL.3466	C	40QA	7.44Y	123.9	0.00	1.07	0.10	0	1	0	100	0.00	0.0	1.937	0.005	0	0	0	1
PL.3467	PD.396	C	#2 ACSR	7.44Y	123.9	0.00	1.07	0.10	0	1	0	100	0.00	0.0	1.963	0.026	1	0	1	1
PL.3462	PL.3086	C	#4 ACSR	7.44Y	124.0	0.00	1.04	0.30	0	2	1	89	0.00	0.0	1.661	0.005	0	0	0	1
PD.393	PL.3462	C	40QA	7.44Y	124.0	0.00	1.04	0.30	1	2	1	89	0.00	0.0	1.661	0.005	0	0	0	1
PL.3463	PD.393	C	#4 ACSR	7.44Y	124.0	0.00	1.04	0.30	0	2	1	89	0.00	0.0	1.736	0.075	2	1	1	1
PL.3464	PL.3604	C	#2 ACSR	7.44Y	124.0	0.00	1.00	1.81	1	13	4	96	0.00	0.0	1.289	0.005	0	0	0	3
PD.395	PL.3464	C	40QA	7.44Y	124.0	0.00	1.00	1.81	5	13	4	96	0.00	0.0	1.289	0.005	0	0	0	3
PL.3465	PD.395	C	#2 ACSR	7.44Y	124.0	0.00	1.00	1.81	1	13	4	96	0.00	0.0	1.309	0.020	13	4	3	3
PL.3562	PL.2581	A	#2 ACSR	7.46Y	124.4	0.00	0.59	1.31	1	9	3	95	0.00	0.0	0.661	0.005	0	0	0	1
PD.416	PL.3562	A	40QA	7.46Y	124.4	0.00	0.59	1.31	3	9	3	95	0.00	0.0	0.661	0.005	0	0	0	1
PL.3563	PD.416	A	#2 ACSR	7.46Y	124.4	0.00	0.59	1.31	1	9	3	95	0.00	0.0	0.680	0.019	9	3	1	1
PL.3422	PL.2581	C	#2 ACSR	7.46Y	124.4	0.00	0.59	1.02	1	7	2	96	0.00	0.0	0.661	0.005	0	0	0	2
PD.374	PL.3422	C	40QA	7.46Y	124.4	0.00	0.59	1.02	3	7	2	96	0.00	0.0	0.661	0.005	0	0	0	2
PL.3423	PD.374	C	#2 ACSR	7.46Y	124.4	0.00	0.59	1.02	1	7	2	96	0.00	0.0	0.679	0.018	7	2	2	2
PL.2576	PL.2863	C	#2 ACSR	7.48Y	124.6	0.00	0.38	4.24	2	31	8	97	0.00	0.0	0.440	0.020	0	0	0	4
PL.3418	PL.2576	C	#2 ACSR	7.48Y	124.6	0.00	0.39	4.24	2	31	8	97	0.00	0.0	0.444	0.005	0	0	0	4
PD.372	PL.3418	C	40QA	7.48Y	124.6	0.00	0.39	4.24	11	31	8	97	0.00	0.0	0.444	0.005	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.3419	PD.372	C	#2 ACSR	7.48Y	124.6	0.00	0.39	4.24	2	31	8	97	0.00	0.0	0.459	0.015	0	0	0	4
PL.2578	PL.3419	C	#4 ACSR	7.48Y	124.6	0.00	0.39	3.30	3	24	7	96	0.00	0.0	0.478	0.019	24	7	3	3
PL.2577	PL.3419	C	#2 ACSR	7.48Y	124.6	0.00	0.39	0.94	1	7	2	96	0.00	0.0	0.495	0.036	7	2	1	1
PL.1257	Goose Rock	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.94	1	62	24	93	0.00	0.0	0.007	0.007	0	0	0	4
PL.7163	PL.1257	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.94	1	62	24	93	0.00	0.0	0.009	0.002	0	0	0	4
----- Feeder No. 5 (Clay Ind Park F5) Beginning with Device PD.1530 -----																				
PD.1530	PL.7163	ABC	480VWE	7.50Y	125.0	0.00	0.00	2.94	0	62	24	93	0.00	0.0	0.009	0.002	0	0	0	4
PL.7164	PD.1530	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.94	1	62	24	93	0.00	0.0	0.020	0.011	0	0	0	4
PL.1299	PL.7164	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	2.94	1	62	24	93	0.00	0.0	0.281	0.261	0	0	0	4
PL.1290	PL.1299	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.94	1	62	24	93	0.00	0.0	0.473	0.192	0	0	0	4
PL.1291	PL.1290	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.94	1	62	24	93	0.00	0.0	0.640	0.167	0	0	0	4
PL.1231	PL.1291	ABC	397 SPACER	7.50Y	125.0	0.00	0.01	2.94	1	62	24	93	0.00	0.0	0.834	0.194	0	0	0	4
PL.1230	PL.1231	ABC	397 SPACER	7.50Y	125.0	0.01	0.02	2.94	1	62	24	93	0.00	0.0	1.491	0.657	0	0	0	4
PL.1343	PL.1230	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	2.94	1	62	24	93	0.00	0.0	1.858	0.367	0	0	0	4
PL.1344	PL.1343	ABC	397 SPACER	7.50Y	125.0	0.00	0.02	2.94	1	62	24	93	0.00	0.0	2.048	0.189	0	0	0	4
PL.1229	PL.1344	ABC	397 SPACER	7.50Y	125.0	0.00	0.03	2.94	1	62	24	93	0.00	0.0	2.369	0.321	0	0	0	4
PL.1245	PL.1229	ABC	336 MCM AC	7.50Y	125.0	0.00	0.03	2.49	0	52	22	92	0.00	0.0	2.577	0.208	0	0	0	3
PL.1240	PL.1245	ABC	336 MCM AC	7.50Y	125.0	0.00	0.04	2.49	0	52	22	92	0.00	0.0	2.756	0.179	0	0	0	3
PL.1227	PL.1240	ABC	336 MCM AC	7.50Y	125.0	0.00	0.04	1.75	0	35	17	90	0.00	0.0	2.802	0.046	0	0	0	2
PL.1347	PL.1227	ABC	350 MCM AL	7.50Y	125.0	0.00	0.04	1.75	1	35	17	90	0.00	0.0	2.805	0.003	0	0	0	2
PD.185-A	PL.1347	ABC	Closed	7.50Y	125.0	0.00	0.04	1.75	0	35	17	90	0.00	0.0	2.805	0.003	0	0	0	2
PD.185-B	PD.185-A	ABC	Closed	7.50Y	125.0	0.00	0.04	1.75	0	35	17	90	0.00	0.0	2.805	0.003	0	0	0	2
PL.1348	PD.185-B	ABC	350 MCM AL	7.50Y	125.0	0.01	0.04	1.75	1	35	17	90	0.00	0.0	3.330	0.524	0	0	0	2
PD.154-A	PL.1348	ABC	Closed	7.50Y	125.0	0.00	0.04	1.75	0	35	17	90	0.00	0.0	3.330	0.524	0	0	0	2
PD.154-B	PD.154-A	ABC	Closed	7.50Y	125.0	0.00	0.04	1.75	0	35	17	90	0.00	0.0	3.330	0.524	0	0	0	2
PL.1225	PD.154-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.04	1.65	1	33	16	90	0.00	0.0	3.481	0.152	0	0	0	1
PD.153-A	PL.1225	ABC	Closed	7.50Y	125.0	0.00	0.04	1.65	0	33	16	90	0.00	0.0	3.481	0.152	0	0	0	1
PD.153-B	PD.153-A	ABC	Closed	7.50Y	125.0	0.00	0.04	1.65	0	33	16	90	0.00	0.0	3.481	0.152	0	0	0	1
PL.1247	PD.153-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.04	1.65	1	33	16	90	0.00	0.0	3.565	0.084	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Goose Rock

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.1248	PL.1247	ABC	350 MCM AL	7.50Y	125.0	0.00	0.04	1.65	1	33	16	90	0.00	0.0	3.586	0.021	33	16	1	1
PL.1226	PD.154-B	ABC	350 MCM AL	7.50Y	125.0	0.00	0.04	0.10	0	2	1	89	0.00	0.0	3.353	0.023	2	1	1	1
PL.1345	PL.1240	ABC	#2 ACSR	7.50Y	125.0	0.00	0.04	0.75	0	16	4	97	0.00	0.0	2.816	0.060	0	0	0	1
PD.184	PL.1345	ABC	100QA	7.50Y	125.0	0.00	0.04	0.75	1	16	4	97	0.00	0.0	2.816	0.060	0	0	0	1
PL.1346	PD.184	ABC	#2 ACSR	7.50Y	125.0	0.00	0.04	0.75	0	16	4	97	0.00	0.0	2.839	0.022	16	4	1	1
PL.63	PL.1229	B	8 A (CWC)	7.50Y	125.0	0.00	0.03	1.36	1	10	3	96	0.00	0.0	2.406	0.037	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	11274	0	0	0	0	0	321		0.00	11595	Lowest Voltage =	118.04	on Element PL.3303
KVAR	3218	0	0	0	0	0	607			3825	Max Accm VoltD =	6.96	on Element PL.3303
											Max Elem VoltD =	0.42	on Element PL.1393