

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

Hargett		ABC	SRC-Harget	7.50Y	125.0	0.00	0.00	341.80	0	7303	2412	95	0.00	0.0	0.000	0.000	0	0	0	1396
PL.21528	Hargett	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	55.55	11	1194	369	96	0.00	0.0	0.005	0.005	0	0	0	246
PL.72940	PL.21528	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	55.55	11	1194	369	96	0.00	0.0	0.009	0.004	0	0	0	246

----- Feeder No. 1 (SpoutSpring F1) Beginning with Device PD.11206 -----																				
PD.11206	PL.72940	ABC	360VWE	7.50Y	125.0	0.00	0.00	55.55	0	1194	369	96	0.00	0.0	0.009	0.004	0	0	0	246
PL.21529	PD.11206	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	55.55	11	1194	369	96	0.00	0.0	0.018	0.009	0	0	0	246
PL.21676	PL.21529	B	#4 ACSR	7.50Y	125.0	0.00	0.00	1.58	1	11	3	96	0.00	0.0	0.022	0.005	0	0	0	2
PD.3093	PL.21676	B	65T	7.50Y	125.0	0.00	0.00	1.58	0	11	3	96	0.00	0.0	0.022	0.005	0	0	0	2
PL.21677	PD.3093	B	#4 ACSR	7.50Y	125.0	0.00	0.00	1.58	1	11	3	96	0.00	0.0	0.048	0.026	6	2	1	2
PL.21608	PL.21677	B	#4 ACSR	7.50Y	125.0	0.00	0.01	0.79	1	6	2	95	0.00	0.0	0.140	0.092	6	2	1	1
PL.21439	PL.21529	ABC	397 SPACER	7.50Y	125.0	0.01	0.02	55.03	11	1183	365	96	0.03	0.0	0.101	0.083	0	0	0	244
PL.21440	PL.21439	ABC	397 SPACER	7.50Y	125.0	0.02	0.03	49.72	10	1069	331	96	0.03	0.0	0.201	0.100	0	0	0	224
PL.21334	PL.21440	ABC	#1/0 ACSR	7.49Y	124.9	0.09	0.13	49.72	22	1069	330	96	0.65	0.1	0.301	0.100	5	2	3	224
PL.21523	PL.21334	ABC	#1/0 ACSR	7.49Y	124.8	0.03	0.16	48.36	21	1039	321	96	0.21	0.0	0.335	0.034	3	1	1	217
PL.21534	PL.21523	ABC	#1/0 ACSR	7.48Y	124.7	0.16	0.31	48.20	21	1035	320	96	1.11	0.1	0.514	0.179	0	0	0	216
PL.21705	PL.21534	B	#4 ACSR	7.48Y	124.7	0.00	0.31	3.37	3	24	7	96	0.00	0.0	0.517	0.003	0	0	0	5
PD.3106	PL.21705	B	35L	7.48Y	124.7	0.00	0.31	3.37	10	24	7	96	0.00	0.0	0.517	0.003	0	0	0	5
PL.21706	PD.3106	B	#4 ACSR	7.48Y	124.7	0.03	0.34	3.37	3	24	7	96	0.00	0.0	0.684	0.167	0	0	0	5
PL.65711	PL.21706	B	#1/0 ACSR	7.48Y	124.7	0.00	0.34	0.00	0	0	0	100	0.00	0.0	0.730	0.046	0	0	0	0
PL.65712	PL.65711	B	1/0 AL URD	7.48Y	124.7	0.00	0.34	0.00	0	0	0	100	0.00	0.0	0.798	0.068	0	0	0	0
PL.21536	PL.21706	B	#4 ACSR	7.48Y	124.6	0.01	0.35	3.37	3	24	7	96	0.00	0.0	0.778	0.094	0	0	0	5
PL.21336	PL.21536	B	6 A (CWC)	7.48Y	124.6	0.03	0.38	3.37	2	24	7	96	0.01	0.0	0.963	0.184	0	0	0	5
PL.21621	PL.21336	B	#4 ACSR	7.48Y	124.6	0.00	0.38	1.39	1	10	3	96	0.00	0.0	0.968	0.005	0	0	0	3
PD.3066	PL.21621	B	15T	7.48Y	124.6	0.00	0.38	1.39	0	10	3	96	0.00	0.0	0.968	0.005	0	0	0	3
PL.21622	PD.3066	B	#4 ACSR	7.48Y	124.6	0.01	0.39	1.39	1	10	3	96	0.00	0.0	1.054	0.086	0	0	0	3
PL.21338	PL.21622	B	#4 ACSR	7.48Y	124.6	0.00	0.39	0.00	0	0	0	100	0.00	0.0	1.190	0.136	0	0	0	0
PL.21339	PL.21622	B	#4 ACSR	7.48Y	124.6	0.01	0.40	1.39	1	10	3	96	0.00	0.0	1.195	0.141	0	0	0	3
PL.21352	PL.21339	B	#4 ACSR	7.48Y	124.6	0.00	0.40	0.59	0	4	1	97	0.00	0.0	1.365	0.170	4	1	1	1
PL.21353	PL.21339	B	#4 ACSR	7.48Y	124.6	0.00	0.40	0.79	1	6	2	95	0.00	0.0	1.296	0.101	0	0	0	2
PL.21497	PL.21353	B	#4 ACSR	7.48Y	124.6	0.00	0.40	0.79	1	6	2	95	0.00	0.0	1.407	0.111	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21480	PL.21497	B	#4 ACSR	7.48Y	124.6	0.01	0.41	0.79	1	6	2	95	0.00	0.0	1.576	0.170	0	0	0	2
PL.21481	PL.21480	B	#4 ACSR	7.48Y	124.6	0.00	0.41	0.79	1	6	2	95	0.00	0.0	1.719	0.143	6	2	2	2
PL.21445	PL.21336	B	6 A (CWC)	7.48Y	124.6	0.00	0.38	1.99	1	14	4	96	0.00	0.0	0.993	0.030	3	1	1	2
PL.21337	PL.21445	B	#4 ACSR	7.48Y	124.6	0.00	0.39	1.57	1	11	3	96	0.00	0.0	1.110	0.117	11	3	1	1
PL.21444	PL.21534	ABC	#1/0 ACSR	7.48Y	124.6	0.06	0.37	47.08	20	1010	311	96	0.40	0.0	0.582	0.068	2	1	1	211
PL.21340	PL.21444	ABC	#1/0 ACSR	7.47Y	124.5	0.15	0.52	46.57	20	998	308	96	1.03	0.1	0.761	0.179	0	0	0	209
PL.21446	PL.21340	ABC	#1/0 ACSR	7.46Y	124.4	0.10	0.63	42.68	19	914	282	96	0.62	0.1	0.890	0.129	0	0	0	196
PL.21496	PL.21446	ABC	#1/0 ACSR	7.46Y	124.3	0.06	0.68	42.68	19	913	281	96	0.35	0.0	0.961	0.072	0	0	0	196
PL.21482	PL.21496	ABC	#1/0 ACSR	7.45Y	124.2	0.08	0.76	42.68	19	913	281	96	0.49	0.1	1.062	0.101	3	1	1	196
PL.21344	PL.21482	ABC	#1/0 ACSR	7.45Y	124.2	0.07	0.83	42.56	19	910	279	96	0.42	0.0	1.150	0.087	0	0	1	195
PL.21548	PL.21344	B	6 A (CWC)	7.45Y	124.2	0.02	0.85	14.96	11	107	32	96	0.01	0.0	1.177	0.027	4	1	1	27
PL.21549	PL.21548	B	6 A (CWC)	7.45Y	124.1	0.04	0.89	14.38	10	103	31	96	0.03	0.0	1.244	0.067	0	0	0	26
PL.21348	PL.21549	B	#4 ACSR	7.45Y	124.1	0.00	0.89	0.80	1	6	2	95	0.00	0.0	1.299	0.055	6	2	1	1
PL.21512	PL.21549	B	6 A (CWC)	7.44Y	124.1	0.06	0.95	13.58	10	97	29	96	0.04	0.0	1.338	0.094	1	0	1	25
PL.21511	PL.21512	B	6 A (CWC)	7.44Y	124.0	0.01	0.96	11.75	8	84	25	96	0.01	0.0	1.359	0.021	0	0	0	22
PL.21711	PL.21511	B	6 A (CWC)	7.44Y	124.0	0.00	0.96	11.75	8	84	25	96	0.00	0.0	1.362	0.003	0	0	0	22
PD.3109	PL.21711	B	35L	7.44Y	124.0	0.00	0.96	11.75	34	84	25	96	0.00	0.0	1.362	0.003	0	0	0	22
PL.21712	PD.3109	B	6 A (CWC)	7.44Y	123.9	0.10	1.06	11.75	8	84	25	96	0.06	0.1	1.544	0.183	0	0	1	22
PL.21510	PL.21712	B	#4 ACSR	7.43Y	123.9	0.08	1.14	11.32	9	81	24	96	0.05	0.1	1.695	0.151	0	0	0	19
PL.21351	PL.21510	B	#4 ACSR	7.43Y	123.9	0.00	1.14	1.03	1	7	2	96	0.00	0.0	1.728	0.033	7	2	1	1
PL.21350	PL.21510	B	#4 ACSR	7.43Y	123.8	0.02	1.15	10.29	8	73	22	96	0.01	0.0	1.728	0.033	0	0	0	18
PL.21448	PL.21350	B	#4 ACSR	7.43Y	123.8	0.06	1.21	9.92	8	71	21	96	0.03	0.0	1.867	0.139	0	0	0	17
PL.21358	PL.21448	B	#4 ACSR	7.43Y	123.8	0.02	1.24	5.65	4	40	12	96	0.01	0.0	1.953	0.086	0	0	0	9
PL.21483	PL.21358	B	#4 ACSR	7.42Y	123.7	0.03	1.26	5.65	4	40	12	96	0.01	0.0	2.059	0.107	0	0	0	9
PL.21360	PL.21483	B	#2 ACSR	7.42Y	123.7	0.01	1.27	2.10	1	15	4	97	0.00	0.0	2.187	0.128	4	1	1	4
PL.21361	PL.21360	B	#2 ACSR	7.42Y	123.7	0.00	1.27	1.58	1	11	3	96	0.00	0.0	2.252	0.064	11	3	3	3
PL.21359	PL.21483	B	#2 ACSR	7.42Y	123.7	0.00	1.26	0.53	0	4	1	97	0.00	0.0	2.131	0.072	4	1	1	1
PL.21554	PL.21483	B	#4 ACSR	7.42Y	123.7	0.01	1.27	3.03	2	22	6	96	0.00	0.0	2.130	0.070	10	3	1	4
PL.21555	PL.21554	B	#4 ACSR	7.42Y	123.7	0.01	1.28	1.57	1	11	3	96	0.00	0.0	2.299	0.170	7	2	1	3
PL.21551	PL.21555	B	#4 ACSR	7.42Y	123.7	0.00	1.28	0.59	0	4	1	97	0.00	0.0	2.361	0.061	0	0	0	2
PL.21550	PL.21551	B	#4 ACSR	7.42Y	123.7	0.00	1.28	0.59	0	4	1	97	0.00	0.0	2.479	0.119	4	1	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21537	PL.21550	B	#4 ACSR	7.42Y	123.7	0.00	1.28	0.02	0	0	0	100	0.00	0.0	2.539	0.059	0	0	1	1
PL.21355	PL.21448	B	#4 ACSR	7.43Y	123.8	0.00	1.21	0.15	0	1	0	100	0.00	0.0	1.983	0.116	1	0	1	1
PL.21552	PL.21448	B	#4 ACSR	7.43Y	123.8	0.01	1.22	4.12	3	29	9	96	0.00	0.0	1.907	0.040	1	0	1	7
PL.21553	PL.21552	B	#4 ACSR	7.43Y	123.8	0.02	1.24	3.94	3	28	8	96	0.00	0.0	2.001	0.094	0	0	0	6
PL.21356	PL.21553	B	#4 ACSR	7.43Y	123.8	0.00	1.24	2.60	2	19	6	95	0.00	0.0	2.068	0.068	19	6	4	4
PL.21357	PL.21553	B	#4 ACSR	7.43Y	123.8	0.00	1.24	1.34	1	10	3	96	0.00	0.0	2.068	0.068	10	3	2	2
PL.21354	PL.21350	B	#4 ACSR	7.43Y	123.8	0.00	1.15	0.37	0	3	1	95	0.00	0.0	1.820	0.092	3	1	1	1
PL.21509	PL.21712	B	#4 ACSR	7.44Y	123.9	0.00	1.06	0.40	0	3	1	95	0.00	0.0	1.609	0.064	0	0	1	2
PL.21349	PL.21509	B	#2 ACSR	7.44Y	123.9	0.00	1.06	0.40	0	3	1	95	0.00	0.0	1.769	0.160	3	1	1	1
PL.21546	PL.21512	B	#4 ACSR	7.44Y	124.0	0.00	0.95	1.73	1	12	4	95	0.00	0.0	1.364	0.026	3	1	1	2
PL.21547	PL.21546	B	#4 ACSR	7.44Y	124.0	0.00	0.95	1.32	1	9	3	95	0.00	0.0	1.412	0.048	9	3	1	1
PL.21709	PL.21344	C	6 A (CWC)	7.45Y	124.2	0.00	0.83	21.89	16	156	47	96	0.00	0.0	1.152	0.003	0	0	0	33
PD.3108	PL.21709	C	35L	7.45Y	124.2	0.00	0.83	21.89	63	156	47	96	0.00	0.0	1.152	0.003	0	0	0	33
PL.21710	PD.3108	C	6 A (CWC)	7.44Y	124.0	0.16	0.99	21.89	16	156	47	96	0.18	0.1	1.319	0.166	12	4	1	33
PL.21362	PL.21710	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	1.82	1	13	4	96	0.00	0.0	1.357	0.038	13	4	1	1
PL.21513	PL.21710	C	6 A (CWC)	7.44Y	124.0	0.04	1.03	18.39	13	131	39	96	0.04	0.0	1.364	0.046	0	0	0	31
PL.21364	PL.21513	C	#1/0 ACSR	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	1.409	0.044	0	0	0	0
PL.21630	PL.21364	C	1/0 AL URD	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	1.413	0.005	0	0	0	0
PD.3071	PL.21630	C	15T	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	1.413	0.005	0	0	0	0
PL.21631	PD.3071	C	1/0 AL URD	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	1.510	0.097	0	0	0	0
PL.21363	PL.21513	C	6 A (CWC)	7.43Y	123.9	0.08	1.11	16.70	12	119	36	96	0.07	0.1	1.462	0.098	0	0	0	30
PL.21366	PL.21363	C	#2 ACSR	7.43Y	123.9	0.00	1.11	0.79	0	6	2	95	0.00	0.0	1.500	0.037	6	2	1	1
PL.21449	PL.21363	C	6 A (CWC)	7.43Y	123.8	0.05	1.16	15.91	11	113	34	96	0.04	0.0	1.534	0.072	0	0	0	29
PL.21517	PL.21449	C	6 A (CWC)	7.43Y	123.8	0.05	1.20	15.26	11	109	33	96	0.04	0.0	1.601	0.067	9	3	1	28
PL.21368	PL.21517	C	#2 ACSR	7.43Y	123.8	0.00	1.21	1.25	1	9	3	95	0.00	0.0	1.662	0.060	9	3	1	1
PL.21518	PL.21517	C	6 A (CWC)	7.43Y	123.8	0.01	1.22	12.79	9	91	27	96	0.01	0.0	1.626	0.024	0	0	0	26
PL.21520	PL.21518	C	6 A (CWC)	7.42Y	123.7	0.06	1.28	12.79	9	91	27	96	0.04	0.0	1.731	0.105	2	1	1	26
PL.21540	PL.21520	C	6 A (CWC)	7.42Y	123.7	0.04	1.32	11.81	8	84	25	96	0.02	0.0	1.802	0.072	7	2	1	23
PL.21541	PL.21540	C	6 A (CWC)	7.42Y	123.6	0.04	1.36	10.83	8	77	23	96	0.03	0.0	1.890	0.088	0	0	0	22
PL.21450	PL.21541	C	6 A (CWC)	7.42Y	123.6	0.04	1.40	10.83	8	77	23	96	0.02	0.0	1.974	0.084	0	0	0	22
PL.21544	PL.21450	C	6 A (CWC)	7.42Y	123.6	0.00	1.40	1.77	1	13	4	96	0.00	0.0	2.009	0.035	6	2	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21545	PL.21544	C	6 A (CWC)	7.42Y	123.6	0.00	1.41	0.90	1	6	2	95	0.00	0.0	2.072	0.063	0	0	0	3
PL.21452	PL.21545	C	6 A (CWC)	7.42Y	123.6	0.00	1.41	0.90	1	6	2	95	0.00	0.0	2.138	0.066	0	0	1	3
PL.21372	PL.21452	C	#2 ACSR	7.42Y	123.6	0.00	1.41	0.90	1	6	2	95	0.00	0.0	2.192	0.054	6	2	2	2
PL.21371	PL.21545	C	#1/0 ACSR	7.42Y	123.6	0.00	1.41	0.00	0	0	0	100	0.00	0.0	2.087	0.016	0	0	0	0
PL.21451	PL.21450	C	6 A (CWC)	7.41Y	123.6	0.02	1.43	9.06	6	64	19	96	0.01	0.0	2.035	0.061	11	3	1	18
PL.21373	PL.21451	C	6 A (CWC)	7.41Y	123.6	0.01	1.44	7.52	5	53	16	96	0.00	0.0	2.069	0.034	0	0	0	17
PL.21453	PL.21373	C	6 A (CWC)	7.41Y	123.5	0.05	1.49	7.33	5	52	16	96	0.02	0.0	2.225	0.156	0	0	0	16
PL.21376	PL.21453	C	#4 ACSR	7.41Y	123.5	0.02	1.51	4.48	3	32	10	95	0.00	0.0	2.306	0.081	0	0	0	12
PL.21378	PL.21376	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.21	0	1	0	100	0.00	0.0	2.354	0.048	0	0	0	2
PL.21703	PL.21378	C	1/0 AL URD	7.41Y	123.5	0.00	1.51	0.21	0	1	0	100	0.00	0.0	2.359	0.005	0	0	0	2
PD.3105	PL.21703	C	15T	7.41Y	123.5	0.00	1.51	0.21	0	1	0	100	0.00	0.0	2.359	0.005	0	0	0	2
PL.21704	PD.3105	C	1/0 AL URD	7.41Y	123.5	0.00	1.51	0.21	0	1	0	100	0.00	0.0	2.418	0.059	1	0	2	2
PL.21522	PL.21376	C	#4 ACSR	7.41Y	123.5	0.02	1.52	4.27	3	30	9	96	0.00	0.0	2.413	0.107	7	2	1	10
PL.21379	PL.21522	C	#4 ACSR	7.41Y	123.5	0.00	1.53	1.18	1	8	3	94	0.00	0.0	2.486	0.073	8	3	2	2
PL.21567	PL.21522	C	#4 ACSR	7.41Y	123.5	0.00	1.53	2.03	2	14	4	96	0.00	0.0	2.464	0.051	7	2	1	7
PL.21568	PL.21567	C	#4 ACSR	7.41Y	123.5	0.00	1.53	1.09	1	8	2	97	0.00	0.0	2.544	0.080	0	0	0	6
PL.21571	PL.21568	C	#4 ACSR	7.41Y	123.5	0.00	1.53	1.09	1	8	2	97	0.00	0.0	2.579	0.035	0	0	0	5
PL.21572	PL.21571	C	#4 ACSR	7.41Y	123.5	0.00	1.54	1.09	1	8	2	97	0.00	0.0	2.642	0.063	0	0	0	5
PL.21381	PL.21572	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	2.720	0.077	0	0	0	2
PL.21454	PL.21381	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	2.837	0.117	0	0	0	0
PL.21484	PL.21454	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	2.963	0.126	0	0	0	0
PL.21485	PL.21484	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	3.066	0.103	0	0	0	0
PL.21486	PL.21485	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	3.169	0.104	0	0	0	0
PL.21382	PL.21381	C	#2 ACSR	7.41Y	123.5	0.00	1.54	0.00	0	0	0	100	0.00	0.0	2.756	0.036	0	0	2	2
PL.21569	PL.21572	C	#4 ACSR	7.41Y	123.5	0.00	1.54	1.09	1	8	2	97	0.00	0.0	2.719	0.076	3	1	1	3
PL.21570	PL.21569	C	#4 ACSR	7.41Y	123.5	0.00	1.54	0.67	1	5	1	98	0.00	0.0	2.802	0.083	5	1	2	2
PL.21380	PL.21568	C	#2 ACSR	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	2.623	0.079	0	0	1	1
PL.21375	PL.21453	C	6 A (CWC)	7.41Y	123.5	0.01	1.50	2.85	2	20	6	96	0.00	0.0	2.305	0.080	0	0	0	4
PL.21542	PL.21375	C	#4 ACSR	7.41Y	123.5	0.00	1.50	1.13	1	8	2	97	0.00	0.0	2.427	0.122	6	2	1	2
PL.21543	PL.21542	C	#4 ACSR	7.41Y	123.5	0.00	1.50	0.23	0	2	0	100	0.00	0.0	2.495	0.068	2	0	1	1
PL.21377	PL.21375	C	6 A (CWC)	7.41Y	123.5	0.00	1.50	1.71	1	12	4	95	0.00	0.0	2.341	0.036	12	4	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21374	PL.21373	C	#2 ACSR	7.41Y	123.6	0.00	1.44	0.19	0	1	0	100	0.00	0.0	2.120	0.051	1	0	1	1
PL.21369	PL.21520	C	6 A (CWC)	7.42Y	123.7	0.00	1.28	0.68	0	5	1	98	0.00	0.0	1.821	0.090	5	1	2	2
PL.21367	PL.21449	C	#4 ACSR	7.43Y	123.8	0.00	1.16	0.65	1	5	1	98	0.00	0.0	1.635	0.101	5	1	1	1
PL.21365	PL.21513	C	#2 ACSR	7.44Y	124.0	0.00	1.03	1.70	1	12	4	95	0.00	0.0	1.514	0.150	12	4	1	1
PL.21345	PL.21344	A C	#1/0 ACSR	7.45Y	124.1	0.03	0.86	45.41	20	646	200	96	0.13	0.0	1.182	0.033	0	0	0	134
PL.21455	PL.21345	A C	#1/0 ACSR	7.45Y	124.1	0.00	0.86	0.00	0	0	0	100	0.00	0.0	1.190	0.007	0	0	0	0
PL.21346	PL.21345	A C	#1/0 ACSR	7.45Y	124.1	0.03	0.89	45.41	20	646	200	96	0.11	0.0	1.209	0.027	0	0	0	134
PL.21556	PL.21346	A C	#1/0 ACSR	7.45Y	124.1	0.00	0.89	1.03	0	15	4	97	0.00	0.0	1.262	0.053	1	0	1	3
PL.21557	PL.21556	A C	#1/0 ACSR	7.45Y	124.1	0.00	0.89	0.99	0	14	4	96	0.00	0.0	1.274	0.012	0	0	0	2
PL.21628	PL.21557	A	#2 ACSR	7.45Y	124.1	0.00	0.89	1.98	1	14	4	96	0.00	0.0	1.279	0.005	0	0	0	2
PD.3070	PL.21628	A	65T	7.45Y	124.1	0.00	0.89	1.98	0	14	4	96	0.00	0.0	1.279	0.005	0	0	0	2
PL.21629	PD.3070	A	#2 ACSR	7.45Y	124.1	0.00	0.89	1.98	1	14	4	96	0.00	0.0	1.392	0.114	14	4	2	2
PL.21347	PL.21346	A C	#1/0 ACSR	7.44Y	124.0	0.08	0.96	44.38	19	632	195	96	0.32	0.1	1.293	0.083	0	0	0	131
PL.21456	PL.21347	A C	#1/0 ACSR	7.44Y	124.0	0.04	1.00	43.90	19	624	193	96	0.15	0.0	1.331	0.039	0	0	0	130
PL.21632	PL.21456	A	#1/0 ACSR	7.44Y	124.0	0.00	1.00	1.14	0	8	2	97	0.00	0.0	1.336	0.005	0	0	0	1
PD.3072	PL.21632	A	65T	7.44Y	124.0	0.00	1.00	1.14	0	8	2	97	0.00	0.0	1.336	0.005	0	0	0	1
PL.21633	PD.3072	A	#1/0 ACSR	7.44Y	124.0	0.00	1.00	1.14	0	8	2	97	0.00	0.0	1.343	0.007	8	2	1	1
PL.21558	PL.21633	A	#1/0 ACSR	7.44Y	124.0	0.00	1.00	0.00	0	0	0	100	0.00	0.0	1.376	0.033	0	0	0	0
PL.21717	PL.21456	A C	#1/0 ACSR	7.44Y	124.0	0.04	1.04	43.33	19	616	190	96	0.16	0.0	1.375	0.044	0	0	0	129
PD.3112	PL.21717	A C	70L	7.44Y	124.0	0.00	1.04	43.33	62	616	190	96	0.00	0.0	1.375	0.044	0	0	0	129
PL.21718	PD.3112	A C	#1/0 ACSR	7.43Y	123.8	0.17	1.21	43.33	19	616	190	96	0.69	0.1	1.562	0.187	0	0	0	129
PL.21681	PL.21718	C	#1/0 ACSR	7.43Y	123.8	0.00	1.21	2.53	1	18	5	96	0.00	0.0	1.566	0.005	0	0	0	3
PD.3096	PL.21681	C	20T	7.43Y	123.8	0.00	1.21	2.53	0	18	5	96	0.00	0.0	1.566	0.005	0	0	0	3
PL.21682	PD.3096	C	#1/0 ACSR	7.43Y	123.8	0.00	1.21	2.53	1	18	5	96	0.00	0.0	1.578	0.012	0	0	0	3
PL.21383	PL.21682	C	6 A (CWC)	7.43Y	123.8	0.00	1.21	2.53	2	18	5	96	0.00	0.0	1.643	0.065	18	5	3	3
PL.21636	PL.21718	A	#1/0 ACSR	7.43Y	123.8	0.00	1.21	0.54	0	4	1	97	0.00	0.0	1.566	0.005	0	0	0	2
PD.3074	PL.21636	A	20T	7.43Y	123.8	0.00	1.21	0.54	0	4	1	97	0.00	0.0	1.566	0.005	0	0	0	2
PL.21637	PD.3074	A	#1/0 ACSR	7.43Y	123.8	0.00	1.21	0.54	0	4	1	97	0.00	0.0	1.587	0.021	4	1	2	2
PL.21559	PL.21718	A C	#1/0 ACSR	7.42Y	123.7	0.07	1.27	41.79	18	593	183	96	0.26	0.0	1.636	0.074	0	0	2	124
PL.21560	PL.21559	A C	#1/0 ACSR	7.42Y	123.7	0.05	1.32	41.79	18	593	182	96	0.19	0.0	1.690	0.054	0	0	0	122
PL.21384	PL.21560	A C	#1/0 ACSR	7.42Y	123.6	0.05	1.37	41.79	18	593	182	96	0.18	0.0	1.742	0.052	0	0	0	122

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21642	PL.21384	C	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.94	0	7	2	96	0.00	0.0	1.747	0.005	0	0	0	1
PD.3077	PL.21642	C	20T	7.42Y	123.6	0.00	1.37	0.94	0	7	2	96	0.00	0.0	1.747	0.005	0	0	0	1
PL.21643	PD.3077	C	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.94	0	7	2	96	0.00	0.0	1.774	0.027	7	2	1	1
PL.21457	PL.21384	A C	#1/0 ACSR	7.41Y	123.5	0.10	1.46	41.32	18	586	180	96	0.37	0.1	1.852	0.109	0	0	0	120
PL.21458	PL.21457	A C	#1/0 ACSR	7.41Y	123.4	0.10	1.56	41.29	18	585	179	96	0.37	0.1	1.962	0.110	0	0	0	119
PL.21638	PL.21458	A	#1/0 ACSR	7.41Y	123.4	0.00	1.56	0.84	0	6	2	95	0.00	0.0	1.966	0.005	0	0	0	1
PD.3075	PL.21638	A	20T	7.41Y	123.4	0.00	1.56	0.84	0	6	2	95	0.00	0.0	1.966	0.005	0	0	0	1
PL.21639	PD.3075	A	#1/0 ACSR	7.41Y	123.4	0.00	1.56	0.84	0	6	2	95	0.00	0.0	1.987	0.021	6	2	1	1
PL.21460	PL.21458	A C	#1/0 ACSR	7.40Y	123.4	0.07	1.63	40.87	18	579	177	96	0.27	0.0	2.043	0.081	0	0	0	118
PL.21644	PL.21460	C	#4 ACSR	7.40Y	123.4	0.00	1.63	1.45	1	10	3	96	0.00	0.0	2.048	0.005	0	0	0	5
PD.3078	PL.21644	C	20T	7.40Y	123.4	0.00	1.63	1.45	0	10	3	96	0.00	0.0	2.048	0.005	0	0	0	5
PL.21645	PD.3078	C	#4 ACSR	7.40Y	123.4	0.00	1.63	1.45	1	10	3	96	0.00	0.0	2.101	0.053	1	0	1	5
PL.21387	PL.21645	C	#4 ACSR	7.40Y	123.4	0.00	1.63	1.24	1	9	3	95	0.00	0.0	2.106	0.005	0	0	0	4
PD.3098	PL.21387	C	20T	7.40Y	123.4	0.00	1.63	1.24	0	9	3	95	0.00	0.0	2.106	0.005	0	0	0	4
PL.21462	PD.3098	C	#4 ACSR	7.40Y	123.4	0.00	1.64	1.24	1	9	3	95	0.00	0.0	2.176	0.070	0	0	0	4
PL.21390	PL.21462	C	#4 ACSR	7.40Y	123.4	0.01	1.64	1.24	1	9	3	95	0.00	0.0	2.321	0.146	4	1	1	4
PL.21508	PL.21390	C	#4 ACSR	7.40Y	123.4	0.00	1.65	0.68	1	5	1	98	0.00	0.0	2.409	0.088	3	1	1	3
PL.21389	PL.21508	C	#2 ACSR	7.40Y	123.4	0.00	1.65	0.00	0	0	0	100	0.00	0.0	2.472	0.063	0	0	0	0
PL.21507	PL.21508	C	#4 ACSR	7.40Y	123.4	0.00	1.65	0.26	0	2	1	89	0.00	0.0	2.470	0.061	2	1	2	2
PL.21388	PD.3098	C	#4 ACSR	7.40Y	123.4	0.00	1.63	0.00	0	0	0	100	0.00	0.0	2.175	0.069	0	0	0	0
PL.21391	PL.21388	C	#4 ACSR	7.40Y	123.4	0.00	1.63	0.00	0	0	0	100	0.00	0.0	2.233	0.058	0	0	0	0
PL.21461	PL.21460	A C	#1/0 ACSR	7.40Y	123.3	0.10	1.73	40.15	17	568	174	96	0.37	0.1	2.160	0.117	0	0	0	113
PL.21685	PL.21461	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	3.27	1	23	7	96	0.00	0.0	2.165	0.005	0	0	0	8
PD.3099	PL.21685	C	20T	7.40Y	123.3	0.00	1.73	3.27	0	23	7	96	0.00	0.0	2.165	0.005	0	0	0	8
PL.21686	PD.3099	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	3.27	1	23	7	96	0.00	0.0	2.181	0.016	4	1	1	8
PL.21573	PL.21686	C	#1/0 ACSR	7.40Y	123.3	0.00	1.73	2.66	1	19	6	95	0.00	0.0	2.239	0.059	1	0	2	7
PL.21574	PL.21573	C	#1/0 ACSR	7.40Y	123.3	0.01	1.74	2.58	1	18	5	96	0.00	0.0	2.331	0.091	0	0	0	5
PL.21393	PL.21574	C	#1/0 ACSR	7.40Y	123.3	0.00	1.74	0.05	0	0	0	100	0.00	0.0	2.388	0.057	0	0	1	1
PL.21575	PL.21574	C	#1/0 ACSR	7.40Y	123.3	0.01	1.74	2.53	1	18	5	96	0.00	0.0	2.436	0.105	4	1	1	4
PL.21576	PL.21575	C	#1/0 ACSR	7.40Y	123.3	0.00	1.75	1.92	1	14	4	96	0.00	0.0	2.538	0.102	11	3	1	3
PL.21395	PL.21576	C	#1/0 ACSR	7.40Y	123.3	0.00	1.75	0.01	0	0	0	100	0.00	0.0	2.595	0.057	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21394	PL.21576	C	#1/0 ACSR	7.40Y	123.3	0.00	1.75	0.38	0	3	1	95	0.00	0.0	2.628	0.090	3	1	1	1
PL.21463	PL.21461	A C	#1/0 ACSR	7.39Y	123.2	0.03	1.76	38.14	17	540	165	96	0.12	0.0	2.202	0.042	0	0	0	103
PL.21392	PL.21463	A C	#1/0 ACSR	7.39Y	123.2	0.03	1.80	38.14	17	539	165	96	0.12	0.0	2.244	0.042	0	0	0	103
PL.21648	PL.21392	C	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.47	0	3	1	95	0.00	0.0	2.248	0.005	0	0	0	1
PD.3080	PL.21648	C	20T	7.39Y	123.2	0.00	1.80	0.47	0	3	1	95	0.00	0.0	2.248	0.005	0	0	0	1
PL.21649	PD.3080	C	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.47	0	3	1	95	0.00	0.0	2.287	0.039	3	1	1	1
PL.21693	PL.21392	A C	#1/0 ACSR	7.39Y	123.1	0.06	1.85	37.85	16	535	163	96	0.21	0.0	2.318	0.074	0	0	0	101
PL.21694	PL.21693	A C	#1/0 ACSR	7.39Y	123.1	0.00	1.86	37.85	16	535	163	96	0.01	0.0	2.322	0.004	10	3	1	101
PL.21689	PL.21694	C	#4 ACSR	7.39Y	123.1	0.00	1.86	4.90	4	35	10	96	0.00	0.0	2.326	0.005	0	0	0	9
PD.3101	PL.21689	C	20T	7.39Y	123.1	0.00	1.86	4.90	0	35	10	96	0.00	0.0	2.326	0.005	0	0	0	9
PL.21690	PD.3101	C	#4 ACSR	7.39Y	123.1	0.01	1.87	4.90	4	35	10	96	0.00	0.0	2.367	0.041	3	1	1	9
PL.21566	PL.21690	C	#4 ACSR	7.39Y	123.1	0.01	1.88	4.55	3	32	10	95	0.00	0.0	2.422	0.055	0	0	0	8
PL.21396	PL.21566	C	#1/0 ACSR	7.39Y	123.1	0.00	1.88	1.31	1	9	3	95	0.00	0.0	2.519	0.097	9	3	1	1
PL.21464	PL.21566	C	#4 ACSR	7.39Y	123.1	0.01	1.89	3.23	2	23	7	96	0.00	0.0	2.480	0.058	8	2	1	7
PL.21397	PL.21464	C	#2 ACSR	7.39Y	123.1	0.00	1.89	2.14	1	15	5	95	0.00	0.0	2.534	0.054	0	0	0	6
PL.21398	PL.21397	C	#1/0 ACSR	7.39Y	123.1	0.01	1.89	1.88	1	13	4	96	0.00	0.0	2.649	0.114	0	0	0	5
PL.21564	PL.21398	C	#1/0 ACSR	7.39Y	123.1	0.00	1.90	1.88	1	13	4	96	0.00	0.0	2.735	0.086	8	2	3	5
PL.21565	PL.21564	C	#1/0 ACSR	7.39Y	123.1	0.00	1.90	0.71	0	5	2	93	0.00	0.0	2.778	0.043	1	0	1	2
PL.21561	PL.21565	C	#1/0 ACSR	7.39Y	123.1	0.00	1.90	0.56	0	4	1	97	0.00	0.0	2.839	0.061	4	1	1	1
PL.21465	PL.21397	C	#2 ACSR	7.39Y	123.1	0.00	1.89	0.26	0	2	1	89	0.00	0.0	2.555	0.020	2	1	1	1
PL.21506	PL.21694	A C	#1/0 ACSR	7.38Y	123.0	0.12	1.98	34.62	15	489	149	96	0.40	0.1	2.491	0.169	0	0	0	90
PL.21695	PL.21506	C	#4 ACSR	7.38Y	123.0	0.00	1.98	0.38	0	3	1	95	0.00	0.0	2.495	0.005	0	0	0	1
PD.3103	PL.21695	C	20T	7.38Y	123.0	0.00	1.98	0.38	0	3	1	95	0.00	0.0	2.495	0.005	0	0	0	1
PL.21700	PD.3103	C	#4 ACSR	7.38Y	123.0	0.00	1.98	0.38	0	3	1	95	0.00	0.0	2.522	0.026	3	1	1	1
PL.21466	PL.21506	A C	#1/0 ACSR	7.38Y	122.9	0.09	2.07	34.43	15	486	148	96	0.29	0.1	2.615	0.124	0	0	0	89
PL.21656	PL.21466	C	#4 ACSR	7.38Y	122.9	0.00	2.07	0.39	0	3	1	95	0.00	0.0	2.620	0.005	0	0	0	1
PD.3083	PL.21656	C	20T	7.38Y	122.9	0.00	2.07	0.39	0	3	1	95	0.00	0.0	2.620	0.005	0	0	0	1
PL.21657	PD.3083	C	#4 ACSR	7.38Y	122.9	0.00	2.07	0.39	0	3	1	95	0.00	0.0	2.655	0.035	3	1	1	1
PL.21467	PL.21466	A C	#1/0 ACSR	7.37Y	122.9	0.08	2.15	33.24	14	469	143	96	0.25	0.1	2.728	0.113	0	0	0	85
PL.21579	PL.21467	A C	#1/0 ACSR	7.37Y	122.8	0.07	2.22	33.24	14	469	142	96	0.22	0.0	2.831	0.103	0	0	1	85
PL.21580	PL.21579	A C	#1/0 ACSR	7.36Y	122.7	0.07	2.29	33.21	14	468	142	96	0.20	0.0	2.926	0.094	8	2	1	84

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21578	PL.21580	A C	#1/0 ACSR	7.36Y	122.7	0.05	2.34	32.63	14	460	139	96	0.15	0.0	2.999	0.073	3	1	2	83
PL.21505	PL.21578	A C	#1/0 ACSR	7.36Y	122.6	0.03	2.37	26.83	12	378	114	96	0.09	0.0	3.061	0.062	0	0	0	65
PL.21652	PL.21505	A C	#1/0 ACSR	7.36Y	122.6	0.04	2.41	26.83	12	378	114	96	0.10	0.0	3.134	0.074	0	0	0	64
PL.21653	PL.21652	A C	#1/0 ACSR	7.36Y	122.6	0.00	2.42	26.83	12	378	114	96	0.01	0.0	3.139	0.004	8	2	1	64
PL.21504	PL.21653	A C	#1/0 ACSR	7.35Y	122.5	0.07	2.48	25.11	11	354	107	96	0.16	0.0	3.268	0.129	6	2	1	61
PL.21587	PL.21504	A C	#1/0 ACSR	7.35Y	122.5	0.02	2.51	18.43	8	259	79	96	0.04	0.0	3.330	0.062	8	2	1	45
PL.21588	PL.21587	A C	#1/0 ACSR	7.35Y	122.5	0.04	2.54	17.86	8	251	76	96	0.06	0.0	3.425	0.095	0	0	0	44
PL.21664	PL.21588	A	#2 ACSR	7.35Y	122.5	0.00	2.54	1.20	1	8	3	94	0.00	0.0	3.430	0.005	0	0	0	2
PD.3087	PL.21664	A	20T	7.35Y	122.5	0.00	2.54	1.20	0	8	3	94	0.00	0.0	3.430	0.005	0	0	0	2
PL.21665	PD.3087	A	#2 ACSR	7.35Y	122.5	0.00	2.55	1.20	1	8	3	94	0.00	0.0	3.518	0.088	8	3	2	2
PL.21473	PL.21588	A C	#1/0 ACSR	7.35Y	122.4	0.03	2.57	17.26	8	243	73	96	0.05	0.0	3.510	0.085	0	0	0	42
PL.21474	PL.21473	A C	#1/0 ACSR	7.34Y	122.4	0.03	2.60	17.10	7	240	73	96	0.04	0.0	3.586	0.076	0	0	0	41
PL.21713	PL.21474	C	#2 ACSR	7.34Y	122.4	0.00	2.60	1.82	1	13	4	96	0.00	0.0	3.622	0.036	0	0	0	3
PD.3110	PL.21713	C	35L	7.34Y	122.4	0.00	2.60	1.82	5	13	4	96	0.00	0.0	3.622	0.036	0	0	0	3
PL.21714	PD.3110	C	#2 ACSR	7.34Y	122.4	0.00	2.60	1.82	1	13	4	96	0.00	0.0	3.657	0.035	13	4	2	3
PL.21596	PL.21714	C	#2 ACSR	7.34Y	122.4	0.00	2.60	0.01	0	0	0	100	0.00	0.0	3.825	0.168	0	0	0	1
PL.21412	PL.21596	C	#2 ACSR	7.34Y	122.4	0.00	2.60	0.01	0	0	0	100	0.00	0.0	3.938	0.114	0	0	1	1
PL.21475	PL.21596	C	#2 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	3.905	0.080	0	0	0	0
PL.21413	PL.21475	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	4.030	0.125	0	0	0	0
PL.21488	PL.21413	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	4.218	0.188	0	0	0	0
PL.21489	PL.21488	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	4.281	0.063	0	0	0	0
PL.21414	PL.21489	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	4.348	0.067	0	0	0	0
PL.21415	PL.21489	C	6 A (CWC)	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	4.337	0.056	0	0	0	0
PL.21409	PL.21474	A	#1/0 ACSR	7.34Y	122.3	0.06	2.66	32.38	14	228	69	96	0.08	0.0	3.659	0.073	0	0	0	38
PL.21410	PL.21409	A	#1/0 ACSR	7.34Y	122.3	0.06	2.72	31.97	14	225	68	96	0.09	0.0	3.738	0.079	0	0	0	37
PL.21715	PL.21410	A	#1/0 ACSR	7.34Y	122.3	0.00	2.72	29.39	13	206	62	96	0.00	0.0	3.741	0.003	0	0	0	36
PD.3111	PL.21715	A	50L	7.34Y	122.3	0.00	2.72	29.39	59	206	62	96	0.00	0.0	3.741	0.003	0	0	0	36
PL.21716	PD.3111	A	#1/0 ACSR	7.34Y	122.3	0.02	2.74	29.39	13	206	62	96	0.03	0.0	3.772	0.031	2	0	2	36
PL.21417	PL.21716	A	#2 ACSR	7.34Y	122.3	0.00	2.74	0.43	0	3	1	95	0.00	0.0	3.905	0.133	0	0	0	2
PL.21650	PL.21417	A	1/0 AL URD	7.34Y	122.3	0.00	2.74	0.43	0	3	1	95	0.00	0.0	3.910	0.005	0	0	0	2
PD.3081	PL.21650	A	15T	7.34Y	122.3	0.00	2.74	0.43	0	3	1	95	0.00	0.0	3.910	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21651	PD.3081	A	1/0 AL URD	7.34Y	122.3	0.00	2.74	0.43	0	3	1	95	0.00	0.0	3.965	0.055	3	1	2	2
PL.21416	PL.21716	A	6 A (CWC)	7.33Y	122.1	0.15	2.89	28.74	21	202	61	96	0.23	0.1	3.887	0.115	0	0	0	32
PL.21490	PL.21416	A	6 A (CWC)	7.32Y	122.0	0.14	3.04	28.74	21	202	61	96	0.22	0.1	3.996	0.109	0	0	0	32
PL.21503	PL.21490	A	6 A (CWC)	7.31Y	121.9	0.09	3.13	25.51	18	179	54	96	0.12	0.1	4.072	0.075	0	0	0	30
PL.21599	PL.21503	A	6 A (CWC)	7.31Y	121.8	0.05	3.18	19.93	14	140	42	96	0.05	0.0	4.129	0.058	9	3	1	24
PL.21600	PL.21599	A	6 A (CWC)	7.30Y	121.7	0.11	3.29	18.65	13	130	39	96	0.11	0.1	4.262	0.133	0	0	0	23
PL.21501	PL.21600	A	6 A (CWC)	7.30Y	121.7	0.01	3.30	3.05	2	21	6	96	0.00	0.0	4.339	0.077	1	0	1	5
PL.21423	PL.21501	A	6 A (CWC)	7.30Y	121.7	0.00	3.31	1.84	1	13	4	96	0.00	0.0	4.426	0.087	11	3	1	3
PL.21425	PL.21423	A	#1/0 ACSR	7.30Y	121.7	0.00	3.31	0.33	0	2	1	89	0.00	0.0	4.480	0.053	2	1	2	2
PL.21502	PL.21501	A	6 A (CWC)	7.30Y	121.7	0.01	3.31	1.12	1	8	2	97	0.00	0.0	4.517	0.177	0	0	0	1
PL.21434	PL.21502	A	#4 ACSR	7.30Y	121.7	0.00	3.31	1.12	1	8	2	97	0.00	0.0	4.523	0.007	8	2	1	1
PL.21424	PL.21600	A	6 A (CWC)	7.29Y	121.6	0.15	3.44	15.59	11	109	33	96	0.12	0.1	4.470	0.208	0	0	0	18
PL.21427	PL.21424	A	6 A (CWC)	7.29Y	121.6	0.00	3.44	0.00	0	0	0	100	0.00	0.0	4.562	0.092	0	0	0	0
PL.21426	PL.21424	A	6 A (CWC)	7.29Y	121.5	0.04	3.48	15.59	11	109	33	96	0.04	0.0	4.530	0.060	0	0	0	18
PL.21499	PL.21426	A	6 A (CWC)	7.29Y	121.5	0.03	3.51	6.87	5	48	14	96	0.01	0.0	4.629	0.098	1	0	1	8
PL.21430	PL.21499	A	#4 ACSR	7.29Y	121.5	0.00	3.52	1.06	1	7	2	96	0.00	0.0	4.712	0.083	7	2	2	2
PL.21500	PL.21499	A	6 A (CWC)	7.29Y	121.5	0.02	3.54	5.71	4	40	12	96	0.01	0.0	4.717	0.088	0	0	0	5
PL.21479	PL.21500	A	6 A (CWC)	7.29Y	121.5	0.00	3.54	2.21	2	15	5	95	0.00	0.0	4.802	0.084	15	5	1	1
PL.21431	PL.21500	A	#2 ACSR	7.29Y	121.4	0.01	3.55	3.50	2	24	7	96	0.00	0.0	4.860	0.142	9	3	1	4
PL.21672	PL.21431	A	1/0 AL URD	7.29Y	121.4	0.00	3.55	2.23	1	16	5	95	0.00	0.0	4.864	0.005	0	0	0	3
PD.3091	PL.21672	A	15T	7.29Y	121.4	0.00	3.55	2.23	0	16	5	95	0.00	0.0	4.864	0.005	0	0	0	3
PL.21673	PD.3091	A	1/0 AL URD	7.29Y	121.4	0.00	3.56	2.23	1	16	5	95	0.00	0.0	4.954	0.090	10	3	2	3
PL.21616	PL.21673	A	1/0 AL URD	7.29Y	121.4	0.00	3.56	0.84	0	6	2	95	0.00	0.0	5.106	0.151	6	2	1	1
PL.21429	PL.21426	A	#2 ACSR	7.29Y	121.5	0.00	3.48	1.05	1	7	2	96	0.00	0.0	4.585	0.055	7	2	1	2
PL.21670	PL.21429	A	1/0 AL URD	7.29Y	121.5	0.00	3.48	0.05	0	0	0	100	0.00	0.0	4.590	0.005	0	0	0	1
PD.3090	PL.21670	A	15T	7.29Y	121.5	0.00	3.48	0.05	0	0	0	100	0.00	0.0	4.590	0.005	0	0	0	1
PL.21671	PD.3090	A	1/0 AL URD	7.29Y	121.5	0.00	3.48	0.05	0	0	0	100	0.00	0.0	4.631	0.041	0	0	1	1
PL.21428	PL.21426	A	#4 ACSR	7.29Y	121.5	0.03	3.51	7.68	6	54	16	96	0.01	0.0	4.624	0.093	7	2	1	8
PL.21601	PL.21428	A	#4 ACSR	7.29Y	121.5	0.02	3.54	6.73	5	47	14	96	0.01	0.0	4.716	0.092	13	4	2	7
PL.21602	PL.21601	A	#4 ACSR	7.29Y	121.4	0.02	3.55	4.83	4	34	10	96	0.00	0.0	4.793	0.078	0	0	0	5
PL.21478	PL.21602	A	#4 ACSR	7.29Y	121.4	0.00	3.56	3.77	3	26	8	96	0.00	0.0	4.819	0.026	7	2	2	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21433	PL.21478	A	#4 ACSR	7.29Y	121.4	0.00	3.56	2.83	2	20	6	96	0.00	0.0	4.847	0.028	0	0	0	2
PL.21435	PL.21433	A	#4 ACSR	7.29Y	121.4	0.01	3.57	1.55	1	11	3	96	0.00	0.0	4.955	0.107	0	0	0	1
PL.21494	PL.21435	A	#4 ACSR	7.29Y	121.4	0.01	3.58	1.55	1	11	3	96	0.00	0.0	5.091	0.136	0	0	0	1
PL.21495	PL.21494	A	#4 ACSR	7.29Y	121.4	0.00	3.58	1.55	1	11	3	96	0.00	0.0	5.192	0.101	11	3	1	1
PL.21438	PL.21433	A	#4 ACSR	7.29Y	121.4	0.00	3.56	1.27	1	9	3	95	0.00	0.0	4.927	0.079	9	3	1	1
PL.21432	PL.21602	A	#4 ACSR	7.29Y	121.4	0.00	3.56	1.06	1	7	2	96	0.00	0.0	4.891	0.097	7	2	1	1
PL.21420	PL.21503	A	6 A (CWC)	7.31Y	121.9	0.02	3.14	5.58	4	39	12	96	0.00	0.0	4.136	0.065	7	2	2	6
PL.21421	PL.21420	A	#2 ACSR	7.31Y	121.8	0.02	3.16	4.63	3	32	10	95	0.00	0.0	4.249	0.112	0	0	0	4
PL.21597	PL.21421	A	#1/0 ACSR	7.31Y	121.8	0.00	3.16	2.69	1	19	6	95	0.00	0.0	4.298	0.049	6	2	1	2
PL.21598	PL.21597	A	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.81	1	13	4	96	0.00	0.0	4.412	0.114	13	4	1	1
PL.21477	PL.21421	A	#2 ACSR	7.31Y	121.8	0.00	3.16	1.95	1	14	4	96	0.00	0.0	4.302	0.053	5	2	1	2
PL.21422	PL.21477	A	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.21	1	8	3	94	0.00	0.0	4.322	0.020	8	3	1	1
PL.21418	PL.21490	A	6 A (CWC)	7.32Y	121.9	0.03	3.06	3.23	2	23	7	96	0.00	0.0	4.178	0.182	0	0	0	2
PL.21491	PL.21418	A	6 A (CWC)	7.32Y	121.9	0.01	3.08	3.23	2	23	7	96	0.00	0.0	4.255	0.077	0	0	0	2
PL.21498	PL.21491	A	6 A (CWC)	7.31Y	121.9	0.02	3.09	3.23	2	23	7	96	0.00	0.0	4.369	0.115	0	0	0	2
PL.21492	PL.21498	A	6 A (CWC)	7.31Y	121.9	0.01	3.10	3.23	2	23	7	96	0.00	0.0	4.447	0.077	0	0	0	2
PL.21419	PL.21492	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.31	0	2	1	89	0.00	0.0	4.573	0.126	0	0	0	1
PL.21493	PL.21419	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.31	0	2	1	89	0.00	0.0	4.643	0.070	2	1	1	1
PL.21476	PL.21492	A	6 A (CWC)	7.31Y	121.9	0.01	3.11	2.93	2	21	6	96	0.00	0.0	4.545	0.098	21	6	1	1
PL.21411	PL.21410	A	#1/0 ACSR	7.34Y	122.3	0.00	2.72	2.58	1	18	5	96	0.00	0.0	3.772	0.034	18	5	1	1
PL.21666	PL.21409	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	0.40	0	3	1	95	0.00	0.0	3.663	0.005	0	0	0	1
PD.3088	PL.21666	A	20T	7.34Y	122.3	0.00	2.66	0.40	0	3	1	95	0.00	0.0	3.663	0.005	0	0	0	1
PL.21667	PD.3088	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	0.40	0	3	1	95	0.00	0.0	3.747	0.083	3	1	1	1
PL.21668	PL.21473	C	#2 ACSR	7.35Y	122.4	0.00	2.57	0.31	0	2	1	89	0.00	0.0	3.514	0.005	0	0	0	1
PD.3089	PL.21668	C	20T	7.35Y	122.4	0.00	2.57	0.31	0	2	1	89	0.00	0.0	3.514	0.005	0	0	0	1
PL.21669	PD.3089	C	#2 ACSR	7.35Y	122.4	0.00	2.57	0.31	0	2	1	89	0.00	0.0	3.562	0.047	2	1	1	1
PL.21662	PL.21504	A	#4 ACSR	7.35Y	122.5	0.00	2.49	12.55	10	88	27	96	0.00	0.0	3.273	0.005	0	0	0	15
PD.3086	PL.21662	A	20T	7.35Y	122.5	0.00	2.49	12.55	0	88	27	96	0.00	0.0	3.273	0.005	0	0	0	15
PL.21663	PD.3086	A	#4 ACSR	7.35Y	122.5	0.02	2.50	12.55	10	88	27	96	0.01	0.0	3.304	0.031	13	4	1	15
PL.21586	PL.21663	A	#4 ACSR	7.35Y	122.5	0.03	2.53	10.66	8	75	23	96	0.02	0.0	3.365	0.062	7	2	1	14
PL.21585	PL.21586	A	#4 ACSR	7.35Y	122.4	0.03	2.56	9.59	7	67	20	96	0.02	0.0	3.440	0.075	0	0	0	13

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21403	PL.21585	A	#4 ACSR	7.35Y	122.4	0.02	2.58	9.22	7	65	19	96	0.01	0.0	3.477	0.037	0	0	0	12
PL.21471	PL.21403	A	#4 ACSR	7.35Y	122.4	0.00	2.58	1.72	1	12	4	95	0.00	0.0	3.551	0.074	12	4	1	1
PL.21404	PL.21403	A	6 A (CWC)	7.34Y	122.4	0.04	2.62	7.50	5	53	16	96	0.02	0.0	3.601	0.124	7	2	1	11
PL.21405	PL.21404	A	#2 ACSR	7.34Y	122.4	0.00	2.62	0.89	1	6	2	95	0.00	0.0	3.643	0.041	6	2	2	2
PL.21583	PL.21404	A	6 A (CWC)	7.34Y	122.4	0.02	2.64	5.65	4	40	12	96	0.01	0.0	3.706	0.105	17	5	2	8
PL.21584	PL.21583	A	6 A (CWC)	7.34Y	122.4	0.01	2.65	3.17	2	22	7	95	0.00	0.0	3.762	0.056	0	0	0	6
PL.21472	PL.21584	A	6 A (CWC)	7.34Y	122.3	0.00	2.65	2.21	2	16	5	95	0.00	0.0	3.802	0.040	0	0	0	5
PL.21407	PL.21472	A	6 A (CWC)	7.34Y	122.3	0.01	2.66	2.21	2	16	5	95	0.00	0.0	3.924	0.122	4	1	1	5
PL.21611	PL.21407	A	6 A (CWC)	7.34Y	122.3	0.01	2.67	1.03	1	7	2	96	0.00	0.0	4.036	0.112	0	0	1	3
PL.21612	PL.21611	A	6 A (CWC)	7.34Y	122.3	0.01	2.68	1.02	1	7	2	96	0.00	0.0	4.199	0.163	0	0	0	2
PL.21609	PL.21612	A	6 A (CWC)	7.34Y	122.3	0.00	2.68	1.02	1	7	2	96	0.00	0.0	4.247	0.048	0	0	1	2
PL.21610	PL.21609	A	6 A (CWC)	7.34Y	122.3	0.00	2.68	0.98	1	7	2	96	0.00	0.0	4.309	0.062	7	2	1	1
PL.21408	PL.21407	A	#4 ACSR	7.34Y	122.3	0.00	2.66	0.58	0	4	1	97	0.00	0.0	3.975	0.051	4	1	1	1
PL.21406	PL.21584	A	#1/0 ACSR	7.34Y	122.4	0.00	2.65	0.96	0	7	2	96	0.00	0.0	3.895	0.134	7	2	1	1
PL.21470	PL.21585	A	#4 ACSR	7.35Y	122.4	0.00	2.56	0.38	0	3	1	95	0.00	0.0	3.526	0.086	3	1	1	1
PL.21654	PL.21653	A	#1/0 ACSR	7.35Y	122.6	0.00	2.42	2.37	1	17	5	96	0.00	0.0	3.144	0.005	0	0	0	2
PD.3082	PL.21654	A	20T	7.35Y	122.6	0.00	2.42	2.37	0	17	5	96	0.00	0.0	3.144	0.005	0	0	0	2
PL.21655	PD.3082	A	#1/0 ACSR	7.35Y	122.6	0.00	2.42	2.37	1	17	5	96	0.00	0.0	3.159	0.015	0	0	1	2
PL.21577	PL.21655	A	#1/0 ACSR	7.35Y	122.6	0.00	2.42	2.37	1	17	5	96	0.00	0.0	3.203	0.044	17	5	1	1
PL.21660	PL.21505	C	#2 ACSR	7.36Y	122.6	0.00	2.37	0.00	0	0	0	100	0.00	0.0	3.065	0.005	0	0	0	1
PD.3085	PL.21660	C	20T	7.36Y	122.6	0.00	2.37	0.00	0	0	0	100	0.00	0.0	3.065	0.005	0	0	0	1
PL.21661	PD.3085	C	#2 ACSR	7.36Y	122.6	0.00	2.37	0.00	0	0	0	100	0.00	0.0	3.111	0.046	0	0	1	1
PL.21658	PL.21578	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	11.13	8	78	24	96	0.00	0.0	3.004	0.005	0	0	0	16
PD.3084	PL.21658	C	20T	7.36Y	122.7	0.00	2.34	11.13	0	78	24	96	0.00	0.0	3.004	0.005	0	0	0	16
PL.21659	PD.3084	C	6 A (CWC)	7.36Y	122.6	0.02	2.36	11.13	8	78	24	96	0.01	0.0	3.042	0.038	1	0	1	16
PL.21582	PL.21659	C	6 A (CWC)	7.36Y	122.6	0.03	2.39	10.97	8	77	23	96	0.02	0.0	3.097	0.055	6	2	1	15
PL.21581	PL.21582	C	6 A (CWC)	7.36Y	122.6	0.03	2.41	10.18	7	72	22	96	0.01	0.0	3.156	0.059	0	0	2	14
PL.21400	PL.21581	C	#2 ACSR	7.35Y	122.6	0.02	2.43	10.18	6	72	22	96	0.01	0.0	3.219	0.063	0	0	0	12
PL.21399	PL.21400	C	#1/0 ACSR	7.35Y	122.6	0.00	2.44	1.28	1	9	3	95	0.00	0.0	3.304	0.085	9	3	1	1
PL.21468	PL.21400	C	#2 ACSR	7.35Y	122.5	0.02	2.45	8.90	5	63	19	96	0.01	0.0	3.281	0.062	0	0	0	11
PL.21589	PL.21468	C	#2 ACSR	7.35Y	122.5	0.02	2.47	8.90	5	63	19	96	0.01	0.0	3.350	0.070	14	4	2	11

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21590	PL.21589	C	#2 ACSR	7.35Y	122.5	0.02	2.49	6.87	4	48	15	95	0.01	0.0	3.430	0.080	0	0	0	9
PL.21401	PL.21590	C	#1/0 ACSR	7.35Y	122.5	0.00	2.49	1.25	1	9	3	95	0.00	0.0	3.479	0.049	9	3	2	2
PL.21469	PL.21590	C	#2 ACSR	7.35Y	122.5	0.02	2.50	5.62	3	40	12	96	0.01	0.0	3.531	0.101	0	0	0	7
PL.21592	PL.21469	C	#1/0 ACSR	7.35Y	122.5	0.00	2.51	1.79	1	13	4	96	0.00	0.0	3.566	0.035	0	0	1	3
PL.21593	PL.21592	C	#1/0 ACSR	7.35Y	122.5	0.00	2.51	1.77	1	12	4	95	0.00	0.0	3.683	0.117	0	0	1	2
PL.21591	PL.21593	C	#1/0 ACSR	7.35Y	122.5	0.00	2.51	1.74	1	12	4	95	0.00	0.0	3.730	0.047	12	4	1	1
PL.21402	PL.21469	C	#2 ACSR	7.35Y	122.5	0.00	2.51	1.98	1	14	4	96	0.00	0.0	3.616	0.084	14	4	2	2
PL.21594	PL.21469	C	#2 ACSR	7.35Y	122.5	0.00	2.51	1.85	1	13	4	96	0.00	0.0	3.574	0.043	10	3	1	2
PL.21595	PL.21594	C	#2 ACSR	7.35Y	122.5	0.00	2.51	0.38	0	3	1	95	0.00	0.0	3.588	0.014	3	1	1	1
PL.21701	PL.21466	A	#4 ACSR	7.38Y	122.9	0.00	2.07	1.98	2	14	4	96	0.00	0.0	2.619	0.005	0	0	0	3
PD.3104	PL.21701	A	20T	7.38Y	122.9	0.00	2.07	1.98	0	14	4	96	0.00	0.0	2.619	0.005	0	0	0	3
PL.21702	PD.3104	A	#4 ACSR	7.38Y	122.9	0.00	2.07	1.98	2	14	4	96	0.00	0.0	2.668	0.049	5	1	1	3
PL.21562	PL.21702	A	#2 ACSR	7.38Y	122.9	0.01	2.08	1.30	1	9	3	95	0.00	0.0	2.804	0.136	0	0	1	2
PL.21563	PL.21562	A	#2 ACSR	7.37Y	122.9	0.00	2.08	1.23	1	9	3	95	0.00	0.0	2.924	0.120	0	0	0	1
PL.21487	PL.21563	A	#2 ACSR	7.37Y	122.9	0.00	2.09	1.23	1	9	3	95	0.00	0.0	2.996	0.072	9	3	1	1
PL.21691	PL.21694	C	#2 ACSR	7.39Y	123.1	0.00	1.86	0.12	0	1	0	100	0.00	0.0	2.326	0.005	0	0	0	1
PD.3102	PL.21691	C	20T	7.39Y	123.1	0.00	1.86	0.12	0	1	0	100	0.00	0.0	2.326	0.005	0	0	0	1
PL.21692	PD.3102	C	#2 ACSR	7.39Y	123.1	0.00	1.86	0.12	0	1	0	100	0.00	0.0	2.389	0.063	1	0	1	1
PL.21687	PL.21392	C	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.11	0	1	0	100	0.00	0.0	2.248	0.005	0	0	0	1
PD.3100	PL.21687	C	20T	7.39Y	123.2	0.00	1.80	0.11	0	1	0	100	0.00	0.0	2.248	0.005	0	0	0	1
PL.21688	PD.3100	C	#1/0 ACSR	7.39Y	123.2	0.00	1.80	0.11	0	1	0	100	0.00	0.0	2.294	0.046	1	0	1	1
PL.21647	PL.21461	A	#1/0 ACSR	7.40Y	123.3	0.00	1.73	0.75	0	5	2	93	0.00	0.0	2.164	0.005	0	0	0	2
PD.3079	PL.21647	A	20T	7.40Y	123.3	0.00	1.73	0.75	0	5	2	93	0.00	0.0	2.164	0.005	0	0	0	2
PL.21646	PD.3079	A	#1/0 ACSR	7.40Y	123.3	0.00	1.73	0.75	0	5	2	93	0.00	0.0	2.208	0.044	5	2	2	2
PL.21640	PL.21457	A	#1/0 ACSR	7.41Y	123.5	0.00	1.46	0.06	0	0	0	100	0.00	0.0	1.856	0.005	0	0	0	1
PD.3076	PL.21640	A	20T	7.41Y	123.5	0.00	1.46	0.06	0	0	0	100	0.00	0.0	1.856	0.005	0	0	0	1
PL.21641	PD.3076	A	#1/0 ACSR	7.41Y	123.5	0.00	1.46	0.06	0	0	0	100	0.00	0.0	1.882	0.026	0	0	0	1
PL.21385	PL.21641	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.06	0	0	0	100	0.00	0.0	1.932	0.050	0	0	0	1
PL.21386	PL.21385	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	1.986	0.054	0	0	0	0
PL.21459	PL.21385	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.06	0	0	0	100	0.00	0.0	2.021	0.089	0	0	1	1
PL.21683	PL.21384	A	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.747	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3097	PL.21683	A	20T	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.747	0.005	0	0	0	1
PL.21684	PD.3097	A	#1/0 ACSR	7.42Y	123.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	1.751	0.005	0	0	1	1
PL.21634	PL.21347	A	#1/0 ACSR	7.44Y	124.0	0.00	0.96	0.97	0	7	2	96	0.00	0.0	1.297	0.005	0	0	0	1
PD.3073	PL.21634	A	65T	7.44Y	124.0	0.00	0.96	0.97	0	7	2	96	0.00	0.0	1.297	0.005	0	0	0	1
PL.21635	PD.3073	A	#1/0 ACSR	7.44Y	124.0	0.00	0.96	0.97	0	7	2	96	0.00	0.0	1.313	0.015	7	2	1	1
PL.21625	PL.21340	A	6 A (CWC)	7.47Y	124.5	0.00	0.53	2.27	2	16	5	95	0.00	0.0	0.766	0.005	0	0	0	1
PD.3068	PL.21625	A	65T	7.47Y	124.5	0.00	0.53	2.27	0	16	5	95	0.00	0.0	0.766	0.005	0	0	0	1
PL.21626	PD.3068	A	6 A (CWC)	7.47Y	124.5	0.00	0.53	2.27	2	16	5	95	0.00	0.0	0.828	0.063	16	5	1	1
PL.21678	PL.21340	C	6 A (CWC)	7.47Y	124.5	0.00	0.53	9.38	7	67	20	96	0.00	0.0	0.766	0.005	0	0	0	12
PD.3094	PL.21678	C	65T	7.47Y	124.5	0.00	0.53	9.38	0	67	20	96	0.00	0.0	0.766	0.005	0	0	0	12
PL.21679	PD.3094	C	6 A (CWC)	7.47Y	124.5	0.01	0.53	9.38	7	67	20	96	0.00	0.0	0.784	0.018	0	0	0	12
PL.21447	PL.21679	C	6 A (CWC)	7.47Y	124.5	0.01	0.55	3.24	2	23	7	96	0.00	0.0	0.859	0.074	3	1	1	5
PL.21342	PL.21447	C	#4 ACSR	7.47Y	124.4	0.01	0.55	2.86	2	20	6	96	0.00	0.0	0.904	0.045	0	0	0	4
PL.21538	PL.21342	C	#4 ACSR	7.47Y	124.4	0.00	0.55	1.65	1	12	4	95	0.00	0.0	0.939	0.035	3	1	2	3
PL.21539	PL.21538	C	#4 ACSR	7.47Y	124.4	0.00	0.55	1.26	1	9	3	95	0.00	0.0	0.974	0.036	9	3	1	1
PL.21343	PL.21342	C	#4 ACSR	7.47Y	124.4	0.00	0.55	1.21	1	9	3	95	0.00	0.0	0.992	0.089	9	3	1	1
PL.21341	PL.21679	C	#1/0 ACSR	7.47Y	124.5	0.01	0.55	6.14	3	44	13	96	0.00	0.0	0.870	0.086	0	0	0	7
PL.21680	PL.21341	C	1/0 AL URD	7.47Y	124.5	0.00	0.55	4.74	3	34	10	96	0.00	0.0	0.875	0.005	0	0	0	5
PD.3095	PL.21680	C	65T	7.47Y	124.5	0.00	0.55	4.74	0	34	10	96	0.00	0.0	0.875	0.005	0	0	0	5
PL.21514	PD.3095	C	1/0 AL URD	7.47Y	124.4	0.01	0.56	4.74	3	34	10	96	0.00	0.0	0.970	0.096	7	2	1	5
PL.21614	PL.21514	C	1/0 AL URD	7.47Y	124.4	0.00	0.56	3.70	2	26	8	96	0.00	0.0	1.002	0.032	8	2	1	4
PL.21615	PL.21614	C	1/0 AL URD	7.47Y	124.4	0.01	0.57	2.57	2	18	6	95	0.00	0.0	1.075	0.073	0	0	0	3
PL.21613	PL.21615	C	1/0 AL URD	7.47Y	124.4	0.00	0.57	2.17	1	16	5	95	0.00	0.0	1.105	0.030	16	5	2	2
PL.21519	PL.21613	C	1/0 AL URD	7.47Y	124.4	0.00	0.57	0.00	0	0	0	100	0.00	0.0	1.171	0.067	0	0	0	0
PL.21437	PL.21615	C	1/0 AL URD	7.47Y	124.4	0.00	0.57	0.39	0	3	1	95	0.00	0.0	1.089	0.014	3	1	1	1
PL.21627	PL.21341	C	1/0 AL URD	7.47Y	124.5	0.00	0.55	1.40	1	10	3	96	0.00	0.0	0.875	0.005	0	0	0	2
PD.3069	PL.21627	C	65T	7.47Y	124.5	0.00	0.55	1.40	0	10	3	96	0.00	0.0	0.875	0.005	0	0	0	2
PL.21515	PD.3069	C	1/0 AL URD	7.47Y	124.4	0.00	0.55	1.40	1	10	3	96	0.00	0.0	0.945	0.071	0	0	0	2
PL.21516	PL.21515	C	1/0 AL URD	7.47Y	124.4	0.00	0.55	0.00	0	0	0	100	0.00	0.0	1.049	0.104	0	0	0	0
PL.21436	PL.21515	C	1/0 AL URD	7.47Y	124.4	0.00	0.55	1.40	1	10	3	96	0.00	0.0	0.988	0.042	10	3	2	2
PL.21623	PL.21444	A	#4 ACSR	7.48Y	124.6	0.00	0.37	1.26	1	9	3	95	0.00	0.0	0.587	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3067	PL.21623	A	65T	7.48Y	124.6	0.00	0.37	1.26	0	9	3	95	0.00	0.0	0.587	0.005	0	0	0	1
PL.21624	PD.3067	A	#4 ACSR	7.48Y	124.6	0.00	0.37	1.26	1	9	3	95	0.00	0.0	0.666	0.079	9	3	1	1
PL.21335	PL.21334	B	#2 ACSR	7.49Y	124.9	0.00	0.13	1.55	1	11	3	96	0.00	0.0	0.352	0.051	11	3	1	1
PL.21619	PL.21334	C	#4 ACSR	7.49Y	124.9	0.00	0.13	1.80	1	13	4	96	0.00	0.0	0.305	0.005	0	0	0	3
PD.3065	PL.21619	C	65T	7.49Y	124.9	0.00	0.13	1.80	0	13	4	96	0.00	0.0	0.305	0.005	0	0	0	3
PL.21620	PD.3065	C	#4 ACSR	7.49Y	124.9	0.00	0.13	1.80	1	13	4	96	0.00	0.0	0.334	0.029	0	0	0	3
PL.21535	PL.21620	C	#4 ACSR	7.49Y	124.9	0.00	0.13	1.80	1	13	4	96	0.00	0.0	0.399	0.065	13	4	3	3
PL.21521	PL.21439	B	#2 ACSR	7.50Y	125.0	0.01	0.03	15.92	9	114	34	96	0.01	0.0	0.125	0.024	10	3	2	20
PL.21707	PL.21521	B	#2 ACSR	7.50Y	125.0	0.00	0.03	14.51	8	104	31	96	0.00	0.0	0.128	0.003	0	0	0	18
PD.3107	PL.21707	B	35L	7.50Y	125.0	0.00	0.03	14.51	41	104	31	96	0.00	0.0	0.128	0.003	0	0	0	18
PL.21708	PD.3107	B	#2 ACSR	7.50Y	124.9	0.02	0.06	14.51	8	104	31	96	0.02	0.0	0.184	0.057	10	3	1	18
PL.21333	PL.21708	B	#4 ACSR	7.50Y	124.9	0.00	0.06	0.87	1	6	2	95	0.00	0.0	0.218	0.034	6	2	1	1
PL.21329	PL.21708	B	6 A (CWC)	7.50Y	124.9	0.01	0.07	12.29	9	88	27	96	0.01	0.0	0.208	0.024	0	0	0	16
PL.21332	PL.21329	B	#2 ACSR	7.50Y	124.9	0.00	0.07	1.58	1	11	3	96	0.00	0.0	0.278	0.070	0	0	0	1
PL.21674	PL.21332	B	1/0 AL URD	7.50Y	124.9	0.00	0.07	1.58	1	11	3	96	0.00	0.0	0.283	0.005	0	0	0	1
PD.3092	PL.21674	B	65T	7.50Y	124.9	0.00	0.07	1.58	0	11	3	96	0.00	0.0	0.283	0.005	0	0	0	1
PL.21675	PD.3092	B	1/0 AL URD	7.50Y	124.9	0.00	0.08	1.58	1	11	3	96	0.00	0.0	0.445	0.162	11	3	1	1
PL.21441	PL.21329	B	6 A (CWC)	7.49Y	124.9	0.04	0.11	10.72	8	77	23	96	0.02	0.0	0.294	0.086	0	0	0	15
PL.21328	PL.21441	B	6 A (CWC)	7.49Y	124.8	0.04	0.15	9.79	7	70	21	96	0.02	0.0	0.388	0.094	10	3	1	12
PL.21324	PL.21328	B	#4 ACSR	7.49Y	124.8	0.01	0.16	8.36	6	60	18	96	0.01	0.0	0.418	0.030	0	0	0	11
PL.21442	PL.21324	B	#4 ACSR	7.49Y	124.8	0.01	0.18	8.36	6	60	18	96	0.01	0.0	0.452	0.034	0	0	0	11
PL.21326	PL.21442	B	#4 ACSR	7.49Y	124.8	0.00	0.18	0.53	0	4	1	97	0.00	0.0	0.534	0.082	4	1	1	1
PL.21606	PL.21442	B	#4 ACSR	7.49Y	124.8	0.02	0.20	7.83	6	56	17	96	0.01	0.0	0.510	0.058	0	0	2	10
PL.21607	PL.21606	B	#4 ACSR	7.49Y	124.8	0.02	0.22	7.78	6	56	17	96	0.01	0.0	0.586	0.076	8	2	2	8
PL.21605	PL.21607	B	#4 ACSR	7.49Y	124.8	0.02	0.24	6.73	5	48	14	96	0.01	0.0	0.653	0.068	0	0	0	6
PL.21323	PL.21605	B	#4 ACSR	7.48Y	124.7	0.01	0.25	5.64	4	40	12	96	0.00	0.0	0.710	0.056	0	0	0	5
PL.21322	PL.21323	B	#4 ACSR	7.48Y	124.7	0.02	0.28	5.24	4	38	11	96	0.01	0.0	0.848	0.139	23	7	1	4
PL.21321	PL.21322	B	#4 ACSR	7.48Y	124.7	0.01	0.29	2.08	2	15	4	97	0.00	0.0	0.931	0.082	0	0	1	3
PL.21320	PL.21321	B	#4 ACSR	7.48Y	124.7	0.00	0.29	1.35	1	10	3	96	0.00	0.0	1.019	0.089	10	3	1	1
PL.21603	PL.21321	B	#4 ACSR	7.48Y	124.7	0.00	0.29	0.71	1	5	2	93	0.00	0.0	1.003	0.073	5	2	1	1
PL.21604	PL.21603	B	#4 ACSR	7.48Y	124.7	0.00	0.29	0.00	0	0	0	100	0.00	0.0	1.090	0.087	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21443	PL.21323	B	#4 ACSR	7.48Y	124.7	0.00	0.26	0.39	0	3	1	95	0.00	0.0	0.766	0.057	3	1	1	1
PL.21325	PL.21605	B	#4 ACSR	7.49Y	124.8	0.00	0.24	1.09	1	8	2	97	0.00	0.0	0.737	0.084	8	2	1	1
PL.21327	PL.21324	B	#4 ACSR	7.49Y	124.8	0.00	0.16	0.00	0	0	0	100	0.00	0.0	0.468	0.049	0	0	0	0
PL.21330	PL.21441	B	#4 ACSR	7.49Y	124.9	0.00	0.11	0.93	1	7	2	96	0.00	0.0	0.350	0.056	7	2	2	2
PL.21331	PL.21441	B	6 A (CWC)	7.49Y	124.9	0.00	0.11	0.01	0	0	0	100	0.00	0.0	0.348	0.054	0	0	1	1
PL.21524	Hargett	ABC	636 SPACER	7.50Y	125.0	0.00	0.00	90.35	17	1928	643	95	0.00	0.0	0.006	0.006	0	0	0	369
PL.72939	PL.21524	ABC	636 SPACER	7.50Y	125.0	0.00	0.00	90.35	17	1928	643	95	0.00	0.0	0.009	0.003	0	0	0	369
----- Feeder No. 3 (Lower Bend F3) Beginning with Device PD.11207 -----																				
PD.11207	PL.72939	ABC	360VWE	7.50Y	125.0	0.00	0.00	90.35	0	1928	643	95	0.00	0.0	0.009	0.003	0	0	0	369
PL.21525	PD.11207	ABC	636 SPACER	7.50Y	125.0	0.00	0.01	90.35	17	1928	643	95	0.01	0.0	0.017	0.009	0	0	0	369
PL.21780	PL.21525	ABC	#2 ACSR	7.50Y	125.0	0.00	0.01	0.00	0	0	0	100	0.00	0.0	0.022	0.005	0	0	0	0
PL.22496	PL.21525	ABC	636 SPACER	7.50Y	125.0	0.02	0.02	90.35	17	1928	643	95	0.04	0.0	0.066	0.049	0	0	0	369
PL.22535	PL.22496	ABC	636 SPACER	7.50Y	125.0	0.02	0.05	90.35	17	1928	642	95	0.06	0.0	0.136	0.070	0	0	0	369
PL.22536	PL.22535	ABC	636 SPACER	7.50Y	124.9	0.03	0.08	90.35	17	1928	641	95	0.08	0.0	0.237	0.101	0	0	0	369
PL.22537	PL.22536	ABC	636 SPACER	7.49Y	124.9	0.02	0.10	90.35	17	1928	640	95	0.05	0.0	0.307	0.070	0	0	0	369
PL.22538	PL.22537	ABC	636 SPACER	7.49Y	124.9	0.03	0.14	90.35	17	1928	639	95	0.08	0.0	0.408	0.101	0	0	0	369
PL.22539	PL.22538	ABC	636 SPACER	7.49Y	124.8	0.04	0.17	90.35	17	1928	637	95	0.09	0.0	0.523	0.114	0	0	0	369
PL.22540	PL.22539	ABC	636 SPACER	7.49Y	124.8	0.04	0.22	90.35	17	1928	635	95	0.10	0.0	0.655	0.132	0	0	0	369
PL.22541	PL.22540	ABC	636 SPACER	7.48Y	124.7	0.05	0.27	90.35	17	1928	633	95	0.12	0.0	0.808	0.153	0	0	0	369
PL.22542	PL.22541	ABC	636 SPACER	7.48Y	124.7	0.03	0.30	90.35	17	1928	631	95	0.08	0.0	0.907	0.098	0	0	0	369
PL.22543	PL.22542	ABC	636 SPACER	7.48Y	124.7	0.04	0.34	90.35	17	1928	630	95	0.09	0.0	1.027	0.120	0	0	0	369
PL.22544	PL.22543	ABC	636 SPACER	7.48Y	124.6	0.04	0.38	90.35	17	1928	628	95	0.11	0.0	1.161	0.134	0	0	0	369
PL.22545	PL.22544	ABC	636 SPACER	7.48Y	124.6	0.03	0.41	90.35	17	1927	626	95	0.06	0.0	1.242	0.081	0	0	0	369
PL.21781	PL.22545	ABC	556 MCM AC	7.47Y	124.5	0.04	0.45	90.35	13	1927	625	95	0.10	0.0	1.368	0.126	0	0	0	369
PL.22546	PL.21781	ABC	556 MCM AC	7.47Y	124.5	0.04	0.49	90.35	13	1927	623	95	0.08	0.0	1.481	0.112	0	0	0	369
PL.22744	PL.22546	C	6 A (CWC)	7.47Y	124.5	0.00	0.49	0.20	0	1	0	100	0.00	0.0	1.486	0.005	0	0	0	1
PD.3205	PL.22744	C	65T	7.47Y	124.5	0.00	0.49	0.20	0	1	0	100	0.00	0.0	1.486	0.005	0	0	0	1
PL.22745	PD.3205	C	6 A (CWC)	7.47Y	124.5	0.00	0.49	0.20	0	1	0	100	0.00	0.0	1.627	0.141	1	0	1	1
PL.22497	PL.22546	ABC	556 MCM AC	7.47Y	124.5	0.02	0.51	90.28	13	1926	621	95	0.04	0.0	1.539	0.058	0	0	0	368

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22498	PL.22497	ABC	556 MCM AC	7.47Y	124.4	0.04	0.55	87.33	12	1863	601	95	0.10	0.0	1.675	0.136	0	0	0	354
PL.22547	PL.22498	ABC	556 MCM AC	7.46Y	124.4	0.05	0.60	87.33	12	1862	599	95	0.11	0.0	1.827	0.151	0	0	0	354
PL.22548	PL.22547	ABC	556 MCM AC	7.46Y	124.4	0.04	0.64	87.33	12	1862	597	95	0.08	0.0	1.945	0.118	0	0	0	354
PL.22549	PL.22548	ABC	556 MCM AC	7.46Y	124.3	0.03	0.67	87.33	12	1862	595	95	0.08	0.0	2.052	0.107	0	0	0	354
PL.22752	PL.22549	A	6 A (CWC)	7.46Y	124.3	0.00	0.67	1.48	1	11	3	96	0.00	0.0	2.057	0.005	0	0	0	4
PD.3209	PL.22752	A	65T	7.46Y	124.3	0.00	0.67	1.48	0	11	3	96	0.00	0.0	2.057	0.005	0	0	0	4
PL.22753	PD.3209	A	6 A (CWC)	7.46Y	124.3	0.01	0.68	1.48	1	11	3	96	0.00	0.0	2.161	0.105	0	0	0	4
PL.22571	PL.22753	A	6 A (CWC)	7.46Y	124.3	0.01	0.68	1.48	1	11	3	96	0.00	0.0	2.268	0.107	4	1	2	4
PL.21784	PL.22571	A	#2 ACSR	7.46Y	124.3	0.00	0.68	0.58	0	4	1	97	0.00	0.0	2.300	0.031	4	1	1	1
PL.22572	PL.22571	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.36	0	3	1	95	0.00	0.0	2.404	0.135	0	0	0	1
PL.22499	PL.22572	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.00	0	0	0	100	0.00	0.0	2.458	0.055	0	0	0	0
PL.22608	PL.22572	A	#4 ACSR	7.46Y	124.3	0.00	0.69	0.36	0	3	1	95	0.00	0.0	2.453	0.050	3	1	1	1
PL.22609	PL.22608	A	#4 ACSR	7.46Y	124.3	0.00	0.69	0.00	0	0	0	100	0.00	0.0	2.550	0.096	0	0	0	0
PL.22816	PL.22549	ABC	556 MCM AC	7.46Y	124.3	0.02	0.69	86.84	12	1852	590	95	0.04	0.0	2.115	0.063	0	0	0	350
PD.3241-A	PL.22816	ABC	Closed	7.46Y	124.3	0.00	0.69	86.84	0	1852	590	95	0.00	0.0	2.115	0.063	0	0	0	350
PD.3241-B	PD.3241-A	ABC	Closed	7.46Y	124.3	0.00	0.69	86.84	0	1852	590	95	0.00	0.0	2.115	0.063	0	0	0	350
PL.22817	PD.3241-B	ABC	556 MCM AC	7.46Y	124.3	0.01	0.70	86.84	12	1852	590	95	0.03	0.0	2.153	0.038	0	0	0	350
PL.22610	PL.22817	ABC	556 MCM AC	7.46Y	124.3	0.04	0.75	86.84	12	1852	589	95	0.10	0.0	2.295	0.142	0	0	0	350
PL.22550	PL.22610	ABC	556 MCM AC	7.45Y	124.2	0.05	0.79	86.84	12	1851	587	95	0.11	0.0	2.447	0.152	0	0	0	350
PL.22551	PL.22550	ABC	556 MCM AC	7.45Y	124.2	0.04	0.84	86.84	12	1851	585	95	0.10	0.0	2.591	0.144	0	0	0	350
PL.22820	PL.22551	ABC	556 MCM AC	7.45Y	124.1	0.05	0.88	86.84	12	1851	583	95	0.10	0.0	2.739	0.148	0	0	0	350
PD.3243-A	PL.22820	ABC	Closed	7.45Y	124.1	0.00	0.88	86.84	0	1851	581	95	0.00	0.0	2.739	0.148	0	0	0	350
PD.3243-B	PD.3243-A	ABC	Closed	7.45Y	124.1	0.00	0.88	86.84	0	1851	581	95	0.00	0.0	2.739	0.148	0	0	0	350
PL.22821	PD.3243-B	ABC	556 MCM AC	7.45Y	124.1	0.01	0.90	86.84	12	1851	581	95	0.03	0.0	2.784	0.045	0	0	0	350
PL.21785	PL.22821	A	#4 ACSR	7.45Y	124.1	0.01	0.91	5.15	4	37	11	96	0.00	0.0	2.835	0.052	0	0	0	8
PL.22754	PL.21785	A	6 A (CWC)	7.45Y	124.1	0.00	0.91	3.70	3	26	8	96	0.00	0.0	2.840	0.005	0	0	0	7
PD.3210	PL.22754	A	20T	7.45Y	124.1	0.00	0.91	3.70	0	26	8	96	0.00	0.0	2.840	0.005	0	0	0	7
PL.22755	PD.3210	A	6 A (CWC)	7.44Y	124.1	0.02	0.93	3.70	3	26	8	96	0.00	0.0	2.943	0.103	4	1	1	7
PL.22617	PL.22755	A	6 A (CWC)	7.44Y	124.1	0.01	0.93	3.18	2	23	7	96	0.00	0.0	2.991	0.047	8	2	1	6
PL.22616	PL.22617	A	6 A (CWC)	7.44Y	124.1	0.00	0.93	2.09	1	15	4	97	0.00	0.0	3.024	0.033	0	0	0	5
PL.22615	PL.22616	A	6 A (CWC)	7.44Y	124.1	0.01	0.94	2.09	1	15	4	97	0.00	0.0	3.080	0.056	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21791	PL.22615	A	#2 ACSR	7.44Y	124.1	0.00	0.94	2.03	1	14	4	96	0.00	0.0	3.182	0.102	14	4	3	3
PL.22736	PL.22615	A	6 A (CWC)	7.44Y	124.1	0.00	0.94	0.06	0	0	0	100	0.00	0.0	3.177	0.097	0	0	0	2
PL.22737	PL.22736	A	6 A (CWC)	7.44Y	124.1	0.00	0.94	0.06	0	0	0	100	0.00	0.0	3.339	0.162	0	0	2	2
PL.21787	PL.21785	A	#2 ACSR	7.45Y	124.1	0.00	0.91	1.45	1	10	3	96	0.00	0.0	2.844	0.009	10	3	1	1
PL.22500	PL.22821	ABC	556 MCM AC	7.44Y	124.1	0.05	0.94	85.13	12	1814	569	95	0.10	0.0	2.934	0.150	0	0	0	342
PL.22552	PL.22500	ABC	556 MCM AC	7.44Y	124.0	0.02	0.96	85.13	12	1814	567	95	0.04	0.0	2.989	0.055	0	0	0	342
PL.22756	PL.22552	C	#4 ACSR	7.44Y	124.0	0.00	0.96	8.18	6	58	18	96	0.00	0.0	2.994	0.005	0	0	0	11
PD.3211	PL.22756	C	65T	7.44Y	124.0	0.00	0.96	8.18	0	58	18	96	0.00	0.0	2.994	0.005	0	0	0	11
PL.22757	PD.3211	C	#4 ACSR	7.44Y	124.0	0.03	0.99	8.18	6	58	18	96	0.01	0.0	3.081	0.087	0	0	0	11
PL.21786	PL.22757	C	#4 ACSR	7.44Y	124.0	0.02	1.01	2.65	2	19	6	95	0.00	0.0	3.228	0.147	0	0	0	2
PL.22655	PL.21786	C	#4 ACSR	7.44Y	124.0	0.01	1.02	2.65	2	19	6	95	0.00	0.0	3.364	0.137	12	4	1	2
PL.22656	PL.22655	C	#4 ACSR	7.44Y	124.0	0.00	1.02	0.96	1	7	2	96	0.00	0.0	3.436	0.072	0	0	0	1
PL.22553	PL.22656	C	#4 ACSR	7.44Y	124.0	0.00	1.03	0.96	1	7	2	96	0.00	0.0	3.573	0.136	7	2	1	1
PL.22502	PL.22757	C	#4 ACSR	7.44Y	124.0	0.01	1.00	2.15	2	15	5	95	0.00	0.0	3.216	0.136	4	1	1	5
PL.21793	PL.22502	C	#4 ACSR	7.44Y	124.0	0.00	1.00	1.02	1	7	2	96	0.00	0.0	3.241	0.025	0	0	0	3
PL.22622	PL.21793	C	6 A (CWC)	7.44Y	124.0	0.00	1.01	1.02	1	7	2	96	0.00	0.0	3.293	0.052	7	2	1	3
PL.22623	PL.22622	C	6 A (CWC)	7.44Y	124.0	0.00	1.01	0.04	0	0	0	100	0.00	0.0	3.390	0.097	0	0	2	2
PL.21794	PL.22502	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.60	0	4	1	97	0.00	0.0	3.249	0.033	4	1	1	1
PL.22620	PL.22757	C	#4 ACSR	7.44Y	124.0	0.01	1.00	3.39	3	24	7	96	0.00	0.0	3.149	0.069	13	4	1	4
PL.22621	PL.22620	C	#4 ACSR	7.44Y	124.0	0.00	1.00	1.57	1	11	3	96	0.00	0.0	3.183	0.034	0	0	0	3
PL.22503	PL.22621	C	#4 ACSR	7.44Y	124.0	0.00	1.00	0.62	0	4	1	97	0.00	0.0	3.240	0.056	0	0	0	2
PL.22618	PL.22503	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.62	0	4	1	97	0.00	0.0	3.262	0.022	4	1	1	2
PL.22619	PL.22618	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.04	0	0	0	100	0.00	0.0	3.309	0.048	0	0	1	1
PL.21792	PL.22621	C	#2 ACSR	7.44Y	124.0	0.00	1.00	0.95	1	7	2	96	0.00	0.0	3.297	0.113	7	2	1	1
PL.22501	PL.22552	ABC	556 MCM AC	7.44Y	124.0	0.04	1.00	82.40	12	1756	549	95	0.09	0.0	3.130	0.141	0	0	0	331
PL.22554	PL.22501	ABC	556 MCM AC	7.44Y	124.0	0.04	1.04	82.40	12	1756	547	95	0.10	0.0	3.284	0.154	0	0	0	331
PL.22653	PL.22554	ABC	556 MCM AC	7.44Y	123.9	0.03	1.07	82.40	12	1756	545	96	0.06	0.0	3.385	0.101	0	0	0	331
PL.22654	PL.22653	ABC	556 MCM AC	7.43Y	123.9	0.05	1.12	82.40	12	1756	544	96	0.10	0.0	3.545	0.159	0	0	0	331
PL.22555	PL.22654	ABC	556 MCM AC	7.43Y	123.8	0.03	1.15	82.40	12	1756	542	96	0.07	0.0	3.651	0.107	0	0	0	331
PL.22658	PL.22555	ABC	#3/0 ACSR	7.43Y	123.8	0.05	1.20	37.81	13	806	246	96	0.26	0.0	3.759	0.108	9	3	2	137
PL.22660	PL.22658	ABC	#3/0 ACSR	7.43Y	123.8	0.03	1.24	37.38	12	797	243	96	0.16	0.0	3.829	0.070	3	1	1	135

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22661	PL.22660	ABC	#3/0 ACSR	7.42Y	123.7	0.03	1.27	37.23	12	793	242	96	0.16	0.0	3.899	0.069	0	0	1	134
PL.22662	PL.22661	B	6 A (CWC)	7.42Y	123.7	0.00	1.27	0.57	0	4	1	97	0.00	0.0	3.928	0.029	4	1	1	1
PL.22804	PL.22662	B	6 A (CWC)	7.42Y	123.7	0.00	1.27	0.00	0	0	0	100	0.00	0.0	3.933	0.005	0	0	0	0
PD.3235	PL.22804	B	65T	7.42Y	123.7	0.00	1.27	0.00	0	0	0	100	0.00	0.0	3.933	0.005	0	0	0	0
PL.22805	PD.3235	B	6 A (CWC)	7.42Y	123.7	0.00	1.27	0.00	0	0	0	100	0.00	0.0	3.972	0.039	0	0	0	0
PL.22663	PL.22661	ABC	#3/0 ACSR	7.42Y	123.7	0.05	1.32	37.04	12	789	240	96	0.24	0.0	4.004	0.105	0	0	1	132
PL.22675	PL.22663	ABC	#3/0 ACSR	7.42Y	123.6	0.05	1.37	37.04	12	789	240	96	0.22	0.0	4.100	0.096	6	2	1	131
PL.22676	PL.22675	ABC	#3/0 ACSR	7.42Y	123.6	0.02	1.39	36.76	12	783	238	96	0.11	0.0	4.149	0.050	0	0	0	130
PL.22530	PL.22676	ABC	#3/0 ACSR	7.41Y	123.5	0.08	1.47	36.00	12	767	233	96	0.37	0.0	4.320	0.171	0	0	0	125
PL.22673	PL.22530	ABC	#3/0 ACSR	7.41Y	123.5	0.02	1.49	36.00	12	766	232	96	0.11	0.0	4.371	0.051	2	1	1	125
PL.22674	PL.22673	ABC	#3/0 ACSR	7.41Y	123.5	0.04	1.53	35.92	12	764	232	96	0.20	0.0	4.462	0.091	0	0	1	124
PL.22768	PL.22674	ABC	#3/0 ACSR	7.41Y	123.4	0.03	1.57	35.92	12	764	231	96	0.15	0.0	4.531	0.069	0	0	0	123
PL.22769	PL.22768	ABC	#3/0 ACSR	7.41Y	123.4	0.00	1.57	35.92	12	764	231	96	0.01	0.0	4.536	0.004	0	0	0	123
PL.22678	PL.22769	ABC	#3/0 ACSR	7.41Y	123.4	0.00	1.57	35.20	12	749	226	96	0.00	0.0	4.538	0.002	8	2	3	122
PL.22679	PL.22678	ABC	#3/0 ACSR	7.40Y	123.4	0.04	1.61	34.84	12	741	224	96	0.19	0.0	4.632	0.094	6	2	1	119
PL.22672	PL.22679	ABC	#3/0 ACSR	7.40Y	123.3	0.08	1.69	34.54	12	734	222	96	0.37	0.1	4.818	0.186	2	0	1	118
PL.22762	PL.22672	A	#2 ACSR	7.40Y	123.3	0.00	1.69	0.49	0	3	1	95	0.00	0.0	4.823	0.005	0	0	0	1
PD.3214	PL.22762	A	65T	7.40Y	123.3	0.00	1.69	0.49	0	3	1	95	0.00	0.0	4.823	0.005	0	0	0	1
PL.22763	PD.3214	A	#2 ACSR	7.40Y	123.3	0.00	1.69	0.49	0	3	1	95	0.00	0.0	4.869	0.047	3	1	1	1
PL.22588	PL.22672	ABC	#3/0 ACSR	7.40Y	123.3	0.03	1.72	34.30	11	729	220	96	0.12	0.0	4.881	0.063	2	1	2	116
PL.22589	PL.22588	ABC	#3/0 ACSR	7.40Y	123.3	0.01	1.73	31.62	11	672	203	96	0.05	0.0	4.911	0.030	15	5	2	105
PL.22826	PL.22589	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	22.18	16	157	47	96	0.00	0.0	4.913	0.003	0	0	0	25
PD.3247	PL.22826	C	35L	7.40Y	123.3	0.00	1.74	22.18	63	157	47	96	0.00	0.0	4.913	0.003	0	0	0	25
PL.22827	PD.3247	C	6 A (CWC)	7.39Y	123.2	0.05	1.78	22.18	16	157	47	96	0.05	0.0	4.962	0.049	17	5	2	25
PL.22669	PL.22827	C	6 A (CWC)	7.39Y	123.2	0.06	1.84	19.79	14	140	42	96	0.06	0.0	5.029	0.066	5	1	1	23
PL.22668	PL.22669	C	6 A (CWC)	7.39Y	123.1	0.01	1.85	19.08	14	135	41	96	0.01	0.0	5.038	0.010	2	1	1	22
PL.22691	PL.22668	C	6 A (CWC)	7.39Y	123.1	0.01	1.86	18.73	13	133	40	96	0.01	0.0	5.052	0.014	12	4	1	21
PL.22692	PL.22691	C	6 A (CWC)	7.39Y	123.1	0.05	1.91	16.97	12	120	36	96	0.04	0.0	5.110	0.058	1	0	1	20
PL.22641	PL.22692	C	6 A (CWC)	7.38Y	123.0	0.05	1.96	16.86	12	119	36	96	0.05	0.0	5.180	0.070	0	0	0	19
PL.22645	PL.22641	C	6 A (CWC)	7.38Y	123.0	0.04	2.00	10.27	7	73	22	96	0.02	0.0	5.258	0.078	8	2	2	10
PL.22646	PL.22645	C	6 A (CWC)	7.38Y	122.9	0.06	2.05	9.18	7	65	20	96	0.03	0.0	5.392	0.134	0	0	0	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22557	PL.22646	C	6 A (CWC)	7.37Y	122.9	0.05	2.10	9.18	7	65	19	96	0.02	0.0	5.511	0.119	0	0	0	8
PL.22643	PL.22557	C	6 A (CWC)	7.37Y	122.9	0.03	2.13	9.18	7	65	19	96	0.01	0.0	5.577	0.066	11	3	3	8
PL.22644	PL.22643	C	6 A (CWC)	7.37Y	122.9	0.02	2.14	7.64	5	54	16	96	0.01	0.0	5.624	0.047	8	2	1	5
PL.22642	PL.22644	C	6 A (CWC)	7.37Y	122.8	0.04	2.19	6.56	5	46	14	96	0.01	0.0	5.780	0.155	12	4	1	4
PL.22637	PL.22642	C	6 A (CWC)	7.37Y	122.8	0.01	2.20	4.89	3	35	10	96	0.00	0.0	5.826	0.047	0	0	0	3
PL.22465	PL.22637	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.21	1	9	3	95	0.00	0.0	5.871	0.045	9	3	1	1
PL.22592	PL.22637	C	6 A (CWC)	7.37Y	122.8	0.01	2.21	1.73	1	12	4	95	0.00	0.0	5.961	0.134	0	0	0	1
PL.22466	PL.22592	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	1.73	1	12	4	95	0.00	0.0	6.021	0.060	12	4	1	1
PL.22593	PL.22592	C	6 A (CWC)	7.37Y	122.8	0.00	2.21	0.00	0	0	0	100	0.00	0.0	6.062	0.102	0	0	0	0
PL.22464	PL.22637	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.95	2	14	4	96	0.00	0.0	5.913	0.086	14	4	1	1
PL.22462	PL.22641	C	6 A (CWC)	7.38Y	123.0	0.01	1.97	6.59	5	47	14	96	0.00	0.0	5.230	0.050	12	4	3	9
PL.22638	PL.22462	C	#4 ACSR	7.38Y	123.0	0.01	1.98	4.86	4	34	10	96	0.00	0.0	5.274	0.044	3	1	1	6
PL.22639	PL.22638	C	#4 ACSR	7.38Y	123.0	0.01	2.00	4.41	3	31	9	96	0.00	0.0	5.339	0.065	8	3	2	5
PL.22640	PL.22639	C	#4 ACSR	7.38Y	123.0	0.01	2.00	3.23	2	23	7	96	0.00	0.0	5.393	0.054	10	3	1	3
PL.22463	PL.22640	C	#2 ACSR	7.38Y	123.0	0.00	2.00	0.70	0	5	1	98	0.00	0.0	5.433	0.039	5	1	1	1
PL.22587	PL.22640	C	#4 ACSR	7.38Y	123.0	0.00	2.00	1.09	1	8	2	97	0.00	0.0	5.462	0.069	8	2	1	1
PL.22670	PL.22589	ABC	#3/0 ACSR	7.39Y	123.2	0.02	1.76	23.50	8	499	151	96	0.07	0.0	4.988	0.078	5	1	1	78
PL.22671	PL.22670	ABC	#3/0 ACSR	7.39Y	123.2	0.01	1.77	23.28	8	494	149	96	0.03	0.0	5.017	0.029	0	0	0	77
PL.22764	PL.22671	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.40	0	3	1	95	0.00	0.0	5.022	0.005	0	0	0	1
PD.3215	PL.22764	C	65T	7.39Y	123.2	0.00	1.77	0.40	0	3	1	95	0.00	0.0	5.022	0.005	0	0	0	1
PL.22765	PD.3215	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.40	0	3	1	95	0.00	0.0	5.044	0.022	3	1	1	1
PL.21818	PL.22671	ABC	#3/0 ACSR	7.39Y	123.2	0.03	1.79	23.14	8	492	148	96	0.08	0.0	5.107	0.090	31	9	4	76
PL.21819	PL.21818	ABC	#3/0 ACSR	7.39Y	123.2	0.03	1.82	21.70	7	461	139	96	0.07	0.0	5.202	0.094	0	0	0	72
PL.22772	PL.21819	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	3.19	2	23	7	96	0.00	0.0	5.206	0.005	0	0	0	3
PD.3219	PL.22772	C	65T	7.39Y	123.2	0.00	1.82	3.19	0	23	7	96	0.00	0.0	5.206	0.005	0	0	0	3
PL.22773	PD.3219	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	3.19	2	23	7	96	0.00	0.0	5.220	0.014	5	1	1	3
PL.21820	PL.22773	C	6 A (CWC)	7.39Y	123.2	0.00	1.82	2.54	2	18	5	96	0.00	0.0	5.252	0.032	18	5	2	2
PL.22596	PL.21819	ABC	#3/0 ACSR	7.39Y	123.2	0.01	1.83	20.64	7	438	132	96	0.04	0.0	5.256	0.055	9	3	1	69
PL.22597	PL.22596	ABC	#3/0 ACSR	7.39Y	123.2	0.01	1.85	11.15	4	237	71	96	0.02	0.0	5.359	0.103	11	3	1	40
PL.22774	PL.22597	A	#4 ACSR	7.39Y	123.2	0.00	1.85	1.07	1	8	2	97	0.00	0.0	5.364	0.005	0	0	0	4
PD.3220	PL.22774	A	65T	7.39Y	123.2	0.00	1.85	1.07	0	8	2	97	0.00	0.0	5.364	0.005	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22775	PD.3220	A	#4 ACSR	7.39Y	123.2	0.00	1.85	1.07	1	8	2	97	0.00	0.0	5.436	0.072	4	1	3	4
PL.22492	PL.22775	A	#1/0 ACSR	7.39Y	123.2	0.00	1.85	0.45	0	3	1	95	0.00	0.0	5.451	0.015	3	1	1	1
PL.21821	PL.22597	ABC	#3/0 ACSR	7.39Y	123.1	0.01	1.86	10.30	3	219	66	96	0.02	0.0	5.446	0.087	6	2	1	35
PL.21822	PL.21821	ABC	#3/0 ACSR	7.39Y	123.1	0.01	1.87	10.03	3	213	64	96	0.01	0.0	5.526	0.080	20	6	3	34
PL.22784	PL.21822	A	#1/0 ACSR	7.39Y	123.1	0.00	1.87	1.37	1	10	3	96	0.00	0.0	5.531	0.005	0	0	0	1
PD.3225	PL.22784	A	65T	7.39Y	123.1	0.00	1.87	1.37	0	10	3	96	0.00	0.0	5.531	0.005	0	0	0	1
PL.22785	PD.3225	A	#1/0 ACSR	7.39Y	123.1	0.00	1.87	1.37	1	10	3	96	0.00	0.0	5.579	0.049	10	3	1	1
PL.22598	PL.21822	ABC	#3/0 ACSR	7.39Y	123.1	0.01	1.88	8.63	3	183	55	96	0.01	0.0	5.613	0.087	10	3	3	30
PL.22782	PL.22598	C	#1/0 ACSR	7.39Y	123.1	0.00	1.88	1.59	1	11	3	96	0.00	0.0	5.618	0.005	0	0	0	1
PD.3224	PL.22782	C	65T	7.39Y	123.1	0.00	1.88	1.59	0	11	3	96	0.00	0.0	5.618	0.005	0	0	0	1
PL.22783	PD.3224	C	#1/0 ACSR	7.39Y	123.1	0.00	1.88	1.59	1	11	3	96	0.00	0.0	5.657	0.039	11	3	1	1
PL.22599	PL.22598	ABC	#3/0 ACSR	7.39Y	123.1	0.01	1.89	6.82	2	145	43	96	0.01	0.0	5.718	0.105	0	0	0	23
PL.22600	PL.22599	ABC	#3/0 ACSR	7.39Y	123.1	0.01	1.89	5.51	2	117	35	96	0.00	0.0	5.797	0.079	11	3	2	19
PL.22778	PL.22600	B	#2 ACSR	7.39Y	123.1	0.00	1.89	1.54	1	11	3	96	0.00	0.0	5.802	0.005	0	0	0	1
PD.3222	PL.22778	B	65T	7.39Y	123.1	0.00	1.89	1.54	0	11	3	96	0.00	0.0	5.802	0.005	0	0	0	1
PL.22779	PD.3222	B	#2 ACSR	7.39Y	123.1	0.00	1.89	1.54	1	11	3	96	0.00	0.0	5.829	0.027	11	3	1	1
PL.22685	PL.22779	B	#2 ACSR	7.39Y	123.1	0.00	1.89	0.00	0	0	0	100	0.00	0.0	5.874	0.045	0	0	0	0
PL.22686	PL.22600	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.89	4.49	1	95	29	96	0.00	0.0	5.838	0.041	0	0	0	16
PL.22687	PL.22686	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	4.49	1	95	29	96	0.00	0.0	5.901	0.063	11	3	2	16
PL.22776	PL.22687	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	2.08	1	15	4	97	0.00	0.0	5.905	0.005	0	0	0	3
PD.3221	PL.22776	A	65T	7.39Y	123.1	0.00	1.90	2.08	0	15	4	97	0.00	0.0	5.905	0.005	0	0	0	3
PL.22777	PD.3221	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	2.08	1	15	4	97	0.00	0.0	5.919	0.014	15	4	3	3
PL.22822	PL.22687	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	3.26	1	69	21	96	0.00	0.0	5.926	0.025	0	0	0	11
PD.3244-A	PL.22822	ABC	Closed	7.39Y	123.1	0.00	1.90	3.26	0	69	21	96	0.00	0.0	5.926	0.025	0	0	0	11
PD.3244-B	PD.3244-A	ABC	Closed	7.39Y	123.1	0.00	1.90	3.26	0	69	21	96	0.00	0.0	5.926	0.025	0	0	0	11
PL.22823	PD.3244-B	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	3.26	1	69	21	96	0.00	0.0	5.957	0.031	8	2	1	11
PL.22786	PL.22823	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	2.36	2	17	5	96	0.00	0.0	5.962	0.005	0	0	0	3
PD.3226	PL.22786	A	65T	7.39Y	123.1	0.00	1.90	2.36	0	17	5	96	0.00	0.0	5.962	0.005	0	0	0	3
PL.22787	PD.3226	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	2.36	2	17	5	96	0.00	0.0	5.990	0.028	0	0	0	3
PL.22647	PL.22787	A	#4 ACSR	7.39Y	123.1	0.01	1.91	2.23	2	16	5	95	0.00	0.0	6.063	0.073	9	3	1	2
PL.22648	PL.22647	A	#4 ACSR	7.39Y	123.1	0.00	1.91	0.91	1	6	2	95	0.00	0.0	6.141	0.078	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22601	PL.22787	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	0.13	0	1	0	100	0.00	0.0	6.037	0.048	1	0	1	1
PL.22602	PL.22823	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	2.11	1	45	13	96	0.00	0.0	6.085	0.128	0	0	0	7
PL.22649	PL.22602	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	0.24	0	5	2	93	0.00	0.0	6.154	0.069	5	2	1	1
PL.22650	PL.22649	ABC	#3/0 ACSR	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	6.188	0.034	0	0	0	0
PD.3618-A	PL.22650	ABC	Open	7.39Y	123.1	0.00	1.90	0.00	0	0	0	100	0.00	0.0	6.188	0.034	0	0	0	0
PL.22760	PL.22602	C	#4 ACSR	7.39Y	123.1	0.00	1.90	5.60	4	40	12	96	0.00	0.0	6.089	0.005	0	0	0	6
PD.3213	PL.22760	C	65T	7.39Y	123.1	0.00	1.90	5.60	0	40	12	96	0.00	0.0	6.089	0.005	0	0	0	6
PL.22761	PD.3213	C	#4 ACSR	7.39Y	123.1	0.01	1.91	5.60	4	40	12	96	0.00	0.0	6.137	0.048	14	4	2	6
PL.22651	PL.22761	C	#4 ACSR	7.38Y	123.1	0.01	1.92	3.56	3	25	8	95	0.00	0.0	6.181	0.044	10	3	2	4
PL.22652	PL.22651	C	#4 ACSR	7.38Y	123.1	0.00	1.92	2.18	2	15	5	95	0.00	0.0	6.276	0.095	15	5	2	2
PL.22780	PL.22599	B	#2 ACSR	7.39Y	123.1	0.00	1.89	1.47	1	10	3	96	0.00	0.0	5.723	0.005	0	0	0	3
PD.3223	PL.22780	B	65T	7.39Y	123.1	0.00	1.89	1.47	0	10	3	96	0.00	0.0	5.723	0.005	0	0	0	3
PL.22781	PD.3223	B	#2 ACSR	7.39Y	123.1	0.00	1.89	1.47	1	10	3	96	0.00	0.0	5.729	0.007	10	3	3	3
PL.22810	PL.22599	C	#4 ACSR	7.39Y	123.1	0.00	1.89	2.45	2	17	5	96	0.00	0.0	5.723	0.005	0	0	0	1
PD.3238	PL.22810	C	65T	7.39Y	123.1	0.00	1.89	2.45	0	17	5	96	0.00	0.0	5.723	0.005	0	0	0	1
PL.22811	PD.3238	C	#4 ACSR	7.39Y	123.1	0.00	1.89	2.45	2	17	5	96	0.00	0.0	5.764	0.041	17	5	1	1
PL.22808	PL.22598	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	2.40	2	17	5	96	0.00	0.0	5.618	0.005	0	0	0	3
PD.3237	PL.22808	A	65T	7.39Y	123.1	0.00	1.88	2.40	0	17	5	96	0.00	0.0	5.618	0.005	0	0	0	3
PL.22809	PD.3237	A	6 A (CWC)	7.39Y	123.1	0.01	1.88	2.40	2	17	5	96	0.00	0.0	5.671	0.053	0	0	1	3
PL.22688	PL.22809	A	6 A (CWC)	7.39Y	123.1	0.01	1.89	2.35	2	17	5	96	0.00	0.0	5.720	0.049	0	0	0	2
PL.22689	PL.22688	A	6 A (CWC)	7.39Y	123.1	0.01	1.90	2.35	2	17	5	96	0.00	0.0	5.791	0.070	0	0	0	2
PL.22690	PL.22689	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	2.35	2	17	5	96	0.00	0.0	5.806	0.015	17	5	2	2
PL.22478	PL.22596	A	6 A (CWC)	7.38Y	123.1	0.10	1.93	27.22	19	193	58	96	0.14	0.1	5.334	0.077	0	0	0	28
PL.22485	PL.22478	A	6 A (CWC)	7.38Y	123.1	0.02	1.94	27.22	19	192	58	96	0.02	0.0	5.346	0.012	4	1	1	28
PL.22828	PL.22485	A	6 A (CWC)	7.38Y	123.1	0.00	1.95	26.65	19	188	57	96	0.00	0.0	5.349	0.003	0	0	0	27
PD.3248	PL.22828	A	50L	7.38Y	123.1	0.00	1.95	26.65	53	188	57	96	0.00	0.0	5.349	0.003	0	0	0	27
PL.22829	PD.3248	A	6 A (CWC)	7.38Y	123.0	0.07	2.02	26.65	19	188	57	96	0.09	0.0	5.411	0.062	38	12	4	27
PL.22595	PL.22829	A	6 A (CWC)	7.38Y	122.9	0.05	2.06	21.07	15	149	45	96	0.05	0.0	5.458	0.047	3	1	1	22
PL.22683	PL.22595	A	#2 ACSR	7.38Y	122.9	0.00	2.07	1.59	1	11	3	96	0.00	0.0	5.542	0.083	0	0	0	1
PL.22684	PL.22683	A	#2 ACSR	7.38Y	122.9	0.00	2.07	1.59	1	11	3	96	0.00	0.0	5.713	0.172	11	3	1	1
PL.21823	PL.22595	A	6 A (CWC)	7.37Y	122.9	0.07	2.13	19.11	14	135	41	96	0.07	0.1	5.538	0.080	9	3	2	20

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22682	PL.21823	A	6 A (CWC)	7.37Y	122.8	0.07	2.20	17.87	13	126	38	96	0.07	0.1	5.629	0.091	0	0	0	18
PL.22680	PL.22682	A	#1/0 ACSR	7.37Y	122.8	0.00	2.21	1.58	1	11	3	96	0.00	0.0	5.663	0.034	10	3	1	2
PL.22681	PL.22680	A	#1/0 ACSR	7.37Y	122.8	0.00	2.21	0.17	0	1	0	100	0.00	0.0	5.803	0.140	1	0	1	1
PL.22594	PL.22682	A	6 A (CWC)	7.36Y	122.7	0.06	2.27	16.29	12	115	35	96	0.05	0.0	5.711	0.082	0	0	0	16
PL.21798	PL.22594	A	6 A (CWC)	7.36Y	122.7	0.04	2.30	14.89	11	105	32	96	0.03	0.0	5.769	0.058	11	3	1	14
PL.21799	PL.21798	A	6 A (CWC)	7.36Y	122.7	0.04	2.34	13.33	10	94	28	96	0.03	0.0	5.830	0.061	0	0	0	13
PL.22814	PL.21799	A	#1/0 ACSR	7.36Y	122.7	0.00	2.34	0.43	0	3	1	95	0.00	0.0	5.835	0.004	0	0	0	2
PD.3240	PL.22814	A	15T	7.36Y	122.7	0.00	2.34	0.43	0	3	1	95	0.00	0.0	5.835	0.004	0	0	0	2
PL.22815	PD.3240	A	#1/0 ACSR	7.36Y	122.7	0.00	2.34	0.43	0	3	1	95	0.00	0.0	5.975	0.140	3	1	2	2
PL.21800	PL.21799	A	6 A (CWC)	7.36Y	122.6	0.02	2.36	12.90	9	91	27	96	0.01	0.0	5.864	0.034	7	2	1	11
PL.21801	PL.21800	A	6 A (CWC)	7.36Y	122.6	0.02	2.38	11.90	8	84	25	96	0.01	0.0	5.892	0.028	0	0	1	10
PL.21802	PL.21801	A	6 A (CWC)	7.36Y	122.6	0.03	2.41	11.89	8	84	25	96	0.02	0.0	5.950	0.057	4	1	1	9
PL.21814	PL.21802	A	#4 ACSR	7.35Y	122.6	0.01	2.42	9.84	8	69	21	96	0.01	0.0	5.983	0.034	7	2	1	7
PL.21815	PL.21814	A	#4 ACSR	7.35Y	122.6	0.00	2.42	8.89	7	63	19	96	0.00	0.0	5.992	0.009	0	0	0	6
PL.22488	PL.21815	A	#4 ACSR	7.35Y	122.6	0.01	2.44	4.13	3	29	9	96	0.00	0.0	6.054	0.062	0	0	0	2
PL.21812	PL.22488	A	#4 ACSR	7.35Y	122.6	0.01	2.44	2.53	2	18	5	96	0.00	0.0	6.114	0.060	0	0	0	1
PL.21813	PL.21812	A	#4 ACSR	7.35Y	122.6	0.01	2.45	2.53	2	18	5	96	0.00	0.0	6.208	0.094	18	5	1	1
PL.22489	PL.22488	A	#1/0 ACSR	7.35Y	122.6	0.00	2.44	1.60	1	11	3	96	0.00	0.0	6.080	0.026	11	3	1	1
PL.22590	PL.21815	A	#4 ACSR	7.35Y	122.6	0.02	2.45	4.76	4	34	10	96	0.00	0.0	6.139	0.147	17	5	2	4
PL.22490	PL.22590	A	#4 ACSR	7.35Y	122.5	0.01	2.46	2.28	2	16	5	95	0.00	0.0	6.233	0.094	0	0	0	2
PL.22491	PL.22490	A	#4 ACSR	7.35Y	122.5	0.00	2.46	2.28	2	16	5	95	0.00	0.0	6.303	0.070	16	5	2	2
PL.22591	PL.22590	A	#4 ACSR	7.35Y	122.6	0.00	2.45	0.00	0	0	0	100	0.00	0.0	6.245	0.105	0	0	0	0
PL.22558	PL.22591	A	#4 ACSR	7.35Y	122.6	0.00	2.45	0.00	0	0	0	100	0.00	0.0	6.336	0.092	0	0	0	0
PL.22487	PL.21802	A	6 A (CWC)	7.36Y	122.6	0.00	2.41	1.47	1	10	3	96	0.00	0.0	6.057	0.108	10	3	1	1
PL.22486	PL.22594	A	#4 ACSR	7.36Y	122.7	0.00	2.27	1.39	1	10	3	96	0.00	0.0	5.779	0.069	10	3	2	2
PL.22479	PL.22829	A	#4 ACSR	7.38Y	123.0	0.00	2.02	0.15	0	1	0	100	0.00	0.0	5.446	0.035	1	0	1	1
PL.22824	PL.22588	A	6 A (CWC)	7.40Y	123.3	0.00	1.72	7.74	6	55	16	96	0.00	0.0	4.884	0.003	0	0	0	9
PD.3246	PL.22824	A	35L	7.40Y	123.3	0.00	1.72	7.74	22	55	16	96	0.00	0.0	4.884	0.003	0	0	0	9
PL.22825	PD.3246	A	6 A (CWC)	7.40Y	123.3	0.01	1.73	7.74	6	55	16	96	0.00	0.0	4.910	0.026	0	0	0	9
PL.22380	PL.22825	A	6 A (CWC)	7.40Y	123.3	0.00	1.73	1.77	1	13	4	96	0.00	0.0	4.978	0.068	13	4	2	2
PL.22531	PL.22825	A	6 A (CWC)	7.39Y	123.2	0.02	1.76	5.97	4	42	13	96	0.01	0.0	4.999	0.090	0	0	0	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22532	PL.22531	A	6 A (CWC)	7.39Y	123.2	0.02	1.78	4.28	3	30	9	96	0.00	0.0	5.107	0.108	0	0	0	5
PL.22382	PL.22532	A	6 A (CWC)	7.39Y	123.2	0.00	1.78	1.76	1	12	4	95	0.00	0.0	5.132	0.025	12	4	1	1
PL.22664	PL.22532	A	6 A (CWC)	7.39Y	123.2	0.00	1.78	2.52	2	18	5	96	0.00	0.0	5.143	0.036	3	1	1	4
PL.22665	PL.22664	A	6 A (CWC)	7.39Y	123.2	0.01	1.79	2.06	1	15	4	97	0.00	0.0	5.267	0.124	11	3	2	3
PL.22666	PL.22665	A	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.50	0	4	1	97	0.00	0.0	5.440	0.173	4	1	1	1
PL.22667	PL.22666	A	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.00	0	0	0	100	0.00	0.0	5.545	0.105	0	0	0	0
PL.22381	PL.22531	A	6 A (CWC)	7.39Y	123.2	0.00	1.76	1.69	1	12	4	95	0.00	0.0	5.037	0.038	12	4	2	2
PL.22766	PL.22769	A	#2 ACSR	7.41Y	123.4	0.00	1.57	2.17	1	15	5	95	0.00	0.0	4.540	0.005	0	0	0	1
PD.3216	PL.22766	A	65T	7.41Y	123.4	0.00	1.57	2.17	0	15	5	95	0.00	0.0	4.540	0.005	0	0	0	1
PL.22767	PD.3216	A	#2 ACSR	7.41Y	123.4	0.00	1.57	2.17	1	15	5	95	0.00	0.0	4.561	0.020	15	5	1	1
PL.22812	PL.22676	C	6 A (CWC)	7.42Y	123.6	0.00	1.39	2.27	2	16	5	95	0.00	0.0	4.154	0.005	0	0	0	5
PD.3239	PL.22812	C	65T	7.42Y	123.6	0.00	1.39	2.27	0	16	5	95	0.00	0.0	4.154	0.005	0	0	0	5
PL.22813	PD.3239	C	6 A (CWC)	7.42Y	123.6	0.00	1.39	2.27	2	16	5	95	0.00	0.0	4.174	0.020	1	0	1	5
PL.22677	PL.22813	C	6 A (CWC)	7.42Y	123.6	0.01	1.40	2.07	1	15	4	97	0.00	0.0	4.296	0.122	4	1	1	4
PL.21810	PL.22677	C	6 A (CWC)	7.42Y	123.6	0.00	1.40	1.57	1	11	3	96	0.00	0.0	4.361	0.064	10	3	1	3
PL.21811	PL.21810	C	6 A (CWC)	7.42Y	123.6	0.00	1.40	0.16	0	1	0	100	0.00	0.0	4.424	0.063	1	0	2	2
PL.22657	PL.22555	ABC	#2 ACSR	7.43Y	123.8	0.03	1.18	44.59	25	949	295	95	0.19	0.0	3.675	0.024	0	0	0	194
PL.22834	PL.22657	ABC	#2 ACSR	7.42Y	123.7	0.08	1.25	44.59	25	949	295	95	0.55	0.1	3.742	0.067	0	0	0	194
PD.3251	PL.22834	ABC	70L	7.42Y	123.7	0.00	1.25	44.59	64	949	294	96	0.00	0.0	3.742	0.067	0	0	0	194
PL.22835	PD.3251	ABC	#2 ACSR	7.42Y	123.7	0.03	1.28	44.59	25	949	294	96	0.22	0.0	3.769	0.027	11	3	2	194
PL.22659	PL.22835	ABC	#2 ACSR	7.41Y	123.5	0.17	1.45	44.07	25	937	291	96	1.19	0.1	3.919	0.149	0	0	0	192
PL.22560	PL.22659	ABC	#2 ACSR	7.40Y	123.4	0.17	1.63	44.07	25	936	290	96	1.23	0.1	4.073	0.154	0	0	0	192
PL.21805	PL.22560	ABC	#2 ACSR	7.40Y	123.3	0.04	1.67	40.62	23	862	267	96	0.26	0.0	4.113	0.039	16	5	2	182
PL.21806	PL.21805	ABC	#2 ACSR	7.39Y	123.2	0.12	1.79	39.86	23	845	262	96	0.80	0.1	4.235	0.123	0	0	0	180
PL.21803	PL.21806	ABC	#2 ACSR	7.39Y	123.1	0.08	1.87	39.86	23	844	262	96	0.50	0.1	4.312	0.077	6	2	1	180
PL.21804	PL.21803	ABC	#2 ACSR	7.39Y	123.1	0.04	1.91	39.59	23	838	260	96	0.26	0.0	4.352	0.040	3	1	2	179
PL.21809	PL.21804	ABC	#1/0 ACSR	7.38Y	123.0	0.06	1.97	39.47	17	835	259	96	0.35	0.0	4.436	0.084	8	2	1	177
PL.22836	PL.21809	ABC	#1/0 ACSR	7.38Y	122.9	0.08	2.05	39.10	17	827	256	96	0.47	0.1	4.552	0.116	0	0	0	176
PL.22837	PL.22836	ABC	#1/0 ACSR	7.37Y	122.9	0.07	2.12	39.10	17	827	256	96	0.38	0.0	4.646	0.093	0	0	0	176
PL.22506	PL.22837	ABC	#1/0 ACSR	7.37Y	122.8	0.12	2.24	39.09	17	826	256	96	0.69	0.1	4.815	0.170	0	0	0	175
PL.22561	PL.22506	ABC	#1/0 ACSR	7.36Y	122.6	0.13	2.37	39.09	17	825	255	96	0.72	0.1	4.992	0.177	0	0	0	175

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22562	PL.22561	ABC	#1/0 ACSR	7.35Y	122.5	0.09	2.46	39.09	17	825	254	96	0.51	0.1	5.118	0.126	0	0	0	175
PL.22563	PL.22562	ABC	#1/0 ACSR	7.35Y	122.4	0.10	2.55	39.09	17	824	254	96	0.54	0.1	5.251	0.133	0	0	0	175
PL.22507	PL.22563	ABC	#1/0 ACSR	7.34Y	122.4	0.05	2.60	18.72	8	395	120	96	0.14	0.0	5.397	0.146	0	0	0	81
PL.22579	PL.22507	ABC	#1/0 ACSR	7.34Y	122.4	0.03	2.63	18.57	8	391	119	96	0.07	0.0	5.472	0.075	2	1	1	80
PL.22707	PL.22579	ABC	#1/0 ACSR	7.34Y	122.4	0.01	2.64	15.29	7	322	98	96	0.03	0.0	5.514	0.042	2	1	1	68
PL.22728	PL.22707	ABC	#1/0 ACSR	7.34Y	122.3	0.04	2.68	15.18	7	320	97	96	0.08	0.0	5.653	0.139	7	2	1	67
PL.22729	PL.22728	ABC	#1/0 ACSR	7.34Y	122.3	0.02	2.70	14.86	6	313	95	96	0.05	0.0	5.739	0.086	8	2	1	66
PL.22730	PL.22729	ABC	#1/0 ACSR	7.34Y	122.3	0.02	2.72	14.48	6	305	92	96	0.05	0.0	5.830	0.092	0	0	0	65
PL.22582	PL.22730	ABC	#1/0 ACSR	7.34Y	122.3	0.02	2.74	13.77	6	290	88	96	0.03	0.0	5.894	0.064	14	4	3	61
PL.22796	PL.22582	A	6 A (CWC)	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	5.899	0.005	0	0	0	0
PD.3231	PL.22796	A	30T	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	5.899	0.005	0	0	0	0
PL.22797	PD.3231	A	6 A (CWC)	7.34Y	122.3	0.00	2.74	0.00	0	0	0	100	0.00	0.0	5.941	0.043	0	0	0	0
PL.22733	PL.22582	ABC	#1/0 ACSR	7.34Y	122.3	0.01	2.75	13.09	6	276	83	96	0.02	0.0	5.930	0.036	1	0	1	58
PL.22734	PL.22733	ABC	#1/0 ACSR	7.33Y	122.2	0.03	2.78	13.05	6	275	83	96	0.05	0.0	6.045	0.114	0	0	0	57
PL.22517	PL.22734	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.79	12.09	5	255	77	96	0.03	0.0	6.111	0.067	0	0	0	53
PL.22519	PL.22517	ABC	#1/0 ACSR	7.33Y	122.2	0.03	2.82	12.08	5	254	77	96	0.06	0.0	6.258	0.146	0	0	0	52
PL.22580	PL.22519	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.84	12.08	5	254	77	96	0.03	0.0	6.322	0.065	0	0	1	52
PL.22830	PL.22580	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.95	1	7	2	96	0.00	0.0	6.382	0.060	0	0	0	3
PD.3249	PL.22830	A	35L	7.33Y	122.2	0.00	2.84	0.95	3	7	2	96	0.00	0.0	6.382	0.060	0	0	0	3
PL.22831	PD.3249	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.95	1	7	2	96	0.00	0.0	6.451	0.069	5	1	2	3
PL.22735	PL.22831	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.26	0	2	1	89	0.00	0.0	6.639	0.189	0	0	0	1
PL.21997	PL.22735	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	0.26	0	2	1	89	0.00	0.0	6.722	0.083	0	0	0	1
PL.21998	PL.21997	A	6 A (CWC)	7.33Y	122.2	0.00	2.85	0.26	0	2	1	89	0.00	0.0	6.830	0.108	0	0	0	1
PL.22400	PL.21998	A	6 A (CWC)	7.33Y	122.2	0.00	2.85	0.00	0	0	0	100	0.00	0.0	6.925	0.095	0	0	0	0
PL.22401	PL.21998	A	6 A (CWC)	7.33Y	122.2	0.00	2.85	0.26	0	2	1	89	0.00	0.0	7.002	0.172	0	0	0	1
PL.22534	PL.22401	A	6 A (CWC)	7.33Y	122.2	0.00	2.85	0.26	0	2	1	89	0.00	0.0	7.092	0.090	0	0	0	1
PL.22402	PL.22534	A	#4 ACSR	7.33Y	122.1	0.00	2.85	0.26	0	2	1	89	0.00	0.0	7.200	0.108	0	0	0	1
PL.22403	PL.22402	A	#4 ACSR	7.33Y	122.1	0.00	2.85	0.26	0	2	1	89	0.00	0.0	7.277	0.077	2	1	1	1
PL.22581	PL.22580	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.84	11.74	5	247	75	96	0.01	0.0	6.349	0.027	0	0	0	48
PL.22832	PL.22581	C	8 A (CWC)	7.33Y	122.2	0.01	2.85	35.21	35	247	75	96	0.01	0.0	6.352	0.003	0	0	0	48
PD.3250	PL.22832	C	50L	7.33Y	122.2	0.00	2.85	35.21	70	247	75	96	0.00	0.0	6.352	0.003	0	0	0	48

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22833	PD.3250	C	8 A (CWC)	7.32Y	122.0	0.17	3.02	35.21	35	247	75	96	0.33	0.1	6.423	0.072	5	2	2	48
PL.22721	PL.22833	C	8 A (CWC)	7.31Y	121.8	0.18	3.20	34.44	34	241	73	96	0.35	0.1	6.503	0.080	0	0	0	46
PL.22398	PL.22721	C	#4 ACSR	7.31Y	121.8	0.00	3.20	0.61	0	4	1	97	0.00	0.0	6.571	0.067	4	1	1	1
PL.22399	PL.22398	C	#1/0 ACSR	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	6.591	0.020	0	0	0	0
PL.22718	PL.22721	C	6 A (CWC)	7.30Y	121.7	0.13	3.33	33.83	24	237	72	96	0.23	0.1	6.588	0.084	10	3	1	45
PL.22719	PL.22718	C	6 A (CWC)	7.29Y	121.6	0.09	3.42	32.37	23	226	68	96	0.15	0.1	6.648	0.061	7	2	1	44
PL.22720	PL.22719	C	6 A (CWC)	7.29Y	121.5	0.09	3.51	31.37	22	219	66	96	0.15	0.1	6.711	0.063	0	0	0	43
PL.22404	PL.22720	C	#4 ACSR	7.29Y	121.5	0.00	3.51	1.31	1	9	3	95	0.00	0.0	6.782	0.071	9	3	1	1
PL.22576	PL.22720	C	6 A (CWC)	7.28Y	121.4	0.11	3.62	30.06	21	210	63	96	0.17	0.1	6.794	0.083	10	3	1	42
PL.22405	PL.22576	C	6 A (CWC)	7.28Y	121.4	0.01	3.63	1.82	1	13	4	96	0.00	0.0	6.864	0.070	0	0	0	2
PL.22406	PL.22405	C	6 A (CWC)	7.28Y	121.4	0.00	3.63	1.82	1	13	4	96	0.00	0.0	6.902	0.039	0	0	0	2
PL.22520	PL.22406	C	6 A (CWC)	7.28Y	121.4	0.00	3.63	0.59	0	4	1	97	0.00	0.0	6.917	0.015	4	1	1	1
PL.22407	PL.22406	C	6 A (CWC)	7.28Y	121.4	0.00	3.63	1.23	1	9	3	95	0.00	0.0	7.003	0.101	9	3	1	1
PL.22716	PL.22576	C	6 A (CWC)	7.28Y	121.3	0.03	3.65	26.75	19	187	56	96	0.04	0.0	6.819	0.025	7	2	1	39
PL.22717	PL.22716	C	6 A (CWC)	7.28Y	121.3	0.07	3.72	25.74	18	179	54	96	0.10	0.1	6.883	0.064	15	5	2	38
PL.22712	PL.22717	C	6 A (CWC)	7.27Y	121.2	0.09	3.81	23.59	17	164	50	96	0.11	0.1	6.964	0.082	2	1	1	36
PL.22713	PL.22712	C	6 A (CWC)	7.26Y	121.1	0.13	3.94	23.32	17	162	49	96	0.15	0.1	7.084	0.119	6	2	1	35
PL.22714	PL.22713	C	6 A (CWC)	7.26Y	121.0	0.05	3.99	22.46	16	156	47	96	0.06	0.0	7.138	0.054	12	3	1	34
PL.22715	PL.22714	C	6 A (CWC)	7.26Y	121.0	0.04	4.03	20.80	15	145	44	96	0.05	0.0	7.183	0.045	0	0	0	33
PL.22412	PL.22715	C	6 A (CWC)	7.26Y	120.9	0.02	4.05	4.09	3	28	9	95	0.00	0.0	7.269	0.086	0	0	0	8
PL.22011	PL.22412	C	6 A (CWC)	7.26Y	120.9	0.02	4.07	4.09	3	28	9	95	0.00	0.0	7.379	0.110	0	0	0	8
PL.22724	PL.22011	C	6 A (CWC)	7.25Y	120.9	0.02	4.09	4.09	3	28	9	95	0.00	0.0	7.469	0.090	2	1	1	8
PL.22725	PL.22724	C	6 A (CWC)	7.25Y	120.9	0.03	4.12	3.79	3	26	8	96	0.01	0.0	7.639	0.170	0	0	0	7
PL.22521	PL.22725	C	6 A (CWC)	7.25Y	120.9	0.01	4.13	3.20	2	22	7	95	0.00	0.0	7.705	0.066	0	0	0	6
PL.22522	PL.22521	C	6 A (CWC)	7.25Y	120.9	0.01	4.14	3.19	2	22	7	95	0.00	0.0	7.802	0.097	0	0	0	5
PL.22012	PL.22522	C	6 A (CWC)	7.25Y	120.8	0.01	4.16	3.19	2	22	7	95	0.00	0.0	7.904	0.102	0	0	0	5
PL.21999	PL.22012	C	6 A (CWC)	7.25Y	120.8	0.01	4.17	3.19	2	22	7	95	0.00	0.0	7.992	0.089	0	0	0	5
PL.22423	PL.21999	C	6 A (CWC)	7.25Y	120.8	0.01	4.18	1.51	1	11	3	96	0.00	0.0	8.113	0.120	0	0	0	4
PL.22000	PL.22423	C	6 A (CWC)	7.25Y	120.8	0.01	4.18	1.51	1	11	3	96	0.00	0.0	8.217	0.105	0	0	0	4
PL.22524	PL.22000	C	6 A (CWC)	7.25Y	120.8	0.00	4.18	0.00	0	0	0	100	0.00	0.0	8.275	0.058	0	0	0	1
PL.22726	PL.22524	C	#1/0 ACSR	7.25Y	120.8	0.00	4.18	0.00	0	0	0	100	0.00	0.0	8.389	0.114	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22727	PL.22726	C	#1/0 ACSR	7.25Y	120.8	0.00	4.18	0.00	0	0	0	100	0.00	0.0	8.485	0.095	0	0	1	1
PL.22424	PL.22000	C	#4 ACSR	7.25Y	120.8	0.00	4.19	1.51	1	11	3	96	0.00	0.0	8.277	0.059	0	0	0	3
PL.22722	PL.22424	C	#4 ACSR	7.25Y	120.8	0.00	4.19	0.38	0	3	1	95	0.00	0.0	8.327	0.050	0	0	1	2
PL.22723	PL.22722	C	#4 ACSR	7.25Y	120.8	0.00	4.19	0.38	0	3	1	95	0.00	0.0	8.394	0.068	3	1	1	1
PL.22525	PL.22424	C	#4 ACSR	7.25Y	120.8	0.00	4.19	1.14	1	8	2	97	0.00	0.0	8.303	0.027	8	2	1	1
PL.22523	PL.21999	C	6 A (CWC)	7.25Y	120.8	0.01	4.17	1.68	1	12	3	97	0.00	0.0	8.064	0.071	0	0	0	1
PL.22425	PL.22523	C	6 A (CWC)	7.25Y	120.8	0.01	4.18	1.68	1	12	3	97	0.00	0.0	8.225	0.161	12	3	1	1
PL.22422	PL.22521	C	6 A (CWC)	7.25Y	120.9	0.00	4.13	0.01	0	0	0	100	0.00	0.0	7.764	0.060	0	0	1	1
PL.22421	PL.22725	C	#1/0 ACSR	7.25Y	120.9	0.00	4.12	0.59	0	4	1	97	0.00	0.0	7.768	0.129	4	1	1	1
PL.22792	PL.22715	C	#4 ACSR	7.26Y	121.0	0.00	4.04	16.36	13	114	34	96	0.00	0.0	7.187	0.004	0	0	0	24
PD.3229	PL.22792	C	20T	7.26Y	121.0	0.00	4.04	16.36	0	114	34	96	0.00	0.0	7.187	0.004	0	0	0	24
PL.22793	PD.3229	C	#4 ACSR	7.26Y	120.9	0.02	4.06	16.36	13	114	34	96	0.02	0.0	7.219	0.032	0	0	0	24
PL.22408	PL.22793	C	6 A (CWC)	7.26Y	120.9	0.00	4.06	0.00	0	0	0	100	0.00	0.0	7.318	0.099	0	0	0	0
PL.22526	PL.22793	C	#4 ACSR	7.25Y	120.9	0.05	4.12	16.36	13	114	34	96	0.05	0.0	7.293	0.074	0	0	0	24
PL.22410	PL.22526	C	6 A (CWC)	7.25Y	120.9	0.00	4.12	0.45	0	3	1	95	0.00	0.0	7.396	0.103	3	1	2	2
PL.22409	PL.22526	C	#1/0 ACSR	7.25Y	120.9	0.00	4.12	1.60	1	11	3	96	0.00	0.0	7.362	0.069	11	3	1	1
PL.22527	PL.22526	C	#4 ACSR	7.25Y	120.8	0.08	4.20	14.31	11	99	30	96	0.06	0.1	7.417	0.124	0	0	0	21
PL.22010	PL.22527	C	#4 ACSR	7.25Y	120.8	0.05	4.24	14.31	11	99	30	96	0.04	0.0	7.491	0.074	0	0	0	21
PL.22001	PL.22010	C	#4 ACSR	7.24Y	120.7	0.10	4.34	14.31	11	99	30	96	0.07	0.1	7.641	0.150	0	0	0	21
PL.22528	PL.22001	C	#4 ACSR	7.23Y	120.6	0.08	4.42	11.59	9	80	24	96	0.05	0.1	7.793	0.151	0	0	0	19
PL.22567	PL.22528	C	#4 ACSR	7.23Y	120.5	0.03	4.45	8.82	7	61	18	96	0.01	0.0	7.886	0.094	11	3	1	16
PL.22568	PL.22567	C	#4 ACSR	7.23Y	120.5	0.04	4.49	7.19	6	50	15	96	0.01	0.0	8.007	0.121	4	1	2	15
PL.22708	PL.22568	C	#4 ACSR	7.23Y	120.5	0.02	4.51	6.08	5	42	13	96	0.00	0.0	8.079	0.071	11	3	2	12
PL.22709	PL.22708	C	#4 ACSR	7.23Y	120.5	0.01	4.52	4.48	3	31	9	96	0.00	0.0	8.152	0.074	8	2	2	10
PL.22018	PL.22709	C	#4 ACSR	7.23Y	120.5	0.01	4.53	1.41	1	10	3	96	0.00	0.0	8.285	0.133	0	0	0	6
PL.22002	PL.22018	C	#4 ACSR	7.23Y	120.5	0.01	4.54	1.41	1	10	3	96	0.00	0.0	8.461	0.176	0	0	0	6
PL.22003	PL.22002	C	#4 ACSR	7.23Y	120.5	0.01	4.54	1.41	1	10	3	96	0.00	0.0	8.567	0.106	0	0	0	6
PL.22529	PL.22003	C	#4 ACSR	7.23Y	120.5	0.00	4.55	1.41	1	10	3	96	0.00	0.0	8.628	0.060	0	0	0	6
PL.22701	PL.22529	C	6 A (CWC)	7.23Y	120.4	0.01	4.55	1.26	1	9	3	95	0.00	0.0	8.754	0.127	2	1	2	3
PL.22702	PL.22701	C	6 A (CWC)	7.23Y	120.4	0.00	4.56	0.96	1	7	2	96	0.00	0.0	8.838	0.084	0	0	0	1
PL.22419	PL.22702	C	#4 ACSR	7.23Y	120.4	0.00	4.56	0.96	1	7	2	96	0.00	0.0	8.988	0.150	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22699	PL.22529	C	6 A (CWC)	7.23Y	120.5	0.00	4.55	0.15	0	1	0	100	0.00	0.0	8.671	0.043	0	0	0	3
PL.22700	PL.22699	C	6 A (CWC)	7.23Y	120.4	0.00	4.55	0.15	0	1	0	100	0.00	0.0	8.926	0.256	0	0	0	3
PL.22004	PL.22700	C	6 A (CWC)	7.23Y	120.4	0.00	4.55	0.15	0	1	0	100	0.00	0.0	9.097	0.170	0	0	0	3
PL.22005	PL.22004	C	6 A (CWC)	7.23Y	120.4	0.00	4.55	0.15	0	1	0	100	0.00	0.0	9.178	0.081	1	0	1	3
PL.22695	PL.22005	C	#4 ACSR	7.23Y	120.4	0.00	4.55	0.02	0	0	0	100	0.00	0.0	9.343	0.165	0	0	1	2
PL.22696	PL.22695	C	#4 ACSR	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	9.442	0.100	0	0	1	1
PL.22417	PL.22709	C	#4 ACSR	7.23Y	120.5	0.00	4.52	1.90	1	13	4	96	0.00	0.0	8.163	0.011	13	4	2	2
PL.22416	PL.22568	C	#4 ACSR	7.23Y	120.5	0.00	4.49	0.57	0	4	1	97	0.00	0.0	8.083	0.075	4	1	1	1
PL.66181	PL.22568	C	#1/0 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	8.031	0.023	0	0	0	0
PL.66182	PL.66181	C	#1/0 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	8.074	0.043	0	0	0	0
PL.66183	PL.66182	C	#1/0 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	8.093	0.019	0	0	0	0
PL.66184	PL.66183	C	#1/0 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	8.162	0.069	0	0	0	0
PL.22415	PL.22567	C	#4 ACSR	7.23Y	120.5	0.00	4.45	0.00	0	0	0	100	0.00	0.0	7.959	0.072	0	0	0	0
PL.22414	PL.22528	C	6 A (CWC)	7.23Y	120.6	0.01	4.43	2.77	2	19	6	95	0.00	0.0	7.869	0.076	0	0	0	3
PL.22710	PL.22414	C	6 A (CWC)	7.23Y	120.6	0.01	4.43	1.51	1	10	3	96	0.00	0.0	7.982	0.113	3	1	1	2
PL.22711	PL.22710	C	6 A (CWC)	7.23Y	120.6	0.00	4.44	1.08	1	7	2	96	0.00	0.0	8.170	0.189	7	2	1	1
PL.22420	PL.22414	C	#4 ACSR	7.23Y	120.6	0.00	4.43	1.26	1	9	3	95	0.00	0.0	7.908	0.039	9	3	1	1
PL.22413	PL.22001	C	6 A (CWC)	7.24Y	120.7	0.00	4.34	2.73	2	19	6	95	0.00	0.0	7.708	0.067	19	6	2	2
PL.22411	PL.22715	C	#1/0 ACSR	7.26Y	121.0	0.00	4.03	0.35	0	2	1	89	0.00	0.0	7.233	0.051	2	1	1	1
PL.22798	PL.22517	C	#1/0 ACSR	7.33Y	122.2	0.00	2.79	0.04	0	0	0	100	0.00	0.0	6.116	0.004	0	0	0	1
PD.3232	PL.22798	C	30T	7.33Y	122.2	0.00	2.79	0.04	0	0	0	100	0.00	0.0	6.116	0.004	0	0	0	1
PL.22799	PD.3232	C	#1/0 ACSR	7.33Y	122.2	0.00	2.79	0.04	0	0	0	100	0.00	0.0	6.185	0.069	0	0	1	1
PL.22395	PL.22734	A	#2 ACSR	7.33Y	122.2	0.00	2.78	1.78	1	12	4	95	0.00	0.0	6.070	0.026	2	1	1	3
PL.22800	PL.22395	A	#2 ACSR	7.33Y	122.2	0.00	2.78	1.48	1	10	3	96	0.00	0.0	6.075	0.005	0	0	0	2
PD.3233	PL.22800	A	30T	7.33Y	122.2	0.00	2.78	1.48	0	10	3	96	0.00	0.0	6.075	0.005	0	0	0	2
PL.22801	PD.3233	A	#2 ACSR	7.33Y	122.2	0.01	2.79	1.48	1	10	3	96	0.00	0.0	6.244	0.169	0	0	0	2
PL.21995	PL.22801	A	#2 ACSR	7.33Y	122.2	0.01	2.79	1.48	1	10	3	96	0.00	0.0	6.352	0.108	0	0	0	2
PL.21996	PL.21995	A	#2 ACSR	7.33Y	122.2	0.00	2.79	1.48	1	10	3	96	0.00	0.0	6.418	0.066	0	0	0	2
PL.22518	PL.21996	A	#2 ACSR	7.33Y	122.2	0.00	2.79	0.19	0	1	0	100	0.00	0.0	6.504	0.086	1	0	1	1
PL.22396	PL.21996	A	#4 ACSR	7.33Y	122.2	0.00	2.80	1.29	1	9	3	95	0.00	0.0	6.504	0.086	9	3	1	1
PL.22802	PL.22734	C	#2 ACSR	7.33Y	122.2	0.00	2.78	1.11	1	8	2	97	0.00	0.0	6.049	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3234	PL.22802	C	30T	7.33Y	122.2	0.00	2.78	1.11	0	8	2	97	0.00	0.0	6.049	0.005	0	0	0	1
PL.22803	PD.3234	C	#2 ACSR	7.33Y	122.2	0.00	2.78	1.11	1	8	2	97	0.00	0.0	6.107	0.058	8	2	1	1
PL.22731	PL.22730	A	#2 ACSR	7.34Y	122.3	0.00	2.73	2.12	1	15	4	97	0.00	0.0	5.853	0.023	0	0	1	4
PL.22732	PL.22731	A	#2 ACSR	7.34Y	122.3	0.00	2.73	2.05	1	14	4	96	0.00	0.0	5.879	0.026	0	0	0	3
PL.22794	PL.22732	A	6 A (CWC)	7.34Y	122.3	0.00	2.73	2.05	1	14	4	96	0.00	0.0	5.884	0.005	0	0	0	3
PD.3230	PL.22794	A	30T	7.34Y	122.3	0.00	2.73	2.05	0	14	4	96	0.00	0.0	5.884	0.005	0	0	0	3
PL.22795	PD.3230	A	6 A (CWC)	7.34Y	122.3	0.01	2.74	2.05	1	14	4	96	0.00	0.0	5.993	0.109	0	0	0	3
PL.22583	PL.22795	A	6 A (CWC)	7.34Y	122.3	0.01	2.75	2.05	1	14	4	96	0.00	0.0	6.115	0.122	10	3	1	3
PL.22393	PL.22583	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.57	0	4	1	97	0.00	0.0	6.245	0.130	4	1	1	1
PL.22584	PL.22583	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.263	0.148	0	0	0	1
PL.21992	PL.22584	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.450	0.187	0	0	0	1
PL.21993	PL.21992	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.534	0.084	0	0	0	1
PL.22006	PL.21993	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.658	0.124	0	0	0	1
PL.22394	PL.22006	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.779	0.121	0	0	0	0
PL.22007	PL.22394	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.856	0.077	0	0	0	0
PL.21994	PL.22007	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.980	0.124	0	0	0	0
PL.22516	PL.22006	A	6 A (CWC)	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	6.769	0.111	0	0	1	1
PL.22388	PL.22579	B	#4 ACSR	7.34Y	122.3	0.04	2.66	9.56	7	67	20	96	0.02	0.0	5.570	0.098	14	4	2	11
PL.22790	PL.22388	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	6.31	5	44	13	96	0.00	0.0	5.578	0.008	0	0	0	8
PD.3228	PL.22790	B	30T	7.34Y	122.3	0.00	2.67	6.31	0	44	13	96	0.00	0.0	5.578	0.008	0	0	0	8
PL.22791	PD.3228	B	6 A (CWC)	7.34Y	122.3	0.02	2.69	6.31	5	44	13	96	0.01	0.0	5.652	0.074	0	0	0	8
PL.22514	PL.22791	B	6 A (CWC)	7.34Y	122.3	0.00	2.69	4.65	3	33	10	96	0.00	0.0	5.668	0.016	3	1	1	7
PL.22575	PL.22514	B	6 A (CWC)	7.34Y	122.3	0.02	2.71	4.20	3	29	9	96	0.00	0.0	5.788	0.120	7	2	1	6
PL.22392	PL.22575	B	6 A (CWC)	7.34Y	122.3	0.02	2.73	2.57	2	18	5	96	0.00	0.0	5.928	0.140	0	0	0	3
PL.22387	PL.22392	B	#4 ACSR	7.34Y	122.3	0.01	2.73	2.00	2	14	4	96	0.00	0.0	6.056	0.128	14	4	2	2
PL.22515	PL.22392	B	6 A (CWC)	7.34Y	122.3	0.00	2.73	0.57	0	4	1	97	0.00	0.0	6.028	0.100	0	0	0	1
PL.21991	PL.22515	B	6 A (CWC)	7.34Y	122.3	0.00	2.73	0.57	0	4	1	97	0.00	0.0	6.122	0.094	4	1	1	1
PL.22705	PL.22575	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	0.59	0	4	1	97	0.00	0.0	5.873	0.086	0	0	0	2
PL.22706	PL.22705	B	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.59	0	4	1	97	0.00	0.0	6.002	0.129	0	0	0	2
PL.22703	PL.22706	B	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.59	0	4	1	97	0.00	0.0	6.113	0.110	0	0	1	2
PL.22704	PL.22703	B	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.54	0	4	1	97	0.00	0.0	6.185	0.073	4	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22391	PL.22791	B	#1/0 ACSR	7.34Y	122.3	0.00	2.69	1.66	1	12	4	95	0.00	0.0	5.683	0.032	12	4	1	1
PL.22577	PL.22388	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	1.26	1	9	3	95	0.00	0.0	5.640	0.070	0	0	0	1
PL.22390	PL.22577	B	#4 ACSR	7.34Y	122.3	0.00	2.67	1.26	1	9	3	95	0.00	0.0	5.717	0.078	9	3	1	1
PL.22578	PL.22577	B	6 A (CWC)	7.34Y	122.3	0.00	2.67	0.00	0	0	0	100	0.00	0.0	5.686	0.046	0	0	0	0
PL.22788	PL.22507	A	#4 ACSR	7.34Y	122.4	0.00	2.60	0.47	0	3	1	95	0.00	0.0	5.401	0.005	0	0	0	1
PD.3227	PL.22788	A	30T	7.34Y	122.4	0.00	2.60	0.47	0	3	1	95	0.00	0.0	5.401	0.005	0	0	0	1
PL.22789	PD.3227	A	#4 ACSR	7.34Y	122.4	0.00	2.60	0.47	0	3	1	95	0.00	0.0	5.517	0.116	3	1	1	1
PL.22389	PL.22507	A	#4 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	5.440	0.043	0	0	0	0
PL.22383	PL.22563	B	6 A (CWC)	7.33Y	122.1	0.33	2.89	61.10	44	429	134	95	1.08	0.3	5.370	0.119	0	0	0	94
PL.22564	PL.22383	B	6 A (CWC)	7.30Y	121.7	0.37	3.25	61.10	44	428	133	95	1.18	0.3	5.500	0.130	0	0	1	94
PL.22385	PL.22564	B	6 A (CWC)	7.30Y	121.7	0.01	3.26	61.10	44	426	132	96	0.02	0.0	5.503	0.003	0	0	0	93
PD.3245	PL.22385	B	100L	7.30Y	121.7	0.00	3.26	61.10	61	426	132	96	0.00	0.0	5.503	0.003	0	0	0	93
PL.22508	PD.3245	B	6 A (CWC)	7.27Y	121.2	0.52	3.78	61.10	44	426	132	96	1.68	0.4	5.687	0.185	0	0	0	93
PL.21985	PL.22508	B	6 A (CWC)	7.25Y	120.9	0.36	4.14	61.10	44	425	131	96	1.17	0.3	5.816	0.128	0	0	0	93
PL.22008	PL.21985	B	6 A (CWC)	7.24Y	120.7	0.19	4.33	61.10	44	423	130	96	0.61	0.1	5.883	0.067	0	0	0	93
PL.21986	PL.22008	B	6 A (CWC)	7.21Y	120.2	0.44	4.77	61.10	44	423	130	96	1.40	0.3	6.037	0.154	0	0	0	93
PL.22573	PL.21986	B	6 A (CWC)	7.19Y	119.8	0.46	5.22	61.10	44	421	129	96	1.47	0.3	6.200	0.162	1	0	1	93
PL.22426	PL.22573	B	#4 ACSR	7.19Y	119.8	0.01	5.24	6.16	5	42	13	96	0.00	0.0	6.246	0.046	0	0	0	5
PL.22635	PL.22426	B	#4 ACSR	7.18Y	119.7	0.01	5.25	5.05	4	35	10	96	0.00	0.0	6.328	0.082	18	6	2	4
PL.22636	PL.22635	B	#4 ACSR	7.18Y	119.7	0.00	5.26	2.38	2	16	5	95	0.00	0.0	6.377	0.049	2	1	1	2
PL.22428	PL.22636	B	#2 ACSR	7.18Y	119.7	0.00	5.26	2.04	1	14	4	96	0.00	0.0	6.491	0.114	14	4	1	1
PL.22427	PL.22426	B	#4 ACSR	7.19Y	119.8	0.00	5.24	1.11	1	8	2	97	0.00	0.0	6.315	0.070	8	2	1	1
PL.22574	PL.22573	B	6 A (CWC)	7.17Y	119.5	0.31	5.54	54.80	39	377	115	96	0.90	0.2	6.323	0.124	0	0	0	87
PL.22632	PL.22574	B	6 A (CWC)	7.14Y	119.0	0.47	6.01	54.80	39	376	115	96	1.36	0.4	6.513	0.190	7	2	1	87
REG58	PL.22632	B	76.2 KVA	7.52Y	125.3	-6.26	-0.25	53.83	54	368	112	96	percent Boost= 0.00 Tap= 0.0						86	
PL.22633	REG58	B	6 A (CWC)	7.51Y	125.2	0.06	-0.19	51.14	37	368	112	96	0.16	0.0	6.538	0.025	0	0	0	86
PL.22634	PL.22633	B	6 A (CWC)	7.49Y	124.9	0.32	0.13	51.14	37	368	112	96	0.86	0.2	6.673	0.135	0	0	0	86
PL.21987	PL.22634	B	6 A (CWC)	7.48Y	124.7	0.20	0.33	51.14	37	367	111	96	0.55	0.2	6.760	0.087	0	0	0	86
PL.22806	PL.21987	B	6 A (CWC)	7.48Y	124.7	0.00	0.33	13.86	10	99	30	96	0.00	0.0	6.764	0.004	0	0	0	22
PD.3236	PL.22806	B	30T	7.48Y	124.7	0.00	0.33	13.86	0	99	30	96	0.00	0.0	6.764	0.004	0	0	0	22
PL.22807	PD.3236	B	6 A (CWC)	7.48Y	124.6	0.06	0.40	13.86	10	99	30	96	0.05	0.0	6.864	0.100	0	0	0	22

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22009	PL.22807	B	6 A (CWC)	7.47Y	124.5	0.08	0.48	13.86	10	99	30	96	0.06	0.1	6.986	0.121	0	0	0	22
PL.21988	PL.22009	B	6 A (CWC)	7.47Y	124.5	0.05	0.52	13.86	10	99	30	96	0.04	0.0	7.064	0.078	0	0	0	22
PL.21989	PL.21988	B	6 A (CWC)	7.46Y	124.4	0.08	0.60	13.86	10	99	30	96	0.06	0.1	7.182	0.118	0	0	0	22
PL.22429	PL.21989	B	6 A (CWC)	7.46Y	124.4	0.00	0.60	1.98	1	14	4	96	0.00	0.0	7.270	0.088	14	4	3	3
PL.22015	PL.21989	B	6 A (CWC)	7.46Y	124.3	0.07	0.67	11.89	8	85	26	96	0.04	0.0	7.305	0.124	5	2	2	19
PL.22693	PL.22015	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	0.01	0	0	0	100	0.00	0.0	7.395	0.089	0	0	1	1
PL.22694	PL.22693	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	0.00	0	0	0	100	0.00	0.0	7.535	0.140	0	0	0	0
PL.22016	PL.22015	B	6 A (CWC)	7.46Y	124.3	0.05	0.72	11.07	8	79	24	96	0.03	0.0	7.409	0.103	6	2	4	15
PL.22431	PL.22016	B	6 A (CWC)	7.46Y	124.3	0.02	0.74	10.23	7	73	22	96	0.01	0.0	7.452	0.043	0	0	0	11
PL.22510	PL.22431	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	0.78	1	6	2	95	0.00	0.0	7.518	0.066	6	2	1	1
PL.22432	PL.22431	B	6 A (CWC)	7.45Y	124.2	0.06	0.79	9.45	7	67	20	96	0.03	0.0	7.583	0.131	0	0	0	10
PL.66260	PL.22432	B	#1/0 ACSR	7.45Y	124.2	0.00	0.79	0.00	0	0	0	100	0.00	0.0	7.624	0.041	0	0	0	0
PL.22433	PL.22432	B	6 A (CWC)	7.45Y	124.2	0.02	0.81	9.45	7	67	20	96	0.01	0.0	7.634	0.051	11	3	3	10
PL.22435	PL.22433	B	6 A (CWC)	7.45Y	124.2	0.01	0.83	3.73	3	27	8	96	0.00	0.0	7.714	0.080	10	3	1	3
PL.22437	PL.22435	B	#4 ACSR	7.45Y	124.2	0.01	0.83	2.35	2	17	5	96	0.00	0.0	7.774	0.060	0	0	0	2
PL.22697	PL.22437	B	#2 ACSR	7.45Y	124.2	0.00	0.83	0.40	0	3	1	95	0.00	0.0	7.871	0.097	3	1	1	1
PL.22698	PL.22697	B	#2 ACSR	7.45Y	124.2	0.00	0.83	0.00	0	0	0	100	0.00	0.0	8.019	0.149	0	0	0	0
PL.22436	PL.22437	B	#2 ACSR	7.45Y	124.2	0.00	0.83	1.95	1	14	4	96	0.00	0.0	7.809	0.035	14	4	1	1
PL.22013	PL.22433	B	6 A (CWC)	7.45Y	124.2	0.01	0.83	3.09	2	22	7	95	0.00	0.0	7.740	0.106	8	2	1	3
PL.22438	PL.22013	B	#4 ACSR	7.45Y	124.2	0.00	0.83	1.37	1	10	3	96	0.00	0.0	7.778	0.038	10	3	1	1
PL.22014	PL.22013	B	6 A (CWC)	7.45Y	124.2	0.00	0.83	0.64	0	5	1	98	0.00	0.0	7.818	0.078	5	1	1	1
PL.22434	PL.22433	B	#4 ACSR	7.45Y	124.2	0.00	0.81	1.02	1	7	2	96	0.00	0.0	7.669	0.035	7	2	1	1
PL.22430	PL.22015	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	0.06	0	0	0	100	0.00	0.0	7.409	0.103	0	0	1	1
PL.22758	PL.21987	B	6 A (CWC)	7.48Y	124.7	0.01	0.34	37.27	27	267	81	96	0.02	0.0	6.764	0.005	0	0	0	64
PD.3212	PL.22758	B	20T	7.48Y	124.7	0.00	0.34	37.27	0	267	81	96	0.00	0.0	6.764	0.005	0	0	0	64
PL.22759	PD.3212	B	6 A (CWC)	7.47Y	124.5	0.17	0.51	37.27	27	267	81	96	0.34	0.1	6.865	0.101	0	0	0	64
PL.22021	PL.22759	B	6 A (CWC)	7.46Y	124.3	0.15	0.66	37.27	27	266	81	96	0.29	0.1	6.954	0.089	12	3	1	64
PL.22022	PL.22021	B	6 A (CWC)	7.45Y	124.1	0.21	0.88	33.14	24	237	72	96	0.38	0.2	7.095	0.141	0	0	0	59
PL.22565	PL.22022	B	6 A (CWC)	7.44Y	123.9	0.19	1.07	32.43	23	231	70	96	0.32	0.1	7.223	0.128	1	0	2	57
PL.22566	PL.22565	B	6 A (CWC)	7.43Y	123.8	0.11	1.17	21.33	15	152	46	96	0.12	0.1	7.330	0.108	0	0	0	37
PL.21990	PL.22566	B	6 A (CWC)	7.42Y	123.7	0.08	1.26	21.33	15	152	46	96	0.09	0.1	7.415	0.085	0	0	0	37

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22456	PL.21990	B	6 A (CWC)	7.42Y	123.6	0.10	1.35	20.67	15	147	44	96	0.11	0.1	7.517	0.102	0	0	0	36
PL.22023	PL.22456	B	6 A (CWC)	7.41Y	123.5	0.11	1.46	15.05	11	107	32	96	0.08	0.1	7.671	0.154	4	1	1	28
PL.22467	PL.22023	B	6 A (CWC)	7.41Y	123.5	0.00	1.46	0.53	0	4	1	97	0.00	0.0	7.741	0.070	4	1	1	1
PL.22024	PL.22023	B	6 A (CWC)	7.41Y	123.4	0.10	1.55	14.02	10	99	30	96	0.07	0.1	7.822	0.151	0	0	0	26
PL.22468	PL.22024	B	#4 ACSR	7.41Y	123.4	0.00	1.56	1.18	1	8	3	94	0.00	0.0	7.884	0.062	8	3	2	2
PL.22740	PL.22024	B	6 A (CWC)	7.40Y	123.4	0.05	1.60	12.84	9	91	27	96	0.03	0.0	7.909	0.088	10	3	4	24
PL.22741	PL.22740	B	6 A (CWC)	7.40Y	123.3	0.06	1.66	11.43	8	81	24	96	0.03	0.0	8.024	0.115	7	2	2	20
PL.22470	PL.22741	B	6 A (CWC)	7.40Y	123.3	0.00	1.66	0.65	0	5	1	98	0.00	0.0	8.086	0.062	5	1	1	1
PL.22469	PL.22741	B	#1/0 ACSR	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	8.070	0.046	0	0	0	0
PL.22025	PL.22741	B	6 A (CWC)	7.40Y	123.3	0.03	1.69	9.82	7	70	21	96	0.02	0.0	8.097	0.073	2	1	2	17
PL.22026	PL.22025	B	6 A (CWC)	7.40Y	123.3	0.04	1.74	8.61	6	61	18	96	0.02	0.0	8.229	0.132	21	6	2	12
PL.22742	PL.22026	B	6 A (CWC)	7.40Y	123.3	0.01	1.75	3.32	2	23	7	96	0.00	0.0	8.303	0.074	11	3	1	6
PL.22743	PL.22742	B	6 A (CWC)	7.40Y	123.3	0.00	1.75	1.74	1	12	4	95	0.00	0.0	8.352	0.049	2	1	1	5
PL.22475	PL.22743	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	1.47	1	10	3	96	0.00	0.0	8.378	0.026	5	2	3	4
PL.22476	PL.22475	B	#1/0 ACSR	7.39Y	123.2	0.00	1.75	0.70	0	5	1	98	0.00	0.0	8.441	0.063	5	1	1	1
PL.22477	PL.22476	B	#1/0 ACSR	7.39Y	123.2	0.00	1.75	0.00	0	0	0	100	0.00	0.0	8.514	0.073	0	0	0	0
PL.22473	PL.22026	B	6 A (CWC)	7.40Y	123.3	0.00	1.74	2.37	2	17	5	96	0.00	0.0	8.273	0.045	0	0	0	4
PL.22513	PL.22473	B	6 A (CWC)	7.40Y	123.3	0.00	1.74	2.05	1	14	4	96	0.00	0.0	8.322	0.049	14	4	3	3
PL.22474	PL.22473	B	#1/0 ACSR	7.40Y	123.3	0.00	1.74	0.32	0	2	1	89	0.00	0.0	8.329	0.056	2	1	1	1
PL.22027	PL.22025	B	6 A (CWC)	7.40Y	123.3	0.00	1.69	0.00	0	0	0	100	0.00	0.0	8.114	0.017	0	0	0	0
PL.22472	PL.22027	B	6 A (CWC)	7.40Y	123.3	0.00	1.69	0.00	0	0	0	100	0.00	0.0	8.212	0.098	0	0	0	0
PL.22481	PL.22472	B	#4 ACSR	7.40Y	123.3	0.00	1.69	0.00	0	0	0	100	0.00	0.0	8.239	0.027	0	0	0	0
PL.22028	PL.22027	B	6 A (CWC)	7.40Y	123.3	0.00	1.69	0.00	0	0	0	100	0.00	0.0	8.175	0.061	0	0	0	0
PL.22480	PL.22028	B	#4 ACSR	7.40Y	123.3	0.00	1.69	0.00	0	0	0	100	0.00	0.0	8.271	0.095	0	0	0	0
PL.22471	PL.22025	B	#4 ACSR	7.40Y	123.3	0.00	1.70	0.89	1	6	2	95	0.00	0.0	8.164	0.067	1	0	1	3
PL.22483	PL.22471	B	#2 ACSR	7.40Y	123.3	0.00	1.70	0.73	0	5	2	93	0.00	0.0	8.247	0.084	5	2	2	2
PL.22484	PL.22483	B	#2 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	8.288	0.041	0	0	0	0
PL.22458	PL.22456	B	6 A (CWC)	7.42Y	123.6	0.04	1.39	5.62	4	40	12	96	0.01	0.0	7.683	0.166	9	3	1	8
PL.22738	PL.22458	B	#4 ACSR	7.42Y	123.6	0.00	1.39	0.24	0	2	1	89	0.00	0.0	7.699	0.015	0	0	1	2
PL.22739	PL.22738	B	#4 ACSR	7.42Y	123.6	0.00	1.39	0.24	0	2	1	89	0.00	0.0	7.774	0.075	2	1	1	1
PL.22460	PL.22458	B	#1/0 ACSR	7.42Y	123.6	0.00	1.39	0.99	0	7	2	96	0.00	0.0	7.757	0.074	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22459	PL.22458	B	#4 ACSR	7.42Y	123.6	0.00	1.39	3.07	2	22	7	95	0.00	0.0	7.706	0.023	0	0	0	4
PL.22569	PL.22459	B	#4 ACSR	7.42Y	123.6	0.01	1.41	3.07	2	22	7	95	0.00	0.0	7.817	0.112	10	3	1	4
PL.22570	PL.22569	B	#4 ACSR	7.42Y	123.6	0.00	1.41	0.09	0	1	0	100	0.00	0.0	7.889	0.072	1	0	1	1
PL.22457	PL.22569	B	#4 ACSR	7.42Y	123.6	0.00	1.41	1.57	1	11	3	96	0.00	0.0	7.883	0.065	11	3	2	2
PL.22455	PL.21990	B	#1/0 ACSR	7.42Y	123.7	0.00	1.26	0.66	0	5	1	98	0.00	0.0	7.472	0.057	5	1	1	1
PL.22628	PL.22565	B	#4 ACSR	7.43Y	123.9	0.02	1.09	10.95	8	78	23	96	0.01	0.0	7.277	0.054	10	3	1	18
PL.22629	PL.22628	B	#4 ACSR	7.43Y	123.8	0.07	1.16	9.57	7	68	21	96	0.03	0.1	7.434	0.157	1	0	1	17
PL.22445	PL.22629	B	#4 ACSR	7.43Y	123.8	0.00	1.16	0.20	0	1	0	100	0.00	0.0	7.455	0.021	1	0	1	1
PL.22624	PL.22629	B	#4 ACSR	7.43Y	123.8	0.03	1.19	9.30	7	66	20	96	0.02	0.0	7.509	0.075	1	0	1	15
PL.22625	PL.22624	B	#4 ACSR	7.43Y	123.8	0.04	1.23	9.10	7	65	19	96	0.02	0.0	7.615	0.106	2	0	1	14
PL.22447	PL.22625	B	#2 ACSR	7.43Y	123.8	0.00	1.24	2.33	1	17	5	96	0.00	0.0	7.664	0.049	0	0	0	5
PL.22446	PL.22447	B	#4 ACSR	7.43Y	123.8	0.00	1.24	2.33	2	17	5	96	0.00	0.0	7.697	0.033	6	2	1	5
PL.22449	PL.22446	B	#1/0 ACSR	7.43Y	123.8	0.00	1.24	1.46	1	10	3	96	0.00	0.0	7.806	0.108	0	0	0	4
PL.22611	PL.22449	B	#1/0 ACSR	7.43Y	123.8	0.00	1.24	1.27	1	9	3	95	0.00	0.0	7.873	0.068	0	0	1	3
PL.22612	PL.22611	B	#1/0 ACSR	7.43Y	123.8	0.00	1.25	1.27	1	9	3	95	0.00	0.0	7.917	0.044	9	3	2	2
PL.22448	PL.22449	B	#1/0 ACSR	7.43Y	123.8	0.00	1.24	0.19	0	1	0	100	0.00	0.0	7.850	0.044	1	0	1	1
PL.22626	PL.22625	B	#4 ACSR	7.42Y	123.7	0.03	1.27	6.55	5	47	14	96	0.01	0.0	7.736	0.121	2	1	1	8
PL.22627	PL.22626	B	#4 ACSR	7.42Y	123.7	0.03	1.30	6.30	5	45	13	96	0.01	0.0	7.871	0.135	8	2	1	7
PL.22017	PL.22627	B	#4 ACSR	7.42Y	123.7	0.00	1.30	4.41	3	31	9	96	0.00	0.0	7.886	0.015	0	0	0	5
PL.22511	PL.22017	B	#4 ACSR	7.42Y	123.7	0.00	1.31	1.08	1	8	2	97	0.00	0.0	7.969	0.084	8	2	1	1
PL.22451	PL.22017	B	#2 ACSR	7.42Y	123.7	0.01	1.32	3.34	2	24	7	96	0.00	0.0	7.996	0.111	0	0	0	4
PL.22452	PL.22451	B	#2 ACSR	7.42Y	123.7	0.00	1.32	0.70	0	5	1	98	0.00	0.0	8.035	0.038	5	1	1	1
PL.22512	PL.22451	B	#2 ACSR	7.42Y	123.7	0.00	1.32	2.63	2	19	6	95	0.00	0.0	8.026	0.030	0	0	0	3
PL.22453	PL.22512	B	#2 ACSR	7.42Y	123.7	0.00	1.32	1.69	1	12	4	95	0.00	0.0	8.088	0.062	12	4	1	1
PL.22613	PL.22512	B	#1/0 ACSR	7.42Y	123.7	0.00	1.32	0.44	0	3	1	95	0.00	0.0	8.141	0.115	3	1	1	1
PL.22614	PL.22613	B	#1/0 ACSR	7.42Y	123.7	0.00	1.32	0.00	0	0	0	100	0.00	0.0	8.260	0.119	0	0	0	0
PL.22454	PL.22512	B	#2 ACSR	7.42Y	123.7	0.00	1.32	0.50	0	4	1	97	0.00	0.0	8.067	0.041	4	1	1	1
PL.22450	PL.22627	B	#4 ACSR	7.42Y	123.7	0.00	1.30	0.83	1	6	2	95	0.00	0.0	7.899	0.029	6	2	1	1
PL.22444	PL.22022	B	6 A (CWC)	7.45Y	124.1	0.00	0.88	0.70	1	5	2	93	0.00	0.0	7.147	0.052	5	2	2	2
PL.22439	PL.22021	B	6 A (CWC)	7.46Y	124.3	0.01	0.67	2.51	2	18	5	96	0.00	0.0	7.011	0.057	0	0	0	4
PL.22443	PL.22439	B	#4 ACSR	7.46Y	124.3	0.01	0.68	2.51	2	18	5	96	0.00	0.0	7.135	0.124	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22440	PL.22443	B	#2 ACSR	7.46Y	124.3	0.00	0.68	0.40	0	3	1	95	0.00	0.0	7.195	0.061	3	1	1	1
PL.22441	PL.22443	B	#2 ACSR	7.46Y	124.3	0.00	0.68	0.01	0	0	0	100	0.00	0.0	7.286	0.151	0	0	1	1
PL.22630	PL.22443	B	#2 ACSR	7.46Y	124.3	0.00	0.69	2.10	1	15	5	95	0.00	0.0	7.194	0.060	6	2	1	2
PL.22631	PL.22630	B	#2 ACSR	7.46Y	124.3	0.00	0.69	1.29	1	9	3	95	0.00	0.0	7.240	0.046	9	3	1	1
PL.22384	PD.3245	B	6 A (CWC)	7.30Y	121.7	0.00	3.26	0.00	0	0	0	100	0.00	0.0	5.610	0.108	0	0	0	0
PL.22509	PL.22384	B	6 A (CWC)	7.30Y	121.7	0.00	3.26	0.00	0	0	0	100	0.00	0.0	5.780	0.170	0	0	0	0
PL.21984	PL.22509	B	6 A (CWC)	7.30Y	121.7	0.00	3.26	0.00	0	0	0	100	0.00	0.0	5.909	0.129	0	0	0	0
PL.22386	PL.22384	B	6 A (CWC)	7.30Y	121.7	0.00	3.26	0.00	0	0	0	100	0.00	0.0	5.708	0.098	0	0	0	0
PL.22770	PL.22837	C	6 A (CWC)	7.37Y	122.9	0.00	2.12	0.04	0	0	0	100	0.00	0.0	4.650	0.005	0	0	0	1
PD.3218	PL.22770	C	30T	7.37Y	122.9	0.00	2.12	0.04	0	0	0	100	0.00	0.0	4.650	0.005	0	0	0	1
PL.22771	PD.3218	C	6 A (CWC)	7.37Y	122.9	0.00	2.12	0.04	0	0	0	100	0.00	0.0	4.717	0.067	0	0	1	1
CP.34	PL.22836	ABC	Cap (300)	7.38Y	122.9	0.00	2.05	0.00	0	0	0	100	0.00	0.0	4.552	0.067	0	0	0	0
PL.21795	PL.22560	C	#4 ACSR	7.40Y	123.4	0.00	1.63	10.35	8	73	22	96	0.00	0.0	4.078	0.005	0	0	0	10
PD.3217	PL.21795	C	30T	7.40Y	123.4	0.00	1.63	10.35	0	73	22	96	0.00	0.0	4.078	0.005	0	0	0	10
PL.21796	PD.3217	C	6 A (CWC)	7.40Y	123.3	0.04	1.67	7.64	5	54	16	96	0.02	0.0	4.192	0.114	0	0	0	8
PL.22378	PL.21796	C	6 A (CWC)	7.40Y	123.3	0.00	1.67	0.97	1	7	2	96	0.00	0.0	4.244	0.052	7	2	1	1
PL.22504	PL.21796	C	6 A (CWC)	7.40Y	123.3	0.01	1.68	6.68	5	47	14	96	0.00	0.0	4.236	0.045	0	0	0	7
PL.21797	PL.22504	C	#4 ACSR	7.40Y	123.3	0.03	1.71	4.74	4	34	10	96	0.01	0.0	4.388	0.152	0	0	0	6
PL.22585	PL.21797	C	#4 ACSR	7.40Y	123.3	0.01	1.73	4.74	4	34	10	96	0.00	0.0	4.456	0.068	0	0	1	6
PL.22586	PL.22585	C	#4 ACSR	7.40Y	123.3	0.00	1.73	2.27	2	16	5	95	0.00	0.0	4.482	0.026	0	0	0	2
PL.21816	PL.22586	C	#4 ACSR	7.40Y	123.3	0.00	1.73	2.27	2	16	5	95	0.00	0.0	4.555	0.074	16	5	1	2
PL.21817	PL.21816	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	4.691	0.136	0	0	1	1
PL.22376	PL.22585	C	6 A (CWC)	7.40Y	123.3	0.01	1.73	2.45	2	17	5	96	0.00	0.0	4.502	0.046	0	0	0	3
PL.22505	PL.22376	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	1.27	1	9	3	95	0.00	0.0	4.611	0.109	9	3	2	2
PL.22377	PL.22376	C	#4 ACSR	7.40Y	123.3	0.00	1.74	1.18	1	8	3	94	0.00	0.0	4.645	0.143	8	3	1	1
PL.22379	PL.22504	C	#4 ACSR	7.40Y	123.3	0.01	1.69	1.94	1	14	4	96	0.00	0.0	4.386	0.150	14	4	1	1
PL.21807	PD.3217	C	#4 ACSR	7.40Y	123.4	0.01	1.63	2.71	2	19	6	95	0.00	0.0	4.135	0.057	9	3	1	2
PL.21808	PL.21807	C	#4 ACSR	7.40Y	123.4	0.01	1.64	1.38	1	10	3	96	0.00	0.0	4.307	0.172	10	3	1	1
PL.22603	PL.22497	ABC	336 MCM AC	7.47Y	124.5	0.00	0.51	2.95	1	63	19	96	0.00	0.0	1.613	0.073	0	0	1	14
PL.22604	PL.22603	ABC	336 MCM AC	7.47Y	124.5	0.00	0.51	2.95	1	63	19	96	0.00	0.0	1.674	0.061	5	1	1	13
PL.22746	PL.22604	A	#1/0 ACSR	7.47Y	124.5	0.00	0.51	3.84	2	27	8	96	0.00	0.0	1.678	0.005	0	0	0	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3206	PL.22746	A	65T	7.47Y	124.5	0.00	0.51	3.84	0	27	8	96	0.00	0.0	1.678	0.005	0	0	0	6
PL.22747	PD.3206	A	#1/0 ACSR	7.47Y	124.5	0.00	0.52	3.84	2	27	8	96	0.00	0.0	1.727	0.049	4	1	1	6
PL.22605	PL.22747	A	#1/0 ACSR	7.47Y	124.5	0.00	0.52	3.32	1	24	7	96	0.00	0.0	1.746	0.018	0	0	1	5
PL.21788	PL.22605	A	#2 ACSR	7.47Y	124.5	0.00	0.52	3.30	2	24	7	96	0.00	0.0	1.790	0.045	0	0	0	4
PL.21782	PL.21788	A	#1/0 ACSR	7.47Y	124.5	0.00	0.52	1.71	1	12	4	95	0.00	0.0	1.853	0.063	12	4	2	2
PL.22606	PL.21788	A	#2 ACSR	7.47Y	124.5	0.00	0.53	1.59	1	11	3	96	0.00	0.0	1.928	0.137	7	2	1	2
PL.22607	PL.22606	A	#2 ACSR	7.47Y	124.5	0.00	0.53	0.59	0	4	1	97	0.00	0.0	1.945	0.018	0	0	0	1
PL.21789	PL.22607	A	#1/0 ACSR	7.47Y	124.5	0.00	0.53	0.59	0	4	1	97	0.00	0.0	2.003	0.058	4	1	1	1
PL.22020	PL.22604	ABC	336 MCM AC	7.47Y	124.5	0.00	0.51	1.45	0	31	9	96	0.00	0.0	1.722	0.048	1	0	1	6
PL.22748	PL.22020	C	#4 ACSR	7.47Y	124.5	0.00	0.51	3.04	2	22	7	95	0.00	0.0	1.727	0.005	0	0	0	4
PD.3207	PL.22748	C	65T	7.47Y	124.5	0.00	0.51	3.04	0	22	7	95	0.00	0.0	1.727	0.005	0	0	0	4
PL.22749	PD.3207	C	#4 ACSR	7.47Y	124.5	0.01	0.52	3.04	2	22	7	95	0.00	0.0	1.787	0.060	5	2	1	4
PL.21783	PL.22749	C	#4 ACSR	7.47Y	124.5	0.00	0.52	1.21	1	9	3	95	0.00	0.0	1.851	0.065	9	3	1	1
PL.21790	PL.22749	C	#1/0 ACSR	7.47Y	124.5	0.00	0.52	1.09	0	8	2	97	0.00	0.0	1.818	0.031	8	2	2	2
PL.22019	PL.22020	ABC	336 MCM AC	7.47Y	124.5	0.00	0.51	0.37	0	8	2	97	0.00	0.0	1.728	0.006	0	0	0	1
PL.22750	PL.22019	A	#2 ACSR	7.47Y	124.5	0.00	0.51	1.11	1	8	2	97	0.00	0.0	1.732	0.005	0	0	0	1
PD.3208	PL.22750	A	65T	7.47Y	124.5	0.00	0.51	1.11	0	8	2	97	0.00	0.0	1.732	0.005	0	0	0	1
PL.22751	PD.3208	A	#2 ACSR	7.47Y	124.5	0.00	0.51	1.11	1	8	2	97	0.00	0.0	1.742	0.010	8	2	1	1
PL.22818	PL.22019	ABC	336 MCM AC	7.47Y	124.5	0.00	0.51	0.00	0	0	0	100	0.00	0.0	1.801	0.073	0	0	0	0
PD.3242-A	PL.22818	ABC	Open	7.47Y	124.5	0.00	0.51	0.00	0	0	0	100	0.00	0.0	1.801	0.073	0	0	0	0
PL.25699	Hargett	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	76.66	15	1642	529	95	0.00	0.0	0.005	0.005	0	0	0	331
PL.72938	PL.25699	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	76.66	15	1642	529	95	0.00	0.0	0.009	0.004	0	0	0	331

----- Feeder No. 4 (Ivory Hill F4) Beginning with Device PD.11205 -----

PD.11205	PL.72938	ABC	360VWE	7.50Y	125.0	0.00	0.00	76.66	0	1642	529	95	0.00	0.0	0.009	0.004	0	0	0	331
PL.25700	PD.11205	ABC	397 SPACER	7.50Y	125.0	0.02	0.02	76.66	15	1642	529	95	0.05	0.0	0.079	0.070	0	0	0	331
PL.24773	PL.25700	ABC	397 SPACER	7.50Y	124.9	0.03	0.05	76.66	15	1642	528	95	0.10	0.0	0.203	0.125	0	0	0	331
PL.24774	PL.24773	ABC	397 SPACER	7.50Y	124.9	0.03	0.08	76.66	15	1642	527	95	0.09	0.0	0.319	0.116	0	0	0	331
PL.24775	PL.24774	ABC	397 SPACER	7.49Y	124.9	0.04	0.12	76.66	15	1642	526	95	0.11	0.0	0.464	0.145	0	0	0	331
PL.24776	PL.24775	ABC	397 SPACER	7.49Y	124.8	0.03	0.15	76.66	15	1642	524	95	0.10	0.0	0.590	0.126	0	0	0	331

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24777	PL.24776	ABC	397 SPACER	7.49Y	124.8	0.03	0.18	76.66	15	1641	523	95	0.10	0.0	0.713	0.123	0	0	0	331
PL.24778	PL.24777	ABC	397 SPACER	7.49Y	124.8	0.04	0.22	76.66	15	1641	522	95	0.11	0.0	0.851	0.138	0	0	0	331
PL.24779	PL.24778	ABC	397 SPACER	7.49Y	124.8	0.03	0.25	76.66	15	1641	521	95	0.08	0.0	0.958	0.107	0	0	0	331
PL.24780	PL.24779	ABC	397 SPACER	7.48Y	124.7	0.04	0.28	76.66	15	1641	520	95	0.11	0.0	1.100	0.141	0	0	0	331
PL.24781	PL.24780	ABC	397 SPACER	7.48Y	124.7	0.03	0.31	76.66	15	1641	519	95	0.09	0.0	1.212	0.113	0	0	0	331
PL.24735	PL.24781	ABC	336 MCM AC	7.48Y	124.7	0.03	0.34	76.66	15	1641	517	95	0.24	0.0	1.261	0.048	0	0	0	331
PL.24664	PL.24735	C	#4 ACSR	7.48Y	124.7	0.00	0.34	1.82	1	13	4	96	0.00	0.0	1.297	0.036	0	0	0	1
PD.3477	PL.24664	C	65T	7.48Y	124.7	0.00	0.34	1.82	0	13	4	96	0.00	0.0	1.297	0.036	0	0	0	1
PL.24665	PD.3477	C	#4 ACSR	7.48Y	124.7	0.00	0.34	1.82	1	13	4	96	0.00	0.0	1.349	0.052	13	4	1	1
PL.24528	PL.24735	ABC	336 MCM AC	7.48Y	124.6	0.08	0.41	76.06	15	1628	513	95	0.63	0.0	1.390	0.129	0	0	0	330
PL.24782	PL.24528	ABC	336 MCM AC	7.47Y	124.5	0.08	0.49	76.06	15	1627	512	95	0.66	0.0	1.525	0.136	0	0	0	330
PL.24783	PL.24782	ABC	336 MCM AC	7.47Y	124.4	0.07	0.57	76.06	15	1626	510	95	0.59	0.0	1.647	0.122	0	0	0	330
PL.24529	PL.24783	ABC	336 MCM AC	7.47Y	124.4	0.00	0.57	0.00	0	0	0	100	0.00	0.0	1.708	0.061	0	0	0	0
PL.22819	PL.24529	ABC	336 MCM AC	7.47Y	124.4	0.00	0.57	0.00	0	0	0	100	0.00	0.0	1.713	0.005	0	0	0	0
PD.3242-B	PL.22819	ABC	Open	7.47Y	124.4	0.00	0.57	0.00	0	0	0	100	0.00	0.0	1.713	0.005	0	0	0	0
PL.24736	PL.24783	ABC	336 MCM AC	7.46Y	124.4	0.05	0.61	75.88	15	1622	507	95	0.37	0.0	1.724	0.077	0	0	0	327
PL.24674	PL.24736	C	#1/0 ACSR	7.46Y	124.4	0.00	0.61	22.76	10	163	49	96	0.00	0.0	1.729	0.005	0	0	0	12
PD.3482	PL.24674	C	65T	7.46Y	124.4	0.00	0.61	22.76	0	163	49	96	0.00	0.0	1.729	0.005	0	0	0	12
PL.24675	PD.3482	C	#1/0 ACSR	7.46Y	124.4	0.03	0.64	22.76	10	163	49	96	0.03	0.0	1.779	0.050	20	6	2	12
PL.24854	PL.24675	C	#1/0 ACSR	7.46Y	124.4	0.01	0.65	5.20	2	37	11	96	0.00	0.0	1.834	0.055	0	0	0	6
PL.24532	PL.24854	C	#1/0 ACSR	7.46Y	124.4	0.00	0.65	1.02	0	7	2	96	0.00	0.0	1.852	0.018	7	2	2	2
PL.24867	PL.24854	C	#1/0 ACSR	7.46Y	124.4	0.00	0.65	4.19	2	30	9	96	0.00	0.0	1.875	0.041	8	3	1	4
PL.24868	PL.24867	C	#1/0 ACSR	7.46Y	124.3	0.00	0.65	3.02	1	22	6	96	0.00	0.0	1.930	0.055	14	4	1	3
PL.24853	PL.24868	C	#1/0 ACSR	7.46Y	124.3	0.00	0.65	0.00	0	0	0	100	0.00	0.0	1.993	0.063	0	0	1	1
PL.24533	PL.24868	C	#1/0 ACSR	7.46Y	124.3	0.00	0.65	1.01	0	7	2	96	0.00	0.0	1.971	0.042	7	2	1	1
PL.24530	PL.24675	C	#1/0 ACSR	7.46Y	124.4	0.00	0.64	1.32	1	9	3	95	0.00	0.0	1.852	0.073	9	3	1	1
PL.24531	PL.24675	C	#1/0 ACSR	7.46Y	124.4	0.01	0.64	13.38	6	96	29	96	0.00	0.0	1.811	0.032	96	29	3	3
PL.24869	PL.24736	ABC	336 MCM AC	7.46Y	124.3	0.07	0.68	68.29	13	1459	458	95	0.52	0.0	1.856	0.132	5	2	2	315
PL.24870	PL.24869	ABC	336 MCM AC	7.46Y	124.3	0.02	0.70	68.05	13	1453	455	95	0.17	0.0	1.899	0.044	1	0	1	313
PL.24856	PL.24870	ABC	336 MCM AC	7.46Y	124.3	0.03	0.74	67.60	13	1443	452	95	0.23	0.0	1.960	0.061	0	0	1	310
PL.24855	PL.24856	ABC	336 MCM AC	7.45Y	124.2	0.03	0.77	67.59	13	1443	451	95	0.24	0.0	2.022	0.062	0	0	0	308

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.25042	PL.24855	A	#2 ACSR	7.45Y	124.2	0.00	0.77	1.86	1	13	4	96	0.00	0.0	2.027	0.005	0	0	0	1
PD.3533	PL.25042	A	65T	7.45Y	124.2	0.00	0.77	1.86	0	13	4	96	0.00	0.0	2.027	0.005	0	0	0	1
PL.25043	PD.3533	A	#2 ACSR	7.45Y	124.2	0.00	0.77	1.86	1	13	4	96	0.00	0.0	2.044	0.017	13	4	1	1
PL.24871	PL.24855	ABC	336 MCM AC	7.45Y	124.2	0.04	0.80	66.97	13	1429	446	95	0.26	0.0	2.091	0.069	1	0	1	307
PL.24872	PL.24871	ABC	336 MCM AC	7.45Y	124.2	0.02	0.82	66.91	13	1428	445	95	0.14	0.0	2.127	0.036	4	1	1	306
PL.24852	PL.24872	ABC	336 MCM AC	7.45Y	124.1	0.05	0.87	66.52	13	1420	443	95	0.34	0.0	2.217	0.091	0	0	0	303
PL.24737	PL.24852	ABC	336 MCM AC	7.45Y	124.1	0.02	0.89	66.44	13	1417	441	95	0.15	0.0	2.259	0.042	0	0	0	302
PL.24738	PL.24737	ABC	336 MCM AC	7.44Y	124.1	0.03	0.92	66.25	13	1413	440	95	0.23	0.0	2.320	0.061	0	0	0	301
PL.25018	PL.24738	A	#2 ACSR	7.44Y	124.1	0.00	0.92	0.18	0	1	0	100	0.00	0.0	2.324	0.005	0	0	0	1
PD.3521	PL.25018	A	65T	7.44Y	124.1	0.00	0.92	0.18	0	1	0	100	0.00	0.0	2.324	0.005	0	0	0	1
PL.25019	PD.3521	A	#2 ACSR	7.44Y	124.1	0.00	0.92	0.18	0	1	0	100	0.00	0.0	2.377	0.053	1	0	1	1
PL.24850	PL.24738	ABC	336 MCM AC	7.44Y	124.0	0.04	0.96	65.92	13	1406	437	95	0.28	0.0	2.396	0.077	0	0	0	299
PL.24851	PL.24850	ABC	336 MCM AC	7.44Y	124.0	0.04	1.00	65.36	13	1394	433	95	0.30	0.0	2.479	0.083	0	0	0	298
PL.25020	PL.24851	A	#1/0 ACSR	7.44Y	124.0	0.00	1.00	0.64	0	5	1	98	0.00	0.0	2.484	0.005	0	0	0	1
PD.3522	PL.25020	A	65T	7.44Y	124.0	0.00	1.00	0.64	0	5	1	98	0.00	0.0	2.484	0.005	0	0	0	1
PL.25021	PD.3522	A	#1/0 ACSR	7.44Y	124.0	0.00	1.00	0.64	0	5	1	98	0.00	0.0	2.520	0.036	5	1	1	1
PL.24672	PL.24851	C	#4 ACSR	7.44Y	124.0	0.00	1.00	0.71	1	5	2	93	0.00	0.0	2.484	0.005	0	0	0	1
PD.3481	PL.24672	C	65T	7.44Y	124.0	0.00	1.00	0.71	0	5	2	93	0.00	0.0	2.484	0.005	0	0	0	1
PL.24673	PD.3481	C	#4 ACSR	7.44Y	124.0	0.00	1.00	0.71	1	5	2	93	0.00	0.0	2.592	0.108	5	2	1	1
PL.24865	PL.24851	ABC	336 MCM AC	7.44Y	124.0	0.01	1.02	64.91	13	1384	429	96	0.10	0.0	2.507	0.028	11	3	1	296
PL.24866	PL.24865	ABC	336 MCM AC	7.43Y	123.9	0.08	1.10	64.40	12	1373	426	96	0.57	0.0	2.671	0.164	0	0	0	295
PL.24739	PL.24866	ABC	336 MCM AC	7.43Y	123.9	0.05	1.15	63.89	12	1361	421	96	0.34	0.0	2.770	0.099	0	0	0	293
PL.25048	PL.24739	ABC	#4 ACSR	7.43Y	123.9	0.00	1.15	0.10	0	2	1	89	0.00	0.0	2.775	0.005	0	0	0	1
PD.3536	PL.25048	ABC	65T	7.43Y	123.9	0.00	1.15	0.10	0	2	1	89	0.00	0.0	2.775	0.005	0	0	0	1
PL.25049	PD.3536	ABC	#4 ACSR	7.43Y	123.9	0.00	1.15	0.10	0	2	1	89	0.00	0.0	2.799	0.024	2	1	1	1
PL.24740	PL.24739	ABC	336 MCM AC	7.43Y	123.8	0.02	1.17	63.79	12	1359	419	96	0.17	0.0	2.819	0.049	0	0	0	292
PL.24971	PL.24740	C	#4 ACSR	7.43Y	123.8	0.00	1.17	1.43	1	10	3	96	0.00	0.0	2.824	0.005	0	0	0	1
PD.3496	PL.24971	C	65T	7.43Y	123.8	0.00	1.17	1.43	0	10	3	96	0.00	0.0	2.824	0.005	0	0	0	1
PL.24972	PD.3496	C	#4 ACSR	7.43Y	123.8	0.00	1.17	1.43	1	10	3	96	0.00	0.0	2.837	0.013	10	3	1	1
PL.24741	PL.24740	ABC	336 MCM AC	7.43Y	123.8	0.06	1.23	63.32	12	1349	416	96	0.41	0.0	2.941	0.122	0	0	0	291
PL.25022	PL.24741	C	#1/0 ACSR	7.43Y	123.8	0.00	1.23	9.11	4	65	19	96	0.00	0.0	2.946	0.005	0	0	0	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3523	PL.25022	C	65T	7.43Y	123.8	0.00	1.23	9.11	0	65	19	96	0.00	0.0	2.946	0.005	0	0	0	16
PL.25023	PD.3523	C	#1/0 ACSR	7.43Y	123.8	0.01	1.24	9.11	4	65	19	96	0.01	0.0	3.018	0.072	14	4	1	16
PL.24535	PL.25023	C	#1/0 ACSR	7.43Y	123.8	0.00	1.24	0.52	0	4	1	97	0.00	0.0	3.149	0.131	3	1	1	2
PL.24536	PL.24535	C	#1/0 ACSR	7.43Y	123.8	0.00	1.24	0.13	0	1	0	100	0.00	0.0	3.223	0.074	1	0	1	1
PL.24847	PL.25023	C	#1/0 ACSR	7.42Y	123.7	0.01	1.25	6.65	3	47	14	96	0.00	0.0	3.073	0.055	0	0	1	13
PL.24573	PL.24847	C	#1/0 ACSR	7.42Y	123.7	0.00	1.25	0.42	0	3	1	95	0.00	0.0	3.106	0.033	3	1	1	1
PL.24654	PL.24847	C	6 A (CWC)	7.42Y	123.7	0.05	1.30	6.17	4	44	13	96	0.02	0.0	3.246	0.173	0	0	0	11
PL.24784	PL.24654	C	6 A (CWC)	7.42Y	123.6	0.05	1.35	6.17	4	44	13	96	0.02	0.0	3.420	0.175	0	0	0	11
PL.24863	PL.24784	C	6 A (CWC)	7.42Y	123.6	0.02	1.38	6.17	4	44	13	96	0.01	0.0	3.517	0.097	9	3	2	11
PL.24864	PL.24863	C	6 A (CWC)	7.42Y	123.6	0.03	1.40	4.97	4	35	11	95	0.01	0.0	3.633	0.116	0	0	0	9
PL.24574	PL.24864	C	6 A (CWC)	7.41Y	123.6	0.02	1.42	3.31	2	24	7	96	0.00	0.0	3.764	0.131	0	0	0	7
PL.24785	PL.24574	C	6 A (CWC)	7.41Y	123.6	0.01	1.44	3.31	2	24	7	96	0.00	0.0	3.884	0.120	10	3	2	7
PL.24650	PL.24785	C	#4 ACSR	7.41Y	123.6	0.00	1.44	1.84	1	13	4	96	0.00	0.0	3.899	0.015	0	0	0	5
PL.24657	PL.24650	C	#4 ACSR	7.41Y	123.6	0.01	1.44	1.84	1	13	4	96	0.00	0.0	3.968	0.068	0	0	0	5
PL.24861	PL.24657	C	#4 ACSR	7.41Y	123.6	0.00	1.45	0.95	1	7	2	96	0.00	0.0	4.034	0.066	1	0	1	2
PL.24862	PL.24861	C	#4 ACSR	7.41Y	123.5	0.00	1.45	0.83	1	6	2	95	0.00	0.0	4.149	0.114	0	0	0	1
PL.24786	PL.24862	C	#4 ACSR	7.41Y	123.5	0.00	1.45	0.83	1	6	2	95	0.00	0.0	4.287	0.139	6	2	1	1
PL.24848	PL.24657	C	6 A (CWC)	7.41Y	123.6	0.00	1.45	0.88	1	6	2	95	0.00	0.0	4.033	0.065	6	2	1	3
PL.24575	PL.24848	C	#4 ACSR	7.41Y	123.6	0.00	1.45	0.06	0	0	0	100	0.00	0.0	4.112	0.079	0	0	1	1
PL.24849	PL.24848	C	6 A (CWC)	7.41Y	123.6	0.00	1.45	0.02	0	0	0	100	0.00	0.0	4.096	0.063	0	0	0	1
PL.24742	PL.24849	C	6 A (CWC)	7.41Y	123.6	0.00	1.45	0.02	0	0	0	100	0.00	0.0	4.199	0.103	0	0	1	1
PL.24651	PL.24849	C	#4 ACSR	7.41Y	123.6	0.00	1.45	0.00	0	0	0	100	0.00	0.0	4.105	0.009	0	0	0	0
PL.24655	PL.24651	C	#4 ACSR	7.41Y	123.6	0.00	1.45	0.00	0	0	0	100	0.00	0.0	4.131	0.026	0	0	0	0
PL.24656	PL.24655	C	#4 ACSR	7.41Y	123.6	0.00	1.45	0.00	0	0	0	100	0.00	0.0	4.173	0.043	0	0	0	0
PL.24646	PL.24864	C	6 A (CWC)	7.42Y	123.6	0.01	1.41	1.66	1	12	4	95	0.00	0.0	3.759	0.126	0	0	0	2
PL.24647	PL.24646	C	6 A (CWC)	7.42Y	123.6	0.00	1.42	1.66	1	12	4	95	0.00	0.0	3.813	0.054	0	0	0	2
PL.24652	PL.24647	C	#4 ACSR	7.42Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	3.896	0.083	0	0	0	0
PL.24648	PL.24647	C	6 A (CWC)	7.41Y	123.6	0.00	1.42	1.66	1	12	4	95	0.00	0.0	3.928	0.115	10	3	1	2
PL.24649	PL.24648	C	6 A (CWC)	7.41Y	123.6	0.00	1.42	0.19	0	1	0	100	0.00	0.0	4.035	0.107	1	0	1	1
PL.25024	PL.24741	A	#1/0 ACSR	7.43Y	123.8	0.00	1.23	10.94	5	78	23	96	0.00	0.0	2.946	0.005	0	0	0	12
PD.3524	PL.25024	A	20T	7.43Y	123.8	0.00	1.23	10.94	0	78	23	96	0.00	0.0	2.946	0.005	0	0	0	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.25025	PD.3524	A	#1/0 ACSR	7.42Y	123.7	0.02	1.25	10.94	5	78	23	96	0.01	0.0	3.027	0.081	0	0	0	12
PL.24900	PL.25025	A	#1/0 ACSR	7.42Y	123.7	0.03	1.28	10.94	5	78	23	96	0.01	0.0	3.142	0.115	6	2	1	12
PL.24901	PL.24900	A	#1/0 ACSR	7.42Y	123.7	0.02	1.30	10.13	4	72	22	96	0.01	0.0	3.227	0.084	12	4	2	11
PL.24542	PL.24901	A	6 A (CWC)	7.42Y	123.7	0.01	1.31	2.20	2	16	5	95	0.00	0.0	3.310	0.083	0	0	0	4
PL.24543	PL.24542	A	#4 ACSR	7.42Y	123.7	0.00	1.31	0.03	0	0	0	100	0.00	0.0	3.368	0.058	0	0	1	1
PL.24544	PL.24542	A	#4 ACSR	7.42Y	123.7	0.01	1.31	2.17	2	15	5	95	0.00	0.0	3.421	0.111	15	5	2	2
PL.24981	PL.24542	A	#4 ACSR	7.42Y	123.7	0.00	1.31	0.01	0	0	0	100	0.00	0.0	3.315	0.005	0	0	0	1
PD.3501	PL.24981	A	40T	7.42Y	123.7	0.00	1.31	0.01	0	0	0	100	0.00	0.0	3.315	0.005	0	0	0	1
PL.24982	PD.3501	A	#4 ACSR	7.42Y	123.7	0.00	1.31	0.01	0	0	0	100	0.00	0.0	3.456	0.141	0	0	0	1
PL.24787	PL.24982	A	#4 ACSR	7.42Y	123.7	0.00	1.31	0.01	0	0	0	100	0.00	0.0	3.645	0.189	0	0	1	1
PL.24902	PL.24901	A	#2 ACSR	7.42Y	123.7	0.01	1.31	4.85	3	35	10	96	0.00	0.0	3.289	0.062	10	3	1	3
PL.24903	PL.24902	A	#2 ACSR	7.42Y	123.7	0.00	1.31	3.49	2	25	7	96	0.00	0.0	3.340	0.051	25	7	2	2
PL.24545	PL.24901	A	#4 ACSR	7.42Y	123.7	0.00	1.30	1.32	1	9	3	95	0.00	0.0	3.259	0.033	9	3	2	2
PL.24845	PL.24741	ABC	#1/0 ACSR	7.42Y	123.7	0.12	1.35	56.64	25	1206	372	96	0.99	0.1	3.058	0.117	5	1	1	263
PL.24975	PL.24845	C	#4 ACSR	7.42Y	123.7	0.00	1.35	1.03	1	7	2	96	0.00	0.0	3.063	0.005	0	0	0	1
PD.3498	PL.24975	C	65T	7.42Y	123.7	0.00	1.35	1.03	0	7	2	96	0.00	0.0	3.063	0.005	0	0	0	1
PL.24976	PD.3498	C	#4 ACSR	7.42Y	123.6	0.00	1.35	1.03	1	7	2	96	0.00	0.0	3.116	0.054	7	2	1	1
PL.24846	PL.24845	ABC	#1/0 ACSR	7.41Y	123.5	0.10	1.45	56.07	24	1193	368	96	0.84	0.1	3.159	0.101	9	3	3	261
PL.24538	PL.24846	C	6 A (CWC)	7.41Y	123.5	0.00	1.45	2.34	2	17	5	96	0.00	0.0	3.163	0.004	0	0	0	4
PD.3502	PL.24538	C	12T	7.41Y	123.5	0.00	1.45	2.34	0	17	5	96	0.00	0.0	3.163	0.004	0	0	0	4
PL.24537	PD.3502	C	#2 ACSR	7.41Y	123.5	0.00	1.46	1.12	1	8	2	97	0.00	0.0	3.346	0.183	8	2	2	2
PL.24743	PD.3502	C	6 A (CWC)	7.41Y	123.5	0.00	1.46	1.22	1	9	3	95	0.00	0.0	3.247	0.084	4	1	1	2
PL.24540	PL.24743	C	#4 ACSR	7.41Y	123.5	0.00	1.46	0.66	1	5	1	98	0.00	0.0	3.257	0.009	0	0	0	1
PL.24539	PL.24540	C	#4 ACSR	7.41Y	123.5	0.00	1.46	0.66	1	5	1	98	0.00	0.0	3.320	0.063	5	1	1	1
PL.24844	PL.24846	ABC	#1/0 ACSR	7.41Y	123.5	0.08	1.53	54.89	24	1167	359	96	0.65	0.1	3.240	0.081	5	1	1	254
PL.24843	PL.24844	ABC	#1/0 ACSR	7.40Y	123.3	0.13	1.66	54.29	24	1153	355	96	1.03	0.1	3.370	0.131	0	0	0	252
PL.24897	PL.24843	ABC	#1/0 ACSR	7.40Y	123.3	0.09	1.75	53.48	23	1135	349	96	0.67	0.1	3.458	0.087	2	0	1	247
PL.24898	PL.24897	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.77	53.40	23	1133	347	96	0.16	0.0	3.479	0.021	0	0	0	246
PL.24967	PL.24898	A	#4 ACSR	7.39Y	123.2	0.00	1.77	1.43	1	10	3	96	0.00	0.0	3.483	0.005	0	0	0	1
PD.3494	PL.24967	A	65T	7.39Y	123.2	0.00	1.77	1.43	0	10	3	96	0.00	0.0	3.483	0.005	0	0	0	1
PL.24968	PD.3494	A	#4 ACSR	7.39Y	123.2	0.00	1.77	1.43	1	10	3	96	0.00	0.0	3.565	0.082	10	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24894	PL.24898	ABC	#1/0 ACSR	7.39Y	123.2	0.07	1.84	52.92	23	1122	344	96	0.51	0.0	3.548	0.069	4	1	2	245
PL.24895	PL.24894	ABC	#1/0 ACSR	7.38Y	123.1	0.08	1.92	52.72	23	1117	342	96	0.61	0.1	3.631	0.084	11	3	2	243
PL.25026	PL.24895	A	#1/0 ACSR	7.38Y	123.1	0.00	1.92	2.72	1	19	6	95	0.00	0.0	3.636	0.004	0	0	0	2
PD.3525	PL.25026	A	65T	7.38Y	123.1	0.00	1.92	2.72	0	19	6	95	0.00	0.0	3.636	0.004	0	0	0	2
PL.25027	PD.3525	A	#1/0 ACSR	7.38Y	123.1	0.00	1.92	2.72	1	19	6	95	0.00	0.0	3.683	0.047	9	3	1	2
PL.24899	PL.25027	A	#1/0 ACSR	7.38Y	123.1	0.00	1.92	1.46	1	10	3	96	0.00	0.0	3.741	0.058	10	3	1	1
PL.24979	PL.24895	C	#2 ACSR	7.38Y	123.1	0.00	1.92	0.40	0	3	1	95	0.00	0.0	3.636	0.005	0	0	0	1
PD.3500	PL.24979	C	65T	7.38Y	123.1	0.00	1.92	0.40	0	3	1	95	0.00	0.0	3.636	0.005	0	0	0	1
PL.24980	PD.3500	C	#2 ACSR	7.38Y	123.1	0.00	1.92	0.40	0	3	1	95	0.00	0.0	3.670	0.034	3	1	1	1
PL.24842	PL.24895	ABC	#1/0 ACSR	7.38Y	123.0	0.13	2.05	51.18	22	1084	332	96	0.97	0.1	3.771	0.140	6	2	1	238
PL.24977	PL.24842	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	0.88	1	6	2	95	0.00	0.0	3.776	0.005	0	0	0	1
PD.3499	PL.24977	C	65T	7.38Y	123.0	0.00	2.05	0.88	0	6	2	95	0.00	0.0	3.776	0.005	0	0	0	1
PL.24978	PD.3499	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	0.88	1	6	2	95	0.00	0.0	3.840	0.064	6	2	1	1
PL.24841	PL.24842	ABC	#1/0 ACSR	7.37Y	122.9	0.07	2.11	50.60	22	1071	327	96	0.48	0.0	3.842	0.070	0	0	0	236
PL.24839	PL.24841	ABC	#1/0 ACSR	7.37Y	122.8	0.09	2.20	46.91	20	992	303	96	0.60	0.1	3.943	0.102	2	1	1	214
PL.24690	PL.24839	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.15	1	8	2	97	0.00	0.0	3.948	0.005	0	0	0	1
PD.3490	PL.24690	C	65T	7.37Y	122.8	0.00	2.20	1.15	0	8	2	97	0.00	0.0	3.948	0.005	0	0	0	1
PL.24691	PD.3490	C	#4 ACSR	7.37Y	122.8	0.00	2.20	1.15	1	8	2	97	0.00	0.0	3.991	0.042	8	2	1	1
PL.24840	PL.24839	ABC	#1/0 ACSR	7.36Y	122.7	0.08	2.28	46.41	20	981	300	96	0.53	0.1	4.036	0.092	0	0	0	212
PL.25052	PL.24840	B	#1/0 ACSR	7.36Y	122.7	0.04	2.32	30.89	13	218	66	96	0.06	0.0	4.094	0.058	0	0	0	48
PD.3538	PL.25052	B	50L	7.36Y	122.7	0.00	2.32	30.89	62	218	66	96	0.00	0.0	4.094	0.058	0	0	0	48
PL.25053	PD.3538	B	#1/0 ACSR	7.36Y	122.6	0.04	2.37	30.89	13	218	66	96	0.06	0.0	4.152	0.059	2	1	1	48
PL.24885	PL.25053	B	#1/0 ACSR	7.35Y	122.6	0.07	2.43	29.08	13	205	62	96	0.09	0.0	4.249	0.096	5	1	1	44
PL.24886	PL.24885	B	#1/0 ACSR	7.35Y	122.5	0.07	2.51	28.42	12	200	61	96	0.10	0.0	4.354	0.105	0	0	0	43
PL.24795	PL.24886	B	#1/0 ACSR	7.35Y	122.4	0.08	2.58	28.42	12	200	60	96	0.10	0.0	4.463	0.109	2	1	2	43
PL.24550	PL.24795	B	#4 ACSR	7.34Y	122.4	0.00	2.59	1.56	1	11	3	96	0.00	0.0	4.559	0.097	11	3	2	2
PL.24549	PL.24795	B	#1/0 ACSR	7.34Y	122.3	0.07	2.66	26.56	12	187	56	96	0.09	0.0	4.578	0.115	0	0	0	39
PL.24796	PL.24549	B	#1/0 ACSR	7.34Y	122.3	0.05	2.71	26.56	12	187	56	96	0.06	0.0	4.655	0.078	0	0	0	39
PL.25030	PL.24796	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	4.00	3	28	8	96	0.00	0.0	4.660	0.005	0	0	0	7
PD.3527	PL.25030	B	15T	7.34Y	122.3	0.00	2.71	4.00	0	28	8	96	0.00	0.0	4.660	0.005	0	0	0	7
PL.25031	PD.3527	B	6 A (CWC)	7.34Y	122.3	0.02	2.73	4.00	3	28	8	96	0.00	0.0	4.803	0.143	12	4	1	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24576	PL.25031	B	6 A (CWC)	7.34Y	122.3	0.01	2.74	2.25	2	16	5	95	0.00	0.0	4.930	0.127	0	0	0	6
PL.24838	PL.24576	B	6 A (CWC)	7.33Y	122.2	0.01	2.75	2.25	2	16	5	95	0.00	0.0	5.043	0.113	1	0	1	6
PL.24577	PL.24838	B	6 A (CWC)	7.33Y	122.2	0.00	2.75	0.23	0	2	0	100	0.00	0.0	5.104	0.061	2	0	2	2
PL.24891	PL.24838	B	6 A (CWC)	7.33Y	122.2	0.00	2.75	1.86	1	13	4	96	0.00	0.0	5.063	0.020	7	2	1	3
PL.24892	PL.24891	B	6 A (CWC)	7.33Y	122.2	0.00	2.76	0.84	1	6	2	95	0.00	0.0	5.137	0.074	6	2	2	2
PL.24688	PL.24796	B	6 A (CWC)	7.34Y	122.3	0.00	2.71	3.18	2	22	7	95	0.00	0.0	4.660	0.005	0	0	0	5
PD.3489	PL.24688	B	20T	7.34Y	122.3	0.00	2.71	3.18	0	22	7	95	0.00	0.0	4.660	0.005	0	0	0	5
PL.24689	PD.3489	B	6 A (CWC)	7.34Y	122.3	0.02	2.73	3.18	2	22	7	95	0.00	0.0	4.802	0.142	0	0	0	5
PL.24881	PL.24689	B	6 A (CWC)	7.34Y	122.3	0.02	2.75	2.95	2	21	6	96	0.00	0.0	4.959	0.157	6	2	1	4
PL.24882	PL.24881	B	6 A (CWC)	7.33Y	122.2	0.01	2.75	2.06	1	14	4	96	0.00	0.0	5.020	0.061	3	1	1	3
PL.24878	PL.24882	B	6 A (CWC)	7.33Y	122.2	0.01	2.76	1.62	1	11	3	96	0.00	0.0	5.089	0.069	0	0	0	2
PL.24746	PL.24878	B	6 A (CWC)	7.33Y	122.2	0.00	2.76	0.17	0	1	0	100	0.00	0.0	5.147	0.058	1	0	1	1
PL.24876	PL.24878	B	#1/0 ACSR	7.33Y	122.2	0.00	2.76	1.45	1	10	3	96	0.00	0.0	5.134	0.045	10	3	1	1
PL.24877	PL.24876	B	#1/0 ACSR	7.33Y	122.2	0.00	2.76	0.00	0	0	0	100	0.00	0.0	5.196	0.062	0	0	0	0
PL.25016	PL.24689	B	6 A (CWC)	7.34Y	122.3	0.00	2.73	0.23	0	2	0	100	0.00	0.0	4.807	0.005	0	0	0	1
PD.3520	PL.25016	B	12T	7.34Y	122.3	0.00	2.73	0.23	0	2	0	100	0.00	0.0	4.807	0.005	0	0	0	1
PL.25017	PD.3520	B	6 A (CWC)	7.34Y	122.3	0.00	2.73	0.23	0	2	0	100	0.00	0.0	4.933	0.126	0	0	0	1
PL.24797	PL.25017	B	6 A (CWC)	7.34Y	122.3	0.00	2.73	0.23	0	2	0	100	0.00	0.0	5.006	0.074	2	0	1	1
PL.24837	PL.24796	B	#1/0 ACSR	7.34Y	122.3	0.03	2.74	19.39	8	136	41	96	0.03	0.0	4.716	0.061	1	0	1	27
PL.24883	PL.24837	B	#1/0 ACSR	7.33Y	122.2	0.02	2.76	18.37	8	129	39	96	0.02	0.0	4.774	0.058	12	4	2	24
PL.24884	PL.24883	B	#1/0 ACSR	7.33Y	122.2	0.05	2.81	16.69	7	117	35	96	0.04	0.0	4.894	0.121	0	0	0	22
PL.24798	PL.24884	B	#1/0 ACSR	7.33Y	122.2	0.04	2.85	16.69	7	117	35	96	0.03	0.0	4.990	0.096	0	0	0	22
PL.24747	PL.24798	B	#1/0 ACSR	7.33Y	122.1	0.03	2.88	16.69	7	117	35	96	0.03	0.0	5.071	0.081	0	0	0	22
PL.24879	PL.24747	B	6 A (CWC)	7.33Y	122.1	0.01	2.90	4.01	3	28	8	96	0.00	0.0	5.152	0.081	1	0	1	7
PL.24880	PL.24879	B	6 A (CWC)	7.33Y	122.1	0.01	2.90	3.86	3	27	8	96	0.00	0.0	5.202	0.050	14	4	1	6
PL.24875	PL.24880	B	6 A (CWC)	7.33Y	122.1	0.00	2.91	1.87	1	13	4	96	0.00	0.0	5.259	0.056	1	0	1	5
PL.24874	PL.24875	B	6 A (CWC)	7.33Y	122.1	0.01	2.91	1.79	1	13	4	96	0.00	0.0	5.339	0.080	3	1	1	4
PL.24873	PL.24874	B	6 A (CWC)	7.32Y	122.1	0.01	2.92	1.41	1	10	3	96	0.00	0.0	5.417	0.078	0	0	0	3
PL.25044	PL.24873	B	6 A (CWC)	7.32Y	122.1	0.00	2.92	1.41	1	10	3	96	0.00	0.0	5.421	0.005	0	0	0	3
PD.3534	PL.25044	B	20T	7.32Y	122.1	0.00	2.92	1.41	0	10	3	96	0.00	0.0	5.421	0.005	0	0	0	3
PL.25045	PD.3534	B	6 A (CWC)	7.32Y	122.1	0.01	2.93	1.41	1	10	3	96	0.00	0.0	5.558	0.136	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24803	PL.25045	B	6 A (CWC)	7.32Y	122.1	0.00	2.93	1.41	1	10	3	96	0.00	0.0	5.679	0.122	10	3	3	3
PL.24684	PL.24747	B	#1/0 ACSR	7.33Y	122.1	0.00	2.88	11.93	5	84	25	96	0.00	0.0	5.075	0.005	0	0	0	14
PD.3487	PL.24684	B	20T	7.33Y	122.1	0.00	2.88	11.93	0	84	25	96	0.00	0.0	5.075	0.005	0	0	0	14
PL.24685	PD.3487	B	#1/0 ACSR	7.33Y	122.1	0.02	2.90	11.93	5	84	25	96	0.01	0.0	5.146	0.071	0	0	0	14
PL.24827	PL.24685	B	#1/0 ACSR	7.32Y	122.1	0.04	2.94	11.93	5	84	25	96	0.02	0.0	5.277	0.131	11	3	1	14
PL.24566	PL.24827	B	6 A (CWC)	7.32Y	122.1	0.00	2.94	1.42	1	10	3	96	0.00	0.0	5.358	0.081	10	3	1	1
PL.24828	PL.24827	B	#1/0 ACSR	7.32Y	122.0	0.01	2.95	8.94	4	63	19	96	0.00	0.0	5.327	0.051	0	0	0	12
PL.24569	PL.24828	B	#1/0 ACSR	7.32Y	122.0	0.03	2.98	7.41	3	52	16	96	0.01	0.0	5.480	0.153	0	0	0	11
PL.24824	PL.24569	B	#1/0 ACSR	7.32Y	122.0	0.02	2.99	7.41	3	52	16	96	0.01	0.0	5.563	0.083	0	0	0	11
PL.24825	PL.24824	B	#1/0 ACSR	7.32Y	122.0	0.02	3.02	6.19	3	43	13	96	0.01	0.0	5.706	0.143	0	0	0	10
PL.24801	PL.24825	B	#1/0 ACSR	7.32Y	122.0	0.01	3.03	6.19	3	43	13	96	0.00	0.0	5.785	0.078	0	0	0	10
PL.24694	PL.24801	B	6 A (CWC)	7.32Y	122.0	0.00	3.03	2.20	2	15	5	95	0.00	0.0	5.789	0.005	0	0	0	4
PD.3492	PL.24694	B	12T	7.32Y	122.0	0.00	3.03	2.20	0	15	5	95	0.00	0.0	5.789	0.005	0	0	0	4
PL.24695	PD.3492	B	6 A (CWC)	7.32Y	122.0	0.00	3.03	2.20	2	15	5	95	0.00	0.0	5.845	0.056	8	2	1	4
PL.24890	PL.24695	B	6 A (CWC)	7.32Y	122.0	0.00	3.03	1.13	1	8	2	97	0.00	0.0	5.909	0.063	8	2	3	3
PL.24571	PL.24801	B	#4 ACSR	7.32Y	122.0	0.00	3.03	0.61	0	4	1	97	0.00	0.0	5.835	0.050	4	1	1	1
PL.24888	PL.24801	B	#1/0 ACSR	7.32Y	122.0	0.01	3.04	3.37	1	24	7	96	0.00	0.0	5.951	0.167	10	3	1	5
PL.24889	PL.24888	B	#1/0 ACSR	7.32Y	122.0	0.00	3.04	2.01	1	14	4	96	0.00	0.0	5.980	0.028	0	0	0	4
PL.24572	PL.24889	B	#4 ACSR	7.32Y	122.0	0.00	3.04	1.73	1	12	4	95	0.00	0.0	6.071	0.091	12	4	2	2
PL.24748	PL.24889	B	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.27	0	2	1	89	0.00	0.0	6.103	0.124	0	0	0	2
PL.24802	PL.24748	B	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.27	0	2	1	89	0.00	0.0	6.291	0.187	2	1	2	2
PL.24570	PL.24824	B	#4 ACSR	7.32Y	122.0	0.00	3.00	1.23	1	9	3	95	0.00	0.0	5.623	0.059	9	3	1	1
PL.24567	PL.24828	B	6 A (CWC)	7.32Y	122.0	0.00	2.95	0.00	0	0	0	100	0.00	0.0	5.376	0.049	0	0	0	0
PL.24568	PL.24828	B	#4 ACSR	7.32Y	122.0	0.01	2.96	1.53	1	11	3	96	0.00	0.0	5.475	0.147	11	3	1	1
PL.24565	PL.24747	B	#4 ACSR	7.33Y	122.1	0.00	2.88	0.75	1	5	2	93	0.00	0.0	5.133	0.062	5	2	1	1
PL.24686	PL.24837	B	#4 ACSR	7.34Y	122.3	0.00	2.74	0.81	1	6	2	95	0.00	0.0	4.720	0.005	0	0	0	2
PD.3488	PL.24686	B	20T	7.34Y	122.3	0.00	2.74	0.81	0	6	2	95	0.00	0.0	4.720	0.005	0	0	0	2
PL.24687	PD.3488	B	#4 ACSR	7.34Y	122.3	0.00	2.74	0.81	1	6	2	95	0.00	0.0	4.772	0.051	6	2	2	2
PL.24692	PL.25053	B	#4 ACSR	7.36Y	122.6	0.00	2.37	1.54	1	11	3	96	0.00	0.0	4.157	0.005	0	0	0	3
PD.3491	PL.24692	B	65T	7.36Y	122.6	0.00	2.37	1.54	0	11	3	96	0.00	0.0	4.157	0.005	0	0	0	3
PL.24693	PD.3491	B	#4 ACSR	7.36Y	122.6	0.01	2.37	1.54	1	11	3	96	0.00	0.0	4.286	0.130	2	1	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24548	PL.24693	B	#4 ACSR	7.36Y	122.6	0.00	2.38	1.16	1	8	2	97	0.00	0.0	4.380	0.094	8	2	1	1
PL.24547	PL.24693	B	#1/0 ACSR	7.36Y	122.6	0.00	2.37	0.03	0	0	0	100	0.00	0.0	4.401	0.114	0	0	1	1
PL.24887	PL.24840	ABC	#1/0 ACSR	7.36Y	122.7	0.05	2.33	36.12	16	763	233	96	0.28	0.0	4.116	0.080	10	3	2	164
PL.25058	PL.24887	ABC	#1/0 ACSR	7.36Y	122.6	0.04	2.37	35.64	15	753	230	96	0.22	0.0	4.182	0.066	0	0	0	162
PD.3541	PL.25058	ABC	50L	7.36Y	122.6	0.00	2.37	35.64	71	752	230	96	0.00	0.0	4.182	0.066	0	0	0	162
PL.25059	PD.3541	ABC	#1/0 ACSR	7.35Y	122.5	0.11	2.48	35.64	15	752	230	96	0.56	0.1	4.347	0.165	0	0	0	162
PL.24804	PL.25059	ABC	#1/0 ACSR	7.34Y	122.4	0.11	2.59	35.64	15	752	229	96	0.55	0.1	4.509	0.162	0	0	0	162
PL.24805	PL.24804	ABC	#1/0 ACSR	7.34Y	122.3	0.09	2.67	35.64	15	751	229	96	0.44	0.1	4.639	0.131	0	0	0	162
PL.24749	PL.24805	ABC	#1/0 ACSR	7.34Y	122.3	0.02	2.70	33.94	15	715	217	96	0.12	0.0	4.680	0.040	0	0	0	156
PL.24807	PL.24749	ABC	#1/0 ACSR	7.33Y	122.2	0.10	2.80	33.94	15	715	217	96	0.52	0.1	4.848	0.169	0	0	0	156
PL.24934	PL.24807	ABC	#1/0 ACSR	7.33Y	122.2	0.04	2.84	33.46	15	704	214	96	0.20	0.0	4.915	0.067	2	0	1	154
PL.24935	PL.24934	ABC	#1/0 ACSR	7.32Y	122.1	0.10	2.94	33.38	15	702	213	96	0.47	0.1	5.073	0.158	2	0	1	153
PL.25060	PL.24935	ABC	#1/0 ACSR	7.32Y	122.1	0.01	2.95	33.31	14	700	212	96	0.04	0.0	5.086	0.013	0	0	0	152
PL.25061	PL.25060	ABC	#1/0 ACSR	7.32Y	122.0	0.05	3.00	33.31	14	700	212	96	0.24	0.0	5.168	0.082	0	0	0	152
PL.24753	PL.25061	ABC	#1/0 ACSR	7.32Y	122.0	0.04	3.04	21.44	9	451	137	96	0.13	0.0	5.270	0.102	0	0	0	103
PL.24987	PL.24753	A	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.00	0	0	0	100	0.00	0.0	5.275	0.005	0	0	0	1
PD.3506	PL.24987	A	20T	7.32Y	122.0	0.00	3.04	0.00	0	0	0	100	0.00	0.0	5.275	0.005	0	0	0	1
PL.24988	PD.3506	A	#1/0 ACSR	7.32Y	122.0	0.00	3.04	0.00	0	0	0	100	0.00	0.0	5.349	0.074	0	0	1	1
PL.24931	PL.24753	ABC	#1/0 ACSR	7.32Y	122.0	0.01	3.05	21.44	9	451	136	96	0.03	0.0	5.296	0.026	8	2	1	102
PL.24932	PL.24931	ABC	#1/0 ACSR	7.31Y	121.9	0.05	3.10	21.08	9	443	134	96	0.15	0.0	5.426	0.130	0	0	0	101
PL.24985	PL.24932	A	6 A (CWC)	7.31Y	121.9	0.00	3.10	1.15	1	8	2	97	0.00	0.0	5.431	0.005	0	0	0	2
PD.3505	PL.24985	A	20T	7.31Y	121.9	0.00	3.10	1.15	0	8	2	97	0.00	0.0	5.431	0.005	0	0	0	2
PL.24986	PD.3505	A	6 A (CWC)	7.31Y	121.9	0.00	3.10	1.15	1	8	2	97	0.00	0.0	5.455	0.024	8	2	2	2
PL.24907	PL.24932	ABC	#1/0 ACSR	7.31Y	121.9	0.05	3.14	20.69	9	435	132	96	0.14	0.0	5.553	0.127	3	1	1	99
PL.24908	PL.24907	ABC	#1/0 ACSR	7.31Y	121.8	0.03	3.18	20.56	9	432	131	96	0.10	0.0	5.640	0.087	0	0	1	98
PL.24906	PL.24908	ABC	#1/0 ACSR	7.31Y	121.8	0.03	3.20	20.55	9	431	130	96	0.08	0.0	5.710	0.070	10	3	3	97
PL.24983	PL.24906	A	6 A (CWC)	7.31Y	121.8	0.00	3.20	2.04	1	14	4	96	0.00	0.0	5.715	0.005	0	0	0	5
PD.3504	PL.24983	A	20T	7.31Y	121.8	0.00	3.20	2.04	0	14	4	96	0.00	0.0	5.715	0.005	0	0	0	5
PL.24984	PD.3504	A	6 A (CWC)	7.31Y	121.8	0.00	3.21	2.04	1	14	4	96	0.00	0.0	5.747	0.032	2	1	1	5
PL.24905	PL.24984	A	6 A (CWC)	7.31Y	121.8	0.00	3.21	1.78	1	12	4	95	0.00	0.0	5.812	0.066	4	1	1	4
PL.24904	PL.24905	A	6 A (CWC)	7.31Y	121.8	0.00	3.21	1.27	1	9	3	95	0.00	0.0	5.874	0.062	7	2	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24624	PL.24904	A	#4 ACSR	7.31Y	121.8	0.00	3.21	0.29	0	2	1	89	0.00	0.0	5.942	0.068	2	1	2	2
PL.24625	PL.24624	A	#4 ACSR	7.31Y	121.8	0.00	3.21	0.00	0	0	0	100	0.00	0.0	5.995	0.053	0	0	0	0
PL.24585	PL.24906	ABC	#1/0 ACSR	7.31Y	121.8	0.02	3.23	19.41	8	407	123	96	0.07	0.0	5.776	0.066	0	0	0	89
PL.24757	PL.24585	ABC	#1/0 ACSR	7.30Y	121.7	0.04	3.27	16.96	7	356	108	96	0.11	0.0	5.920	0.144	0	0	0	78
PL.24813	PL.24757	ABC	#1/0 ACSR	7.30Y	121.7	0.03	3.30	16.96	7	356	108	96	0.07	0.0	6.015	0.095	0	0	0	78
PL.24950	PL.24813	ABC	#1/0 ACSR	7.30Y	121.7	0.01	3.31	16.96	7	356	108	96	0.02	0.0	6.039	0.024	2	1	1	78
PL.24951	PL.24950	ABC	#1/0 ACSR	7.30Y	121.7	0.02	3.33	16.86	7	354	107	96	0.05	0.0	6.111	0.071	3	1	2	77
PL.24949	PL.24951	ABC	#1/0 ACSR	7.30Y	121.6	0.05	3.38	16.70	7	350	106	96	0.11	0.0	6.265	0.154	0	0	0	75
PL.25007	PL.24949	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	1.87	1	13	4	96	0.00	0.0	6.269	0.005	0	0	0	2
PD.3516	PL.25007	A	20T	7.30Y	121.6	0.00	3.38	1.87	0	13	4	96	0.00	0.0	6.269	0.005	0	0	0	2
PL.25008	PD.3516	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	1.87	1	13	4	96	0.00	0.0	6.347	0.078	13	4	2	2
PL.24759	PL.24949	ABC	#1/0 ACSR	7.30Y	121.6	0.04	3.41	16.08	7	337	102	96	0.09	0.0	6.392	0.128	0	0	0	73
PL.25005	PL.24759	C	6 A (CWC)	7.30Y	121.6	0.00	3.41	1.19	1	8	3	94	0.00	0.0	6.397	0.005	0	0	0	3
PD.3515	PL.25005	C	20T	7.30Y	121.6	0.00	3.41	1.19	0	8	3	94	0.00	0.0	6.397	0.005	0	0	0	3
PL.25006	PD.3515	C	6 A (CWC)	7.29Y	121.6	0.01	3.42	1.19	1	8	3	94	0.00	0.0	6.530	0.133	0	0	1	3
PL.24586	PL.25006	C	#4 ACSR	7.29Y	121.6	0.00	3.42	1.18	1	8	2	97	0.00	0.0	6.605	0.075	8	2	1	1
PL.24587	PL.25006	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.01	0	0	0	100	0.00	0.0	6.614	0.084	0	0	1	1
PL.24947	PL.24759	ABC	#1/0 ACSR	7.29Y	121.6	0.02	3.43	15.24	7	319	96	96	0.03	0.0	6.449	0.057	13	4	1	69
PL.24948	PL.24947	ABC	#1/0 ACSR	7.29Y	121.6	0.00	3.43	14.61	6	306	92	96	0.01	0.0	6.463	0.014	0	0	0	68
PL.24760	PL.24948	ABC	#1/0 ACSR	7.29Y	121.5	0.03	3.46	14.42	6	302	91	96	0.06	0.0	6.575	0.112	0	0	0	67
PL.24761	PL.24760	ABC	#1/0 ACSR	7.29Y	121.5	0.02	3.48	14.18	6	297	90	96	0.05	0.0	6.660	0.085	0	0	0	66
PL.24762	PL.24761	ABC	#1/0 ACSR	7.29Y	121.5	0.04	3.53	14.02	6	294	89	96	0.09	0.0	6.826	0.166	0	0	0	65
PL.24997	PL.24762	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	0.64	0	4	1	97	0.00	0.0	6.831	0.005	0	0	0	2
PD.3511	PL.24997	A	20T	7.29Y	121.5	0.00	3.53	0.64	0	4	1	97	0.00	0.0	6.831	0.005	0	0	0	2
PL.24998	PD.3511	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	0.64	0	4	1	97	0.00	0.0	6.884	0.053	0	0	1	2
PL.24946	PL.24998	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	0.60	0	4	1	97	0.00	0.0	6.927	0.043	4	1	1	1
PL.24763	PL.24762	ABC	#1/0 ACSR	7.29Y	121.5	0.02	3.55	12.96	6	271	82	96	0.04	0.0	6.912	0.086	0	0	0	60
PL.24943	PL.24763	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.56	12.57	5	263	79	96	0.03	0.0	6.981	0.069	3	1	1	59
PL.24944	PL.24943	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.58	12.43	5	260	78	96	0.03	0.0	7.052	0.072	0	0	0	58
PL.24938	PL.24944	B	6 A (CWC)	7.28Y	121.4	0.05	3.62	22.53	16	157	47	96	0.05	0.0	7.097	0.045	7	2	1	34
PL.25054	PL.24938	B	6 A (CWC)	7.28Y	121.4	0.00	3.63	21.46	15	150	45	96	0.00	0.0	7.100	0.003	0	0	0	33

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3539	PL.25054	B	50L	7.28Y	121.4	0.00	3.63	21.46	43	150	45	96	0.00	0.0	7.100	0.003	0	0	0	33
PL.25055	PD.3539	B	6 A (CWC)	7.28Y	121.3	0.08	3.71	21.46	15	150	45	96	0.09	0.1	7.184	0.084	0	0	0	33
PL.24590	PL.25055	B	6 A (CWC)	7.28Y	121.3	0.00	3.71	0.78	1	5	2	93	0.00	0.0	7.264	0.080	5	2	1	1
PL.24831	PL.25055	B	6 A (CWC)	7.27Y	121.2	0.11	3.82	20.68	15	144	43	96	0.12	0.1	7.305	0.121	10	3	1	32
PL.24993	PL.24831	B	#1/0 ACSR	7.27Y	121.2	0.00	3.82	1.19	1	8	2	97	0.00	0.0	7.310	0.005	0	0	0	2
PD.3509	PL.24993	B	20T	7.27Y	121.2	0.00	3.82	1.19	0	8	2	97	0.00	0.0	7.310	0.005	0	0	0	2
PL.24994	PD.3509	B	#1/0 ACSR	7.27Y	121.2	0.00	3.82	1.19	1	8	2	97	0.00	0.0	7.337	0.027	8	2	2	2
PL.24591	PL.24831	B	6 A (CWC)	7.27Y	121.2	0.00	3.82	0.46	0	3	1	95	0.00	0.0	7.365	0.059	3	1	1	2
PL.24592	PL.24591	B	#1/0 ACSR	7.27Y	121.2	0.00	3.82	0.02	0	0	0	100	0.00	0.0	7.407	0.042	0	0	1	1
PL.24832	PL.24831	B	6 A (CWC)	7.27Y	121.1	0.07	3.89	17.63	13	123	37	96	0.07	0.1	7.392	0.087	0	0	0	27
PL.24593	PL.24832	B	6 A (CWC)	7.27Y	121.1	0.02	3.91	2.96	2	21	6	96	0.00	0.0	7.573	0.182	8	2	1	4
PL.24594	PL.24593	B	6 A (CWC)	7.26Y	121.1	0.01	3.92	1.79	1	12	4	95	0.00	0.0	7.668	0.095	0	0	0	3
PL.24767	PL.24594	B	6 A (CWC)	7.26Y	121.1	0.01	3.93	1.79	1	12	4	95	0.00	0.0	7.783	0.114	0	0	0	3
PL.24814	PL.24767	B	6 A (CWC)	7.26Y	121.1	0.01	3.94	1.79	1	12	4	95	0.00	0.0	7.883	0.100	0	0	0	3
PL.24936	PL.24814	B	6 A (CWC)	7.26Y	121.1	0.00	3.94	1.79	1	12	4	95	0.00	0.0	7.959	0.077	6	2	1	3
PL.24937	PL.24936	B	6 A (CWC)	7.26Y	121.1	0.01	3.95	0.93	1	7	2	96	0.00	0.0	8.094	0.135	0	0	0	2
PL.24815	PL.24937	B	6 A (CWC)	7.26Y	121.0	0.01	3.95	0.93	1	7	2	96	0.00	0.0	8.214	0.120	0	0	0	2
PL.24816	PL.24815	B	6 A (CWC)	7.26Y	121.0	0.00	3.96	0.93	1	7	2	96	0.00	0.0	8.296	0.082	0	0	0	2
PL.24768	PL.24816	B	6 A (CWC)	7.26Y	121.0	0.00	3.96	0.36	0	2	1	89	0.00	0.0	8.439	0.143	2	1	1	1
PL.24596	PL.24816	B	6 A (CWC)	7.26Y	121.0	0.00	3.96	0.58	0	4	1	97	0.00	0.0	8.347	0.051	4	1	1	1
PL.24833	PL.24832	B	6 A (CWC)	7.26Y	121.0	0.08	3.97	14.67	10	102	31	96	0.06	0.1	7.513	0.121	10	3	1	23
PL.24829	PL.24833	B	#2 ACSR	7.26Y	121.0	0.00	3.97	1.29	1	9	3	95	0.00	0.0	7.581	0.068	0	0	0	2
PL.24597	PL.24829	B	#2 ACSR	7.26Y	121.0	0.00	3.97	0.24	0	2	1	89	0.00	0.0	7.595	0.014	2	1	1	1
PL.24830	PL.24829	B	#2 ACSR	7.26Y	121.0	0.00	3.97	1.05	1	7	2	96	0.00	0.0	7.639	0.058	7	2	1	1
PL.24834	PL.24833	B	6 A (CWC)	7.26Y	121.0	0.03	4.00	11.91	9	83	25	96	0.02	0.0	7.570	0.057	0	0	0	20
PL.24598	PL.24834	B	#1/0 ACSR	7.26Y	121.0	0.00	4.00	0.93	0	6	2	95	0.00	0.0	7.615	0.045	6	2	1	1
PL.24769	PL.24834	B	6 A (CWC)	7.26Y	121.0	0.04	4.04	10.97	8	76	23	96	0.02	0.0	7.644	0.074	0	0	0	19
PL.24599	PL.24769	B	6 A (CWC)	7.26Y	121.0	0.00	4.04	0.00	0	0	0	100	0.00	0.0	7.699	0.055	0	0	1	1
PL.24660	PL.24769	B	6 A (CWC)	7.26Y	120.9	0.03	4.07	10.97	8	76	23	96	0.02	0.0	7.713	0.069	11	3	1	18
PL.24661	PL.24660	B	6 A (CWC)	7.25Y	120.9	0.05	4.12	9.40	7	65	20	96	0.02	0.0	7.828	0.115	0	0	0	17
PL.24600	PL.24661	B	#4 ACSR	7.25Y	120.9	0.00	4.12	0.86	1	6	2	95	0.00	0.0	7.902	0.073	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24658	PL.24661	B	6 A (CWC)	7.25Y	120.8	0.04	4.16	8.54	6	59	18	96	0.02	0.0	7.940	0.112	4	1	1	16
PL.24659	PL.24658	B	6 A (CWC)	7.25Y	120.8	0.03	4.19	8.00	6	56	17	96	0.01	0.0	8.014	0.074	0	0	0	15
PL.24835	PL.24659	B	6 A (CWC)	7.25Y	120.8	0.03	4.22	8.00	6	56	17	96	0.01	0.0	8.108	0.093	2	1	1	15
PL.24601	PL.24835	B	#1/0 ACSR	7.25Y	120.8	0.00	4.22	0.82	0	6	2	95	0.00	0.0	8.137	0.029	6	2	1	1
PL.24836	PL.24835	B	6 A (CWC)	7.25Y	120.8	0.01	4.24	6.91	5	48	14	96	0.00	0.0	8.149	0.041	0	0	1	13
PL.24602	PL.24836	B	#4 ACSR	7.24Y	120.7	0.02	4.26	6.91	5	48	14	96	0.01	0.0	8.220	0.072	12	4	2	12
PL.24603	PL.24602	B	6 A (CWC)	7.24Y	120.7	0.01	4.27	5.19	4	36	11	96	0.00	0.0	8.266	0.046	0	0	0	10
PL.24770	PL.24603	B	6 A (CWC)	7.24Y	120.7	0.00	4.27	0.53	0	4	1	97	0.00	0.0	8.339	0.072	4	1	1	1
PL.24589	PL.24603	B	6 A (CWC)	7.24Y	120.7	0.02	4.29	4.67	3	32	10	95	0.00	0.0	8.350	0.084	0	0	0	9
PL.24817	PL.24589	B	6 A (CWC)	7.24Y	120.7	0.02	4.31	4.67	3	32	10	95	0.01	0.0	8.445	0.095	0	0	0	9
PL.24964	PL.24817	B	6 A (CWC)	7.24Y	120.7	0.01	4.32	4.67	3	32	10	95	0.00	0.0	8.512	0.067	8	2	1	9
PL.24965	PL.24964	B	6 A (CWC)	7.24Y	120.7	0.00	4.32	3.57	3	25	7	96	0.00	0.0	8.540	0.028	0	0	0	8
PL.24604	PL.24965	B	#4 ACSR	7.24Y	120.7	0.00	4.32	0.19	0	1	0	100	0.00	0.0	8.636	0.096	1	0	1	1
PL.24771	PL.24965	B	6 A (CWC)	7.24Y	120.7	0.02	4.35	3.38	2	23	7	96	0.00	0.0	8.701	0.161	0	0	0	7
PL.24607	PL.24771	B	#4 ACSR	7.24Y	120.7	0.00	4.35	0.55	0	4	1	97	0.00	0.0	8.744	0.043	4	1	2	2
PL.24606	PL.24771	B	#1/0 ACSR	7.24Y	120.7	0.00	4.35	0.12	0	1	0	100	0.00	0.0	8.768	0.068	1	0	1	1
PL.24605	PL.24771	B	#1/0 ACSR	7.24Y	120.7	0.00	4.35	0.43	0	3	1	95	0.00	0.0	8.740	0.040	3	1	1	1
PL.24962	PL.24771	B	6 A (CWC)	7.24Y	120.6	0.01	4.36	2.27	2	16	5	95	0.00	0.0	8.884	0.183	12	4	1	3
PL.24963	PL.24962	B	6 A (CWC)	7.24Y	120.6	0.00	4.36	0.55	0	4	1	97	0.00	0.0	8.901	0.017	1	0	1	2
PL.24608	PL.24963	B	#4 ACSR	7.24Y	120.6	0.00	4.36	0.39	0	3	1	95	0.00	0.0	8.977	0.076	3	1	1	1
PL.25056	PL.24944	C	6 A (CWC)	7.29Y	121.4	0.00	3.58	14.75	11	103	31	96	0.00	0.0	7.055	0.003	0	0	0	24
PD.3540	PL.25056	C	50L	7.29Y	121.4	0.00	3.58	14.75	30	103	31	96	0.00	0.0	7.055	0.003	0	0	0	24
PL.25057	PD.3540	C	6 A (CWC)	7.28Y	121.3	0.10	3.68	14.75	11	103	31	96	0.08	0.1	7.205	0.150	0	0	0	24
PL.24826	PL.25057	C	6 A (CWC)	7.27Y	121.2	0.08	3.76	13.65	10	95	29	96	0.06	0.1	7.336	0.131	2	0	1	22
PL.24941	PL.24826	C	6 A (CWC)	7.27Y	121.2	0.06	3.83	9.61	7	67	20	96	0.03	0.0	7.488	0.152	8	3	2	16
PL.24942	PL.24941	C	6 A (CWC)	7.27Y	121.1	0.03	3.86	8.41	6	59	18	96	0.01	0.0	7.579	0.091	10	3	2	14
PL.24614	PL.24942	C	6 A (CWC)	7.27Y	121.1	0.00	3.86	0.47	0	3	1	95	0.00	0.0	7.683	0.104	3	1	1	1
PL.24823	PL.24942	C	6 A (CWC)	7.27Y	121.1	0.02	3.88	6.53	5	45	14	95	0.01	0.0	7.647	0.068	0	0	0	11
PL.24939	PL.24823	C	6 A (CWC)	7.27Y	121.1	0.03	3.91	5.59	4	39	12	96	0.01	0.0	7.807	0.161	18	5	1	10
PL.24940	PL.24939	C	6 A (CWC)	7.26Y	121.1	0.01	3.92	3.01	2	21	6	96	0.00	0.0	7.895	0.088	0	0	0	9
PL.24616	PL.24940	C	#4 ACSR	7.26Y	121.1	0.00	3.92	0.16	0	1	0	100	0.00	0.0	7.927	0.031	1	0	4	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24766	PL.24940	C	6 A (CWC)	7.26Y	121.1	0.02	3.94	2.68	2	19	6	95	0.00	0.0	8.035	0.140	0	0	0	4
PL.24617	PL.24766	C	6 A (CWC)	7.26Y	121.1	0.00	3.94	0.43	0	3	1	95	0.00	0.0	8.095	0.061	3	1	1	1
PL.24619	PL.24766	C	#4 ACSR	7.26Y	121.1	0.00	3.95	1.13	1	8	2	97	0.00	0.0	8.193	0.158	8	2	1	1
PL.24618	PL.24766	C	#4 ACSR	7.26Y	121.1	0.00	3.94	1.12	1	8	2	97	0.00	0.0	8.077	0.042	8	2	2	2
PL.24615	PL.24940	C	6 A (CWC)	7.26Y	121.1	0.00	3.92	0.18	0	1	0	100	0.00	0.0	7.981	0.086	1	0	1	1
PL.24613	PL.24823	C	#4 ACSR	7.27Y	121.1	0.00	3.88	0.94	1	7	2	96	0.00	0.0	7.665	0.019	7	2	1	1
PL.24610	PL.24826	C	6 A (CWC)	7.27Y	121.2	0.01	3.78	3.81	3	27	8	96	0.00	0.0	7.420	0.084	0	0	0	5
PL.24611	PL.24610	C	6 A (CWC)	7.27Y	121.2	0.00	3.78	1.95	1	14	4	96	0.00	0.0	7.470	0.050	14	4	1	1
PL.24764	PL.24610	C	6 A (CWC)	7.27Y	121.2	0.00	3.78	1.86	1	13	4	96	0.00	0.0	7.467	0.047	2	1	1	4
PL.24643	PL.24764	C	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.60	1	11	3	96	0.00	0.0	7.561	0.094	0	0	0	3
PL.24612	PL.24643	C	#1/0 ACSR	7.27Y	121.2	0.00	3.79	0.39	0	3	1	95	0.00	0.0	7.618	0.058	3	1	1	1
PL.24765	PL.24643	C	#1/0 ACSR	7.27Y	121.2	0.00	3.79	1.21	1	8	3	94	0.00	0.0	7.689	0.128	8	3	2	2
PL.24609	PL.25057	C	6 A (CWC)	7.28Y	121.3	0.00	3.69	1.10	1	8	2	97	0.00	0.0	7.302	0.097	1	0	1	2
PL.24642	PL.24609	C	#1/0 ACSR	7.28Y	121.3	0.00	3.69	0.97	0	7	2	96	0.00	0.0	7.383	0.081	7	2	1	1
PL.24995	PL.24763	C	6 A (CWC)	7.29Y	121.5	0.00	3.55	1.16	1	8	2	97	0.00	0.0	6.916	0.005	0	0	0	1
PD.3510	PL.24995	C	20T	7.29Y	121.5	0.00	3.55	1.16	0	8	2	97	0.00	0.0	6.916	0.005	0	0	0	1
PL.24996	PD.3510	C	6 A (CWC)	7.29Y	121.5	0.00	3.55	1.16	1	8	2	97	0.00	0.0	6.968	0.051	8	2	1	1
PL.25038	PL.24762	C	6 A (CWC)	7.29Y	121.5	0.00	3.53	2.55	2	18	5	96	0.00	0.0	6.831	0.005	0	0	0	3
PD.3531	PL.25038	C	20T	7.29Y	121.5	0.00	3.53	2.55	0	18	5	96	0.00	0.0	6.831	0.005	0	0	0	3
PL.25039	PD.3531	C	6 A (CWC)	7.29Y	121.5	0.01	3.53	2.55	2	18	5	96	0.00	0.0	6.877	0.047	0	0	0	3
PL.24945	PL.25039	C	6 A (CWC)	7.29Y	121.5	0.01	3.54	2.55	2	18	5	96	0.00	0.0	6.991	0.114	5	2	1	3
PL.24588	PL.24945	C	#1/0 ACSR	7.29Y	121.5	0.00	3.55	1.78	1	12	4	95	0.00	0.0	7.039	0.047	12	4	2	2
PL.24999	PL.24761	A	6 A (CWC)	7.29Y	121.5	0.00	3.48	0.47	0	3	1	95	0.00	0.0	6.665	0.005	0	0	0	1
PD.3512	PL.24999	A	20T	7.29Y	121.5	0.00	3.48	0.47	0	3	1	95	0.00	0.0	6.665	0.005	0	0	0	1
PL.25000	PD.3512	A	6 A (CWC)	7.29Y	121.5	0.00	3.48	0.47	0	3	1	95	0.00	0.0	6.687	0.022	3	1	1	1
PL.25001	PL.24760	C	6 A (CWC)	7.29Y	121.5	0.00	3.46	0.74	1	5	2	93	0.00	0.0	6.580	0.005	0	0	0	1
PD.3513	PL.25001	C	20T	7.29Y	121.5	0.00	3.46	0.74	0	5	2	93	0.00	0.0	6.580	0.005	0	0	0	1
PL.25002	PD.3513	C	6 A (CWC)	7.29Y	121.5	0.00	3.46	0.74	1	5	2	93	0.00	0.0	6.606	0.026	5	2	1	1
PL.25003	PL.24948	C	#1/0 ACSR	7.29Y	121.6	0.00	3.43	0.56	0	4	1	97	0.00	0.0	6.467	0.005	0	0	0	1
PD.3514	PL.25003	C	20T	7.29Y	121.6	0.00	3.43	0.56	0	4	1	97	0.00	0.0	6.467	0.005	0	0	0	1
PL.25004	PD.3514	C	#1/0 ACSR	7.29Y	121.6	0.00	3.43	0.56	0	4	1	97	0.00	0.0	6.514	0.047	4	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.25036	PL.24759	A	6 A (CWC)	7.30Y	121.6	0.00	3.41	1.31	1	9	3	95	0.00	0.0	6.397	0.005	0	0	0	1
PD.3530	PL.25036	A	20T	7.30Y	121.6	0.00	3.41	1.31	0	9	3	95	0.00	0.0	6.397	0.005	0	0	0	1
PL.25037	PD.3530	A	6 A (CWC)	7.29Y	121.6	0.01	3.42	1.31	1	9	3	95	0.00	0.0	6.574	0.177	9	3	1	1
PL.25012	PL.24585	C	6 A (CWC)	7.31Y	121.8	0.00	3.23	4.65	3	33	10	96	0.00	0.0	5.781	0.005	0	0	0	8
PD.3517	PL.25012	C	20T	7.31Y	121.8	0.00	3.23	4.65	0	33	10	96	0.00	0.0	5.781	0.005	0	0	0	8
PL.25013	PD.3517	C	6 A (CWC)	7.31Y	121.8	0.01	3.23	4.65	3	33	10	96	0.00	0.0	5.816	0.035	0	0	0	8
PL.24758	PL.25013	C	6 A (CWC)	7.31Y	121.8	0.00	3.24	0.59	0	4	1	97	0.00	0.0	5.870	0.054	4	1	2	2
PL.24955	PL.25013	C	#2 ACSR	7.31Y	121.8	0.00	3.24	4.06	2	28	9	95	0.00	0.0	5.828	0.012	9	3	1	6
PL.24956	PL.24955	C	#2 ACSR	7.31Y	121.8	0.00	3.24	2.84	2	20	6	96	0.00	0.0	5.897	0.069	10	3	1	5
PL.24623	PL.24956	C	6 A (CWC)	7.31Y	121.8	0.00	3.24	1.37	1	10	3	96	0.00	0.0	5.957	0.060	4	1	2	4
PL.24953	PL.24623	C	#4 ACSR	7.31Y	121.8	0.00	3.25	0.83	1	6	2	95	0.00	0.0	6.025	0.067	1	0	1	2
PL.24954	PL.24953	C	#4 ACSR	7.31Y	121.8	0.00	3.25	0.70	1	5	1	98	0.00	0.0	6.083	0.058	5	1	1	1
PL.25034	PL.24585	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	2.69	2	19	6	95	0.00	0.0	5.781	0.004	0	0	0	3
PD.3529	PL.25034	A	20T	7.31Y	121.8	0.00	3.23	2.69	0	19	6	95	0.00	0.0	5.781	0.004	0	0	0	3
PL.25035	PD.3529	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	2.69	2	19	6	95	0.00	0.0	5.843	0.062	19	6	2	3
PL.24952	PL.25035	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	5.930	0.087	0	0	0	1
PL.24812	PL.24952	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	6.040	0.110	0	0	1	1
PL.25032	PL.25061	A	6 A (CWC)	7.32Y	122.0	0.00	3.00	4.18	3	29	9	96	0.00	0.0	5.173	0.004	0	0	0	6
PD.3528	PL.25032	A	20T	7.32Y	122.0	0.00	3.00	4.18	0	29	9	96	0.00	0.0	5.173	0.004	0	0	0	6
PL.25033	PD.3528	A	6 A (CWC)	7.32Y	122.0	0.01	3.01	4.18	3	29	9	96	0.00	0.0	5.243	0.071	0	0	0	6
PL.24579	PL.25033	A	6 A (CWC)	7.32Y	122.0	0.01	3.02	3.76	3	26	8	96	0.00	0.0	5.322	0.079	5	2	1	5
PL.24583	PL.24579	A	#4 ACSR	7.32Y	122.0	0.01	3.03	3.01	2	21	6	96	0.00	0.0	5.364	0.041	0	0	0	4
PL.24808	PL.24583	A	#4 ACSR	7.32Y	121.9	0.03	3.05	3.01	2	21	6	96	0.00	0.0	5.551	0.188	0	0	0	4
PL.24581	PL.24808	A	#4 ACSR	7.32Y	121.9	0.00	3.06	1.33	1	9	3	95	0.00	0.0	5.662	0.111	9	3	1	1
PL.24754	PL.24808	A	#4 ACSR	7.32Y	121.9	0.01	3.06	1.67	1	12	4	95	0.00	0.0	5.677	0.126	0	0	1	3
PL.24810	PL.24754	A	#4 ACSR	7.32Y	121.9	0.01	3.07	1.66	1	12	4	95	0.00	0.0	5.827	0.150	0	0	0	2
PL.24809	PL.24810	A	#4 ACSR	7.32Y	121.9	0.01	3.08	1.66	1	12	4	95	0.00	0.0	5.897	0.070	0	0	0	2
PL.24580	PL.24809	A	#1/0 ACSR	7.31Y	121.9	0.00	3.08	1.66	1	12	4	95	0.00	0.0	6.011	0.114	0	0	0	2
PL.24909	PL.24580	A	#1/0 ACSR	7.31Y	121.9	0.00	3.09	1.66	1	12	4	95	0.00	0.0	6.125	0.113	2	1	1	2
PL.24910	PL.24909	A	#1/0 ACSR	7.31Y	121.9	0.00	3.09	1.32	1	9	3	95	0.00	0.0	6.281	0.157	0	0	0	1
PL.24811	PL.24910	A	#1/0 ACSR	7.31Y	121.9	0.00	3.09	1.32	1	9	3	95	0.00	0.0	6.349	0.067	9	3	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24755	PL.24809	A	#4 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	5.912	0.015	0	0	0	0
PL.24645	PL.24755	A	#4 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	6.028	0.116	0	0	0	0
PL.24582	PL.25033	A	#2 ACSR	7.32Y	122.0	0.00	3.01	0.42	0	3	1	95	0.00	0.0	5.262	0.019	3	1	1	1
PL.24989	PL.25061	A	6 A (CWC)	7.32Y	122.0	0.01	3.00	31.42	22	220	66	96	0.01	0.0	5.173	0.004	0	0	0	43
PD.3507	PL.24989	A	20T	7.32Y	122.0	0.00	3.00	31.42	0	220	66	96	0.00	0.0	5.173	0.004	0	0	0	43
PL.24990	PD.3507	A	6 A (CWC)	7.32Y	122.0	0.05	3.05	31.42	22	220	66	96	0.08	0.0	5.204	0.032	2	1	1	43
PL.24933	PL.24990	A	6 A (CWC)	7.31Y	121.9	0.10	3.15	31.13	22	218	66	96	0.16	0.1	5.273	0.069	0	0	0	42
PL.24756	PL.24933	A	6 A (CWC)	7.31Y	121.8	0.02	3.16	29.42	21	206	62	96	0.02	0.0	5.285	0.012	9	3	1	39
PL.24925	PL.24756	A	6 A (CWC)	7.30Y	121.7	0.09	3.25	28.17	20	197	59	96	0.13	0.1	5.356	0.072	7	2	2	38
PL.24926	PL.24925	A	6 A (CWC)	7.30Y	121.7	0.05	3.30	27.13	19	190	57	96	0.07	0.0	5.397	0.041	23	7	3	36
PL.24628	PL.24926	A	6 A (CWC)	7.30Y	121.6	0.10	3.41	15.12	11	106	32	96	0.08	0.1	5.548	0.151	0	0	0	25
PL.24911	PL.24628	A	6 A (CWC)	7.30Y	121.6	0.01	3.41	1.39	1	10	3	96	0.00	0.0	5.666	0.118	2	0	1	3
PL.24912	PL.24911	A	6 A (CWC)	7.29Y	121.6	0.00	3.42	1.17	1	8	2	97	0.00	0.0	5.797	0.131	8	2	2	2
PL.24923	PL.24628	A	6 A (CWC)	7.29Y	121.6	0.03	3.44	13.73	10	96	29	96	0.02	0.0	5.597	0.049	0	0	0	22
PL.24924	PL.24923	A	6 A (CWC)	7.29Y	121.5	0.09	3.53	13.73	10	96	29	96	0.06	0.1	5.738	0.141	0	0	0	22
PL.24634	PL.24924	A	6 A (CWC)	7.28Y	121.3	0.13	3.65	12.58	9	88	26	96	0.08	0.1	5.955	0.217	0	0	0	21
PL.24633	PL.24634	A	6 A (CWC)	7.28Y	121.3	0.01	3.66	2.41	2	17	5	96	0.00	0.0	6.034	0.079	0	0	0	5
PL.24636	PL.24633	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.27	0	2	1	89	0.00	0.0	6.119	0.085	2	1	1	1
PL.24914	PL.24633	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.41	0	3	1	95	0.00	0.0	6.143	0.109	0	0	1	3
PL.24915	PL.24914	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.41	0	3	1	95	0.00	0.0	6.211	0.068	1	0	1	2
PL.24913	PL.24915	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.25	0	2	1	89	0.00	0.0	6.298	0.087	2	1	1	1
PL.24637	PL.24633	A	#4 ACSR	7.28Y	121.3	0.00	3.66	1.74	1	12	4	95	0.00	0.0	6.082	0.048	12	4	1	1
PL.24635	PL.24634	A	6 A (CWC)	7.28Y	121.3	0.03	3.68	10.16	7	71	21	96	0.01	0.0	6.011	0.056	0	0	0	16
PL.24638	PL.24635	A	6 A (CWC)	7.28Y	121.3	0.06	3.74	7.84	6	55	16	96	0.03	0.0	6.198	0.188	7	2	2	14
PL.24639	PL.24638	A	6 A (CWC)	7.28Y	121.3	0.00	3.74	1.02	1	7	2	96	0.00	0.0	6.262	0.064	7	2	2	2
PL.24919	PL.24638	A	#4 ACSR	7.27Y	121.2	0.01	3.75	5.86	5	41	12	96	0.00	0.0	6.239	0.040	8	2	1	10
PL.24920	PL.24919	A	#4 ACSR	7.27Y	121.2	0.01	3.76	4.76	4	33	10	96	0.00	0.0	6.293	0.054	5	2	4	9
PL.24640	PL.24920	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	0.60	0	4	1	97	0.00	0.0	6.358	0.064	4	1	2	2
PL.24917	PL.24920	A	#4 ACSR	7.27Y	121.2	0.01	3.77	3.43	3	24	7	96	0.00	0.0	6.341	0.048	9	3	1	3
PL.24918	PL.24917	A	#4 ACSR	7.27Y	121.2	0.01	3.77	2.14	2	15	4	97	0.00	0.0	6.412	0.071	7	2	1	2
PL.24916	PL.24918	A	#4 ACSR	7.27Y	121.2	0.00	3.77	1.12	1	8	2	97	0.00	0.0	6.465	0.054	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24921	PL.24635	A	#2 ACSR	7.28Y	121.3	0.00	3.68	2.32	1	16	5	95	0.00	0.0	6.027	0.016	13	4	1	2
PL.24922	PL.24921	A	#2 ACSR	7.28Y	121.3	0.00	3.68	0.52	0	4	1	97	0.00	0.0	6.104	0.078	4	1	1	1
PL.24632	PL.24634	A	#4 ACSR	7.28Y	121.3	0.00	3.65	0.00	0	0	0	100	0.00	0.0	6.010	0.055	0	0	0	0
PL.24641	PL.24924	A	#4 ACSR	7.29Y	121.5	0.00	3.53	1.15	1	8	2	97	0.00	0.0	5.797	0.060	8	2	1	1
PL.24626	PL.24926	A	#4 ACSR	7.30Y	121.7	0.04	3.34	8.68	7	61	18	96	0.02	0.0	5.495	0.098	9	3	1	8
PL.24629	PL.24626	A	#2 ACSR	7.30Y	121.7	0.01	3.34	2.47	1	17	5	96	0.00	0.0	5.617	0.122	8	2	1	2
PL.24630	PL.24629	A	#2 ACSR	7.30Y	121.7	0.00	3.34	1.34	1	9	3	95	0.00	0.0	5.654	0.037	9	3	1	1
PL.24927	PL.24626	A	#2 ACSR	7.30Y	121.7	0.01	3.34	4.96	3	35	10	96	0.00	0.0	5.546	0.051	21	6	2	5
PL.24928	PL.24927	A	#2 ACSR	7.30Y	121.7	0.00	3.35	1.93	1	13	4	96	0.00	0.0	5.602	0.055	2	0	1	3
PL.24631	PL.24928	A	#4 ACSR	7.30Y	121.7	0.00	3.35	1.08	1	8	2	97	0.00	0.0	5.727	0.125	8	2	1	1
PL.24929	PL.24928	A	#2 ACSR	7.30Y	121.7	0.00	3.35	0.62	0	4	1	97	0.00	0.0	5.668	0.067	0	0	0	1
PL.24930	PL.24929	A	#2 ACSR	7.30Y	121.7	0.00	3.35	0.62	0	4	1	97	0.00	0.0	5.715	0.046	4	1	1	1
PL.24627	PL.24926	A	#2 ACSR	7.30Y	121.7	0.00	3.30	0.00	0	0	0	100	0.00	0.0	5.483	0.086	0	0	0	0
PL.24584	PL.24933	A	6 A (CWC)	7.31Y	121.9	0.00	3.15	1.71	1	12	4	95	0.00	0.0	5.314	0.041	12	4	3	3
CP.36	PL.25060	ABC	Cap (300)	7.32Y	122.1	0.00	2.95	0.00	0	0	0	100	0.00	0.0	5.086	0.041	0	0	0	0
PL.24991	PL.24807	C	6 A (CWC)	7.33Y	122.2	0.00	2.80	1.44	1	10	3	96	0.00	0.0	4.853	0.005	0	0	0	2
PD.3508	PL.24991	C	20T	7.33Y	122.2	0.00	2.80	1.44	0	10	3	96	0.00	0.0	4.853	0.005	0	0	0	2
PL.24992	PD.3508	C	6 A (CWC)	7.33Y	122.2	0.00	2.80	1.44	1	10	3	96	0.00	0.0	4.953	0.100	10	3	2	2
PL.24578	PL.24805	A	6 A (CWC)	7.34Y	122.3	0.04	2.72	5.11	4	36	11	96	0.01	0.0	4.830	0.191	0	0	0	6
PL.24806	PL.24578	A	6 A (CWC)	7.34Y	122.3	0.00	2.72	5.11	4	36	11	96	0.00	0.0	4.835	0.005	0	0	0	6
PD.3503	PL.24806	A	20T	7.34Y	122.3	0.00	2.72	5.11	0	36	11	96	0.00	0.0	4.835	0.005	0	0	0	6
PL.24750	PD.3503	A	6 A (CWC)	7.34Y	122.3	0.02	2.74	5.11	4	36	11	96	0.00	0.0	4.913	0.078	0	0	0	6
PL.24621	PL.24750	A	6 A (CWC)	7.34Y	122.3	0.00	2.74	0.72	1	5	2	93	0.00	0.0	4.938	0.024	5	2	2	2
PL.24622	PL.24750	A	6 A (CWC)	7.33Y	122.2	0.02	2.75	4.28	3	30	9	96	0.00	0.0	4.998	0.084	0	0	0	3
PL.24752	PL.24622	A	6 A (CWC)	7.33Y	122.2	0.00	2.76	1.04	1	7	2	96	0.00	0.0	5.164	0.166	7	2	1	1
PL.24644	PL.24622	A	#4 ACSR	7.33Y	122.2	0.02	2.77	3.24	2	23	7	96	0.00	0.0	5.145	0.147	12	4	1	2
PL.24772	PL.24644	A	#4 ACSR	7.33Y	122.2	0.00	2.77	1.52	1	11	3	96	0.00	0.0	5.198	0.053	11	3	1	1
PL.24751	PL.24750	A	6 A (CWC)	7.34Y	122.3	0.00	2.74	0.11	0	1	0	100	0.00	0.0	4.996	0.083	1	0	1	1
PL.24620	PD.3503	A	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	4.963	0.128	0	0	0	0
PL.25028	PL.24841	A	#1/0 ACSR	7.37Y	122.9	0.00	2.11	0.07	0	0	0	100	0.00	0.0	3.846	0.005	0	0	0	1
PD.3526	PL.25028	A	65T	7.37Y	122.9	0.00	2.11	0.07	0	0	0	100	0.00	0.0	3.846	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.25029	PD.3526	A	#1/0 ACSR	7.37Y	122.9	0.00	2.11	0.07	0	0	0	100	0.00	0.0	3.890	0.044	0	0	1	1
PL.25050	PL.24841	C	6 A (CWC)	7.37Y	122.9	0.00	2.11	11.00	8	78	23	96	0.00	0.0	3.844	0.003	0	0	0	21
PD.3537	PL.25050	C	50L	7.37Y	122.9	0.00	2.11	11.00	22	78	23	96	0.00	0.0	3.844	0.003	0	0	0	21
PL.25051	PD.3537	C	6 A (CWC)	7.37Y	122.8	0.09	2.20	11.00	8	78	23	96	0.05	0.1	4.019	0.175	0	0	0	21
PL.24744	PL.25051	C	6 A (CWC)	7.37Y	122.8	0.00	2.20	1.14	1	8	2	97	0.00	0.0	4.089	0.070	8	2	1	1
PL.24546	PL.25051	C	6 A (CWC)	7.37Y	122.8	0.04	2.25	9.86	7	70	21	96	0.02	0.0	4.118	0.099	0	0	0	20
PL.24788	PL.24546	C	6 A (CWC)	7.36Y	122.7	0.04	2.29	9.86	7	70	21	96	0.02	0.0	4.211	0.093	0	0	0	20
PL.24563	PL.24788	C	6 A (CWC)	7.36Y	122.7	0.04	2.33	9.86	7	70	21	96	0.02	0.0	4.304	0.093	0	0	0	20
PL.24820	PL.24563	C	6 A (CWC)	7.36Y	122.6	0.05	2.38	9.86	7	70	21	96	0.02	0.0	4.407	0.103	0	0	0	20
PL.24789	PL.24820	C	6 A (CWC)	7.35Y	122.6	0.04	2.42	9.86	7	69	21	96	0.02	0.0	4.503	0.096	0	0	0	20
PL.24821	PL.24789	C	6 A (CWC)	7.35Y	122.5	0.05	2.47	9.86	7	69	21	96	0.02	0.0	4.602	0.099	0	0	0	20
PL.24790	PL.24821	C	6 A (CWC)	7.35Y	122.5	0.04	2.51	9.86	7	69	21	96	0.02	0.0	4.699	0.096	0	0	0	20
PL.24822	PL.24790	C	6 A (CWC)	7.35Y	122.4	0.06	2.57	9.86	7	69	21	96	0.03	0.0	4.829	0.130	0	0	0	20
PL.24562	PL.24822	C	6 A (CWC)	7.34Y	122.4	0.02	2.59	8.72	6	61	18	96	0.01	0.0	4.887	0.058	0	0	0	18
PL.24653	PL.24562	C	#4 ACSR	7.34Y	122.4	0.01	2.60	8.72	7	61	18	96	0.00	0.0	4.907	0.020	0	0	0	18
PL.24559	PL.24653	C	#4 ACSR	7.34Y	122.3	0.05	2.65	8.72	7	61	18	96	0.02	0.0	5.032	0.124	0	0	0	18
PL.24558	PL.24559	C	#4 ACSR	7.34Y	122.3	0.04	2.69	6.29	5	44	13	96	0.01	0.0	5.184	0.153	9	3	1	14
PL.24560	PL.24558	C	#4 ACSR	7.34Y	122.3	0.00	2.69	0.50	0	3	1	95	0.00	0.0	5.252	0.067	0	0	0	6
PL.24561	PL.24560	C	#4 ACSR	7.34Y	122.3	0.00	2.69	0.19	0	1	0	100	0.00	0.0	5.330	0.078	1	0	2	4
PL.25014	PL.24561	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.334	0.005	0	0	0	2
PD.3519	PL.25014	C	20T	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.334	0.005	0	0	0	2
PL.25015	PD.3519	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.474	0.139	0	0	0	2
PL.24792	PL.25015	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.590	0.116	0	0	0	2
PL.24819	PL.24792	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.664	0.074	0	0	0	2
PL.24793	PL.24819	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.822	0.157	0	0	0	2
PL.24794	PL.24793	C	#1/0 ACSR	7.34Y	122.3	0.00	2.69	0.07	0	1	0	100	0.00	0.0	5.887	0.066	1	0	2	2
PL.24745	PL.24794	C	#4 ACSR	7.34Y	122.3	0.00	2.69	0.31	0	2	1	89	0.00	0.0	5.372	0.120	2	1	2	2
PL.24554	PL.24745	C	#4 ACSR	7.34Y	122.3	0.02	2.70	4.51	3	32	10	95	0.00	0.0	5.263	0.079	0	0	0	7
PL.24556	PL.24554	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	4.51	2	32	10	95	0.00	0.0	5.268	0.005	0	0	0	7
PD.3518	PL.24556	C	20T	7.34Y	122.3	0.00	2.71	4.51	0	32	10	95	0.00	0.0	5.268	0.005	0	0	0	7
PL.24960	PD.3518	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	3.67	2	26	8	96	0.00	0.0	5.304	0.036	13	4	1	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24961	PL.24960	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	1.87	1	13	4	96	0.00	0.0	5.360	0.055	2	0	1	5
PL.24959	PL.24961	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	1.64	1	12	3	97	0.00	0.0	5.399	0.040	0	0	0	4
PL.24957	PL.24959	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	1.64	1	11	3	96	0.00	0.0	5.513	0.114	6	2	2	3
PL.24958	PL.24957	C	#1/0 ACSR	7.34Y	122.3	0.00	2.72	0.84	0	6	2	95	0.00	0.0	5.562	0.048	6	2	1	1
PL.24557	PL.24959	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	0.00	0	0	0	100	0.00	0.0	5.511	0.111	0	0	1	1
PL.24555	PD.3518	C	#1/0 ACSR	7.34Y	122.3	0.00	2.71	0.84	0	6	2	95	0.00	0.0	5.356	0.088	6	2	1	1
PL.24552	PL.24559	C	6 A (CWC)	7.34Y	122.3	0.01	2.66	2.43	2	17	5	96	0.00	0.0	5.145	0.113	9	3	1	4
PL.24553	PL.24552	C	6 A (CWC)	7.34Y	122.3	0.00	2.66	1.13	1	8	2	97	0.00	0.0	5.199	0.054	0	0	0	3
PL.25046	PL.24553	C	6 A (CWC)	7.34Y	122.3	0.00	2.66	1.13	1	8	2	97	0.00	0.0	5.203	0.005	0	0	0	3
PD.3535	PL.25046	C	20T	7.34Y	122.3	0.00	2.66	1.13	0	8	2	97	0.00	0.0	5.203	0.005	0	0	0	3
PL.25047	PD.3535	C	6 A (CWC)	7.34Y	122.3	0.00	2.67	1.13	1	8	2	97	0.00	0.0	5.331	0.128	7	2	2	3
PL.24551	PL.25047	C	#2 ACSR	7.34Y	122.3	0.00	2.67	0.08	0	1	0	100	0.00	0.0	5.408	0.077	1	0	1	1
PL.24662	PL.24822	C	#4 ACSR	7.35Y	122.4	0.00	2.57	1.14	1	8	2	97	0.00	0.0	4.834	0.005	0	0	0	2
PD.3476	PL.24662	C	20T	7.35Y	122.4	0.00	2.57	1.14	0	8	2	97	0.00	0.0	4.834	0.005	0	0	0	2
PL.24663	PD.3476	C	#4 ACSR	7.35Y	122.4	0.01	2.58	1.14	1	8	2	97	0.00	0.0	4.960	0.126	0	0	0	2
PL.24818	PL.24663	C	#4 ACSR	7.34Y	122.4	0.01	2.59	1.14	1	8	2	97	0.00	0.0	5.121	0.162	0	0	0	2
PL.24791	PL.24818	C	#4 ACSR	7.34Y	122.4	0.01	2.59	1.14	1	8	2	97	0.00	0.0	5.240	0.119	0	0	0	2
PL.24857	PL.24791	C	#4 ACSR	7.34Y	122.4	0.01	2.60	1.14	1	8	2	97	0.00	0.0	5.367	0.127	0	0	1	2
PL.24858	PL.24857	C	#4 ACSR	7.34Y	122.4	0.00	2.60	1.13	1	8	2	97	0.00	0.0	5.523	0.156	8	2	1	1
PL.24696	PL.24843	A	6 A (CWC)	7.40Y	123.3	0.00	1.66	2.44	2	17	5	96	0.00	0.0	3.375	0.005	0	0	0	5
PD.3493	PL.24696	A	15T	7.40Y	123.3	0.00	1.66	2.44	0	17	5	96	0.00	0.0	3.375	0.005	0	0	0	5
PL.24966	PD.3493	A	6 A (CWC)	7.40Y	123.3	0.00	1.67	2.44	2	17	5	96	0.00	0.0	3.416	0.041	3	1	2	5
PL.24896	PL.24966	A	6 A (CWC)	7.40Y	123.3	0.01	1.68	1.95	1	14	4	96	0.00	0.0	3.578	0.162	3	1	1	3
PL.24893	PL.24896	A	6 A (CWC)	7.40Y	123.3	0.00	1.68	1.56	1	11	3	96	0.00	0.0	3.635	0.058	4	1	1	2
PL.24541	PL.24893	A	#2 ACSR	7.40Y	123.3	0.00	1.69	1.02	1	7	2	96	0.00	0.0	3.687	0.051	7	2	1	1
PL.24969	PL.24844	C	#2 ACSR	7.41Y	123.5	0.00	1.53	1.11	1	8	2	97	0.00	0.0	3.244	0.005	0	0	0	1
PD.3495	PL.24969	C	65T	7.41Y	123.5	0.00	1.53	1.11	0	8	2	97	0.00	0.0	3.244	0.005	0	0	0	1
PL.24970	PD.3495	C	#2 ACSR	7.41Y	123.5	0.00	1.54	1.11	1	8	2	97	0.00	0.0	3.303	0.059	8	2	1	1
PL.24973	PL.24866	A	#1/0 ACSR	7.43Y	123.9	0.00	1.10	1.53	1	11	3	96	0.00	0.0	2.676	0.005	0	0	0	2
PD.3497	PL.24973	A	65T	7.43Y	123.9	0.00	1.10	1.53	0	11	3	96	0.00	0.0	2.676	0.005	0	0	0	2
PL.24974	PD.3497	A	#1/0 ACSR	7.43Y	123.9	0.00	1.10	1.53	1	11	3	96	0.00	0.0	2.705	0.029	11	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24670	PL.24850	A	#1/0 ACSR	7.44Y	124.0	0.00	0.96	1.66	1	12	4	95	0.00	0.0	2.401	0.005	0	0	0	1
PD.3480	PL.24670	A	65T	7.44Y	124.0	0.00	0.96	1.66	0	12	4	95	0.00	0.0	2.401	0.005	0	0	0	1
PL.24671	PD.3480	A	#1/0 ACSR	7.44Y	124.0	0.00	0.96	1.66	1	12	4	95	0.00	0.0	2.425	0.024	12	4	1	1
PL.24668	PL.24738	C	#2 ACSR	7.44Y	124.1	0.00	0.92	0.82	0	6	2	95	0.00	0.0	2.324	0.005	0	0	0	1
PD.3479	PL.24668	C	65T	7.44Y	124.1	0.00	0.92	0.82	0	6	2	95	0.00	0.0	2.324	0.005	0	0	0	1
PL.24669	PD.3479	C	#2 ACSR	7.44Y	124.1	0.00	0.92	0.82	0	6	2	95	0.00	0.0	2.346	0.021	6	2	1	1
PL.24682	PL.24737	A	#2 ACSR	7.45Y	124.1	0.00	0.89	0.57	0	4	1	97	0.00	0.0	2.263	0.005	0	0	0	1
PD.3486	PL.24682	A	65T	7.45Y	124.1	0.00	0.89	0.57	0	4	1	97	0.00	0.0	2.263	0.005	0	0	0	1
PL.24683	PD.3486	A	#2 ACSR	7.45Y	124.1	0.00	0.89	0.57	0	4	1	97	0.00	0.0	2.334	0.071	4	1	1	1
PL.24680	PL.24852	C	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.24	0	2	1	89	0.00	0.0	2.222	0.005	0	0	0	1
PD.3485	PL.24680	C	65T	7.45Y	124.1	0.00	0.87	0.24	0	2	1	89	0.00	0.0	2.222	0.005	0	0	0	1
PL.24681	PD.3485	C	#1/0 ACSR	7.45Y	124.1	0.00	0.87	0.24	0	2	1	89	0.00	0.0	2.240	0.018	2	1	1	1
PL.24678	PL.24872	A	#1/0 ACSR	7.45Y	124.2	0.00	0.82	0.54	0	4	1	97	0.00	0.0	2.131	0.005	0	0	0	2
PD.3484	PL.24678	A	65T	7.45Y	124.2	0.00	0.82	0.54	0	4	1	97	0.00	0.0	2.131	0.005	0	0	0	2
PL.24679	PD.3484	A	#1/0 ACSR	7.45Y	124.2	0.00	0.82	0.54	0	4	1	97	0.00	0.0	2.159	0.028	4	1	2	2
PL.25040	PL.24856	A	#1/0 ACSR	7.46Y	124.3	0.00	0.74	0.00	0	0	0	100	0.00	0.0	1.965	0.005	0	0	0	1
PD.3532	PL.25040	A	65T	7.46Y	124.3	0.00	0.74	0.00	0	0	0	100	0.00	0.0	1.965	0.005	0	0	0	1
PL.25041	PD.3532	A	#1/0 ACSR	7.46Y	124.3	0.00	0.74	0.00	0	0	0	100	0.00	0.0	1.996	0.031	0	0	1	1
PL.24676	PL.24870	A	#1/0 ACSR	7.46Y	124.3	0.00	0.70	1.24	1	9	3	95	0.00	0.0	1.904	0.005	0	0	0	2
PD.3483	PL.24676	A	65T	7.46Y	124.3	0.00	0.70	1.24	0	9	3	95	0.00	0.0	1.904	0.005	0	0	0	2
PL.24677	PD.3483	A	#1/0 ACSR	7.46Y	124.3	0.00	0.70	1.24	1	9	3	95	0.00	0.0	1.982	0.078	9	3	2	2
PL.24534	PL.24677	A	6 A (CWC)	7.46Y	124.3	0.00	0.70	0.00	0	0	0	100	0.00	0.0	2.082	0.101	0	0	0	0
PL.24666	PL.24783	C	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.53	0	4	1	97	0.00	0.0	1.652	0.005	0	0	0	3
PD.3478	PL.24666	C	15T	7.47Y	124.4	0.00	0.57	0.53	0	4	1	97	0.00	0.0	1.652	0.005	0	0	0	3
PL.24667	PD.3478	C	#1/0 ACSR	7.47Y	124.4	0.00	0.57	0.53	0	4	1	97	0.00	0.0	1.698	0.046	0	0	1	3
PL.24859	PL.24667	C	#4 ACSR	7.47Y	124.4	0.00	0.57	0.53	0	4	1	97	0.00	0.0	1.713	0.015	0	0	1	2
PL.24860	PL.24859	C	#4 ACSR	7.47Y	124.4	0.00	0.57	0.53	0	4	1	97	0.00	0.0	1.772	0.059	4	1	1	1
PL.21526	Hargett	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	119.26	23	2538	871	95	0.01	0.0	0.005	0.005	0	0	0	450
PL.72941	PL.21526	ABC	397 SPACER	7.50Y	125.0	0.00	0.00	119.26	23	2538	871	95	0.01	0.0	0.009	0.004	0	0	0	450

----- Feeder No. 2 (Dry Branch F2) Beginning with Device PD.11204 -----

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.11204	PL.72941	ABC	360VWE	7.50Y	125.0	0.00	0.00	119.26	0	2538	871	95	0.00	0.0	0.009	0.004	0	0	0	450
PL.21527	PD.11204	ABC	397 SPACER	7.50Y	124.9	0.06	0.07	119.26	23	2538	871	95	0.29	0.0	0.161	0.153	9	3	2	450
PL.22224	PL.21527	ABC	397 SPACER	7.49Y	124.9	0.06	0.13	118.86	23	2529	865	95	0.29	0.0	0.317	0.155	0	0	0	448
PL.21770	PL.22224	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.19	0	1	0	100	0.00	0.0	0.321	0.004	0	0	0	1
PD.3200	PL.21770	A	65T	7.49Y	124.9	0.00	0.13	0.19	0	1	0	100	0.00	0.0	0.321	0.004	0	0	0	1
PL.21771	PD.3200	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.19	0	1	0	100	0.00	0.0	0.367	0.046	1	0	1	1
PL.22062	PL.22224	A	6 A (CWC)	7.49Y	124.9	0.00	0.13	1.88	1	13	4	96	0.00	0.0	0.328	0.011	0	0	0	3
PD.3176	PL.22062	A	65T	7.49Y	124.9	0.00	0.13	1.88	0	13	4	96	0.00	0.0	0.328	0.011	0	0	0	3
PL.22338	PD.3176	A	6 A (CWC)	7.49Y	124.9	0.00	0.13	1.88	1	13	4	96	0.00	0.0	0.332	0.004	2	1	2	3
PL.22225	PL.22338	A	6 A (CWC)	7.49Y	124.9	0.01	0.14	1.62	1	12	4	95	0.00	0.0	0.414	0.082	0	0	0	1
PL.21719	PL.22225	A	#4 ACSR	7.49Y	124.9	0.00	0.14	1.62	1	12	4	95	0.00	0.0	0.466	0.052	12	4	1	1
PL.21916	PL.22224	ABC	397 SPACER	7.49Y	124.8	0.05	0.18	118.18	23	2514	857	95	0.20	0.0	0.427	0.110	0	0	0	444
PL.22063	PL.21916	A	#4 ACSR	7.49Y	124.8	0.00	0.18	1.09	1	8	2	97	0.00	0.0	0.437	0.010	0	0	0	1
PD.3171	PL.22063	A	65T	7.49Y	124.8	0.00	0.18	1.09	0	8	2	97	0.00	0.0	0.437	0.010	0	0	0	1
PL.22330	PD.3171	A	#4 ACSR	7.49Y	124.8	0.00	0.18	1.09	1	8	2	97	0.00	0.0	0.485	0.048	8	2	1	1
PL.21917	PL.21916	ABC	397 SPACER	7.49Y	124.8	0.03	0.21	115.56	22	2458	838	95	0.12	0.0	0.497	0.070	2	1	1	433
PL.22066	PL.21917	ABC	397 SPACER	7.49Y	124.8	0.02	0.23	115.48	22	2456	836	95	0.09	0.0	0.548	0.051	7	2	1	432
PL.22242	PL.22066	ABC	397 SPACER	7.49Y	124.8	0.02	0.24	114.71	22	2439	830	95	0.07	0.0	0.588	0.039	6	2	1	429
PL.22243	PL.22242	ABC	397 SPACER	7.48Y	124.7	0.02	0.26	114.41	22	2433	827	95	0.07	0.0	0.629	0.041	9	3	1	428
PL.22241	PL.22243	ABC	397 SPACER	7.48Y	124.7	0.02	0.28	113.99	22	2424	823	95	0.07	0.0	0.671	0.041	9	3	1	427
PL.22044	PL.22241	ABC	397 SPACER	7.48Y	124.7	0.04	0.32	113.55	22	2414	820	95	0.19	0.0	0.782	0.111	0	0	0	426
PL.22235	PL.22044	ABC	397 SPACER	7.48Y	124.7	0.01	0.33	111.50	21	2370	804	95	0.05	0.0	0.813	0.031	4	1	1	414
PL.22236	PL.22235	ABC	397 SPACER	7.48Y	124.6	0.04	0.37	111.33	21	2366	802	95	0.17	0.0	0.918	0.106	0	0	0	413
PL.21920	PL.22236	ABC	397 SPACER	7.48Y	124.6	0.01	0.39	110.12	21	2340	792	95	0.06	0.0	0.957	0.039	5	1	1	407
PL.22045	PL.21920	ABC	397 SPACER	7.47Y	124.6	0.04	0.43	109.89	21	2335	790	95	0.17	0.0	1.065	0.108	0	0	0	406
PL.21921	PL.22045	ABC	397 SPACER	7.47Y	124.5	0.05	0.48	107.13	21	2275	770	95	0.22	0.0	1.211	0.146	14	4	2	404
PL.22203	PL.21921	ABC	336 MCM AC	7.47Y	124.5	0.04	0.52	106.47	21	2261	764	95	0.40	0.0	1.253	0.042	0	0	1	402
PL.22204	PL.22203	ABC	336 MCM AC	7.46Y	124.4	0.12	0.64	106.47	21	2260	763	95	1.40	0.1	1.400	0.147	0	0	0	401
PL.22300	PL.22204	C	#2 ACSR	7.46Y	124.4	0.00	0.64	0.80	0	6	2	95	0.00	0.0	1.404	0.005	0	0	0	2
PD.3156	PL.22300	C	65T	7.46Y	124.4	0.00	0.64	0.80	0	6	2	95	0.00	0.0	1.404	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22301	PD.3156	C	#2 ACSR	7.46Y	124.4	0.00	0.64	0.80	0	6	2	95	0.00	0.0	1.413	0.008	6	2	2	2
PL.22197	PL.22204	ABC	336 MCM AC	7.46Y	124.3	0.08	0.72	106.20	20	2253	758	95	0.91	0.0	1.496	0.096	0	0	1	399
PL.22198	PL.22197	ABC	336 MCM AC	7.45Y	124.2	0.04	0.77	106.19	20	2252	755	95	0.50	0.0	1.548	0.053	10	3	1	398
PL.22067	PL.22198	ABC	336 MCM AC	7.45Y	124.1	0.10	0.87	105.45	20	2236	749	95	1.13	0.1	1.669	0.121	0	0	0	395
PL.22343	PL.22067	C	#2 ACSR	7.45Y	124.1	0.00	0.87	1.73	1	12	4	95	0.00	0.0	1.674	0.005	0	0	0	1
PD.3179	PL.22343	C	65T	7.45Y	124.1	0.00	0.87	1.73	0	12	4	95	0.00	0.0	1.674	0.005	0	0	0	1
PL.22344	PD.3179	C	#2 ACSR	7.45Y	124.1	0.00	0.87	1.73	1	12	4	95	0.00	0.0	1.789	0.115	12	4	1	1
PL.22298	PL.22067	C	#2 ACSR	7.45Y	124.1	0.00	0.87	3.09	2	22	7	95	0.00	0.0	1.674	0.005	0	0	0	2
PD.3155	PL.22298	C	65T	7.45Y	124.1	0.00	0.87	3.09	0	22	7	95	0.00	0.0	1.674	0.005	0	0	0	2
PL.22299	PD.3155	C	#2 ACSR	7.45Y	124.1	0.00	0.87	3.09	2	22	7	95	0.00	0.0	1.749	0.075	22	7	2	2
PL.22345	PL.22067	ABC	336 MCM AC	7.45Y	124.1	0.00	0.87	103.85	20	2200	737	95	0.04	0.0	1.673	0.004	0	0	0	392
PL.22346	PL.22345	ABC	336 MCM AC	7.44Y	124.1	0.07	0.94	103.85	20	2200	736	95	0.74	0.0	1.755	0.081	0	0	0	392
PL.21922	PL.22346	ABC	336 MCM AC	7.44Y	123.9	0.14	1.07	103.68	20	2196	734	95	1.52	0.1	1.923	0.168	0	0	0	390
PL.22349	PL.21922	A	#1/0 ACSR	7.44Y	123.9	0.00	1.08	2.18	1	15	5	95	0.00	0.0	1.927	0.005	0	0	0	3
PD.3181	PL.22349	A	65T	7.44Y	123.9	0.00	1.08	2.18	0	15	5	95	0.00	0.0	1.927	0.005	0	0	0	3
PL.22350	PD.3181	A	#1/0 ACSR	7.44Y	123.9	0.00	1.08	2.18	1	15	5	95	0.00	0.0	1.977	0.050	6	2	1	3
PL.22202	PL.22350	A	#1/0 ACSR	7.44Y	123.9	0.00	1.08	1.37	1	10	3	96	0.00	0.0	2.005	0.028	9	3	1	2
PL.22199	PL.22202	A	#1/0 ACSR	7.44Y	123.9	0.00	1.08	0.09	0	1	0	100	0.00	0.0	2.053	0.048	1	0	1	1
PL.21923	PL.21922	ABC	336 MCM AC	7.43Y	123.8	0.08	1.15	102.96	20	2179	725	95	0.85	0.0	2.018	0.095	0	0	0	387
PL.21732	PL.21923	A	#1/0 ACSR	7.43Y	123.8	0.00	1.15	0.25	0	2	1	89	0.00	0.0	2.022	0.005	0	0	0	1
PD.3182	PL.21732	A	65T	7.43Y	123.8	0.00	1.15	0.25	0	2	1	89	0.00	0.0	2.022	0.005	0	0	0	1
PL.21733	PD.3182	A	#1/0 ACSR	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	2.071	0.048	0	0	0	0
PL.21924	PD.3182	A	#1/0 ACSR	7.43Y	123.8	0.00	1.15	0.25	0	2	1	89	0.00	0.0	2.052	0.030	2	1	1	1
PL.22195	PL.21923	ABC	336 MCM AC	7.43Y	123.8	0.05	1.20	102.88	20	2176	723	95	0.51	0.0	2.075	0.058	6	2	2	386
PL.22196	PL.22195	ABC	336 MCM AC	7.43Y	123.8	0.04	1.24	102.61	20	2170	720	95	0.45	0.0	2.126	0.050	7	2	1	384
PL.22353	PL.22196	ABC	336 MCM AC	7.42Y	123.7	0.08	1.32	102.28	20	2163	717	95	0.85	0.0	2.223	0.097	0	0	0	383
PL.22354	PL.22353	ABC	336 MCM AC	7.42Y	123.7	0.00	1.32	102.28	20	2162	715	95	0.04	0.0	2.227	0.004	0	0	0	383
PL.22304	PL.22354	A	#2 ACSR	7.42Y	123.7	0.00	1.32	0.98	1	7	2	96	0.00	0.0	2.232	0.005	0	0	0	2
PD.3158	PL.22304	A	65T	7.42Y	123.7	0.00	1.32	0.98	0	7	2	96	0.00	0.0	2.232	0.005	0	0	0	2
PL.22305	PD.3158	A	#2 ACSR	7.42Y	123.7	0.00	1.32	0.98	1	7	2	96	0.00	0.0	2.244	0.012	7	2	2	2
PL.22351	PL.22354	A	#2 ACSR	7.42Y	123.7	0.00	1.32	2.16	1	15	5	95	0.00	0.0	2.232	0.005	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3183	PL.22351	A	65T	7.42Y	123.7	0.00	1.32	2.16	0	15	5	95	0.00	0.0	2.232	0.005	0	0	0	5
PL.22352	PD.3183	A	#2 ACSR	7.42Y	123.7	0.01	1.33	2.16	1	15	5	95	0.00	0.0	2.417	0.186	3	1	2	5
PL.22200	PL.22352	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	1.74	1	12	4	95	0.00	0.0	2.455	0.038	8	2	1	3
PL.22201	PL.22200	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.67	0	5	1	98	0.00	0.0	2.520	0.065	3	1	1	2
PL.21734	PL.22201	A	#1/0 ACSR	7.42Y	123.7	0.00	1.33	0.31	0	2	1	89	0.00	0.0	2.552	0.032	2	1	1	1
PL.22205	PL.22354	ABC	336 MCM AC	7.42Y	123.6	0.05	1.37	101.23	20	2140	708	95	0.53	0.0	2.288	0.061	15	5	2	376
PL.22206	PL.22205	ABC	336 MCM AC	7.42Y	123.6	0.04	1.41	100.52	19	2124	702	95	0.40	0.0	2.336	0.047	0	0	0	374
PL.21735	PL.22206	ABC	336 MCM AC	7.41Y	123.5	0.07	1.48	100.52	19	2123	701	95	0.74	0.0	2.422	0.087	0	0	0	374
PL.21737	PL.21735	A	#2 ACSR	7.41Y	123.5	0.00	1.48	1.18	1	8	3	94	0.00	0.0	2.442	0.019	0	0	0	3
PL.22302	PL.21737	A	6 A (CWC)	7.41Y	123.5	0.00	1.48	1.18	1	8	3	94	0.00	0.0	2.446	0.005	0	0	0	3
PD.3157	PL.22302	A	65T	7.41Y	123.5	0.00	1.48	1.18	0	8	3	94	0.00	0.0	2.446	0.005	0	0	0	3
PL.22303	PD.3157	A	6 A (CWC)	7.41Y	123.5	0.00	1.48	1.18	1	8	3	94	0.00	0.0	2.510	0.064	0	0	0	3
PL.21738	PL.22303	A	6 A (CWC)	7.41Y	123.5	0.00	1.48	1.18	1	8	3	94	0.00	0.0	2.567	0.057	8	3	3	3
PL.22259	PL.22303	A	6 A (CWC)	7.41Y	123.5	0.00	1.48	0.00	0	0	0	100	0.00	0.0	2.600	0.090	0	0	0	0
PL.21736	PL.21735	A	#2 ACSR	7.41Y	123.5	0.02	1.49	7.74	4	55	17	96	0.01	0.0	2.497	0.075	7	2	1	11
PL.22306	PL.21736	A	6 A (CWC)	7.41Y	123.5	0.00	1.49	6.69	5	47	14	96	0.00	0.0	2.502	0.005	0	0	0	10
PD.3159	PL.22306	A	65T	7.41Y	123.5	0.00	1.49	6.69	0	47	14	96	0.00	0.0	2.502	0.005	0	0	0	10
PL.22307	PD.3159	A	6 A (CWC)	7.41Y	123.5	0.04	1.53	6.69	5	47	14	96	0.01	0.0	2.618	0.116	0	0	0	10
PL.21871	PL.22307	A	6 A (CWC)	7.41Y	123.4	0.02	1.55	6.69	5	47	14	96	0.01	0.0	2.688	0.070	0	0	0	10
PL.21926	PL.21871	A	6 A (CWC)	7.41Y	123.4	0.03	1.58	5.75	4	41	12	96	0.01	0.0	2.796	0.108	0	0	0	8
PL.22252	PL.21926	A	6 A (CWC)	7.40Y	123.4	0.03	1.61	5.75	4	41	12	96	0.01	0.0	2.900	0.104	5	1	1	8
PL.22253	PL.22252	A	6 A (CWC)	7.40Y	123.4	0.01	1.62	5.11	4	36	11	96	0.00	0.0	2.960	0.060	6	2	1	7
PL.22068	PL.22253	A	6 A (CWC)	7.40Y	123.4	0.01	1.63	3.40	2	24	7	96	0.00	0.0	3.037	0.077	0	0	0	5
PL.21873	PL.22068	A	6 A (CWC)	7.40Y	123.4	0.01	1.64	3.40	2	24	7	96	0.00	0.0	3.093	0.056	4	1	1	5
PL.22254	PL.21873	A	#4 ACSR	7.40Y	123.4	0.01	1.65	2.77	2	20	6	96	0.00	0.0	3.145	0.053	1	0	2	4
PL.22255	PL.22254	A	#4 ACSR	7.40Y	123.3	0.01	1.65	2.60	2	18	6	95	0.00	0.0	3.219	0.074	12	3	1	2
PL.22256	PL.22255	A	#4 ACSR	7.40Y	123.3	0.00	1.65	0.96	1	7	2	96	0.00	0.0	3.298	0.079	0	0	0	1
PL.21874	PL.22256	A	#4 ACSR	7.40Y	123.3	0.00	1.66	0.96	1	7	2	96	0.00	0.0	3.368	0.070	7	2	1	1
PL.21872	PL.22253	A	#2 ACSR	7.40Y	123.4	0.00	1.62	0.92	1	7	2	96	0.00	0.0	3.042	0.082	7	2	1	1
PL.22250	PL.21871	A	6 A (CWC)	7.41Y	123.4	0.00	1.55	0.94	1	7	2	96	0.00	0.0	2.739	0.051	3	1	1	2
PL.22251	PL.22250	A	6 A (CWC)	7.41Y	123.4	0.00	1.55	0.49	0	4	1	97	0.00	0.0	2.777	0.037	4	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21925	PL.21735	ABC	336 MCM AC	7.40Y	123.4	0.13	1.61	97.55	19	2059	681	95	1.35	0.1	2.591	0.169	0	0	0	360
PL.21927	PL.21925	ABC	336 MCM AC	7.40Y	123.3	0.05	1.65	97.55	19	2058	677	95	0.51	0.0	2.655	0.064	0	0	0	360
PL.22310	PL.21927	C	#2 ACSR	7.40Y	123.3	0.00	1.66	2.10	1	15	4	97	0.00	0.0	2.709	0.054	0	0	0	2
PD.3161	PL.22310	C	65T	7.40Y	123.3	0.00	1.66	2.10	0	15	4	97	0.00	0.0	2.709	0.054	0	0	0	2
PL.22311	PD.3161	C	#2 ACSR	7.40Y	123.3	0.01	1.67	2.10	1	15	4	97	0.00	0.0	2.844	0.135	3	1	1	2
PL.22208	PL.22311	C	#2 ACSR	7.40Y	123.3	0.00	1.67	1.67	1	12	4	95	0.00	0.0	2.882	0.037	12	4	1	1
PL.21739	PL.21927	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.70	96.85	42	2043	672	95	0.58	0.0	2.679	0.023	0	0	0	358
PL.21740	PL.21739	C	#4 ACSR	7.40Y	123.3	0.04	1.73	13.12	10	93	28	96	0.03	0.0	2.740	0.061	0	0	0	11
PL.21743	PL.21740	C	6 A (CWC)	7.39Y	123.2	0.03	1.76	12.76	9	90	27	96	0.02	0.0	2.793	0.053	7	2	1	9
PL.21766	PL.21743	C	6 A (CWC)	7.39Y	123.2	0.00	1.76	11.80	8	84	25	96	0.00	0.0	2.797	0.005	0	0	0	8
PD.3198	PL.21766	C	65T	7.39Y	123.2	0.00	1.76	11.80	0	84	25	96	0.00	0.0	2.797	0.005	0	0	0	8
PL.21767	PD.3198	C	6 A (CWC)	7.39Y	123.1	0.09	1.86	11.80	8	84	25	96	0.06	0.1	2.968	0.171	0	0	0	8
PL.22047	PL.21767	C	6 A (CWC)	7.39Y	123.1	0.05	1.91	11.80	8	83	25	96	0.03	0.0	3.058	0.090	0	0	0	8
PL.22060	PL.22047	C	6 A (CWC)	7.38Y	123.0	0.06	1.96	11.80	8	83	25	96	0.03	0.0	3.161	0.103	0	0	0	8
PL.22048	PL.22060	C	6 A (CWC)	7.38Y	123.0	0.06	2.02	11.80	8	83	25	96	0.04	0.0	3.272	0.111	0	0	0	8
PL.21746	PL.22048	C	6 A (CWC)	7.38Y	123.0	0.01	2.03	1.31	1	9	3	95	0.00	0.0	3.459	0.187	0	0	0	2
PL.21928	PL.21746	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.44	0	3	1	95	0.00	0.0	3.638	0.179	0	0	0	1
PL.22049	PL.21928	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.44	0	3	1	95	0.00	0.0	3.817	0.180	3	1	1	1
PL.21747	PL.21746	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.87	1	6	2	95	0.00	0.0	3.557	0.098	6	2	1	1
PL.21745	PL.22048	C	6 A (CWC)	7.38Y	122.9	0.05	2.07	10.49	7	74	22	96	0.03	0.0	3.367	0.095	0	0	0	6
PL.22050	PL.21745	C	6 A (CWC)	7.37Y	122.9	0.05	2.12	10.49	7	74	22	96	0.03	0.0	3.467	0.100	0	0	0	6
PL.22193	PL.22050	C	#4 ACSR	7.37Y	122.9	0.03	2.15	10.49	8	74	22	96	0.02	0.0	3.536	0.069	9	3	1	6
PL.22194	PL.22193	C	#4 ACSR	7.37Y	122.8	0.01	2.16	9.15	7	65	19	96	0.00	0.0	3.556	0.020	3	1	1	5
PL.22177	PL.22194	C	#4 ACSR	7.37Y	122.8	0.03	2.18	8.31	6	59	18	96	0.01	0.0	3.633	0.077	6	2	1	3
PL.22178	PL.22177	C	#4 ACSR	7.37Y	122.8	0.02	2.21	7.39	6	52	16	96	0.01	0.0	3.702	0.069	0	0	0	2
PL.21748	PL.22178	C	#4 ACSR	7.37Y	122.8	0.00	2.21	6.16	5	43	13	96	0.00	0.0	3.724	0.021	43	13	1	1
PL.21749	PL.22178	C	#4 ACSR	7.37Y	122.8	0.00	2.21	1.23	1	9	3	95	0.00	0.0	3.777	0.074	9	3	1	1
PL.21959	PL.22194	C	2 AL URD	7.37Y	122.8	0.00	2.16	0.38	0	3	1	95	0.00	0.0	3.561	0.005	0	0	0	1
PD.3140	PL.21959	C	40T	7.37Y	122.8	0.00	2.16	0.38	0	3	1	95	0.00	0.0	3.561	0.005	0	0	0	1
PL.21960	PD.3140	C	2 AL URD	7.37Y	122.8	0.00	2.16	0.38	0	3	1	95	0.00	0.0	3.620	0.060	3	1	1	1
PL.22260	PL.21743	C	6 A (CWC)	7.39Y	123.2	0.00	1.76	0.00	0	0	0	100	0.00	0.0	2.797	0.005	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21742	PL.21740	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	0.35	0	3	1	95	0.00	0.0	2.770	0.030	3	1	2	2
PL.21915	PL.21739	ABC	#1/0 ACSR	7.39Y	123.2	0.11	1.80	91.63	40	1931	638	95	1.43	0.1	2.742	0.064	0	0	0	345
PL.21929	PL.21915	ABC	#1/0 ACSR	7.39Y	123.1	0.06	1.86	84.30	37	1782	565	95	0.74	0.0	2.781	0.039	0	0	0	344
PL.21741	PL.21929	ABC	#1/0 ACSR	7.38Y	123.0	0.18	2.04	84.30	37	1781	564	95	2.14	0.1	2.895	0.113	0	0	0	344
PL.21973	PL.21741	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	1.17	1	8	2	97	0.00	0.0	2.899	0.005	0	0	0	2
PD.3147	PL.21973	C	65T	7.38Y	123.0	0.00	2.04	1.17	0	8	2	97	0.00	0.0	2.899	0.005	0	0	0	2
PL.21974	PD.3147	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	1.17	1	8	2	97	0.00	0.0	2.978	0.078	0	0	1	2
PL.21744	PL.21974	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	1.16	1	8	2	97	0.00	0.0	3.055	0.077	8	2	1	1
PL.21930	PL.21741	ABC	#1/0 ACSR	7.37Y	122.9	0.07	2.11	83.91	36	1771	560	95	0.86	0.0	2.940	0.046	0	0	0	342
PL.21971	PL.21930	A	#4 ACSR	7.37Y	122.9	0.00	2.11	1.02	1	7	2	96	0.00	0.0	2.945	0.005	0	0	0	1
PD.3146	PL.21971	A	65T	7.37Y	122.9	0.00	2.11	1.02	0	7	2	96	0.00	0.0	2.945	0.005	0	0	0	1
PL.21972	PD.3146	A	#4 ACSR	7.37Y	122.9	0.00	2.11	1.02	1	7	2	96	0.00	0.0	2.973	0.028	7	2	1	1
PL.21931	PL.21930	ABC	#1/0 ACSR	7.36Y	122.7	0.14	2.25	83.57	36	1763	557	95	1.75	0.1	3.034	0.094	0	0	0	341
PL.22051	PL.21931	ABC	#1/0 ACSR	7.35Y	122.5	0.23	2.49	83.57	36	1761	555	95	2.83	0.2	3.186	0.152	0	0	0	341
PL.21932	PL.22051	ABC	#1/0 ACSR	7.35Y	122.5	0.03	2.52	82.67	36	1739	547	95	0.38	0.0	3.207	0.021	0	0	0	338
PL.21751	PL.21932	ABC	#1/0 ACSR	7.34Y	122.3	0.18	2.70	82.67	36	1739	546	95	2.13	0.1	3.324	0.117	0	0	0	338
PL.21933	PL.21751	ABC	#1/0 ACSR	7.33Y	122.2	0.09	2.79	81.96	36	1722	540	95	1.12	0.1	3.386	0.062	0	0	0	336
PL.22190	PL.21933	ABC	#1/0 ACSR	7.33Y	122.1	0.07	2.86	81.77	36	1717	537	95	0.82	0.0	3.433	0.046	11	3	1	335
PL.22191	PL.22190	ABC	#1/0 ACSR	7.33Y	122.1	0.04	2.90	81.27	35	1705	533	95	0.49	0.0	3.460	0.028	0	0	0	334
PL.22192	PL.22191	ABC	#1/0 ACSR	7.32Y	122.0	0.09	2.99	81.27	35	1705	533	95	1.04	0.1	3.519	0.059	0	0	0	334
PL.22355	PL.22192	C	6 A (CWC)	7.32Y	122.0	0.00	2.99	5.13	4	36	11	96	0.00	0.0	3.524	0.005	0	0	0	7
PD.3184	PL.22355	C	65T	7.32Y	122.0	0.00	2.99	5.13	0	36	11	96	0.00	0.0	3.524	0.005	0	0	0	7
PL.22356	PD.3184	C	6 A (CWC)	7.32Y	122.0	0.02	3.01	5.13	4	36	11	96	0.01	0.0	3.622	0.098	6	2	1	7
PL.21753	PL.22356	C	6 A (CWC)	7.32Y	122.0	0.00	3.01	1.56	1	11	3	96	0.00	0.0	3.687	0.065	11	3	1	1
PL.22071	PL.22356	C	6 A (CWC)	7.32Y	122.0	0.01	3.02	2.76	2	19	6	95	0.00	0.0	3.694	0.072	4	1	1	5
PL.22069	PL.22071	C	#4 ACSR	7.32Y	122.0	0.00	3.02	1.11	1	8	2	97	0.00	0.0	3.756	0.062	0	0	0	3
PL.21756	PL.22069	C	#4 ACSR	7.32Y	122.0	0.00	3.02	1.11	1	8	2	97	0.00	0.0	3.772	0.017	8	2	3	3
PL.22070	PL.22071	C	#4 ACSR	7.32Y	122.0	0.00	3.02	1.04	1	7	2	96	0.00	0.0	3.746	0.052	7	2	1	1
PL.22182	PL.22192	ABC	#1/0 ACSR	7.32Y	122.0	0.06	3.05	79.26	34	1661	519	95	0.69	0.0	3.561	0.042	16	5	3	326
PL.22183	PL.22182	ABC	#1/0 ACSR	7.31Y	121.9	0.07	3.12	78.49	34	1644	514	95	0.83	0.1	3.612	0.051	7	2	2	323
PL.21963	PL.22183	C	#4 ACSR	7.31Y	121.9	0.00	3.12	2.15	2	15	5	95	0.00	0.0	3.617	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3142	PL.21963	C	65T	7.31Y	121.9	0.00	3.12	2.15	0	15	5	95	0.00	0.0	3.617	0.005	0	0	0	2
PL.21964	PD.3142	C	#4 ACSR	7.31Y	121.9	0.00	3.13	2.15	2	15	5	95	0.00	0.0	3.648	0.031	6	2	1	2
PL.21755	PL.21964	C	#4 ACSR	7.31Y	121.9	0.00	3.13	1.30	1	9	3	95	0.00	0.0	3.740	0.092	9	3	1	1
PL.22180	PL.22183	ABC	#1/0 ACSR	7.31Y	121.8	0.10	3.22	77.44	34	1622	506	95	1.11	0.1	3.682	0.070	12	3	2	319
PL.22181	PL.22180	ABC	#1/0 ACSR	7.30Y	121.6	0.14	3.36	76.89	33	1609	502	95	1.52	0.1	3.779	0.097	8	2	3	317
PL.22073	PL.22181	ABC	#1/0 ACSR	7.29Y	121.5	0.09	3.45	76.30	33	1595	497	95	1.02	0.1	3.844	0.066	0	0	0	312
PL.21965	PL.22073	A	#2 ACSR	7.29Y	121.5	0.00	3.45	8.44	5	59	18	96	0.00	0.0	3.849	0.005	0	0	0	9
PD.3143	PL.21965	A	65T	7.29Y	121.5	0.00	3.45	8.44	0	59	18	96	0.00	0.0	3.849	0.005	0	0	0	9
PL.21966	PD.3143	A	#2 ACSR	7.29Y	121.5	0.02	3.47	8.44	5	59	18	96	0.01	0.0	3.918	0.069	8	2	1	9
PL.21757	PL.21966	A	6 A (CWC)	7.29Y	121.5	0.02	3.49	7.31	5	51	15	96	0.01	0.0	3.971	0.054	0	0	0	8
PL.21758	PL.21757	A	#1/0 ACSR	7.29Y	121.5	0.00	3.49	1.37	1	10	3	96	0.00	0.0	4.015	0.044	10	3	1	1
PL.22074	PL.21757	A	6 A (CWC)	7.29Y	121.5	0.04	3.52	5.93	4	41	12	96	0.01	0.0	4.103	0.131	0	0	0	7
PL.22075	PL.22074	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	2.97	2	21	6	96	0.00	0.0	4.139	0.036	0	0	0	3
PL.21854	PL.22075	A	#4 ACSR	7.29Y	121.5	0.00	3.53	2.20	2	15	5	95	0.00	0.0	4.207	0.068	15	5	1	1
PL.21855	PL.22075	A	6 A (CWC)	7.29Y	121.5	0.00	3.53	0.77	1	5	2	93	0.00	0.0	4.223	0.084	5	2	2	2
PL.22188	PL.22074	A	#4 ACSR	7.29Y	121.5	0.01	3.53	2.96	2	21	6	96	0.00	0.0	4.162	0.060	7	2	1	4
PL.22187	PL.22188	A	#4 ACSR	7.29Y	121.5	0.00	3.53	1.91	1	13	4	96	0.00	0.0	4.213	0.050	0	0	0	3
PL.21853	PL.22187	A	#4 ACSR	7.29Y	121.5	0.00	3.54	0.95	1	7	2	96	0.00	0.0	4.355	0.143	7	2	1	1
PL.22223	PL.22187	A	#4 ACSR	7.29Y	121.5	0.00	3.54	0.96	1	7	2	96	0.00	0.0	4.257	0.045	3	1	1	2
PL.22222	PL.22223	A	#4 ACSR	7.29Y	121.5	0.00	3.54	0.59	0	4	1	97	0.00	0.0	4.310	0.053	4	1	1	1
PL.22184	PL.22073	ABC	#1/0 ACSR	7.29Y	121.5	0.03	3.48	73.49	32	1535	478	95	0.36	0.0	3.870	0.025	1	0	1	303
PL.22185	PL.22184	ABC	#1/0 ACSR	7.28Y	121.3	0.20	3.68	73.45	32	1534	477	95	2.14	0.1	4.019	0.149	8	2	1	302
PL.21969	PL.22185	A	#4 ACSR	7.28Y	121.3	0.00	3.68	0.54	0	4	1	97	0.00	0.0	4.024	0.005	0	0	0	1
PD.3145	PL.21969	A	65T	7.28Y	121.3	0.00	3.68	0.54	0	4	1	97	0.00	0.0	4.024	0.005	0	0	0	1
PL.21970	PD.3145	A	#4 ACSR	7.28Y	121.3	0.00	3.69	0.54	0	4	1	97	0.00	0.0	4.075	0.051	4	1	1	1
PL.22186	PL.21970	A	#4 ACSR	7.28Y	121.3	0.00	3.69	0.00	0	0	0	100	0.00	0.0	4.102	0.027	0	0	0	0
PL.22076	PL.22185	ABC	#1/0 ACSR	7.27Y	121.2	0.10	3.79	72.90	32	1520	472	96	1.06	0.1	4.094	0.075	0	0	0	300
PL.22218	PL.22076	ABC	#1/0 ACSR	7.27Y	121.2	0.03	3.82	72.73	32	1516	470	96	0.35	0.0	4.119	0.025	13	4	4	299
PL.22219	PL.22218	ABC	#1/0 ACSR	7.26Y	121.1	0.12	3.94	72.11	31	1502	466	96	1.28	0.1	4.212	0.093	0	0	0	295
PL.21851	PL.22219	A	#4 ACSR	7.26Y	121.1	0.00	3.94	1.83	1	13	4	96	0.00	0.0	4.237	0.025	0	0	0	2
PL.22322	PL.21851	A	#4 ACSR	7.26Y	121.1	0.00	3.94	1.83	1	13	4	96	0.00	0.0	4.242	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PD.3167	PL.22322	A	65T	7.26Y	121.1	0.00	3.94	1.83	0	13	4	96	0.00	0.0	4.242	0.005	0	0	0	2
PL.22323	PD.3167	A	#4 ACSR	7.26Y	121.1	0.00	3.95	1.83	1	13	4	96	0.00	0.0	4.284	0.042	0	0	0	2
PL.21852	PL.22323	A	#4 ACSR	7.26Y	121.1	0.00	3.95	0.42	0	3	1	95	0.00	0.0	4.314	0.031	3	1	1	1
PL.21934	PL.22323	A	#4 ACSR	7.26Y	121.1	0.00	3.95	1.41	1	10	3	96	0.00	0.0	4.308	0.025	10	3	1	1
PL.22081	PL.22219	ABC	#1/0 ACSR	7.26Y	121.0	0.06	4.01	71.50	31	1488	461	96	0.67	0.0	4.262	0.050	20	6	3	293
PL.22359	PL.22081	C	6 A (CWC)	7.26Y	121.0	0.00	4.01	1.20	1	8	3	94	0.00	0.0	4.266	0.005	0	0	0	3
PD.3186	PL.22359	C	65T	7.26Y	121.0	0.00	4.01	1.20	0	8	3	94	0.00	0.0	4.266	0.005	0	0	0	3
PL.22360	PD.3186	C	6 A (CWC)	7.26Y	121.0	0.00	4.01	1.20	1	8	3	94	0.00	0.0	4.328	0.062	0	0	0	3
PL.21850	PL.22360	C	#4 ACSR	7.26Y	121.0	0.00	4.01	1.20	1	8	3	94	0.00	0.0	4.386	0.058	0	0	1	3
PL.22209	PL.21850	C	#4 ACSR	7.26Y	121.0	0.00	4.01	1.19	1	8	2	97	0.00	0.0	4.415	0.029	8	2	2	2
PL.22210	PL.22209	C	#4 ACSR	7.26Y	121.0	0.00	4.01	0.00	0	0	0	100	0.00	0.0	4.453	0.038	0	0	0	0
PL.22082	PL.22081	ABC	#1/0 ACSR	7.25Y	120.9	0.11	4.12	69.72	30	1451	449	96	1.13	0.1	4.349	0.088	0	0	0	286
PL.22312	PL.22082	C	#4 ACSR	7.25Y	120.9	0.00	4.12	0.22	0	2	0	100	0.00	0.0	4.354	0.005	0	0	0	1
PD.3162	PL.22312	C	65T	7.25Y	120.9	0.00	4.12	0.22	0	2	0	100	0.00	0.0	4.354	0.005	0	0	0	1
PL.22313	PD.3162	C	#4 ACSR	7.25Y	120.9	0.00	4.12	0.22	0	2	0	100	0.00	0.0	4.370	0.016	2	0	1	1
PL.22211	PL.22082	ABC	#1/0 ACSR	7.25Y	120.8	0.07	4.19	69.53	30	1446	446	96	0.73	0.1	4.406	0.057	2	1	1	284
PL.22212	PL.22211	ABC	#1/0 ACSR	7.24Y	120.7	0.09	4.28	69.44	30	1443	445	96	0.92	0.1	4.478	0.072	8	2	1	283
PL.22363	PL.22212	C	#4 ACSR	7.24Y	120.7	0.00	4.28	1.23	1	9	3	95	0.00	0.0	4.483	0.004	0	0	0	3
PD.3188	PL.22363	C	65T	7.24Y	120.7	0.00	4.28	1.23	0	9	3	95	0.00	0.0	4.483	0.004	0	0	0	3
PL.22364	PD.3188	C	#4 ACSR	7.24Y	120.7	0.00	4.28	1.23	1	9	3	95	0.00	0.0	4.542	0.060	0	0	0	3
PL.21856	PL.22364	C	#4 ACSR	7.24Y	120.7	0.00	4.29	0.71	1	5	1	98	0.00	0.0	4.576	0.034	5	1	1	1
PL.21935	PL.22364	C	#4 ACSR	7.24Y	120.7	0.00	4.29	0.52	0	4	1	97	0.00	0.0	4.624	0.082	4	1	2	2
PL.22318	PL.22212	A	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	4.483	0.005	0	0	0	0
PD.3165	PL.22318	A	65T	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	4.483	0.005	0	0	0	0
PL.22319	PD.3165	A	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	4.530	0.048	0	0	0	0
PL.22216	PL.22212	ABC	#1/0 ACSR	7.24Y	120.6	0.08	4.36	68.65	30	1425	439	96	0.79	0.1	4.541	0.063	0	0	0	279
PL.22217	PL.22216	ABC	#1/0 ACSR	7.24Y	120.6	0.05	4.41	68.65	30	1425	439	96	0.52	0.0	4.582	0.041	3	1	1	279
PL.22087	PL.22217	ABC	#1/0 ACSR	7.23Y	120.5	0.12	4.53	68.44	30	1420	437	96	1.22	0.1	4.680	0.097	0	0	0	277
PL.21858	PL.22087	ABC	#1/0 ACSR	7.23Y	120.5	0.01	4.54	66.49	29	1378	424	96	0.09	0.0	4.687	0.008	10	3	1	268
PL.22244	PL.21858	ABC	#4 ACSR	7.23Y	120.5	0.00	4.55	1.26	1	26	8	96	0.00	0.0	4.729	0.042	5	2	1	2
PL.22245	PL.22244	ABC	#4 ACSR	7.23Y	120.5	0.00	4.55	1.01	1	21	6	96	0.00	0.0	4.740	0.010	21	6	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22213	PL.21858	ABC	#1/0 ACSR	7.22Y	120.4	0.07	4.61	64.76	28	1342	413	96	0.67	0.0	4.747	0.060	0	0	1	265
PL.22214	PL.22213	ABC	#1/0 ACSR	7.22Y	120.4	0.03	4.64	64.76	28	1342	412	96	0.26	0.0	4.771	0.024	11	3	3	264
PL.22092	PL.22214	ABC	#1/0 ACSR	7.22Y	120.3	0.10	4.74	62.57	27	1296	398	96	0.89	0.1	4.857	0.086	1	0	1	254
PL.22367	PL.22092	C	6 A (CWC)	7.22Y	120.3	0.00	4.74	0.35	0	2	1	89	0.00	0.0	4.862	0.005	0	0	0	1
PD.3190	PL.22367	C	65T	7.22Y	120.3	0.00	4.74	0.35	0	2	1	89	0.00	0.0	4.862	0.005	0	0	0	1
PL.22368	PD.3190	C	6 A (CWC)	7.22Y	120.3	0.00	4.74	0.35	0	2	1	89	0.00	0.0	4.918	0.057	2	1	1	1
PL.22326	PL.22092	A	#4 ACSR	7.22Y	120.3	0.00	4.74	2.59	2	18	5	96	0.00	0.0	4.861	0.005	0	0	0	3
PD.3169	PL.22326	A	65T	7.22Y	120.3	0.00	4.74	2.59	0	18	5	96	0.00	0.0	4.861	0.005	0	0	0	3
PL.22327	PD.3169	A	#4 ACSR	7.22Y	120.3	0.00	4.75	2.59	2	18	5	96	0.00	0.0	4.924	0.062	18	5	3	3
PL.22093	PL.22092	ABC	#1/0 ACSR	7.21Y	120.2	0.07	4.81	61.52	27	1273	391	96	0.60	0.0	4.916	0.059	0	0	0	249
PL.22220	PL.22093	ABC	#1/0 ACSR	7.21Y	120.2	0.02	4.83	61.31	27	1268	389	96	0.20	0.0	4.936	0.020	8	3	2	248
PL.22221	PL.22220	ABC	#1/0 ACSR	7.20Y	120.1	0.10	4.93	60.90	26	1259	386	96	0.90	0.1	5.027	0.091	0	0	0	246
PL.22287	PL.22221	C	#4 ACSR	7.20Y	120.1	0.00	4.93	2.31	2	16	5	95	0.00	0.0	5.031	0.005	0	0	0	3
PD.3127	PL.22287	C	65T	7.20Y	120.1	0.00	4.93	2.31	0	16	5	95	0.00	0.0	5.031	0.005	0	0	0	3
PL.22288	PD.3127	C	#4 ACSR	7.20Y	120.1	0.00	4.93	2.31	2	16	5	95	0.00	0.0	5.073	0.042	10	3	2	3
PL.21861	PL.22288	C	#4 ACSR	7.20Y	120.1	0.00	4.94	0.81	1	6	2	95	0.00	0.0	5.160	0.087	6	2	1	1
PL.22095	PL.22221	ABC	#1/0 ACSR	7.20Y	120.0	0.11	5.04	59.82	26	1236	378	96	0.96	0.1	5.127	0.101	3	1	1	242
PL.22285	PL.22095	C	#4 ACSR	7.20Y	120.0	0.00	5.04	1.59	1	11	3	96	0.00	0.0	5.132	0.005	0	0	0	1
PD.3126	PL.22285	C	65T	7.20Y	120.0	0.00	5.04	1.59	0	11	3	96	0.00	0.0	5.132	0.005	0	0	0	1
PL.22286	PD.3126	C	#4 ACSR	7.20Y	120.0	0.00	5.04	1.59	1	11	3	96	0.00	0.0	5.180	0.048	11	3	1	1
PL.22096	PL.22095	ABC	#1/0 ACSR	7.19Y	119.9	0.09	5.13	59.14	26	1221	373	96	0.79	0.1	5.212	0.084	0	0	0	240
PL.21936	PL.22096	ABC	#1/0 ACSR	7.19Y	119.8	0.09	5.22	58.06	25	1198	366	96	0.75	0.1	5.296	0.084	15	4	2	237
PL.66258	PL.21936	ABC	#1/0 ACSR	7.18Y	119.7	0.07	5.29	57.35	25	1183	361	96	0.58	0.0	5.362	0.066	0	0	0	235
PD.10006	PL.66258	ABC	100L	7.18Y	119.7	0.00	5.29	57.35	57	1182	360	96	0.00	0.0	5.362	0.066	0	0	0	235
PL.66259	PD.10006	ABC	#1/0 ACSR	7.18Y	119.7	0.02	5.31	57.35	25	1182	360	96	0.20	0.0	5.385	0.023	12	4	3	235
PL.22100	PL.66259	ABC	#1/0 ACSR	7.18Y	119.6	0.07	5.38	54.90	24	1131	345	96	0.54	0.0	5.451	0.067	0	0	0	226
PL.22289	PL.22100	C	6 A (CWC)	7.18Y	119.6	0.00	5.38	7.42	5	51	15	96	0.00	0.0	5.456	0.005	0	0	0	14
PD.3128	PL.22289	C	65T	7.18Y	119.6	0.00	5.38	7.42	0	51	15	96	0.00	0.0	5.456	0.005	0	0	0	14
PL.22290	PD.3128	C	6 A (CWC)	7.18Y	119.6	0.01	5.40	7.42	5	51	15	96	0.01	0.0	5.503	0.046	11	3	3	14
PL.22163	PL.22290	C	#4 ACSR	7.18Y	119.6	0.00	5.40	2.83	2	19	6	95	0.00	0.0	5.518	0.015	14	4	3	5
PL.22164	PL.22163	C	#4 ACSR	7.18Y	119.6	0.00	5.40	0.73	1	5	2	93	0.00	0.0	5.547	0.029	5	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22098	PL.22290	C	6 A (CWC)	7.18Y	119.6	0.01	5.41	3.02	2	21	6	96	0.00	0.0	5.580	0.077	0	0	0	6
PL.21863	PL.22098	C	6 A (CWC)	7.18Y	119.6	0.00	5.41	1.65	1	11	3	96	0.00	0.0	5.623	0.043	11	3	2	2
PL.22158	PL.22098	C	6 A (CWC)	7.18Y	119.6	0.00	5.41	1.37	1	9	3	95	0.00	0.0	5.605	0.026	0	0	2	4
PL.22159	PL.22158	C	6 A (CWC)	7.18Y	119.6	0.00	5.41	1.36	1	9	3	95	0.00	0.0	5.654	0.049	0	0	0	2
PL.22157	PL.22159	C	6 A (CWC)	7.18Y	119.6	0.00	5.42	1.36	1	9	3	95	0.00	0.0	5.707	0.053	0	0	0	2
PL.21864	PL.22157	C	#4 ACSR	7.17Y	119.6	0.00	5.42	0.81	1	6	2	95	0.00	0.0	5.845	0.139	6	2	1	1
PL.21937	PL.22157	C	6 A (CWC)	7.18Y	119.6	0.00	5.42	0.55	0	4	1	97	0.00	0.0	5.729	0.022	4	1	1	1
PL.22101	PL.22100	ABC	#1/0 ACSR	7.17Y	119.5	0.10	5.48	52.43	23	1080	329	96	0.78	0.1	5.558	0.107	0	0	0	212
PL.22283	PL.22101	B	6 A (CWC)	7.17Y	119.5	0.00	5.49	11.91	9	82	25	96	0.00	0.0	5.563	0.005	0	0	0	23
PD.3125	PL.22283	B	65T	7.17Y	119.5	0.00	5.49	11.91	0	82	25	96	0.00	0.0	5.563	0.005	0	0	0	23
PL.22284	PD.3125	B	6 A (CWC)	7.17Y	119.5	0.02	5.51	11.91	9	82	25	96	0.01	0.0	5.605	0.042	0	0	1	23
PL.22160	PL.22284	B	6 A (CWC)	7.17Y	119.5	0.02	5.53	11.86	8	81	24	96	0.01	0.0	5.638	0.034	0	0	0	22
PL.21947	PL.22160	B	#2 ACSR	7.17Y	119.5	0.00	5.53	0.21	0	1	0	100	0.00	0.0	5.643	0.005	0	0	0	1
PD.3134	PL.21947	B	65T	7.17Y	119.5	0.00	5.53	0.21	0	1	0	100	0.00	0.0	5.643	0.005	0	0	0	1
PL.21948	PD.3134	B	#2 ACSR	7.17Y	119.5	0.00	5.53	0.21	0	1	0	100	0.00	0.0	5.683	0.040	1	0	1	1
PL.22102	PL.22160	B	6 A (CWC)	7.17Y	119.5	0.02	5.54	11.65	8	80	24	96	0.01	0.0	5.672	0.033	9	3	3	21
PL.21865	PL.22102	B	6 A (CWC)	7.17Y	119.4	0.02	5.56	10.36	7	71	21	96	0.01	0.0	5.714	0.042	12	4	2	18
PL.22166	PL.21865	B	6 A (CWC)	7.16Y	119.4	0.03	5.59	8.63	6	59	18	96	0.01	0.0	5.786	0.072	11	3	2	16
PL.22167	PL.22166	B	6 A (CWC)	7.16Y	119.4	0.01	5.60	7.03	5	48	15	95	0.00	0.0	5.832	0.046	12	4	1	14
PL.22168	PL.22167	B	6 A (CWC)	7.16Y	119.4	0.00	5.60	5.30	4	36	11	96	0.00	0.0	5.853	0.021	36	11	13	13
PL.21938	PL.22101	ABC	#1/0 ACSR	7.16Y	119.4	0.13	5.61	48.46	21	997	304	96	0.91	0.1	5.704	0.145	0	0	0	189
PL.22029	PL.21938	ABC	#1/0 ACSR	7.16Y	119.3	0.06	5.67	48.19	21	991	301	96	0.44	0.0	5.774	0.070	0	0	0	188
PL.22030	PL.22029	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.69	47.76	21	981	298	96	0.11	0.0	5.793	0.019	7	2	1	187
PL.21867	PL.22030	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.70	7.67	3	158	47	96	0.02	0.0	5.896	0.104	0	0	0	33
PL.22371	PL.21867	C	6 A (CWC)	7.16Y	119.3	0.00	5.71	1.26	1	9	3	95	0.00	0.0	5.901	0.005	0	0	0	2
PD.3192	PL.22371	C	65T	7.16Y	119.3	0.00	5.71	1.26	0	9	3	95	0.00	0.0	5.901	0.005	0	0	0	2
PL.22372	PD.3192	C	6 A (CWC)	7.16Y	119.3	0.00	5.71	1.26	1	9	3	95	0.00	0.0	5.945	0.044	9	3	2	2
PL.21945	PL.21867	A	6 A (CWC)	7.16Y	119.3	0.00	5.71	1.13	1	8	2	97	0.00	0.0	5.901	0.005	0	0	0	1
PD.3133	PL.21945	A	65T	7.16Y	119.3	0.00	5.71	1.13	0	8	2	97	0.00	0.0	5.901	0.005	0	0	0	1
PL.21946	PD.3133	A	6 A (CWC)	7.16Y	119.3	0.00	5.71	1.13	1	8	2	97	0.00	0.0	5.954	0.053	8	2	1	1
PL.22103	PL.21867	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.72	6.88	3	141	43	96	0.01	0.0	5.985	0.088	3	1	1	30

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21949	PL.22103	C	6 A (CWC)	7.16Y	119.3	0.00	5.72	1.95	1	13	4	96	0.00	0.0	5.989	0.005	0	0	0	3
PD.3135	PL.21949	C	65T	7.16Y	119.3	0.00	5.72	1.95	0	13	4	96	0.00	0.0	5.989	0.005	0	0	0	3
PL.21950	PD.3135	C	6 A (CWC)	7.16Y	119.3	0.01	5.73	1.95	1	13	4	96	0.00	0.0	6.127	0.138	0	0	0	3
PL.21868	PL.21950	C	6 A (CWC)	7.16Y	119.3	0.00	5.73	1.95	1	13	4	96	0.00	0.0	6.170	0.042	5	2	2	3
PL.21953	PL.21868	C	#4 ACSR	7.16Y	119.3	0.00	5.73	1.17	1	8	2	97	0.00	0.0	6.174	0.005	0	0	0	1
PD.3137	PL.21953	C	40T	7.16Y	119.3	0.00	5.73	1.17	0	8	2	97	0.00	0.0	6.174	0.005	0	0	0	1
PL.21954	PD.3137	C	#4 ACSR	7.16Y	119.3	0.01	5.74	1.17	1	8	2	97	0.00	0.0	6.285	0.111	0	0	0	1
PL.21870	PL.21954	C	#4 ACSR	7.16Y	119.3	0.01	5.74	1.17	1	8	2	97	0.00	0.0	6.408	0.123	0	0	0	1
PL.22052	PL.21870	C	#4 ACSR	7.15Y	119.2	0.01	5.75	1.17	1	8	2	97	0.00	0.0	6.552	0.144	0	0	0	1
PL.22053	PL.22052	C	#4 ACSR	7.15Y	119.2	0.00	5.76	1.17	1	8	2	97	0.00	0.0	6.646	0.094	0	0	0	1
PL.22061	PL.22053	C	#4 ACSR	7.15Y	119.2	0.00	5.76	1.17	1	8	2	97	0.00	0.0	6.742	0.095	0	0	0	1
PL.22054	PL.22061	C	#4 ACSR	7.15Y	119.2	0.00	5.77	1.17	1	8	2	97	0.00	0.0	6.881	0.140	8	2	1	1
PL.21869	PL.21950	C	6 A (CWC)	7.16Y	119.3	0.00	5.73	0.00	0	0	0	100	0.00	0.0	6.206	0.079	0	0	0	0
PL.22104	PL.22103	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.73	6.06	3	125	37	96	0.01	0.0	6.092	0.107	0	0	0	26
PL.22173	PL.22104	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.73	5.21	2	107	32	96	0.00	0.0	6.166	0.074	26	8	4	22
PL.22174	PL.22173	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.74	3.93	2	81	24	96	0.00	0.0	6.224	0.058	2	1	2	18
PL.21955	PL.22174	C	6 A (CWC)	7.16Y	119.3	0.00	5.74	2.08	1	14	4	96	0.00	0.0	6.228	0.005	0	0	0	3
PD.3138	PL.21955	C	65T	7.16Y	119.3	0.00	5.74	2.08	0	14	4	96	0.00	0.0	6.228	0.005	0	0	0	3
PL.21956	PD.3138	C	6 A (CWC)	7.16Y	119.3	0.00	5.74	2.08	1	14	4	96	0.00	0.0	6.267	0.039	7	2	1	3
PL.22169	PL.21956	C	#4 ACSR	7.16Y	119.3	0.01	5.75	1.05	1	7	2	96	0.00	0.0	6.389	0.121	0	0	1	2
PL.22170	PL.22169	C	#4 ACSR	7.16Y	119.3	0.00	5.75	1.01	1	7	2	96	0.00	0.0	6.441	0.053	7	2	1	1
PL.22171	PL.22174	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.74	2.88	1	59	18	96	0.00	0.0	6.287	0.063	3	1	2	12
PL.22172	PL.22171	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.74	2.72	1	56	17	96	0.00	0.0	6.346	0.060	7	2	3	10
PL.21876	PL.22172	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.75	2.37	1	49	15	96	0.00	0.0	6.399	0.053	0	0	0	7
PL.21957	PL.21876	A	6 A (CWC)	7.16Y	119.3	0.00	5.75	5.02	4	34	10	96	0.00	0.0	6.404	0.005	0	0	0	6
PD.3139	PL.21957	A	65T	7.16Y	119.3	0.00	5.75	5.02	0	34	10	96	0.00	0.0	6.404	0.005	0	0	0	6
PL.21958	PD.3139	A	6 A (CWC)	7.15Y	119.2	0.01	5.75	5.02	4	34	10	96	0.00	0.0	6.439	0.035	10	3	2	6
PL.21879	PL.21958	A	6 A (CWC)	7.15Y	119.2	0.00	5.76	1.67	1	11	3	96	0.00	0.0	6.468	0.029	11	3	2	2
PL.21878	PL.21958	A	6 A (CWC)	7.15Y	119.2	0.00	5.76	1.82	1	12	4	95	0.00	0.0	6.468	0.030	12	4	2	2
PL.21774	PL.21876	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.75	0.00	0	0	0	100	0.00	0.0	6.444	0.045	0	0	0	0
PD.3202-A	PL.21774	ABC	Open	7.16Y	119.3	0.00	5.75	0.00	0	0	0	100	0.00	0.0	6.444	0.045	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21877	PL.21876	A	6 A (CWC)	7.16Y	119.3	0.00	5.75	2.08	1	14	4	96	0.00	0.0	6.455	0.055	14	4	1	1
PL.22375	PL.22174	A	#2 ACSR	7.16Y	119.3	0.00	5.74	0.76	0	5	2	93	0.00	0.0	6.228	0.005	0	0	0	1
PD.3194	PL.22375	A	65T	7.16Y	119.3	0.00	5.74	0.76	0	5	2	93	0.00	0.0	6.228	0.005	0	0	0	1
PL.21759	PD.3194	A	#2 ACSR	7.16Y	119.3	0.00	5.74	0.76	0	5	2	93	0.00	0.0	6.310	0.082	5	2	1	1
PL.22373	PL.22104	A	6 A (CWC)	7.16Y	119.3	0.00	5.73	0.98	1	7	2	96	0.00	0.0	6.096	0.005	0	0	0	2
PD.3193	PL.22373	A	65T	7.16Y	119.3	0.00	5.73	0.98	0	7	2	96	0.00	0.0	6.096	0.005	0	0	0	2
PL.22374	PD.3193	A	6 A (CWC)	7.16Y	119.3	0.00	5.73	0.98	1	7	2	96	0.00	0.0	6.158	0.061	7	2	2	2
PL.21951	PL.22104	C	1/0 AL URD	7.16Y	119.3	0.00	5.73	1.58	1	11	3	96	0.00	0.0	6.096	0.005	0	0	0	2
PD.3136	PL.21951	C	65T	7.16Y	119.3	0.00	5.73	1.58	0	11	3	96	0.00	0.0	6.096	0.005	0	0	0	2
PL.21952	PD.3136	C	1/0 AL URD	7.16Y	119.3	0.00	5.73	1.58	1	11	3	96	0.00	0.0	6.133	0.037	11	3	2	2
PL.21866	PL.22030	ABC	#1/0 ACSR	7.15Y	119.2	0.07	5.76	39.75	17	817	248	96	0.40	0.0	5.888	0.095	3	1	2	153
PL.21880	PL.21866	ABC	#1/0 ACSR	7.15Y	119.2	0.05	5.81	39.06	17	802	244	96	0.29	0.0	5.959	0.071	0	0	0	149
PL.22031	PL.21880	ABC	#1/0 ACSR	7.15Y	119.1	0.08	5.89	36.90	16	757	230	96	0.42	0.1	6.075	0.116	5	2	2	142
PL.22097	PL.22031	ABC	#1/0 ACSR	7.14Y	119.0	0.07	5.95	36.64	16	752	228	96	0.35	0.0	6.173	0.098	10	3	2	140
PL.22151	PL.22097	ABC	#1/0 ACSR	7.14Y	119.0	0.05	6.00	35.25	15	723	219	96	0.25	0.0	6.250	0.077	2	0	1	136
PL.22152	PL.22151	ABC	#1/0 ACSR	7.14Y	118.9	0.07	6.07	35.17	15	721	219	96	0.34	0.0	6.353	0.103	0	0	0	135
PL.22277	PL.22152	C	6 A (CWC)	7.14Y	118.9	0.00	6.07	6.32	5	43	13	96	0.00	0.0	6.357	0.005	0	0	0	7
PD.3122	PL.22277	C	65T	7.14Y	118.9	0.00	6.07	6.32	0	43	13	96	0.00	0.0	6.357	0.005	0	0	0	7
PL.22278	PD.3122	C	6 A (CWC)	7.13Y	118.9	0.02	6.09	6.32	5	43	13	96	0.01	0.0	6.416	0.059	0	0	0	7
PL.21883	PL.22278	C	#4 ACSR	7.13Y	118.9	0.01	6.09	6.32	5	43	13	96	0.00	0.0	6.436	0.019	0	0	0	7
PL.22149	PL.21883	C	#4 ACSR	7.13Y	118.9	0.01	6.10	5.09	4	35	10	96	0.00	0.0	6.476	0.040	18	5	3	6
PL.22150	PL.22149	C	#4 ACSR	7.13Y	118.9	0.00	6.10	2.45	2	17	5	96	0.00	0.0	6.507	0.031	17	5	3	3
PL.21884	PL.21883	C	#4 ACSR	7.13Y	118.9	0.00	6.09	1.23	1	8	3	94	0.00	0.0	6.476	0.040	8	3	1	1
PL.22033	PL.22152	ABC	#1/0 ACSR	7.13Y	118.9	0.06	6.13	33.06	14	677	205	96	0.30	0.0	6.457	0.104	0	0	0	128
PL.22275	PL.22033	A	#4 ACSR	7.13Y	118.9	0.00	6.13	1.00	1	7	2	96	0.00	0.0	6.461	0.005	0	0	0	4
PD.3121	PL.22275	A	65T	7.13Y	118.9	0.00	6.13	1.00	0	7	2	96	0.00	0.0	6.461	0.005	0	0	0	4
PL.22276	PD.3121	A	#4 ACSR	7.13Y	118.9	0.00	6.13	1.00	1	7	2	96	0.00	0.0	6.514	0.053	7	2	4	4
PL.22145	PL.22033	ABC	#1/0 ACSR	7.13Y	118.8	0.02	6.15	32.73	14	670	203	96	0.11	0.0	6.496	0.039	13	4	1	124
PL.22146	PL.22145	ABC	#1/0 ACSR	7.13Y	118.8	0.09	6.24	32.11	14	658	199	96	0.41	0.1	6.645	0.149	4	1	2	123
PL.22273	PL.22146	A	6 A (CWC)	7.13Y	118.8	0.00	6.25	21.44	15	146	44	96	0.01	0.0	6.650	0.005	0	0	0	23
PD.3120	PL.22273	A	65T	7.13Y	118.8	0.00	6.25	21.44	0	146	44	96	0.00	0.0	6.650	0.005	0	0	0	23

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22274	PD.3120	A	6 A (CWC)	7.12Y	118.7	0.04	6.29	21.44	15	146	44	96	0.05	0.0	6.695	0.046	11	3	1	23
PL.21885	PL.22274	A	6 A (CWC)	7.12Y	118.7	0.01	6.30	6.73	5	46	14	96	0.00	0.0	6.735	0.040	25	8	5	8
PL.21888	PL.21885	A	6 A (CWC)	7.12Y	118.7	0.00	6.30	3.03	2	21	6	96	0.00	0.0	6.806	0.071	21	6	3	3
PL.22142	PL.22274	A	6 A (CWC)	7.12Y	118.7	0.00	6.29	1.77	1	12	4	95	0.00	0.0	6.730	0.035	8	2	2	3
PL.22147	PL.22142	A	6 A (CWC)	7.12Y	118.7	0.00	6.29	0.64	0	4	1	97	0.00	0.0	6.769	0.039	4	1	1	1
PL.22148	PL.22147	A	6 A (CWC)	7.12Y	118.7	0.00	6.29	0.00	0	0	0	100	0.00	0.0	6.807	0.038	0	0	0	0
PL.22094	PL.22274	A	6 A (CWC)	7.12Y	118.7	0.03	6.32	11.32	8	77	23	96	0.02	0.0	6.760	0.065	17	5	3	11
PL.21886	PL.22094	A	6 A (CWC)	7.12Y	118.7	0.01	6.33	4.00	3	27	8	96	0.00	0.0	6.814	0.053	14	4	2	3
PL.21887	PL.21886	A	#4 ACSR	7.12Y	118.7	0.00	6.33	2.00	2	14	4	96	0.00	0.0	6.851	0.037	14	4	1	1
PL.22143	PL.22094	A	6 A (CWC)	7.12Y	118.7	0.01	6.33	4.86	3	33	10	96	0.00	0.0	6.804	0.043	17	5	2	5
PL.22144	PL.22143	A	6 A (CWC)	7.12Y	118.7	0.00	6.33	2.37	2	16	5	95	0.00	0.0	6.843	0.039	16	5	2	3
PL.21889	PL.22144	A	6 A (CWC)	7.12Y	118.7	0.00	6.33	0.00	0	0	0	100	0.00	0.0	6.875	0.032	0	0	0	1
PL.21890	PL.21889	A	#4 ACSR	7.12Y	118.7	0.00	6.33	0.00	0	0	0	100	0.00	0.0	6.928	0.053	0	0	1	1
PL.22153	PL.22146	ABC	#1/0 ACSR	7.12Y	118.7	0.04	6.28	24.76	11	507	153	96	0.15	0.0	6.740	0.095	21	6	2	98
PL.22154	PL.22153	ABC	#1/0 ACSR	7.12Y	118.7	0.02	6.30	23.72	10	485	147	96	0.06	0.0	6.777	0.037	2	0	1	96
PL.22271	PL.22154	A	6 A (CWC)	7.12Y	118.7	0.00	6.30	1.40	1	10	3	96	0.00	0.0	6.782	0.005	0	0	0	1
PD.3119	PL.22271	A	65T	7.12Y	118.7	0.00	6.30	1.40	0	10	3	96	0.00	0.0	6.782	0.005	0	0	0	1
PL.22272	PD.3119	A	6 A (CWC)	7.12Y	118.7	0.00	6.30	1.40	1	10	3	96	0.00	0.0	6.873	0.091	10	3	1	1
PL.21891	PL.22154	ABC	#1/0 ACSR	7.12Y	118.7	0.04	6.34	23.17	10	474	143	96	0.15	0.0	6.881	0.104	0	0	0	94
PL.21776	PL.21891	C	6 A (CWC)	7.12Y	118.6	0.03	6.37	23.85	17	163	49	96	0.03	0.0	6.904	0.023	0	0	0	32
PD.3203	PL.21776	C	35L	7.12Y	118.6	0.00	6.37	23.85	68	163	49	96	0.00	0.0	6.904	0.023	0	0	0	32
PL.21777	PD.3203	C	6 A (CWC)	7.11Y	118.6	0.07	6.44	23.85	17	163	49	96	0.09	0.1	6.971	0.067	0	0	0	32
PL.22134	PL.21777	C	6 A (CWC)	7.11Y	118.5	0.04	6.49	23.85	17	162	49	96	0.05	0.0	7.011	0.040	0	0	0	32
PL.21897	PL.22134	C	#1/0 ACSR	7.11Y	118.5	0.00	6.49	1.13	0	8	2	97	0.00	0.0	7.070	0.059	8	2	1	1
PL.22084	PL.22134	C	6 A (CWC)	7.10Y	118.4	0.13	6.62	22.72	16	155	47	96	0.16	0.1	7.140	0.129	0	0	0	31
PL.22088	PL.22084	C	6 A (CWC)	7.10Y	118.4	0.02	6.64	7.20	5	49	15	96	0.01	0.0	7.209	0.070	1	0	1	13
PL.22089	PL.22088	C	6 A (CWC)	7.10Y	118.4	0.00	6.64	0.04	0	0	0	100	0.00	0.0	7.265	0.056	0	0	1	1
PL.22090	PL.22088	C	6 A (CWC)	7.10Y	118.3	0.02	6.66	6.95	5	47	14	96	0.01	0.0	7.272	0.063	7	2	3	11
PL.22125	PL.22090	C	6 A (CWC)	7.10Y	118.3	0.00	6.66	1.43	1	10	3	96	0.00	0.0	7.298	0.026	1	0	1	3
PL.22126	PL.22125	C	6 A (CWC)	7.10Y	118.3	0.00	6.67	1.34	1	9	3	95	0.00	0.0	7.355	0.057	9	3	2	2
PL.22124	PL.22090	C	#4 ACSR	7.10Y	118.3	0.01	6.67	4.53	3	31	9	96	0.00	0.0	7.337	0.065	10	3	2	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22123	PL.22124	C	#4 ACSR	7.10Y	118.3	0.00	6.68	3.06	2	21	6	96	0.00	0.0	7.399	0.062	21	6	3	3
PL.22122	PL.22084	C	6 A (CWC)	7.10Y	118.3	0.09	6.71	15.52	11	106	32	96	0.07	0.1	7.267	0.127	8	2	1	18
PL.22121	PL.22122	C	6 A (CWC)	7.09Y	118.2	0.08	6.79	14.35	10	97	29	96	0.06	0.1	7.383	0.116	0	0	0	17
PL.22085	PL.22121	C	#4 ACSR	7.09Y	118.2	0.01	6.79	1.67	1	11	3	96	0.00	0.0	7.509	0.127	0	0	0	2
PL.22055	PL.22085	C	#4 ACSR	7.09Y	118.2	0.01	6.81	1.67	1	11	3	96	0.00	0.0	7.680	0.171	0	0	0	2
PL.22118	PL.22055	C	#4 ACSR	7.09Y	118.2	0.01	6.82	1.67	1	11	3	96	0.00	0.0	7.865	0.184	5	2	1	2
PL.22117	PL.22118	C	#4 ACSR	7.09Y	118.2	0.00	6.82	0.90	1	6	2	95	0.00	0.0	7.962	0.097	6	2	1	1
PL.22086	PL.22121	C	#4 ACSR	7.09Y	118.2	0.02	6.80	12.68	10	86	26	96	0.01	0.0	7.411	0.028	8	2	1	15
PL.21894	PL.22086	C	6 A (CWC)	7.09Y	118.1	0.05	6.85	11.49	8	78	23	96	0.03	0.0	7.507	0.096	1	0	1	14
PL.22119	PL.21894	C	6 A (CWC)	7.09Y	118.1	0.01	6.86	11.41	8	77	23	96	0.01	0.0	7.531	0.025	7	2	1	13
PL.22120	PL.22119	C	6 A (CWC)	7.09Y	118.1	0.02	6.88	10.36	7	70	21	96	0.01	0.0	7.571	0.040	0	0	0	12
PL.22127	PL.22120	C	6 A (CWC)	7.08Y	118.1	0.06	6.95	9.37	7	64	19	96	0.03	0.0	7.728	0.157	9	3	2	11
PL.22128	PL.22127	C	6 A (CWC)	7.08Y	118.0	0.01	6.95	8.08	6	55	16	96	0.00	0.0	7.750	0.021	11	3	2	9
PL.22129	PL.22128	C	6 A (CWC)	7.08Y	118.0	0.01	6.97	6.47	5	44	13	96	0.00	0.0	7.797	0.047	7	2	2	7
PL.22267	PL.22129	C	#1/0 ACSR	7.08Y	118.0	0.00	6.97	0.51	0	3	1	95	0.00	0.0	7.801	0.005	0	0	0	1
PD.3117	PL.22267	C	15T	7.08Y	118.0	0.00	6.97	0.51	0	3	1	95	0.00	0.0	7.801	0.005	0	0	0	1
PL.22268	PD.3117	C	#1/0 ACSR	7.08Y	118.0	0.00	6.97	0.51	0	3	1	95	0.00	0.0	7.873	0.071	3	1	1	1
PL.21896	PL.22129	C	6 A (CWC)	7.08Y	118.0	0.00	6.97	4.87	3	33	10	96	0.00	0.0	7.836	0.039	33	10	4	4
PL.21895	PL.22120	C	#1/0 ACSR	7.09Y	118.1	0.00	6.88	1.00	0	7	2	96	0.00	0.0	7.635	0.064	7	2	1	1
PL.22135	PL.21891	A	6 A (CWC)	7.11Y	118.6	0.10	6.44	43.37	31	295	90	96	0.22	0.1	6.930	0.049	0	0	1	59
PL.21778	PL.22135	A	6 A (CWC)	7.11Y	118.4	0.14	6.58	43.32	31	295	89	96	0.31	0.1	6.998	0.068	0	0	0	58
PD.3204	PL.21778	A	70L	7.11Y	118.4	0.00	6.58	43.32	62	295	89	96	0.00	0.0	6.998	0.068	0	0	0	58
PL.21779	PD.3204	A	6 A (CWC)	7.10Y	118.3	0.12	6.70	43.32	31	295	89	96	0.27	0.1	7.058	0.060	8	2	1	58
PL.21898	PL.21779	A	#2 ACSR	7.10Y	118.3	0.00	6.70	0.81	0	5	2	93	0.00	0.0	7.217	0.159	0	0	0	1
PL.22056	PL.21898	A	#2 ACSR	7.10Y	118.3	0.00	6.70	0.81	0	5	2	93	0.00	0.0	7.271	0.054	5	2	1	1
PL.22083	PL.21779	A	6 A (CWC)	7.09Y	118.2	0.15	6.84	41.31	30	281	85	96	0.32	0.1	7.135	0.077	1	0	2	56
REG59	PL.22083	A	76.2 KVA	7.51Y	125.2	-7.04	-0.20	41.20	41	280	84	96	percent Boost= 5.62 Tap= 9.0							54
PL.21899	REG59	A	6 A (CWC)	7.50Y	125.1	0.14	-0.06	38.88	28	280	84	96	0.29	0.1	7.215	0.080	0	0	0	54
PL.22132	PL.21899	A	6 A (CWC)	7.50Y	125.0	0.01	-0.05	37.70	27	271	82	96	0.02	0.0	7.222	0.007	7	2	3	53
PL.22133	PL.22132	A	6 A (CWC)	7.49Y	124.9	0.15	0.10	36.77	26	264	80	96	0.28	0.1	7.308	0.086	0	0	0	50
PL.22130	PL.22133	A	6 A (CWC)	7.49Y	124.9	0.00	0.10	2.29	2	16	5	95	0.00	0.0	7.319	0.012	10	3	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22131	PL.22130	A	6 A (CWC)	7.49Y	124.9	0.00	0.10	0.86	1	6	2	95	0.00	0.0	7.363	0.044	6	2	2	2
PL.21913	PL.22133	A	#4 ACSR	7.49Y	124.8	0.08	0.18	34.47	27	247	75	96	0.15	0.1	7.361	0.053	0	0	0	47
PL.22079	PL.21913	A	#4 ACSR	7.49Y	124.8	0.02	0.20	10.19	8	73	22	96	0.01	0.0	7.399	0.039	12	3	1	14
PL.22249	PL.22079	A	#4 ACSR	7.49Y	124.8	0.00	0.20	1.34	1	10	3	96	0.00	0.0	7.439	0.039	6	2	1	3
PL.22248	PL.22249	A	#4 ACSR	7.49Y	124.8	0.00	0.20	0.52	0	4	1	97	0.00	0.0	7.468	0.029	4	1	2	2
PL.22080	PL.22079	A	#4 ACSR	7.49Y	124.8	0.01	0.21	7.23	6	52	16	96	0.00	0.0	7.436	0.036	23	7	3	10
PL.21914	PL.22080	A	#2 ACSR	7.49Y	124.8	0.00	0.21	1.00	1	7	2	96	0.00	0.0	7.521	0.086	7	2	1	1
PL.22106	PL.22080	A	#4 ACSR	7.49Y	124.8	0.01	0.22	2.96	2	21	6	96	0.00	0.0	7.520	0.085	8	2	3	6
PL.22107	PL.22106	A	#4 ACSR	7.49Y	124.8	0.01	0.22	1.90	1	14	4	96	0.00	0.0	7.638	0.118	8	3	1	3
PL.22105	PL.22107	A	#4 ACSR	7.49Y	124.8	0.00	0.23	0.73	1	5	2	93	0.00	0.0	7.699	0.060	0	0	1	2
PL.22265	PL.22105	A	#4 ACSR	7.49Y	124.8	0.00	0.23	0.73	1	5	2	93	0.00	0.0	7.703	0.005	0	0	0	1
PD.3116	PL.22265	A	20T	7.49Y	124.8	0.00	0.23	0.73	0	5	2	93	0.00	0.0	7.703	0.005	0	0	0	1
PL.22266	PD.3116	A	#4 ACSR	7.49Y	124.8	0.00	0.23	0.73	1	5	2	93	0.00	0.0	7.804	0.101	0	0	0	1
PL.22057	PL.22266	A	#4 ACSR	7.49Y	124.8	0.00	0.23	0.73	1	5	2	93	0.00	0.0	7.948	0.145	0	0	0	1
PL.22058	PL.22057	A	#4 ACSR	7.49Y	124.8	0.00	0.24	0.73	1	5	2	93	0.00	0.0	8.066	0.118	0	0	0	1
PL.22059	PL.22058	A	#4 ACSR	7.49Y	124.8	0.00	0.24	0.73	1	5	2	93	0.00	0.0	8.156	0.090	5	2	1	1
PL.22078	PL.21913	A	#4 ACSR	7.48Y	124.7	0.15	0.33	24.29	19	174	52	96	0.19	0.1	7.496	0.135	0	0	1	33
PL.22077	PL.22078	A	#4 ACSR	7.48Y	124.7	0.00	0.33	0.96	1	7	2	96	0.00	0.0	7.507	0.012	7	2	2	2
PL.22269	PL.22078	A	#4 ACSR	7.48Y	124.7	0.00	0.33	23.29	18	167	50	96	0.01	0.0	7.500	0.005	0	0	0	30
PD.3118	PL.22269	A	20T	7.48Y	124.7	0.00	0.33	23.29	0	167	50	96	0.00	0.0	7.500	0.005	0	0	0	30
PL.22270	PD.3118	A	#4 ACSR	7.47Y	124.6	0.10	0.44	23.29	18	167	50	96	0.13	0.1	7.599	0.098	0	0	1	30
PL.22137	PL.22270	A	#4 ACSR	7.47Y	124.5	0.03	0.47	19.86	15	142	43	96	0.03	0.0	7.638	0.040	20	6	3	24
PL.22138	PL.22137	A	#4 ACSR	7.47Y	124.4	0.10	0.57	17.06	13	122	37	96	0.09	0.1	7.766	0.128	0	0	1	21
PL.22114	PL.22138	A	#4 ACSR	7.46Y	124.4	0.03	0.60	17.03	13	122	37	96	0.03	0.0	7.808	0.042	7	2	1	20
PL.22113	PL.22114	A	#4 ACSR	7.46Y	124.4	0.02	0.62	16.10	12	115	35	96	0.02	0.0	7.838	0.030	0	0	0	19
PL.22263	PL.22113	A	#2 ACSR	7.46Y	124.4	0.00	0.62	16.10	9	115	35	96	0.00	0.0	7.843	0.004	0	0	0	19
PD.3115	PL.22263	A	30T	7.46Y	124.4	0.00	0.62	16.10	0	115	35	96	0.00	0.0	7.843	0.004	0	0	0	19
PL.22264	PD.3115	A	#2 ACSR	7.46Y	124.3	0.03	0.65	16.10	9	115	35	96	0.03	0.0	7.904	0.062	0	0	0	19
PL.21902	PL.22264	A	#1/0 ACSR	7.46Y	124.3	0.00	0.65	0.72	0	5	2	93	0.00	0.0	7.952	0.048	5	2	1	1
PL.22034	PL.22264	A	#2 ACSR	7.46Y	124.3	0.02	0.67	14.21	8	102	31	96	0.01	0.0	7.948	0.044	0	0	0	17
PL.22111	PL.22034	A	#4 ACSR	7.46Y	124.3	0.03	0.70	10.82	8	77	23	96	0.02	0.0	8.013	0.065	9	3	1	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22112	PL.22111	A	#4 ACSR	7.46Y	124.3	0.01	0.71	9.56	7	68	21	96	0.01	0.0	8.040	0.026	0	0	0	13
PL.22072	PL.22112	A	#4 ACSR	7.46Y	124.3	0.03	0.75	8.04	6	57	17	96	0.01	0.0	8.129	0.089	0	0	0	10
PL.21904	PL.22072	A	#2 ACSR	7.46Y	124.3	0.00	0.75	0.74	0	5	2	93	0.00	0.0	8.162	0.033	5	2	1	1
PL.22110	PL.22072	A	#4 ACSR	7.45Y	124.2	0.01	0.76	7.29	6	52	16	96	0.00	0.0	8.168	0.040	1	0	1	9
PL.22115	PL.22110	A	#4 ACSR	7.45Y	124.2	0.02	0.78	7.18	6	51	15	96	0.01	0.0	8.224	0.055	9	3	1	8
PL.22116	PL.22115	A	#4 ACSR	7.45Y	124.2	0.01	0.79	5.96	5	43	13	96	0.00	0.0	8.261	0.038	0	0	0	7
PL.21905	PL.22116	A	#1/0 ACSR	7.45Y	124.2	0.00	0.79	1.81	1	13	4	96	0.00	0.0	8.327	0.066	13	4	2	2
PL.22036	PL.22116	A	#4 ACSR	7.45Y	124.2	0.01	0.79	2.83	2	20	6	96	0.00	0.0	8.332	0.071	0	0	0	4
PL.21907	PL.22036	A	#2 ACSR	7.45Y	124.2	0.00	0.79	0.06	0	0	0	100	0.00	0.0	8.364	0.032	0	0	1	1
PL.22037	PL.22036	A	#4 ACSR	7.45Y	124.2	0.01	0.80	2.77	2	20	6	96	0.00	0.0	8.377	0.045	0	0	0	3
PL.22038	PL.22037	A	#4 ACSR	7.45Y	124.2	0.01	0.81	1.68	1	12	4	95	0.00	0.0	8.453	0.077	0	0	0	2
PL.22039	PL.22038	A	#4 ACSR	7.45Y	124.2	0.00	0.81	1.68	1	12	4	95	0.00	0.0	8.501	0.047	0	0	0	2
PL.22040	PL.22039	A	#4 ACSR	7.45Y	124.2	0.00	0.81	1.68	1	12	4	95	0.00	0.0	8.539	0.038	0	0	0	2
PL.22041	PL.22040	A	#4 ACSR	7.45Y	124.2	0.00	0.81	0.71	1	5	2	93	0.00	0.0	8.584	0.045	5	2	1	1
PL.21912	PL.22040	A	#4 ACSR	7.45Y	124.2	0.00	0.81	0.96	1	7	2	96	0.00	0.0	8.585	0.046	7	2	1	1
PL.21909	PL.22038	A	#4 ACSR	7.45Y	124.2	0.00	0.81	0.00	0	0	0	100	0.00	0.0	8.497	0.043	0	0	0	0
PL.21908	PL.22037	A	#1/0 ACSR	7.45Y	124.2	0.00	0.80	1.10	0	8	2	97	0.00	0.0	8.404	0.027	8	2	1	1
PL.21906	PL.22116	A	#4 ACSR	7.45Y	124.2	0.00	0.79	1.32	1	9	3	95	0.00	0.0	8.311	0.050	9	3	1	1
PL.22261	PL.22112	A	#4 ACSR	7.46Y	124.3	0.00	0.71	1.52	1	11	3	96	0.00	0.0	8.044	0.005	0	0	0	3
PD.3114	PL.22261	A	12T	7.46Y	124.3	0.00	0.71	1.52	0	11	3	96	0.00	0.0	8.044	0.005	0	0	0	3
PL.22262	PD.3114	A	#4 ACSR	7.46Y	124.3	0.00	0.72	1.52	1	11	3	96	0.00	0.0	8.111	0.067	0	0	0	3
PL.21903	PL.22262	A	#2 ACSR	7.46Y	124.3	0.00	0.72	1.21	1	9	3	95	0.00	0.0	8.154	0.043	9	3	1	1
PL.22108	PL.22262	A	#4 ACSR	7.46Y	124.3	0.00	0.72	0.31	0	2	1	89	0.00	0.0	8.237	0.126	2	1	2	2
PL.22109	PL.22108	A	#4 ACSR	7.46Y	124.3	0.00	0.72	0.00	0	0	0	100	0.00	0.0	8.353	0.116	0	0	0	0
PL.22035	PL.22034	A	#2 ACSR	7.46Y	124.3	0.00	0.67	1.12	1	8	2	97	0.00	0.0	7.965	0.017	8	2	1	1
PL.22246	PL.22034	A	#4 ACSR	7.46Y	124.3	0.00	0.68	2.28	2	16	5	95	0.00	0.0	8.002	0.054	9	3	1	2
PL.22247	PL.22246	A	#4 ACSR	7.46Y	124.3	0.00	0.68	0.96	1	7	2	96	0.00	0.0	8.041	0.040	7	2	1	1
PL.21901	PL.22264	A	#2 ACSR	7.46Y	124.3	0.00	0.65	1.17	1	8	3	94	0.00	0.0	7.921	0.017	8	3	1	1
PL.22136	PL.22270	A	#4 ACSR	7.47Y	124.6	0.01	0.44	3.43	3	25	7	96	0.00	0.0	7.651	0.052	0	0	0	5
PL.22139	PL.22136	A	#4 ACSR	7.47Y	124.5	0.01	0.45	3.43	3	25	7	96	0.00	0.0	7.726	0.075	20	6	3	5
PL.22141	PL.22139	A	#4 ACSR	7.47Y	124.5	0.00	0.45	0.61	0	4	1	97	0.00	0.0	7.747	0.021	0	0	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22140	PL.22141	A	#4 ACSR	7.47Y	124.5	0.00	0.45	0.61	0	4	1	97	0.00	0.0	7.806	0.059	4	1	1	1
PL.21900	PL.21899	A	#2 ACSR	7.50Y	125.1	0.00	-0.06	1.19	1	9	3	95	0.00	0.0	7.258	0.043	9	3	1	1
PL.21892	PL.21891	B	6 A (CWC)	7.12Y	118.7	0.00	6.35	1.03	1	7	2	96	0.00	0.0	6.957	0.076	7	2	1	1
PL.21893	PL.21891	A	#4 ACSR	7.12Y	118.7	0.00	6.34	1.27	1	9	3	95	0.00	0.0	6.894	0.013	9	3	2	2
PL.22279	PL.22097	C	#4 ACSR	7.14Y	119.0	0.00	5.95	2.68	2	18	6	95	0.00	0.0	6.177	0.005	0	0	0	2
PD.3123	PL.22279	C	65T	7.14Y	119.0	0.00	5.95	2.68	0	18	6	95	0.00	0.0	6.177	0.005	0	0	0	2
PL.22280	PD.3123	C	#4 ACSR	7.14Y	119.0	0.00	5.96	2.68	2	18	6	95	0.00	0.0	6.236	0.059	18	6	2	2
PL.22281	PL.21880	C	6 A (CWC)	7.15Y	119.2	0.00	5.81	4.42	3	30	9	96	0.00	0.0	5.964	0.005	0	0	0	5
PD.3124	PL.22281	C	65T	7.15Y	119.2	0.00	5.81	4.42	0	30	9	96	0.00	0.0	5.964	0.005	0	0	0	5
PL.22282	PD.3124	C	6 A (CWC)	7.15Y	119.2	0.01	5.82	4.42	3	30	9	96	0.00	0.0	6.026	0.062	0	0	0	5
PL.22175	PL.22282	C	6 A (CWC)	7.15Y	119.2	0.00	5.83	3.37	2	23	7	96	0.00	0.0	6.064	0.039	10	3	1	4
PL.22176	PL.22175	C	6 A (CWC)	7.15Y	119.2	0.00	5.83	1.93	1	13	4	96	0.00	0.0	6.105	0.041	8	2	2	3
PL.21881	PL.22176	C	#1/0 ACSR	7.15Y	119.2	0.00	5.83	0.74	0	5	2	93	0.00	0.0	6.143	0.038	5	2	1	1
PL.22032	PL.22282	C	6 A (CWC)	7.15Y	119.2	0.00	5.83	1.05	1	7	2	96	0.00	0.0	6.161	0.135	7	2	1	1
PL.21760	PL.21880	A	6 A (CWC)	7.15Y	119.2	0.00	5.81	2.05	1	14	4	96	0.00	0.0	5.964	0.005	0	0	0	2
PD.3195	PL.21760	A	65T	7.15Y	119.2	0.00	5.81	2.05	0	14	4	96	0.00	0.0	5.964	0.005	0	0	0	2
PL.21761	PD.3195	A	6 A (CWC)	7.15Y	119.2	0.01	5.82	2.05	1	14	4	96	0.00	0.0	6.090	0.126	7	2	1	2
PL.21882	PL.21761	A	#4 ACSR	7.15Y	119.2	0.00	5.82	0.98	1	7	2	96	0.00	0.0	6.125	0.035	7	2	1	1
PL.21941	PL.21866	C	6 A (CWC)	7.15Y	119.2	0.00	5.76	1.58	1	11	3	96	0.00	0.0	5.892	0.005	0	0	0	2
PD.3131	PL.21941	C	65T	7.15Y	119.2	0.00	5.76	1.58	0	11	3	96	0.00	0.0	5.892	0.005	0	0	0	2
PL.21942	PD.3131	C	6 A (CWC)	7.15Y	119.2	0.00	5.76	1.58	1	11	3	96	0.00	0.0	5.948	0.056	11	3	2	2
PL.21764	PL.22029	C	#1/0 ACSR	7.16Y	119.3	0.00	5.67	1.31	1	9	3	95	0.00	0.0	5.778	0.005	0	0	0	1
PD.3197	PL.21764	C	65T	7.16Y	119.3	0.00	5.67	1.31	0	9	3	95	0.00	0.0	5.778	0.005	0	0	0	1
PL.21765	PD.3197	C	#1/0 ACSR	7.16Y	119.3	0.00	5.68	1.31	1	9	3	95	0.00	0.0	5.860	0.082	9	3	1	1
PL.21943	PL.21938	A	#4 ACSR	7.16Y	119.4	0.00	5.61	0.80	1	5	2	93	0.00	0.0	5.708	0.005	0	0	0	1
PD.3132	PL.21943	A	65T	7.16Y	119.4	0.00	5.61	0.80	0	5	2	93	0.00	0.0	5.708	0.005	0	0	0	1
PL.21944	PD.3132	A	#4 ACSR	7.16Y	119.4	0.00	5.61	0.80	1	5	2	93	0.00	0.0	5.767	0.059	5	2	1	1
PL.21862	PL.66259	B	#4 ACSR	7.18Y	119.7	0.00	5.32	1.18	1	8	2	97	0.00	0.0	5.427	0.042	8	2	2	2
PL.22291	PL.66259	A	#4 ACSR	7.18Y	119.7	0.00	5.31	4.37	3	30	9	96	0.00	0.0	5.389	0.005	0	0	0	4
PD.3129	PL.22291	A	65T	7.18Y	119.7	0.00	5.31	4.37	0	30	9	96	0.00	0.0	5.389	0.005	0	0	0	4
PL.22292	PD.3129	A	#4 ACSR	7.18Y	119.7	0.01	5.33	4.37	3	30	9	96	0.00	0.0	5.460	0.070	4	1	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22162	PL.22292	A	#4 ACSR	7.18Y	119.7	0.00	5.33	3.72	3	26	8	96	0.00	0.0	5.509	0.049	26	8	3	3
PL.21939	PL.22096	C	#4 ACSR	7.19Y	119.9	0.00	5.13	3.24	2	22	7	95	0.00	0.0	5.216	0.005	0	0	0	3
PD.3130	PL.21939	C	65T	7.19Y	119.9	0.00	5.13	3.24	0	22	7	95	0.00	0.0	5.216	0.005	0	0	0	3
PL.21940	PD.3130	C	#4 ACSR	7.19Y	119.9	0.01	5.14	3.24	2	22	7	95	0.00	0.0	5.251	0.035	0	0	0	3
PL.22165	PL.21940	C	#4 ACSR	7.19Y	119.9	0.01	5.14	3.24	2	22	7	95	0.00	0.0	5.295	0.044	8	2	1	3
PL.22161	PL.22165	C	#4 ACSR	7.19Y	119.9	0.00	5.14	2.11	2	15	4	97	0.00	0.0	5.320	0.025	15	4	2	2
PL.22369	PL.22221	A	#4 ACSR	7.20Y	120.1	0.00	4.93	0.93	1	6	2	95	0.00	0.0	5.031	0.004	0	0	0	1
PD.3191	PL.22369	A	65T	7.20Y	120.1	0.00	4.93	0.93	0	6	2	95	0.00	0.0	5.031	0.004	0	0	0	1
PL.22370	PD.3191	A	#4 ACSR	7.20Y	120.1	0.00	4.93	0.93	1	6	2	95	0.00	0.0	5.095	0.064	6	2	1	1
PL.22328	PL.22093	A	#4 ACSR	7.21Y	120.2	0.00	4.81	0.64	0	4	1	97	0.00	0.0	4.921	0.005	0	0	0	1
PD.3170	PL.22328	A	65T	7.21Y	120.2	0.00	4.81	0.64	0	4	1	97	0.00	0.0	4.921	0.005	0	0	0	1
PL.22329	PD.3170	A	#4 ACSR	7.21Y	120.2	0.00	4.81	0.64	0	4	1	97	0.00	0.0	4.959	0.038	4	1	1	1
PL.22316	PL.22214	C	#4 ACSR	7.22Y	120.4	0.00	4.64	4.66	4	32	10	95	0.00	0.0	4.776	0.005	0	0	0	6
PD.3164	PL.22316	C	65T	7.22Y	120.4	0.00	4.64	4.66	0	32	10	95	0.00	0.0	4.776	0.005	0	0	0	6
PL.22317	PD.3164	C	#4 ACSR	7.22Y	120.3	0.01	4.66	4.66	4	32	10	95	0.00	0.0	4.842	0.067	0	0	0	6
PL.22091	PL.22317	C	#4 ACSR	7.22Y	120.3	0.00	4.66	4.11	3	28	9	95	0.00	0.0	4.874	0.031	18	6	2	4
PL.22155	PL.22091	C	#1/0 ACSR	7.22Y	120.3	0.00	4.66	1.45	1	10	3	96	0.00	0.0	4.905	0.031	0	0	0	2
PL.22156	PL.22155	C	#1/0 ACSR	7.22Y	120.3	0.00	4.66	1.45	1	10	3	96	0.00	0.0	4.940	0.035	10	3	2	2
PL.21860	PL.22317	C	#1/0 ACSR	7.22Y	120.3	0.00	4.66	0.54	0	4	1	97	0.00	0.0	4.882	0.039	4	1	2	2
PL.22365	PL.22214	A	#4 ACSR	7.22Y	120.4	0.00	4.64	0.34	0	2	1	89	0.00	0.0	4.775	0.004	0	0	0	1
PD.3189	PL.22365	A	65T	7.22Y	120.4	0.00	4.64	0.34	0	2	1	89	0.00	0.0	4.775	0.004	0	0	0	1
PL.22366	PD.3189	A	#4 ACSR	7.22Y	120.4	0.00	4.64	0.34	0	2	1	89	0.00	0.0	4.821	0.046	2	1	1	1
PL.22314	PL.22087	C	6 A (CWC)	7.23Y	120.5	0.00	4.54	5.07	4	35	11	95	0.00	0.0	4.684	0.005	0	0	0	5
PD.3163	PL.22314	C	65T	7.23Y	120.5	0.00	4.54	5.07	0	35	11	95	0.00	0.0	4.684	0.005	0	0	0	5
PL.22315	PD.3163	C	6 A (CWC)	7.23Y	120.5	0.01	4.55	5.07	4	35	11	95	0.00	0.0	4.749	0.065	9	3	1	5
PL.22215	PL.22315	C	6 A (CWC)	7.23Y	120.4	0.01	4.56	3.77	3	26	8	96	0.00	0.0	4.868	0.119	18	5	3	4
PL.21859	PL.22215	C	#4 ACSR	7.23Y	120.4	0.00	4.56	1.24	1	9	3	95	0.00	0.0	4.918	0.049	9	3	1	1
PL.21857	PL.22087	B	#4 ACSR	7.23Y	120.5	0.00	4.53	0.77	1	5	2	93	0.00	0.0	4.714	0.035	5	2	4	4
PL.22320	PL.22217	C	6 A (CWC)	7.24Y	120.6	0.00	4.41	0.21	0	1	0	100	0.00	0.0	4.587	0.005	0	0	0	1
PD.3166	PL.22320	C	65T	7.24Y	120.6	0.00	4.41	0.21	0	1	0	100	0.00	0.0	4.587	0.005	0	0	0	1
PL.22321	PD.3166	C	6 A (CWC)	7.24Y	120.6	0.00	4.41	0.21	0	1	0	100	0.00	0.0	4.642	0.056	1	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22361	PL.22082	A	#4 ACSR	7.25Y	120.9	0.00	4.12	0.35	0	2	1	89	0.00	0.0	4.354	0.005	0	0	0	1
PD.3187	PL.22361	A	65T	7.25Y	120.9	0.00	4.12	0.35	0	2	1	89	0.00	0.0	4.354	0.005	0	0	0	1
PL.22362	PD.3187	A	#4 ACSR	7.25Y	120.9	0.00	4.12	0.35	0	2	1	89	0.00	0.0	4.378	0.024	2	1	1	1
PL.22324	PL.22081	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	1.18	1	8	2	97	0.00	0.0	4.266	0.005	0	0	0	1
PD.3168	PL.22324	B	65T	7.26Y	121.0	0.00	4.01	1.18	0	8	2	97	0.00	0.0	4.266	0.005	0	0	0	1
PL.22325	PD.3168	B	6 A (CWC)	7.26Y	121.0	0.00	4.01	1.18	1	8	2	97	0.00	0.0	4.376	0.109	8	2	1	1
PL.22357	PL.22076	B	#4 ACSR	7.27Y	121.2	0.00	3.79	0.52	0	4	1	97	0.00	0.0	4.099	0.005	0	0	0	1
PD.3185	PL.22357	B	65T	7.27Y	121.2	0.00	3.79	0.52	0	4	1	97	0.00	0.0	4.099	0.005	0	0	0	1
PL.22358	PD.3185	B	#4 ACSR	7.27Y	121.2	0.00	3.79	0.52	0	4	1	97	0.00	0.0	4.166	0.067	4	1	1	1
PL.21967	PL.22181	C	#2 ACSR	7.30Y	121.6	0.00	3.36	0.65	0	5	1	98	0.00	0.0	3.783	0.005	0	0	0	2
PD.3144	PL.21967	C	65T	7.30Y	121.6	0.00	3.36	0.65	0	5	1	98	0.00	0.0	3.783	0.005	0	0	0	2
PL.21968	PD.3144	C	#2 ACSR	7.30Y	121.6	0.00	3.36	0.65	0	5	1	98	0.00	0.0	3.828	0.045	0	0	1	2
PL.22189	PL.21968	C	#2 ACSR	7.30Y	121.6	0.00	3.36	0.58	0	4	1	97	0.00	0.0	3.869	0.040	0	0	0	1
PL.22179	PL.22189	C	#2 ACSR	7.30Y	121.6	0.00	3.36	0.58	0	4	1	97	0.00	0.0	3.907	0.038	4	1	1	1
PL.21961	PL.22192	A	6 A (CWC)	7.32Y	122.0	0.00	2.99	0.91	1	6	2	95	0.00	0.0	3.524	0.004	0	0	0	1
PD.3141	PL.21961	A	65T	7.32Y	122.0	0.00	2.99	0.91	0	6	2	95	0.00	0.0	3.524	0.004	0	0	0	1
PL.21962	PD.3141	A	6 A (CWC)	7.32Y	122.0	0.00	2.99	0.91	1	6	2	95	0.00	0.0	3.551	0.027	0	0	0	1
PL.21754	PL.21962	A	#1/0 ACSR	7.32Y	122.0	0.00	2.99	0.91	0	6	2	95	0.00	0.0	3.581	0.029	6	2	1	1
PL.21975	PL.21933	A	#4 ACSR	7.33Y	122.2	0.00	2.79	0.56	0	4	1	97	0.00	0.0	3.391	0.005	0	0	0	1
PD.3148	PL.21975	A	65T	7.33Y	122.2	0.00	2.79	0.56	0	4	1	97	0.00	0.0	3.391	0.005	0	0	0	1
PL.21976	PD.3148	A	#4 ACSR	7.33Y	122.2	0.00	2.79	0.56	0	4	1	97	0.00	0.0	3.432	0.041	4	1	1	1
PL.21762	PL.21751	C	#4 ACSR	7.34Y	122.3	0.00	2.70	2.12	2	15	4	97	0.00	0.0	3.329	0.005	0	0	0	2
PD.3196	PL.21762	C	65T	7.34Y	122.3	0.00	2.70	2.12	0	15	4	97	0.00	0.0	3.329	0.005	0	0	0	2
PL.21763	PD.3196	C	#4 ACSR	7.34Y	122.3	0.00	2.70	2.12	2	15	4	97	0.00	0.0	3.383	0.054	15	4	2	2
PL.21750	PL.22051	C	#4 ACSR	7.35Y	122.5	0.01	2.49	1.82	1	13	4	96	0.00	0.0	3.255	0.069	0	0	0	2
PL.21979	PL.21750	C	#4 ACSR	7.35Y	122.5	0.00	2.49	1.82	1	13	4	96	0.00	0.0	3.260	0.005	0	0	0	2
PD.3150	PL.21979	C	65T	7.35Y	122.5	0.00	2.49	1.82	0	13	4	96	0.00	0.0	3.260	0.005	0	0	0	2
PL.21980	PD.3150	C	#4 ACSR	7.35Y	122.5	0.01	2.50	1.82	1	13	4	96	0.00	0.0	3.326	0.066	0	0	0	2
PL.21752	PL.21980	C	#4 ACSR	7.35Y	122.5	0.00	2.50	1.82	1	13	4	96	0.00	0.0	3.340	0.014	13	4	2	2
PL.21977	PL.22051	A	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.88	0	6	2	95	0.00	0.0	3.191	0.005	0	0	0	1
PD.3149	PL.21977	A	65T	7.35Y	122.5	0.00	2.49	0.88	0	6	2	95	0.00	0.0	3.191	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21978	PD.3149	A	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.88	0	6	2	95	0.00	0.0	3.311	0.120	6	2	1	1
PL.21772	PL.21915	ABC	#4 ACSR	7.39Y	123.2	0.00	1.81	7.40	6	148	71	90	0.00	0.0	2.747	0.005	0	0	0	1
PD.3201	PL.21772	ABC	65T	7.39Y	123.2	0.00	1.81	7.40	0	148	71	90	0.00	0.0	2.747	0.005	0	0	0	1
PL.21773	PD.3201	ABC	#4 ACSR	7.39Y	123.2	0.00	1.81	7.40	6	148	71	90	0.00	0.0	2.760	0.013	0	0	0	1
PL.22207	PL.21773	ABC	#4 ACSR	7.39Y	123.2	0.00	1.81	7.40	6	148	71	90	0.00	0.0	2.774	0.014	148	71	1	1
PL.21768	PL.21739	A	6 A (CWC)	7.40Y	123.3	0.00	1.70	2.55	2	18	5	96	0.00	0.0	2.683	0.005	0	0	0	2
PD.3199	PL.21768	A	65T	7.40Y	123.3	0.00	1.70	2.55	0	18	5	96	0.00	0.0	2.683	0.005	0	0	0	2
PL.21769	PD.3199	A	6 A (CWC)	7.40Y	123.3	0.01	1.70	2.55	2	18	5	96	0.00	0.0	2.746	0.063	0	0	0	2
PL.22257	PL.21769	A	#2 ACSR	7.40Y	123.3	0.00	1.71	2.55	1	18	5	96	0.00	0.0	2.820	0.074	13	4	1	2
PL.22258	PL.22257	A	#2 ACSR	7.40Y	123.3	0.00	1.71	0.66	0	5	1	98	0.00	0.0	2.898	0.078	0	0	0	1
PL.21875	PL.22258	A	#2 ACSR	7.40Y	123.3	0.00	1.71	0.66	0	5	1	98	0.00	0.0	2.962	0.064	5	1	1	1
PL.22308	PL.21925	C	#1/0 ACSR	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	2.596	0.004	0	0	0	0
PD.3160	PL.22308	C	65T	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	2.596	0.004	0	0	0	0
PL.22309	PD.3160	C	#1/0 ACSR	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	2.623	0.027	0	0	0	0
PL.22294	PL.22346	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.49	0	3	1	95	0.00	0.0	1.759	0.005	0	0	0	2
PD.3153	PL.22294	A	65T	7.44Y	124.1	0.00	0.94	0.49	0	3	1	95	0.00	0.0	1.759	0.005	0	0	0	2
PL.22295	PD.3153	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.49	0	3	1	95	0.00	0.0	1.767	0.008	0	0	0	2
PL.21730	PL.22295	A	#4 ACSR	7.44Y	124.1	0.00	0.94	0.49	0	3	1	95	0.00	0.0	1.883	0.115	0	0	0	2
PL.22046	PL.21730	A	#4 ACSR	7.44Y	124.1	0.00	0.94	0.49	0	3	1	95	0.00	0.0	1.965	0.082	0	0	1	2
PL.21731	PL.22046	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	1.989	0.024	0	0	0	1
PL.21983	PL.21731	A	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	1.994	0.005	0	0	0	1
PD.3152	PL.21983	A	40T	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	1.994	0.005	0	0	0	1
PL.22293	PD.3152	A	1/0 AL URD	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	2.012	0.019	0	0	0	1
PL.21981	PL.22293	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	2.017	0.005	0	0	0	1
PD.3151	PL.21981	A	25T	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	2.017	0.005	0	0	0	1
PL.21982	PD.3151	A	#1/0 ACSR	7.44Y	124.1	0.00	0.94	0.47	0	3	1	95	0.00	0.0	2.179	0.162	3	1	1	1
PL.22347	PL.22067	A	#4 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	1.674	0.005	0	0	0	0
PD.3180	PL.22347	A	65T	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	1.674	0.005	0	0	0	0
PL.22348	PD.3180	A	#4 ACSR	7.45Y	124.1	0.00	0.87	0.00	0	0	0	100	0.00	0.0	1.710	0.036	0	0	0	0
PL.22296	PL.22198	A	#2 ACSR	7.45Y	124.2	0.00	0.77	0.76	0	5	2	93	0.00	0.0	1.553	0.005	0	0	0	2
PD.3154	PL.22296	A	65T	7.45Y	124.2	0.00	0.77	0.76	0	5	2	93	0.00	0.0	1.553	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22297	PD.3154	A	#2 ACSR	7.45Y	124.2	0.00	0.77	0.76	0	5	2	93	0.00	0.0	1.591	0.038	5	2	2	2
PL.22341	PL.22045	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	8.30	4	59	18	96	0.00	0.0	1.069	0.004	0	0	0	2
PD.3178	PL.22341	C	65T	7.47Y	124.6	0.00	0.43	8.30	0	59	18	96	0.00	0.0	1.069	0.004	0	0	0	2
PL.22342	PD.3178	C	#1/0 ACSR	7.47Y	124.6	0.00	0.43	8.30	4	59	18	96	0.00	0.0	1.086	0.016	59	18	2	2
PL.22333	PL.22236	A	#4 ACSR	7.48Y	124.6	0.00	0.37	3.63	3	26	8	96	0.00	0.0	0.922	0.004	0	0	0	6
PD.3173	PL.22333	A	65T	7.48Y	124.6	0.00	0.37	3.63	0	26	8	96	0.00	0.0	0.922	0.004	0	0	0	6
PL.22334	PD.3173	A	#4 ACSR	7.48Y	124.6	0.01	0.38	3.63	3	26	8	96	0.00	0.0	0.993	0.070	8	2	1	6
PL.22234	PL.22334	A	#4 ACSR	7.48Y	124.6	0.00	0.39	2.51	2	18	5	96	0.00	0.0	1.031	0.038	5	1	3	5
PL.22233	PL.22234	A	#4 ACSR	7.48Y	124.6	0.00	0.39	1.87	1	13	4	96	0.00	0.0	1.115	0.085	13	4	1	2
PL.22331	PL.22233	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	0.08	0	1	0	100	0.00	0.0	1.120	0.005	0	0	0	1
PD.3172	PL.22331	A	40T	7.48Y	124.6	0.00	0.39	0.08	0	1	0	100	0.00	0.0	1.120	0.005	0	0	0	1
PL.22332	PD.3172	A	#1/0 ACSR	7.48Y	124.6	0.00	0.39	0.08	0	1	0	100	0.00	0.0	1.177	0.057	1	0	1	1
PL.22335	PL.22044	C	#4 ACSR	7.48Y	124.7	0.00	0.32	6.17	5	44	13	96	0.00	0.0	0.786	0.004	0	0	0	12
PD.3174	PL.22335	C	65T	7.48Y	124.7	0.00	0.32	6.17	0	44	13	96	0.00	0.0	0.786	0.004	0	0	0	12
PL.22336	PD.3174	C	#4 ACSR	7.48Y	124.7	0.01	0.33	6.17	5	44	13	96	0.00	0.0	0.831	0.045	14	4	3	12
PL.22240	PL.22336	C	#4 ACSR	7.48Y	124.6	0.02	0.35	4.27	3	31	9	96	0.00	0.0	0.939	0.108	1	0	1	9
PL.22239	PL.22240	C	#4 ACSR	7.48Y	124.6	0.01	0.36	4.18	3	30	9	96	0.00	0.0	1.014	0.075	4	1	2	8
PL.21726	PL.22239	C	#2 ACSR	7.48Y	124.6	0.00	0.36	1.23	1	9	3	95	0.00	0.0	1.040	0.026	9	3	1	1
PL.21727	PL.22239	C	#4 ACSR	7.48Y	124.6	0.00	0.37	2.36	2	17	5	96	0.00	0.0	1.058	0.044	4	1	2	5
PL.21729	PL.21727	C	#2 ACSR	7.48Y	124.6	0.00	0.37	1.41	1	10	3	96	0.00	0.0	1.087	0.030	0	0	0	2
PL.22237	PL.21729	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	1.41	1	10	3	96	0.00	0.0	1.101	0.014	5	1	1	2
PL.22238	PL.22237	C	#1/0 ACSR	7.48Y	124.6	0.00	0.37	0.74	0	5	2	93	0.00	0.0	1.203	0.102	5	2	1	1
PL.21919	PL.21729	C	#2 ACSR	7.48Y	124.6	0.00	0.37	0.00	0	0	0	100	0.00	0.0	1.125	0.037	0	0	0	0
PL.21728	PL.21727	C	#4 ACSR	7.48Y	124.6	0.00	0.37	0.42	0	3	1	95	0.00	0.0	1.092	0.034	3	1	1	1
PL.22065	PL.22066	B	#1/0 ACSR	7.49Y	124.8	0.00	0.23	1.37	1	10	3	96	0.00	0.0	0.559	0.011	0	0	0	2
PD.3175	PL.22065	B	65T	7.49Y	124.8	0.00	0.23	1.37	0	10	3	96	0.00	0.0	0.559	0.011	0	0	0	2
PL.22337	PD.3175	B	#1/0 ACSR	7.49Y	124.8	0.00	0.23	1.37	1	10	3	96	0.00	0.0	0.613	0.054	0	0	1	2
PL.22226	PL.22337	B	#1/0 ACSR	7.49Y	124.8	0.00	0.23	1.30	1	9	3	95	0.00	0.0	0.657	0.044	9	3	1	1
PL.22339	PL.21916	A	6 A (CWC)	7.49Y	124.8	0.00	0.18	6.78	5	49	15	96	0.00	0.0	0.431	0.004	0	0	0	10
PD.3177	PL.22339	A	65T	7.49Y	124.8	0.00	0.18	6.78	0	49	15	96	0.00	0.0	0.431	0.004	0	0	0	10
PL.22340	PD.3177	A	6 A (CWC)	7.49Y	124.8	0.02	0.20	6.78	5	49	15	96	0.01	0.0	0.510	0.079	0	0	0	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Hargett

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22064	PL.22340	A	6 A (CWC)	7.49Y	124.8	0.01	0.21	1.65	1	12	4	95	0.00	0.0	0.613	0.103	0	0	0	4
PL.22042	PL.22064	A	6 A (CWC)	7.49Y	124.8	0.01	0.22	1.65	1	12	4	95	0.00	0.0	0.729	0.116	0	0	0	4
PL.21918	PL.22042	A	6 A (CWC)	7.49Y	124.8	0.01	0.23	1.36	1	10	3	96	0.00	0.0	0.831	0.102	0	0	0	3
PL.22229	PL.21918	A	6 A (CWC)	7.49Y	124.8	0.01	0.23	1.36	1	10	3	96	0.00	0.0	0.940	0.109	0	0	1	3
PL.22230	PL.22229	A	6 A (CWC)	7.49Y	124.8	0.00	0.24	1.36	1	10	3	96	0.00	0.0	0.989	0.049	0	0	0	2
PL.22227	PL.22230	A	#2 ACSR	7.49Y	124.8	0.00	0.24	0.86	0	6	2	95	0.00	0.0	1.044	0.055	6	2	1	1
PL.22228	PL.22227	A	#2 ACSR	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.115	0.071	0	0	0	0
PL.22043	PL.22228	A	#2 ACSR	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.248	0.132	0	0	0	0
PL.21722	PL.22230	A	6 A (CWC)	7.49Y	124.8	0.00	0.24	0.50	0	4	1	97	0.00	0.0	1.079	0.090	4	1	1	1
PL.21723	PL.21722	A	#2 ACSR	7.49Y	124.8	0.00	0.24	0.00	0	0	0	100	0.00	0.0	1.121	0.042	0	0	0	0
PL.21721	PL.22042	A	#4 ACSR	7.49Y	124.8	0.00	0.22	0.29	0	2	1	89	0.00	0.0	0.797	0.069	2	1	1	1
PL.21720	PL.22340	A	#1/0 ACSR	7.49Y	124.8	0.00	0.21	5.13	2	37	11	96	0.00	0.0	0.528	0.018	4	1	1	6
PL.22231	PL.21720	A	#1/0 ACSR	7.49Y	124.8	0.00	0.21	4.63	2	33	10	96	0.00	0.0	0.576	0.048	5	2	1	5
PL.22232	PL.22231	A	#1/0 ACSR	7.49Y	124.8	0.00	0.21	3.91	2	28	8	96	0.00	0.0	0.624	0.048	8	2	1	4
PL.21724	PL.22232	A	#1/0 ACSR	7.49Y	124.8	0.00	0.22	1.78	1	13	4	96	0.00	0.0	0.707	0.083	13	4	2	2
PL.21725	PL.22232	A	#1/0 ACSR	7.49Y	124.8	0.00	0.21	1.06	0	8	2	97	0.00	0.0	0.674	0.050	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load Losses	Total		
KW	7167	0	0	0	0	0	135	0.00	7303	Lowest Voltage = 118.03 on Element PL.21896	
KVAR	2181	0	0	0	0	0	231		2412	Max Accm VoltD = 6.97 on Element PL.21896	
										Max Elem VoltD = 0.52 on Element PL.22508	