

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Keavy 2		ABC	SRC-Keavy	7.50Y	125.0	0.00	0.00	589.42	0	12594	4155	95	0.00	0.0	0.000	0.000	0	0	0	1487
PL.59428	Keavy 2	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	190.39	37	4081	1304	95	0.08	0.0	0.003	0.003	0	0	0	458
PL.59420	PL.59428	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	190.39	37	4081	1303	95	0.08	0.0	0.005	0.003	0	0	0	458
----- Feeder No. 3 (Level Green F3) Beginning with Device PD.8768 -----																				
PD.8768	PL.59420	ABC	400VWE	7.50Y	125.0	0.00	0.01	190.39	0	4080	1303	95	0.00	0.0	0.005	0.003	0	0	0	458
PL.59285	PD.8768	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	190.39	37	4080	1303	95	0.10	0.0	0.008	0.003	0	0	1	458
PL.59286	PL.59285	ABC	336 MCM AC	7.47Y	124.5	0.49	0.50	190.39	37	4080	1303	95	10.12	0.2	0.340	0.332	8	2	1	457
PL.42177	PL.59286	ABC	336 MCM AC	7.45Y	124.2	0.28	0.78	190.00	37	4062	1277	95	5.77	0.1	0.530	0.190	0	0	0	456
PL.42179	PL.42177	C	6 A (CWC)	7.45Y	124.2	0.00	0.78	0.00	0	0	0	100	0.00	0.0	0.536	0.006	0	0	0	0
PD.6643	PL.42179	C	75QA	7.45Y	124.2	0.00	0.78	0.00	0	0	0	100	0.00	0.0	0.536	0.006	0	0	0	0
PL.56489	PD.6643	C	6 A (CWC)	7.45Y	124.2	0.00	0.78	0.00	0	0	0	100	0.00	0.0	0.567	0.031	0	0	0	0
PL.57174	PL.56489	C	6 A (CWC)	7.45Y	124.2	0.00	0.78	0.00	0	0	0	100	0.00	0.0	0.651	0.084	0	0	0	0
PL.42178	PL.42177	ABC	336 MCM AC	7.45Y	124.1	0.10	0.88	190.00	37	4056	1264	95	2.02	0.0	0.597	0.067	12	3	2	456
PL.41280	PL.42178	ABC	6 A (CWC)	7.45Y	124.1	0.01	0.88	3.05	2	61	30	90	0.00	0.0	0.640	0.043	0	0	0	1
PL.41893	PL.41280	C	1/0 AL URD	7.45Y	124.1	0.00	0.89	9.15	5	61	30	90	0.00	0.0	0.646	0.006	0	0	0	1
PD.6477	PL.41893	C	60QA	7.45Y	124.1	0.00	0.89	9.15	15	61	30	90	0.00	0.0	0.646	0.006	0	0	0	1
PL.41894	PD.6477	C	1/0 AL URD	7.45Y	124.1	0.00	0.89	9.15	5	61	30	90	0.00	0.0	0.661	0.015	61	30	1	1
PL.41895	PL.42178	ABC	336 MCM AC	7.45Y	124.1	0.04	0.92	186.45	36	3981	1226	96	0.76	0.0	0.623	0.026	0	0	0	453
PL.41896	PL.41895	ABC	#4 ACSR	7.45Y	124.1	0.00	0.92	0.00	0	0	0	100	0.00	0.0	0.628	0.006	0	0	0	0
PD.6644	PL.41896	ABC	20QA	7.45Y	124.1	0.00	0.92	0.00	0	0	0	100	0.00	0.0	0.628	0.006	0	0	0	0
PL.41897	PD.6644	ABC	#4 ACSR	7.45Y	124.1	0.00	0.92	0.00	0	0	0	100	0.00	0.0	0.666	0.037	0	0	0	0
PL.56653	PL.41895	ABC	336 MCM AC	7.43Y	123.8	0.28	1.19	186.45	36	3980	1224	96	5.71	0.1	0.818	0.195	2	1	1	453
PL.56654	PL.56653	ABC	336 MCM AC	7.42Y	123.7	0.07	1.26	186.36	36	3973	1211	96	1.39	0.0	0.865	0.047	0	0	0	452
PL.58931	PL.56654	ABC	336 MCM AC	7.41Y	123.5	0.26	1.53	186.36	36	3971	1207	96	5.41	0.1	1.050	0.185	9	2	1	452
PL.62343	PL.58931	ABC	336 MCM AC	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	1.050	0.000	0	0	0	0
PD.9332	PL.62343	C	30T	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	1.050	0.000	0	0	0	0
PL.62346	PD.9332	C	6 A (CWC)	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	1.051	0.000	0	0	0	0
PL.62344	PL.62346	C	6 A (CWC)	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	1.088	0.037	0	0	0	0
PL.62345	PL.62346	C	6 A (CWC)	7.41Y	123.5	0.00	1.53	0.00	0	0	0	100	0.00	0.0	1.120	0.069	0	0	0	0
PL.59363	PL.58931	ABC	336 MCM AC	7.40Y	123.3	0.14	1.66	185.92	36	3956	1192	96	2.80	0.1	1.147	0.096	11	3	1	451

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59365	PL.59363	ABC	#3/0 ACSR	7.39Y	123.1	0.24	1.90	169.84	57	3608	1094	96	5.34	0.1	1.257	0.111	22	6	2	406
PL.56225	PL.59365	A	6 A (CWC)	7.39Y	123.1	0.00	1.90	1.69	1	12	3	97	0.00	0.0	1.263	0.006	0	0	0	1
PD.8315	PL.56225	A	60QA	7.39Y	123.1	0.00	1.90	1.69	3	12	3	97	0.00	0.0	1.263	0.006	0	0	0	1
PL.56226	PD.8315	A	6 A (CWC)	7.39Y	123.1	0.00	1.91	1.69	1	12	3	97	0.00	0.0	1.320	0.057	12	3	1	1
PL.56501	PL.59365	ABC	#3/0 ACSR	7.38Y	123.0	0.15	2.05	168.27	56	3569	1077	96	3.20	0.1	1.325	0.067	8	2	1	403
PL.56502	PL.56501	ABC	#3/0 ACSR	7.37Y	122.8	0.12	2.17	167.89	56	3558	1070	96	2.68	0.1	1.381	0.057	14	4	3	402
PL.41784	PL.56502	ABC	#3/0 ACSR	7.36Y	122.7	0.14	2.31	167.23	56	3541	1063	96	3.08	0.1	1.447	0.066	13	4	1	399
PL.56504	PL.41784	ABC	#3/0 ACSR	7.35Y	122.5	0.21	2.52	166.61	56	3525	1055	96	4.59	0.1	1.546	0.098	6	2	1	398
PL.56726	PL.56504	A	6 A (CWC)	7.35Y	122.5	0.00	2.52	0.63	0	4	1	97	0.00	0.0	1.573	0.028	0	0	0	1
PL.56725	PL.56726	A	#1/0 ACSR	7.35Y	122.5	0.00	2.52	0.63	0	4	1	97	0.00	0.0	1.777	0.204	4	1	1	1
PL.56730	PL.56726	A	6 A (CWC)	7.35Y	122.5	0.00	2.52	0.00	0	0	0	100	0.00	0.0	1.610	0.037	0	0	0	0
PL.56505	PL.56504	A	6 A (CWC)	7.35Y	122.5	0.00	2.52	1.59	1	11	3	96	0.00	0.0	1.551	0.006	0	0	0	1
PD.6766	PL.56505	A	60QA	7.35Y	122.5	0.00	2.52	1.59	3	11	3	96	0.00	0.0	1.551	0.006	0	0	0	1
PL.56224	PD.6766	A	6 A (CWC)	7.35Y	122.5	0.00	2.52	1.59	1	11	3	96	0.00	0.0	1.588	0.036	11	3	1	1
PL.56506	PL.56504	ABC	#3/0 ACSR	7.34Y	122.3	0.22	2.74	165.58	55	3498	1042	96	4.72	0.1	1.648	0.103	9	2	1	395
PL.41786	PL.56506	ABC	#3/0 ACSR	7.32Y	122.0	0.21	2.95	163.93	55	3458	1026	96	4.58	0.1	1.750	0.101	0	0	0	391
PL.42532	PL.41786	ABC	#3/0 ACSR	7.32Y	122.0	0.06	3.01	162.57	54	3425	1012	96	1.26	0.0	1.778	0.028	7	2	1	389
PL.42533	PL.42532	ABC	#3/0 ACSR	7.31Y	121.9	0.11	3.12	162.22	54	3416	1008	96	2.35	0.1	1.831	0.053	11	3	1	388
PL.42534	PL.42533	B	6 A (CWC)	7.31Y	121.9	0.01	3.13	26.16	19	185	49	97	0.01	0.0	1.837	0.006	0	0	0	24
PD.6612	PL.42534	B	60QA	7.31Y	121.9	0.00	3.13	26.16	44	185	49	97	0.00	0.0	1.837	0.006	0	0	0	24
PL.57978	PD.6612	B	6 A (CWC)	7.31Y	121.8	0.12	3.25	26.16	19	185	49	97	0.16	0.1	1.949	0.112	34	9	3	24
PL.61173	PL.57978	B	1/0 AL URD	7.30Y	121.7	0.00	3.25	1.02	1	7	2	96	0.00	0.0	1.983	0.034	0	0	0	2
PL.61174	PL.61173	B	1/0 AL URD	7.30Y	121.7	0.00	3.25	1.02	1	7	2	96	0.00	0.0	2.062	0.079	7	2	2	2
PL.57980	PL.57978	B	6 A (CWC)	7.30Y	121.7	0.04	3.28	20.38	15	144	38	97	0.04	0.0	1.987	0.038	0	0	0	19
PL.57981	PL.57980	B	6 A (CWC)	7.30Y	121.6	0.09	3.37	16.48	12	116	31	97	0.07	0.1	2.107	0.120	12	3	1	16
PL.57979	PL.57981	B	6 A (CWC)	7.30Y	121.6	0.04	3.41	12.85	9	91	24	97	0.02	0.0	2.177	0.070	19	5	1	14
PL.56930	PL.57979	B	6 A (CWC)	7.29Y	121.6	0.02	3.43	10.15	7	72	19	97	0.01	0.0	2.221	0.044	9	2	1	13
PL.56931	PL.56930	B	6 A (CWC)	7.29Y	121.5	0.02	3.45	8.93	6	63	17	97	0.01	0.0	2.291	0.070	18	5	2	12
PL.56932	PL.56931	B	6 A (CWC)	7.29Y	121.5	0.01	3.46	6.37	5	45	12	97	0.00	0.0	2.327	0.036	0	0	0	10
PL.56708	PL.56932	B	6 A (CWC)	7.29Y	121.5	0.01	3.48	5.86	4	41	11	97	0.00	0.0	2.381	0.054	0	0	0	8
PL.56709	PL.56708	B	6 A (CWC)	7.29Y	121.5	0.00	3.48	2.18	2	15	4	97	0.00	0.0	2.433	0.052	6	2	3	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56707	PL.56709	B	#2 ACSR	7.29Y	121.5	0.00	3.48	1.34	1	9	2	98	0.00	0.0	2.480	0.047	9	2	2	2
PL.56706	PL.56709	B	6 A (CWC)	7.29Y	121.5	0.00	3.48	0.00	0	0	0	100	0.00	0.0	2.447	0.014	0	0	0	0
PL.56710	PL.56708	B	#1/0 ACSR	7.29Y	121.5	0.00	3.48	3.68	2	26	7	97	0.00	0.0	2.406	0.025	0	0	0	3
PL.56711	PL.56710	B	#1/0 ACSR	7.29Y	121.5	0.00	3.48	3.68	2	26	7	97	0.00	0.0	2.429	0.023	10	3	1	3
PL.62033	PL.56711	B	#1/0 ACSR	7.29Y	121.5	0.01	3.48	2.31	1	16	4	97	0.00	0.0	2.547	0.118	6	1	1	2
PL.62034	PL.62033	B	#1/0 ACSR	7.29Y	121.5	0.00	3.49	1.51	1	11	3	96	0.00	0.0	2.619	0.072	11	3	1	1
PL.56705	PL.56932	B	#1/0 ACSR	7.29Y	121.5	0.00	3.46	0.51	0	4	1	97	0.00	0.0	2.370	0.043	4	1	2	2
PL.72484	PL.57979	B	#2 ACSR	7.30Y	121.6	0.00	3.41	0.00	0	0	0	100	0.00	0.0	2.201	0.023	0	0	0	0
PL.57977	PL.57981	B	#4 ACSR	7.30Y	121.6	0.00	3.37	1.88	1	13	4	96	0.00	0.0	2.140	0.033	13	4	1	1
PL.57982	PL.57980	B	4/0 AL URD	7.30Y	121.7	0.00	3.28	3.89	2	28	7	97	0.00	0.0	1.987	0.000	18	5	2	3
PL.63222	PL.57982	B	1/0 AL URD	7.30Y	121.7	0.00	3.29	1.41	1	10	3	96	0.00	0.0	2.033	0.047	0	0	0	1
PL.63472	PL.63222	B	1/0 AL URD	7.30Y	121.7	0.00	3.29	1.41	1	10	3	96	0.00	0.0	2.117	0.083	0	0	0	1
PL.63473	PL.63472	B	1/0 AL URD	7.30Y	121.7	0.00	3.29	1.41	1	10	3	96	0.00	0.0	2.117	0.000	10	3	1	1
PL.56961	PL.42533	ABC	#3/0 ACSR	7.30Y	121.6	0.29	3.41	152.98	51	3218	953	96	5.76	0.2	1.978	0.147	11	3	1	363
PL.56962	PL.56961	ABC	#3/0 ACSR	7.29Y	121.5	0.14	3.54	152.16	51	3195	940	96	2.73	0.1	2.048	0.070	0	0	0	360
PL.56934	PL.56962	A	#4 ACSR	7.29Y	121.5	0.00	3.55	3.35	3	24	6	97	0.00	0.0	2.054	0.006	0	0	0	2
PD.8335	PL.56934	A	20QA	7.29Y	121.5	0.00	3.55	3.35	17	24	6	97	0.00	0.0	2.054	0.006	0	0	0	2
PL.56927	PD.8335	A	#4 ACSR	7.29Y	121.4	0.01	3.55	3.35	3	24	6	97	0.00	0.0	2.115	0.060	0	0	0	2
PL.56926	PL.56927	A	#4 ACSR	7.29Y	121.4	0.00	3.56	3.35	3	24	6	97	0.00	0.0	2.142	0.027	24	6	2	2
PL.42037	PL.56962	ABC	#1/0 ACSR	7.27Y	121.2	0.23	3.78	108.22	47	2264	688	96	3.68	0.2	2.166	0.118	5	1	1	253
PL.56734	PL.42037	ABC	#1/0 ACSR	7.26Y	121.0	0.20	3.98	107.81	47	2251	682	96	3.20	0.1	2.270	0.103	0	0	0	251
PL.56735	PL.56734	C	#4 ACSR	7.26Y	121.0	0.00	3.98	4.92	4	35	9	97	0.00	0.0	2.275	0.006	0	0	0	4
PD.6636	PL.56735	C	60QA	7.26Y	121.0	0.00	3.98	4.92	8	35	9	97	0.00	0.0	2.275	0.006	0	0	0	4
PL.42038	PD.6636	C	#4 ACSR	7.26Y	121.0	0.01	3.99	4.92	4	35	9	97	0.00	0.0	2.321	0.046	26	7	2	4
PL.42039	PL.42038	C	#4 ACSR	7.26Y	121.0	0.00	3.99	1.26	1	9	2	98	0.00	0.0	2.373	0.051	9	2	2	2
PL.56736	PL.56734	ABC	#1/0 ACSR	7.26Y	121.0	0.05	4.03	106.17	46	2214	670	96	0.79	0.0	2.296	0.026	1	0	1	247
PL.56724	PL.56736	ABC	#1/0 ACSR	7.25Y	120.8	0.18	4.21	106.13	46	2212	669	96	2.79	0.1	2.389	0.093	0	0	0	246
PL.56723	PL.56724	ABC	#1/0 ACSR	7.24Y	120.7	0.09	4.30	105.26	46	2191	661	96	1.34	0.1	2.434	0.046	11	3	1	243
PL.56490	PL.56723	ABC	#1/0 ACSR	7.24Y	120.6	0.07	4.37	104.75	46	2179	657	96	1.05	0.0	2.470	0.036	4	1	1	242
PL.58488	PL.56490	C	#4 ACSR	7.24Y	120.6	0.00	4.37	3.76	3	26	7	97	0.00	0.0	2.474	0.003	0	0	0	5
PD.8693	PL.58488	C	25T	7.24Y	120.6	0.00	4.37	3.76	0	26	7	97	0.00	0.0	2.474	0.003	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58489	PD.8693	C	#4 ACSR	7.24Y	120.6	0.01	4.38	3.76	3	26	7	97	0.00	0.0	2.513	0.040	0	0	1	5
PL.58487	PL.58489	C	#4 ACSR	7.24Y	120.6	0.01	4.39	3.69	3	26	7	97	0.00	0.0	2.600	0.087	0	0	0	4
PL.52128	PL.58487	C	#4 ACSR	7.24Y	120.6	0.01	4.40	3.69	3	26	7	97	0.00	0.0	2.672	0.072	7	2	1	4
PL.62020	PL.52128	C	#4 ACSR	7.24Y	120.6	0.01	4.40	2.70	2	19	5	97	0.00	0.0	2.731	0.059	10	3	1	3
PL.62021	PL.62020	C	#4 ACSR	7.24Y	120.6	0.00	4.41	1.30	1	9	2	98	0.00	0.0	2.773	0.042	4	1	1	2
PL.62022	PL.62021	C	#4 ACSR	7.24Y	120.6	0.00	4.41	0.74	1	5	1	98	0.00	0.0	2.786	0.012	5	1	1	1
PL.52127	PL.58487	C	#4 ACSR	7.24Y	120.6	0.00	4.39	0.00	0	0	0	100	0.00	0.0	2.652	0.052	0	0	0	0
PL.56839	PL.56490	ABC	#1/0 ACSR	7.22Y	120.3	0.30	4.67	103.31	45	2147	648	96	4.56	0.2	2.631	0.160	0	0	1	236
PL.56840	PL.56839	ABC	#1/0 ACSR	7.21Y	120.2	0.09	4.76	102.69	45	2130	641	96	1.37	0.1	2.679	0.049	0	0	0	234
PL.52125	PL.56840	A	6 A (CWC)	7.21Y	120.2	0.01	4.77	2.65	2	18	5	96	0.00	0.0	2.799	0.119	18	5	3	3
PL.56922	PL.56840	ABC	#1/0 ACSR	7.20Y	120.0	0.22	4.98	101.81	44	2110	634	96	3.27	0.2	2.798	0.119	12	3	2	231
PL.56450	PL.56922	ABC	#1/0 ACSR	7.19Y	119.9	0.15	5.13	69.22	30	1426	450	95	1.53	0.1	2.918	0.120	0	0	0	138
PL.56451	PL.56450	ABC	#1/0 ACSR	7.19Y	119.8	0.08	5.21	34.79	15	725	194	97	0.40	0.1	3.041	0.123	0	0	0	85
PL.56951	PL.56451	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.23	34.79	15	725	194	97	0.07	0.0	3.063	0.022	0	0	0	85
PL.42155	PL.56951	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.23	34.79	15	725	194	97	0.02	0.0	3.069	0.006	0	0	0	85
PD.6804	PL.42155	ABC	100L	7.19Y	119.8	0.00	5.23	34.79	35	725	194	97	0.00	0.0	3.069	0.006	0	0	0	85
PL.42156	PD.6804	ABC	#1/0 ACSR	7.18Y	119.7	0.03	5.26	34.79	15	725	194	97	0.14	0.0	3.114	0.045	0	0	0	85
PL.42157	PL.42156	A	#4 ACSR	7.18Y	119.7	0.00	5.26	2.49	2	17	5	96	0.00	0.0	3.119	0.006	0	0	0	2
PD.6471	PL.42157	A	50QA	7.18Y	119.7	0.00	5.26	2.49	5	17	5	96	0.00	0.0	3.119	0.006	0	0	0	2
PL.56491	PD.6471	A	#4 ACSR	7.18Y	119.7	0.00	5.26	2.49	2	17	5	96	0.00	0.0	3.145	0.026	17	5	2	2
PL.42158	PL.42156	ABC	#1/0 ACSR	7.18Y	119.7	0.07	5.32	33.96	15	707	189	97	0.34	0.0	3.224	0.110	2	0	2	83
PL.42159	PL.42158	ABC	#1/0 ACSR	7.18Y	119.7	0.02	5.35	33.88	15	705	188	97	0.12	0.0	3.264	0.040	0	0	0	81
PL.42160	PL.42159	A	#4 ACSR	7.18Y	119.7	0.00	5.35	0.86	1	6	2	95	0.00	0.0	3.269	0.006	0	0	0	1
PD.6536	PL.42160	A	50QA	7.18Y	119.7	0.00	5.35	0.86	2	6	2	95	0.00	0.0	3.269	0.006	0	0	0	1
PL.42161	PD.6536	A	#4 ACSR	7.18Y	119.7	0.00	5.35	0.86	1	6	2	95	0.00	0.0	3.299	0.030	6	2	1	1
PL.42572	PL.42159	ABC	#1/0 ACSR	7.18Y	119.6	0.06	5.41	33.60	15	699	187	97	0.30	0.0	3.362	0.099	0	0	0	80
PL.41355	PL.42572	B	#4 ACSR	7.18Y	119.6	0.00	5.41	1.96	2	14	4	96	0.00	0.0	3.427	0.064	14	4	1	1
PL.42573	PL.42572	ABC	#1/0 ACSR	7.17Y	119.5	0.06	5.47	32.94	14	685	183	97	0.30	0.0	3.468	0.105	0	0	0	79
PL.42574	PL.42573	A	#4 ACSR	7.17Y	119.5	0.00	5.47	1.79	1	12	3	97	0.00	0.0	3.473	0.006	0	0	0	1
PD.6778	PL.42574	A	50QA	7.17Y	119.5	0.00	5.47	1.79	4	12	3	97	0.00	0.0	3.473	0.006	0	0	0	1
PL.57582	PD.6778	A	#4 ACSR	7.17Y	119.5	0.00	5.47	1.79	1	12	3	97	0.00	0.0	3.500	0.026	12	3	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42575	PL.42573	C	6 A (CWC)	7.17Y	119.5	0.00	5.47	5.48	4	38	10	97	0.00	0.0	3.473	0.006	0	0	0	4
PD.6705	PL.42575	C	50QA	7.17Y	119.5	0.00	5.47	5.48	11	38	10	97	0.00	0.0	3.473	0.006	0	0	0	4
PL.42576	PD.6705	C	6 A (CWC)	7.17Y	119.5	0.01	5.48	5.48	4	38	10	97	0.00	0.0	3.500	0.026	16	4	1	4
PL.42577	PL.42576	C	6 A (CWC)	7.17Y	119.5	0.00	5.48	3.20	2	22	6	96	0.00	0.0	3.563	0.063	22	6	3	3
PL.42578	PL.42573	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.49	30.52	13	635	169	97	0.11	0.0	3.512	0.044	7	2	1	74
PL.42579	PL.42578	ABC	#1/0 ACSR	7.17Y	119.5	0.01	5.51	30.17	13	627	167	97	0.05	0.0	3.534	0.022	5	1	1	73
PL.42581	PL.42579	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.52	29.94	13	622	166	97	0.08	0.0	3.568	0.034	0	0	0	72
PL.42580	PL.42581	C	#4 ACSR	7.17Y	119.5	0.00	5.52	1.36	1	9	2	98	0.00	0.0	3.574	0.006	0	0	0	1
PD.6446	PL.42580	C	50QA	7.17Y	119.5	0.00	5.52	1.36	3	9	2	98	0.00	0.0	3.574	0.006	0	0	0	1
PL.42582	PD.6446	C	#4 ACSR	7.17Y	119.5	0.00	5.53	1.36	1	9	2	98	0.00	0.0	3.624	0.050	0	0	0	1
PL.42583	PL.42582	C	#4 ACSR	7.17Y	119.5	0.00	5.53	1.36	1	9	2	98	0.00	0.0	3.668	0.044	9	2	1	1
PL.42584	PL.42581	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.54	29.48	13	613	163	97	0.07	0.0	3.597	0.029	0	0	0	71
PL.42585	PL.42584	A	6 A (CWC)	7.17Y	119.5	0.00	5.54	0.51	0	4	1	97	0.00	0.0	3.602	0.006	0	0	0	1
PD.6522	PL.42585	A	50QA	7.17Y	119.5	0.00	5.54	0.51	1	4	1	97	0.00	0.0	3.602	0.006	0	0	0	1
PL.42586	PD.6522	A	6 A (CWC)	7.17Y	119.5	0.00	5.54	0.51	0	4	1	97	0.00	0.0	3.668	0.066	4	1	1	1
PL.52711	PL.42584	ABC	#1/0 ACSR	7.17Y	119.4	0.01	5.55	29.31	13	609	162	97	0.06	0.0	3.622	0.026	0	0	0	70
PL.57184	PL.52711	ABC	#1/0 ACSR	7.17Y	119.4	0.02	5.57	29.31	13	609	162	97	0.10	0.0	3.665	0.042	0	0	0	70
PL.59378	PL.57184	ABC	#1/0 ACSR	7.16Y	119.4	0.05	5.62	26.76	12	556	148	97	0.18	0.0	3.761	0.097	8	2	1	65
PL.59379	PL.59378	A	#4 ACSR	7.16Y	119.4	0.00	5.62	4.94	4	34	9	97	0.00	0.0	3.767	0.006	0	0	0	4
PD.6539	PL.59379	A	20T	7.16Y	119.4	0.00	5.62	4.94	0	34	9	97	0.00	0.0	3.767	0.006	0	0	0	4
PL.57011	PD.6539	A	#4 ACSR	7.16Y	119.4	0.02	5.64	4.94	4	34	9	97	0.00	0.0	3.857	0.090	9	2	1	4
PL.57013	PL.57011	A	#4 ACSR	7.16Y	119.4	0.00	5.64	1.30	1	9	2	98	0.00	0.0	3.897	0.040	9	2	1	1
PL.57014	PL.57013	A	#4 ACSR	7.16Y	119.4	0.00	5.64	0.00	0	0	0	100	0.00	0.0	3.950	0.053	0	0	0	0
PL.57012	PL.57011	A	#2 ACSR	7.16Y	119.4	0.00	5.64	2.41	1	17	4	97	0.00	0.0	3.863	0.006	0	0	0	2
PD.6472	PL.57012	A	25QA	7.16Y	119.4	0.00	5.64	2.41	10	17	4	97	0.00	0.0	3.863	0.006	0	0	0	2
PL.57007	PD.6472	A	#2 ACSR	7.16Y	119.4	0.00	5.64	2.41	1	17	4	97	0.00	0.0	3.892	0.029	17	4	2	2
PL.59380	PL.59378	ABC	#1/0 ACSR	7.16Y	119.4	0.02	5.65	24.74	11	514	137	97	0.09	0.0	3.817	0.055	15	4	4	60
PL.57008	PL.59380	ABC	#1/0 ACSR	7.16Y	119.3	0.02	5.67	24.01	10	498	133	97	0.08	0.0	3.870	0.053	8	2	1	56
PL.56522	PL.57008	B	6 A (CWC)	7.16Y	119.3	0.05	5.72	69.09	49	478	127	97	0.18	0.0	3.885	0.015	0	0	0	54
PL.42587	PL.56522	B	6 A (CWC)	7.16Y	119.3	0.02	5.73	67.20	48	465	124	97	0.06	0.0	3.891	0.006	0	0	0	53
PD.6805	PL.42587	B	100L	7.16Y	119.3	0.00	5.73	67.20	67	465	124	97	0.00	0.0	3.891	0.006	0	0	0	53

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42588	PD.6805	B	6 A (CWC)	7.15Y	119.2	0.10	5.83	67.20	48	465	124	97	0.34	0.1	3.923	0.032	14	4	1	53
PL.42590	PL.42588	B	6 A (CWC)	7.14Y	119.1	0.10	5.93	60.16	43	416	111	97	0.29	0.1	3.960	0.037	48	13	5	46
PL.42591	PL.42590	B	6 A (CWC)	7.14Y	119.0	0.04	5.97	53.22	38	367	98	97	0.12	0.0	3.977	0.017	0	0	0	41
PL.42592	PL.42591	B	#4 ACSR	7.14Y	119.0	0.01	5.98	12.64	10	87	23	97	0.01	0.0	4.001	0.024	17	4	2	9
PL.42593	PL.42592	B	#4 ACSR	7.14Y	119.0	0.02	6.00	10.21	8	71	19	97	0.01	0.0	4.047	0.045	27	7	3	7
PL.56902	PL.42593	B	#4 ACSR	7.14Y	119.0	0.01	6.01	6.28	5	43	11	97	0.00	0.0	4.094	0.048	0	0	0	4
PL.56903	PL.56902	B	#4 ACSR	7.14Y	119.0	0.00	6.01	2.59	2	18	5	96	0.00	0.0	4.134	0.040	10	3	1	2
PL.42594	PL.56903	B	#4 ACSR	7.14Y	119.0	0.00	6.01	1.19	1	8	2	97	0.00	0.0	4.172	0.038	8	2	1	1
PL.56904	PL.56902	B	#4 ACSR	7.14Y	119.0	0.00	6.01	3.69	3	25	7	96	0.00	0.0	4.130	0.036	25	7	2	2
PL.62224	PL.42591	B	6 A (CWC)	7.14Y	118.9	0.11	6.08	40.58	29	280	75	97	0.24	0.1	4.038	0.061	13	4	3	32
PL.63461	PL.62224	B	6 A (CWC)	7.13Y	118.8	0.14	6.22	38.64	28	266	71	97	0.29	0.1	4.117	0.079	0	0	0	29
PL.63462	PL.63461	B	6 A (CWC)	7.11Y	118.5	0.25	6.47	36.38	26	251	67	97	0.48	0.2	4.267	0.150	0	0	0	28
PL.62225	PL.63462	B	#4 ACSR	7.11Y	118.5	0.00	6.47	1.52	1	10	3	96	0.00	0.0	4.322	0.055	1	0	1	2
PL.42595	PL.62225	B	#4 ACSR	7.11Y	118.5	0.00	6.47	1.41	1	10	3	96	0.00	0.0	4.354	0.032	10	3	1	1
PL.62226	PL.63462	B	6 A (CWC)	7.10Y	118.4	0.12	6.59	34.85	25	240	64	97	0.22	0.1	4.346	0.079	12	3	1	26
REG63	PL.62226	B	76.2 KVA	7.53Y	125.5	-7.06	-0.47	33.06	33	227	60	97	percent Boost= 0.00			Tap= 0.0				25
PL.57120	REG63	B	6 A (CWC)	7.52Y	125.4	0.08	-0.39	31.20	22	227	60	97	0.12	0.1	4.401	0.055	16	4	4	25
PL.57118	PL.57120	B	#4 ACSR	7.52Y	125.4	0.01	-0.38	9.76	8	71	19	97	0.01	0.0	4.438	0.037	15	4	1	6
PL.57114	PL.57118	B	#4 ACSR	7.52Y	125.4	0.01	-0.37	7.69	6	56	15	97	0.00	0.0	4.466	0.028	27	7	2	5
PL.57182	PL.57114	B	#2 ACSR	7.52Y	125.4	0.01	-0.36	4.03	2	29	8	96	0.00	0.0	4.536	0.070	13	4	1	3
PL.57183	PL.57182	B	#2 ACSR	7.52Y	125.4	0.00	-0.36	2.20	1	16	4	97	0.00	0.0	4.625	0.089	16	4	2	2
PL.56691	PL.57183	B	#4 ACSR	7.52Y	125.4	0.00	-0.36	0.00	0	0	0	100	0.00	0.0	4.671	0.046	0	0	0	0
PL.57119	PL.57120	B	#1/0 ACSR	7.52Y	125.4	0.00	-0.39	2.22	1	16	4	97	0.00	0.0	4.414	0.013	16	4	1	1
PL.57117	PL.57120	B	6 A (CWC)	7.52Y	125.3	0.10	-0.29	17.04	12	124	33	97	0.09	0.1	4.529	0.128	0	0	0	14
PL.57115	PL.57117	B	6 A (CWC)	7.52Y	125.3	0.00	-0.29	15.78	11	115	30	97	0.00	0.0	4.535	0.006	0	0	0	13
PD.6524	PL.57115	B	40QA	7.52Y	125.3	0.00	-0.29	15.78	39	115	30	97	0.00	0.0	4.535	0.006	0	0	0	13
PL.42196	PD.6524	B	6 A (CWC)	7.51Y	125.2	0.06	-0.23	15.78	11	115	30	97	0.05	0.0	4.618	0.083	0	0	0	13
PL.41831	PL.42196	B	#1/0 ACSR	7.51Y	125.2	0.00	-0.23	1.50	1	11	3	96	0.00	0.0	4.694	0.075	11	3	1	1
PL.42197	PL.42196	B	6 A (CWC)	7.51Y	125.1	0.14	-0.09	12.58	9	91	24	97	0.09	0.1	4.877	0.259	12	3	1	10
PL.56850	PL.42197	B	6 A (CWC)	7.50Y	125.0	0.06	-0.03	10.96	8	79	21	97	0.04	0.0	5.006	0.129	0	0	0	9
PL.61143	PL.56850	B	6 A (CWC)	7.50Y	125.0	0.00	-0.02	4.94	4	36	9	97	0.00	0.0	5.033	0.026	15	4	2	4

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.61144	PL.61143	B	6 A (CWC)	7.50Y	125.0	0.00	-0.02	1.32	1	10	3	96	0.00	0.0	5.066	0.033	10	3	1	1
PL.61145	PL.61144	B	6 A (CWC)	7.50Y	125.0	0.00	-0.02	0.00	0	0	0	100	0.00	0.0	5.124	0.058	0	0	0	0
PL.61142	PL.61143	B	6 A (CWC)	7.50Y	125.0	0.01	-0.01	1.58	1	11	3	96	0.00	0.0	5.145	0.112	0	0	0	1
PL.51773	PL.61142	B	6 A (CWC)	7.50Y	125.0	0.00	-0.01	1.58	1	11	3	96	0.00	0.0	5.197	0.052	0	0	0	1
PL.51774	PL.51773	B	6 A (CWC)	7.50Y	125.0	0.00	-0.00	1.58	1	11	3	96	0.00	0.0	5.265	0.069	0	0	0	1
PL.51775	PL.51774	B	6 A (CWC)	7.50Y	125.0	0.00	-0.00	1.58	1	11	3	96	0.00	0.0	5.287	0.021	11	3	1	1
PL.56952	PL.56850	B	6 A (CWC)	7.50Y	125.0	0.04	0.02	6.01	4	44	12	96	0.01	0.0	5.202	0.195	19	5	1	5
PL.56953	PL.56952	B	6 A (CWC)	7.50Y	125.0	0.01	0.02	3.34	2	24	6	97	0.00	0.0	5.263	0.061	0	0	1	4
PL.57104	PL.56953	B	6 A (CWC)	7.50Y	124.9	0.05	0.08	3.29	2	24	6	97	0.01	0.0	5.608	0.345	0	0	0	3
PL.57103	PL.57104	B	6 A (CWC)	7.49Y	124.9	0.01	0.09	3.29	2	24	6	97	0.00	0.0	5.690	0.082	12	3	2	3
PL.63470	PL.57103	B	#1/0 ACSR	7.49Y	124.9	0.00	0.09	1.63	1	12	3	97	0.00	0.0	5.748	0.058	0	0	0	1
PL.63471	PL.63470	B	#1/0 ACSR	7.49Y	124.9	0.00	0.09	1.63	1	12	3	97	0.00	0.0	5.800	0.051	12	3	1	1
PL.57105	PL.57104	B	6 A (CWC)	7.50Y	124.9	0.00	0.08	0.00	0	0	0	100	0.00	0.0	5.812	0.203	0	0	0	0
PL.57274	PL.57105	B	6 A (CWC)	7.50Y	124.9	0.00	0.08	0.00	0	0	0	100	0.00	0.0	5.879	0.068	0	0	0	0
PL.56712	PL.42196	B	#4 ACSR	7.51Y	125.2	0.00	-0.23	1.71	1	12	3	97	0.00	0.0	4.711	0.093	12	3	2	2
PL.57116	PL.57117	B	#4 ACSR	7.52Y	125.3	0.00	-0.29	1.26	1	9	2	98	0.00	0.0	4.577	0.048	9	2	1	1
PL.42195	PL.57116	B	#4 ACSR	7.52Y	125.3	0.00	-0.29	0.00	0	0	0	100	0.00	0.0	4.652	0.075	0	0	0	0
PL.63463	PL.63461	B	#1/0 ACSR	7.13Y	118.8	0.00	6.22	2.26	1	16	4	97	0.00	0.0	4.121	0.004	0	0	0	1
PD.9424	PL.63463	B	10T	7.13Y	118.8	0.00	6.22	2.26	0	16	4	97	0.00	0.0	4.121	0.004	0	0	0	1
PL.63474	PD.9424	B	#1/0 ACSR	7.13Y	118.8	0.00	6.22	2.26	1	16	4	97	0.00	0.0	4.195	0.075	16	4	1	1
PL.57009	PL.42588	B	6 A (CWC)	7.15Y	119.2	0.01	5.84	5.06	4	35	9	97	0.00	0.0	3.980	0.058	2	1	1	6
PL.57010	PL.57009	B	6 A (CWC)	7.15Y	119.1	0.02	5.86	4.77	3	33	9	96	0.00	0.0	4.086	0.105	22	6	3	5
PL.42589	PL.57010	B	6 A (CWC)	7.15Y	119.1	0.00	5.86	1.57	1	11	3	96	0.00	0.0	4.147	0.062	11	3	2	2
PL.41696	PL.56522	B	#2 ACSR	7.16Y	119.3	0.00	5.72	1.89	1	13	3	97	0.00	0.0	3.944	0.059	13	3	1	1
PL.64546	PL.41696	B	#1/0 ACSR	7.16Y	119.3	0.00	5.72	0.00	0	0	0	100	0.00	0.0	3.952	0.008	0	0	0	0
PL.64547	PL.64546	B	#1/0 ACSR	7.16Y	119.3	0.00	5.72	0.00	0	0	0	100	0.00	0.0	3.986	0.033	0	0	0	0
PL.56523	PL.57008	C	#1/0 ACSR	7.16Y	119.3	0.00	5.67	1.71	1	12	3	97	0.00	0.0	3.896	0.026	12	3	1	1
PL.56521	PL.57008	ABC	#1/0 ACSR	7.16Y	119.3	0.00	5.67	0.00	0	0	0	100	0.00	0.0	3.906	0.036	0	0	0	0
PD.6815-B	PL.56521	ABC	Open	7.16Y	119.3	0.00	5.67	0.00	0	0	0	100	0.00	0.0	3.906	0.036	0	0	0	0
PL.57186	PL.57184	B	6 A (CWC)	7.17Y	119.4	0.00	5.58	7.65	5	53	14	97	0.00	0.0	3.669	0.004	0	0	0	5
PD.8271	PL.57186	B	20QA	7.17Y	119.4	0.00	5.58	7.65	38	53	14	97	0.00	0.0	3.669	0.004	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.57187	PD.8271	B	6 A (CWC)	7.16Y	119.4	0.02	5.60	7.65	5	53	14	97	0.01	0.0	3.729	0.060	5	1	1	5
PL.57185	PL.57187	B	6 A (CWC)	7.16Y	119.4	0.02	5.62	6.98	5	48	13	97	0.01	0.0	3.798	0.069	12	3	1	4
PL.57093	PL.57185	B	6 A (CWC)	7.16Y	119.4	0.00	5.62	5.27	4	37	10	97	0.00	0.0	3.814	0.016	4	1	1	3
PL.57092	PL.57093	B	6 A (CWC)	7.16Y	119.4	0.01	5.63	4.68	3	32	9	96	0.00	0.0	3.901	0.087	13	4	1	2
PL.56870	PL.57092	B	#1/0 ACSR	7.16Y	119.4	0.00	5.64	2.74	1	19	5	97	0.00	0.0	4.016	0.115	19	5	1	1
CP.83	PL.52711	ABC	Cap (300)	7.17Y	119.4	0.00	5.55	0.00	0	0	0	100	0.00	0.0	3.622	0.115	0	0	0	0
PL.56448	PL.56450	ABC	#1/0 ACSR	7.19Y	119.8	0.07	5.20	34.37	15	697	254	94	0.32	0.0	3.022	0.103	4	1	1	52
PL.56452	PL.56448	B	6 A (CWC)	7.19Y	119.8	0.01	5.21	76.08	54	519	171	95	0.05	0.0	3.026	0.004	0	0	0	49
PL.57108	PL.56452	B	6 A (CWC)	7.17Y	119.5	0.30	5.52	76.08	54	519	171	95	1.20	0.2	3.111	0.086	0	0	0	49
PL.57106	PL.57108	B	6 A (CWC)	7.17Y	119.5	0.02	5.54	76.08	54	518	170	95	0.08	0.0	3.117	0.006	0	0	0	49
PD.8333	PL.57106	B	140L	7.17Y	119.5	0.00	5.54	76.08	54	518	170	95	0.00	0.0	3.117	0.006	0	0	0	49
PL.57107	PD.8333	B	6 A (CWC)	7.15Y	119.2	0.25	5.79	76.08	54	518	170	95	1.00	0.2	3.189	0.072	6	2	1	49
PL.56925	PL.57107	B	6 A (CWC)	7.14Y	119.0	0.21	6.00	73.75	53	501	165	95	0.83	0.2	3.251	0.063	0	0	0	47
PL.56846	PL.56925	B	6 A (CWC)	7.14Y	119.0	0.00	6.01	1.85	1	13	3	97	0.00	0.0	3.362	0.110	13	3	1	1
PL.56847	PL.56925	B	6 A (CWC)	7.14Y	118.9	0.08	6.08	71.90	51	487	161	95	0.28	0.1	3.274	0.023	0	0	0	46
PL.56605	PL.56847	B	1/0 AL URD	7.14Y	118.9	0.00	6.08	1.77	1	12	3	97	0.00	0.0	3.316	0.042	12	3	1	1
PL.56604	PL.56847	B	6 A (CWC)	7.13Y	118.8	0.11	6.19	70.14	50	475	158	95	0.36	0.1	3.317	0.043	172	77	4	45
REG62	PL.56604	B	114.3 KVA	7.50Y	125.1	-6.25	-0.06	43.97	29	303	81	97	percent Boost= 0.00 Tap= 0.0							41
PL.56603	REG62	B	6 A (CWC)	7.49Y	124.9	0.17	0.11	41.77	30	303	81	97	0.37	0.1	3.405	0.088	0	0	0	41
PL.42262	PL.56603	B	6 A (CWC)	7.48Y	124.7	0.15	0.26	41.00	29	297	80	97	0.33	0.1	3.485	0.080	0	0	0	40
PL.42144	PL.42262	B	6 A (CWC)	7.48Y	124.7	0.01	0.27	5.79	4	42	11	97	0.00	0.0	3.527	0.042	0	0	0	3
PL.42145	PL.42144	B	6 A (CWC)	7.48Y	124.7	0.00	0.27	3.17	2	23	6	97	0.00	0.0	3.593	0.066	22	6	1	2
PL.42146	PL.42145	B	6 A (CWC)	7.48Y	124.7	0.00	0.27	0.10	0	1	0	100	0.00	0.0	3.648	0.056	1	0	1	1
PL.41015	PL.42144	B	6 A (CWC)	7.48Y	124.7	0.01	0.27	2.62	2	19	5	97	0.00	0.0	3.616	0.090	19	5	1	1
PL.42147	PL.42262	B	6 A (CWC)	7.46Y	124.4	0.38	0.64	35.21	25	255	68	97	0.72	0.3	3.726	0.241	3	1	1	37
PL.57121	PL.42147	B	6 A (CWC)	7.44Y	124.0	0.32	0.96	34.79	25	251	67	97	0.58	0.2	3.928	0.202	6	1	1	36
PL.59394	PL.57121	B	#4 ACSR	7.44Y	124.0	0.01	0.96	2.38	2	17	5	96	0.00	0.0	4.024	0.096	17	5	1	1
PL.57122	PL.57121	B	6 A (CWC)	7.44Y	123.9	0.13	1.08	31.64	23	228	61	97	0.21	0.1	4.014	0.087	0	0	0	34
PL.42148	PL.57122	B	6 A (CWC)	7.42Y	123.7	0.24	1.33	31.28	22	225	60	97	0.41	0.2	4.185	0.170	0	0	0	33
PL.42151	PL.42148	B	6 A (CWC)	7.42Y	123.6	0.09	1.41	28.40	20	204	54	97	0.13	0.1	4.253	0.068	3	1	1	29
PL.42152	PL.42151	B	6 A (CWC)	7.40Y	123.3	0.32	1.73	28.04	20	201	53	97	0.47	0.2	4.500	0.248	1	0	2	28

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42119	PL.42152	B	#2 ACSR	7.40Y	123.3	0.00	1.73	0.04	0	0	0	100	0.00	0.0	4.550	0.050	0	0	3	3
PL.42153	PL.42152	B	6 A (CWC)	7.39Y	123.1	0.14	1.87	27.82	20	199	53	97	0.21	0.1	4.615	0.114	0	0	0	23
PL.56618	PL.42153	B	#1/0 ACSR	7.39Y	123.1	0.00	1.87	3.56	2	25	7	96	0.00	0.0	4.646	0.031	25	7	2	2
PL.42154	PL.42153	B	6 A (CWC)	7.38Y	123.0	0.08	1.95	24.26	17	173	46	97	0.10	0.1	4.688	0.073	7	2	1	21
PL.56499	PL.42154	B	6 A (CWC)	7.38Y	123.0	0.04	1.99	23.30	17	166	44	97	0.05	0.0	4.725	0.037	9	2	1	20
PL.56500	PL.56499	B	6 A (CWC)	7.38Y	122.9	0.07	2.07	22.05	16	157	42	97	0.09	0.1	4.800	0.075	3	1	1	19
PL.56492	PL.56500	B	#4 ACSR	7.37Y	122.9	0.02	2.09	6.65	5	47	13	96	0.01	0.0	4.867	0.067	0	0	0	8
PL.56493	PL.56492	B	#4 ACSR	7.37Y	122.9	0.00	2.09	0.79	1	6	1	99	0.00	0.0	4.907	0.041	6	1	1	1
PL.56741	PL.56493	B	#4 ACSR	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	4.970	0.063	0	0	0	0
PL.56496	PL.56492	B	#4 ACSR	7.37Y	122.9	0.01	2.09	3.17	2	23	6	97	0.00	0.0	4.921	0.054	0	0	0	6
PL.56498	PL.56496	B	#2 ACSR	7.37Y	122.9	0.00	2.09	2.06	1	15	4	97	0.00	0.0	4.940	0.019	15	4	2	2
PL.56497	PL.56496	B	#4 ACSR	7.37Y	122.9	0.00	2.10	1.11	1	8	2	97	0.00	0.0	5.000	0.079	1	0	2	4
PL.56494	PL.56497	B	#4 ACSR	7.37Y	122.9	0.00	2.10	0.91	1	6	2	95	0.00	0.0	5.014	0.013	6	2	2	2
PL.64314	PL.56492	B	#1/0 ACSR	7.37Y	122.9	0.00	2.09	2.69	1	19	5	97	0.00	0.0	4.933	0.066	0	0	0	1
PL.64315	PL.64314	B	#1/0 ACSR	7.37Y	122.9	0.00	2.09	2.69	1	19	5	97	0.00	0.0	4.995	0.062	19	5	1	1
PL.56740	PL.56500	B	#2 ACSR	7.37Y	122.9	0.04	2.11	14.95	9	107	28	97	0.03	0.0	4.891	0.091	0	0	0	10
PL.56592	PL.56740	B	6 A (CWC)	7.37Y	122.9	0.00	2.11	2.77	2	20	5	97	0.00	0.0	4.935	0.044	20	5	4	4
PL.56593	PL.56740	B	#2 ACSR	7.37Y	122.9	0.01	2.12	12.18	7	87	23	97	0.01	0.0	4.929	0.038	0	0	0	6
PL.56595	PL.56593	B	#1/0 ACSR	7.37Y	122.9	0.00	2.12	1.57	1	11	3	96	0.00	0.0	4.945	0.016	11	3	1	1
PL.56594	PL.56593	B	#2 ACSR	7.37Y	122.9	0.02	2.15	10.61	6	76	20	97	0.01	0.0	5.004	0.075	0	0	0	5
PL.56222	PL.56594	B	#1/0 ACSR	7.37Y	122.9	0.00	2.15	2.73	1	19	5	97	0.00	0.0	5.015	0.012	19	5	1	1
PL.56221	PL.56594	B	#2 ACSR	7.37Y	122.8	0.02	2.17	7.88	5	56	15	97	0.01	0.0	5.080	0.076	0	0	0	4
PL.56743	PL.56221	B	#2 ACSR	7.37Y	122.8	0.01	2.17	2.73	2	19	5	97	0.00	0.0	5.163	0.084	6	2	1	2
PL.56744	PL.56743	B	#1/0 ACSR	7.37Y	122.8	0.00	2.18	1.85	1	13	3	97	0.00	0.0	5.223	0.060	0	0	0	1
PL.56745	PL.56744	B	#1/0 ACSR	7.37Y	122.8	0.00	2.18	1.85	1	13	3	97	0.00	0.0	5.329	0.106	13	3	1	1
PL.56746	PL.56745	B	#1/0 ACSR	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	5.356	0.027	0	0	0	0
PL.63469	PL.56221	B	1/0 AL URD	7.37Y	122.8	0.00	2.17	2.51	1	18	5	96	0.00	0.0	5.120	0.041	18	5	1	1
PL.56742	PL.56221	B	#2 ACSR	7.37Y	122.8	0.00	2.17	2.65	2	19	5	97	0.00	0.0	5.144	0.064	19	5	1	1
PL.42149	PL.42148	B	#4 ACSR	7.42Y	123.7	0.01	1.34	2.89	2	21	5	97	0.00	0.0	4.311	0.126	6	2	3	4
PL.42150	PL.42149	B	#4 ACSR	7.42Y	123.7	0.00	1.34	2.02	2	15	4	97	0.00	0.0	4.342	0.031	15	4	1	1
PL.56228	PL.57122	B	#4 ACSR	7.43Y	123.9	0.00	1.08	0.36	0	3	1	95	0.00	0.0	4.134	0.119	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56713	PL.56603	B	#1/0 ACSR	7.49Y	124.9	0.00	0.11	0.77	0	6	1	99	0.00	0.0	3.424	0.019	6	1	1	1
PL.59354	PL.57107	B	6 A (CWC)	7.15Y	119.2	0.00	5.79	1.42	1	10	3	96	0.00	0.0	3.304	0.115	10	3	1	1
PL.56449	PL.56448	ABC	#1/0 ACSR	7.19Y	119.8	0.03	5.23	8.33	4	162	78	90	0.03	0.0	3.200	0.179	0	0	0	1
PL.56920	PL.56449	ABC	#2 ACSR	7.19Y	119.8	0.00	5.23	0.00	0	0	0	100	0.00	0.0	3.246	0.045	0	0	0	0
PL.56921	PL.56449	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.23	8.33	4	162	78	90	0.00	0.0	3.210	0.010	162	78	1	1
PL.56453	PL.56448	A	#2 ACSR	7.19Y	119.8	0.00	5.20	1.60	1	11	3	96	0.00	0.0	3.027	0.005	0	0	0	1
PD.8245	PL.56453	A	40QA	7.19Y	119.8	0.00	5.20	1.60	4	11	3	96	0.00	0.0	3.027	0.005	0	0	0	1
PL.56851	PD.8245	A	#2 ACSR	7.19Y	119.8	0.00	5.20	1.60	1	11	3	96	0.00	0.0	3.116	0.089	11	3	1	1
PL.56454	PL.56450	C	#1/0 ACSR	7.19Y	119.9	0.00	5.13	0.39	0	3	1	95	0.00	0.0	2.924	0.006	0	0	0	1
PD.8331	PL.56454	C	20QA	7.19Y	119.9	0.00	5.13	0.39	2	3	1	95	0.00	0.0	2.924	0.006	0	0	0	1
PL.56780	PD.8331	C	#1/0 ACSR	7.19Y	119.9	0.00	5.14	0.39	0	3	1	95	0.00	0.0	2.971	0.047	3	1	1	1
PL.56923	PL.56922	ABC	#1/0 ACSR	7.20Y	120.0	0.02	5.01	31.63	14	660	176	97	0.11	0.0	2.840	0.042	0	0	0	90
PL.42041	PL.56923	ABC	#1/0 ACSR	7.20Y	120.0	0.00	5.01	31.63	14	660	176	97	0.02	0.0	2.846	0.006	0	0	0	90
PD.6813	PL.42041	ABC	50L	7.20Y	120.0	0.00	5.01	31.63	63	660	176	97	0.00	0.0	2.846	0.006	0	0	0	90
PL.42042	PD.6813	ABC	#1/0 ACSR	7.20Y	120.0	0.02	5.03	31.63	14	660	176	97	0.10	0.0	2.884	0.038	8	2	1	90
PL.41817	PL.42042	A	#1/0 ACSR	7.20Y	120.0	0.00	5.03	0.00	0	0	0	100	0.00	0.0	2.987	0.103	0	0	1	1
PL.56392	PL.42042	ABC	#1/0 ACSR	7.20Y	119.9	0.04	5.07	31.22	14	652	173	97	0.20	0.0	2.962	0.078	0	0	0	88
PL.56393	PL.56392	C	#1/0 ACSR	7.20Y	119.9	0.00	5.07	0.62	0	4	1	97	0.00	0.0	2.968	0.006	0	0	0	1
PD.8005	PL.56393	C	40QA	7.20Y	119.9	0.00	5.07	0.62	2	4	1	97	0.00	0.0	2.968	0.006	0	0	0	1
PL.52054	PD.8005	C	#1/0 ACSR	7.20Y	119.9	0.00	5.07	0.62	0	4	1	97	0.00	0.0	3.011	0.044	4	1	1	1
PL.56394	PL.56392	ABC	#1/0 ACSR	7.19Y	119.9	0.04	5.11	29.10	13	607	161	97	0.17	0.0	3.037	0.075	12	3	2	82
PL.42043	PL.56394	A	#2 ACSR	7.19Y	119.9	0.00	5.11	0.96	1	7	2	96	0.00	0.0	3.043	0.006	0	0	0	1
PD.6639	PL.42043	A	40QA	7.19Y	119.9	0.00	5.11	0.96	2	7	2	96	0.00	0.0	3.043	0.006	0	0	0	1
PL.42044	PD.6639	A	#2 ACSR	7.19Y	119.9	0.00	5.11	0.96	1	7	2	96	0.00	0.0	3.095	0.052	7	2	1	1
PL.42045	PL.56394	A	#2 ACSR	7.19Y	119.9	0.00	5.11	1.12	1	8	2	97	0.00	0.0	3.043	0.006	0	0	0	3
PD.6768	PL.42045	A	40QA	7.19Y	119.9	0.00	5.11	1.12	3	8	2	97	0.00	0.0	3.043	0.006	0	0	0	3
PL.62046	PD.6768	A	#2 ACSR	7.19Y	119.9	0.00	5.11	1.12	1	8	2	97	0.00	0.0	3.105	0.063	5	1	2	3
PL.62047	PL.62046	A	#2 ACSR	7.19Y	119.9	0.00	5.11	0.41	0	3	1	95	0.00	0.0	3.131	0.025	3	1	1	1
PL.42046	PL.56394	ABC	#1/0 ACSR	7.19Y	119.9	0.04	5.15	27.82	12	580	154	97	0.15	0.0	3.111	0.074	6	2	1	76
PL.42047	PL.42046	ABC	#1/0 ACSR	7.19Y	119.8	0.08	5.23	27.54	12	574	152	97	0.34	0.1	3.281	0.170	0	0	0	75
PL.42049	PL.42047	A	#2 ACSR	7.19Y	119.8	0.00	5.23	1.10	1	8	2	97	0.00	0.0	3.287	0.006	0	0	0	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6426	PL.42049	A	40QA	7.19Y	119.8	0.00	5.23	1.10	3	8	2	97	0.00	0.0	3.287	0.006	0	0	0	1
PL.42050	PD.6426	A	#2 ACSR	7.19Y	119.8	0.00	5.23	1.10	1	8	2	97	0.00	0.0	3.312	0.025	8	2	1	1
PL.42051	PL.42047	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.25	26.86	12	560	148	97	0.06	0.0	3.311	0.030	0	0	0	73
PL.42053	PL.42051	A	#4 ACSR	7.19Y	119.8	0.00	5.25	1.28	1	9	2	98	0.00	0.0	3.317	0.006	0	0	0	1
PD.6638	PL.42053	A	40QA	7.19Y	119.8	0.00	5.25	1.28	3	9	2	98	0.00	0.0	3.317	0.006	0	0	0	1
PL.42054	PD.6638	A	#2 ACSR	7.19Y	119.8	0.00	5.25	1.28	1	9	2	98	0.00	0.0	3.360	0.043	9	2	1	1
PL.42055	PL.42051	A	#2 ACSR	7.19Y	119.8	0.00	5.25	1.45	1	10	3	96	0.00	0.0	3.317	0.006	0	0	0	1
PD.6640	PL.42055	A	40QA	7.19Y	119.8	0.00	5.25	1.45	4	10	3	96	0.00	0.0	3.317	0.006	0	0	0	1
PL.42056	PD.6640	A	#2 ACSR	7.19Y	119.8	0.00	5.25	1.45	1	10	3	96	0.00	0.0	3.344	0.027	10	3	1	1
PL.42052	PL.42051	ABC	#1/0 ACSR	7.18Y	119.7	0.05	5.30	25.95	11	541	143	97	0.19	0.0	3.418	0.107	0	0	0	71
PL.42057	PL.42052	A	6 A (CWC)	7.18Y	119.7	0.01	5.30	23.36	17	162	43	97	0.01	0.0	3.424	0.006	0	0	0	17
PD.6535	PL.42057	A	40QA	7.18Y	119.7	0.00	5.30	23.36	58	162	43	97	0.00	0.0	3.424	0.006	0	0	0	17
PL.42058	PD.6535	A	6 A (CWC)	7.18Y	119.7	0.03	5.33	23.36	17	162	43	97	0.04	0.0	3.453	0.029	15	4	1	17
PL.42059	PL.42058	A	6 A (CWC)	7.18Y	119.6	0.06	5.39	21.14	15	147	39	97	0.06	0.0	3.512	0.059	0	0	0	16
PL.42060	PL.42059	A	6 A (CWC)	7.17Y	119.6	0.04	5.43	21.14	15	147	39	97	0.05	0.0	3.555	0.042	0	0	1	16
PL.42061	PL.42060	A	6 A (CWC)	7.17Y	119.5	0.05	5.48	21.13	15	147	39	97	0.05	0.0	3.604	0.049	3	1	1	15
PL.56645	PL.42061	A	6 A (CWC)	7.17Y	119.4	0.09	5.57	20.65	15	143	38	97	0.10	0.1	3.707	0.103	14	4	2	14
PL.56646	PL.56645	A	#4 ACSR	7.16Y	119.4	0.06	5.63	11.90	9	82	22	97	0.04	0.0	3.830	0.123	15	4	1	8
PL.42015	PL.56646	A	#4 ACSR	7.16Y	119.3	0.05	5.68	9.75	8	68	18	97	0.02	0.0	3.954	0.125	13	3	1	7
PL.42016	PL.42015	A	#4 ACSR	7.16Y	119.3	0.01	5.69	6.56	5	45	12	97	0.00	0.0	4.006	0.052	7	2	1	5
PL.41556	PL.42016	A	#4 ACSR	7.16Y	119.3	0.00	5.70	2.48	2	17	5	96	0.00	0.0	4.086	0.080	17	5	2	2
PL.56714	PL.42016	A	6 A (CWC)	7.16Y	119.3	0.00	5.69	1.49	1	10	3	96	0.00	0.0	4.041	0.035	10	3	1	1
PL.56715	PL.56714	A	6 A (CWC)	7.16Y	119.3	0.00	5.69	0.00	0	0	0	100	0.00	0.0	4.095	0.055	0	0	0	0
PL.56596	PL.42016	A	#4 ACSR	7.16Y	119.3	0.01	5.70	1.58	1	11	3	96	0.00	0.0	4.162	0.156	11	3	1	1
PL.41555	PL.42015	A	#4 ACSR	7.16Y	119.3	0.01	5.68	1.37	1	9	2	98	0.00	0.0	4.121	0.167	9	2	1	1
PL.64675	PL.56645	A	#4 ACSR	7.16Y	119.4	0.01	5.58	6.77	5	47	12	97	0.01	0.0	3.752	0.046	0	0	0	4
PL.64676	PL.64675	A	#4 ACSR	7.16Y	119.4	0.00	5.58	6.77	5	47	12	97	0.00	0.0	3.752	0.000	11	3	1	4
PL.41418	PL.64676	A	#4 ACSR	7.16Y	119.4	0.01	5.59	5.16	4	36	9	97	0.00	0.0	3.806	0.054	10	3	1	3
PL.56647	PL.41418	A	#1/0 ACSR	7.16Y	119.4	0.01	5.61	3.73	2	26	7	97	0.00	0.0	3.957	0.151	10	3	1	2
PL.56648	PL.56647	A	#1/0 ACSR	7.16Y	119.4	0.00	5.61	2.26	1	16	4	97	0.00	0.0	4.008	0.051	0	0	0	1
PL.56649	PL.56648	A	#1/0 ACSR	7.16Y	119.4	0.01	5.62	2.26	1	16	4	97	0.00	0.0	4.323	0.315	16	4	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56643	PL.64676	A	#4 ACSR	7.16Y	119.4	0.00	5.58	0.00	0	0	0	100	0.00	0.0	3.824	0.072	0	0	0	0
PL.56644	PL.56643	A	#4 ACSR	7.16Y	119.4	0.00	5.58	0.00	0	0	0	100	0.00	0.0	3.904	0.080	0	0	0	0
PL.41802	PL.56644	A	#4 ACSR	7.16Y	119.4	0.00	5.58	0.00	0	0	0	100	0.00	0.0	4.020	0.116	0	0	0	0
PL.41577	PL.42052	ABC	#1/0 ACSR	7.18Y	119.7	0.03	5.33	18.16	8	378	100	97	0.07	0.0	3.503	0.084	0	0	0	54
PL.59295	PL.41577	A	6 A (CWC)	7.18Y	119.7	0.01	5.33	36.09	26	250	66	97	0.01	0.0	3.506	0.003	0	0	0	36
PD.8774	PL.59295	A	40T	7.18Y	119.7	0.00	5.33	36.09	0	250	66	97	0.00	0.0	3.506	0.003	0	0	0	36
PL.59296	PD.8774	A	6 A (CWC)	7.18Y	119.6	0.08	5.41	36.09	26	250	66	97	0.16	0.1	3.556	0.051	4	1	2	36
PL.56601	PL.59296	A	6 A (CWC)	7.17Y	119.6	0.01	5.43	6.78	5	47	12	97	0.00	0.0	3.647	0.091	47	12	5	5
PL.56602	PL.59296	A	6 A (CWC)	7.17Y	119.5	0.05	5.46	28.67	20	199	53	97	0.07	0.0	3.594	0.038	18	5	2	29
PL.56698	PL.56602	A	6 A (CWC)	7.17Y	119.5	0.07	5.54	26.12	19	181	48	97	0.10	0.1	3.657	0.063	0	0	0	27
PL.59396	PL.56698	A	6 A (CWC)	7.16Y	119.4	0.09	5.62	26.12	19	181	48	97	0.12	0.1	3.730	0.074	10	3	1	27
PL.59397	PL.59396	A	6 A (CWC)	7.15Y	119.2	0.14	5.76	24.64	18	171	45	97	0.18	0.1	3.855	0.125	10	3	1	26
PL.56597	PL.59397	A	#4 ACSR	7.15Y	119.2	0.01	5.77	4.44	3	31	8	97	0.00	0.0	3.954	0.099	19	5	2	3
PL.56598	PL.56597	A	#1/0 ACSR	7.15Y	119.2	0.00	5.77	1.75	1	12	3	97	0.00	0.0	4.033	0.078	12	3	1	1
PL.56238	PL.59397	A	6 A (CWC)	7.15Y	119.2	0.04	5.80	12.53	9	87	23	97	0.03	0.0	3.939	0.084	11	3	2	16
PL.57823	PL.56238	A	6 A (CWC)	7.15Y	119.2	0.02	5.82	6.71	5	46	12	97	0.01	0.0	4.018	0.080	11	3	3	12
PL.57822	PL.57823	A	6 A (CWC)	7.15Y	119.2	0.00	5.82	0.67	0	5	1	98	0.00	0.0	4.155	0.136	5	1	1	1
PL.57824	PL.57823	A	6 A (CWC)	7.15Y	119.2	0.00	5.83	4.40	3	30	8	97	0.00	0.0	4.046	0.027	7	2	2	8
PL.56509	PL.57824	A	6 A (CWC)	7.15Y	119.2	0.01	5.84	3.35	2	23	6	97	0.00	0.0	4.135	0.089	0	0	0	6
PL.56510	PL.56509	A	6 A (CWC)	7.15Y	119.2	0.00	5.84	2.35	2	16	4	97	0.00	0.0	4.168	0.033	0	0	0	1
PL.42259	PL.56510	A	6 A (CWC)	7.15Y	119.1	0.01	5.85	2.35	2	16	4	97	0.00	0.0	4.295	0.127	16	4	1	1
PL.56689	PL.56509	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	1.01	0	7	2	96	0.00	0.0	4.175	0.040	1	0	1	5
PL.56690	PL.56689	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	0.86	0	6	2	95	0.00	0.0	4.207	0.032	2	1	2	4
PL.56511	PL.56690	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	0.50	0	3	1	95	0.00	0.0	4.219	0.013	2	1	1	2
PL.42143	PL.56511	A	#1/0 ACSR	7.15Y	119.2	0.00	5.84	0.17	0	1	0	100	0.00	0.0	4.276	0.057	1	0	1	1
PL.56495	PL.56238	A	#2 ACSR	7.15Y	119.2	0.00	5.80	4.18	2	29	8	96	0.00	0.0	3.968	0.030	29	8	2	2
PL.56236	PL.59397	A	6 A (CWC)	7.15Y	119.2	0.00	5.76	2.60	2	18	5	96	0.00	0.0	3.906	0.051	18	5	3	3
PL.56237	PL.59397	A	6 A (CWC)	7.15Y	119.2	0.01	5.76	3.69	3	26	7	97	0.00	0.0	3.941	0.086	26	7	3	3
PL.42252	PL.41577	A	6 A (CWC)	7.18Y	119.7	0.00	5.33	18.39	13	128	34	97	0.00	0.0	3.508	0.006	0	0	0	18
PD.6478	PL.42252	A	40QA	7.18Y	119.7	0.00	5.33	18.39	46	128	34	97	0.00	0.0	3.508	0.006	0	0	0	18
PL.56599	PD.6478	A	6 A (CWC)	7.18Y	119.7	0.02	5.35	18.39	13	128	34	97	0.02	0.0	3.531	0.023	22	6	2	18

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56702	PL.56599	A	6 A (CWC)	7.18Y	119.6	0.03	5.38	11.37	8	79	21	97	0.02	0.0	3.593	0.062	8	2	1	8
PL.56701	PL.56702	A	#2 ACSR	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.619	0.026	0	0	0	0
PL.56703	PL.56702	A	6 A (CWC)	7.18Y	119.6	0.00	5.38	10.27	7	71	19	97	0.00	0.0	3.598	0.006	0	0	0	7
PD.6744	PL.56703	A	40QA	7.18Y	119.6	0.00	5.38	10.27	26	71	19	97	0.00	0.0	3.598	0.006	0	0	0	7
PL.56700	PD.6744	A	6 A (CWC)	7.18Y	119.6	0.02	5.40	10.27	7	71	19	97	0.01	0.0	3.647	0.049	15	4	1	7
PL.56848	PL.56700	A	6 A (CWC)	7.18Y	119.6	0.01	5.41	8.18	6	57	15	97	0.00	0.0	3.676	0.028	0	0	0	6
PL.56947	PL.56848	A	6 A (CWC)	7.17Y	119.6	0.01	5.43	6.34	5	44	12	96	0.00	0.0	3.724	0.049	0	0	0	5
PL.56946	PL.56947	A	6 A (CWC)	7.17Y	119.6	0.00	5.43	1.60	1	11	3	96	0.00	0.0	3.752	0.028	11	3	1	1
PL.56948	PL.56947	A	6 A (CWC)	7.17Y	119.6	0.01	5.43	4.74	3	33	9	96	0.00	0.0	3.754	0.030	10	3	1	4
PL.56949	PL.56948	A	6 A (CWC)	7.17Y	119.6	0.01	5.44	3.28	2	23	6	97	0.00	0.0	3.811	0.056	9	2	1	3
PL.56950	PL.56949	A	#4 ACSR	7.17Y	119.6	0.00	5.44	1.95	2	14	4	96	0.00	0.0	3.830	0.019	14	4	2	2
PL.56849	PL.56848	A	#4 ACSR	7.18Y	119.6	0.00	5.41	1.84	1	13	3	97	0.00	0.0	3.700	0.024	0	0	0	1
PL.56223	PL.56849	A	#4 ACSR	7.18Y	119.6	0.00	5.42	1.84	1	13	3	97	0.00	0.0	3.750	0.050	13	3	1	1
PL.63223	PL.56599	A	6 A (CWC)	7.18Y	119.7	0.00	5.35	0.00	0	0	0	100	0.00	0.0	3.531	0.000	0	0	0	0
PL.63224	PL.63223	A	6 A (CWC)	7.18Y	119.7	0.00	5.35	0.00	0	0	0	100	0.00	0.0	3.576	0.045	0	0	0	0
PL.56600	PL.56599	A	#4 ACSR	7.18Y	119.6	0.01	5.36	3.85	3	27	7	97	0.00	0.0	3.611	0.080	3	1	1	8
PL.42570	PL.56600	A	#4 ACSR	7.18Y	119.6	0.00	5.36	3.36	3	23	6	97	0.00	0.0	3.641	0.030	0	0	0	7
PL.56606	PL.42570	A	#4 ACSR	7.18Y	119.6	0.02	5.38	3.36	3	23	6	97	0.00	0.0	3.741	0.100	0	0	0	7
PL.56610	PL.56606	A	#4 ACSR	7.18Y	119.6	0.01	5.39	3.36	3	23	6	97	0.00	0.0	3.802	0.061	3	1	3	6
PL.56611	PL.56610	A	#4 ACSR	7.18Y	119.6	0.00	5.39	2.88	2	20	5	97	0.00	0.0	3.844	0.042	6	2	1	3
PL.56609	PL.56611	A	#4 ACSR	7.18Y	119.6	0.00	5.40	1.95	2	14	4	96	0.00	0.0	3.885	0.042	0	0	0	2
PL.56607	PL.56609	A	#4 ACSR	7.18Y	119.6	0.01	5.40	1.95	2	14	4	96	0.00	0.0	3.945	0.060	0	0	0	2
PL.42571	PL.56607	A	#4 ACSR	7.18Y	119.6	0.00	5.40	1.95	2	14	4	96	0.00	0.0	4.001	0.055	14	4	2	2
PL.56608	PL.56606	A	#1/0 ACSR	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.801	0.060	0	0	1	1
PL.56699	PL.56600	A	#2 ACSR	7.18Y	119.6	0.00	5.36	0.00	0	0	0	100	0.00	0.0	3.641	0.030	0	0	0	0
PL.42048	PL.42047	A	#2 ACSR	7.19Y	119.8	0.00	5.23	0.93	1	6	2	95	0.00	0.0	3.287	0.006	0	0	0	1
PD.6641	PL.42048	A	40QA	7.19Y	119.8	0.00	5.23	0.93	2	6	2	95	0.00	0.0	3.287	0.006	0	0	0	1
PL.64689	PD.6641	A	#1/0 ACSR	7.19Y	119.8	0.00	5.23	0.93	0	6	2	95	0.00	0.0	3.306	0.019	0	0	0	1
PL.64690	PL.64689	A	#2 ACSR	7.19Y	119.8	0.00	5.23	0.93	1	6	2	95	0.00	0.0	3.306	0.000	6	2	1	1
PL.64691	PL.64690	A	#1/0 ACSR	7.19Y	119.8	0.00	5.23	0.00	0	0	0	100	0.00	0.0	3.365	0.059	0	0	0	0
PL.64692	PL.64691	A	#1/0 ACSR	7.19Y	119.8	0.00	5.23	0.00	0	0	0	100	0.00	0.0	3.407	0.042	0	0	0	0

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56395	PL.56392	A	#1/0 ACSR	7.20Y	119.9	0.00	5.07	5.75	2	40	11	96	0.00	0.0	2.966	0.004	0	0	0	5
PD.8314	PL.56395	A	20QA	7.20Y	119.9	0.00	5.07	5.75	29	40	11	96	0.00	0.0	2.966	0.004	0	0	0	5
PL.56396	PD.8314	A	#1/0 ACSR	7.19Y	119.9	0.01	5.08	5.75	2	40	11	96	0.00	0.0	3.044	0.078	0	0	0	5
PL.59357	PL.56396	A	#1/0 ACSR	7.19Y	119.9	0.01	5.09	5.75	2	40	11	96	0.00	0.0	3.108	0.065	0	0	0	5
PL.59358	PL.59357	A	#1/0 ACSR	7.19Y	119.9	0.00	5.09	1.53	1	11	3	96	0.00	0.0	3.176	0.067	11	3	1	1
PL.59359	PL.59357	A	#1/0 ACSR	7.19Y	119.9	0.00	5.09	1.09	0	8	2	97	0.00	0.0	3.158	0.049	8	2	1	1
PL.62251	PL.59357	A	#1/0 ACSR	7.19Y	119.9	0.00	5.10	3.12	1	22	6	96	0.00	0.0	3.149	0.041	8	2	1	3
PL.62250	PL.62251	A	#1/0 ACSR	7.19Y	119.9	0.00	5.10	1.93	1	13	4	96	0.00	0.0	3.191	0.042	7	2	1	2
PL.62249	PL.62250	A	1/0 AL URD	7.19Y	119.9	0.00	5.10	0.93	1	6	2	95	0.00	0.0	3.201	0.010	6	2	1	1
PL.56924	PL.56922	C	#2 ACSR	7.20Y	120.0	0.00	4.98	1.27	1	9	2	98	0.00	0.0	2.804	0.006	0	0	0	1
PD.6720	PL.56924	C	40QA	7.20Y	120.0	0.00	4.98	1.27	3	9	2	98	0.00	0.0	2.804	0.006	0	0	0	1
PL.42040	PD.6720	C	#2 ACSR	7.20Y	120.0	0.00	4.98	1.27	1	9	2	98	0.00	0.0	2.851	0.047	9	2	1	1
PL.56841	PL.56839	C	6 A (CWC)	7.22Y	120.3	0.00	4.67	1.84	1	13	3	97	0.00	0.0	2.636	0.006	0	0	0	1
PD.6615	PL.56841	C	60QA	7.22Y	120.3	0.00	4.67	1.84	3	13	3	97	0.00	0.0	2.636	0.006	0	0	0	1
PL.52126	PD.6615	C	6 A (CWC)	7.22Y	120.3	0.00	4.67	1.84	1	13	3	97	0.00	0.0	2.673	0.037	13	3	1	1
PL.56722	PL.56724	C	6 A (CWC)	7.25Y	120.8	0.00	4.21	2.60	2	18	5	96	0.00	0.0	2.395	0.006	0	0	0	3
PD.6637	PL.56722	C	60QA	7.25Y	120.8	0.00	4.21	2.60	4	18	5	96	0.00	0.0	2.395	0.006	0	0	0	3
PL.52177	PD.6637	C	6 A (CWC)	7.25Y	120.8	0.00	4.22	2.60	2	18	5	96	0.00	0.0	2.426	0.032	2	1	1	3
PL.52178	PL.52177	C	6 A (CWC)	7.25Y	120.8	0.00	4.22	2.28	2	16	4	97	0.00	0.0	2.463	0.036	16	4	2	2
PL.41321	PL.42037	C	#1/0 ACSR	7.27Y	121.2	0.00	3.78	0.53	0	4	1	97	0.00	0.0	2.192	0.025	4	1	1	1
PL.41751	PL.56962	ABC	#1/0 ACSR	7.29Y	121.4	0.01	3.56	42.84	19	905	242	97	0.09	0.0	2.068	0.019	0	0	0	105
PL.41789	PL.41751	ABC	#1/0 ACSR	7.29Y	121.4	0.00	3.56	42.84	19	905	242	97	0.03	0.0	2.073	0.006	0	0	0	105
PD.6812	PL.41789	ABC	70L	7.29Y	121.4	0.00	3.56	42.84	61	905	242	97	0.00	0.0	2.073	0.006	0	0	0	105
PL.51929	PD.6812	ABC	#1/0 ACSR	7.28Y	121.4	0.05	3.61	42.84	19	905	242	97	0.29	0.0	2.135	0.061	14	4	1	105
PL.51932	PL.51929	ABC	#1/0 ACSR	7.28Y	121.3	0.04	3.65	42.16	18	890	238	97	0.27	0.0	2.191	0.056	0	0	0	104
PL.56717	PL.51932	C	#2 ACSR	7.28Y	121.3	0.00	3.65	2.29	1	16	4	97	0.00	0.0	2.195	0.003	0	0	0	2
PD.8330	PL.56717	C	10QA	7.28Y	121.3	0.00	3.65	2.29	0	16	4	97	0.00	0.0	2.195	0.003	0	0	0	2
PL.56718	PD.8330	C	#2 ACSR	7.28Y	121.3	0.00	3.66	2.29	1	16	4	97	0.00	0.0	2.231	0.036	0	0	0	2
PL.56716	PL.56718	C	#2 ACSR	7.28Y	121.3	0.00	3.66	2.29	1	16	4	97	0.00	0.0	2.270	0.040	16	4	2	2
PL.51933	PL.51932	ABC	#1/0 ACSR	7.28Y	121.3	0.03	3.69	41.39	18	874	233	97	0.20	0.0	2.236	0.045	0	0	0	102
PL.51931	PL.51933	ABC	#1/0 ACSR	7.28Y	121.3	0.03	3.71	41.39	18	873	233	97	0.16	0.0	2.271	0.036	10	3	1	102

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41432	PL.51931	ABC	#1/0 ACSR	7.27Y	121.2	0.10	3.81	40.19	17	848	226	97	0.60	0.1	2.411	0.140	0	0	0	99
PL.41433	PL.41432	ABC	#1/0 ACSR	7.27Y	121.1	0.04	3.85	40.19	17	847	226	97	0.24	0.0	2.467	0.057	0	0	0	99
PL.41434	PL.41433	A	#2 ACSR	7.27Y	121.1	0.00	3.85	1.46	1	10	3	96	0.00	0.0	2.473	0.006	0	0	0	2
PD.6625	PL.41434	A	25QA	7.27Y	121.1	0.00	3.85	1.46	6	10	3	96	0.00	0.0	2.473	0.006	0	0	0	2
PL.59276	PD.6625	A	#2 ACSR	7.27Y	121.1	0.00	3.86	1.46	1	10	3	96	0.00	0.0	2.511	0.038	10	3	2	2
PL.41435	PL.41433	ABC	#1/0 ACSR	7.26Y	121.1	0.07	3.92	39.70	17	837	223	97	0.41	0.0	2.565	0.098	0	0	0	97
PL.41436	PL.41435	ABC	#1/0 ACSR	7.26Y	121.0	0.05	3.98	39.13	17	824	219	97	0.30	0.0	2.640	0.075	17	4	2	96
PL.41779	PL.41436	A	#2 ACSR	7.26Y	121.0	0.00	3.98	4.82	3	34	9	97	0.00	0.0	2.646	0.006	0	0	0	2
PD.6613	PL.41779	A	40QA	7.26Y	121.0	0.00	3.98	4.82	12	34	9	97	0.00	0.0	2.646	0.006	0	0	0	2
PL.41780	PD.6613	A	#2 ACSR	7.26Y	121.0	0.00	3.98	4.82	3	34	9	97	0.00	0.0	2.666	0.020	0	0	0	2
PL.51750	PL.41780	A	#2 ACSR	7.26Y	121.0	0.01	3.99	4.82	3	34	9	97	0.00	0.0	2.744	0.078	20	5	1	2
PL.56243	PL.51750	A	#2 ACSR	7.26Y	121.0	0.00	3.99	1.96	1	14	4	96	0.00	0.0	2.787	0.044	0	0	0	1
PL.56244	PL.56243	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	1.96	1	14	4	96	0.00	0.0	2.951	0.164	14	4	1	1
PL.56935	PL.41436	C	#2 ACSR	7.26Y	121.0	0.01	3.98	28.71	16	202	53	97	0.01	0.0	2.646	0.006	0	0	0	24
PD.8336	PL.56935	C	40QA	7.26Y	121.0	0.00	3.98	28.71	72	202	53	97	0.00	0.0	2.646	0.006	0	0	0	24
PL.56936	PD.8336	C	#2 ACSR	7.25Y	120.9	0.10	4.09	28.71	16	202	53	97	0.15	0.1	2.763	0.117	4	1	2	24
PL.56937	PL.56936	C	#2 ACSR	7.25Y	120.8	0.11	4.19	28.20	16	198	52	97	0.16	0.1	2.885	0.122	0	0	0	22
PL.56938	PL.56937	C	#2 ACSR	7.25Y	120.8	0.00	4.19	1.85	1	13	3	97	0.00	0.0	2.935	0.050	13	3	1	1
PL.56939	PL.56937	C	#2 ACSR	7.25Y	120.8	0.00	4.19	0.65	0	5	1	98	0.00	0.0	2.948	0.064	5	1	1	1
PL.56940	PL.56937	C	#2 ACSR	7.25Y	120.8	0.03	4.23	25.70	15	180	48	97	0.05	0.0	2.928	0.043	0	0	0	20
PL.41658	PL.56940	C	#2 ACSR	7.24Y	120.7	0.03	4.26	23.00	13	161	43	97	0.04	0.0	2.969	0.041	0	0	0	19
PL.41836	PL.41658	C	#4 ACSR	7.24Y	120.7	0.00	4.26	1.33	1	9	2	98	0.00	0.0	3.016	0.047	9	2	1	1
PL.41659	PL.41658	C	#2 ACSR	7.24Y	120.7	0.06	4.31	21.66	12	152	40	97	0.06	0.0	3.053	0.084	7	2	1	18
PL.41660	PL.41659	C	#2 ACSR	7.24Y	120.7	0.02	4.33	20.72	12	145	38	97	0.02	0.0	3.081	0.028	21	6	2	17
PL.62048	PL.41660	C	#2 ACSR	7.24Y	120.6	0.03	4.36	17.73	10	124	33	97	0.03	0.0	3.139	0.058	0	0	1	15
PL.61542	PL.62048	C	#4 ACSR	7.24Y	120.6	0.00	4.37	1.45	1	10	3	96	0.00	0.0	3.214	0.075	0	0	0	1
PL.41790	PL.61542	C	#4 ACSR	7.24Y	120.6	0.00	4.37	1.45	1	10	3	96	0.00	0.0	3.268	0.054	10	3	1	1
PL.61543	PL.62048	C	#4 ACSR	7.24Y	120.6	0.04	4.40	7.57	6	53	14	97	0.02	0.0	3.273	0.134	12	3	2	6
PL.56614	PL.61543	C	#2 ACSR	7.24Y	120.6	0.00	4.40	1.43	1	10	3	96	0.00	0.0	3.341	0.068	10	3	1	1
PL.56613	PL.61543	C	#1/0 ACSR	7.24Y	120.6	0.00	4.40	1.65	1	12	3	97	0.00	0.0	3.277	0.004	0	0	0	1
PD.8313	PL.56613	C	20QA	7.24Y	120.6	0.00	4.40	1.65	8	12	3	97	0.00	0.0	3.277	0.004	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.57481	PD.8313	C	#1/0 ACSR	7.24Y	120.6	0.00	4.40	1.65	1	12	3	97	0.00	0.0	3.365	0.088	12	3	1	1
PL.56612	PL.61543	C	#4 ACSR	7.24Y	120.6	0.01	4.41	2.72	2	19	5	97	0.00	0.0	3.329	0.056	9	2	1	2
PL.56615	PL.56612	C	1/0 AL URD	7.24Y	120.6	0.00	4.41	1.43	1	10	3	96	0.00	0.0	3.348	0.019	10	3	1	1
PL.61544	PL.62048	C	#2 ACSR	7.24Y	120.6	0.04	4.41	8.67	5	61	16	97	0.02	0.0	3.298	0.159	0	0	0	7
PL.64087	PL.61544	C	#2 ACSR	7.24Y	120.6	0.00	4.41	2.30	1	16	4	97	0.00	0.0	3.412	0.114	16	4	1	1
PL.41334	PL.61544	C	#4 ACSR	7.24Y	120.6	0.00	4.41	0.42	0	3	1	95	0.00	0.0	3.355	0.058	3	1	1	1
PL.56245	PL.61544	C	#2 ACSR	7.23Y	120.6	0.02	4.43	5.95	3	42	11	97	0.01	0.0	3.423	0.126	0	0	0	5
PL.56246	PL.56245	C	#2 ACSR	7.23Y	120.6	0.01	4.44	4.17	2	29	8	96	0.00	0.0	3.498	0.075	10	3	1	4
PL.56391	PL.56246	C	#2 ACSR	7.23Y	120.6	0.00	4.44	2.68	2	19	5	97	0.00	0.0	3.568	0.070	19	5	3	3
PL.56247	PL.56245	C	#2 ACSR	7.23Y	120.6	0.00	4.43	1.78	1	12	3	97	0.00	0.0	3.440	0.016	12	3	1	1
PL.56589	PL.56245	C	#2 ACSR	7.23Y	120.6	0.00	4.43	0.00	0	0	0	100	0.00	0.0	3.447	0.024	0	0	0	0
PL.56590	PL.56589	C	#2 ACSR	7.23Y	120.6	0.00	4.43	0.00	0	0	0	100	0.00	0.0	3.474	0.027	0	0	0	0
PL.56591	PL.56589	C	1/0 AL URD	7.23Y	120.6	0.00	4.43	0.00	0	0	0	100	0.00	0.0	3.599	0.152	0	0	0	0
PL.42032	PL.56940	C	#2 ACSR	7.25Y	120.8	0.00	4.23	2.70	2	19	5	97	0.00	0.0	2.946	0.019	19	5	1	1
PL.56485	PL.41436	ABC	#1/0 ACSR	7.26Y	121.0	0.03	4.00	27.15	12	572	152	97	0.10	0.0	2.695	0.055	34	9	3	68
PL.56778	PL.56485	ABC	#1/0 ACSR	7.26Y	121.0	0.02	4.02	25.53	11	537	143	97	0.08	0.0	2.741	0.045	0	0	1	65
PL.56779	PL.56778	ABC	#1/0 ACSR	7.26Y	121.0	0.02	4.04	25.53	11	537	143	97	0.07	0.0	2.778	0.038	0	0	0	64
PL.42263	PL.56779	ABC	#1/0 ACSR	7.26Y	120.9	0.02	4.06	25.53	11	537	143	97	0.08	0.0	2.826	0.048	7	2	1	64
PL.41791	PL.42263	ABC	#1/0 ACSR	7.26Y	120.9	0.02	4.08	24.38	11	513	136	97	0.06	0.0	2.866	0.041	0	0	0	61
PL.56941	PL.41791	ABC	#1/0 ACSR	7.25Y	120.9	0.02	4.10	24.38	11	513	136	97	0.07	0.0	2.909	0.042	0	0	0	61
PL.56943	PL.56941	ABC	#1/0 ACSR	7.25Y	120.9	0.03	4.13	23.67	10	498	132	97	0.11	0.0	2.986	0.078	15	4	2	59
PL.56944	PL.56943	ABC	#1/0 ACSR	7.25Y	120.8	0.04	4.17	22.96	10	483	128	97	0.15	0.0	3.092	0.106	0	0	0	57
PL.56945	PL.56944	ABC	#1/0 ACSR	7.25Y	120.8	0.02	4.20	22.96	10	483	128	97	0.07	0.0	3.144	0.051	0	0	0	57
PL.52114	PL.56945	ABC	#1/0 ACSR	7.25Y	120.8	0.03	4.22	22.96	10	483	128	97	0.10	0.0	3.213	0.070	10	3	2	57
PL.52113	PL.52114	ABC	#1/0 ACSR	7.24Y	120.7	0.03	4.26	17.72	8	372	99	97	0.09	0.0	3.323	0.110	0	0	0	43
PL.42559	PL.52113	A	#4 ACSR	7.24Y	120.7	0.00	4.26	3.77	3	26	7	97	0.00	0.0	3.329	0.006	0	0	0	2
PD.6630	PL.42559	A	10QA	7.24Y	120.7	0.00	4.26	3.77	0	26	7	97	0.00	0.0	3.329	0.006	0	0	0	2
PL.56616	PD.6630	A	#4 ACSR	7.24Y	120.7	0.01	4.27	3.77	3	26	7	97	0.00	0.0	3.441	0.112	26	7	2	2
PL.42558	PL.52113	ABC	#1/0 ACSR	7.24Y	120.7	0.03	4.29	16.33	7	343	91	97	0.07	0.0	3.428	0.105	0	0	0	40
PL.42561	PL.42558	A	#2 ACSR	7.24Y	120.7	0.00	4.29	0.52	0	4	1	97	0.00	0.0	3.433	0.006	0	0	0	2
PD.6614	PL.42561	A	10QA	7.24Y	120.7	0.00	4.29	0.52	0	4	1	97	0.00	0.0	3.433	0.006	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.51930	PD.6614	A	#2 ACSR	7.24Y	120.7	0.00	4.29	0.52	0	4	1	97	0.00	0.0	3.483	0.050	4	1	2	2
PL.57906	PL.42558	ABC	#1/0 ACSR	7.24Y	120.7	0.02	4.30	12.80	6	269	71	97	0.03	0.0	3.495	0.067	12	3	1	31
PL.57907	PL.57906	ABC	#1/0 ACSR	7.24Y	120.7	0.02	4.33	12.25	5	257	68	97	0.04	0.0	3.602	0.107	11	3	1	30
PL.42566	PL.57907	ABC	#1/0 ACSR	7.24Y	120.7	0.01	4.33	11.74	5	247	65	97	0.01	0.0	3.635	0.032	0	0	0	29
PL.42567	PL.42566	ABC	#1/0 ACSR	7.24Y	120.7	0.01	4.34	11.74	5	247	65	97	0.01	0.0	3.673	0.038	0	0	0	29
PL.42568	PL.42567	ABC	#1/0 ACSR	7.24Y	120.7	0.00	4.34	11.74	5	247	65	97	0.00	0.0	3.673	0.000	2	1	1	29
PL.42569	PL.42568	C	#4 ACSR	7.24Y	120.7	0.00	4.34	2.17	2	15	4	97	0.00	0.0	3.679	0.006	0	0	0	2
PD.6655	PL.42569	C	30QA	7.24Y	120.7	0.00	4.34	2.17	7	15	4	97	0.00	0.0	3.679	0.006	0	0	0	2
PL.56400	PD.6655	C	#4 ACSR	7.24Y	120.7	0.01	4.35	2.17	2	15	4	97	0.00	0.0	3.799	0.120	13	3	1	2
PL.56401	PL.56400	C	#4 ACSR	7.24Y	120.6	0.00	4.35	0.39	0	3	1	95	0.00	0.0	3.913	0.114	3	1	1	1
PL.42007	PL.42568	ABC	#1/0 ACSR	7.24Y	120.6	0.02	4.36	10.92	5	229	61	97	0.03	0.0	3.771	0.098	0	0	0	26
PL.42010	PL.42007	C	#2 ACSR	7.24Y	120.6	0.00	4.36	1.49	1	10	3	96	0.00	0.0	3.777	0.006	0	0	0	1
PD.6767	PL.42010	C	30QA	7.24Y	120.6	0.00	4.36	1.49	5	10	3	96	0.00	0.0	3.777	0.006	0	0	0	1
PL.42011	PD.6767	C	#2 ACSR	7.24Y	120.6	0.00	4.36	1.49	1	10	3	96	0.00	0.0	3.923	0.146	10	3	1	1
PL.42012	PL.42007	ABC	#1/0 ACSR	7.24Y	120.6	0.01	4.38	9.02	4	189	50	97	0.02	0.0	3.864	0.093	30	8	3	23
PL.56233	PL.42012	ABC	#1/0 ACSR	7.24Y	120.6	0.01	4.39	7.60	3	160	42	97	0.01	0.0	3.960	0.096	8	2	1	20
PL.56232	PL.56233	ABC	#1/0 ACSR	7.24Y	120.6	0.00	4.39	4.12	2	86	23	97	0.00	0.0	4.015	0.055	2	0	1	13
PL.51969	PL.56232	B	6 A (CWC)	7.24Y	120.6	0.00	4.39	12.10	9	85	22	97	0.00	0.0	4.021	0.006	0	0	0	12
PD.6635	PL.51969	B	40QA	7.24Y	120.6	0.00	4.39	12.10	30	85	22	97	0.00	0.0	4.021	0.006	0	0	0	12
PL.41305	PD.6635	B	6 A (CWC)	7.23Y	120.6	0.03	4.42	12.10	9	85	22	97	0.02	0.0	4.077	0.056	18	5	2	12
PL.56229	PL.41305	B	6 A (CWC)	7.23Y	120.6	0.02	4.45	8.34	6	58	15	97	0.01	0.0	4.148	0.071	14	4	1	8
PL.56230	PL.56229	B	6 A (CWC)	7.23Y	120.5	0.01	4.46	6.37	5	45	12	97	0.00	0.0	4.205	0.057	8	2	1	7
PL.56231	PL.56230	B	6 A (CWC)	7.23Y	120.5	0.01	4.47	5.16	4	36	10	96	0.00	0.0	4.249	0.044	0	0	0	6
PL.41608	PL.56231	B	6 A (CWC)	7.23Y	120.5	0.02	4.49	5.16	4	36	10	96	0.01	0.0	4.347	0.098	2	1	1	6
PL.42120	PL.41608	B	6 A (CWC)	7.23Y	120.5	0.00	4.50	1.23	1	9	2	98	0.00	0.0	4.390	0.043	9	2	1	1
PL.41609	PL.41608	B	6 A (CWC)	7.23Y	120.5	0.01	4.50	3.64	3	25	7	96	0.00	0.0	4.387	0.040	11	3	1	4
PL.41689	PL.41609	B	6 A (CWC)	7.23Y	120.5	0.00	4.50	2.08	1	15	4	97	0.00	0.0	4.422	0.035	0	0	0	3
PL.41499	PL.41689	B	6 A (CWC)	7.23Y	120.5	0.00	4.50	0.67	0	5	1	98	0.00	0.0	4.551	0.128	5	1	1	2
PL.41016	PL.41499	B	#2 ACSR	7.23Y	120.5	0.00	4.50	0.00	0	0	0	100	0.00	0.0	4.697	0.146	0	0	1	1
PL.41500	PL.41499	B	6 A (CWC)	7.23Y	120.5	0.00	4.50	0.00	0	0	0	100	0.00	0.0	4.598	0.047	0	0	0	0
PL.41695	PL.41689	B	#2 ACSR	7.23Y	120.5	0.00	4.50	1.41	1	10	3	96	0.00	0.0	4.462	0.040	10	3	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41837	PL.41305	B	6 A (CWC)	7.23Y	120.6	0.00	4.42	0.63	0	4	1	97	0.00	0.0	4.167	0.090	4	1	1	1
PL.41353	PL.41305	B	6 A (CWC)	7.23Y	120.6	0.00	4.42	0.51	0	4	1	97	0.00	0.0	4.129	0.052	4	1	1	1
PL.56234	PL.56233	C	#4 ACSR	7.24Y	120.6	0.00	4.39	2.46	2	17	5	96	0.00	0.0	3.966	0.006	0	0	0	2
PD.6633	PL.56234	C	10QA	7.24Y	120.6	0.00	4.39	2.46	0	17	5	96	0.00	0.0	3.966	0.006	0	0	0	2
PL.42014	PD.6633	C	#4 ACSR	7.24Y	120.6	0.00	4.39	2.46	2	17	5	96	0.00	0.0	4.040	0.074	17	5	2	2
PL.56235	PL.56233	A	#4 ACSR	7.24Y	120.6	0.02	4.41	6.88	5	48	13	97	0.01	0.0	4.022	0.063	0	0	0	4
PL.41278	PL.56235	A	#4/0 ACSR	7.24Y	120.6	0.00	4.41	0.25	0	2	0	100	0.00	0.0	4.121	0.099	2	0	1	1
PL.42033	PL.56235	A	#4 ACSR	7.23Y	120.6	0.03	4.43	6.63	5	46	12	97	0.01	0.0	4.117	0.095	0	0	0	3
PL.42035	PL.42033	A	#4/0 ACSR	7.23Y	120.6	0.00	4.44	2.33	1	16	4	97	0.00	0.0	4.123	0.006	0	0	0	2
PD.6634	PL.42035	A	25QA	7.23Y	120.6	0.00	4.44	2.33	9	16	4	97	0.00	0.0	4.123	0.006	0	0	0	2
PL.42036	PD.6634	A	#4/0 ACSR	7.23Y	120.6	0.00	4.44	2.33	1	16	4	97	0.00	0.0	4.253	0.130	16	4	2	2
PL.42034	PL.42033	A	#4 ACSR	7.23Y	120.6	0.01	4.45	4.30	3	30	8	97	0.00	0.0	4.238	0.121	30	8	1	1
PL.41543	PL.42012	C	#2 ACSR	7.24Y	120.6	0.00	4.38	0.00	0	0	0	100	0.00	0.0	3.899	0.035	0	0	0	0
PL.42013	PL.42012	C	#4 ACSR	7.24Y	120.6	0.00	4.38	0.00	0	0	0	100	0.00	0.0	3.870	0.006	0	0	0	0
PD.6632	PL.42013	C	10QA	7.24Y	120.6	0.00	4.38	0.00	0	0	0	100	0.00	0.0	3.870	0.006	0	0	0	0
PL.63464	PD.6632	C	#4 ACSR	7.24Y	120.6	0.00	4.38	0.00	0	0	0	100	0.00	0.0	3.898	0.029	0	0	0	0
PL.42008	PL.42007	A	#2 ACSR	7.24Y	120.6	0.00	4.36	4.21	2	29	8	96	0.00	0.0	3.777	0.006	0	0	0	2
PD.6631	PL.42008	A	10QA	7.24Y	120.6	0.00	4.36	4.21	0	29	8	96	0.00	0.0	3.777	0.006	0	0	0	2
PL.42009	PD.6631	A	#2 ACSR	7.24Y	120.6	0.00	4.36	4.21	2	29	8	96	0.00	0.0	3.795	0.018	29	8	2	2
PL.42562	PL.42558	A	6 A (CWC)	7.24Y	120.7	0.00	4.29	10.06	7	70	19	97	0.00	0.0	3.433	0.006	0	0	0	7
PD.6425	PL.42562	A	20QA	7.24Y	120.7	0.00	4.29	10.06	50	70	19	97	0.00	0.0	3.433	0.006	0	0	0	7
PL.42563	PD.6425	A	6 A (CWC)	7.24Y	120.7	0.04	4.33	10.06	7	70	19	97	0.02	0.0	3.528	0.094	20	5	1	7
PL.42564	PL.42563	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.98	1	7	2	96	0.00	0.0	3.568	0.040	0	0	0	1
PL.42565	PL.42564	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.98	1	7	2	96	0.00	0.0	3.663	0.095	7	2	1	1
PL.56617	PL.42563	A	#2 ACSR	7.24Y	120.7	0.01	4.34	6.21	4	43	11	97	0.00	0.0	3.618	0.090	43	11	5	5
PL.42560	PL.52113	C	#4 ACSR	7.24Y	120.7	0.00	4.26	0.40	0	3	1	95	0.00	0.0	3.329	0.006	0	0	0	1
PD.6629	PL.42560	C	10QA	7.24Y	120.7	0.00	4.26	0.40	0	3	1	95	0.00	0.0	3.329	0.006	0	0	0	1
PL.52116	PD.6629	C	#4 ACSR	7.24Y	120.7	0.00	4.26	0.40	0	3	1	95	0.00	0.0	3.361	0.033	3	1	1	1
PL.52112	PL.52114	C	#4/0 ACSR	7.25Y	120.8	0.00	4.22	14.31	4	100	27	97	0.00	0.0	3.219	0.006	0	0	0	12
PD.6534	PL.52112	C	30QA	7.25Y	120.8	0.00	4.22	14.31	48	100	27	97	0.00	0.0	3.219	0.006	0	0	0	12
PL.41792	PD.6534	C	#4/0 ACSR	7.25Y	120.8	0.00	4.23	14.31	4	100	27	97	0.00	0.0	3.233	0.014	0	0	0	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41793	PL.41792	C	#4/0 ACSR	7.25Y	120.8	0.01	4.24	14.31	4	100	27	97	0.01	0.0	3.289	0.056	2	1	2	12
PL.52115	PL.41793	C	#4/0 ACSR	7.25Y	120.8	0.01	4.25	13.97	4	98	26	97	0.01	0.0	3.339	0.050	11	3	1	10
PL.52121	PL.52115	C	#4/0 ACSR	7.24Y	120.7	0.02	4.27	12.42	4	87	23	97	0.01	0.0	3.451	0.112	0	0	0	9
PL.52120	PL.52121	C	6 A (CWC)	7.24Y	120.7	0.00	4.27	0.75	1	5	1	98	0.00	0.0	3.542	0.091	5	1	1	1
PL.52123	PL.52121	C	#4/0 ACSR	7.24Y	120.7	0.00	4.27	2.93	1	20	5	97	0.00	0.0	3.561	0.110	8	2	1	2
PL.52117	PL.52123	C	#4/0 ACSR	7.24Y	120.7	0.00	4.27	1.80	1	13	3	97	0.00	0.0	3.645	0.084	13	3	1	1
PL.52124	PL.52117	C	#4/0 ACSR	7.24Y	120.7	0.00	4.27	0.00	0	0	0	100	0.00	0.0	3.900	0.254	0	0	0	0
PL.52119	PL.52121	C	#4/0 ACSR	7.24Y	120.7	0.00	4.27	1.51	0	11	3	96	0.00	0.0	3.542	0.091	11	3	2	2
PL.66121	PL.52121	C	#4 ACSR	7.24Y	120.7	0.01	4.28	7.23	6	51	13	97	0.00	0.0	3.482	0.030	6	2	1	4
PL.66122	PL.66121	C	#4 ACSR	7.24Y	120.7	0.02	4.29	6.34	5	44	12	96	0.00	0.0	3.572	0.091	28	7	2	3
PL.52118	PL.66122	C	#4 ACSR	7.24Y	120.7	0.00	4.30	2.35	2	16	4	97	0.00	0.0	3.598	0.026	16	4	1	1
PL.56942	PL.56941	C	#2 ACSR	7.25Y	120.9	0.00	4.10	2.13	1	15	4	97	0.00	0.0	2.914	0.006	0	0	0	2
PD.6628	PL.56942	C	10QA	7.25Y	120.9	0.00	4.10	2.13	0	15	4	97	0.00	0.0	2.914	0.006	0	0	0	2
PL.52111	PD.6628	C	#2 ACSR	7.25Y	120.9	0.00	4.10	2.13	1	15	4	97	0.00	0.0	2.947	0.033	15	4	2	2
PL.51752	PL.42263	C	#4 ACSR	7.26Y	120.9	0.00	4.06	2.49	2	17	5	96	0.00	0.0	2.860	0.034	6	2	1	2
PL.51754	PL.51752	C	#4 ACSR	7.26Y	120.9	0.00	4.07	1.64	1	12	3	97	0.00	0.0	2.866	0.006	0	0	0	1
PD.6627	PL.51754	C	25QA	7.26Y	120.9	0.00	4.07	1.64	7	12	3	97	0.00	0.0	2.866	0.006	0	0	0	1
PL.51755	PD.6627	C	#4 ACSR	7.26Y	120.9	0.00	4.07	1.64	1	12	3	97	0.00	0.0	2.953	0.088	12	3	1	1
PL.51753	PL.51752	C	#4 ACSR	7.26Y	120.9	0.00	4.06	0.00	0	0	0	100	0.00	0.0	2.876	0.017	0	0	0	0
PL.41437	PL.41435	A	#2 ACSR	7.26Y	121.1	0.00	3.92	1.72	1	12	3	97	0.00	0.0	2.571	0.006	0	0	0	1
PD.6626	PL.41437	A	25QA	7.26Y	121.1	0.00	3.92	1.72	7	12	3	97	0.00	0.0	2.571	0.006	0	0	0	1
PL.51751	PD.6626	A	#2 ACSR	7.26Y	121.1	0.00	3.92	1.72	1	12	3	97	0.00	0.0	2.588	0.017	12	3	1	1
PL.41037	PL.51931	C	#2 ACSR	7.28Y	121.3	0.00	3.71	2.15	1	15	4	97	0.00	0.0	2.277	0.006	0	0	0	2
PD.6587	PL.41037	C	20QA	7.28Y	121.3	0.00	3.71	2.15	11	15	4	97	0.00	0.0	2.277	0.006	0	0	0	2
PL.41038	PD.6587	C	#2 ACSR	7.28Y	121.3	0.00	3.71	2.15	1	15	4	97	0.00	0.0	2.311	0.034	12	3	1	2
PL.41431	PL.41038	C	#2 ACSR	7.28Y	121.3	0.00	3.71	0.40	0	3	1	95	0.00	0.0	2.351	0.040	3	1	1	1
PL.56933	PL.56961	C	#2 ACSR	7.30Y	121.6	0.00	3.41	0.89	1	6	2	95	0.00	0.0	1.984	0.006	0	0	0	2
PD.8334	PL.56933	C	60QA	7.30Y	121.6	0.00	3.41	0.89	1	6	2	95	0.00	0.0	1.984	0.006	0	0	0	2
PL.57973	PD.8334	C	#2 ACSR	7.30Y	121.6	0.00	3.41	0.89	1	6	2	95	0.00	0.0	2.011	0.027	6	2	2	2
PL.57974	PL.57973	C	#2 ACSR	7.30Y	121.6	0.00	3.41	0.00	0	0	0	100	0.00	0.0	2.031	0.020	0	0	0	0
PL.59395	PL.41786	B	#1/0 ACSR	7.32Y	122.0	0.00	2.95	4.08	2	29	8	96	0.00	0.0	1.789	0.039	29	8	2	2

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41785	PL.56506	C	6 A (CWC)	7.34Y	122.3	0.00	2.74	3.72	3	26	7	97	0.00	0.0	1.654	0.006	0	0	0	3
PD.6537	PL.41785	C	60QA	7.34Y	122.3	0.00	2.74	3.72	6	26	7	97	0.00	0.0	1.654	0.006	0	0	0	3
PL.56650	PD.6537	C	6 A (CWC)	7.33Y	122.2	0.03	2.77	3.72	3	26	7	97	0.01	0.0	1.809	0.155	0	0	0	3
PL.56651	PL.56650	C	6 A (CWC)	7.33Y	122.2	0.01	2.77	3.72	3	26	7	97	0.00	0.0	1.862	0.052	14	4	1	3
PL.59334	PL.56651	C	6 A (CWC)	7.33Y	122.2	0.00	2.77	0.02	0	0	0	100	0.00	0.0	1.899	0.037	0	0	1	1
PL.56652	PL.56651	C	6 A (CWC)	7.33Y	122.2	0.00	2.78	1.72	1	12	3	97	0.00	0.0	1.930	0.068	12	3	1	1
PL.59364	PL.59363	A	6 A (CWC)	7.40Y	123.3	0.07	1.73	46.68	33	334	89	97	0.18	0.1	1.181	0.034	11	3	1	44
PL.41892	PL.59364	A	6 A (CWC)	7.39Y	123.2	0.08	1.82	45.20	32	323	86	97	0.20	0.1	1.223	0.042	12	3	2	43
PL.56227	PL.41892	A	6 A (CWC)	7.38Y	123.0	0.14	1.96	41.14	29	294	78	97	0.30	0.1	1.295	0.072	0	0	0	38
PL.56719	PL.56227	A	6 A (CWC)	7.38Y	123.0	0.05	2.00	41.14	29	294	78	97	0.11	0.0	1.321	0.026	0	0	0	38
PL.56733	PL.56719	A	6 A (CWC)	7.38Y	123.0	0.01	2.01	5.05	4	36	10	96	0.00	0.0	1.383	0.062	26	7	2	4
PL.56727	PL.56733	A	#1/0 ACSR	7.38Y	123.0	0.00	2.01	1.45	1	10	3	96	0.00	0.0	1.402	0.019	10	3	2	2
PL.56720	PL.56719	A	6 A (CWC)	7.38Y	123.0	0.01	2.01	36.08	26	257	68	97	0.02	0.0	1.327	0.006	0	0	0	34
PD.6803	PL.56720	A	50L	7.38Y	123.0	0.00	2.01	36.08	72	257	68	97	0.00	0.0	1.327	0.006	0	0	0	34
PL.56721	PD.6803	A	6 A (CWC)	7.37Y	122.9	0.13	2.14	36.08	26	257	68	97	0.24	0.1	1.406	0.080	21	6	3	34
PL.56731	PL.56721	A	6 A (CWC)	7.37Y	122.8	0.08	2.21	33.15	24	236	63	97	0.13	0.1	1.458	0.051	13	3	2	31
PL.56732	PL.56731	A	6 A (CWC)	7.36Y	122.7	0.07	2.29	29.06	21	207	55	97	0.11	0.1	1.514	0.057	9	2	1	28
PL.63465	PL.56732	A	6 A (CWC)	7.36Y	122.6	0.11	2.40	27.80	20	198	52	97	0.16	0.1	1.604	0.090	15	4	2	27
PL.63466	PL.63465	A	6 A (CWC)	7.35Y	122.6	0.04	2.43	25.64	18	182	48	97	0.05	0.0	1.636	0.032	13	3	2	25
PL.57095	PL.63466	A	6 A (CWC)	7.35Y	122.5	0.04	2.47	23.87	17	170	45	97	0.05	0.0	1.675	0.038	10	3	2	23
PL.57129	PL.57095	A	6 A (CWC)	7.35Y	122.5	0.02	2.49	22.37	16	159	42	97	0.02	0.0	1.695	0.020	0	0	0	20
PL.57131	PL.57129	A	6 A (CWC)	7.35Y	122.5	0.05	2.54	22.37	16	159	42	97	0.06	0.0	1.744	0.049	0	0	0	20
PL.57133	PL.57131	A	#1/0 ACSR	7.35Y	122.5	0.00	2.55	1.57	1	11	3	96	0.00	0.0	1.804	0.060	11	3	1	1
PL.57132	PL.57131	A	6 A (CWC)	7.34Y	122.4	0.07	2.62	20.80	15	148	39	97	0.08	0.1	1.823	0.079	10	3	1	19
PL.57130	PL.57132	A	6 A (CWC)	7.34Y	122.4	0.03	2.64	17.19	12	122	32	97	0.02	0.0	1.859	0.035	14	4	1	13
PL.42017	PL.57130	A	6 A (CWC)	7.34Y	122.3	0.02	2.66	15.16	11	108	28	97	0.02	0.0	1.893	0.034	20	5	2	12
PL.42018	PL.42017	A	6 A (CWC)	7.34Y	122.3	0.04	2.70	10.14	7	72	19	97	0.02	0.0	1.986	0.093	11	3	1	9
PL.59272	PL.42018	A	6 A (CWC)	7.34Y	122.3	0.00	2.71	1.44	1	10	3	96	0.00	0.0	2.032	0.047	10	3	1	1
PL.42019	PL.42018	A	6 A (CWC)	7.34Y	122.3	0.02	2.72	7.16	5	51	13	97	0.01	0.0	2.038	0.052	0	0	0	7
PL.42020	PL.42019	A	6 A (CWC)	7.34Y	122.3	0.01	2.73	5.67	4	40	11	96	0.00	0.0	2.080	0.042	0	0	0	6
PL.52007	PL.42020	A	6 A (CWC)	7.33Y	122.2	0.03	2.76	2.79	2	20	5	97	0.00	0.0	2.326	0.246	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56409	PL.52007	A	#4 ACSR	7.33Y	122.2	0.00	2.77	1.27	1	9	2	98	0.00	0.0	2.448	0.122	9	2	1	1
PL.56672	PL.52007	A	6 A (CWC)	7.33Y	122.2	0.01	2.77	1.52	1	11	3	96	0.00	0.0	2.474	0.148	0	0	0	3
PL.56673	PL.56672	A	6 A (CWC)	7.33Y	122.2	0.01	2.78	1.52	1	11	3	96	0.00	0.0	2.558	0.083	0	0	0	3
PL.56670	PL.56673	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	1.48	1	11	3	96	0.00	0.0	2.585	0.027	6	2	1	2
PL.56671	PL.56670	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.62	0	4	1	97	0.00	0.0	2.630	0.045	4	1	1	1
PL.41883	PL.56671	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.00	0	0	0	100	0.00	0.0	2.721	0.091	0	0	0	0
PL.41631	PL.56673	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.03	0	0	0	100	0.00	0.0	2.611	0.054	0	0	1	1
PL.52008	PL.52007	A	6 A (CWC)	7.33Y	122.2	0.00	2.76	0.00	0	0	0	100	0.00	0.0	2.457	0.131	0	0	0	0
PL.41853	PL.42020	A	6 A (CWC)	7.34Y	122.3	0.00	2.74	2.88	2	20	5	97	0.00	0.0	2.128	0.048	20	5	2	2
PL.41554	PL.42019	A	#4 ACSR	7.34Y	122.3	0.00	2.72	1.48	1	11	3	96	0.00	0.0	2.088	0.050	11	3	1	1
PL.41502	PL.42017	A	#4 ACSR	7.34Y	122.3	0.00	2.67	2.14	2	15	4	97	0.00	0.0	1.936	0.043	15	4	1	1
PL.57179	PL.57132	A	#2 ACSR	7.34Y	122.4	0.00	2.62	2.18	1	15	4	97	0.00	0.0	1.876	0.053	8	2	2	5
PL.57180	PL.57179	A	#2 ACSR	7.34Y	122.4	0.00	2.62	1.04	1	7	2	96	0.00	0.0	1.937	0.061	7	2	3	3
PL.57128	PL.57132	A	#2 ACSR	7.34Y	122.4	0.00	2.62	0.00	0	0	0	100	0.00	0.0	1.867	0.043	0	0	0	0
PL.57096	PL.57095	A	#2 ACSR	7.35Y	122.5	0.00	2.47	0.04	0	0	0	100	0.00	0.0	1.706	0.032	0	0	1	1
PL.56656	PL.56731	A	#4 ACSR	7.37Y	122.8	0.01	2.22	2.30	2	16	4	97	0.00	0.0	1.599	0.141	16	4	1	1
PL.56503	PL.41892	A	6 A (CWC)	7.39Y	123.2	0.00	1.82	2.35	2	17	4	97	0.00	0.0	1.294	0.071	17	4	3	3
PL.59280	Keavy 2	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	134.04	26	2902	821	96	0.04	0.0	0.003	0.003	0	0	0	352
PL.59281	PL.59280	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	134.04	26	2902	820	96	0.03	0.0	0.005	0.002	0	0	0	352

----- Feeder No. 5 (Locust Grove F5) Beginning with Device PD.8770 -----

PD.8770	PL.59281	ABC	400VWE	7.50Y	125.0	0.00	0.01	134.04	0	2902	820	96	0.00	0.0	0.005	0.002	0	0	0	352
PL.59279	PD.8770	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	134.04	26	2902	820	96	0.06	0.0	0.009	0.004	0	0	0	352
PL.59426	PL.59279	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	0.00	0	0	0	100	0.00	0.0	0.010	0.001	0	0	0	0
PD.8769-A	PL.59426	ABC	Open	7.50Y	125.0	0.00	0.01	0.00	0	0	0	100	0.00	0.0	0.010	0.001	0	0	0	0
PL.59425	PL.59279	ABC	336 MCM AC	7.50Y	125.0	0.02	0.03	134.04	26	2902	820	96	0.31	0.0	0.029	0.020	0	0	0	352
PL.59422	PL.59425	ABC	336 MCM AC	7.49Y	124.8	0.17	0.20	134.04	26	2902	820	96	2.60	0.1	0.201	0.172	0	0	0	352
PL.59411	PL.59422	C	6 A (CWC)	7.49Y	124.8	0.00	0.20	8.08	6	58	15	97	0.00	0.0	0.207	0.006	0	0	0	2
PD.6448	PL.59411	C	75QA	7.49Y	124.8	0.00	0.20	8.08	11	58	15	97	0.00	0.0	0.207	0.006	0	0	0	2
PL.42651	PD.6448	C	6 A (CWC)	7.49Y	124.8	0.00	0.21	8.08	6	58	15	97	0.00	0.0	0.223	0.017	58	15	2	2

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59410	PL.59422	ABC	336 MCM AC	7.48Y	124.7	0.06	0.26	131.34	25	2840	798	96	0.89	0.0	0.262	0.061	0	0	0	350
PL.41531	PL.59410	ABC	336 MCM AC	7.48Y	124.6	0.13	0.39	129.72	25	2804	787	96	1.90	0.1	0.397	0.135	15	4	1	345
PL.55734	PL.41531	ABC	336 MCM AC	7.47Y	124.5	0.07	0.46	129.02	25	2787	778	96	1.00	0.0	0.469	0.072	18	5	2	344
PL.55735	PL.55734	ABC	336 MCM AC	7.47Y	124.5	0.04	0.50	128.18	25	2768	771	96	0.62	0.0	0.514	0.045	13	3	2	342
PL.41535	PL.55735	ABC	336 MCM AC	7.46Y	124.4	0.09	0.60	124.96	24	2698	751	96	1.32	0.0	0.615	0.100	4	1	1	331
PL.55699	PL.41535	ABC	336 MCM AC	7.46Y	124.4	0.05	0.65	124.78	24	2693	747	96	0.71	0.0	0.669	0.054	2	1	1	330
PL.55627	PL.55699	ABC	#1/0 ACSR	7.45Y	124.2	0.16	0.81	123.28	54	2659	737	96	2.92	0.1	0.741	0.072	0	0	0	326
PL.55630	PL.55627	ABC	#1/0 ACSR	7.45Y	124.1	0.08	0.89	122.14	53	2632	728	96	1.43	0.1	0.777	0.036	6	2	1	323
PL.55631	PL.55630	ABC	#1/0 ACSR	7.44Y	124.0	0.07	0.95	121.85	53	2624	724	96	1.19	0.0	0.807	0.030	29	8	4	322
PL.55629	PL.55631	ABC	#1/0 ACSR	7.43Y	123.8	0.20	1.15	120.52	52	2594	716	96	3.54	0.1	0.899	0.092	17	5	1	318
PL.42834	PL.55629	ABC	#1/0 ACSR	7.43Y	123.8	0.08	1.23	119.72	52	2573	708	96	1.43	0.1	0.937	0.037	0	0	0	317
PL.42835	PL.42834	A	#4 ACSR	7.43Y	123.8	0.00	1.23	1.62	1	12	3	97	0.00	0.0	0.942	0.006	0	0	0	1
PD.6453	PL.42835	A	60QA	7.43Y	123.8	0.00	1.23	1.62	3	12	3	97	0.00	0.0	0.942	0.006	0	0	0	1
PL.62265	PD.6453	A	#4 ACSR	7.43Y	123.8	0.00	1.23	1.62	1	12	3	97	0.00	0.0	0.997	0.055	12	3	1	1
PL.42836	PL.42834	ABC	#1/0 ACSR	7.42Y	123.6	0.16	1.39	119.18	52	2560	703	96	2.83	0.1	1.012	0.075	0	0	0	316
PL.42837	PL.42836	ABC	#1/0 ACSR	7.41Y	123.5	0.15	1.54	119.18	52	2557	701	96	2.64	0.1	1.081	0.070	0	0	0	316
PL.62431	PL.42837	ABC	#1/0 ACSR	7.40Y	123.3	0.15	1.69	116.82	51	2504	685	96	2.53	0.1	1.151	0.070	0	0	0	312
PL.62432	PL.62431	ABC	#1/0 ACSR	7.38Y	123.1	0.25	1.94	97.17	42	2081	569	96	3.54	0.2	1.292	0.141	0	0	0	232
PL.42893	PL.62432	C	#4 ACSR	7.38Y	123.1	0.00	1.94	3.75	3	27	7	97	0.00	0.0	1.297	0.006	0	0	0	2
PD.6653	PL.42893	C	60QA	7.38Y	123.1	0.00	1.94	3.75	6	27	7	97	0.00	0.0	1.297	0.006	0	0	0	2
PL.51534	PD.6653	C	#4 ACSR	7.38Y	123.1	0.00	1.94	3.75	3	27	7	97	0.00	0.0	1.331	0.034	27	7	2	2
PL.42894	PL.62432	A	#2 ACSR	7.38Y	123.1	0.00	1.94	2.45	1	17	5	96	0.00	0.0	1.297	0.006	0	0	0	1
PD.6454	PL.42894	A	40QA	7.38Y	123.1	0.00	1.94	2.45	6	17	5	96	0.00	0.0	1.297	0.006	0	0	0	1
PL.51533	PD.6454	A	#2 ACSR	7.38Y	123.1	0.00	1.94	2.45	1	17	5	96	0.00	0.0	1.385	0.088	17	5	1	1
PL.42895	PL.62432	ABC	#1/0 ACSR	7.38Y	122.9	0.14	2.08	95.11	41	2033	554	96	1.96	0.1	1.374	0.082	21	5	1	229
PL.41702	PL.42895	B	#2 ACSR	7.38Y	122.9	0.00	2.08	2.11	1	15	4	97	0.00	0.0	1.454	0.080	15	4	1	1
PL.64789	PL.42895	ABC	#1/0 ACSR	7.38Y	122.9	0.00	2.08	93.44	41	1995	542	97	0.00	0.0	1.374	0.000	0	0	0	227
PL.64790	PL.64789	ABC	#1/0 ACSR	7.37Y	122.8	0.09	2.16	93.44	41	1995	542	97	1.17	0.1	1.425	0.051	42	11	8	227
PL.55905	PL.64790	ABC	#1/0 ACSR	7.37Y	122.8	0.09	2.25	91.09	40	1944	528	97	1.16	0.1	1.478	0.053	14	4	2	218
PL.42899	PL.55905	ABC	#1/0 ACSR	7.36Y	122.6	0.13	2.38	89.68	39	1912	519	97	1.79	0.1	1.561	0.084	0	0	0	214
PL.42900	PL.42899	ABC	#1/0 ACSR	7.35Y	122.6	0.06	2.44	88.98	39	1896	513	97	0.73	0.0	1.596	0.035	15	4	1	212

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42902	PL.42900	A	6 A (CWC)	7.35Y	122.6	0.01	2.44	26.46	19	188	50	97	0.01	0.0	1.602	0.006	0	0	0	20
PD.6689	PL.42902	A	60QA	7.35Y	122.6	0.00	2.44	26.46	44	188	50	97	0.00	0.0	1.602	0.006	0	0	0	20
PL.42992	PD.6689	A	6 A (CWC)	7.35Y	122.5	0.06	2.50	26.46	19	188	50	97	0.08	0.0	1.652	0.050	8	2	1	20
PL.42993	PL.42992	A	6 A (CWC)	7.34Y	122.4	0.13	2.64	25.30	18	180	48	97	0.17	0.1	1.775	0.123	23	6	3	19
PL.41679	PL.42993	A	6 A (CWC)	7.34Y	122.4	0.00	2.64	4.08	3	29	8	96	0.00	0.0	1.821	0.046	29	8	2	2
PL.42994	PL.42993	A	6 A (CWC)	7.34Y	122.3	0.02	2.65	18.04	13	128	34	97	0.02	0.0	1.795	0.020	0	0	0	14
PL.42780	PL.42994	A	6 A (CWC)	7.34Y	122.3	0.04	2.70	18.04	13	128	34	97	0.04	0.0	1.848	0.054	6	2	1	14
PL.55814	PL.42780	A	6 A (CWC)	7.33Y	122.2	0.07	2.77	17.18	12	122	32	97	0.06	0.0	1.946	0.098	21	5	2	13
PL.55815	PL.55814	A	#2 ACSR	7.33Y	122.2	0.03	2.79	13.91	8	99	26	97	0.02	0.0	2.010	0.064	0	0	0	10
PL.55817	PL.55815	A	#2 ACSR	7.33Y	122.2	0.01	2.80	13.91	8	99	26	97	0.00	0.0	2.026	0.016	10	3	1	10
PL.55816	PL.55817	A	6 A (CWC)	7.33Y	122.2	0.04	2.84	12.48	9	88	23	97	0.02	0.0	2.102	0.077	33	9	3	9
PL.42441	PL.55816	A	6 A (CWC)	7.33Y	122.2	0.01	2.84	7.77	6	55	15	96	0.00	0.0	2.128	0.025	13	3	1	6
PL.55824	PL.42441	A	6 A (CWC)	7.33Y	122.1	0.02	2.87	4.14	3	29	8	96	0.01	0.0	2.248	0.120	0	0	0	4
PL.55837	PL.55824	A	#1/0 ACSR	7.33Y	122.1	0.00	2.87	1.43	1	10	3	96	0.00	0.0	2.296	0.048	10	3	2	2
PL.55825	PL.55824	A	6 A (CWC)	7.33Y	122.1	0.01	2.87	2.71	2	19	5	97	0.00	0.0	2.294	0.046	0	0	0	2
PL.42442	PL.55825	A	6 A (CWC)	7.33Y	122.1	0.01	2.88	2.71	2	19	5	97	0.00	0.0	2.372	0.079	0	0	0	2
PL.42443	PL.42442	A	6 A (CWC)	7.33Y	122.1	0.03	2.91	2.71	2	19	5	97	0.00	0.0	2.631	0.259	0	0	0	2
PL.55492	PL.42443	A	6 A (CWC)	7.33Y	122.1	0.00	2.91	2.15	2	15	4	97	0.00	0.0	2.649	0.018	15	4	1	1
PL.55493	PL.42443	A	6 A (CWC)	7.33Y	122.1	0.00	2.91	0.56	0	4	1	97	0.00	0.0	2.653	0.022	4	1	1	1
PL.55836	PL.55825	A	6 A (CWC)	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	2.343	0.049	0	0	0	0
PL.41741	PL.42441	A	6 A (CWC)	7.33Y	122.2	0.00	2.85	1.83	1	13	3	97	0.00	0.0	2.209	0.082	13	3	1	1
PL.55813	PL.55814	A	6 A (CWC)	7.33Y	122.2	0.00	2.77	0.34	0	2	1	89	0.00	0.0	1.994	0.048	2	1	1	1
PL.41855	PL.42900	ABC	#1/0 ACSR	7.35Y	122.5	0.11	2.54	79.44	35	1691	459	97	1.25	0.1	1.671	0.075	12	3	1	191
PL.42445	PL.41855	ABC	#1/0 ACSR	7.34Y	122.3	0.15	2.70	70.44	31	1498	407	97	1.60	0.1	1.793	0.122	11	3	2	164
PL.42446	PL.42445	ABC	#1/0 ACSR	7.33Y	122.2	0.15	2.85	69.93	30	1486	402	97	1.55	0.1	1.912	0.119	0	0	0	162
PL.55771	PL.42446	ABC	#1/0 ACSR	7.32Y	122.0	0.12	2.96	69.02	30	1465	396	97	1.19	0.1	2.007	0.094	8	2	2	161
PL.55772	PL.55771	ABC	#1/0 ACSR	7.32Y	122.0	0.08	3.05	68.66	30	1456	393	97	0.86	0.1	2.075	0.069	0	0	0	159
PL.52899	PL.55772	C	6 A (CWC)	7.32Y	122.0	0.00	3.05	1.21	1	9	2	98	0.00	0.0	2.081	0.006	0	0	0	1
PD.6467	PL.52899	C	60QA	7.32Y	122.0	0.00	3.05	1.21	2	9	2	98	0.00	0.0	2.081	0.006	0	0	0	1
PL.55773	PD.6467	C	6 A (CWC)	7.32Y	121.9	0.00	3.05	1.21	1	9	2	98	0.00	0.0	2.131	0.050	9	2	1	1
PL.52898	PL.55772	B	#2 ACSR	7.32Y	121.9	0.00	3.05	2.09	1	15	4	97	0.00	0.0	2.113	0.037	15	4	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.52900	PL.55772	ABC	#1/0 ACSR	7.31Y	121.9	0.09	3.14	67.56	29	1432	386	97	0.93	0.1	2.152	0.077	20	5	2	157
PL.52891	PL.52900	ABC	#1/0 ACSR	7.31Y	121.8	0.11	3.25	66.60	29	1411	379	97	1.04	0.1	2.240	0.088	0	0	0	155
PL.52893	PL.52891	ABC	#1/0 ACSR	7.30Y	121.7	0.06	3.31	39.24	17	830	223	97	0.36	0.0	2.327	0.087	0	0	0	94
PL.42162	PL.52893	ABC	#1/0 ACSR	7.29Y	121.6	0.13	3.43	39.15	17	828	222	97	0.73	0.1	2.506	0.179	0	0	0	93
PL.42164	PL.42162	A	6 A (CWC)	7.29Y	121.6	0.00	3.44	2.79	2	20	5	97	0.00	0.0	2.512	0.006	0	0	0	2
PD.6659	PL.42164	A	25T	7.29Y	121.6	0.00	3.44	2.79	0	20	5	97	0.00	0.0	2.512	0.006	0	0	0	2
PL.42165	PD.6659	A	6 A (CWC)	7.29Y	121.6	0.01	3.44	2.79	2	20	5	97	0.00	0.0	2.594	0.083	9	2	1	2
PL.42543	PL.42165	A	6 A (CWC)	7.29Y	121.6	0.00	3.45	1.55	1	11	3	96	0.00	0.0	2.637	0.042	0	0	0	1
PL.42544	PL.42543	A	6 A (CWC)	7.29Y	121.6	0.00	3.45	0.00	0	0	0	100	0.00	0.0	2.727	0.091	0	0	0	0
PL.55446	PL.42543	A	6 A (CWC)	7.29Y	121.6	0.00	3.45	1.55	1	11	3	96	0.00	0.0	2.686	0.050	11	3	1	1
PL.55450	PL.42162	ABC	#1/0 ACSR	7.29Y	121.5	0.11	3.55	38.22	17	808	216	97	0.64	0.1	2.672	0.166	11	3	2	91
PL.55451	PL.55450	ABC	#1/0 ACSR	7.29Y	121.4	0.02	3.57	37.71	16	797	213	97	0.14	0.0	2.709	0.037	34	9	3	89
PL.55452	PL.55451	ABC	#1/0 ACSR	7.28Y	121.4	0.04	3.61	36.09	16	762	204	97	0.21	0.0	2.769	0.060	1	0	1	86
PL.52896	PL.55452	ABC	#1/0 ACSR	7.28Y	121.4	0.02	3.64	35.40	15	747	200	97	0.13	0.0	2.808	0.039	0	0	0	81
PL.52897	PL.52896	A	6 A (CWC)	7.28Y	121.4	0.00	3.64	14.46	10	102	27	97	0.00	0.0	2.814	0.006	0	0	0	12
PD.6642	PL.52897	A	60QA	7.28Y	121.4	0.00	3.64	14.46	24	102	27	97	0.00	0.0	2.814	0.006	0	0	0	12
PL.55453	PD.6642	A	6 A (CWC)	7.28Y	121.3	0.03	3.67	14.46	10	102	27	97	0.02	0.0	2.864	0.050	26	7	2	12
PL.55454	PL.55453	A	6 A (CWC)	7.28Y	121.3	0.04	3.71	10.77	8	76	20	97	0.02	0.0	2.944	0.080	0	0	0	10
PL.55706	PL.55454	A	6 A (CWC)	7.28Y	121.3	0.02	3.73	10.77	8	76	20	97	0.01	0.0	2.996	0.052	24	6	3	10
PL.55707	PL.55706	A	6 A (CWC)	7.28Y	121.3	0.01	3.74	7.35	5	52	14	97	0.00	0.0	3.056	0.060	40	10	4	7
PL.55708	PL.55707	A	6 A (CWC)	7.28Y	121.3	0.00	3.74	1.72	1	12	3	97	0.00	0.0	3.114	0.058	12	3	3	3
PL.55955	PL.52896	ABC	#1/0 ACSR	7.28Y	121.3	0.07	3.71	30.57	13	645	172	97	0.32	0.0	2.940	0.132	16	4	1	69
PL.55954	PL.55955	C	#1/0 ACSR	7.28Y	121.3	0.00	3.71	0.00	0	0	0	100	0.00	0.0	3.026	0.086	0	0	0	0
PL.55956	PL.55955	ABC	#1/0 ACSR	7.27Y	121.2	0.06	3.77	29.82	13	629	168	97	0.28	0.0	3.059	0.119	15	4	1	68
PL.55953	PL.55956	ABC	#2 ACSR	7.27Y	121.2	0.00	3.77	0.72	0	15	4	97	0.00	0.0	3.150	0.091	8	2	2	3
PL.55704	PL.55953	ABC	#2 ACSR	7.27Y	121.2	0.00	3.77	0.34	0	7	2	96	0.00	0.0	3.238	0.088	7	2	1	1
PL.55705	PL.55704	ABC	#2 ACSR	7.27Y	121.2	0.00	3.77	0.00	0	0	0	100	0.00	0.0	3.291	0.053	0	0	0	0
PD.6816-A	PL.55705	ABC	Open	7.27Y	121.2	0.00	3.77	0.00	0	0	0	100	0.00	0.0	3.291	0.053	0	0	0	0
PL.58448	PL.55956	B	6 A (CWC)	7.26Y	121.0	0.27	4.04	85.12	61	598	160	97	1.21	0.2	3.129	0.070	14	4	1	64
PL.58450	PL.58448	B	6 A (CWC)	7.26Y	121.0	0.00	4.04	28.17	20	198	52	97	0.00	0.0	3.131	0.002	0	0	0	18
PD.8594	PL.58450	B	20T	7.26Y	121.0	0.00	4.04	28.17	0	198	52	97	0.00	0.0	3.131	0.002	0	0	0	18

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58451	PD.8594	B	6 A (CWC)	7.25Y	120.9	0.08	4.12	28.17	20	198	52	97	0.11	0.1	3.198	0.067	36	10	2	18
PL.55952	PL.58451	B	6 A (CWC)	7.25Y	120.9	0.02	4.14	22.30	16	156	41	97	0.02	0.0	3.215	0.017	7	2	2	15
PL.55455	PL.55952	B	6 A (CWC)	7.25Y	120.8	0.02	4.16	21.23	15	149	39	97	0.02	0.0	3.234	0.018	0	0	0	13
PL.55456	PL.55455	B	6 A (CWC)	7.25Y	120.8	0.01	4.17	17.91	13	126	33	97	0.01	0.0	3.252	0.018	11	3	1	11
PL.55959	PL.55456	B	6 A (CWC)	7.25Y	120.8	0.04	4.21	16.36	12	115	30	97	0.03	0.0	3.316	0.064	30	8	3	10
PL.55843	PL.55959	B	6 A (CWC)	7.25Y	120.8	0.01	4.22	6.08	4	43	11	97	0.00	0.0	3.375	0.059	20	5	2	4
PL.42167	PL.55843	B	6 A (CWC)	7.25Y	120.8	0.01	4.23	3.23	2	23	6	97	0.00	0.0	3.455	0.081	23	6	2	2
PL.55842	PL.55959	B	#4 ACSR	7.25Y	120.8	0.01	4.22	5.94	5	42	11	97	0.00	0.0	3.387	0.071	28	7	2	3
PL.42166	PL.55842	B	#4 ACSR	7.25Y	120.8	0.00	4.22	1.89	1	13	3	97	0.00	0.0	3.424	0.037	13	3	1	1
PL.61146	PL.55455	B	#1/0 ACSR	7.25Y	120.8	0.00	4.16	3.32	1	23	6	97	0.00	0.0	3.268	0.034	23	6	2	2
PL.55951	PL.58451	B	6 A (CWC)	7.25Y	120.9	0.00	4.12	0.72	1	5	1	98	0.00	0.0	3.254	0.055	5	1	1	1
PL.58449	PL.58448	B	6 A (CWC)	7.25Y	120.9	0.09	4.13	55.00	39	386	103	97	0.26	0.1	3.165	0.035	0	0	0	45
PL.41815	PL.58449	B	6 A (CWC)	7.25Y	120.9	0.00	4.13	0.00	0	0	0	100	0.00	0.0	3.200	0.036	0	0	0	0
PL.55958	PL.58449	B	6 A (CWC)	7.25Y	120.8	0.12	4.25	54.15	39	379	101	97	0.35	0.1	3.214	0.050	8	2	1	44
PL.55957	PL.55958	B	6 A (CWC)	7.24Y	120.7	0.01	4.26	52.96	38	371	99	97	0.04	0.0	3.220	0.006	0	0	0	43
PD.6794	PL.55957	B	100L	7.24Y	120.7	0.00	4.26	52.96	53	371	99	97	0.00	0.0	3.220	0.006	0	0	0	43
PL.41564	PD.6794	B	6 A (CWC)	7.23Y	120.5	0.21	4.47	52.96	38	371	99	97	0.59	0.2	3.307	0.087	3	1	1	43
PL.62044	PL.41564	B	6 A (CWC)	7.23Y	120.5	0.06	4.53	52.49	37	367	98	97	0.17	0.0	3.333	0.026	20	5	2	42
PL.62042	PL.62044	B	6 A (CWC)	7.23Y	120.5	0.00	4.54	1.25	1	9	2	98	0.00	0.0	3.410	0.077	9	2	1	1
PL.62043	PL.62044	B	6 A (CWC)	7.22Y	120.3	0.15	4.68	48.41	35	338	90	97	0.38	0.1	3.400	0.067	0	0	0	39
PL.55713	PL.62043	B	6 A (CWC)	7.22Y	120.3	0.00	4.68	0.96	1	7	2	96	0.00	0.0	3.442	0.042	7	2	1	1
PL.55714	PL.62043	B	6 A (CWC)	7.22Y	120.3	0.00	4.68	1.91	1	13	4	96	0.00	0.0	3.419	0.018	13	4	1	1
PL.55715	PL.55714	B	6 A (CWC)	7.22Y	120.3	0.00	4.68	0.00	0	0	0	100	0.00	0.0	3.448	0.030	0	0	0	0
PL.55716	PL.55715	B	6 A (CWC)	7.22Y	120.3	0.00	4.68	0.00	0	0	0	100	0.00	0.0	3.463	0.014	0	0	0	0
PL.55719	PL.62043	B	6 A (CWC)	7.21Y	120.2	0.10	4.78	45.54	33	318	84	97	0.24	0.1	3.451	0.051	26	7	2	37
PL.55718	PL.55719	B	6 A (CWC)	7.20Y	120.0	0.19	4.97	39.36	28	274	73	97	0.39	0.1	3.558	0.107	10	3	1	33
PL.41833	PL.55718	B	6 A (CWC)	7.20Y	120.0	0.00	4.97	2.44	2	17	4	97	0.00	0.0	3.587	0.029	17	4	2	2
PL.42089	PL.55718	B	6 A (CWC)	7.19Y	119.9	0.15	5.12	35.50	25	247	66	97	0.28	0.1	3.650	0.091	0	0	0	30
PL.52946	PL.42089	B	6 A (CWC)	7.19Y	119.8	0.06	5.18	35.50	25	247	65	97	0.11	0.0	3.687	0.037	20	5	3	30
PL.52949	PL.52946	B	6 A (CWC)	7.19Y	119.8	0.07	5.24	30.70	22	213	57	97	0.11	0.1	3.735	0.048	7	2	1	25
PL.52948	PL.52949	B	6 A (CWC)	7.18Y	119.6	0.13	5.37	27.00	19	188	50	97	0.18	0.1	3.839	0.104	0	0	0	23

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55459	PL.52948	B	6 A (CWC)	7.17Y	119.5	0.09	5.47	23.83	17	165	44	97	0.11	0.1	3.928	0.089	13	4	3	22
PL.55458	PL.55459	B	6 A (CWC)	7.17Y	119.5	0.03	5.49	7.11	5	49	13	97	0.01	0.0	4.012	0.084	0	0	0	4
PL.42097	PL.55458	B	6 A (CWC)	7.17Y	119.5	0.04	5.53	5.09	4	35	9	97	0.01	0.0	4.193	0.181	7	2	1	3
PL.41591	PL.42097	B	6 A (CWC)	7.17Y	119.5	0.00	5.53	0.00	0	0	0	100	0.00	0.0	4.308	0.115	0	0	0	0
PL.42098	PL.42097	B	6 A (CWC)	7.17Y	119.5	0.02	5.55	4.12	3	29	8	96	0.00	0.0	4.294	0.101	0	0	0	2
PL.41816	PL.42098	B	6 A (CWC)	7.17Y	119.4	0.01	5.56	3.38	2	23	6	97	0.00	0.0	4.388	0.093	23	6	1	1
PL.41463	PL.42098	B	6 A (CWC)	7.17Y	119.4	0.00	5.55	0.75	1	5	1	98	0.00	0.0	4.417	0.123	5	1	1	1
PL.41563	PL.55458	B	6 A (CWC)	7.17Y	119.5	0.00	5.50	2.02	1	14	4	96	0.00	0.0	4.060	0.047	0	0	0	1
PL.55460	PL.41563	B	6 A (CWC)	7.17Y	119.5	0.00	5.50	2.02	1	14	4	96	0.00	0.0	4.086	0.026	14	4	1	1
PL.55457	PL.55459	B	6 A (CWC)	7.17Y	119.5	0.03	5.49	14.80	11	103	27	97	0.02	0.0	3.970	0.041	0	0	0	15
PL.62220	PL.55457	B	6 A (CWC)	7.17Y	119.5	0.04	5.53	14.80	11	103	27	97	0.03	0.0	4.027	0.057	16	4	4	15
PL.62222	PL.62220	B	6 A (CWC)	7.17Y	119.5	0.02	5.54	7.58	5	53	14	97	0.01	0.0	4.079	0.052	16	4	2	7
PL.62223	PL.62222	B	6 A (CWC)	7.17Y	119.4	0.01	5.56	5.23	4	36	10	96	0.00	0.0	4.127	0.048	0	0	1	5
PL.62218	PL.62223	B	6 A (CWC)	7.17Y	119.4	0.00	5.56	1.25	1	9	2	98	0.00	0.0	4.198	0.071	9	2	1	1
PL.62219	PL.62223	B	6 A (CWC)	7.17Y	119.4	0.01	5.56	3.97	3	27	7	97	0.00	0.0	4.161	0.034	0	0	0	3
PL.42728	PL.62219	B	6 A (CWC)	7.17Y	119.4	0.02	5.58	3.97	3	27	7	97	0.00	0.0	4.257	0.097	7	2	1	3
PL.42727	PL.42728	B	6 A (CWC)	7.17Y	119.4	0.00	5.58	2.94	2	20	5	97	0.00	0.0	4.294	0.037	0	0	0	2
PL.41885	PL.42727	B	6 A (CWC)	7.16Y	119.4	0.00	5.59	2.94	2	20	5	97	0.00	0.0	4.351	0.057	20	5	2	2
PL.41565	PL.42727	B	6 A (CWC)	7.17Y	119.4	0.00	5.58	0.00	0	0	0	100	0.00	0.0	4.403	0.109	0	0	0	0
PL.41039	PL.62219	B	#1/0 ACSR	7.17Y	119.4	0.00	5.56	0.00	0	0	0	100	0.00	0.0	4.178	0.018	0	0	0	0
PL.62221	PL.62220	B	6 A (CWC)	7.17Y	119.5	0.01	5.53	4.85	3	34	9	97	0.00	0.0	4.063	0.035	16	4	2	4
PL.55894	PL.62221	B	6 A (CWC)	7.17Y	119.5	0.00	5.54	2.51	2	17	5	96	0.00	0.0	4.081	0.019	17	5	2	2
PL.55766	PL.55457	B	6 A (CWC)	7.17Y	119.5	0.00	5.49	0.00	0	0	0	100	0.00	0.0	4.023	0.053	0	0	0	0
PL.52904	PL.52948	B	#2 ACSR	7.18Y	119.6	0.00	5.37	3.17	2	22	6	96	0.00	0.0	3.875	0.035	22	6	1	1
PL.52947	PL.52949	B	6 A (CWC)	7.19Y	119.8	0.01	5.25	2.74	2	19	5	97	0.00	0.0	3.819	0.084	19	5	1	1
PL.52945	PL.52946	B	6 A (CWC)	7.19Y	119.8	0.00	5.18	1.86	1	13	3	97	0.00	0.0	3.751	0.064	13	3	2	2
PL.55717	PL.55719	B	6 A (CWC)	7.21Y	120.2	0.01	4.79	2.44	2	17	4	97	0.00	0.0	3.556	0.106	17	4	2	2
PL.41562	PL.58449	B	6 A (CWC)	7.25Y	120.9	0.00	4.13	0.85	1	6	2	95	0.00	0.0	3.211	0.047	6	2	1	1
PL.42545	PL.55452	C	#4 ACSR	7.28Y	121.4	0.00	3.61	1.91	1	13	4	96	0.00	0.0	2.818	0.049	13	3	2	4
PL.42546	PL.42545	C	#4 ACSR	7.28Y	121.4	0.00	3.61	0.10	0	1	0	100	0.00	0.0	2.887	0.069	0	0	1	2
PL.42547	PL.42546	C	#4 ACSR	7.28Y	121.4	0.00	3.61	0.10	0	1	0	100	0.00	0.0	3.018	0.131	1	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42163	PL.52893	C	#4 ACSR	7.30Y	121.7	0.00	3.31	0.25	0	2	0	100	0.00	0.0	2.333	0.006	0	0	0	1
PD.6531	PL.42163	C	60QA	7.30Y	121.7	0.00	3.31	0.25	0	2	0	100	0.00	0.0	2.333	0.006	0	0	0	1
PL.55444	PD.6531	C	#4 ACSR	7.30Y	121.7	0.00	3.31	0.25	0	2	0	100	0.00	0.0	2.378	0.045	2	0	1	1
PL.52894	PL.52891	A	6 A (CWC)	7.29Y	121.6	0.17	3.42	82.10	59	579	155	97	0.75	0.1	2.287	0.046	13	3	1	61
PL.52895	PL.52894	A	6 A (CWC)	7.28Y	121.4	0.20	3.62	80.25	57	565	151	97	0.87	0.2	2.343	0.056	10	3	2	60
PL.61132	PL.52895	A	#1/0 ACSR	7.28Y	121.4	0.00	3.62	1.20	1	8	2	97	0.00	0.0	2.366	0.023	8	2	1	1
PL.52892	PL.52895	A	6 A (CWC)	7.27Y	121.2	0.13	3.75	77.59	55	546	146	97	0.53	0.1	2.379	0.036	0	0	0	57
PL.42447	PL.52892	A	6 A (CWC)	7.27Y	121.2	0.02	3.77	77.59	55	545	146	97	0.08	0.0	2.385	0.006	0	0	0	57
PD.6793	PL.42447	A	140L	7.27Y	121.2	0.00	3.77	77.59	55	545	146	97	0.00	0.0	2.385	0.006	0	0	0	57
PL.55447	PD.6793	A	6 A (CWC)	7.26Y	121.1	0.16	3.93	77.59	55	545	146	97	0.65	0.1	2.430	0.045	11	3	1	57
PL.55449	PL.55447	A	6 A (CWC)	7.25Y	120.9	0.20	4.13	68.00	49	477	127	97	0.71	0.1	2.493	0.064	6	2	1	51
PL.41381	PL.55449	A	6 A (CWC)	7.25Y	120.9	0.00	4.13	1.11	1	8	2	97	0.00	0.0	2.688	0.195	8	2	1	1
PL.42448	PL.55449	A	6 A (CWC)	7.23Y	120.5	0.35	4.48	63.87	46	448	119	97	1.18	0.3	2.618	0.125	25	7	2	47
PL.41852	PL.42448	A	6 A (CWC)	7.23Y	120.5	0.00	4.48	2.61	2	18	5	96	0.00	0.0	2.653	0.034	18	5	1	1
PL.42449	PL.42448	A	6 A (CWC)	7.21Y	120.2	0.30	4.77	57.63	41	403	107	97	0.90	0.2	2.732	0.114	10	3	1	44
PL.55462	PL.42449	A	6 A (CWC)	7.21Y	120.1	0.08	4.85	54.27	39	378	100	97	0.22	0.1	2.764	0.032	12	3	1	42
PL.55463	PL.55462	A	6 A (CWC)	7.20Y	120.1	0.07	4.92	52.58	38	366	97	97	0.19	0.1	2.793	0.028	3	1	1	41
PL.57709	PL.55463	A	6 A (CWC)	7.20Y	120.0	0.12	5.04	52.15	37	363	96	97	0.31	0.1	2.843	0.050	29	8	2	40
PL.57712	PL.57709	A	6 A (CWC)	7.19Y	119.9	0.06	5.09	21.02	15	146	39	97	0.06	0.0	2.904	0.061	18	5	1	11
PL.57708	PL.57712	A	6 A (CWC)	7.19Y	119.9	0.06	5.15	18.49	13	129	34	97	0.05	0.0	2.981	0.076	30	8	3	10
PL.57707	PL.57708	A	6 A (CWC)	7.19Y	119.8	0.06	5.21	14.18	10	99	26	97	0.05	0.0	3.081	0.100	0	0	0	7
PL.42451	PL.57707	A	6 A (CWC)	7.19Y	119.8	0.01	5.22	8.34	6	58	15	97	0.00	0.0	3.118	0.037	31	8	2	4
PL.55461	PL.42451	A	6 A (CWC)	7.19Y	119.8	0.00	5.22	0.00	0	0	0	100	0.00	0.0	3.165	0.047	0	0	0	0
PL.59315	PL.42451	A	6 A (CWC)	7.19Y	119.8	0.01	5.23	3.84	3	27	7	97	0.00	0.0	3.154	0.036	5	1	1	2
PL.59316	PL.59315	A	6 A (CWC)	7.19Y	119.8	0.00	5.23	3.08	2	21	6	96	0.00	0.0	3.215	0.062	21	6	1	1
PL.59332	PL.57707	A	6 A (CWC)	7.19Y	119.8	0.02	5.23	5.84	4	41	11	97	0.01	0.0	3.158	0.077	7	2	1	3
PL.59333	PL.59332	A	6 A (CWC)	7.19Y	119.8	0.02	5.25	4.89	3	34	9	97	0.00	0.0	3.237	0.079	0	0	0	2
PL.55637	PL.59333	A	1/0 AL URD	7.18Y	119.7	0.00	5.25	2.17	1	15	4	97	0.00	0.0	3.278	0.041	15	4	1	1
PL.55636	PL.59333	A	6 A (CWC)	7.18Y	119.7	0.01	5.26	2.72	2	19	5	97	0.00	0.0	3.309	0.072	0	0	0	1
PL.55635	PL.55636	A	6 A (CWC)	7.18Y	119.7	0.00	5.26	2.72	2	19	5	97	0.00	0.0	3.388	0.079	19	5	1	1
PL.57706	PL.57708	A	#4 ACSR	7.19Y	119.9	0.00	5.15	0.00	0	0	0	100	0.00	0.0	3.032	0.052	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.57711	PL.57709	A	6 A (CWC)	7.19Y	119.9	0.05	5.09	24.37	17	170	45	97	0.07	0.0	2.890	0.047	0	0	0	24
PL.55762	PL.57711	A	6 A (CWC)	7.19Y	119.9	0.02	5.11	22.78	16	158	42	97	0.03	0.0	2.913	0.024	12	3	1	23
PL.55761	PL.55762	A	6 A (CWC)	7.19Y	119.8	0.06	5.18	19.60	14	136	36	97	0.07	0.0	2.985	0.072	0	0	0	21
PL.55764	PL.55761	A	6 A (CWC)	7.19Y	119.8	0.02	5.19	17.58	13	122	32	97	0.02	0.0	3.007	0.022	0	0	0	20
PL.55692	PL.55764	A	6 A (CWC)	7.19Y	119.8	0.05	5.25	16.73	12	116	31	97	0.05	0.0	3.086	0.079	23	6	4	17
PL.64548	PL.55692	A	6 A (CWC)	7.18Y	119.7	0.03	5.28	13.44	10	93	25	97	0.02	0.0	3.141	0.055	6	2	1	13
PL.64549	PL.64548	A	6 A (CWC)	7.18Y	119.7	0.02	5.30	12.60	9	88	23	97	0.01	0.0	3.184	0.042	42	11	6	12
PL.55927	PL.64549	A	6 A (CWC)	7.18Y	119.7	0.02	5.32	6.09	4	42	11	97	0.01	0.0	3.247	0.063	0	0	0	4
PL.55804	PL.55927	A	6 A (CWC)	7.18Y	119.7	0.00	5.32	6.09	4	42	11	97	0.00	0.0	3.262	0.016	13	3	1	4
PL.55805	PL.55804	A	6 A (CWC)	7.18Y	119.7	0.00	5.32	2.68	2	19	5	97	0.00	0.0	3.287	0.025	1	0	1	2
PL.55464	PL.55805	A	6 A (CWC)	7.18Y	119.7	0.00	5.32	2.55	2	18	5	96	0.00	0.0	3.324	0.037	18	5	1	1
PL.55465	PL.55464	A	6 A (CWC)	7.18Y	119.7	0.00	5.32	0.00	0	0	0	100	0.00	0.0	3.366	0.042	0	0	0	0
PL.55803	PL.55804	A	6 A (CWC)	7.18Y	119.7	0.00	5.32	1.61	1	11	3	96	0.00	0.0	3.313	0.050	11	3	1	1
PL.61141	PL.55804	A	#1/0 ACSR	7.18Y	119.7	0.00	5.32	0.00	0	0	0	100	0.00	0.0	3.307	0.045	0	0	0	0
PL.55926	PL.64549	A	6 A (CWC)	7.18Y	119.7	0.00	5.30	0.46	0	3	1	95	0.00	0.0	3.213	0.029	3	1	2	2
PL.55765	PL.55764	A	6 A (CWC)	7.19Y	119.8	0.01	5.20	0.85	1	6	2	95	0.00	0.0	3.144	0.137	0	0	0	3
PL.42705	PL.55765	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.85	1	6	2	95	0.00	0.0	3.196	0.051	0	0	0	3
PL.42706	PL.42705	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.00	0	0	0	100	0.00	0.0	3.348	0.152	0	0	0	0
PL.41417	PL.42706	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.00	0	0	0	100	0.00	0.0	3.494	0.146	0	0	0	0
PL.55494	PL.42706	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.00	0	0	0	100	0.00	0.0	3.454	0.106	0	0	0	0
PL.59133	PL.42705	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.85	1	6	2	95	0.00	0.0	3.243	0.047	1	0	1	3
PL.59134	PL.59133	A	6 A (CWC)	7.19Y	119.8	0.00	5.20	0.77	1	5	1	98	0.00	0.0	3.298	0.055	5	1	2	2
PL.42703	PL.55761	A	6 A (CWC)	7.19Y	119.8	0.01	5.18	2.02	1	14	4	96	0.00	0.0	3.045	0.060	0	0	0	1
PL.42704	PL.42703	A	6 A (CWC)	7.19Y	119.8	0.00	5.18	2.02	1	14	4	96	0.00	0.0	3.080	0.035	14	4	1	1
PL.55763	PL.55762	A	#1/0 ACSR	7.19Y	119.9	0.00	5.11	1.48	1	10	3	96	0.00	0.0	2.928	0.015	10	3	1	1
PL.55760	PL.57711	A	#1/0 ACSR	7.19Y	119.9	0.00	5.09	1.60	1	11	3	96	0.00	0.0	2.908	0.018	11	3	1	1
PL.57710	PL.57709	A	6 A (CWC)	7.20Y	120.0	0.01	5.04	2.66	2	19	5	97	0.00	0.0	2.908	0.065	10	3	1	3
PL.42450	PL.57710	A	6 A (CWC)	7.20Y	120.0	0.00	5.04	1.29	1	9	2	98	0.00	0.0	2.974	0.066	9	2	2	2
PL.41401	PL.42449	A	6 A (CWC)	7.21Y	120.2	0.00	4.78	1.89	1	13	3	97	0.00	0.0	2.802	0.069	13	3	1	1
PL.55445	PL.55449	A	6 A (CWC)	7.25Y	120.9	0.00	4.13	2.17	2	15	4	97	0.00	0.0	2.560	0.067	15	4	2	2
PL.55448	PL.55447	A	6 A (CWC)	7.26Y	121.0	0.04	3.97	7.96	6	56	15	97	0.02	0.0	2.561	0.131	12	3	1	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.52901	PL.55448	A	6 A (CWC)	7.26Y	121.0	0.02	3.99	6.22	4	44	12	96	0.00	0.0	2.622	0.062	9	2	1	4
PL.52902	PL.52901	A	6 A (CWC)	7.26Y	121.0	0.00	3.99	4.97	4	35	9	97	0.00	0.0	2.649	0.027	13	3	1	3
PL.52903	PL.52902	A	6 A (CWC)	7.26Y	121.0	0.00	4.00	1.72	1	12	3	97	0.00	0.0	2.770	0.120	12	3	1	1
PL.59135	PL.52902	A	#1/0 ACSR	7.26Y	121.0	0.00	3.99	1.44	1	10	3	96	0.00	0.0	2.697	0.048	10	3	1	1
PL.42444	PL.42446	C	#4 ACSR	7.33Y	122.2	0.00	2.85	2.70	2	19	5	97	0.00	0.0	1.918	0.006	0	0	0	1
PD.6771	PL.42444	C	60QA	7.33Y	122.2	0.00	2.85	2.70	5	19	5	97	0.00	0.0	1.918	0.006	0	0	0	1
PL.63481	PD.6771	C	#1/0 ACSR	7.33Y	122.2	0.00	2.85	2.70	1	19	5	97	0.00	0.0	1.928	0.010	0	0	0	1
PL.63483	PL.63481	C	#1/0 ACSR	7.33Y	122.2	0.00	2.85	0.00	0	0	0	100	0.00	0.0	1.979	0.051	0	0	0	0
PL.63482	PL.63481	C	#1/0 ACSR	7.33Y	122.2	0.00	2.85	2.70	1	19	5	97	0.00	0.0	1.950	0.022	19	5	1	1
PL.41596	PL.41855	A	6 A (CWC)	7.35Y	122.5	0.00	2.54	0.57	0	4	1	97	0.00	0.0	1.730	0.059	4	1	3	3
PL.56066	PL.41855	C	6 A (CWC)	7.35Y	122.4	0.01	2.55	24.79	18	176	47	97	0.01	0.0	1.679	0.008	0	0	0	23
PD.8294	PL.56066	C	75QA	7.35Y	122.4	0.00	2.55	24.79	33	176	47	97	0.00	0.0	1.679	0.008	0	0	0	23
PL.56067	PD.8294	C	6 A (CWC)	7.34Y	122.4	0.09	2.64	24.79	18	176	47	97	0.12	0.1	1.758	0.079	0	0	0	23
PL.53047	PL.56067	C	#2 ACSR	7.34Y	122.4	0.00	2.64	0.10	0	1	0	100	0.00	0.0	1.857	0.099	1	0	1	1
PL.41335	PL.56067	C	#2 ACSR	7.34Y	122.4	0.00	2.64	1.84	1	13	3	97	0.00	0.0	1.841	0.084	13	3	1	1
PL.41592	PL.56067	C	6 A (CWC)	7.33Y	122.2	0.12	2.77	22.85	16	162	43	97	0.15	0.1	1.880	0.123	11	3	1	21
PL.41386	PL.41592	C	6 A (CWC)	7.33Y	122.2	0.00	2.77	2.51	2	18	5	96	0.00	0.0	1.927	0.046	18	5	3	3
PL.41727	PL.41592	C	6 A (CWC)	7.33Y	122.2	0.04	2.81	18.75	13	133	35	97	0.04	0.0	1.931	0.051	0	0	0	17
PL.41644	PL.41727	C	6 A (CWC)	7.33Y	122.1	0.11	2.92	16.70	12	118	31	97	0.10	0.1	2.072	0.140	0	0	0	15
PL.41812	PL.41644	C	6 A (CWC)	7.32Y	121.9	0.14	3.05	16.70	12	118	31	97	0.12	0.1	2.254	0.182	0	0	0	15
PL.41646	PL.41812	C	6 A (CWC)	7.32Y	121.9	0.00	3.06	1.35	1	10	3	96	0.00	0.0	2.300	0.045	7	2	1	3
PL.41811	PL.41646	C	6 A (CWC)	7.32Y	121.9	0.00	3.06	0.42	0	3	1	95	0.00	0.0	2.353	0.053	1	0	1	2
PL.41645	PL.41811	C	6 A (CWC)	7.32Y	121.9	0.00	3.06	0.33	0	2	1	89	0.00	0.0	2.388	0.035	2	1	1	1
PL.55907	PL.41812	C	#1/0 ACSR	7.32Y	121.9	0.00	3.06	1.47	1	10	3	96	0.00	0.0	2.292	0.038	10	3	1	1
PL.41690	PL.41812	C	6 A (CWC)	7.31Y	121.9	0.05	3.11	13.89	10	98	26	97	0.04	0.0	2.342	0.088	15	4	2	11
PL.53042	PL.41690	C	6 A (CWC)	7.31Y	121.9	0.03	3.13	11.80	8	83	22	97	0.02	0.0	2.395	0.053	9	2	1	9
PL.55925	PL.53042	C	#1/0 ACSR	7.31Y	121.9	0.00	3.13	0.00	0	0	0	100	0.00	0.0	2.458	0.063	0	0	0	0
PL.53043	PL.53042	C	6 A (CWC)	7.31Y	121.8	0.02	3.16	10.48	7	74	20	97	0.01	0.0	2.447	0.053	17	4	3	8
PL.41724	PL.53043	C	#1/0 ACSR	7.31Y	121.8	0.00	3.16	1.30	1	9	2	98	0.00	0.0	2.499	0.052	9	2	1	1
PL.53044	PL.53043	C	6 A (CWC)	7.31Y	121.8	0.00	3.16	1.74	1	12	3	97	0.00	0.0	2.497	0.049	12	3	1	1
PL.42030	PL.53043	C	6 A (CWC)	7.31Y	121.8	0.01	3.16	5.04	4	36	9	97	0.00	0.0	2.481	0.034	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41747	PL.42030	C	6 A (CWC)	7.31Y	121.8	0.01	3.17	5.04	4	36	9	97	0.00	0.0	2.522	0.041	0	0	0	3
PL.41748	PL.41747	C	6 A (CWC)	7.31Y	121.8	0.00	3.17	1.62	1	11	3	96	0.00	0.0	2.578	0.055	11	3	1	1
PL.41745	PL.41747	C	6 A (CWC)	7.31Y	121.8	0.01	3.18	3.43	2	24	6	97	0.00	0.0	2.583	0.060	8	2	1	2
PL.41746	PL.41745	C	6 A (CWC)	7.31Y	121.8	0.00	3.18	2.25	2	16	4	97	0.00	0.0	2.609	0.026	16	4	1	1
PL.41728	PL.41727	C	#2 ACSR	7.33Y	122.2	0.00	2.81	2.05	1	15	4	97	0.00	0.0	1.994	0.063	2	1	1	2
PL.41729	PL.41728	C	#2 ACSR	7.33Y	122.2	0.00	2.81	1.74	1	12	3	97	0.00	0.0	2.050	0.056	12	3	1	1
PL.42901	PL.42899	C	#1/0 ACSR	7.36Y	122.6	0.00	2.38	2.10	1	15	4	97	0.00	0.0	1.567	0.006	0	0	0	2
PD.6456	PL.42901	C	30QA	7.36Y	122.6	0.00	2.38	2.10	7	15	4	97	0.00	0.0	1.567	0.006	0	0	0	2
PL.53048	PD.6456	C	#1/0 ACSR	7.36Y	122.6	0.00	2.39	2.10	1	15	4	97	0.00	0.0	1.685	0.118	4	1	1	2
PL.52888	PL.53048	C	#1/0 ACSR	7.36Y	122.6	0.00	2.39	1.49	1	11	3	96	0.00	0.0	1.700	0.015	11	3	1	1
PL.42897	PL.55905	C	6 A (CWC)	7.37Y	122.8	0.00	2.25	2.25	2	16	4	97	0.00	0.0	1.483	0.006	0	0	0	2
PD.6690	PL.42897	C	60QA	7.37Y	122.8	0.00	2.25	2.25	4	16	4	97	0.00	0.0	1.483	0.006	0	0	0	2
PL.42898	PD.6690	C	6 A (CWC)	7.36Y	122.7	0.00	2.25	2.25	2	16	4	97	0.00	0.0	1.557	0.073	16	4	2	2
PL.55904	PL.64790	A	#4 ACSR	7.37Y	122.8	0.00	2.16	1.15	1	8	2	97	0.00	0.0	1.431	0.006	0	0	0	1
PD.6455	PL.55904	A	60QA	7.37Y	122.8	0.00	2.16	1.15	2	8	2	97	0.00	0.0	1.431	0.006	0	0	0	1
PL.42896	PD.6455	A	#4 ACSR	7.37Y	122.8	0.00	2.16	1.15	1	8	2	97	0.00	0.0	1.492	0.061	8	2	1	1
PL.62505	PL.62431	C	#1/0 ACSR	7.40Y	123.3	0.01	1.70	58.92	26	421	113	97	0.04	0.0	1.162	0.011	5	1	1	80
PL.62506	PL.62505	C	#1/0 ACSR	7.39Y	123.2	0.07	1.78	58.29	25	416	112	97	0.20	0.0	1.216	0.054	0	0	0	79
PL.42090	PL.62506	C	#1/0 ACSR	7.39Y	123.2	0.01	1.78	58.29	25	416	112	97	0.02	0.0	1.222	0.006	0	0	0	79
PD.6792	PL.42090	C	100L	7.39Y	123.2	0.00	1.78	58.29	58	416	112	97	0.00	0.0	1.222	0.006	0	0	0	79
PL.55819	PD.6792	C	#1/0 ACSR	7.38Y	123.0	0.17	1.96	58.29	25	416	112	97	0.47	0.1	1.352	0.131	12	3	1	79
PL.64684	PL.55819	C	#1/0 ACSR	7.38Y	123.0	0.00	1.96	56.62	25	404	108	97	0.00	0.0	1.352	0.000	0	0	0	78
PL.64685	PL.64684	C	#1/0 ACSR	7.38Y	123.0	0.05	2.01	56.62	25	404	108	97	0.13	0.0	1.389	0.037	0	0	0	78
PL.64686	PL.64685	C	#1/0 ACSR	7.38Y	123.0	0.04	2.05	56.62	25	404	108	97	0.11	0.0	1.420	0.030	1	0	1	78
PL.55818	PL.64686	C	#1/0 ACSR	7.37Y	122.9	0.08	2.13	56.46	25	402	108	97	0.22	0.1	1.484	0.064	8	2	1	77
PL.55901	PL.55818	C	#1/0 ACSR	7.37Y	122.8	0.05	2.18	55.31	24	394	105	97	0.14	0.0	1.525	0.042	0	0	0	76
PL.55902	PL.55901	C	#1/0 ACSR	7.36Y	122.7	0.07	2.25	53.65	23	382	102	97	0.17	0.0	1.582	0.057	10	3	1	75
PL.55485	PL.55902	C	#1/0 ACSR	7.36Y	122.6	0.11	2.36	52.31	23	372	99	97	0.27	0.1	1.675	0.093	4	1	2	74
PL.55484	PL.55485	C	#1/0 ACSR	7.35Y	122.5	0.11	2.47	51.80	23	368	98	97	0.27	0.1	1.767	0.091	0	0	0	72
PL.51535	PL.55484	C	#1/0 ACSR	7.35Y	122.5	0.06	2.53	36.00	16	256	68	97	0.10	0.0	1.840	0.073	11	3	2	54
PL.51536	PL.51535	C	#1/0 ACSR	7.34Y	122.4	0.06	2.59	34.41	15	244	65	97	0.09	0.0	1.909	0.070	0	0	5	52

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.51834	PL.51536	C	#4 ACSR	7.34Y	122.4	0.06	2.64	18.24	14	130	34	97	0.05	0.0	1.978	0.069	5	1	1	30
PL.53040	PL.51834	C	#4 ACSR	7.34Y	122.4	0.01	2.65	17.60	14	125	33	97	0.01	0.0	1.988	0.009	0	0	1	29
PL.53041	PL.53040	C	#4 ACSR	7.34Y	122.3	0.02	2.67	17.60	14	125	33	97	0.02	0.0	2.018	0.030	0	0	0	28
PL.55432	PL.53041	C	#4 ACSR	7.34Y	122.3	0.00	2.67	1.71	1	12	3	97	0.00	0.0	2.090	0.073	12	3	4	4
PL.53039	PL.53041	C	#4 ACSR	7.34Y	122.3	0.08	2.75	15.89	12	113	30	97	0.06	0.1	2.125	0.107	0	0	0	24
PL.59352	PL.53039	C	#4 ACSR	7.33Y	122.2	0.02	2.77	15.89	12	113	30	97	0.02	0.0	2.161	0.036	12	3	2	24
PL.59353	PL.59352	C	#4 ACSR	7.33Y	122.2	0.03	2.80	14.21	11	101	27	97	0.02	0.0	2.211	0.050	34	9	6	22
PL.59317	PL.59353	C	#1/0 ACSR	7.33Y	122.2	0.00	2.80	3.20	1	23	6	97	0.00	0.0	2.239	0.028	23	6	7	7
PL.59350	PL.59353	C	#4 ACSR	7.33Y	122.2	0.01	2.81	6.25	5	44	12	96	0.00	0.0	2.262	0.052	14	4	1	9
PL.64306	PL.59350	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	1.91	1	14	4	96	0.00	0.0	2.301	0.038	2	1	3	5
PL.64307	PL.64306	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	1.58	1	11	3	96	0.00	0.0	2.325	0.025	0	0	0	2
PL.66151	PL.64307	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	1.58	1	11	3	96	0.00	0.0	2.348	0.023	11	3	2	2
PL.59351	PL.59350	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	2.44	1	17	5	96	0.00	0.0	2.284	0.022	17	5	3	3
PL.59131	PL.51536	C	#1/0 ACSR	7.34Y	122.4	0.04	2.63	16.15	7	115	30	97	0.03	0.0	2.018	0.109	0	0	0	17
PL.59132	PL.59131	C	#1/0 ACSR	7.34Y	122.3	0.04	2.67	16.15	7	115	30	97	0.03	0.0	2.138	0.120	0	0	0	17
PL.53045	PL.59132	C	#1/0 ACSR	7.34Y	122.3	0.00	2.67	0.69	0	5	1	98	0.00	0.0	2.169	0.031	0	0	0	1
PL.53046	PL.53045	C	#1/0 ACSR	7.34Y	122.3	0.00	2.67	0.69	0	5	1	98	0.00	0.0	2.210	0.041	0	0	0	1
PL.41794	PL.53046	C	#1/0 ACSR	7.34Y	122.3	0.00	2.67	0.69	0	5	1	98	0.00	0.0	2.265	0.055	5	1	1	1
PL.51835	PL.59132	C	#1/0 ACSR	7.34Y	122.3	0.04	2.71	15.47	7	110	29	97	0.03	0.0	2.242	0.104	0	0	0	16
PL.51836	PL.51835	C	#1/0 ACSR	7.33Y	122.2	0.06	2.76	15.47	7	110	29	97	0.04	0.0	2.407	0.165	6	2	1	16
PL.51837	PL.51836	C	6 A (CWC)	7.33Y	122.2	0.00	2.76	0.00	0	0	0	100	0.00	0.0	2.487	0.080	0	0	0	0
PL.51838	PL.51836	C	#1/0 ACSR	7.33Y	122.2	0.08	2.84	14.58	6	103	27	97	0.05	0.1	2.647	0.240	7	2	1	15
PL.51844	PL.51838	C	6 A (CWC)	7.33Y	122.2	0.01	2.85	2.52	2	18	5	96	0.00	0.0	2.750	0.103	18	5	1	1
PL.55750	PL.51838	C	6 A (CWC)	7.33Y	122.1	0.01	2.86	2.00	1	14	4	96	0.00	0.0	2.792	0.144	0	0	0	4
PL.55751	PL.55750	C	6 A (CWC)	7.33Y	122.1	0.01	2.86	2.00	1	14	4	96	0.00	0.0	2.869	0.078	0	0	1	4
PL.55752	PL.55751	C	6 A (CWC)	7.33Y	122.1	0.01	2.87	0.95	1	7	2	96	0.00	0.0	3.003	0.134	0	0	0	2
PL.55754	PL.55752	C	6 A (CWC)	7.33Y	122.1	0.00	2.87	0.95	1	7	2	96	0.00	0.0	3.079	0.076	7	2	2	2
PL.55753	PL.55752	C	6 A (CWC)	7.33Y	122.1	0.00	2.87	0.00	0	0	0	100	0.00	0.0	3.073	0.070	0	0	0	0
PL.55755	PL.55751	C	#4 ACSR	7.33Y	122.1	0.00	2.86	1.05	1	7	2	96	0.00	0.0	2.948	0.078	7	2	1	1
PL.59260	PL.51838	C	#1/0 ACSR	7.33Y	122.2	0.00	2.84	1.23	1	9	2	98	0.00	0.0	2.651	0.004	0	0	0	1
PD.8757	PL.59260	C	20QA	7.33Y	122.2	0.00	2.84	1.23	6	9	2	98	0.00	0.0	2.651	0.004	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59347	PD.8757	C	#1/0 ACSR	7.33Y	122.2	0.00	2.84	1.23	1	9	2	98	0.00	0.0	2.739	0.088	9	2	1	1
PL.59258	PL.51838	C	#1/0 ACSR	7.33Y	122.1	0.02	2.86	7.80	3	55	15	96	0.01	0.0	2.732	0.085	0	0	0	8
PL.59259	PL.59258	C	#1/0 ACSR	7.33Y	122.1	0.02	2.87	7.80	3	55	15	96	0.01	0.0	2.827	0.096	11	3	1	8
PL.51842	PL.59259	C	6 A (CWC)	7.33Y	122.1	0.00	2.88	6.28	4	45	12	97	0.00	0.0	2.847	0.019	16	4	4	7
PL.51841	PL.51842	C	6 A (CWC)	7.33Y	122.1	0.01	2.89	3.96	3	28	7	97	0.00	0.0	2.919	0.072	9	2	1	3
PL.51839	PL.51841	C	#2 ACSR	7.33Y	122.1	0.00	2.89	0.00	0	0	0	100	0.00	0.0	3.017	0.098	0	0	0	0
PL.51840	PL.51841	C	6 A (CWC)	7.33Y	122.1	0.01	2.90	2.65	2	19	5	97	0.00	0.0	3.049	0.131	11	3	1	2
PL.51843	PL.51840	C	6 A (CWC)	7.33Y	122.1	0.00	2.90	1.06	1	7	2	96	0.00	0.0	3.112	0.063	7	2	1	1
PL.55433	PL.55484	C	#4 ACSR	7.35Y	122.5	0.04	2.51	15.79	12	112	30	97	0.03	0.0	1.823	0.056	20	5	2	17
PL.55434	PL.55433	C	#4 ACSR	7.35Y	122.5	0.01	2.52	13.03	10	93	24	97	0.01	0.0	1.841	0.018	0	0	0	15
PL.55435	PL.55434	C	#4 ACSR	7.35Y	122.5	0.01	2.53	9.78	8	70	18	97	0.01	0.0	1.872	0.031	17	4	1	13
PL.55888	PL.55435	C	#4 ACSR	7.35Y	122.4	0.03	2.56	7.42	6	53	14	97	0.01	0.0	1.974	0.103	16	4	4	12
PL.55841	PL.55888	C	#4 ACSR	7.35Y	122.4	0.00	2.56	1.34	1	9	3	95	0.00	0.0	2.002	0.027	9	3	2	2
PL.55889	PL.55888	C	#4 ACSR	7.35Y	122.4	0.01	2.57	3.81	3	27	7	97	0.00	0.0	2.037	0.063	1	0	1	6
PL.42701	PL.55889	C	#4 ACSR	7.35Y	122.4	0.00	2.57	1.91	1	14	4	96	0.00	0.0	2.070	0.033	14	4	3	3
PL.41550	PL.55889	C	#2 ACSR	7.35Y	122.4	0.00	2.57	1.74	1	12	3	97	0.00	0.0	2.107	0.070	0	0	1	2
PL.66267	PL.41550	C	#1/0 ACSR	7.35Y	122.4	0.00	2.57	1.73	1	12	3	97	0.00	0.0	2.135	0.028	12	3	1	1
PL.55436	PL.55434	C	#1/0 ACSR	7.35Y	122.5	0.00	2.52	3.24	1	23	6	97	0.00	0.0	1.861	0.020	9	2	1	2
PL.55437	PL.55436	C	#1/0 ACSR	7.35Y	122.5	0.00	2.52	1.94	1	14	4	96	0.00	0.0	1.942	0.081	14	4	1	1
PL.41385	PL.55484	C	6 A (CWC)	7.35Y	122.5	0.00	2.47	0.00	0	0	0	100	0.00	0.0	1.847	0.081	0	0	1	1
PL.55903	PL.55901	C	#1/0 ACSR	7.37Y	122.8	0.00	2.18	1.67	1	12	3	97	0.00	0.0	1.593	0.068	12	3	1	1
PL.42838	PL.42837	A	6 A (CWC)	7.41Y	123.5	0.00	1.54	7.10	5	51	13	97	0.00	0.0	1.087	0.006	0	0	0	4
PD.6722	PL.42838	A	60QA	7.41Y	123.5	0.00	1.54	7.10	12	51	13	97	0.00	0.0	1.087	0.006	0	0	0	4
PL.55895	PD.6722	A	6 A (CWC)	7.40Y	123.4	0.06	1.60	7.10	5	51	13	97	0.02	0.0	1.343	0.256	33	9	2	4
PL.55897	PL.55895	A	6 A (CWC)	7.40Y	123.4	0.00	1.60	2.47	2	18	5	96	0.00	0.0	1.378	0.035	0	0	0	2
PL.55898	PL.55897	A	#4 ACSR	7.40Y	123.4	0.00	1.61	1.36	1	10	3	96	0.00	0.0	1.406	0.028	0	0	0	1
PL.55896	PL.55898	A	#4 ACSR	7.40Y	123.4	0.00	1.61	1.36	1	10	3	96	0.00	0.0	1.429	0.023	10	3	1	1
PL.55899	PL.55897	A	#1/0 ACSR	7.40Y	123.4	0.00	1.61	1.11	0	8	2	97	0.00	0.0	1.452	0.074	0	0	0	1
PL.55900	PL.55899	A	#1/0 ACSR	7.40Y	123.4	0.00	1.61	1.11	0	8	2	97	0.00	0.0	1.548	0.095	8	2	1	1
PL.55628	PL.55627	A	6 A (CWC)	7.45Y	124.2	0.00	0.81	3.42	2	25	6	97	0.00	0.0	0.746	0.006	0	0	0	3
PD.6721	PL.55628	A	60QA	7.45Y	124.2	0.00	0.81	3.42	6	25	6	97	0.00	0.0	0.746	0.006	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55697	PD.6721	A	6 A (CWC)	7.45Y	124.2	0.00	0.81	3.42	2	25	6	97	0.00	0.0	0.778	0.032	9	2	1	3
PL.55698	PL.55697	A	6 A (CWC)	7.45Y	124.2	0.01	0.82	2.12	2	15	4	97	0.00	0.0	0.846	0.068	0	0	0	2
PL.55696	PL.55698	A	6 A (CWC)	7.45Y	124.2	0.01	0.82	2.12	2	15	4	97	0.00	0.0	0.913	0.067	4	1	1	2
PL.63221	PL.55696	A	#1/0 ACSR	7.45Y	124.2	0.00	0.82	1.62	1	12	3	97	0.00	0.0	0.966	0.053	12	3	1	1
PL.55700	PL.55699	C	#4 ACSR	7.46Y	124.4	0.00	0.65	4.18	3	30	8	97	0.00	0.0	0.674	0.006	0	0	0	3
PD.6452	PL.55700	C	30T	7.46Y	124.4	0.00	0.65	4.18	0	30	8	97	0.00	0.0	0.674	0.006	0	0	0	3
PL.41536	PD.6452	C	#4 ACSR	7.46Y	124.3	0.01	0.66	4.18	3	30	8	97	0.00	0.0	0.762	0.088	10	3	1	3
PL.41537	PL.41536	C	#4 ACSR	7.46Y	124.3	0.01	0.67	2.83	2	20	5	97	0.00	0.0	0.879	0.117	9	2	1	2
PL.41304	PL.41537	C	#4 ACSR	7.46Y	124.3	0.00	0.67	0.00	0	0	0	100	0.00	0.0	0.986	0.106	0	0	0	0
PL.55625	PL.41537	C	#4 ACSR	7.46Y	124.3	0.00	0.68	1.52	1	11	3	96	0.00	0.0	0.978	0.099	11	3	1	1
PL.55626	PL.55625	C	#4 ACSR	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	1.023	0.045	0	0	0	0
PL.41532	PL.55735	A	#2 ACSR	7.47Y	124.5	0.00	0.50	6.35	4	46	12	97	0.00	0.0	0.520	0.006	0	0	0	8
PD.6451	PL.41532	A	60QA	7.47Y	124.5	0.00	0.50	6.35	11	46	12	97	0.00	0.0	0.520	0.006	0	0	0	8
PL.55732	PD.6451	A	#2 ACSR	7.47Y	124.5	0.02	0.52	6.35	4	46	12	97	0.01	0.0	0.620	0.101	9	2	1	8
PL.55733	PL.55732	A	#2 ACSR	7.47Y	124.5	0.01	0.53	5.13	3	37	10	97	0.00	0.0	0.670	0.050	10	3	2	7
PL.55892	PL.55733	A	#2 ACSR	7.47Y	124.5	0.00	0.53	3.75	2	27	7	97	0.00	0.0	0.731	0.061	17	4	2	5
PL.55893	PL.55892	A	#2 ACSR	7.47Y	124.5	0.00	0.54	1.45	1	10	3	96	0.00	0.0	0.788	0.057	0	0	2	3
PL.55794	PL.55893	A	#2 ACSR	7.47Y	124.5	0.00	0.54	1.44	1	10	3	96	0.00	0.0	0.843	0.054	0	0	0	1
PL.55795	PL.55794	A	#2 ACSR	7.47Y	124.5	0.00	0.54	1.44	1	10	3	96	0.00	0.0	0.910	0.067	10	3	1	1
PL.41533	PL.55735	C	#4 ACSR	7.47Y	124.5	0.00	0.50	1.52	1	11	3	96	0.00	0.0	0.520	0.006	0	0	0	1
PD.6770	PL.41533	C	60QA	7.47Y	124.5	0.00	0.50	1.52	3	11	3	96	0.00	0.0	0.520	0.006	0	0	0	1
PL.41534	PD.6770	C	#4 ACSR	7.47Y	124.5	0.00	0.51	1.52	1	11	3	96	0.00	0.0	0.590	0.070	11	3	1	1
PL.41872	PL.59410	C	#4 ACSR	7.48Y	124.7	0.00	0.26	4.86	4	35	9	97	0.00	0.0	0.268	0.006	0	0	0	5
PD.6450	PL.41872	C	75QA	7.48Y	124.7	0.00	0.26	4.86	6	35	9	97	0.00	0.0	0.268	0.006	0	0	0	5
PL.41873	PD.6450	C	#4 ACSR	7.48Y	124.7	0.01	0.27	4.86	4	35	9	97	0.00	0.0	0.324	0.056	3	1	1	5
PL.41874	PL.41873	C	#4 ACSR	7.48Y	124.7	0.01	0.28	4.44	3	32	8	97	0.00	0.0	0.365	0.042	1	0	1	4
PL.41529	PL.41874	C	#2 ACSR	7.48Y	124.7	0.00	0.29	2.68	2	19	5	97	0.00	0.0	0.433	0.067	10	3	1	2
PL.41530	PL.41529	C	#2 ACSR	7.48Y	124.7	0.00	0.29	1.37	1	10	3	96	0.00	0.0	0.503	0.071	10	3	1	1
PL.41875	PL.41874	C	#4 ACSR	7.48Y	124.7	0.00	0.28	1.65	1	12	3	97	0.00	0.0	0.417	0.052	12	3	1	1
PL.59423	PL.59425	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	0.036	0.007	0	0	0	0
PL.59283	Keavy 2	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	265.24	51	5612	2031	94	0.17	0.0	0.003	0.003	0	0	0	677

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59284	PL.59283	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	265.24	51	5611	2031	94	0.10	0.0	0.005	0.002	0	0	0	677
----- Feeder No. 4 (Bald Rock F4) Beginning with Device PD.8771 -----																				
PD.8771	PL.59284	ABC	400VWE	7.50Y	125.0	0.00	0.01	265.24	0	5611	2030	94	0.00	0.0	0.005	0.002	0	0	0	677
PL.59282	PD.8771	ABC	336 MCM AC	7.50Y	125.0	0.01	0.02	265.24	51	5611	2030	94	0.23	0.0	0.009	0.004	0	0	0	677
PL.59427	PL.59282	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	0.00	0	0	0	100	0.00	0.0	0.009	0.000	0	0	0	0
PD.8769-B	PL.59427	ABC	Open	7.50Y	125.0	0.00	0.02	0.00	0	0	0	100	0.00	0.0	0.009	0.000	0	0	0	0
PL.59424	PL.59282	ABC	336 MCM AC	7.49Y	124.9	0.10	0.12	265.24	51	5611	2030	94	2.85	0.1	0.057	0.048	0	0	0	677
PL.59421	PL.59424	ABC	336 MCM AC	7.48Y	124.7	0.14	0.26	265.24	51	5608	2023	94	3.78	0.1	0.121	0.064	0	0	0	677
PL.52993	PL.59421	C	#3/0 ACSR	7.48Y	124.7	0.00	0.26	0.67	0	5	1	98	0.00	0.0	0.126	0.006	0	0	0	1
PD.6675	PL.52993	C	75QA	7.48Y	124.7	0.00	0.26	0.67	1	5	1	98	0.00	0.0	0.126	0.006	0	0	0	1
PL.56838	PD.6675	C	#3/0 ACSR	7.48Y	124.7	0.00	0.26	0.67	0	5	1	98	0.00	0.0	0.151	0.024	5	1	1	1
PL.52994	PL.59421	ABC	336 MCM AC	7.47Y	124.5	0.19	0.45	265.01	51	5600	2013	94	5.30	0.1	0.210	0.090	18	5	2	676
PL.42122	PL.52994	ABC	336 MCM AC	7.46Y	124.4	0.17	0.62	263.84	51	5569	1994	94	4.71	0.1	0.291	0.081	15	4	1	673
PL.42123	PL.42122	ABC	336 MCM AC	7.46Y	124.3	0.05	0.67	263.17	51	5549	1979	94	1.37	0.0	0.314	0.024	0	0	0	672
PL.42124	PL.42123	C	6 A (CWC)	7.46Y	124.3	0.00	0.67	5.84	4	42	11	97	0.00	0.0	0.320	0.006	0	0	0	9
PD.6518	PL.42124	C	75QA	7.46Y	124.3	0.00	0.67	5.84	8	42	11	97	0.00	0.0	0.320	0.006	0	0	0	9
PL.42125	PD.6518	C	6 A (CWC)	7.46Y	124.3	0.01	0.68	5.84	4	42	11	97	0.00	0.0	0.349	0.029	9	2	3	9
PL.42126	PL.42125	C	6 A (CWC)	7.46Y	124.3	0.01	0.69	4.60	3	33	9	96	0.00	0.0	0.379	0.030	11	3	3	6
PL.42127	PL.42126	C	6 A (CWC)	7.46Y	124.3	0.00	0.69	3.11	2	22	6	96	0.00	0.0	0.414	0.034	0	0	0	3
PL.42128	PL.42127	C	6 A (CWC)	7.46Y	124.3	0.01	0.70	3.11	2	22	6	96	0.00	0.0	0.461	0.047	8	2	1	3
PL.42129	PL.42128	C	6 A (CWC)	7.46Y	124.3	0.00	0.70	2.01	1	14	4	96	0.00	0.0	0.492	0.031	3	1	1	2
PL.42130	PL.42129	C	6 A (CWC)	7.46Y	124.3	0.00	0.70	1.64	1	12	3	97	0.00	0.0	0.551	0.059	12	3	1	1
PL.42176	PL.42123	ABC	336 MCM AC	7.45Y	124.1	0.24	0.91	261.23	50	5506	1965	94	6.48	0.1	0.427	0.113	10	3	2	663
PL.56486	PL.42176	ABC	336 MCM AC	7.43Y	123.8	0.30	1.21	260.79	50	5490	1947	94	8.11	0.1	0.569	0.142	0	0	0	661
PL.56487	PL.56486	ABC	336 MCM AC	7.42Y	123.7	0.07	1.28	260.79	50	5482	1928	94	1.97	0.0	0.603	0.034	2	1	1	661
PL.56488	PL.56487	ABC	336 MCM AC	7.40Y	123.3	0.38	1.66	260.68	50	5477	1923	94	10.43	0.2	0.786	0.182	1	0	1	660
PL.56748	PL.56488	C	#1/0 ACSR	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	0.790	0.004	0	0	0	2
PD.8242	PL.56748	C	20QA	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	0.790	0.004	0	0	0	2
PL.59392	PD.8242	C	#1/0 ACSR	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	0.837	0.047	0	0	1	2

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59393	PL.59392	C	#1/0 ACSR	7.40Y	123.3	0.00	1.66	0.00	0	0	0	100	0.00	0.0	0.899	0.063	0	0	1	1
PL.56960	PL.56488	ABC	336 MCM AC	7.40Y	123.3	0.05	1.71	260.63	50	5466	1898	94	1.41	0.0	0.810	0.025	16	4	1	657
PL.56958	PL.56960	ABC	336 MCM AC	7.39Y	123.2	0.09	1.80	259.86	50	5448	1891	94	2.44	0.0	0.853	0.043	9	2	1	656
PL.56959	PL.56958	ABC	336 MCM AC	7.38Y	123.1	0.12	1.92	259.46	50	5437	1883	94	3.26	0.1	0.911	0.058	0	0	0	655
PL.41898	PL.56959	A	6 A (CWC)	7.38Y	123.1	0.00	1.92	3.71	3	26	7	97	0.00	0.0	0.916	0.006	0	0	0	3
PD.6745	PL.41898	A	60QA	7.38Y	123.1	0.00	1.92	3.71	6	26	7	97	0.00	0.0	0.916	0.006	0	0	0	3
PL.56507	PD.6745	A	6 A (CWC)	7.38Y	123.1	0.00	1.93	3.71	3	26	7	97	0.00	0.0	0.951	0.035	12	3	2	3
PL.56508	PL.56507	A	6 A (CWC)	7.38Y	123.1	0.00	1.93	1.98	1	14	4	96	0.00	0.0	0.983	0.032	14	4	1	1
PL.41899	PL.56959	ABC	336 MCM AC	7.38Y	123.1	0.03	1.95	258.23	50	5407	1868	95	0.72	0.0	0.923	0.013	0	0	0	652
PL.62037	PL.41899	ABC	336 MCM AC	7.38Y	123.0	0.03	1.98	258.23	50	5406	1866	95	0.94	0.0	0.940	0.017	0	0	0	652
PL.62038	PL.62037	ABC	336 MCM AC	7.37Y	122.9	0.14	2.12	258.23	50	5405	1864	95	3.83	0.1	1.009	0.068	19	5	2	652
PL.41509	PL.62038	ABC	336 MCM AC	7.36Y	122.7	0.21	2.34	257.33	50	5383	1850	95	5.83	0.1	1.113	0.105	16	4	1	650
PL.41732	PL.41509	ABC	336 MCM AC	7.36Y	122.6	0.01	2.35	52.30	10	1066	443	92	0.07	0.0	1.146	0.033	11	3	1	54
PL.41733	PL.41732	ABC	336 MCM AC	7.36Y	122.6	0.04	2.40	51.80	10	1056	440	92	0.23	0.0	1.246	0.100	0	0	1	53
PL.41769	PL.41733	ABC	336 MCM AC	7.35Y	122.6	0.05	2.44	51.80	10	1055	439	92	0.24	0.0	1.353	0.107	0	0	0	52
PL.41867	PL.41769	A	#4 ACSR	7.35Y	122.5	0.01	2.45	4.74	4	34	9	97	0.00	0.0	1.444	0.091	34	9	1	1
PL.41770	PL.41769	ABC	336 MCM AC	7.35Y	122.5	0.02	2.46	50.24	10	1022	430	92	0.11	0.0	1.403	0.050	0	0	0	51
PL.41771	PL.41770	ABC	336 MCM AC	7.35Y	122.5	0.00	2.47	50.24	10	1021	430	92	0.01	0.0	1.408	0.006	0	0	0	51
PD.6790	PL.41771	ABC	240VWE	7.35Y	122.5	0.00	2.47	50.24	0	1021	429	92	0.00	0.0	1.408	0.006	0	0	0	51
PL.41772	PD.6790	ABC	336 MCM AC	7.35Y	122.5	0.01	2.48	50.24	10	1021	429	92	0.07	0.0	1.442	0.034	0	0	0	51
PL.41850	PL.41772	ABC	#1/0 ACSR	7.35Y	122.4	0.07	2.55	42.55	18	856	385	91	0.42	0.0	1.529	0.087	0	0	0	26
PL.42626	PL.41850	ABC	#1/0 ACSR	7.34Y	122.3	0.12	2.67	38.75	17	773	363	91	0.62	0.1	1.683	0.154	0	0	0	10
PL.42627	PL.42626	ABC	#1/0 ACSR	7.34Y	122.3	0.06	2.73	38.22	17	761	360	90	0.32	0.0	1.766	0.083	5	1	1	9
PL.42628	PL.42627	ABC	#1/0 ACSR	7.33Y	122.2	0.08	2.81	37.70	16	749	356	90	0.41	0.1	1.874	0.108	0	0	0	7
PL.42629	PL.42628	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	2.78	1	20	5	97	0.00	0.0	1.880	0.006	0	0	0	3
PD.6118	PL.42629	C	40QA	7.33Y	122.2	0.00	2.81	2.78	7	20	5	97	0.00	0.0	1.880	0.006	0	0	0	3
PL.42630	PD.6118	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	2.78	1	20	5	97	0.00	0.0	1.895	0.015	8	2	1	3
PL.42631	PL.42630	C	#1/0 ACSR	7.33Y	122.2	0.00	2.81	1.59	1	11	3	96	0.00	0.0	1.923	0.029	11	3	2	2
PL.42632	PL.42628	ABC	#1/0 ACSR	7.33Y	122.2	0.03	2.84	36.79	16	729	351	90	0.14	0.0	1.912	0.039	0	0	0	4
PL.41891	PL.42632	A	6 A (CWC)	7.33Y	122.2	0.00	2.84	1.15	1	8	2	97	0.00	0.0	1.963	0.051	8	2	1	1
PL.42633	PL.42632	ABC	#1/0 ACSR	7.33Y	122.1	0.05	2.89	36.42	16	721	349	90	0.27	0.0	1.989	0.077	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42634	PL.42633	ABC	#1/0 ACSR	7.32Y	122.0	0.07	2.96	36.42	16	721	348	90	0.33	0.0	2.082	0.093	0	0	0	3
PL.42635	PL.42634	ABC	#1/0 ACSR	7.32Y	122.0	0.05	3.00	36.42	16	720	348	90	0.24	0.0	2.149	0.067	4	1	1	3
PL.42636	PL.42635	ABC	#1/0 ACSR	7.31Y	121.9	0.12	3.12	36.24	16	716	347	90	0.59	0.1	2.318	0.169	0	0	0	2
PL.42637	PL.42636	ABC	1/0 AL URD	7.31Y	121.9	0.00	3.13	36.24	21	716	346	90	0.03	0.0	2.324	0.006	0	0	0	2
PD.6718	PL.42637	ABC	50QA	7.31Y	121.9	0.00	3.13	36.24	72	716	346	90	0.00	0.0	2.324	0.006	0	0	0	2
PL.42638	PD.6718	ABC	1/0 AL URD	7.28Y	121.4	0.48	3.61	36.24	21	716	346	90	2.99	0.4	2.985	0.661	0	0	0	2
PL.52666	PL.42638	ABC	#2 ACSR	7.28Y	121.4	0.02	3.63	36.24	21	713	345	90	0.13	0.0	3.010	0.025	0	0	0	2
PL.52667	PL.52666	ABC	#2 ACSR	7.28Y	121.4	0.00	3.63	36.24	21	713	345	90	0.01	0.0	3.016	0.007	713	345	2	2
PL.41465	PL.42627	A	#4 ACSR	7.34Y	122.3	0.00	2.73	0.95	1	7	2	96	0.00	0.0	1.902	0.136	7	2	1	1
PL.58556	PL.42626	C	#4 ACSR	7.34Y	122.3	0.00	2.67	1.62	1	11	3	96	0.00	0.0	1.685	0.003	0	0	0	1
PD.8619	PL.58556	C	25T	7.34Y	122.3	0.00	2.67	1.62	0	11	3	96	0.00	0.0	1.685	0.003	0	0	0	1
PL.58557	PD.8619	C	#4 ACSR	7.34Y	122.3	0.00	2.67	1.62	1	11	3	96	0.00	0.0	1.779	0.094	11	3	1	1
PL.66650	PL.41850	A	6 A (CWC)	7.35Y	122.4	0.00	2.55	11.56	8	82	22	97	0.00	0.0	1.532	0.003	0	0	0	16
PD.10407	PL.66650	A	30T	7.35Y	122.4	0.00	2.55	11.56	0	82	22	97	0.00	0.0	1.532	0.003	0	0	0	16
PL.66651	PD.10407	A	6 A (CWC)	7.34Y	122.3	0.17	2.73	11.56	8	82	22	97	0.11	0.1	1.860	0.328	0	0	0	16
PL.56242	PL.66651	A	6 A (CWC)	7.34Y	122.3	0.02	2.74	11.56	8	82	22	97	0.01	0.0	1.892	0.032	0	0	0	16
PL.41783	PL.56242	A	#4 ACSR	7.34Y	122.3	0.00	2.75	5.99	5	43	11	97	0.00	0.0	1.898	0.006	0	0	0	4
PD.6577	PL.41783	A	50T	7.34Y	122.3	0.00	2.75	5.99	0	43	11	97	0.00	0.0	1.898	0.006	0	0	0	4
PL.56239	PD.6577	A	#4 ACSR	7.33Y	122.2	0.01	2.76	5.99	5	43	11	97	0.00	0.0	1.946	0.049	18	5	2	4
PL.56240	PL.56239	A	#4 ACSR	7.33Y	122.2	0.01	2.76	3.39	3	24	6	97	0.00	0.0	1.992	0.045	9	2	1	2
PL.56747	PL.56240	A	1/0 AL URD	7.33Y	122.2	0.00	2.76	2.06	1	15	4	97	0.00	0.0	2.076	0.084	15	4	1	1
PL.56696	PL.56242	A	6 A (CWC)	7.33Y	122.2	0.01	2.76	5.27	4	37	10	97	0.00	0.0	1.956	0.064	9	2	1	10
PL.56697	PL.56696	A	6 A (CWC)	7.33Y	122.2	0.01	2.77	4.02	3	28	8	96	0.00	0.0	2.013	0.057	3	1	1	9
PL.56695	PL.56697	A	6 A (CWC)	7.33Y	122.2	0.00	2.77	3.65	3	26	7	97	0.00	0.0	2.039	0.026	4	1	2	8
PL.56694	PL.56695	A	6 A (CWC)	7.33Y	122.2	0.01	2.78	3.04	2	22	6	96	0.00	0.0	2.084	0.045	0	0	0	6
PL.42625	PL.56694	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.69	0	5	1	98	0.00	0.0	2.130	0.045	3	1	3	4
PL.56397	PL.42625	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.24	0	2	0	100	0.00	0.0	2.218	0.088	2	0	1	1
PL.56398	PL.56397	A	6 A (CWC)	7.33Y	122.2	0.00	2.78	0.00	0	0	0	100	0.00	0.0	2.261	0.043	0	0	0	0
PL.56399	PL.56398	A	1/0 AL URD	7.33Y	122.2	0.00	2.78	0.00	0	0	0	100	0.00	0.0	2.282	0.020	0	0	0	0
PL.56692	PL.56694	A	#2 ACSR	7.33Y	122.2	0.00	2.78	0.00	0	0	0	100	0.00	0.0	2.130	0.045	0	0	0	0
PL.56693	PL.56694	A	#4 ACSR	7.33Y	122.2	0.01	2.78	2.35	2	17	4	97	0.00	0.0	2.138	0.054	0	0	0	2

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56704	PL.56693	A	#2 ACSR	7.33Y	122.2	0.00	2.78	2.35	1	17	4	97	0.00	0.0	2.155	0.017	17	4	2	2
PL.41455	PL.56242	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.29	0	2	1	89	0.00	0.0	1.936	0.044	2	1	2	2
PL.56051	PL.41772	C	#4 ACSR	7.35Y	122.5	0.00	2.48	0.27	0	2	1	89	0.00	0.0	1.482	0.039	2	1	1	1
PL.58195	PL.41772	B	6 A (CWC)	7.35Y	122.5	0.00	2.48	23.06	16	164	43	97	0.00	0.0	1.445	0.003	0	0	0	24
PL.58196	PL.58195	B	6 A (CWC)	7.34Y	122.4	0.11	2.59	23.06	16	164	43	97	0.13	0.1	1.549	0.104	0	0	0	24
PL.42639	PL.58196	B	6 A (CWC)	7.34Y	122.4	0.03	2.63	20.69	15	147	39	97	0.03	0.0	1.584	0.034	12	3	1	23
PL.64119	PL.42639	B	6 A (CWC)	7.34Y	122.4	0.00	2.63	18.95	14	135	36	97	0.00	0.0	1.588	0.004	0	0	0	22
PD.9528	PL.64119	B	40T	7.34Y	122.4	0.00	2.63	18.95	0	135	36	97	0.00	0.0	1.588	0.004	0	0	0	22
PL.64120	PD.9528	B	6 A (CWC)	7.34Y	122.4	0.01	2.64	18.95	14	135	36	97	0.01	0.0	1.604	0.017	12	3	2	22
PL.42640	PL.64120	B	6 A (CWC)	7.34Y	122.3	0.06	2.71	17.32	12	123	33	97	0.06	0.0	1.690	0.086	11	3	2	20
PL.41739	PL.42640	B	#2 ACSR	7.34Y	122.3	0.00	2.71	1.42	1	10	3	96	0.00	0.0	1.745	0.055	10	3	1	1
PL.42641	PL.42640	B	6 A (CWC)	7.34Y	122.3	0.04	2.74	14.31	10	102	27	97	0.03	0.0	1.752	0.061	12	3	1	17
PL.42642	PL.42641	B	6 A (CWC)	7.33Y	122.2	0.04	2.79	12.57	9	89	24	97	0.03	0.0	1.826	0.074	3	1	1	16
PL.42643	PL.42642	B	6 A (CWC)	7.33Y	122.2	0.04	2.83	12.14	9	86	23	97	0.02	0.0	1.905	0.079	13	3	2	15
PL.41020	PL.42643	B	#4 ACSR	7.33Y	122.2	0.00	2.83	1.26	1	9	2	98	0.00	0.0	1.968	0.062	9	2	1	1
PL.42644	PL.42643	B	6 A (CWC)	7.33Y	122.1	0.05	2.88	9.01	6	64	17	97	0.02	0.0	2.047	0.142	12	3	2	12
PL.42645	PL.42644	B	6 A (CWC)	7.33Y	122.1	0.02	2.90	6.02	4	43	11	97	0.01	0.0	2.118	0.071	0	0	0	8
PL.41453	PL.42645	B	#4 ACSR	7.33Y	122.1	0.00	2.90	0.77	1	5	1	98	0.00	0.0	2.159	0.040	5	1	2	2
PL.42646	PL.42645	B	6 A (CWC)	7.33Y	122.1	0.01	2.91	5.25	4	37	10	97	0.00	0.0	2.158	0.039	0	0	0	6
PL.41561	PL.42646	B	#1/0 ACSR	7.33Y	122.1	0.00	2.91	1.48	1	11	3	96	0.00	0.0	2.200	0.043	11	3	1	1
PL.42647	PL.42646	B	6 A (CWC)	7.33Y	122.1	0.00	2.91	3.77	3	27	7	97	0.00	0.0	2.181	0.023	0	0	0	5
PL.41464	PL.42647	B	#4 ACSR	7.33Y	122.1	0.00	2.91	0.01	0	0	0	100	0.00	0.0	2.216	0.035	0	0	2	2
PL.42648	PL.42647	B	6 A (CWC)	7.32Y	122.1	0.01	2.92	3.76	3	27	7	97	0.00	0.0	2.223	0.042	9	2	1	3
PL.42649	PL.42648	B	6 A (CWC)	7.32Y	122.1	0.00	2.92	0.94	1	7	2	96	0.00	0.0	2.358	0.135	7	2	1	1
PL.41701	PL.42648	B	#4 ACSR	7.32Y	122.1	0.00	2.92	1.61	1	11	3	96	0.00	0.0	2.266	0.043	11	3	1	1
PL.41495	PL.42644	B	#4 ACSR	7.33Y	122.1	0.00	2.88	1.26	1	9	2	98	0.00	0.0	2.112	0.064	9	2	2	2
PL.41497	PL.58196	B	#2 ACSR	7.34Y	122.4	0.00	2.60	2.36	1	17	4	97	0.00	0.0	1.592	0.042	17	4	1	1
PL.41510	PL.41509	ABC	336 MCM AC	7.36Y	122.6	0.07	2.41	204.42	39	4294	1390	95	1.52	0.0	1.157	0.043	3	1	2	595
PL.41511	PL.41510	B	#4 ACSR	7.36Y	122.6	0.00	2.41	0.00	0	0	0	100	0.00	0.0	1.162	0.006	0	0	0	0
PD.6785	PL.41511	B	60QA	7.36Y	122.6	0.00	2.41	0.00	0	0	0	100	0.00	0.0	1.162	0.006	0	0	0	0
PL.41512	PD.6785	B	#4 ACSR	7.36Y	122.6	0.00	2.41	0.00	0	0	0	100	0.00	0.0	1.202	0.040	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

-----																				
Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
-----																				
PL.41513	PL.41510	ABC	336 MCM AC	7.35Y	122.5	0.14	2.55	204.30	39	4290	1385	95	3.10	0.1	1.245	0.088	0	0	0	593
PL.66130	PL.41513	ABC	336 MCM AC	7.34Y	122.4	0.06	2.61	204.30	39	4287	1378	95	1.39	0.0	1.284	0.040	0	0	0	593
PL.66131	PL.66130	ABC	336 MCM AC	7.34Y	122.3	0.05	2.66	204.06	39	4280	1374	95	1.06	0.0	1.314	0.030	0	0	0	592
PL.42021	PL.66131	ABC	336 MCM AC	7.34Y	122.3	0.08	2.74	203.42	39	4266	1368	95	1.85	0.0	1.368	0.053	9	2	1	591
PL.42022	PL.42021	ABC	336 MCM AC	7.33Y	122.2	0.05	2.79	202.98	39	4255	1361	95	1.16	0.0	1.401	0.033	0	0	0	590
PL.42023	PL.42022	C	6 A (CWC)	7.33Y	122.2	0.00	2.80	2.45	2	17	5	96	0.00	0.0	1.407	0.006	0	0	0	3
PD.6463	PL.42023	C	60QA	7.33Y	122.2	0.00	2.80	2.45	4	17	5	96	0.00	0.0	1.407	0.006	0	0	0	3
PL.42024	PD.6463	C	#2 ACSR	7.33Y	122.2	0.00	2.80	2.45	1	17	5	96	0.00	0.0	1.461	0.054	6	2	1	3
PL.51982	PL.42024	C	#2 ACSR	7.33Y	122.2	0.00	2.80	1.57	1	11	3	96	0.00	0.0	1.547	0.086	11	3	2	2
PL.42025	PL.42022	ABC	336 MCM AC	7.33Y	122.1	0.10	2.90	202.17	39	4236	1353	95	2.20	0.1	1.465	0.064	7	2	1	587
PL.42026	PL.42025	ABC	336 MCM AC	7.32Y	121.9	0.18	3.08	201.84	39	4227	1347	95	3.97	0.1	1.581	0.116	0	0	0	586
PL.42027	PL.42026	C	6 A (CWC)	7.31Y	121.9	0.01	3.09	37.42	27	265	70	97	0.02	0.0	1.586	0.006	0	0	0	35
PD.6786	PL.42027	C	60QA	7.31Y	121.9	0.00	3.09	37.42	62	265	70	97	0.00	0.0	1.586	0.006	0	0	0	35
PL.42028	PD.6786	C	6 A (CWC)	7.30Y	121.7	0.18	3.26	37.42	27	265	70	97	0.34	0.1	1.693	0.106	15	4	2	35
PL.42029	PL.42028	C	6 A (CWC)	7.30Y	121.7	0.01	3.27	9.82	7	69	18	97	0.00	0.0	1.711	0.019	6	2	2	12
PL.42271	PL.42029	C	#4 ACSR	7.30Y	121.7	0.00	3.27	2.07	2	15	4	97	0.00	0.0	1.735	0.024	15	4	2	4
PL.42272	PL.42271	C	#4 ACSR	7.30Y	121.7	0.00	3.27	0.01	0	0	0	100	0.00	0.0	1.778	0.042	0	0	2	2
PL.42273	PL.42029	C	6 A (CWC)	7.30Y	121.7	0.02	3.29	6.90	5	49	13	97	0.01	0.0	1.774	0.062	13	3	1	6
PL.59277	PL.42273	C	6 A (CWC)	7.30Y	121.7	0.01	3.29	5.03	4	36	9	97	0.00	0.0	1.817	0.043	20	5	4	5
PL.59278	PL.59277	C	6 A (CWC)	7.30Y	121.7	0.00	3.30	2.23	2	16	4	97	0.00	0.0	1.872	0.055	16	4	1	1
PL.42274	PL.42028	C	6 A (CWC)	7.30Y	121.7	0.04	3.30	25.45	18	180	48	97	0.05	0.0	1.726	0.033	14	4	1	21
PL.42275	PL.42274	C	6 A (CWC)	7.30Y	121.7	0.05	3.35	23.47	17	166	44	97	0.06	0.0	1.771	0.046	0	0	0	20
PL.59274	PL.42275	C	6 A (CWC)	7.30Y	121.6	0.03	3.38	18.55	13	131	35	97	0.03	0.0	1.816	0.044	36	9	4	15
PL.59275	PL.59274	C	6 A (CWC)	7.29Y	121.6	0.04	3.42	13.48	10	95	25	97	0.03	0.0	1.884	0.068	11	3	1	11
PL.42277	PL.59275	C	6 A (CWC)	7.29Y	121.6	0.03	3.45	11.86	8	84	22	97	0.02	0.0	1.940	0.056	22	6	4	10
PL.42278	PL.42277	C	6 A (CWC)	7.29Y	121.5	0.02	3.46	7.65	5	54	14	97	0.01	0.0	1.997	0.057	24	6	3	5
PL.57589	PL.42278	C	6 A (CWC)	7.29Y	121.5	0.01	3.47	4.31	3	30	8	97	0.00	0.0	2.031	0.034	0	0	0	2
PL.57590	PL.57589	C	6 A (CWC)	7.29Y	121.5	0.00	3.47	2.01	1	14	4	96	0.00	0.0	2.110	0.079	14	4	1	1
PL.57591	PL.57589	C	6 A (CWC)	7.29Y	121.5	0.00	3.47	2.30	2	16	4	97	0.00	0.0	2.082	0.051	16	4	1	1
PL.62030	PL.42277	C	6 A (CWC)	7.29Y	121.6	0.00	3.45	1.10	1	8	2	97	0.00	0.0	1.975	0.035	8	2	1	1
PL.42276	PL.42275	C	#2 ACSR	7.30Y	121.6	0.01	3.36	4.92	3	35	9	97	0.00	0.0	1.826	0.055	0	0	2	5

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.57937	PL.42276	C	#2 ACSR	7.30Y	121.6	0.01	3.36	4.91	3	35	9	97	0.00	0.0	1.871	0.045	8	2	1	3
PL.57938	PL.57937	C	#2 ACSR	7.30Y	121.6	0.00	3.36	0.00	0	0	0	100	0.00	0.0	1.917	0.046	0	0	0	0
PL.61166	PL.57937	C	#1/0 ACSR	7.30Y	121.6	0.00	3.36	3.74	2	26	7	97	0.00	0.0	1.894	0.023	26	7	2	2
PL.42279	PL.42026	ABC	336 MCM AC	7.31Y	121.9	0.06	3.14	189.39	36	3958	1267	95	1.31	0.0	1.624	0.043	13	3	1	551
PL.59381	PL.42279	ABC	336 MCM AC	7.30Y	121.7	0.13	3.27	188.79	36	3945	1261	95	2.58	0.1	1.710	0.086	17	4	1	550
PL.63237	PL.59381	A	#1/0 ACSR	7.30Y	121.7	0.00	3.27	1.12	0	8	2	97	0.00	0.0	1.714	0.003	0	0	0	1
PD.9475	PL.63237	A	20T	7.30Y	121.7	0.00	3.27	1.12	0	8	2	97	0.00	0.0	1.714	0.003	0	0	0	1
PL.63238	PD.9475	A	#1/0 ACSR	7.30Y	121.7	0.00	3.27	1.12	0	8	2	97	0.00	0.0	1.745	0.031	8	2	1	1
PL.59382	PL.59381	ABC	336 MCM AC	7.30Y	121.6	0.09	3.36	187.62	36	3917	1248	95	1.89	0.0	1.774	0.064	0	0	0	548
PL.42281	PL.59382	ABC	336 MCM AC	7.29Y	121.6	0.06	3.42	185.07	36	3861	1230	95	1.21	0.0	1.816	0.042	8	2	2	543
PL.42282	PL.42281	ABC	336 MCM AC	7.29Y	121.5	0.09	3.51	184.71	36	3852	1225	95	1.87	0.0	1.881	0.065	0	0	0	541
PL.42283	PL.42282	C	#4 ACSR	7.29Y	121.5	0.00	3.51	0.83	1	6	2	95	0.00	0.0	1.887	0.006	0	0	0	2
PD.6396	PL.42283	C	60QA	7.29Y	121.5	0.00	3.51	0.83	1	6	2	95	0.00	0.0	1.887	0.006	0	0	0	2
PL.42284	PD.6396	C	#4 ACSR	7.29Y	121.5	0.00	3.52	0.83	1	6	2	95	0.00	0.0	1.968	0.081	6	2	2	2
PL.42285	PL.42282	ABC	336 MCM AC	7.29Y	121.4	0.04	3.56	184.43	36	3844	1219	95	0.89	0.0	1.912	0.031	7	2	1	539
PL.42288	PL.42285	ABC	336 MCM AC	7.28Y	121.4	0.07	3.62	184.09	35	3836	1215	95	1.32	0.0	1.959	0.046	4	1	1	538
PL.42289	PL.42288	ABC	336 MCM AC	7.28Y	121.3	0.09	3.71	183.89	35	3831	1211	95	1.76	0.0	2.021	0.062	0	0	0	537
PL.42290	PL.42289	C	#4 ACSR	7.28Y	121.3	0.00	3.71	1.39	1	10	3	96	0.00	0.0	2.026	0.006	0	0	0	1
PD.6657	PL.42290	C	60QA	7.28Y	121.3	0.00	3.71	1.39	2	10	3	96	0.00	0.0	2.026	0.006	0	0	0	1
PL.42291	PD.6657	C	#4 ACSR	7.28Y	121.3	0.00	3.71	1.39	1	10	3	96	0.00	0.0	2.039	0.012	10	3	1	1
PL.42292	PL.42289	ABC	336 MCM AC	7.27Y	121.2	0.06	3.78	183.43	35	3819	1204	95	1.27	0.0	2.065	0.045	0	0	1	536
PL.42293	PL.42292	ABC	336 MCM AC	7.27Y	121.1	0.08	3.86	183.43	35	3818	1201	95	1.60	0.0	2.122	0.057	8	2	1	535
PL.42294	PL.42293	ABC	336 MCM AC	7.26Y	121.0	0.18	4.04	183.07	35	3809	1195	95	3.58	0.1	2.249	0.127	0	0	0	534
PL.42297	PL.42294	ABC	336 MCM AC	7.25Y	120.8	0.18	4.22	182.93	35	3802	1186	95	3.63	0.1	2.378	0.129	21	5	4	532
PL.42298	PL.42297	ABC	336 MCM AC	7.24Y	120.7	0.10	4.32	181.95	35	3778	1172	96	2.01	0.1	2.450	0.072	9	2	1	528
PL.41293	PL.42298	A	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.27	0	2	1	89	0.00	0.0	2.494	0.044	2	1	1	1
PL.42299	PL.42298	ABC	336 MCM AC	7.24Y	120.6	0.09	4.41	181.41	35	3765	1164	96	1.83	0.0	2.517	0.066	10	3	3	526
PL.42300	PL.42299	A	6 A (CWC)	7.24Y	120.6	0.00	4.41	1.42	1	10	3	96	0.00	0.0	2.522	0.006	0	0	0	1
PD.6465	PL.42300	A	60QA	7.24Y	120.6	0.00	4.41	1.42	2	10	3	96	0.00	0.0	2.522	0.006	0	0	0	1
PL.42301	PD.6465	A	6 A (CWC)	7.24Y	120.6	0.00	4.41	1.42	1	10	3	96	0.00	0.0	2.555	0.033	10	3	1	1
PL.59355	PL.42299	ABC	336 MCM AC	7.23Y	120.5	0.07	4.48	180.46	35	3743	1155	96	1.29	0.0	2.564	0.047	52	14	5	522

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59356	PL.59355	ABC	336 MCM AC	7.23Y	120.5	0.07	4.55	177.96	34	3689	1138	96	1.35	0.0	2.615	0.051	14	4	2	517
PL.42302	PL.59356	A	#4 ACSR	7.23Y	120.4	0.01	4.55	20.50	16	143	38	97	0.01	0.0	2.620	0.006	0	0	0	16
PD.6397	PL.42302	A	30T	7.23Y	120.4	0.00	4.55	20.50	0	143	38	97	0.00	0.0	2.620	0.006	0	0	0	16
PL.66261	PD.6397	A	#4 ACSR	7.23Y	120.4	0.03	4.58	20.50	16	143	38	97	0.03	0.0	2.653	0.033	3	1	1	16
PL.66262	PL.66261	A	#4 ACSR	7.22Y	120.4	0.02	4.60	20.00	15	140	37	97	0.02	0.0	2.682	0.029	18	5	2	15
PL.57584	PL.66262	A	#4 ACSR	7.22Y	120.4	0.01	4.61	6.22	5	43	11	97	0.00	0.0	2.723	0.041	31	8	3	5
PL.57585	PL.57584	A	#4 ACSR	7.22Y	120.4	0.00	4.61	0.00	0	0	0	100	0.00	0.0	2.764	0.041	0	0	0	0
PL.57583	PL.57584	A	#4 ACSR	7.22Y	120.4	0.00	4.61	1.80	1	13	3	97	0.00	0.0	2.761	0.038	13	3	2	2
PL.42304	PL.66262	A	#4 ACSR	7.22Y	120.4	0.04	4.64	11.18	9	78	21	97	0.02	0.0	2.767	0.085	15	4	1	8
PL.57600	PL.42304	A	#4 ACSR	7.22Y	120.4	0.00	4.64	0.56	0	4	1	97	0.00	0.0	2.815	0.049	4	1	1	1
PL.42305	PL.42304	A	#4 ACSR	7.22Y	120.3	0.02	4.66	8.52	7	60	16	97	0.01	0.0	2.821	0.054	28	7	3	6
PL.42306	PL.42305	A	#4 ACSR	7.22Y	120.3	0.02	4.68	4.51	3	31	8	97	0.00	0.0	2.941	0.120	9	2	1	3
PL.42307	PL.42306	A	#4 ACSR	7.22Y	120.3	0.00	4.68	3.24	2	23	6	97	0.00	0.0	3.003	0.062	23	6	2	2
PL.41787	PL.59356	ABC	336 MCM AC	7.22Y	120.4	0.05	4.60	170.47	33	3531	1093	96	0.96	0.0	2.654	0.039	0	0	0	499
PL.41788	PL.41787	ABC	336 MCM AC	7.22Y	120.4	0.04	4.64	170.47	33	3530	1091	96	0.84	0.0	2.688	0.034	3	1	2	499
PL.59345	PL.41788	ABC	336 MCM AC	7.22Y	120.3	0.04	4.68	170.35	33	3526	1089	96	0.71	0.0	2.717	0.029	15	4	3	497
PL.59346	PL.59345	ABC	336 MCM AC	7.22Y	120.3	0.05	4.74	169.64	33	3511	1083	96	1.01	0.0	2.759	0.042	0	0	0	494
PL.42221	PL.59346	ABC	336 MCM AC	7.21Y	120.2	0.04	4.77	169.64	33	3510	1081	96	0.73	0.0	2.789	0.030	0	0	0	494
PL.62809	PL.42221	ABC	336 MCM AC	7.20Y	120.1	0.16	4.93	169.64	33	3509	1079	96	2.97	0.1	2.912	0.122	1	0	1	494
PL.62812	PL.62809	B	#4 ACSR	7.20Y	120.1	0.00	4.94	14.36	11	100	26	97	0.00	0.0	2.915	0.004	0	0	0	14
PD.9451	PL.62812	B	40T	7.20Y	120.1	0.00	4.94	14.36	0	100	26	97	0.00	0.0	2.915	0.004	0	0	0	14
PL.58930	PD.9451	B	#4 ACSR	7.20Y	120.0	0.02	4.96	14.36	11	100	26	97	0.02	0.0	2.948	0.033	0	0	0	14
PL.64687	PL.58930	B	#4 ACSR	7.20Y	120.0	0.00	4.96	14.36	11	100	26	97	0.00	0.0	2.949	0.000	0	0	0	14
PL.64688	PL.64687	B	#4 ACSR	7.20Y	120.0	0.02	4.98	14.36	11	100	26	97	0.02	0.0	2.986	0.038	5	1	1	14
PL.41656	PL.64688	B	#4 ACSR	7.20Y	120.0	0.03	5.02	13.67	11	95	25	97	0.02	0.0	3.050	0.064	24	6	2	13
PL.42308	PL.41656	B	#4 ACSR	7.20Y	120.0	0.02	5.04	10.29	8	72	19	97	0.01	0.0	3.113	0.063	29	8	3	11
PL.42309	PL.42308	B	#4 ACSR	7.20Y	120.0	0.01	5.05	6.09	5	42	11	97	0.00	0.0	3.150	0.037	11	3	1	8
PL.42310	PL.42309	B	#4 ACSR	7.20Y	120.0	0.00	5.05	4.57	4	32	8	97	0.00	0.0	3.166	0.016	7	2	1	7
PL.42311	PL.42310	B	#4 ACSR	7.20Y	119.9	0.00	5.05	3.59	3	25	7	96	0.00	0.0	3.182	0.016	12	3	1	6
PL.42312	PL.42311	B	#4 ACSR	7.20Y	119.9	0.00	5.05	1.82	1	13	3	97	0.00	0.0	3.199	0.017	13	3	3	5
PL.42313	PL.42312	B	#4 ACSR	7.20Y	119.9	0.00	5.05	0.00	0	0	0	100	0.00	0.0	3.248	0.049	0	0	2	2

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.62811	PL.62809	ABC	336 MCM AC	7.20Y	120.0	0.08	5.01	164.80	32	3405	1045	96	1.40	0.0	2.973	0.061	0	0	0	479
PL.42315	PL.62811	A	6 A (CWC)	7.20Y	120.0	0.00	5.01	3.83	3	27	7	97	0.00	0.0	2.979	0.006	0	0	0	2
PD.6398	PL.42315	A	60QA	7.20Y	120.0	0.00	5.01	3.83	6	27	7	97	0.00	0.0	2.979	0.006	0	0	0	2
PL.59128	PD.6398	A	6 A (CWC)	7.20Y	120.0	0.01	5.02	3.83	3	27	7	97	0.00	0.0	3.013	0.035	0	0	0	2
PL.59129	PL.59128	A	6 A (CWC)	7.20Y	120.0	0.01	5.03	3.83	3	27	7	97	0.00	0.0	3.105	0.091	27	7	2	2
PL.42314	PL.62811	ABC	336 MCM AC	7.18Y	119.7	0.28	5.29	163.53	32	3377	1035	96	4.95	0.1	3.193	0.220	0	0	0	477
PL.42316	PL.42314	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	1.55	1	11	3	96	0.00	0.0	3.198	0.006	0	0	0	3
PD.6399	PL.42316	C	60QA	7.18Y	119.7	0.00	5.29	1.55	3	11	3	96	0.00	0.0	3.198	0.006	0	0	0	3
PL.42317	PD.6399	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	1.55	1	11	3	96	0.00	0.0	3.238	0.039	0	0	0	3
PL.41756	PL.42317	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	1.55	1	11	3	96	0.00	0.0	3.299	0.061	11	3	1	3
PL.41544	PL.41756	C	#4 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	3.351	0.052	0	0	0	0
PL.41466	PL.41756	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	3.345	0.046	0	0	1	1
PL.41394	PL.41756	C	6 A (CWC)	7.18Y	119.7	0.00	5.29	0.02	0	0	0	100	0.00	0.0	3.360	0.061	0	0	0	1
PL.64795	PL.41394	C	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.02	0	0	0	100	0.00	0.0	3.399	0.040	0	0	1	1
PL.41467	PL.42314	A	6 A (CWC)	7.18Y	119.7	0.01	5.30	32.52	23	226	60	97	0.01	0.0	3.198	0.006	0	0	0	30
PD.6791	PL.41467	A	50L	7.18Y	119.7	0.00	5.30	32.52	65	226	60	97	0.00	0.0	3.198	0.006	0	0	0	30
PL.56043	PD.6791	A	6 A (CWC)	7.17Y	119.6	0.13	5.43	32.52	23	226	60	97	0.22	0.1	3.293	0.095	25	7	3	30
PL.56044	PL.56043	A	6 A (CWC)	7.17Y	119.5	0.09	5.51	28.95	21	201	53	97	0.13	0.1	3.359	0.066	0	0	0	27
PL.56049	PL.56044	A	6 A (CWC)	7.17Y	119.4	0.06	5.58	19.08	14	132	35	97	0.06	0.0	3.434	0.075	14	4	2	20
PL.56050	PL.56049	A	6 A (CWC)	7.16Y	119.4	0.07	5.64	17.05	12	118	31	97	0.06	0.0	3.520	0.087	7	2	2	18
PL.41309	PL.56050	A	6 A (CWC)	7.16Y	119.4	0.00	5.64	0.97	1	7	2	96	0.00	0.0	3.581	0.060	7	2	1	1
PL.41471	PL.56050	A	6 A (CWC)	7.15Y	119.2	0.11	5.75	15.01	11	104	27	97	0.09	0.1	3.680	0.160	0	0	0	15
PL.41472	PL.41471	A	6 A (CWC)	7.15Y	119.2	0.03	5.78	11.63	8	80	21	97	0.02	0.0	3.742	0.062	5	1	1	11
PL.41473	PL.41472	A	6 A (CWC)	7.15Y	119.2	0.02	5.81	10.97	8	76	20	97	0.01	0.0	3.793	0.051	5	1	1	10
PL.61164	PL.41473	A	6 A (CWC)	7.15Y	119.2	0.01	5.82	10.25	7	71	19	97	0.01	0.0	3.833	0.040	28	7	3	9
PL.61165	PL.61164	A	6 A (CWC)	7.15Y	119.2	0.02	5.84	6.27	4	43	11	97	0.00	0.0	3.907	0.074	21	6	2	6
PL.41474	PL.61165	A	6 A (CWC)	7.15Y	119.2	0.01	5.84	3.22	2	22	6	96	0.00	0.0	3.976	0.069	21	6	3	4
PL.41475	PL.41474	A	6 A (CWC)	7.15Y	119.2	0.00	5.84	0.12	0	1	0	100	0.00	0.0	4.034	0.058	0	0	0	1
PL.41889	PL.41475	A	#2 ACSR	7.15Y	119.2	0.00	5.84	0.12	0	1	0	100	0.00	0.0	4.108	0.074	1	0	1	1
PL.41478	PL.41475	A	6 A (CWC)	7.15Y	119.2	0.00	5.84	0.00	0	0	0	100	0.00	0.0	4.084	0.050	0	0	0	0
PL.61163	PL.61164	A	6 A (CWC)	7.15Y	119.2	0.00	5.82	0.00	0	0	0	100	0.00	0.0	4.256	0.424	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41414	PL.41471	A	6 A (CWC)	7.15Y	119.2	0.01	5.76	3.38	2	23	6	97	0.00	0.0	3.761	0.080	23	6	4	4
PL.58915	PL.56044	A	6 A (CWC)	7.17Y	119.5	0.00	5.52	9.87	7	68	18	97	0.00	0.0	3.362	0.003	0	0	0	7
PD.8488	PL.58915	A	20T	7.17Y	119.5	0.00	5.52	9.87	0	68	18	97	0.00	0.0	3.362	0.003	0	0	0	7
PL.58916	PD.8488	A	6 A (CWC)	7.17Y	119.5	0.01	5.52	9.87	7	68	18	97	0.00	0.0	3.380	0.018	5	1	2	7
PL.56048	PL.58916	A	6 A (CWC)	7.17Y	119.4	0.03	5.56	9.16	7	64	17	97	0.01	0.0	3.473	0.093	20	5	2	5
PL.41468	PL.56048	A	6 A (CWC)	7.17Y	119.4	0.03	5.58	6.30	4	44	12	96	0.01	0.0	3.580	0.107	14	4	1	3
PL.41469	PL.41468	A	6 A (CWC)	7.16Y	119.4	0.00	5.59	4.34	3	30	8	97	0.00	0.0	3.607	0.027	30	8	2	2
PL.41470	PL.41469	A	6 A (CWC)	7.16Y	119.4	0.00	5.59	0.00	0	0	0	100	0.00	0.0	3.673	0.066	0	0	0	0
PL.56045	PL.42314	ABC	336 MCM AC	7.18Y	119.6	0.09	5.38	152.18	29	3135	961	96	1.48	0.0	3.269	0.076	14	4	1	444
PL.56046	PL.56045	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.275	0.006	0	0	0	0
PD.6607	PL.56046	C	60QA	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.275	0.006	0	0	0	0
PL.41340	PD.6607	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.327	0.053	0	0	0	0
PL.41341	PL.41340	C	#4 ACSR	7.18Y	119.6	0.00	5.38	0.00	0	0	0	100	0.00	0.0	3.399	0.071	0	0	0	0
PL.56047	PL.56045	ABC	336 MCM AC	7.17Y	119.6	0.06	5.44	151.06	29	3110	951	96	1.00	0.0	3.321	0.052	11	3	1	442
PL.41458	PL.56047	ABC	336 MCM AC	7.17Y	119.5	0.07	5.51	150.51	29	3098	946	96	1.20	0.0	3.384	0.063	6	2	1	441
PL.41459	PL.41458	C	6 A (CWC)	7.17Y	119.5	0.00	5.51	3.98	3	28	7	97	0.00	0.0	3.390	0.006	0	0	0	3
PD.6501	PL.41459	C	60QA	7.17Y	119.5	0.00	5.51	3.98	7	28	7	97	0.00	0.0	3.390	0.006	0	0	0	3
PL.41476	PD.6501	C	6 A (CWC)	7.17Y	119.5	0.01	5.52	3.98	3	28	7	97	0.00	0.0	3.432	0.042	10	3	1	3
PL.41859	PL.41476	C	6 A (CWC)	7.17Y	119.5	0.00	5.52	0.04	0	0	0	100	0.00	0.0	3.520	0.087	0	0	1	1
PL.41477	PL.41476	C	6 A (CWC)	7.17Y	119.5	0.01	5.52	2.56	2	18	5	96	0.00	0.0	3.526	0.093	18	5	1	1
PL.59398	PL.41458	ABC	336 MCM AC	7.16Y	119.3	0.22	5.73	148.88	29	3063	934	96	3.61	0.1	3.578	0.194	12	3	1	437
PL.59402	PL.59398	ABC	336 MCM AC	7.15Y	119.2	0.04	5.77	148.28	29	3047	922	96	0.59	0.0	3.610	0.032	0	0	0	436
PL.59404	PL.59402	C	#1/0 ACSR	7.15Y	119.2	0.00	5.77	0.06	0	0	0	100	0.00	0.0	3.667	0.057	0	0	1	1
PL.59403	PL.59402	ABC	336 MCM AC	7.15Y	119.1	0.15	5.91	148.27	29	3046	921	96	2.43	0.1	3.741	0.131	0	0	0	435
PL.59400	PL.59403	C	#4 ACSR	7.15Y	119.1	0.00	5.91	0.04	0	0	0	100	0.00	0.0	3.747	0.006	0	0	0	1
PD.6693	PL.59400	C	60QA	7.15Y	119.1	0.00	5.91	0.04	0	0	0	100	0.00	0.0	3.747	0.006	0	0	0	1
PL.41479	PD.6693	C	#4 ACSR	7.15Y	119.1	0.00	5.91	0.04	0	0	0	100	0.00	0.0	3.801	0.054	0	0	0	1
PL.41480	PL.41479	C	#4 ACSR	7.15Y	119.1	0.00	5.91	0.04	0	0	0	100	0.00	0.0	3.892	0.091	0	0	1	1
PL.59399	PL.59403	ABC	336 MCM AC	7.14Y	119.0	0.10	6.01	147.43	28	3026	910	96	1.57	0.1	3.827	0.086	0	0	0	433
PL.41819	PL.59399	ABC	336 MCM AC	7.13Y	118.9	0.07	6.08	147.43	28	3025	907	96	1.22	0.0	3.893	0.066	0	0	0	433
PL.41820	PL.41819	ABC	336 MCM AC	7.13Y	118.9	0.01	6.10	78.88	15	1608	515	95	0.12	0.0	3.917	0.024	0	0	0	264

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41368	PL.41820	ABC	#3/0 ACSR	7.13Y	118.9	0.01	6.11	78.88	26	1608	515	95	0.06	0.0	3.923	0.006	0	0	0	264
PD.6622	PL.41368	ABC	140VWE	7.13Y	118.9	0.00	6.11	78.88	38	1608	515	95	0.00	0.0	3.923	0.006	0	0	0	264
PL.41369	PD.6622	ABC	#3/0 ACSR	7.13Y	118.8	0.13	6.24	78.88	26	1608	515	95	1.33	0.1	4.050	0.128	0	0	0	264
PL.41482	PL.41369	ABC	#3/0 ACSR	7.12Y	118.6	0.16	6.39	76.45	25	1556	500	95	1.56	0.1	4.209	0.159	4	1	1	261
PL.54053	PL.41482	ABC	#3/0 ACSR	7.11Y	118.5	0.08	6.47	76.27	25	1551	496	95	0.76	0.0	4.289	0.079	33	9	2	260
PL.62010	PL.54053	ABC	#3/0 ACSR	7.11Y	118.5	0.03	6.50	73.99	25	1503	483	95	0.30	0.0	4.322	0.033	8	2	1	256
PL.62011	PL.62010	ABC	#3/0 ACSR	7.10Y	118.4	0.09	6.60	73.61	25	1495	480	95	0.89	0.1	4.419	0.098	0	0	0	255
PL.41483	PL.62011	C	6 A (CWC)	7.10Y	118.4	0.00	6.60	10.26	7	70	19	97	0.00	0.0	4.425	0.006	0	0	0	12
PD.6733	PL.41483	C	50QA	7.10Y	118.4	0.00	6.60	10.26	21	70	19	97	0.00	0.0	4.425	0.006	0	0	0	12
PL.41484	PD.6733	C	6 A (CWC)	7.10Y	118.4	0.03	6.63	10.26	7	70	19	97	0.02	0.0	4.494	0.070	0	0	0	12
PL.41601	PL.41484	C	6 A (CWC)	7.10Y	118.4	0.00	6.63	1.05	1	7	2	96	0.00	0.0	4.552	0.058	7	2	1	1
PL.41485	PL.41484	C	6 A (CWC)	7.10Y	118.3	0.03	6.66	9.21	7	63	17	97	0.01	0.0	4.578	0.083	10	3	1	11
PL.41486	PL.41485	C	6 A (CWC)	7.10Y	118.3	0.05	6.71	7.69	5	53	14	97	0.02	0.0	4.719	0.141	0	0	0	10
PL.41487	PL.41486	C	6 A (CWC)	7.10Y	118.3	0.03	6.75	6.03	4	41	11	97	0.01	0.0	4.832	0.113	0	0	0	8
PL.41518	PL.41487	C	6 A (CWC)	7.09Y	118.2	0.02	6.76	4.42	3	30	8	97	0.00	0.0	4.909	0.077	0	0	0	5
PL.41519	PL.41518	C	6 A (CWC)	7.09Y	118.2	0.01	6.77	4.42	3	30	8	97	0.00	0.0	4.947	0.039	0	0	0	5
PL.41520	PL.41519	C	6 A (CWC)	7.09Y	118.2	0.01	6.77	4.42	3	30	8	97	0.00	0.0	4.984	0.037	12	3	2	5
PL.59136	PL.41520	C	6 A (CWC)	7.09Y	118.2	0.00	6.78	2.61	2	18	5	96	0.00	0.0	5.046	0.062	18	5	2	3
PL.62045	PL.59136	C	6 A (CWC)	7.09Y	118.2	0.00	6.78	0.00	0	0	0	100	0.00	0.0	5.087	0.041	0	0	1	1
PL.41488	PL.41487	C	6 A (CWC)	7.09Y	118.2	0.01	6.75	1.60	1	11	3	96	0.00	0.0	4.911	0.080	0	0	0	3
PL.41489	PL.41488	C	#4 ACSR	7.09Y	118.2	0.00	6.76	1.60	1	11	3	96	0.00	0.0	4.972	0.061	0	0	0	3
PL.56041	PL.41489	C	#4 ACSR	7.09Y	118.2	0.00	6.76	1.60	1	11	3	96	0.00	0.0	5.022	0.050	11	3	2	3
PL.56042	PL.56041	C	#1/0 ACSR	7.09Y	118.2	0.00	6.76	0.01	0	0	0	100	0.00	0.0	5.080	0.057	0	0	0	1
PL.53836	PL.56042	C	#1/0 ACSR	7.09Y	118.2	0.00	6.76	0.01	0	0	0	100	0.00	0.0	5.104	0.024	0	0	0	1
PL.53784	PL.53836	C	#1/0 ACSR	7.09Y	118.2	0.00	6.76	0.01	0	0	0	100	0.00	0.0	5.148	0.044	0	0	1	1
PL.41757	PL.41488	C	6 A (CWC)	7.09Y	118.2	0.00	6.75	0.00	0	0	0	100	0.00	0.0	4.958	0.047	0	0	0	0
PL.41395	PL.41757	C	#4 ACSR	7.09Y	118.2	0.00	6.75	0.00	0	0	0	100	0.00	0.0	5.002	0.044	0	0	0	0
PL.41517	PL.41757	C	6 A (CWC)	7.09Y	118.2	0.00	6.75	0.00	0	0	0	100	0.00	0.0	5.007	0.049	0	0	0	0
PL.41460	PL.41486	C	6 A (CWC)	7.10Y	118.3	0.00	6.72	1.66	1	11	3	96	0.00	0.0	4.776	0.058	11	3	2	2
PL.41440	PL.62011	ABC	#3/0 ACSR	7.10Y	118.3	0.06	6.65	70.20	23	1423	460	95	0.51	0.0	4.481	0.062	0	0	0	243
PL.41522	PL.41440	A	#2 ACSR	7.10Y	118.3	0.00	6.66	5.92	3	41	11	97	0.00	0.0	4.487	0.006	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6692	PL.41522	A	50QA	7.10Y	118.3	0.00	6.66	5.92	12	41	11	97	0.00	0.0	4.487	0.006	0	0	0	4
PL.41523	PD.6692	A	#2 ACSR	7.10Y	118.3	0.02	6.67	5.92	3	41	11	97	0.00	0.0	4.572	0.085	0	0	0	4
PL.41524	PL.41523	A	#2 ACSR	7.10Y	118.3	0.01	6.68	5.92	3	41	11	97	0.00	0.0	4.645	0.073	0	0	0	4
PL.41593	PL.41524	A	#2 ACSR	7.10Y	118.3	0.00	6.68	0.00	0	0	0	100	0.00	0.0	4.684	0.039	0	0	0	0
PL.41525	PL.41524	A	#2 ACSR	7.10Y	118.3	0.02	6.70	5.92	3	41	11	97	0.00	0.0	4.774	0.129	20	5	1	4
PL.64796	PL.41525	A	#2 ACSR	7.10Y	118.3	0.00	6.71	2.96	2	20	5	97	0.00	0.0	4.801	0.027	0	0	0	3
PL.64797	PL.64796	A	#2 ACSR	7.10Y	118.3	0.00	6.71	2.96	2	20	5	97	0.00	0.0	4.801	0.000	14	4	1	3
PL.63534	PL.64797	A	#1/0 ACSR	7.10Y	118.3	0.00	6.71	0.86	0	6	2	95	0.00	0.0	4.810	0.008	0	0	0	2
PL.63535	PL.63534	A	#1/0 ACSR	7.10Y	118.3	0.00	6.71	0.86	0	6	2	95	0.00	0.0	4.853	0.044	6	2	2	2
PL.41521	PL.41440	A	#4 ACSR	7.10Y	118.3	0.00	6.65	0.00	0	0	0	100	0.00	0.0	4.487	0.006	0	0	0	0
PD.6484	PL.41521	A	50QA	7.10Y	118.3	0.00	6.65	0.00	0	0	0	100	0.00	0.0	4.487	0.006	0	0	0	0
PL.54052	PD.6484	A	#4 ACSR	7.10Y	118.3	0.00	6.65	0.00	0	0	0	100	0.00	0.0	4.541	0.054	0	0	0	0
PL.42180	PL.41440	ABC	#3/0 ACSR	7.10Y	118.3	0.03	6.69	68.23	23	1382	449	95	0.29	0.0	4.517	0.036	0	0	0	239
PL.62230	PL.42180	ABC	#3/0 ACSR	7.09Y	118.2	0.12	6.81	68.23	23	1382	449	95	1.04	0.1	4.651	0.133	0	0	0	239
REG60	PL.62230	ABC	114.3 KVA	7.51Y	125.2	-7.04	-0.24	68.23	45	1381	447	95	percent Boost= 5.62 Tap= 9.0						239	
PL.62231	REG60	ABC	#3/0 ACSR	7.50Y	125.0	0.27	0.03	64.15	21	1376	446	95	2.21	0.2	4.970	0.320	0	0	0	238
PL.42183	PL.62231	ABC	#3/0 ACSR	7.49Y	124.9	0.08	0.11	63.85	21	1367	441	95	0.65	0.0	5.065	0.094	0	0	0	236
PL.42184	PL.42183	A	#4 ACSR	7.49Y	124.9	0.00	0.11	2.85	2	21	5	97	0.00	0.0	5.070	0.006	0	0	0	2
PD.6485	PL.42184	A	50QA	7.49Y	124.9	0.00	0.11	2.85	6	21	5	97	0.00	0.0	5.070	0.006	0	0	0	2
PL.63232	PD.6485	A	#4 ACSR	7.49Y	124.9	0.01	0.12	2.85	2	21	5	97	0.00	0.0	5.139	0.068	0	0	0	2
PL.63233	PL.63232	A	#4 ACSR	7.49Y	124.9	0.00	0.12	2.85	2	21	5	97	0.00	0.0	5.169	0.031	3	1	1	2
PL.63234	PL.63233	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	2.42	1	18	5	96	0.00	0.0	5.173	0.004	0	0	0	1
PD.9474	PL.63234	A	20T	7.49Y	124.9	0.00	0.12	2.42	0	18	5	96	0.00	0.0	5.173	0.004	0	0	0	1
PL.63235	PD.9474	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	2.42	1	18	5	96	0.00	0.0	5.201	0.028	0	0	0	1
PL.63532	PL.63235	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	2.42	1	18	5	96	0.00	0.0	5.261	0.060	18	5	1	1
PL.63839	PL.42183	ABC	#3/0 ACSR	7.49Y	124.9	0.03	0.14	62.90	21	1346	434	95	0.28	0.0	5.107	0.042	0	0	0	234
PL.63840	PL.63839	ABC	#3/0 ACSR	7.49Y	124.9	0.00	0.14	62.90	21	1345	434	95	0.00	0.0	5.107	0.000	7	2	1	234
PL.62217	PL.63840	ABC	#3/0 ACSR	7.49Y	124.8	0.05	0.19	62.56	21	1338	432	95	0.36	0.0	5.162	0.056	5	1	1	233
PL.61156	PL.62217	ABC	#3/0 ACSR	7.48Y	124.7	0.07	0.26	62.35	21	1333	430	95	0.60	0.0	5.254	0.092	0	0	0	232
PD.9099-A	PL.61156	ABC	Closed	7.48Y	124.7	0.00	0.26	62.35	0	1332	429	95	0.00	0.0	5.254	0.092	0	0	0	232
PD.9099-B	PD.9099-A	ABC	Closed	7.48Y	124.7	0.00	0.26	62.35	0	1332	429	95	0.00	0.0	5.254	0.092	0	0	0	232

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

-----																				
Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
-----																				
PL.62017	PD.9099-B	ABC	#3/0 ACSR	7.48Y	124.7	0.02	0.28	62.35	21	1332	429	95	0.19	0.0	5.283	0.029	4	1	1	232
PL.62018	PL.62017	ABC	#3/0 ACSR	7.48Y	124.7	0.03	0.32	62.16	21	1328	428	95	0.25	0.0	5.321	0.038	9	2	1	231
PL.62019	PL.62018	ABC	#3/0 ACSR	7.48Y	124.6	0.04	0.35	61.74	21	1319	425	95	0.29	0.0	5.366	0.045	0	0	0	230
PL.62013	PL.62019	ABC	#3/0 ACSR	7.47Y	124.6	0.07	0.42	60.67	20	1295	419	95	0.52	0.0	5.450	0.084	0	0	0	226
PL.62806	PL.62013	ABC	#3/0 ACSR	7.46Y	124.3	0.25	0.67	54.01	18	1150	379	95	1.73	0.2	5.803	0.353	0	0	0	211
PL.62808	PL.62806	ABC	#3/0 ACSR	7.41Y	123.5	0.80	1.47	52.33	17	1112	367	95	5.36	0.5	6.969	1.166	0	0	0	205
PD.9450-A	PL.62808	ABC	Closed	7.41Y	123.5	0.00	1.47	52.33	0	1107	359	95	0.00	0.0	6.969	1.166	0	0	0	205
PD.9450-B	PD.9450-A	ABC	Closed	7.41Y	123.5	0.00	1.47	52.33	0	1107	359	95	0.00	0.0	6.969	1.166	0	0	0	205
PL.61157	PD.9450-B	ABC	#3/0 ACSR	7.36Y	122.7	0.87	2.34	52.33	17	1107	359	95	5.87	0.5	8.244	1.275	0	0	0	205
PD.9100-A	PL.61157	ABC	Closed	7.36Y	122.7	0.00	2.34	52.33	0	1101	351	95	0.00	0.0	8.244	1.275	0	0	0	205
PD.9100-B	PD.9100-A	ABC	Closed	7.36Y	122.7	0.00	2.34	52.33	0	1101	351	95	0.00	0.0	8.244	1.275	0	0	0	205
PL.61158	PD.9100-B	ABC	#3/0 ACSR	7.36Y	122.6	0.03	2.36	52.33	17	1101	351	95	0.17	0.0	8.281	0.037	0	0	0	205
PL.41681	PL.61158	ABC	#3/0 ACSR	7.36Y	122.6	0.01	2.37	52.33	17	1101	351	95	0.08	0.0	8.299	0.018	0	0	0	205
PL.59323	PL.41681	ABC	#3/0 ACSR	7.36Y	122.6	0.00	2.38	52.33	17	1101	351	95	0.01	0.0	8.302	0.003	0	0	0	205
RG.58	PL.59323	ABC	76.2 KVA	7.45Y	124.2	-1.55	0.82	52.33	52	1100	351	95	percent Boost= 1.25 Tap= 2.0							205
PL.59324	RG.58	ABC	#3/0 ACSR	7.40Y	123.4	0.82	1.65	51.67	17	1100	351	95	5.49	0.5	9.527	1.224	0	0	0	205
PL.52803	PL.59324	ABC	#3/0 ACSR	7.38Y	123.0	0.40	2.05	51.67	17	1095	343	95	2.69	0.2	10.133	0.606	16	4	1	205
PL.52804	PL.52803	ABC	#3/0 ACSR	7.37Y	122.9	0.04	2.09	50.94	17	1077	335	95	0.28	0.0	10.197	0.064	7	2	1	204
PL.41900	PL.52804	C	6 A (CWC)	7.37Y	122.9	0.00	2.09	1.03	1	7	2	96	0.00	0.0	10.279	0.082	7	2	1	1
PL.41901	PL.41900	C	6 A (CWC)	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	10.327	0.049	0	0	0	0
PL.41903	PL.41901	C	1/0 AL URD	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	10.333	0.006	0	0	0	0
PD.6457	PL.41903	C	50QA	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	10.333	0.006	0	0	0	0
PL.59309	PD.6457	C	1/0 AL URD	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	10.371	0.038	0	0	0	0
PL.41902	PL.41901	C	6 A (CWC)	7.37Y	122.9	0.00	2.09	0.00	0	0	0	100	0.00	0.0	10.433	0.105	0	0	0	0
PL.41402	PL.52804	ABC	#3/0 ACSR	7.37Y	122.9	0.05	2.14	50.26	17	1062	330	95	0.36	0.0	10.281	0.084	0	0	0	202
PL.42004	PL.41402	ABC	#1/0 ACSR	7.37Y	122.8	0.06	2.21	49.49	22	1045	325	95	0.43	0.0	10.349	0.068	34	9	2	197
PL.42005	PL.42004	ABC	#1/0 ACSR	7.37Y	122.8	0.04	2.25	47.89	21	1010	316	95	0.30	0.0	10.399	0.050	3	1	1	195
PL.42006	PL.42005	ABC	#1/0 ACSR	7.36Y	122.7	0.06	2.31	47.75	21	1007	315	95	0.43	0.0	10.470	0.071	0	0	0	194
PL.41420	PL.42006	ABC	#1/0 ACSR	7.36Y	122.6	0.09	2.40	47.23	21	995	312	95	0.61	0.1	10.573	0.102	5	1	1	192
PL.41421	PL.41420	ABC	#1/0 ACSR	7.35Y	122.6	0.03	2.43	46.97	20	989	310	95	0.24	0.0	10.613	0.040	6	2	1	191
PL.42250	PL.41421	ABC	#1/0 ACSR	7.35Y	122.5	0.04	2.48	28.03	12	597	160	97	0.18	0.0	10.698	0.085	7	2	2	170

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42251	PL.42250	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.48	27.68	12	590	158	97	0.03	0.0	10.713	0.016	0	0	0	168
PL.42328	PL.42251	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	27.68	12	590	158	97	0.01	0.0	10.719	0.006	0	0	0	168
PD.6800	PL.42328	ABC	50H	7.35Y	122.5	0.00	2.49	27.68	55	590	158	97	0.00	0.0	10.719	0.006	0	0	0	168
PL.42329	PD.6800	ABC	#1/0 ACSR	7.35Y	122.5	0.04	2.53	27.68	12	590	158	97	0.16	0.0	10.796	0.077	4	1	1	168
PL.42330	PL.42329	C	#4 ACSR	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	10.802	0.006	0	0	0	0
PD.6488	PL.42330	C	40QA	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	10.802	0.006	0	0	0	0
PL.42331	PD.6488	C	#4 ACSR	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	10.821	0.019	0	0	0	0
PL.42332	PL.42329	C	6 A (CWC)	7.35Y	122.4	0.05	2.58	6.64	5	47	12	97	0.02	0.0	10.985	0.189	8	2	1	6
PL.42333	PL.42332	C	6 A (CWC)	7.34Y	122.4	0.01	2.59	5.48	4	39	10	97	0.00	0.0	11.026	0.041	0	0	0	5
PL.42334	PL.42333	C	6 A (CWC)	7.34Y	122.4	0.01	2.60	5.48	4	39	10	97	0.00	0.0	11.087	0.061	12	3	1	5
PL.42335	PL.42334	C	6 A (CWC)	7.34Y	122.4	0.01	2.61	3.74	3	27	7	97	0.00	0.0	11.159	0.073	15	4	2	4
PL.42336	PL.42335	C	6 A (CWC)	7.34Y	122.4	0.01	2.62	1.64	1	12	3	97	0.00	0.0	11.320	0.161	12	3	2	2
PL.42337	PL.42329	ABC	#1/0 ACSR	7.35Y	122.4	0.03	2.56	25.27	11	538	144	97	0.13	0.0	10.870	0.074	0	0	0	161
PL.41736	PL.42337	A	#1/0 ACSR	7.35Y	122.4	0.00	2.56	0.00	0	0	0	100	0.00	0.0	10.944	0.074	0	0	1	1
PL.42338	PL.42337	ABC	#1/0 ACSR	7.35Y	122.4	0.01	2.57	25.27	11	538	144	97	0.05	0.0	10.899	0.029	2	0	1	160
PL.42339	PL.42338	ABC	#1/0 ACSR	7.34Y	122.4	0.02	2.60	25.19	11	536	143	97	0.09	0.0	10.951	0.052	17	4	4	159
PL.42340	PL.42339	ABC	#1/0 ACSR	7.34Y	122.4	0.04	2.63	24.39	11	519	139	97	0.14	0.0	11.042	0.091	15	4	2	155
PL.42341	PL.42340	ABC	#1/0 ACSR	7.34Y	122.3	0.04	2.68	23.66	10	504	135	97	0.16	0.0	11.148	0.105	6	2	1	152
PL.42345	PL.42341	ABC	#1/0 ACSR	7.34Y	122.3	0.03	2.71	22.64	10	481	129	97	0.09	0.0	11.216	0.068	8	2	2	149
PL.42346	PL.42345	C	6 A (CWC)	7.34Y	122.3	0.00	2.71	4.12	3	29	8	96	0.00	0.0	11.222	0.006	0	0	0	5
PD.6736	PL.42346	C	40QA	7.34Y	122.3	0.00	2.71	4.12	10	29	8	96	0.00	0.0	11.222	0.006	0	0	0	5
PL.42347	PD.6736	C	6 A (CWC)	7.34Y	122.3	0.01	2.72	4.12	3	29	8	96	0.00	0.0	11.309	0.087	18	5	3	5
PL.42348	PL.42347	C	6 A (CWC)	7.34Y	122.3	0.00	2.72	1.53	1	11	3	96	0.00	0.0	11.333	0.024	0	0	0	2
PL.42349	PL.42348	C	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.53	0	4	1	97	0.00	0.0	11.384	0.051	4	1	1	1
PL.41371	PL.42348	C	#2 ACSR	7.34Y	122.3	0.00	2.72	1.00	1	7	2	96	0.00	0.0	11.438	0.105	7	2	1	1
PL.42350	PL.42345	ABC	#1/0 ACSR	7.33Y	122.2	0.05	2.76	20.86	9	444	119	97	0.16	0.0	11.354	0.138	8	2	2	142
PL.42351	PL.42350	ABC	#1/0 ACSR	7.33Y	122.2	0.02	2.78	20.47	9	435	116	97	0.05	0.0	11.402	0.049	0	0	1	140
PL.42352	PL.42351	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.79	20.46	9	435	116	97	0.03	0.0	11.433	0.031	5	1	1	139
PL.66265	PL.42352	C	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.66	0	5	1	98	0.00	0.0	11.513	0.080	0	0	0	2
PL.66266	PL.66265	C	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.66	0	5	1	98	0.00	0.0	11.513	0.000	5	1	2	2
PL.42355	PL.66266	C	6 A (CWC)	7.33Y	122.2	0.00	2.79	0.00	0	0	0	100	0.00	0.0	11.570	0.057	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42353	PL.42352	ABC	#1/0 ACSR	7.33Y	122.1	0.07	2.86	19.73	9	419	112	97	0.21	0.0	11.639	0.206	11	3	1	134
PL.42367	PL.42353	ABC	#1/0 ACSR	7.32Y	122.1	0.06	2.92	18.59	8	395	105	97	0.17	0.0	11.825	0.186	1	0	2	131
PL.42368	PL.42367	ABC	#1/0 ACSR	7.32Y	122.1	0.03	2.95	18.54	8	394	105	97	0.08	0.0	11.911	0.086	7	2	1	129
PL.42369	PL.42368	ABC	#1/0 ACSR	7.32Y	122.0	0.03	2.98	18.19	8	386	103	97	0.07	0.0	11.991	0.081	0	0	1	128
PL.42370	PL.42369	ABC	#1/0 ACSR	7.32Y	122.0	0.02	2.99	18.18	8	386	103	97	0.05	0.0	12.050	0.058	9	2	1	127
PL.42371	PL.42370	ABC	#1/0 ACSR	7.32Y	122.0	0.02	3.01	17.78	8	377	101	97	0.04	0.0	12.103	0.053	2	1	1	126
PL.42372	PL.42371	ABC	#1/0 ACSR	7.32Y	122.0	0.02	3.03	17.67	8	375	100	97	0.05	0.0	12.164	0.061	0	0	0	125
PL.42374	PL.42372	ABC	#1/0 ACSR	7.32Y	121.9	0.03	3.06	16.62	7	353	94	97	0.08	0.0	12.272	0.108	9	2	1	122
PL.66273	PL.42374	C	#1/0 ACSR	7.32Y	121.9	0.00	3.06	0.68	0	5	1	98	0.00	0.0	12.274	0.002	0	0	0	1
PD.10009	PL.66273	C	20T	7.32Y	121.9	0.00	3.06	0.68	0	5	1	98	0.00	0.0	12.274	0.002	0	0	0	1
PL.66274	PD.10009	C	#1/0 ACSR	7.32Y	121.9	0.00	3.06	0.68	0	5	1	98	0.00	0.0	12.344	0.070	5	1	1	1
PL.66270	PL.42374	ABC	#1/0 ACSR	7.32Y	121.9	0.00	3.06	15.98	7	339	90	97	0.00	0.0	12.272	0.000	0	0	0	120
PL.66271	PL.66270	ABC	#1/0 ACSR	7.32Y	121.9	0.01	3.07	15.98	7	339	90	97	0.03	0.0	12.315	0.043	12	3	1	120
PL.42380	PL.66271	ABC	#1/0 ACSR	7.31Y	121.9	0.02	3.09	14.80	6	314	84	97	0.04	0.0	12.386	0.071	9	2	1	111
PL.42381	PL.42380	C	6 A (CWC)	7.31Y	121.9	0.00	3.09	1.06	1	8	2	97	0.00	0.0	12.391	0.006	0	0	0	3
PD.6474	PL.42381	C	40QA	7.31Y	121.9	0.00	3.09	1.06	3	8	2	97	0.00	0.0	12.391	0.006	0	0	0	3
PL.61153	PD.6474	C	6 A (CWC)	7.31Y	121.9	0.00	3.09	1.06	1	8	2	97	0.00	0.0	12.405	0.014	6	2	1	3
PL.61154	PL.61153	C	6 A (CWC)	7.31Y	121.9	0.00	3.09	0.16	0	1	0	100	0.00	0.0	12.631	0.226	1	0	2	2
PL.42382	PL.61154	C	6 A (CWC)	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	12.684	0.053	0	0	0	0
PL.42383	PL.42382	C	6 A (CWC)	7.31Y	121.9	0.00	3.09	0.00	0	0	0	100	0.00	0.0	12.751	0.067	0	0	0	0
PL.41589	PL.42380	ABC	#1/0 ACSR	7.31Y	121.9	0.02	3.11	14.00	6	297	79	97	0.03	0.0	12.452	0.066	0	0	0	107
PL.41338	PL.41589	A	6 A (CWC)	7.31Y	121.9	0.00	3.11	1.72	1	12	3	97	0.00	0.0	12.458	0.006	0	0	0	2
PD.6475	PL.41338	A	40QA	7.31Y	121.9	0.00	3.11	1.72	4	12	3	97	0.00	0.0	12.458	0.006	0	0	0	2
PL.41339	PD.6475	A	6 A (CWC)	7.31Y	121.9	0.00	3.11	1.72	1	12	3	97	0.00	0.0	12.489	0.032	12	3	2	2
PL.56455	PL.41589	ABC	#1/0 ACSR	7.31Y	121.9	0.01	3.12	13.43	6	285	76	97	0.02	0.0	12.487	0.035	14	4	1	105
PL.57100	PL.56455	ABC	#1/0 ACSR	7.31Y	121.9	0.02	3.14	12.78	6	271	72	97	0.05	0.0	12.597	0.110	7	2	1	104
PL.57101	PL.57100	C	#4 ACSR	7.31Y	121.9	0.00	3.14	0.74	1	5	1	98	0.00	0.0	12.603	0.006	0	0	0	2
PD.8332	PL.57101	C	40QA	7.31Y	121.9	0.00	3.14	0.74	2	5	1	98	0.00	0.0	12.603	0.006	0	0	0	2
PL.57102	PD.8332	C	#4 ACSR	7.31Y	121.9	0.00	3.14	0.74	1	5	1	98	0.00	0.0	12.692	0.089	5	1	2	2
PL.61147	PL.57100	ABC	#1/0 ACSR	7.31Y	121.8	0.02	3.17	12.18	5	258	69	97	0.04	0.0	12.707	0.109	13	3	2	101
PL.61148	PL.61147	C	#4 ACSR	7.31Y	121.8	0.00	3.17	11.49	9	81	21	97	0.00	0.0	12.713	0.006	0	0	0	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6476	PL.61148	C	40QA	7.31Y	121.8	0.00	3.17	11.49	29	81	21	97	0.00	0.0	12.713	0.006	0	0	0	25
PL.59385	PD.6476	C	#4 ACSR	7.31Y	121.8	0.04	3.21	11.49	9	81	21	97	0.02	0.0	12.788	0.075	6	2	2	25
PL.59386	PL.59385	C	#4 ACSR	7.31Y	121.8	0.03	3.24	10.68	8	75	20	97	0.02	0.0	12.854	0.065	4	1	1	23
PL.59388	PL.59386	C	#4 ACSR	7.31Y	121.8	0.00	3.24	0.38	0	3	1	95	0.00	0.0	12.907	0.053	3	1	1	1
PL.59387	PL.59386	C	#4 ACSR	7.31Y	121.8	0.01	3.25	9.74	7	69	18	97	0.01	0.0	12.883	0.029	0	0	2	21
PL.41602	PL.59387	C	#4 ACSR	7.30Y	121.7	0.02	3.26	9.70	7	69	18	97	0.01	0.0	12.919	0.036	0	0	1	19
PL.62244	PL.41602	C	#4 ACSR	7.30Y	121.7	0.03	3.29	7.80	6	55	15	96	0.01	0.0	13.011	0.092	7	2	3	13
PL.62245	PL.62244	C	#4 ACSR	7.30Y	121.7	0.00	3.30	1.29	1	9	2	98	0.00	0.0	13.079	0.068	1	0	1	3
PL.42215	PL.62245	C	#4 ACSR	7.30Y	121.7	0.00	3.30	1.21	1	9	2	98	0.00	0.0	13.126	0.047	8	2	1	2
PL.41588	PL.42215	C	#4 ACSR	7.30Y	121.7	0.00	3.30	0.00	0	0	0	100	0.00	0.0	13.169	0.043	0	0	0	0
PL.42216	PL.42215	C	#4 ACSR	7.30Y	121.7	0.00	3.30	0.12	0	1	0	100	0.00	0.0	13.171	0.045	1	0	1	1
PL.62246	PL.62244	C	#4 ACSR	7.30Y	121.7	0.01	3.30	5.46	4	39	10	97	0.00	0.0	13.053	0.042	0	0	0	7
PL.41388	PL.62246	C	#2 ACSR	7.30Y	121.7	0.01	3.31	3.76	2	27	7	97	0.00	0.0	13.200	0.147	27	7	2	2
PL.42217	PL.62246	C	#4 ACSR	7.30Y	121.7	0.00	3.31	1.71	1	12	3	97	0.00	0.0	13.089	0.036	1	0	1	5
PL.42356	PL.42217	C	#4 ACSR	7.30Y	121.7	0.00	3.31	1.63	1	12	3	97	0.00	0.0	13.111	0.021	0	0	0	4
PL.41782	PL.42356	C	#4 ACSR	7.30Y	121.7	0.00	3.31	1.09	1	8	2	97	0.00	0.0	13.140	0.029	8	2	1	1
PL.42357	PL.42356	C	#4 ACSR	7.30Y	121.7	0.00	3.31	0.54	0	4	1	97	0.00	0.0	13.165	0.055	0	0	0	3
PL.42358	PL.42357	C	#4 ACSR	7.30Y	121.7	0.00	3.31	0.54	0	4	1	97	0.00	0.0	13.217	0.051	4	1	2	3
PL.42359	PL.42358	C	#4 ACSR	7.30Y	121.7	0.00	3.31	0.00	0	0	0	100	0.00	0.0	13.254	0.038	0	0	1	1
PL.41576	PL.41602	C	#4 ACSR	7.30Y	121.7	0.00	3.27	1.73	1	12	3	97	0.00	0.0	12.955	0.037	12	3	2	2
PL.41603	PL.41602	C	#4 ACSR	7.30Y	121.7	0.00	3.26	0.16	0	1	0	100	0.00	0.0	12.924	0.006	0	0	0	3
PD.6588	PL.41603	C	25QA	7.30Y	121.7	0.00	3.26	0.16	1	1	0	100	0.00	0.0	12.924	0.006	0	0	0	3
PL.41604	PD.6588	C	#4 ACSR	7.30Y	121.7	0.00	3.26	0.16	0	1	0	100	0.00	0.0	12.956	0.032	1	0	3	3
PL.64088	PL.59385	C	#1/0 ACSR	7.31Y	121.8	0.00	3.21	0.00	0	0	0	100	0.00	0.0	12.822	0.033	0	0	0	0
PL.61151	PL.61147	C	6 A (CWC)	7.31Y	121.8	0.02	3.18	23.21	17	164	44	97	0.02	0.0	12.722	0.016	0	0	0	74
PD.9098	PL.61151	C	35L	7.31Y	121.8	0.00	3.18	23.21	66	164	44	97	0.00	0.0	12.722	0.016	0	0	0	74
PL.61152	PD.9098	C	6 A (CWC)	7.30Y	121.7	0.10	3.28	23.21	17	164	44	97	0.12	0.1	12.819	0.097	7	2	1	74
PL.61149	PL.61152	C	6 A (CWC)	7.29Y	121.6	0.14	3.43	22.20	16	157	42	97	0.17	0.1	12.961	0.142	0	0	0	73
PL.41281	PL.61149	C	6 A (CWC)	7.29Y	121.5	0.08	3.51	20.28	14	143	38	97	0.09	0.1	13.050	0.089	0	0	0	71
PL.42218	PL.41281	C	6 A (CWC)	7.27Y	121.1	0.37	3.88	18.65	13	131	35	97	0.37	0.3	13.483	0.433	0	0	0	69
PL.41800	PL.42218	C	6 A (CWC)	7.26Y	121.0	0.09	3.97	18.05	13	127	34	97	0.08	0.1	13.590	0.106	2	1	1	68

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41801	PL.41800	C	6 A (CWC)	7.26Y	120.9	0.11	4.08	17.77	13	125	33	97	0.11	0.1	13.727	0.138	0	0	0	67
PL.41575	PL.41801	C	#4 ACSR	7.26Y	120.9	0.00	4.08	0.06	0	0	0	100	0.00	0.0	13.767	0.040	0	0	2	2
PL.42384	PL.41801	C	6 A (CWC)	7.25Y	120.9	0.07	4.15	17.71	13	124	33	97	0.07	0.1	13.817	0.089	0	0	0	65
PL.42385	PL.42384	C	6 A (CWC)	7.24Y	120.7	0.14	4.29	17.71	13	124	33	97	0.14	0.1	13.995	0.178	0	0	0	65
PL.41390	PL.42385	C	#4 ACSR	7.24Y	120.7	0.01	4.30	1.24	1	9	2	98	0.00	0.0	14.323	0.328	9	2	4	4
PL.42388	PL.42385	C	6 A (CWC)	7.22Y	120.3	0.46	4.75	16.47	12	115	31	97	0.40	0.3	14.604	0.609	0	0	1	61
PL.42389	PL.42388	C	6 A (CWC)	7.21Y	120.2	0.06	4.81	16.40	12	114	30	97	0.05	0.0	14.699	0.095	20	5	2	60
PL.61135	PL.42389	C	6 A (CWC)	7.21Y	120.1	0.07	4.88	13.48	10	94	25	97	0.05	0.0	14.805	0.106	1	0	1	58
PL.61138	PL.61135	C	6 A (CWC)	7.21Y	120.1	0.01	4.89	13.37	10	93	25	97	0.01	0.0	14.829	0.024	10	3	1	57
PL.61139	PL.61138	C	6 A (CWC)	7.21Y	120.1	0.02	4.91	12.00	9	84	22	97	0.01	0.0	14.864	0.034	1	0	1	56
PL.61136	PL.61139	C	6 A (CWC)	7.20Y	120.1	0.02	4.93	8.70	6	61	16	97	0.01	0.0	14.908	0.044	8	2	2	51
PL.42390	PL.61136	C	6 A (CWC)	7.20Y	120.0	0.05	4.98	7.49	5	52	14	97	0.02	0.0	15.051	0.143	0	0	0	49
PL.42391	PL.42390	C	6 A (CWC)	7.20Y	120.0	0.02	4.99	6.76	5	47	12	97	0.01	0.0	15.111	0.060	3	1	1	48
PL.41389	PL.42391	C	6 A (CWC)	7.20Y	120.0	0.02	5.02	6.32	5	44	12	96	0.01	0.0	15.196	0.085	0	0	1	47
PL.41774	PL.41389	C	6 A (CWC)	7.20Y	120.0	0.02	5.04	6.32	5	44	12	96	0.01	0.0	15.257	0.061	0	0	0	46
PL.42400	PL.41774	C	6 A (CWC)	7.20Y	119.9	0.01	5.05	4.46	3	31	8	97	0.00	0.0	15.342	0.085	12	3	3	44
PL.42401	PL.42400	C	6 A (CWC)	7.20Y	119.9	0.01	5.06	2.76	2	19	5	97	0.00	0.0	15.408	0.066	0	0	0	41
PL.42402	PL.42401	C	6 A (CWC)	7.20Y	119.9	0.01	5.07	2.76	2	19	5	97	0.00	0.0	15.468	0.060	0	0	0	41
PL.42405	PL.42402	C	6 A (CWC)	7.20Y	119.9	0.01	5.08	2.76	2	19	5	97	0.00	0.0	15.544	0.075	0	0	0	41
PL.54137	PL.42405	C	6 A (CWC)	7.19Y	119.9	0.01	5.09	2.76	2	19	5	97	0.00	0.0	15.657	0.113	0	0	0	41
PL.58554	PL.54137	C	6 A (CWC)	7.19Y	119.9	0.00	5.09	0.94	1	7	2	96	0.00	0.0	15.659	0.002	0	0	0	25
PD.8618	PL.58554	C	25T	7.19Y	119.9	0.00	5.09	0.94	0	7	2	96	0.00	0.0	15.659	0.002	0	0	0	25
PL.58555	PD.8618	C	6 A (CWC)	7.19Y	119.9	0.04	5.13	0.94	1	7	2	96	0.00	0.0	16.553	0.894	1	0	3	25
PL.54138	PL.58555	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.83	1	6	2	95	0.00	0.0	16.588	0.035	1	0	3	22
PL.42411	PL.54138	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.76	1	5	1	98	0.00	0.0	16.648	0.059	2	0	3	19
PL.41725	PL.42411	C	#4 ACSR	7.19Y	119.9	0.00	5.13	0.05	0	0	0	100	0.00	0.0	16.759	0.111	0	0	1	1
PL.42412	PL.42411	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.47	0	3	1	95	0.00	0.0	16.682	0.034	1	0	3	15
PL.42413	PL.42412	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.26	0	2	0	100	0.00	0.0	16.704	0.022	0	0	3	12
PL.42414	PL.42413	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.26	0	2	0	100	0.00	0.0	16.742	0.038	1	0	2	9
PL.42415	PL.42414	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.10	0	1	0	100	0.00	0.0	16.795	0.053	0	0	3	7
PL.42416	PL.42415	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.06	0	0	0	100	0.00	0.0	16.842	0.047	0	0	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42417	PL.42416	C	6 A (CWC)	7.19Y	119.9	0.00	5.13	0.06	0	0	0	100	0.00	0.0	16.949	0.107	0	0	1	3
PL.42418	PL.42417	C	#2 ACSR	7.19Y	119.9	0.00	5.13	0.06	0	0	0	100	0.00	0.0	16.974	0.025	0	0	1	2
PL.58845	PL.42418	C	#2 ACSR	7.19Y	119.9	0.00	5.13	0.05	0	0	0	100	0.00	0.0	17.007	0.033	0	0	1	1
PL.58552	PL.54137	C	6 A (CWC)	7.19Y	119.9	0.00	5.09	1.82	1	13	3	97	0.00	0.0	15.660	0.003	0	0	0	16
PD.8617	PL.58552	C	25QA	7.19Y	119.9	0.00	5.09	1.82	7	13	3	97	0.00	0.0	15.660	0.003	0	0	0	16
PL.58553	PD.8617	C	6 A (CWC)	7.19Y	119.9	0.02	5.11	1.82	1	13	3	97	0.00	0.0	15.993	0.334	5	1	2	16
PL.58551	PL.58553	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.02	0	0	0	100	0.00	0.0	16.110	0.117	0	0	2	5
PL.42409	PL.58551	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.306	0.196	0	0	0	3
PL.42407	PL.42409	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.348	0.042	0	0	0	0
PL.61155	PL.42407	C	#1/0 ACSR	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.377	0.028	0	0	0	0
PL.42408	PL.42407	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.509	0.161	0	0	0	0
PL.42410	PL.42409	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.345	0.039	0	0	3	3
PL.63838	PL.42410	C	6 A (CWC)	7.19Y	119.9	0.00	5.11	0.00	0	0	0	100	0.00	0.0	16.384	0.039	0	0	0	0
PL.58550	PL.58553	C	6 A (CWC)	7.19Y	119.9	0.01	5.12	1.04	1	7	2	96	0.00	0.0	16.251	0.258	2	1	1	9
PL.41551	PL.58550	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.65	0	5	1	98	0.00	0.0	16.315	0.064	5	1	4	4
PL.42406	PL.58550	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.10	0	1	0	100	0.00	0.0	16.344	0.092	0	0	1	4
PL.56928	PL.42406	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.10	0	1	0	100	0.00	0.0	16.423	0.079	1	0	1	3
PL.56929	PL.56928	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.02	0	0	0	100	0.00	0.0	16.492	0.069	0	0	2	2
PL.42403	PL.42402	C	#4 ACSR	7.20Y	119.9	0.00	5.07	0.00	0	0	0	100	0.00	0.0	15.533	0.064	0	0	0	0
PL.42404	PL.42403	C	#4 ACSR	7.20Y	119.9	0.00	5.07	0.00	0	0	0	100	0.00	0.0	15.574	0.041	0	0	0	0
PL.41607	PL.42401	C	6 A (CWC)	7.20Y	119.9	0.00	5.06	0.00	0	0	0	100	0.00	0.0	15.520	0.112	0	0	0	0
PL.41775	PL.41774	C	6 A (CWC)	7.20Y	120.0	0.01	5.05	1.86	1	13	3	97	0.00	0.0	15.354	0.097	0	0	0	2
PL.41043	PL.41775	C	#4 ACSR	7.20Y	120.0	0.00	5.05	1.04	1	7	2	96	0.00	0.0	15.399	0.045	7	2	1	1
PL.41829	PL.41775	C	6 A (CWC)	7.20Y	120.0	0.00	5.05	0.82	1	6	2	95	0.00	0.0	15.412	0.058	0	0	0	1
PL.42396	PL.41829	C	6 A (CWC)	7.20Y	120.0	0.00	5.05	0.82	1	6	2	95	0.00	0.0	15.433	0.021	0	0	0	1
PL.42397	PL.42396	C	6 A (CWC)	7.20Y	119.9	0.00	5.05	0.82	1	6	2	95	0.00	0.0	15.493	0.060	0	0	0	1
PL.42398	PL.42397	C	6 A (CWC)	7.20Y	119.9	0.00	5.05	0.82	1	6	2	95	0.00	0.0	15.527	0.034	0	0	0	1
PL.42399	PL.42398	C	6 A (CWC)	7.20Y	119.9	0.00	5.05	0.82	1	6	2	95	0.00	0.0	15.560	0.034	6	2	1	1
PL.42386	PL.41829	C	#4 ACSR	7.20Y	120.0	0.00	5.05	0.00	0	0	0	100	0.00	0.0	15.457	0.045	0	0	0	0
PL.42387	PL.42386	C	#4 ACSR	7.20Y	120.0	0.00	5.05	0.00	0	0	0	100	0.00	0.0	15.502	0.045	0	0	0	0
PL.41350	PL.42390	C	#4 ACSR	7.20Y	120.0	0.00	4.98	0.73	1	5	1	98	0.00	0.0	15.114	0.063	5	1	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.61137	PL.61139	C	6 A (CWC)	7.20Y	120.1	0.01	4.92	3.17	2	22	6	96	0.00	0.0	14.972	0.108	13	3	2	4
PL.42392	PL.61137	C	6 A (CWC)	7.20Y	120.1	0.00	4.92	1.38	1	10	3	96	0.00	0.0	14.986	0.014	0	0	0	2
PL.41312	PL.42392	C	#4 ACSR	7.20Y	120.1	0.00	4.92	0.00	0	0	0	100	0.00	0.0	15.148	0.163	0	0	0	0
PL.42393	PL.42392	C	6 A (CWC)	7.20Y	120.1	0.00	4.93	1.38	1	10	3	96	0.00	0.0	15.062	0.076	0	0	0	2
PL.42394	PL.42393	C	6 A (CWC)	7.20Y	120.1	0.00	4.93	1.38	1	10	3	96	0.00	0.0	15.130	0.068	9	2	1	2
PL.42395	PL.42394	C	6 A (CWC)	7.20Y	120.1	0.00	4.93	0.02	0	0	0	100	0.00	0.0	15.278	0.148	0	0	1	1
PL.41798	PL.42218	C	#4 ACSR	7.27Y	121.1	0.00	3.88	0.60	0	4	1	97	0.00	0.0	13.521	0.038	4	1	1	1
PL.41799	PL.41798	C	#4 ACSR	7.27Y	121.1	0.00	3.88	0.00	0	0	0	100	0.00	0.0	13.593	0.072	0	0	0	0
PL.41282	PL.41281	C	#4 ACSR	7.29Y	121.5	0.00	3.51	1.64	1	12	3	97	0.00	0.0	13.107	0.057	7	2	1	2
PL.41283	PL.41282	C	#4 ACSR	7.29Y	121.5	0.00	3.51	0.69	1	5	1	98	0.00	0.0	13.138	0.032	0	0	0	1
PL.41284	PL.41283	C	#4 ACSR	7.29Y	121.5	0.00	3.52	0.69	1	5	1	98	0.00	0.0	13.286	0.148	0	0	0	1
PL.41285	PL.41284	C	#4 ACSR	7.29Y	121.5	0.00	3.52	0.69	1	5	1	98	0.00	0.0	13.371	0.085	5	1	1	1
PL.41730	PL.61149	C	6 A (CWC)	7.29Y	121.6	0.00	3.43	1.91	1	13	4	96	0.00	0.0	12.999	0.038	0	0	0	2
PL.41731	PL.41730	C	6 A (CWC)	7.29Y	121.6	0.00	3.43	0.00	0	0	0	100	0.00	0.0	13.052	0.053	0	0	1	1
PL.41279	PL.41730	C	#4 ACSR	7.29Y	121.6	0.00	3.43	1.91	1	13	4	96	0.00	0.0	13.039	0.039	13	4	1	1
PL.61150	PL.61152	C	#4 ACSR	7.30Y	121.7	0.00	3.28	0.00	0	0	0	100	0.00	0.0	12.852	0.033	0	0	0	0
PL.42376	PL.66271	A	6 A (CWC)	7.32Y	121.9	0.00	3.07	1.78	1	13	3	97	0.00	0.0	12.320	0.006	0	0	0	8
PD.6734	PL.42376	A	40QA	7.32Y	121.9	0.00	3.07	1.78	4	13	3	97	0.00	0.0	12.320	0.006	0	0	0	8
PL.42377	PD.6734	A	6 A (CWC)	7.32Y	121.9	0.01	3.08	1.78	1	13	3	97	0.00	0.0	12.403	0.082	4	1	3	8
PL.42378	PL.42377	A	6 A (CWC)	7.32Y	121.9	0.00	3.08	1.28	1	9	2	98	0.00	0.0	12.433	0.030	9	2	5	5
PL.42379	PL.42378	A	6 A (CWC)	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	12.474	0.041	0	0	0	0
PL.42373	PL.42372	C	#4 ACSR	7.32Y	122.0	0.00	3.03	3.14	2	22	6	96	0.00	0.0	12.169	0.006	0	0	0	3
PD.6414	PL.42373	C	40QA	7.32Y	122.0	0.00	3.03	3.14	8	22	6	96	0.00	0.0	12.169	0.006	0	0	0	3
PL.59348	PD.6414	C	#4 ACSR	7.32Y	122.0	0.01	3.04	3.14	2	22	6	96	0.00	0.0	12.286	0.116	18	5	1	3
PL.59349	PL.59348	C	#4 ACSR	7.32Y	122.0	0.00	3.04	0.56	0	4	1	97	0.00	0.0	12.328	0.043	4	1	2	2
PL.42363	PL.42353	C	6 A (CWC)	7.33Y	122.1	0.00	2.86	1.89	1	13	4	96	0.00	0.0	11.645	0.006	0	0	0	2
PD.6470	PL.42363	C	40QA	7.33Y	122.1	0.00	2.86	1.89	5	13	4	96	0.00	0.0	11.645	0.006	0	0	0	2
PL.42364	PD.6470	C	6 A (CWC)	7.33Y	122.1	0.01	2.87	1.89	1	13	4	96	0.00	0.0	11.731	0.087	0	0	0	2
PL.42365	PL.42364	C	6 A (CWC)	7.33Y	122.1	0.00	2.87	1.89	1	13	4	96	0.00	0.0	11.748	0.017	2	1	1	2
PL.42366	PL.42365	C	6 A (CWC)	7.33Y	122.1	0.00	2.87	1.54	1	11	3	96	0.00	0.0	11.838	0.090	11	3	1	1
PL.42360	PL.42352	C	#4 ACSR	7.33Y	122.2	0.00	2.79	0.89	1	6	2	95	0.00	0.0	11.439	0.006	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6489	PL.42360	C	40QA	7.33Y	122.2	0.00	2.79	0.89	2	6	2	95	0.00	0.0	11.439	0.006	0	0	0	2
PL.42361	PD.6489	C	#4 ACSR	7.33Y	122.2	0.00	2.79	0.89	1	6	2	95	0.00	0.0	11.526	0.087	3	1	1	2
PL.42362	PL.42361	C	#4 ACSR	7.33Y	122.2	0.00	2.79	0.48	0	3	1	95	0.00	0.0	11.631	0.104	3	1	1	1
PL.42342	PL.42341	C	6 A (CWC)	7.34Y	122.3	0.00	2.68	2.18	2	16	4	97	0.00	0.0	11.153	0.006	0	0	0	2
PD.6735	PL.42342	C	40QA	7.34Y	122.3	0.00	2.68	2.18	5	16	4	97	0.00	0.0	11.153	0.006	0	0	0	2
PL.42343	PD.6735	C	6 A (CWC)	7.34Y	122.3	0.01	2.69	2.18	2	16	4	97	0.00	0.0	11.219	0.066	5	1	1	2
PL.42344	PL.42343	C	6 A (CWC)	7.34Y	122.3	0.00	2.69	1.51	1	11	3	96	0.00	0.0	11.305	0.085	11	3	1	1
PL.61169	PL.42340	B	#1/0 ACSR	7.34Y	122.4	0.00	2.64	0.02	0	0	0	100	0.00	0.0	11.074	0.032	0	0	1	1
PL.41422	PL.41421	A	6 A (CWC)	7.35Y	122.6	0.01	2.45	56.22	40	386	148	93	0.04	0.0	10.619	0.006	0	0	0	20
PD.6623	PL.41422	A	100CodeSMo	7.35Y	122.6	0.00	2.45	56.22	0	386	148	93	0.00	0.0	10.619	0.006	0	0	0	20
PL.41423	PD.6623	A	6 A (CWC)	7.35Y	122.4	0.12	2.57	56.22	40	386	148	93	0.36	0.1	10.666	0.047	1	0	1	20
PL.56535	PL.41423	A	#2 ACSR	7.35Y	122.4	0.00	2.58	1.20	1	9	2	98	0.00	0.0	10.739	0.073	0	0	0	3
PL.56536	PL.56535	A	#2 ACSR	7.35Y	122.4	0.00	2.58	1.20	1	9	2	98	0.00	0.0	10.779	0.040	2	0	1	3
PL.56534	PL.56536	A	#2 ACSR	7.35Y	122.4	0.00	2.58	0.96	1	7	2	96	0.00	0.0	10.820	0.042	3	1	1	2
PL.41424	PL.56534	A	#2 ACSR	7.35Y	122.4	0.00	2.58	0.55	0	4	1	97	0.00	0.0	10.870	0.050	4	1	1	1
PL.62039	PL.41423	A	#1/0 ACSR	7.35Y	122.4	0.00	2.57	0.05	0	0	0	100	0.00	0.0	10.689	0.023	0	0	1	1
PL.41425	PL.41423	A	6 A (CWC)	7.33Y	122.2	0.22	2.79	54.87	39	376	145	93	0.61	0.2	10.751	0.085	5	1	1	15
PL.41426	PL.41425	A	6 A (CWC)	7.32Y	122.0	0.17	2.96	54.22	39	371	143	93	0.46	0.1	10.817	0.067	16	4	1	14
PL.41427	PL.41426	A	6 A (CWC)	7.31Y	121.8	0.25	3.21	51.18	37	349	137	93	0.66	0.2	10.924	0.106	8	2	1	12
PL.41691	PL.41427	A	#4 ACSR	7.31Y	121.8	0.01	3.21	1.60	1	11	3	96	0.00	0.0	11.004	0.080	0	0	0	1
PL.57892	PL.41691	A	#1/0 ACSR	7.31Y	121.8	0.00	3.22	1.60	1	11	3	96	0.00	0.0	11.053	0.050	11	3	1	1
PL.41428	PL.41427	A	6 A (CWC)	7.30Y	121.6	0.14	3.35	48.48	35	329	132	93	0.36	0.1	10.986	0.063	0	0	0	10
PL.41507	PL.41428	A	#4 ACSR	7.28Y	121.4	0.26	3.62	47.53	37	322	130	93	0.66	0.2	11.108	0.122	0	0	0	7
PL.59670	PL.41507	A	#4 ACSR	7.24Y	120.6	0.79	4.40	47.17	36	318	129	93	1.94	0.6	11.477	0.369	4	1	1	6
PL.59669	PL.59670	A	#4 ACSR	7.23Y	120.5	0.11	4.52	46.57	36	312	127	93	0.28	0.1	11.530	0.053	0	0	0	5
PL.59671	PL.59669	A	2 AL URD	7.23Y	120.5	0.00	4.52	46.57	27	312	127	93	0.01	0.0	11.532	0.003	0	0	0	5
PL.63488	PL.59671	A	2 AL URD	7.20Y	120.0	0.50	5.02	46.57	27	312	127	93	0.89	0.3	11.945	0.413	198	96	0	5
PL.63487	PL.63488	A	1/0 AL URD	7.18Y	119.7	0.28	5.30	14.94	9	104	27	97	0.24	0.2	12.544	0.599	0	0	0	3
PL.42233	PL.63487	A	1/0 AL URD	7.18Y	119.7	0.00	5.30	0.49	0	3	1	95	0.00	0.0	12.616	0.072	3	1	1	1
PL.42134	PL.63487	A	1/0 AL URD	7.18Y	119.7	0.01	5.31	14.45	9	100	26	97	0.01	0.0	12.566	0.022	0	0	0	2
PL.42135	PL.42134	A	1/0 AL URD	7.18Y	119.7	0.01	5.32	14.45	9	100	26	97	0.01	0.0	12.585	0.019	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42234	PL.42135	A	1/0 AL URD	7.18Y	119.7	0.00	5.32	4.81	3	33	9	96	0.00	0.0	12.612	0.027	33	9	1	1
PL.42136	PL.42135	A	1/0 AL URD	7.18Y	119.7	0.03	5.35	9.64	6	67	18	97	0.01	0.0	12.778	0.194	67	18	1	1
PL.63490	PL.63488	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	1.30	1	9	2	98	0.00	0.0	12.003	0.058	9	2	2	2
PL.63491	PL.63490	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.150	0.147	0	0	0	0
PD.9522	PL.63491	A	100CodeSMo	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.150	0.147	0	0	0	0
PL.63489	PD.9522	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.360	0.210	0	0	0	0
PD.9455	PL.63489	A	100CodeSMo	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.360	0.210	0	0	0	0
PL.63023	PD.9455	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.448	0.087	0	0	0	0
PL.63024	PL.63023	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.539	0.092	0	0	0	0
PD.9456	PL.63024	A	100CodeSMo	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.539	0.092	0	0	0	0
PL.63025	PD.9456	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.654	0.114	0	0	0	0
PL.64222	PL.63025	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.714	0.061	0	0	0	0
PL.63029	PD.9455	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.444	0.084	0	0	0	0
PL.63030	PL.63029	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.480	0.036	0	0	0	0
PD.9457	PL.63030	A	100CodeSMo	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.480	0.036	0	0	0	0
PL.63031	PD.9457	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.535	0.055	0	0	0	0
PL.63032	PL.63031	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.579	0.044	0	0	0	0
PL.63033	PL.63032	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.668	0.089	0	0	0	0
PL.63034	PL.63033	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.763	0.095	0	0	0	0
PL.63941	PL.63034	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.827	0.063	0	0	0	0
PL.63942	PL.63941	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.878	0.052	0	0	0	0
PL.63022	PL.63034	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.787	0.024	0	0	0	0
PD.9458	PL.63022	A	100CodeSMo	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.787	0.024	0	0	0	0
PL.62732	PD.9458	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.889	0.102	0	0	0	0
PL.63936	PL.62732	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.949	0.060	0	0	0	0
PL.63937	PL.62732	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.944	0.054	0	0	0	0
PL.63938	PL.63937	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.985	0.041	0	0	0	0
PL.63939	PD.9458	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.827	0.040	0	0	0	0
PL.63940	PL.63939	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.873	0.046	0	0	0	0
PL.63026	PD.9455	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.388	0.028	0	0	0	0
PL.63027	PL.63026	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.442	0.054	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.63028	PL.63027	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.513	0.071	0	0	0	0
PL.64220	PL.63028	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.585	0.072	0	0	0	0
PL.64221	PL.64220	A	1/0 AL URD	7.20Y	120.0	0.00	5.02	0.00	0	0	0	100	0.00	0.0	12.662	0.077	0	0	0	0
PL.41557	PL.41507	A	#4 ACSR	7.28Y	121.4	0.00	3.62	0.37	0	3	1	95	0.00	0.0	11.277	0.168	3	1	1	1
PL.41429	PL.41428	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.90	1	6	2	95	0.00	0.0	11.028	0.041	6	2	1	1
PL.41430	PL.41429	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.00	0	0	0	100	0.00	0.0	11.047	0.020	0	0	0	0
PL.41506	PL.41430	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.00	0	0	0	100	0.00	0.0	11.215	0.167	0	0	0	0
PL.57557	PL.41428	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.05	0	0	0	100	0.00	0.0	11.109	0.123	0	0	0	2
PL.57559	PL.57557	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.05	0	0	0	100	0.00	0.0	11.161	0.052	0	0	0	2
PL.59273	PL.57559	A	#1/0 ACSR	7.30Y	121.6	0.00	3.35	0.05	0	0	0	100	0.00	0.0	11.208	0.047	0	0	2	2
PL.57558	PL.57557	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.00	0	0	0	100	0.00	0.0	11.216	0.107	0	0	0	0
PL.41552	PL.57558	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.00	0	0	0	100	0.00	0.0	11.421	0.205	0	0	0	0
PL.41508	PL.57558	A	#4 ACSR	7.30Y	121.6	0.00	3.35	0.00	0	0	0	100	0.00	0.0	11.280	0.064	0	0	0	0
PL.41456	PL.41426	A	6 A (CWC)	7.32Y	122.0	0.00	2.96	0.74	1	5	1	98	0.00	0.0	10.910	0.093	5	1	1	1
PL.62233	PL.42006	A	6 A (CWC)	7.36Y	122.7	0.00	2.31	1.56	1	11	3	96	0.00	0.0	10.531	0.061	11	3	2	2
PL.42137	PL.41402	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	10.287	0.006	0	0	0	0
PD.6802	PL.42137	A	35L	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	10.287	0.006	0	0	0	0
PL.42138	PD.6802	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.404	2.118	0	0	0	0
PL.42139	PL.42138	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.537	0.133	0	0	0	0
PL.42140	PL.42139	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.844	0.306	0	0	0	0
PL.41755	PL.42140	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.875	0.031	0	0	0	0
PL.42141	PL.42140	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.896	0.052	0	0	0	0
PL.42142	PL.42141	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.983	0.087	0	0	0	0
PL.41307	PL.42139	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	12.628	0.090	0	0	0	0
PL.41904	PL.41402	B	6 A (CWC)	7.37Y	122.9	0.00	2.14	2.34	2	17	4	97	0.00	0.0	10.287	0.006	0	0	0	5
PD.6589	PL.41904	B	50QA	7.37Y	122.9	0.00	2.14	2.34	5	17	4	97	0.00	0.0	10.287	0.006	0	0	0	5
PL.41905	PD.6589	B	6 A (CWC)	7.37Y	122.9	0.00	2.15	2.34	2	17	4	97	0.00	0.0	10.303	0.016	0	0	0	5
PL.56538	PL.41905	B	6 A (CWC)	7.37Y	122.8	0.00	2.15	2.34	2	17	4	97	0.00	0.0	10.348	0.045	0	0	0	5
PL.56539	PL.56538	B	6 A (CWC)	7.37Y	122.8	0.02	2.17	2.34	2	17	4	97	0.00	0.0	10.497	0.150	0	0	0	5
PL.41906	PL.56539	B	6 A (CWC)	7.37Y	122.8	0.00	2.17	0.71	1	5	1	98	0.00	0.0	10.600	0.103	2	1	1	2
PL.41907	PL.41906	B	6 A (CWC)	7.37Y	122.8	0.00	2.17	0.42	0	3	1	95	0.00	0.0	10.699	0.100	0	0	0	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

-----																				
Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
-----																				
PL.41908	PL.41907	B	6 A (CWC)	7.37Y	122.8	0.00	2.17	0.42	0	3	1	95	0.00	0.0	10.800	0.100	3	1	1	1
PL.41909	PL.56539	B	6 A (CWC)	7.37Y	122.8	0.01	2.18	1.63	1	12	3	97	0.00	0.0	10.608	0.111	0	0	0	3
PL.41910	PL.41909	B	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.95	1	7	2	96	0.00	0.0	10.719	0.111	7	2	2	2
PL.41911	PL.41910	B	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	11.032	0.314	0	0	0	0
PL.41912	PL.41911	B	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.00	0	0	0	100	0.00	0.0	11.061	0.028	0	0	0	0
PL.41684	PL.41909	B	#4 ACSR	7.37Y	122.8	0.00	2.18	0.68	1	5	1	98	0.00	0.0	10.688	0.080	5	1	1	1
PL.56537	PL.56538	B	#4 ACSR	7.37Y	122.8	0.00	2.15	0.00	0	0	0	100	0.00	0.0	10.463	0.115	0	0	0	0
PL.41734	PL.61158	ABC	#3/0 ACSR	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	8.341	0.060	0	0	0	0
PL.41526	PL.61158	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	8.639	0.358	0	0	0	0
PL.41527	PL.41526	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	8.706	0.067	0	0	0	0
PL.41703	PL.41527	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	8.744	0.039	0	0	0	0
PL.41528	PL.41527	B	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.00	0	0	0	100	0.00	0.0	9.089	0.384	0	0	0	0
PL.62807	PL.62806	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	5.07	4	37	10	97	0.00	0.0	5.809	0.006	0	0	0	6
PD.6694	PL.62807	B	50QA	7.46Y	124.3	0.00	0.67	5.07	10	37	10	97	0.00	0.0	5.809	0.006	0	0	0	6
PL.42326	PD.6694	B	6 A (CWC)	7.46Y	124.3	0.04	0.71	5.07	4	37	10	97	0.01	0.0	6.009	0.200	2	1	1	6
PL.42327	PL.42326	B	6 A (CWC)	7.46Y	124.3	0.00	0.72	3.63	3	26	7	97	0.00	0.0	6.036	0.027	0	0	0	4
PL.42131	PL.42327	B	#4 ACSR	7.46Y	124.3	0.00	0.72	0.39	0	3	1	95	0.00	0.0	6.075	0.039	0	0	0	1
PL.42132	PL.42131	B	#4 ACSR	7.46Y	124.3	0.00	0.72	0.39	0	3	1	95	0.00	0.0	6.142	0.067	3	1	1	1
PL.42133	PL.42327	B	6 A (CWC)	7.46Y	124.3	0.01	0.73	3.25	2	23	6	97	0.00	0.0	6.091	0.055	0	0	0	3
PL.41357	PL.42133	B	#4 ACSR	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	6.152	0.062	0	0	0	0
PL.64677	PL.42133	B	6 A (CWC)	7.46Y	124.3	0.02	0.74	3.25	2	23	6	97	0.00	0.0	6.210	0.119	0	0	0	3
PL.64678	PL.64677	B	#1/0 ACSR	7.46Y	124.3	0.00	0.75	3.25	1	23	6	97	0.00	0.0	6.249	0.039	14	4	1	3
PL.64679	PL.64678	B	#1/0 ACSR	7.46Y	124.3	0.00	0.75	1.36	1	10	3	96	0.00	0.0	6.288	0.039	0	0	0	2
PL.64680	PL.64679	B	#1/0 ACSR	7.46Y	124.3	0.00	0.75	1.36	1	10	3	96	0.00	0.0	6.309	0.021	0	0	0	2
PL.64316	PL.64680	B	#4 ACSR	7.46Y	124.3	0.00	0.75	0.53	0	4	1	97	0.00	0.0	6.407	0.098	4	1	1	1
PL.64317	PL.64316	B	#4 ACSR	7.46Y	124.3	0.00	0.75	0.00	0	0	0	100	0.00	0.0	6.495	0.087	0	0	0	0
PL.62028	PL.64680	B	#1/0 ACSR	7.46Y	124.3	0.00	0.75	0.83	0	6	2	95	0.00	0.0	6.311	0.002	0	0	0	1
PD.9307	PL.62028	B	10T	7.46Y	124.3	0.00	0.75	0.83	0	6	2	95	0.00	0.0	6.311	0.002	0	0	0	1
PL.62029	PD.9307	B	#1/0 ACSR	7.46Y	124.3	0.00	0.75	0.83	0	6	2	95	0.00	0.0	6.375	0.064	6	2	1	1
PL.41496	PL.42326	B	6 A (CWC)	7.46Y	124.3	0.00	0.72	1.10	1	8	2	97	0.00	0.0	6.053	0.045	8	2	1	1
PL.41315	PL.62013	C	6 A (CWC)	7.47Y	124.5	0.09	0.51	20.01	14	145	39	97	0.10	0.1	5.550	0.100	3	1	1	15

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41558	PL.41315	C	6 A (CWC)	7.47Y	124.5	0.04	0.55	19.58	14	141	38	97	0.04	0.0	5.594	0.044	0	0	0	14
PL.41559	PL.41558	C	6 A (CWC)	7.46Y	124.3	0.12	0.67	19.58	14	141	38	97	0.13	0.1	5.732	0.138	0	0	0	14
PL.41405	PL.41559	C	6 A (CWC)	7.46Y	124.3	0.01	0.68	19.58	14	141	38	97	0.01	0.0	5.738	0.006	0	0	0	14
PD.6801	PL.41405	C	50L	7.46Y	124.3	0.00	0.68	19.58	39	141	38	97	0.00	0.0	5.738	0.006	0	0	0	14
PL.41406	PD.6801	C	6 A (CWC)	7.44Y	123.9	0.38	1.06	19.58	14	141	38	97	0.37	0.3	6.218	0.480	32	9	2	14
PL.41407	PL.41406	C	6 A (CWC)	7.43Y	123.9	0.05	1.11	15.07	11	108	29	97	0.04	0.0	6.291	0.073	0	0	0	12
PL.41408	PL.41407	C	6 A (CWC)	7.43Y	123.9	0.00	1.11	11.04	8	79	21	97	0.00	0.0	6.297	0.006	0	0	0	7
PD.6462	PL.41408	C	40QA	7.43Y	123.9	0.00	1.11	11.04	28	79	21	97	0.00	0.0	6.297	0.006	0	0	0	7
PL.41409	PD.6462	C	6 A (CWC)	7.43Y	123.9	0.04	1.15	11.04	8	79	21	97	0.02	0.0	6.374	0.077	9	2	1	7
PL.41411	PL.41409	C	6 A (CWC)	7.40Y	123.4	0.49	1.63	9.79	7	70	19	97	0.24	0.3	7.561	1.187	11	3	1	6
PL.41412	PL.41411	C	6 A (CWC)	7.40Y	123.4	0.01	1.64	8.28	6	59	16	97	0.00	0.0	7.583	0.023	0	0	0	5
PL.42318	PL.41412	C	6 A (CWC)	7.40Y	123.3	0.02	1.66	4.60	3	33	9	96	0.00	0.0	7.671	0.087	0	0	0	2
PL.41042	PL.42318	C	#4 ACSR	7.40Y	123.3	0.00	1.66	1.93	1	14	4	96	0.00	0.0	7.735	0.064	14	4	1	1
PL.42319	PL.42318	C	6 A (CWC)	7.40Y	123.3	0.01	1.67	2.67	2	19	5	97	0.00	0.0	7.785	0.115	19	5	1	1
PL.41032	PL.41412	C	6 A (CWC)	7.40Y	123.3	0.02	1.67	3.68	3	26	7	97	0.00	0.0	7.763	0.180	9	2	2	3
PL.54760	PL.41032	C	6 A (CWC)	7.40Y	123.3	0.00	1.67	2.41	2	17	5	96	0.00	0.0	7.808	0.045	0	0	0	1
PL.54761	PL.54760	C	6 A (CWC)	7.40Y	123.3	0.00	1.67	2.41	2	17	5	96	0.00	0.0	7.840	0.031	17	5	1	1
PL.54046	PL.54761	C	6 A (CWC)	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	7.877	0.038	0	0	0	0
PL.41410	PL.41407	C	6 A (CWC)	7.43Y	123.9	0.01	1.12	4.04	3	29	8	96	0.00	0.0	6.343	0.052	0	0	0	5
PL.42320	PL.41410	C	6 A (CWC)	7.43Y	123.8	0.05	1.17	4.04	3	29	8	96	0.01	0.0	6.659	0.317	7	2	1	5
PL.42321	PL.42320	C	6 A (CWC)	7.43Y	123.8	0.01	1.18	3.12	2	22	6	96	0.00	0.0	6.718	0.058	0	0	0	4
PL.41860	PL.42321	C	#2 ACSR	7.43Y	123.8	0.00	1.18	0.00	0	0	0	100	0.00	0.0	6.803	0.085	0	0	0	0
PL.42322	PL.42321	C	6 A (CWC)	7.43Y	123.8	0.01	1.18	3.12	2	22	6	96	0.00	0.0	6.758	0.041	0	0	0	4
PL.42323	PL.42322	C	6 A (CWC)	7.43Y	123.8	0.00	1.18	0.00	0	0	0	100	0.00	0.0	6.880	0.122	0	0	0	0
PL.42324	PL.42322	C	6 A (CWC)	7.43Y	123.8	0.03	1.21	3.12	2	22	6	96	0.00	0.0	7.023	0.265	14	4	2	4
PL.42325	PL.42324	C	6 A (CWC)	7.43Y	123.8	0.00	1.21	1.21	1	9	2	98	0.00	0.0	7.078	0.055	9	2	2	2
PL.41663	PL.41558	C	#4 ACSR	7.47Y	124.5	0.00	0.55	0.00	0	0	0	100	0.00	0.0	5.697	0.103	0	0	0	0
PL.62014	PL.62019	C	#4 ACSR	7.48Y	124.6	0.00	0.35	0.23	0	2	0	100	0.00	0.0	5.372	0.006	0	0	0	1
PD.6486	PL.62014	C	50QA	7.48Y	124.6	0.00	0.35	0.23	0	2	0	100	0.00	0.0	5.372	0.006	0	0	0	1
PL.42185	PD.6486	C	#4 ACSR	7.48Y	124.6	0.00	0.35	0.23	0	2	0	100	0.00	0.0	5.419	0.047	2	0	1	1
PL.62015	PL.62019	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	5.372	0.006	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6487	PL.62015	A	50QA	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	5.372	0.006	0	0	0	0
PL.42186	PD.6487	A	#1/0 ACSR	7.48Y	124.6	0.00	0.35	0.00	0	0	0	100	0.00	0.0	5.447	0.075	0	0	0	0
PL.62016	PL.62019	B	#4 ACSR	7.48Y	124.6	0.01	0.36	2.97	2	21	6	96	0.00	0.0	5.436	0.070	0	0	0	3
PL.42187	PL.62016	B	#4 ACSR	7.48Y	124.6	0.02	0.38	2.12	2	15	4	97	0.00	0.0	5.606	0.170	0	0	0	2
PL.42188	PL.42187	B	#4 ACSR	7.48Y	124.6	0.01	0.38	2.12	2	15	4	97	0.00	0.0	5.662	0.056	0	0	0	2
PL.42189	PL.42188	B	#4 ACSR	7.48Y	124.6	0.00	0.39	2.12	2	15	4	97	0.00	0.0	5.721	0.060	15	4	2	2
PL.41356	PL.42187	B	#4 ACSR	7.48Y	124.6	0.00	0.38	0.00	0	0	0	100	0.00	0.0	5.754	0.148	0	0	0	0
PL.41865	PL.62016	B	#4 ACSR	7.48Y	124.6	0.00	0.36	0.84	1	6	2	95	0.00	0.0	5.484	0.049	6	2	1	1
PL.62012	PL.62017	A	#4 ACSR	7.48Y	124.7	0.00	0.28	0.00	0	0	0	100	0.00	0.0	5.334	0.051	0	0	0	0
PL.42181	PL.62231	A	6 A (CWC)	7.50Y	125.0	0.00	0.03	0.89	1	6	2	95	0.00	0.0	4.998	0.028	3	1	1	2
PL.41744	PL.42181	A	#4 ACSR	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	5.091	0.093	0	0	0	0
PL.42182	PL.42181	A	6 A (CWC)	7.50Y	125.0	0.00	0.03	0.50	0	4	1	97	0.00	0.0	5.046	0.048	4	1	1	1
PL.62232	REG60	C	#1/0 ACSR	7.51Y	125.2	0.00	-0.24	0.73	0	5	1	98	0.00	0.0	4.697	0.046	5	1	1	1
PL.54054	PL.54053	B	#1/0 ACSR	7.11Y	118.5	0.00	6.47	2.11	1	15	4	97	0.00	0.0	4.305	0.016	0	0	0	2
PD.8121	PL.54054	B	40QA	7.11Y	118.5	0.00	6.47	2.11	5	15	4	97	0.00	0.0	4.305	0.016	0	0	0	2
PL.54055	PD.8121	B	#1/0 ACSR	7.11Y	118.5	0.00	6.47	2.11	1	15	4	97	0.00	0.0	4.307	0.002	15	4	2	2
PL.59383	PL.41482	C	#1/0 ACSR	7.12Y	118.6	0.00	6.39	0.00	0	0	0	100	0.00	0.0	4.253	0.044	0	0	0	0
PL.41370	PL.41369	C	#4 ACSR	7.13Y	118.8	0.00	6.24	7.31	6	50	13	97	0.00	0.0	4.056	0.006	0	0	0	3
PD.6458	PL.41370	C	50QA	7.13Y	118.8	0.00	6.24	7.31	15	50	13	97	0.00	0.0	4.056	0.006	0	0	0	3
PL.41372	PD.6458	C	#4 ACSR	7.12Y	118.7	0.02	6.26	7.31	6	50	13	97	0.01	0.0	4.123	0.067	0	0	0	3
PL.41373	PL.41372	C	#4 ACSR	7.12Y	118.7	0.03	6.29	7.31	6	50	13	97	0.01	0.0	4.215	0.092	13	3	1	3
PL.41374	PL.41373	C	#4 ACSR	7.12Y	118.7	0.01	6.29	5.47	4	38	10	97	0.00	0.0	4.239	0.025	12	3	1	2
PL.41375	PL.41374	C	#4 ACSR	7.12Y	118.7	0.01	6.30	3.72	3	26	7	97	0.00	0.0	4.319	0.079	26	7	1	1
PL.53055	PL.41819	ABC	336 MCM AC	7.13Y	118.9	0.01	6.09	68.58	13	1415	389	96	0.07	0.0	3.911	0.018	0	0	0	169
PD.7988-A	PL.53055	ABC	Closed	7.13Y	118.9	0.00	6.09	68.58	0	1415	388	96	0.00	0.0	3.911	0.018	0	0	0	169
PD.7988-B	PD.7988-A	ABC	Closed	7.13Y	118.9	0.00	6.09	68.58	0	1415	388	96	0.00	0.0	3.911	0.018	0	0	0	169
PL.53054	PD.7988-B	ABC	336 MCM AC	7.13Y	118.9	0.03	6.13	68.58	13	1415	388	96	0.27	0.0	3.979	0.067	0	0	0	169
PL.41449	PL.53054	A	#1/0 ACSR	7.13Y	118.9	0.00	6.13	1.03	0	7	2	96	0.00	0.0	3.984	0.006	0	0	0	1
PD.6406	PL.41449	A	40QA	7.13Y	118.9	0.00	6.13	1.03	3	7	2	96	0.00	0.0	3.984	0.006	0	0	0	1
PL.41450	PD.6406	A	#1/0 ACSR	7.13Y	118.9	0.00	6.13	1.03	0	7	2	96	0.00	0.0	4.027	0.043	7	2	1	1
PL.57751	PL.53054	ABC	336 MCM AC	7.13Y	118.8	0.08	6.21	68.23	13	1408	386	96	0.60	0.0	4.134	0.155	15	7	2	168

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

-----																				
Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
-----																				
PL.57752	PL.57751	ABC	336 MCM AC	7.13Y	118.8	0.03	6.23	67.49	13	1393	378	97	0.21	0.0	4.189	0.055	0	0	0	166
PL.42419	PL.57752	ABC	336 MCM AC	7.12Y	118.7	0.02	6.25	67.49	13	1393	377	97	0.13	0.0	4.224	0.035	0	0	0	166
PL.42420	PL.42419	A	#1/0 ACSR	7.12Y	118.7	0.00	6.25	0.00	0	0	0	100	0.00	0.0	4.229	0.006	0	0	0	0
PD.6604	PL.42420	A	40QA	7.12Y	118.7	0.00	6.25	0.00	0	0	0	100	0.00	0.0	4.229	0.006	0	0	0	0
PL.42421	PD.6604	A	#1/0 ACSR	7.12Y	118.7	0.00	6.25	0.00	0	0	0	100	0.00	0.0	4.323	0.094	0	0	0	0
PL.42422	PL.42421	A	#1/0 ACSR	7.12Y	118.7	0.00	6.25	0.00	0	0	0	100	0.00	0.0	4.690	0.367	0	0	0	0
PL.64309	PL.42419	ABC	336 MCM AC	7.12Y	118.7	0.02	6.27	67.49	13	1393	377	97	0.18	0.0	4.270	0.046	6	2	2	166
PL.64312	PL.64309	ABC	336 MCM AC	7.12Y	118.7	0.08	6.35	67.21	13	1387	375	97	0.59	0.0	4.424	0.154	0	0	0	164
PL.66268	PL.64312	C	#1/0 ACSR	7.12Y	118.7	0.00	6.35	0.00	0	0	0	100	0.00	0.0	4.445	0.021	0	0	0	0
PL.66269	PL.66268	C	#1/0 ACSR	7.12Y	118.7	0.00	6.35	0.00	0	0	0	100	0.00	0.0	4.445	0.000	0	0	0	0
PL.64311	PL.64312	ABC	336 MCM AC	7.12Y	118.6	0.02	6.37	67.21	13	1386	374	97	0.16	0.0	4.466	0.043	0	0	0	164
PL.64310	PL.64311	ABC	336 MCM AC	7.12Y	118.6	0.01	6.38	67.21	13	1386	373	97	0.07	0.0	4.486	0.019	4	1	2	164
PL.42423	PL.64310	ABC	336 MCM AC	7.11Y	118.6	0.05	6.43	67.02	13	1382	372	97	0.36	0.0	4.580	0.094	4	1	1	162
PL.42424	PL.42423	ABC	#1/0 ACSR	7.11Y	118.6	0.00	6.43	9.42	4	194	51	97	0.00	0.0	4.586	0.006	0	0	0	26
PD.6570	PL.42424	ABC	20QA	7.11Y	118.6	0.00	6.43	9.42	47	194	51	97	0.00	0.0	4.586	0.006	0	0	0	26
PL.42425	PD.6570	ABC	#1/0 ACSR	7.11Y	118.6	0.01	6.43	9.42	4	194	51	97	0.01	0.0	4.627	0.041	23	6	4	26
PL.42429	PL.42425	A	#2 ACSR	7.11Y	118.6	0.01	6.44	3.12	2	21	6	96	0.00	0.0	4.693	0.066	0	0	0	2
PL.41742	PL.42429	A	#2 ACSR	7.11Y	118.6	0.00	6.44	1.78	1	12	3	97	0.00	0.0	4.712	0.019	12	3	1	1
PL.64089	PL.42429	A	#2 ACSR	7.11Y	118.6	0.00	6.44	1.34	1	9	2	98	0.00	0.0	4.736	0.044	0	0	0	1
PL.64090	PL.64089	A	#2 ACSR	7.11Y	118.6	0.00	6.44	1.34	1	9	2	98	0.00	0.0	4.736	0.000	9	2	1	1
PL.42430	PL.42425	ABC	#1/0 ACSR	7.11Y	118.6	0.01	6.44	7.26	3	150	40	97	0.01	0.0	4.689	0.063	10	3	1	20
PL.66123	PL.42430	ABC	#1/0 ACSR	7.11Y	118.6	0.00	6.44	6.77	3	140	37	97	0.00	0.0	4.689	0.000	0	0	0	19
PL.66124	PL.66123	ABC	#1/0 ACSR	7.11Y	118.6	0.00	6.45	6.77	3	140	37	97	0.00	0.0	4.733	0.044	27	7	1	19
PL.61162	PL.66124	ABC	#1/0 ACSR	7.11Y	118.5	0.01	6.45	5.46	2	113	30	97	0.01	0.0	4.805	0.071	0	0	0	18
PL.42431	PL.61162	A	#2 ACSR	7.11Y	118.5	0.00	6.45	1.55	1	11	3	96	0.00	0.0	4.810	0.006	0	0	0	1
PD.6571	PL.42431	A	40QA	7.11Y	118.5	0.00	6.45	1.55	4	11	3	96	0.00	0.0	4.810	0.006	0	0	0	1
PL.42432	PD.6571	A	#2 ACSR	7.11Y	118.5	0.00	6.45	1.55	1	11	3	96	0.00	0.0	4.824	0.013	11	3	1	1
PL.42433	PL.61162	ABC	#1/0 ACSR	7.11Y	118.5	0.00	6.46	4.95	2	102	27	97	0.00	0.0	4.848	0.044	5	1	1	17
PL.42434	PL.42433	ABC	#1/0 ACSR	7.11Y	118.5	0.01	6.46	4.69	2	97	26	97	0.00	0.0	4.929	0.081	8	2	1	16
PL.58689	PL.42434	ABC	#1/0 ACSR	7.11Y	118.5	0.01	6.47	4.32	2	89	24	97	0.00	0.0	5.005	0.077	0	0	0	15
PL.58688	PL.58689	A	#4 ACSR	7.11Y	118.5	0.00	6.47	0.00	0	0	0	100	0.00	0.0	5.059	0.053	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58690	PL.58689	A	6 A (CWC)	7.11Y	118.5	0.01	6.48	0.57	0	4	1	97	0.00	0.0	5.234	0.228	0	0	0	2
PL.42436	PL.58690	A	#4 ACSR	7.11Y	118.5	0.00	6.48	0.00	0	0	0	100	0.00	0.0	5.263	0.030	0	0	0	0
PL.42437	PL.42436	A	#4 ACSR	7.11Y	118.5	0.00	6.48	0.00	0	0	0	100	0.00	0.0	5.304	0.041	0	0	0	0
PL.42435	PL.58690	A	6 A (CWC)	7.11Y	118.5	0.00	6.48	0.57	0	4	1	97	0.00	0.0	5.300	0.066	4	1	2	2
PL.58691	PL.58689	A	6 A (CWC)	7.11Y	118.5	0.00	6.47	12.38	9	85	23	97	0.00	0.0	5.009	0.004	0	0	0	12
PD.8641	PL.58691	A	30T	7.11Y	118.5	0.00	6.47	12.38	0	85	23	97	0.00	0.0	5.009	0.004	0	0	0	12
PL.58692	PD.8641	A	6 A (CWC)	7.11Y	118.5	0.03	6.50	12.38	9	85	23	97	0.02	0.0	5.056	0.047	0	0	0	12
PL.41714	PL.58692	A	6 A (CWC)	7.11Y	118.5	0.03	6.53	12.38	9	85	23	97	0.02	0.0	5.113	0.056	0	0	1	12
PL.41890	PL.41714	A	#4 ACSR	7.11Y	118.5	0.00	6.53	0.00	0	0	0	100	0.00	0.0	5.143	0.030	0	0	0	0
PL.41343	PL.41714	A	6 A (CWC)	7.10Y	118.4	0.07	6.60	12.02	9	83	22	97	0.05	0.1	5.246	0.133	0	0	0	10
PL.56052	PL.41343	A	6 A (CWC)	7.10Y	118.4	0.04	6.64	12.02	9	83	22	97	0.03	0.0	5.323	0.077	5	1	1	10
PL.56057	PL.56052	A	6 A (CWC)	7.10Y	118.3	0.07	6.72	9.32	7	64	17	97	0.03	0.1	5.528	0.205	21	6	2	7
PL.56058	PL.56057	A	6 A (CWC)	7.10Y	118.3	0.01	6.73	6.23	4	43	11	97	0.00	0.0	5.563	0.035	0	0	0	5
PL.41678	PL.56058	A	6 A (CWC)	7.10Y	118.3	0.00	6.73	0.76	1	5	1	98	0.00	0.0	5.601	0.038	5	1	1	1
PL.60845	PL.56058	A	6 A (CWC)	7.10Y	118.3	0.02	6.74	5.46	4	37	10	97	0.00	0.0	5.628	0.065	0	0	0	4
PL.60846	PL.60845	A	6 A (CWC)	7.09Y	118.2	0.02	6.76	4.09	3	28	7	97	0.00	0.0	5.740	0.111	0	0	0	3
PL.62247	PL.60846	A	6 A (CWC)	7.09Y	118.2	0.01	6.77	4.09	3	28	7	97	0.00	0.0	5.785	0.045	18	5	2	3
PL.62248	PL.62247	A	6 A (CWC)	7.09Y	118.2	0.00	6.77	1.43	1	10	3	96	0.00	0.0	5.866	0.081	10	3	1	1
PL.60847	PL.60845	A	#1/0 ACSR	7.10Y	118.3	0.00	6.74	1.38	1	9	2	98	0.00	0.0	5.685	0.057	9	2	1	1
PL.56053	PL.56052	A	6 A (CWC)	7.10Y	118.4	0.00	6.64	0.00	0	0	0	100	0.00	0.0	5.357	0.034	0	0	0	0
PL.56054	PL.56052	A	#4 ACSR	7.10Y	118.4	0.00	6.65	2.00	2	14	4	96	0.00	0.0	5.384	0.062	7	2	1	2
PL.56055	PL.56054	A	#4 ACSR	7.10Y	118.4	0.00	6.65	0.00	0	0	0	100	0.00	0.0	5.427	0.042	0	0	0	0
PL.56056	PL.56054	A	#1/0 ACSR	7.10Y	118.4	0.00	6.65	0.91	0	6	2	95	0.00	0.0	5.398	0.013	6	2	1	1
PL.41715	PL.41714	A	#2 ACSR	7.11Y	118.5	0.00	6.53	0.34	0	2	1	89	0.00	0.0	5.145	0.033	0	0	0	1
PL.41342	PL.41715	A	#2 ACSR	7.11Y	118.5	0.00	6.53	0.34	0	2	1	89	0.00	0.0	5.233	0.087	2	1	1	1
PL.41011	PL.58692	A	#4 ACSR	7.11Y	118.5	0.00	6.50	0.00	0	0	0	100	0.00	0.0	5.234	0.177	0	0	0	0
PL.42031	PL.42430	C	#2 ACSR	7.11Y	118.6	0.00	6.44	0.00	0	0	0	100	0.00	0.0	4.750	0.061	0	0	0	0
PL.63467	PL.42423	A	#2 ACSR	7.11Y	118.6	0.00	6.43	2.15	1	15	4	97	0.00	0.0	4.628	0.048	3	1	1	2
PL.63468	PL.63467	A	#2 ACSR	7.11Y	118.6	0.00	6.43	1.70	1	12	3	97	0.00	0.0	4.668	0.041	12	3	1	1
PL.42426	PL.42423	A	#4 ACSR	7.11Y	118.6	0.00	6.43	2.50	2	17	5	96	0.00	0.0	4.586	0.006	0	0	0	2
PD.6759	PL.42426	A	60QA	7.11Y	118.6	0.00	6.43	2.50	4	17	5	96	0.00	0.0	4.586	0.006	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

-----																				
Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
-----																				
PL.42427	PD.6759	A	#4 ACSR	7.11Y	118.6	0.00	6.43	2.50	2	17	5	96	0.00	0.0	4.605	0.020	7	2	1	2
PL.42428	PL.42427	A	#4 ACSR	7.11Y	118.6	0.00	6.43	1.43	1	10	3	96	0.00	0.0	4.631	0.026	10	3	1	1
PL.42438	PL.42423	ABC	336 MCM AC	7.11Y	118.5	0.03	6.46	55.88	11	1152	310	97	0.19	0.0	4.652	0.072	4	1	2	131
PL.42439	PL.42438	ABC	336 MCM AC	7.11Y	118.5	0.02	6.48	55.71	11	1148	309	97	0.13	0.0	4.700	0.048	0	0	0	129
PL.42440	PL.42439	A	#2 ACSR	7.11Y	118.5	0.00	6.48	1.22	1	8	2	97	0.00	0.0	4.706	0.006	0	0	0	1
PD.6572	PL.42440	A	25T	7.11Y	118.5	0.00	6.48	1.22	0	8	2	97	0.00	0.0	4.706	0.006	0	0	0	1
PL.42515	PD.6572	A	#2 ACSR	7.11Y	118.5	0.00	6.48	1.22	1	8	2	97	0.00	0.0	4.744	0.038	8	2	1	1
PL.42516	PL.42439	ABC	336 MCM AC	7.11Y	118.5	0.07	6.55	55.30	11	1139	306	97	0.44	0.0	4.874	0.174	23	6	2	128
PL.42519	PL.42516	ABC	336 MCM AC	7.11Y	118.4	0.02	6.56	53.71	10	1106	297	97	0.10	0.0	4.916	0.042	0	0	0	125
PL.41622	PL.42519	ABC	336 MCM AC	7.11Y	118.4	0.01	6.57	53.40	10	1100	295	97	0.07	0.0	4.946	0.031	17	4	3	124
PL.59306	PL.41622	ABC	336 MCM AC	7.10Y	118.4	0.02	6.60	51.70	10	1065	285	97	0.15	0.0	5.012	0.066	25	7	3	119
PL.59308	PL.59306	C	#2 ACSR	7.10Y	118.4	0.00	6.60	3.59	2	25	7	96	0.00	0.0	5.016	0.004	0	0	0	3
PD.8758	PL.59308	C	40QA	7.10Y	118.4	0.00	6.60	3.59	9	25	7	96	0.00	0.0	5.016	0.004	0	0	0	3
PL.59305	PD.8758	C	#2 ACSR	7.10Y	118.4	0.00	6.60	3.59	2	25	7	96	0.00	0.0	5.044	0.028	25	7	3	3
PL.59307	PL.59306	ABC	336 MCM AC	7.10Y	118.4	0.02	6.62	49.30	9	1015	272	97	0.10	0.0	5.062	0.049	0	0	0	113
PL.41626	PL.59307	ABC	336 MCM AC	7.10Y	118.4	0.03	6.65	49.30	9	1015	272	97	0.17	0.0	5.146	0.084	0	0	0	113
PL.42521	PL.41626	ABC	336 MCM AC	7.10Y	118.3	0.02	6.67	49.30	9	1015	271	97	0.13	0.0	5.210	0.064	3	1	1	113
PL.42522	PL.42521	A	#2 ACSR	7.10Y	118.3	0.00	6.67	1.20	1	8	2	97	0.00	0.0	5.216	0.006	0	0	0	3
PD.6574	PL.42522	A	40QA	7.10Y	118.3	0.00	6.67	1.20	3	8	2	97	0.00	0.0	5.216	0.006	0	0	0	3
PL.54066	PD.6574	A	#2 ACSR	7.10Y	118.3	0.00	6.67	1.20	1	8	2	97	0.00	0.0	5.253	0.037	1	0	1	3
PL.54067	PL.54066	A	#1/0 ACSR	7.10Y	118.3	0.00	6.67	0.37	0	3	1	95	0.00	0.0	5.308	0.055	3	1	1	1
PL.54068	PL.54066	A	#1/0 ACSR	7.10Y	118.3	0.00	6.67	0.75	0	5	1	98	0.00	0.0	5.268	0.016	5	1	1	1
PL.41539	PL.42521	A	#2 ACSR	7.10Y	118.3	0.00	6.67	1.15	1	8	2	97	0.00	0.0	5.261	0.051	8	2	1	1
PL.42523	PL.42521	ABC	336 MCM AC	7.10Y	118.3	0.02	6.69	48.36	9	995	266	97	0.13	0.0	5.277	0.066	0	0	0	108
PL.42524	PL.42523	C	#2 ACSR	7.10Y	118.3	0.00	6.70	4.53	3	31	8	97	0.00	0.0	5.282	0.006	0	0	0	2
PD.6761	PL.42524	C	40QA	7.10Y	118.3	0.00	6.70	4.53	11	31	8	97	0.00	0.0	5.282	0.006	0	0	0	2
PL.42525	PD.6761	C	#2 ACSR	7.10Y	118.3	0.02	6.71	4.53	3	31	8	97	0.00	0.0	5.415	0.133	12	3	1	2
PL.42526	PL.42525	C	#2 ACSR	7.10Y	118.3	0.00	6.71	2.79	2	19	5	97	0.00	0.0	5.515	0.100	19	5	1	1
PL.42527	PL.42523	ABC	336 MCM AC	7.10Y	118.3	0.02	6.71	46.85	9	964	257	97	0.08	0.0	5.320	0.044	0	0	0	106
PL.42528	PL.42527	A	#2 ACSR	7.10Y	118.3	0.00	6.71	0.00	0	0	0	100	0.00	0.0	5.326	0.006	0	0	0	0
PD.6605	PL.42528	A	40QA	7.10Y	118.3	0.00	6.71	0.00	0	0	0	100	0.00	0.0	5.326	0.006	0	0	0	0

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.42529	PD.6605	A	#2 ACSR	7.10Y	118.3	0.00	6.71	0.00	0	0	0	100	0.00	0.0	5.354	0.028	0	0	0	0
PL.42530	PL.42527	ABC	336 MCM AC	7.09Y	118.2	0.08	6.79	46.85	9	964	257	97	0.46	0.0	5.568	0.247	0	0	0	106
PL.54049	PL.42530	ABC	336 MCM AC	7.09Y	118.2	0.02	6.81	46.71	9	960	255	97	0.09	0.0	5.616	0.049	11	3	1	105
PL.54050	PL.54049	ABC	336 MCM AC	7.09Y	118.2	0.03	6.84	46.15	9	949	252	97	0.13	0.0	5.694	0.077	38	10	4	104
PL.54047	PL.54050	ABC	336 MCM AC	7.09Y	118.1	0.02	6.85	44.32	9	911	242	97	0.09	0.0	5.750	0.056	12	3	1	100
PL.54048	PL.54047	ABC	336 MCM AC	7.09Y	118.1	0.01	6.86	43.72	8	899	238	97	0.05	0.0	5.781	0.031	0	0	0	99
PL.41807	PL.54048	ABC	336 MCM AC	7.09Y	118.1	0.02	6.88	42.66	8	877	233	97	0.08	0.0	5.831	0.050	10	3	1	97
REG61	PL.41807	ABC	76.2 KVA	7.51Y	125.2	-7.04	-0.16	42.16	42	867	230	97	percent Boost= 5.62 Tap= 9.0							96
PL.41806	REG61	ABC	336 MCM AC	7.51Y	125.1	0.01	-0.15	39.79	8	867	230	97	0.06	0.0	5.879	0.048	0	0	0	96
PL.41808	PL.41806	B	6 A (CWC)	7.51Y	125.1	0.01	-0.13	50.69	36	368	97	97	0.04	0.0	5.885	0.006	0	0	0	29
PD.6117	PL.41808	B	75QA	7.51Y	125.1	0.00	-0.13	50.69	68	368	97	97	0.00	0.0	5.885	0.006	0	0	0	29
PL.54059	PD.6117	B	6 A (CWC)	7.50Y	125.1	0.06	-0.07	50.69	36	368	97	97	0.17	0.0	5.913	0.028	0	0	0	29
PL.59130	PL.54059	B	#4 ACSR	7.50Y	125.1	0.00	-0.07	3.31	3	24	6	97	0.00	0.0	5.932	0.019	24	6	2	2
PL.54060	PL.54059	B	6 A (CWC)	7.50Y	125.1	0.01	-0.06	41.37	30	300	80	97	0.01	0.0	5.916	0.003	0	0	0	26
PD.8122	PL.54060	B	60QA	7.50Y	125.1	0.00	-0.06	41.37	69	300	80	97	0.00	0.0	5.916	0.003	0	0	0	26
PL.64682	PD.8122	B	6 A (CWC)	7.50Y	125.0	0.04	-0.02	41.37	30	300	80	97	0.08	0.0	5.938	0.022	48	13	4	26
PL.64683	PL.64682	B	6 A (CWC)	7.50Y	125.0	0.05	0.03	30.38	22	220	58	97	0.08	0.0	5.975	0.038	0	0	0	20
PL.64545	PL.64683	B	6 A (CWC)	7.50Y	124.9	0.04	0.07	30.38	22	220	58	97	0.07	0.0	6.005	0.029	3	1	1	20
PL.54016	PL.64545	B	6 A (CWC)	7.49Y	124.8	0.11	0.18	29.91	21	217	57	97	0.17	0.1	6.093	0.088	27	7	3	19
PL.53155	PL.54016	B	6 A (CWC)	7.48Y	124.7	0.12	0.30	26.15	19	189	50	97	0.17	0.1	6.202	0.110	17	4	1	16
PL.53157	PL.53155	B	6 A (CWC)	7.48Y	124.6	0.09	0.40	23.82	17	172	46	97	0.11	0.1	6.289	0.087	14	4	1	15
PL.53160	PL.53157	B	6 A (CWC)	7.48Y	124.6	0.02	0.42	12.24	9	88	23	97	0.01	0.0	6.326	0.036	0	0	0	8
PL.53161	PL.53160	B	6 A (CWC)	7.47Y	124.5	0.05	0.47	11.09	8	80	21	97	0.03	0.0	6.428	0.102	3	1	1	7
PL.53158	PL.53161	B	6 A (CWC)	7.47Y	124.5	0.01	0.47	10.61	8	77	20	97	0.00	0.0	6.446	0.018	13	3	1	6
PL.53159	PL.53158	B	6 A (CWC)	7.47Y	124.5	0.03	0.51	8.82	6	64	17	97	0.01	0.0	6.523	0.077	0	0	0	5
PL.41319	PL.53159	B	#1/0 ACSR	7.47Y	124.5	0.00	0.51	0.00	0	0	0	100	0.00	0.0	6.600	0.077	0	0	0	0
PL.53028	PL.53159	B	#1/0 ACSR	7.47Y	124.5	0.00	0.51	4.54	2	33	9	96	0.00	0.0	6.564	0.041	15	4	1	2
PL.53156	PL.53028	B	#1/0 ACSR	7.47Y	124.5	0.00	0.51	2.50	1	18	5	96	0.00	0.0	6.597	0.033	18	5	1	1
PL.54056	PL.53159	B	6 A (CWC)	7.47Y	124.5	0.01	0.51	4.28	3	31	8	97	0.00	0.0	6.570	0.047	14	4	1	3
PL.54057	PL.54056	B	6 A (CWC)	7.47Y	124.5	0.00	0.52	2.30	2	17	4	97	0.00	0.0	6.653	0.083	17	4	2	2
PL.53154	PL.53160	B	6 A (CWC)	7.47Y	124.6	0.00	0.42	1.15	1	8	2	97	0.00	0.0	6.347	0.021	8	2	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53025	PL.53157	B	#4 ACSR	7.48Y	124.6	0.00	0.40	1.19	1	9	2	98	0.00	0.0	6.329	0.039	9	2	1	1
PL.53026	PL.53157	B	6 A (CWC)	7.47Y	124.6	0.03	0.42	8.49	6	61	16	97	0.01	0.0	6.357	0.068	0	0	1	5
PL.53027	PL.53026	B	6 A (CWC)	7.47Y	124.6	0.02	0.45	8.43	6	61	16	97	0.01	0.0	6.418	0.061	0	0	0	4
PL.62040	PL.53027	B	6 A (CWC)	7.47Y	124.5	0.00	0.45	8.19	6	59	16	97	0.00	0.0	6.439	0.021	45	12	2	3
PL.62041	PL.62040	B	6 A (CWC)	7.47Y	124.5	0.00	0.45	1.99	1	14	4	96	0.00	0.0	6.490	0.051	14	4	1	1
PL.60844	PL.53027	B	6 A (CWC)	7.47Y	124.6	0.00	0.45	0.25	0	2	0	100	0.00	0.0	6.515	0.097	2	0	1	1
PL.64681	PL.64682	B	#4 ACSR	7.50Y	125.0	0.00	-0.02	4.39	3	32	8	97	0.00	0.0	5.967	0.030	32	8	1	2
PL.54014	PL.64681	B	#4 ACSR	7.50Y	125.0	0.00	-0.02	0.02	0	0	0	100	0.00	0.0	5.985	0.017	0	0	0	1
PL.54015	PL.54014	B	#4 ACSR	7.50Y	125.0	0.00	-0.02	0.02	0	0	0	100	0.00	0.0	6.015	0.031	0	0	1	1
PL.54058	PL.54059	B	#4 ACSR	7.50Y	125.1	0.00	-0.07	6.01	5	44	12	96	0.00	0.0	5.934	0.022	44	12	1	1
PL.57494	PL.41806	C	6 A (CWC)	7.51Y	125.1	0.01	-0.14	41.84	30	304	81	97	0.01	0.0	5.883	0.003	0	0	0	43
PD.8502	PL.57494	C	40T	7.51Y	125.1	0.00	-0.14	41.84	0	304	81	97	0.00	0.0	5.883	0.003	0	0	0	43
PL.57495	PD.8502	C	6 A (CWC)	7.50Y	125.0	0.10	-0.04	41.84	30	304	81	97	0.22	0.1	5.940	0.057	42	11	5	43
PL.57493	PL.57495	C	6 A (CWC)	7.50Y	124.9	0.09	0.05	36.04	26	261	69	97	0.17	0.1	5.995	0.055	9	2	4	38
PL.54061	PL.57493	C	6 A (CWC)	7.49Y	124.8	0.12	0.17	27.93	20	202	54	97	0.17	0.1	6.088	0.094	10	3	1	27
PL.41560	PL.54061	C	6 A (CWC)	7.48Y	124.7	0.10	0.26	26.58	19	192	51	97	0.13	0.1	6.168	0.079	3	1	1	26
PL.41854	PL.41560	C	#4 ACSR	7.48Y	124.7	0.00	0.27	2.03	2	15	4	97	0.00	0.0	6.251	0.084	15	4	1	1
PL.41673	PL.41560	C	6 A (CWC)	7.48Y	124.7	0.08	0.34	22.73	16	164	44	97	0.09	0.1	6.243	0.075	0	0	0	23
PL.41387	PL.41673	C	#4 ACSR	7.48Y	124.7	0.00	0.34	1.28	1	9	2	98	0.00	0.0	6.312	0.070	9	2	1	1
PL.41674	PL.41673	C	6 A (CWC)	7.48Y	124.6	0.04	0.38	21.45	15	155	41	97	0.04	0.0	6.282	0.039	4	1	1	22
PL.41610	PL.41674	C	6 A (CWC)	7.47Y	124.6	0.06	0.44	20.90	15	151	40	97	0.07	0.0	6.349	0.067	13	3	3	21
PL.41611	PL.41610	C	6 A (CWC)	7.47Y	124.5	0.07	0.51	17.83	13	129	34	97	0.07	0.1	6.438	0.089	9	2	2	17
PL.41612	PL.41611	C	6 A (CWC)	7.47Y	124.5	0.03	0.54	14.35	10	104	27	97	0.02	0.0	6.482	0.044	9	2	2	14
PL.41613	PL.41612	C	6 A (CWC)	7.47Y	124.4	0.03	0.57	10.90	8	79	21	97	0.02	0.0	6.543	0.061	3	1	1	10
PL.72989	PL.41613	C	6 A (CWC)	7.46Y	124.4	0.04	0.60	9.07	6	65	17	97	0.02	0.0	6.631	0.088	0	0	0	8
PD.11217	PL.72989	C	20T	7.46Y	124.4	0.00	0.60	9.07	0	65	17	97	0.00	0.0	6.631	0.088	0	0	0	8
PL.72990	PD.11217	C	6 A (CWC)	7.46Y	124.4	0.01	0.61	9.07	6	65	17	97	0.01	0.0	6.661	0.029	11	3	1	8
PL.41617	PL.72990	C	6 A (CWC)	7.46Y	124.4	0.01	0.62	7.57	5	55	14	97	0.00	0.0	6.690	0.029	0	0	0	7
PL.41571	PL.41617	C	#4 ACSR	7.46Y	124.4	0.00	0.62	0.00	0	0	0	100	0.00	0.0	6.750	0.060	0	0	0	0
PL.41618	PL.41617	C	6 A (CWC)	7.46Y	124.3	0.05	0.67	7.57	5	55	14	97	0.02	0.0	6.827	0.137	0	0	0	7
PL.41606	PL.41618	C	6 A (CWC)	7.46Y	124.3	0.01	0.68	1.59	1	11	3	96	0.00	0.0	6.975	0.148	11	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.41619	PL.41618	C	6 A (CWC)	7.46Y	124.3	0.01	0.69	5.02	4	36	10	96	0.00	0.0	6.901	0.074	9	2	1	4
PL.41620	PL.41619	C	6 A (CWC)	7.46Y	124.3	0.03	0.71	3.74	3	27	7	97	0.00	0.0	7.099	0.197	9	3	1	3
PL.59366	PL.41620	C	#1/0 ACSR	7.46Y	124.3	0.00	0.71	1.30	1	9	2	98	0.00	0.0	7.141	0.043	9	2	1	1
PL.41621	PL.41620	C	6 A (CWC)	7.46Y	124.3	0.00	0.72	1.13	1	8	2	97	0.00	0.0	7.207	0.109	8	2	1	1
PL.63533	PL.41618	C	#1/0 ACSR	7.46Y	124.3	0.00	0.67	0.96	0	7	2	96	0.00	0.0	6.893	0.066	7	2	1	1
PL.41614	PL.41613	C	6 A (CWC)	7.47Y	124.4	0.00	0.57	1.44	1	10	3	96	0.00	0.0	6.584	0.040	10	3	1	1
PL.41615	PL.41614	C	6 A (CWC)	7.47Y	124.4	0.00	0.57	0.00	0	0	0	100	0.00	0.0	6.642	0.058	0	0	0	0
PL.72485	PL.41612	C	#2 ACSR	7.47Y	124.5	0.00	0.54	2.17	1	16	4	97	0.00	0.0	6.496	0.014	8	2	1	2
PL.72486	PL.72485	C	#2 ACSR	7.47Y	124.5	0.00	0.54	1.04	1	8	2	97	0.00	0.0	6.526	0.030	8	2	1	1
PL.41364	PL.41611	C	#4 ACSR	7.47Y	124.5	0.00	0.51	2.29	2	17	4	97	0.00	0.0	6.513	0.075	17	4	1	1
PL.41856	PL.41610	C	#2 ACSR	7.47Y	124.6	0.00	0.44	1.34	1	10	3	96	0.00	0.0	6.399	0.050	10	3	1	1
PL.41546	PL.41674	C	#2 ACSR	7.48Y	124.6	0.00	0.38	0.00	0	0	0	100	0.00	0.0	6.313	0.030	0	0	0	0
PL.41333	PL.41560	C	#4 ACSR	7.48Y	124.7	0.00	0.26	1.37	1	10	3	96	0.00	0.0	6.251	0.083	10	3	1	1
PL.54071	PL.57493	C	#4 ACSR	7.49Y	124.9	0.05	0.10	6.82	5	49	13	97	0.02	0.0	6.153	0.159	0	0	0	7
PL.54073	PL.54071	C	#1/0 ACSR	7.49Y	124.9	0.00	0.10	1.39	1	10	3	96	0.00	0.0	6.210	0.057	10	3	1	1
PL.54072	PL.54071	C	#4 ACSR	7.49Y	124.9	0.01	0.11	5.43	4	39	10	97	0.00	0.0	6.187	0.034	7	2	1	6
PL.41675	PL.54072	C	#4 ACSR	7.49Y	124.9	0.02	0.12	4.52	3	33	9	96	0.00	0.0	6.303	0.115	12	3	2	5
PL.62035	PL.41675	C	#4 ACSR	7.49Y	124.9	0.01	0.13	2.80	2	20	5	97	0.00	0.0	6.458	0.156	19	5	1	3
PL.62036	PL.62035	C	#4 ACSR	7.49Y	124.9	0.00	0.13	0.14	0	1	0	100	0.00	0.0	6.483	0.025	1	0	2	2
PL.54070	PL.41806	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.14	8.95	2	195	52	97	0.00	0.0	5.938	0.059	18	5	1	24
PL.54069	PL.54070	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.14	8.11	2	177	47	97	0.00	0.0	6.000	0.062	15	4	1	23
PL.41877	PL.54069	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.14	6.47	1	141	37	97	0.00	0.0	6.020	0.019	0	0	0	17
PL.41879	PL.41877	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.14	6.11	1	133	35	97	0.00	0.0	6.081	0.061	0	0	0	15
PL.41036	PL.41879	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.13	5.05	1	110	29	97	0.00	0.0	6.124	0.043	0	0	0	10
PL.42190	PL.41036	C	6 A (CWC)	7.51Y	125.1	0.00	-0.13	13.31	10	97	26	97	0.00	0.0	6.129	0.006	0	0	0	9
PD.6779	PL.42190	C	40QA	7.51Y	125.1	0.00	-0.13	13.31	33	97	26	97	0.00	0.0	6.129	0.006	0	0	0	9
PL.42192	PD.6779	C	6 A (CWC)	7.51Y	125.1	0.02	-0.11	13.31	10	97	26	97	0.01	0.0	6.156	0.027	14	4	1	9
PL.61178	PL.42192	C	6 A (CWC)	7.50Y	125.1	0.05	-0.07	11.34	8	82	22	97	0.03	0.0	6.262	0.106	24	6	2	8
PL.66263	PL.61178	C	6 A (CWC)	7.50Y	125.1	0.01	-0.05	8.03	6	58	15	97	0.01	0.0	6.301	0.039	0	0	0	6
PL.66264	PL.66263	C	6 A (CWC)	7.50Y	125.0	0.01	-0.05	8.03	6	58	15	97	0.00	0.0	6.315	0.014	0	0	0	6
PL.61177	PL.66264	C	6 A (CWC)	7.50Y	125.0	0.02	-0.03	8.03	6	58	15	97	0.01	0.0	6.360	0.045	7	2	1	6

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.54087	PL.61177	C	6 A (CWC)	7.50Y	125.0	0.02	-0.01	7.11	5	52	14	97	0.01	0.0	6.455	0.095	20	5	3	5
PL.42193	PL.54087	C	6 A (CWC)	7.50Y	125.0	0.01	-0.00	4.36	3	32	8	97	0.00	0.0	6.531	0.076	32	8	2	2
PL.42191	PL.41036	A	#4 ACSR	7.51Y	125.1	0.00	-0.13	1.83	1	13	4	96	0.00	0.0	6.129	0.006	0	0	0	1
PD.6702	PL.42191	A	40QA	7.51Y	125.1	0.00	-0.13	1.83	5	13	4	96	0.00	0.0	6.129	0.006	0	0	0	1
PL.54361	PD.6702	A	#4 ACSR	7.51Y	125.1	0.00	-0.13	1.83	1	13	4	96	0.00	0.0	6.148	0.019	0	0	0	1
PL.54362	PL.54361	A	#4 ACSR	7.51Y	125.1	0.01	-0.12	1.83	1	13	4	96	0.00	0.0	6.418	0.270	13	4	1	1
PL.41035	PL.41036	ABC	336 MCM AC	7.51Y	125.1	0.00	-0.13	0.00	0	0	0	100	0.00	0.0	6.251	0.127	0	0	0	0
PL.59264	PL.41035	ABC	#3/0 ACSR	7.51Y	125.1	0.00	-0.13	0.00	0	0	0	100	0.00	0.0	6.255	0.004	0	0	0	0
PD.8755-B	PL.59264	ABC	Open	7.51Y	125.1	0.00	-0.13	0.00	0	0	0	100	0.00	0.0	6.255	0.004	0	0	0	0
PL.41881	PL.41879	C	#1/0 ACSR	7.51Y	125.1	0.00	-0.13	0.64	0	5	1	98	0.00	0.0	6.087	0.006	0	0	0	1
PD.6492	PL.41881	C	40QA	7.51Y	125.1	0.00	-0.13	0.64	2	5	1	98	0.00	0.0	6.087	0.006	0	0	0	1
PL.41882	PD.6492	C	#1/0 ACSR	7.51Y	125.1	0.00	-0.13	0.64	0	5	1	98	0.00	0.0	6.103	0.016	5	1	1	1
PL.41880	PL.41879	C	#2 ACSR	7.51Y	125.1	0.00	-0.13	2.55	1	19	5	97	0.00	0.0	6.087	0.006	0	0	0	4
PD.6703	PL.41880	C	40QA	7.51Y	125.1	0.00	-0.13	2.55	6	19	5	97	0.00	0.0	6.087	0.006	0	0	0	4
PL.41033	PD.6703	C	#2 ACSR	7.51Y	125.1	0.01	-0.13	2.55	1	19	5	97	0.00	0.0	6.164	0.077	5	1	1	4
PL.41034	PL.41033	C	#2 ACSR	7.51Y	125.1	0.00	-0.13	1.89	1	14	4	96	0.00	0.0	6.203	0.039	14	4	3	3
PL.41878	PL.41877	A	#2 ACSR	7.51Y	125.1	0.00	-0.14	1.08	1	8	2	97	0.00	0.0	6.025	0.006	0	0	0	2
PD.6493	PL.41878	A	40QA	7.51Y	125.1	0.00	-0.14	1.08	3	8	2	97	0.00	0.0	6.025	0.006	0	0	0	2
PL.54062	PD.6493	A	#2 ACSR	7.51Y	125.1	0.00	-0.14	1.08	1	8	2	97	0.00	0.0	6.035	0.009	8	2	2	2
PL.41876	PL.54069	A	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.77	2	20	5	97	0.00	0.0	6.006	0.006	0	0	0	5
PD.6784	PL.41876	A	40QA	7.51Y	125.1	0.00	-0.14	2.77	7	20	5	97	0.00	0.0	6.006	0.006	0	0	0	5
PL.54063	PD.6784	A	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.77	2	20	5	97	0.00	0.0	6.013	0.007	0	0	0	5
PL.54064	PL.54063	A	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.77	2	20	5	97	0.00	0.0	6.060	0.047	20	5	4	4
PL.54065	PL.54063	A	#1/0 ACSR	7.51Y	125.1	0.00	-0.14	0.00	0	0	0	100	0.00	0.0	6.065	0.052	0	0	1	1
PL.41803	PL.54048	A	#2 ACSR	7.09Y	118.1	0.00	6.86	1.39	1	9	3	95	0.00	0.0	5.787	0.006	0	0	0	1
PD.6576	PL.41803	A	40QA	7.09Y	118.1	0.00	6.86	1.39	3	9	3	95	0.00	0.0	5.787	0.006	0	0	0	1
PL.59360	PD.6576	A	#2 ACSR	7.09Y	118.1	0.00	6.87	1.39	1	9	3	95	0.00	0.0	5.804	0.017	9	3	1	1
PL.41804	PL.54048	C	#2 ACSR	7.09Y	118.1	0.00	6.87	1.80	1	12	3	97	0.00	0.0	5.787	0.006	0	0	0	1
PD.6116	PL.41804	C	40QA	7.09Y	118.1	0.00	6.87	1.80	4	12	3	97	0.00	0.0	5.787	0.006	0	0	0	1
PL.41805	PD.6116	C	#2 ACSR	7.09Y	118.1	0.00	6.87	1.80	1	12	3	97	0.00	0.0	5.797	0.011	12	3	1	1
PL.42531	PL.42530	A	#2 ACSR	7.09Y	118.2	0.00	6.79	0.42	0	3	1	95	0.00	0.0	5.573	0.006	0	0	0	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low



Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.6575	PL.42531	A	40QA	7.09Y	118.2	0.00	6.79	0.42	1	3	1	95	0.00	0.0	5.573	0.006	0	0	0	1
PL.54051	PD.6575	A	#2 ACSR	7.09Y	118.2	0.00	6.79	0.42	0	3	1	95	0.00	0.0	5.602	0.029	3	1	1	1
PL.41627	PL.41626	C	#2 ACSR	7.10Y	118.4	0.00	6.65	0.00	0	0	0	100	0.00	0.0	5.151	0.006	0	0	0	0
PD.6760	PL.41627	C	40QA	7.10Y	118.4	0.00	6.65	0.00	0	0	0	100	0.00	0.0	5.151	0.006	0	0	0	0
PL.41628	PD.6760	C	#2 ACSR	7.10Y	118.4	0.00	6.65	0.00	0	0	0	100	0.00	0.0	5.159	0.008	0	0	0	0
PL.41623	PL.41622	A	#2 ACSR	7.11Y	118.4	0.00	6.57	2.65	2	18	5	96	0.00	0.0	4.952	0.006	0	0	0	2
PD.6683	PL.41623	A	40QA	7.11Y	118.4	0.00	6.57	2.65	7	18	5	96	0.00	0.0	4.952	0.006	0	0	0	2
PL.41624	PD.6683	A	#2 ACSR	7.11Y	118.4	0.00	6.58	2.65	2	18	5	96	0.00	0.0	4.988	0.036	13	4	1	2
PL.41625	PL.41624	A	#2 ACSR	7.11Y	118.4	0.00	6.58	0.71	0	5	1	98	0.00	0.0	5.022	0.034	5	1	1	1
PL.42520	PL.42519	A	#2 ACSR	7.11Y	118.4	0.00	6.56	0.92	1	6	2	95	0.00	0.0	4.921	0.006	0	0	0	1
PD.6682	PL.42520	A	50QA	7.11Y	118.4	0.00	6.56	0.92	2	6	2	95	0.00	0.0	4.921	0.006	0	0	0	1
PL.41657	PD.6682	A	#2 ACSR	7.11Y	118.4	0.00	6.56	0.92	1	6	2	95	0.00	0.0	4.929	0.007	6	2	1	1
PL.42517	PL.42516	C	#2 ACSR	7.11Y	118.5	0.00	6.55	1.44	1	10	3	96	0.00	0.0	4.880	0.006	0	0	0	1
PD.6573	PL.42517	C	40QA	7.11Y	118.5	0.00	6.55	1.44	4	10	3	96	0.00	0.0	4.880	0.006	0	0	0	1
PL.42518	PD.6573	C	#1/0 ACSR	7.11Y	118.5	0.00	6.55	1.44	1	10	3	96	0.00	0.0	4.911	0.032	10	3	1	1
PL.41366	PL.41819	C	#1/0 ACSR	7.13Y	118.9	0.00	6.08	0.00	0	0	0	100	0.00	0.0	3.899	0.006	0	0	0	0
PD.6758	PL.41366	C	40QA	7.13Y	118.9	0.00	6.08	0.00	0	0	0	100	0.00	0.0	3.899	0.006	0	0	0	0
PL.41367	PD.6758	C	#1/0 ACSR	7.13Y	118.9	0.00	6.08	0.00	0	0	0	100	0.00	0.0	3.908	0.009	0	0	0	0
PL.59401	PL.59403	B	6 A (CWC)	7.15Y	119.1	0.00	5.91	2.48	2	17	5	96	0.00	0.0	3.747	0.006	0	0	0	1
PD.6466	PL.59401	B	60QA	7.15Y	119.1	0.00	5.91	2.48	4	17	5	96	0.00	0.0	3.747	0.006	0	0	0	1
PL.41481	PD.6466	B	6 A (CWC)	7.15Y	119.1	0.00	5.92	2.48	2	17	5	96	0.00	0.0	3.786	0.039	17	5	1	1
PL.61140	PL.56045	C	#1/0 ACSR	7.18Y	119.6	0.00	5.38	1.38	1	10	3	96	0.00	0.0	3.314	0.045	10	3	1	1
PL.62810	PL.62809	B	#4 ACSR	7.20Y	120.1	0.00	4.93	0.00	0	0	0	100	0.00	0.0	2.917	0.006	0	0	0	0
PD.6787	PL.62810	B	40QA	7.20Y	120.1	0.00	4.93	0.00	0	0	0	100	0.00	0.0	2.917	0.006	0	0	0	0
PL.41654	PD.6787	B	#4 ACSR	7.20Y	120.1	0.00	4.93	0.00	0	0	0	100	0.00	0.0	3.052	0.135	0	0	0	0
PL.41655	PL.41654	B	#4 ACSR	7.20Y	120.1	0.00	4.93	0.00	0	0	0	100	0.00	0.0	3.196	0.144	0	0	0	0
PL.42295	PL.42294	A	6 A (CWC)	7.26Y	121.0	0.00	4.04	0.42	0	3	1	95	0.00	0.0	2.254	0.006	0	0	0	2
PD.6578	PL.42295	A	60QA	7.26Y	121.0	0.00	4.04	0.42	1	3	1	95	0.00	0.0	2.254	0.006	0	0	0	2
PL.42296	PD.6578	A	6 A (CWC)	7.26Y	121.0	0.00	4.04	0.42	0	3	1	95	0.00	0.0	2.295	0.041	3	1	2	2
PL.42286	PL.42285	B	#4 ACSR	7.29Y	121.4	0.00	3.56	0.00	0	0	0	100	0.00	0.0	1.918	0.006	0	0	0	0
PD.6606	PL.42286	B	60QA	7.29Y	121.4	0.00	3.56	0.00	0	0	0	100	0.00	0.0	1.918	0.006	0	0	0	0

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

Balanced Voltage Drop Report  
Source: Keavy 2

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\  
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky  
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.42287	PD.6606	B	#4 ACSR	7.29Y	121.4	0.00	3.56	0.00	0	0	0	100	0.00	0.0	1.964	0.046	0	0	0	0
PL.42280	PL.59382	C	6 A (CWC)	7.30Y	121.6	0.00	3.36	7.67	5	54	14	97	0.00	0.0	1.780	0.006	0	0	0	5
PD.6464	PL.42280	C	60QA	7.30Y	121.6	0.00	3.36	7.67	13	54	14	97	0.00	0.0	1.780	0.006	0	0	0	5
PL.59335	PD.6464	C	6 A (CWC)	7.30Y	121.6	0.01	3.38	7.67	5	54	14	97	0.01	0.0	1.831	0.052	22	6	3	5
PL.59336	PL.59335	C	#1/0 ACSR	7.30Y	121.6	0.00	3.38	4.54	2	32	8	97	0.00	0.0	1.847	0.015	32	8	2	2
PL.41515	PL.66131	C	#2 ACSR	7.34Y	122.3	0.00	2.66	1.90	1	14	4	96	0.00	0.0	1.320	0.006	0	0	0	1
PD.6395	PL.41515	C	10QA	7.34Y	122.3	0.00	2.66	1.90	0	14	4	96	0.00	0.0	1.320	0.006	0	0	0	1
PL.41516	PD.6395	C	#2 ACSR	7.34Y	122.3	0.00	2.66	1.90	1	14	4	96	0.00	0.0	1.333	0.013	14	4	1	1
PL.66132	PL.66130	C	#1/0 ACSR	7.34Y	122.4	0.00	2.61	0.73	0	5	1	98	0.00	0.0	1.287	0.003	0	0	0	1
PD.9996	PL.66132	C	20T	7.34Y	122.4	0.00	2.61	0.73	0	5	1	98	0.00	0.0	1.287	0.003	0	0	0	1
PL.66133	PD.9996	C	#1/0 ACSR	7.34Y	122.4	0.00	2.61	0.73	0	5	1	98	0.00	0.0	1.315	0.028	5	1	1	1
PL.42269	PL.52994	C	#4 ACSR	7.47Y	124.5	0.00	0.45	1.05	1	8	2	97	0.00	0.0	0.216	0.006	0	0	0	1
PD.6517	PL.42269	C	75QA	7.47Y	124.5	0.00	0.45	1.05	1	8	2	97	0.00	0.0	0.216	0.006	0	0	0	1
PL.42270	PD.6517	C	#4 ACSR	7.47Y	124.5	0.00	0.45	1.05	1	8	2	97	0.00	0.0	0.250	0.034	8	2	1	1

KEY-> L = Low Voltage    H = High Voltage    C = Capacity Over Limit (%capacity or load amps)    G = Generator Out of kvar Limits    P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load Losses	Total		
KW	12208	0	0	0	0	0	386	0.00	12594	Lowest Voltage = 118.12 on Element PL.41807	
KVAR	3507	0	0	0	0	0	648		4155	Max Accm VoltD = 6.88 on Element PL.41807	
										Max Elem VoltD = 0.87 on Element PL.61157	