

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Three Links		ABC	SRC-Three	7.50Y	125.0	0.00	0.00	294.70	0	6298	2072	95	0.00	0.0	0.000	0.000	0	0	0	1172
PL.53062	Three Links	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	96.92	19	2088	628	96	0.02	0.0	0.002	0.002	0	0	0	455
PL.53065	PL.53062	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	96.92	19	2088	628	96	0.02	0.0	0.004	0.002	0	0	0	455
----- Feeder No. 3 (Disputanta F3) Beginning with Device PD.8075 -----																				
PD.8075	PL.53065	ABC	360VWE	7.50Y	125.0	0.00	0.00	96.92	0	2088	627	96	0.00	0.0	0.004	0.002	0	0	0	455
PL.38482	PD.8075	ABC	336 MCM AC	7.50Y	124.9	0.07	0.08	96.92	19	2088	627	96	0.79	0.0	0.104	0.100	0	0	0	455
PL.37978	PL.38482	ABC	336 MCM AC	7.49Y	124.9	0.07	0.14	96.92	19	2088	626	96	0.73	0.0	0.196	0.092	0	0	0	455
PL.52499	PL.37978	ABC	336 MCM AC	7.48Y	124.7	0.11	0.26	96.92	19	2087	624	96	1.21	0.1	0.349	0.153	0	0	0	455
PL.52501	PL.52499	A	#4 ACSR	7.48Y	124.7	0.00	0.26	0.25	0	2	0	100	0.00	0.0	0.351	0.001	0	0	0	1
PD.6077	PL.52501	A	75QA	7.48Y	124.7	0.00	0.26	0.25	0	2	0	100	0.00	0.0	0.351	0.001	0	0	0	1
PL.37581	PD.6077	A	#4 ACSR	7.48Y	124.7	0.00	0.26	0.25	0	2	0	100	0.00	0.0	0.531	0.180	0	0	0	1
PL.37287	PL.37581	A	#4 ACSR	7.48Y	124.7	0.00	0.26	0.00	0	0	0	100	0.00	0.0	0.698	0.167	0	0	0	0
PL.37477	PL.37581	A	#4 ACSR	7.48Y	124.7	0.00	0.26	0.25	0	2	0	100	0.00	0.0	0.609	0.078	2	0	1	1
PL.52500	PL.52499	ABC	336 MCM AC	7.47Y	124.6	0.18	0.44	96.83	19	2084	621	96	1.93	0.1	0.593	0.244	0	0	0	454
PL.37726	PL.52500	C	#2 ACSR	7.47Y	124.6	0.00	0.44	0.53	0	4	1	97	0.00	0.0	0.593	0.000	0	0	0	1
PD.6017	PL.37726	C	60QA	7.47Y	124.6	0.00	0.44	0.53	1	4	1	97	0.00	0.0	0.593	0.000	0	0	0	1
PL.37388	PD.6017	C	#2 ACSR	7.47Y	124.6	0.00	0.44	0.53	0	4	1	97	0.00	0.0	0.645	0.051	4	1	1	1
PL.37389	PL.52500	ABC	336 MCM AC	7.47Y	124.5	0.05	0.48	96.66	19	2078	615	96	0.51	0.0	0.658	0.065	6	1	2	453
PL.37390	PL.37389	A	#4 ACSR	7.47Y	124.5	0.00	0.48	0.44	0	3	1	95	0.00	0.0	0.662	0.004	0	0	0	2
PD.6018	PL.37390	A	75QA	7.47Y	124.5	0.00	0.48	0.44	1	3	1	95	0.00	0.0	0.662	0.004	0	0	0	2
PL.37402	PD.6018	A	#4 ACSR	7.47Y	124.5	0.00	0.49	0.44	0	3	1	95	0.00	0.0	0.713	0.051	3	1	1	2
PL.37118	PL.37402	A	#4 ACSR	7.47Y	124.5	0.00	0.49	0.07	0	1	0	100	0.00	0.0	0.747	0.034	0	0	0	1
PL.37050	PL.37118	A	#4 ACSR	7.47Y	124.5	0.00	0.49	0.07	0	1	0	100	0.00	0.0	0.781	0.034	1	0	1	1
PL.58008	PL.37389	ABC	336 MCM AC	7.46Y	124.4	0.11	0.59	96.24	19	2068	612	96	1.16	0.1	0.806	0.148	0	0	0	449
PL.62882	PL.58008	ABC	336 MCM AC	7.46Y	124.3	0.07	0.66	95.51	18	2051	605	96	0.74	0.0	0.903	0.097	0	0	0	445
PL.62880	PL.62882	A	#1/0 ACSR	7.46Y	124.3	0.00	0.66	0.11	0	1	0	100	0.00	0.0	0.908	0.004	0	0	0	1
PD.9441	PL.62880	A	15T	7.46Y	124.3	0.00	0.66	0.11	0	1	0	100	0.00	0.0	0.908	0.004	0	0	0	1
PL.62885	PD.9441	A	#1/0 ACSR	7.46Y	124.3	0.00	0.66	0.11	0	1	0	100	0.00	0.0	0.951	0.044	1	0	1	1
PL.62881	PL.62882	ABC	336 MCM AC	7.46Y	124.3	0.05	0.72	95.47	18	2050	603	96	0.56	0.0	0.976	0.073	0	0	0	444
PL.62883	PL.62881	ABC	336 MCM AC	7.45Y	124.1	0.15	0.86	95.04	18	2040	600	96	1.55	0.1	1.180	0.203	0	0	0	443

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.36749	PL.62883	C	6 A (CWC)	7.45Y	124.1	0.00	0.86	0.00	0	0	0	100	0.00	0.0	1.182	0.003	0	0	0	0
PD.5905	PL.36749	C	75QA	7.45Y	124.1	0.00	0.86	0.00	0	0	0	100	0.00	0.0	1.182	0.003	0	0	0	0
PL.37057	PD.5905	C	6 A (CWC)	7.45Y	124.1	0.00	0.86	0.00	0	0	0	100	0.00	0.0	1.265	0.082	0	0	0	0
PL.37052	PL.62883	ABC	336 MCM AC	7.44Y	124.0	0.14	1.00	95.04	18	2038	596	96	1.44	0.1	1.369	0.189	0	0	1	443
PL.37053	PL.37052	ABC	336 MCM AC	7.44Y	123.9	0.08	1.07	95.02	18	2036	593	96	0.80	0.0	1.474	0.106	0	0	0	442
PL.38230	PL.37053	ABC	336 MCM AC	7.43Y	123.8	0.08	1.15	95.02	18	2036	591	96	0.85	0.0	1.586	0.111	0	0	0	442
PL.38231	PL.38230	B	#2 ACSR	7.43Y	123.8	0.00	1.15	0.68	0	5	1	98	0.00	0.0	1.588	0.003	0	0	0	1
PD.6030	PL.38231	B	50QA	7.43Y	123.8	0.00	1.15	0.68	1	5	1	98	0.00	0.0	1.588	0.003	0	0	0	1
PL.38232	PD.6030	B	#2 ACSR	7.43Y	123.8	0.00	1.15	0.68	0	5	1	98	0.00	0.0	1.604	0.016	5	1	1	1
PL.37058	PL.38230	ABC	336 MCM AC	7.42Y	123.7	0.12	1.28	94.79	18	2030	588	96	1.32	0.1	1.760	0.174	0	0	0	441
PL.37060	PL.37058	ABC	336 MCM AC	7.42Y	123.7	0.00	1.28	0.00	0	0	0	100	0.00	0.0	1.763	0.003	0	0	0	0
PD.6045	PL.37060	ABC	75QA	7.42Y	123.7	0.00	1.28	0.00	0	0	0	100	0.00	0.0	1.763	0.003	0	0	0	0
PL.37061	PD.6045	ABC	336 MCM AC	7.42Y	123.7	0.00	1.28	0.00	0	0	0	100	0.00	0.0	1.847	0.084	0	0	0	0
PL.37059	PL.37058	ABC	336 MCM AC	7.42Y	123.6	0.08	1.36	94.79	18	2029	584	96	0.85	0.0	1.873	0.113	3	1	1	441
PL.37733	PL.37059	C	#4 ACSR	7.42Y	123.6	0.00	1.36	10.50	8	76	18	97	0.00	0.0	1.877	0.005	0	0	0	10
PD.5891	PL.37733	C	75QA	7.42Y	123.6	0.00	1.36	10.50	14	76	18	97	0.00	0.0	1.877	0.005	0	0	0	10
PL.37277	PD.5891	C	#4 ACSR	7.41Y	123.6	0.06	1.42	10.50	8	76	18	97	0.03	0.0	2.044	0.166	28	7	2	10
PL.37278	PL.37277	C	#4 ACSR	7.41Y	123.6	0.01	1.44	6.67	5	48	12	97	0.01	0.0	2.094	0.051	0	0	0	8
PL.37062	PL.37278	C	#4 ACSR	7.41Y	123.5	0.02	1.46	6.67	5	48	12	97	0.01	0.0	2.193	0.099	19	5	2	8
PL.37888	PL.37062	C	336 MCM AC	7.41Y	123.5	0.00	1.46	1.01	0	7	2	96	0.00	0.0	2.216	0.023	7	2	1	1
PL.52039	PL.37062	C	#4 ACSR	7.41Y	123.5	0.01	1.47	3.05	2	22	5	98	0.00	0.0	2.269	0.076	8	2	2	5
PL.52040	PL.52039	C	#4 ACSR	7.41Y	123.5	0.02	1.49	2.01	2	14	4	96	0.00	0.0	2.574	0.305	2	1	1	3
PL.37063	PL.52040	C	#4 ACSR	7.41Y	123.5	0.01	1.51	1.68	1	12	3	97	0.00	0.0	2.759	0.185	2	0	1	2
PL.37064	PL.37063	C	#4 ACSR	7.41Y	123.5	0.01	1.51	1.42	1	10	2	98	0.00	0.0	2.955	0.196	10	2	1	1
PL.37816	PL.37059	ABC	336 MCM AC	7.42Y	123.6	0.05	1.41	91.18	18	1949	563	96	0.55	0.0	1.951	0.079	0	0	0	430
PL.38135	PL.37816	ABC	#1/0 ACSR	7.41Y	123.5	0.11	1.52	89.94	39	1922	556	96	1.43	0.1	2.018	0.066	0	0	0	425
PL.37833	PL.38135	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.52	89.94	39	1921	554	96	0.05	0.0	2.020	0.002	0	0	0	425
PD.9280-A	PL.37833	ABC	Closed	7.41Y	123.5	0.00	1.52	89.94	0	1921	554	96	0.00	0.0	2.020	0.002	0	0	0	425
PD.9280-B	PD.9280-A	ABC	Closed	7.41Y	123.5	0.00	1.52	89.94	0	1921	554	96	0.00	0.0	2.020	0.002	0	0	0	425
PL.37438	PD.9280-B	ABC	#1/0 ACSR	7.40Y	123.3	0.21	1.74	89.94	39	1921	554	96	2.80	0.1	2.150	0.130	2	1	2	425
PL.37846	PL.37438	ABC	#1/0 ACSR	7.39Y	123.1	0.12	1.86	89.54	39	1909	549	96	1.58	0.1	2.224	0.074	1	0	1	422

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.37847	PL.37846	ABC	#1/0 ACSR	7.38Y	123.0	0.13	1.99	89.48	39	1906	548	96	1.74	0.1	2.305	0.081	0	0	0	421
PL.37848	PL.37847	A	#4 ACSR	7.38Y	123.0	0.00	1.99	1.03	1	7	2	96	0.00	0.0	2.307	0.002	0	0	0	3
PD.6015	PL.37848	A	40QA	7.38Y	123.0	0.00	1.99	1.03	3	7	2	96	0.00	0.0	2.307	0.002	0	0	0	3
PL.37441	PD.6015	A	#4 ACSR	7.38Y	123.0	0.00	1.99	1.03	1	7	2	96	0.00	0.0	2.359	0.052	0	0	0	3
PL.37442	PL.37441	A	#4 ACSR	7.38Y	123.0	0.00	1.99	0.24	0	2	0	100	0.00	0.0	2.421	0.062	2	0	2	2
PL.37443	PL.37442	A	#4 ACSR	7.38Y	123.0	0.00	1.99	0.00	0	0	0	100	0.00	0.0	2.484	0.063	0	0	0	0
PL.37626	PL.37441	A	#2 ACSR	7.38Y	123.0	0.00	1.99	0.79	0	6	1	99	0.00	0.0	2.413	0.054	6	1	1	1
PL.38129	PL.37441	A	#4 ACSR	7.38Y	123.0	0.00	1.99	0.00	0	0	0	100	0.00	0.0	2.399	0.040	0	0	0	0
PL.37444	PL.37847	ABC	#1/0 ACSR	7.37Y	122.9	0.14	2.13	89.14	39	1897	544	96	1.87	0.1	2.394	0.088	1	0	2	418
PL.37445	PL.37444	ABC	#1/0 ACSR	7.37Y	122.8	0.05	2.18	89.11	39	1895	542	96	0.66	0.0	2.425	0.031	0	0	0	416
PL.38393	PL.37445	ABC	#1/0 ACSR	7.34Y	122.4	0.41	2.60	86.98	38	1848	530	96	5.30	0.3	2.689	0.263	6	1	2	405
PL.37037	PL.38393	A	#1/0 ACSR	7.34Y	122.4	0.00	2.60	1.11	0	8	2	97	0.00	0.0	2.689	0.001	0	0	0	2
PD.5243	PL.37037	A	40QA	7.34Y	122.4	0.00	2.60	1.11	3	8	2	97	0.00	0.0	2.689	0.001	0	0	0	2
PL.38204	PD.5243	A	#1/0 ACSR	7.34Y	122.4	0.00	2.60	1.11	0	8	2	97	0.00	0.0	2.731	0.042	0	0	1	2
PL.37307	PL.38204	A	#2 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	2.857	0.126	0	0	0	0
PL.37217	PL.38204	A	#1/0 ACSR	7.34Y	122.4	0.00	2.60	1.09	0	8	2	97	0.00	0.0	2.826	0.095	8	2	1	1
PL.37100	PL.37217	A	#1/0 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	2.846	0.021	0	0	0	0
PL.51972	PL.38393	ABC	#1/0 ACSR	7.34Y	122.3	0.13	2.72	86.33	38	1829	522	96	1.61	0.1	2.770	0.081	0	0	0	401
PL.51970	PL.51972	C	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	2.773	0.003	0	0	0	0
PD.5242	PL.51970	C	20QA	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	2.773	0.003	0	0	0	0
PL.38439	PD.5242	C	6 A (CWC)	7.34Y	122.3	0.00	2.72	0.00	0	0	0	100	0.00	0.0	2.807	0.034	0	0	0	0
PL.51971	PL.51972	ABC	#1/0 ACSR	7.31Y	121.8	0.45	3.17	86.33	38	1827	520	96	5.66	0.3	3.055	0.285	0	0	0	401
PL.51973	PL.51971	C	#1/0 ACSR	7.31Y	121.8	0.00	3.17	0.00	0	0	0	100	0.00	0.0	3.057	0.002	0	0	0	0
PD.6053	PL.51973	C	20QA	7.31Y	121.8	0.00	3.17	0.00	0	0	0	100	0.00	0.0	3.057	0.002	0	0	0	0
PL.38205	PD.6053	C	#1/0 ACSR	7.31Y	121.8	0.00	3.17	0.00	0	0	0	100	0.00	0.0	3.093	0.036	0	0	0	0
PL.51974	PL.51971	ABC	#1/0 ACSR	7.28Y	121.3	0.53	3.69	86.33	38	1822	515	96	6.69	0.4	3.392	0.337	0	0	0	401
PL.38206	PL.51974	ABC	#1/0 ACSR	7.27Y	121.2	0.07	3.76	85.94	37	1807	507	96	0.88	0.0	3.437	0.045	0	0	2	399
PL.38441	PL.38206	ABC	#1/0 ACSR	7.26Y	121.0	0.27	4.03	85.94	37	1806	506	96	3.41	0.2	3.610	0.173	0	0	0	397
PL.38443	PL.38441	A	6 A (CWC)	7.26Y	121.0	0.00	4.03	0.00	0	0	0	100	0.00	0.0	3.612	0.002	0	0	0	1
PD.6028	PL.38443	A	20QA	7.26Y	121.0	0.00	4.03	0.00	0	0	0	100	0.00	0.0	3.612	0.002	0	0	0	1
PL.38444	PD.6028	A	6 A (CWC)	7.26Y	121.0	0.00	4.03	0.00	0	0	0	100	0.00	0.0	3.651	0.040	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38442	PL.38441	ABC	#1/0 ACSR	7.23Y	120.6	0.39	4.42	85.94	37	1803	502	96	4.95	0.3	3.862	0.252	1	0	1	396
PL.38445	PL.38442	A	#1/0 ACSR	7.23Y	120.6	0.00	4.42	0.00	0	0	0	100	0.00	0.0	3.866	0.004	0	0	0	1
PD.5231	PL.38445	A	20QA	7.23Y	120.6	0.00	4.42	0.00	0	0	0	100	0.00	0.0	3.866	0.004	0	0	0	1
PL.38446	PD.5231	A	#1/0 ACSR	7.23Y	120.6	0.00	4.42	0.00	0	0	0	100	0.00	0.0	3.917	0.051	0	0	1	1
PL.38447	PL.38442	ABC	#1/0 ACSR	7.22Y	120.4	0.18	4.60	85.87	37	1796	497	96	2.27	0.1	3.977	0.116	0	0	0	394
PL.37097	PL.38447	A	#2 ACSR	7.22Y	120.4	0.00	4.60	0.00	0	0	0	100	0.00	0.0	3.979	0.001	0	0	0	0
PD.6039	PL.37097	A	20QA	7.22Y	120.4	0.00	4.60	0.00	0	0	0	100	0.00	0.0	3.979	0.001	0	0	0	0
PL.37098	PD.6039	A	#2 ACSR	7.22Y	120.4	0.00	4.60	0.00	0	0	0	100	0.00	0.0	4.039	0.060	0	0	0	0
PL.37099	PL.38447	ABC	#1/0 ACSR	7.17Y	119.6	0.85	5.45	85.87	37	1794	495	96	10.73	0.6	4.525	0.547	4	1	1	394
PL.51716	PL.37099	ABC	#1/0 ACSR	7.15Y	119.2	0.39	5.84	85.68	37	1779	484	96	4.98	0.3	4.779	0.255	0	0	0	393
PL.53408	PL.51716	ABC	#1/0 ACSR	7.14Y	119.1	0.10	5.94	85.68	37	1774	479	97	1.26	0.1	4.844	0.064	0	0	0	393
PL.62135	PL.53408	ABC	#1/0 ACSR	7.14Y	118.9	0.13	6.07	72.08	31	1490	408	96	1.39	0.1	4.944	0.101	2	0	1	331
PL.62138	PL.62135	ABC	#1/0 ACSR	7.13Y	118.9	0.06	6.13	71.77	31	1482	405	96	0.67	0.0	4.993	0.049	0	0	0	329
RG.60	PL.62138	ABC	114.3 KVA	7.46Y	124.3	-5.44	0.70	71.77	48	1482	404	96	percent Boost= 4.38 Tap= 7.0							329
PL.62139	RG.60	ABC	#1/0 ACSR	7.45Y	124.2	0.06	0.75	68.63	30	1482	404	96	0.59	0.0	5.040	0.047	7	2	1	329
PL.62137	PL.62139	ABC	#1/0 ACSR	7.45Y	124.2	0.09	0.85	68.31	30	1474	402	96	0.94	0.1	5.116	0.076	0	0	0	328
PL.53414	PL.62137	ABC	#1/0 ACSR	7.44Y	124.1	0.09	0.93	68.31	30	1473	401	96	0.88	0.1	5.187	0.071	0	0	0	328
PL.53415	PL.53414	A	6 A (CWC)	7.44Y	124.1	0.00	0.93	2.50	2	18	4	98	0.00	0.0	5.188	0.002	0	0	0	5
PD.7914	PL.53415	A	20QA	7.44Y	124.1	0.00	0.93	2.50	13	18	4	98	0.00	0.0	5.188	0.002	0	0	0	5
PL.53416	PD.7914	A	6 A (CWC)	7.44Y	124.1	0.02	0.95	2.50	2	18	4	98	0.00	0.0	5.333	0.145	2	1	1	5
PL.53604	PL.53416	A	6 A (CWC)	7.44Y	124.0	0.02	0.97	2.17	2	16	4	97	0.00	0.0	5.505	0.172	0	0	0	4
PL.37619	PL.53604	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	1.20	1	9	2	98	0.00	0.0	5.556	0.051	0	0	0	3
PL.38251	PL.37619	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.93	1	7	2	96	0.00	0.0	5.659	0.103	0	0	0	1
PL.37546	PL.38251	A	#2 ACSR	7.44Y	124.0	0.00	0.97	0.93	1	7	2	96	0.00	0.0	5.735	0.076	7	2	1	1
PL.38252	PL.38251	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.00	0	0	0	100	0.00	0.0	5.811	0.152	0	0	0	0
PL.37022	PL.37619	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.27	0	2	0	100	0.00	0.0	5.615	0.058	0	0	0	2
PL.37023	PL.37022	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.14	0	1	0	100	0.00	0.0	5.761	0.146	1	0	1	1
PL.37215	PL.37022	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.13	0	1	0	100	0.00	0.0	5.738	0.123	1	0	1	1
PL.55967	PL.53604	A	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.97	1	7	2	96	0.00	0.0	5.538	0.033	7	2	1	1
PL.56773	PL.53414	ABC	#1/0 ACSR	7.44Y	124.0	0.06	1.00	67.47	29	1454	396	96	0.63	0.0	5.239	0.052	0	0	1	323
PL.56774	PL.56773	ABC	#1/0 ACSR	7.43Y	123.9	0.11	1.11	67.47	29	1453	395	96	1.11	0.1	5.330	0.092	2	1	1	322

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.53606	PL.56774	ABC	#1/0 ACSR	7.42Y	123.7	0.21	1.32	67.37	29	1450	393	97	2.08	0.1	5.502	0.172	0	0	1	321
PL.53608	PL.53606	ABC	#1/0 ACSR	7.41Y	123.5	0.15	1.47	67.22	29	1445	391	97	1.52	0.1	5.628	0.126	0	0	1	319
PL.53609	PL.53608	ABC	#1/0 ACSR	7.38Y	123.0	0.50	1.97	67.20	29	1443	389	97	4.98	0.3	6.042	0.414	1	0	1	318
PL.53610	PL.53609	ABC	#1/0 ACSR	7.38Y	123.0	0.07	2.04	67.14	29	1436	384	97	0.71	0.0	6.102	0.060	6	2	1	317
PL.53611	PL.53610	ABC	#1/0 ACSR	7.36Y	122.6	0.37	2.41	66.85	29	1430	382	97	3.65	0.3	6.409	0.307	0	0	0	316
PL.53613	PL.53611	ABC	#1/0 ACSR	7.35Y	122.5	0.12	2.53	66.85	29	1426	378	97	1.19	0.1	6.508	0.100	0	0	0	316
PL.53614	PL.53613	C	#4 ACSR	7.35Y	122.5	0.00	2.53	1.32	1	9	2	98	0.00	0.0	6.512	0.004	0	0	0	1
PD.7918	PL.53614	C	10QA	7.35Y	122.5	0.00	2.53	1.32	0	9	2	98	0.00	0.0	6.512	0.004	0	0	0	1
PL.53612	PD.7918	C	#4 ACSR	7.35Y	122.5	0.00	2.53	1.32	1	9	2	98	0.00	0.0	6.557	0.045	9	2	1	1
PL.53615	PL.53613	ABC	#1/0 ACSR	7.34Y	122.3	0.13	2.66	66.41	29	1415	375	97	1.30	0.1	6.620	0.111	7	2	2	315
PL.53618	PL.53615	ABC	#1/0 ACSR	7.33Y	122.2	0.14	2.80	65.54	28	1395	369	97	1.39	0.1	6.741	0.122	0	0	0	312
PL.57320	PL.53618	ABC	#1/0 ACSR	7.33Y	122.1	0.08	2.88	65.54	28	1394	368	97	0.80	0.1	6.812	0.070	10	2	1	312
PL.57321	PL.57320	ABC	#1/0 ACSR	7.31Y	121.9	0.22	3.11	65.07	28	1383	365	97	2.16	0.2	7.004	0.192	2	1	1	311
PL.57323	PL.57321	ABC	#1/0 ACSR	7.29Y	121.5	0.40	3.51	64.68	28	1373	360	97	3.87	0.3	7.351	0.347	0	0	0	309
PL.53621	PL.57323	ABC	#1/0 ACSR	7.28Y	121.4	0.12	3.63	64.68	28	1369	357	97	1.15	0.1	7.454	0.103	0	0	0	309
PL.53622	PL.53621	A	6 A (CWC)	7.28Y	121.4	0.00	3.63	0.49	0	3	1	95	0.00	0.0	7.457	0.003	0	0	0	1
PD.7921	PL.53622	A	10QA	7.28Y	121.4	0.00	3.63	0.49	0	3	1	95	0.00	0.0	7.457	0.003	0	0	0	1
PL.53623	PD.7921	A	6 A (CWC)	7.28Y	121.4	0.00	3.63	0.49	0	3	1	95	0.00	0.0	7.557	0.100	3	1	1	1
PL.53624	PL.53621	ABC	#1/0 ACSR	7.28Y	121.3	0.07	3.70	64.51	28	1364	355	97	0.70	0.1	7.517	0.063	4	1	1	308
PL.53625	PL.53624	ABC	#1/0 ACSR	7.27Y	121.2	0.09	3.79	64.30	28	1359	353	97	0.89	0.1	7.598	0.081	3	1	1	307
PL.53626	PL.53625	ABC	#1/0 ACSR	7.26Y	121.0	0.22	4.02	64.18	28	1355	352	97	2.11	0.2	7.790	0.192	0	0	0	306
PL.53628	PL.53626	ABC	#1/0 ACSR	7.23Y	120.4	0.54	4.55	64.18	28	1353	350	97	5.14	0.4	8.258	0.468	0	0	0	306
PL.57369	PL.53628	ABC	#1/0 ACSR	7.20Y	120.0	0.48	5.03	64.18	28	1348	345	97	4.56	0.3	8.674	0.416	0	0	0	306
PL.57371	PL.57369	ABC	#1/0 ACSR	7.19Y	119.8	0.21	5.24	63.95	28	1339	339	97	2.01	0.2	8.859	0.185	0	0	0	305
PL.61793	PL.57371	ABC	#1/0 ACSR	7.16Y	119.3	0.43	5.67	63.95	28	1337	337	97	4.11	0.3	9.236	0.378	0	0	0	305
PL.62111	PL.61793	ABC	#1/0 ACSR	7.15Y	119.2	0.14	5.80	63.95	28	1333	333	97	1.31	0.1	9.357	0.120	0	0	0	305
PL.62109	PL.62111	C	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.00	0	0	0	100	0.00	0.0	9.436	0.080	0	0	0	0
PD.9259-A	PL.62109	C	Open	7.15Y	119.2	0.00	5.80	0.00	0	0	0	100	0.00	0.0	9.436	0.080	0	0	0	0
PL.61794	PL.62111	ABC	#1/0 ACSR	7.15Y	119.1	0.06	5.87	63.95	28	1331	332	97	0.58	0.0	9.410	0.053	0	0	0	305
PL.48958	PL.61794	C	6 A (CWC)	7.15Y	119.1	0.00	5.87	13.63	10	95	23	97	0.00	0.0	9.410	0.001	0	0	0	26
PL.47531	PL.48958	C	6 A (CWC)	7.15Y	119.1	0.00	5.87	0.00	0	0	0	100	0.00	0.0	9.494	0.083	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48962	PL.48958	C	6 A (CWC)	7.14Y	119.0	0.13	6.00	13.63	10	95	23	97	0.09	0.1	9.643	0.233	16	4	5	26
PL.46430	PL.48962	C	6 A (CWC)	7.14Y	119.0	0.00	6.00	0.33	0	2	1	89	0.00	0.0	9.703	0.060	2	1	2	2
PL.47863	PL.48962	C	6 A (CWC)	7.14Y	118.9	0.06	6.06	11.01	8	76	19	97	0.03	0.0	9.770	0.127	8	2	1	19
PL.48187	PL.47863	C	6 A (CWC)	7.14Y	118.9	0.00	6.06	0.04	0	0	0	100	0.00	0.0	9.770	0.000	0	0	0	1
PL.48188	PL.48187	C	6 A (CWC)	7.14Y	118.9	0.00	6.06	0.04	0	0	0	100	0.00	0.0	9.805	0.035	0	0	1	1
PL.47864	PL.47863	C	6 A (CWC)	7.13Y	118.9	0.03	6.09	9.80	7	68	17	97	0.02	0.0	9.847	0.077	0	0	0	17
PL.47865	PL.47864	C	6 A (CWC)	7.13Y	118.9	0.02	6.11	8.55	6	59	14	97	0.01	0.0	9.907	0.060	15	4	3	16
PL.47866	PL.47865	C	6 A (CWC)	7.13Y	118.9	0.02	6.13	6.42	5	44	11	97	0.01	0.0	9.981	0.075	0	0	0	13
PL.47746	PL.47866	C	6 A (CWC)	7.13Y	118.9	0.00	6.13	0.27	0	2	0	100	0.00	0.0	10.089	0.108	2	0	1	1
PL.47867	PL.47866	C	6 A (CWC)	7.13Y	118.9	0.00	6.14	1.39	1	10	2	98	0.00	0.0	10.045	0.064	5	1	2	4
PL.47868	PL.47867	C	6 A (CWC)	7.13Y	118.9	0.00	6.14	0.64	0	4	1	97	0.00	0.0	10.084	0.039	4	1	2	2
PL.47869	PL.47866	C	6 A (CWC)	7.13Y	118.8	0.02	6.16	4.75	3	33	8	97	0.01	0.0	10.099	0.118	6	2	1	8
PL.47870	PL.47869	C	6 A (CWC)	7.13Y	118.8	0.02	6.18	3.86	3	27	7	97	0.00	0.0	10.227	0.128	0	0	0	7
PL.47812	PL.47870	C	6 A (CWC)	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.536	0.308	0	0	0	0
PL.47529	PL.47812	C	6 A (CWC)	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.576	0.040	0	0	0	0
PL.51927	PL.47812	C	6 A (CWC)	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.739	0.204	0	0	0	0
PL.51928	PL.51927	C	#2 ACSR	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.742	0.003	0	0	0	0
PD.7957-A	PL.51928	C	Open	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.742	0.003	0	0	0	0
PL.51926	PL.51927	C	6 A (CWC)	7.13Y	118.8	0.00	6.18	0.00	0	0	0	100	0.00	0.0	10.822	0.083	0	0	0	0
PL.47871	PL.47870	C	6 A (CWC)	7.13Y	118.8	0.01	6.19	3.86	3	27	7	97	0.00	0.0	10.279	0.052	0	0	0	7
PL.47873	PL.47871	C	6 A (CWC)	7.13Y	118.8	0.01	6.19	2.45	2	17	4	97	0.00	0.0	10.398	0.118	17	4	2	3
PL.47874	PL.47873	C	6 A (CWC)	7.13Y	118.8	0.00	6.19	0.00	0	0	0	100	0.00	0.0	10.417	0.019	0	0	1	1
PL.47872	PL.47871	C	6 A (CWC)	7.13Y	118.8	0.01	6.20	1.42	1	10	2	98	0.00	0.0	10.403	0.124	0	0	0	4
PL.61947	PL.47872	C	6 A (CWC)	7.13Y	118.8	0.01	6.20	1.42	1	10	2	98	0.00	0.0	10.506	0.103	0	0	0	4
PL.61949	PL.61947	C	6 A (CWC)	7.13Y	118.8	0.00	6.20	0.16	0	1	0	100	0.00	0.0	10.641	0.135	1	0	1	1
PL.61948	PL.61947	C	6 A (CWC)	7.13Y	118.8	0.01	6.21	1.26	1	9	2	98	0.00	0.0	10.719	0.213	0	0	0	3
PL.47875	PL.61948	C	6 A (CWC)	7.13Y	118.8	0.00	6.21	0.00	0	0	0	100	0.00	0.0	11.399	0.680	0	0	0	0
PL.47810	PL.61948	C	#4 ACSR	7.13Y	118.8	0.01	6.23	1.26	1	9	2	98	0.00	0.0	11.039	0.320	3	1	1	3
PL.47811	PL.47810	C	#4 ACSR	7.13Y	118.8	0.00	6.23	0.78	1	5	1	98	0.00	0.0	11.061	0.021	5	1	2	2
PL.47912	PL.47865	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.00	0	0	0	100	0.00	0.0	9.939	0.033	0	0	0	0
PL.47454	PL.47864	C	#1/0 ACSR	7.13Y	118.9	0.00	6.09	1.25	1	9	2	98	0.00	0.0	9.909	0.062	9	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.66242	PL.61794	C	6 A (CWC)	7.15Y	119.1	0.00	5.87	1.43	1	10	2	98	0.00	0.0	9.413	0.004	0	0	0	2
PD.10004	PL.66242	C	20T	7.15Y	119.1	0.00	5.87	1.43	0	10	2	98	0.00	0.0	9.413	0.004	0	0	0	2
PL.66243	PD.10004	C	6 A (CWC)	7.15Y	119.1	0.00	5.87	1.43	1	10	2	98	0.00	0.0	9.466	0.053	10	2	2	2
PL.62112	PL.61794	ABC	#1/0 ACSR	7.14Y	119.0	0.11	5.97	58.93	26	1226	306	97	0.93	0.1	9.512	0.102	16	4	2	277
PL.62113	PL.62112	C	6 A (CWC)	7.14Y	119.0	0.00	5.97	6.78	5	47	11	97	0.00	0.0	9.513	0.001	0	0	0	8
PD.7399	PL.62113	C	40QA	7.14Y	119.0	0.00	5.97	6.78	17	47	11	97	0.00	0.0	9.513	0.001	0	0	0	8
PL.48959	PD.7399	C	6 A (CWC)	7.14Y	119.0	0.01	5.98	6.78	5	47	11	97	0.00	0.0	9.550	0.037	30	7	4	8
PL.48960	PL.48959	C	6 A (CWC)	7.14Y	119.0	0.00	5.98	2.43	2	17	4	97	0.00	0.0	9.600	0.050	11	3	2	4
PL.48961	PL.48960	C	6 A (CWC)	7.14Y	119.0	0.00	5.98	0.79	1	5	1	98	0.00	0.0	9.621	0.022	5	1	2	2
PL.62114	PL.62112	ABC	#1/0 ACSR	7.13Y	118.9	0.14	6.11	55.88	24	1162	290	97	1.13	0.1	9.648	0.136	0	0	0	267
PL.62115	PL.62114	C	#4 ACSR	7.13Y	118.9	0.00	6.11	0.72	1	5	1	98	0.00	0.0	9.693	0.045	5	1	2	2
PL.62118	PL.62114	ABC	#1/0 ACSR	7.11Y	118.6	0.33	6.43	55.06	24	1144	284	97	2.71	0.2	9.983	0.335	0	0	0	263
PL.62119	PL.62118	C	#4 ACSR	7.11Y	118.6	0.00	6.43	2.11	2	15	4	97	0.00	0.0	9.984	0.001	0	0	0	3
PD.7397	PL.62119	C	15T	7.11Y	118.6	0.00	6.43	2.11	0	15	4	97	0.00	0.0	9.984	0.001	0	0	0	3
PL.48965	PD.7397	C	#4 ACSR	7.11Y	118.6	0.00	6.44	2.11	2	15	4	97	0.00	0.0	10.067	0.083	15	4	3	3
PL.62117	PL.62118	ABC	#1/0 ACSR	7.10Y	118.3	0.23	6.66	54.36	24	1126	278	97	1.85	0.2	10.218	0.235	0	0	0	260
REG87	PL.62117	ABC	114.3 KVA	7.52Y	125.4	-7.05	-0.39	54.36	36	1124	276	97	percent Boost= 5.62 Tap= 9.0							260
PL.48967	REG87	ABC	#2 ACSR	7.52Y	125.3	0.14	-0.26	51.30	29	1124	276	97	1.14	0.1	10.323	0.105	0	0	0	260
PL.48966	PL.48967	ABC	#2 ACSR	7.50Y	124.9	0.34	0.08	51.20	29	1121	275	97	2.81	0.3	10.585	0.262	0	0	0	258
PL.46961	PL.48966	ABC	#2 ACSR	7.49Y	124.8	0.09	0.17	34.94	20	763	187	97	0.52	0.1	10.690	0.105	14	3	2	181
PL.47937	PL.46961	A	#2 ACSR	7.49Y	124.8	0.00	0.17	0.00	0	0	0	100	0.00	0.0	10.692	0.002	0	0	0	0
PD.7582	PL.47937	A	40QA	7.49Y	124.8	0.00	0.17	0.00	0	0	0	100	0.00	0.0	10.692	0.002	0	0	0	0
PL.47938	PD.7582	A	#2 ACSR	7.49Y	124.8	0.00	0.17	0.00	0	0	0	100	0.00	0.0	10.721	0.029	0	0	0	0
PL.47939	PL.47938	A	#2 ACSR	7.49Y	124.8	0.00	0.17	0.00	0	0	0	100	0.00	0.0	10.833	0.112	0	0	0	0
PL.46960	PL.46961	ABC	#2 ACSR	7.49Y	124.8	0.07	0.24	34.30	20	749	183	97	0.36	0.0	10.766	0.076	7	2	1	179
PL.46959	PL.46960	ABC	#2 ACSR	7.48Y	124.7	0.04	0.27	33.99	19	742	181	97	0.20	0.0	10.810	0.044	12	3	2	178
PL.48101	PL.46959	C	#2 ACSR	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	10.812	0.002	0	0	0	0
PD.7387	PL.48101	C	30QA	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	10.812	0.002	0	0	0	0
PL.48102	PD.7387	C	#2 ACSR	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	10.839	0.027	0	0	0	0
PL.48100	PL.46959	ABC	#2 ACSR	7.48Y	124.7	0.04	0.31	33.43	19	729	178	97	0.22	0.0	10.858	0.047	0	0	0	176
PL.48098	PL.48100	C	#4 ACSR	7.48Y	124.7	0.00	0.32	1.96	2	14	3	98	0.00	0.0	10.886	0.029	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48099	PL.48098	C	#4 ACSR	7.48Y	124.7	0.00	0.32	1.96	2	14	3	98	0.00	0.0	10.907	0.021	14	3	3	3
PL.65277	PL.48100	ABC	#2 ACSR	7.48Y	124.7	0.00	0.31	32.78	19	715	175	97	0.00	0.0	10.858	0.000	0	0	0	173
PL.65276	PL.65277	ABC	#2 ACSR	7.48Y	124.6	0.04	0.35	32.78	19	715	175	97	0.21	0.0	10.905	0.047	8	2	1	173
PL.63707	PL.65276	ABC	#2 ACSR	7.48Y	124.6	0.00	0.35	32.06	18	699	171	97	0.00	0.0	10.905	0.000	0	0	0	171
PL.63706	PL.63707	ABC	#2 ACSR	7.48Y	124.6	0.02	0.37	32.06	18	699	171	97	0.10	0.0	10.928	0.023	5	1	1	171
PL.63459	PL.63706	ABC	#2 ACSR	7.48Y	124.6	0.04	0.41	30.93	18	674	165	97	0.20	0.0	10.979	0.051	11	3	3	166
PL.63457	PL.63459	ABC	#2 ACSR	7.47Y	124.6	0.02	0.43	29.13	17	635	155	97	0.09	0.0	11.005	0.025	0	0	0	158
PL.48282	PL.63457	A	6 A (CWC)	7.47Y	124.6	0.00	0.43	4.10	3	30	7	97	0.00	0.0	11.005	0.001	0	0	0	5
PD.7596	PL.48282	A	40QA	7.47Y	124.6	0.00	0.43	4.10	10	30	7	97	0.00	0.0	11.005	0.001	0	0	0	5
PL.48283	PD.7596	A	6 A (CWC)	7.47Y	124.6	0.01	0.44	4.10	3	30	7	97	0.00	0.0	11.077	0.072	3	1	1	5
PL.48284	PL.48283	A	6 A (CWC)	7.47Y	124.6	0.00	0.44	3.68	3	27	7	97	0.00	0.0	11.106	0.029	8	2	1	4
PL.48285	PL.48284	A	6 A (CWC)	7.47Y	124.6	0.01	0.45	2.55	2	19	5	97	0.00	0.0	11.152	0.046	2	0	1	3
PL.48286	PL.48285	A	6 A (CWC)	7.47Y	124.5	0.00	0.45	0.62	0	4	1	97	0.00	0.0	11.192	0.040	4	1	1	1
PL.47948	PL.48285	A	#2 ACSR	7.47Y	124.5	0.00	0.45	1.65	1	12	3	97	0.00	0.0	11.179	0.026	12	3	1	1
PL.47949	PL.47948	A	#2 ACSR	7.47Y	124.5	0.00	0.45	0.00	0	0	0	100	0.00	0.0	11.211	0.032	0	0	0	0
PL.47770	PL.63457	ABC	#2 ACSR	7.47Y	124.5	0.05	0.48	27.77	16	605	148	97	0.23	0.0	11.080	0.076	22	5	4	153
PL.47580	PL.47770	B	6 A (CWC)	7.47Y	124.5	0.00	0.48	18.94	14	137	34	97	0.00	0.0	11.081	0.001	0	0	0	35
PD.7385	PL.47580	B	30T	7.47Y	124.5	0.00	0.48	18.94	0	137	34	97	0.00	0.0	11.081	0.001	0	0	0	35
PL.47581	PD.7385	B	6 A (CWC)	7.47Y	124.5	0.04	0.52	18.94	14	137	34	97	0.04	0.0	11.125	0.044	7	2	2	35
PL.58971	PL.47581	B	6 A (CWC)	7.47Y	124.4	0.04	0.55	18.03	13	131	32	97	0.03	0.0	11.171	0.046	7	2	2	33
PL.58972	PL.58971	B	6 A (CWC)	7.46Y	124.4	0.03	0.58	17.07	12	124	30	97	0.03	0.0	11.209	0.039	0	0	0	31
PL.47279	PL.58972	B	6 A (CWC)	7.46Y	124.4	0.00	0.58	1.79	1	13	3	97	0.00	0.0	11.226	0.017	13	3	2	2
PL.47582	PL.58972	B	6 A (CWC)	7.46Y	124.4	0.03	0.62	15.28	11	111	27	97	0.03	0.0	11.258	0.049	10	2	2	29
PL.58975	PL.47582	B	6 A (CWC)	7.46Y	124.4	0.02	0.64	7.00	5	51	12	97	0.01	0.0	11.335	0.077	6	2	1	14
PL.58973	PL.58975	B	6 A (CWC)	7.46Y	124.3	0.01	0.65	4.73	3	34	8	97	0.00	0.0	11.407	0.072	6	1	1	12
PL.47292	PL.58973	B	6 A (CWC)	7.46Y	124.3	0.02	0.67	3.93	3	28	7	97	0.00	0.0	11.515	0.107	0	0	0	11
PL.47293	PL.47292	B	6 A (CWC)	7.46Y	124.3	0.00	0.68	3.88	3	28	7	97	0.00	0.0	11.539	0.025	2	0	1	10
PL.48164	PL.47293	B	6 A (CWC)	7.46Y	124.3	0.03	0.71	3.66	3	27	6	98	0.01	0.0	11.720	0.181	0	0	0	9
PL.46950	PL.48164	B	6 A (CWC)	7.46Y	124.3	0.00	0.71	0.64	0	5	1	98	0.00	0.0	11.797	0.077	0	0	0	3
PL.47413	PL.46950	B	#4 ACSR	7.46Y	124.3	0.00	0.71	0.53	0	4	1	97	0.00	0.0	12.057	0.259	4	1	2	2
PL.46951	PL.46950	B	6 A (CWC)	7.46Y	124.3	0.00	0.71	0.11	0	1	0	100	0.00	0.0	11.899	0.102	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48588	PL.46951	B	6 A (CWC)	7.46Y	124.3	0.00	0.71	0.11	0	1	0	100	0.00	0.0	11.986	0.087	0	0	0	1
PL.48589	PL.48588	B	6 A (CWC)	7.46Y	124.3	0.00	0.71	0.11	0	1	0	100	0.00	0.0	12.187	0.201	1	0	1	1
PL.48165	PL.48164	B	#2 ACSR	7.46Y	124.3	0.01	0.71	3.02	2	22	5	98	0.00	0.0	11.816	0.096	7	2	1	6
PL.47935	PL.48165	B	#2 ACSR	7.46Y	124.3	0.00	0.72	2.00	1	14	4	96	0.00	0.0	11.854	0.037	8	2	4	5
PL.47936	PL.47935	B	#2 ACSR	7.46Y	124.3	0.00	0.72	0.92	1	7	2	96	0.00	0.0	11.945	0.091	7	2	1	1
PL.47300	PL.47292	B	6 A (CWC)	7.46Y	124.3	0.00	0.67	0.05	0	0	0	100	0.00	0.0	11.547	0.033	0	0	1	1
PL.58974	PL.58975	B	#4 ACSR	7.46Y	124.4	0.00	0.64	1.40	1	10	2	98	0.00	0.0	11.390	0.055	10	2	1	1
PL.47583	PL.47582	B	#4 ACSR	7.46Y	124.4	0.01	0.63	6.88	5	50	12	97	0.00	0.0	11.297	0.038	7	2	1	13
PL.47584	PL.47583	B	#4 ACSR	7.46Y	124.4	0.01	0.64	5.87	5	43	10	97	0.00	0.0	11.353	0.056	0	0	2	12
PL.48108	PL.47584	B	#4 ACSR	7.46Y	124.4	0.01	0.65	4.27	3	31	8	97	0.00	0.0	11.407	0.054	17	4	2	7
PL.48109	PL.48108	B	#4 ACSR	7.46Y	124.3	0.00	0.65	1.90	1	14	3	98	0.00	0.0	11.460	0.053	1	0	1	5
PL.48110	PL.48109	B	#4 ACSR	7.46Y	124.3	0.00	0.66	1.76	1	13	3	97	0.00	0.0	11.492	0.032	0	0	0	4
PL.48111	PL.48110	B	#4 ACSR	7.46Y	124.3	0.00	0.66	1.76	1	13	3	97	0.00	0.0	11.493	0.001	0	0	0	4
PL.48114	PL.48111	B	#4 ACSR	7.46Y	124.3	0.00	0.66	1.76	1	13	3	97	0.00	0.0	11.543	0.050	1	0	1	4
PL.48115	PL.48114	B	#4 ACSR	7.46Y	124.3	0.00	0.66	1.56	1	11	3	96	0.00	0.0	11.556	0.013	0	0	0	3
PL.46954	PL.48115	B	#4 ACSR	7.46Y	124.3	0.01	0.67	1.56	1	11	3	96	0.00	0.0	11.652	0.096	2	0	1	3
PL.48281	PL.46954	B	#4 ACSR	7.46Y	124.3	0.00	0.67	1.31	1	10	2	98	0.00	0.0	11.692	0.040	10	2	2	2
PL.48106	PL.47584	B	#4 ACSR	7.46Y	124.4	0.00	0.64	1.55	1	11	3	96	0.00	0.0	11.365	0.012	4	1	1	3
PL.48107	PL.48106	B	#4 ACSR	7.46Y	124.4	0.00	0.64	0.95	1	7	2	96	0.00	0.0	11.432	0.067	7	2	2	2
PL.48112	PL.48107	B	#4 ACSR	7.46Y	124.4	0.00	0.64	0.00	0	0	0	100	0.00	0.0	11.486	0.054	0	0	0	0
PL.48113	PL.48112	B	#4 ACSR	7.46Y	124.4	0.00	0.64	0.00	0	0	0	100	0.00	0.0	11.535	0.049	0	0	0	0
PL.60031	PL.47770	ABC	#2 ACSR	7.47Y	124.5	0.03	0.50	20.42	12	445	109	97	0.08	0.0	11.131	0.051	35	8	5	114
PL.60030	PL.60031	ABC	#2 ACSR	7.47Y	124.5	0.00	0.51	17.93	10	390	95	97	0.00	0.0	11.132	0.001	0	0	0	104
PL.46958	PL.60030	ABC	#2 ACSR	7.47Y	124.5	0.04	0.54	17.93	10	390	95	97	0.11	0.0	11.218	0.086	20	5	2	104
PL.46956	PL.46958	B	#4 ACSR	7.47Y	124.5	0.00	0.54	2.52	2	18	4	98	0.00	0.0	11.220	0.002	0	0	0	8
PD.7367	PL.46956	B	40QA	7.47Y	124.5	0.00	0.54	2.52	6	18	4	98	0.00	0.0	11.220	0.002	0	0	0	8
PL.46957	PD.7367	B	#4 ACSR	7.47Y	124.5	0.01	0.55	2.52	2	18	4	98	0.00	0.0	11.283	0.063	2	0	1	8
PL.47217	PL.46957	B	#4 ACSR	7.47Y	124.4	0.01	0.56	2.31	2	17	4	97	0.00	0.0	11.341	0.058	3	1	2	7
PL.47719	PL.47217	B	#4 ACSR	7.47Y	124.4	0.00	0.56	0.26	0	2	0	100	0.00	0.0	11.370	0.029	2	0	1	1
PL.46912	PL.47217	B	#4 ACSR	7.47Y	124.4	0.00	0.56	1.05	1	8	2	97	0.00	0.0	11.412	0.071	8	2	3	3
PL.47908	PL.47217	B	#4 ACSR	7.47Y	124.4	0.00	0.56	0.60	0	4	1	97	0.00	0.0	11.405	0.064	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.61694	PL.47908	B	#1/0 ACSR	7.47Y	124.4	0.00	0.56	0.60	0	4	1	97	0.00	0.0	11.408	0.003	0	0	0	1
PD.9152	PL.61694	B	15T	7.47Y	124.4	0.00	0.56	0.60	0	4	1	97	0.00	0.0	11.408	0.003	0	0	0	1
PL.61695	PD.9152	B	#1/0 ACSR	7.47Y	124.4	0.00	0.56	0.60	0	4	1	97	0.00	0.0	11.443	0.035	4	1	1	1
PL.47216	PL.46958	ABC	#2 ACSR	7.47Y	124.4	0.03	0.57	16.15	9	351	86	97	0.07	0.0	11.287	0.069	3	1	2	94
PL.62166	PL.47216	ABC	#2 ACSR	7.46Y	124.4	0.02	0.59	16.00	9	348	85	97	0.06	0.0	11.345	0.057	0	0	0	92
PL.62167	PL.62166	C	#2 ACSR	7.46Y	124.4	0.00	0.59	0.80	0	6	1	99	0.00	0.0	11.345	0.001	0	0	0	1
PD.7598	PL.62167	C	40QA	7.46Y	124.4	0.00	0.59	0.80	2	6	1	99	0.00	0.0	11.345	0.001	0	0	0	1
PL.46955	PD.7598	C	#2 ACSR	7.46Y	124.4	0.00	0.59	0.80	0	6	1	99	0.00	0.0	11.390	0.045	6	1	1	1
PL.62120	PL.62166	ABC	#2 ACSR	7.46Y	124.4	0.01	0.60	15.73	9	342	84	97	0.02	0.0	11.363	0.018	0	0	0	91
PL.47311	PL.62120	ABC	#2 ACSR	7.46Y	124.4	0.02	0.62	15.73	9	342	84	97	0.05	0.0	11.410	0.047	6	2	2	91
PL.48898	PL.47311	ABC	#2 ACSR	7.46Y	124.4	0.00	0.62	15.43	9	336	82	97	0.01	0.0	11.418	0.008	0	0	0	89
PD.7599-A	PL.48898	ABC	Closed	7.46Y	124.4	0.00	0.62	15.43	0	336	82	97	0.00	0.0	11.418	0.008	0	0	0	89
PD.7599-B	PD.7599-A	ABC	Closed	7.46Y	124.4	0.00	0.62	15.43	0	336	82	97	0.00	0.0	11.418	0.008	0	0	0	89
PL.48897	PD.7599-B	ABC	#2 ACSR	7.46Y	124.4	0.00	0.62	15.43	9	336	82	97	0.00	0.0	11.419	0.001	0	0	0	89
PL.47310	PL.48897	ABC	#2 ACSR	7.46Y	124.4	0.00	0.63	15.43	9	336	82	97	0.01	0.0	11.429	0.010	10	2	2	89
PL.47309	PL.47310	ABC	#2 ACSR	7.46Y	124.3	0.03	0.66	14.97	9	326	79	97	0.07	0.0	11.507	0.078	0	0	0	87
PL.47481	PL.47309	ABC	#2 ACSR	7.46Y	124.3	0.01	0.67	10.63	6	231	56	97	0.02	0.0	11.545	0.038	0	0	1	67
PL.47480	PL.47481	ABC	#2 ACSR	7.46Y	124.3	0.01	0.67	10.62	6	231	56	97	0.01	0.0	11.576	0.031	0	0	0	66
PL.47479	PL.47480	ABC	#2 ACSR	7.46Y	124.3	0.00	0.68	10.57	6	230	56	97	0.01	0.0	11.595	0.019	0	0	0	65
PL.47482	PL.47479	C	6 A (CWC)	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	11.596	0.001	0	0	0	0
PD.7366	PL.47482	C	60QA	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	11.596	0.001	0	0	0	0
PL.47483	PD.7366	C	6 A (CWC)	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	11.683	0.087	0	0	0	0
PL.47478	PL.47479	ABC	#2 ACSR	7.46Y	124.3	0.06	0.74	10.57	6	230	56	97	0.10	0.0	11.816	0.221	0	0	0	65
PL.48893	PL.47478	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	2.43	2	18	4	98	0.00	0.0	11.817	0.001	0	0	0	3
PD.7497	PL.48893	B	60QA	7.46Y	124.3	0.00	0.74	2.43	4	18	4	98	0.00	0.0	11.817	0.001	0	0	0	3
PL.48894	PD.7497	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	2.43	2	18	4	98	0.00	0.0	11.866	0.050	9	2	1	3
PL.48895	PL.48894	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	1.15	1	8	2	97	0.00	0.0	11.916	0.050	8	2	2	2
PL.48896	PL.48895	B	6 A (CWC)	7.46Y	124.3	0.00	0.74	0.00	0	0	0	100	0.00	0.0	11.937	0.021	0	0	0	0
PL.48892	PL.47478	ABC	#2 ACSR	7.45Y	124.2	0.07	0.81	4.58	3	99	24	97	0.05	0.1	12.421	0.605	0	0	0	35
PL.48891	PL.48892	ABC	#2 ACSR	7.45Y	124.2	0.00	0.81	4.58	3	99	24	97	0.00	0.0	12.422	0.001	0	0	0	35
PL.48877	PL.48891	ABC	#2 ACSR	7.45Y	124.2	0.01	0.82	4.58	3	99	24	97	0.01	0.0	12.522	0.100	0	0	0	35

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.48881	PL.48877	ABC	#2 ACSR	7.45Y	124.2	0.00	0.82	4.58	3	99	24	97	0.00	0.0	12.522	0.001	0	0	1	35
PL.48882	PL.48881	C	#2 ACSR	7.45Y	124.2	0.00	0.82	0.36	0	3	1	95	0.00	0.0	12.523	0.001	0	0	0	1
PD.7472	PL.48882	C	30QA	7.45Y	124.2	0.00	0.82	0.36	1	3	1	95	0.00	0.0	12.523	0.001	0	0	0	1
PL.48883	PD.7472	C	#2 ACSR	7.45Y	124.2	0.00	0.82	0.36	0	3	1	95	0.00	0.0	12.568	0.044	3	1	1	1
PL.48884	PL.48881	A	#4 ACSR	7.45Y	124.2	0.00	0.82	2.83	2	20	5	97	0.00	0.0	12.523	0.001	0	0	0	6
PD.7574	PL.48884	A	60QA	7.45Y	124.2	0.00	0.82	2.83	5	20	5	97	0.00	0.0	12.523	0.001	0	0	0	6
PL.48885	PD.7574	A	#4 ACSR	7.45Y	124.2	0.01	0.83	2.83	2	20	5	97	0.00	0.0	12.645	0.122	12	3	2	6
PL.48886	PL.48885	A	#4 ACSR	7.45Y	124.2	0.00	0.83	1.15	1	8	2	97	0.00	0.0	12.697	0.052	3	1	2	4
PL.48889	PL.48886	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.76	1	5	1	98	0.00	0.0	12.778	0.081	0	0	0	2
PL.48890	PL.48889	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.76	1	5	1	98	0.00	0.0	12.779	0.001	0	0	0	2
PL.48887	PL.48890	A	#4 ACSR	7.45Y	124.2	0.00	0.84	0.76	1	5	1	98	0.00	0.0	12.825	0.046	2	1	1	2
PL.48888	PL.48887	A	#4 ACSR	7.45Y	124.2	0.00	0.84	0.42	0	3	1	95	0.00	0.0	12.920	0.095	3	1	1	1
PL.48880	PL.48881	ABC	#2 ACSR	7.45Y	124.2	0.01	0.83	3.51	2	76	19	97	0.01	0.0	12.627	0.105	3	1	1	27
PL.48876	PL.48880	ABC	#2 ACSR	7.45Y	124.2	0.00	0.83	3.37	2	73	18	97	0.00	0.0	12.655	0.028	0	0	0	26
PL.48875	PL.48876	ABC	#2 ACSR	7.45Y	124.2	0.00	0.83	3.37	2	73	18	97	0.00	0.0	12.683	0.028	0	0	1	26
PL.48874	PL.48875	ABC	#2 ACSR	7.45Y	124.2	0.00	0.83	3.26	2	71	17	97	0.00	0.0	12.710	0.027	3	1	1	24
PL.48873	PL.48874	ABC	#2 ACSR	7.45Y	124.2	0.00	0.84	3.13	2	68	17	97	0.00	0.0	12.760	0.050	0	0	0	23
PL.48870	PL.48873	A	#4 ACSR	7.45Y	124.2	0.00	0.84	2.46	2	18	4	98	0.00	0.0	12.761	0.001	0	0	0	3
PD.7549	PL.48870	A	60QA	7.45Y	124.2	0.00	0.84	2.46	4	18	4	98	0.00	0.0	12.761	0.001	0	0	0	3
PL.48871	PD.7549	A	#4 ACSR	7.45Y	124.2	0.00	0.84	2.46	2	18	4	98	0.00	0.0	12.782	0.020	0	0	0	3
PL.48872	PL.48871	A	#4 ACSR	7.45Y	124.2	0.00	0.84	2.46	2	18	4	98	0.00	0.0	12.848	0.066	18	4	3	3
PL.48869	PL.48873	ABC	#2 ACSR	7.45Y	124.2	0.01	0.85	2.30	1	50	12	97	0.00	0.0	12.871	0.111	0	0	0	20
PL.48866	PL.48869	ABC	#2 ACSR	7.45Y	124.2	0.00	0.85	2.30	1	50	12	97	0.00	0.0	12.872	0.001	0	0	0	20
PL.48867	PL.48866	C	#4 ACSR	7.45Y	124.2	0.00	0.85	0.94	1	7	2	96	0.00	0.0	12.873	0.001	0	0	0	1
PD.7471	PL.48867	C	60QA	7.45Y	124.2	0.00	0.85	0.94	2	7	2	96	0.00	0.0	12.873	0.001	0	0	0	1
PL.48868	PD.7471	C	#4 ACSR	7.45Y	124.2	0.00	0.85	0.94	1	7	2	96	0.00	0.0	12.952	0.079	7	2	1	1
PL.48865	PL.48866	ABC	#2 ACSR	7.45Y	124.2	0.00	0.85	1.99	1	43	11	97	0.00	0.0	12.927	0.055	0	0	0	19
PL.48863	PL.48865	A	#4 ACSR	7.45Y	124.2	0.00	0.85	0.00	0	0	0	100	0.00	0.0	12.928	0.002	0	0	0	1
PD.7371	PL.48863	A	60QA	7.45Y	124.2	0.00	0.85	0.00	0	0	0	100	0.00	0.0	12.928	0.002	0	0	0	1
PL.48864	PD.7371	A	#4 ACSR	7.45Y	124.2	0.00	0.85	0.00	0	0	0	100	0.00	0.0	12.971	0.043	0	0	1	1
PL.48861	PL.48865	ABC	#2 ACSR	7.45Y	124.1	0.01	0.85	1.99	1	43	11	97	0.00	0.0	13.036	0.109	0	0	0	18

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48852	PL.48861	ABC	#2 ACSR	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	13.104	0.069	0	0	1	1
PL.62169	PL.48852	ABC	#2 ACSR	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	13.216	0.112	0	0	0	0
PD.9279-B	PL.62169	ABC	Open	7.45Y	124.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	13.216	0.112	0	0	0	0
PL.47760	PL.48861	C	6 A (CWC)	7.45Y	124.1	0.02	0.88	4.86	3	35	9	97	0.01	0.0	13.148	0.112	0	0	0	15
PL.48862	PL.47760	C	6 A (CWC)	7.45Y	124.1	0.00	0.88	4.86	3	35	9	97	0.00	0.0	13.149	0.001	0	0	0	15
PD.7564	PL.48862	C	50L	7.45Y	124.1	0.00	0.88	4.86	10	35	9	97	0.00	0.0	13.149	0.001	0	0	0	15
PL.56317	PD.7564	C	6 A (CWC)	7.45Y	124.1	0.01	0.89	4.86	3	35	9	97	0.00	0.0	13.213	0.064	0	0	1	15
PL.56316	PL.56317	C	6 A (CWC)	7.45Y	124.1	0.01	0.91	4.83	3	35	9	97	0.00	0.0	13.277	0.064	3	1	1	14
PL.48859	PL.56316	C	#4 ACSR	7.45Y	124.1	0.00	0.91	0.26	0	2	0	100	0.00	0.0	13.298	0.021	0	0	0	1
PL.48860	PL.48859	C	#4 ACSR	7.45Y	124.1	0.00	0.91	0.26	0	2	0	100	0.00	0.0	13.367	0.068	2	0	1	1
PL.64659	PL.48859	C	#2 ACSR	7.45Y	124.1	0.00	0.91	0.00	0	0	0	100	0.00	0.0	13.334	0.036	0	0	0	0
PL.64660	PL.64659	C	#2 ACSR	7.45Y	124.1	0.00	0.91	0.00	0	0	0	100	0.00	0.0	13.346	0.012	0	0	0	0
PL.47548	PL.56316	C	6 A (CWC)	7.44Y	124.0	0.05	0.95	4.22	3	31	7	98	0.01	0.0	13.520	0.243	0	0	0	12
PL.48941	PL.47548	C	6 A (CWC)	7.44Y	124.0	0.00	0.95	0.79	1	6	1	99	0.00	0.0	13.573	0.052	0	0	1	2
PL.47515	PL.48941	C	6 A (CWC)	7.44Y	124.0	0.00	0.96	0.79	1	6	1	99	0.00	0.0	13.631	0.058	6	1	1	1
PL.59561	PL.47548	C	6 A (CWC)	7.44Y	124.0	0.01	0.96	1.67	1	12	3	97	0.00	0.0	13.591	0.070	0	0	0	3
PL.59562	PL.59561	C	6 A (CWC)	7.44Y	124.0	0.00	0.96	1.67	1	12	3	97	0.00	0.0	13.599	0.009	0	0	0	3
PL.48942	PL.59562	C	6 A (CWC)	7.44Y	124.0	0.01	0.97	1.67	1	12	3	97	0.00	0.0	13.741	0.142	3	1	1	3
PL.48943	PL.48942	C	6 A (CWC)	7.44Y	124.0	0.01	0.97	1.27	1	9	2	98	0.00	0.0	13.853	0.112	0	0	0	2
PL.48945	PL.48943	C	#4 ACSR	7.44Y	124.0	0.00	0.98	1.07	1	8	2	97	0.00	0.0	13.902	0.049	0	0	0	1
PL.48946	PL.48945	C	#4 ACSR	7.44Y	124.0	0.00	0.98	1.07	1	8	2	97	0.00	0.0	14.002	0.100	8	2	1	1
PL.48944	PL.48943	C	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.20	0	1	0	100	0.00	0.0	13.934	0.081	1	0	1	1
PL.59565	PL.47548	C	6 A (CWC)	7.44Y	124.0	0.02	0.97	1.76	1	13	3	97	0.00	0.0	13.769	0.248	2	0	1	7
PL.59566	PL.59565	C	6 A (CWC)	7.44Y	124.0	0.00	0.98	1.50	1	11	3	96	0.00	0.0	13.841	0.072	0	0	0	6
PL.48947	PL.59566	C	6 A (CWC)	7.44Y	124.0	0.01	0.98	1.50	1	11	3	96	0.00	0.0	13.950	0.109	0	0	0	6
PL.47654	PL.48947	C	6 A (CWC)	7.44Y	124.0	0.00	0.98	0.00	0	0	0	100	0.00	0.0	14.003	0.053	0	0	0	0
PL.48948	PL.48947	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	1.50	1	11	3	96	0.00	0.0	14.022	0.071	0	0	0	6
PL.48949	PL.48948	C	6 A (CWC)	7.44Y	124.0	0.01	0.99	1.50	1	11	3	96	0.00	0.0	14.117	0.096	0	0	0	6
PL.48950	PL.48949	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	0.33	0	2	1	89	0.00	0.0	14.172	0.055	2	1	1	2
PL.48951	PL.48950	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	0.00	0	0	0	100	0.00	0.0	14.218	0.046	0	0	1	1
PL.48952	PL.48949	C	6 A (CWC)	7.44Y	124.0	0.01	1.00	1.17	1	8	2	97	0.00	0.0	14.303	0.186	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48953	PL.48952	C	6 A (CWC)	7.44Y	124.0	0.02	1.02	1.17	1	8	2	97	0.00	0.0	14.595	0.292	0	0	1	4
PL.48956	PL.48953	C	6 A (CWC)	7.44Y	124.0	0.01	1.03	1.04	1	8	2	97	0.00	0.0	15.082	0.487	7	2	1	2
PL.48957	PL.48956	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	0.02	0	0	0	100	0.00	0.0	15.174	0.091	0	0	0	1
PL.48262	PL.48957	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	0.02	0	0	0	100	0.00	0.0	15.229	0.055	0	0	1	1
PL.48954	PL.48953	C	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.12	0	1	0	100	0.00	0.0	14.659	0.064	1	0	1	1
PL.48955	PL.48954	C	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	14.679	0.020	0	0	0	0
PL.47160	PL.48953	C	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	14.673	0.077	0	0	0	0
PL.62110	PL.48953	C	6 A (CWC)	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	14.987	0.391	0	0	0	0
PD.9259-B	PL.62110	C	Open	7.44Y	124.0	0.00	1.02	0.00	0	0	0	100	0.00	0.0	14.987	0.391	0	0	0	0
PL.47319	PL.48952	C	6 A (CWC)	7.44Y	124.0	0.00	1.00	0.00	0	0	0	100	0.00	0.0	14.352	0.048	0	0	0	0
PL.48853	PL.48861	A	#2 ACSR	7.45Y	124.1	0.00	0.85	1.12	1	8	2	97	0.00	0.0	13.040	0.004	0	0	0	2
PD.7548	PL.48853	A	60QA	7.45Y	124.1	0.00	0.85	1.12	2	8	2	97	0.00	0.0	13.040	0.004	0	0	0	2
PL.48854	PD.7548	A	#2 ACSR	7.45Y	124.1	0.00	0.85	1.12	1	8	2	97	0.00	0.0	13.061	0.021	0	0	0	2
PL.48855	PL.48854	A	#2 ACSR	7.45Y	124.1	0.00	0.86	1.12	1	8	2	97	0.00	0.0	13.210	0.149	6	2	1	2
PL.48857	PL.48855	A	#2 ACSR	7.45Y	124.1	0.00	0.86	0.22	0	2	0	100	0.00	0.0	13.262	0.052	0	0	0	1
PL.48858	PL.48857	A	#2 ACSR	7.45Y	124.1	0.00	0.86	0.22	0	2	0	100	0.00	0.0	13.295	0.032	2	0	1	1
PL.48856	PL.48858	A	#2 ACSR	7.45Y	124.1	0.00	0.86	0.00	0	0	0	100	0.00	0.0	13.367	0.072	0	0	0	0
PL.48878	PL.48875	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.31	0	2	1	89	0.00	0.0	12.685	0.001	0	0	0	1
PD.7591	PL.48878	A	60QA	7.45Y	124.2	0.00	0.83	0.31	1	2	1	89	0.00	0.0	12.685	0.001	0	0	0	1
PL.48879	PD.7591	A	#4 ACSR	7.45Y	124.2	0.00	0.83	0.31	0	2	1	89	0.00	0.0	12.736	0.052	2	1	1	1
CP.67	PL.48892	ABC	Cap (300)	7.45Y	124.2	0.00	0.81	0.00	0	0	0	100	0.00	0.0	12.421	0.052	0	0	0	0
PL.47178	PL.47478	B	6 A (CWC)	7.45Y	124.2	0.06	0.80	15.55	11	113	27	97	0.05	0.0	11.909	0.093	10	3	2	27
PL.47661	PL.47178	B	#1/0 ACSR	7.45Y	124.2	0.00	0.80	0.00	0	0	0	100	0.00	0.0	11.964	0.055	0	0	1	1
PL.47452	PL.47178	B	#4 ACSR	7.45Y	124.2	0.00	0.80	1.10	1	8	2	97	0.00	0.0	11.949	0.041	8	2	2	2
PL.47879	PL.47178	B	6 A (CWC)	7.45Y	124.2	0.00	0.80	13.00	9	94	23	97	0.00	0.0	11.910	0.001	0	0	0	22
PD.7565	PL.47879	B	35L	7.45Y	124.2	0.00	0.80	13.00	37	94	23	97	0.00	0.0	11.910	0.001	0	0	0	22
PL.47880	PD.7565	B	6 A (CWC)	7.45Y	124.2	0.03	0.83	13.00	9	94	23	97	0.02	0.0	11.954	0.044	1	0	1	22
PL.47881	PL.47880	B	6 A (CWC)	7.45Y	124.1	0.03	0.86	12.80	9	93	23	97	0.02	0.0	12.017	0.062	20	5	3	21
PL.47882	PL.47881	B	6 A (CWC)	7.45Y	124.1	0.04	0.90	10.03	7	73	18	97	0.02	0.0	12.111	0.094	15	4	2	18
PL.47883	PL.47882	B	6 A (CWC)	7.45Y	124.1	0.01	0.91	5.95	4	43	10	97	0.00	0.0	12.150	0.039	0	0	0	14
PL.47884	PL.47883	B	6 A (CWC)	7.45Y	124.1	0.01	0.92	5.95	4	43	10	97	0.00	0.0	12.177	0.027	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.47459	PL.47884	B	6 A (CWC)	7.45Y	124.1	0.00	0.92	0.53	0	4	1	97	0.00	0.0	12.250	0.074	4	1	2	2
PL.47885	PL.47884	B	6 A (CWC)	7.44Y	124.1	0.02	0.93	5.42	4	39	10	97	0.00	0.0	12.248	0.071	3	1	1	12
PL.47886	PL.47885	B	6 A (CWC)	7.44Y	124.1	0.02	0.95	5.07	4	37	9	97	0.00	0.0	12.314	0.067	0	0	0	11
PL.47909	PL.47886	B	6 A (CWC)	7.44Y	124.1	0.00	0.95	0.68	0	5	1	98	0.00	0.0	12.369	0.055	5	1	2	2
PL.47887	PL.47886	B	6 A (CWC)	7.44Y	124.0	0.00	0.95	4.39	3	32	8	97	0.00	0.0	12.343	0.028	10	3	1	9
PL.47888	PL.47887	B	6 A (CWC)	7.44Y	124.0	0.01	0.96	2.94	2	21	5	97	0.00	0.0	12.410	0.067	2	0	1	8
PL.47889	PL.47888	B	6 A (CWC)	7.44Y	124.0	0.00	0.96	2.73	2	20	5	97	0.00	0.0	12.424	0.015	6	1	1	7
PL.59563	PL.47889	B	6 A (CWC)	7.44Y	124.0	0.00	0.97	1.68	1	12	3	97	0.00	0.0	12.483	0.058	8	2	2	5
PL.59564	PL.59563	B	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.61	0	4	1	97	0.00	0.0	12.615	0.133	4	1	1	3
PL.47890	PL.59564	B	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.01	0	0	0	100	0.00	0.0	12.711	0.096	0	0	0	2
PL.47718	PL.47890	B	#4 ACSR	7.44Y	124.0	0.00	0.97	0.00	0	0	0	100	0.00	0.0	12.750	0.038	0	0	0	0
PL.47891	PL.47890	B	6 A (CWC)	7.44Y	124.0	0.00	0.97	0.01	0	0	0	100	0.00	0.0	12.755	0.044	0	0	2	2
PL.60162	PL.47889	B	#1/0 ACSR	7.44Y	124.0	0.00	0.96	0.29	0	2	1	89	0.00	0.0	12.428	0.003	0	0	0	1
PD.8923	PL.60162	B	15T	7.44Y	124.0	0.00	0.96	0.29	0	2	1	89	0.00	0.0	12.428	0.003	0	0	0	1
PL.60163	PD.8923	B	#1/0 ACSR	7.44Y	124.0	0.00	0.96	0.29	0	2	1	89	0.00	0.0	12.540	0.112	2	1	1	1
PL.47702	PL.47882	B	#4 ACSR	7.45Y	124.1	0.00	0.90	2.05	2	15	4	97	0.00	0.0	12.132	0.021	15	4	2	2
PL.46923	PL.47480	C	#2 ACSR	7.46Y	124.3	0.00	0.67	0.15	0	1	0	100	0.00	0.0	11.620	0.044	1	0	1	1
PL.47307	PL.47309	C	#2 ACSR	7.46Y	124.3	0.00	0.66	0.95	1	7	2	96	0.00	0.0	11.509	0.001	0	0	0	1
PD.7498	PL.47307	C	60QA	7.46Y	124.3	0.00	0.66	0.95	2	7	2	96	0.00	0.0	11.509	0.001	0	0	0	1
PL.47308	PD.7498	C	#2 ACSR	7.46Y	124.3	0.00	0.66	0.95	1	7	2	96	0.00	0.0	11.578	0.069	7	2	1	1
PL.47305	PL.47309	A	6 A (CWC)	7.46Y	124.3	0.00	0.66	12.08	9	88	21	97	0.00	0.0	11.508	0.001	0	0	0	19
PD.7365	PL.47305	A	60QA	7.46Y	124.3	0.00	0.66	12.08	20	88	21	97	0.00	0.0	11.508	0.001	0	0	0	19
PL.47306	PD.7365	A	6 A (CWC)	7.46Y	124.3	0.05	0.71	12.08	9	88	21	97	0.03	0.0	11.599	0.090	0	0	0	19
PL.46903	PL.47306	A	#4 ACSR	7.46Y	124.3	0.00	0.71	2.27	2	16	4	97	0.00	0.0	11.639	0.040	0	0	0	3
PL.48899	PL.46903	A	#4 ACSR	7.46Y	124.3	0.00	0.71	1.12	1	8	2	97	0.00	0.0	11.676	0.037	0	0	1	2
PL.48900	PL.48899	A	#4 ACSR	7.46Y	124.3	0.00	0.71	1.12	1	8	2	97	0.00	0.0	11.703	0.027	8	2	1	1
PL.46481	PL.46903	A	#2 ACSR	7.46Y	124.3	0.00	0.71	1.16	1	8	2	97	0.00	0.0	11.669	0.030	8	2	1	1
PL.46902	PL.47306	A	6 A (CWC)	7.46Y	124.3	0.02	0.73	9.80	7	71	17	97	0.01	0.0	11.649	0.051	9	2	2	16
PL.46904	PL.46902	A	6 A (CWC)	7.46Y	124.3	0.01	0.74	8.59	6	62	15	97	0.01	0.0	11.678	0.029	0	0	0	14
PL.47703	PL.46904	A	#4 ACSR	7.46Y	124.3	0.00	0.74	3.71	3	27	7	97	0.00	0.0	11.691	0.013	27	7	4	4
PL.47134	PL.46904	A	6 A (CWC)	7.46Y	124.3	0.01	0.75	4.88	3	35	9	97	0.00	0.0	11.717	0.039	10	2	1	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.47755	PL.47134	A	#2 ACSR	7.46Y	124.3	0.00	0.75	0.00	0	0	0	100	0.00	0.0	11.749	0.031	0	0	1	1
PL.47390	PL.47134	A	6 A (CWC)	7.45Y	124.2	0.01	0.76	3.52	3	26	6	97	0.00	0.0	11.788	0.071	4	1	1	8
PL.47543	PL.47390	A	#4 ACSR	7.45Y	124.2	0.01	0.76	0.92	1	7	2	96	0.00	0.0	12.070	0.282	7	2	1	1
PL.47391	PL.47390	A	6 A (CWC)	7.45Y	124.2	0.00	0.76	2.05	1	15	4	97	0.00	0.0	11.834	0.045	3	1	1	6
PL.47392	PL.47391	A	6 A (CWC)	7.45Y	124.2	0.00	0.76	1.67	1	12	3	97	0.00	0.0	11.909	0.076	5	1	2	5
PL.47643	PL.47392	A	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.94	1	7	2	96	0.00	0.0	11.985	0.076	0	0	2	3
PL.47644	PL.47643	A	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.90	1	7	2	96	0.00	0.0	12.027	0.042	0	0	0	1
PL.47411	PL.47644	A	6 A (CWC)	7.45Y	124.2	0.00	0.77	0.90	1	7	2	96	0.00	0.0	12.109	0.081	7	2	1	1
PL.60032	PL.60031	A	#2 ACSR	7.47Y	124.5	0.00	0.51	2.71	2	20	5	97	0.00	0.0	11.135	0.003	0	0	0	5
PD.8911	PL.60032	A	40QA	7.47Y	124.5	0.00	0.51	2.71	7	20	5	97	0.00	0.0	11.135	0.003	0	0	0	5
PL.65296	PD.8911	A	#2 ACSR	7.47Y	124.5	0.00	0.51	2.71	2	20	5	97	0.00	0.0	11.199	0.064	5	1	2	5
PL.65297	PL.65296	A	#2 ACSR	7.47Y	124.5	0.00	0.51	2.07	1	15	4	97	0.00	0.0	11.199	0.000	15	4	3	3
PL.63458	PL.63459	C	#2 ACSR	7.48Y	124.6	0.00	0.41	3.84	2	28	7	97	0.00	0.0	10.980	0.001	0	0	0	5
PD.7481	PL.63458	C	40QA	7.48Y	124.6	0.00	0.41	3.84	10	28	7	97	0.00	0.0	10.980	0.001	0	0	0	5
PL.59591	PD.7481	C	#2 ACSR	7.48Y	124.6	0.01	0.42	3.84	2	28	7	97	0.00	0.0	11.045	0.064	6	2	1	5
PL.59592	PL.59591	C	#2 ACSR	7.47Y	124.6	0.00	0.42	2.97	2	22	5	98	0.00	0.0	11.058	0.013	16	4	3	4
PL.59593	PL.59592	C	#2 ACSR	7.47Y	124.6	0.00	0.42	0.74	0	5	1	98	0.00	0.0	11.087	0.030	5	1	1	1
PL.48934	PL.63706	B	#4 ACSR	7.48Y	124.6	0.00	0.37	2.63	2	19	5	97	0.00	0.0	10.930	0.001	0	0	0	4
PD.7386	PL.48934	B	40QA	7.48Y	124.6	0.00	0.37	2.63	7	19	5	97	0.00	0.0	10.930	0.001	0	0	0	4
PL.48935	PD.7386	B	#4 ACSR	7.48Y	124.6	0.00	0.37	2.63	2	19	5	97	0.00	0.0	10.959	0.029	10	2	2	4
PL.48936	PL.48935	B	#4 ACSR	7.48Y	124.6	0.00	0.37	1.30	1	9	2	98	0.00	0.0	10.975	0.016	6	1	1	2
PL.48094	PL.48936	B	#4 ACSR	7.48Y	124.6	0.00	0.37	0.50	0	4	1	97	0.00	0.0	10.993	0.019	4	1	1	1
PL.48095	PL.65276	C	6 A (CWC)	7.48Y	124.6	0.00	0.35	1.04	1	8	2	97	0.00	0.0	10.907	0.002	0	0	0	1
PD.7595	PL.48095	C	40QA	7.48Y	124.6	0.00	0.35	1.04	3	8	2	97	0.00	0.0	10.907	0.002	0	0	0	1
PL.48096	PD.7595	C	6 A (CWC)	7.48Y	124.6	0.00	0.35	1.04	1	8	2	97	0.00	0.0	10.936	0.029	8	2	1	1
PL.47940	PL.48966	ABC	#1/0 ACSR	7.49Y	124.9	0.00	0.08	16.27	7	355	87	97	0.01	0.0	10.601	0.016	5	1	1	77
PL.59585	PL.47940	ABC	#1/0 ACSR	7.49Y	124.9	0.02	0.10	16.05	7	350	86	97	0.05	0.0	10.673	0.072	8	2	1	76
PL.59586	PL.59585	ABC	#1/0 ACSR	7.49Y	124.9	0.01	0.12	15.68	7	342	84	97	0.03	0.0	10.721	0.049	0	0	0	75
PL.47941	PL.59586	ABC	#1/0 ACSR	7.49Y	124.9	0.02	0.14	15.40	7	336	82	97	0.04	0.0	10.784	0.063	0	0	0	72
PL.48903	PL.47941	ABC	#1/0 ACSR	7.49Y	124.9	0.00	0.14	15.40	7	336	82	97	0.00	0.0	10.785	0.001	0	0	0	72
PD.7583	PL.48903	ABC	40QA	7.49Y	124.9	0.00	0.14	15.40	38	336	82	97	0.00	0.0	10.785	0.001	0	0	0	72

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48904	PD.7583	ABC	#1/0 ACSR	7.49Y	124.8	0.02	0.15	15.40	7	336	82	97	0.04	0.0	10.842	0.057	0	0	0	72
PL.48905	PL.48904	B	#1/0 ACSR	7.49Y	124.8	0.00	0.15	2.94	1	21	5	97	0.00	0.0	10.843	0.001	0	0	0	6
PD.7373	PL.48905	B	40QA	7.49Y	124.8	0.00	0.15	2.94	7	21	5	97	0.00	0.0	10.843	0.001	0	0	0	6
PL.59588	PD.7373	B	#1/0 ACSR	7.49Y	124.8	0.01	0.16	2.94	1	21	5	97	0.00	0.0	10.945	0.102	0	0	1	6
PL.59589	PL.59588	B	#1/0 ACSR	7.49Y	124.8	0.00	0.16	0.87	0	6	2	95	0.00	0.0	11.005	0.060	0	0	0	2
PL.47269	PL.59589	B	#4 ACSR	7.49Y	124.8	0.00	0.16	0.87	1	6	2	95	0.00	0.0	11.037	0.032	6	2	2	2
PL.59590	PL.59588	B	#4 ACSR	7.49Y	124.8	0.00	0.16	0.68	1	5	1	98	0.00	0.0	10.997	0.052	3	1	1	2
PL.48084	PL.59590	B	#4 ACSR	7.49Y	124.8	0.00	0.16	0.29	0	2	1	89	0.00	0.0	11.053	0.055	2	1	1	1
PL.48085	PL.48084	B	#4 ACSR	7.49Y	124.8	0.00	0.16	0.00	0	0	0	100	0.00	0.0	11.075	0.023	0	0	0	0
PL.59587	PL.59588	B	#4 ACSR	7.49Y	124.8	0.00	0.16	1.38	1	10	2	98	0.00	0.0	10.955	0.010	10	2	1	1
PL.48906	PL.48904	ABC	#1/0 ACSR	7.49Y	124.8	0.03	0.18	14.42	6	315	77	97	0.06	0.0	10.944	0.102	5	1	1	66
PL.48086	PL.48906	ABC	#1/0 ACSR	7.49Y	124.8	0.02	0.19	14.17	6	309	76	97	0.04	0.0	11.013	0.068	9	2	2	65
PL.48087	PL.48086	ABC	#1/0 ACSR	7.49Y	124.8	0.03	0.22	13.76	6	300	73	97	0.05	0.0	11.121	0.109	0	0	0	63
PL.47931	PL.48087	ABC	#1/0 ACSR	7.49Y	124.8	0.01	0.23	9.89	4	216	53	97	0.01	0.0	11.158	0.037	3	1	1	46
PL.46952	PL.47931	ABC	#1/0 ACSR	7.49Y	124.8	0.01	0.24	9.74	4	212	52	97	0.01	0.0	11.215	0.056	0	0	0	45
PL.46953	PL.46952	A	#1/0 ACSR	7.49Y	124.8	0.00	0.24	1.08	0	8	2	97	0.00	0.0	11.216	0.001	0	0	0	1
PD.7393	PL.46953	A	40QA	7.49Y	124.8	0.00	0.24	1.08	3	8	2	97	0.00	0.0	11.216	0.001	0	0	0	1
PL.47576	PD.7393	A	#1/0 ACSR	7.49Y	124.8	0.00	0.24	1.08	0	8	2	97	0.00	0.0	11.242	0.026	8	2	1	1
PL.47577	PL.46952	ABC	#1/0 ACSR	7.49Y	124.8	0.01	0.25	9.38	4	205	50	97	0.01	0.0	11.268	0.053	0	0	0	44
PL.47578	PL.47577	ABC	#1/0 ACSR	7.48Y	124.7	0.01	0.25	9.17	4	200	49	97	0.01	0.0	11.322	0.054	9	2	2	42
PL.59580	PL.47578	ABC	#1/0 ACSR	7.48Y	124.7	0.01	0.26	8.75	4	191	47	97	0.01	0.0	11.374	0.052	14	3	2	40
PL.59581	PL.59580	ABC	#1/0 ACSR	7.48Y	124.7	0.00	0.27	8.10	4	177	43	97	0.00	0.0	11.403	0.029	3	1	1	38
PL.48581	PL.59581	ABC	#1/0 ACSR	7.48Y	124.7	0.02	0.28	7.98	3	174	43	97	0.02	0.0	11.526	0.123	3	1	1	37
PL.48582	PL.48581	A	#4 ACSR	7.48Y	124.7	0.00	0.28	0.90	1	7	2	96	0.00	0.0	11.528	0.002	0	0	0	1
PD.7584	PL.48582	A	40QA	7.48Y	124.7	0.00	0.28	0.90	2	7	2	96	0.00	0.0	11.528	0.002	0	0	0	1
PL.48583	PD.7584	A	#4 ACSR	7.48Y	124.7	0.00	0.29	0.90	1	7	2	96	0.00	0.0	11.627	0.098	0	0	0	1
PL.48584	PL.48583	A	#4 ACSR	7.48Y	124.7	0.00	0.29	0.90	1	7	2	96	0.00	0.0	11.699	0.073	0	0	0	1
PL.47557	PL.48584	A	#4 ACSR	7.48Y	124.7	0.01	0.30	0.90	1	7	2	96	0.00	0.0	12.150	0.451	7	2	1	1
PL.48585	PL.48581	ABC	#1/0 ACSR	7.48Y	124.7	0.00	0.29	7.56	3	165	40	97	0.00	0.0	11.555	0.028	0	0	0	35
PL.48586	PL.48585	ABC	#1/0 ACSR	7.48Y	124.7	0.01	0.29	7.30	3	159	39	97	0.01	0.0	11.612	0.057	4	1	2	34
PL.48593	PL.48586	A	6 A (CWC)	7.48Y	124.7	0.00	0.30	21.33	15	155	38	97	0.00	0.0	11.613	0.001	0	0	0	32

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.7396	PL.48593	A	40QA	7.48Y	124.7	0.00	0.30	21.33	53	155	38	97	0.00	0.0	11.613	0.001	0	0	0	32
PL.48594	PD.7396	A	6 A (CWC)	7.48Y	124.7	0.03	0.32	21.33	15	155	38	97	0.03	0.0	11.643	0.031	2	1	1	32
PL.48595	PL.48594	A	6 A (CWC)	7.47Y	124.5	0.17	0.50	21.03	15	153	37	97	0.19	0.1	11.826	0.182	6	1	1	31
PL.47607	PL.48595	A	6 A (CWC)	7.47Y	124.4	0.07	0.57	9.86	7	72	17	97	0.04	0.1	11.998	0.172	8	2	3	16
PL.47617	PL.47607	A	#4 ACSR	7.46Y	124.4	0.02	0.59	7.16	6	52	13	97	0.01	0.0	12.084	0.086	26	6	3	10
PL.47618	PL.47617	A	#4 ACSR	7.46Y	124.4	0.01	0.59	3.57	3	26	6	97	0.00	0.0	12.116	0.032	0	0	0	7
PL.47619	PL.47618	A	#4 ACSR	7.46Y	124.4	0.01	0.60	2.64	2	19	5	97	0.00	0.0	12.176	0.060	3	1	1	6
PL.47620	PL.47619	A	#4 ACSR	7.46Y	124.4	0.04	0.64	2.24	2	16	4	97	0.01	0.0	12.607	0.431	0	0	0	5
PL.48596	PL.47620	A	#4 ACSR	7.46Y	124.3	0.03	0.67	2.17	2	16	4	97	0.00	0.0	12.994	0.387	10	2	3	4
PL.48937	PL.48596	A	#4 ACSR	7.46Y	124.3	0.00	0.67	0.81	1	6	1	99	0.00	0.0	13.036	0.042	6	1	1	1
PL.48938	PL.47620	A	#4 ACSR	7.46Y	124.4	0.00	0.64	0.07	0	1	0	100	0.00	0.0	12.635	0.028	1	0	1	1
PL.48939	PL.48938	A	#4 ACSR	7.46Y	124.4	0.00	0.64	0.00	0	0	0	100	0.00	0.0	13.096	0.461	0	0	0	0
PL.48940	PL.48939	A	#4 ACSR	7.46Y	124.4	0.00	0.64	0.00	0	0	0	100	0.00	0.0	13.277	0.181	0	0	0	0
PL.47320	PL.47618	A	#4 ACSR	7.46Y	124.4	0.00	0.59	0.94	1	7	2	96	0.00	0.0	12.175	0.059	7	2	1	1
PL.47615	PL.47607	A	#4 ACSR	7.47Y	124.4	0.01	0.57	1.60	1	12	3	97	0.00	0.0	12.090	0.092	0	0	0	3
PL.47616	PL.47615	A	#4 ACSR	7.47Y	124.4	0.00	0.57	1.60	1	12	3	97	0.00	0.0	12.107	0.017	12	3	3	3
PL.47608	PL.48595	A	6 A (CWC)	7.47Y	124.5	0.00	0.50	2.99	2	22	5	98	0.00	0.0	11.867	0.041	6	2	2	7
PL.47609	PL.47608	A	6 A (CWC)	7.47Y	124.5	0.00	0.50	2.13	2	15	4	97	0.00	0.0	11.916	0.050	7	2	2	5
PL.47613	PL.47609	A	6 A (CWC)	7.47Y	124.5	0.00	0.51	1.19	1	9	2	98	0.00	0.0	11.991	0.075	9	2	3	3
PL.47614	PL.47613	A	6 A (CWC)	7.47Y	124.5	0.00	0.51	0.00	0	0	0	100	0.00	0.0	12.082	0.091	0	0	0	0
PL.47610	PL.48595	A	#4 ACSR	7.47Y	124.5	0.02	0.52	7.38	6	54	13	97	0.01	0.0	11.917	0.091	24	6	3	7
PL.47611	PL.47610	A	#4 ACSR	7.47Y	124.5	0.01	0.52	4.04	3	29	7	97	0.00	0.0	11.954	0.037	13	3	2	4
PL.47612	PL.47611	A	#4 ACSR	7.47Y	124.5	0.00	0.53	2.29	2	17	4	97	0.00	0.0	12.044	0.090	17	4	2	2
PL.48591	PL.48585	A	6 A (CWC)	7.48Y	124.7	0.00	0.29	0.78	1	6	1	99	0.00	0.0	11.556	0.002	0	0	0	1
PD.7585	PL.48591	A	40QA	7.48Y	124.7	0.00	0.29	0.78	2	6	1	99	0.00	0.0	11.556	0.002	0	0	0	1
PL.48592	PD.7585	A	6 A (CWC)	7.48Y	124.7	0.00	0.29	0.78	1	6	1	99	0.00	0.0	11.613	0.057	6	1	1	1
PL.48587	PL.48585	C	#1/0 ACSR	7.48Y	124.7	0.00	0.29	0.00	0	0	0	100	0.00	0.0	11.556	0.002	0	0	0	0
PD.7486	PL.48587	C	40QA	7.48Y	124.7	0.00	0.29	0.00	0	0	0	100	0.00	0.0	11.556	0.002	0	0	0	0
PL.48590	PD.7486	C	#1/0 ACSR	7.48Y	124.7	0.00	0.29	0.00	0	0	0	100	0.00	0.0	11.622	0.066	0	0	0	0
PL.47579	PL.47577	A	#1/0 ACSR	7.49Y	124.8	0.00	0.25	0.62	0	5	1	98	0.00	0.0	11.269	0.001	0	0	0	2
PD.7395	PL.47579	A	40QA	7.49Y	124.8	0.00	0.25	0.62	2	5	1	98	0.00	0.0	11.269	0.001	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.47143	PD.7395	A	#1/0 ACSR	7.49Y	124.8	0.00	0.25	0.62	0	5	1	98	0.00	0.0	11.352	0.083	2	0	1	2
PL.47144	PL.47143	A	#1/0 ACSR	7.49Y	124.8	0.00	0.25	0.36	0	3	1	95	0.00	0.0	11.431	0.079	3	1	1	1
PL.48089	PL.48087	C	6 A (CWC)	7.49Y	124.8	0.00	0.22	0.00	0	0	0	100	0.00	0.0	11.123	0.002	0	0	0	1
PD.7490	PL.48089	C	40QA	7.49Y	124.8	0.00	0.22	0.00	0	0	0	100	0.00	0.0	11.123	0.002	0	0	0	1
PL.48090	PD.7490	C	6 A (CWC)	7.49Y	124.8	0.00	0.22	0.00	0	0	0	100	0.00	0.0	11.163	0.040	0	0	1	1
PL.48091	PL.48087	A	6 A (CWC)	7.49Y	124.8	0.00	0.22	11.61	8	84	21	97	0.00	0.0	11.123	0.002	0	0	0	16
PD.7550	PL.48091	A	40QA	7.49Y	124.8	0.00	0.22	11.61	29	84	21	97	0.00	0.0	11.123	0.002	0	0	0	16
PL.48092	PD.7550	A	6 A (CWC)	7.49Y	124.8	0.02	0.24	11.61	8	84	21	97	0.01	0.0	11.162	0.039	0	0	0	16
PL.48093	PL.48092	A	6 A (CWC)	7.48Y	124.7	0.02	0.26	10.24	7	74	18	97	0.01	0.0	11.207	0.045	21	5	3	12
PL.47930	PL.48093	A	6 A (CWC)	7.48Y	124.7	0.01	0.27	7.36	5	54	13	97	0.00	0.0	11.243	0.036	6	1	1	9
PL.47932	PL.47930	A	6 A (CWC)	7.48Y	124.7	0.01	0.28	5.24	4	38	9	97	0.00	0.0	11.300	0.057	3	1	1	6
PL.59010	PL.47932	A	6 A (CWC)	7.48Y	124.7	0.01	0.29	4.82	3	35	9	97	0.00	0.0	11.335	0.035	1	0	1	5
PL.59011	PL.59010	A	6 A (CWC)	7.48Y	124.7	0.00	0.29	1.23	1	9	2	98	0.00	0.0	11.403	0.069	9	2	2	2
PL.59012	PL.59010	A	#1/0 ACSR	7.48Y	124.7	0.00	0.29	3.52	2	26	6	97	0.00	0.0	11.336	0.002	0	0	0	2
PD.8663	PL.59012	A	15T	7.48Y	124.7	0.00	0.29	3.52	0	26	6	97	0.00	0.0	11.336	0.002	0	0	0	2
PL.59013	PD.8663	A	#1/0 ACSR	7.48Y	124.7	0.00	0.29	3.52	2	26	6	97	0.00	0.0	11.346	0.010	26	6	2	2
PL.48088	PL.47930	A	6 A (CWC)	7.48Y	124.7	0.00	0.27	1.33	1	10	2	98	0.00	0.0	11.273	0.030	10	2	2	2
PL.49463	PL.48088	A	6 A (CWC)	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	11.294	0.022	0	0	0	0
PL.49464	PL.49463	A	6 A (CWC)	7.48Y	124.7	0.00	0.27	0.00	0	0	0	100	0.00	0.0	11.309	0.015	0	0	0	0
PL.47933	PL.48092	A	6 A (CWC)	7.49Y	124.8	0.00	0.24	1.15	1	8	2	97	0.00	0.0	11.222	0.061	8	2	1	2
PL.47934	PL.47933	A	6 A (CWC)	7.49Y	124.8	0.00	0.24	0.01	0	0	0	100	0.00	0.0	11.255	0.033	0	0	0	1
PL.48189	PL.47934	A	6 A (CWC)	7.49Y	124.8	0.00	0.24	0.01	0	0	0	100	0.00	0.0	11.304	0.049	0	0	1	1
PL.64606	PL.48092	A	#1/0 ACSR	7.49Y	124.8	0.00	0.24	0.22	0	2	0	100	0.00	0.0	11.191	0.030	2	0	2	2
PL.48901	PL.59586	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	0.85	0	6	2	95	0.00	0.0	10.723	0.001	0	0	0	3
PD.7394	PL.48901	A	40QA	7.49Y	124.9	0.00	0.12	0.85	2	6	2	95	0.00	0.0	10.723	0.001	0	0	0	3
PL.48902	PD.7394	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	0.85	0	6	2	95	0.00	0.0	10.746	0.023	2	0	1	3
PL.47429	PL.48902	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	0.64	0	5	1	98	0.00	0.0	10.803	0.057	5	1	2	2
PL.47430	PL.47429	A	#1/0 ACSR	7.49Y	124.9	0.00	0.12	0.00	0	0	0	100	0.00	0.0	10.860	0.057	0	0	0	0
PL.48968	PL.48967	A	6 A (CWC)	7.52Y	125.3	0.00	-0.26	0.29	0	2	1	89	0.00	0.0	10.324	0.001	0	0	0	2
PD.7531	PL.48968	A	40QA	7.52Y	125.3	0.00	-0.26	0.29	1	2	1	89	0.00	0.0	10.324	0.001	0	0	0	2
PL.48969	PD.7531	A	6 A (CWC)	7.52Y	125.3	0.00	-0.26	0.29	0	2	1	89	0.00	0.0	10.374	0.050	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.48970	PL.48969	A	6 A (CWC)	7.52Y	125.3	0.00	-0.26	0.29	0	2	1	89	0.00	0.0	10.438	0.064	1	0	1	2
PL.48199	PL.48970	A	6 A (CWC)	7.52Y	125.3	0.00	-0.25	0.21	0	2	0	100	0.00	0.0	10.488	0.050	0	0	0	1
PL.48200	PL.48199	A	6 A (CWC)	7.52Y	125.3	0.00	-0.25	0.21	0	2	0	100	0.00	0.0	10.614	0.126	0	0	0	1
PL.48201	PL.48200	A	6 A (CWC)	7.52Y	125.3	0.00	-0.25	0.21	0	2	0	100	0.00	0.0	10.689	0.075	2	0	1	1
PL.62116	PL.62114	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	1.73	1	12	3	97	0.00	0.0	9.649	0.001	0	0	0	2
PD.7398	PL.62116	C	40QA	7.13Y	118.9	0.00	6.11	1.73	4	12	3	97	0.00	0.0	9.649	0.001	0	0	0	2
PL.48964	PD.7398	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	1.73	1	12	3	97	0.00	0.0	9.690	0.041	0	0	0	2
PL.59549	PL.48964	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	1.73	1	12	3	97	0.00	0.0	9.744	0.054	12	3	2	2
PL.59550	PL.59549	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.00	0	0	0	100	0.00	0.0	9.783	0.039	0	0	0	0
PL.48963	PL.48964	C	6 A (CWC)	7.13Y	118.9	0.00	6.11	0.00	0	0	0	100	0.00	0.0	9.831	0.141	0	0	0	0
PL.57370	PL.57369	A	#1/0 ACSR	7.20Y	120.0	0.00	5.03	0.68	0	5	1	98	0.00	0.0	8.679	0.005	0	0	0	1
PD.7923	PL.57370	A	10QA	7.20Y	120.0	0.00	5.03	0.68	0	5	1	98	0.00	0.0	8.679	0.005	0	0	0	1
PL.53630	PD.7923	A	#1/0 ACSR	7.20Y	120.0	0.00	5.03	0.68	0	5	1	98	0.00	0.0	8.731	0.052	5	1	1	1
PL.53629	PL.53628	A	#2 ACSR	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	8.262	0.003	0	0	0	0
PD.7922	PL.53629	A	10QA	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	8.262	0.003	0	0	0	0
PL.53627	PD.7922	A	#2 ACSR	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	8.336	0.074	0	0	0	0
PL.57374	PL.53628	C	6 A (CWC)	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	8.261	0.002	0	0	0	0
PD.8357-B	PL.57374	C	Open	7.23Y	120.4	0.00	4.55	0.00	0	0	0	100	0.00	0.0	8.261	0.002	0	0	0	0
PL.57322	PL.57321	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.86	1	6	1	99	0.00	0.0	7.008	0.005	0	0	0	1
PD.7920	PL.57322	A	10QA	7.31Y	121.9	0.00	3.11	0.86	0	6	1	99	0.00	0.0	7.008	0.005	0	0	0	1
PL.53620	PD.7920	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.86	1	6	1	99	0.00	0.0	7.106	0.097	6	1	1	1
PL.53619	PL.53620	A	#4 ACSR	7.31Y	121.9	0.00	3.11	0.00	0	0	0	100	0.00	0.0	7.237	0.131	0	0	0	0
PL.53616	PL.53615	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	1.59	1	11	3	96	0.00	0.0	6.624	0.005	0	0	0	1
PD.7919	PL.53616	A	10QA	7.34Y	122.3	0.00	2.66	1.59	0	11	3	96	0.00	0.0	6.624	0.005	0	0	0	1
PL.53617	PD.7919	A	6 A (CWC)	7.34Y	122.3	0.00	2.66	1.59	1	11	3	96	0.00	0.0	6.684	0.060	11	3	1	1
PL.53607	PL.53606	C	#4 ACSR	7.42Y	123.7	0.00	1.32	0.47	0	3	1	95	0.00	0.0	5.505	0.003	0	0	0	1
PD.7915	PL.53607	C	10QA	7.42Y	123.7	0.00	1.32	0.47	0	3	1	95	0.00	0.0	5.505	0.003	0	0	0	1
PL.53605	PD.7915	C	#4 ACSR	7.42Y	123.7	0.00	1.32	0.47	0	3	1	95	0.00	0.0	5.576	0.071	3	1	1	1
PL.62136	PL.62135	A	#1/0 ACSR	7.14Y	118.9	0.00	6.07	0.69	0	5	1	98	0.00	0.0	4.948	0.004	0	0	0	1
PD.7913	PL.62136	A	10QA	7.14Y	118.9	0.00	6.07	0.69	0	5	1	98	0.00	0.0	4.948	0.004	0	0	0	1
PL.53413	PD.7913	A	#1/0 ACSR	7.14Y	118.9	0.00	6.07	0.69	0	5	1	98	0.00	0.0	4.964	0.016	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.53411	PL.53408	C	#4 ACSR	7.14Y	119.1	0.00	5.94	40.81	31	283	70	97	0.01	0.0	4.846	0.003	0	0	0	62
PD.7912	PL.53411	C	70L	7.14Y	119.1	0.00	5.94	40.81	58	283	70	97	0.00	0.0	4.846	0.003	0	0	0	62
PL.53412	PD.7912	C	#4 ACSR	7.14Y	119.0	0.04	5.98	40.81	31	283	70	97	0.08	0.0	4.866	0.020	0	0	0	62
PL.53410	PL.53412	C	#4 ACSR	7.12Y	118.6	0.37	6.35	40.02	31	277	69	97	0.80	0.3	5.080	0.214	7	2	1	61
PL.38453	PL.53410	C	#4 ACSR	7.12Y	118.6	0.05	6.40	38.99	30	269	67	97	0.10	0.0	5.106	0.027	0	0	0	60
PL.38452	PL.38453	C	#4 ACSR	7.11Y	118.5	0.13	6.53	38.99	30	269	67	97	0.28	0.1	5.182	0.076	1	0	1	60
REG86	PL.38452	C	76.2 KVA	7.53Y	125.5	-7.06	-0.53	38.82	39	268	66	97	percent Boost= 0.00		Tap= 0.0				59	
PL.37734	REG86	C	#4 ACSR	7.53Y	125.4	0.11	-0.42	36.64	28	268	66	97	0.22	0.1	5.251	0.068	4	1	1	59
PL.38451	PL.37734	C	#4 ACSR	7.52Y	125.3	0.13	-0.29	35.18	27	257	64	97	0.24	0.1	5.332	0.082	2	0	1	57
PL.37617	PL.38451	C	#4 ACSR	7.49Y	124.9	0.41	0.12	31.83	24	232	58	97	0.70	0.3	5.633	0.301	11	3	1	53
PL.57313	PL.37617	C	6 A (CWC)	7.49Y	124.9	0.00	0.12	8.88	6	65	16	97	0.00	0.0	5.636	0.003	0	0	0	14
PD.8276	PL.57313	C	60QA	7.49Y	124.9	0.00	0.12	8.88	15	65	16	97	0.00	0.0	5.636	0.003	0	0	0	14
PL.57314	PD.8276	C	6 A (CWC)	7.48Y	124.7	0.18	0.30	8.88	6	65	16	97	0.08	0.1	6.122	0.486	8	2	1	14
PL.38211	PL.57314	C	6 A (CWC)	7.48Y	124.7	0.00	0.30	0.00	0	0	0	100	0.00	0.0	6.291	0.169	0	0	0	0
PL.38212	PL.38211	C	6 A (CWC)	7.48Y	124.7	0.00	0.30	0.00	0	0	0	100	0.00	0.0	6.357	0.066	0	0	0	0
PL.38210	PL.57314	C	6 A (CWC)	7.47Y	124.5	0.23	0.54	7.72	6	56	14	97	0.10	0.2	6.791	0.669	0	0	0	13
PL.37621	PL.38210	C	6 A (CWC)	7.46Y	124.3	0.14	0.68	7.72	6	56	14	97	0.06	0.1	7.204	0.413	0	0	0	13
PL.37480	PL.37621	C	6 A (CWC)	7.46Y	124.3	0.00	0.68	0.00	0	0	0	100	0.00	0.0	7.313	0.109	0	0	0	0
PL.37620	PL.37621	C	6 A (CWC)	7.45Y	124.2	0.14	0.82	7.72	6	56	14	97	0.06	0.1	7.597	0.393	0	0	0	13
PL.37614	PL.37620	C	6 A (CWC)	7.44Y	124.0	0.15	0.97	7.56	5	55	13	97	0.06	0.1	8.097	0.500	13	3	1	11
PL.37613	PL.37614	C	6 A (CWC)	7.44Y	124.0	0.05	1.03	5.80	4	42	10	97	0.02	0.0	8.334	0.236	11	3	3	10
PL.37612	PL.37613	C	6 A (CWC)	7.44Y	124.0	0.02	1.04	4.25	3	31	7	98	0.00	0.0	8.428	0.094	0	0	0	6
PL.38209	PL.37612	C	6 A (CWC)	7.44Y	123.9	0.02	1.07	4.19	3	30	7	97	0.01	0.0	8.559	0.131	0	0	0	5
PL.37675	PL.38209	C	#2 ACSR	7.44Y	123.9	0.00	1.07	1.36	1	10	2	98	0.00	0.0	8.592	0.032	10	2	1	1
PL.37784	PL.38209	C	6 A (CWC)	7.44Y	123.9	0.01	1.07	1.42	1	10	2	98	0.00	0.0	8.644	0.085	0	0	0	2
PL.37782	PL.37784	C	#2 ACSR	7.44Y	123.9	0.00	1.08	1.01	1	7	2	96	0.00	0.0	8.687	0.043	7	2	1	1
PL.37783	PL.37782	C	#2 ACSR	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	8.763	0.076	0	0	0	0
PL.38208	PL.37784	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.40	0	3	1	95	0.00	0.0	8.692	0.048	0	0	0	1
PL.37781	PL.38208	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.40	0	3	1	95	0.00	0.0	8.738	0.046	3	1	1	1
PL.38207	PL.37781	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	8.821	0.083	0	0	0	0
PL.37780	PL.38207	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	8.980	0.159	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.57372	PL.37780	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	9.057	0.077	0	0	0	0
PL.57373	PL.57372	C	6 A (CWC)	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	9.367	0.309	0	0	0	0
PD.8357-A	PL.57373	C	Open	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	9.367	0.309	0	0	0	0
PL.37861	PL.38209	C	#2 ACSR	7.44Y	123.9	0.00	1.07	1.41	1	10	2	98	0.00	0.0	8.594	0.035	10	2	2	2
PL.37723	PL.37612	C	#4 ACSR	7.44Y	124.0	0.00	1.04	0.06	0	0	0	100	0.00	0.0	8.486	0.058	0	0	1	1
PL.37304	PL.37613	C	#4 ACSR	7.44Y	124.0	0.00	1.03	0.03	0	0	0	100	0.00	0.0	8.418	0.084	0	0	1	1
PL.37615	PL.37620	C	#4 ACSR	7.45Y	124.2	0.00	0.82	0.16	0	1	0	100	0.00	0.0	8.120	0.523	1	0	1	2
PL.37616	PL.37615	C	#4 ACSR	7.45Y	124.2	0.00	0.82	0.02	0	0	0	100	0.00	0.0	8.308	0.187	0	0	1	1
PL.37479	PL.38210	C	6 A (CWC)	7.47Y	124.5	0.00	0.54	0.00	0	0	0	100	0.00	0.0	7.164	0.373	0	0	0	0
PL.37281	PL.37617	C	#1/0 ACSR	7.49Y	124.8	0.03	0.15	21.50	9	156	39	97	0.03	0.0	5.698	0.065	1	0	1	38
PL.37282	PL.37281	C	#1/0 ACSR	7.49Y	124.8	0.02	0.17	21.36	9	155	38	97	0.02	0.0	5.730	0.033	0	0	0	37
PL.63841	PL.37282	C	#2 ACSR	7.49Y	124.8	0.03	0.20	1.25	1	9	2	98	0.00	0.0	6.550	0.819	0	0	0	1
PL.63842	PL.63841	C	#2 ACSR	7.49Y	124.8	0.00	0.20	0.00	0	0	0	100	0.00	0.0	6.885	0.335	0	0	0	0
PL.63843	PL.63841	C	#1/0 ACSR	7.49Y	124.8	0.00	0.20	1.25	1	9	2	98	0.00	0.0	6.622	0.073	0	0	0	1
PL.63844	PL.63843	C	#1/0 ACSR	7.49Y	124.8	0.00	0.20	1.25	1	9	2	98	0.00	0.0	6.734	0.112	0	0	0	1
PL.63845	PL.63844	C	#1/0 ACSR	7.49Y	124.8	0.00	0.21	1.25	1	9	2	98	0.00	0.0	6.790	0.056	9	2	1	1
PL.38454	PL.37282	C	#1/0 ACSR	7.48Y	124.6	0.23	0.40	20.11	9	146	36	97	0.22	0.1	6.238	0.508	3	1	1	36
PL.38455	PL.38454	C	#1/0 ACSR	7.47Y	124.6	0.03	0.42	18.48	8	134	33	97	0.02	0.0	6.302	0.063	0	0	0	32
PL.38457	PL.38455	C	6 A (CWC)	7.47Y	124.5	0.05	0.47	17.46	12	127	31	97	0.04	0.0	6.359	0.057	0	0	0	31
PL.38458	PL.38457	C	6 A (CWC)	7.47Y	124.5	0.04	0.51	17.46	12	127	31	97	0.03	0.0	6.406	0.047	0	0	0	31
PL.37646	PL.38458	C	6 A (CWC)	7.47Y	124.4	0.05	0.55	15.81	11	115	28	97	0.04	0.0	6.469	0.064	0	0	0	29
PL.63054	PL.37646	C	6 A (CWC)	7.46Y	124.4	0.06	0.61	15.81	11	115	28	97	0.05	0.0	6.551	0.081	0	0	0	29
PL.63056	PL.63054	C	#1/0 ACSR	7.46Y	124.4	0.00	0.61	0.97	0	7	2	96	0.00	0.0	6.555	0.004	0	0	0	1
PD.9410	PL.63056	C	25T	7.46Y	124.4	0.00	0.61	0.97	0	7	2	96	0.00	0.0	6.555	0.004	0	0	0	1
PL.63057	PD.9410	C	#1/0 ACSR	7.46Y	124.4	0.00	0.61	0.97	0	7	2	96	0.00	0.0	6.630	0.075	7	2	1	1
PL.63055	PL.63054	C	6 A (CWC)	7.44Y	124.0	0.39	1.00	14.84	11	108	26	97	0.31	0.3	7.136	0.585	2	0	2	28
PL.37647	PL.63055	C	6 A (CWC)	7.44Y	123.9	0.05	1.05	14.57	10	105	26	97	0.04	0.0	7.212	0.076	0	0	1	26
PL.38459	PL.37647	C	6 A (CWC)	7.43Y	123.9	0.10	1.15	14.56	10	105	26	97	0.07	0.1	7.356	0.144	0	0	0	25
PL.57782	PL.38459	C	6 A (CWC)	7.43Y	123.8	0.03	1.18	14.56	10	105	26	97	0.02	0.0	7.404	0.047	11	3	3	25
PL.57783	PL.57782	C	6 A (CWC)	7.43Y	123.8	0.02	1.20	13.01	9	94	23	97	0.02	0.0	7.443	0.039	0	0	0	22
PL.37648	PL.57783	C	6 A (CWC)	7.42Y	123.7	0.10	1.30	13.01	9	94	23	97	0.07	0.1	7.607	0.165	0	0	0	22

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38460	PL.37648	C	6 A (CWC)	7.42Y	123.7	0.05	1.35	11.63	8	84	21	97	0.03	0.0	7.706	0.099	0	0	0	21
PL.38461	PL.38460	C	6 A (CWC)	7.41Y	123.5	0.14	1.49	10.83	8	78	19	97	0.08	0.1	7.991	0.285	0	0	1	20
PL.38462	PL.38461	C	6 A (CWC)	7.41Y	123.5	0.05	1.54	10.78	8	78	19	97	0.03	0.0	8.093	0.102	0	0	0	19
PL.38463	PL.38462	C	6 A (CWC)	7.41Y	123.5	0.00	1.54	5.99	4	43	11	97	0.00	0.0	8.099	0.006	0	0	0	10
PD.6071	PL.38463	C	40QA	7.41Y	123.5	0.00	1.54	5.99	15	43	11	97	0.00	0.0	8.099	0.006	0	0	0	10
PL.57643	PD.6071	C	6 A (CWC)	7.41Y	123.4	0.02	1.56	5.99	4	43	11	97	0.01	0.0	8.174	0.075	2	1	2	10
PL.57642	PL.57643	C	6 A (CWC)	7.41Y	123.4	0.02	1.57	5.66	4	41	10	97	0.00	0.0	8.232	0.059	0	0	0	8
PL.38465	PL.57642	C	6 A (CWC)	7.40Y	123.4	0.03	1.60	5.66	4	41	10	97	0.01	0.0	8.341	0.109	0	0	0	8
PL.37765	PL.38465	C	6 A (CWC)	7.40Y	123.4	0.00	1.60	2.00	1	14	3	98	0.00	0.0	8.408	0.066	14	3	2	2
PL.38046	PL.38465	C	6 A (CWC)	7.40Y	123.4	0.04	1.64	3.67	3	26	6	97	0.01	0.0	8.627	0.285	6	1	1	6
PL.38047	PL.38046	C	6 A (CWC)	7.40Y	123.3	0.02	1.66	2.84	2	20	5	97	0.00	0.0	8.773	0.147	5	1	1	5
PL.38466	PL.38047	C	6 A (CWC)	7.40Y	123.3	0.01	1.67	2.13	2	15	4	97	0.00	0.0	8.835	0.062	0	0	0	4
PL.37643	PL.38466	C	#4 ACSR	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	8.866	0.032	0	0	0	0
PL.37649	PL.38466	C	6 A (CWC)	7.40Y	123.3	0.03	1.70	2.13	2	15	4	97	0.00	0.0	9.185	0.350	0	0	0	4
PL.38467	PL.37649	C	6 A (CWC)	7.40Y	123.3	0.00	1.70	2.13	2	15	4	97	0.00	0.0	9.234	0.049	3	1	1	4
PL.38436	PL.38467	C	6 A (CWC)	7.40Y	123.3	0.00	1.71	1.76	1	13	3	97	0.00	0.0	9.304	0.069	5	1	1	3
PL.38468	PL.38436	C	6 A (CWC)	7.40Y	123.3	0.00	1.71	1.07	1	8	2	97	0.00	0.0	9.392	0.089	0	0	1	2
PL.38469	PL.38468	C	6 A (CWC)	7.40Y	123.3	0.01	1.73	1.04	1	7	2	96	0.00	0.0	9.694	0.302	0	0	0	1
PL.38470	PL.38469	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	9.695	0.001	0	0	0	0
PD.5233	PL.38470	C	25QA	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	9.695	0.001	0	0	0	0
PL.38471	PD.5233	C	6 A (CWC)	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	9.814	0.119	0	0	0	0
PL.36874	PL.38469	C	6 A (CWC)	7.40Y	123.3	0.02	1.75	1.04	1	7	2	96	0.00	0.0	10.176	0.482	0	0	0	1
PL.36873	PL.36874	C	6 A (CWC)	7.39Y	123.2	0.02	1.77	1.04	1	7	2	96	0.00	0.0	10.592	0.416	0	0	0	1
PL.38481	PL.36873	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	1.04	1	7	2	96	0.00	0.0	10.751	0.158	7	2	1	1
PL.38480	PL.38481	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.00	0	0	0	100	0.00	0.0	10.924	0.173	0	0	0	0
PL.37400	PL.38480	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.00	0	0	0	100	0.00	0.0	11.198	0.274	0	0	0	0
PL.38476	PL.37400	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.00	0	0	0	100	0.00	0.0	11.340	0.142	0	0	0	0
PL.38472	PL.38476	C	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.00	0	0	0	100	0.00	0.0	11.385	0.045	0	0	0	0
PL.37724	PL.36874	C	6 A (CWC)	7.40Y	123.3	0.00	1.75	0.00	0	0	0	100	0.00	0.0	10.355	0.179	0	0	0	0
PL.38218	PL.38462	C	6 A (CWC)	7.41Y	123.4	0.03	1.56	4.79	3	34	8	97	0.01	0.0	8.226	0.133	6	1	1	9
PL.37655	PL.38218	C	6 A (CWC)	7.41Y	123.4	0.00	1.56	0.00	0	0	0	100	0.00	0.0	8.271	0.046	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58944	PL.38218	C	6 A (CWC)	7.40Y	123.4	0.02	1.59	3.93	3	28	7	97	0.00	0.0	8.386	0.161	9	2	2	8
PL.58945	PL.58944	C	6 A (CWC)	7.40Y	123.4	0.00	1.59	2.65	2	19	5	97	0.00	0.0	8.390	0.004	0	0	0	6
PD.8747	PL.58945	C	40QA	7.40Y	123.4	0.00	1.59	2.65	7	19	5	97	0.00	0.0	8.390	0.004	0	0	0	6
PL.58943	PD.8747	C	6 A (CWC)	7.40Y	123.4	0.03	1.62	2.65	2	19	5	97	0.00	0.0	8.652	0.262	0	0	0	6
PL.38464	PL.58943	C	6 A (CWC)	7.40Y	123.3	0.06	1.68	2.65	2	19	5	97	0.01	0.0	9.137	0.485	0	0	0	6
PL.65736	PL.38464	C	6 A (CWC)	7.40Y	123.3	0.01	1.69	2.65	2	19	5	97	0.00	0.0	9.232	0.094	0	0	0	6
PD.9582-A	PL.65736	C	Closed	7.40Y	123.3	0.00	1.69	2.65	0	19	5	97	0.00	0.0	9.232	0.094	0	0	0	6
PD.9582-B	PD.9582-A	C	Closed	7.40Y	123.3	0.00	1.69	2.65	0	19	5	97	0.00	0.0	9.232	0.094	0	0	0	6
PL.65737	PD.9582-B	C	6 A (CWC)	7.40Y	123.3	0.04	1.73	2.65	2	19	5	97	0.00	0.0	9.680	0.449	9	2	1	6
PL.37245	PL.65737	C	6 A (CWC)	7.40Y	123.3	0.01	1.74	1.36	1	10	2	98	0.00	0.0	9.798	0.118	0	0	0	5
PL.37880	PL.37245	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	9.851	0.053	0	0	0	0
PL.37246	PL.37245	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	1.36	1	10	2	98	0.00	0.0	9.882	0.084	6	2	2	5
PL.37756	PL.37246	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	10.316	0.433	0	0	0	1
PL.37881	PL.37756	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	10.373	0.057	0	0	0	0
PL.38424	PL.37756	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	10.940	0.624	0	0	0	1
PL.61397	PL.38424	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	11.127	0.187	0	0	1	1
PL.61398	PL.61397	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	11.228	0.101	0	0	0	0
PD.7998-B	PL.61398	C	Open	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	11.228	0.101	0	0	0	0
PL.37350	PL.37756	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.00	0	0	0	100	0.00	0.0	10.496	0.180	0	0	0	0
PL.39284	PL.37246	C	6 A (CWC)	7.40Y	123.3	0.00	1.74	0.49	0	4	1	97	0.00	0.0	9.884	0.002	0	0	0	2
PD.6038	PL.39284	C	40QA	7.40Y	123.3	0.00	1.74	0.49	1	4	1	97	0.00	0.0	9.884	0.002	0	0	0	2
PL.37653	PD.6038	C	6 A (CWC)	7.40Y	123.3	0.00	1.75	0.49	0	4	1	97	0.00	0.0	10.097	0.213	0	0	1	2
PL.37654	PL.37653	C	6 A (CWC)	7.39Y	123.2	0.01	1.75	0.49	0	4	1	97	0.00	0.0	10.915	0.818	4	1	1	1
PL.37830	PL.38464	C	6 A (CWC)	7.40Y	123.3	0.00	1.68	0.00	0	0	0	100	0.00	0.0	9.704	0.566	0	0	0	0
PL.62827	PL.38460	C	#2 ACSR	7.42Y	123.7	0.00	1.35	0.80	0	6	1	99	0.00	0.0	7.729	0.023	6	1	1	1
PL.37396	PL.37648	C	#2 ACSR	7.42Y	123.7	0.00	1.30	1.38	1	10	2	98	0.00	0.0	7.663	0.056	10	2	1	1
PL.37266	PL.38458	C	#2 ACSR	7.47Y	124.5	0.00	0.51	1.65	1	12	3	97	0.00	0.0	6.462	0.056	5	1	1	2
PL.38456	PL.37266	C	#2 ACSR	7.47Y	124.5	0.00	0.51	0.97	1	7	2	96	0.00	0.0	6.505	0.043	7	2	1	1
PL.64508	PL.38455	C	#4 ACSR	7.47Y	124.6	0.00	0.43	1.03	1	7	2	96	0.00	0.0	6.404	0.103	0	0	0	1
PL.37711	PL.64508	C	#2 ACSR	7.47Y	124.6	0.00	0.43	1.03	1	7	2	96	0.00	0.0	6.453	0.048	7	2	1	1
PL.38394	PL.64508	C	#4 ACSR	7.47Y	124.6	0.00	0.43	0.00	0	0	0	100	0.00	0.0	6.486	0.081	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.37629	PL.38454	C	#4 ACSR	7.48Y	124.6	0.00	0.40	1.23	1	9	2	98	0.00	0.0	6.370	0.132	9	2	3	3
PL.63065	PL.38451	C	#4 ACSR	7.52Y	125.3	0.00	-0.29	3.10	2	23	6	97	0.00	0.0	5.370	0.038	12	3	1	3
PL.63066	PL.63065	C	#4 ACSR	7.52Y	125.3	0.00	-0.29	1.43	1	10	3	96	0.00	0.0	5.403	0.033	1	0	1	2
PL.37618	PL.63066	C	#4 ACSR	7.52Y	125.3	0.00	-0.29	1.29	1	9	2	98	0.00	0.0	5.466	0.063	9	2	1	1
PL.38227	PL.37734	C	#4 ACSR	7.53Y	125.4	0.00	-0.42	0.85	1	6	2	95	0.00	0.0	5.298	0.048	6	2	1	1
PL.38228	PL.38227	C	#4 ACSR	7.53Y	125.4	0.00	-0.42	0.00	0	0	0	100	0.00	0.0	5.387	0.088	0	0	0	0
PL.53409	PL.53412	C	#4 ACSR	7.14Y	119.0	0.00	5.98	0.79	1	5	1	98	0.00	0.0	4.905	0.039	5	1	1	1
PL.37095	PL.51974	C	#1/0 ACSR	7.28Y	121.3	0.00	3.69	1.14	0	8	2	97	0.00	0.0	3.394	0.002	0	0	0	2
PD.5241	PL.37095	C	25QA	7.28Y	121.3	0.00	3.69	1.14	5	8	2	97	0.00	0.0	3.394	0.002	0	0	0	2
PL.37096	PD.5241	C	#1/0 ACSR	7.28Y	121.3	0.00	3.70	1.14	0	8	2	97	0.00	0.0	3.471	0.078	8	2	2	2
PL.37308	PL.37445	C	6 A (CWC)	7.37Y	122.8	0.00	2.18	6.39	5	46	11	97	0.00	0.0	2.428	0.003	0	0	0	11
PD.6075	PL.37308	C	30T	7.37Y	122.8	0.00	2.18	6.39	0	46	11	97	0.00	0.0	2.428	0.003	0	0	0	11
PL.36715	PD.6075	C	6 A (CWC)	7.37Y	122.8	0.01	2.19	6.39	5	46	11	97	0.00	0.0	2.452	0.024	12	3	1	11
PL.37866	PL.36715	C	6 A (CWC)	7.37Y	122.8	0.03	2.22	4.78	3	34	8	97	0.01	0.0	2.600	0.147	5	1	1	10
PL.37867	PL.37866	C	6 A (CWC)	7.37Y	122.8	0.01	2.23	4.15	3	30	7	97	0.00	0.0	2.648	0.048	0	0	0	9
PL.37446	PL.37867	C	6 A (CWC)	7.37Y	122.8	0.01	2.24	4.15	3	30	7	97	0.00	0.0	2.717	0.070	0	0	0	9
PL.37447	PL.37446	C	6 A (CWC)	7.36Y	122.7	0.04	2.28	4.15	3	30	7	97	0.01	0.0	2.924	0.207	6	1	1	9
PL.37449	PL.37447	C	6 A (CWC)	7.36Y	122.7	0.02	2.29	3.33	2	24	6	97	0.00	0.0	3.031	0.106	0	0	0	8
PL.37450	PL.37449	C	6 A (CWC)	7.36Y	122.7	0.01	2.30	3.33	2	24	6	97	0.00	0.0	3.095	0.064	1	0	1	8
PL.37451	PL.37450	C	6 A (CWC)	7.36Y	122.6	0.06	2.36	3.20	2	23	6	97	0.01	0.0	3.476	0.382	0	0	0	7
PL.37454	PL.37451	C	6 A (CWC)	7.36Y	122.6	0.00	2.36	2.15	2	15	4	97	0.00	0.0	3.527	0.051	0	0	0	3
PL.37455	PL.37454	C	6 A (CWC)	7.36Y	122.6	0.03	2.39	2.15	2	15	4	97	0.00	0.0	3.854	0.327	0	0	0	3
PL.37482	PL.37455	C	6 A (CWC)	7.36Y	122.6	0.01	2.40	1.38	1	10	2	98	0.00	0.0	3.938	0.083	0	0	0	2
PL.37458	PL.37482	C	6 A (CWC)	7.36Y	122.6	0.01	2.41	1.38	1	10	2	98	0.00	0.0	4.048	0.110	0	0	0	2
PL.37483	PL.37458	C	6 A (CWC)	7.36Y	122.6	0.01	2.41	1.38	1	10	2	98	0.00	0.0	4.166	0.118	1	0	1	2
PL.37484	PL.37483	C	6 A (CWC)	7.35Y	122.6	0.01	2.42	1.29	1	9	2	98	0.00	0.0	4.264	0.098	0	0	0	1
PL.37485	PL.37484	C	6 A (CWC)	7.35Y	122.6	0.01	2.42	1.29	1	9	2	98	0.00	0.0	4.357	0.093	0	0	0	1
PL.37776	PL.37485	C	#4 ACSR	7.35Y	122.6	0.00	2.43	1.29	1	9	2	98	0.00	0.0	4.531	0.174	9	2	1	1
PL.37637	PL.37485	C	6 A (CWC)	7.35Y	122.6	0.00	2.42	0.00	0	0	0	100	0.00	0.0	4.584	0.227	0	0	0	0
PL.38398	PL.37455	C	6 A (CWC)	7.36Y	122.6	0.01	2.40	0.77	1	6	1	99	0.00	0.0	4.038	0.184	0	0	0	1
PL.37036	PL.38398	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.77	1	6	1	99	0.00	0.0	4.307	0.270	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38400	PL.37036	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.00	0	0	0	100	0.00	0.0	4.532	0.224	0	0	0	0
PL.38401	PL.38400	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	0.00	0	0	0	100	0.00	0.0	4.889	0.357	0	0	0	0
PL.37452	PL.37451	C	6 A (CWC)	7.36Y	122.6	0.00	2.36	1.05	1	7	2	96	0.00	0.0	3.551	0.075	1	0	1	4
PL.37453	PL.37452	C	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.91	1	6	2	95	0.00	0.0	3.643	0.092	0	0	0	3
PL.37286	PL.37453	C	6 A (CWC)	7.36Y	122.6	0.00	2.36	0.15	0	1	0	100	0.00	0.0	3.677	0.035	1	0	1	1
PL.37456	PL.37453	C	#4 ACSR	7.36Y	122.6	0.00	2.37	0.76	1	5	1	98	0.00	0.0	3.688	0.045	0	0	1	2
PL.37457	PL.37456	C	#4 ACSR	7.36Y	122.6	0.00	2.37	0.73	1	5	1	98	0.00	0.0	3.733	0.045	5	1	1	1
PL.37638	PL.37449	C	#2 ACSR	7.36Y	122.7	0.00	2.29	0.00	0	0	0	100	0.00	0.0	3.047	0.016	0	0	0	0
PL.37439	PL.37438	A	#4 ACSR	7.40Y	123.3	0.00	1.74	0.89	1	6	2	95	0.00	0.0	2.150	0.001	0	0	0	1
PD.6029	PL.37439	A	40QA	7.40Y	123.3	0.00	1.74	0.89	2	6	2	95	0.00	0.0	2.150	0.001	0	0	0	1
PL.37440	PD.6029	A	#4 ACSR	7.40Y	123.3	0.00	1.74	0.89	1	6	2	95	0.00	0.0	2.197	0.046	6	2	1	1
PL.37288	PL.37816	ABC	336 MCM AC	7.42Y	123.6	0.00	1.41	1.24	0	27	7	97	0.00	0.0	2.021	0.070	0	0	0	5
PL.37289	PL.37288	ABC	336 MCM AC	7.42Y	123.6	0.00	1.41	1.24	0	27	7	97	0.00	0.0	2.068	0.047	0	0	0	5
PL.37448	PL.37289	ABC	336 MCM AC	7.42Y	123.6	0.00	1.41	1.09	0	24	6	97	0.00	0.0	2.316	0.249	0	0	0	4
PL.38419	PL.37448	C	#4 ACSR	7.41Y	123.6	0.01	1.42	3.27	3	24	6	97	0.00	0.0	2.396	0.080	18	5	3	4
PL.38420	PL.38419	C	#4 ACSR	7.41Y	123.6	0.00	1.42	0.70	1	5	1	98	0.00	0.0	2.457	0.062	5	1	1	1
PL.62170	PL.37448	ABC	336 MCM AC	7.42Y	123.6	0.00	1.41	0.00	0	0	0	100	0.00	0.0	2.356	0.040	0	0	0	0
PD.9281-A	PL.62170	ABC	Open	7.42Y	123.6	0.00	1.41	0.00	0	0	0	100	0.00	0.0	2.356	0.040	0	0	0	0
PL.37644	PL.37289	C	#4 ACSR	7.42Y	123.6	0.00	1.41	0.45	0	3	1	95	0.00	0.0	2.072	0.004	0	0	0	1
PD.6076	PL.37644	C	40T	7.42Y	123.6	0.00	1.41	0.45	0	3	1	95	0.00	0.0	2.072	0.004	0	0	0	1
PL.37645	PD.6076	C	#4 ACSR	7.42Y	123.6	0.00	1.41	0.45	0	3	1	95	0.00	0.0	2.129	0.057	3	1	1	1
PL.37790	PL.37288	C	#4 ACSR	7.42Y	123.6	0.00	1.41	0.00	0	0	0	100	0.00	0.0	2.108	0.087	0	0	0	0
PL.62884	PL.62881	A	#1/0 ACSR	7.46Y	124.3	0.00	0.72	1.29	1	9	2	98	0.00	0.0	0.978	0.002	0	0	0	1
PD.5893	PL.62884	A	10QA	7.46Y	124.3	0.00	0.72	1.29	0	9	2	98	0.00	0.0	0.978	0.002	0	0	0	1
PL.37051	PD.5893	A	#1/0 ACSR	7.46Y	124.3	0.00	0.72	1.29	1	9	2	98	0.00	0.0	1.014	0.036	9	2	1	1
PL.58007	PL.58008	C	6 A (CWC)	7.46Y	124.4	0.00	0.59	2.19	2	16	4	97	0.00	0.0	0.810	0.004	0	0	0	4
PD.5906	PL.58007	C	30T	7.46Y	124.4	0.00	0.59	2.19	0	16	4	97	0.00	0.0	0.810	0.004	0	0	0	4
PL.37732	PD.5906	C	6 A (CWC)	7.46Y	124.4	0.01	0.60	2.19	2	16	4	97	0.00	0.0	0.904	0.094	0	0	0	4
PL.37331	PL.37732	C	6 A (CWC)	7.46Y	124.4	0.00	0.60	0.00	0	0	0	100	0.00	0.0	0.969	0.065	0	0	0	0
PL.37054	PL.37732	C	6 A (CWC)	7.46Y	124.4	0.01	0.61	2.19	2	16	4	97	0.00	0.0	0.982	0.078	10	2	2	4
PL.37055	PL.37054	C	6 A (CWC)	7.46Y	124.4	0.00	0.61	0.85	1	6	2	95	0.00	0.0	1.047	0.065	6	1	1	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.37056	PL.37055	C	6 A (CWC)	7.46Y	124.4	0.00	0.61	0.02	0	0	0	100	0.00	0.0	1.163	0.116	0	0	0	1
PL.38399	PL.37056	C	6 A (CWC)	7.46Y	124.4	0.00	0.61	0.02	0	0	0	100	0.00	0.0	1.251	0.088	0	0	1	1
PL.37399	PL.37055	C	6 A (CWC)	7.46Y	124.4	0.00	0.61	0.00	0	0	0	100	0.00	0.0	1.096	0.049	0	0	0	0
PL.37979	PL.38482	ABC	336 MCM AC	7.50Y	124.9	0.00	0.08	0.00	0	0	0	100	0.00	0.0	0.105	0.000	0	0	0	0
PL.53023	Three Links	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	160.03	31	3385	1227	94	0.08	0.0	0.004	0.004	0	0	0	510
PL.53063	PL.53023	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	160.03	31	3385	1227	94	0.08	0.0	0.007	0.004	0	0	0	510
----- Feeder No. 1 (Pine Grove F1) Beginning with Device PD.8073 -----																				
PD.8073	PL.53063	ABC	360VWE	7.50Y	125.0	0.00	0.01	160.03	0	3385	1227	94	0.00	0.0	0.007	0.004	0	0	0	510
PL.37641	PD.8073	ABC	336 MCM AC	7.50Y	125.0	0.02	0.03	160.03	31	3385	1227	94	0.39	0.0	0.025	0.018	0	0	0	510
PL.37981	PL.37641	ABC	336 MCM AC	7.50Y	125.0	0.00	0.03	0.00	0	0	0	100	0.00	0.0	0.039	0.014	0	0	0	0
PL.38239	PL.37641	ABC	336 MCM AC	7.49Y	124.9	0.10	0.13	160.03	31	3385	1226	94	1.69	0.0	0.103	0.078	0	0	0	510
PL.38241	PL.38239	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.30	0	2	1	89	0.00	0.0	0.109	0.006	0	0	0	1
PD.5899	PL.38241	A	75QA	7.49Y	124.9	0.00	0.13	0.30	0	2	1	89	0.00	0.0	0.109	0.006	0	0	0	1
PL.38242	PD.5899	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.30	0	2	1	89	0.00	0.0	0.176	0.067	2	1	1	1
PL.38247	PL.38239	ABC	336 MCM AC	7.49Y	124.8	0.11	0.24	159.94	31	3381	1222	94	1.77	0.1	0.185	0.082	0	0	0	509
PL.63043	PL.38247	ABC	336 MCM AC	7.48Y	124.7	0.10	0.35	159.64	31	3372	1216	94	1.74	0.1	0.267	0.081	0	0	0	505
PL.63045	PL.63043	B	#1/0 ACSR	7.48Y	124.7	0.00	0.35	0.00	0	0	0	100	0.00	0.0	0.329	0.062	0	0	0	0
PL.63044	PL.63043	ABC	336 MCM AC	7.46Y	124.3	0.35	0.69	159.64	31	3371	1212	94	5.75	0.2	0.535	0.268	0	0	0	505
PL.38125	PL.63044	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.54	0	4	1	97	0.00	0.0	0.537	0.002	0	0	0	1
PD.6035	PL.38125	A	75QA	7.46Y	124.3	0.00	0.69	0.54	1	4	1	97	0.00	0.0	0.537	0.002	0	0	0	1
PL.38243	PD.6035	A	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.54	0	4	1	97	0.00	0.0	0.657	0.120	4	1	1	1
PL.38331	PL.63044	C	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.37	0	3	1	95	0.00	0.0	0.537	0.002	0	0	0	1
PD.5904	PL.38331	C	75QA	7.46Y	124.3	0.00	0.69	0.37	0	3	1	95	0.00	0.0	0.537	0.002	0	0	0	1
PL.38332	PD.5904	C	6 A (CWC)	7.46Y	124.3	0.00	0.69	0.37	0	3	1	95	0.00	0.0	0.602	0.065	3	1	1	1
PL.37874	PL.63044	ABC	336 MCM AC	7.45Y	124.1	0.19	0.88	159.34	31	3358	1197	94	3.10	0.1	0.680	0.145	11	3	3	503
PL.38333	PL.37874	ABC	336 MCM AC	7.44Y	123.9	0.17	1.05	158.84	31	3344	1187	94	2.88	0.1	0.815	0.135	0	0	0	500
PL.38484	PL.38333	ABC	336 MCM AC	7.43Y	123.8	0.17	1.22	158.52	31	3335	1179	94	2.74	0.1	0.945	0.130	9	2	1	499
PL.38485	PL.38484	ABC	336 MCM AC	7.42Y	123.6	0.19	1.41	158.12	30	3323	1170	94	3.17	0.1	1.096	0.151	3	1	1	498
PL.38486	PL.38485	ABC	336 MCM AC	7.40Y	123.3	0.27	1.68	157.97	30	3317	1162	94	4.46	0.1	1.308	0.213	14	3	2	497

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.38487	PL.38486	ABC	336 MCM AC	7.40Y	123.3	0.06	1.73	157.32	30	3298	1148	94	0.93	0.0	1.353	0.044	0	0	0	495
PL.38488	PL.38487	ABC	336 MCM AC	7.38Y	123.0	0.22	1.95	156.78	30	3285	1143	94	3.64	0.1	1.528	0.176	0	0	0	494
PL.37928	PL.38488	ABC	336 MCM AC	7.37Y	122.8	0.23	2.18	154.03	30	3222	1120	94	3.68	0.1	1.713	0.184	0	0	0	478
PL.57229	PL.37928	ABC	336 MCM AC	7.36Y	122.7	0.16	2.34	153.82	30	3214	1110	95	2.64	0.1	1.846	0.133	9	2	1	477
PL.57230	PL.57229	ABC	336 MCM AC	7.34Y	122.4	0.26	2.60	153.38	30	3202	1102	95	4.20	0.1	2.057	0.212	0	0	0	476
PL.37931	PL.57230	ABC	#4 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	2.058	0.001	0	0	0	0
PD.6044	PL.37931	ABC	75QA	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	2.058	0.001	0	0	0	0
PL.37932	PD.6044	ABC	#4 ACSR	7.34Y	122.4	0.00	2.60	0.00	0	0	0	100	0.00	0.0	2.101	0.043	0	0	0	0
PL.37933	PL.57230	ABC	336 MCM AC	7.34Y	122.4	0.04	2.64	153.38	30	3198	1092	95	0.64	0.0	2.090	0.032	2	0	2	476
PL.37934	PL.37933	ABC	336 MCM AC	7.33Y	122.2	0.21	2.85	153.31	30	3196	1090	95	3.36	0.1	2.259	0.170	0	0	0	474
PL.36741	PL.37934	A	6 A (CWC)	7.32Y	122.1	0.08	2.93	19.93	14	142	35	97	0.08	0.1	2.344	0.085	0	0	0	32
PL.36742	PL.36741	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	19.93	14	142	35	97	0.00	0.0	2.346	0.001	0	0	0	32
PD.6087	PL.36742	A	50L	7.32Y	122.1	0.00	2.93	19.93	40	142	35	97	0.00	0.0	2.346	0.001	0	0	0	32
PL.36743	PD.6087	A	6 A (CWC)	7.32Y	122.1	0.02	2.95	19.93	14	142	35	97	0.02	0.0	2.367	0.021	0	0	0	32
PL.37757	PL.36743	A	6 A (CWC)	7.32Y	121.9	0.13	3.08	19.93	14	142	35	97	0.14	0.1	2.514	0.148	4	1	1	32
PL.37935	PL.37757	A	6 A (CWC)	7.31Y	121.9	0.06	3.13	19.32	14	137	34	97	0.06	0.0	2.579	0.064	5	1	1	31
PL.37936	PL.37935	A	6 A (CWC)	7.31Y	121.8	0.08	3.21	18.66	13	133	32	97	0.08	0.1	2.672	0.093	0	0	0	30
PL.37937	PL.37936	A	6 A (CWC)	7.30Y	121.7	0.13	3.34	18.00	13	128	31	97	0.12	0.1	2.836	0.164	8	2	1	29
PL.37938	PL.37937	A	6 A (CWC)	7.30Y	121.6	0.04	3.38	16.91	12	120	29	97	0.04	0.0	2.888	0.052	0	0	0	28
PL.37939	PL.37938	A	6 A (CWC)	7.30Y	121.6	0.00	3.39	1.75	1	12	3	97	0.00	0.0	2.946	0.058	0	0	0	2
PL.37940	PL.37939	A	6 A (CWC)	7.30Y	121.6	0.00	3.39	0.27	0	2	0	100	0.00	0.0	3.048	0.103	2	0	1	1
PL.37775	PL.37939	A	6 A (CWC)	7.30Y	121.6	0.00	3.39	1.48	1	11	3	96	0.00	0.0	3.007	0.061	11	3	1	1
PL.37941	PL.37938	A	6 A (CWC)	7.29Y	121.5	0.10	3.49	14.18	10	100	25	97	0.08	0.1	3.057	0.169	8	2	1	25
PL.37486	PL.37941	A	6 A (CWC)	7.29Y	121.4	0.08	3.56	13.11	9	93	23	97	0.05	0.1	3.194	0.137	6	2	2	24
PL.37487	PL.37486	A	6 A (CWC)	7.28Y	121.4	0.05	3.62	12.22	9	87	21	97	0.03	0.0	3.289	0.096	3	1	1	22
PL.37949	PL.37487	A	6 A (CWC)	7.28Y	121.3	0.04	3.65	3.71	3	26	6	97	0.01	0.0	3.513	0.224	0	0	1	8
PL.38343	PL.37949	A	6 A (CWC)	7.28Y	121.3	0.01	3.66	3.68	3	26	6	97	0.00	0.0	3.566	0.053	3	1	2	7
PL.38344	PL.38343	A	6 A (CWC)	7.28Y	121.3	0.02	3.69	3.20	2	23	6	97	0.00	0.0	3.734	0.168	0	0	0	4
PL.38345	PL.38344	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	2.02	1	14	3	98	0.00	0.0	3.784	0.050	10	2	1	2
PL.38346	PL.38345	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	0.60	0	4	1	97	0.00	0.0	3.837	0.054	4	1	1	1
PL.38347	PL.38344	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	1.18	1	8	2	97	0.00	0.0	3.826	0.092	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38348	PL.38347	A	6 A (CWC)	7.28Y	121.3	0.00	3.69	1.18	1	8	2	97	0.00	0.0	3.863	0.037	8	2	2	2
PL.37815	PL.38343	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.02	0	0	0	100	0.00	0.0	3.690	0.124	0	0	1	1
PL.37942	PL.37487	A	6 A (CWC)	7.28Y	121.4	0.03	3.64	6.61	5	47	11	97	0.01	0.0	3.385	0.096	0	0	0	12
PL.37943	PL.37942	A	6 A (CWC)	7.28Y	121.3	0.03	3.67	5.15	4	36	9	97	0.01	0.0	3.495	0.110	0	0	0	10
PL.38349	PL.37943	A	6 A (CWC)	7.28Y	121.3	0.05	3.72	5.07	4	36	9	97	0.01	0.0	3.697	0.202	0	0	0	7
PL.37777	PL.38349	A	6 A (CWC)	7.28Y	121.3	0.00	3.72	0.00	0	0	0	100	0.00	0.0	3.776	0.079	0	0	0	0
PL.38448	PL.38349	A	6 A (CWC)	7.27Y	121.2	0.04	3.76	5.07	4	36	9	97	0.01	0.0	3.866	0.170	0	0	0	7
PL.38350	PL.38448	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	0.31	0	2	1	89	0.00	0.0	3.896	0.029	0	0	0	1
PL.38351	PL.38350	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	0.31	0	2	1	89	0.00	0.0	3.923	0.027	2	1	1	1
PL.36759	PL.38448	A	6 A (CWC)	7.27Y	121.2	0.04	3.80	4.75	3	34	8	97	0.01	0.0	4.053	0.186	0	0	0	6
PL.37749	PL.36759	A	6 A (CWC)	7.27Y	121.2	0.01	3.80	4.75	3	34	8	97	0.00	0.0	4.099	0.046	6	1	1	6
PL.38449	PL.37749	A	6 A (CWC)	7.27Y	121.2	0.01	3.82	3.95	3	28	7	97	0.00	0.0	4.173	0.074	0	0	0	5
PL.37227	PL.38449	A	6 A (CWC)	7.27Y	121.2	0.02	3.84	2.44	2	17	4	97	0.00	0.0	4.372	0.199	0	0	0	2
PL.38354	PL.37227	A	6 A (CWC)	7.27Y	121.1	0.02	3.86	2.44	2	17	4	97	0.00	0.0	4.526	0.154	0	0	0	2
PL.38355	PL.38354	A	6 A (CWC)	7.27Y	121.1	0.00	3.86	0.98	1	7	2	96	0.00	0.0	4.577	0.052	7	2	1	1
PL.37426	PL.38355	A	6 A (CWC)	7.27Y	121.1	0.00	3.86	0.00	0	0	0	100	0.00	0.0	4.661	0.084	0	0	0	0
PL.37333	PL.38354	A	#4 ACSR	7.27Y	121.1	0.00	3.86	1.46	1	10	3	96	0.00	0.0	4.590	0.064	10	3	1	1
PL.38352	PL.38449	A	#4 ACSR	7.27Y	121.2	0.00	3.82	1.51	1	11	3	96	0.00	0.0	4.246	0.073	3	1	2	3
PL.38353	PL.38352	A	#4 ACSR	7.27Y	121.2	0.00	3.82	1.02	1	7	2	96	0.00	0.0	4.273	0.027	7	2	1	1
PL.37488	PL.37943	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.08	0	1	0	100	0.00	0.0	3.520	0.025	0	0	0	3
PL.37946	PL.37488	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.08	0	1	0	100	0.00	0.0	3.577	0.057	0	0	1	3
PL.37489	PL.37946	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.07	0	0	0	100	0.00	0.0	3.710	0.133	0	0	1	2
PL.37947	PL.37489	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.06	0	0	0	100	0.00	0.0	3.792	0.082	0	0	0	1
PL.37490	PL.37947	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.06	0	0	0	100	0.00	0.0	3.840	0.048	0	0	1	1
PL.37948	PL.37490	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	3.949	0.109	0	0	0	0
PL.37950	PL.37948	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	3.996	0.047	0	0	0	0
PL.38131	PL.37489	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	3.792	0.081	0	0	0	0
PL.37944	PL.37942	A	6 A (CWC)	7.28Y	121.4	0.00	3.65	1.46	1	10	3	96	0.00	0.0	3.439	0.055	10	3	2	2
PL.37945	PL.37944	A	6 A (CWC)	7.28Y	121.4	0.00	3.65	0.00	0	0	0	100	0.00	0.0	3.482	0.043	0	0	0	0
PL.37300	PL.37487	A	6 A (CWC)	7.28Y	121.4	0.00	3.62	1.44	1	10	2	98	0.00	0.0	3.322	0.033	10	2	1	1
PL.37708	PL.37938	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	0.98	1	7	2	96	0.00	0.0	2.945	0.057	7	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37754	PL.37936	A	6 A (CWC)	7.31Y	121.8	0.00	3.21	0.67	0	5	1	98	0.00	0.0	2.711	0.039	5	1	1	1
PL.36716	PL.37934	ABC	336 MCM AC	7.32Y	121.9	0.21	3.06	146.70	28	3051	1048	95	3.30	0.1	2.441	0.182	4	1	1	442
PL.38406	PL.36716	ABC	336 MCM AC	7.31Y	121.9	0.09	3.15	146.51	28	3043	1039	95	1.37	0.0	2.517	0.076	8	2	1	441
PL.38009	PL.38406	ABC	336 MCM AC	7.30Y	121.7	0.11	3.26	145.58	28	3022	1031	95	1.67	0.1	2.611	0.094	0	0	0	438
PL.36717	PL.38009	ABC	336 MCM AC	7.30Y	121.6	0.13	3.38	145.58	28	3020	1027	95	1.94	0.1	2.719	0.108	0	0	0	438
PL.38407	PL.36717	A	#1/0 ACSR	7.30Y	121.6	0.00	3.38	1.19	1	8	2	97	0.00	0.0	2.720	0.001	0	0	0	1
PD.6001	PL.38407	A	40QA	7.30Y	121.6	0.00	3.38	1.19	3	8	2	97	0.00	0.0	2.720	0.001	0	0	0	1
PL.38012	PD.6001	A	#1/0 ACSR	7.30Y	121.6	0.00	3.38	1.19	1	8	2	97	0.00	0.0	2.778	0.058	8	2	1	1
PL.38509	PL.36717	ABC	336 MCM AC	7.29Y	121.6	0.05	3.43	145.18	28	3010	1020	95	0.74	0.0	2.761	0.042	0	0	0	437
PL.38510	PL.38509	C	6 A (CWC)	7.29Y	121.6	0.00	3.43	0.38	0	3	1	95	0.00	0.0	2.764	0.003	0	0	0	2
PD.5888	PL.38510	C	75QA	7.29Y	121.6	0.00	3.43	0.38	1	3	1	95	0.00	0.0	2.764	0.003	0	0	0	2
PL.38511	PD.5888	C	6 A (CWC)	7.29Y	121.6	0.00	3.43	0.38	0	3	1	95	0.00	0.0	2.870	0.106	3	1	2	2
PL.63059	PL.38509	ABC	336 MCM AC	7.29Y	121.5	0.10	3.54	145.06	28	3007	1018	95	1.60	0.1	2.851	0.090	0	0	0	435
PL.63061	PL.63059	C	#1/0 ACSR	7.29Y	121.5	0.00	3.54	0.67	0	5	1	98	0.00	0.0	2.854	0.003	0	0	0	1
PD.9411	PL.63061	C	10T	7.29Y	121.5	0.00	3.54	0.67	0	5	1	98	0.00	0.0	2.854	0.003	0	0	0	1
PL.63062	PD.9411	C	#1/0 ACSR	7.29Y	121.5	0.00	3.54	0.67	0	5	1	98	0.00	0.0	2.913	0.059	5	1	1	1
PL.63060	PL.63059	ABC	336 MCM AC	7.28Y	121.3	0.18	3.71	144.84	28	3000	1013	95	2.70	0.1	3.004	0.153	0	0	0	434
PL.38517	PL.63060	ABC	336 MCM AC	7.27Y	121.2	0.09	3.80	142.79	28	2954	996	95	1.40	0.0	3.086	0.082	0	0	0	425
PL.38518	PL.38517	ABC	336 MCM AC	7.27Y	121.1	0.08	3.88	142.79	28	2953	993	95	1.14	0.0	3.152	0.067	0	0	0	425
PL.38519	PL.38518	ABC	336 MCM AC	7.26Y	121.1	0.05	3.93	142.79	28	2952	990	95	0.78	0.0	3.198	0.045	0	0	0	425
PL.37800	PL.38519	A	6 A (CWC)	7.26Y	121.1	0.00	3.93	0.00	0	0	0	100	0.00	0.0	3.376	0.178	0	0	0	0
PL.37606	PL.38519	ABC	336 MCM AC	7.24Y	120.7	0.38	4.31	142.79	28	2951	988	95	5.72	0.2	3.532	0.334	10	3	2	425
PL.38654	PL.37606	ABC	336 MCM AC	7.23Y	120.6	0.13	4.44	142.31	27	2935	973	95	2.02	0.1	3.650	0.118	0	0	0	423
PL.38006	PL.38654	B	6 A (CWC)	7.23Y	120.6	0.00	4.44	0.76	1	5	1	98	0.00	0.0	3.651	0.001	0	0	0	2
PD.5887	PL.38006	B	75QA	7.23Y	120.6	0.00	4.44	0.76	1	5	1	98	0.00	0.0	3.651	0.001	0	0	0	2
PL.38007	PD.5887	B	6 A (CWC)	7.23Y	120.6	0.01	4.45	0.76	1	5	1	98	0.00	0.0	4.054	0.403	5	1	2	2
PL.38003	PL.38654	ABC	336 MCM AC	7.22Y	120.4	0.20	4.64	142.05	27	2927	967	95	3.08	0.1	3.832	0.182	8	2	2	421
PL.38004	PL.38003	ABC	336 MCM AC	7.22Y	120.3	0.05	4.69	140.94	27	2901	954	95	0.79	0.0	3.879	0.047	7	2	2	417
PL.52498	PL.38004	ABC	336 MCM AC	7.21Y	120.2	0.08	4.78	140.62	27	2893	950	95	1.24	0.0	3.954	0.075	2	1	2	415
PL.52497	PL.52498	ABC	336 MCM AC	7.21Y	120.1	0.08	4.85	140.51	27	2890	947	95	1.17	0.0	4.024	0.071	0	0	0	413
PL.38002	PL.52497	ABC	336 MCM AC	7.20Y	120.1	0.08	4.93	140.51	27	2888	944	95	1.17	0.0	4.095	0.071	3	1	2	413

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38001	PL.38002	ABC	336 MCM AC	7.20Y	120.0	0.04	4.97	140.38	27	2885	940	95	0.65	0.0	4.135	0.040	25	6	3	411
PL.38000	PL.38001	ABC	336 MCM AC	7.20Y	119.9	0.10	5.07	139.21	27	2859	933	95	1.50	0.1	4.226	0.092	0	0	0	408
PL.37998	PL.38000	ABC	336 MCM AC	7.19Y	119.9	0.05	5.13	138.35	27	2840	925	95	0.79	0.0	4.275	0.049	0	0	1	404
PL.37996	PL.37998	ABC	336 MCM AC	7.19Y	119.8	0.02	5.15	138.35	27	2839	923	95	0.34	0.0	4.296	0.021	0	0	0	403
PL.37481	PL.37996	A	6 A (CWC)	7.19Y	119.8	0.00	5.15	0.13	0	1	0	100	0.00	0.0	4.335	0.039	1	0	2	2
PL.37992	PL.37996	ABC	336 MCM AC	7.19Y	119.8	0.04	5.19	137.65	27	2824	919	95	0.53	0.0	4.330	0.033	0	0	0	398
PL.39116	PL.37992	ABC	336 MCM AC	7.18Y	119.7	0.09	5.28	70.82	14	1427	545	93	0.64	0.0	4.483	0.154	20	5	2	135
PL.36718	PL.39116	ABC	336 MCM AC	7.18Y	119.7	0.00	5.28	41.75	8	811	391	90	0.00	0.0	4.483	0.000	0	0	0	3
PD.6084	PL.36718	ABC	75QA	7.18Y	119.7	0.00	5.28	41.75	56	811	391	90	0.00	0.0	4.483	0.000	0	0	0	3
PL.36719	PD.6084	ABC	336 MCM AC	7.18Y	119.7	0.01	5.29	41.75	8	811	391	90	0.04	0.0	4.512	0.028	9	2	1	3
PL.64503	PL.36719	ABC	336 MCM AC	7.18Y	119.7	0.00	5.29	41.33	8	802	388	90	0.02	0.0	4.524	0.013	0	0	0	2
PD.9547	PL.64503	ABC	80T	7.18Y	119.7	0.00	5.29	41.33	0	802	388	90	0.00	0.0	4.524	0.013	0	0	0	2
PL.64504	PD.9547	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	41.33	18	802	388	90	0.00	0.0	4.525	0.001	802	388	2	2
PL.64505	PL.64504	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.586	0.061	0	0	0	0
PL.64498	PL.64505	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.638	0.052	0	0	0	0
PL.64499	PL.64498	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.640	0.003	0	0	0	0
PL.64500	PL.64499	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.654	0.014	0	0	0	0
PL.64501	PL.64500	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.658	0.004	0	0	0	0
PL.64502	PL.64501	ABC	#1/0 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.661	0.003	0	0	0	0
CP.104	PL.64498	ABC	Cap (450)	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.638	0.003	0	0	0	0
PL.39117	PL.39116	ABC	336 MCM AC	7.18Y	119.7	0.02	5.29	28.47	5	595	148	97	0.06	0.0	4.576	0.093	0	0	0	130
PL.39118	PL.39117	A	#4 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.577	0.001	0	0	0	0
PD.6005	PL.39118	A	75QA	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.577	0.001	0	0	0	0
PL.39119	PD.6005	A	#4 ACSR	7.18Y	119.7	0.00	5.29	0.00	0	0	0	100	0.00	0.0	4.626	0.049	0	0	0	0
PL.38876	PL.39117	ABC	336 MCM AC	7.18Y	119.7	0.04	5.34	28.47	5	595	148	97	0.14	0.0	4.788	0.212	0	0	0	130
PL.38879	PL.38876	ABC	336 MCM AC	7.18Y	119.6	0.01	5.35	28.47	5	595	147	97	0.04	0.0	4.850	0.061	0	0	0	130
PL.38880	PL.38879	ABC	336 MCM AC	7.18Y	119.6	0.06	5.41	28.37	5	593	147	97	0.21	0.0	5.160	0.311	0	0	1	129
PL.37087	PL.38880	A	#4 ACSR	7.17Y	119.6	0.01	5.42	16.13	12	112	28	97	0.01	0.0	5.177	0.016	0	0	0	30
PL.37661	PL.37087	A	#4 ACSR	7.17Y	119.6	0.00	5.43	16.13	12	112	28	97	0.00	0.0	5.177	0.000	0	0	0	30
PD.6088	PL.37661	A	35L	7.17Y	119.6	0.00	5.43	16.13	46	112	28	97	0.00	0.0	5.177	0.000	0	0	0	30
PL.38881	PD.6088	A	#4 ACSR	7.17Y	119.5	0.05	5.48	16.13	12	112	28	97	0.05	0.0	5.249	0.072	0	0	1	30

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.38416	PL.38881	A	#4 ACSR	7.16Y	119.4	0.17	5.65	16.12	12	112	28	97	0.15	0.1	5.492	0.243	5	1	4	29
PL.39227	PL.38416	A	#4 ACSR	7.16Y	119.3	0.08	5.73	15.34	12	107	26	97	0.07	0.1	5.617	0.125	0	0	0	25
PL.39223	PL.39227	A	#4 ACSR	7.15Y	119.2	0.09	5.82	15.34	12	107	26	97	0.08	0.1	5.752	0.135	0	0	1	25
PL.39224	PL.39223	A	#4 ACSR	7.15Y	119.1	0.04	5.86	15.34	12	107	26	97	0.04	0.0	5.814	0.063	0	0	1	24
PL.38865	PL.39224	A	#4 ACSR	7.14Y	119.0	0.10	5.96	15.34	12	106	26	97	0.08	0.1	5.960	0.146	0	0	0	23
PL.38223	PL.38865	A	#4 ACSR	7.14Y	119.0	0.07	6.03	15.34	12	106	26	97	0.06	0.1	6.063	0.102	0	0	0	23
PL.37887	PL.38223	A	#4 ACSR	7.14Y	119.0	0.00	6.03	1.15	1	8	2	97	0.00	0.0	6.146	0.084	8	2	2	2
PL.38866	PL.38223	A	#4 ACSR	7.13Y	118.9	0.10	6.13	14.19	11	98	24	97	0.07	0.1	6.223	0.160	9	2	1	21
PL.38867	PL.38866	A	#4 ACSR	7.12Y	118.7	0.15	6.28	12.92	10	89	22	97	0.11	0.1	6.486	0.263	0	0	0	20
PL.38868	PL.38867	A	#4 ACSR	7.12Y	118.6	0.13	6.41	12.92	10	89	22	97	0.09	0.1	6.723	0.237	9	2	2	20
PL.38869	PL.38868	A	#4 ACSR	7.12Y	118.6	0.01	6.41	6.77	5	47	11	97	0.00	0.0	6.748	0.025	2	0	1	14
PL.38947	PL.38869	A	#4 ACSR	7.11Y	118.5	0.04	6.46	6.52	5	45	11	97	0.01	0.0	6.889	0.141	0	0	0	13
PL.38875	PL.38947	A	#4 ACSR	7.11Y	118.5	0.03	6.48	3.97	3	27	7	97	0.01	0.0	7.095	0.206	11	3	4	7
PL.38949	PL.38875	A	#4 ACSR	7.11Y	118.5	0.01	6.49	2.42	2	17	4	97	0.00	0.0	7.184	0.089	7	2	1	3
PL.38950	PL.38949	A	#4 ACSR	7.11Y	118.5	0.00	6.50	1.43	1	10	2	98	0.00	0.0	7.292	0.108	10	2	2	2
PL.38948	PL.38947	A	#4 ACSR	7.11Y	118.5	0.01	6.46	2.55	2	18	4	98	0.00	0.0	6.955	0.066	0	0	0	6
PL.38873	PL.38948	A	#4 ACSR	7.11Y	118.5	0.00	6.46	1.88	1	13	3	97	0.00	0.0	6.997	0.042	13	3	3	4
PL.38874	PL.38873	A	#4 ACSR	7.11Y	118.5	0.00	6.46	0.06	0	0	0	100	0.00	0.0	7.096	0.099	0	0	1	1
PL.38872	PL.38948	A	#4 ACSR	7.11Y	118.5	0.01	6.47	0.67	1	5	1	98	0.00	0.0	7.140	0.185	0	0	0	2
PL.37666	PL.38872	A	#4 ACSR	7.11Y	118.5	0.00	6.47	0.67	1	5	1	98	0.00	0.0	7.245	0.105	5	1	1	2
PL.61390	PL.37666	A	#4 ACSR	7.11Y	118.5	0.00	6.47	0.00	0	0	0	100	0.00	0.0	7.295	0.049	0	0	0	1
PL.61399	PL.61390	A	#1/0 ACSR	7.11Y	118.5	0.00	6.47	0.00	0	0	0	100	0.00	0.0	7.389	0.094	0	0	1	1
PL.61400	PL.61399	A	#1/0 ACSR	7.11Y	118.5	0.00	6.47	0.00	0	0	0	100	0.00	0.0	7.699	0.310	0	0	0	0
PL.38870	PL.38868	A	#4 ACSR	7.11Y	118.6	0.02	6.43	4.85	4	34	8	97	0.01	0.0	6.846	0.123	9	2	1	4
PL.37273	PL.38870	A	#4 ACSR	7.11Y	118.6	0.01	6.44	3.56	3	25	6	97	0.00	0.0	6.915	0.069	12	3	2	3
PL.38224	PL.37273	A	#4 ACSR	7.11Y	118.6	0.00	6.44	1.85	1	13	3	97	0.00	0.0	6.967	0.052	13	3	1	1
PL.38871	PL.38224	A	#4 ACSR	7.11Y	118.6	0.00	6.44	0.00	0	0	0	100	0.00	0.0	7.003	0.036	0	0	0	0
PL.37374	PL.39227	A	#4 ACSR	7.16Y	119.3	0.00	5.73	0.00	0	0	0	100	0.00	0.0	5.652	0.035	0	0	0	0
PL.37681	PL.38880	C	#4 ACSR	7.18Y	119.6	0.00	5.41	0.00	0	0	0	100	0.00	0.0	5.161	0.000	0	0	0	0
PD.6052	PL.37681	C	75QA	7.18Y	119.6	0.00	5.41	0.00	0	0	0	100	0.00	0.0	5.161	0.000	0	0	0	0
PL.37682	PD.6052	C	#4 ACSR	7.18Y	119.6	0.00	5.41	0.00	0	0	0	100	0.00	0.0	5.198	0.037	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.38882	PL.38880	ABC	336 MCM AC	7.17Y	119.6	0.01	5.43	22.97	4	480	118	97	0.03	0.0	5.236	0.075	0	0	0	98
PL.38883	PL.38882	ABC	336 MCM AC	7.17Y	119.6	0.01	5.43	22.97	4	480	118	97	0.02	0.0	5.271	0.036	10	2	1	98
PL.37665	PL.38883	ABC	336 MCM AC	7.17Y	119.6	0.00	5.43	0.59	0	12	3	97	0.00	0.0	5.311	0.040	1	0	1	3
PL.38888	PL.37665	ABC	336 MCM AC	7.17Y	119.6	0.00	5.43	0.56	0	12	3	97	0.00	0.0	5.468	0.156	0	0	0	2
PL.38889	PL.38888	ABC	336 MCM AC	7.17Y	119.6	0.00	5.43	0.29	0	6	1	99	0.00	0.0	5.628	0.161	0	0	0	1
PL.37808	PL.38889	A	#4 ACSR	7.17Y	119.6	0.00	5.43	0.86	1	6	1	99	0.00	0.0	5.630	0.001	0	0	0	1
PD.5230	PL.37808	A	75QA	7.17Y	119.6	0.00	5.43	0.86	1	6	1	99	0.00	0.0	5.630	0.001	0	0	0	1
PL.37475	PD.5230	A	#4 ACSR	7.17Y	119.6	0.00	5.43	0.86	1	6	1	99	0.00	0.0	5.700	0.070	6	1	1	1
PL.37809	PL.37475	A	#4 ACSR	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	5.820	0.120	0	0	0	0
PL.37474	PL.38889	ABC	336 MCM AC	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	5.673	0.044	0	0	0	0
PL.30476	PL.37474	ABC	336 MCM AC	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	5.676	0.003	0	0	0	0
PD.4261-A	PL.30476	ABC	Open	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	5.676	0.003	0	0	0	0
PL.38890	PL.38888	C	#2 ACSR	7.17Y	119.6	0.00	5.43	0.83	0	6	1	99	0.00	0.0	5.469	0.001	0	0	0	1
PD.6009	PL.38890	C	40QA	7.17Y	119.6	0.00	5.43	0.83	2	6	1	99	0.00	0.0	5.469	0.001	0	0	0	1
PL.38891	PD.6009	C	#2 ACSR	7.17Y	119.6	0.00	5.43	0.83	0	6	1	99	0.00	0.0	5.553	0.085	6	1	1	1
PL.37216	PL.38883	ABC	#1/0 ACSR	7.17Y	119.6	0.00	5.43	21.93	10	458	113	97	0.01	0.0	5.280	0.009	0	0	0	94
PL.38884	PL.37216	ABC	#1/0 ACSR	7.17Y	119.6	0.00	5.43	21.93	10	458	113	97	0.00	0.0	5.280	0.000	0	0	0	94
PD.5914	PL.38884	ABC	50L	7.17Y	119.6	0.00	5.43	21.93	44	458	113	97	0.00	0.0	5.280	0.000	0	0	0	94
PL.37662	PD.5914	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.45	21.93	10	458	113	97	0.06	0.0	5.326	0.046	0	0	0	94
PL.38892	PL.37662	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.47	21.92	10	458	113	97	0.07	0.0	5.380	0.054	0	0	0	93
PL.38256	PL.38892	ABC	#1/0 ACSR	7.17Y	119.5	0.03	5.50	21.91	10	458	113	97	0.10	0.0	5.458	0.077	0	0	0	92
PL.38255	PL.38256	B	#1/0 ACSR	7.17Y	119.5	0.00	5.50	1.42	1	10	2	98	0.00	0.0	5.505	0.048	10	2	2	2
PL.38257	PL.38256	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.53	21.43	9	448	110	97	0.07	0.0	5.515	0.058	0	0	0	90
PL.38253	PL.38257	B	#1/0 ACSR	7.17Y	119.5	0.00	5.53	1.96	1	14	3	98	0.00	0.0	5.518	0.003	0	0	0	2
PD.5228	PL.38253	B	25QA	7.17Y	119.5	0.00	5.53	1.96	8	14	3	98	0.00	0.0	5.518	0.003	0	0	0	2
PL.38254	PD.5228	B	#1/0 ACSR	7.17Y	119.5	0.00	5.53	1.96	1	14	3	98	0.00	0.0	5.700	0.182	14	3	2	2
PL.38885	PL.38257	ABC	#1/0 ACSR	7.17Y	119.5	0.02	5.55	20.78	9	434	107	97	0.07	0.0	5.579	0.064	0	0	0	88
PL.38893	PL.38885	C	#2 ACSR	7.17Y	119.5	0.00	5.55	1.17	1	8	2	97	0.00	0.0	5.580	0.001	0	0	0	2
PD.5227	PL.38893	C	25QA	7.17Y	119.5	0.00	5.55	1.17	5	8	2	97	0.00	0.0	5.580	0.001	0	0	0	2
PL.38894	PD.5227	C	#2 ACSR	7.17Y	119.5	0.00	5.55	1.17	1	8	2	97	0.00	0.0	5.588	0.008	2	1	1	2
PL.38887	PL.38894	C	#2 ACSR	7.17Y	119.4	0.00	5.55	0.87	0	6	1	99	0.00	0.0	5.617	0.029	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38886	PL.38885	ABC	#1/0 ACSR	7.17Y	119.4	0.03	5.58	20.39	9	426	105	97	0.08	0.0	5.655	0.076	0	0	0	86
PL.38405	PL.38886	ABC	#1/0 ACSR	7.16Y	119.4	0.02	5.60	20.39	9	426	105	97	0.07	0.0	5.718	0.063	0	0	0	86
PL.37667	PL.38405	B	6 A (CWC)	7.16Y	119.4	0.00	5.60	10.09	7	70	17	97	0.00	0.0	5.719	0.000	0	0	0	15
PD.5226	PL.37667	B	25QA	7.16Y	119.4	0.00	5.60	10.09	40	70	17	97	0.00	0.0	5.719	0.000	0	0	0	15
PL.37843	PD.5226	B	6 A (CWC)	7.16Y	119.4	0.01	5.61	10.09	7	70	17	97	0.00	0.0	5.731	0.013	0	0	0	15
PL.37844	PL.37843	B	6 A (CWC)	7.16Y	119.4	0.01	5.61	10.09	7	70	17	97	0.00	0.0	5.749	0.018	0	0	0	15
PL.38951	PL.37844	B	6 A (CWC)	7.16Y	119.3	0.04	5.66	10.09	7	70	17	97	0.02	0.0	5.848	0.099	8	2	1	15
PL.38952	PL.38951	B	6 A (CWC)	7.16Y	119.3	0.02	5.68	8.99	6	63	15	97	0.01	0.0	5.896	0.048	7	2	1	14
PL.38953	PL.38952	B	6 A (CWC)	7.16Y	119.3	0.02	5.70	7.57	5	53	13	97	0.01	0.0	5.985	0.088	22	5	4	12
PL.38956	PL.38953	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	0.50	0	3	1	95	0.00	0.0	6.065	0.081	0	0	0	2
PL.38957	PL.38956	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	0.50	0	3	1	95	0.00	0.0	6.148	0.082	3	1	2	2
PL.38954	PL.38953	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	1.47	1	10	2	98	0.00	0.0	6.031	0.046	6	1	1	2
PL.38955	PL.38954	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	0.61	0	4	1	97	0.00	0.0	6.093	0.062	4	1	1	1
PL.37688	PL.38953	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	2.40	2	17	4	97	0.00	0.0	6.038	0.054	17	4	2	4
PL.37689	PL.37688	B	6 A (CWC)	7.16Y	119.3	0.00	5.70	0.00	0	0	0	100	0.00	0.0	6.095	0.056	0	0	2	2
PL.36720	PL.38952	B	6 A (CWC)	7.16Y	119.3	0.00	5.68	0.35	0	2	1	89	0.00	0.0	5.958	0.061	2	1	1	1
PL.37766	PL.38405	ABC	#1/0 ACSR	7.16Y	119.4	0.04	5.64	17.03	7	355	88	97	0.11	0.0	5.857	0.139	0	0	0	71
PL.37690	PL.37766	A	#2 ACSR	7.16Y	119.4	0.00	5.64	0.81	0	6	1	99	0.00	0.0	5.858	0.001	0	0	0	2
PD.5225	PL.37690	A	25QA	7.16Y	119.4	0.00	5.64	0.81	3	6	1	99	0.00	0.0	5.858	0.001	0	0	0	2
PL.37691	PD.5225	A	#2 ACSR	7.16Y	119.4	0.00	5.64	0.81	0	6	1	99	0.00	0.0	5.879	0.021	6	1	2	2
PL.38958	PL.37766	ABC	#1/0 ACSR	7.16Y	119.4	0.01	5.65	10.78	5	225	56	97	0.01	0.0	5.886	0.029	0	0	0	43
PL.38959	PL.38958	ABC	#1/0 ACSR	7.16Y	119.3	0.01	5.65	10.78	5	225	56	97	0.01	0.0	5.918	0.032	0	0	0	43
PL.39229	PL.38959	B	#4 ACSR	7.16Y	119.3	0.00	5.66	32.34	25	225	56	97	0.00	0.0	5.919	0.001	0	0	0	43
PD.6008	PL.39229	B	50QA	7.16Y	119.3	0.00	5.66	32.34	65	225	56	97	0.00	0.0	5.919	0.001	0	0	0	43
PL.39230	PD.6008	B	#4 ACSR	7.16Y	119.3	0.05	5.71	32.34	25	225	56	97	0.09	0.0	5.956	0.037	4	1	1	43
PL.38417	PL.39230	B	#4 ACSR	7.15Y	119.2	0.14	5.84	31.71	24	220	55	97	0.23	0.1	6.056	0.100	16	4	3	42
PL.39231	PL.38417	B	#4 ACSR	7.14Y	119.0	0.14	5.98	29.34	23	204	50	97	0.22	0.1	6.163	0.107	0	0	0	39
PL.37825	PL.39231	B	#4 ACSR	7.14Y	119.0	0.00	5.98	2.00	2	14	3	98	0.00	0.0	6.223	0.060	14	3	2	2
PL.39232	PL.39231	B	#4 ACSR	7.14Y	118.9	0.07	6.05	27.34	21	190	47	97	0.11	0.1	6.223	0.060	0	0	0	37
PL.39233	PL.39232	B	#4 ACSR	7.13Y	118.8	0.12	6.17	27.34	21	189	47	97	0.17	0.1	6.320	0.097	0	0	1	37
REG84	PL.39233	B	76.2 KVA	7.50Y	125.1	-6.25	-0.08	27.34	27	189	47	97	percent Boost= 0.00 Tap= 0.0						36	

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.39234	REG84	B	#4 ACSR	7.50Y	125.0	0.06	-0.02	25.97	20	189	47	97	0.09	0.0	6.376	0.056	3	1	1	36
PL.39235	PL.39234	B	#4 ACSR	7.49Y	124.8	0.21	0.19	23.77	18	173	43	97	0.26	0.2	6.574	0.199	7	2	1	34
PL.39236	PL.39235	B	#4 ACSR	7.48Y	124.7	0.08	0.27	22.83	18	166	41	97	0.10	0.1	6.655	0.080	0	0	0	32
PL.39237	PL.39236	B	#4 ACSR	7.46Y	124.4	0.34	0.60	21.62	17	157	39	97	0.39	0.2	7.020	0.365	11	3	2	31
PL.39238	PL.39237	B	#4 ACSR	7.44Y	124.1	0.33	0.93	20.12	15	146	36	97	0.36	0.2	7.386	0.366	0	0	0	29
PL.39239	PL.39238	B	#4 ACSR	7.43Y	123.9	0.16	1.09	20.12	15	145	36	97	0.18	0.1	7.571	0.185	0	0	0	29
PL.37226	PL.39239	B	#4 ACSR	7.43Y	123.9	0.00	1.09	0.00	0	0	0	100	0.00	0.0	7.641	0.071	0	0	0	0
PL.39240	PL.39239	B	#4 ACSR	7.43Y	123.8	0.07	1.16	20.12	15	145	36	97	0.08	0.1	7.650	0.079	0	0	0	29
PL.37298	PL.39240	B	#4 ACSR	7.43Y	123.8	0.00	1.17	2.51	2	18	4	98	0.00	0.0	7.698	0.048	18	4	2	2
PL.39241	PL.39240	B	#4 ACSR	7.43Y	123.8	0.07	1.24	17.62	14	127	31	97	0.07	0.1	7.744	0.094	0	0	0	27
PL.37877	PL.39241	B	6 A (CWC)	7.41Y	123.6	0.19	1.42	17.62	13	127	31	97	0.18	0.1	7.976	0.232	0	0	0	27
PL.39242	PL.37877	B	6 A (CWC)	7.41Y	123.6	0.00	1.43	8.44	6	61	15	97	0.00	0.0	7.982	0.006	0	0	0	11
PD.6019	PL.39242	B	40QA	7.41Y	123.6	0.00	1.43	8.44	21	61	15	97	0.00	0.0	7.982	0.006	0	0	0	11
PL.39243	PD.6019	B	6 A (CWC)	7.41Y	123.5	0.04	1.46	8.44	6	61	15	97	0.02	0.0	8.081	0.099	8	2	2	11
PL.38403	PL.39243	B	6 A (CWC)	7.41Y	123.4	0.09	1.55	7.34	5	53	13	97	0.03	0.1	8.411	0.330	19	5	2	9
PL.38404	PL.38403	B	6 A (CWC)	7.41Y	123.4	0.01	1.56	4.70	3	34	8	97	0.00	0.0	8.464	0.052	0	0	0	7
PL.37291	PL.38404	B	#4 ACSR	7.41Y	123.4	0.00	1.56	0.20	0	1	0	100	0.00	0.0	8.517	0.054	1	0	1	1
PL.39306	PL.38404	B	6 A (CWC)	7.40Y	123.4	0.06	1.62	4.49	3	32	8	97	0.01	0.0	8.748	0.284	2	0	1	6
PL.39307	PL.39306	B	6 A (CWC)	7.40Y	123.4	0.03	1.65	4.26	3	31	7	98	0.01	0.0	8.926	0.179	11	3	2	5
PL.38652	PL.39307	B	6 A (CWC)	7.40Y	123.3	0.02	1.66	2.69	2	19	5	97	0.00	0.0	9.081	0.155	3	1	1	3
PL.61386	PL.38652	B	6 A (CWC)	7.40Y	123.3	0.00	1.67	2.30	2	17	4	97	0.00	0.0	9.155	0.074	13	3	1	2
PL.61387	PL.61386	B	6 A (CWC)	7.40Y	123.3	0.00	1.67	0.56	0	4	1	97	0.00	0.0	9.323	0.168	4	1	1	1
PL.39244	PL.37877	B	6 A (CWC)	7.41Y	123.5	0.07	1.49	9.18	7	66	16	97	0.03	0.0	8.134	0.158	0	0	0	16
PL.39245	PL.39244	B	6 A (CWC)	7.41Y	123.5	0.05	1.54	9.18	7	66	16	97	0.02	0.0	8.264	0.131	7	2	1	16
PL.39246	PL.39245	B	6 A (CWC)	7.41Y	123.4	0.02	1.56	8.22	6	59	14	97	0.01	0.0	8.325	0.061	2	1	1	15
PL.38895	PL.39246	B	6 A (CWC)	7.40Y	123.4	0.04	1.60	7.90	6	57	14	97	0.02	0.0	8.439	0.113	7	2	3	14
PL.38896	PL.38895	B	6 A (CWC)	7.40Y	123.4	0.02	1.62	6.88	5	50	12	97	0.01	0.0	8.526	0.087	20	5	6	11
PL.38897	PL.38896	B	6 A (CWC)	7.40Y	123.4	0.02	1.64	4.09	3	29	7	97	0.00	0.0	8.623	0.098	10	2	2	5
PL.38898	PL.38897	B	6 A (CWC)	7.40Y	123.4	0.01	1.64	2.01	1	14	4	96	0.00	0.0	8.747	0.123	14	4	2	2
PL.39228	PL.38898	B	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	8.827	0.080	0	0	0	0
PL.51770	PL.39228	B	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	8.830	0.003	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5966-B	PL.51770	B	Open	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	8.830	0.003	0	0	0	0
PL.38203	PL.39228	B	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	8.832	0.005	0	0	0	0
PD.5915-B	PL.38203	B	Open	7.40Y	123.4	0.00	1.64	0.00	0	0	0	100	0.00	0.0	8.832	0.005	0	0	0	0
PL.37657	PL.38897	B	6 A (CWC)	7.40Y	123.4	0.00	1.64	0.72	1	5	1	98	0.00	0.0	8.723	0.100	5	1	1	1
PL.37798	PL.39236	B	#4 ACSR	7.48Y	124.7	0.00	0.27	1.21	1	9	2	98	0.00	0.0	6.699	0.044	9	2	1	1
PL.37225	PL.39235	B	#4 ACSR	7.49Y	124.8	0.00	0.19	0.01	0	0	0	100	0.00	0.0	6.679	0.104	0	0	1	1
PL.37408	PL.39234	B	#4 ACSR	7.50Y	125.0	0.00	-0.02	1.80	1	13	3	97	0.00	0.0	6.445	0.070	13	3	1	1
PL.37692	PL.37766	B	6 A (CWC)	7.16Y	119.3	0.02	5.66	17.93	13	125	30	97	0.02	0.0	5.884	0.026	19	5	5	26
PL.39305	PL.37692	B	6 A (CWC)	7.16Y	119.3	0.06	5.72	15.26	11	106	26	97	0.05	0.0	5.971	0.087	0	0	1	21
PL.38649	PL.39305	B	6 A (CWC)	7.15Y	119.2	0.03	5.75	15.26	11	106	26	97	0.03	0.0	6.019	0.048	4	1	3	20
PL.39304	PL.38649	B	6 A (CWC)	7.15Y	119.2	0.04	5.79	13.51	10	94	23	97	0.03	0.0	6.091	0.072	19	5	1	15
PL.37695	PL.39304	B	6 A (CWC)	7.15Y	119.2	0.04	5.83	10.81	8	75	18	97	0.02	0.0	6.171	0.080	0	0	0	14
PL.37224	PL.37695	B	#4 ACSR	7.15Y	119.2	0.00	5.83	0.00	0	0	0	100	0.00	0.0	6.250	0.079	0	0	0	0
PL.39303	PL.37695	B	6 A (CWC)	7.15Y	119.1	0.06	5.90	10.81	8	75	18	97	0.04	0.0	6.297	0.126	0	0	0	14
PL.37995	PL.39303	B	#4 ACSR	7.14Y	119.1	0.03	5.93	7.78	6	54	13	97	0.01	0.0	6.395	0.099	5	1	2	10
PL.37728	PL.37995	B	6 A (CWC)	7.14Y	119.1	0.00	5.93	0.00	0	0	0	100	0.00	0.0	6.527	0.132	0	0	0	0
PL.37237	PL.37995	B	#4 ACSR	7.14Y	119.0	0.03	5.96	7.12	5	49	12	97	0.01	0.0	6.514	0.118	12	3	2	8
PL.39291	PL.37237	B	#4 ACSR	7.14Y	119.0	0.02	5.98	5.37	4	37	9	97	0.00	0.0	6.595	0.082	6	1	1	6
PL.39292	PL.39291	B	#4 ACSR	7.14Y	119.0	0.02	6.00	4.52	3	31	8	97	0.00	0.0	6.723	0.128	10	2	2	5
PL.39293	PL.39292	B	#4 ACSR	7.14Y	119.0	0.01	6.01	3.14	2	22	5	98	0.00	0.0	6.774	0.051	0	0	0	3
PL.39296	PL.39293	B	#4 ACSR	7.14Y	119.0	0.01	6.01	1.32	1	9	2	98	0.00	0.0	6.907	0.133	0	0	0	1
PL.56963	PL.39296	B	#4 ACSR	7.14Y	119.0	0.00	6.01	0.00	0	0	0	100	0.00	0.0	6.962	0.055	0	0	0	0
PL.37238	PL.39296	B	#4 ACSR	7.14Y	119.0	0.00	6.02	1.32	1	9	2	98	0.00	0.0	7.046	0.139	9	2	1	1
PL.39297	PL.37238	B	#4 ACSR	7.14Y	119.0	0.00	6.02	0.00	0	0	0	100	0.00	0.0	7.158	0.112	0	0	0	0
PL.39298	PL.39297	B	#4 ACSR	7.14Y	119.0	0.00	6.02	0.00	0	0	0	100	0.00	0.0	7.250	0.092	0	0	0	0
PL.39299	PL.39297	B	#4 ACSR	7.14Y	119.0	0.00	6.02	0.00	0	0	0	100	0.00	0.0	7.248	0.090	0	0	0	0
PL.39300	PL.39299	B	#4 ACSR	7.14Y	119.0	0.00	6.02	0.00	0	0	0	100	0.00	0.0	7.266	0.018	0	0	0	0
PL.39294	PL.39293	B	#4 ACSR	7.14Y	119.0	0.01	6.01	1.82	1	13	3	97	0.00	0.0	6.872	0.098	0	0	0	2
PL.39295	PL.39294	B	#4 ACSR	7.14Y	119.0	0.00	6.02	1.82	1	13	3	97	0.00	0.0	6.985	0.113	13	3	2	2
PL.39301	PL.39303	B	#4 ACSR	7.15Y	119.1	0.02	5.91	3.02	2	21	5	97	0.00	0.0	6.467	0.170	10	2	2	4
PL.39302	PL.39301	B	#4 ACSR	7.15Y	119.1	0.00	5.92	1.62	1	11	3	96	0.00	0.0	6.548	0.081	11	3	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37223	PL.38649	B	#4 ACSR	7.15Y	119.2	0.00	5.76	1.19	1	8	2	97	0.00	0.0	6.072	0.053	8	2	2	2
PL.37387	PL.38892	B	#2 ACSR	7.17Y	119.5	0.00	5.47	0.03	0	0	0	100	0.00	0.0	5.399	0.019	0	0	1	1
PL.37663	PL.37662	A	#2 ACSR	7.17Y	119.5	0.00	5.45	0.03	0	0	0	100	0.00	0.0	5.327	0.001	0	0	0	1
PD.5229	PL.37663	A	25QA	7.17Y	119.5	0.00	5.45	0.03	0	0	0	100	0.00	0.0	5.327	0.001	0	0	0	1
PL.37664	PD.5229	A	#2 ACSR	7.17Y	119.5	0.00	5.45	0.03	0	0	0	100	0.00	0.0	5.342	0.015	0	0	1	1
PL.37222	PL.38879	A	#4 ACSR	7.18Y	119.6	0.00	5.35	0.30	0	2	1	89	0.00	0.0	4.877	0.027	2	1	1	1
PL.38877	PL.38876	A	#4 ACSR	7.18Y	119.7	0.00	5.34	0.00	0	0	0	100	0.00	0.0	4.811	0.023	0	0	0	0
PL.38878	PL.38877	A	#4 ACSR	7.18Y	119.7	0.00	5.34	0.00	0	0	0	100	0.00	0.0	4.839	0.028	0	0	0	0
PL.37101	PL.37992	ABC	#1/0 ACSR	7.19Y	119.8	0.04	5.23	67.01	29	1396	373	97	0.40	0.0	4.363	0.034	0	0	0	263
PD.6086	PL.37101	ABC	100L	7.19Y	119.8	0.00	5.23	67.01	67	1396	372	97	0.00	0.0	4.363	0.034	0	0	0	263
PL.37102	PD.6086	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.23	67.01	29	1396	372	97	0.00	0.0	4.364	0.000	0	0	0	263
PL.37990	PL.37102	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.24	67.01	29	1396	372	97	0.09	0.0	4.372	0.008	8	2	1	263
PL.37991	PL.37990	ABC	#1/0 ACSR	7.18Y	119.7	0.04	5.27	66.61	29	1387	370	97	0.35	0.0	4.401	0.030	0	0	0	262
PL.37988	PL.37991	A	6 A (CWC)	7.18Y	119.7	0.00	5.27	2.99	2	21	5	97	0.00	0.0	4.402	0.001	0	0	0	5
PD.5977	PL.37988	A	40QA	7.18Y	119.7	0.00	5.27	2.99	7	21	5	97	0.00	0.0	4.402	0.001	0	0	0	5
PL.37989	PD.5977	A	6 A (CWC)	7.18Y	119.7	0.01	5.28	2.99	2	21	5	97	0.00	0.0	4.489	0.087	0	0	0	5
PL.37819	PL.37989	A	6 A (CWC)	7.18Y	119.7	0.03	5.31	2.99	2	21	5	97	0.00	0.0	4.711	0.222	0	0	0	5
PL.37994	PL.37819	A	6 A (CWC)	7.18Y	119.7	0.01	5.33	2.99	2	21	5	97	0.00	0.0	4.812	0.101	6	2	1	5
PL.38520	PL.37994	A	6 A (CWC)	7.18Y	119.7	0.01	5.34	2.09	1	15	4	97	0.00	0.0	4.925	0.113	0	0	2	4
PL.38541	PL.38520	A	6 A (CWC)	7.18Y	119.7	0.01	5.34	2.06	1	14	3	98	0.00	0.0	5.043	0.118	14	3	2	2
PL.37212	PL.37819	A	6 A (CWC)	7.18Y	119.7	0.00	5.31	0.00	0	0	0	100	0.00	0.0	4.800	0.089	0	0	0	0
PL.57225	PL.37991	ABC	#1/0 ACSR	7.18Y	119.6	0.09	5.36	65.61	29	1366	365	97	0.88	0.1	4.477	0.076	0	0	0	257
PL.57226	PL.57225	ABC	#1/0 ACSR	7.17Y	119.4	0.21	5.57	65.25	28	1358	362	97	2.04	0.2	4.659	0.181	10	3	1	256
PL.37696	PL.57226	ABC	1/0 AL URD	7.17Y	119.4	0.00	5.57	4.43	3	86	41	90	0.00	0.0	4.687	0.028	86	41	1	1
PL.37759	PL.57226	ABC	#1/0 ACSR	7.16Y	119.3	0.08	5.65	60.42	26	1260	316	97	0.73	0.1	4.734	0.075	0	0	0	254
PL.36725	PL.37759	B	#4 ACSR	7.16Y	119.3	0.00	5.65	0.02	0	0	0	100	0.00	0.0	4.830	0.096	0	0	0	1
PL.64301	PL.36725	B	#4 ACSR	7.16Y	119.3	0.00	5.65	0.02	0	0	0	100	0.00	0.0	4.874	0.044	0	0	1	1
PL.37758	PL.37759	ABC	#1/0 ACSR	7.16Y	119.3	0.06	5.71	60.41	26	1259	316	97	0.50	0.0	4.786	0.052	0	0	0	253
PL.37984	PL.37758	ABC	#1/0 ACSR	7.15Y	119.2	0.06	5.77	59.02	26	1229	308	97	0.56	0.0	4.848	0.063	55	13	3	251
PL.38431	PL.37984	A	6 A (CWC)	7.15Y	119.2	0.00	5.77	2.46	2	17	4	97	0.00	0.0	4.848	0.000	0	0	0	4
PD.6011	PL.38431	A	40QA	7.15Y	119.2	0.00	5.77	2.46	6	17	4	97	0.00	0.0	4.848	0.000	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.64451	PD.6011	A	6 A (CWC)	7.15Y	119.2	0.01	5.78	2.46	2	17	4	97	0.00	0.0	4.898	0.050	0	0	0	4
PL.64450	PL.64451	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	2.04	1	14	3	98	0.00	0.0	4.962	0.064	14	3	2	2
PL.64449	PL.64451	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	0.42	0	3	1	95	0.00	0.0	4.964	0.066	3	1	1	2
PL.64453	PL.64449	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	4.995	0.030	0	0	1	1
PL.63068	PL.64453	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	4.995	0.000	0	0	0	0
PL.63067	PL.63068	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	5.154	0.159	0	0	0	0
PL.38259	PL.63067	A	6 A (CWC)	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	5.195	0.041	0	0	0	0
PL.64452	PL.64451	A	#2 ACSR	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	4.970	0.072	0	0	0	0
PL.37983	PL.64452	A	#2 ACSR	7.15Y	119.2	0.00	5.78	0.00	0	0	0	100	0.00	0.0	5.040	0.070	0	0	0	0
PL.38429	PL.37984	ABC	#1/0 ACSR	7.15Y	119.2	0.04	5.81	55.57	24	1157	290	97	0.32	0.0	4.887	0.039	0	0	1	244
PL.38430	PL.38429	ABC	#1/0 ACSR	7.15Y	119.1	0.04	5.86	55.57	24	1156	290	97	0.37	0.0	4.932	0.045	0	0	0	243
PL.37982	PL.38430	ABC	#1/0 ACSR	7.14Y	119.0	0.19	6.04	55.57	24	1156	289	97	1.55	0.1	5.120	0.188	4	1	1	243
PL.36876	PL.37982	ABC	#1/0 ACSR	7.13Y	118.9	0.10	6.14	55.39	24	1151	287	97	0.79	0.1	5.217	0.097	8	2	2	242
PL.58436	PL.36876	A	#4 ACSR	7.13Y	118.9	0.00	6.14	1.92	1	13	3	97	0.00	0.0	5.218	0.001	0	0	0	2
PD.8590	PL.58436	A	20T	7.13Y	118.9	0.00	6.14	1.92	0	13	3	97	0.00	0.0	5.218	0.001	0	0	0	2
PL.58437	PD.8590	A	#4 ACSR	7.13Y	118.9	0.00	6.14	1.92	1	13	3	97	0.00	0.0	5.262	0.044	13	3	2	2
PL.58435	PL.58437	A	#4 ACSR	7.13Y	118.9	0.00	6.14	0.00	0	0	0	100	0.00	0.0	5.391	0.129	0	0	0	0
PL.38503	PL.36876	ABC	#1/0 ACSR	7.12Y	118.6	0.22	6.36	54.34	24	1128	281	97	1.79	0.2	5.445	0.227	0	0	0	237
PL.38505	PL.38503	A	#4 ACSR	7.12Y	118.6	0.00	6.36	0.67	1	5	1	98	0.00	0.0	5.445	0.001	0	0	0	1
PD.6067	PL.38505	A	40QA	7.12Y	118.6	0.00	6.36	0.67	2	5	1	98	0.00	0.0	5.445	0.001	0	0	0	1
PL.38506	PD.6067	A	#4 ACSR	7.12Y	118.6	0.00	6.36	0.67	1	5	1	98	0.00	0.0	5.498	0.052	5	1	1	1
PL.38504	PL.38503	ABC	#1/0 ACSR	7.11Y	118.5	0.09	6.45	54.04	23	1120	278	97	0.75	0.1	5.542	0.097	0	0	0	235
REG85	PL.38504	ABC	114.3 KVA	7.54Y	125.6	-7.07	-0.62	54.04	36	1119	277	97	percent Boost= 5.62 Tap= 9.0							235
PL.38428	REG85	ABC	#1/0 ACSR	7.53Y	125.6	0.06	-0.56	51.00	22	1119	277	97	0.44	0.0	5.606	0.064	6	2	1	235
PL.38500	PL.38428	ABC	#1/0 ACSR	7.53Y	125.5	0.05	-0.51	50.71	22	1113	275	97	0.37	0.0	5.661	0.055	17	4	2	234
PL.38136	PL.38500	ABC	#1/0 ACSR	7.53Y	125.4	0.08	-0.43	39.60	17	868	215	97	0.45	0.1	5.768	0.108	0	0	0	191
PL.38138	PL.38136	A	#4 ACSR	7.53Y	125.4	0.00	-0.43	1.53	1	11	3	96	0.00	0.0	5.771	0.003	0	0	0	2
PD.6066	PL.38138	A	40QA	7.53Y	125.4	0.00	-0.43	1.53	4	11	3	96	0.00	0.0	5.771	0.003	0	0	0	2
PL.38139	PD.6066	A	#4 ACSR	7.53Y	125.4	0.00	-0.43	1.53	1	11	3	96	0.00	0.0	5.841	0.070	11	3	2	2
PL.38140	PL.38136	A	#1/0 ACSR	7.53Y	125.4	0.00	-0.43	1.64	1	12	3	97	0.00	0.0	5.770	0.002	0	0	0	3
PD.6049	PL.38140	A	40QA	7.53Y	125.4	0.00	-0.43	1.64	4	12	3	97	0.00	0.0	5.770	0.002	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38015	PD.6049	A	#1/0 ACSR	7.53Y	125.4	0.00	-0.43	1.64	1	12	3	97	0.00	0.0	5.839	0.069	12	3	3	3
PL.38137	PL.38136	ABC	#1/0 ACSR	7.52Y	125.4	0.06	-0.38	38.54	17	845	209	97	0.33	0.0	5.851	0.083	0	0	0	186
PL.37328	PL.38137	ABC	#1/0 ACSR	7.52Y	125.3	0.05	-0.33	27.04	12	593	146	97	0.21	0.0	5.957	0.105	0	0	0	134
PL.37329	PL.37328	ABC	#1/0 ACSR	7.52Y	125.3	0.03	-0.30	26.65	12	584	144	97	0.11	0.0	6.015	0.058	0	0	0	131
PL.38013	PL.37329	ABC	#1/0 ACSR	7.52Y	125.3	0.03	-0.27	25.14	11	551	136	97	0.12	0.0	6.086	0.071	0	0	0	126
PL.37435	PL.38013	ABC	#1/0 ACSR	7.51Y	125.2	0.04	-0.23	24.66	11	540	133	97	0.14	0.0	6.175	0.089	9	2	1	123
PL.37432	PL.37435	C	#4 ACSR	7.51Y	125.2	0.00	-0.23	2.57	2	19	5	97	0.00	0.0	6.176	0.001	0	0	0	6
PD.6068	PL.37432	C	40QA	7.51Y	125.2	0.00	-0.23	2.57	6	19	5	97	0.00	0.0	6.176	0.001	0	0	0	6
PL.37412	PD.6068	C	#4 ACSR	7.51Y	125.2	0.00	-0.22	2.57	2	19	5	97	0.00	0.0	6.213	0.037	0	0	0	6
PL.37433	PL.37412	C	#4 ACSR	7.51Y	125.2	0.01	-0.22	2.57	2	19	5	97	0.00	0.0	6.275	0.061	4	1	5	6
PL.37434	PL.37433	C	#4 ACSR	7.51Y	125.2	0.00	-0.21	2.05	2	15	4	97	0.00	0.0	6.320	0.045	15	4	1	1
PL.37431	PL.37435	ABC	#1/0 ACSR	7.51Y	125.1	0.08	-0.14	23.41	10	512	126	97	0.30	0.1	6.380	0.205	7	2	1	116
PL.56894	PL.37431	ABC	#1/0 ACSR	7.51Y	125.1	0.04	-0.11	22.82	10	499	123	97	0.12	0.0	6.468	0.088	10	2	4	112
PL.56893	PL.56894	ABC	#1/0 ACSR	7.51Y	125.1	0.01	-0.10	22.04	10	482	118	97	0.04	0.0	6.498	0.030	0	0	0	106
PL.37744	PL.56893	ABC	#1/0 ACSR	7.51Y	125.1	0.01	-0.09	21.68	9	474	116	97	0.02	0.0	6.518	0.020	10	2	2	102
PL.37428	PL.37744	ABC	#1/0 ACSR	7.50Y	125.1	0.02	-0.07	21.22	9	464	114	97	0.05	0.0	6.559	0.041	7	2	1	100
PL.64416	PL.37428	A C	#1/0 ACSR	7.50Y	125.0	0.03	-0.05	31.38	14	457	112	97	0.08	0.0	6.600	0.040	0	0	0	99
PL.64417	PL.64416	A C	#1/0 ACSR	7.50Y	125.0	0.00	-0.05	31.38	14	457	112	97	0.00	0.0	6.600	0.000	15	4	3	99
PL.38551	PL.64417	A C	#1/0 ACSR	7.50Y	125.0	0.01	-0.04	30.33	13	442	108	97	0.03	0.0	6.616	0.016	0	0	0	96
PL.62727	PL.38551	A C	#1/0 ACSR	7.50Y	125.0	0.00	-0.04	30.33	13	442	108	97	0.01	0.0	6.619	0.003	0	0	0	96
PD.8893	PL.62727	A C	50L	7.50Y	125.0	0.00	-0.04	30.33	61	442	108	97	0.00	0.0	6.619	0.003	0	0	0	96
PL.62724	PD.8893	A C	#1/0 ACSR	7.50Y	125.0	0.01	-0.02	30.33	13	442	108	97	0.03	0.0	6.635	0.017	2	0	1	96
PL.62726	PL.62724	A	#1/0 ACSR	7.50Y	125.0	0.00	-0.02	1.21	1	9	2	98	0.00	0.0	6.636	0.001	0	0	0	3
PD.7944	PL.62726	A	10QA	7.50Y	125.0	0.00	-0.02	1.21	0	9	2	98	0.00	0.0	6.636	0.001	0	0	0	3
PL.51886	PD.7944	A	#1/0 ACSR	7.50Y	125.0	0.00	-0.02	1.21	1	9	2	98	0.00	0.0	6.647	0.011	9	2	3	3
PL.62725	PL.62724	A C	#1/0 ACSR	7.50Y	125.0	0.01	-0.02	29.62	13	432	106	97	0.03	0.0	6.650	0.015	9	2	1	92
PL.56975	PL.62725	A C	#1/0 ACSR	7.50Y	125.0	0.02	0.01	29.04	13	423	104	97	0.06	0.0	6.691	0.041	23	6	5	91
PL.51890	PL.56975	A C	#1/0 ACSR	7.50Y	125.0	0.03	0.04	25.51	11	372	91	97	0.08	0.0	6.753	0.062	0	0	0	78
PL.51893	PL.51890	C	#1/0 ACSR	7.50Y	125.0	0.00	0.04	6.67	3	49	12	97	0.00	0.0	6.753	0.000	0	0	0	10
PD.7946	PL.51893	C	10QA	7.50Y	125.0	0.00	0.04	6.67	0	49	12	97	0.00	0.0	6.753	0.000	0	0	0	10
PL.51894	PD.7946	C	#1/0 ACSR	7.50Y	125.0	0.00	0.04	6.67	3	49	12	97	0.00	0.0	6.753	0.000	0	0	0	10

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.51892	PL.51894	C	#1/0 ACSR	7.50Y	125.0	0.01	0.05	6.67	3	49	12	97	0.00	0.0	6.814	0.061	31	8	7	10
PL.51889	PL.51892	C	6 A (CWC)	7.50Y	125.0	0.00	0.05	1.17	1	9	2	98	0.00	0.0	6.881	0.066	9	2	1	1
PL.51891	PL.51892	C	#1/0 ACSR	7.50Y	125.0	0.00	0.05	1.21	1	9	2	98	0.00	0.0	6.878	0.063	0	0	0	2
PL.37716	PL.51891	C	6 A (CWC)	7.50Y	125.0	0.00	0.05	1.21	1	9	2	98	0.00	0.0	6.957	0.079	9	2	2	2
PL.38552	PL.51891	C	#1/0 ACSR	7.50Y	125.0	0.00	0.05	0.00	0	0	0	100	0.00	0.0	6.976	0.098	0	0	0	0
PL.51895	PL.51890	A C	#1/0 ACSR	7.50Y	124.9	0.02	0.05	22.18	10	323	79	97	0.03	0.0	6.786	0.033	0	0	1	68
PL.51898	PL.51895	A C	#1/0 ACSR	7.50Y	124.9	0.02	0.08	22.15	10	323	79	97	0.05	0.0	6.837	0.051	0	0	0	67
PL.51900	PL.51898	C	#1/0 ACSR	7.50Y	124.9	0.00	0.08	0.63	0	5	1	98	0.00	0.0	6.838	0.001	0	0	0	3
PD.7948	PL.51900	C	10QA	7.50Y	124.9	0.00	0.08	0.63	0	5	1	98	0.00	0.0	6.838	0.001	0	0	0	3
PL.51901	PD.7948	C	#1/0 ACSR	7.50Y	124.9	0.00	0.08	0.63	0	5	1	98	0.00	0.0	6.852	0.014	5	1	3	3
PL.51899	PL.51898	A C	#1/0 ACSR	7.49Y	124.9	0.03	0.11	21.84	9	318	78	97	0.07	0.0	6.912	0.075	0	0	0	64
PL.51902	PL.51899	A	#1/0 ACSR	7.49Y	124.9	0.00	0.11	0.19	0	1	0	100	0.00	0.0	6.939	0.027	1	0	1	1
PL.51903	PL.51899	A	#1/0 ACSR	7.49Y	124.9	0.00	0.11	23.95	10	174	43	97	0.00	0.0	6.913	0.001	0	0	0	38
PD.7949	PL.51903	A	40QA	7.49Y	124.9	0.00	0.11	23.95	60	174	43	97	0.00	0.0	6.913	0.001	0	0	0	38
PL.51904	PD.7949	A	#1/0 ACSR	7.49Y	124.9	0.03	0.14	23.95	10	174	43	97	0.03	0.0	6.962	0.049	0	0	0	38
PL.38566	PL.51904	A	#4 ACSR	7.47Y	124.4	0.44	0.58	20.17	16	147	36	97	0.49	0.3	7.461	0.498	0	0	0	33
PL.38168	PL.38566	A	#4 ACSR	7.46Y	124.3	0.09	0.67	20.17	16	146	36	97	0.10	0.1	7.561	0.101	0	0	0	33
PL.37254	PL.38168	A	#4 ACSR	7.46Y	124.3	0.00	0.67	0.00	0	0	0	100	0.00	0.0	7.633	0.072	0	0	0	0
PL.64292	PL.38168	A	#4 ACSR	7.46Y	124.3	0.06	0.73	20.17	16	146	36	97	0.06	0.0	7.629	0.068	6	2	1	33
PL.64291	PL.64292	A	#4 ACSR	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	7.693	0.064	0	0	0	0
PL.64293	PL.64292	A	#4 ACSR	7.45Y	124.1	0.16	0.89	19.30	15	140	34	97	0.17	0.1	7.817	0.188	0	0	0	32
PL.38410	PL.64293	A	6 A (CWC)	7.44Y	124.0	0.08	0.97	19.30	14	140	34	97	0.08	0.1	7.903	0.086	0	0	0	32
PL.56421	PL.38410	A	6 A (CWC)	7.43Y	123.9	0.15	1.12	19.30	14	140	34	97	0.16	0.1	8.077	0.174	0	0	0	32
PL.56424	PL.56421	A	#4 ACSR	7.43Y	123.9	0.01	1.13	4.05	3	29	7	97	0.00	0.0	8.125	0.048	7	2	1	5
PL.56426	PL.56424	A	#4 ACSR	7.43Y	123.9	0.00	1.13	3.05	2	22	5	98	0.00	0.0	8.143	0.018	10	2	2	4
PL.56425	PL.56426	A	#4 ACSR	7.43Y	123.9	0.00	1.13	1.71	1	12	3	97	0.00	0.0	8.205	0.062	12	3	2	2
PL.56422	PL.56421	A	6 A (CWC)	7.43Y	123.9	0.00	1.12	1.27	1	9	2	98	0.00	0.0	8.115	0.038	9	2	2	2
PL.56423	PL.56421	A	6 A (CWC)	7.43Y	123.8	0.06	1.18	13.98	10	101	25	97	0.05	0.0	8.174	0.097	1	0	1	25
PL.38169	PL.56423	A	6 A (CWC)	7.42Y	123.7	0.09	1.27	13.86	10	100	24	97	0.07	0.1	8.322	0.147	4	1	4	24
PL.38170	PL.38169	A	6 A (CWC)	7.42Y	123.7	0.02	1.29	13.35	10	96	23	97	0.01	0.0	8.351	0.029	7	2	2	20
PL.38171	PL.38170	A	6 A (CWC)	7.42Y	123.7	0.05	1.33	12.37	9	89	22	97	0.03	0.0	8.437	0.086	9	2	2	18

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.38172	PL.38171	A	6 A (CWC)	7.42Y	123.6	0.06	1.39	11.13	8	80	20	97	0.03	0.0	8.579	0.142	35	8	4	16
PL.38173	PL.38172	A	6 A (CWC)	7.42Y	123.6	0.01	1.40	6.33	5	46	11	97	0.00	0.0	8.614	0.035	11	3	3	12
PL.38174	PL.38173	A	6 A (CWC)	7.42Y	123.6	0.01	1.41	4.78	3	34	8	97	0.00	0.0	8.673	0.059	4	1	2	9
PL.38175	PL.38174	A	6 A (CWC)	7.42Y	123.6	0.00	1.41	4.17	3	30	7	97	0.00	0.0	8.693	0.019	6	1	1	6
PL.57913	PL.38175	A	6 A (CWC)	7.41Y	123.6	0.00	1.42	0.71	1	5	1	98	0.00	0.0	8.938	0.245	5	1	2	2
PL.38176	PL.38175	A	6 A (CWC)	7.42Y	123.6	0.00	1.42	1.30	1	9	2	98	0.00	0.0	8.729	0.037	9	2	1	2
PL.37745	PL.38176	A	6 A (CWC)	7.42Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	8.784	0.054	0	0	1	1
PL.37221	PL.37745	A	6 A (CWC)	7.42Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	8.833	0.050	0	0	0	0
PL.36726	PL.38175	A	6 A (CWC)	7.42Y	123.6	0.00	1.42	1.38	1	10	2	98	0.00	0.0	8.733	0.040	10	2	1	1
PL.37411	PL.38174	A	6 A (CWC)	7.42Y	123.6	0.00	1.41	0.01	0	0	0	100	0.00	0.0	8.686	0.013	0	0	1	1
PL.38409	PL.64293	A	#4 ACSR	7.45Y	124.1	0.00	0.89	0.00	0	0	0	100	0.00	0.0	7.821	0.004	0	0	0	0
PL.64290	PL.64292	A	#4 ACSR	7.46Y	124.3	0.00	0.73	0.00	0	0	0	100	0.00	0.0	7.668	0.039	0	0	0	0
PL.36727	PL.51904	A	#4 ACSR	7.49Y	124.9	0.00	0.14	2.34	2	17	4	97	0.00	0.0	6.993	0.030	17	4	3	3
PL.37255	PL.51904	A	#4 ACSR	7.49Y	124.9	0.00	0.14	1.44	1	10	3	96	0.00	0.0	7.011	0.049	10	3	2	2
PL.51905	PL.51899	C	#1/0 ACSR	7.49Y	124.9	0.00	0.11	19.53	8	142	35	97	0.00	0.0	6.913	0.001	0	0	0	25
PD.7950	PL.51905	C	25T	7.49Y	124.9	0.00	0.11	19.53	0	142	35	97	0.00	0.0	6.913	0.001	0	0	0	25
PL.51906	PD.7950	C	#1/0 ACSR	7.49Y	124.9	0.02	0.13	19.53	8	142	35	97	0.02	0.0	6.967	0.054	5	1	1	25
PL.37413	PL.51906	C	#4 ACSR	7.49Y	124.8	0.04	0.18	18.79	14	137	33	97	0.04	0.0	7.020	0.053	7	2	1	24
PL.57234	PL.37413	C	#2 ACSR	7.49Y	124.8	0.00	0.18	1.07	1	8	2	97	0.00	0.0	7.051	0.031	8	2	2	2
PL.37750	PL.37413	C	#2 ACSR	7.49Y	124.8	0.00	0.18	1.41	1	10	3	96	0.00	0.0	7.071	0.050	0	0	0	3
PL.55408	PL.37750	C	#2 ACSR	7.49Y	124.8	0.00	0.18	1.41	1	10	3	96	0.00	0.0	7.129	0.058	10	3	3	3
PL.55409	PL.55408	C	#2 ACSR	7.49Y	124.8	0.00	0.18	0.00	0	0	0	100	0.00	0.0	7.357	0.228	0	0	0	0
PL.55414	PL.37413	C	#4 ACSR	7.49Y	124.8	0.03	0.21	15.39	12	112	27	97	0.03	0.0	7.075	0.055	17	4	2	18
PL.55413	PL.55414	C	#4 ACSR	7.49Y	124.8	0.03	0.24	13.06	10	95	23	97	0.02	0.0	7.121	0.045	6	2	1	16
PL.55411	PL.55413	C	#4 ACSR	7.49Y	124.8	0.00	0.24	2.90	2	21	5	97	0.00	0.0	7.162	0.041	21	5	3	3
PL.55410	PL.55413	C	#4 ACSR	7.49Y	124.8	0.01	0.25	3.47	3	25	6	97	0.00	0.0	7.195	0.074	0	0	0	4
PL.55415	PL.55410	C	#4 ACSR	7.48Y	124.7	0.01	0.25	3.47	3	25	6	97	0.00	0.0	7.234	0.040	6	2	1	4
PL.55416	PL.55415	C	#4 ACSR	7.48Y	124.7	0.00	0.26	2.61	2	19	5	97	0.00	0.0	7.259	0.025	16	4	2	3
PL.55790	PL.55416	C	#4 ACSR	7.48Y	124.7	0.00	0.26	0.43	0	3	1	95	0.00	0.0	7.297	0.037	3	1	1	1
PL.55412	PL.55413	C	#4 ACSR	7.49Y	124.8	0.01	0.25	5.82	4	42	10	97	0.00	0.0	7.169	0.048	10	2	2	8
PL.55406	PL.55412	C	#4 ACSR	7.49Y	124.8	0.00	0.25	0.63	0	5	1	98	0.00	0.0	7.209	0.040	5	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.55407	PL.55412	C	#4 ACSR	7.48Y	124.7	0.01	0.26	3.83	3	28	7	97	0.00	0.0	7.232	0.064	17	4	2	4
PL.38553	PL.55407	C	#4 ACSR	7.48Y	124.7	0.00	0.26	1.53	1	11	3	96	0.00	0.0	7.267	0.035	0	0	0	2
PL.38554	PL.38553	C	#4 ACSR	7.48Y	124.7	0.00	0.26	1.29	1	9	2	98	0.00	0.0	7.269	0.002	0	0	0	1
PD.6007	PL.38554	C	40QA	7.48Y	124.7	0.00	0.26	1.29	3	9	2	98	0.00	0.0	7.269	0.002	0	0	0	1
PL.37209	PD.6007	C	#4 ACSR	7.48Y	124.7	0.00	0.26	1.29	1	9	2	98	0.00	0.0	7.352	0.083	0	0	0	1
PL.38132	PL.37209	C	#4 ACSR	7.48Y	124.7	0.00	0.26	0.00	0	0	0	100	0.00	0.0	7.406	0.055	0	0	0	0
PL.37210	PL.37209	C	#4 ACSR	7.48Y	124.7	0.00	0.26	1.29	1	9	2	98	0.00	0.0	7.387	0.036	9	2	1	1
PL.38555	PL.38553	C	6 A (CWC)	7.48Y	124.7	0.00	0.26	0.24	0	2	0	100	0.00	0.0	7.328	0.061	2	0	1	1
PL.38556	PL.38555	C	6 A (CWC)	7.48Y	124.7	0.00	0.26	0.00	0	0	0	100	0.00	0.0	7.459	0.131	0	0	0	0
PL.51896	PL.51895	A	#1/0 ACSR	7.50Y	124.9	0.00	0.05	0.00	0	0	0	100	0.00	0.0	6.787	0.001	0	0	0	0
PD.7947	PL.51896	A	10QA	7.50Y	124.9	0.00	0.05	0.00	0	0	0	100	0.00	0.0	6.787	0.001	0	0	0	0
PL.51897	PD.7947	A	#1/0 ACSR	7.50Y	124.9	0.00	0.05	0.00	0	0	0	100	0.00	0.0	6.807	0.021	0	0	0	0
PL.51887	PL.56975	C	#1/0 ACSR	7.50Y	125.0	0.00	0.01	3.83	2	28	7	97	0.00	0.0	6.692	0.001	0	0	0	8
PD.7945	PL.51887	C	10QA	7.50Y	125.0	0.00	0.01	3.83	0	28	7	97	0.00	0.0	6.692	0.001	0	0	0	8
PL.51888	PD.7945	C	#1/0 ACSR	7.50Y	125.0	0.00	0.01	3.83	2	28	7	97	0.00	0.0	6.725	0.033	28	7	8	8
PL.37427	PL.37428	A	6 A (CWC)	7.50Y	125.1	0.00	-0.07	0.00	0	0	0	100	0.00	0.0	6.561	0.002	0	0	0	0
PL.37429	PL.56893	A	#1/0 ACSR	7.51Y	125.1	0.00	-0.10	1.06	0	8	2	97	0.00	0.0	6.498	0.000	0	0	0	4
PD.6012	PL.37429	A	40QA	7.51Y	125.1	0.00	-0.10	1.06	3	8	2	97	0.00	0.0	6.498	0.000	0	0	0	4
PL.37793	PD.6012	A	#1/0 ACSR	7.51Y	125.1	0.00	-0.10	1.06	0	8	2	97	0.00	0.0	6.552	0.054	7	2	2	4
PL.37794	PL.37793	A	#1/0 ACSR	7.51Y	125.1	0.00	-0.10	0.10	0	1	0	100	0.00	0.0	6.596	0.045	1	0	2	2
PL.61052	PL.56894	B	#1/0 ACSR	7.51Y	125.1	0.00	-0.11	1.00	0	7	2	96	0.00	0.0	6.471	0.004	0	0	0	2
PD.9134	PL.61052	B	12T	7.51Y	125.1	0.00	-0.11	1.00	0	7	2	96	0.00	0.0	6.471	0.004	0	0	0	2
PL.61053	PD.9134	B	#1/0 ACSR	7.51Y	125.1	0.00	-0.11	1.00	0	7	2	96	0.00	0.0	6.484	0.013	7	2	1	2
PL.61385	PL.61053	B	#1/0 ACSR	7.51Y	125.1	0.00	-0.11	0.01	0	0	0	100	0.00	0.0	6.510	0.025	0	0	1	1
PL.37430	PL.37431	C	6 A (CWC)	7.51Y	125.1	0.00	-0.14	0.84	1	6	1	99	0.00	0.0	6.381	0.001	0	0	0	3
PD.6069	PL.37430	C	40QA	7.51Y	125.1	0.00	-0.14	0.84	2	6	1	99	0.00	0.0	6.381	0.001	0	0	0	3
PL.36750	PD.6069	C	6 A (CWC)	7.51Y	125.1	0.00	-0.14	0.84	1	6	1	99	0.00	0.0	6.478	0.097	6	1	3	3
PL.36751	PL.36750	C	6 A (CWC)	7.51Y	125.1	0.00	-0.14	0.00	0	0	0	100	0.00	0.0	6.530	0.052	0	0	0	0
PL.56287	PL.38013	A	6 A (CWC)	7.52Y	125.3	0.00	-0.27	1.46	1	11	3	96	0.00	0.0	6.086	0.000	0	0	0	3
PD.8228	PL.56287	A	40QA	7.52Y	125.3	0.00	-0.27	1.46	4	11	3	96	0.00	0.0	6.086	0.000	0	0	0	3
PL.56288	PD.8228	A	6 A (CWC)	7.52Y	125.3	0.00	-0.27	1.46	1	11	3	96	0.00	0.0	6.086	0.000	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.56289	PL.56288	A	6 A (CWC)	7.52Y	125.3	0.00	-0.27	1.46	1	11	3	96	0.00	0.0	6.102	0.015	11	3	3	3
PL.56290	PL.56288	A	#1/0 ACSR	7.52Y	125.3	0.00	-0.27	0.00	0	0	0	100	0.00	0.0	6.140	0.054	0	0	0	0
PL.38014	PL.37329	A	6 A (CWC)	7.52Y	125.3	0.00	-0.30	4.53	3	33	8	97	0.00	0.0	6.015	0.000	0	0	0	5
PD.5982	PL.38014	A	40QA	7.52Y	125.3	0.00	-0.30	4.53	11	33	8	97	0.00	0.0	6.015	0.000	0	0	0	5
PL.56419	PD.5982	A	6 A (CWC)	7.52Y	125.3	0.01	-0.29	4.53	3	33	8	97	0.00	0.0	6.089	0.074	21	5	2	5
PL.56420	PL.56419	A	6 A (CWC)	7.52Y	125.3	0.00	-0.29	1.62	1	12	3	97	0.00	0.0	6.112	0.023	12	3	3	3
PL.37330	PL.37328	A	#2 ACSR	7.52Y	125.3	0.00	-0.33	1.16	1	8	2	97	0.00	0.0	5.957	0.000	0	0	0	3
PD.5980	PL.37330	A	40QA	7.52Y	125.3	0.00	-0.33	1.16	3	8	2	97	0.00	0.0	5.957	0.000	0	0	0	3
PL.36734	PD.5980	A	#2 ACSR	7.52Y	125.3	0.00	-0.32	1.16	1	8	2	97	0.00	0.0	5.992	0.035	8	2	3	3
PL.51812	PL.38137	B	#1/0 ACSR	7.52Y	125.4	0.00	-0.37	34.50	15	252	63	97	0.01	0.0	5.856	0.005	0	0	0	52
PD.7934	PL.51812	B	70L	7.52Y	125.4	0.00	-0.37	34.50	49	252	63	97	0.00	0.0	5.856	0.005	0	0	0	52
PL.51813	PD.7934	B	#1/0 ACSR	7.52Y	125.3	0.12	-0.26	34.50	15	252	63	97	0.19	0.1	5.999	0.143	0	0	0	52
PL.51811	PL.51813	B	#1/0 ACSR	7.50Y	125.1	0.19	-0.07	33.91	15	247	61	97	0.30	0.1	6.238	0.239	8	2	1	51
PL.37707	PL.51811	B	6 A (CWC)	7.50Y	125.1	0.00	-0.06	0.90	1	7	2	96	0.00	0.0	6.332	0.094	7	2	2	2
PL.37891	PL.51811	B	#1/0 ACSR	7.50Y	125.0	0.06	-0.01	31.95	14	233	57	97	0.09	0.0	6.320	0.082	0	0	0	48
PL.37892	PL.37891	B	#1/0 ACSR	7.50Y	124.9	0.07	0.06	31.95	14	233	57	97	0.10	0.0	6.407	0.088	4	1	1	48
PL.62463	PL.37892	B	#1/0 ACSR	7.50Y	124.9	0.00	0.06	28.23	12	205	51	97	0.00	0.0	6.411	0.003	0	0	0	42
PD.9344	PL.62463	B	25T	7.50Y	124.9	0.00	0.06	28.23	0	205	51	97	0.00	0.0	6.411	0.003	0	0	0	42
PL.62464	PD.9344	B	#1/0 ACSR	7.49Y	124.9	0.02	0.08	28.23	12	205	51	97	0.03	0.0	6.445	0.034	6	2	1	42
PL.57280	PL.62464	B	#1/0 ACSR	7.49Y	124.8	0.11	0.20	27.37	12	199	49	97	0.15	0.1	6.623	0.178	0	0	0	41
PL.57315	PL.57280	B	6 A (CWC)	7.49Y	124.8	0.00	0.20	0.66	0	5	1	98	0.00	0.0	6.626	0.004	0	0	0	1
PD.8277	PL.57315	B	100CodeSMo	7.49Y	124.8	0.00	0.20	0.66	0	5	1	98	0.00	0.0	6.626	0.004	0	0	0	1
PL.57316	PD.8277	B	6 A (CWC)	7.49Y	124.8	0.00	0.20	0.66	0	5	1	98	0.00	0.0	6.690	0.064	5	1	1	1
PL.57283	PL.57316	B	6 A (CWC)	7.49Y	124.8	0.00	0.20	0.00	0	0	0	100	0.00	0.0	6.757	0.066	0	0	0	0
PL.38544	PL.57280	B	#1/0 ACSR	7.48Y	124.7	0.06	0.26	26.71	12	194	48	97	0.07	0.0	6.719	0.096	9	2	2	40
PL.55792	PL.38544	B	#1/0 ACSR	7.48Y	124.7	0.07	0.33	25.41	11	185	45	97	0.09	0.0	6.842	0.123	0	0	0	38
PL.55793	PL.55792	B	#1/0 ACSR	7.48Y	124.6	0.05	0.38	17.97	8	131	32	97	0.04	0.0	6.948	0.106	0	0	0	26
PL.37640	PL.55793	B	6 A (CWC)	7.48Y	124.6	0.00	0.38	1.46	1	11	3	96	0.00	0.0	7.018	0.070	0	0	0	1
PL.63946	PL.37640	B	#1/0 ACSR	7.48Y	124.6	0.00	0.38	1.46	1	11	3	96	0.00	0.0	7.067	0.049	11	3	1	1
PL.37893	PL.55793	B	#1/0 ACSR	7.47Y	124.6	0.04	0.42	16.52	7	120	29	97	0.03	0.0	7.053	0.105	0	0	0	25
PL.37894	PL.37893	B	#1/0 ACSR	7.47Y	124.6	0.03	0.45	16.52	7	120	29	97	0.02	0.0	7.132	0.079	0	0	0	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																	KW	KVAR	Cons On	Cons Thru
PL.38545	PL.37894	B	#1/0 ACSR	7.47Y	124.5	0.03	0.47	15.31	7	111	27	97	0.02	0.0	7.205	0.072	6	1	2	24
PL.38229	PL.38545	B	6 A (CWC)	7.47Y	124.5	0.00	0.48	1.16	1	8	2	97	0.00	0.0	7.237	0.032	8	2	1	1
PL.38233	PL.38545	B	#1/0 ACSR	7.47Y	124.5	0.03	0.51	13.35	6	97	24	97	0.02	0.0	7.310	0.106	9	2	1	21
PL.38546	PL.38233	B	#1/0 ACSR	7.47Y	124.5	0.04	0.55	12.10	5	88	21	97	0.02	0.0	7.454	0.144	0	0	0	20
PL.38547	PL.38546	B	#1/0 ACSR	7.47Y	124.4	0.03	0.58	10.84	5	79	19	97	0.02	0.0	7.585	0.131	0	0	0	18
PL.37065	PL.38547	B	6 A (CWC)	7.46Y	124.4	0.05	0.63	6.89	5	50	12	97	0.02	0.0	7.743	0.157	0	0	0	9
PL.55610	PL.37065	B	6 A (CWC)	7.46Y	124.4	0.00	0.63	0.19	0	1	0	100	0.00	0.0	7.804	0.061	1	0	1	1
PL.55826	PL.37065	B	6 A (CWC)	7.46Y	124.4	0.02	0.65	6.70	5	49	12	97	0.01	0.0	7.815	0.072	18	4	3	8
PL.55827	PL.55826	B	#1/0 ACSR	7.46Y	124.4	0.00	0.65	1.47	1	11	3	96	0.00	0.0	7.870	0.055	11	3	1	1
PL.64304	PL.55826	B	6 A (CWC)	7.46Y	124.3	0.01	0.65	2.82	2	20	5	97	0.00	0.0	7.873	0.058	7	2	1	4
PL.64305	PL.64304	B	6 A (CWC)	7.46Y	124.3	0.00	0.66	1.82	1	13	3	97	0.00	0.0	7.897	0.024	0	0	0	3
PL.64298	PL.64305	B	6 A (CWC)	7.46Y	124.3	0.00	0.66	1.82	1	13	3	97	0.00	0.0	7.934	0.038	0	0	0	3
PL.64299	PL.64298	B	6 A (CWC)	7.46Y	124.3	0.00	0.66	1.82	1	13	3	97	0.00	0.0	7.987	0.053	8	2	1	3
PL.63069	PL.64299	B	#1/0 ACSR	7.46Y	124.3	0.00	0.66	0.73	0	5	1	98	0.00	0.0	8.014	0.027	5	1	2	2
PL.64300	PL.64298	B	#4 ACSR	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	8.066	0.132	0	0	0	0
PL.55614	PL.64305	B	#4 ACSR	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	7.998	0.101	0	0	0	0
PL.55615	PL.55614	B	#4 ACSR	7.46Y	124.3	0.00	0.66	0.00	0	0	0	100	0.00	0.0	8.050	0.052	0	0	0	0
PL.38549	PL.38547	B	#1/0 ACSR	7.46Y	124.4	0.01	0.59	3.95	2	29	7	97	0.00	0.0	7.667	0.082	0	0	0	9
PL.55607	PL.38549	B	#1/0 ACSR	7.46Y	124.4	0.00	0.60	2.59	1	19	5	97	0.00	0.0	7.777	0.110	7	2	2	6
PL.55608	PL.55607	B	#1/0 ACSR	7.46Y	124.4	0.00	0.60	1.68	1	12	3	97	0.00	0.0	7.897	0.120	0	0	0	4
PL.37066	PL.55608	B	#1/0 ACSR	7.46Y	124.4	0.00	0.60	1.45	1	10	3	96	0.00	0.0	8.021	0.123	0	0	0	1
PL.52647	PL.37066	B	#1/0 ACSR	7.46Y	124.4	0.01	0.61	1.45	1	10	3	96	0.00	0.0	8.211	0.191	0	0	0	1
PL.52648	PL.52647	B	#1/0 ACSR	7.46Y	124.4	0.00	0.61	0.00	0	0	0	100	0.00	0.0	8.296	0.084	0	0	0	0
PL.52649	PL.52647	B	6 A (CWC)	7.46Y	124.4	0.00	0.61	1.45	1	10	3	96	0.00	0.0	8.267	0.055	10	3	1	1
PL.37119	PL.55608	B	#2 ACSR	7.46Y	124.4	0.00	0.60	0.24	0	2	0	100	0.00	0.0	8.012	0.114	2	0	2	3
PL.37120	PL.37119	B	#2 ACSR	7.46Y	124.4	0.00	0.60	0.00	0	0	0	100	0.00	0.0	8.065	0.053	0	0	1	1
PL.55606	PL.38549	B	6 A (CWC)	7.46Y	124.4	0.00	0.59	0.69	0	5	1	98	0.00	0.0	7.708	0.040	5	1	1	1
PL.55913	PL.38549	B	#4 ACSR	7.46Y	124.4	0.00	0.59	0.67	1	5	1	98	0.00	0.0	7.839	0.172	5	1	2	2
PL.55914	PL.55913	B	#4 ACSR	7.46Y	124.4	0.00	0.59	0.00	0	0	0	100	0.00	0.0	7.970	0.131	0	0	0	0
PL.38548	PL.38546	B	#4 ACSR	7.47Y	124.4	0.00	0.55	1.25	1	9	2	98	0.00	0.0	7.551	0.097	9	2	1	2
PL.55609	PL.38548	B	#4 ACSR	7.47Y	124.4	0.00	0.55	0.04	0	0	0	100	0.00	0.0	7.595	0.045	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37404	PL.37894	B	6 A (CWC)	7.47Y	124.5	0.00	0.45	1.20	1	9	2	98	0.00	0.0	7.230	0.097	9	2	1	1
PL.55791	PL.55792	B	#4 ACSR	7.47Y	124.6	0.09	0.42	7.44	6	54	13	97	0.03	0.1	7.141	0.299	12	3	1	12
PL.37121	PL.55791	B	#4 ACSR	7.47Y	124.6	0.03	0.45	5.76	4	42	10	97	0.01	0.0	7.251	0.110	8	2	2	11
PL.37122	PL.37121	B	#4 ACSR	7.47Y	124.5	0.01	0.46	4.69	4	34	8	97	0.00	0.0	7.327	0.077	4	1	1	9
PL.37067	PL.37122	B	#4 ACSR	7.47Y	124.5	0.01	0.47	4.15	3	30	7	97	0.00	0.0	7.392	0.065	3	1	1	8
PL.55611	PL.37067	B	#4 ACSR	7.47Y	124.5	0.02	0.49	3.73	3	27	7	97	0.00	0.0	7.541	0.149	13	3	4	7
PL.55612	PL.55611	B	#4 ACSR	7.47Y	124.5	0.00	0.49	1.96	2	14	3	98	0.00	0.0	7.586	0.046	0	0	0	3
PL.55613	PL.55612	B	#4 ACSR	7.47Y	124.5	0.00	0.49	0.44	0	3	1	95	0.00	0.0	7.684	0.098	3	1	1	1
PL.38550	PL.55612	B	#4 ACSR	7.47Y	124.5	0.00	0.50	1.52	1	11	3	96	0.00	0.0	7.662	0.076	5	1	1	2
PL.52646	PL.38550	B	#1/0 ACSR	7.47Y	124.5	0.00	0.50	0.80	0	6	1	99	0.00	0.0	7.835	0.172	6	1	1	1
PL.38542	PL.37892	B	6 A (CWC)	7.50Y	124.9	0.01	0.07	3.17	2	23	6	97	0.00	0.0	6.487	0.080	0	0	1	5
PL.38543	PL.38542	B	6 A (CWC)	7.49Y	124.9	0.02	0.09	3.15	2	23	6	97	0.00	0.0	6.595	0.108	0	0	0	4
PL.57281	PL.38543	B	6 A (CWC)	7.49Y	124.9	0.01	0.09	2.05	1	15	4	97	0.00	0.0	6.740	0.144	15	4	3	3
PL.37709	PL.38543	B	6 A (CWC)	7.49Y	124.9	0.00	0.09	1.10	1	8	2	97	0.00	0.0	6.717	0.122	8	2	1	1
PL.51810	PL.51813	B	6 A (CWC)	7.52Y	125.3	0.00	-0.26	0.59	0	4	1	97	0.00	0.0	6.000	0.001	0	0	0	1
PL.51717	PL.51810	B	6 A (CWC)	7.52Y	125.3	0.00	-0.25	0.59	0	4	1	97	0.00	0.0	6.077	0.077	4	1	1	1
PL.38018	PL.38500	C	#4 ACSR	7.53Y	125.5	0.00	-0.51	31.04	24	227	55	97	0.00	0.0	5.661	0.000	0	0	0	41
PD.5981	PL.38018	C	25T	7.53Y	125.5	0.00	-0.51	31.04	0	227	55	97	0.00	0.0	5.661	0.000	0	0	0	41
PL.37436	PD.5981	C	#4 ACSR	7.52Y	125.4	0.10	-0.41	31.04	24	227	55	97	0.17	0.1	5.734	0.073	0	0	0	41
PL.37785	PL.37436	C	#4 ACSR	7.52Y	125.3	0.12	-0.29	31.04	24	227	55	97	0.20	0.1	5.822	0.088	9	2	1	41
PL.37786	PL.37785	C	#4 ACSR	7.51Y	125.2	0.08	-0.21	29.87	23	218	53	97	0.12	0.1	5.884	0.062	36	9	7	40
PL.38499	PL.37786	C	#4 ACSR	7.51Y	125.2	0.00	-0.21	1.45	1	11	3	96	0.00	0.0	5.967	0.083	3	1	1	3
PL.38126	PL.38499	C	#4 ACSR	7.51Y	125.2	0.00	-0.21	1.01	1	7	2	96	0.00	0.0	5.993	0.026	3	1	1	2
PL.38127	PL.38126	C	#4 ACSR	7.51Y	125.2	0.00	-0.21	0.60	0	4	1	97	0.00	0.0	6.037	0.044	4	1	1	1
PL.38498	PL.37786	C	#4 ACSR	7.51Y	125.2	0.03	-0.19	6.50	5	47	12	97	0.01	0.0	5.989	0.105	8	2	1	11
PL.51985	PL.38498	C	#4 ACSR	7.51Y	125.2	0.01	-0.18	5.42	4	40	10	97	0.00	0.0	6.028	0.039	2	0	2	10
PL.51986	PL.51985	C	#4 ACSR	7.51Y	125.2	0.01	-0.17	5.16	4	38	9	97	0.00	0.0	6.067	0.039	14	3	1	8
PL.39108	PL.51986	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	2.39	2	17	4	97	0.00	0.0	6.105	0.038	0	0	0	5
PL.39109	PL.39108	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	0.00	0	0	0	100	0.00	0.0	6.127	0.022	0	0	0	0
PL.39110	PL.39109	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	0.00	0	0	0	100	0.00	0.0	6.196	0.068	0	0	0	0
PL.39112	PL.39108	C	#4 ACSR	7.51Y	125.2	0.01	-0.16	2.39	2	17	4	97	0.00	0.0	6.169	0.064	8	2	2	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.39113	PL.39112	C	#4 ACSR	7.51Y	125.2	0.00	-0.16	1.33	1	10	2	98	0.00	0.0	6.250	0.081	0	0	0	3
PL.61036	PL.39113	C	#4 ACSR	7.51Y	125.2	0.00	-0.15	1.33	1	10	2	98	0.00	0.0	6.277	0.027	2	0	1	3
PL.61037	PL.61036	C	#4 ACSR	7.51Y	125.2	0.00	-0.15	1.12	1	8	2	97	0.00	0.0	6.303	0.026	8	2	2	2
PL.39111	PL.51986	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	0.88	1	6	2	95	0.00	0.0	6.116	0.049	0	0	0	2
PL.39114	PL.39111	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	0.88	1	6	2	95	0.00	0.0	6.241	0.125	6	2	2	2
PL.39115	PL.39114	C	#4 ACSR	7.51Y	125.2	0.00	-0.17	0.00	0	0	0	100	0.00	0.0	6.338	0.097	0	0	0	0
PL.38019	PL.37786	C	#2 ACSR	7.51Y	125.2	0.02	-0.19	17.03	10	124	30	97	0.02	0.0	5.927	0.044	9	2	1	19
PL.52640	PL.38019	C	#2 ACSR	7.51Y	125.2	0.04	-0.15	15.87	9	116	28	97	0.03	0.0	6.003	0.075	0	0	0	18
PL.52641	PL.52640	C	#2 ACSR	7.51Y	125.1	0.02	-0.13	7.87	4	57	14	97	0.01	0.0	6.097	0.095	10	2	1	8
PL.52642	PL.52641	C	#2 ACSR	7.51Y	125.1	0.02	-0.11	6.56	4	48	12	97	0.01	0.0	6.223	0.126	5	1	1	7
PL.52643	PL.52642	C	#2 ACSR	7.51Y	125.1	0.01	-0.10	5.91	3	43	10	97	0.00	0.0	6.276	0.053	24	6	3	6
PL.37332	PL.52643	C	#2 ACSR	7.51Y	125.1	0.00	-0.10	0.78	0	6	1	99	0.00	0.0	6.331	0.055	6	1	1	1
PL.37719	PL.52643	C	#2 ACSR	7.51Y	125.1	0.00	-0.10	1.79	1	13	3	97	0.00	0.0	6.311	0.035	13	3	2	2
PL.52639	PL.52640	C	#2 ACSR	7.51Y	125.1	0.01	-0.14	8.00	5	58	14	97	0.01	0.0	6.059	0.056	0	0	0	10
PL.38380	PL.52639	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.46	1	18	4	98	0.00	0.0	6.078	0.020	2	1	1	4
PL.61393	PL.38380	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.16	1	16	4	97	0.00	0.0	6.101	0.022	0	0	0	3
PL.61395	PL.61393	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	2.16	1	16	4	97	0.00	0.0	6.126	0.025	7	2	2	3
PL.61396	PL.61395	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	1.24	1	9	2	98	0.00	0.0	6.150	0.025	9	2	1	1
PL.61394	PL.61396	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	0.00	0	0	0	100	0.00	0.0	6.207	0.057	0	0	0	0
PL.37796	PL.52639	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	4.55	3	33	8	97	0.00	0.0	6.097	0.038	11	3	2	5
PL.38381	PL.37796	C	#2 ACSR	7.51Y	125.1	0.00	-0.13	3.09	2	23	5	98	0.00	0.0	6.136	0.039	6	2	1	3
PL.39106	PL.38381	C	#2 ACSR	7.51Y	125.1	0.00	-0.13	2.23	1	16	4	97	0.00	0.0	6.186	0.050	10	3	1	2
PL.39107	PL.39106	C	#2 ACSR	7.51Y	125.1	0.00	-0.13	0.83	0	6	1	99	0.00	0.0	6.279	0.093	6	1	1	1
PL.37873	PL.52639	C	#2 ACSR	7.51Y	125.1	0.00	-0.14	0.99	1	7	2	96	0.00	0.0	6.122	0.063	7	2	1	1
PL.38016	PL.38500	A	#4 ACSR	7.53Y	125.5	0.00	-0.51	0.00	0	0	0	100	0.00	0.0	5.661	0.000	0	0	0	0
PD.6006	PL.38016	A	40QA	7.53Y	125.5	0.00	-0.51	0.00	0	0	0	100	0.00	0.0	5.661	0.000	0	0	0	0
PL.38017	PD.6006	A	#4 ACSR	7.53Y	125.5	0.00	-0.51	0.00	0	0	0	100	0.00	0.0	5.750	0.090	0	0	0	0
PL.38501	PL.38503	C	#4 ACSR	7.12Y	118.6	0.00	6.36	0.26	0	2	0	100	0.00	0.0	5.445	0.001	0	0	0	1
PD.6050	PL.38501	C	40QA	7.12Y	118.6	0.00	6.36	0.26	1	2	0	100	0.00	0.0	5.445	0.001	0	0	0	1
PL.38502	PD.6050	C	#4 ACSR	7.12Y	118.6	0.00	6.36	0.26	0	2	0	100	0.00	0.0	5.653	0.208	2	0	1	1
PL.38507	PL.36876	C	#4 ACSR	7.13Y	118.9	0.00	6.14	0.00	0	0	0	100	0.00	0.0	5.218	0.001	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5983	PL.38507	C	40QA	7.13Y	118.9	0.00	6.14	0.00	0	0	0	100	0.00	0.0	5.218	0.001	0	0	0	1
PL.38508	PD.5983	C	#4 ACSR	7.13Y	118.9	0.00	6.14	0.00	0	0	0	100	0.00	0.0	5.523	0.305	0	0	1	1
PL.37985	PL.37758	C	6 A (CWC)	7.16Y	119.3	0.00	5.71	4.17	3	29	7	97	0.00	0.0	4.786	0.001	0	0	0	2
PD.5978	PL.37985	C	40QA	7.16Y	119.3	0.00	5.71	4.17	10	29	7	97	0.00	0.0	4.786	0.001	0	0	0	2
PL.37986	PD.5978	C	6 A (CWC)	7.16Y	119.3	0.00	5.71	4.17	3	29	7	97	0.00	0.0	4.834	0.048	29	7	2	2
PL.37987	PL.37986	C	6 A (CWC)	7.16Y	119.3	0.00	5.71	0.00	0	0	0	100	0.00	0.0	4.869	0.036	0	0	0	0
PL.57227	PL.57225	C	#1/0 ACSR	7.18Y	119.6	0.00	5.36	1.08	0	8	2	97	0.00	0.0	4.480	0.003	0	0	0	1
PD.8272	PL.57227	C	40QA	7.18Y	119.6	0.00	5.36	1.08	3	8	2	97	0.00	0.0	4.480	0.003	0	0	0	1
PL.57228	PD.8272	C	#1/0 ACSR	7.18Y	119.6	0.00	5.36	1.08	0	8	2	97	0.00	0.0	4.584	0.104	8	2	1	1
PL.37993	PL.37996	A	6 A (CWC)	7.19Y	119.8	0.00	5.15	2.00	1	14	3	98	0.00	0.0	4.297	0.001	0	0	0	3
PD.6064	PL.37993	A	75QA	7.19Y	119.8	0.00	5.15	2.00	3	14	3	98	0.00	0.0	4.297	0.001	0	0	0	3
PL.56964	PD.6064	A	6 A (CWC)	7.19Y	119.8	0.01	5.16	2.00	1	14	3	98	0.00	0.0	4.364	0.067	4	1	2	3
PL.57055	PL.56964	A	6 A (CWC)	7.19Y	119.8	0.00	5.16	1.37	1	10	2	98	0.00	0.0	4.403	0.039	0	0	0	1
PL.37997	PL.57055	A	6 A (CWC)	7.19Y	119.8	0.00	5.16	1.37	1	10	2	98	0.00	0.0	4.436	0.034	10	2	1	1
PL.37999	PL.38000	A	#4 ACSR	7.20Y	119.9	0.00	5.07	2.58	2	18	4	98	0.00	0.0	4.227	0.001	0	0	0	4
PD.6065	PL.37999	A	75QA	7.20Y	119.9	0.00	5.07	2.58	3	18	4	98	0.00	0.0	4.227	0.001	0	0	0	4
PL.57056	PD.6065	A	#4 ACSR	7.20Y	119.9	0.01	5.08	2.58	2	18	4	98	0.00	0.0	4.290	0.062	7	2	2	4
PL.57057	PL.57056	A	#4 ACSR	7.20Y	119.9	0.00	5.08	1.55	1	11	3	96	0.00	0.0	4.367	0.077	11	3	2	2
PL.38005	PL.38003	A	#4 ACSR	7.22Y	120.4	0.00	4.64	2.19	2	15	4	97	0.00	0.0	3.833	0.001	0	0	0	2
PD.5979	PL.38005	A	75QA	7.22Y	120.4	0.00	4.64	2.19	3	15	4	97	0.00	0.0	3.833	0.001	0	0	0	2
PL.38008	PD.5979	A	#4 ACSR	7.22Y	120.4	0.01	4.65	2.19	2	15	4	97	0.00	0.0	3.888	0.056	0	0	0	2
PL.61029	PL.38008	A	#4 ACSR	7.22Y	120.3	0.00	4.65	2.19	2	15	4	97	0.00	0.0	3.945	0.057	9	2	1	2
PL.61415	PL.61029	A	#1/0 ACSR	7.22Y	120.3	0.00	4.65	0.92	0	6	2	95	0.00	0.0	3.982	0.037	6	2	1	1
PL.37677	PL.63060	B	6 A (CWC)	7.28Y	121.3	0.00	3.71	6.15	4	43	11	97	0.00	0.0	3.007	0.003	0	0	0	9
PD.6013	PL.37677	B	75QA	7.28Y	121.3	0.00	3.71	6.15	8	43	11	97	0.00	0.0	3.007	0.003	0	0	0	9
PL.37678	PD.6013	B	6 A (CWC)	7.28Y	121.3	0.04	3.75	6.15	4	43	11	97	0.01	0.0	3.143	0.137	0	0	0	9
PL.37729	PL.37678	B	6 A (CWC)	7.28Y	121.3	0.00	3.75	0.38	0	3	1	95	0.00	0.0	3.198	0.054	3	1	2	2
PL.38512	PL.37678	B	6 A (CWC)	7.27Y	121.2	0.01	3.76	5.77	4	41	10	97	0.00	0.0	3.179	0.036	7	2	2	7
PL.38513	PL.38512	B	6 A (CWC)	7.27Y	121.2	0.03	3.79	4.80	3	34	8	97	0.01	0.0	3.334	0.155	0	0	0	5
PL.38133	PL.38513	B	6 A (CWC)	7.27Y	121.2	0.00	3.80	1.80	1	13	3	97	0.00	0.0	3.430	0.096	13	3	2	2
PL.38514	PL.38513	B	6 A (CWC)	7.27Y	121.2	0.01	3.80	3.00	2	21	5	97	0.00	0.0	3.393	0.060	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38515	PL.38514	B	6 A (CWC)	7.27Y	121.2	0.02	3.82	2.13	2	15	4	97	0.00	0.0	3.571	0.178	0	0	0	2
PL.38516	PL.38515	B	6 A (CWC)	7.27Y	121.2	0.00	3.82	1.36	1	10	2	98	0.00	0.0	3.710	0.139	10	2	1	1
PL.37878	PL.38515	B	6 A (CWC)	7.27Y	121.2	0.00	3.82	0.77	1	5	1	98	0.00	0.0	3.618	0.048	5	1	1	1
PL.37416	PL.38514	B	6 A (CWC)	7.27Y	121.2	0.00	3.80	0.87	1	6	2	95	0.00	0.0	3.471	0.078	6	2	1	1
PL.38010	PL.38406	A	#4 ACSR	7.31Y	121.9	0.00	3.15	1.68	1	12	3	97	0.00	0.0	2.520	0.003	0	0	0	2
PD.6051	PL.38010	A	75QA	7.31Y	121.9	0.00	3.15	1.68	2	12	3	97	0.00	0.0	2.520	0.003	0	0	0	2
PL.38011	PD.6051	A	#4 ACSR	7.31Y	121.8	0.02	3.17	1.68	1	12	3	97	0.00	0.0	2.822	0.302	2	0	1	2
PL.61391	PL.38011	A	#1/0 ACSR	7.31Y	121.8	0.00	3.17	1.46	1	10	3	96	0.00	0.0	2.877	0.055	10	3	1	1
PL.37929	PL.37928	C	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.62	0	4	1	97	0.00	0.0	1.713	0.000	0	0	0	1
PD.6014	PL.37929	C	75QA	7.37Y	122.8	0.00	2.18	0.62	1	4	1	97	0.00	0.0	1.713	0.000	0	0	0	1
PL.37930	PD.6014	C	6 A (CWC)	7.37Y	122.8	0.00	2.18	0.62	0	4	1	97	0.00	0.0	1.779	0.066	4	1	1	1
PL.37401	PL.38488	A	6 A (CWC)	7.38Y	123.0	0.00	1.96	8.30	6	60	15	97	0.00	0.0	1.533	0.004	0	0	0	16
PD.5909	PL.37401	A	50L	7.38Y	123.0	0.00	1.96	8.30	17	60	15	97	0.00	0.0	1.533	0.004	0	0	0	16
PL.37650	PD.5909	A	6 A (CWC)	7.38Y	123.0	0.07	2.02	8.30	6	60	15	97	0.03	0.1	1.715	0.182	0	0	0	16
PL.38425	PL.37650	A	6 A (CWC)	7.38Y	122.9	0.04	2.07	8.30	6	59	15	97	0.02	0.0	1.825	0.110	0	0	1	16
PL.38491	PL.38425	A	6 A (CWC)	7.37Y	122.9	0.04	2.10	8.30	6	59	14	97	0.02	0.0	1.926	0.101	0	0	0	15
PL.38492	PL.38491	A	6 A (CWC)	7.37Y	122.8	0.05	2.15	7.12	5	51	12	97	0.02	0.0	2.093	0.167	8	2	2	14
PL.38493	PL.38492	A	6 A (CWC)	7.37Y	122.8	0.01	2.17	6.00	4	43	10	97	0.00	0.0	2.142	0.049	0	0	1	12
PL.38494	PL.38493	A	6 A (CWC)	7.37Y	122.8	0.02	2.18	5.97	4	43	10	97	0.01	0.0	2.206	0.063	0	0	0	11
PL.37604	PL.38494	A	6 A (CWC)	7.37Y	122.8	0.01	2.19	1.38	1	10	2	98	0.00	0.0	2.396	0.190	10	2	1	1
PL.37605	PL.37604	A	#2 ACSR	7.37Y	122.8	0.00	2.19	0.00	0	0	0	100	0.00	0.0	2.510	0.114	0	0	0	0
PL.38495	PL.38494	A	6 A (CWC)	7.37Y	122.8	0.01	2.20	4.59	3	33	8	97	0.00	0.0	2.279	0.074	5	1	2	10
PL.38496	PL.38495	A	6 A (CWC)	7.37Y	122.8	0.01	2.21	2.19	2	16	4	97	0.00	0.0	2.397	0.118	6	2	2	7
PL.38497	PL.38496	A	6 A (CWC)	7.37Y	122.8	0.02	2.23	1.33	1	10	2	98	0.00	0.0	2.777	0.380	1	0	1	5
PL.38427	PL.38497	A	6 A (CWC)	7.37Y	122.8	0.01	2.24	1.21	1	9	2	98	0.00	0.0	2.979	0.202	0	0	1	4
PL.38426	PL.38427	A	#2 ACSR	7.37Y	122.8	0.00	2.24	0.63	0	5	1	98	0.00	0.0	3.024	0.045	5	1	1	1
PL.37925	PL.38427	A	6 A (CWC)	7.37Y	122.8	0.00	2.24	0.57	0	4	1	97	0.00	0.0	3.152	0.173	4	1	1	2
PL.37926	PL.37925	A	6 A (CWC)	7.37Y	122.8	0.00	2.24	0.00	0	0	0	100	0.00	0.0	3.192	0.040	0	0	0	1
PL.37927	PL.37926	A	6 A (CWC)	7.37Y	122.8	0.00	2.24	0.00	0	0	0	100	0.00	0.0	3.227	0.035	0	0	1	1
PL.37764	PL.38495	A	6 A (CWC)	7.37Y	122.8	0.00	2.20	1.70	1	12	3	97	0.00	0.0	2.381	0.102	12	3	1	1
PL.37088	PL.38491	A	#2 ACSR	7.37Y	122.9	0.00	2.11	1.18	1	8	2	97	0.00	0.0	2.035	0.109	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37752	PL.37650	A	#4 ACSR	7.38Y	123.0	0.00	2.02	0.00	0	0	0	100	0.00	0.0	1.849	0.133	0	0	0	0
PL.38489	PL.38487	C	#4 ACSR	7.40Y	123.3	0.00	1.73	1.62	1	12	3	97	0.00	0.0	1.353	0.001	0	0	0	1
PD.5902	PL.38489	C	75QA	7.40Y	123.3	0.00	1.73	1.62	2	12	3	97	0.00	0.0	1.353	0.001	0	0	0	1
PL.38490	PD.5902	C	#4 ACSR	7.40Y	123.3	0.00	1.73	1.62	1	12	3	97	0.00	0.0	1.386	0.032	12	3	1	1
PL.38334	PL.38333	B	#4 ACSR	7.44Y	123.9	0.00	1.05	0.95	1	7	2	96	0.00	0.0	0.816	0.001	0	0	0	1
PD.5903	PL.38334	B	75QA	7.44Y	123.9	0.00	1.05	0.95	1	7	2	96	0.00	0.0	0.816	0.001	0	0	0	1
PL.38335	PD.5903	B	#4 ACSR	7.44Y	123.9	0.00	1.05	0.95	1	7	2	96	0.00	0.0	0.883	0.067	7	2	1	1
PL.38329	PL.38247	C	6 A (CWC)	7.49Y	124.8	0.00	0.24	0.89	1	6	2	95	0.00	0.0	0.187	0.001	0	0	0	4
PD.5898	PL.38329	C	75QA	7.49Y	124.8	0.00	0.24	0.89	1	6	2	95	0.00	0.0	0.187	0.001	0	0	0	4
PL.38330	PD.5898	C	6 A (CWC)	7.49Y	124.8	0.00	0.24	0.89	1	6	2	95	0.00	0.0	0.247	0.061	6	2	4	4
PL.38240	PL.38239	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.00	0	0	0	100	0.00	0.0	0.109	0.006	0	0	0	0
PD.6055	PL.38240	A	75QA	7.49Y	124.9	0.00	0.13	0.00	0	0	0	100	0.00	0.0	0.109	0.006	0	0	0	0
PL.38245	PD.6055	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.00	0	0	0	100	0.00	0.0	0.169	0.060	0	0	0	0
PL.38246	PL.38245	A	#4 ACSR	7.49Y	124.9	0.00	0.13	0.00	0	0	0	100	0.00	0.0	0.277	0.108	0	0	0	0
PL.53024	Three Links	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	37.92	7	825	217	97	0.00	0.0	0.003	0.003	0	0	0	207
PL.53064	PL.53024	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	37.92	7	825	217	97	0.00	0.0	0.005	0.003	0	0	0	207

----- Feeder No. 2 (Red Hill F2) Beginning with Device PD.8074 -----

PD.8074	PL.53064	ABC	360VWE	7.50Y	125.0	0.00	0.00	37.92	0	825	217	97	0.00	0.0	0.005	0.003	0	0	0	207
PL.37267	PD.8074	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	37.92	7	825	217	97	0.01	0.0	0.017	0.012	0	0	0	207
PL.37580	PL.37267	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	0.00	0	0	0	100	0.00	0.0	0.018	0.000	0	0	0	0
PL.37268	PL.37267	ABC	336 MCM AC	7.50Y	125.0	0.02	0.02	37.92	7	825	217	97	0.08	0.0	0.081	0.064	0	0	0	207
PL.37980	PL.37268	ABC	336 MCM AC	7.50Y	125.0	0.00	0.02	0.00	0	0	0	100	0.00	0.0	0.198	0.117	0	0	0	0
PL.38421	PL.37268	ABC	336 MCM AC	7.50Y	125.0	0.01	0.04	37.92	7	825	217	97	0.06	0.0	0.131	0.050	5	1	2	207
PL.36770	PL.38421	ABC	336 MCM AC	7.50Y	124.9	0.04	0.07	37.67	7	819	216	97	0.16	0.0	0.268	0.137	7	2	1	205
PL.38236	PL.36770	C	6 A (CWC)	7.50Y	124.9	0.00	0.07	0.61	0	4	1	97	0.00	0.0	0.269	0.001	0	0	0	1
PD.5901	PL.38236	C	50QA	7.50Y	124.9	0.00	0.07	0.61	1	4	1	97	0.00	0.0	0.269	0.001	0	0	0	1
PL.38237	PD.5901	C	6 A (CWC)	7.50Y	124.9	0.00	0.07	0.61	0	4	1	97	0.00	0.0	0.298	0.028	0	0	0	1
PL.38238	PL.38237	C	6 A (CWC)	7.50Y	124.9	0.00	0.08	0.61	0	4	1	97	0.00	0.0	0.341	0.044	4	1	1	1
PL.37269	PL.38238	C	6 A (CWC)	7.50Y	124.9	0.00	0.08	0.00	0	0	0	100	0.00	0.0	0.433	0.091	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37270	PL.37269	C	6 A (CWC)	7.50Y	124.9	0.00	0.08	0.00	0	0	0	100	0.00	0.0	1.198	0.765	0	0	0	0
PL.37271	PL.36770	ABC	336 MCM AC	7.49Y	124.9	0.02	0.10	37.13	7	808	212	97	0.11	0.0	0.360	0.092	9	2	1	203
PL.37884	PL.37271	ABC	336 MCM AC	7.49Y	124.9	0.02	0.12	36.74	7	799	210	97	0.10	0.0	0.444	0.084	0	0	0	202
PL.37885	PL.37884	A	#4 ACSR	7.49Y	124.9	0.00	0.12	0.62	0	4	1	97	0.00	0.0	0.449	0.004	0	0	0	1
PD.5900	PL.37885	A	50QA	7.49Y	124.9	0.00	0.12	0.62	1	4	1	97	0.00	0.0	0.449	0.004	0	0	0	1
PL.37886	PD.5900	A	#4 ACSR	7.49Y	124.9	0.00	0.12	0.62	0	4	1	97	0.00	0.0	0.528	0.079	4	1	1	1
PL.39193	PL.37884	ABC	336 MCM AC	7.49Y	124.9	0.01	0.13	36.32	7	790	208	97	0.04	0.0	0.485	0.040	0	0	0	200
PL.39194	PL.39193	C	6 A (CWC)	7.49Y	124.9	0.00	0.13	0.92	1	7	2	96	0.00	0.0	0.488	0.003	0	0	0	1
PD.6032	PL.39194	C	40QA	7.49Y	124.9	0.00	0.13	0.92	2	7	2	96	0.00	0.0	0.488	0.003	0	0	0	1
PL.39195	PD.6032	C	6 A (CWC)	7.49Y	124.9	0.00	0.13	0.92	1	7	2	96	0.00	0.0	0.528	0.040	7	2	1	1
PL.37283	PL.39193	ABC	336 MCM AC	7.49Y	124.9	0.01	0.14	36.01	7	783	206	97	0.05	0.0	0.532	0.047	0	0	0	199
PL.38244	PL.37283	A	#2 ACSR	7.49Y	124.9	0.00	0.15	1.01	1	7	2	96	0.00	0.0	0.655	0.124	7	2	1	1
PL.39196	PL.38244	A	#2 ACSR	7.49Y	124.9	0.00	0.15	0.00	0	0	0	100	0.00	0.0	1.117	0.462	0	0	0	0
PL.39197	PL.37283	ABC	336 MCM AC	7.49Y	124.8	0.04	0.18	35.68	7	775	204	97	0.15	0.0	0.669	0.137	0	0	0	198
PL.39198	PL.39197	ABC	336 MCM AC	7.49Y	124.8	0.05	0.23	35.39	7	769	202	97	0.22	0.0	0.876	0.207	0	0	0	197
PL.38475	PL.39198	ABC	336 MCM AC	7.49Y	124.8	0.01	0.25	35.39	7	769	202	97	0.06	0.0	0.933	0.057	0	0	0	197
PL.37735	PL.38475	ABC	336 MCM AC	7.48Y	124.7	0.01	0.26	35.13	7	763	200	97	0.06	0.0	0.988	0.055	0	0	0	196
PL.37179	PL.37735	ABC	336 MCM AC	7.48Y	124.7	0.01	0.28	35.13	7	763	200	97	0.06	0.0	1.046	0.058	0	0	0	196
PL.38477	PL.37179	ABC	336 MCM AC	7.48Y	124.7	0.01	0.29	35.13	7	763	200	97	0.06	0.0	1.103	0.057	0	0	0	196
PL.38478	PL.38477	C	#2 ACSR	7.48Y	124.7	0.00	0.29	0.63	0	5	1	98	0.00	0.0	1.103	0.000	0	0	0	2
PD.5896	PL.38478	C	40QA	7.48Y	124.7	0.00	0.29	0.63	2	5	1	98	0.00	0.0	1.103	0.000	0	0	0	2
PL.38479	PD.5896	C	#2 ACSR	7.48Y	124.7	0.00	0.29	0.63	0	5	1	98	0.00	0.0	1.153	0.049	5	1	2	2
PL.37630	PL.38477	ABC	336 MCM AC	7.48Y	124.7	0.01	0.31	34.92	7	758	199	97	0.06	0.0	1.161	0.059	0	0	0	194
PL.37631	PL.37630	C	#2 ACSR	7.48Y	124.7	0.00	0.31	0.00	0	0	0	100	0.00	0.0	1.163	0.002	0	0	0	0
PD.5895	PL.37631	C	40QA	7.48Y	124.7	0.00	0.31	0.00	0	0	0	100	0.00	0.0	1.163	0.002	0	0	0	0
PL.37180	PD.5895	C	#2 ACSR	7.48Y	124.7	0.00	0.31	0.00	0	0	0	100	0.00	0.0	1.188	0.024	0	0	0	0
PL.37972	PL.37630	ABC	336 MCM AC	7.48Y	124.7	0.02	0.33	34.92	7	758	198	97	0.10	0.0	1.256	0.094	0	0	0	194
PL.38483	PL.37972	C	#2 ACSR	7.48Y	124.7	0.00	0.33	0.60	0	4	1	97	0.00	0.0	1.261	0.005	0	0	0	2
PD.6031	PL.38483	C	40QA	7.48Y	124.7	0.00	0.33	0.60	1	4	1	97	0.00	0.0	1.261	0.005	0	0	0	2
PL.37973	PD.6031	C	#2 ACSR	7.48Y	124.7	0.00	0.33	0.60	0	4	1	97	0.00	0.0	1.332	0.071	0	0	0	2
PL.63039	PL.37973	C	#2 ACSR	7.48Y	124.7	0.00	0.33	0.00	0	0	0	100	0.00	0.0	1.389	0.058	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.63040	PL.37973	C	#2 ACSR	7.48Y	124.7	0.00	0.33	0.60	0	4	1	97	0.00	0.0	1.437	0.105	0	0	0	2
PL.63041	PL.63040	C	#2 ACSR	7.48Y	124.7	0.00	0.33	0.00	0	0	0	100	0.00	0.0	1.498	0.061	0	0	1	1
PL.63042	PL.63040	C	1/0 AL URD	7.48Y	124.7	0.00	0.33	0.60	0	4	1	97	0.00	0.0	1.480	0.043	4	1	1	1
PL.37327	PL.37972	ABC	336 MCM AC	7.48Y	124.7	0.01	0.34	34.72	7	754	197	97	0.05	0.0	1.310	0.054	0	0	0	192
PL.37974	PL.37327	ABC	336 MCM AC	7.47Y	124.5	0.13	0.48	34.72	7	754	197	97	0.54	0.1	1.843	0.533	0	0	0	192
PL.37975	PL.37974	ABC	336 MCM AC	7.46Y	124.3	0.21	0.69	33.69	6	731	190	97	0.81	0.1	2.694	0.851	4	1	1	191
PL.37025	PL.37975	ABC	336 MCM AC	7.46Y	124.3	0.04	0.73	33.49	6	726	187	97	0.17	0.0	2.877	0.183	0	0	0	190
PL.39190	PL.37025	ABC	336 MCM AC	7.45Y	124.2	0.03	0.76	33.49	6	726	187	97	0.13	0.0	3.011	0.134	0	0	0	190
PL.37468	PL.39190	ABC	336 MCM AC	7.45Y	124.2	0.02	0.79	33.29	6	721	186	97	0.08	0.0	3.097	0.085	0	0	0	189
PL.37465	PL.37468	ABC	336 MCM AC	7.45Y	124.2	0.01	0.80	33.29	6	721	185	97	0.04	0.0	3.142	0.045	0	0	0	189
PL.37461	PL.37465	ABC	336 MCM AC	7.45Y	124.2	0.04	0.84	32.93	6	713	183	97	0.16	0.0	3.313	0.171	0	0	0	187
PL.37462	PL.37461	ABC	336 MCM AC	7.45Y	124.1	0.03	0.86	32.78	6	710	182	97	0.10	0.0	3.425	0.112	1	0	1	186
PL.39189	PL.37462	ABC	336 MCM AC	7.44Y	124.0	0.12	0.98	32.71	6	708	182	97	0.44	0.1	3.913	0.489	0	0	0	185
PL.38392	PL.39189	ABC	336 MCM AC	7.44Y	124.0	0.07	1.05	32.43	6	701	179	97	0.26	0.0	4.210	0.297	8	2	1	183
PL.38395	PL.38392	B	6 A (CWC)	7.44Y	124.0	0.00	1.05	0.88	1	6	2	95	0.00	0.0	4.211	0.001	0	0	0	1
PD.6040	PL.38395	B	40QA	7.44Y	124.0	0.00	1.05	0.88	2	6	2	95	0.00	0.0	4.211	0.001	0	0	0	1
PL.57665	PD.6040	B	6 A (CWC)	7.44Y	123.9	0.00	1.05	0.88	1	6	2	95	0.00	0.0	4.274	0.063	0	0	0	1
PL.57666	PL.57665	B	#1/0 ACSR	7.44Y	123.9	0.00	1.05	0.88	0	6	2	95	0.00	0.0	4.312	0.038	0	0	0	1
PL.57664	PL.57666	B	#1/0 ACSR	7.44Y	123.9	0.00	1.05	0.88	0	6	2	95	0.00	0.0	4.369	0.057	0	0	0	1
PL.57667	PL.57664	B	#1/0 ACSR	7.44Y	123.9	0.00	1.05	0.88	0	6	2	95	0.00	0.0	4.426	0.057	6	2	1	1
PL.39187	PL.38392	ABC	336 MCM AC	7.44Y	123.9	0.03	1.08	31.79	6	687	175	97	0.11	0.0	4.344	0.134	0	0	0	181
PL.39188	PL.39187	ABC	336 MCM AC	7.43Y	123.9	0.05	1.12	31.79	6	687	175	97	0.17	0.0	4.541	0.197	0	0	0	181
PL.37469	PL.39188	ABC	336 MCM AC	7.43Y	123.8	0.04	1.16	25.72	5	556	142	97	0.12	0.0	4.748	0.207	0	0	0	145
PL.37792	PL.37469	B	6 A (CWC)	7.43Y	123.8	0.00	1.16	0.00	0	0	0	100	0.00	0.0	4.844	0.096	0	0	0	0
PL.37470	PL.37469	ABC	336 MCM AC	7.43Y	123.8	0.02	1.18	25.72	5	555	142	97	0.06	0.0	4.849	0.101	0	0	0	145
PL.37024	PL.37470	B	6 A (CWC)	7.43Y	123.8	0.00	1.18	0.96	1	7	2	96	0.00	0.0	4.850	0.001	0	0	0	5
PD.6020	PL.37024	B	40QA	7.43Y	123.8	0.00	1.18	0.96	2	7	2	96	0.00	0.0	4.850	0.001	0	0	0	5
PL.39205	PD.6020	B	6 A (CWC)	7.43Y	123.8	0.01	1.19	0.96	1	7	2	96	0.00	0.0	4.999	0.149	0	0	0	5
PL.64515	PL.39205	B	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.02	0	0	0	100	0.00	0.0	5.053	0.053	0	0	1	2
PL.64516	PL.64515	B	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.00	0	0	0	100	0.00	0.0	5.053	0.000	0	0	1	1
PL.39206	PL.39205	B	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.94	1	7	2	96	0.00	0.0	5.109	0.110	3	1	1	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37393	PL.39206	B	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.56	0	4	1	97	0.00	0.0	5.203	0.094	0	0	0	2
PL.37394	PL.37393	B	6 A (CWC)	7.43Y	123.8	0.00	1.20	0.56	0	4	1	97	0.00	0.0	5.326	0.122	4	1	2	2
PL.39202	PL.37470	ABC	336 MCM AC	7.43Y	123.8	0.02	1.20	25.40	5	548	140	97	0.05	0.0	4.947	0.098	0	0	0	140
PL.37395	PL.39202	ABC	336 MCM AC	7.43Y	123.8	0.05	1.25	24.41	5	527	135	97	0.13	0.0	5.214	0.267	0	0	0	138
PL.39207	PL.37395	ABC	336 MCM AC	7.42Y	123.7	0.02	1.27	24.41	5	527	134	97	0.06	0.0	5.332	0.118	0	0	0	138
PL.39209	PL.39207	ABC	336 MCM AC	7.42Y	123.7	0.01	1.28	24.41	5	527	134	97	0.02	0.0	5.374	0.042	0	0	0	138
PL.39210	PL.39209	ABC	336 MCM AC	7.42Y	123.7	0.01	1.29	24.41	5	527	134	97	0.04	0.0	5.457	0.083	0	0	0	138
PL.61046	PL.39210	ABC	336 MCM AC	7.42Y	123.7	0.03	1.32	24.41	5	527	134	97	0.08	0.0	5.616	0.159	0	0	0	138
PL.61047	PL.61046	ABC	336 MCM AC	7.42Y	123.7	0.01	1.33	24.12	5	520	132	97	0.02	0.0	5.665	0.050	0	0	0	137
PL.39211	PL.61047	ABC	336 MCM AC	7.42Y	123.7	0.02	1.35	23.83	5	514	131	97	0.05	0.0	5.776	0.111	0	0	0	136
PL.39208	PL.39211	B	#4 ACSR	7.42Y	123.7	0.00	1.35	0.65	1	5	1	98	0.00	0.0	5.779	0.003	0	0	0	3
PD.6056	PL.39208	B	40QA	7.42Y	123.7	0.00	1.35	0.65	2	5	1	98	0.00	0.0	5.779	0.003	0	0	0	3
PL.39215	PD.6056	B	#4 ACSR	7.42Y	123.7	0.00	1.35	0.65	1	5	1	98	0.00	0.0	5.822	0.043	3	1	2	3
PL.39214	PL.39215	B	#4 ACSR	7.42Y	123.7	0.00	1.35	0.28	0	2	0	100	0.00	0.0	5.949	0.127	2	0	1	1
PL.39216	PL.39211	ABC	#1/0 ACSR	7.42Y	123.6	0.05	1.39	23.61	10	509	130	97	0.17	0.0	5.888	0.112	0	0	0	133
PL.38969	PL.39216	ABC	#1/0 ACSR	7.41Y	123.6	0.03	1.42	23.61	10	509	129	97	0.10	0.0	5.957	0.068	8	2	1	133
PL.38396	PL.38969	C	#2 ACSR	7.41Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	5.959	0.003	0	0	0	1
PD.5234	PL.38396	C	20QA	7.41Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	5.959	0.003	0	0	0	1
PL.38726	PD.5234	C	#2 ACSR	7.41Y	123.6	0.00	1.42	0.00	0	0	0	100	0.00	0.0	5.995	0.036	0	0	1	1
PL.37829	PL.38969	ABC	#1/0 ACSR	7.41Y	123.5	0.04	1.46	23.23	10	501	127	97	0.14	0.0	6.054	0.098	9	2	1	131
PL.38727	PL.37829	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.48	22.84	10	492	125	97	0.07	0.0	6.101	0.047	0	0	0	130
PL.38728	PL.38727	ABC	#1/0 ACSR	7.41Y	123.5	0.03	1.51	22.84	10	492	125	97	0.09	0.0	6.163	0.062	0	0	0	130
PL.37822	PL.38728	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.53	22.83	10	492	125	97	0.08	0.0	6.219	0.056	11	3	2	129
PL.38722	PL.37822	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.54	22.34	10	481	122	97	0.05	0.0	6.259	0.040	1	0	1	127
PL.38731	PL.38722	ABC	#1/0 ACSR	7.41Y	123.4	0.02	1.57	22.29	10	480	122	97	0.08	0.0	6.317	0.058	0	0	0	126
PL.38723	PL.38731	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.59	22.29	10	480	122	97	0.07	0.0	6.371	0.054	16	4	1	126
PL.38724	PL.38723	C	#2 ACSR	7.40Y	123.4	0.00	1.59	1.88	1	14	3	98	0.00	0.0	6.377	0.006	0	0	0	1
PD.6000	PL.38724	C	20QA	7.40Y	123.4	0.00	1.59	1.88	9	14	3	98	0.00	0.0	6.377	0.006	0	0	0	1
PL.38725	PD.6000	C	#2 ACSR	7.40Y	123.4	0.00	1.59	1.88	1	14	3	98	0.00	0.0	6.481	0.104	14	3	1	1
PL.38732	PL.38725	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.61	20.94	9	451	115	97	0.06	0.0	6.420	0.048	1	0	1	124
PL.38735	PL.38732	ABC	#1/0 ACSR	7.40Y	123.4	0.01	1.62	20.90	9	450	114	97	0.03	0.0	6.450	0.030	5	1	1	123

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.58760	PL.38735	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.66	20.69	9	445	113	97	0.14	0.0	6.569	0.119	0	0	0	122
PD.8746	PL.58760	ABC	70L	7.40Y	123.3	0.00	1.66	20.69	30	445	113	97	0.00	0.0	6.569	0.119	0	0	0	122
PL.58761	PD.8746	ABC	#1/0 ACSR	7.40Y	123.3	0.05	1.72	20.69	9	445	113	97	0.17	0.0	6.718	0.149	0	0	0	122
PL.38390	PL.58761	ABC	#1/0 ACSR	7.39Y	123.1	0.17	1.88	20.69	9	445	113	97	0.51	0.1	7.169	0.450	0	0	0	122
PL.37879	PL.38390	ABC	#1/0 ACSR	7.38Y	123.1	0.05	1.93	20.44	9	439	111	97	0.15	0.0	7.304	0.136	0	0	0	118
PL.39218	PL.37879	A	#1/0 ACSR	7.38Y	123.1	0.00	1.93	0.00	0	0	0	100	0.00	0.0	7.306	0.001	0	0	0	0
PD.5999	PL.39218	A	20T	7.38Y	123.1	0.00	1.93	0.00	0	0	0	100	0.00	0.0	7.306	0.001	0	0	0	0
PL.39219	PD.5999	A	#1/0 ACSR	7.38Y	123.1	0.00	1.93	0.00	0	0	0	100	0.00	0.0	7.331	0.025	0	0	0	0
PL.39220	PL.37879	ABC	#1/0 ACSR	7.38Y	123.0	0.04	1.97	19.59	9	421	107	97	0.11	0.0	7.413	0.109	0	0	0	112
PL.39221	PL.39220	ABC	#1/0 ACSR	7.38Y	123.0	0.01	1.98	19.59	9	421	107	97	0.04	0.0	7.452	0.039	0	0	0	112
PL.39222	PL.39221	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.01	19.59	9	421	106	97	0.08	0.0	7.531	0.079	0	0	0	112
PL.52795	PL.39222	ABC	#1/0 ACSR	7.37Y	122.9	0.12	2.13	19.59	9	421	106	97	0.35	0.1	7.874	0.343	0	0	0	112
PL.52796	PL.52795	A	#1/0 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.876	0.001	0	0	0	0
PD.5998	PL.52796	A	20QA	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.876	0.001	0	0	0	0
PL.39247	PD.5998	A	#1/0 ACSR	7.37Y	122.9	0.00	2.13	0.00	0	0	0	100	0.00	0.0	7.891	0.016	0	0	0	0
PL.52797	PL.52795	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.15	19.59	9	420	106	97	0.07	0.0	7.940	0.066	3	1	1	112
PL.39248	PL.52797	ABC	#1/0 ACSR	7.37Y	122.8	0.04	2.19	19.46	8	417	105	97	0.11	0.0	8.046	0.106	0	0	0	111
PL.39249	PL.39248	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.21	19.46	8	417	105	97	0.05	0.0	8.096	0.050	0	0	0	111
PL.39250	PL.39249	ABC	#1/0 ACSR	7.37Y	122.8	0.03	2.24	19.46	8	417	105	97	0.09	0.0	8.184	0.088	0	0	0	111
PL.39251	PL.39250	C	6 A (CWC)	7.37Y	122.8	0.00	2.24	2.56	2	18	4	98	0.00	0.0	8.190	0.005	0	0	0	5
PD.5956	PL.39251	C	40QA	7.37Y	122.8	0.00	2.24	2.56	6	18	4	98	0.00	0.0	8.190	0.005	0	0	0	5
PL.39257	PD.5956	C	6 A (CWC)	7.36Y	122.7	0.03	2.27	2.56	2	18	4	98	0.00	0.0	8.425	0.236	1	0	1	5
PL.39252	PL.39257	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	2.40	2	17	4	97	0.00	0.0	8.471	0.045	8	2	1	4
PL.39258	PL.39252	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	1.35	1	10	2	98	0.00	0.0	8.549	0.078	2	0	1	3
PL.39253	PL.39258	C	6 A (CWC)	7.36Y	122.7	0.00	2.28	1.09	1	8	2	97	0.00	0.0	8.652	0.103	8	2	2	2
PL.39254	PL.39253	C	6 A (CWC)	7.36Y	122.7	0.00	2.28	0.00	0	0	0	100	0.00	0.0	8.875	0.223	0	0	0	0
PL.37259	PL.39250	ABC	#1/0 ACSR	7.36Y	122.6	0.14	2.37	18.60	8	399	101	97	0.38	0.1	8.595	0.411	0	0	0	106
PL.37260	PL.37259	ABC	#1/0 ACSR	7.36Y	122.6	0.02	2.39	18.60	8	398	100	97	0.05	0.0	8.645	0.050	0	0	0	106
PL.37303	PL.37260	ABC	#1/0 ACSR	7.35Y	122.6	0.03	2.42	9.62	4	206	52	97	0.04	0.0	8.811	0.166	0	0	0	54
PL.39259	PL.37303	B	6 A (CWC)	7.35Y	122.5	0.06	2.48	28.86	21	206	52	97	0.10	0.0	8.859	0.048	0	0	0	54
PL.37720	PL.39259	B	6 A (CWC)	7.35Y	122.5	0.01	2.49	28.86	21	206	52	97	0.01	0.0	8.864	0.005	0	0	0	54

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.5910	PL.37720	B	50L	7.35Y	122.5	0.00	2.49	28.86	58	206	52	97	0.00	0.0	8.864	0.005	0	0	0	54
PL.37721	PD.5910	B	6 A (CWC)	7.35Y	122.4	0.09	2.58	28.86	21	206	52	97	0.14	0.1	8.933	0.069	0	0	0	54
PL.37722	PL.37721	B	6 A (CWC)	7.31Y	121.9	0.55	3.13	28.86	21	206	52	97	0.85	0.4	9.351	0.418	0	0	0	54
PL.39260	PL.37722	B	6 A (CWC)	7.31Y	121.8	0.11	3.24	28.36	20	201	50	97	0.17	0.1	9.437	0.086	0	0	0	53
PL.39261	PL.39260	B	6 A (CWC)	7.30Y	121.7	0.01	3.25	3.06	2	22	5	98	0.00	0.0	9.563	0.125	9	2	1	3
PL.37741	PL.39261	B	#2 ACSR	7.30Y	121.7	0.00	3.25	1.17	1	8	2	97	0.00	0.0	9.614	0.052	8	2	1	1
PL.39262	PL.39261	B	6 A (CWC)	7.30Y	121.7	0.00	3.25	0.58	0	4	1	97	0.00	0.0	9.649	0.087	4	1	1	1
PL.37407	PL.39260	B	6 A (CWC)	7.28Y	121.3	0.44	3.68	25.31	18	179	45	97	0.59	0.3	9.818	0.380	0	0	0	50
PL.37763	PL.37407	B	6 A (CWC)	7.26Y	120.9	0.38	4.06	24.04	17	170	42	97	0.49	0.3	10.167	0.350	0	0	0	46
PL.37714	PL.37763	B	#4 ACSR	7.26Y	120.9	0.00	4.06	1.10	1	8	2	97	0.00	0.0	10.218	0.051	8	2	1	1
PL.37403	PL.37763	B	6 A (CWC)	7.25Y	120.8	0.11	4.17	22.94	16	162	40	97	0.14	0.1	10.275	0.107	0	0	0	45
PL.37233	PL.37403	B	6 A (CWC)	7.24Y	120.7	0.16	4.33	22.94	16	161	40	97	0.20	0.1	10.428	0.154	0	0	0	45
PL.37207	PL.37233	B	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.27	0	2	0	100	0.00	0.0	10.452	0.024	2	0	1	1
PL.39270	PL.37233	B	6 A (CWC)	7.23Y	120.5	0.15	4.48	22.66	16	159	39	97	0.18	0.1	10.578	0.150	6	2	1	44
PL.37234	PL.39270	B	6 A (CWC)	7.22Y	120.3	0.19	4.67	21.76	16	153	38	97	0.22	0.1	10.773	0.195	0	0	0	43
PL.37864	PL.37234	B	#4 ACSR	7.22Y	120.3	0.00	4.67	0.39	0	3	1	95	0.00	0.0	10.837	0.064	3	1	1	1
PL.39271	PL.37234	B	6 A (CWC)	7.20Y	120.0	0.30	4.97	21.36	15	150	37	97	0.33	0.2	11.084	0.311	5	1	3	41
PL.39272	PL.39271	B	6 A (CWC)	7.20Y	120.0	0.07	5.04	20.59	15	144	35	97	0.08	0.1	11.164	0.080	5	1	1	38
PL.37627	PL.39272	B	6 A (CWC)	7.19Y	119.8	0.15	5.19	17.61	13	123	30	97	0.14	0.1	11.356	0.192	0	0	0	35
PL.37236	PL.37627	B	6 A (CWC)	7.19Y	119.8	0.00	5.20	1.46	1	10	2	98	0.00	0.0	11.384	0.028	0	0	0	4
PL.36756	PL.37236	B	#2 ACSR	7.19Y	119.8	0.00	5.20	0.00	0	0	0	100	0.00	0.0	11.435	0.051	0	0	0	0
PL.61041	PL.37236	B	6 A (CWC)	7.19Y	119.8	0.01	5.21	1.46	1	10	2	98	0.00	0.0	11.569	0.185	4	1	1	4
PL.61042	PL.61041	B	6 A (CWC)	7.19Y	119.8	0.00	5.21	0.93	1	7	2	96	0.00	0.0	11.658	0.089	7	2	3	3
PL.39275	PL.37627	B	6 A (CWC)	7.18Y	119.7	0.07	5.26	16.15	12	113	28	97	0.06	0.1	11.452	0.097	6	1	1	31
PL.37544	PL.39275	B	6 A (CWC)	7.18Y	119.7	0.08	5.34	15.29	11	107	26	97	0.07	0.1	11.574	0.122	7	2	3	30
PL.52002	PL.37544	B	6 A (CWC)	7.18Y	119.6	0.03	5.38	13.42	10	94	23	97	0.02	0.0	11.627	0.053	0	0	0	26
PL.52001	PL.52002	B	6 A (CWC)	7.18Y	119.6	0.00	5.38	0.90	1	6	2	95	0.00	0.0	11.721	0.094	6	2	1	1
PL.52005	PL.52002	B	6 A (CWC)	7.17Y	119.5	0.12	5.50	12.52	9	87	21	97	0.08	0.1	11.845	0.218	0	0	0	25
PL.52004	PL.52005	B	6 A (CWC)	7.17Y	119.5	0.03	5.53	12.36	9	86	21	97	0.02	0.0	11.897	0.052	0	0	0	24
PL.59166	PL.52004	B	6 A (CWC)	7.17Y	119.5	0.00	5.53	12.36	9	86	21	97	0.00	0.0	11.900	0.003	0	0	0	24
PD.8805	PL.59166	B	100CodeSMo	7.17Y	119.5	0.00	5.53	12.36	0	86	21	97	0.00	0.0	11.900	0.003	0	0	0	24

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.59167	PD.8805	B	6 A (CWC)	7.17Y	119.5	0.02	5.55	12.36	9	86	21	97	0.01	0.0	11.930	0.030	7	2	1	24
PL.37418	PL.59167	B	6 A (CWC)	7.16Y	119.4	0.05	5.60	10.14	7	71	17	97	0.03	0.0	12.040	0.110	0	0	0	19
PL.38202	PL.37418	B	6 A (CWC)	7.16Y	119.4	0.03	5.63	3.82	3	27	6	98	0.01	0.0	12.220	0.180	0	0	0	6
PL.39059	PL.38202	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	3.82	3	27	6	98	0.00	0.0	12.244	0.024	10	2	2	6
PL.39062	PL.39059	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.56	0	4	1	97	0.00	0.0	12.328	0.084	4	1	1	1
PL.37262	PL.39062	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	12.965	0.637	0	0	0	0
PL.39065	PL.37262	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	13.108	0.143	0	0	0	0
PL.37670	PL.39065	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	13.386	0.279	0	0	0	0
PL.37263	PL.39065	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	13.253	0.145	0	0	0	0
PL.37264	PL.37263	B	6 A (CWC)	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	13.699	0.446	0	0	0	0
PL.37676	PL.37262	B	#4 ACSR	7.16Y	119.4	0.00	5.63	0.00	0	0	0	100	0.00	0.0	13.007	0.042	0	0	0	0
PL.39063	PL.39059	B	6 A (CWC)	7.16Y	119.4	0.01	5.64	1.85	1	13	3	97	0.00	0.0	12.353	0.109	0	0	0	3
PL.39064	PL.39063	B	6 A (CWC)	7.16Y	119.4	0.00	5.64	1.71	1	12	3	97	0.00	0.0	12.438	0.086	12	3	2	2
PL.37715	PL.39063	B	6 A (CWC)	7.16Y	119.4	0.00	5.64	0.14	0	1	0	100	0.00	0.0	12.421	0.068	1	0	1	1
PL.37772	PL.37418	B	6 A (CWC)	7.16Y	119.4	0.00	5.60	6.32	5	44	11	97	0.00	0.0	12.041	0.001	0	0	0	13
PD.5889	PL.37772	B	20QA	7.16Y	119.4	0.00	5.60	6.32	32	44	11	97	0.00	0.0	12.041	0.001	0	0	0	13
PL.37773	PD.5889	B	6 A (CWC)	7.16Y	119.3	0.06	5.65	6.32	5	44	11	97	0.02	0.0	12.243	0.203	2	1	2	13
PL.37774	PL.37773	B	6 A (CWC)	7.16Y	119.3	0.04	5.69	5.98	4	42	10	97	0.01	0.0	12.373	0.129	0	0	0	11
PL.37321	PL.37774	B	#4 ACSR	7.16Y	119.3	0.00	5.69	1.15	1	8	2	97	0.00	0.0	12.421	0.048	8	2	1	1
PL.39049	PL.37774	B	6 A (CWC)	7.16Y	119.3	0.02	5.71	4.82	3	34	8	97	0.01	0.0	12.481	0.108	3	1	1	10
PL.39050	PL.39049	B	6 A (CWC)	7.16Y	119.3	0.01	5.72	4.43	3	31	8	97	0.00	0.0	12.542	0.061	0	0	1	9
PL.39051	PL.39050	B	6 A (CWC)	7.16Y	119.3	0.02	5.74	4.41	3	31	7	98	0.00	0.0	12.638	0.096	0	0	0	8
PL.39052	PL.39051	B	6 A (CWC)	7.15Y	119.2	0.01	5.76	3.31	2	23	6	97	0.00	0.0	12.716	0.079	0	0	0	7
PL.39053	PL.39052	B	6 A (CWC)	7.15Y	119.2	0.01	5.77	3.31	2	23	6	97	0.00	0.0	12.789	0.073	0	0	0	7
PL.36731	PL.39053	B	6 A (CWC)	7.15Y	119.2	0.00	5.77	0.45	0	3	1	95	0.00	0.0	12.835	0.046	3	1	2	2
PL.37185	PL.39053	B	6 A (CWC)	7.15Y	119.2	0.01	5.77	2.86	2	20	5	97	0.00	0.0	12.851	0.062	2	1	1	5
PL.37186	PL.37185	B	6 A (CWC)	7.15Y	119.2	0.01	5.78	2.52	2	18	4	98	0.00	0.0	12.937	0.085	0	0	0	4
PL.39054	PL.37186	B	#2 ACSR	7.15Y	119.2	0.00	5.79	0.90	1	6	2	95	0.00	0.0	13.185	0.248	6	2	1	1
PL.39055	PL.39054	B	#2 ACSR	7.15Y	119.2	0.00	5.79	0.00	0	0	0	100	0.00	0.0	13.218	0.033	0	0	0	0
PL.37187	PL.37186	B	6 A (CWC)	7.15Y	119.2	0.01	5.79	1.61	1	11	3	96	0.00	0.0	13.057	0.121	0	0	0	3
PL.39058	PL.37187	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	1.61	1	11	3	96	0.00	0.0	13.097	0.039	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.38201	PL.39058	B	6 A (CWC)	7.15Y	119.2	0.01	5.80	0.76	1	5	1	98	0.00	0.0	13.287	0.190	0	0	1	2
PL.39060	PL.38201	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.69	0	5	1	98	0.00	0.0	13.333	0.045	0	0	0	1
PL.39061	PL.39060	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.69	0	5	1	98	0.00	0.0	13.375	0.042	5	1	1	1
PL.39056	PL.39058	B	6 A (CWC)	7.15Y	119.2	0.01	5.80	0.86	1	6	1	99	0.00	0.0	13.238	0.141	0	0	0	1
PL.39057	PL.39056	B	6 A (CWC)	7.15Y	119.2	0.00	5.80	0.86	1	6	1	99	0.00	0.0	13.423	0.186	6	1	1	1
PL.37683	PL.39051	B	6 A (CWC)	7.16Y	119.3	0.00	5.75	1.11	1	8	2	97	0.00	0.0	12.727	0.089	8	2	1	1
PL.59619	PL.59167	B	6 A (CWC)	7.17Y	119.4	0.01	5.55	1.17	1	8	2	97	0.00	0.0	12.063	0.133	0	0	0	3
PL.59165	PL.59619	B	6 A (CWC)	7.17Y	119.4	0.02	5.57	1.17	1	8	2	97	0.00	0.0	12.356	0.293	0	0	0	3
PL.63047	PL.59165	B	6 A (CWC)	7.17Y	119.4	0.00	5.57	1.17	1	8	2	97	0.00	0.0	12.416	0.060	0	0	0	3
PL.63048	PL.63047	B	#1/0 ACSR	7.17Y	119.4	0.00	5.57	0.51	0	4	1	97	0.00	0.0	12.421	0.005	0	0	0	2
PD.9409	PL.63048	B	25T	7.17Y	119.4	0.00	5.57	0.51	0	4	1	97	0.00	0.0	12.421	0.005	0	0	0	2
PL.63049	PD.9409	B	#1/0 ACSR	7.17Y	119.4	0.00	5.57	0.51	0	4	1	97	0.00	0.0	12.462	0.041	0	0	0	2
PL.63050	PL.63049	B	#1/0 ACSR	7.17Y	119.4	0.00	5.57	0.51	0	4	1	97	0.00	0.0	12.519	0.058	0	0	0	2
PL.63051	PL.63050	B	#1/0 ACSR	7.17Y	119.4	0.00	5.57	0.51	0	4	1	97	0.00	0.0	12.560	0.041	4	1	2	2
PL.63046	PL.63047	B	6 A (CWC)	7.17Y	119.4	0.00	5.58	0.66	0	5	1	98	0.00	0.0	12.631	0.215	5	1	1	1
PL.59620	PL.59619	B	6 A (CWC)	7.17Y	119.4	0.00	5.55	0.00	0	0	0	100	0.00	0.0	12.116	0.054	0	0	0	0
PL.39014	PL.59620	B	6 A (CWC)	7.17Y	119.4	0.00	5.55	0.00	0	0	0	100	0.00	0.0	12.194	0.078	0	0	0	0
PL.37797	PL.59620	B	6 A (CWC)	7.17Y	119.4	0.00	5.55	0.00	0	0	0	100	0.00	0.0	12.197	0.081	0	0	0	0
PL.37727	PL.59167	B	6 A (CWC)	7.17Y	119.5	0.00	5.55	0.05	0	0	0	100	0.00	0.0	11.978	0.048	0	0	1	1
PL.52003	PL.52005	B	6 A (CWC)	7.17Y	119.5	0.00	5.50	0.16	0	1	0	100	0.00	0.0	11.892	0.047	1	0	1	1
PL.36724	PL.37544	B	6 A (CWC)	7.18Y	119.7	0.00	5.35	0.93	1	6	2	95	0.00	0.0	11.728	0.154	6	2	1	1
PL.37235	PL.39272	B	6 A (CWC)	7.20Y	120.0	0.01	5.05	2.22	2	15	4	97	0.00	0.0	11.227	0.063	0	0	0	2
PL.39273	PL.37235	B	6 A (CWC)	7.20Y	119.9	0.03	5.07	2.22	2	15	4	97	0.00	0.0	11.497	0.269	0	0	0	2
PL.39274	PL.39273	B	6 A (CWC)	7.20Y	119.9	0.00	5.07	0.00	0	0	0	100	0.00	0.0	11.571	0.075	0	0	0	0
PL.37718	PL.39273	B	#2 ACSR	7.20Y	119.9	0.00	5.07	0.09	0	1	0	100	0.00	0.0	11.529	0.033	1	0	1	1
PL.36723	PL.39273	B	#2 ACSR	7.20Y	119.9	0.00	5.08	2.12	1	15	4	97	0.00	0.0	11.598	0.101	15	4	1	1
PL.36733	PL.37234	B	#4 ACSR	7.22Y	120.3	0.00	4.67	0.00	0	0	0	100	0.00	0.0	10.872	0.099	0	0	1	1
PL.37316	PL.37407	B	6 A (CWC)	7.28Y	121.3	0.01	3.69	1.26	1	9	2	98	0.00	0.0	10.019	0.201	2	0	1	4
PL.39263	PL.37316	B	6 A (CWC)	7.28Y	121.3	0.00	3.69	0.98	1	7	2	96	0.00	0.0	10.095	0.076	0	0	0	3
PL.39266	PL.39263	B	#4 ACSR	7.28Y	121.3	0.00	3.69	0.33	0	2	1	89	0.00	0.0	10.152	0.057	0	0	0	2
PL.39267	PL.39266	B	#4 ACSR	7.28Y	121.3	0.00	3.69	0.31	0	2	1	89	0.00	0.0	10.194	0.041	2	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.39268	PL.39266	B	#4 ACSR	7.28Y	121.3	0.00	3.69	0.02	0	0	0	100	0.00	0.0	10.328	0.176	0	0	0	1
PL.39269	PL.39268	B	#4 ACSR	7.28Y	121.3	0.00	3.69	0.02	0	0	0	100	0.00	0.0	10.501	0.173	0	0	1	1
PL.39264	PL.39263	B	#4 ACSR	7.28Y	121.3	0.00	3.69	0.66	1	5	1	98	0.00	0.0	10.163	0.068	0	0	0	1
PL.39265	PL.39264	B	#4 ACSR	7.28Y	121.3	0.01	3.70	0.66	1	5	1	98	0.00	0.0	10.586	0.422	5	1	1	1
PL.36732	PL.37722	B	#2 ACSR	7.31Y	121.9	0.00	3.13	0.50	0	4	1	97	0.00	0.0	9.382	0.031	4	1	1	1
PL.39255	PL.37260	A	#1/0 ACSR	7.36Y	122.6	0.00	2.39	26.95	12	192	49	97	0.00	0.0	8.651	0.005	0	0	0	52
PD.5955	PL.39255	A	40QA	7.36Y	122.6	0.00	2.39	26.95	67	192	48	97	0.00	0.0	8.651	0.005	0	0	0	52
PL.39256	PD.5955	A	#1/0 ACSR	7.36Y	122.6	0.01	2.40	26.95	12	192	48	97	0.01	0.0	8.660	0.009	0	0	0	52
PL.37261	PL.39256	A	#1/0 ACSR	7.34Y	122.4	0.23	2.63	26.95	12	192	48	97	0.29	0.2	9.040	0.379	3	1	1	52
PL.37302	PL.37261	A	#2 ACSR	7.34Y	122.4	0.00	2.63	0.96	1	7	2	96	0.00	0.0	9.119	0.080	7	2	1	1
PL.57941	PL.37261	A	#1/0 ACSR	7.34Y	122.3	0.05	2.69	25.60	11	182	46	97	0.06	0.0	9.135	0.095	11	3	1	50
PL.57942	PL.57941	A	#1/0 ACSR	7.32Y	122.0	0.34	3.03	24.11	10	172	43	97	0.38	0.2	9.772	0.637	9	2	2	49
PL.37201	PL.57942	A	#1/0 ACSR	7.31Y	121.9	0.11	3.14	22.82	10	162	40	97	0.12	0.1	9.991	0.219	0	0	0	47
PL.37730	PL.37201	A	#4 ACSR	7.31Y	121.9	0.00	3.14	1.34	1	9	2	98	0.00	0.0	10.119	0.128	9	2	2	2
PL.39276	PL.37201	A	#1/0 ACSR	7.31Y	121.8	0.06	3.20	21.48	9	152	38	97	0.06	0.0	10.109	0.118	0	0	0	45
PL.37301	PL.39276	A	#4 ACSR	7.31Y	121.8	0.00	3.20	0.00	0	0	0	100	0.00	0.0	10.391	0.282	0	0	1	1
PL.39277	PL.39276	A	#1/0 ACSR	7.30Y	121.7	0.09	3.29	21.48	9	152	38	97	0.09	0.1	10.290	0.181	0	0	0	44
PL.52023	PL.39277	A	#1/0 ACSR	7.30Y	121.7	0.01	3.30	20.11	9	143	35	97	0.01	0.0	10.319	0.029	0	0	0	43
PL.51993	PL.52023	A	#1/0 ACSR	7.30Y	121.7	0.04	3.34	20.11	9	143	35	97	0.04	0.0	10.415	0.096	0	0	0	43
PL.51995	PL.51993	A	#1/0 ACSR	7.30Y	121.7	0.00	3.35	1.05	0	7	2	96	0.00	0.0	10.555	0.139	0	0	0	4
PL.51996	PL.51995	A	#1/0 ACSR	7.30Y	121.7	0.00	3.35	1.05	0	7	2	96	0.00	0.0	10.556	0.001	0	0	0	4
PD.8002	PL.51996	A	40QA	7.30Y	121.7	0.00	3.35	1.05	3	7	2	96	0.00	0.0	10.556	0.001	0	0	0	4
PL.51997	PD.8002	A	#1/0 ACSR	7.30Y	121.6	0.00	3.35	1.05	0	7	2	96	0.00	0.0	10.749	0.193	0	0	0	4
PL.51998	PL.51997	A	#1/0 ACSR	7.30Y	121.6	0.00	3.36	1.05	0	7	2	96	0.00	0.0	10.896	0.147	0	0	0	4
PL.51999	PL.51998	A	#1/0 ACSR	7.30Y	121.6	0.01	3.37	1.05	0	7	2	96	0.00	0.0	11.452	0.556	0	0	0	4
PL.52000	PL.51999	A	#1/0 ACSR	7.30Y	121.6	0.00	3.37	1.05	0	7	2	96	0.00	0.0	11.633	0.181	0	0	0	4
PL.52006	PL.52000	A	#1/0 ACSR	7.30Y	121.6	0.00	3.37	1.05	0	7	2	96	0.00	0.0	11.667	0.034	0	0	0	4
PL.37811	PL.52006	A	6 A (CWC)	7.30Y	121.6	0.01	3.38	1.05	1	7	2	96	0.00	0.0	11.840	0.173	2	0	1	4
PL.37810	PL.37811	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	0.82	1	6	1	99	0.00	0.0	12.009	0.169	6	1	2	3
PL.39046	PL.37810	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.143	0.134	0	0	0	1
PL.39045	PL.39046	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.369	0.226	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37476	PL.39045	A	6 A (CWC)	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.559	0.190	0	0	0	1
PL.39048	PL.37476	A	#4 ACSR	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.560	0.001	0	0	0	1
PD.6022	PL.39048	A	10QA	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.560	0.001	0	0	0	1
PL.64653	PD.6022	A	#4 ACSR	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.680	0.120	0	0	1	1
PL.64654	PL.64653	A	#4 ACSR	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.680	0.000	0	0	0	0
PL.39047	PL.64654	A	#4 ACSR	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	13.019	0.339	0	0	0	0
PL.37669	PL.64654	A	#4 ACSR	7.30Y	121.6	0.00	3.38	0.00	0	0	0	100	0.00	0.0	12.763	0.083	0	0	0	0
PL.51994	PL.51993	A	#1/0 ACSR	7.28Y	121.4	0.25	3.59	19.06	8	135	34	97	0.23	0.2	10.993	0.577	0	0	0	39
PL.53652	PL.51994	A	6 A (CWC)	7.28Y	121.4	0.00	3.59	0.41	0	3	1	95	0.00	0.0	10.996	0.003	0	0	0	1
PD.7917	PL.53652	A	40QA	7.28Y	121.4	0.00	3.59	0.41	1	3	1	95	0.00	0.0	10.996	0.003	0	0	0	1
PL.53653	PD.7917	A	6 A (CWC)	7.28Y	121.4	0.00	3.60	0.41	0	3	1	95	0.00	0.0	11.245	0.249	0	0	0	1
PL.39287	PL.53653	A	6 A (CWC)	7.28Y	121.4	0.01	3.61	0.41	0	3	1	95	0.00	0.0	11.735	0.491	0	0	0	1
PL.39289	PL.39287	A	6 A (CWC)	7.28Y	121.4	0.00	3.61	0.41	0	3	1	95	0.00	0.0	11.846	0.110	0	0	0	1
PL.39290	PL.39289	A	6 A (CWC)	7.28Y	121.4	0.00	3.61	0.41	0	3	1	95	0.00	0.0	12.007	0.161	0	0	0	1
PL.37398	PL.39290	A	#1/0 ACSR	7.28Y	121.4	0.00	3.61	0.00	0	0	0	100	0.00	0.0	12.083	0.076	0	0	0	0
PL.39288	PL.39290	A	6 A (CWC)	7.28Y	121.4	0.00	3.61	0.41	0	3	1	95	0.00	0.0	12.066	0.059	3	1	1	1
PL.37202	PL.39287	A	#2 ACSR	7.28Y	121.4	0.00	3.61	0.00	0	0	0	100	0.00	0.0	11.833	0.097	0	0	0	0
PL.63118	PL.51994	A	6 A (CWC)	7.26Y	121.0	0.42	4.01	18.65	13	132	33	97	0.42	0.3	11.485	0.492	0	0	0	38
PD.9463-A	PL.63118	A	Closed	7.26Y	121.0	0.00	4.01	18.65	0	131	32	97	0.00	0.0	11.485	0.492	0	0	0	38
PD.9463-B	PD.9463-A	A	Closed	7.26Y	121.0	0.00	4.01	18.65	0	131	32	97	0.00	0.0	11.485	0.492	0	0	0	38
PL.63119	PD.9463-B	A	#1/0 ACSR	7.26Y	121.0	0.02	4.03	18.65	8	131	32	97	0.02	0.0	11.534	0.049	0	0	0	38
PL.63120	PL.63119	A	#1/0 ACSR	7.26Y	121.0	0.00	4.03	0.05	0	0	0	100	0.00	0.0	11.578	0.044	0	0	1	1
PL.63122	PL.63119	A	#1/0 ACSR	7.25Y	120.9	0.10	4.13	18.59	8	131	32	97	0.09	0.1	11.770	0.237	2	0	1	37
PL.63121	PL.63122	A	#1/0 ACSR	7.25Y	120.8	0.03	4.17	18.30	8	129	32	97	0.03	0.0	11.853	0.082	0	0	0	36
PL.39286	PL.63121	A	6 A (CWC)	7.25Y	120.8	0.01	4.18	2.11	2	15	4	97	0.00	0.0	11.982	0.129	6	1	1	3
PL.37247	PL.39286	A	6 A (CWC)	7.25Y	120.8	0.00	4.18	1.25	1	9	2	98	0.00	0.0	12.013	0.031	8	2	1	2
PL.37248	PL.37247	A	6 A (CWC)	7.25Y	120.8	0.00	4.18	0.13	0	1	0	100	0.00	0.0	12.114	0.101	0	0	0	1
PL.37249	PL.37248	A	6 A (CWC)	7.25Y	120.8	0.00	4.18	0.13	0	1	0	100	0.00	0.0	12.342	0.228	1	0	1	1
PL.63127	PL.63121	A	#1/0 ACSR	7.25Y	120.8	0.02	4.18	16.19	7	114	28	97	0.01	0.0	11.901	0.048	0	0	1	33
PL.63126	PL.63127	A	#1/0 ACSR	7.24Y	120.7	0.07	4.25	16.19	7	114	28	97	0.06	0.0	12.095	0.194	0	0	0	32
PL.63123	PL.63126	A	6 A (CWC)	7.24Y	120.7	0.00	4.25	0.02	0	0	0	100	0.00	0.0	12.129	0.035	0	0	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.63125	PL.63126	A	6 A (CWC)	7.24Y	120.7	0.03	4.28	6.54	5	46	11	97	0.01	0.0	12.181	0.086	0	0	0	9
PL.57541	PL.63125	A	6 A (CWC)	7.24Y	120.7	0.01	4.29	3.89	3	27	7	97	0.00	0.0	12.260	0.079	5	1	2	7
PL.57542	PL.57541	A	#2 ACSR	7.24Y	120.7	0.00	4.29	1.37	1	10	2	98	0.00	0.0	12.311	0.051	10	2	1	1
PL.57540	PL.57541	A	6 A (CWC)	7.24Y	120.7	0.02	4.31	1.79	1	13	3	97	0.00	0.0	12.449	0.190	0	0	0	4
PD.6037	PL.57540	A	40QA	7.24Y	120.7	0.00	4.31	1.79	4	13	3	97	0.00	0.0	12.449	0.190	0	0	0	4
PL.37603	PD.6037	A	6 A (CWC)	7.24Y	120.7	0.00	4.31	1.79	1	13	3	97	0.00	0.0	12.450	0.001	0	0	0	4
PL.38743	PL.37603	A	6 A (CWC)	7.24Y	120.7	0.00	4.31	1.79	1	13	3	97	0.00	0.0	12.513	0.063	1	0	1	4
PL.38742	PL.38743	A	6 A (CWC)	7.24Y	120.7	0.01	4.32	1.66	1	12	3	97	0.00	0.0	12.600	0.087	0	0	0	3
PL.39285	PL.38742	A	6 A (CWC)	7.24Y	120.7	0.01	4.33	1.66	1	12	3	97	0.00	0.0	12.784	0.184	10	2	1	3
PL.37789	PL.39285	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.00	0	0	0	100	0.00	0.0	12.893	0.109	0	0	0	0
PL.38653	PL.39285	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.28	0	2	0	100	0.00	0.0	13.070	0.286	0	0	0	2
PL.52021	PL.38653	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.28	0	2	0	100	0.00	0.0	13.181	0.111	2	0	2	2
PL.52022	PL.52021	A	6 A (CWC)	7.24Y	120.7	0.00	4.33	0.00	0	0	0	100	0.00	0.0	13.182	0.000	0	0	0	0
PD.7998-A	PL.52022	A	Open	7.24Y	120.7	0.00	4.33	0.00	0	0	0	100	0.00	0.0	13.182	0.000	0	0	0	0
PL.37713	PL.38742	A	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.00	0	0	0	100	0.00	0.0	12.665	0.065	0	0	0	0
PL.37674	PL.63125	A	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.46	0	3	1	95	0.00	0.0	12.220	0.039	3	1	1	1
PL.37607	PL.63125	A	#2 ACSR	7.24Y	120.7	0.00	4.28	2.19	1	15	4	97	0.00	0.0	12.252	0.071	15	4	1	1
PL.37608	PL.37607	A	#2 ACSR	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	12.283	0.032	0	0	0	0
PL.63124	PL.63126	A	#1/0 ACSR	7.24Y	120.7	0.01	4.26	9.63	4	68	17	97	0.00	0.0	12.142	0.047	0	0	0	21
PL.37736	PL.63124	A	#2 ACSR	7.24Y	120.7	0.00	4.27	0.90	1	6	2	95	0.00	0.0	12.209	0.067	6	2	1	1
PL.37337	PL.63124	A	6 A (CWC)	7.24Y	120.7	0.00	4.26	0.07	0	0	0	100	0.00	0.0	12.186	0.044	0	0	1	1
PL.37609	PL.63124	A	#1/0 ACSR	7.24Y	120.7	0.01	4.27	8.66	4	61	15	97	0.00	0.0	12.183	0.041	0	0	0	19
PL.37610	PL.37609	A	#1/0 ACSR	7.24Y	120.7	0.02	4.29	8.66	4	61	15	97	0.01	0.0	12.290	0.107	2	1	1	19
PL.63128	PL.37610	A	#1/0 ACSR	7.24Y	120.7	0.01	4.31	8.37	4	59	14	97	0.01	0.0	12.361	0.070	2	1	1	18
PL.63129	PL.63128	A	#1/0 ACSR	7.24Y	120.7	0.03	4.34	8.08	4	57	14	97	0.01	0.0	12.544	0.183	0	0	0	17
PL.63132	PL.63129	A	#1/0 ACSR	7.24Y	120.6	0.03	4.37	8.08	4	57	14	97	0.01	0.0	12.703	0.160	0	0	0	17
PL.63131	PL.63132	A	#2 ACSR	7.24Y	120.6	0.00	4.37	0.69	0	5	1	98	0.00	0.0	12.731	0.028	5	1	1	1
PL.63133	PL.63132	A	#1/0 ACSR	7.24Y	120.6	0.01	4.38	7.39	3	52	13	97	0.00	0.0	12.785	0.081	0	0	0	16
PL.63134	PL.63133	A	#1/0 ACSR	7.23Y	120.6	0.04	4.42	7.39	3	52	13	97	0.01	0.0	12.999	0.215	0	0	0	16
PL.64655	PL.63134	A	#1/0 ACSR	7.23Y	120.6	0.00	4.42	1.24	1	9	2	98	0.00	0.0	13.073	0.073	5	1	1	2
PL.64656	PL.64655	A	#1/0 ACSR	7.23Y	120.6	0.00	4.42	0.58	0	4	1	97	0.00	0.0	13.135	0.063	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.64657	PL.64656	A	1/0 AL URD	7.23Y	120.6	0.00	4.42	0.58	0	4	1	97	0.00	0.0	13.189	0.054	4	1	1	1
PL.63135	PL.63134	A	#1/0 ACSR	7.23Y	120.6	0.02	4.44	6.15	3	43	11	97	0.01	0.0	13.172	0.172	0	0	0	14
PL.63136	PL.63135	A	#1/0 ACSR	7.23Y	120.6	0.01	4.45	6.15	3	43	11	97	0.00	0.0	13.214	0.043	9	2	3	14
PL.63139	PL.63136	A	#1/0 ACSR	7.23Y	120.5	0.00	4.45	4.92	2	35	8	97	0.00	0.0	13.261	0.047	3	1	2	11
PL.63140	PL.63139	A	#1/0 ACSR	7.23Y	120.5	0.00	4.46	3.69	2	26	6	97	0.00	0.0	13.290	0.029	0	0	0	6
PL.63142	PL.63140	A	#1/0 ACSR	7.23Y	120.5	0.02	4.48	2.86	1	20	5	97	0.00	0.0	13.716	0.426	5	1	2	5
PL.63143	PL.63142	A	#1/0 ACSR	7.23Y	120.5	0.00	4.48	2.08	1	15	4	97	0.00	0.0	13.872	0.155	15	4	3	3
PL.63141	PL.63143	A	#2 ACSR	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	14.203	0.331	0	0	0	0
PL.53167	PL.63141	A	#2 ACSR	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	14.325	0.122	0	0	0	0
PL.53166	PL.53167	A	#2 ACSR	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	14.529	0.204	0	0	0	0
PD.7957-B	PL.53166	A	Open	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	14.529	0.204	0	0	0	0
PL.63137	PL.63140	A	#1/0 ACSR	7.23Y	120.5	0.00	4.46	0.83	0	6	1	99	0.00	0.0	13.355	0.065	6	1	1	1
PL.63138	PL.63139	A	#1/0 ACSR	7.23Y	120.5	0.00	4.46	0.83	0	6	1	99	0.00	0.0	13.579	0.318	3	1	1	3
PL.57573	PL.63138	A	#1/0 ACSR	7.23Y	120.5	0.00	4.46	0.02	0	0	0	100	0.00	0.0	13.648	0.068	0	0	1	1
PL.57572	PL.63138	A	#4 ACSR	7.23Y	120.5	0.00	4.46	0.40	0	3	1	95	0.00	0.0	13.627	0.048	3	1	1	1
PL.63130	PL.63129	A	#4 ACSR	7.24Y	120.7	0.00	4.34	0.00	0	0	0	100	0.00	0.0	12.599	0.055	0	0	0	0
PL.37801	PL.39277	A	#2 ACSR	7.30Y	121.7	0.00	3.29	1.37	1	10	2	98	0.00	0.0	10.338	0.048	10	2	1	1
PL.39280	PL.37879	C	#1/0 ACSR	7.38Y	123.1	0.00	1.94	2.52	1	18	4	98	0.00	0.0	7.376	0.072	0	0	0	6
PL.39281	PL.39280	C	#1/0 ACSR	7.38Y	123.1	0.00	1.94	0.32	0	2	1	89	0.00	0.0	7.540	0.164	1	0	2	3
PL.39279	PL.39281	C	#1/0 ACSR	7.38Y	123.1	0.00	1.94	0.20	0	1	0	100	0.00	0.0	7.575	0.035	1	0	1	1
PL.39278	PL.39280	C	#4 ACSR	7.38Y	123.1	0.00	1.94	2.20	2	16	4	97	0.00	0.0	7.380	0.004	0	0	0	3
PD.5957	PL.39278	C	50QA	7.38Y	123.1	0.00	1.94	2.20	4	16	4	97	0.00	0.0	7.380	0.004	0	0	0	3
PL.57784	PD.5957	C	#4 ACSR	7.38Y	123.0	0.02	1.95	2.20	2	16	4	97	0.00	0.0	7.546	0.166	0	0	0	3
PL.57785	PL.57784	C	#4 ACSR	7.38Y	123.0	0.01	1.96	2.20	2	16	4	97	0.00	0.0	7.648	0.103	9	2	2	3
PL.39282	PL.57785	C	#4 ACSR	7.38Y	123.0	0.00	1.96	1.00	1	7	2	96	0.00	0.0	7.691	0.043	7	2	1	1
PL.38736	PL.38390	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.25	0	5	1	98	0.00	0.0	7.169	0.000	0	0	0	4
PD.6027	PL.38736	ABC	75QA	7.39Y	123.1	0.00	1.88	0.25	0	5	1	98	0.00	0.0	7.169	0.000	0	0	0	4
PL.59721	PD.6027	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.25	0	5	1	98	0.00	0.0	7.191	0.022	0	0	0	4
PL.59722	PL.59721	A	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.75	0	5	1	98	0.00	0.0	7.195	0.004	0	0	0	4
PD.8890	PL.59722	A	10T	7.39Y	123.1	0.00	1.88	0.75	0	5	1	98	0.00	0.0	7.195	0.004	0	0	0	4
PL.59147	PD.8890	A	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.75	0	5	1	98	0.00	0.0	7.290	0.095	3	1	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.38738	PL.59147	A	#1/0 ACSR	7.39Y	123.1	0.00	1.89	0.36	0	3	1	95	0.00	0.0	7.438	0.148	1	0	1	3
PL.38739	PL.38738	A	#1/0 ACSR	7.39Y	123.1	0.00	1.89	0.27	0	2	0	100	0.00	0.0	7.581	0.144	2	0	2	2
PL.38740	PL.38739	A	#1/0 ACSR	7.39Y	123.1	0.00	1.89	0.00	0	0	0	100	0.00	0.0	7.730	0.148	0	0	0	0
PL.59723	PL.59721	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	7.259	0.068	0	0	0	0
PL.38737	PL.59723	ABC	#1/0 ACSR	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	7.264	0.005	0	0	0	0
PL.38733	PL.38732	C	#4 ACSR	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	6.423	0.003	0	0	0	0
PD.5958	PL.38733	C	20QA	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	6.423	0.003	0	0	0	0
PL.38734	PD.5958	C	#4 ACSR	7.40Y	123.4	0.00	1.61	0.00	0	0	0	100	0.00	0.0	6.927	0.503	0	0	0	0
PL.38729	PL.38728	A	#1/0 ACSR	7.41Y	123.5	0.00	1.51	0.04	0	0	0	100	0.00	0.0	6.166	0.002	0	0	0	1
PD.6070	PL.38729	A	20QA	7.41Y	123.5	0.00	1.51	0.04	0	0	0	100	0.00	0.0	6.166	0.002	0	0	0	1
PL.38730	PD.6070	A	#1/0 ACSR	7.41Y	123.5	0.00	1.51	0.04	0	0	0	100	0.00	0.0	6.195	0.029	0	0	1	1
PL.39217	PL.39216	A	#1/0 ACSR	7.42Y	123.6	0.00	1.39	0.00	0	0	0	100	0.00	0.0	5.891	0.003	0	0	0	0
PD.5232	PL.39217	A	25QA	7.42Y	123.6	0.00	1.39	0.00	0	0	0	100	0.00	0.0	5.891	0.003	0	0	0	0
PL.38968	PD.5232	A	#1/0 ACSR	7.42Y	123.6	0.00	1.39	0.00	0	0	0	100	0.00	0.0	5.932	0.041	0	0	0	0
PL.39212	PL.61047	B	#4 ACSR	7.42Y	123.7	0.00	1.33	0.86	1	6	2	95	0.00	0.0	5.668	0.002	0	0	0	1
PD.6057	PL.39212	B	40QA	7.42Y	123.7	0.00	1.33	0.86	2	6	2	95	0.00	0.0	5.668	0.002	0	0	0	1
PL.39213	PD.6057	B	#4 ACSR	7.42Y	123.7	0.00	1.33	0.86	1	6	2	95	0.00	0.0	5.700	0.033	6	2	1	1
PL.61048	PL.61046	C	#1/0 ACSR	7.42Y	123.7	0.00	1.32	0.89	0	6	2	95	0.00	0.0	5.619	0.003	0	0	0	1
PD.9133	PL.61048	C	20T	7.42Y	123.7	0.00	1.32	0.89	0	6	2	95	0.00	0.0	5.619	0.003	0	0	0	1
PL.61049	PD.9133	C	#1/0 ACSR	7.42Y	123.7	0.00	1.32	0.89	0	6	2	95	0.00	0.0	5.760	0.141	6	2	1	1
PL.39203	PL.39202	B	#4 ACSR	7.43Y	123.8	0.00	1.20	2.96	2	21	5	97	0.00	0.0	4.949	0.002	0	0	0	2
PD.5235	PL.39203	B	40QA	7.43Y	123.8	0.00	1.20	2.96	7	21	5	97	0.00	0.0	4.949	0.002	0	0	0	2
PL.39204	PD.5235	B	#4 ACSR	7.43Y	123.8	0.00	1.20	2.96	2	21	5	97	0.00	0.0	5.010	0.060	21	5	2	2
PL.38435	PL.39188	A	6 A (CWC)	7.43Y	123.9	0.02	1.14	18.20	13	131	32	97	0.02	0.0	4.563	0.022	14	3	2	36
PL.39185	PL.38435	A	6 A (CWC)	7.43Y	123.8	0.04	1.19	16.30	12	118	29	97	0.04	0.0	4.623	0.060	0	0	0	34
PD.5911	PL.39185	A	35L	7.43Y	123.8	0.00	1.19	16.30	47	118	29	97	0.00	0.0	4.623	0.060	0	0	0	34
PL.39186	PD.5911	A	6 A (CWC)	7.43Y	123.8	0.00	1.19	16.30	12	118	29	97	0.00	0.0	4.623	0.001	0	0	0	34
PL.59438	PL.39186	A	#1/0 ACSR	7.42Y	123.7	0.07	1.25	16.30	7	118	29	97	0.05	0.0	4.799	0.176	0	0	0	34
PL.59439	PL.59438	A	#1/0 ACSR	7.42Y	123.7	0.07	1.32	16.30	7	117	29	97	0.05	0.0	5.000	0.201	10	3	1	34
PL.59440	PL.59439	A	#1/0 ACSR	7.41Y	123.5	0.14	1.46	14.85	6	107	26	97	0.09	0.1	5.417	0.416	7	2	2	33
PL.37753	PL.59440	A	#1/0 ACSR	7.41Y	123.5	0.03	1.49	13.93	6	100	25	97	0.02	0.0	5.516	0.099	0	0	0	31

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.59429	PL.37753	A	#1/0 ACSR	7.41Y	123.4	0.06	1.55	12.29	5	88	22	97	0.04	0.0	5.740	0.224	4	1	4	27
PL.59443	PL.59429	A	6 A (CWC)	7.40Y	123.4	0.04	1.59	11.80	8	85	21	97	0.03	0.0	5.816	0.077	0	0	0	23
PL.37731	PL.59443	A	6 A (CWC)	7.40Y	123.4	0.00	1.59	0.00	0	0	0	100	0.00	0.0	5.877	0.060	0	0	0	0
PL.37347	PL.59443	A	6 A (CWC)	7.40Y	123.3	0.13	1.72	11.80	8	85	21	97	0.08	0.1	6.080	0.263	10	3	3	23
PL.37739	PL.37347	A	6 A (CWC)	7.40Y	123.3	0.00	1.73	1.03	1	7	2	96	0.00	0.0	6.125	0.045	7	2	2	2
PL.39182	PL.37347	A	6 A (CWC)	7.39Y	123.2	0.04	1.76	7.84	6	56	14	97	0.02	0.0	6.183	0.103	0	0	0	16
PL.39181	PL.39182	A	6 A (CWC)	7.39Y	123.2	0.07	1.83	7.84	6	56	14	97	0.03	0.1	6.390	0.208	4	1	2	16
PL.38128	PL.39181	A	6 A (CWC)	7.39Y	123.2	0.00	1.83	0.74	1	5	1	98	0.00	0.0	6.434	0.043	5	1	2	2
PL.37346	PL.39181	A	6 A (CWC)	7.39Y	123.1	0.05	1.88	6.51	5	47	11	97	0.02	0.0	6.545	0.154	0	0	0	12
PL.37478	PL.37346	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	6.674	0.130	0	0	0	0
PL.37345	PL.37346	A	6 A (CWC)	7.38Y	123.0	0.07	1.95	6.04	4	43	11	97	0.02	0.1	6.811	0.266	0	0	0	11
PL.38225	PL.37345	A	6 A (CWC)	7.38Y	123.0	0.05	2.00	3.36	2	24	6	97	0.01	0.0	7.206	0.395	6	2	1	8
PL.38226	PL.38225	A	6 A (CWC)	7.38Y	123.0	0.03	2.03	2.47	2	18	4	98	0.00	0.0	7.477	0.271	0	0	0	7
PL.37761	PL.38226	A	6 A (CWC)	7.38Y	122.9	0.03	2.07	2.47	2	18	4	98	0.00	0.0	7.783	0.306	0	0	0	7
PL.37762	PL.37761	A	6 A (CWC)	7.38Y	122.9	0.01	2.08	1.49	1	11	3	96	0.00	0.0	7.922	0.139	0	0	0	4
PL.38899	PL.37762	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.94	1	7	2	96	0.00	0.0	8.058	0.136	7	2	1	2
PL.38900	PL.38899	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.02	0	0	0	100	0.00	0.0	8.087	0.029	0	0	1	1
PL.37178	PL.38900	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.00	0	0	0	100	0.00	0.0	8.156	0.069	0	0	0	0
PD.5915-A	PL.37178	A	Open	7.38Y	122.9	0.00	2.08	0.00	0	0	0	100	0.00	0.0	8.156	0.069	0	0	0	0
PL.37305	PL.37762	A	6 A (CWC)	7.38Y	122.9	0.00	2.08	0.54	0	4	1	97	0.00	0.0	7.972	0.050	4	1	2	2
PL.39120	PL.37761	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	0.98	1	7	2	96	0.00	0.0	7.817	0.033	0	0	0	3
PL.39121	PL.39120	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	0.98	1	7	2	96	0.00	0.0	7.862	0.046	1	0	2	3
PL.38418	PL.39121	A	6 A (CWC)	7.38Y	122.9	0.00	2.07	0.80	1	6	1	99	0.00	0.0	7.881	0.019	6	1	1	1
PL.37693	PL.38226	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	0.00	0	0	0	100	0.00	0.0	7.681	0.204	0	0	0	0
PL.37791	PL.37693	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	0.00	0	0	0	100	0.00	0.0	7.767	0.086	0	0	0	0
PL.37694	PL.37693	A	6 A (CWC)	7.38Y	123.0	0.00	2.03	0.00	0	0	0	100	0.00	0.0	8.047	0.366	0	0	0	0
PL.39122	PL.37345	A	6 A (CWC)	7.38Y	123.0	0.01	1.96	0.93	1	7	2	96	0.00	0.0	7.132	0.321	0	0	0	1
PL.39123	PL.39122	A	6 A (CWC)	7.38Y	123.0	0.00	1.96	0.93	1	7	2	96	0.00	0.0	7.186	0.054	7	2	1	1
PL.37211	PL.39122	A	6 A (CWC)	7.38Y	123.0	0.00	1.96	0.00	0	0	0	100	0.00	0.0	7.213	0.081	0	0	0	0
PL.37279	PL.37345	A	6 A (CWC)	7.38Y	123.0	0.00	1.95	1.75	1	13	3	97	0.00	0.0	6.918	0.107	13	3	2	2
PL.37814	PL.37346	A	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.47	0	3	1	95	0.00	0.0	6.678	0.133	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.37373	PL.37347	A	6 A (CWC)	7.40Y	123.3	0.01	1.73	1.50	1	11	3	96	0.00	0.0	6.331	0.251	11	3	2	2
PL.59441	PL.37753	A	6 A (CWC)	7.41Y	123.5	0.00	1.49	1.64	1	12	3	97	0.00	0.0	5.520	0.004	0	0	0	4
PD.8779	PL.59441	A	40QA	7.41Y	123.5	0.00	1.49	1.64	4	12	3	97	0.00	0.0	5.520	0.004	0	0	0	4
PL.59442	PD.8779	A	6 A (CWC)	7.41Y	123.5	0.01	1.50	1.64	1	12	3	97	0.00	0.0	5.676	0.156	3	1	2	4
PL.39183	PL.59442	A	6 A (CWC)	7.41Y	123.5	0.00	1.50	1.21	1	9	2	98	0.00	0.0	5.721	0.045	6	2	1	2
PL.39184	PL.39183	A	6 A (CWC)	7.41Y	123.5	0.00	1.50	0.31	0	2	1	89	0.00	0.0	5.814	0.093	2	1	1	1
PL.37871	PL.39189	B	#4 ACSR	7.44Y	124.0	0.00	0.98	0.85	1	6	1	99	0.00	0.0	3.957	0.044	0	0	0	2
PL.37889	PL.37871	B	#2 ACSR	7.44Y	124.0	0.00	0.98	0.70	0	5	1	98	0.00	0.0	4.093	0.136	5	1	1	1
PL.37383	PL.37871	B	#4 ACSR	7.44Y	124.0	0.00	0.98	0.15	0	1	0	100	0.00	0.0	4.580	0.623	0	0	0	1
PL.37384	PL.37383	B	#1/0 ACSR	7.44Y	124.0	0.00	0.99	0.15	0	1	0	100	0.00	0.0	4.682	0.102	0	0	0	1
PL.39199	PL.37384	B	#1/0 ACSR	7.44Y	124.0	0.00	0.99	0.15	0	1	0	100	0.00	0.0	4.911	0.229	1	0	1	1
PL.39200	PL.37383	B	#4 ACSR	7.44Y	124.0	0.00	0.98	0.00	0	0	0	100	0.00	0.0	4.663	0.083	0	0	0	0
PL.39201	PL.39200	B	#4 ACSR	7.44Y	124.0	0.00	0.98	0.00	0	0	0	100	0.00	0.0	4.776	0.113	0	0	0	0
PL.37463	PL.37461	B	#4 ACSR	7.45Y	124.2	0.00	0.84	0.43	0	3	1	95	0.00	0.0	3.314	0.001	0	0	0	1
PD.6036	PL.37463	B	50QA	7.45Y	124.2	0.00	0.84	0.43	1	3	1	95	0.00	0.0	3.314	0.001	0	0	0	1
PL.37464	PD.6036	B	#4 ACSR	7.45Y	124.2	0.00	0.84	0.43	0	3	1	95	0.00	0.0	3.387	0.073	3	1	1	1
PL.37466	PL.37465	A	#4 ACSR	7.45Y	124.2	0.00	0.80	1.08	1	8	2	97	0.00	0.0	3.151	0.009	0	0	0	2
PD.5997	PL.37466	A	50QA	7.45Y	124.2	0.00	0.80	1.08	2	8	2	97	0.00	0.0	3.151	0.009	0	0	0	2
PL.37467	PD.5997	A	#4 ACSR	7.45Y	124.2	0.00	0.80	1.08	1	8	2	97	0.00	0.0	3.225	0.074	0	0	0	2
PL.37258	PL.37467	A	#4 ACSR	7.45Y	124.2	0.00	0.80	0.33	0	2	1	89	0.00	0.0	3.316	0.091	2	1	1	1
PL.37276	PL.37467	A	#1/0 ACSR	7.45Y	124.2	0.00	0.80	0.75	0	5	1	98	0.00	0.0	3.292	0.066	5	1	1	1
PL.36739	PL.39190	B	6 A (CWC)	7.45Y	124.2	0.00	0.76	0.63	0	5	1	98	0.00	0.0	3.012	0.000	0	0	0	1
PD.6021	PL.36739	B	40QA	7.45Y	124.2	0.00	0.76	0.63	2	5	1	98	0.00	0.0	3.012	0.000	0	0	0	1
PL.36740	PD.6021	B	6 A (CWC)	7.45Y	124.2	0.00	0.76	0.63	0	5	1	98	0.00	0.0	3.021	0.009	5	1	1	1
PL.37976	PL.37974	C	#2 ACSR	7.47Y	124.5	0.00	0.48	3.09	2	22	5	98	0.00	0.0	1.849	0.006	0	0	0	1
PD.6033	PL.37976	C	50QA	7.47Y	124.5	0.00	0.48	3.09	6	22	5	98	0.00	0.0	1.849	0.006	0	0	0	1
PL.37977	PD.6033	C	#2 ACSR	7.47Y	124.5	0.00	0.48	3.09	2	22	5	98	0.00	0.0	1.933	0.084	22	5	1	1
PL.36875	PL.38475	C	6 A (CWC)	7.49Y	124.8	0.00	0.25	0.00	0	0	0	100	0.00	0.0	0.934	0.001	0	0	0	0
PL.38473	PL.38475	C	6 A (CWC)	7.49Y	124.8	0.00	0.25	0.76	1	6	1	99	0.00	0.0	0.934	0.001	0	0	0	1
PD.5897	PL.38473	C	40QA	7.49Y	124.8	0.00	0.25	0.76	2	6	1	99	0.00	0.0	0.934	0.001	0	0	0	1
PL.38474	PD.5897	C	6 A (CWC)	7.48Y	124.7	0.00	0.25	0.76	1	6	1	99	0.00	0.0	1.036	0.102	6	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Three Links

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.37284	PL.39197	A	#2 ACSR	7.49Y	124.8	0.00	0.18	0.87	0	6	2	95	0.00	0.0	0.671	0.002	0	0	0	1
PD.6054	PL.37284	A	40QA	7.49Y	124.8	0.00	0.18	0.87	2	6	2	95	0.00	0.0	0.671	0.002	0	0	0	1
PL.37285	PD.6054	A	#2 ACSR	7.49Y	124.8	0.00	0.18	0.87	0	6	2	95	0.00	0.0	0.708	0.037	6	2	1	1
PL.39191	PL.37884	C	#4 ACSR	7.49Y	124.9	0.00	0.12	0.64	0	5	1	98	0.00	0.0	0.448	0.004	0	0	0	1
PD.6034	PL.39191	C	50QA	7.49Y	124.9	0.00	0.12	0.64	1	5	1	98	0.00	0.0	0.448	0.004	0	0	0	1
PL.39192	PD.6034	C	#4 ACSR	7.49Y	124.9	0.00	0.12	0.64	0	5	1	98	0.00	0.0	0.602	0.154	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load Losses	Total			
KW	6033	0	0	0	0	0	266	0.00	6298	Lowest Voltage = 118.34 on Element PL.62117		
KVAR	1683	0	0	0	0	0	390		2072	Max Accm VoltD = 6.66 on Element PL.62117		
										Max Elem VoltD = 0.85 on Element PL.37099		