



STEVEN L. BESHEAR  
GOVERNOR

LEONARD K. PETERS  
SECRETARY

**ENERGY AND ENVIRONMENT CABINET**  
DEPARTMENT FOR ENVIRONMENTAL PROTECTION  
DIVISION OF WATER  
200 FAIR OAKS LANE, 4TH FLOOR  
FRANKFORT KENTUCKY 40601  
[www.kentucky.gov](http://www.kentucky.gov)

May 11, 2010

RECEIVED

MAY 14 2010

PUBLIC SERVICE  
COMMISSION

Mr. Jeff Derouen  
Executive Director  
Public Service Commission  
211 Sower Blvd  
Frankfort, KY 40602


Re: Garrison-Quincy-KY-O-Heights Water District  
PSC Case No. 2010-00163

Dear Mr. Derouen:

This letter is in response to the Public Service Commission's inquiry about the permits issued by the Division of Water to The Garrison Water District to build a wastewater collection system consisting of 415 grinder pumps, approximately 49,350 linear feet of small diameter force main and 114,100 gallons per day wastewater treatment plant. Construction plans and specifications for both the collection system (including the force main and grinder pumps) and the wastewater treatment plant have been reviewed and approved by the Division. The construction permit for the wastewater treatment plant expires on July 16, 2010, while the collection system's construction permit expires on December 8, 2010. In addition to the construction permits, the Division has also issued a Kentucky Pollutant Discharge Elimination System discharge permit (No.KY0105422) for the wastewater treatment plant. The discharge permit is currently up for renewal but while the renewal process is ongoing, the original permit remains valid until the renewed one can be issued.

If we can be of any further assistance or should you wish to discuss this correspondence, please do not hesitate to contact Shafiq Amawi, Manager of the Water Infrastructure Branch, at (502) 564-3410.

Sincerely,

  
Sandy L. Gruzesky, P.E.,  
Division of Water Director

C. Jeff Reynolds, P.E. HMP Engineers  
Gerald Wuetcher