

LG&E/KU – Mill Creek Station

Phase II Air Quality Control Study

Operations and Maintenance Cost Estimate

March 9, 2011

Revision B – Issued For Client Review

B&V File Number 41.0805.1



Table of Contents

1.0 Operations and Maintenance Cost Estimate 1-2
 1.1 Fixed Costs..... 1-2
 1.2 Variable Costs..... 1-3

Appendix A Auxiliary Power Costs

DRAFT - CLIENT REVIEW

1.0 Operations and Maintenance Cost Estimate

The levelized annual incremental Operations and Maintenance (O&M) cost estimates for the LG&E/KU Mill Creek Station Phase II Air Quality Control Study were derived from proprietary Black & Veatch O&M estimating tools and representative estimates for similar projects. Costs were based on vendor estimates and recommendations; estimated performance information; typical costs for materials, supplies, consumables and chemicals; and input from LG&E/KU for existing plant staffing and labor rates. Black & Veatch has summarized these costs into two primary categories: fixed costs and variable costs. Fixed costs, expressed as dollars per unit of net capacity per year (\$/kW-yr), do not vary directly with plant power generation and consist primarily of wages and wage-related overheads for the permanent plant staff and routine equipment maintenance. This is in contrast to the variable costs, expressed as dollars per unit of net generation (\$/MWh), which tend to vary in nearly direct proportion to the output of the unit. Variable O&M includes costs associated with ash and Wet Flue Gas Desulfurization (WFGD) byproduct disposal, chemicals, reagents, utilities, and other consumables.

An electricity cost due to increased plant auxiliary power was estimated by Black & Veatch with input from LG&E/KU for the cost per unit of generation in 2011. The cost of lost revenue due to increased auxiliary power requirements is not included in the total fixed or variable O&M cost, but is listed separately at the bottom of Table 1-2.

Fuel costs are determined separately and not included in either fixed or variable O&M costs.

1.1 Fixed Costs

The major element in the estimate of incremental fixed O&M is the cost of wages for the additional labor to staff the facility. Increased staffing was estimated for the plant as a whole, not on an individual unit basis, with the understanding that there is one common control room for all four units. It was estimated that the plant would require one additional operator per shift to support the additional Air Quality Control (AQC) equipment at the site. Mill Creek currently has four distinct operating crews which would result in a total of 4 additional operators. It was also estimated that the plant would need additional maintenance support at the site. The maintenance craft personnel would consist of a total of two mechanical maintenance personnel and two instrument and control (I&C) technicians in order to ensure the reliability of the additional plant systems.

Table 1-1 shows the estimated incremental staffing plan and associated salaries. The salaries for each added position were based on an average rate of \$63.89/hour and

**LG&E/KU – Mill Creek Station
Operations and Maintenance Cost Estimate**

2,080 hours per year. It was understood that the rate of \$63.89/hour, provided by LG&E/KU, is a fully-loaded labor rate.

Other incremental fixed O&M costs include routine maintenance for the additional AQC equipment on each unit. The routine maintenance costs for the ash handling systems for all four units were increased based on the added equipment and additional byproduct being captured. Units 1 and 2, where a Pulse Jet Fabric Filter (PJFF) is replacing a Cold-side Electrostatic Precipitator (CS-ESP), considered the reduction in costs of the CS-ESP ash handling equipment. Unit 1 will utilize the existing fly ash handling system while Unit 2 will have its own separate fly ash handling system. Units 3 and 4 will each have a separate fly ash handling system for waste ash that is collected in the PJFF and sellable ash that is collected in the CS-ESPs and existing system. The incremental routine maintenance costs for the particulate control systems on Units 1 and 2 were determined by including maintenance expenses for the PJFF system while subtracting the maintenance expenses for the CS-ESP for each Unit. The average annual CS-ESP maintenance expenses for Units 1 and 2 were estimated using a historic Mill Creek plant budget from 2001-2011 and then pro-rating the total plant expenses for each unit based on gross capacity.

On Units 1 and 2 new ID fans with Variable Frequency Drives (VFD) are replacing existing ID fans and booster fans with hydraulic couplings while for Units 3 and 4 new booster fans with VFDs are supplementing the existing ID fans with hydraulic couplings, resulting in the same number of overall fans at the plant. Based on previous Black & Veatch studies, it is estimated that the maintenance cost for centrifugal fans with a hydraulic coupling versus centrifugal fans with a VFD are similar. As a result it was estimated that the difference in annual maintenance cost for the ID and booster fans at the Mill Creek plant would be negligible.

The estimate of annual fixed O&M costs in 2011 US \$/kW-yr is shown in Table 1-2.

1.2 Variable Costs

The major elements of the expected incremental variable costs include ash and WFGD byproduct disposal, reagents, and other consumables. Ash and WFGD byproduct disposal costs include the additional byproduct being generated due to added AQC equipment and increased limestone consumption. Fly ash quantities currently sold or given away were provided by LG&E/KU on a plant basis and were not available on a unit by unit basis. Black & Veatch verified that this amount, to be collected in the Unit 3 and 4 CS-ESPs, will be available to be sold or given away in the new AQC configuration; therefore, it was assumed that the same amount of fly ash that is currently being sold or given away will continue to be sold or given away. The actual increases in ash and

**LG&E/KU – Mill Creek Station
Operations and Maintenance Cost Estimate**

WFGD byproduct disposal were not able to be determined on a unit basis, but the overall increase in ash and WFGD byproduct disposal for the plant were calculated.

Reagents and other consumables costs are based upon unit price input from LG&E/KU to the extent available, selected vendors, and Black & Veatch's past project experience for the selected technology, given the expected fuel constituents and the respective emissions limits.

The estimate of annual variable O&M costs in 2011 US \$/MWh is included in Table 1-2. The total net generation (in MWh) is based on the estimated capacity factor and rated net winter capacity for each respective unit.

Variable O&M costs are based on the following assumptions:

- Annual reagent and consumables usage and ash and WFGD byproduct generation are based on full load unit operation and each unit's respective capacity factor
 - Unit 1: 68.00%
 - Unit 2: 70.00%
 - Unit 3: 75.00%
 - Unit 4: 75.00%
- Ash and WFGD byproduct waste disposal cost is \$15/ton
- Limestone cost is \$7.54/ton
- Pulse jet fabric filter bag replacement cost is \$100/bag
- Pulse jet fabric filter cage replacement cost is \$50/cage
- Pulse jet fabric filter bags and cages are replaced every three years
- Ammonia cost for SCR is \$530.03/ton
- SCR catalyst replacement cost is \$6,500/m³
- SCR catalyst is replaced every 16,000 hours
- SCR grid tuning and testing is performed every two years at a cost of \$100K per Unit
- Halogenated PAC cost is \$1.10/lb
- Trona cost is \$195/ton
- Changes in revenue from ash and gypsum sales were not considered
- Incremental water usage, water disposal, and water treatment costs are considered to be negligible

The incremental auxiliary power increase for each unit was estimated by Black & Veatch while the auxiliary power cost for each unit was provided by LG&E/KU. Incremental auxiliary power use and costs are listed in Appendix A.

LG&E/KU – Mill Creek Station
 Operations and Maintenance Cost Estimate

Table 1-1. Incremental O&M Staffing Plan and Labor Expenses

	Per Shift	Shifts	Total	Annual Base Wages ¹	Over Time %	Payroll	Burden %	Total Annual Expense
OPERATIONS								
Operator	1	4	4	\$132,891	0	\$531,565	0	\$531,565
						Operations Subtotal		\$531,565
MAINTENANCE								
Mechanic	2	1	2	\$132,891	0	\$265,782	0	\$265,782
I&E Technician	2	1	2	\$132,891	0	\$265,782	0	\$265,782
						Maintenance Subtotal		\$531,565
	Total Staff		8	Grand Total Annual Labor Expenses				\$1,063,130
Notes:								
1. Fully loaded labor rate.								

LG&E/KU – Mill Creek Station
Operations and Maintenance Cost Estimate

Table 1-2. Summary of Annual Incremental Fixed and Variable O&M Costs
(all costs in \$1000)

	Unit 1	Unit 2	Unit 3	Unit 4	Total Plant
Labor¹					
Operations	\$133	\$133	\$133	\$133	\$532
Maintenance	\$133	\$133	\$133	\$133	\$532
Labor Subtotal	\$266	\$266	\$266	\$266	\$1,063
Maintenance					
Ash Handling System	\$14	\$74	\$92	\$110	\$289
SCR & Associated Systems	\$29	\$29	\$0	\$0	\$59
Particulate Control System (PJFF)	\$7	\$7	\$44	\$52	\$110
PAC Injection System	\$13	\$13	\$13	\$13	\$52
Trona Injection System	\$35	\$35	\$35	\$35	\$140
Maintenance Subtotal	\$98	\$159	\$183	\$209	\$649
TOTAL FIXED COSTS	\$364	\$425	\$449	\$475	\$1,712
Ash/WFGD byproduct Disposal ²	\$198	\$210	\$534	\$561	\$1,504
Limestone Usage	\$8	\$8	\$79	\$72	\$167
PJFF Bag & Cage Replacement	\$464	\$464	\$552	\$656	\$2,135
SCR (Ammonia)	\$357	\$372	\$0	\$0	\$729
SCR Catalyst Replacement	\$429	\$441	\$0	\$0	\$870
SCR Grid Tuning and Testing	\$50	\$50	\$0	\$0	\$100
Mercury Control (PAC Injection)	\$5,133	\$5,518	\$7,097	\$8,643	\$26,391
SO ₃ Control (Trona Injection)	\$2,237	\$2,364	\$3,220	\$3,918	\$11,739
Neural Network Support	\$50	\$50	\$50	\$50	\$200
TOTAL VARIABLE COSTS	\$8,925	\$9,477	\$11,532	\$13,900	\$43,834
Winter Net Capacity (MW)	303	299	397	492	1,491
Net Generation (MWh)	1,805,609	1,833,468	2,608,290	3,232,440	9,479,807
Fixed Costs, \$/kW-yr	\$1.20	\$1.42	\$1.13	\$0.97	\$1.15
Variable Costs, \$/MWh	\$4.94	\$5.17	\$4.42	\$4.30	\$4.62
ELECTRICITY TOTAL COST	\$462	\$510	\$968	\$1,631	\$3,571

Notes:

1. Staffing and associated costs shown for total plant, but divided up equally among the four units.
2. Current annual fly ash quantities sold or given away were not provided on a unit basis. All fly ash to be sold or given away shall come from Units 3 & 4. Therefore, changes in ash/byproduct disposal costs do not reflect actual increases for each unit. Ash/WFGD byproduct disposal costs shown for total plant should be used.

Appendix A
Auxiliary Power Costs

DRAFT - CLIENT REVIEW

The table below is a summary of the Mill Creek differential auxiliary power costs.

Mill Creek Differential Auxiliary Power Costs					
Units	Differential Aux	Capacity	Annual Diff.	Aux Power	Annual Aux
	Operating (kW)	Factor	Aux (MWh)	Cost (\$/MWh)	Power Cost
Unit 1	3,595	68%	21,413	\$21.56	\$461,669
Unit 2	3,835	70%	23,519	\$21.69	\$510,120
Unit 3	6,320	75%	41,520	\$23.31	\$967,839
Unit 4	11,110	75%	72,990	\$22.35	\$1,631,326
Total	24,859		159,442		\$3,570,954

DRAFT - CLIENT REVIEW

The tables below are a detailed breakdown of the differential auxiliary power use for each Mill Creek unit.

Mill Creek Unit 1					
List of Items	Normal Quantity	Normal	Normal	Normal	Total
	Operating	Operating HP	Operating Time	Operating kW	Operating kW
ID FANS					
ID FANS	2.0	5400.0	24.0	4739.3	9,479
MISC ID FAN LOADS (lube oil pumps, heater, cooling fans)	2.0	15.0	24.0	12.0	24
CURRENT EXISTING ID AND BOOSTER FANS	2.0	-3800.0	24.0	-3335.1	-6,670
EXISTING MISC ID AND BOOSTER FAN LOADS CANCEL OUT W/ NEW FAN	2.0	-15.0	24.0	-12.0	-24
ID FAN SUBTOTAL					2,808
PULSE JET FABRIC FILTER (PJFF)					
PJFF SUBTOTAL					397
EXISTING ELECTROSTATIC PRECIPITATOR (ESP)					
CURRENT ESP	1.0		24.0	-500.0	-500
ESP SUBTOTAL					-500
SELECTIVE CATALYTIC REDUCTION (SCR)					
RILEY POWER INC SCR SYSTEM	1.0		24.0	200.0	200
SCR SUBTOTAL					200
POWDER ACTIVATED CARBON (PAC) INJECTION					
PAC INJECTION SUBTOTAL					44
SORBENT INJECTION					
SORBENT INJECTION SUBTOTAL					59
ENCLOSURE LOADS					
ENCLOSURE LOADS SUBTOTAL					183
MISCELLANEOUS LOADS					
MISC LOADS SUBTOTAL					402
TOTAL					3,595

Notes:

Motor Efficiencies were assumed at 93% except for compressors and ID fan drivers including 1 VFDs which were assumed at 85%

Mill Creek Unit 2					
List of Items	Normal Quantity	Normal	Normal	Normal	Total
	Operating	Operating HP	Operating Time	Operating kW	Operating kW
ID FANS					
ID FANS	2.0	5400.0	24.0	4739.3	9,479
MISC ID FAN LOADS (lube oil pumps, heater, cooling fans)	2.0	16.0	24.0	12.8	26
CURRENT EXISTING ID AND BOOSTER FANS	2.0	-3800.0	24.0	-3335.1	-6,670
EXISTING MISC ID AND BOOSTER FAN LOADS CANCEL OUT W/ NEW FAN	2.0	-16.0	24.0	-12.8	-26
ID FAN SUBTOTAL					2,808
PULSE JET FABRIC FILTER (PJFF)					
PJFF SUBTOTAL					638
EXISTING ELECTROSTATIC PRECIPITATOR (ESP)					
CURRENT ESP	1.0		24.0	-500.0	-500
ESP SUBTOTAL					-500
SELECTIVE CATALYTIC REDUCTION (SCR)					
SCR SUBTOTAL					200
POWDER ACTIVATED CARBON (PAC) INJECTION					
PAC INJECTION SUBTOTAL					44
SORBENT INJECTION					
SORBENT INJECTION SUBTOTAL					59
ENCLOSURE LOADS					
ENCLOSURE LOADS SUBTOTAL					183
MISCELLANEOUS LOADS					
MISC LOADS SUBTOTAL					402
TOTAL					3,835

Notes:

Motor Efficiencies were assumed at 93% except for compressors and ID fan drivers including 1 VFDs which were assumed at 85%

Mill Creek Unit 3					
List of Items	Normal Quantity	Normal	Normal	Normal	Total
	Operating	Operating HP	Operating Time	Operating kW	Operating kW
BOOSTER FANS					
BOOSTER FANS	2.0	3500.0	24.0	3071.8	6,144
MISC BOOSTER FAN LOADS (lube oil pumps, heater, cooling fans)	2.0	14.0	24.0	11.2	22
CURRENT EXISTING ID FANS	2.0	-6100.0	24.0	-5353.6	-10,707
FUTURE EXISTING ID FANS	2.0	4500.0	24.0	3949.4	7,899
MISC ID FAN LOADS CANCEL OUT	2.0	0.0	24.0	0.0	0
BOOSTER FAN SUBTOTAL					3,358
PULSE JET FABRIC FILTER (PJFF)					
PJFF SUBTOTAL					773
POWDER ACTIVATED CARBON (PAC) INJECTION					
PAC INJECTION SUBTOTAL					44
SORBENT INJECTION					
SORBENT INJECTION SUBTOTAL					59
WET FLUE GAS DESULFURIZATION (WFGD)					
CURRENT UNIT 3 SCRUBBER	1.0		24.0	-4000.0	-4,000
CURRENT UNIT 4 SCRUBBER	1.0		24.0	5500.0	5,500
ESP SUBTOTAL					1,500
ENCLOSURE LOADS					
ENCLOSURE LOADS SUBTOTAL					183
MISCELLANEOUS LOADS					
MISC LOADS SUBTOTAL					402
TOTAL					6,320

Notes:

Motor Efficiencies were assumed at 93% except for compressors and ID fan drivers including
 1 VFDs which were assumed at 85%

Mill Creek Unit 4					
List of Items	Normal Quantity	Normal	Normal	Normal	Total
	Operating	Operating HP	Operating Time	Operating kW	Operating kW
BOOSTER FANS					
BOOSTER FANS	2.0	3700.0	24.0	3247.3	6,495
MISC BOOSTER FAN LOADS (lube oil pumps, heater, cooling fans)	2.0	15.0	24.0	12.0	24
CURRENT EXISTING ID FANS	2.0	-7500.0	24.0	-6582.4	-13,165
FUTURE EXISTING ID FANS	2.0	5500.0	24.0	4827.1	9,654
MISC ID FAN LOADS CANCEL OUT	2.0	0.0	24.0	0.0	0
BOOSTER FAN SUBTOTAL					3,008
PULSE JET FABRIC FILTER (PJFF)					
PJFF SUBTOTAL					1,101
POWDER ACTIVATED CARBON (PAC) INJECTION					
PAC INJECTION SUBTOTAL					44
SORBENT INJECTION					
SORBENT INJECTION SUBTOTAL					59
WET FLUE GAS DESULFURIZATION (WFGD)					
REACTION TANK AGITATORS	4.0	75.0	24.0	60.2	241
RECYCLE PUMPS	5.0	2000.0	24.0	1604.3	8,022
SLURRY BLEED PUMPS	1.0	175.0	24.0	140.4	140
OXIDATION AIR BLOWERS	1.0	3000.0	24.0	2406.5	2,406
OXIDATION AIR BLOWER INLET GUIDE VANES	1.0	3.0	24.0	2.4	2
OXIDATION AIR LUBE OIL PUMPS	2.0	25.0	24.0	20.1	40
OXIDATION AIR BLOWER BLOWOFF VALVE MOTORS	1.0	3.0	24.0	2.4	2
OXIDATION AIR BLOWER DISCHARGE DIFFUSER VANE MOTORS	1.0	3.0	24.0	2.4	2
MIST ELIMINATOR WASH WATER PUMPS	1.0	115.0	24.0	92.2	92
ABSORBER AREA SUMP PUMPS	1.0	30.0	1.0	24.1	1
ABSORBER AREA SUMP AGITATORS	1.0	8.5	24.0	6.8	7
CHLORINE BLEED PUMPS	1.0	20.0	24.0	16.0	16
HYDROCYCLONE UNDERFLOW TRANSFER TANK AGITATOR	1.0	75.0	24.0	60.2	60
HYDROCYCLONE UNDERFLOW TRANSFER PUMPS	1.0	175.0	24.0	140.4	140
CURRENT EXISTING UNIT 4 SCRUBBER	1.0		24.0	-5500.0	-5,500
WFGD SUBTOTAL					5,673
ENCLOSURE LOADS					
ENCLOSURE LOADS SUBTOTAL					620
MISCELLANEOUS LOADS					
MISC LOADS SUBTOTAL					604
TOTAL					11,110

Notes:

1	Motor Efficiencies were assumed at 93% except for compressors and ID fan drivers including VFDs which were assumed at 85%
---	---