

Archived: Thursday, May 31, 2012 3:41:01 PM
From: [Eric M. Robeson](#)
Sent: Tuesday, February 07, 2012 9:17:00 AM
To: CALEB.L.KADERA@Sargentlundy.com
Subject: RE: CCR
Importance: Normal

Thanks

Agree report needs slight clarification

I believe table ES-6 was to be revised to include cap ex number

From: CALEB.L.KADERA@Sargentlundy.com
[\[mailto:CALEB.L.KADERA@Sargentlundy.com\]](mailto:CALEB.L.KADERA@Sargentlundy.com)
Sent: Tuesday, February 07, 2012 8:56 AM
To: Eric M. Robeson
Subject: RE: CCR

Eric,

HMP&L and Green would be \$28M each (per site not unit) and Coleman should be \$38M because the existing fly ash handling system would need to be converted to a dry pneumatic system. I will update this in report to help clarify the recommendation.

Best Regards,

Caleb Kadera
Mechanical Associate
Fossil Power Technologies
Sargent & Lundy LLC
55 E Monroe, Chicago, IL 60603
Fax: 312-269-7430
Phone: 312-269-2773

From: "Eric M. Robeson" <Eric.Robeson@bigrivers.com>
To: "CALEB.L.KADERA@Sargentlundy.com" <
CALEB.L.KADERA@Sargentlundy.com>
Date: 02/07/2012 08:27 AM
Subject: RE: CCR

\$28M each?

From: CALEB.L.KADERA@Sargentlundy.com
[<mailto:CALEB.L.KADERA@Sargentlundy.com>]
Sent: Tuesday, February 07, 2012 8:27 AM
To: Eric M. Robeson
Subject: Re: CCR

Correct. Remote SSC's at each.

Best Regards,

Caleb Kadera
Mechanical Associate
Fossil Power Technologies
Sargent & Lundy LLC
55 E Monroe, Chicago, IL 60603
Fax: 312-269-7430
Phone: 312-269-2773

From: "Eric M. Robeson" <Eric.Robeson@bigrivers.com>
To: "caleb.l.kadera@sargentlundy.com" <caleb.l.kadera@sargentlundy.com>
Date: 02/06/2012 08:37 PM
Subject: CCR

Is recommended plan SSC at Green HMPL and Coleman at a cost of \$28M each?

The information contained in this transmission is intended only for the person or entity to which it is directly addressed or copied. It may contain material of confidential and/or private nature. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is not allowed. If you receive this message and the information contained therein by error, please contact the sender and delete the material from your/any storage medium.