

Archived: Thursday, May 31, 2012 4:00:20 PM
From: [Mike Galbraith](#)
Sent: Monday, August 08, 2011 9:10:56 AM
To: [Eric M. Robeson](#); [Bob Berry](#); [Wayne O'Bryan](#)
Cc: [Tom Shaw](#); [Mark Bertram](#); [Chad Phillips](#)
Subject: Coleman preliminary data
Importance: Normal
Attachments: [Coleman preliminary HCl-HF.xls](#) ;

Attached are the preliminary results of HCl and HF testing performed at the Coleman Station. No surprises, results typical of a unit with a wet FGD and well below the proposed HAPS HCl limit (0.002 lbs/mmBtu).

I will forward additional results as they become available.

Mike