

**Archived:** Thursday, May 31, 2012 3:40:13 PM  
**From:** [ADAM.C.LANDRY@sargentlundy.com](mailto:ADAM.C.LANDRY@sargentlundy.com)  
**Sent:** Friday, June 24, 2011 11:45:48 AM  
**To:** Tom Shaw; Mike Galbraith  
**Cc:** Eric M. Robeson; [KENNETH.J.SNELL@sargentlundy.com](mailto:KENNETH.J.SNELL@sargentlundy.com);  
[PAUL.S.FARBER@sargentlundy.com](mailto:PAUL.S.FARBER@sargentlundy.com)  
**Subject:** Green Unit 2 PM test results  
**Importance:** Normal

---

---

==

Tom / Mike,

We have noticed the following PM emissions data for Green Unit 2:

Stack Test May 20-22, 2008: PM(f) = 0.00168 lb/MMBtu (average of three runs)

ICR Stack Test: PM(f) = 0.047 lb/MMBtu

PM(c) = 0.013 lb/MMBtu

PM(t) = 0.060 lb/MMBtu

The ICR PM(f) value is almost 30 x's higher than the 2008 stack test result. Was there an issue with the testing or operations, or other explanation, for the discrepancy?

Regards,

---

*Adam C. Landry*  
*Professional Engineer of Indiana, Illinois, Alberta*  
*Project Manager*

Sargent & Lundy, LLC  
55 East Monroe Street  
Chicago, Illinois 60603

Phone: 312-269-7292  
Cell: 312-656-2464  
Fax: 312-269-9602