

**Archived:** Thursday, May 31, 2012 3:41:22 PM  
**From:** Eric M. Robeson  
**Sent:** Friday, August 19, 2011 2:09:00 PM  
**To:** ADAM.C.LANDRY@sargentlundy.com  
**Subject:** FW: HMP&L Removal w one pump operation  
**Response requested:** No  
**Importance:** Normal

---

---

**From:** Mark A Roby  
**Sent:** Thursday, August 18, 2011 6:35 AM  
**To:** Eric M. Robeson  
**Subject:** RE: HMP&L Removal

Eric,

Here is the removal for the full month of July at HMP&L.....it should give you a better idea of the removal before the extra pump was put in service.

Big Rivers Henderson Emission Report

DATE	DAILY INLET		DAILY OUTLET			
	Unit 1 SO2	Unit 2 SO2	Unit 1 SO2	Unit 2 SO2	Unit 1 REM	Unit 2 REM
07/01/2011	5.29	5.37	0.32	0.53	94.51	90.11
07/02/2011	5.21	5.38	0.29	0.51	94.42	90.46
07/03/2011	5.17	5.31	0.31	0.56	94.03	89.48
07/04/2011	5.16	5.30	0.30	0.56	94.28	89.52
07/05/2011	5.08	5.31	0.30	0.42	94.15	92.01
07/06/2011	5.05	5.26	0.26	0.15	94.93	97.10
07/07/2011	5.03	5.23	0.27	0.15	94.70	97.17
07/08/2011	5.07	5.24	0.28	0.20	94.75	96.29
07/09/2011	5.16	5.36	0.31	0.15	93.94	97.17
07/10/2011	5.10	5.30	0.28	0.13	94.61	97.43
07/11/2011	5.07	5.25	0.38	0.13	92.60	97.57
07/12/2011	5.21	5.27	0.34	0.53	94.20	90.56
07/13/2011	5.31	5.46	0.36	0.66	93.14	87.95
07/14/2011	5.21	5.42	0.38	0.69	92.76	87.21
07/15/2011	5.19	5.35	0.40	0.69	92.26	87.13
07/16/2011	5.29	5.36	0.44	0.63	91.71	88.31
07/17/2011	5.30	5.40	0.33	0.73	93.75	86.42
07/18/2011	5.25	5.35	0.37	0.65	92.90	87.79
07/19/2011	5.25	5.34	0.36	0.59	93.10	88.92
07/20/2011	5.23	5.38	0.28	0.49	94.73	90.96
07/21/2011	5.26	5.39	0.33	0.61	93.71	88.67
07/22/2011	5.20	5.35	0.34	0.62	93.46	88.51
07/23/2011	5.26	5.37	0.35	0.63	93.44	88.28

07/24/2011	5.26	5.35	0.35	0.61	93.39	88.61
07/25/2011	5.24	5.36	0.40	0.74	92.32	86.15
07/26/2011	5.26	5.40	0.47	0.85	91.15	84.28
07/27/2011	5.26	5.39	0.36	0.68	93.10	87.32
07/28/2011	5.23	5.32	0.32	0.59	93.93	88.97
07/29/2011	5.27	5.39	0.31	0.56	94.20	89.54
07/30/2011	5.25	5.31	0.48	0.55	90.87	89.67
07/31/2011	5.20	0.00	0.30	0.00	94.27	0.00

=====

---

**From:** Eric M. Robeson  
**Sent:** Wednesday, August 17, 2011 9:53 AM  
**To:** Mark A Roby  
**Subject:** RE: HMP&L Removal

What sort of removal rate were you getting with one pump in service?

---

**From:** Mark A Roby  
**Sent:** Wednesday, August 17, 2011 6:27 AM  
**To:** Jim Garrett; Jeffrey A Francis; Bob Berry; Eric M. Robeson  
**Cc:** Tom Shaw; Mark Bertram  
**Subject:** HMP&L Removal

**Mark Roby**  
**Sr. Environmental Scientist**  
**Big Rivers Electric Corporation**  
Phone: (270) 844-6033  
Fax: (270) 844-6023  
Cell: (270) 993-1601  
e-mail: [mark.robby@bigrivers.com](mailto:mark.robby@bigrivers.com)

