

Archived: Thursday, May 31, 2012 3:59:37 PM
From: [Ken Daniel](#)
Sent: Wednesday, March 07, 2012 10:21:19 AM
To: [Eric M. Robeson](#)
Cc: [Bob Berry](#); [Ron Gregory](#)
Subject: Wilson FGD Capital Evaluation
Importance: Normal
Attachments: [FGD Writeoff.xlsx](#) ;

=

Eric,

I have reviewed the capital asset list again with the following assumptions:

- vertical tower limestone scrubber utilizing existing limestone prep equipment
- primary dewatering using hydroclones maintaining the existing thickeners for water balance control
- secondary dewatering using existing rotary vacuum filter drums
- utilizing the unit # 2 stack liner

Based on these assumptions, the equipment that would not be required is highlighted in red. I hope this helps.

Ken