

Calibration Data

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 9/13/2010

Operator: jburton

Time	Meter Box $\Delta H @$				Meter Box Y_d				Meter Box Y_d				Barometric Pressure (in. Hg.)		Results	
	1.810	0.9904	29.50		1.810	0.9904	29.50		1.810	0.9904	29.50			0.9904	1.810	
θ (min)	K'	Vacuum	T_{amb}	V_{cr}	V_{final}	V_d	ΔH	T_i	T_o	T_{avg}	V_{mead}	Q	Y_d	$\Delta H @$		
5.0	0.3455	23.0	80	2.193	473.80	2.28	0.63	77	74	75.5	2.219	0.439	0.9882	1.789		
5.0	0.3455	23.0	81	2.191	476.08	2.29	0.63	78	75	76.5	2.225	0.438	0.9849	1.776		
5.0	0.3455	23.0	82	2.189	478.37	2.29	0.63	78	75	76.5	2.225	0.438	0.9839	1.776		
5.0	0.4434	21.0	82	2.809	481.00	2.93	1.05	79	76	77.5	2.844	0.562	0.9877	1.812		
5.0	0.4434	21.0	82	2.809	483.93	2.95	1.05	80	77	78.5	2.858	0.562	0.9829	1.791		
5.0	0.4434	21.0	82	2.809	486.88	2.94	1.05	80	78	79.0	2.846	0.562	0.9871	1.805		
5.0	0.5926	20.0	83	3.751	490.20	3.92	1.9	81	78	79.5	3.799	0.750	0.9874	1.838		
5.0	0.5926	20.0	83	3.751	494.12	3.92	1.9	83	79	81.0	3.788	0.750	0.9901	1.844		
5.0	0.5926	20.0	83	3.751	498.04	3.92	1.9	84	79	81.5	3.785	0.750	0.9910	1.845		
5.0	0.7965	17.0	83	5.042	502.60	5.20	3.3	86	80	83.0	5.024	1.008	1.0035	1.826		
5.0	0.7965	17.0	83	5.042	507.80	5.23	3.3	88	81	84.5	5.039	1.008	1.0005	1.810		
5.0	0.7965	17.0	83	5.042	513.03	5.24	3.3	86	82	84.0	5.054	1.008	0.9976	1.802		
Average													0.9904	1.810		

Nomenclature	
K'	Critical Orifice Coefficient
T_{amb}	Ambient Temperature (°F)
V_{cr}	Volume Through Orifice (scf)
V_d	Gas Meter Volume (ft ³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T_i	Meter Inlet Temperature (°F)
T_o	Meter Outlet Temperature (°F)
T_{avg}	Average Meter Box Temperature (°F)
V_{mead}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y_d	Meter Correction Factor (dimensionless)
$\Delta H @$	ΔH yielding 0.75 scfm

Vacuum Guage (in. Hg.)	Thermometers (°F)			Equations	
	Standard	Vacuum Gauge	Ch. No	Ch. No	Ch. No
5	5.0	32	33	2	3
10	10.0	50	51	33	33
15	15.0	100	101	51	51
20	20.0	150	152	101	102
25	25.0	212	214	152	152
		250	252	214	214
		300	302	252	252
		350	352	302	302
		400	402	352	352
		500	502	402	402
		600	602	502	502
				602	602

$V_{cr} = K' \cdot P_b \cdot \theta$
 $(T_{amb} + 460) \cdot 0.5$
 $V_{mead} = 17.64 \cdot \frac{V_d \cdot (P_b + \Delta H + 460)}{(T_{avg} + 460)}$
 $Q = V_{cr} \cdot \theta$
 $Y_d = V_{cr} / V_{mead}$
 $\Delta H @ = 0.319 \cdot \frac{\Delta H \cdot (T_{amb} + 460) \cdot \theta \cdot Y_d}{P_b \cdot V_d \cdot \theta}$

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.776	Meter ID	M-2

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	348.00	351.88	355.76
Final Volume (ft ³)	351.88	355.76	359.64
Volume Metered (ft ³)	3.88	3.88	3.88
DGM Inlet Temperature (°F)	84	85	85
DGM Outlet Temperature (°F)	80	81	81
Average DGM Temperature (°F)	82.0	83.0	83.0
Ambient Temperature (°F)	84	83	84
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.75	1.75	1.75
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
Vcr (ft ³)	3.722	3.725	3.722
Vmstd (ft ³)	3.741	3.735	3.735
Post Test Yc	0.9947	0.9975	0.9965
Full Test Yd	0.9904	0.9904	0.9904
% Difference	-0.44	-0.71	-0.62
Average % Difference			-0.59

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	7/27/2011
Highest Field Vacuum (inches Hg)	5	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.784	Meter ID	M-3

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	248.00	251.92	255.84
Final Volume (ft ³)	251.92	255.84	259.75
Volume Metered (ft ³)	3.92	3.92	3.91
DGM Inlet Temperature (°F)	87	88	89
DGM Outlet Temperature (°F)	82	83	83
Average DGM Temperature (°F)	84.5	85.5	86.0
Ambient Temperature (°F)	80	80	80
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.735	3.735	3.735
V _{mstd} (ft ³)	3.763	3.756	3.743
Post Test Y _c	0.9926	0.9945	0.9979
Full Test Y _d	0.9891	0.9891	0.9891
% Difference	-0.36	-0.54	-0.89
Average % Difference			-0.60

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 5/23/2011

Operator: J.Burton

Meter Box ID M-7	Meter Box $\Delta H@$	1.815	Meter Box Y_d	0.9799	Barometric Pressure (in. Hg.)	29.50										
Time	Orifice Data					Meter Box Data					Results					
	K'	Vacuum	T_{amb}	V_{or}	V_{inlet}	V_{final}	V_d	ΔH	T_i	T_o	T_{avg}	V_{meas}	Q	Y_d	$\Delta H@$	
5.0	0.3445	20.0	83	2.181	904.10	906.37	2.27	0.63	74	72	73	2.220	0.436	0.9824	1.835	
5.0	0.3445	20.0	83	2.181	906.37	908.65	2.28	0.63	76	72	73.5	2.227	0.436	0.9790	1.820	
5.0	0.3445	20.0	83	2.181	906.65	910.93	2.28	0.63	76	73	74.5	2.223	0.436	0.9808	1.824	
5.0	0.4436	18.0	85	2.803	911.30	914.24	2.94	1.05	77	73	75.0	2.867	0.561	0.9775	1.830	
5.0	0.4436	18.0	85	2.803	914.24	917.18	2.94	1.05	79	74	76.5	2.859	0.561	0.9803	1.835	
5.0	0.4436	18.0	85	2.803	917.18	920.12	2.94	1.05	79	75	77.0	2.856	0.561	0.9812	1.837	
5.0	0.5885	16.0	86	3.715	937.80	941.74	3.94	1.8	83	78	80.5	3.810	0.743	0.9749	1.764	
5.0	0.5885	16.0	86	3.715	941.74	945.65	3.91	1.8	83	78	80.5	3.781	0.743	0.9824	1.792	
5.0	0.5885	16.0	86	3.715	945.65	949.58	3.93	1.8	84	79	81.5	3.794	0.743	0.9792	1.777	
5.0	0.7954	14.0	86	5.021	950.00	955.30	5.30	3.35	84	79	81.5	5.136	1.004	0.9776	1.818	
5.0	0.7954	14.0	86	5.021	955.30	960.60	5.30	3.35	86	80	83.0	5.122	1.004	0.9803	1.823	
5.0	0.7954	14.0	86	5.021	960.60	965.89	5.29	3.35	87	80	83.5	5.107	1.004	0.9831	1.832	
														Average	0.9799	1.815

Nomenclature	
K'	Critical Orifice Coefficient
T_{amb}	Ambient Temperature (°F)
V_{or}	Volume Through Orifice (scf)
V_d	Gas Meter Volume (ft³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T_i	Meter Inlet Temperature (°F)
T_o	Meter Outlet Temperature (°F)
T_{avg}	Average Meter Box Temperature (°F)
V_{meas}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y_d	Meter Correction Factor (dimensionless)
$\Delta H@$	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg)	Thermometers (°F)			Equations
	Standard	Ch No	Ch No	
Standard	Vacuum Gauge	Ch No	Ch No	$V_{or} = K' * P_o * \theta$ $V_{meas} = 17.64 * V_d * (P_o + (\Delta H / 13.6)) / (T_{avg} + 460)$ $Q = V_{or} / \theta$ $Y_d = V_{or} / V_{meas}$ $\Delta H@ = \frac{0.0319 * \Delta H + (T_{avg} + 460) * 9.2}{P_o * Y_d^2 * V_m^2}$
5	32	2	3	
10	50	33	33	
15	100	51	51	
20	150	101	102	
25	212	151	150	
	250	213	213	
	300	251	251	
	350	301	301	
	400	350	350	
	500	401	400	
	600	501	500	
	600	600	598	

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.240	Date	7/27/2011
Highest Field Vacuum (inches Hg)	12	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.788	Meter ID	M-7

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	416.80	420.74	424.70
Final Volume (ft ³)	420.74	424.7	428.64
Volume Metered (ft ³)	3.94	3.96	3.94
DGM Inlet Temperature (°F)	83	84	86
DGM Outlet Temperature (°F)	78	79	80
Average DGM Temperature (°F)	80.5	81.5	83.0
Ambient Temperature (°F)	78	78	77
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.90	1.90	1.90
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	16	16	16
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.742	3.742	3.746
V _{mstd} (ft ³)	3.811	3.824	3.794
Post Test Yc	0.9819	0.9788	0.9874
Full Test Yd	0.9799	0.9799	0.9799
% Difference	-0.21	0.12	-0.76
Average % Difference			-0.28

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 2/11/2011 Operator: Jburton

Time	Orifice Data		Meter Box Data								0.9891	29.50			
	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	ΔH	T _i	T _o	T _{avg}	V _{meas}	Barometric Pressure (in. Hg.)	Results	
	θ (min)	K'	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	ΔH	T _i	T _o	T _{avg}	V _{meas}	Q	Y _d	ΔH@
5.0	0.3455	22.0	64	2.226	310.10	312.38	2.28	0.66	67	65	66	2.259	0.445	0.9854	1.845
5.0	0.3455	22.0	65	2.224	312.38	314.65	2.27	0.66	68	67	67.5	2.243	0.445	0.9916	1.867
5.0	0.3455	22.0	66	2.222	314.65	316.92	2.27	0.66	68	67	67.5	2.243	0.444	0.9906	1.867
5.0	0.4434	21.0	66	2.852	317.20	320.13	2.93	1.10	69	67	68.0	2.896	0.570	0.9848	1.869
5.0	0.4434	21.0	66	2.852	320.13	323.07	2.94	1.10	70	68	69.0	2.900	0.570	0.9833	1.860
5.0	0.4434	21.0	66	2.852	323.07	325.99	2.92	1.10	71	68	69.5	2.878	0.570	0.9910	1.888
5.0	0.5926	19.0	66	3.811	326.20	330.11	3.91	1.9	72	68	70.0	3.857	0.762	0.9881	1.820
5.0	0.5926	19.0	67	3.808	330.11	334.02	3.91	1.9	72	69	70.5	3.854	0.762	0.9881	1.822
5.0	0.5926	19.0	67	3.808	334.02	337.93	3.91	1.9	74	70	72.0	3.843	0.762	0.9909	1.827
5.0	0.7965	17.0	66	5.123	338.30	343.56	5.26	3.5	77	71	74.0	5.171	1.025	0.9907	1.867
5.0	0.7965	17.0	66	5.123	343.56	348.82	5.26	3.5	79	71	75.0	5.161	1.025	0.9926	1.870
5.0	0.7965	17.0	66	5.123	348.82	354.09	5.27	3.5	80	72	76.0	5.161	1.025	0.9925	1.866
													Average	0.9891	1.856

Nomenclature		Vacuum Gauge (in. Hg.)				Thermometers (°F)				Equations
K'	Critical Orifice Coefficient	Standard	Vacuum Gauge	Standard	Ch. No.	Ch. No.	Ch. No.	Ch. No.	Equations	
T _{amb}	Ambient Temperature (°F)	5	5.0	32	1	2	3	3	$V_{cr} = K' \cdot E_a \cdot \theta$ $V_{meas} = 17.64 \cdot V_d \cdot \frac{(T_o + 460)}{(T_{avg} + 460)} \wedge 0.5$ $Q = V_{cr} \cdot \theta$ $Y_d = V_{cr} / V_{meas}$ $\Delta H@ = .0319 \cdot \Delta H \cdot \frac{(T_o + 460)}{P_b \cdot Y_d \cdot 2 - V_{cr} \cdot \theta \cdot 2}$	
V _d	Volume Through Orifice (scf)	10	10.0	50	31	50	49	32		
ΔH	Orifice Pressure Differential (in. H ₂ O)	15	15.0	100	49	100	100	49		
T _i	Meter Inlet Temperature (°F)	20	20.0	150	99	150	150	100		
T _o	Meter Outlet Temperature (°F)	25	25.0	212	150	212	212	150		
T _{avg}	Average Meter Box Temperature (°F)			250	212	251	251	212		
V _{meas}	Volume Metered Standardized (scf)			300	299	301	301	250		
Q	Flow Rate (scfm)			350	350	350	350	301		
Y _d	Meter Correction Factor (dimensionless)			400	399	401	401	350		
ΔH@	ΔH yielding 0.75 scfm			500	500	501	501	401		
				600	599	600	600	501		

Airtech Environmental Services

Meter Post Calibration

Average Field Sample Rate (ΔH)	1.300	Date	7/27/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.778	Meter ID	M-9

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	244.50	248.39	252.29
Final Volume (ft ³)	248.39	252.29	256.19
Volume Metered (ft ³)	3.89	3.90	3.90
DGM Inlet Temperature (°F)	82	84	84
DGM Outlet Temperature (°F)	79	80	80
Average DGM Temperature (°F)	80.5	82.0	82.0
Ambient Temperature (°F)	84	83	84
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.90	1.90	1.90
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.722	3.725	3.722
V _{mstd} (ft ³)	3.763	3.762	3.762
Post Test Y _c	0.9890	0.9901	0.9892
Full Test Y _d	0.9891	0.9891	0.9891
% Difference	0.01	-0.11	-0.01
Average % Difference			-0.04

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 9/13/2010

Operator: i. burton

Time	Meter Box ID M-14											Barometric Pressure (in. Hg.)		Results	
	Office Data					Meter Box ΔH@						Meter Box Y _d			
θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	ΔH	T _i	T _o	T _{avg}	V _{meas}	Q	Y _d	ΔH@
5.0	0.3455	22.0	83	2.187	510.30	512.57	2.27	0.63	82	89	86.5	2.169	0.437	1.0083	1.772
5.0	0.3455	22.0	83	2.187	512.57	514.83	2.26	0.63	83	80	81.5	2.175	0.437	1.0054	1.775
5.0	0.3455	22.0	83	2.187	514.83	517.09	2.26	0.63	84	81	82.5	2.171	0.437	1.0072	1.778
5.0	0.4434	20.0	84	2.804	517.40	520.33	2.93	1.05	85	82	83.5	2.813	0.561	0.9969	1.766
5.0	0.4434	20.0	84	2.804	520.33	523.27	2.94	1.05	87	82	84.5	2.817	0.561	0.9964	1.757
5.0	0.4434	20.0	84	2.804	523.27	526.17	2.90	1.05	89	83	86.0	2.771	0.561	1.0119	1.811
5.0	0.5926	18.0	84	3.748	526.60	530.50	3.90	1.9	91	84	87.5	3.724	0.750	1.0062	1.817
5.0	0.5926	18.0	84	3.748	530.50	534.40	3.90	1.9	93	85	89.0	3.714	0.750	1.0090	1.822
5.0	0.5926	18.0	84	3.748	534.40	538.30	3.90	1.9	94	86	90.0	3.707	0.750	1.0108	1.826
5.0	0.7965	15.0	84	5.037	538.90	544.13	5.23	3.4	97	87	92.0	4.972	1.007	1.0130	1.823
5.0	0.7965	15.0	84	5.037	544.13	549.36	5.23	3.4	100	89	94.5	4.950	1.007	1.0176	1.831
5.0	0.7965	15.0	84	5.037	549.36	554.58	5.22	3.4	102	90	96.0	4.927	1.007	1.0223	1.843
													Average	1.0087	1.802

Nomenclature	Vacuum Gauge (in. Hg.)				Thermometers (°F)				Equations	
	Standard	Vacuum Gauge	Ch. No.	Standard	Ch. No.	Ch. No.	Ch. No.	Ch. No.	Equations	
K'			1		1	2	3		$V_{cr} = K' \cdot T_{amb} \cdot \theta$ $(T_{amb} + 460)^{1.5}$	
T _{amb}			32		32	33	32		$V_{meas} = 17.64 \cdot V_d \cdot (P_b + \Delta H / 3.6) / (T_{avg} + 460)$	
V _{cr}			51		51	101	50		$Q = V_{cr} / \theta$	
V _d			100		100	151	100		$Y_d = V_{cr} / V_{meas}$	
ΔH			151		151	213	150		$\Delta H @ = \frac{0.0319 \cdot \Delta H_{cr} \cdot (T_{cr} + 460) \cdot \theta^2}{P_b \cdot V_d^2 \cdot V_{cr}^2}$	
T _i			213		213	251	212			
T _o			251		251	301	250			
T _{avg}			301		301	350	349			
V _{meas}			350		350	400	399			
Q			400		400	500	498			
V _d			500		500	599	598			
ΔH@			600		600					

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.300	Date	7/27/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.754	Meter ID	M-14

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	603.10	606.87	610.63
Final Volume (ft ³)	606.87	610.63	614.40
Volume Metered (ft ³)	3.77	3.76	3.77
DGM Inlet Temperature (°F)	82	83	84
DGM Outlet Temperature (°F)	78	78	78
Average DGM Temperature (°F)	80.0	80.5	81.0
Ambient Temperature (°F)	86	87	88
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.715	3.711	3.708
V _{mstd} (ft ³)	3.649	3.636	3.643
Post Test Y _c	1.0180	1.0207	1.0180
Full Test Y _d	1.0087	1.0087	1.0087
% Difference	-0.92	-1.19	-0.92
Average % Difference			-1.01

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 2/3/2011

Operator: jburton

Meter Box ID M-15				Meter Box $\Delta H @$				Meter Box V_d				Barometric Pressure (in. Hg.)				Results			
Orifice Data				Meter Box Data								Equations							
Time	K'	Vacuum	T_{amb}	V_{or}	$V_{initial}$	V_{final}	V_d	ΔH	T_i	T_o	T_{avg}	V_{meas}	Q	Y_d	$\Delta H @$				
5.0	0.3455	22.0	76	2.201	23.00	25.19	2.19	0.65	71	68	69.5	2.156	0.440	1.0211	1.880				
5.0	0.3455	22.0	76	2.201	25.19	27.38	2.19	0.65	72	68	70.0	2.154	0.440	1.0220	1.882				
5.0	0.3455	22.0	76	2.201	27.38	29.56	2.18	0.65	73	69	71.0	2.140	0.440	1.0287	1.902				
5.0	0.4434	21.0	76	2.825	30.50	33.36	2.86	1.10	73	71	72.0	2.805	0.565	1.0070	1.874				
5.0	0.4434	21.0	76	2.825	33.36	36.22	2.86	1.10	74	72	73.0	2.800	0.565	1.0089	1.878				
5.0	0.4434	21.0	76	2.825	36.22	39.07	2.85	1.10	75	72	73.5	2.788	0.565	1.0134	1.893				
5.0	0.5926	19.0	76	3.775	39.60	43.43	3.83	1.9	77	73	75.0	3.743	0.755	1.0088	1.767				
5.0	0.5926	19.0	76	3.775	43.43	47.22	3.79	1.9	78	73	75.5	3.700	0.755	1.0204	1.807				
5.0	0.5926	19.0	76	3.775	47.22	51.05	3.83	1.9	80	74	77.0	3.729	0.755	1.0126	1.774				
5.0	0.7965	17.0	76	5.075	51.40	55.55	5.15	3.4	83	74	78.5	5.019	1.015	1.0111	1.808				
5.0	0.7965	17.0	76	5.075	56.55	61.68	5.13	3.4	84	75	79.5	4.990	1.015	1.0169	1.826				
5.0	0.7965	17.0	76	5.075	61.68	66.81	5.13	3.4	86	76	81.0	4.976	1.015	1.0197	1.831				
													Average	1.0159	1.843				

Nomenclature	
K'	Critical Orifice Coefficient
T_{amb}	Ambient Temperature (°F)
V_{or}	Volume Through Orifice (scf)
V_d	Gas Meter Volume (ft ³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T_i	Meter Inlet Temperature (°F)
T_o	Meter Outlet Temperature (°F)
T_{avg}	Average Meter Box Temperature (°F)
V_{meas}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y_d	Meter Correction Factor (dimensionless)
$\Delta H @$	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg)		Thermometers (°F)					Equations	
Standard	Vacuum Gauge	Ch. No.	Ch. No.	Ch. No.	Ch. No.	Ch. No.	Equations	
5	5.0	31	32	33	34	35	$V_{or} = K' * F_s * \theta$ $(T_{amb} + 460)^{-0.5}$ $V_{meas} = 17.64 * V_d * (P_b + \Delta H / 13.6)$ $(T_{avg} + 460)$ $Q = V_{or} * \theta$ $Y_d = V_{or} / V_{meas}$ $\Delta H @ = .0319 * \Delta H * (T_{avg} + 460) / \theta * 2$ $P_b * Y_d * 2 * V_{or} * 2$	
10	10.0	49	50	51	52	53		
15	15.0	99	101	102	103	104		
20	20.0	150	151	152	153	154		
25	25.0	212	213	214	215	216		
		250	252	253	254	255		
		300	302	303	304	305		
		350	352	353	354	355		
		400	402	403	404	405		
		500	502	503	504	505		
		600	602	603	604	605		

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.75	Meter ID	M-15

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	174.50	178.25	182.02
Final Volume (ft ³)	178.25	182.02	185.78
Volume Metered (ft ³)	3.75	3.77	3.76
DGM Inlet Temperature (°F)	85	86	87
DGM Outlet Temperature (°F)	79	80	80
Average DGM Temperature (°F)	82.0	83.0	83.5
Ambient Temperature (°F)	85	85	85
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.5885	0.5885	0.5885
Vcr (ft ³)	3.718	3.718	3.718
Vmstd (ft ³)	3.617	3.629	3.616
Post Test Yc	1.0281	1.0246	1.0282
Full Test Yd	1.0159	1.0159	1.0159
% Difference	-1.20	-0.85	-1.21
Average % Difference			-1.09

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.754	Meter ID	M-17

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	267.50	271.27	275.05
Final Volume (ft ³)	271.27	275.05	278.81
Volume Metered (ft ³)	3.77	3.78	3.76
DGM Inlet Temperature (°F)	93	93	94
DGM Outlet Temperature (°F)	86	86	87
Average DGM Temperature (°F)	89.5	89.5	90.5
Ambient Temperature (°F)	85	85	86
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.718	3.718	3.715
V _{mstd} (ft ³)	3.586	3.596	3.570
Post Test Y _c	1.0368	1.0341	1.0405
Full Test Y _d	1.0141	1.0141	1.0141
% Difference	-2.24	-1.97	-2.60
Average % Difference			-2.27

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 11/11/2010

Operator: Iburton

Time	Orifice Data				Meter Box $\Delta H @$				Meter Box V_d				Barometric Pressure (in. Hg.)					
	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _d	V _{final}	V _d	V _d	T _o	T _i	T _{a,g}	T _o	T _i	V _{std}	Q	Y _d	$\Delta H @$
5.0	0.3455	22.0	67	2.220	956.60	2.29	958.89	2.29	0.64	73	70	70	67	73	2.252	0.444	0.9857	1.766
5.0	0.3455	22.0	67	2.220	958.89	2.28	961.17	2.28	0.64	75	72.0	72.0	69	75	2.234	0.444	0.9938	1.788
5.0	0.3455	22.0	67	2.220	961.17	2.29	963.46	2.29	0.64	77	73.5	73.5	70	77	2.237	0.444	0.9922	1.777
5.0	0.4434	20.0	67	2.849	963.70	2.97	966.67	2.97	1.05	79	75.5	75.5	72	79	2.894	0.570	0.9845	1.740
5.0	0.4434	20.0	67	2.849	966.67	2.96	969.63	2.96	1.05	80	76.0	76.0	72	80	2.881	0.570	0.9888	1.753
5.0	0.4434	20.0	67	2.849	969.63	2.96	972.59	2.96	1.05	82	74	78.0	74	82	2.871	0.570	0.9925	1.760
5.0	0.5926	18.0	68	3.804	993.00	4.01	997.01	4.01	1.9	90	85.5	85.5	81	90	3.843	0.761	0.9897	1.759
5.0	0.5926	18.0	68	3.804	997.01	4.00	1001.01	4.00	1.9	93	87.5	87.5	82	93	3.820	0.761	0.9958	1.775
5.0	0.5926	18.0	68	3.804	1001.01	4.04	1005.05	4.04	1.9	94	88.5	88.5	83	94	3.851	0.761	0.9878	1.743
5.0	0.7995	16.0	68	5.132	1005.70	5.35	1011.05	5.35	3.5	95	89.5	89.5	84	95	5.111	1.026	1.0042	1.834
5.0	0.7995	16.0	69	5.127	1011.05	5.31	1016.36	5.31	3.5	98	91.5	91.5	85	98	5.054	1.025	1.0145	1.869
5.0	0.7995	16.0	69	5.127	1016.36	5.33	1021.69	5.33	3.5	99	92.5	92.5	86	99	5.064	1.025	1.0125	1.858
																Average	0.9952	1.785

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (scf)
V _i	Gas Meter Volume (ft³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{std}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
$\Delta H @$	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg.)			Thermometers (°F)			Equations
Standard	Vacuum Gauge	Ch. No.	Standard	Ch. No.	Ch. No.	
5	5.0	32	1	2	3	$V_{cr} = K' \cdot P_b \cdot \theta / (T_{amb} + 460)^{0.5}$ $V_{std} = 17.64 \cdot V_d \cdot (P_b + \Delta H / 13.6) / (T_{a,i} + 460)$ $Q = V_{cr} \cdot \theta$ $Y_d = V_{std} / V_{meas}$ $\Delta H @ = 0.319 \cdot \Delta H \cdot (T_{a,i} + 460) \cdot \theta^2 / (P_b \cdot Y_d^2 \cdot V_{std}^2)$
10	10.0	50	33	31	31	
15	15.0	100	51	50	49	
20	20.0	150	101	100	100	
25	25.0	212	151	151	150	
		250	213	213	213	
		300	251	251	251	
		350	300	301	301	
		400	350	352	351	
		500	400	402	402	
		600	501	502	501	
			601	602	602	

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/8/2011
Highest Field Vacuum (inches Hg)	5	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.766	Meter ID	M-20

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	825.60	829.43	833.26
Final Volume (ft ³)	829.43	833.26	837.08
Volume Metered (ft ³)	3.83	3.83	3.82
DGM Inlet Temperature (°F)	90	90	90
DGM Outlet Temperature (°F)	84	84	84
Average DGM Temperature (°F)	87.0	87.0	87.0
Ambient Temperature (°F)	90	89	88
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.701	3.705	3.708
V _{mstd} (ft ³)	3.660	3.660	3.650
Post Test Y _c	1.0113	1.0122	1.0158
Full Test Y _d	0.9952	0.9952	0.9952
% Difference	-1.62	-1.71	-2.07
Average % Difference			-1.80

Meter Box Full Test Calibration

R-20078

DATE: 7/10/2011

Operator: Joe Ward

Meter Box No: DB30B-0711-2019		Meter Box H@: 0.0000		Meter Box Yd 1.0072		Barometric Pressure: 29.79			
#1	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (pF)		Meter Box Temperature (pF)		
	Initial	Final	Initial	Final	Inlet	Outlet	Avg.	H@	
Q	P	H	Yds	Vf	Vf	Inlet	Outlet	Time	Yd
0.04	-0.30	0.00	1.0000	1.000	1.018	75.0	75.0	26.40	1.0124
0.04	-0.30	0.00	1.0000	1.000	1.019	75.0	75.0	26.38	1.0115
0.02	-0.30	0.00	1.0000	.520	.536	75.0	75.0	22.14	1.0035
0.02	-0.30	0.00	1.0000	.500	.516	75.0	75.0	22.09	1.0041
0.02	-0.30	0.00	1.0000	.500	.523	76.0	76.0	32.22	1.0067
0.02	-0.30	0.00	1.0000	.500	.524	76.0	76.0	32.20	1.0048
AVERAGE									0.0000

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	16.0
20.0	21.0

New Ashtead

Meter Box Full Test Calibration

Operator: Joe Ward

DATE: 7/11/2011

R-20078

Q	P	H	Yds	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (pF)		Meter Box Temperature (pF)		Time	Yd	H@			
				Initial	Final	Initial	Final	Inlet	Outlet	Inlet	Outlet						
				Vf	Vf	Vf	Vf	Avg.	Avg.	Avg.	Avg.						
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.024	.000	1.024	75.0	75.0	75.0	92.0	92.0	30.56	1.0083	0.0000
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.025	0.000	1.025	75.0	75.0	75.0	92.0	92.0	30.48	1.0074	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.518	.000	.518	75.0	75.0	75.0	94.0	94.0	22.10	1.0003	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.518	.000	.518	75.0	75.0	75.0	94.0	94.0	21.90	1.0003	0.0000
0.01	-0.30	0.00	1.0000	0.0	.500	.500	.528	.000	.528	76.0	76.0	76.0	98.0	98.0	38.94	0.9866	0.0000
0.01	-0.30	0.00	1.0000	0.0	.500	.500	.527	.000	.527	76.0	76.0	76.0	98.0	98.0	38.85	0.9884	0.0000
AVERAGE													0.9985	0.9985	0.0000		

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

R-20078

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove
Client: Ashtead Technology Rentals
Job or Reference No.:DB30B-0711-2019

Temperature Scale Used

Fahrenheit
 Celsius

Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.473	Meter ID	R-20078A

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.676	9.411	
Final Volume (l³)	4.676	9.411	14.181	
Volume Metered (l³)	4.676	4.735	4.770	
DGM Temperature (°F)	106	108	112	
Ambient Temperature (°F)	87	88	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.285	4.281	4.281	
Vmstd (l³)	4.303	4.342	4.344	
Post Test Yc	0.99572	0.98589	0.98555	
Full Test Yd	1.0072	1.0072	1.0072	
% Difference	1.14	2.12	2.15	
	Average Difference		1.80	

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.487	Meter ID	R-20078B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.891	9.779	
Final Volume (l³)	4.891	9.779	14.623	
Volume Metered (l³)	4.891	4.888	4.844	
DGM Temperature (°F)	116	116	115	
Ambient Temperature (°F)	87	87	86	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.5	0.5	0.5	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	18.0	18.0	18.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.285	4.285	4.289	
Vmstd (l³)	4.424	4.422	4.389	
Post Test Yc	0.96853	0.96912	0.97712	
Full Test Yd	0.9985	0.9985	0.9985	
% Difference	3.00	2.94	2.14	
	Average Difference		2.69	

Airtech Environmental Services, Inc.
308 Meter Box Full Test Calibration

Date: 1/5/2011

Operator: S. Behanish

Meter Box	M-25 A	Meter Box Y _d	0.9994	Barometric Pressure (in. Hg.)	24.57								
Office Data		Results											
Time	θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{inlet}	V _d	LPM	T _m	V _{m, id}	Q	Y _d	ΔH@
10.0	10.0	0.012	15.0	75	3.610	4.84	4.84	0.48	115	3.654	0.361	0.9880	1.544
10.0	10.0	0.012	15.0	75	3.610	9.63	4.79	0.48	115	3.616	0.361	0.9983	1.560
10.0	10.0	0.012	15.0	75	3.610	14.47	4.84	0.48	116	3.647	0.361	0.9897	1.547
10.0	10.0	0.028	14.0	75	8.422	10.95	10.95	1.10	115	8.281	0.842	1.0171	0.663
10.0	10.0	0.028	14.0	75	8.422	22.03	11.08	1.11	115	8.379	0.842	1.0051	0.675
10.0	10.0	0.028	14.0	75	8.422	33.00	10.97	1.10	116	8.282	0.842	1.0170	0.663
10.0	10.0	0.051	12.5	76	15.326	20.30	20.30	2.03	116	15.368	1.533	0.9973	0.369
10.0	10.0	0.051	12.5	77	15.312	20.30	20.38	2.04	116	15.429	1.531	0.9925	0.367
10.0	10.0	0.051	12.5	78	15.298	40.68	61.10	2.04	116	15.459	1.530	0.9896	0.367
											Average	0.9994	0.866

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (L)
V _d	Gas Meter Volume (L)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{std}	Volume Metered Standardized (L)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
ΔH@	ΔH yielding 0.75 scfm

Vacuum Gauges (in. Hg)		Thermometers (°F)			
Standard	Vacuum Range	CH No.	Gr. No.	Aux 1	Aux 2
5	5.0	33	34	34	34
10	10.0	50	51	51	51
15	15.0	100	102	102	102
20	20.0	150	152	152	152
25	25.0	212	214	214	214
		250	252	252	252
		300	302	302	302
		350	352	352	352
		400	402	402	402
		500	502	502	502
		600	602	602	602

Equations	
$V_{cr} = K' \cdot P_b \cdot \theta$	$(T_{amb} + 460) \wedge 0.5$
$V_{std} = 17.64 \cdot V_d \cdot \frac{(P_b + \Delta H / 13.6)}{(T_{avg} + 460)}$	
$Q = V_{cr} / \theta$	
$Y_d = V_{cr} / V_{std}$	
$\Delta H@ = 0.319 \cdot \frac{\Delta H \cdot (T_{avg} + 460) \cdot \theta \wedge 2}{P_b \cdot Y_d \wedge 2 \cdot V_{cr} \wedge 2}$	

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/12/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4486	Meter ID	M-25-A

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.486	9.072
Final Volume (l)	4.486	9.072	13.869
Volume Metered (l)	4.486	4.586	4.797
DGM Inlet Temperature (°F)	94	99	104
DGM Outlet Temperature (°F)	94	99	104
Average DGM Temperature (°F)	94.0	99.0	104.0
Ambient Temperature (°F)	79	78	79
Elapsed Time (min.)	10	10	10
ΔH (inches H ₂ O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.0120	0.0120	0.0120
Vcr (l)	4.318	4.322	4.318
Vmstd (l)	4.218	4.273	4.430
Post Test Yc	1.0237	1.0113	0.9746
Full Test Yd	0.9994	0.9994	0.9994
% Difference	-2.43	-1.19	2.48
Average % Difference			-0.38

Airtech Environmental Services, Inc.
308 Meter Box Full Test Calibration

Date: 3/29/2011

Operator: Iburton

Meter Box		M-25B		Office Data		Meter Box Y _d		1.0017		Barometric Pressure (in. Hg.)		29.50	
Time		Water Box Data										Results	
θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	LPM	T _m	V _{mead}	Q	Y _d	ΔH@
10.0	0.012	21.0	70	4.354	0.000	4.634	4.634	0.46	100	4.311	0.435	1.0100	1.293
10.0	0.012	21.0	70	4.354	4.634	9.253	4.619	0.46	99	4.305	0.435	1.0115	1.299
10.0	0.012	21.0	70	4.354	9.253	13.827	4.574	0.46	98	4.271	0.435	1.0196	1.322
10.0	0.019	20.0	68	6.907	0.000	7.530	7.530	0.75	97	7.048	0.691	0.9800	0.794
10.0	0.019	20.0	69	6.901	7.530	14.961	7.431	0.74	96	6.968	0.690	0.9904	0.803
10.0	0.019	20.0	70	6.894	14.961	22.428	7.467	0.75	96	7.002	0.689	0.9846	0.806
10.0	0.028	20.0	69	10.169	0.000	10.753	10.753	1.08	96	10.091	1.017	1.0078	0.560
10.0	0.028	20.0	69	10.169	10.753	21.576	10.823	1.08	96	10.157	1.017	1.0012	0.552
10.0	0.028	20.0	68	10.179	21.576	32.297	10.721	1.07	95	10.079	1.018	1.0099	0.557
10.0	0.041	19.0	68	14.905	0.000	15.482	15.482	1.55	95	14.572	1.491	1.0228	0.387
10.0	0.041	19.0	68	14.905	15.482	30.965	15.483	1.55	95	14.573	1.491	1.0228	0.387
10.0	0.041	19.0	68	14.905	30.985	46.450	15.465	1.55	95	14.556	1.491	1.0240	0.388
											Average	1.0017	0.887

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (L)
V _d	Gas Meter Volume (L)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{mead}	Volume Metered Standardized (L)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
ΔH@	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg.)		Thermometers (°F)	
Standard	Volume (Gauge)	Sn. No.	Sn. No.
5	5.0	32	probe
10	10.0	50	32
15	15.0	100	49
20	20.0	152	101
25	25.0	212	152
		250	213
		300	251
		350	301
		400	351
		500	400
		600	501
			599

Equations

$$V_{cr} = K' \cdot E_b \cdot \theta$$

$$V_{mead} = 17.64 \cdot V_d \cdot (P_b + \Delta H / 13.6) / (T_{m,0} + 460) \wedge 0.5$$

$$Q = V_{cr} / \theta$$

$$Y_d = V_{cr} / V_{mead}$$

$$\Delta H@ = .0319 \cdot \Delta H \cdot (T_{m,0} + 460) \cdot \theta \wedge 2 / (P_b \cdot Y_d \wedge 2 \cdot V_{m,0} \wedge 2)$$

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/12/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4864	Meter ID	M-25-B

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.864	9.786
Final Volume (l)	4.864	9.786	14.644
Volume Metered (l)	4.864	4.922	4.858
DGM Inlet Temperature (°F)	113	115	116
DGM Outlet Temperature (°F)	113	115	116
Average DGM Temperature (°F)	113.0	115.0	116.0
Ambient Temperature (°F)	82	81	81
Elapsed Time (min.)	10	10	10
ΔH (inches H₂O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.0120	0.0120	0.0120
Vcr (l)	4.306	4.310	4.310
Vmstd (l)	4.422	4.459	4.393
Post Test Yc	0.9738	0.9666	0.9810
Full Test Yd	1.0017	1.0017	1.0017
% Difference	2.79	3.51	2.07
Average % Difference			2.79

Meter Box Full Test Calibration

M26-

DATE: 7/8/2011

Operator: Joe Ward

Meter Box No: DB30B-0711-2018		Meter Box H@: 0.0000		Meter Box Yd 0.9958		Barometric Pressure: 29.78											
#1	Standard Meter Gas			Meter Box Gas			Std. Meter		Meter Box								
	Q	P	H	Yds	Initial	Final	Vf	Volume (ft ³)	Initial	Final	Vf	Inlet	Outlet	Avg.	Time	Yd	H@
0.04	-0.30	0.00	1.0000	0.0	1.000	1.015	1.015	1.015	.000	1.015	1.015	76.0	76.0	76.0	27.04	0.9951	0.0000
0.04	-0.30	0.00	1.0000	0.0	1.000	1.014	1.014	1.014	0.000	1.014	1.014	76.0	76.0	76.0	27.06	0.9943	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.500	.503	.000	.503	.503	77.0	77.0	77.0	29.91	1.0003	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.500	.502	.000	.502	.502	77.0	77.0	77.0	29.52	1.0023	0.0000
0.03	-0.30	0.00	1.0000	0.0	.500	.500	.500	.507	.000	.507	.507	78.0	78.0	78.0	17.92	0.9924	0.0000
0.03	-0.30	0.00	1.0000	0.0	.500	.500	.500	.508	.000	.508	.508	78.0	78.0	78.0	17.79	0.9905	0.0000
AVERAGE																	
															0.9958	0.0000	

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	16.0
20.0	21.0
25.0	26.0

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.479	Meter ID	M-26 A

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.798	9.564	
Final Volume (l³)	4.798	9.564	14.362	
Volume Metered (l³)	4.798	4.766	4.798	
DGM Temperature (°F)	104	105	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	19.0	19.0	19.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.281	4.285	4.281	
Vmstd (l³)	4.431	4.394	4.408	
Post Test Yc	0.96609	0.97519	0.97123	
Full Test Yd	0.9958	0.9958	0.9958	
% Difference	2.98	2.07	2.47	
	Average Difference		2.51	

Meter Box Full Test Calibration

DATE: 7/10/2011

M-26

Operator: Joe Ward

Meter Box No: DB30B-0711-2018		Meter Box H@: 0.0000		Meter Box Yd 0.9902		Barometric Pressure: 29.75				
#2	Standard Meter Gas		Volume (ft ³)		Std. Meter Temperature (pF)		Time	Yd	H@	
	Initial	Final	Vf	Vf	Inlet	Outlet				
0.01	0.0	.280	.280	.294	75.0	75.0	18.66	0.9834	0.0000	
0.01	0.0	.285	.285	.299	75.0	75.0	18.64	0.9842	0.0000	
0.03	0.0	1.000	1.000	1.033	75.0	75.0	29.14	1.0014	0.0000	
0.03	0.0	1.000	1.000	1.032	75.0	75.0	29.10	1.0023	0.0000	
0.02	0.0	.500	.500	.527	75.0	75.0	22.89	0.9850	0.0000	
0.02	0.0	.500	.500	.527	75.0	75.0	22.80	0.9850	0.0000	
AVERAGE								0.9902	0.0000	0.0000

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.480	Meter ID	M-26 B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.802	9.592	
Final Volume (l³)	4.802	9.592	14.401	
Volume Metered (l³)	4.802	4.790	4.809	
DGM Temperature (°F)	106	108	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
V_{cr} (l³)	4.281	4.285	4.281	
V_{mstd} (l³)	4.419	4.393	4.418	
Post Test Y_c	0.96871	0.97546	0.96901	
Full Test Y_d	0.9902	0.9902	0.9902	
% Difference	2.17	1.49	2.14	
	Average Difference		1.93	



APEX INSTRUMENTS METER CONSOLE CALIBRATION

Meter Console Information

Console Model	XC-260	Console Serial Number	0905008-A	Encoder Model	HEDS-9100-F00
Gas Meter Model	SK25	Totalizer Scale Factor (Initial)	1.0000	Totalizer Model	RED LION
Gas Meter Serial#	8005093	Totalizer Scale Factor (Final)	0.9728	Temp Display Model	JENCO

Calibration Conditions

WTM ID	539783	Calibration Technician	EW	Calibration Date	16-Aug-10
WTM Cal Factor	1.0001	Barometric Pressure	(Pb) 735.5 mm Hg		

Calibration Data

Run Time	Dry Gas Meter			Wet Test Meter			Standardized Volumes				Results	
	Gas Pressure (P _m)	Gas Volume (V _m)	Gas Temp (t _m)	Gas Volume (V _w)	Gas Temp (t _w)	Gas Totalizer Display	Initial SF (V _{m(std)})	Final SF (V _{m(std)})	Totalizer	Wet Test Meter	Totalizer Gamma	Corrected Flowrate
Elapsed (e)	mm H ₂ O	liters	°C	liters	°C	liters	std liters	std liters	std liters	std liters	(Y)	(Q _m)
Run 1 - Initial	0	0	23.33	0.000	780.096	24.0						
Final	0	0	23.33	13.406	793.113	24.0						
Total/Avg	0	0	23.33	13.406	13.017	24.0	12.837	12.488	12.438	12.438	0.9960	-0.004
Run 2 - Initial	0	0	23.33	13.406	793.113	24.0						
Final	0	0	23.33	26.513	805.870	24.0						
Total/Avg	0	0	23.33	13.107	12.757	24.0	12.551	12.209	12.189	12.189	0.9984	-0.002
Run 3 - Initial	0	0	23.33	26.513	805.870	24.0						
Final	0	0	23.33	37.917	816.961	24.0						
Total/Avg	0	0	23.33	11.404	11.091	24.0	10.920	10.623	10.597	10.597	0.9976	-0.002
Run 4 - Initial	0	0	23.33	37.917	816.961	24.0						
Final	0	0	23.89	50.554	829.294	24.0						
Total/Avg	0	0	23.61	12.637	12.333	24.0	12.089	11.760	11.784	11.784	1.0020	0.002
Run 5 - Initial	0	0	23.89	50.554	829.294	24.0						
Final	0	0	23.89	63.375	841.845	24.0						
Total/Avg	0	0	23.89	12.821	12.551	24.0	12.254	11.920	11.993	11.993	1.0060	0.006

Average Meter Calibration Factor Y

1.0000

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using a Precision Wet Test Meter, which in turn was calibrated using the Ashtead Bell Prover #3795, certificate # F-07, which is traceable to the National Bureau of Standards (NIST).

Signature


[Signature]

Date

8/16/10

219075

Electronic Totalizer Y vs Standardized Flowrate



Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Airtech Environmental

Job or Reference No.:DB30B-0711-2018

Temperature Scale Used

- Fahrenheit
 Celsius

- Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/1/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4479	Meter ID	R19075A

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.479	8.984
Final Volume (l)	4.479	8.984	13.48
Volume Metered (l)	4.479	4.51	4.50
DGM Inlet Temperature (°F)	83	84	85
DGM Outlet Temperature (°F)	83	84	85
Average DGM Temperature (°F)	83.0	84.0	85.0
Ambient Temperature (°F)	80	80	80
Elapsed Time (min.)	10	10	10
ΔH (inches H ₂ O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.58	29.58	29.58
Pump Vacuum (inches Hg)	22	22	22
K'	0.0120	0.0120	0.0120
Vcr (l)	4.325	4.325	4.325
Vmstd (l)	4.308	4.325	4.313
Post Test Yc	1.0040	1.0000	1.0030
Full Test Yd	1.000	1.0000	1.0000
% Difference	-0.40	0.00	-0.30
Average % Difference			-0.23



APEX INSTRUMENTS METER CONSOLE CALIBRATION

Meter Console Information			
Console Model	XC-260	Console Serial Number	0905008-B
Encoder Model		Encoder Model	HEDS-9100-F00
Gas Meter Model	SK25	Totalizer Scale Factor (Initial)	1.0000
Gas Meter Serial#	8005094	Totalizer Scale Factor (Final)	0.9756
		Temp Display Model	JENCO

Calibration Conditions			
WTM ID	539784	Calibration Technician	EW
WTM Cal Factor	1.0024	Barometric Pressure (Pb)	735.5 mm Hg
		Calibration Date	16-Aug-10

Calibration Data												Results			
Run Time	Dry Gas Meter				Wet Test Meter				Standardized Volumes				Totalizer Gamma		
	Gas Pressure (P _m) mm H ₂ O	Gas Volume (V _m) liters	Gas Temp (t _m) °C	Totalizer Display	Gas Volume (V _w) liters	Gas Temp (t _w) °C	Totalizer Display	Initial SF (V _{m(stp)}) std liters	Final SF (V _{w(stp)}) std liters	Totalizer Wet Test Meter (V _{w(stp)}) std liters	Initial SF (V _{m(stp)}) std liters	Final SF (V _{w(stp)}) std liters	Final (Y)	Variation (ΔY)	Corrected Flowrate (Q _m)
Run 1 - Initial	0	0	23.89	0.000	195.508	24.0		12.753	12.443	12.422	0.9984	-0.002			2.49
Final	0	0	24.44	13.356	208.479	24.0									
Total/Avg	0	0	24.17	13.356	12.971	24.0									
Run 2 - Initial	0	0	24.44	13.356	208.479	24.0		12.532	12.227	12.208	0.9984	-0.002			2.04
Final	0	0	25.00	26.505	221.226	24.0									
Total/Avg	0	0	24.72	13.149	12.747	24.0									
Run 3 - Initial	0	0	25.00	26.505	221.226	24.0		10.818	10.554	10.552	0.9998	0.000			1.51
Final	0	0	25.00	37.866	232.244	24.0									
Total/Avg	0	0	25.00	11.361	11.018	24.0									
Run 4 - Initial	0	0	25.00	37.866	232.244	24.0		12.292	11.992	12.001	1.0007	0.001			1.00
Final	0	0	25.00	50.775	244.775	24.0									
Total/Avg	0	0	25.00	12.909	12.531	24.0									
Run 5 - Initial	0	0	25.00	50.775	244.775	24.0		13.056	12.738	12.772	1.0027	0.003			0.53
Final	0	0	25.56	64.499	258.111	24.0									
Total/Avg	0	0	25.28	13.724	13.336	24.0									

Average Meter Calibration Factor Y **1.0000**


Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using a Precision Wet Test Meter, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature *[Signature]* Date *8/16/10*

319075

Electronic Totalizer Y vs Standardized Flowrate



Console Serial:

0905008-B

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/1/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4553	Meter ID	R19075B

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.553	9.078
Final Volume (l)	4.553	9.078	13.65
Volume Metered (l)	4.553	4.53	4.57
DGM Inlet Temperature (°F)	87	87	87
DGM Outlet Temperature (°F)	87	87	87
Average DGM Temperature (°F)	87.0	87.0	87.0
Ambient Temperature (°F)	80	80	80
Elapsed Time (min.)	10	10	10
ΔH (inches H ₂ O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.58	29.58	29.58
Pump Vacuum (inches Hg)	21	21	21
K'	0.0120	0.0120	0.0120
Vcr (l)	4.325	4.325	4.325
Vmstd (l)	4.347	4.321	4.366
Post Test Yc	0.9949	1.0011	0.9908
Full Test Yd	1.000	1.0000	1.0000
% Difference	0.51	-0.11	0.92
Average % Difference			0.44

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date January 18, 2011
 Pitot ID AE2-10-1
 Operator A. Kienitz

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.344	NA
Base To Opening Distance - Pb (inches)	0.359	NA
Pa/Dt	1.376	1.05-1.50
Pb/Dt	1.436	1.05-1.50
Angle, $\alpha 1(^{\circ})$	0	10
Angle, $\alpha 2(^{\circ})$	0	10
Angle, B1($^{\circ}$)	2	5
Angle, B1($^{\circ}$)	4	5
Opening to Opening Distance Pa+Pb (inches)	0.703	NA
Angle, Z ($^{\circ}$)	92	NA
z (inches)	0.120	0.125
Angle, W ($^{\circ}$)	89	NA
w (inches)	0.013	0.031
Pitot to Thermocouple Distance, W (inches)	2.50	≥ 2

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly **NO**
 If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle, X (inches)	NA	0.75
Pitot to Sample Probe Distance, Y (inches)	NA	3

Does the Pitot Tube Meet the Above Requirements **Yes**
 Is the Pitot Tube Free of Damage **Yes**

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
 If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/26/11
 Pitot ID AE2-10-2
 Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.367	NA
Base To Opening Distance - Pb (inches)	0.367	NA
Pa/Dt	1.47	1.05-1.50
Pb/Dt	1.47	1.05-1.50
Angle $\alpha 1(^{\circ})$	2.4	10
Angle $\alpha 2(^{\circ})$	1.9	10
Angle B1($^{\circ}$)	2.9	5
Angle B1($^{\circ}$)	3.1	5
Opening to Opening Distance Pa+Pb (inches)	0.734	NA
Angle Z ($^{\circ}$)	1.2	NA
z (inches)	0.0154	0.125
Angle W ($^{\circ}$)	0.3	NA
w (inches)	0.004	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
 If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	NA	0.75 in.
Pitot to Thermocouple Distance (inches)	2.5	2 in.
Pitot to Sample Probe Distance (inches)	5.5	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
 Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
 If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/26/11
 Pitot ID AE2-12-2
 Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.37	NA
Base To Opening Distance - Pb (inches)	0.37	NA
Pa/Dt	1.48	1.05-1.50
Pb/Dt	1.48	1.05-1.50
Angle $\alpha 1(^{\circ})$	1.1	10
Angle $\alpha 2(^{\circ})$	1.2	10
Angle B1($^{\circ}$)	1.5	5
Angle B1($^{\circ}$)	1.3	5
Opening to Opening Distance Pa+Pb (inches)	0.740	NA
Angle Z ($^{\circ}$)	2.2	NA
z (inches)	0.028	0.125
Angle W ($^{\circ}$)	0.6	NA
w (inches)	0.008	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
 If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	NA	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	6.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
 Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
 If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc. S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE-5-6-1
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.373	NA
Base To Opening Distance - Pb (inches)	0.373	NA
Pa/Dt	1.49	1.05-1.50
Pb/Dt	1.49	1.05-1.50
Angle $\alpha 1$ (°)	2.4	10
Angle $\alpha 2$ (°)	0.7	10
Angle B1 (°)	2.3	5
Angle B1 (°)	2.3	5
Opening to Opening Distance Pa+Pb (inches)	0.746	NA
Angle Z (°)	1.6	NA
z (inches)	0.0208	0.125
Angle W (°)	0.3	NA
w (inches)	0.004	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2.25	2 in.
Pitot to Sample Probe Distance (inches)	5.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE-5-6-7
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.362	NA
Base To Opening Distance - Pb (inches)	0.362	NA
Pa/Dt	1.45	1.05-1.50
Pb/Dt	1.45	1.05-1.50
Angle $\alpha 1$ (°)	0.5	10
Angle $\alpha 2$ (°)	1	10
Angle B1 (°)	3	5
Angle B1 (°)	4	5
Opening to Opening Distance Pa+Pb (inches)	0.744	NA
Angle Z (°)	2	NA
z (inches)	0.0260	0.125
Angle W (°)	0.5	NA
w (inches)	0.006	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	5.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc. S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE5-6-11
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.37	NA
Base To Opening Distance - Pb (inches)	0.37	NA
Pa/Dt	1.48	1.05-1.50
Pb/Dt	1.48	1.05-1.50
Angle $\alpha 1$ (°)	0.7	10
Angle $\alpha 2$ (°)	1	10
Angle B1 (°)	2.2	5
Angle B1 (°)	1	5
Opening to Opening Distance Pa+Pb (inches)	0.740	NA
Angle Z (°)	1.3	NA
z (inches)	0.017	0.125
Angle W (°)	0.6	NA
w (inches)	0.008	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly? Yes

If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2.5	2 in.
Pitot to Sample Probe Distance (inches)	6.25	3 in.

Does the Pitot Tube Meet the Above Requirements? Yes

Is the Pitot Tube Free of Damage? Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date January 17, 2011
Pitot ID AE5-10-1
Operator A. Kienitz

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.363	NA
Base To Opening Distance - Pb (inches)	0.359	NA
Pa/Dt	1.452	1.05-1.50
Pb/Dt	1.436	1.05-1.50
Angle, $\alpha 1(^{\circ})$	2	10
Angle, $\alpha 2(^{\circ})$	2	10
Angle, B1($^{\circ}$)	2	5
Angle, B1($^{\circ}$)	4	5
Opening to Opening Distance Pa+Pb (inches)	0.722	NA
Angle, Z ($^{\circ}$)	89	NA
z (inches)	0.015	0.125
Angle, W ($^{\circ}$)	91	NA
w (inches)	0.010	0.031
Pitot to Thermocouple Distance, W (inches)	2.125	≥ 2

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly **Yes**
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle, X (inches)	0.75	0.75
Pitot to Sample Probe Distance, Y (inches)	4.25	3

Does the Pitot Tube Meet the Above Requirements **Yes**
Is the Pitot Tube Free of Damage **Yes**

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/26/11
Pitot ID AE-5-10-3
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.357	NA
Base To Opening Distance - Pb (inches)	0.357	NA
Pa/Dt	1.43	1.05-1.50
Pb/Dt	1.43	1.05-1.50
Angle $\alpha 1$ (°)	2	10
Angle $\alpha 2$ (°)	0.8	10
Angle B1 (°)	2.5	5
Angle B1 (°)	3.9	5
Opening to Opening Distance Pa+Pb (inches)	0.714	NA
Angle Z (°)	2.5	NA
z (inches)	0.0311	0.125
Angle W (°)	0.2	NA
w (inches)	0.002	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2.5	2 in.
Pitot to Sample Probe Distance (inches)	4.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/26/11
Pitot ID AE-5-10-4
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.358	NA
Base To Opening Distance - Pb (inches)	0.358	NA
Pa/Dt	1.43	1.05-1.50
Pb/Dt	1.43	1.05-1.50
Angle $\alpha 1$ (°)	2.1	10
Angle $\alpha 2$ (°)	0.1	10
Angle B1 (°)	0.2	5
Angle B1 (°)	0.2	5
Opening to Opening Distance Pa+Pb (inches)	0.716	NA
Angle Z (°)	2.2	NA
z (inches)	0.0275	0.125
Angle W (°)	0.5	NA
w (inches)	0.006	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	5.5	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc. S-Type Pitot Tube Inspection Form

Date January 17, 2011
 Pitot ID AE5-10-5
 Operator A. Kienitz

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.332	NA
Base To Opening Distance - Pb (inches)	0.340	NA
Pa/Dt	1.328	1.05-1.50
Pb/Dt	1.360	1.05-1.50
Angle, $\alpha 1(^{\circ})$	2	10
Angle, $\alpha 2(^{\circ})$	3	10
Angle, B1($^{\circ}$)	3	5
Angle, B1($^{\circ}$)	5	5
Opening to Opening Distance Pa+Pb (inches)	0.672	NA
Angle, Z ($^{\circ}$)	90	NA
z (inches)	0.000	0.125
Angle, W ($^{\circ}$)	91	NA
w (inches)	0.005	0.031
Pitot to Thermocouple Distance, W (inches)	2.00	≥ 2

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly **YES**

If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle, X (inches)	0.75	0.75
Pitot to Sample Probe Distance, Y (inches)	4.25	3

Does the Pitot Tube Meet the Above Requirements **Yes**

Is the Pitot Tube Free of Damage **Yes**

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned

If No to Either, then the Pitot Tube Must be Calibrated



Pitot Tube Calibration

Probe Type: M5 with S-Type Pitot I.D. Number: M-10-1
 Project Number: _____

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: _____ Pyrometer I.D. No: _____ Units: *F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient					
2	200°F-250°F					

* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = -1$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = -2$	$\beta 2 = -1$	$\leq 5^\circ$	YES
$\gamma = 2$	$\theta = 0$	None	N/A
$A = 0.706$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.353$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.412$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.025$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.000$ inches	$\leq 0.03125"$	YES

Pitot Cp= 0.84 according to 40 CFR 60 section 10.1

Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1" O.D.)		
Tip to Static	$\geq 6^\circ$ O.D.		
Static to Bend	$\geq 8^\circ$ O.D.		

Pitot Cp=

Airtech Environmental Services, Inc.
Nozzle Calibration Form

Client	WKE	Job No.	3648
Plant	Coleman Station	Hansville, Ky	

	Nozzle 1	Nozzle 2	Nozzle 3
Date	7-7-11	7-7-11	
Nozzle ID	.248	.249	
Operator	C.S	C.S	
Test Location	Stack	Stack	
Run Number (s)	1-3 M-29	1-3 M-26	
Diameter 1	.248	.250	
Diameter 2	.248	.249	
Diameter 3	.249	.249	
Average	.248	.249	

	Nozzle 4	Nozzle 5	Nozzle 6
Date			
Nozzle ID			
Operator			
Test Location			
Run Number (s)			
Diameter 1			
Diameter 2			
Diameter 3			
Average			

Notes:

Measurements must be made to the nearest 0.001 inches.

Three different diameters should be measured.

The difference between the high and low measurement must be less than 0.004 inches.

Signed



Date

7-7-11