

Calibration Data

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.772	Meter ID	M-16

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	627.50	631.36	635.21
Final Volume (ft ³)	631.36	635.21	639.08
Volume Metered (ft ³)	3.86	3.85	3.87
DGM Inlet Temperature (°F)	86	87	88
DGM Outlet Temperature (°F)	82	82	82
Average DGM Temperature (°F)	84.0	84.5	85.0
Ambient Temperature (°F)	88	87	87
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.708	3.711	3.711
V _{mstd} (ft ³)	3.709	3.696	3.712
Post Test Y _c	0.9998	1.0042	0.9999
Full Test Y _d	0.9907	0.9907	0.9907
% Difference	-0.91	-1.36	-0.93
Average % Difference			-1.07

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.754	Meter ID	M-17

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	267.50	271.27	275.05
Final Volume (ft ³)	271.27	275.05	278.81
Volume Metered (ft ³)	3.77	3.78	3.76
DGM Inlet Temperature (°F)	93	93	94
DGM Outlet Temperature (°F)	86	86	87
Average DGM Temperature (°F)	89.5	89.5	90.5
Ambient Temperature (°F)	85	85	86
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.718	3.718	3.715
V _{mstd} (ft ³)	3.586	3.596	3.570
Post Test Y _c	1.0368	1.0341	1.0405
Full Test Y _d	1.0141	1.0141	1.0141
% Difference	-2.24	-1.97	-2.60
Average % Difference			-2.27

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/8/2011
Highest Field Vacuum (inches Hg)	5	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.766	Meter ID	M-20

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	825.60	829.43	833.26
Final Volume (ft ³)	829.43	833.26	837.08
Volume Metered (ft ³)	3.83	3.83	3.82
DGM Inlet Temperature (°F)	90	90	90
DGM Outlet Temperature (°F)	84	84	84
Average DGM Temperature (°F)	87.0	87.0	87.0
Ambient Temperature (°F)	90	89	88
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.701	3.705	3.708
V _{mstd} (ft ³)	3.660	3.660	3.650
Post Test Y _c	1.0113	1.0122	1.0158
Full Test Y _d	0.9952	0.9952	0.9952
% Difference	-1.62	-1.71	-2.07
Average % Difference			-1.80

Meter Box Full Test Calibration

DATE: 7/15/2011

Operator: Joe Ward

Meter Box No: 2142		M-27		Meter Box H@: 1.9109		Meter Box Yd 1.0034		Barometric Pressure: 29.82						
Standard Meter Gas Volume				Meter Box Gas Volume (ft ³)		Std. Meter Temperature (PF)		Meter Box Temperature (PF)						
Q	P	H	Yds	Initial	Final	Vf	Inlet	Outlet	Avg.	Time	Yd	H@		
0.93	-0.60	3.00	1.0000	0.0	5.000	5.000	64.130	5.088	74.0	74.0	80.0	5.32	1.0082	1.9186
0.92	-0.60	3.00	1.0000	0.0	5.005	5.005	64.130	5.101	74.0	74.0	80.0	5.35	1.0066	1.9364
0.38	-0.30	0.50	1.0000	0.0	5.000	5.000	72.320	5.070	74.0	74.0	79.0	13.01	1.0002	1.9158
0.38	-0.30	0.50	1.0000	0.0	5.005	5.005	77.390	5.081	74.0	74.0	79.0	13.09	0.9990	1.9356
0.66	-0.40	1.50	1.0000	0.0	5.000	5.000	93.758	5.092	74.0	74.0	79.0	7.45	1.0022	1.8847
0.66	-0.40	1.50	1.0000	0.0	6.965	6.965	98.850	7.079	74.0	74.0	79.0	10.35	1.0042	1.8746
AVERAGE											1.0034	1.9109		

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0
25.0	25.0

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Airtech Environmental

Job or Reference No.:2142

M-27

Temperature Scale Used Fahrenheit

Full Test

Celsius

Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Airtech Environmental Services

Meter Post Calibration

Average Field Sample Rate (ΔH)	1.750	Date	8/2/2011
Highest Field Vacuum (inches Hg)	13	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.792	Meter ID	M-27

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	534.00	537.96	541.91
Final Volume (ft ³)	537.96	541.91	545.87
Volume Measured (ft ³)	3.96	3.95	3.96
DGM Inlet Temperature (°F)	87	88	89
DGM Outlet Temperature (°F)	85	85	86
Average DGM Temperature (°F)	86.0	86.5	87.5
Ambient Temperature (°F)	88	88	89
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	2.00	2.00	2.00
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.708	3.708	3.705
V _{mstd} (ft ³)	3.793	3.780	3.783
Post Test Yc	0.9776	0.9810	0.9794
Full Test Yd	1.0034	1.0034	1.0034
% Difference	2.57	2.23	2.39
Average % Difference			2.40

Meter Box Full Test Calibration

DATE: 7/15/2011

Operator: Joe Ward

Meter Box No: 2143		M-28		Meter Box H@: 1.8295		Meter Box Yd 0.9976		Barometric Pressure: 29.79							
Standard Meter Gas		Volume		Meter Box Gas		Std. Meter		Meter Box							
Q	P	H	Yds	Initial	Final	Vf	Inlet	Outlet	Avg.	Time	Yd	H@			
0.96	-0.70	3.00	1.0000	0.0	5.000	5.000	71.639	76.825	5.186	74.0	74.0	91.0	5.15	1.0039	1.7799
0.95	-0.70	3.00	1.0000	0.0	5.000	5.000	76.825	82.002	5.177	74.0	74.0	91.0	5.18	1.0057	1.8007
0.67	-0.60	1.50	1.0000	0.0	5.005	5.005	88.458	93.637	5.179	74.0	74.0	91.0	7.32	0.9978	1.7944
0.68	-0.60	1.50	1.0000	0.0	5.005	5.005	93.637	98.827	5.190	74.0	74.0	91.0	7.28	0.9957	1.7748
0.38	-0.40	0.50	1.0000	0.0	5.000	5.000	102.295	107.455	5.160	74.0	74.0	86.0	13.07	0.9902	1.9213
0.38	-0.40	0.50	1.0000	0.0	5.005	5.005	107.455	112.609	5.154	74.0	74.0	86.0	13.03	0.9924	1.9057
AVERAGE											0.9976	1.8295			

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0
25.0	25.0

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Airtech Environmental

Job or Reference No.:2143

Temperature Scale Used Fahrenheit

Full Test

Celsius

Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	2.250	Date	8/2/2011
Highest Field Vacuum (inches Hg)	9	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.8	Meter ID	M-28

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	281.00	285.00	289.00
Final Volume (ft ³)	285.00	289.00	293.00
Volume Metered (ft ³)	4.00	4.00	4.00
DGM Inlet Temperature (°F)	88	89	90
DGM Outlet Temperature (°F)	85	86	86
Average DGM Temperature (°F)	86.5	87.5	88.0
Ambient Temperature (°F)	91	91	91
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.90	1.90	1.90
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
Vcr (ft ³)	3.698	3.698	3.698
Vmstd (ft ³)	3.827	3.820	3.816
Post Test Yc	0.9663	0.9681	0.9690
Full Test Yd	0.9976	0.9976	0.9976
% Difference	3.14	2.96	2.87
Average % Difference			2.99

Airtech Environmental Services, Inc.
30B Meter Box Full Test Calibration

Date: 1/5/2011

Operator: S. Behanish

Meter Box		M-25 A		Meter Box Y _d		0.9994		Barometric Pressure (in. Hg.)		24.57				
Onflow Data						Meter Box Data								
Time	θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{inlet}	V _{final}	V _d	LPM	T _{in}	V _{mead}	Q	Y _d	ΔH@
10.0	10.0	0.012	15.0	75	3.610	0.00	4.84	4.84	0.48	115	3.654	0.361	0.9880	1.544
10.0	10.0	0.012	15.0	75	3.610	4.84	9.63	4.79	0.48	115	3.616	0.361	0.9983	1.560
10.0	10.0	0.012	15.0	75	3.610	9.63	14.47	4.84	0.48	116	3.647	0.361	0.9897	1.547
10.0	10.0	0.028	14.0	75	8.422	0.00	10.95	10.95	1.10	115	8.281	0.842	1.0171	0.683
10.0	10.0	0.028	14.0	75	8.422	10.95	22.03	11.08	1.11	115	8.379	0.842	1.0051	0.675
10.0	10.0	0.028	14.0	75	8.422	22.03	33.00	10.97	1.10	116	8.282	0.842	1.0170	0.683
10.0	10.0	0.051	12.5	76	15.326	0.00	20.30	20.30	2.03	116	15.368	1.533	0.9973	0.369
10.0	10.0	0.051	12.5	77	15.312	20.30	40.68	20.38	2.04	116	15.429	1.531	0.9925	0.367
10.0	10.0	0.051	12.5	78	15.298	40.68	61.10	20.42	2.04	116	15.459	1.530	0.9896	0.367
												Average	0.9994	0.866

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (L)
V _d	Gas Meter Volume (L)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{mead}	Volume Metered Standardized (L)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
ΔH@	ΔH yielding 0.75 scfm

Vacuum Gauge		Thermometers (°F)	
Standard	Scale	SR No.	CR No.
5	5.0	Stack	Aux 1
10	10.0	33	34
15	15.0	50	51
20	20.0	101	102
25	25.0	151	152
		213	214
		251	252
		300	302
		350	352
		400	402
		500	502
		601	602

$$V_{cr} = K' * P_o * \theta$$

$$V_{mead} = 17.64 * V_d * (P_o + \Delta H / 13.6) / (T_{avg} + 460) ^ 0.5$$

$$Q = V_{cr} / \theta$$

$$Y_d = V_{cr} / V_{mead}$$

$$\Delta H@ = .0319 * \Delta H * (T_{avg} + 460) * \theta ^ 2 / (P_o * Y_d ^ 2 * V_{cr} ^ 2)$$

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/12/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4486	Meter ID	M-25-A

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.486	9.072
Final Volume (l)	4.486	9.072	13.869
Volume Metered (l)	4.486	4.586	4.797
DGM Inlet Temperature (°F)	94	99	104
DGM Outlet Temperature (°F)	94	99	104
Average DGM Temperature (°F)	94.0	99.0	104.0
Ambient Temperature (°F)	79	78	79
Elapsed Time (min.)	10	10	10
ΔH (inches H ₂ O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.0120	0.0120	0.0120
Vcr (l)	4.318	4.322	4.318
Vmstd (l)	4.218	4.273	4.430
Post Test Yc	1.0237	1.0113	0.9746
Full Test Yd	0.9994	0.9994	0.9994
% Difference	-2.43	-1.19	2.48
Average % Difference			-0.38

Airtech Environmental Services, Inc.
30B Meter Box Full Test Calibration

Date: 3/29/2011

Operator: i_burton

Meter Box		M-25B				Meter Box Y _d				1.0017				Barometric Pressure (in. Hg.)				Results							
Time		Orifice Data												Meter Box Data											
θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	LPM	V _{std}	T _{in}	V _{std}	Q	Y _d	ΔH@											
10.0	0.012	21.0	70	4.354	0.000	4.634	4.634	0.46		100	4.311	0.435	1.0100	1.293											
10.0	0.012	21.0	70	4.354	4.634	9.253	4.619	0.46		99	4.305	0.435	1.0115	1.299											
10.0	0.012	21.0	70	4.354	9.253	13.827	4.574	0.46		98	4.271	0.435	1.0196	1.322											
10.0	0.019	20.0	68	6.907	0.000	7.530	7.530	0.75		97	7.048	0.691	0.9800	0.794											
10.0	0.019	20.0	69	6.901	7.530	14.961	7.431	0.74		96	6.968	0.690	0.9904	0.803											
10.0	0.019	20.0	70	6.894	14.961	22.428	7.467	0.75		96	7.002	0.689	0.9846	0.806											
10.0	0.028	20.0	69	10.169	0.000	10.753	10.753	1.08		96	10.091	1.017	1.0078	0.560											
10.0	0.028	20.0	69	10.169	10.753	21.576	10.823	1.08		96	10.157	1.017	1.0012	0.552											
10.0	0.028	20.0	68	10.179	21.576	32.297	10.721	1.07		95	10.079	1.018	1.0099	0.557											
10.0	0.041	19.0	68	14.905	0.000	15.482	15.482	1.55		95	14.572	1.491	1.0228	0.387											
10.0	0.041	19.0	68	14.905	15.482	30.965	15.483	1.55		95	14.573	1.491	1.0228	0.387											
10.0	0.041	19.0	68	14.905	30.985	46.450	15.485	1.55		95	14.556	1.491	1.0240	0.388											
												Average	1.0017	0.887											

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (L)
V _d	Gas Meter Volume (L)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{std}	Volume Metered Standardized (L)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
ΔH@	ΔH yielding 0.75 scfm

Vacuum Gauge		Thermometers		Equations	
Std. No.	Standard	Chr. No.	Chr. No.		
5	5.0	1	probe	$V_{cr} = K' * P_b * \theta$	
10	10.0	32	32	$V_{std} = 17.64 * V_d * (P_b + \Delta H / 13.6) / (T_{avg} + 460)$	
15	15.0	50	49	$Q = V_{cr} / \theta$	
20	20.0	100	101	$Y_d = V_{cr} / V_{std}$	
25	25.0	152	152	$\Delta H@ = .0319 * \Delta H * (T_{avg} + 460) * \theta^2 / P_b * V_d^2 * V_{cr}^2$	
		212	213		
		250	251		
		300	301		
		350	351		
		400	401		
		500	501		
		600	601		
			599		

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (lpm)	0.500	Date	8/12/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.4864	Meter ID	M-25-B

	Run 1	Run 2	Run 3
Initial Volume (l)	0.00	4.864	9.786
Final Volume (l)	4.864	9.786	14.644
Volume Metered (l)	4.864	4.922	4.858
DGM Inlet Temperature (°F)	113	115	116
DGM Outlet Temperature (°F)	113	115	116
Average DGM Temperature (°F)	113.0	115.0	116.0
Ambient Temperature (°F)	82	81	81
Elapsed Time (min.)	10	10	10
ΔH (inches H ₂ O)	0.40	0.40	0.40
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.0120	0.0120	0.0120
Vcr (l)	4.306	4.310	4.310
Vmstd (l)	4.422	4.459	4.393
Post Test Yc	0.9738	0.9666	0.9810
Full Test Yd	1.0017	1.0017	1.0017
% Difference	2.79	3.51	2.07
Average % Difference			2.79

Meter Box Full Test Calibration

M26-

DATE: 7/8/2011

Operator: Joe Ward

Meter Box No: DB30B-0711-2018		Meter Box H@: 0.0000		Meter Box Yd 0.9958		Barometric Pressure: 29.78							
#1	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (pF)		Meter Box Temperature (pF)						
	Initial	Final	Initial	Final	Inlet	Outlet	Inlet	Outlet					
Q	P	H	Yds	Vf	Vf	Inlet	Outlet	Avg.	Time	Yd	H@		
0.04	-0.30	0.00	1.0000	1.000	1.015	76.0	76.0	76.0	81.0	81.0	27.04	0.9951	0.0000
0.04	-0.30	0.00	1.0000	1.000	1.014	76.0	76.0	76.0	80.0	80.0	27.06	0.9943	0.0000
0.02	-0.30	0.00	1.0000	0.500	0.503	77.0	77.0	77.0	80.0	80.0	29.91	1.0003	0.0000
0.02	-0.30	0.00	1.0000	0.500	0.502	77.0	77.0	77.0	80.0	80.0	29.52	1.0023	0.0000
0.03	-0.30	0.00	1.0000	0.500	0.507	78.0	78.0	78.0	81.0	81.0	17.92	0.9924	0.0000
0.03	-0.30	0.00	1.0000	0.500	0.508	78.0	78.0	78.0	81.0	81.0	17.79	0.9905	0.0000
AVERAGE										0.9958	0.0000		

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	16.0
20.0	21.0
25.0	26.0

Meter Box Full Test Calibration

DATE: 7/10/2011 M-26

Operator: Joe Ward

Meter Box No: DB30B-0711-2018		Meter Box H@: 0.0000		Meter Box Yd 0.9902		Barometric Pressure: 29.75						
#2	Standard Meter Gas		Meter Box Gas		Std. Meter Temperature (pF)		Meter Box Temperature (pF)					
	Initial	Final	Initial	Final	Inlet	Outlet	Inlet	Outlet				
0.01	0.0	.280	.280	.294	.294	75.0	75.0	92.0	92.0	18.66	0.9834	0.0000
0.01	0.0	.285	.285	.299	.299	75.0	75.0	92.0	92.0	18.64	0.9842	0.0000
0.03	0.0	1.000	1.000	1.033	1.033	75.0	75.0	93.0	93.0	29.14	1.0014	0.0000
0.03	0.0	1.000	1.000	1.032	1.032	75.0	75.0	93.0	93.0	29.10	1.0023	0.0000
0.02	0.0	.500	.500	.527	.527	75.0	75.0	95.0	95.0	22.89	0.9850	0.0000
0.02	0.0	.500	.500	.527	.527	75.0	75.0	95.0	95.0	22.80	0.9850	0.0000
AVERAGE												
											0.9902	0.0000

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Airtech Environmental

Job or Reference No.:DB30B-0711-2018

Temperature Scale Used

- Fahrenheit
 Celsius

- Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.479	Meter ID	M-26 A

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.798	9.564	
Final Volume (l³)	4.798	9.564	14.362	
Volume Metered (l³)	4.798	4.766	4.798	
DGM Temperature (°F)	104	105	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	19.0	19.0	19.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.281	4.285	4.281	
Vmstd (l³)	4.431	4.394	4.408	
Post Test Yc	0.96609	0.97519	0.97123	
Full Test Yd	0.9958	0.9958	0.9958	
% Difference	2.98	2.07	2.47	
	Average Difference		2.51	

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.480	Meter ID	M-26 B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.802	9.592	
Final Volume (l³)	4.802	9.592	14.401	
Volume Metered (l³)	4.802	4.790	4.809	
DGM Temperature (°F)	106	108	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.281	4.285	4.281	
Vmstd (l³)	4.419	4.393	4.418	
Post Test Yc	0.96871	0.97546	0.96901	
Full Test Yd	0.9902	0.9902	0.9902	
% Difference	2.17	1.49	2.14	
	Average Difference		1.93	

Meter Box Full Test Calibration

DATE: 7/10/2011
 Operator: Joe Ward

Meter Box No: DB30B-0711-2019		Meter Box H@: 0.0000		Meter Box Yd 1.0072		Barometric Pressure: 29.79											
#1	Standard Meter Gas Volume		Meter Box Gas Volume (ft.)		Std. Meter Temperature (pF)		Time	Yd	H@								
	P	H	Yds	Initial	Final	Vf				Inlet	Outlet	Avg.					
0.04	-0.30	0.00	1.000	1.000	1.018	1.018	75.0	75.0	75.0	91.0	91.0	91.0	26.40	1.0124	0.0000		
0.04	-0.30	0.00	1.000	1.000	1.019	1.019	75.0	75.0	75.0	91.0	91.0	91.0	26.38	1.0115	0.0000		
0.02	-0.30	0.00	1.000	0.520	.520	.536	75.0	75.0	75.0	93.0	93.0	93.0	22.14	1.0035	0.0000		
0.02	-0.30	0.00	1.000	0.500	.500	.516	75.0	75.0	75.0	94.0	94.0	94.0	22.09	1.0041	0.0000		
0.02	-0.30	0.00	1.000	0.500	.500	.523	76.0	76.0	76.0	104.0	104.0	104.0	32.22	1.0067	0.0000		
0.02	-0.30	0.00	1.000	0.500	.500	.524	76.0	76.0	76.0	104.0	104.0	104.0	32.20	1.0048	0.0000		
AVERAGE														1.0072		0.0000	

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	16.0
20.0	21.0

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

New Ashtead

R-20078

Meter Box Full Test Calibration

DATE: 7/11/2011 Operator: Joe Ward

Meter Box No: DB30B-0711-2019		Meter Box H@:		Meter Box Gas		Meter Box Yd		Barometric Pressure:											
		0.0000		0.9985		0.9985		29.69											
#2	Standard Meter Gas		Volume		Meter Box Gas		Std. Meter		Temperature (PF)		Time	Yd	H@						
	Q	P	H	Yds	Initial	Final	Vf	Initial	Final	Vf				Inlet	Outlet	Avg.			
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.024	.000	1.024	1.024	75.0	75.0	75.0	92.0	92.0	92.0	30.56	1.0083	0.0000
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.025	0.000	1.025	1.025	75.0	75.0	75.0	92.0	92.0	92.0	30.48	1.0074	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.518	.000	.518	.518	75.0	75.0	75.0	94.0	94.0	94.0	22.10	1.0003	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.518	.000	.518	.518	75.0	75.0	75.0	94.0	94.0	94.0	21.90	1.0003	0.0000
0.01	-0.30	0.00	1.0000	0.0	.500	.500	.528	.000	.528	.528	76.0	76.0	76.0	98.0	98.0	98.0	38.94	0.9866	0.0000
0.01	-0.30	0.00	1.0000	0.0	.500	.500	.527	.000	.527	.527	76.0	76.0	76.0	98.0	98.0	98.0	38.85	0.9884	0.0000
AVERAGE																			
										0.9985		0.9985		0.9866		0.9884		0.0000	

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

R-20078

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove
Client: Ashtead Technology Rentals
Job or Reference No.: DB30B-0711-2019

Temperature Scale Used

Fahrenheit
 Celsius

Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.473	Meter ID	R-20078A

	Run 1	Run 2	Run 3	
Initial Volume (l ³)	0.000	4.676	9.411	
Final Volume (l ³)	4.676	9.411	14.181	
Volume Metered (l ³)	4.676	4.735	4.770	
DGM Temperature (°F)	106	108	112	
Ambient Temperature (°F)	87	88	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
Vcr (l ³)	4.285	4.281	4.281	
Vmstd (l ³)	4.303	4.342	4.344	
Post Test Yc	0.99572	0.98589	0.98555	
Full Test Yd	1.0072	1.0072	1.0072	
% Difference	1.14	2.12	2.15	
	Average Difference		1.80	

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.487	Meter ID	R-20078B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.891	9.779	
Final Volume (l³)	4.891	9.779	14.623	
Volume Metered (l³)	4.891	4.888	4.844	
DGM Temperature (°F)	116	116	115	
Ambient Temperature (°F)	87	87	86	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.5	0.5	0.5	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	18.0	18.0	18.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.285	4.285	4.289	
Vmstd (l³)	4.424	4.422	4.389	
Post Test Yc	0.96853	0.96912	0.97712	
Full Test Yd	0.9985	0.9985	0.9985	
% Difference	3.00	2.94	2.14	
	Average Difference		2.69	

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE5-6-2
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.356	NA
Base To Opening Distance - Pb (inches)	0.356	NA
Pa/Dt	1.42	1.05-1.50
Pb/Dt	1.42	1.05-1.50
Angle α1 (°)	2.7	10
Angle α2 (°)	2.6	10
Angle B1 (°)	4	5
Angle B1 (°)	0.6	5
Opening to Opening Distance Pa+Pb (inches)	0.712	NA
Angle Z (°)	0.4	NA
z (inches)	0.0050	0.125
Angle W (°)	0	NA
w (inches)	0.000	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	6.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE-5-6-4WC
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.329	NA
Base To Opening Distance - Pb (inches)	0.329	NA
Pa/Dt	1.32	1.05-1.50
Pb/Dt	1.32	1.05-1.50
Angle $\alpha 1$ (°)	2.3	10
Angle $\alpha 2$ (°)	1.7	10
Angle B1 (°)	3.9	5
Angle B1 (°)	3.5	5
Opening to Opening Distance Pa+Pb (inches)	0.658	NA
Angle Z (°)	2.5	NA
z (inches)	0.0287	0.125
Angle W (°)	0.3	NA
w (inches)	0.003	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	5	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
 Pitot ID AE5-6-11
 Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.37	NA
Base To Opening Distance - Pb (inches)	0.37	NA
Pa/Dt	1.48	1.05-1.50
Pb/Dt	1.48	1.05-1.50
Angle $\alpha 1$ (°)	0.7	10
Angle $\alpha 2$ (°)	1	10
Angle B1 (°)	2.2	5
Angle B1 (°)	1	5
Opening to Opening Distance Pa+Pb (inches)	0.740	NA
Angle Z (°)	1.3	NA
z (inches)	0.017	0.125
Angle W (°)	0.6	NA
w (inches)	0.008	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly?

If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2.5	2 in.
Pitot to Sample Probe Distance (inches)	6.25	3 in.

Does the Pitot Tube Meet the Above Requirements?

Is the Pitot Tube Free of Damage?

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned

If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date January 26, 2011
Pitot ID AE5-12-3
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.338	NA
Base To Opening Distance - Pb (inches)	0.338	NA
Pa/Dt	1.35	1.05-1.50
Pb/Dt	1.35	1.05-1.50
Angle $\alpha 1$ (°)	1.1	10
Angle $\alpha 2$ (°)	1.1	10
Angle B1 (°)	2.1	5
Angle B2 (°)	3.5	5
Opening to Opening Distance Pa+Pb (inches)	0.676	NA
Angle Z (°)	4.3	NA
z (inches)	0.05	0.125
Angle W (°)	0.9	NA
w (inches)	0.01	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

	Measured	Allowed
Distance From Nozzle X (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance W (inches)	2.25	2 in.
Pitot to Sample Probe Distance Y (inches)	3.500	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date January 17, 2011
 Pitot ID AE5-12-4
 Operator A. Kienitz

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.356	NA
Base To Opening Distance - Pb (inches)	0.356	NA
Pa/Dt	1.424	1.05-1.50
Pb/Dt	1.424	1.05-1.50
Angle, $\alpha 1$ (°)	1	10
Angle, $\alpha 2$ (°)	0	10
Angle, B1 (°)	0	5
Angle, B1 (°)	3	5
Opening to Opening Distance Pa+Pb (inches)	0.712	NA
Angle, Z (°)	89	NA
z (inches)	0.030	0.125
Angle, W (°)	90	NA
w (inches)	0.003	0.031
Pitot to Thermocouple Distance, W (inches)	2.50	≥ 2

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly **Yes**
 If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle, X (inches)	0.75	0.75
Pitot to Sample Probe Distance, Y (inches)	4.50	3

Does the Pitot Tube Meet the Above Requirements **Yes**
 Is the Pitot Tube Free of Damage **Yes**

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
 If No to Either, then the Pitot Tube Must be Calibrated