

Calibration Data

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 9/13/2010

Operator: J Birtford

Meter Box ID M-2														Meter Box $\Delta H@$ 1.810					Meter Box Y_d 0.9904					Barometric Pressure (in. Hg.) 29.50			
Time	Orifice Data							Meter Box Data							Results												
	θ (min)	K'	Vacuum	T_{amb}	V_{cr}	$V_{initial}$	V_{final}	V_d	ΔH	T_i	T_o	T_{avg}	V_{mid}	Q	Y_d	$\Delta H@$											
5.0	0.3455	23.0	80	2.193	473.80	476.08	2.28	0.63	77	74	75.5	2.219	0.439	0.9882	1.789												
5.0	0.3455	23.0	81	2.191	476.08	478.37	2.29	0.63	78	75	76.5	2.225	0.438	0.9849	1.776												
5.0	0.3455	23.0	82	2.189	478.37	480.66	2.29	0.63	78	75	76.5	2.225	0.438	0.9839	1.776												
5.0	0.4434	21.0	82	2.809	481.00	483.93	2.93	1.05	79	76	77.5	2.844	0.562	0.9877	1.812												
5.0	0.4434	21.0	82	2.809	483.93	486.88	2.95	1.05	80	77	78.5	2.858	0.562	0.9829	1.791												
5.0	0.4434	21.0	82	2.809	486.88	489.82	2.94	1.05	80	78	79.0	2.846	0.562	0.9871	1.805												
5.0	0.5926	20.0	83	3.751	490.20	494.12	3.92	1.9	81	78	79.5	3.799	0.750	0.9874	1.838												
5.0	0.5926	20.0	83	3.751	494.12	498.04	3.92	1.9	83	79	81.0	3.788	0.750	0.9901	1.844												
5.0	0.5926	20.0	83	3.751	498.04	501.96	3.92	1.9	84	79	81.5	3.785	0.750	0.9910	1.845												
5.0	0.7965	17.0	83	5.042	502.60	507.80	5.20	3.3	86	80	83.0	5.024	1.008	1.0035	1.826												
5.0	0.7965	17.0	83	5.042	507.80	513.03	5.23	3.3	88	81	84.5	5.039	1.008	1.0005	1.810												
5.0	0.7965	17.0	83	5.042	513.03	518.27	5.24	3.3	86	82	84.0	5.054	1.008	0.9976	1.802												
Average																											

Nomenclature	
K'	Critical Orifice Coefficient
T_{amb}	Ambient Temperature (°F)
V_{cr}	Volume Through Orifice (scf)
V_d	Gas Meter Volume (ft³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T_i	Meter Inlet Temperature (°F)
T_o	Meter Outlet Temperature (°F)
T_{avg}	Average Meter Box Temperature (°F)
V_{mid}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y_d	Meter Correction Factor (dimensionless)
$\Delta H@$	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg.)	Thermometers (°F)				Equations
	Standard	Vacuum Gauge	Ch. No	Ch. No	
5		5.0	32	2	$V_{cr} = K' \cdot P_o \cdot \theta / (T_{mb} + 460) \cdot 0.5$
10		10.0	49	33	$V_{mid} = 17.64 \cdot V_d \cdot (P_o + \Delta H / 13.6) / (T_{mc} + 460)$
15		15.0	99	51	$Q = V_{cr} / \theta$
20		20.0	150	152	$Y_d = V_{cr} / V_{mid}$
25		25.0	212	214	$\Delta H@ = .0319 \cdot \Delta H \cdot (T_{avg} + 460) \cdot \theta \cdot 2 / (P_o \cdot Y_d^2 \cdot V_m^2)$
			249	252	
			301	302	
			350	352	
			400	402	
			500	502	
			600	602	
Average					Average 0.9904

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.776	Meter ID	M-2

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	348.00	351.88	355.76
Final Volume (ft ³)	351.88	355.76	359.64
Volume Metered (ft ³)	3.88	3.88	3.88
DGM Inlet Temperature (°F)	84	85	85
DGM Outlet Temperature (°F)	80	81	81
Average DGM Temperature (°F)	82.0	83.0	83.0
Ambient Temperature (°F)	84	83	84
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.75	1.75	1.75
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.722	3.725	3.722
V _{mstd} (ft ³)	3.741	3.735	3.735
Post Test Yc	0.9947	0.9975	0.9965
Full Test Yd	0.9904	0.9904	0.9904
% Difference	-0.44	-0.71	-0.62
Average % Difference			-0.59

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.050	Date	8/9/2011
Highest Field Vacuum (inches Hg)	4	Client	BREC
Critical Orifice ID	BB-55	Project No.	3648
Orifice Flow Rate (cfm)	0.59	Meter ID	M-3

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	494.00	496.95	499.88
Final Volume (ft ³)	496.95	499.88	502.83
Volume Metered (ft ³)	2.95	2.93	2.95
DGM Inlet Temperature (°F)	81	81	82
DGM Outlet Temperature (°F)	78	79	79
Average DGM Temperature (°F)	79.5	80.0	80.5
Ambient Temperature (°F)	82	81	82
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.05	1.05	1.05
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.4436	0.4436	0.4436
Vcr (ft ³)	2.811	2.813	2.811
Vmstd (ft ³)	2.853	2.831	2.848
Post Test Yc	0.9851	0.9937	0.9870
Full Test Yd	0.9891	0.9891	0.9891
% Difference	0.40	-0.47	0.22
Average % Difference			0.05

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 4/13/2011

Operator: J.Burton

Time	Meter Box ΔH@				Meter Box Y _d				Barometric Pressure (in. Hg.)				Results		
	1.903	1.903	1.903	1.903	0.9918	0.9918	0.9918	0.9918	29.50	29.50	29.50	29.50			
Meter Box Data															
Orifice Data				Meter Box Data								Results			
θ (min)	K'	Vacuum	T _{amb}	V _{cr}	V _{initial}	V _{final}	V _d	ΔH	T _i	T _o	T _{avg}	V _{read}	Q	Y _d	ΔH@
5.0	0.3445	22.0	68	2.211	309.00	311.19	2.19	0.66	69	66	67.5	2.164	0.442	1.0219	1.995
5.0	0.3445	22.0	66	2.216	311.19	313.38	2.19	0.66	71	67	69.0	2.158	0.443	1.0268	2.001
5.0	0.3445	22.0	66	2.216	313.38	315.58	2.20	0.66	72	68	70.0	2.164	0.443	1.0240	1.986
5.0	0.4436	21.0	66	2.853	315.90	318.83	2.93	1.10	73	69	71.0	2.879	0.571	0.9908	1.870
5.0	0.4436	21.0	67	2.850	318.83	321.75	2.92	1.10	75	69	72.0	2.864	0.570	0.9952	1.886
5.0	0.4436	21.0	67	2.850	321.75	324.69	2.94	1.10	76	70	73.0	2.878	0.570	0.9903	1.864
5.0	0.5885	19.0	66	3.785	325.00	328.97	3.97	2.0	78	71	74.5	3.884	0.757	0.9744	1.864
5.0	0.5885	19.0	66	3.785	328.97	332.93	3.96	2.0	80	72	76.0	3.864	0.757	0.9796	1.879
5.0	0.5885	19.0	66	3.785	332.93	336.89	3.96	2.0	82	73	77.5	3.853	0.757	0.9823	1.884
5.0	0.7954	17.0	66	5.115	337.30	342.73	5.43	3.7	86	74	80.0	5.281	1.023	0.9687	1.862
5.0	0.7954	17.0	66	5.115	342.73	348.15	5.42	3.7	88	75	81.5	5.257	1.023	0.9731	1.874
5.0	0.7954	17.0	66	5.115	348.15	353.58	5.43	3.7	91	76	83.5	5.247	1.023	0.9749	1.874
												Average	0.9918	1.903	

Nomenclature	
K'	Critical Orifice Coefficient
T _{amb}	Ambient Temperature (°F)
V _{cr}	Volume Through Orifice (scf)
V _d	Gas Meter Volume (ft ³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T _i	Meter Inlet Temperature (°F)
T _o	Meter Outlet Temperature (°F)
T _{avg}	Average Meter Box Temperature (°F)
V _{read}	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y _d	Meter Correction Factor (dimensionless)
ΔH@	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg.)			Thermometers (°F)		
Standard	Vacuum Gauge	Ch. No.	Standard	Ch. No.	Ch. No.
5	5.0	32	31	2	3
10	10.0	50	49	32	31
15	15.0	100	99	51	50
20	20.0	150	149	101	100
25	25.0	212	213	151	150
		250	251	213	212
		300	301	251	251
		350	351	301	301
		400	400	351	350
		500	500	402	400
		600	601	502	501
			602	602	600

$$V_{cr} = K' \cdot P_b \cdot \theta$$

$$(T_{amb} + 460) \cdot 0.5$$

$$V_{read} = 17.64 \cdot V_{cr} \cdot \left(\frac{P_b}{T_{amb} + 460} \right)^{1.35}$$

$$Q = V_{cr} \cdot \theta$$

$$Y_d = V_{cr} / V_{read}$$

$$\Delta H@ = 0.319 \cdot \frac{\Delta H \cdot (T_{amb} + 460) \cdot \theta^2}{P_b \cdot Y_d^2 \cdot V_{cr}^2}$$

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/10/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.786	Meter ID	M-5

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	26.00	29.93	33.85
Final Volume (ft ³)	29.93	33.85	37.78
Volume Metered (ft ³)	3.93	3.92	3.93
DGM Inlet Temperature (°F)	87	88	90
DGM Outlet Temperature (°F)	80	82	82
Average DGM Temperature (°F)	83.5	85.0	86.0
Ambient Temperature (°F)	74	75	76
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	2.00	2.00	2.00
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.756	3.753	3.749
V _{mstd} (ft ³)	3.782	3.762	3.764
Post Test Y _c	0.9933	0.9977	0.9960
Full Test Y _d	0.9953	0.9953	0.9953
% Difference	0.20	-0.24	-0.07
Average % Difference			-0.04

Airtech Environmental Services, Inc.
Meter Box Full Test Calibration

Date: 9/13/2010

Operator: i burton

Meter Box ID M-14			Meter Box $\Delta H @$			1.802			Meter Box Y_d			1.0087			Barometric Pressure (in. Hg.)			Results				
Time		Orifice Data									Meter Box Data									Results		
θ (min)	K'	Vacuum	T_{amb}	V_{cr}	V_{inlet}	V_{final}	V_d	ΔH	T_i	T_o	T_{avg}	V_{inlet}	Q	Y_d	$\Delta H @$							
5.0	0.3455	22.0	83	2.187	510.30	512.57	2.27	0.63	82	89	85.5	2.169	0.437	1.0083	1.772							
5.0	0.3455	22.0	83	2.187	512.57	514.83	2.26	0.63	83	80	81.5	2.175	0.437	1.0054	1.775							
5.0	0.3455	22.0	83	2.187	514.83	517.09	2.26	0.63	84	81	82.5	2.171	0.437	1.0072	1.778							
5.0	0.4434	20.0	84	2.804	517.40	520.33	2.93	1.05	85	82	83.5	2.813	0.561	0.9969	1.766							
5.0	0.4434	20.0	84	2.804	520.33	523.27	2.94	1.05	87	82	84.5	2.817	0.561	0.9954	1.767							
5.0	0.4434	20.0	84	2.804	523.27	526.17	2.90	1.05	89	83	86.0	2.771	0.561	1.0119	1.811							
5.0	0.5926	18.0	84	3.748	526.60	530.50	3.90	1.9	91	84	87.5	3.724	0.750	1.0062	1.817							
5.0	0.5926	18.0	84	3.748	530.50	534.40	3.90	1.9	93	85	89.0	3.714	0.750	1.0090	1.822							
5.0	0.5926	18.0	84	3.748	534.40	538.30	3.90	1.9	94	86	90.0	3.707	0.750	1.0108	1.826							
5.0	0.7965	15.0	84	5.037	538.90	544.13	5.23	3.4	97	87	92.0	4.972	1.007	1.0130	1.823							
5.0	0.7965	15.0	84	5.037	544.13	549.26	5.23	3.4	100	89	94.5	4.950	1.007	1.0176	1.831							
5.0	0.7965	15.0	84	5.037	549.36	554.58	5.22	3.4	102	90	96.0	4.927	1.007	1.0223	1.843							
														Average	1.0087	1.802						

Nomenclature	
K'	Critical Orifice Coefficient
T_{amb}	Ambient Temperature (°F)
V_{cr}	Volume Through Orifice (scf)
V_d	Gas Meter Volume (ft³)
ΔH	Orifice Pressure Differential (in. H ₂ O)
T_i	Meter Inlet Temperature (°F)
T_o	Meter Outlet Temperature (°F)
T_{avg}	Average Meter Box Temperature (°F)
$V_{m(in)}$	Volume Metered Standardized (scf)
Q	Flow Rate (scfm)
Y_d	Meter Correction Factor (dimensionless)
$\Delta H @$	ΔH yielding 0.75 scfm

Vacuum Gauge (in. Hg.)		Thermometers (°F)		
Standard	Vacuum Gauge	Ch No	Ch No	Ch No
5	5.0	32	2	3
10	10.0	51	33	32
15	15.0	100	51	50
20	20.0	151	101	100
25	25.0	212	151	150
		251	213	212
		300	251	250
		350	301	300
		400	350	349
		450	400	399
		500	450	498
		550	500	599
		600	550	598

$$V_{cr} = K' \cdot P_a \cdot \theta$$

$$(T_{amb} + 460) \cdot 0.5$$

$$V_{inlet} = 17.64 \cdot V_d \cdot \sqrt{\frac{P_a \cdot (P_a + \Delta H / 3.6))}{(T_{amb} + 460)}}$$

$$Q = V_{cr} / \theta$$

$$Y_d = V_{cr} / V_{inlet}$$

$$\Delta H @ = \frac{0.0319 \cdot \Delta H \cdot (T_{amb} + 460) \cdot \theta \cdot 2}{P_a \cdot Y_d \cdot 2 \cdot V_{m(in)}}$$

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.76	Meter ID	M-14

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	105.00	108.80	112.67
Final Volume (ft ³)	108.80	112.67	116.51
Volume Metered (ft ³)	3.80	3.87	3.84
DGM Inlet Temperature (°F)	91	92	92
DGM Outlet Temperature (°F)	85	86	86
Average DGM Temperature (°F)	88.0	89.0	89.0
Ambient Temperature (°F)	90	90	90
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
Vcr (ft ³)	3.701	3.701	3.701
Vmstd (ft ³)	3.625	3.685	3.656
Post Test Yc	1.0211	1.0045	1.0124
Full Test Yd	1.0087	1.0087	1.0087
% Difference	-1.23	0.42	-0.36
Average % Difference			-0.39

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.75	Meter ID	M-15

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	174.50	178.25	182.02
Final Volume (ft ³)	178.25	182.02	185.78
Volume Metered (ft ³)	3.75	3.77	3.76
DGM Inlet Temperature (°F)	85	86	87
DGM Outlet Temperature (°F)	79	80	80
Average DGM Temperature (°F)	82.0	83.0	83.5
Ambient Temperature (°F)	85	85	85
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	19	19	19
K'	0.5885	0.5885	0.5885
Vcr (ft ³)	3.718	3.718	3.718
Vmstd (ft ³)	3.617	3.629	3.616
Post Test Yc	1.0281	1.0246	1.0282
Full Test Yd	1.0159	1.0159	1.0159
% Difference	-1.20	-0.85	-1.21
Average % Difference			-1.09

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/9/2011
Highest Field Vacuum (inches Hg)	10	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.772	Meter ID	M-16

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	627.50	631.36	635.21
Final Volume (ft ³)	631.36	635.21	639.08
Volume Metered (ft ³)	3.86	3.85	3.87
DGM Inlet Temperature (°F)	86	87	88
DGM Outlet Temperature (°F)	82	82	82
Average DGM Temperature (°F)	84.0	84.5	85.0
Ambient Temperature (°F)	88	87	87
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	20	20	20
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.708	3.711	3.711
V _{mstd} (ft ³)	3.709	3.696	3.712
Post Test Y _c	0.9998	1.0042	0.9999
Full Test Y _d	0.9907	0.9907	0.9907
% Difference	-0.91	-1.36	-0.93
Average % Difference			-1.07

Airtech Environmental Services Meter Post Calibration

Average Field Sample Rate (ΔH)	1.500	Date	8/8/2011
Highest Field Vacuum (inches Hg)	5	Client	BREC
Critical Orifice ID	AA-63	Project No.	3648
Orifice Flow Rate (cfm)	0.766	Meter ID	M-20

	Run 1	Run 2	Run 3
Initial Volume (ft ³)	825.60	829.43	833.26
Final Volume (ft ³)	829.43	833.26	837.08
Volume Metered (ft ³)	3.83	3.83	3.82
DGM Inlet Temperature (°F)	90	90	90
DGM Outlet Temperature (°F)	84	84	84
Average DGM Temperature (°F)	87.0	87.0	87.0
Ambient Temperature (°F)	90	89	88
Elapsed Time (min.)	5	5	5
ΔH (inches H ₂ O)	1.80	1.80	1.80
Barometric Pressure (inches Hg)	29.5	29.5	29.5
Pump Vacuum (inches Hg)	18	18	18
K'	0.5885	0.5885	0.5885
V _{cr} (ft ³)	3.701	3.705	3.708
V _{mstd} (ft ³)	3.660	3.660	3.650
Post Test Y _c	1.0113	1.0122	1.0158
Full Test Y _d	0.9952	0.9952	0.9952
% Difference	-1.62	-1.71	-2.07
Average % Difference			-1.80

Meter Box Full Test Calibration

DATE: 7/8/2011

M26

Operator: Joe Ward

Meter Box No: DB30B-0711-2018		Meter Box H@:		Meter Box Gas		Meter Box Yd		Meter Box		Barometric Pressure:									
		Volume		Volume (ft ³)		Temperature (pF)		Temperature (pF)											
#1	P	H	Yds	Initial	Final	Vf	Inlet	Outlet	Avg.	Inlet	Outlet	Avg.	Time	Yd	H@				
0.04	-0.30	0.00	1.0000	0.0	1.000	1.000	.000	1.015	1.015	.503	76.0	76.0	76.0	81.0	81.0	27.04	0.9951	0.0000	
0.04	-0.30	0.00	1.0030	0.0	1.000	1.000	0.000	1.014	1.014	.503	76.0	76.0	76.0	80.0	80.0	27.06	0.9943	0.0000	
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.000	.503	.503	.507	77.0	77.0	77.0	80.0	80.0	29.91	1.0003	0.0000	
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.000	.502	.502	.507	77.0	77.0	77.0	80.0	80.0	29.52	1.0023	0.0000	
0.03	-0.30	0.00	1.0000	0.0	.500	.500	.000	.507	.507	.508	78.0	78.0	78.0	81.0	81.0	17.92	0.9924	0.0000	
0.03	-0.30	0.00	1.0000	0.0	.500	.500	.000	.508	.508	.508	78.0	78.0	78.0	81.0	81.0	17.79	0.9905	0.0000	
AVERAGE																			
AVERAGE												0.9958	0.9958	0.0000	0.9958	0.0000	29.78		

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	15.0
20.0	21.0
25.0	26.0

Meter Box Full Test Calibration

DATE: 7/10/2011

M-26

Operator: Joe Ward

Meter Box No DB30B-0711-2018		Meter Box H@: 0.0000		Meter Box Yd 0.9902		Barometric Pressure: 29.75										
#2	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (PF)		Meter Box Temperature (PF)									
	Q	P	H	Yds	Initial	Final	Vf	Inlet	Outlet	Avg.	Time	Yd	H@			
0.01	-0.30	0.00	1.0000	0.0	.280	.280	.294	75.0	75.0	75.0	92.0	92.0	92.0	18.66	0.9834	0.0000
0.01	-0.30	0.00	1.0000	0.0	.285	.285	.299	75.0	75.0	75.0	92.0	92.0	92.0	18.64	0.9842	0.0000
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.033	75.0	75.0	75.0	93.0	93.0	93.0	29.14	1.0014	0.0000
0.03	-0.30	0.00	1.0000	0.0	1.000	1.000	1.032	75.0	75.0	75.0	93.0	93.0	93.0	29.10	1.0023	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.527	75.0	75.0	75.0	95.0	95.0	95.0	22.89	0.9850	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.527	75.0	75.0	75.0	95.0	95.0	95.0	22.80	0.9850	0.0000
AVERAGE													0.9902	0.0000		

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Airtech Environmental

Job or Reference No.:DB30B-0711-2018

Temperature Scale Used

- Fahrenheit
 Celsius

- Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.479	Meter ID	M-26 A

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.798	9.564	
Final Volume (l³)	4.798	9.564	14.362	
Volume Metered (l³)	4.798	4.766	4.798	
DGM Temperature (°F)	104	105	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	19.0	19.0	19.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.281	4.285	4.281	
Vmstd (l³)	4.431	4.394	4.408	
Post Test Yc	0.96609	0.97519	0.97123	
Full Test Yd	0.9958	0.9958	0.9958	
% Difference	2.98	2.07	2.47	
	Average Difference		2.51	

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.480	Meter ID	M-26 B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.802	9.592	
Final Volume (l³)	4.802	9.592	14.401	
Volume Metered (l³)	4.802	4.790	4.809	
DGM Temperature (°F)	106	108	107	
Ambient Temperature (°F)	88	87	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
V_{cr} (l³)	4.281	4.285	4.281	
V_{mstd} (l³)	4.419	4.393	4.418	
Post Test Yc	0.96871	0.97546	0.96901	
Full Test Yd	0.9902	0.9902	0.9902	
% Difference	2.17	1.49	2.14	
	Average Difference		1.93	

Meter Box Full Test Calibration

R-20098

DATE: 7/10/2011

Operator: Joe Ward

Meter Box No: DB30B-0711-2019		Meter Box H@: 0.0000		Meter Box Yd 1.0072		Barometric Pressure: 29.79							
#1	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (pF)		Meter Box Temperature (pF)						
	Q	P	H	Yds	Initial	Final	Vf	Inlet	Outlet	Avg.	Time	Yd	H@
0.04	-0.30	0.00	1.0000	0.0	1.000	1.000	1.018	75.0	75.0	75.0	26.40	1.0124	0.0000
0.04	-0.30	0.00	1.0000	0.0	1.000	1.000	1.019	75.0	75.0	75.0	26.38	1.0115	0.0000
0.02	-0.30	0.00	1.0000	0.0	.520	.520	.536	75.0	75.0	75.0	22.14	1.0035	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.516	75.0	75.0	75.0	22.09	1.0041	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.523	76.0	76.0	76.0	32.22	1.0067	0.0000
0.02	-0.30	0.00	1.0000	0.0	.500	.500	.524	76.0	76.0	76.0	32.20	1.0048	0.0000
AVERAGE												1.0072	0.0000

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.5
10.0	10.5
15.0	16.0
20.0	21.0

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

New Ashtead

R-20078

Meter Box Full Test Calibration

DATE: 7/11/2011

Operator: Joe Ward

Meter Box No. DB30B-0711-2019		Meter Box H@: 0.0000		Meter Box Yd 0.9985		Barometric Pressure: 29.69							
#2	Q	Standard Meter Gas Volume		Meter Box Gas Volume (ft ³)		Std. Meter Temperature (PF)		Meter Box Temperature (PF)		Time	Yd	H@	
		Initial	Final	Vf	Vf	Inlet	Outlet	Avg.	Inlet				Outlet
0.03	-0.30	0.00	1.000	1.000	1.024	1.024	75.0	75.0	92.0	92.0	30.56	1.0083	0.0000
0.03	-0.30	0.00	1.000	1.000	1.025	1.025	75.0	75.0	92.0	92.0	30.48	1.0074	0.0000
0.02	-0.30	0.00	1.000	0.500	0.518	0.518	75.0	75.0	94.0	94.0	22.10	1.0003	0.0000
0.02	-0.30	0.00	1.000	0.500	0.518	0.518	75.0	75.0	94.0	94.0	21.90	1.0003	0.0000
0.01	-0.30	0.00	1.000	0.500	0.528	0.528	76.0	76.0	98.0	98.0	38.94	0.9866	0.0000
0.01	-0.30	0.00	1.000	0.500	0.527	0.527	76.0	76.0	98.0	98.0	38.85	0.9884	0.0000
AVERAGE											0.9985	0.0000	

Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL, 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail millennium@millinst.com
 www.millinst.com

R-20078

Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove
Client: Ashtead Technology Rentals
Job or Reference No.:DB30B-0711-2019

Temperature Scale Used

Fahrenheit
 Celsius

Full Test
 Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	10°C
100° F	100° F	38°C
150° F	150° F	66°C
200° F	200° F	93°C
250° F	250° F	121°C
300° F	300° F	149°C
350° F	350° F	177°C
400° F	400° F	204°C
450° F	450° F	232°C
500° F	500° F	260°C
550° F	550° F	288°C
600° F	600° F	316°C

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.473	Meter ID	R-20078A

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.676	9.411	
Final Volume (l³)	4.676	9.411	14.181	
Volume Metered (l³)	4.676	4.735	4.770	
DGM Temperature (°F)	106	108	112	
Ambient Temperature (°F)	87	88	88	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.4	0.4	0.4	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	20.0	20.0	20.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.285	4.281	4.281	
Vmstd (l³)	4.303	4.342	4.344	
Post Test Yc	0.99572	0.98589	0.98555	
Full Test Yd	1.0072	1.0072	1.0072	
% Difference	1.14	2.12	2.15	
	Average Difference		1.80	

Method 30B Post-Test Meter Calibration

Average Field Sample Rate (lpm)	0.5	Date	8/8/2011
Highest Field Vacuum (inches Hg)	10.0	Client	BREC
Critical Orifice ID	.5LPM	Project No.	3648
Orifice Flow Rate (lpm)	0.487	Meter ID	R-20078B

	Run 1	Run 2	Run 3	
Initial Volume (l³)	0.000	4.891	9.779	
Final Volume (l³)	4.891	9.779	14.623	
Volume Metered (l³)	4.891	4.888	4.844	
DGM Temperature (°F)	116	116	115	
Ambient Temperature (°F)	87	87	86	
Elapsed Time (min.)	10.0	10.0	10.0	
Setting (l/min)	0.5	0.5	0.5	
Barometric Pressure (inches Hg)	29.50	29.50	29.50	
Pump Vacuum (inches Hg)	18.0	18.0	18.0	
K'	0.012	0.012	0.012	
Vcr (l³)	4.285	4.285	4.289	
Vmstd (l³)	4.424	4.422	4.389	
Post Test Yc	0.96853	0.96912	0.97712	
Full Test Yd	0.9985	0.9985	0.9985	
% Difference	3.00	2.94	2.14	
	Average Difference		2.69	

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE5-6-2
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.356	NA
Base To Opening Distance - Pb (inches)	0.356	NA
Pa/Dt	1.42	1.05-1.50
Pb/Dt	1.42	1.05-1.50
Angle $\alpha 1(^{\circ})$	2.7	10
Angle $\alpha 2(^{\circ})$	2.6	10
Angle B1($^{\circ}$)	4	5
Angle B1($^{\circ}$)	0.6	5
Opening to Opening Distance Pa+Pb (inches)	0.712	NA
Angle Z ($^{\circ}$)	0.4	NA
z (inches)	0.0050	0.125
Angle W ($^{\circ}$)	0	NA
w (inches)	0.000	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	6.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE-5-6-3
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.362	NA
Base To Opening Distance - Pb (inches)	0.362	NA
Pa/Dt	1.45	1.05-1.50
Pb/Dt	1.45	1.05-1.50
Angle $\alpha 1$ (°)	3.4	10
Angle $\alpha 2$ (°)	2	10
Angle B1 (°)	1.3	5
Angle B1 (°)	2.1	5
Opening to Opening Distance Pa+Pb (inches)	0.724	NA
Angle Z (°)	0	NA
z (inches)	0.0000	0.125
Angle W (°)	0.9	NA
w (inches)	0.011	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	4.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE-5-6-4WC
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.329	NA
Base To Opening Distance - Pb (inches)	0.329	NA
Pa/Dt	1.32	1.05-1.50
Pb/Dt	1.32	1.05-1.50
Angle $\alpha 1$ (°)	2.3	10
Angle $\alpha 2$ (°)	1.7	10
Angle B1 (°)	3.9	5
Angle B1 (°)	3.5	5
Opening to Opening Distance Pa+Pb (inches)	0.658	NA
Angle Z (°)	2.5	NA
z (inches)	0.0287	0.125
Angle W (°)	0.3	NA
w (inches)	0.003	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2	2 in.
Pitot to Sample Probe Distance (inches)	5	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date 1/25/11
Pitot ID AE5-6-5
Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.344	NA
Base To Opening Distance - Pb (inches)	0.344	NA
Pa/Dt	1.38	1.05-1.50
Pb/Dt	1.38	1.05-1.50
Angle $\alpha 1(^{\circ})$	1.2	10
Angle $\alpha 2(^{\circ})$	1.5	10
Angle B1($^{\circ}$)	3.1	5
Angle B1($^{\circ}$)	3.7	5
Opening to Opening Distance Pa+Pb (inches)	0.688	NA
Angle Z ($^{\circ}$)	2.6	NA
z (inches)	0.0312	0.125
Angle W ($^{\circ}$)	0.4	NA
w (inches)	0.005	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly Yes
If Yes, Complete the Section Below

Pitot	Measured	Minimum
Distance From Nozzle (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance (inches)	2.25	2 in.
Pitot to Sample Probe Distance (inches)	5.25	3 in.

Does the Pitot Tube Meet the Above Requirements Yes
Is the Pitot Tube Free of Damage Yes

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
If No to Either, then the Pitot Tube Must be Calibrated

Airtech Environmental Services, Inc.
S-Type Pitot Tube Inspection Form

Date January 26, 2011
 Pitot ID AE5-12-3
 Operator EA

	Measured	Allowed
Outside Tube Diameter - Dt (inches)	0.250	NA
Base To Opening Distance - Pa (inches)	0.338	NA
Base To Opening Distance - Pb (inches)	0.338	NA
Pa/Dt	1.35	1.05-1.50
Pb/Dt	1.35	1.05-1.50
Angle $\alpha 1(^{\circ})$	1.1	10
Angle $\alpha 2(^{\circ})$	1.1	10
Angle B1($^{\circ}$)	2.1	5
Angle B2($^{\circ}$)	3.5	5
Opening to Opening Distance Pa+Pb (inches)	0.676	NA
Angle Z ($^{\circ}$)	4.3	NA
z (inches)	0.05	0.125
Angle W ($^{\circ}$)	0.9	NA
w (inches)	0.01	0.031

Note Any Damage, Nicks or Dents to the Pitot Tube

Is the Pitot Tube Part of an Assembly **Yes**
 If Yes, Complete the Section Below

	Measured	Allowed
Distance From Nozzle, X (inches)	0.75	0.75 in.
Pitot to Thermocouple Distance, W (inches)	2.25	2 in.
Pitot to Sample Probe Distance, Y (inches)	3.500	3 in.

Does the Pitot Tube Meet the Above Requirements **Yes**
 Is the Pitot Tube Free of Damage **Yes**

If Yes to Both, a Pitot Tube Coefficient of 0.84 is Assigned
 If No to Either, then the Pitot Tube Must be Calibrated

Sample Probe Calibration

Probe Type: 12FT M-5 PROBE I.D. Number: 7/8/11-3

Thermocouple Calibration

Reference Type _____ Reference I.D. No. _____ Pyrometer I.D. No: _____ Degrees: _____

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ice-32F					%Difference ≤ 1.5
2	Ambient-70F					
3	Hot Oil-150F					
4	Boiling H ₂ O-212					
5	Hot Oil-320F					

* Based on Absolute Temperature (Rankine)

Does assembly meet specifications? _____

Geometric Pitot Calibration

"S" Pitot			Standard Pitot		
Measurement		Specification	Measurement (Inches)		Specification
$\alpha 1 (^{\circ}) = 1.000$	$\alpha 2 (^{\circ}) = 0.000$	≤ 10°	Tube O.D.	_____	(D)
$\beta 1 (^{\circ}) = 1.000$	$\beta 2 (^{\circ}) = 1.000$	≤ 05°	Static Hole I.D.	_____	- 0.1 x (D)
$\gamma (^{\circ}) = 0.000$	$\theta (^{\circ}) = 0.000$		Length:		
$P a (^{\circ}) = 0.363$	$P b (^{\circ}) = 0.363$	$P a + P b = A$	Tip to Static	_____	≤ 6 x (D)
$A (^{\circ}) = 0.725$	$D i (^{\circ}) = 0.250$		Static to Bend	_____	≤ 8 x (D)
Calculations					
$Z (^{\circ}) = A \sin \gamma =$		0.0000			
$W (^{\circ}) = A \sin \theta =$		0.00000			
		≤ 0.125"			
		≤ 0.03125"			

Does assembly meet specifications? _____

YES

→ If "Yes", "S" pitot Cp=0.84; Std. Pitot=0.99. If "No", wind tunnel calibration is required.

Wind Tunnel Calibration

Reference Pitot I.D. No: _____ Reference Pitot Cp: _____

Pitot Side 'A':				Deviation from Average Cp*	Specification
Trial No.	Reference P	Probe P	Probe Cp*		
1					Cp Deviations ≤ 0.01
2					
3					
Side 'A' Average Probe Cp=					

Pitot Side 'B':				Deviation from Average Cp*	Specification
Trial No.	Reference P	Probe P	Probe Cp*		
1					Cp Deviations ≤ 0.01
2					
3					
Side 'B' Average Probe Cp=					

*Probe Cp= (Reference Cp)/(Reference P/Probe P); Cp Deviation= Trial Cp - Average Probe Cp

'A' Average Cp _____ - 'B' Average Cp _____ = Difference _____ |Difference| ≤ 0.01

Does assembly meet specifications? _____

→ If "Yes", Cp= Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.84 Calibrated by: Dscreen Date: 7/8/2011

