

Sample Calculations

Sample Calculations, Unit 2 Stack, Method 5B/202, Run 1

Area of Sample Location

$$A_s = \pi \times \left(\frac{d_s}{2 \times 12} \right)^2$$

$$A_s = \pi \times \left(\frac{192.0}{2 \times 12} \right)^2$$

$$A_s = 201 \text{ ft}^2$$

where:

- A_s = area of sample location (ft²)
- d_s = diameter of sample location (in)
- 12 = conversion factor (in/ft)
- 2 = conversion factor (diameter to radius)

Stack Pressure Absolute

$$P_a = P_b + \frac{P_s}{13.6}$$

$$P_a = 29.41 + \frac{-0.4}{13.6}$$

$$P_a = 29.38 \text{ in.Hg}$$

where:

- P_a = stack pressure absolute (in. Hg)
- P_b = barometric pressure (in. Hg)
- P_s = static pressure (in. H₂O)
- 13.6 = conversion factor (in. H₂O/in. Hg)

Volume of Dry Gas Collected Corrected to Standard Temperature and Pressure

$$V_{m(std)} = \frac{17.64(V_m)(Y_d)\left(P_b + \frac{\Delta H}{13.6}\right)}{(T_m + 460)}$$
$$V_{m(std)} = \frac{17.64(52.01)(1.0141)\left(29.41 + \frac{1.12}{13.6}\right)}{(105 + 460)}$$
$$V_{m(std)} = 48.61 scf$$

where:

- $V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)
- V_m = volume of gas sampled at meter conditions (ft³)
- Y_d = gas meter correction factor (dimensionless)
- P_b = barometric pressure (in. Hg)
- ΔH = average sample pressure (in. H₂O)
- T_m = average gas meter temperature (°F)
- 13.6 = conversion factor (in. H₂O/in. Hg)
- 17.64 = ratio of standard temperature over standard pressure (°R/in. Hg)
- 460 = conversion (°F to °R)

Volume of Water Vapor Collected Corrected to Standard Temperature and Pressure

$$V_{w(std)} = 0.04715 \times (V_{wc} + V_{wsg})$$
$$V_{w(std)} = 0.04715 \times (143.9 + 34.7)$$
$$V_{w(std)} = 8.42 scf$$

where:

- $V_{w(std)}$ = volume of water vapor at standard conditions (scf)
- V_{wc} = weight of liquid collected (g)
- V_{wsg} = weight gain of silica gel (g)
- 0.04715 = volume occupied by one gram of water at standard temperature and pressure (ft³/g)

Percent Moisture²

$$B_{ws} = 100 \times \left[\frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}} \right]$$

$$B_{ws} = 100 \times \left[\frac{8.42}{(48.61 + 8.42)} \right]$$

$$B_{ws} = 14.8\%$$

where:

- B_{ws} = moisture content of the gas stream (%)
- $V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)
- $V_{w(std)}$ = volume of water vapor at standard conditions (scf)
- 100 = conversion factor

Molecular Weight of Dry Gas Stream³

$$M_d = \left(44 \times \frac{\%CO_2}{100} \right) + \left(32 \times \frac{\%O_2}{100} \right) + \left(28 \times \frac{\%N_2}{100} \right)$$

$$M_d = \left(44 \times \frac{12.8}{100} \right) + \left(32 \times \frac{6.20}{100} \right) + \left(28 \times \frac{81.0}{100} \right)$$

$$M_d = 30.30 \text{ lb / lbmole}$$

where:

- M_d = molecular weight of the dry gas stream (lb/lb-mole)
- $\%CO_2$ = carbon dioxide content of the dry gas stream (%)
- 44 = molecular weight of carbon dioxide (lb/lb-mole)
- $\%O_2$ = oxygen content of the dry gas stream (%)
- 32 = molecular weight of oxygen (lb/lb-mole)
- $\%N_2$ = nitrogen content of the dry gas stream (%)
- 28 = molecular weight of nitrogen and carbon monoxide (lb/lb-mole)
- 100 = conversion factor

² The moisture saturation point is used for all calculations if it is exceeded by the actual moisture content.

³ The remainder of the gas stream after subtracting carbon dioxide and oxygen is assumed to be nitrogen.

Molecular Weight of Wet Gas Stream

$$M_s = \left(M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right) + \left(18 \times \frac{B_{ws}}{100} \right)$$

$$M_s = \left(30.30 \times \left(1 - \frac{14.8}{100} \right) \right) + \left(18 \times \frac{14.8}{100} \right)$$

$$M_s = 28.48 \text{ lb/lbmole}$$

where:

- M_s = molecular weight of the wet gas stream (lb/lb-mole)
- M_d = molecular weight of the dry gas stream (lb/lb-mole)
- B_{ws} = moisture content of the gas stream (%)
- 18 = molecular weight of water (lb/lb-mole)
- 100 = conversion factor

Velocity of Gas Stream

$$V_s = 85.49(C_p) \left(\sqrt{\Delta P} \right) \sqrt{\frac{(T_s + 460)}{\left(M_s \left(P_b + \frac{P_s}{13.6} \right) \right)}}$$

$$V_s = 85.49(0.84)(0.707) \sqrt{\frac{(130 + 460)}{\left(28.48 \left(29.41 + \frac{-0.4}{13.6} \right) \right)}}$$

$$V_s = 42.6 \text{ ft/sec}$$

where:

- V_s = average velocity of the gas stream (ft/sec)
- C_p = pitot tube coefficient dimensionless
- $\sqrt{\Delta P}$ = average square root of velocity pressures (in. H₂O)^{1/2}
- T_s = average stack temperature (°F)
- M_s = molecular weight of the wet gas stream (lb/lb-mole)
- P_b = barometric pressure (in. Hg)
- P_s = static pressure of gas stream (in. H₂O)
- 85.49 = pitot tube constant (ft/sec)/[(lb/lb-mole)(in. Hg)]/[(⁰R)(in. H₂O)]^{1/2}
- 460 = conversion (°F to °R)
- 13.6 = conversion factor (in. H₂O/in. Hg)

Volumetric Flow of Gas Stream - Actual Conditions

$$Q_a = 60(V_s)(A_s)$$

$$Q_a = 60(42.6)(201)$$

$$Q_a = 513,880 \text{ acfm}$$

where:

- Q_a = volumetric flow rate of the gas stream at actual conditions (acfm)
- V_s = average velocity of the gas stream (ft/sec)
- A_s = area of duct or stack (ft²)
- 60 = conversion factor (min/hr)

Volumetric Flow of Gas Stream - Standard Conditions

$$Q_{std} = \frac{17.64(Q_a) \left(P_b + \frac{P_s}{13.6} \right)}{(T_s + 460)}$$

$$Q_{std} = \frac{17.64(513,880) \left(29.41 + \frac{-0.4}{13.6} \right)}{(130 + 460)}$$

$$Q_{std} = 451,663 \text{ scfm}$$

where:

- Q_{std} = volumetric flow rate of the gas stream at standard conditions (scfm)
- Q_a = volumetric flow rate of the gas stream at actual conditions (acfm)
- T_s = average stack temperature (°F)
- P_b = barometric pressure (in. Hg)
- P_s = static pressure of gas stream (in. H₂O)
- 13.6 = conversion factor (in. H₂O/in. Hg)
- 17.64 = ratio of standard temperature over standard pressure (°R/in. Hg)
- 460 = conversion (°F to °R)

Volumetric Flow of Gas Stream - Standard Conditions - Dry Basis

$$Q_{dstd} = Q_{std} \left(1 - \frac{B_{ws}}{100} \right)$$

$$Q_{dstd} = 451,663 \left(1 - \frac{14.8}{100} \right)$$

$$Q_{dstd} = 385,124 \text{ dscfm}$$

where:

Q_{dstd} = volumetric flow rate of the gas stream at standard conditions, on a dry basis (dscfm)

Q_{std} = volumetric flow rate of the gas stream at standard conditions (scfm)

B_{wsat} = moisture saturation point of the gas stream (%)

100 = conversion factor

Area of Nozzle

$$A_n = \pi \times \left(\frac{d_n}{2 \times 12} \right)^2$$

$$A_n = \pi \times \left(\frac{0.230}{2 \times 12} \right)^2$$

$$A_n = 0.000289 \text{ ft}^2$$

where:

A_n = area of nozzle (ft²)

d_n = diameter of nozzle (in)

12 = conversion factor (in/ft)

2 = conversion factor (diameter to radius)

Percent Isokinetic

$$I = \frac{0.0945(T_s + 460)(V_{m(std)})}{\left(P_b + \frac{P_s}{13.6}\right)(v_s)(A_n)(\Theta)\left(1 - \frac{B_{ws}}{100}\right)}$$

$$I = \frac{0.0945(130 + 460)(48.61)}{\left(29.41 + \frac{-0.4}{13.6}\right)(42.6)(2.89 \times 10^{-4})(90)\left(1 - \frac{14.8}{100}\right)}$$

$$I = 97.8\%$$

where:

I	= percent isokinetic (%)
T _s	= average stack temperature (°F)
V _{m(std)}	= volume of gas collected at standard temperature and pressure (scf)
P _b	= barometric pressure (in. Hg)
P _s	= static pressure of gas stream (in. H ₂ O)
V _s	= average velocity of the gas stream (ft/sec)
A _n	= cross sectional area of nozzle (ft ²)
Θ	= sample time (min)
B _{ws}	= moisture content of the gas stream (%)
0.0945	= constant (°R/in. Hg)
460	= conversion (°F to °R)
13.6	= conversion factor (in. H ₂ O/in Hg)
100	= conversion factor

Acetone Wash Blank-Particulate

$$W_a = \frac{(m_{ab})(v_{aw})}{v_{awb}}$$

$$W_a = \frac{(0.0006)(100)}{200}$$

$$W_a = 0.0000g$$

where:

W_a = particulate mass in acetone wash, blank corrected (g)

m_{ab} = mass collected, acetone wash blank (g)

v_{aw} = volume of acetone wash (ml)

v_{awb} = volume of acetone wash blank (ml)

Mass in Front Half, Acetone Blank Corrected

$$m_f = m_{fil} + (m_a - W_a)$$

$$m_f = 0.0195 + (0.0055 - 0.0000)$$

$$m_f = 0.0250g$$

where:

m_f = mass in front half filter, and acetone wash, blank corrected (g)

m_{fil} = mass in front half filter (g)

m_a = mass in acetone wash (g)

W_a = particulate mass in acetone wash blank (g)

Total Particulate Catch

$$M_n = m_f + m_b$$

$$M_n = 0.0250 + 0.0293$$

$$M_n = 0.0543g$$

where:

M_n = total mass catch (g)

m_f = mass in front half filter, and acetone wash, blank corrected (g)

m_b = mass in back half organic fraction, and inorganic fraction, blank corrected (g)

Total Particulate Concentration, grains/dscf

$$C_{gr/dscf} = \frac{(M_n)(15.43)}{V_{m,std}}$$

$$C_{gr/dscf} = \frac{(0.0543)(15.43)}{48.61}$$

$$C_{gr/dscf} = 0.0172 \text{ grains / dscf}$$

where:

- $C_{gr/dscf}$ = particulate concentration (grains/dscf)
- M_n = total particulate catch (g)
- $V_{m(std)}$ = volume of gas collected at standard conditions (scf)
- 15.43 = conversion factor (grains/g)

Calculated F_d Factor, dscf/mmBtu

$$F_d = K((K_{hd} \times H) + (K_c \times C) + (K_s \times S) + (K_n \times N) - (K_o \times O_2)) / GCV_w$$

$$F_d = 10^6 ((3.64 \times 5.12) + (1.53 \times 73.85) + (0.57 \times 3.07) + (0.14 \times 1.59) - (0.46 \times 6.96)) / 13,544$$

$$F_d = 9,628$$

where:

- F_d = calculated fuel factor (dscf/mmBtu)
- K = conversion factor (Btu/million Btu)
- K_{hd} = constant (scf/lb)
- H = weight percent hydrogen in coal (%)
- K_c = constant (scf/lb)
- C = weight percent carbon in coal (%)
- K_s = constant (scf/lb)
- S = weight percent sulfur in coal (%)
- K_n = constant (scf/lb)
- N = weight percent nitrogen in coal (%)
- K_o = constant (scf/lb)
- O_2 = weight percent oxygen in coal (%)
- GCV_w = gross calorific value of fuel, wet (Btu/lb)

Total Particulate Emission Rate, lb/mmBtu⁴

$$E_{PM} = \frac{(M_n)(F_d)(20.9)}{(V_{m(std)})(453.6)(20.9 - O_2)}$$

$$E_{PM} = \frac{(0.0543)(9,628)(20.9)}{(48.61)(453.6)(20.9 - 6.20)}$$

$$E_{PM} = 0.0337 \text{ lb / mmBtu}$$

where:

E_{PM} = total particulate matter emission rate, (lb/mmBtu)

M_n = total particulate catch (g)

F_d = fuel factor (dcsf/mmBtu)

20.9 = oxygen content of ambient air (%)

$V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)

453.6 = conversion factor (g/lb)

% O_2 = oxygen content of the dry gas stream (%)

Total Particulate Emission Rate, lb/hr

$$E_{lb/hr} = \frac{(M_n)(Q_{dstd})(60)}{(V_{m,std})(453.6)}$$

$$E_{lb/hr} = \frac{(0.0543)(385,124)(60)}{(48.61)(453.6)}$$

$$E_{lb/hr} = 56.9 \text{ lb / hr}$$

where:

$E_{lb/hr}$ = particulate emission rate (lb/hr)

M_n = total particulate catch (g)

$V_{m(std)}$ = volume of gas collected at standard conditions (scf)

Q_{dstd} = volumetric flow rate of the dry gas stream at standard conditions (dscfm)

60 = conversion factor (min/hr)

453.6 = conversion factor (g/lb)

⁴ All particulate emission rates are calculated in a similar manner.

Sample Calculations, Method 26A, Run 1

Concentration of Hydrogen Chloride in Flue Gas (lb/dscf)⁵

$$C_{HCl} = \frac{(M_{HCl})}{(V_{m(std)})(10^3)(453.59)}$$

$$C_{HCl} = \frac{(4.97)}{(84.70)(10^3)(453.59)}$$

$$C_{HCl} = 1.29 \times 10^{-7} \text{ lb / dscf}$$

where:

- C_{HCl} = concentration of hydrogen chloride in flue gas (lb/dscf)
- M_{HCl} = mass of hydrogen chloride collected in sample (mg)
- $V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)
- 10^3 = conversion factor (mg/g)
- 453.59 = conversion factor (g/lb)

Concentration of Hydrogen Chloride in Flue Gas (ppmdv)⁶

$$C_{ppmv} = \frac{(M_{HCl})(385.3)(10^6)}{(MW_{HCl})(V_{m(std)})(10^3)(453.59)}$$

$$C_{ppmv} = \frac{(4.97)(385.3)(10^6)}{(36.458)(84.70)(10^3)(453.59)}$$

$$C_{ppmv} = 1.37 \text{ ppmdv}$$

where:

- C_{ppmv} = concentration of hydrogen chloride in flue gas (ppmv)
- M_{HCl} = mass of hydrogen chloride collected in sample (mg)
- 385.3 = volume occupied by one pound gas at standard conditions (dscf/lbmole)
- 10^6 = conversion factor (fraction to ppm)
- MW_{HCl} = molecular weight of hydrogen chloride (lb/lb-mole)
- $V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)
- 10^3 = conversion factor (mg/g)
- 453.59 = conversion factor (g/lb)

⁵ The HF concentration was calculated in a similar manner.

⁶ The HF concentration was calculated in a similar manner.

Hydrogen Chloride Emission Rate, lb/mmBtu⁷

$$E_{HCl} = \frac{(C_{HCl})(F_d)(20.9)}{(20.9 - O_2)}$$

$$E_{HCl} = \frac{(1.29 \times 10^{-7})(9,628)(20.9)}{(20.9 - 6.20)}$$

$$E_{HCl} = 0.00177 \text{ lb/mmBtu}$$

where:

- E_{HCl} = hydrogen chloride emission rate, (lb/mmBtu)
- C_{HCl} = hydrogen chloride concentration, (lb/dscf)
- F_d = fuel factor (dscf/mmBtu)
- 20.9 = oxygen content of ambient air (%)
- % O_2 = oxygen content of the dry gas stream (%)

Hydrogen Chloride Emission Rate⁸

$$E_{HCl} = C_{HCl} \times Q_{dstd} \times 60$$

$$E_{HCl} = 1.29 \times 10^{-7} \times 366,612 \times 60$$

$$E_{HCl} = 2.85 \text{ lb/hr}$$

where:

- E_{HCl} = hydrogen chloride emission rate, (lb/hr)
- $C_{ppm dv}$ = hydrogen chloride concentration, dry basis, (ppm dv)
- Q_{dstd} = volumetric flow rate of the dry gas stream at standard conditions (dscfm)
- MW = molecular weight of hydrogen chloride (lb/lbmole)
- 60 = conversion factor (min/hr)
- 385.3 = volume occupied by one pound gas at standard conditions (dscf/lbmole)
- 10^6 = conversion factor (fraction to ppm)

⁷ The emission rate of HF is calculated in a similar manner.

⁸ The HF emission rate was calculated in a similar manner.

Sample Calculations, Method 29, Run 1

Concentration of Lead in Flue Gas, ug/dscm⁹

$$C_{ug/dscm} = \frac{(M_c)}{(V_{m(std)})} (35.31)$$

$$C_{ug/dscm} = \frac{(11.3)}{(65.56)} (35.31)$$

$$C_{ug/dscm} = 6.06 \text{ ug / dscm}$$

where:

- $C_{ug/dscm}$ = concentration of lead in flue gas (ug/dscm)
- M_c = mass of lead in sample (ug)
- $V_{m(std)}$ = volume of gas collected at standard temperature and pressure (scf)
- 35.31 = conversion factor (ft^3/m^3)

Emission Rate of Lead in Flue Gas, lb/mmBtu¹⁰

$$E = \frac{(C_{ug/dscm})(F_d)(20.9)}{(35.315)(20.9 - \%O_2)(453.6)(10^6)}$$

$$E = \frac{(6.06)(9,628)(20.9)}{(35.315)(20.9 - 6.20)(453.6)(10^6)}$$

$$E = 5.18 \times 10^{-6} \text{ mg / dscm @ 7\% } O_2$$

where:

- E = lead emission rate (lb/mmBtu)
- $C_{ug/dscm}$ = lead concentration (ug/dscm)
- F_d = fuel factor (dcsf/mmBtu)
- 35.315 = conversion factor (ft^3/m^3)
- 20.9 = oxygen content of ambient air (%)
- $\%O_2$ = oxygen content of the dry gas stream (%)
- 453.6 = conversion factor (g/lb)
- 10^6 = conversion factor (ug/g)

⁹ The concentrations of all MHs and mercury are calculated in a similar manner.

¹⁰ The emission rates of all MHs and mercury are calculated in a similar manner.

Lead Emission Rate, lb/hr

$$E_{lb/hr} = \frac{(C_{ug/dscm})(Q_{dstd})(60)}{(35.31)(10^6)(453.6)}$$

$$E_{lb/hr} = \frac{(6.06)(381,636)(60)}{(35.31)(10^3)(10^3)(453.6)}$$

$$E_{lb/hr} = 0.00867 lb/hr$$

where:

- $E_{lb/hr}$ = lead emission rate (lb/hr)
- $C_{ug/dscm}$ = lead concentration (ug/dscm)
- Q_{dstd} = volumetric flow rate of dry gas stream at standard conditions (dscfm)
- 10^3 = conversion factor (ug/mg)
- 10^3 = conversion factor (mg/g)
- 35.31 = conversion factor (ft³/m³)
- 60.0 = conversion factor (min/hr)
- 453.59 = conversion factor (g/lb)