



Steven L. Beshear
Governor

Leonard K. Peters
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P O. Box 615
Frankfort, Kentucky 40602-0615
Telephone (502) 564-3940
Fax (502) 564-3460
psc.ky.gov

David L. Armstrong
Chairman

James W. Gardner
Vice Chairman

Linda Breathitt
Commissioner

February 8, 2013

PARTIES OF RECORD

Re: Case No. 2012-00239

The attached summary report received via electronic mail message has been filed in the record of the above referenced case.

Sincerely,

A handwritten signature in black ink, appearing to read "Jeff Depouen".

Jeff Depouen
Executive Director

Attachment

Cc: Parties of record

KPSC Status Report

LG&E Project - Resetting Gas Regulator Facility Operating Pressures (As of February 1, 2013)

January – Work Completed

The resetting of operating pressures for all gas regulation facilities supplying LG&E's 60 psig distribution systems was completed January 11th. Resetting the operating pressures for all gas regulator facilities supplying the 50 psig distribution systems began January 14th and was completed February 1st. The 50 psig and 60 psig distribution systems combined serve 111,434 customers (approximately 35% of LG&E's total gas customers).

February – Work Planned

In February gas regulation technicians are scheduled to reset operating pressures at gas regulator facilities for single feed distribution systems with recent pressure excursions and resetting operating pressures on gas regulation facilities supplying LG&E's 35 psig systems.

Project Status Summary

Provided below is a table with completion percentage for resetting operating pressures of LG&E's distribution systems broken down primarily by pressure class. For each pressure class, the following data is provided: total customer count, total number of gas regulator facilities, number of gas regulator facilities that operating pressure has been reset, and percent complete for each pressure class.

Systems Pressure Class (psig)	No. Customers	Regulator Facilities		
		Total	No. Pressure Resets Completed	Percent Completed
60	53,120	15	15	100.0%
50	58,364	27	27	100.0%
35	149,103	96	0	0.0%
30	1,589	3	0	0.0%
20	14,684	10	0	0.0%
15	399	2	0	0.0%
Single feed ¹	12,058	174	3	1.7%
Totals	289,317	327	45	13.8%

¹ Single fed single gas regulator facilities supply a single distribution system and operate at various pressures