

**CANNONSBURG WATER DISTRICT**

1606 CANNONSBURG ROAD

ASHLAND, KY 41102

606-928-9808

FAX# 606-928-4788

[www.cannonsburgwater.com](http://www.cannonsburgwater.com)

RECEIVED

OCT 19 2015

PUBLIC SERVICE  
COMMISSION

October 9, 2015

Mr. Jeff Derouen  
Executive Director  
Public Service Commission  
PO Box 615  
Frankfort, KY 40602

RE: CASE NO 2014-00267  
Surcharge Monthly Activity Report

Dear Mr. Derouen:

Please find this as our monthly Sur-Charge activity report.

1. Cannonsburg Water District (CWD) had been obtaining the readings of 7 of the replacement master meters that were inoperable. One of the seven is getting a reading but there is no usage registering. We changed the boxes for the meters to have more room because the registers wires were too short to connect to the meters. Four are now not in operating order at this date. C. I. Thornburg Inc. are scheduled to come on Tuesday, October 13, 2015 to work on the registers that are not working now. We had not heard when the new registers will be shipped as C. I. Thornburg would not order them until the boxes were changed. We have told C. I. Thornburg that this is taking too long to resolve and they need to act on this ASAP!
2. CWD has found and repaired 10 water leaks throughout the District in the month of September 2015.
3. The Bids for the replacement of service lines are still not ready for bid due to the registers not working at this time on the master meters.

Sincerely,



Danny R. Clarkson  
Manager  
Enclosure