

*Cannonsburg Water District*  
*1606 Cannonsburg Road*  
*Ashland, KY 41102*  
*Office: (606) 928-9808*  
*Fax: (606) 928-4788*



October 12, 2016

Mr. Jeff Derouen  
Executive Director  
Public Service Commission  
PO Box 615  
Frankfort, KY 40602

RECEIVED

OCT 14 2016

Public Service  
Commission

RE: Case No. 2014-00267 – Surcharge Activity Report

Mr. Derouen,

Please take a moment to review the status and actions Cannonsburg Water District has taken this month to further gain control of its water loss.

CI Thornburg now has the parts to repair the Seamen meters used for zone measurements and has sent a request to their technical staff to make the repairs as soon as possible.

With regards to repairs, CWD has continued to have an unusually high amount of leaks this month due to the extremely dry conditions. 26 repairs were made this month with 16 of those repairs being service lines pulling or splitting near the main.

If at any time you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

Tim Webb  
General Manager