

Cannonsburg Water District
1606 Cannonsburg Road
Ashland, KY 41102
Office: (606) 928-9808
Fax: (606) 928-4788



November 11, 2016

RECEIVED

Mr. Jeff Derouen
Executive Director
Public Service Commission
PO Box 615
Frankfort, KY 40602

NOV 17 2016

Public Service
Commission

RE: Case No. 2014-00267 – Surcharge Activity Report

Mr. Derouen,

Please take a moment to review the status and actions Cannonsburg Water District has taken this month to further gain control of its water loss.

CI Thornburg has made repairs to (1) zone meter. (2) zone meters will require register replacement due to poor podding from the factor. As of this day I am awaiting a schedule for this to be completed. With the remaining meters, CWD has completed its billing and zoning area division. This will allow us to start comparing metered zones to billing once all meters are in operation.

CWD has still continued to work diligently on leak discovery and repair. 12 line repairs were completed I the month of October.

If at any time you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

Tim Webb
General Manager