

Cannonsburg Water District
1606 Cannonsburg Road
Ashland, KY 41102
Office: (606) 928-9808
Fax: (606) 928-4788



RECEIVED

January 10, 2017

JAN 17 2017

Public Service Commission
Attn: Jeff Derouen-Executive Director
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602

Public Service
Commission

RE: Case No. 2014-00267 – Water Loss Report

Mr. Derouen,

Please see the attached Water Use Report for the month of October.

This report is not reflective as of yet of the repair made in the Zone 8 area. The repair in that area was made at the end of November, the leak is still evident on this report and will still be seen on much of the November report.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Webb", is written over a horizontal line.

Tim Webb
General Manager

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:

For the Month of: Year:

LINE #	ITEM	GALLONS (Omit 000's)	
1	WATER PRODUCED, PURCHASED & DISTRIBUTED		
2	Water Produced	-	
3	Water Purchased	34,454,000	
4	TOTAL PRODUCED AND PURCHASED	34,454,000	
5	WATER SALES		
7	Residential	11,426,200	
8	Commercial	3,598,600	
9	Industrial	1,529,800	
10	Bulk Loading Stations	18,000	
11	Wholesale		
12	Other Sales		
13	TOTAL WATER SALES	16,572,600	48.1%
14	OTHER WATER USED		
16	Utility and/or Water Treatment Plant	35,800	
17	Wastewater Plant	-	
18	System Flushing	1,190,000	
19	Fire Department	6,000	
20	Other		
21	TOTAL OTHER WATER USED	1,231,800	3.6%
22	WATER LOSS		
24	Tank Overflows	-	
25	Line Breaks	1,712,000	
26	Line Leaks	14,937,600	
27	Other		
28	TOTAL LINE LOSS	16,649,600	48.3%
29			
30	Note: Line 13 + Line 21 + Line 28 Must Equal Line 4		
31			
32	WATER LOSS PERCENTAGE		
33	Unaccounted-For Water (Line 28 divided by Line 4)		48.3%