

*Cannonsburg Water District
1606 Cannonsburg Road
Ashland, KY 41102
Office: (606) 928-9808
Fax: (606) 928-4788*



April 13, 2018

Public Service Commission
Attn: Talina Mathews-Executive Director
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602

RECEIVED

APR 20 2018

PUBLIC SERVICE
COMMISSION

RE: Case No. 2014-00267 – Water Loss Report

Ms. Mathews,

Please see the attached Water Use Report for the month of January 2018.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Webb", is written over a horizontal line.

Tim Webb
General Manager

RECEIVED

APR 20 2018

PUBLIC SERVICE COMMISSION

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:

For the Month of: Year:

LINE #	ITEM	GALLONS (Omit 000's)	
1	WATER PRODUCED, PURCHASED & DISTRIBUTED		
2	Water Produced	-	
3	Water Purchased	43,718,000	
4	TOTAL PRODUCED AND PURCHASED	43,718,000	
5			
6	WATER SALES		
7	Residential	13,165,000	
8	Commercial	5,229,000	
9	Industrial	947,000	
10	Bulk Loading Stations	3,000	
11	Wholesale	11,129,000	
12	Other Sales	-	
13	TOTAL WATER SALES	30,473,000	69.7%
14			
15	OTHER WATER USED		
16	Utility and/or Water Treatment Plant	32,000	
17	Wastewater Plant	-	
18	System Flushing	118,000	
19	Fire Department	3,000	
20	Other	-	
21	TOTAL OTHER WATER USED	153,000	0.3%
22			
23	WATER LOSS		
24	Tank Overflows	-	
25	Line Breaks	1,317,000	
26	Line Leaks	11,775,000	
27	Other	-	
28	TOTAL LINE LOSS	13,092,000	29.9%
29			
30	Note: Line 13 + Line 21 + Line 28 Must Equal Line 4		
31			
32	WATER LOSS PERCENTAGE		
33	Unaccounted-For Water (Line 28 divided by Line 4)		29.9%