

CANNONSBURG WATER DISTRICT

1606 CANNONSBURG ROAD

ASHLAND, KY 41102

606-928-9808

FAX# 606-928-4788

www.cannonsburgwater.com

November 11, 2015

Mr. Jeff Derouen
Executive Director
Public Service Commission
PO Box 615
Frankfort, KY 40602

RECEIVED

NOV 17 2015

PUBLIC SERVICE
COMMISSION

RE: CASE NO 2014-00267
Surcharge Monthly Activity Report

Dear Mr. Derouen:

Please find this as our monthly Sur-Charge activity report.

1. Cannonsburg Water District is still not reading the Master Meters due to faulty equipment. Please find enclosed a copy of a letter from C I Thornburg Co., Inc. on their update on the master meters.
2. Alan Morrison, P.E. of C I Thornburg Co., Inc. informed me today that the meters are still not water proof and is meeting with the Siemens Mag Meter Co. this week to see what can be done with this problem.
3. CWD has found and repaired 15 water leaks throughout the District in the month of October 2015.
4. The Bids for the replacement of service lines are still not ready for bid due to the Master Meters not working at this time.

Sincerely,



Danny R. Clarkson
Manager
Enclosure



The C.I. Thornburg Co., Inc.

P.O. Box 2163 • Huntington, WV 25722
4034 Altizer Avenue • Huntington, WV 25705
(304) 523-3484 • FAX (304) 523-0510

October 26, 2015

Mr. Danny Clarkston
Cannonsburg Water District
1606 Cannonsburg Road
Cannonsburg, KY 41102

Re: Ten (10) 6" Main Line Meters

Dear Mr. Clarkston,

As promised in my August letter, we received and attempted installation of the replacement Siemens Transmitters on the non-reading Siemens Mag Meters. Unfortunately, the Transmitters received from Siemens were delivered without Battery Packs, Radio Cards and the Transmitters did not have the water sealing potting installed in the bottom of the Transmitters.

The Transmitters are here in our office in Huntington, and we are awaiting receipt of the missing parts from Siemens. We expect them within the next 1-2 weeks. These parts will be installed as soon as they are received and we will install them onto your non-reading meters

I continue to apologize for this situation, and promise our continued efforts.

If you have additional questions, please let me know. Thanks for your understanding and assistance on this project.

Sincerely,

The C. I. Thornburg Co., Inc.

A handwritten signature in cursive script that reads "AS Morrison".

Alan S. Morrison, P. E.
Business Development

Cc: Mr. Paul Amburgey, P. E.
E. L. Robinson Engineering Co.
3145 Greenup Ave.
Ashland, KY 41101

Leading the World Through Clean Water

Branch Offices: Bowling Green, KY • Bridgeport, WV • Huntington, WV • Nashville, TN
www.cithornburg.com

CANNONSBURG WATER DISTRICT

1606 CANNONSBURG ROAD

ASHLAND, KY 41102

606-928-9808

FAX# 606-928-4788

www.cannonsburgwater.com

November 9, 2015

Mr. Jeff Derouen
Executive Director
Public Service Commission
PO Box 615
Frankfort, KY 40602

Re: Case No. 2014-00267
Water Loss Report

Dear Mr. Derouen:

Please find enclosed copy of our water loss for August 2015.

If you have any further questions, please let me know.



Danny R. Clarkson
Manager

Enclosures

RECEIVED

NOV 17 2015

PUBLIC SERVICE
COMMISSION

Water Use Report

Water Utility: Cannonsburg Water District PWSID: KY0100064

For the Month of: August Year: 2015

1	PRODUCTION COST PER THOUSAND	\$0.00
2	PURCHASE COST PER THOUSAND	\$0.00

GALLONS

WATER PRODUCED or PURCHASED			
3	Water Produced	\$0.00	0
4	Water Purchased	\$0.00	36,882,100
5	TOTAL PRODUCED AND PURCHASED		36,882,100
6	TOTAL COST		\$0.00

0%
100%

WATER SOLD

7	Residential	13,886,300
8	Commercial	4,994,400
9	Industrial	7,533,300
10	Bulk Loading Stations	5,500
11	Wholesale	0
12	Other Sales (explain)	0

13	TOTAL WATER SOLD	26,419,500	71.63%
14	TOTAL WATER NOT SOLD	10,462,600	28.37%

BREAKDOWN OF WATER USAGE

15	Water Treatment Plant	25,000
16	Wastewater Treatment Plant	0
17	System Flushing	655,000
18	Fire Department Usage	100,000
19	Other Usage (explain)	0

20	TOTAL USAGE	780,000
----	--------------------	---------

21	WATER LOSS PERCENTAGE FOR RATE PURPOSES	26.25%
----	--	--------

BREAKDOWN OF WATER LOST

22	Tank Overflows	0
23	Excavation Breaks	0
24	Repaired Line Breaks	1,267,000
25	Unknown Loss	8,415,600

22.82%

26	TOTAL WATER NOT SOLD OR USED	9,682,600
27	COST OF WATER NOT SOLD OR USED	\$0.00

"UNKNOWN LOSS" FLOW RATE AND COST:		
28	"Unknown Loss"	8,415,600
29	% "Unknown Loss"	22.82%
30	Number of Days in Period	31
31	"Unknown Loss" per Day (Gallons per Day)	271,471
32	"Unknown Loss" per Minute (GPM)	188.52
33	"Unknown Loss" Cost for Month	\$0.00