

City of Liberty

P.O. Box 127 • Liberty, KY 42539

RECEIVED

AUG 21 2020

PUBLIC SERVICE
COMMISSION

August 18, 2020

Kentucky Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, KY 40602

Re: Case No. 2017-00053

Dear Commission,

The gas leakage survey for the Liberty Gas System was completed by Heath Consultants in July 2020. During the survey, two (2) grade 3 above ground leaks were discovered in Liberty's gas system.

The grade 3 leaks will be inspected routinely and repairs are on schedule to be made within the allotted time frame. Repair reports will be sent to the Commission as soon as they are repaired.

Please contact me at 606-787-9973 or libertybb@windstream.net for any questions or concerns.

Sincerely,



Bridgett Blake, City Clerk
City of Liberty, Kentucky



City Hall
(606) 787-9973

Utilities
(606) 787-6691

Fax (606) 787-7992

TDD # 1-800-247-2510




Leak Survey Report

CITY OF LIBERTY GAS DEPARTMENT

LIBERTY, KY.

Heath Consultants





Heath Consultants Incorporated

8-7-2020

Bridgett Blake
City of Liberty Gas Dept.
51 Jockey St.
Liberty, KY. 42539

Ms Blake,

This is your final report of the results obtained during the recently completed gas leakage control survey.

The summary page following will give you further details concerning your survey. Should you have any questions or comments regarding the survey or this report, please contact us at 615.361.8306.

We appreciate this opportunity to be of service to you and look forward to serving you again in the near future.

Sincerely,

Shawn Baumgardner
Director of Operations
Heath Consultants Incorporated



SUMMARY OF

Gas Leak Survey

LEAKAGE CONTROL SURVEY

City of Liberty Gas Dept.
Client

Liberty, KY.
City and State

40
District or Division

Conducted by our Consultant(s)

Marty Bryan

Date Start 7/28/2020

Date Completed 7/29/2020

Total Day 2

Number of Hours 16

Miles of Main Surveyed 32

Number of Services Inspected 490

Number of Leak Indications 2

Under Ground Classification*		
GR-1	GR-2	GR-3
0	0	0

Key Map Symbols

x Indicates Leak Indication

//// Estimated Area Affected

Δ Catch Basin

* Tree

[] House & Building

— Indicates the Main

— Represents curb line or edge of road
unless designated as property line.

Above Ground Classification*		
GR-1	GR-2	GR-3
0	0	2

Leak Indication Classification*

Grade 1- Schedule for Immediate Repair

Grade 2- Schedule for Repair after Grade 1

Indications are completed. Recheck
mandatory if leak cannot be repaired
within six months or before frost.

Grade 3- Repair as work scheduled permit if
Indications cannot be repaired within
one year, indication should be
checked.

Special Cases

Contact HEATH CONSULTANTS INCORPORATED for further information regarding any Special Cases such as analysis, sample collecting, investigation, verification, survey recheck, etc. Our Consultant will be available on 24-hour notice to assist you.

*Leak Indication is not an exact science in spite of use of the most modern instruments plus complete training and experience by the Consultant it is impossible to determine the exact condition of underground piping and equipment without actually exposing same. In view of this limitation our Consultant is intended as an aid in scheduling repairs based upon the information available, the Consultants judgment and and site conditions at the time the report is prepared. Variable factors beyond our control may alter this Classification at any time. Main and service line leak Indications are classified individually. Classifications for buildings where leakage is found refer to the situation as it applies to the entire building. Individual building leaks are not classified.



CONSULTANT'S WEEKLY RESUME

ORDER NO.:

CLIENT: City Of Liberty

WEEK ENDING: 08/01/20

LOCATION: Liberty Kentucky

DAYS TO COMPLETE SURVEY: _____

				UNDERGROUND LEAKS				ABOVE GROUND LEAKS							BILLABLE HOURS	
Date	Town	Miles	Services	1 or A	2 or B	3 or C	Reports	Buildings	Negative	Positive	1 or A	2 or B	3 or C	Leaks	Reports	
7/26																
7/27																
7/28	Liberty	16	258										2	2		8
7/29	Liberty	16	232													8
7/30																
7/31																
8/1																
	TOTAL FOR WEEK	32	490	0	0	0	0	0	0	0	0	0	2	2	0	16
	TOTAL THRU LAST WEEK	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	TOTAL TO DATE	32	490	0	0	0	0	0	0	0	0	0	2	2	0	16

Day	DPIR PPM	DPIR Alarm	Passed Test?	RMLD PPM-M	RMLD Alarm	Passed Test?	OMD PPM	OMD Alarm	Passed Test?
Sunday									
Monday									
Tuesday									
Wednesday									
Thursday									
Friday									
Saturday									

Calibration Verified: (delete one Yes or No) S/N

RMLD

DPIR

OMD

Marty C Bryan

Consultant

Above Ground Leaks



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 1

DATE	ROUTE	HOUSE#	ADDRESS	Grade	Remarks		
7/28/2020	102	374	Fair St	3	Wingcock		
7/28/2020	101	546	Middleburg St	3	Shutoff		

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 1

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	102	353	Fair St	OK		X
7/28/2020	102	374	Fair St	OK	xGR 3	X
7/28/2020	102	454	Whipp Av	OK		X
7/28/2020	102	240	Trammel St	OK		X
7/28/2020	102		Adams St	OK		X
7/28/2020	102	241	Trammel St	OK		X
7/28/2020	102	223	Trammel St	OK		X
7/28/2020	102	453	Adams St	OK		X
7/28/2020	102	427	Adams St	OK		X
7/28/2020	102	438	Adams St	OK		X
7/28/2020	102	210	Fair St	OK		X
7/28/2020	102	138	Fair St	OK		X
7/28/2020	102	110	Fair St	OK		X
7/28/2020	102	378	Wolford St	OK		X
7/28/2020	102	109	Fair St	OK		X
7/28/2020	102	349	Wolford St	OK		X
7/28/2020	102	352	Wolford St	OK		X
7/28/2020	102	338	Wolford St	NP		X
7/28/2020	102	339	Wolford St	OK		X
7/28/2020	102	323	Wolford St	OK		X
7/28/2020	102	320	Wolford St	OK		X
7/28/2020	102	112	Allen St	OK		X
7/28/2020	102	539	Allen St	OK		X
7/28/2020	102	411	Hustonville St	OK		X
7/28/2020	102	587	Allen St	OK		X
7/28/2020	102	109	Phillips St	OK		X
7/28/2020	102	109	Wall St	OK		X
7/28/2020	102	147	Wall St	OK		X
7/28/2020	102	167	Wall St	OK		X
7/28/2020	102	241	Phillips St	OK		X
7/28/2020	102	232	Phillips St	OK		X
7/28/2020	102	225	Phillips St	OK		X
7/28/2020	102	188	Phillips St	OK		X
7/28/2020	102	189	Phillips St	OK		X
7/28/2020	102	161	Phillips St	OK		X
7/28/2020	102	141	Phillips St	OK		X
7/28/2020	102	451	Hustonville St	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY
 TECHNICIAN: Marty C. Bryan
 PAGE: 2

LEGEND: AC Atmospheric Corrosion
 NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	102	540	Hustonville St	OK		X
7/28/2020	102	549	Hustonville St	OK		X
7/28/2020	102	612	Hustonville St	OK		X
7/28/2020	102	476	Carmicle St	NP		X
7/28/2020	102	464	Carmicle St	OK		X
7/28/2020	102	470	Carmicle St	OK		X
7/28/2020	102	453	Carmicle St	OK		X
7/28/2020	102	440	Carmicle St	OK		X
7/28/2020	102	427	Carmicle St	OK		X
7/28/2020	102	417	Carmicle St	OK		X
7/28/2020	102	404	Carmicle St	OK		X
7/28/2020	102	372	Carmicle St	OK		X
7/28/2020	102	360	Carmicle St	OK		X
7/28/2020	102	318	Carmicle St	OK		X
7/28/2020	102	410	Phillips St	OK		X
7/28/2020	102	425	Phillips St	OK		X
7/28/2020	102	844	Hustonville St	OK		X
7/28/2020	102	728	Hustonville St	OK		X
7/28/2020	102	450	Popplewell	OK		X
7/28/2020	102	432	Popplewell	OK		X
7/28/2020	102	388	Popplewell	OK		X
7/28/2020	102	369	Popplewell	OK		X
7/28/2020	102	651	Whipp Av	OK		X
7/28/2020	102	671	Wolford Av	OK		X
7/28/2020	102	578	Whipp Av	OK		X
7/28/2020	102	574	Whipp Av	OK		X
7/28/2020	102	521	Whipp Av	OK		X
7/28/2020	102	510	Whipp Av	OK		X
7/28/2020	102	451	Whipp Av	OK		X
7/28/2020	102	338	Trammel St	OK		X
7/28/2020	102	341	Trammel St	OK		X
7/28/2020	102	363	Trammel St	OK		X
7/28/2020	102	377	Trammel St	OK		X
7/28/2020	102	411	Trammel St	OK		X
7/28/2020	102	434	Weddle St	OK		X
7/28/2020	101	817	KY 49	OK		X
7/28/2020	101	219	Hustonville St	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 3

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	101	246	Hustonville St	OK		X
7/28/2020	101	283	Hustonville St	OK		X
7/28/2020	101	300	Hustonville St	OK		X
7/28/2020	101	327	Hustonville St	OK		X
7/28/2020	101	52	Combest St	NP		X
7/28/2020	101	367	Hustonville St	OK		X
7/28/2020	101	625	Campbellsville St	OK		X
7/28/2020	101	231	Campbellsville St	OK		X
7/28/2020	101	169	Courthouse SQ	OK		X
7/28/2020	101	169	Courthouse SQ	OK		X
7/28/2020	101	763	Campbellsville St	OK		X
7/28/2020	101	913	Campbellsville St	OK		X
7/28/2020	101	932	Campbellsville St	OK		X
7/28/2020	101	966	Campbellsville St	OK		X
7/28/2020	101	959	Campbellsville St	OK		X
7/28/2020	101	1019	Campbellsville St	OK		X
7/28/2020	101	1087	Campbellsville St	OK		X
7/28/2020	101	1140	Campbellsville St	OK		X
7/28/2020	101	1109	Campbellsville St	OK		X
7/28/2020	101	1139	Campbellsville St	OK		X
7/28/2020	101	1139	Campbellsville St	OK		X
7/28/2020	101	1172	Campbellsville St	OK		X
7/28/2020	101		Campbellsville St	OK		X
7/28/2020	101	1188	Campbellsville St	NP	xGR3	X
7/28/2020	101	812	Campbellsville St	OK		X
7/28/2020	101	770	Campbellsville St	OK		X
7/28/2020	101	752	Campbellsville St	OK		X
7/28/2020	101	718	Campbellsville St	OK		X
7/28/2020	101	770	Campbellsville St	OK		X
7/28/2020	101		Gosser St	OK		X
7/28/2020	101	668	Campbellsville St	OK		X
7/28/2020	101	664	Campbellsville St	OK		X
7/28/2020	101	654	Campbellsville St	OK		X
7/28/2020	101	636	Campbellsville St	OK		X
7/28/2020	101	630	Campbellsville St	OK		X
7/28/2020	101	628	Campbellsville St	OK		X
7/28/2020	101	628	Campbellsville St	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 4

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	101	626	Campbellsville St	OK		X
7/28/2020	101	626	Campbellsville St	OK		X
7/28/2020	101	33	Hustonville St	OK		X
7/28/2020	101	33	Hustonville St	OK		X
7/28/2020	101	58	Hustonville St	OK		X
7/28/2020	101	58	Hustonville St	OK		X
7/28/2020	101	56	Hustonville St	NP		X
7/28/2020	101	36	Hustonville St	OK		X
7/28/2020	101	546	Middleburg St	NP	xGR3	X
7/28/2020	101	14	Hustonville St	OK		X
7/28/2020	101	108	Hustonville St	OK		X
7/28/2020	101	132	Hustonville St	OK		X
7/28/2020	101	11	KY 49	OK		X
7/28/2020	101	30	Brown Ct	OK		X
7/28/2020	101	54	Brown Ct	OK		X
7/28/2020	101	75	Brown Ct	OK		X
7/28/2020	101	82	Brown Ct	OK		X
7/28/2020	101	163	Hustonville St	OK		X
7/28/2020	101	95	KY 49	OK		X
7/28/2020	101	124	KY 49	NP		X
7/28/2020	101	142	KY 49	OK		X
7/28/2020	101	142	KY 49	OK		X
7/28/2020	101	158	KY 49	OK		X
7/28/2020	101	43	Bartie Heights	OK		X
7/28/2020	101	216	KY 49	OK		X
7/28/2020	101	230	KY 49	NP		X
7/28/2020	101	250	KY 49	NP		X
7/28/2020	101	278	KY 49	NP		X
7/28/2020	101	454	KY 49	NP		X
7/28/2020	101	501	KY 49	OK		X
7/28/2020	101	625	KY 49	OK		X
7/28/2020	101	693	KY 49	OK		X
7/28/2020	101	785	KY 49	OK		X
7/28/2020	103	176	Wolfert Av	OK		X
7/28/2020	103	52	Montgomery Av	OK		X
7/28/2020	103	105	Montgomery Av	NP		X
7/28/2020	103	53	Montgomery Av	NP		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 5

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	103	31	Montgomery Av	OK		X
7/28/2020	103	14	Montgomery Av	OK		X
7/28/2020	103	150	Foster St	OK		X
7/28/2020	103	150	Foster St	OK		X
7/28/2020	103	99	Wallace Wilkerson	OK		X
7/28/2020	103	150	Wallace Wilkerson	OK		X
7/28/2020	103	150	Foster St	OK		X
7/28/2020	103	115	Wallace Wilkerson	OK		X
7/28/2020	103	115	Wallace Wilkerson	OK		X
7/28/2020	103	34	Foster St	OK		X
7/28/2020	103	271	Wolford Av	OK		X
7/28/2020	103	139	Allen St	OK		X
7/28/2020	103	222	Allen St	OK		X
7/28/2020	103	223	Allen St	OK		X
7/28/2020	103	269	Adams St	OK		X
7/28/2020	103	312	Adams St	OK		X
7/28/2020	103	328	Adams St	OK		X
7/28/2020	103	351	Adams St	OK		X
7/28/2020	103	356	Adams St	OK		X
7/28/2020	103	139	Fair St	OK		X
7/28/2020	103	280	Fair St	OK		X
7/28/2020	103	379	Whipp Av	OK		X
7/28/2020	103	340	Whipp Av	OK		X
7/28/2020	103	356	Allen St	OK		X
7/28/2020	103	418	Allen St	OK		X
7/28/2020	103	452	Allen St	OK		X
7/28/2020	103	455	Allen St	OK		X
7/28/2020	103	398	Beldon Av	OK		X
7/28/2020	103	397	Beldon Av	OK		X
7/28/2020	103	384	Beldon Av	OK		X
7/28/2020	103	364	Beldon Av	OK		X
7/28/2020	103	321	Beldon Av	OK		X
7/28/2020	103	316	Beldon Av	OK		X
7/28/2020	103	280	Beldon Av	OK		X
7/28/2020	103	250	Beldon Av	OK		X
7/28/2020	103	241	Beldon Av	OK		X
7/28/2020	103	107	Beldon Av	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 6

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	103	32	Beldon Av	OK		X
7/28/2020	103	58	Beldon Av	OK		X
7/28/2020	103	72	Beldon Av	OK		X
7/28/2020	103	88	Beldon Av	OK		X
7/28/2020	103	98	Beldon Av	OK		X
7/28/2020	103	116	Beldon Av	OK		X
7/28/2020	103	451	Beldon Av	OK		X
7/28/2020	103	444	Beldon Av	OK		X
7/28/2020	103	425	Beldon Av	OK		X
7/28/2020	103	334	Montgomery	OK		X
7/28/2020	103	362	Montgomery	OK		X
7/28/2020	103	108	Taylor St	OK		X
7/28/2020	103	410	Montgomery	OK		X
7/28/2020	103	136	Taylor St	OK		X
7/28/2020	103	164	Taylor St	OK		X
7/28/2020	103	176	Taylor St	OK		X
7/28/2020	103	205	Taylor St	OK		X
7/28/2020	103	214	Taylor St	OK		X
7/28/2020	103	228	Taylor St	OK		X
7/28/2020	103	237	Taylor St	OK		X
7/28/2020	103	244	Taylor St	OK		X
7/28/2020	103	253	Taylor St	OK		X
7/28/2020	103	271	Taylor St	OK		X
7/28/2020	103	369	Allen St	OK		X
7/28/2020	103	351	Allen St	OK		X
7/28/2020	103	331	Allen St	OK		X
7/28/2020	103	292	Allen St	OK		X
7/28/2020	103	278	Allen St	OK		X
7/28/2020	103	275	Whipp Av	OK		X
7/28/2020	103	261	Whipp Av	OK		X
7/28/2020	103	264	Whipp Av	OK		X
7/28/2020	103	252	Whipp Av	OK		X
7/28/2020	103	236	Whipp Av	OK		X
7/28/2020	103	245	Whipp Av	OK		X
7/28/2020	103	231	Whipp Av	OK		X
7/28/2020	103	217	Whipp Av	OK		X
7/28/2020	103	199	Whipp Av	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 7

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/28/2020	103	218	Whipp Av	OK		X
7/28/2020	103	198	Whipp Av	OK		X
7/28/2020	103	190	Whipp Av	OK		X
7/28/2020	103	189	Whipp Av	OK		X
7/28/2020	103	178	Whipp Av	OK		X
7/28/2020	103	166	Whipp Av	OK		X
7/28/2020	103	173	Whipp Av	OK		X
7/28/2020	103	163	Whipp Av	OK		X
7/28/2020	103	150	Whipp Av	OK		X
7/28/2020	103	139	Whipp Av	OK		X
7/28/2020	103	111	Whipp Av	OK		X
7/28/2020	103	315	Montgomery	OK		X
7/28/2020	103	276	Montgomery	OK		X
7/28/2020	103		Sanders St	OK		X
7/28/2020	103	154	Sanders St	OK		X
7/28/2020	103	174	Sanders St	OK		X
7/28/2020	103	236	Sanders St	OK		X
7/28/2020	103	198	Sanders St	OK		X
7/28/2020	103	75	College St	OK		X
7/28/2020	103	98	College St	OK		X
7/28/2020	103	58	College St	OK		X
7/28/2020	103	80	College St	OK		X
7/28/2020	103	121	Montgomery	OK		X
7/28/2020	103	116	Montgomery	OK		X
7/28/2020	103		Montgomery	OK		X
7/28/2020	103	192	Wolford	OK		X
7/28/2020	103	206	Wolford	OK		X
7/28/2020	103	230	Wolford	OK		X
7/28/2020	103	244	Wolford	OK		X
7/28/2020	103	241	Wolford	OK		X
7/28/2020	103	244	Adams St	OK		X
7/28/2020	103	251	Adams St	OK		X
7/28/2020	103	237	Adams St	OK		X
7/28/2020	103	227	Adams St	OK		X
7/28/2020	103	211	Adams St	OK		X
7/28/2020	103	134	Griffin St	OK		X
7/29/2020	104	511	N. Wilkinson	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 8

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	104	543	N Wilkinson	OK		X
7/29/2020	104	579	N Wallace Wilkinson	OK		X
7/29/2020	104	112	Dillon St	OK		X
7/29/2020	104	112	Dillon St	OK		X
7/29/2020	104	130	Dillon St	OK		X
7/29/2020	104	130	Dillon St	OK		X
7/29/2020	104	150	Dillon St	OK		X
7/29/2020	104	150	Dillon St	OK		X
7/29/2020	104	180	Dillon St	OK		X
7/29/2020	104	260	Dillon St	OK		X
7/29/2020	104	260	Dillon St	OK		X
7/29/2020	104	230	Dillon St	OK		X
7/29/2020	104	212	Dillon St	OK		X
7/29/2020	104	15	RiverdaleDr	OK		X
7/29/2020	104	35	RiverdaleDr	OK		X
7/29/2020	104	19	RiverdaleDr	OK		X
7/29/2020	104	19	RiverdaleDr	OK		X
7/29/2020	104	700	N Wilkinson	OK		X
7/29/2020	104	19	RiverdaleDr	OK		X
7/29/2020	104	25	RiverdaleDr	OK		X
7/29/2020	104	25	RiverdaleDr	OK		X
7/29/2020	104	25	RiverdaleDr	OK		X
7/29/2020	104	25	RiverdaleDr	OK		X
7/29/2020	104	20	RiverdaleDr	OK		X
7/29/2020	104	20	RiverdaleDr	OK		X
7/29/2020	104	20	RiverdaleDr	OK		X
7/29/2020	104	20	RiverdaleDr	OK		X
7/29/2020	104	750	N Wilkinson	OK		X
7/29/2020	104		Dillon St	OK		X
7/29/2020	104	85	RiverdaleDr	OK		X
7/29/2020	104	85	RiverdaleDr	OK		X
7/29/2020	104	85	RiverdaleDr	OK		X
7/29/2020	104	85	RiverdaleDr	OK		X
7/29/2020	104	50	RiverdaleDr	OK		X
7/29/2020	104	50	RiverdaleDr	OK		X
7/29/2020	104	50	RiverdaleDr	OK		X
7/29/2020	104	50	RiverdaleDr	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 9

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	104	100	Riverdale Dr	OK		X
7/29/2020	104	100	Riverdale Dr	OK		X
7/29/2020	104	100	Riverdale Dr	OK		X
7/29/2020	104	100	Riverdale Dr	OK		X
7/29/2020	104	90	Riverdale Dr	OK		X
7/29/2020	104	90	Riverdale Dr	OK		X
7/29/2020	104	90	Riverdale Dr	OK		X
7/29/2020	104	90	Riverdale Dr	OK		x
7/29/2020	104	735	N Wilkinson	OK		X
7/29/2020	104	936	N Wilkinson	OK		X
7/29/2020	104	968	N Wilkinson	OK		X
7/29/2020	104	735	N Wilkinson	OK		X
7/29/2020	104	775	N Wilkinson	OK		X
7/29/2020	104	1200	Wallace Wilkinson	OK		X
7/29/2020	104	750	Wallace Wilkinson	OK		X
7/29/2020	104	750	Wallace Wilkinson	OK		X
7/29/2020	104	1621	N Wilkinson	OK		X
7/29/2020	104	1699	N Wilkinson	OK		X
7/29/2020	104	1749	Wallace Wilkinson	OK		X
7/29/2020	104		N Hwy 127	NP		X
7/29/2020	104	46	Farmers Bank Dr	OK		X
7/29/2020	104	46	Farmers Bank Dr	OK		X
7/29/2020	104	1031	Hustonville St	OK		X
7/29/2020	104	1024	Hustonville St	OK		X
7/29/2020	104	1004	Hustonville St	OK		X
7/29/2020	104	37	Middleburg St	OK		X
7/29/2020	104	57	Middleburg St	OK		X
7/29/2020	104	58	Middleburg St	OK		X
7/29/2020	104	74	Middleburg St	OK		X
7/29/2020	104	94	Middleburg St	OK		X
7/29/2020	104	89	Middleburg St	OK		X
7/29/2020	104	115	Middleburg St	OK		X
7/29/2020	104	106	Middleburg St	OK		X
7/29/2020	104	118	Middleburg St	OK		X
7/29/2020	104	248	Middleburg St	OK		X
7/29/2020	104	233	Middleburg St	OK		X
7/29/2020	104	253	Middleburg St	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 10

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	104	266	Middleburg St	OK		X
7/29/2020	104	296	Middleburg St	OK		X
7/29/2020	104	322	Middleburg St	OK		X
7/29/2020	104	275	Middleburg St	OK		X
7/29/2020	104	44	Maple	OK		X
7/29/2020	104	57	Maple	OK		X
7/29/2020	104	71	Maple	OK		X
7/29/2020	104	138	Middleburg St	OK		X
7/29/2020	104	173	Middleburg St	OK		X
7/29/2020	104	209	Middleburg St	OK		X
7/29/2020	104	38	Conner St	OK		X
7/29/2020	104	62	Conner St	OK		X
7/29/2020	104	79	Conner St	OK		X
7/29/2020	104	238	Middleburg St	OK		X
7/29/2020	104	58	Maple	OK		X
7/29/2020	104	80	Maple	OK		X
7/29/2020	104	77	Northcut St	OK		X
7/29/2020	104	120	Randolph St	OK		X
7/29/2020	104	323	Middleburg St	OK		X
7/29/2020	104	417	Middleburg St	OK		X
7/29/2020	104	414	Middleburg St	OK		X
7/29/2020	104	438	Middleburg St	OK		X
7/29/2020	104	14	Beldon St	OK		X
7/29/2020	104	511	Middleburg St	OK		X
7/29/2020	104	511	Middleburg St	OK		X
7/29/2020	104	523	Middleburg St	OK		X
7/29/2020	104	529	Middleburg St	OK		X
7/29/2020	104	535	Middleburg St	OK		X
7/29/2020	104	539	Middleburg St	OK		X
7/29/2020	104		Middleburg St	OK		X
7/29/2020	104	113	Courthouse SQ	OK		X
7/29/2020	104	133	Courthouse SQ	OK		X
7/29/2020	104	137	Courthouse SQ	OK		X
7/29/2020	104	92	N Wilkinson	OK		X
7/29/2020	104	130	N Wilkinson	OK		X
7/29/2020	104	176	N Wilkinson	OK		X
7/29/2020	104	206	N Wilkinson	OK		X



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 11

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	104	224	N Wilkinson	OK		X
7/29/2020	104	261	Wallace Wilkinson	OK		X
7/29/2020	104	245	Wallace Wilkinson	OK		X
7/29/2020	104	245	Wallace Wilkinson	OK		X
7/29/2020	104	223	N Wilkinson	OK		X
7/29/2020	104	245	N Wilkinson	OK		X
7/29/2020	104		N Wilkinson	NP		X
7/29/2020	104	371	N Wilkinson	OK		X
7/29/2020	104	397	N Wilkinson	OK		X
7/29/2020	104	410	N Wilkinson	OK		X
7/29/2020	104	100	Liberty St	OK		X
7/29/2020	104	112	Liberty St	OK		X
7/29/2020	104	112	Liberty St	OK		X
7/29/2020	104	122	Liberty St	OK		X
7/29/2020	104	140	Liberty St	OK		X
7/29/2020	104	150	Liberty St	OK		X
7/29/2020	104	154	Liberty St	OK		X
7/29/2020	104	49	Scanlon Dr	OK		X
7/29/2020	104	436	Wallace Wilkinson	OK		X
7/29/2020	105	1713	KY 49	OK		X
7/29/2020	105	1705	KY 49	OK		X
7/29/2020	105	1714	KY 49	OK		X
7/29/2020	105	1870	KY 49	OK		X
7/29/2020	105	1830	KY 49	OK		X
7/29/2020	105	1976	KY 49	OK		X
7/29/2020	105	2063	KY 49	OK		X
7/29/2020	105	2411	KY 49	OK		X
7/29/2020	105	3265	KY 49	OK		X
7/29/2020	105	3804	KY 49	OK		X
7/29/2020	105	3804	KY 49	OK		X
7/29/2020	105	5227	KY 49	OK		X
7/29/2020	105	5917	KY 49	OK		X
7/29/2020	105	6290	KY 49	OK		X
7/29/2020	105	7009	KY 49	OK		X
7/29/2020	105	4399	Caney Fork	OK		X
7/29/2020	105	7293	KY 49	OK		X
7/29/2020	105	7276	KY 49	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 12

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	105	7486	KY 49	OK		X
7/29/2020	105	7806	KY 49	OK		X
7/29/2020	105	11669	KY 49	OK		X
7/29/2020	105	11168	KY 49	OK		X
7/29/2020	105	165	Button Knob	OK		X
7/29/2020	105	10963	KY 1547	OK		X
7/29/2020	105	11138	KY 1547	OK		X
7/29/2020	105	617	Button Knob	OK		X
7/29/2020	105	653	Button Knob	OK		X
7/29/2020	105	10520	KY 1547	OK		X
7/29/2020	105	10253	KY 1547	OK		X
7/29/2020	105	10167	KY 1547	OK		X
7/29/2020	105	10045	KY 1547	OK		X
7/29/2020	105	10006	KY 1547	OK		X
7/29/2020	105	9972	KY 1547	OK		X
7/29/2020	105	14	Sheepskin RD	OK		X
7/29/2020	105	9758	KY 1547	OK		X
7/29/2020	105	9748	KY 1547	OK		X
7/29/2020	105	9717	KY 1547	OK		X
7/29/2020	105	9653	KY 1547	OK		X
7/29/2020	105	356	Bartle Dr	OK		X
7/29/2020	105	1166	Woodrum Rd	OK		X
7/29/2020	105	1106	Woodrum Rd	OK		X
7/29/2020	105	1256	Woodrum Rd	OK		X
7/29/2020	105	139	Viewpoint Dr	OK		X
7/29/2020	105	1491	Woodrum Rd	OK		X
7/29/2020	105	224	Viewpoint Dr	OK		X
7/29/2020	105	1817	Viewpoint Dr	OK		X
7/29/2020	105	107	Woodrum Rd	OK		X
7/29/2020	105	107	Woodrum Rd	OK		X
7/29/2020	105	909	Hustonville	OK		X
7/29/2020	105	221	Napier	OK		X
7/29/2020	105	100	Napier	OK		X
7/29/2020	105	100	Napier	OK		X
7/29/2020	105	100	Napier	OK		X
7/29/2020	105	187	Woodrum Rd	OK		X
7/29/2020	105	162	Sweeney	OK		X

Leak Survey 2020



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 13

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
7/29/2020	105	200	Sweeney	OK		X
7/29/2020	105	256	Sweeney	OK		X
7/29/2020	105	1152	KY 70	OK		X
7/29/2020	105	1168	KY 70	OK		X
7/29/2020	105	1190	KY 70	OK		X
7/29/2020	105	1305	KY 70	OK		X
7/29/2020	105	1377	KY 70	OK		X
7/29/2020	105	1397	KY 70	OK		X
7/29/2020	105	1423	KY 70	OK		X
7/29/2020	105	1423	KY 70	OK		X
7/29/2020	105	1533	KY 70	OK		X
7/29/2020	105	1520	KY 70	OK		X
7/29/2020	105	1563	KY 70	OK		X
7/29/2020	105	1611	KY 70	OK		X
7/29/2020	105	1841	KY 70	OK		X
7/29/2020	105	1723	KY 70	OK		X
7/29/2020	105	1841	KY 70	OK		X
7/29/2020	105	1841	KY 70	OK		X
7/29/2020	105	1841	KY 70	OK		X
7/29/2020	105	1983	KY 70	OK		X
7/29/2020	105	1983	KY 70	OK		X
7/29/2020	105		KY 70	OK		X
7/29/2020	105	1983	KY 70	OK		X
7/29/2020	105		KY 70	OK		X
7/29/2020	105	225	S Wilkinson	OK		X
7/29/2020	105	155	S Wilkinson	OK		X
7/29/2020	105	289	S Wilkinson	OK		X
7/29/2020	105	155	S Wilkinson	OK		X
7/29/2020	105	253	S Wilkinson	OK		X
7/29/2020	105	581	S Wilkinson	OK		X
7/29/2020	105	126	Sharp Hollow	OK		X
7/29/2020	105	54	Sharp Hollow	OK		X
7/29/2020	105	611	S Wilkinson	OK		X
7/29/2020	105	54	Sharp Hollow	OK		X
7/29/2020	105	616	S Wilkinson	OK		X
7/29/2020	105	690	S Wilkinson	OK		X
7/29/2020	105	713	S Wilkinson	OK		X

Leak Survey 2020



COMPANY: Liberty Utilitlies, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 14

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

[illegible]