

City of Liberty

518 Middleburg Street, PO Box 127, Liberty, KY 42539
606-787-9973 – fax 606-787-7992

RECEIVED

SEP 02 2022

PUBLIC SERVICE
COMMISSION

August 23, 2022

Kentucky Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, KY 40602

Re: Case No. 2017-00053

Dear Commission,

The gas leakage survey for the Liberty Gas System was completed by Heath Consultants in August 2022. No leaks were discovered during the survey.

Please contact me at 606-787-9973 or libertybb@windstream.net for any questions or concerns.

Sincerely,




Bridgett Blake, City Clerk
City of Liberty, Kentucky

Leak Survey Report

CITY OF LIBERTY GAS DEPARTMENT

LIBERTY, KY.

Heath Consultants





Heath Consultants Incorporated

8-18-2022

Bridgett Blake
City of Liberty Gas Dept.
51 Jockey St.
Liberty, KY. 42539

Ms. Blake,

This is your final report of the results obtained during the recently completed gas leakage control survey.

The summary page following will give you further details concerning your survey. Should you have any questions or comments regarding the survey or this report, please contact us at 615.361.8306.

We appreciate this opportunity to be of service to you and look forward to serving you again in the near future.

Sincerely,

A handwritten signature in black ink, appearing to read "Shawn Baumgardner".

Shawn Baumgardner
Director of Operations
Heath Consultants Incorporated



SUMMARY OF Gas Leak Survey
LEAKAGE CONTROL SURVEY

City of Liberty Gas Dept. Liberty, KY 40
Client **City and State** **District or Division**

Conducted by our Consultant(s) Marty Bryan

Date Start 8/9/2022 **Date Completed** 8/10/2022 **Total Day** 2

Number of Hours 16.5

Miles of Main Surveyed 32

Number of Services Inspected 453

Number of Leak Indications 0

Under Ground Classification*		
GR-1	GR-2	GR-3
0	0	0

Above Ground Classification*		
GR-1	GR-2	GR-3
0	0	0

Key Map Symbols
 x Indicates Leak Indication
 /// Estimated Area Affected
 Δ Catch Basin
 * Tree
 □ House & Building
 ---Indicates the Main
 ____ Represents curb line or edge of road unless designated as property line.

Leak Indication Classification*
 Grade 1- Schedule for Immediate Repair
 Grade 2- Schedule for Repair after Grade 1 indications are completed. Recheck mandatory if leak cannot be repaired within six months or before frost.
 Grade 3- Repair as work scheduled permit if indications cannot be repaired within one year, indication should be checked.

Special Cases

Contact HEATH CONSULTANTS INCORPORATED for further information regarding any Special Cases such as analysis, sample collecting, investigation, verification, survey recheck, etc. Our Consultant will be available on 24-hour notice to assist you.

*Leak indication is not an exact science in spite of use of the most modern instruments plus complete training and experience by the Consultant it is impossible to determine the exact condition of underground piping and equipment without actually exposing same. In view of this limitation our Consultant is intended as an aid in scheduling repairs based upon the information available, the Consultants judgment and and site conditions at the time the report is prepared. Variable factors beyond our control may alter this Classification at any time. Main and service line leak indications are classified individually. Classifications for buildings where leakage is found refer to the situation as it applies to the entire building. Individual building leaks are not classified.



CONSULTANT'S WEEKLY RESUME

ORDER NO.: _____

CLIENT: Liberty Utilities

WEEK ENDING: 08/13/22

LOCATION: Liberty Kentucky

DAYS TO COMPLETE SURVEY: _____

				UNDERGROUND LEAKS				ABOVE GROUND LEAKS							BILLABLE HOURS		
Date	Town	Miles	Services	1 or C	2 or B	3 or A	Reports	Buildings	Negative	Positive	1 or C	2 or B	3 or A	Leaks	Reports		
8/7																	
8/8	Billable Travel																5.75
8/9	Liberty	16	259														8.5
8/10	Liberty	16	194														8
8/11	Billable Travel																5.75
8/12																	
8/13																	
TOTAL FOR WEEK		32	453	0	0	0	0	0	0	0	0	0	0	0	0	0	28
TOTAL THRU LAST WEEK		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8
TOTAL TO DATE		32	453	0	0	0	0	0	0	0	0	0	0	0	0	0	36

Day	DPIR PPM	DPIR Alarm	Passed Test?	RMLD PPM-M	RMLD Alarm	Passed Test?	OMD PPM	OMD Alarm	Passed Test?
Sunday									
Monday									
Tuesday									
Wednesday									
Thursday									
Friday									
Saturday									

Calibration Verified: (delete one Yes or No) S/N

RMLD _____

DPIR _____

OMD _____

Marty C Bryan
Consultant

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 1

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	102	539	Allen St	OK		X
8/9/2022	102	411	Hustonville St	OK		X
8/9/2022	102	587	Allen St	OK		X
8/9/2022	102	109	Wall St	OK		X
8/9/2022	102	147	Wall St	OK		X
8/9/2022	102	167	Wall St	OK		x
8/9/2022	102	241	Phillips St	OK		X
8/9/2022	102	232	Phillips St	OK		X
8/9/2022	102	225	Phillips St	OK		X
8/9/2022	102	189	Phillips St	OK		X
8/9/2022	102	161	Phillips St	OK		X
8/9/2022	102	141	Phillips St	OK		X
8/9/2022	102	540	Hustonville St	OK		x
8/9/2022	102	549	Hustonville St	OK		x
8/9/2022	102	476	Carmicle St	OK		x
8/9/2022	102	463	Carmicle St	OK		x
8/9/2022	102	470	Carmicle St	OK		x
8/9/2022	102	453	Carmicle St	OK		x
8/9/2022	102	440	Carmicle St	OK		x
8/9/2022	102	430	Carmicle St	OK		x
8/9/2022	102	427	Carmicle St	OK		x
8/9/2022	102	417	Carmicle St	OK		x
8/9/2022	102	360	Carmicle St	OK		x
8/9/2022	102	410	Phillips St	OK		x
8/9/2022	102	425	Phillips St	OK		x
8/9/2022	102	740	Hustonville St	OK		x
8/9/2022	102	450	Popplewell St	OK		x
8/9/2022	102	435	Popplewell St	OK		x
8/9/2022	102	369	Popplewell St	OK		x
8/9/2022	102	651	Whipp Av	OK		x
8/9/2022	102	671	Wolford Av	OK		x
8/9/2022	102	578	Whipp Av	OK		x
8/9/2022	102	521	Whipp Av	OK		X
8/9/2022	102	510	Whipp Av	OK		x
8/9/2022	102	338	Trammell St	OK		x
8/9/2022	102	341	Trammell St	OK		x
8/9/2022	102	377	Trammell St	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 2

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	102	426	Trammell St	OK		x
8/9/2022	102	438	Trammell St	OK		x
8/9/2022	102	411	Trammell St	OK		x
8/9/2022	102	434	Weddle St	OK		x
8/9/2022	102	353	Fair St	OK		x
8/9/2022	102	454	Whipp Av	OK		x
8/9/2022	102	240	Trammell St	OK		x
8/9/2022	102		Adams St	OK		x
8/9/2022	102	241	Trammell St	OK		x
8/9/2022	102	378	Wolford Av	OK		x
8/9/2022	102	109	Fair St	OK		x
8/9/2022	102	357	Wolford Av	OK		x
8/9/2022	102	339	Wolford Av	OK		x
8/9/2022	102	323	Wolford Av	OK		x
8/9/2022	102	320	Wolford Av	OK		x
8/9/2022	102	112	Allen St	OK		x
8/9/2022	103	340	Whipp Av	OK		x
8/9/2022	103	356	Allen St	OK		x
8/9/2022	103	418	Allen St	OK		x
8/9/2022	103	452	Allen St	OK		x
8/9/2022	103	455	Allen St	OK		x
8/9/2022	103	397	Beldon St	OK		x
8/9/2022	103	384	Beldon St	OK		x
8/9/2022	103	364	Beldon St	OK		x
8/9/2022	103	321	Beldon St	OK		x
8/9/2022	103	314	Beldon St	OK		x
8/9/2022	103	280	Beldon St	OK		x
8/9/2022	103	250	Beldon St	OK		x
8/9/2022	103	241	Beldon St	OK		x
8/9/2022	103	107	Beldon St	OK		x
8/9/2022	103	36	Beldon St	OK		x
8/9/2022	103	58	Beldon St	OK		x
8/9/2022	103	72	Beldon St	OK		x
8/9/2022	103	88	Beldon St	OK		x
8/9/2022	103	116	Beldon St	OK		x
8/9/2022	103	451	Montgomery	OK		x
8/9/2022	103	444	Montgomery	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 3

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	103	425	Montgomery	OK		x
8/9/2022	103	334	Montgomery	OK		x
8/9/2022	103	362	Montgomery	OK		x
8/9/2022	103	108	Taylor St	OK		x
8/9/2022	103	410	Montgomery	OK		x
8/9/2022	103	136	Taylor St	OK		x
8/9/2022	103	164	Taylor St	OK		x
8/9/2022	103	176	Taylor St	OK		x
8/9/2022	103	205	Taylor St	OK		x
8/9/2022	103	237	Taylor St	OK		x
8/9/2022	103	244	Taylor St	OK		x
8/9/2022	103	253	Taylor St	OK		x
8/9/2022	103	271	Taylor St	OK		x
8/9/2022	103	369	Allen St	OK		x
8/9/2022	103	351	Allen St	OK		x
8/9/2022	103	331	Allen St	OK		x
8/9/2022	103	292	Whipp Av	OK		x
8/9/2022	103	274	Whipp Av	OK		x
8/9/2022	103	275	Whipp Av	OK		x
8/9/2022	103	264	Whipp Av	OK		x
8/9/2022	103	252	Whipp Av	OK		x
8/9/2022	103	236	Whipp Av	OK		x
8/9/2022	103	245	Whipp Av	OK		x
8/9/2022	103	231	Whipp Av	OK		x
8/9/2022	103	217	Whipp Av	OK		x
8/9/2022	103	199	Whipp Av	OK		x
8/9/2022	103	218	Whipp Av	OK		x
8/9/2022	103	198	Whipp Av	OK		x
8/9/2022	103	190	Whipp Av	OK		x
8/9/2022	103	189	Whipp Av	OK		x
8/9/2022	103	178	Whipp Av	OK		x
8/9/2022	103	166	Whipp Av	OK		x
8/9/2022	103	139	Whipp Av	OK		x
8/9/2022	103	111	Whipp Av	OK		x
8/9/2022	103	315	Montgomery	OK		x
8/9/2022	103	276	Montgomery	OK		x
8/9/2022	103		Sanders	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 4

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	103	199	Sanders	OK		x
8/9/2022	103	75	College St	OK		x
8/9/2022	103	98	College St	OK		x
8/9/2022	103	58	College St	OK		x
8/9/2022	103	80	College St	OK		x
8/9/2022	103	116	Montgomery	OK		x
8/9/2022	103		Montgomery	OK		x
8/9/2022	103	230	Wolford Av	OK		x
8/9/2022	103	244	Wolford Av	OK		x
8/9/2022	103	241	Wolford Av	OK		x
8/9/2022	103	244	Adams St	OK		x
8/9/2022	103	251	Adams St	OK		x
8/9/2022	103	237	Adams St	OK		x
8/9/2022	103	211	Adams St	OK		x
8/9/2022	103	134	Griffin St	OK		x
8/9/2022	103	176	Wolford Av	OK		x
8/9/2022	103	52	Montgomery	OK		x
8/9/2022	103	105	Montgomery	OK		x
8/9/2022	103	53	Montgomery	OK		x
8/9/2022	103	31	Montgomery	OK		x
8/9/2022	103	14	Montgomery	OK		x
8/9/2022	103	150	Foster St	OK		x
8/9/2022	103	150	Foster St	OK		x
8/9/2022	103	99	Wallace	OK		x
8/9/2022	103	150	Foster St	OK		x
8/9/2022	103	150	Foster St	OK		x
8/9/2022	103	115	N Wallace Wilkerson	OK		x
8/9/2022	103	115	N Wallace Wilkerson	OK		x
8/9/2022	103	14	Foster St	OK		x
8/9/2022	103	271	Wolford Av	OK		x
8/9/2022	103	222	Allen St	OK		x
8/9/2022	103	239	Allen St	OK		x
8/9/2022	103	223	Allen St	Ok		x
8/9/2022	103	269	Allen St	OK		x
8/9/2022	103	312	Allen St	OK		x
8/9/2022	103	328	Allen St	OK		x
8/9/2022	103	351	Allen St	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 5

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	103	351	Adams St	OK		x
8/9/2022	103	356	Adams St	OK		x
8/9/2022	103	139	Fair St	OK		x
8/9/2022	103	242	Fair St	OK		x
8/9/2022	103	256	Fair St	OK		x
8/9/2022	103	280	Fair St	OK		x
8/9/2022	103	340	Whipp Av	OK		x
8/9/2022	103	356	Allen St	OK		x
8/9/2022	103	418	Allen St	OK		x
8/9/2022	103	452	Allen St	OK		x
8/9/2022	101	625	Campbellsville St	OK		x
8/9/2022	101	231	Courthouse square	OK		x
8/9/2022	101	169	Courthouse square	OK		x
8/9/2022	101	169	Courthouse square	OK		x
8/9/2022	101	763	Campbellsville St	OK		x
8/9/2022	101	913	Campbellsville St	OK		x
8/9/2022	101	932	Campbellsville St	OK		x
8/9/2022	101	966	Campbellsville St	OK		x
8/9/2022	101	959	Campbellsville St	OK		x
8/9/2022	101	1019	Campbellsville St	OK		x
8/9/2022	101	1109	Campbellsville St	OK		x
8/9/2022	101	1139	Campbellsville St	OK		x
8/9/2022	101	1139	Campbellsville St	OK		x
8/9/2022	101	1171	Campbellsville St	OK		x
8/9/2022	101	770	Campbellsville St	OK		x
8/9/2022	101	752	Campbellsville St	OK		x
8/9/2022	101	718	Campbellsville St	OK		x
8/9/2022	101	770	Campbellsville St	OK		x
8/9/2022	101		Gosser St	OK		x
8/9/2022	101	668	Campbellsville St	OK		x
8/9/2022	101	664	Campbellsville St	OK		x
8/9/2022	101	654	Campbellsville St	OK		x
8/9/2022	101	634	Campbellsville St	OK		x
8/9/2022	101	630	Campbellsville St	OK		x
8/9/2022	101	628	Campbellsville St	OK		x
8/9/2022	101	628	Campbellsville St	OK		x
8/9/2022	101	626	Campbellsville St	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 6

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	101	26	Campbellville St	OK		x
8/9/2022	101	33	Hustonville St	OK		x
8/9/2022	101	33	Hustonville St	OK		x
8/9/2022	101	58	Hustonville St	OK		x
8/9/2022	101	58	Hustonville St	ok		x
8/9/2022	101	56	Hustonville St	OK		x
8/9/2022	101	36	Hustonville St	OK		x
8/9/2022	101	546	Middleburg St	OK		x
8/9/2022	101	546	Middleburg St	OK		x
8/9/2022	101	14	Hustonville St	OK		x
8/9/2022	101	108	Hustonville St	OK		x
8/9/2022	101	132	Hustonville St	OK		x
8/9/2022	101	11	KY 49	OK		x
8/9/2022	101	30	Brown Ct	OK		x
8/9/2022	101	54	Brown Ct	OK		x
8/9/2022	101	75	Brown Ct	OK		x
8/9/2022	101	82	Brown Ct	OK		x
8/9/2022	101	67	Brown Ct	OK		x
8/9/2022	101	163	Hustonville St	OK		x
8/9/2022	101	95	KY 49	OK		x
8/9/2022	101	119	KY 49	OK		x
8/9/2022	101	124	KY 49	OK		x
8/9/2022	101	142	KY 49	OK		x
8/9/2022	101	142	KY 49	OK		x
8/9/2022	101	158	KY 49	OK		x
8/9/2022	101	43	Bartle Heights	OK		x
8/9/2022	101	216	KY 49	OK		x
8/9/2022	101	230	KY 49	OK		x
8/9/2022	101	250	KY 49	OK		x
8/9/2022	101	279	KY 49	OK		x
8/9/2022	101	391	KY 49	OK		x
8/9/2022	101	454	KY 49	OK		x
8/9/2022	101	501	KY 49	OK		x
8/9/2022	101	625	KY 49	OK		x
8/9/2022	101	693	KY 49	OK		x
8/9/2022	101	817	KY 49	OK		x
8/9/2022	101	219	Hustonville St	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 7

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/9/2022	101	246	Hustonville St	OK		x
8/9/2022	101	327	Hustonville St	OK		x
8/9/2022	101	367	Hustonville St	OK		x
8/9/2022	104	57	Middleburg St	OK		x
8/9/2022	104	58	Middleburg St	OK		x
8/9/2022	104	74	Middleburg St	OK		x
8/9/2022	104	94	Middleburg St	OK		x
8/9/2022	104	89	Middleburg St	OK		x
8/9/2022	104	115	Middleburg St	OK		x
8/9/2022	104	106	Middleburg St	OK		x
8/9/2022	104	118	Middleburg St	OK		x
8/9/2022	104	138	Middleburg St	OK		x
8/9/2022	104	173	Middleburg St	OK		x
8/9/2022	104	38	Conner St	OK		x
8/9/2022	104	62	Conner St	OK		x
8/9/2022	104	79	Conner St	OK		x
8/9/2022	104	238	Middleburg St	OK		x
8/9/2022	104	248	Middleburg St	OK		x
8/9/2022	104	253	Middleburg St	OK		x
8/9/2022	104	44	Maple	OK		x
8/9/2022	104	57	Maple	OK		x
8/9/2022	104	71	Maple	OK		x
8/9/2022	104	58	Maple	OK		x
8/9/2022	104	80	Maple	OK		x
8/9/2022	104	77	Northcut St	OK		x
8/9/2022	104	323	Middleburg St	OK		x
8/9/2022	104	417	Middleburg St	OK		x
8/9/2022	104	414	Middleburg St	OK		x
8/9/2022	104	438	Middleburg St	OK		x
8/9/2022	104	14	Beldon St	OK		x
8/9/2022	104	532	Middleburg St	OK		x
8/9/2022	104	511	Middleburg St	OK		x
8/9/2022	104	523	Middleburg St	OK		x
8/9/2022	104	529	Middleburg St	OK		x
8/9/2022	104		Middleburg St	OK		x
8/9/2022	104	113	Courthouse SQ	OK		x
8/9/2022	104	133	Courthouse SQ	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 8

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	104	21	S wilkerson Blvd	OK		x
8/10/2022	104	92	N Wilkinson Blvd	OK		x
8/10/2022	104	130	N Wilkinson Blvd	OK		x
8/10/2022	104	130	N Wilkinson Blvd	OK		x
8/10/2022	104	206	N Wilkinson Blvd	OK		x
8/10/2022	104	224	N Wilkinson Blvd	OK		x
8/10/2022	104	262	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	255	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	261	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	245	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	245	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	223	N Wilkinson Blvd	OK		x
8/10/2022	104	245	N Wilkinson Blvd	OK		x
8/10/2022	104		N Wilkinson Blvd	OK		x
8/10/2022	104	343	N Wilkinson Blvd	OK		x
8/10/2022	104	371	N Wilkinson Blvd	OK		x
8/10/2022	104	397	N Wallace wilkinson Blvd	OK		x
8/10/2022	104	410	N Wallace wilkinson Blvd	ok		x
8/10/2022	104	100	Liberty sq	OK		x
8/10/2022	104	112	Liberty sq	OK		x
8/10/2022	104	112	Liberty sq	OK		x
8/10/2022	104	122	Liberty sq	OK		x
8/10/2022	104	140	Liberty sq	OK		x
8/10/2022	104	150	Liberty sq	OK		x
8/10/2022	104	49	Scanlon Dr	OK		x
8/10/2022	104	49	Scanlon Dr	ok		x
8/10/2022	104	472	Wallace Wilkinson	OK		x
8/10/2022	104	543	N Wilkinson Blvd	OK		x
8/10/2022	104	579	Wallace Wilkinson	OK		x
8/10/2022	104	112	Dillon St	OK		x
8/10/2022	104	112	Dillon St	OK		x
8/10/2022	104	130	Dillon St	OK		x
8/10/2022	104	130	Dillon St	OK		x
8/10/2022	104	150	Dillon St	OK		x
8/10/2022	104	150	Dillon St	OK		x
8/10/2022	104	180	Dillon St	OK		x
8/10/2022	104	180	Dillon St	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 9

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	104	705	N Wilkinson	OK		X
8/10/2022	104	260	Dillion St	OK		x
8/10/2022	104	260	Dillion St	OK		x
8/10/2022	104	230	Dillion St	OK		x
8/10/2022	104	212	Dillion St	OK		x
8/10/2022	104	15	Riverdale Dr	OK		x
8/10/2022	104	35	Riverdale Dr	OK		x
8/10/2022	104	19	Riverdale Dr	OK		x
8/10/2022	104	19	Riverdale Dr	OK		x
8/10/2022	104	19	Riverdale Dr	OK		x
8/10/2022	104	700	N Wilkinson	OK		x
8/10/2022	104	19	Riverdale Dr	OK		x
8/10/2022	104	29	Riverdale Dr	OK		x
8/10/2022	104	25	Riverdale Dr	OK		x
8/10/2022	104	25	Riverdale Dr	OK		x
8/10/2022	104	25	Riverdale Dr	OK		x
8/10/2022	104	25	Riverdale Dr	OK		x
8/10/2022	104	20	Riverdale Dr	OK		x
8/10/2022	104	20	Riverdale Dr	OK		x
8/10/2022	104	20	Riverdale Dr	OK		x
8/10/2022	104	20	Riverdale Dr	OK		x
8/10/2022	104	20	Riverdale Dr	OK		x
8/10/2022	104	750	N Wilkinson	OK		x
8/10/2022	104		Dillion St	OK		x
8/10/2022	104	85	Riverdale Dr	OK		x
8/10/2022	104	85	Riverdale Dr	OK		x
8/10/2022	104	85	Riverdale Dr	OK		x
8/10/2022	104	85	Riverdale Dr	OK		x
8/10/2022	104	50	Riverdale Dr	OK		x
8/10/2022	104	50	Riverdale Dr	OK		x
8/10/2022	104	50	Riverdale Dr	OK		x
8/10/2022	104	50	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x

Leak Survey 2022



COMPANY: Liberty Utilitlies, Liberty KY

LEGEND: AC Atmospheric Corrisoin

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 10

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	104	50	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	100	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	90	Riverdale Dr	OK		x
8/10/2022	104	735	N Wilkinson Blvd	OK		x
8/10/2022	104	938	N Wilkinson Blvd	OK		x
8/10/2022	104	775	N Wilkinson Blvd	OK		x
8/10/2022	104	1200	Wallace Wilkinson	OK		x
8/10/2022	104	750	Wallace Wilkinson	OK		x
8/10/2022	104		N Hwy 127	OK		x
8/10/2022	104	815	Wallace Wilkinson	OK		x
8/10/2022	104	46	Farmers Bank Dr	OK		x
8/10/2022	104	46	Farmers Bank Dr	OK		x
8/10/2022	104	1124	Hustonville St	OK		x
8/10/2022	104	1031	Hustonville St	OK		x
8/10/2022	104	1031	Hustonville St	OK		x
8/10/2022	104	1024	Hustonville St	OK		x
8/10/2022	104	1004	Hustonville St	OK		x
8/10/2022	105	107	Woodrum Ridge	OK		x
8/10/2022	105	107	Woodrum Ridge	OK		x
8/10/2022	105	909	Hustonville St	OK		x
8/10/2022	105	221	Napier St	OK		x
8/10/2022	105	100	Napier St	OK		x
8/10/2022	105	465	Woodrum Ridge	OK		x
8/10/2022	105	187	Woodrum Ridge	OK		x
8/10/2022	105	186	Woodrum Ridge	OK		x
8/10/2022	105	256	Sweeney St	OK		x
8/10/2022	105	774	E KY 70	OK		x
8/10/2022	105	1168	E KY 70	OK		x
8/10/2022	105	1190	E KY 70	OK		x
8/10/2022	105	1305	E KY 70	OK		x
8/10/2022	105	1377	E KY 70	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

LEGEND: AC Atmospheric Corrosion

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 11

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	105	1397	E KY 70	OK		x
8/10/2022	105	1423	E KY 70	OK		x
8/10/2022	105	1533	E KY 70	OK		x
8/10/2022	105	1520	E KY 70	OK		x
8/10/2022	105	1563	E KY 70	OK		x
8/10/2022	105	1611	E KY 70	OK		x
8/10/2022	105	1841	E KY 70	OK		x
8/10/2022	105	1723	E KY 70	OK		x
8/10/2022	105	1841	E KY 70	OK		x
8/10/2022	105	1841	E KY 70	OK		x
8/10/2022	105	1841	E KY 70	OK		x
8/10/2022	105	1983	E KY 70	OK		x
8/10/2022	105	1983	E KY 70	OK		x
8/10/2022	105	1983	E KY 70	OK		x
8/10/2022	105	1820	E KY 70	OK		x
8/10/2022	105	289	W Wilkinson	OK		x
8/10/2022	105	289	W Wilkinson	OK		x
8/10/2022	105	581	W Wilkinson	OK		x
8/10/2022	105	126	Sharp Hollow	OK		x
8/10/2022	105	54	Sharp Hollow	OK		x
8/10/2022	105	611	S Wilkinson	OK		x
8/10/2022	105	54	Sharp Hollow	OK		x
8/10/2022	105	616	S Wilkinson	OK		x
8/10/2022	105	690	S Wilkinson	OK		x
8/10/2022	105	713	S Wilkinson	OK		x
8/10/2022	105	876	S Wilkinson	OK		x
8/10/2022	105	83	Believers Ln	OK		x
8/10/2022	105	67	Believers Ln	OK		x
8/10/2022	105	1074	S Wilkinson	OK		x
8/10/2022	105	1173	S Wilkinson	OK		x
8/10/2022	105	1214	S Wilkinson	OK		x
8/10/2022	105	1498	S Wilkinson	OK		x
8/10/2022	105	1500	S Wilkinson	OK		x
8/10/2022	105	1517	S Wilkinson	OK		x
8/10/2022	105	1678	S Wilkinson	OK		x
8/10/2022	105	98	Hilltop Dr	OK		x
8/10/2022	105	1713	KY 49	OK		x

Leak Survey 2022



COMPANY: Liberty Utilitlies, Liberty KY

LEGEND: AC Atmospheric Corrisoin

TECHNICIAN: Marty C. Bryan

NP- Needs Paints

PAGE: 12

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	105	1705	KY 49	OK		X
8/10/2022	105	1714	KY 49	OK		x
8/10/2022	105	1870	KY 49	OK		x
8/10/2022	105	1830	KY 49	OK		x
8/10/2022	105	1976	KY 49	OK		x
8/10/2022	105	2059	KY 49	OK		x
8/10/2022	105	2063	KY 49	OK		x
8/10/2022	105	2411	KY 49	OK		x
8/10/2022	105	3265	KY 49	OK		x
8/10/2022	105	3804	KY 49	OK		x
8/10/2022	105	2804	KY 49	OK		x
8/10/2022	105	5727	KY 49	OK		x
8/10/2022	105	5717	KY 49	OK		x
8/10/2022	105	6290	KY 49	OK		x
8/10/2022	105	7009	KY 49	OK		x
8/10/2022	105	4399	Caney Fork Ln	OK		x
8/10/2022	105	7293	KY 49	OK		x
8/10/2022	105	7274	KY 49	OK		x
8/10/2022	105	7806	KY 49	OK		x
8/10/2022	105	11669	KY 1547	OK		x
8/10/2022	105	11168	KY 1547	OK		x
8/10/2022	105	165	Button Knob	OK		x
8/10/2022	105	10963	KY 1547	OK		x
8/10/2022	105	11138	KY 1547	OK		x
8/10/2022	105	10887	KY 1547	OK		x
8/10/2022	105	361	Button Knob	OK		x
8/10/2022	105	653	Button Knob	OK		x
8/10/2022	105	10520	KY 1547	OK		x
8/10/2022	105	10523	KY 1547	OK		x
8/10/2022	105	10167	KY 1547	OK		x
8/10/2022	105	10045	KY 1547	OK		x
8/10/2022	105	10006	KY 1547	OK		x
8/10/2022	105	9972k	KY 1547	OK		x
8/10/2022	105	14	Sheepskin Rd	OK		x
8/10/2022	105	9758	KY 1547	ok		x
8/10/2022	105	9745	KY 1547	OK		x
8/10/2022	105	9717	KY 1547	OK		x

Leak Survey 2022



COMPANY: Liberty Utilities, Liberty KY

TECHNICIAN: Marty C. Bryan

PAGE: 13

LEGEND: AC Atmospheric Corrosion

NP- Needs Paints

DATE	ROUTE	HOUSE#	ADDRESS	AC	POS	NEG
8/10/2022	105	9653	KY 1547	OK		x
8/10/2022	105	356	Bartle Dr	OK		x
8/10/2022	105	1166	Woodrum Ridge	OK		x
8/10/2022	105	1106	Woodrum Ridge	OK		x
8/10/2022	105	1256	Woodrum Ridge	OK		x
8/10/2022	105	139	Viewpoint Dt	OK		x
8/10/2022	105	1494	Woodrum Ridge	OK		x
8/10/2022	105	224	Viewpoint Dt	OK		x
8/10/2022	105	1817	Woodrum Ridge	OK		x