



GERALD WUETCHER
DIRECT DIAL: (859) 231-3017
DIRECT FAX: (859) 259-3517
gerald.wuetcher@skofirm.com

300 WEST VINE STREET
SUITE 2100
LEXINGTON, KY 40507-1801
MAIN: (859) 231-3000
FAX: (859) 253-1093

October 7, 2021

Ms. Linda C. Bridwell, P.E.
Executive Director
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602-0615

Re: *Hyden-Leslie County Water District*

Dear Ms. Bridwell:

Pursuant to KAR 278.180 and 807 KAR 5;011, Sections 6 and 9, Hyden-Leslie County Water District ("District") files the enclosed tariff sheet to replace Original Sheet No. 17.1 of its present tariff. The revised sheet deletes Rule 11.m from the District's tariff.

The current Rule 11.m permits an applicant or customer to install an individual pressure booster with the District's approval. District approval of such installations appears to conflict with the Recommended Standards for Water Works, which is incorporated by reference into Division of Water regulations. Two provisions of the Ten States Standards specifically address and unequivocally prohibit the use of booster pumps on residential service. §6.4.4 states: "Private booster pumps shall not be allowed for any individual residential service from the public water supply main." Repeating this prohibition, §8.11.2 states: "Individual booster pumps shall not be allowed for any individual residential service from the public water supply mains." To comply with Division of Water regulations, the District is proposing to delete the rule.

Sincerely,

Stoll Keenon Ogden PLLC

A handwritten signature in blue ink that reads "Gerald E. Wuetcher".

Gerald E. Wuetcher

GEW
Enclosure

AREA Clay, Leslie, Perry Counties, Ky

PSC KY NO. 6

First Revised SHEET NO. 17.1

Hyden-Leslie County Water District

CANCELLING PSC KY NO. 6

Original SHEET NO. 17.1

RULES AND REGULATIONS

(3) If the District is unable to continue providing water service to an existing customer at a pressure of at least 30 psig at the meter but can do so if an individual pump is installed on the customer’s side of the point of connection, it shall at its own expense install such a pump and shall be responsible for the pump’s maintenance and repair. If an installed pump fails and such failure is not the result of the customer’s negligence or willful misconduct, the District shall at its own expense replace the failed pump and shall be responsible for the replacement pump’s maintenance and repair.**

k. [Reserved for Future Use]

l. If the applicant/Customer’s point of usage is at a higher elevation than the meter, the customer should consult with a reputable engineering firm to properly size the service line from the meter to the point of usage.

m. [Reserved for Future Use.]

(D)

** These provisions are the subject of an application for rehearing filed in Case No. 2021-00071 on August 27, 2021.

DATE OF ISSUE October 7, 2021
MONTH / DATE / YEAR

DATE EFFECTIVE November 7, 2021
MONTH / DATE / YEAR

ISSUED BY /s/Kevin Cook
SIGNATURE OF OFFICER

TITLE Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE
COMMISSION IN CASE NO. _____ DATED _____