



Andy Beshear
Governor

Rebecca W. Goodman
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

Angie Hatton
Chair

Mary Pat Regan
Commissioner

John Will Stacy
Commissioner

September 12, 2024

PARTIES OF RECORD

Re: Case No. 2023-00194

Notice is given to all parties that the attached McKinney Water District Informal Conference and attendance sheet has been filed into the record of this proceeding.

If you have any comments you would like to make regarding the contents of the document, please do so within five days of receipt of this letter. If you have any questions, please contact Whitney Saffari, Staff Attorney, at whitney.saffari@ky.gov.

Sincerely,

A handwritten signature in blue ink that reads "Linda C. Bridwell".

Linda C. Bridwell, PE
Executive Director

Attachment

INTRA-AGENCY MEMORANDUM

KENTUCKY PUBLIC SERVICE COMMISSION

TO: Case File No. 2023-00194

FROM: Whitney Saffari, Staff Attorney

DATE: September 10, 2024

RE: Informal Conference of September 10, 2024

Pursuant to a Staff Notice issued on August 22, 2024, an informal conference (IC) was conducted on September 10, 2024. Attached is a copy of the attendance roster.

The purpose of the IC was to discuss the requirements of the monthly surcharge activity and water loss reports. McKinney Water District (McKinney District) stated it would file the July reports soon in order to get caught up.

McKinney District had its engineers, AGE Engineering, available for the informal conference. Taylor Stamper, utility inspector for the Commission, asked a few questions regarding the QIIP filed December 26, 2023 and McKinney District's response to Commission Staff's First Request for Information. McKinney District clarified that it seeks to add a master meter between the Ottenheim Pump Station and the Stanford system because currently, the Mag Meter located at the Ottenheim Pump Station is not tested and there is no way to test it, as it only operates when the pump operates. The proposed new master meter would allow McKinney District to more accurately read and calculate water usage and water loss from this location. Commission Staff informed McKinney District that the QIIP was still in the review process. Commission Staff also reminded the utility that, before spending any funds from the water loss surcharge account, it needed to request permission from the Commission and provide supporting documentation and invoices in order to receive reimbursement.

There being no further discussion, the IC was then adjourned.

cc: Parties of Record

PSC INFORMAL CONFERENCE SIGN IN SHEET

CASE NUMBER: IC 2023-00194 MCKINNEY WATER DISTRICT

LOCATION: Microsoft Teams

DATE: September 10, 2024 10:00am – 11:00am

NAME	COMPANY
Moriah Tussey	PSC
Jennifer Fell	PSC
William Pearce	PSC
Benjamin Rogness	PSC
Whitney Saffari	PSC
Lonnie Brown	McKinney Water District
Donna Yocum	McKinney Water District
Marty Spears	AGE Engineering Services
Luther Galloway	AGE Engineering Services

*Robert K. Miller
Straightline Kentucky LLC
113 North Birchwood Ave.
Louisville, KENTUCKY 40206

*McKinney Water District
2900 KY HWY 198
Hustonville, KY 40437

*Matt Rankin
Chairman
McKinney Water District
P. O. Box 7
McKinney, KY 40448