

Andy Beshear
Governor

Rebecca W. Goodman
Secretary
Energy and Environment Cabinet



Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
psc.ky.gov

Angie Hatton
Chair

Mary Pat Regan
Commissioner

Andrew W. Wood
Commissioner

November 7, 2025

PARTIES OF RECORD

Re: Case No. 2025-00027

Notice is given to all parties that the attached Peterman V. Kentucky Power Informal Conference Memorandum and attendance list has been filed into the record of this proceeding.

If you have any comments you would like to make regarding the contents of the document, please do so within five days of receipt of this letter. If you have any questions, please contact Ellen Fouser-Gormley, Staff Attorney, at Ellen.FouserGormley@ky.gov

Sincerely,

A handwritten signature in blue ink that reads "Linda C. Bridwell".

Linda C. Bridwell, PE
Executive Director

Attachment

INTRA-AGENCY MEMORANDUM

KENTUCKY PUBLIC SERVICE COMMISSION

TO: Case File No. 2025-00027

FROM: Ellen Fouser-Gormley, Staff Attorney

DATE: October 30, 2025

RE: Informal Conference of October 30, 2025

Pursuant to Commission Staff's Notice issued on September 29, 2025, a second Informal Conference was conducted on October 30, 2025. Attached is a copy of the attendance roster.

The purpose of the second Informal Conference was to follow up on a possible on-site visit discussed during the first Informal Conference conducted on August 18, 2025, arising from a complaint filed by Larry and Debra Peterman against Kentucky Power Company (Kentucky Power) on December 6, 2024, concerning stray voltage in and around the Petermans' pool.

Kentucky Power advised they increased the scope of testing that had been performed during prior on-site visits to the Petermans' house in September and November of 2024, by conducting drive around testing, and installing additional ground wires with no noticeable change. Kentucky Power stated that all voltage readings were consistent with previous findings.

The prior disconnect between the Petermans and Kentucky Power concerning exactly what tests had been conducted and the final interpretation of those results appeared to have been resolved, with Kentucky Power stating that the data indicated a bonding issue with the pool, and the Petermans taking steps to reinforce and correct the bonding of the pool.

Both parties agreed to remain in contact concerning the issue, but agreed that the re-bonding of the pool couldn't be verified with voltage readings until spring.

There being no further discussion, the IC was then adjourned.

cc: Parties of Record

PSC INFORMAL CONFERENCE SIGN IN SHEET

CASE NUMBER: IC 2025-00027 Peterman v. Kentucky Power

LOCATION: Microsoft Teams

DATE: October 30, 2025 10:00 am

NAME	COMPANY
Moriah Tussey	Public Service Commission
Ellen Fouser-Gormley	Public Service Commission
John Redfern	Public Service Commission
Brandon Bruner	Public Service Commission
Michael Ferguson	Public Service Commission
Jeffrey Moore	Public Service Commission
Jeff Abshire	Public Service Commission
Jessica Norris-Canfield	Public Service Commission
Harlee Havens	Stites & Harbison PLLC
Tanner Wolfrom	Kentucky Power Company
Michael Lewis	Kentucky Power Company
Phillip Tolliver	Kentucky Power Company
Larry Peterman	Complainant

*Kentucky Power Company
1645 Winchester Avenue
Ashland, KY 41101

*Larry Peterman
51 Woodland Way
Grayson, KY 41143