

**COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION**

**RECEIVED**

APR 10 2026

PUBLIC SERVICE  
COMMISSION

Re: CASE NO. 2026-00090

(Complaints - Service)

Jason Kremer, Complainant; Northern Kentucky Water District, Defendant


**Complainant's Supplement to Complaint and Submission of Additional  
Photographs**

Comes the Complainant, Jason Kremer, and states as follows:

1. Complainant previously filed the Complaint in this matter. The filing was date-stamped received by the Commission on April 6, 2026, and was assigned Case No. 2026-00090.
2. Complainant submits this Supplement to provide additional evidence relevant to the issues raised in the original Complaint.
3. Specifically, Complainant is submitting additional photographs depicting the location where the water meter existed before a Northern Kentucky Water District meter technician removed the meter and installed a steel plug on a potable water line.
4. The attached photographs also show the existing six meters visible in the photograph, with the meter mount where the removed meter had been located circled for reference.
5. Complainant brought to the technician's attention that plumbing components installed on a potable water line must be lead free. The technician indicated that the lead-free standard did not apply to Northern Kentucky Water District.
6. Federal law provides that pipes, pipe fittings, plumbing fittings, and fixtures used in the installation or repair of any public water system or any plumbing in a residential or nonresidential facility providing water for human consumption must be lead free. See 42 U.S.C. 300g-6. Kentucky administrative regulations likewise adopt plumbing standards requiring lead-free materials for potable water applications, including 815 KAR 20:010.
7. These photographs are relevant to the facts and circumstances at issue in this matter and are submitted for the Commission's consideration and inclusion in the record.

WHEREFORE, Complainant respectfully requests that the Commission accept this Supplement to Complaint and include the attached photographs in the record in this proceeding.

Respectfully submitted,

A handwritten signature in black ink that reads "Jason Kremer". The signature is written in a cursive style with a large initial 'J' and a long horizontal stroke at the end.

Jason Kremer

Date: April 8, 2026

