



an e-on company

Jeff Derouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

RECEIVED

MAR 03 2010

PUBLIC SERVICE
COMMISSION

E.ON U.S. LLC

State Regulation and Rates
220 W. Main Street
Louisville, KY 40202
www.eon-us.com

Martin J. Reinert
Sr. Regulatory Analyst
O 502-627-4173
marty.reinert@eon-us.com

February 25, 2010

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Louisville Gas and Electric Company

Dear Mr. Derouen:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.


Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Louisville Gas and Electric Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2009 Statistical Sampling Test Results and Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Marty J. Reinert". The signature is written in a cursive style with a large, prominent initial "M".

Marty J. Reinert

Cc: Reggie Chaney, Engineering Director PSC

Attachments

ATTACHMENT
A

Certified Test Results

**Louisville Gas Electric
New Single Phase Meters 2009**

Mfg	Mfg Model	Meter Number	Test Date	Full Load	Light Load	PF
ITRON	C1S	847539	1/5/2009	100.10	99.97	100.00
ITRON	C1S	847540	1/5/2009	100.06	100.03	100.10
ITRON	C1S	847541	1/5/2009	100.06	99.93	100.00
ITRON	C1S	847542	1/5/2009	100.06	99.92	100.07
ITRON	C1S	847543	1/5/2009	100.06	99.96	100.00
ITRON	C1S	847544	1/5/2009	100.08	100.11	100.22
ITRON	C1S	847545	1/5/2009	100.11	100.08	100.18
ITRON	C1S	847546	1/5/2009	100.07	99.94	100.08
ITRON	C1S	847547	1/5/2009	100.06	100.09	100.24
ITRON	C1S	847548	1/5/2009	100.09	100.01	99.91
ITRON	C1S	847549	1/5/2009	100.08	99.99	100.08
ITRON	C1S	847550	1/5/2009	100.10	99.97	100.12
ITRON	C1S	847551	1/5/2009	100.11	99.96	100.25
ITRON	C1S	847552	1/5/2009	100.08	100.12	100.19
ITRON	C1S	847553	1/5/2009	100.09	100.12	100.21
ITRON	C1S	847554	1/5/2009	100.09	100.07	100.21
ITRON	C1S	847555	1/5/2009	100.08	100.04	100.15
ITRON	C1S	847556	1/5/2009	100.06	100.03	100.13
ITRON	C1S	847557	1/5/2009	100.10	99.92	100.13
ITRON	C1S	847558	1/5/2009	100.10	99.98	100.13
ITRON	C1S	847559	1/5/2009	100.06	99.94	99.99
ITRON	C1S	847560	1/5/2009	100.06	100.04	100.04
ITRON	C1S	847561	1/5/2009	100.07	99.98	100.01
ITRON	C1S	847562	1/5/2009	100.05	100.04	100.19
ITRON	C1S	847563	1/5/2009	100.09	100.04	100.18
ITRON	C1S	847564	1/5/2009	100.09	99.98	100.06
ITRON	C1S	847565	1/5/2009	100.07	99.92	99.99
ITRON	C1S	847566	1/5/2009	100.10	99.99	100.06
ITRON	C1S	847567	1/5/2009	100.10	100.11	100.22
ITRON	C1S	847568	1/5/2009	100.08	99.99	100.08
ITRON	C1S	847569	1/5/2009	100.06	100.04	100.16
ITRON	C1S	847570	1/5/2009	100.06	100.04	100.11
ITRON	C1S	847571	1/5/2009	100.07	100.01	100.16
ITRON	C1S	847572	1/5/2009	100.08	99.86	100.25
ITRON	C1S	847573	1/5/2009	100.10	99.90	100.09
ITRON	C1S	847574	1/5/2009	100.09	100.06	100.20
ITRON	C1S	847575	1/5/2009	100.09	99.91	100.10
ITRON	C1S	847576	1/5/2009	100.10	100.07	100.16
ITRON	C1S	847577	1/5/2009	100.07	100.10	100.17
ITRON	C1S	847578	1/5/2009	100.09	100.05	100.20
ITRON	C1S	847579	1/5/2009	100.06	100.03	100.14
ITRON	C1S	847580	1/5/2009	100.10	100.12	100.22
ITRON	C1S	847581	1/5/2009	100.09	100.02	99.88
ITRON	C1S	847582	1/5/2009	100.11	100.06	100.16
ITRON	C1S	847583	1/5/2009	100.07	99.87	100.05

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	847584	1/5/2009	100.09	99.96	100.16
ITRON	C1S	847585	1/5/2009	100.10	100.01	99.96
ITRON	C1S	847586	1/5/2009	100.05	99.94	100.07
ITRON	C1S	847587	1/5/2009	100.08	99.96	100.13
ITRON	C1S	847588	1/5/2009	100.07	99.97	100.05
ITRON	C1S	847589	1/5/2009	100.10	100.06	100.14
ITRON	C1S	847590	1/5/2009	100.06	100.01	100.03
ITRON	C1S	847591	1/5/2009	100.06	100.01	100.00
ITRON	C1S	847592	1/5/2009	100.10	99.94	100.06
ITRON	C1S	847593	1/5/2009	100.07	100.06	100.15
ITRON	C1S	847594	1/5/2009	100.10	100.07	100.19
ITRON	C1S	847595	1/5/2009	100.09	99.98	100.19
ITRON	C1S	847596	1/5/2009	100.06	99.99	100.14
ITRON	C1S	847597	1/5/2009	100.08	99.93	100.18
ITRON	C1S	847598	1/5/2009	100.07	100.03	100.23
ITRON	C1S	847599	1/5/2009	100.06	99.97	99.85
ITRON	C1S	847600	1/5/2009	100.09	100.05	99.97
ITRON	C1S	847601	1/5/2009	100.07	99.93	100.10
ITRON	C1S	847602	1/5/2009	100.08	99.95	100.02
ITRON	C1S	847603	1/5/2009	100.09	100.06	100.20
ITRON	C1S	847604	1/5/2009	100.06	99.89	100.03
ITRON	C1S	847605	1/5/2009	100.08	99.94	100.06
ITRON	C1S	847606	1/5/2009	100.07	100.06	100.14
ITRON	C1S	847607	1/5/2009	100.09	100.00	100.04
ITRON	C1S	847608	1/5/2009	100.09	99.90	99.97
ITRON	C1S	847609	1/5/2009	100.11	100.11	100.16
ITRON	C1S	847610	1/5/2009	100.10	99.97	99.99
ITRON	C1S	847611	1/5/2009	100.08	100.00	100.14
ITRON	C1S	847612	1/5/2009	100.09	99.97	100.25
ITRON	C1S	847613	1/5/2009	100.08	100.11	100.22
ITRON	C1S	847614	1/5/2009	100.08	99.95	100.07
ITRON	C1S	847615	1/5/2009	100.08	99.93	100.12
ITRON	C1S	847616	1/5/2009	100.09	99.90	100.12
ITRON	C1S	847617	1/5/2009	100.09	100.17	100.20
ITRON	C1S	847618	1/5/2009	100.07	99.95	100.08
ITRON	C1S	847619	1/5/2009	100.08	99.96	100.05
ITRON	C1S	847620	1/5/2009	100.07	100.11	100.19
ITRON	C1S	847621	1/5/2009	100.07	99.99	99.87
ITRON	C1S	847622	1/5/2009	100.08	100.05	100.12
ITRON	C1S	847623	1/5/2009	100.09	100.00	100.03
ITRON	C1S	847624	1/5/2009	100.08	99.94	100.03
ITRON	C1S	847625	1/5/2009	100.06	100.05	100.13
ITRON	C1S	847626	1/5/2009	100.06	100.03	100.19
ITRON	C1S	847627	1/5/2009	100.11	100.05	100.20
ITRON	C1S	847628	1/5/2009	100.10	99.95	100.13
ITRON	C1S	847629	1/5/2009	100.08	100.06	100.14
ITRON	C1S	847630	1/5/2009	100.07	99.95	100.08

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847631	1/5/2009	100.09	100.02	99.92
ITRON	C1S	847632	1/5/2009	100.07	99.97	100.03
ITRON	C1S	847633	1/5/2009	100.05	99.94	100.08
ITRON	C1S	847634	1/5/2009	100.10	99.99	100.10
ITRON	C1S	847635	1/5/2009	100.11	100.07	100.18
ITRON	C1S	847636	1/5/2009	100.08	100.09	100.16
ITRON	C1S	847637	1/5/2009	100.06	99.97	100.17
ITRON	C1S	847638	1/5/2009	100.10	99.99	100.17
ITRON	C1S	847639	1/5/2009	100.10	99.91	100.21
ITRON	C1S	847640	1/5/2009	100.08	99.98	100.12
ITRON	C1S	847641	1/5/2009	100.06	99.94	100.12
ITRON	C1S	847642	1/5/2009	100.09	99.91	100.05
ITRON	C1S	847643	1/5/2009	100.08	99.92	100.03
ITRON	C1S	847644	1/5/2009	100.09	100.02	100.13
ITRON	C1S	847645	1/5/2009	100.06	100.00	100.18
ITRON	C1S	847646	1/5/2009	100.07	99.95	100.12
ITRON	C1S	847647	1/5/2009	100.07	100.08	100.17
ITRON	C1S	847648	1/5/2009	100.07	99.99	100.21
ITRON	C1S	847649	1/5/2009	100.05	99.96	100.01
ITRON	C1S	847650	1/5/2009	100.07	99.99	100.23
ITRON	C1S	847651	1/5/2009	100.06	99.94	100.18
ITRON	C1S	847652	1/5/2009	100.06	100.08	100.18
ITRON	C1S	847653	1/5/2009	100.10	99.99	100.06
ITRON	C1S	847654	1/5/2009	100.09	99.96	100.06
ITRON	C1S	847655	1/5/2009	100.09	99.93	100.21
ITRON	C1S	847656	1/5/2009	100.09	99.98	100.03
ITRON	C1S	847657	1/5/2009	100.10	99.94	99.89
ITRON	C1S	847658	1/5/2009	100.06	99.90	100.13
ITRON	C1S	847659	1/5/2009	100.09	99.93	100.14
ITRON	C1S	847660	1/5/2009	100.07	99.91	100.08
ITRON	C1S	847661	1/5/2009	100.08	100.16	100.20
ITRON	C1S	847662	1/5/2009	100.08	99.97	100.13
ITRON	C1S	847663	1/5/2009	100.10	99.93	100.02
ITRON	C1S	847664	1/5/2009	100.08	100.05	100.16
ITRON	C1S	847665	1/5/2009	100.09	99.99	100.15
ITRON	C1S	847666	1/5/2009	100.08	99.94	100.14
ITRON	C1S	847667	1/5/2009	100.09	100.10	100.23
ITRON	C1S	847668	1/5/2009	100.09	100.09	100.20
ITRON	C1S	847669	1/5/2009	100.09	100.06	100.13
ITRON	C1S	847670	1/5/2009	100.09	100.02	100.02
ITRON	C1S	847671	1/5/2009	100.07	100.06	100.15
ITRON	C1S	847672	1/5/2009	100.07	100.00	99.99
ITRON	C1S	847673	1/5/2009	100.08	100.05	100.14
ITRON	C1S	847674	1/5/2009	100.09	99.92	100.25
ITRON	C1S	847675	1/5/2009	100.08	99.98	99.96
ITRON	C1S	847676	1/5/2009	100.05	100.00	100.11
ITRON	C1S	847677	1/5/2009	100.06	99.87	100.20

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847678	1/5/2009	100.10	100.01	100.02
ITRON	C1S	847679	1/5/2009	100.07	100.02	100.15
ITRON	C1S	847680	1/5/2009	100.08	99.98	100.03
ITRON	C1S	847681	1/5/2009	100.08	99.96	100.09
ITRON	C1S	847682	1/5/2009	100.07	99.97	100.05
ITRON	C1S	847683	1/5/2009	100.10	99.96	100.09
ITRON	C1S	847684	1/5/2009	100.10	100.08	100.12
ITRON	C1S	847685	1/5/2009	100.07	100.00	99.98
ITRON	C1S	847686	1/5/2009	100.10	100.02	100.19
ITRON	C1S	847687	1/5/2009	100.08	99.96	100.17
ITRON	C1S	847688	1/5/2009	100.05	99.96	100.02
ITRON	C1S	847689	1/5/2009	100.10	100.05	100.20
ITRON	C1S	847690	1/5/2009	100.09	99.92	100.13
ITRON	C1S	847691	1/5/2009	100.07	99.89	100.13
ITRON	C1S	847692	1/5/2009	100.08	99.93	100.13
ITRON	C1S	847693	1/5/2009	100.07	99.94	100.19
ITRON	C1S	847694	1/5/2009	100.07	100.01	100.14
ITRON	C1S	847695	1/5/2009	100.08	100.06	100.17
ITRON	C1S	847696	1/5/2009	100.08	99.99	99.99
ITRON	C1S	847697	1/5/2009	100.06	99.97	100.15
ITRON	C1S	847698	1/5/2009	100.06	100.05	100.14
ITRON	C1S	847699	1/5/2009	100.08	100.04	100.17
ITRON	C1S	847700	1/5/2009	100.10	100.08	100.16
ITRON	C1S	847701	1/5/2009	100.08	99.88	100.13
ITRON	C1S	847702	1/5/2009	100.09	99.94	100.07
ITRON	C1S	847703	1/5/2009	100.09	100.08	100.19
ITRON	C1S	847704	1/5/2009	100.09	99.93	100.11
ITRON	C1S	847705	1/5/2009	100.06	99.96	100.14
ITRON	C1S	847706	1/5/2009	100.08	100.06	100.13
ITRON	C1S	847707	1/5/2009	100.10	100.07	100.22
ITRON	C1S	847708	1/5/2009	100.08	100.00	99.96
ITRON	C1S	847709	1/5/2009	100.07	99.92	100.14
ITRON	C1S	847710	1/5/2009	100.10	100.10	100.20
ITRON	C1S	847711	1/5/2009	100.07	99.93	100.02
ITRON	C1S	847712	1/5/2009	100.06	100.01	100.10
ITRON	C1S	847713	1/5/2009	100.10	99.98	100.14
ITRON	C1S	847714	1/5/2009	100.11	99.93	100.07
ITRON	C1S	847715	1/5/2009	100.08	100.02	100.15
ITRON	C1S	847716	1/5/2009	100.09	100.09	100.20
ITRON	C1S	847717	1/5/2009	100.10	99.98	100.14
ITRON	C1S	847718	1/5/2009	100.08	100.15	100.13
ITRON	C1S	847719	1/5/2009	100.10	99.94	100.08
ITRON	C1S	847720	1/5/2009	100.07	99.88	100.16
ITRON	C1S	847721	1/5/2009	100.08	99.96	100.05
ITRON	C1S	847722	1/5/2009	100.07	100.00	99.95
ITRON	C1S	847723	1/5/2009	100.07	100.01	100.14
ITRON	C1S	847724	1/5/2009	100.10	100.02	100.17

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847725	1/5/2009	100.08	100.04	100.06
ITRON	C1S	847726	1/5/2009	100.09	100.11	100.22
ITRON	C1S	847727	1/5/2009	100.06	99.95	99.92
ITRON	C1S	847728	1/5/2009	100.10	100.08	100.24
ITRON	C1S	847729	1/5/2009	100.08	99.92	100.03
ITRON	C1S	847730	1/5/2009	100.05	99.91	100.02
ITRON	C1S	847731	1/5/2009	100.09	99.98	100.10
ITRON	C1S	847732	1/5/2009	100.08	100.02	100.15
ITRON	C1S	847733	1/5/2009	100.10	99.98	100.06
ITRON	C1S	847734	1/5/2009	100.06	99.92	100.09
ITRON	C1S	847735	1/5/2009	100.08	99.98	100.06
ITRON	C1S	847736	1/5/2009	100.06	100.01	100.15
ITRON	C1S	847737	1/5/2009	100.08	100.00	100.08
ITRON	C1S	847738	1/5/2009	100.10	100.05	100.20
ITRON	C1S	847739	1/5/2009	100.09	99.99	100.01
ITRON	C1S	847740	1/5/2009	100.07	99.95	100.07
ITRON	C1S	847741	1/5/2009	100.08	100.00	100.04
ITRON	C1S	847742	1/5/2009	100.09	99.98	100.05
ITRON	C1S	847743	1/5/2009	100.07	99.90	100.00
ITRON	C1S	847744	1/5/2009	100.10	100.00	100.18
ITRON	C1S	847745	1/5/2009	100.06	99.96	100.05
ITRON	C1S	847746	1/5/2009	100.06	99.97	100.08
ITRON	C1S	847747	1/5/2009	100.09	100.03	100.06
ITRON	C1S	847748	1/5/2009	100.09	100.02	100.25
ITRON	C1S	847749	1/5/2009	100.09	99.98	100.18
ITRON	C1S	847750	1/5/2009	100.06	100.08	100.08
ITRON	C1S	847751	1/5/2009	100.06	99.89	100.06
ITRON	C1S	847752	1/5/2009	100.08	100.07	100.21
ITRON	C1S	847753	1/5/2009	100.08	100.09	100.17
ITRON	C1S	847754	1/5/2009	100.06	99.90	99.98
ITRON	C1S	847755	1/5/2009	100.09	100.12	100.18
ITRON	C1S	847756	1/5/2009	100.09	100.09	100.20
ITRON	C1S	847757	1/5/2009	100.08	99.99	100.12
ITRON	C1S	847758	1/5/2009	100.11	100.00	100.02
ITRON	C1S	847759	1/5/2009	100.06	100.06	100.09
ITRON	C1S	847760	1/5/2009	100.06	99.90	100.00
ITRON	C1S	847761	1/5/2009	100.06	99.92	100.05
ITRON	C1S	847762	1/5/2009	100.08	99.95	100.06
ITRON	C1S	847763	1/5/2009	100.06	100.09	100.18
ITRON	C1S	847764	1/5/2009	100.09	99.97	100.15
ITRON	C1S	847765	1/5/2009	100.10	100.02	100.15
ITRON	C1S	847766	1/5/2009	100.08	99.99	100.15
ITRON	C1S	847767	1/5/2009	100.05	99.99	100.11
ITRON	C1S	847768	1/5/2009	100.05	99.92	100.10
ITRON	C1S	847769	1/5/2009	100.08	100.00	100.17
ITRON	C1S	847770	1/5/2009	100.10	100.00	99.93
ITRON	C1S	847771	1/5/2009	100.09	99.98	100.21

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	847772	1/5/2009	100.08	100.00	100.14
ITRON	C1S	847773	1/5/2009	100.11	100.05	100.18
ITRON	C1S	847774	1/5/2009	100.07	100.13	100.17
ITRON	C1S	847775	1/5/2009	100.08	100.06	100.17
ITRON	C1S	847776	1/5/2009	100.07	99.92	100.14
ITRON	C1S	847777	1/5/2009	100.07	99.89	100.12
ITRON	C1S	847778	1/5/2009	100.06	99.96	100.17
ITRON	C1S	847779	1/5/2009	100.06	100.05	100.15
ITRON	C1S	847780	1/5/2009	100.09	99.94	100.05
ITRON	C1S	847781	1/5/2009	100.06	99.91	100.03
ITRON	C1S	847782	1/5/2009	100.06	99.85	100.23
ITRON	C1S	847783	1/5/2009	100.06	99.95	99.88
ITRON	C1S	847784	1/5/2009	100.09	100.09	100.25
ITRON	C1S	847785	1/5/2009	100.07	99.93	100.11
ITRON	C1S	847786	1/5/2009	100.08	99.95	100.03
ITRON	C1S	847787	1/5/2009	100.08	99.97	100.13
ITRON	C1S	847788	1/5/2009	100.09	100.03	100.13
ITRON	C1S	847789	1/5/2009	100.09	99.97	100.02
ITRON	C1S	847790	1/5/2009	100.07	99.92	100.08
ITRON	C1S	847791	1/5/2009	100.10	99.97	100.02
ITRON	C1S	847792	1/5/2009	100.07	100.09	100.09
ITRON	C1S	847793	1/5/2009	100.08	99.92	99.97
ITRON	C1S	847794	1/5/2009	100.08	99.92	100.11
ITRON	C1S	847795	1/5/2009	100.08	99.92	100.11
ITRON	C1S	847796	1/5/2009	100.10	99.97	100.12
ITRON	C1S	847797	1/5/2009	100.10	99.96	100.09
ITRON	C1S	847798	1/5/2009	100.08	99.94	100.15
ITRON	C1S	847799	1/5/2009	100.08	100.04	100.25
ITRON	C1S	847800	1/5/2009	100.11	99.97	100.13
ITRON	C1S	847801	1/5/2009	100.09	99.99	100.04
ITRON	C1S	847802	1/5/2009	100.07	99.94	100.06
ITRON	C1S	847803	1/5/2009	100.07	99.96	100.03
ITRON	C1S	847804	1/5/2009	100.06	99.96	100.11
ITRON	C1S	847805	1/5/2009	100.09	100.09	100.23
ITRON	C1S	847806	1/5/2009	100.10	100.16	100.21
ITRON	C1S	847807	1/5/2009	100.08	99.98	100.20
ITRON	C1S	847808	1/5/2009	100.06	99.95	100.06
ITRON	C1S	847809	1/5/2009	100.10	100.02	99.92
ITRON	C1S	847810	1/5/2009	100.09	100.01	100.26
ITRON	C1S	847811	1/5/2009	100.07	99.96	100.03
ITRON	C1S	847812	1/5/2009	100.08	99.96	100.11
ITRON	C1S	847813	1/5/2009	100.09	100.00	100.09
ITRON	C1S	847814	1/5/2009	100.06	99.90	100.13
ITRON	C1S	847815	1/5/2009	100.11	100.10	100.15
ITRON	C1S	847816	1/5/2009	100.06	100.03	100.15
ITRON	C1S	847817	1/5/2009	100.08	99.94	100.13
ITRON	C1S	847818	1/5/2009	100.05	99.92	99.94

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847819	1/5/2009	100.08	99.96	99.85
ITRON	C1S	847820	1/5/2009	100.09	100.10	100.15
ITRON	C1S	847821	1/5/2009	100.08	99.97	99.97
ITRON	C1S	847822	1/5/2009	100.08	99.98	100.11
ITRON	C1S	847823	1/5/2009	100.09	99.96	100.04
ITRON	C1S	847824	1/5/2009	100.06	99.91	100.00
ITRON	C1S	847825	1/5/2009	100.06	100.07	100.07
ITRON	C1S	847826	1/5/2009	100.08	99.89	100.11
ITRON	C1S	847827	1/5/2009	100.08	99.90	100.24
ITRON	C1S	847828	1/5/2009	100.06	99.88	99.92
ITRON	C1S	847829	1/5/2009	100.10	100.01	100.14
ITRON	C1S	847830	1/5/2009	100.07	100.01	100.16
ITRON	C1S	847831	1/5/2009	100.08	100.08	100.21
ITRON	C1S	847832	1/5/2009	100.09	100.04	100.02
ITRON	C1S	847833	1/5/2009	100.06	99.96	100.09
ITRON	C1S	847834	1/5/2009	100.09	100.08	100.26
ITRON	C1S	847835	1/5/2009	100.10	100.03	100.16
ITRON	C1S	847836	1/5/2009	100.08	100.00	100.12
ITRON	C1S	847837	1/5/2009	100.08	99.91	100.11
ITRON	C1S	847838	1/5/2009	100.09	100.03	100.05
ITRON	C1S	847839	1/5/2009	100.08	100.09	100.14
ITRON	C1S	847840	1/5/2009	100.07	100.01	99.95
ITRON	C1S	847841	1/5/2009	100.06	99.88	100.01
ITRON	C1S	847842	1/5/2009	100.06	99.91	100.00
ITRON	C1S	847843	1/5/2009	100.07	99.89	100.19
ITRON	C1S	847844	1/5/2009	100.06	100.00	100.13
ITRON	C1S	847845	1/5/2009	100.06	99.94	99.97
ITRON	C1S	847846	1/5/2009	100.06	99.97	100.00
ITRON	C1S	847847	1/5/2009	100.08	100.03	100.17
ITRON	C1S	847848	1/5/2009	100.07	99.94	100.13
ITRON	C1S	847849	1/5/2009	100.09	99.93	100.06
ITRON	C1S	847850	1/5/2009	100.07	99.97	100.03
ITRON	C1S	847851	1/5/2009	100.10	99.93	100.15
ITRON	C1S	847852	1/5/2009	100.09	99.92	100.03
ITRON	C1S	847853	1/5/2009	100.08	99.97	100.10
ITRON	C1S	847854	1/5/2009	100.06	99.93	100.01
ITRON	C1S	847855	1/5/2009	100.09	100.02	100.05
ITRON	C1S	847856	1/5/2009	100.08	99.87	100.25
ITRON	C1S	847857	1/5/2009	100.06	99.97	100.22
ITRON	C1S	847858	1/5/2009	100.10	100.02	100.15
ITRON	C1S	847859	1/5/2009	100.08	99.95	100.27
ITRON	C1S	847860	1/5/2009	100.10	99.98	100.12
ITRON	C1S	847861	1/5/2009	100.11	100.05	100.08
ITRON	C1S	847862	1/5/2009	100.06	100.02	100.10
ITRON	C1S	847863	1/5/2009	100.11	100.01	100.03
ITRON	C1S	847864	1/5/2009	100.06	100.04	100.16
ITRON	C1S	847865	1/5/2009	100.09	100.02	100.17

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847866	1/5/2009	100.06	99.98	100.09
ITRON	C1S	847867	1/5/2009	100.08	100.10	100.19
ITRON	C1S	847868	1/5/2009	100.05	100.03	100.23
ITRON	C1S	847869	1/5/2009	100.09	100.15	100.19
ITRON	C1S	847870	1/5/2009	100.07	100.02	100.19
ITRON	C1S	847871	1/5/2009	100.09	100.05	100.18
ITRON	C1S	847872	1/5/2009	100.07	100.06	100.12
ITRON	C1S	847873	1/5/2009	100.08	99.97	100.07
ITRON	C1S	847874	1/5/2009	100.06	99.95	100.15
ITRON	C1S	847875	1/5/2009	100.05	99.98	100.13
ITRON	C1S	847876	1/5/2009	100.09	99.95	100.16
ITRON	C1S	847877	1/5/2009	100.10	99.98	100.12
ITRON	C1S	847878	1/5/2009	100.09	99.94	100.09
ITRON	C1S	847879	1/5/2009	100.08	99.95	100.11
ITRON	C1S	847880	1/5/2009	100.05	100.03	100.16
ITRON	C1S	847881	1/5/2009	100.10	99.97	100.12
ITRON	C1S	847882	1/5/2009	100.06	99.92	100.12
ITRON	C1S	847883	1/5/2009	100.07	100.03	100.19
ITRON	C1S	847884	1/5/2009	100.08	99.96	100.01
ITRON	C1S	847885	1/5/2009	100.08	99.99	99.91
ITRON	C1S	847886	1/5/2009	100.08	99.94	100.20
ITRON	C1S	847887	1/5/2009	100.07	100.05	100.18
ITRON	C1S	847888	1/5/2009	100.10	100.16	100.14
ITRON	C1S	847889	1/5/2009	100.06	100.06	100.15
ITRON	C1S	847890	1/5/2009	100.06	99.95	100.10
ITRON	C1S	847891	1/5/2009	100.09	99.95	100.26
ITRON	C1S	847892	1/5/2009	100.06	100.07	100.22
ITRON	C1S	847893	1/5/2009	100.07	100.08	100.08
ITRON	C1S	847894	1/5/2009	100.09	100.14	100.16
ITRON	C1S	847895	1/5/2009	100.05	100.06	100.11
ITRON	C1S	847896	1/5/2009	100.07	100.07	100.17
ITRON	C1S	847897	1/5/2009	100.10	100.10	100.22
ITRON	C1S	847898	1/5/2009	100.08	100.04	100.03
ITRON	C1S	847899	1/5/2009	100.08	99.99	100.12
ITRON	C1S	847900	1/5/2009	100.08	100.00	99.99
ITRON	C1S	847901	1/5/2009	100.10	100.03	100.05
ITRON	C1S	847902	1/5/2009	100.06	100.02	99.88
ITRON	C1S	847903	1/5/2009	100.08	99.91	100.18
ITRON	C1S	847904	1/5/2009	100.07	99.87	100.10
ITRON	C1S	847905	1/5/2009	100.08	100.08	100.24
ITRON	C1S	847906	1/5/2009	100.08	100.08	100.20
ITRON	C1S	847907	1/5/2009	100.06	100.02	100.11
ITRON	C1S	847908	1/5/2009	100.08	99.94	100.14
ITRON	C1S	847909	1/5/2009	100.06	100.02	100.08
ITRON	C1S	847910	1/5/2009	100.08	100.05	100.13
ITRON	C1S	847911	1/5/2009	100.07	100.06	100.11
ITRON	C1S	847912	1/5/2009	100.11	100.06	100.10

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847913	1/5/2009	100.08	99.95	100.17
ITRON	C1S	847914	1/5/2009	100.10	99.88	100.14
ITRON	C1S	847915	1/5/2009	100.07	99.92	100.09
ITRON	C1S	847916	1/5/2009	100.06	99.94	100.11
ITRON	C1S	847917	1/5/2009	100.07	99.89	100.11
ITRON	C1S	847918	1/5/2009	100.06	100.01	100.06
ITRON	C1S	847919	1/5/2009	100.06	99.89	100.12
ITRON	C1S	847920	1/5/2009	100.08	100.06	100.19
ITRON	C1S	847921	1/5/2009	100.06	100.07	100.12
ITRON	C1S	847922	1/5/2009	100.09	100.09	100.22
ITRON	C1S	847923	1/5/2009	100.07	99.98	100.11
ITRON	C1S	847924	1/5/2009	100.09	99.96	100.06
ITRON	C1S	847925	1/5/2009	100.10	100.03	100.06
ITRON	C1S	847926	1/5/2009	100.07	99.91	100.04
ITRON	C1S	847927	1/5/2009	100.10	100.01	100.04
ITRON	C1S	847928	1/5/2009	100.10	100.06	100.11
ITRON	C1S	847929	1/5/2009	100.08	100.00	100.14
ITRON	C1S	847930	1/5/2009	100.10	99.97	100.18
ITRON	C1S	847931	1/5/2009	100.09	100.03	100.18
ITRON	C1S	847932	1/5/2009	100.10	100.02	100.19
ITRON	C1S	847933	1/5/2009	100.07	99.93	100.12
ITRON	C1S	847934	1/5/2009	100.06	99.94	100.10
ITRON	C1S	847935	1/5/2009	100.08	100.00	100.09
ITRON	C1S	847936	1/5/2009	100.09	99.99	100.19
ITRON	C1S	847937	1/5/2009	100.09	99.92	100.16
ITRON	C1S	847938	1/5/2009	100.10	99.99	100.24
ITRON	C1S	847939	1/5/2009	100.06	99.93	100.08
ITRON	C1S	847940	1/5/2009	100.08	100.06	100.19
ITRON	C1S	847941	1/5/2009	100.09	99.98	100.23
ITRON	C1S	847942	1/5/2009	100.06	99.94	100.05
ITRON	C1S	847943	1/5/2009	100.07	100.08	100.24
ITRON	C1S	847944	1/5/2009	100.06	99.96	100.03
ITRON	C1S	847945	1/5/2009	100.09	99.99	99.94
ITRON	C1S	847946	1/5/2009	100.10	100.12	100.22
ITRON	C1S	847947	1/5/2009	100.10	99.98	100.11
ITRON	C1S	847948	1/5/2009	100.07	100.06	100.16
ITRON	C1S	847949	1/5/2009	100.09	99.95	100.22
ITRON	C1S	847950	1/5/2009	100.07	99.97	99.85
ITRON	C1S	847951	1/5/2009	100.08	99.92	100.22
ITRON	C1S	847952	1/5/2009	100.09	100.02	100.09
ITRON	C1S	847953	1/5/2009	100.08	99.85	100.09
ITRON	C1S	847954	1/5/2009	100.09	99.97	100.16
ITRON	C1S	847955	1/5/2009	100.09	99.98	99.99
ITRON	C1S	847956	1/5/2009	100.06	99.94	100.07
ITRON	C1S	847957	1/5/2009	100.08	100.00	100.12
ITRON	C1S	847958	1/5/2009	100.10	99.97	99.99
ITRON	C1S	847959	1/5/2009	100.08	99.94	100.13

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	847960	1/5/2009	100.06	99.92	100.23
ITRON	C1S	847961	1/5/2009	100.09	99.99	100.11
ITRON	C1S	847962	1/5/2009	100.07	100.07	100.21
ITRON	C1S	847963	1/5/2009	100.07	99.96	100.03
ITRON	C1S	847964	1/5/2009	100.08	100.07	100.13
ITRON	C1S	847965	1/5/2009	100.09	100.13	100.24
ITRON	C1S	847966	1/5/2009	100.11	100.01	100.07
ITRON	C1S	847967	1/5/2009	100.07	100.01	99.92
ITRON	C1S	847968	1/5/2009	100.08	100.06	100.12
ITRON	C1S	847969	1/5/2009	100.07	99.91	100.13
ITRON	C1S	847970	1/5/2009	100.11	99.95	100.27
ITRON	C1S	847971	1/5/2009	100.09	100.04	100.22
ITRON	C1S	847972	1/5/2009	100.07	100.04	100.17
ITRON	C1S	847973	1/5/2009	100.06	99.83	100.12
ITRON	C1S	847974	1/5/2009	100.08	99.96	100.08
ITRON	C1S	847975	1/5/2009	100.09	100.10	100.21
ITRON	C1S	847976	1/5/2009	100.09	100.01	100.00
ITRON	C1S	847977	1/5/2009	100.10	100.09	100.21
ITRON	C1S	847978	1/5/2009	100.10	99.99	99.98
ITRON	C1S	847979	1/5/2009	100.06	99.99	100.13
ITRON	C1S	847980	1/5/2009	100.05	100.01	100.13
ITRON	C1S	847981	1/5/2009	100.10	100.00	100.07
ITRON	C1S	847982	1/5/2009	100.09	99.95	100.09
ITRON	C1S	847983	1/5/2009	100.09	100.06	100.09
ITRON	C1S	847984	1/5/2009	100.07	100.09	100.19
ITRON	C1S	847985	1/5/2009	100.06	99.95	100.17
ITRON	C1S	847986	1/5/2009	100.11	100.07	100.20
ITRON	C1S	847987	1/5/2009	100.09	99.95	100.13
ITRON	C1S	847988	1/5/2009	100.07	99.89	100.02
ITRON	C1S	847989	1/5/2009	100.06	100.08	100.06
ITRON	C1S	847990	1/5/2009	100.08	99.96	99.97
ITRON	C1S	847991	1/5/2009	100.09	100.09	100.13
ITRON	C1S	847992	1/5/2009	100.08	99.99	99.86
ITRON	C1S	847993	1/5/2009	100.07	100.03	100.08
ITRON	C1S	847994	1/5/2009	100.10	100.03	100.07
ITRON	C1S	847995	1/5/2009	100.07	99.94	100.24
ITRON	C1S	847996	1/5/2009	100.07	100.07	100.17
ITRON	C1S	847997	1/5/2009	100.08	100.02	100.00
ITRON	C1S	847998	1/5/2009	100.09	100.09	100.23
ITRON	C1S	847999	1/5/2009	100.09	99.96	100.01
ITRON	C1S	848000	1/5/2009	100.08	99.97	100.04
ITRON	C1S	848001	1/5/2009	100.10	99.99	100.05
ITRON	C1S	848002	1/5/2009	100.09	100.19	100.15
ITRON	C1S	848003	1/5/2009	100.10	99.87	100.09
ITRON	C1S	848004	1/5/2009	100.06	99.86	100.05
ITRON	C1S	848005	1/5/2009	100.10	100.09	100.20
ITRON	C1S	848006	1/5/2009	100.11	99.95	100.05

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848007	1/5/2009	100.09	100.02	100.14
ITRON	C1S	848008	1/5/2009	100.06	99.99	100.10
ITRON	C1S	848009	1/5/2009	100.10	100.05	100.21
ITRON	C1S	848010	1/5/2009	100.09	100.00	100.04
ITRON	C1S	848011	1/5/2009	100.07	100.02	100.02
ITRON	C1S	848012	1/5/2009	100.07	100.02	99.88
ITRON	C1S	848013	1/5/2009	100.09	100.01	100.07
ITRON	C1S	848014	1/5/2009	100.10	100.04	100.21
ITRON	C1S	848015	1/5/2009	100.08	99.90	100.17
ITRON	C1S	848016	1/5/2009	100.06	99.90	100.16
ITRON	C1S	848017	1/5/2009	100.09	100.08	100.22
ITRON	C1S	848018	1/5/2009	100.06	99.89	100.15
ITRON	C1S	848019	1/5/2009	100.08	100.00	99.86
ITRON	C1S	848020	1/5/2009	100.10	100.04	100.09
ITRON	C1S	848021	1/5/2009	100.06	100.03	100.14
ITRON	C1S	848022	1/5/2009	100.08	100.05	100.17
ITRON	C1S	848023	1/5/2009	100.06	100.02	100.16
ITRON	C1S	848024	1/5/2009	100.08	100.09	100.16
ITRON	C1S	848025	1/5/2009	100.09	99.98	100.05
ITRON	C1S	848026	1/5/2009	100.06	100.03	100.12
ITRON	C1S	848027	1/5/2009	100.06	99.91	99.95
ITRON	C1S	848028	1/5/2009	100.07	99.98	100.06
ITRON	C1S	848029	1/5/2009	100.06	99.95	100.11
ITRON	C1S	848030	1/5/2009	100.06	99.91	100.05
ITRON	C1S	848031	1/5/2009	100.08	100.06	100.18
ITRON	C1S	848032	1/5/2009	100.08	100.03	100.14
ITRON	C1S	848033	1/5/2009	100.09	100.11	100.21
ITRON	C1S	848034	1/5/2009	100.06	100.00	100.11
ITRON	C1S	848035	1/5/2009	100.06	100.00	100.15
ITRON	C1S	848036	1/5/2009	100.07	100.03	100.14
ITRON	C1S	848037	1/5/2009	100.07	100.05	100.10
ITRON	C1S	848038	1/5/2009	100.08	100.08	100.18
ITRON	C1S	848039	1/5/2009	100.10	99.96	100.14
ITRON	C1S	848040	1/5/2009	100.08	100.07	100.24
ITRON	C1S	848041	1/5/2009	100.09	100.08	100.18
ITRON	C1S	848042	1/5/2009	100.05	100.06	100.21
ITRON	C1S	848043	1/5/2009	100.06	99.98	100.15
ITRON	C1S	848044	1/5/2009	100.09	100.03	100.17
ITRON	C1S	848045	1/5/2009	100.07	99.99	100.12
ITRON	C1S	848046	1/5/2009	100.06	99.92	100.11
ITRON	C1S	848047	1/5/2009	100.06	99.94	100.12
ITRON	C1S	848048	1/5/2009	100.09	99.94	100.14
ITRON	C1S	848049	1/5/2009	100.08	99.95	100.06
ITRON	C1S	848050	1/5/2009	100.08	99.95	100.03
ITRON	C1S	848051	1/5/2009	100.08	99.98	100.08
ITRON	C1S	848052	1/5/2009	100.07	100.00	100.04
ITRON	C1S	848053	1/5/2009	100.08	99.96	100.06

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848054	1/5/2009	100.05	100.07	100.18
ITRON	C1S	848055	1/5/2009	100.10	99.93	100.12
ITRON	C1S	848056	1/5/2009	100.08	99.92	100.06
ITRON	C1S	848057	1/5/2009	100.09	100.00	100.09
ITRON	C1S	848058	1/5/2009	100.07	100.01	100.02
ITRON	C1S	848059	1/5/2009	100.07	100.00	100.08
ITRON	C1S	848060	1/5/2009	100.09	100.03	100.19
ITRON	C1S	848061	1/5/2009	100.09	100.02	100.01
ITRON	C1S	848062	1/5/2009	100.07	99.92	99.94
ITRON	C1S	848063	1/5/2009	100.08	100.01	99.99
ITRON	C1S	848064	1/5/2009	100.07	100.02	100.12
ITRON	C1S	848065	1/5/2009	100.10	99.97	100.11
ITRON	C1S	848066	1/5/2009	100.10	99.97	100.13
ITRON	C1S	848067	1/5/2009	100.06	99.95	100.01
ITRON	C1S	848068	1/5/2009	100.05	99.85	100.08
ITRON	C1S	848069	1/5/2009	100.08	100.03	100.19
ITRON	C1S	848070	1/5/2009	100.06	100.11	100.16
ITRON	C1S	848071	1/5/2009	100.07	99.83	100.09
ITRON	C1S	848072	1/5/2009	100.11	100.12	100.24
ITRON	C1S	848073	1/5/2009	100.10	100.09	100.20
ITRON	C1S	848074	1/5/2009	100.10	99.99	100.13
ITRON	C1S	848075	1/5/2009	100.08	100.03	100.21
ITRON	C1S	848076	1/5/2009	100.10	100.09	100.16
ITRON	C1S	848077	1/5/2009	100.06	100.03	100.12
ITRON	C1S	848078	1/5/2009	100.09	100.01	100.04
ITRON	C1S	848079	1/5/2009	100.08	100.07	100.16
ITRON	C1S	848080	1/5/2009	100.07	99.97	100.02
ITRON	C1S	848081	1/5/2009	100.06	100.07	100.22
ITRON	C1S	848082	1/5/2009	100.05	100.05	100.18
ITRON	C1S	848083	1/5/2009	100.09	99.96	100.10
ITRON	C1S	848084	1/5/2009	100.07	99.97	100.05
ITRON	C1S	848085	1/5/2009	100.06	99.96	100.02
ITRON	C1S	848086	1/5/2009	100.05	100.00	99.99
ITRON	C1S	848087	1/5/2009	100.08	99.94	100.14
ITRON	C1S	848088	1/5/2009	100.06	99.93	100.06
ITRON	C1S	848089	1/5/2009	100.09	99.90	100.00
ITRON	C1S	848090	1/5/2009	100.06	99.96	100.11
ITRON	C1S	848091	1/5/2009	100.07	99.96	100.06
ITRON	C1S	848092	1/5/2009	100.06	99.99	100.11
ITRON	C1S	848093	1/5/2009	100.06	100.02	100.10
ITRON	C1S	848094	1/5/2009	100.07	99.99	99.98
ITRON	C1S	848095	1/5/2009	100.09	100.09	100.23
ITRON	C1S	848096	1/5/2009	100.08	100.13	100.22
ITRON	C1S	848097	1/5/2009	100.06	100.03	100.10
ITRON	C1S	848098	1/5/2009	100.07	99.91	100.10
ITRON	C1S	848099	1/5/2009	100.07	100.05	100.16
ITRON	C1S	848100	1/5/2009	100.05	99.95	100.06

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848101	1/5/2009	100.09	99.93	100.24
ITRON	C1S	848102	1/5/2009	100.07	99.97	100.09
ITRON	C1S	848103	1/5/2009	100.06	99.95	100.11
ITRON	C1S	848104	1/5/2009	100.06	99.95	100.11
ITRON	C1S	848105	1/5/2009	100.06	100.01	100.05
ITRON	C1S	848106	1/5/2009	100.07	100.03	100.16
ITRON	C1S	848107	1/5/2009	100.05	100.05	100.18
ITRON	C1S	848108	1/5/2009	100.06	99.95	100.06
ITRON	C1S	848109	1/5/2009	100.05	99.96	99.87
ITRON	C1S	848110	1/5/2009	100.07	100.11	100.19
ITRON	C1S	848111	1/5/2009	100.09	100.05	100.16
ITRON	C1S	848112	1/5/2009	100.06	99.89	100.04
ITRON	C1S	848113	1/5/2009	100.11	100.06	100.24
ITRON	C1S	848114	1/5/2009	100.10	99.96	100.16
ITRON	C1S	848115	1/5/2009	100.10	99.94	100.09
ITRON	C1S	848116	1/5/2009	100.06	99.98	100.08
ITRON	C1S	848117	1/5/2009	100.07	100.03	100.21
ITRON	C1S	848118	1/5/2009	100.07	99.92	100.23
ITRON	C1S	848119	1/5/2009	100.06	99.89	100.09
ITRON	C1S	848120	1/5/2009	100.06	99.99	99.92
ITRON	C1S	848121	1/5/2009	100.06	99.89	100.08
ITRON	C1S	848122	1/5/2009	100.10	100.01	100.05
ITRON	C1S	848123	1/5/2009	100.06	99.94	100.06
ITRON	C1S	848124	1/5/2009	100.06	99.97	99.94
ITRON	C1S	848125	1/5/2009	100.07	99.99	100.03
ITRON	C1S	848126	1/5/2009	100.10	99.96	100.12
ITRON	C1S	848127	1/5/2009	100.08	99.96	99.97
ITRON	C1S	848128	1/5/2009	100.11	99.97	100.12
ITRON	C1S	848129	1/5/2009	100.08	99.92	100.06
ITRON	C1S	848130	1/5/2009	100.09	100.13	100.16
ITRON	C1S	848131	1/5/2009	100.07	100.11	100.19
ITRON	C1S	848132	1/5/2009	100.05	100.03	100.15
ITRON	C1S	848133	1/5/2009	100.10	99.96	100.23
ITRON	C1S	848134	1/5/2009	100.11	100.00	100.12
ITRON	C1S	848135	1/5/2009	100.09	100.01	100.23
ITRON	C1S	848136	1/5/2009	100.08	99.98	100.03
ITRON	C1S	848137	1/5/2009	100.06	99.98	100.08
ITRON	C1S	848138	1/5/2009	100.05	100.06	100.02
ITRON	C1S	848139	1/5/2009	100.07	99.96	99.95
ITRON	C1S	848140	1/5/2009	100.07	100.03	100.03
ITRON	C1S	848141	1/5/2009	100.09	100.05	100.20
ITRON	C1S	848142	1/5/2009	100.10	99.99	99.99
ITRON	C1S	848143	1/5/2009	100.08	100.00	99.98
ITRON	C1S	848144	1/5/2009	100.07	100.03	100.22
ITRON	C1S	848145	1/5/2009	100.07	99.98	100.12
ITRON	C1S	848146	1/5/2009	100.08	100.12	100.18
ITRON	C1S	848147	1/5/2009	100.09	100.00	100.16

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848148	1/5/2009	100.08	100.12	100.16
ITRON	C1S	848149	1/5/2009	100.05	99.97	100.12
ITRON	C1S	848150	1/5/2009	100.09	99.99	100.05
ITRON	C1S	848151	1/5/2009	100.10	100.00	100.03
ITRON	C1S	848152	1/5/2009	100.06	100.06	100.12
ITRON	C1S	848153	1/5/2009	100.08	100.03	100.10
ITRON	C1S	848154	1/5/2009	100.10	100.16	100.19
ITRON	C1S	848155	1/5/2009	100.08	100.03	100.21
ITRON	C1S	848156	1/5/2009	100.08	100.03	100.25
ITRON	C1S	848157	1/5/2009	100.08	100.07	100.18
ITRON	C1S	848158	1/5/2009	100.08	99.97	100.07
ITRON	C1S	848159	1/5/2009	100.07	100.00	100.11
ITRON	C1S	848160	1/5/2009	100.07	99.94	100.07
ITRON	C1S	848161	1/5/2009	100.07	100.03	100.14
ITRON	C1S	848162	1/5/2009	100.07	99.99	100.01
ITRON	C1S	848163	1/5/2009	100.07	100.01	100.21
ITRON	C1S	848164	1/5/2009	100.08	99.90	99.98
ITRON	C1S	848165	1/5/2009	100.10	100.00	100.15
ITRON	C1S	848166	1/5/2009	100.08	100.11	100.22
ITRON	C1S	848167	1/5/2009	100.09	99.97	100.19
ITRON	C1S	848168	1/5/2009	100.06	99.91	99.85
ITRON	C1S	848169	1/5/2009	100.07	99.91	100.13
ITRON	C1S	848170	1/5/2009	100.10	99.91	100.11
ITRON	C1S	848171	1/5/2009	100.06	99.88	100.11
ITRON	C1S	848172	1/5/2009	100.07	99.99	100.01
ITRON	C1S	848173	1/5/2009	100.10	100.15	100.24
ITRON	C1S	848174	1/5/2009	100.08	99.91	100.09
ITRON	C1S	848175	1/5/2009	100.09	100.00	100.01
ITRON	C1S	848176	1/5/2009	100.09	100.04	100.21
ITRON	C1S	848177	1/5/2009	100.10	99.99	100.05
ITRON	C1S	848178	1/5/2009	100.10	100.02	99.91
ITRON	C1S	848179	1/5/2009	100.08	100.05	100.18
ITRON	C1S	848180	1/5/2009	100.08	100.04	100.20
ITRON	C1S	848181	1/5/2009	100.06	100.09	100.21
ITRON	C1S	848182	1/5/2009	100.07	99.84	100.11
ITRON	C1S	848183	1/5/2009	100.06	100.07	100.20
ITRON	C1S	848184	1/5/2009	100.11	99.98	100.03
ITRON	C1S	848185	1/5/2009	100.10	99.90	100.10
ITRON	C1S	848186	1/5/2009	100.08	100.02	100.03
ITRON	C1S	848187	1/5/2009	100.06	100.01	99.91
ITRON	C1S	848188	1/5/2009	100.09	100.05	100.03
ITRON	C1S	848189	1/5/2009	100.08	100.10	100.17
ITRON	C1S	848190	1/5/2009	100.06	100.03	100.14
ITRON	C1S	848191	1/5/2009	100.06	100.01	100.20
ITRON	C1S	848192	1/5/2009	100.09	100.05	100.20
ITRON	C1S	848193	1/5/2009	100.10	100.11	100.18
ITRON	C1S	848194	1/5/2009	100.07	99.97	99.97

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848195	1/5/2009	100.10	100.05	100.04
ITRON	C1S	848196	1/5/2009	100.07	100.13	100.14
ITRON	C1S	848197	1/5/2009	100.06	99.92	100.02
ITRON	C1S	848198	1/5/2009	100.09	99.95	100.10
ITRON	C1S	848199	1/5/2009	100.10	100.16	100.22
ITRON	C1S	848200	1/5/2009	100.09	99.96	100.12
ITRON	C1S	848201	1/5/2009	100.06	99.94	99.95
ITRON	C1S	848202	1/5/2009	100.10	100.01	100.20
ITRON	C1S	848203	1/5/2009	100.09	100.03	99.98
ITRON	C1S	848204	1/5/2009	100.07	99.97	100.08
ITRON	C1S	848205	1/5/2009	100.07	99.94	100.13
ITRON	C1S	848206	1/5/2009	100.09	100.05	100.12
ITRON	C1S	848207	1/5/2009	100.11	100.09	100.26
ITRON	C1S	848208	1/5/2009	100.09	99.92	100.19
ITRON	C1S	848209	1/5/2009	100.09	99.96	100.17
ITRON	C1S	848210	1/5/2009	100.08	100.08	100.18
ITRON	C1S	848211	1/5/2009	100.08	100.08	100.19
ITRON	C1S	848212	1/5/2009	100.08	99.94	100.11
ITRON	C1S	848213	1/5/2009	100.07	100.10	100.15
ITRON	C1S	848214	1/5/2009	100.05	99.93	99.97
ITRON	C1S	848215	1/5/2009	100.10	100.06	100.22
ITRON	C1S	848216	1/5/2009	100.06	99.97	100.19
ITRON	C1S	848217	1/5/2009	100.10	100.00	100.08
ITRON	C1S	848218	1/5/2009	100.06	100.06	100.14
ITRON	C1S	848219	1/5/2009	100.11	100.02	100.12
ITRON	C1S	848220	1/5/2009	100.06	99.98	99.95
ITRON	C1S	848221	1/5/2009	100.09	100.07	100.16
ITRON	C1S	848222	1/5/2009	100.07	99.94	100.05
ITRON	C1S	848223	1/5/2009	100.10	100.06	100.17
ITRON	C1S	848224	1/5/2009	100.06	100.02	100.12
ITRON	C1S	848225	1/5/2009	100.08	99.93	100.00
ITRON	C1S	848226	1/5/2009	100.08	100.10	100.18
ITRON	C1S	848227	1/5/2009	100.06	100.04	100.18
ITRON	C1S	848228	1/5/2009	100.10	100.13	100.21
ITRON	C1S	848229	1/5/2009	100.07	99.95	100.11
ITRON	C1S	848230	1/5/2009	100.08	100.03	100.10
ITRON	C1S	848231	1/5/2009	100.10	100.05	100.14
ITRON	C1S	848232	1/5/2009	100.06	99.89	100.06
ITRON	C1S	848233	1/5/2009	100.05	99.93	100.02
ITRON	C1S	848234	1/5/2009	100.09	100.03	100.05
ITRON	C1S	848235	1/5/2009	100.08	99.96	100.08
ITRON	C1S	848236	1/5/2009	100.10	100.03	100.05
ITRON	C1S	848237	1/5/2009	100.06	99.87	100.14
ITRON	C1S	848238	1/5/2009	100.06	99.90	100.08
ITRON	C1S	848239	1/5/2009	100.06	99.97	100.14
ITRON	C1S	848240	1/5/2009	100.07	99.96	100.09
ITRON	C1S	848241	1/5/2009	100.09	99.99	100.07

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848242	1/5/2009	100.06	100.08	100.12
ITRON	C1S	848243	1/5/2009	100.11	100.18	100.26
ITRON	C1S	848244	1/5/2009	100.11	100.04	100.19
ITRON	C1S	848245	1/5/2009	100.10	100.00	100.15
ITRON	C1S	848246	1/5/2009	100.05	99.94	100.10
ITRON	C1S	848247	1/5/2009	100.08	99.96	100.19
ITRON	C1S	848248	1/5/2009	100.06	99.92	100.05
ITRON	C1S	848249	1/5/2009	100.09	100.03	100.15
ITRON	C1S	848250	1/5/2009	100.06	99.92	100.03
ITRON	C1S	848251	1/5/2009	100.07	99.94	100.12
ITRON	C1S	848252	1/5/2009	100.09	99.99	100.08
ITRON	C1S	848253	1/5/2009	100.09	100.09	100.25
ITRON	C1S	848254	1/5/2009	100.08	100.08	100.15
ITRON	C1S	848255	1/5/2009	100.06	99.99	100.04
ITRON	C1S	848256	1/5/2009	100.06	99.90	100.05
ITRON	C1S	848257	1/5/2009	100.10	99.99	100.02
ITRON	C1S	848258	1/5/2009	100.09	100.04	100.02
ITRON	C1S	848259	1/5/2009	100.07	99.90	99.97
ITRON	C1S	848260	1/5/2009	100.09	99.95	100.10
ITRON	C1S	848261	1/5/2009	100.08	99.94	100.15
ITRON	C1S	848262	1/5/2009	100.10	99.98	100.07
ITRON	C1S	848263	1/5/2009	100.06	100.13	100.14
ITRON	C1S	848264	1/5/2009	100.09	100.02	100.16
ITRON	C1S	848265	1/5/2009	100.09	100.07	100.19
ITRON	C1S	848266	1/5/2009	100.10	100.10	100.20
ITRON	C1S	848267	1/5/2009	100.11	100.15	100.19
ITRON	C1S	848268	1/5/2009	100.07	100.06	100.16
ITRON	C1S	848269	1/5/2009	100.09	100.10	100.14
ITRON	C1S	848270	1/5/2009	100.10	100.13	100.18
ITRON	C1S	848271	1/5/2009	100.06	100.10	100.15
ITRON	C1S	848272	1/5/2009	100.07	99.95	100.03
ITRON	C1S	848273	1/5/2009	100.06	100.01	100.17
ITRON	C1S	848274	1/5/2009	100.07	100.06	100.23
ITRON	C1S	848275	1/5/2009	100.09	100.02	100.06
ITRON	C1S	848276	1/5/2009	100.07	100.02	100.13
ITRON	C1S	848277	1/5/2009	100.06	100.07	100.17
ITRON	C1S	848278	1/5/2009	100.07	100.00	100.10
ITRON	C1S	848279	1/5/2009	100.08	100.05	100.14
ITRON	C1S	848280	1/5/2009	100.07	99.93	100.20
ITRON	C1S	848281	1/5/2009	100.07	99.99	100.08
ITRON	C1S	848282	1/5/2009	100.06	99.89	100.14
ITRON	C1S	848283	1/5/2009	100.09	100.03	100.11
ITRON	C1S	848284	1/5/2009	100.08	100.04	100.14
ITRON	C1S	848285	1/5/2009	100.06	100.00	100.02
ITRON	C1S	848286	1/5/2009	100.10	100.00	100.16
ITRON	C1S	848287	1/5/2009	100.10	99.96	100.09
ITRON	C1S	848288	1/5/2009	100.07	100.05	100.19

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848289	1/5/2009	100.07	100.01	100.16
ITRON	C1S	848290	1/5/2009	100.07	99.97	100.05
ITRON	C1S	848291	1/5/2009	100.10	99.97	99.93
ITRON	C1S	848292	1/5/2009	100.10	100.03	100.15
ITRON	C1S	848293	1/5/2009	100.05	100.00	100.01
ITRON	C1S	848294	1/5/2009	100.06	99.99	100.02
ITRON	C1S	848295	1/5/2009	100.05	100.03	100.10
ITRON	C1S	848296	1/5/2009	100.08	99.95	100.12
ITRON	C1S	848297	1/5/2009	100.10	100.08	99.98
ITRON	C1S	848298	1/5/2009	100.09	100.00	100.05
ITRON	C1S	848299	1/5/2009	100.09	100.00	100.08
ITRON	C1S	848300	1/5/2009	100.09	99.93	100.17
ITRON	C1S	848301	1/5/2009	100.10	99.94	100.16
ITRON	C1S	848302	1/5/2009	100.09	99.93	100.03
ITRON	C1S	848303	1/5/2009	100.07	99.93	100.12
ITRON	C1S	848304	1/5/2009	100.06	100.11	100.14
ITRON	C1S	848305	1/5/2009	100.08	100.04	100.21
ITRON	C1S	848306	1/5/2009	100.08	100.05	100.22
ITRON	C1S	848307	1/5/2009	100.07	100.10	100.20
ITRON	C1S	848308	1/5/2009	100.08	99.93	100.05
ITRON	C1S	848309	1/5/2009	100.09	99.93	100.04
ITRON	C1S	848310	1/5/2009	100.09	100.00	100.11
ITRON	C1S	848311	1/5/2009	100.06	99.89	100.07
ITRON	C1S	848312	1/5/2009	100.06	99.88	100.12
ITRON	C1S	848313	1/5/2009	100.07	99.93	100.10
ITRON	C1S	848314	1/5/2009	100.10	100.01	100.05
ITRON	C1S	848315	1/5/2009	100.06	99.97	100.01
ITRON	C1S	848316	1/5/2009	100.06	100.03	100.20
ITRON	C1S	848317	1/5/2009	100.09	100.03	100.05
ITRON	C1S	848318	1/5/2009	100.06	100.03	100.20
ITRON	C1S	848319	1/5/2009	100.07	99.99	100.11
ITRON	C1S	848320	1/5/2009	100.11	100.06	100.17
ITRON	C1S	848321	1/5/2009	100.10	100.10	100.02
ITRON	C1S	848322	1/5/2009	100.06	99.94	100.06
ITRON	C1S	848323	1/5/2009	100.06	100.00	100.15
ITRON	C1S	848324	1/5/2009	100.06	99.98	99.85
ITRON	C1S	848325	1/5/2009	100.07	99.93	100.08
ITRON	C1S	848326	1/5/2009	100.09	99.97	99.90
ITRON	C1S	848327	1/5/2009	100.08	100.03	100.11
ITRON	C1S	848328	1/5/2009	100.08	100.12	100.21
ITRON	C1S	848329	1/5/2009	100.08	100.00	99.94
ITRON	C1S	848330	1/5/2009	100.06	99.97	100.19
ITRON	C1S	848331	1/5/2009	100.09	100.03	100.00
ITRON	C1S	848332	1/5/2009	100.07	99.99	100.17
ITRON	C1S	848333	1/5/2009	100.06	99.97	100.06
ITRON	C1S	848334	1/5/2009	100.10	99.94	100.25
ITRON	C1S	848335	1/5/2009	100.06	99.99	100.20

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848336	1/5/2009	100.10	99.97	100.09
ITRON	C1S	848337	1/5/2009	100.08	99.87	100.00
ITRON	C1S	848338	1/5/2009	100.09	100.03	100.07
ITRON	C1S	848339	1/5/2009	100.09	100.09	100.19
ITRON	C1S	848340	1/5/2009	100.07	99.98	100.14
ITRON	C1S	848341	1/5/2009	100.07	99.98	100.02
ITRON	C1S	848342	1/5/2009	100.06	99.92	99.92
ITRON	C1S	848343	1/5/2009	100.10	99.96	100.11
ITRON	C1S	848344	1/5/2009	100.10	99.96	100.11
ITRON	C1S	848345	1/5/2009	100.09	100.05	100.02
ITRON	C1S	848346	1/5/2009	100.07	100.09	100.19
ITRON	C1S	848347	1/5/2009	100.06	99.89	100.10
ITRON	C1S	848348	1/5/2009	100.05	99.92	100.03
ITRON	C1S	848349	1/5/2009	100.08	100.03	100.11
ITRON	C1S	848350	1/5/2009	100.06	100.04	100.13
ITRON	C1S	848351	1/5/2009	100.06	99.92	100.06
ITRON	C1S	848352	1/5/2009	100.07	100.00	100.04
ITRON	C1S	848353	1/5/2009	100.09	99.97	100.05
ITRON	C1S	848354	1/5/2009	100.05	99.90	100.05
ITRON	C1S	848355	1/5/2009	100.07	100.03	100.17
ITRON	C1S	848356	1/5/2009	100.06	100.03	100.17
ITRON	C1S	848357	1/5/2009	100.08	100.00	100.01
ITRON	C1S	848358	1/5/2009	100.05	99.95	100.11
ITRON	C1S	848359	1/5/2009	100.06	100.08	100.20
ITRON	C1S	848360	1/5/2009	100.08	99.98	100.02
ITRON	C1S	848361	1/5/2009	100.09	99.98	100.00
ITRON	C1S	848362	1/5/2009	100.06	99.95	100.01
ITRON	C1S	848363	1/5/2009	100.05	99.93	99.92
ITRON	C1S	848364	1/5/2009	100.07	99.92	100.12
ITRON	C1S	848365	1/5/2009	100.06	99.89	100.07
ITRON	C1S	848366	1/5/2009	100.08	99.95	100.09
ITRON	C1S	848367	1/5/2009	100.06	99.93	99.96
ITRON	C1S	848368	1/5/2009	100.07	99.94	100.04
ITRON	C1S	848369	1/5/2009	100.10	100.07	100.20
ITRON	C1S	848370	1/5/2009	100.06	99.97	99.83
ITRON	C1S	848371	1/5/2009	100.06	100.10	100.14
ITRON	C1S	848372	1/5/2009	100.10	100.09	100.21
ITRON	C1S	848373	1/5/2009	100.06	99.98	100.06
ITRON	C1S	848374	1/5/2009	100.06	99.95	100.15
ITRON	C1S	848375	1/5/2009	100.10	100.00	100.15
ITRON	C1S	848376	1/5/2009	100.08	99.95	100.16
ITRON	C1S	848377	1/5/2009	100.07	100.00	100.14
ITRON	C1S	848378	1/5/2009	100.09	99.90	100.02
ITRON	C1S	848379	1/5/2009	100.10	100.03	100.19
ITRON	C1S	848380	1/5/2009	100.08	99.91	100.08
ITRON	C1S	848381	1/5/2009	100.09	99.95	100.17
ITRON	C1S	848382	1/5/2009	100.07	99.95	99.99

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848383	1/5/2009	100.07	99.95	100.16
ITRON	C1S	848384	1/5/2009	100.09	99.97	100.08
ITRON	C1S	848385	1/5/2009	100.08	99.96	100.12
ITRON	C1S	848386	1/5/2009	100.08	100.03	100.09
ITRON	C1S	848387	1/5/2009	100.09	100.00	100.03
ITRON	C1S	848388	1/5/2009	100.09	99.97	100.07
ITRON	C1S	848389	1/5/2009	100.09	99.96	100.04
ITRON	C1S	848390	1/5/2009	100.08	100.01	100.17
ITRON	C1S	848391	1/5/2009	100.08	100.05	100.14
ITRON	C1S	848392	1/5/2009	100.09	99.90	100.12
ITRON	C1S	848393	1/5/2009	100.09	99.97	100.12
ITRON	C1S	848394	1/5/2009	100.09	99.95	100.01
ITRON	C1S	848395	1/5/2009	100.07	99.95	100.00
ITRON	C1S	848396	1/5/2009	100.09	99.96	100.08
ITRON	C1S	848397	1/5/2009	100.06	100.05	100.16
ITRON	C1S	848398	1/5/2009	100.11	99.97	100.12
ITRON	C1S	848399	1/5/2009	100.06	100.09	100.15
ITRON	C1S	848400	1/5/2009	100.09	100.03	100.23
ITRON	C1S	848401	1/5/2009	100.06	100.09	100.15
ITRON	C1S	848402	1/5/2009	100.06	99.93	99.98
ITRON	C1S	848403	1/5/2009	100.08	100.09	100.15
ITRON	C1S	848404	1/5/2009	100.07	100.04	100.11
ITRON	C1S	848405	1/5/2009	100.07	100.06	100.13
ITRON	C1S	848406	1/5/2009	100.10	100.04	100.11
ITRON	C1S	848407	1/5/2009	100.10	100.00	100.17
ITRON	C1S	848408	1/5/2009	100.09	100.14	100.20
ITRON	C1S	848409	1/5/2009	100.08	100.13	100.23
ITRON	C1S	848410	1/5/2009	100.06	100.07	100.13
ITRON	C1S	848411	1/5/2009	100.09	100.12	100.24
ITRON	C1S	848412	1/5/2009	100.06	100.08	100.18
ITRON	C1S	848413	1/5/2009	100.09	100.07	100.24
ITRON	C1S	848414	1/5/2009	100.07	100.07	100.16
ITRON	C1S	848415	1/5/2009	100.11	100.09	100.20
ITRON	C1S	848416	1/5/2009	100.06	99.97	99.97
ITRON	C1S	848417	1/5/2009	100.10	100.12	100.24
ITRON	C1S	848418	1/5/2009	100.09	99.94	100.17
ITRON	C1S	848419	1/5/2009	100.09	100.10	100.18
ITRON	C1S	848420	1/5/2009	100.06	99.94	100.06
ITRON	C1S	848421	1/5/2009	100.07	99.91	100.14
ITRON	C1S	848422	1/5/2009	100.08	99.97	100.09
ITRON	C1S	848423	1/5/2009	100.06	99.93	100.05
ITRON	C1S	848424	1/5/2009	100.10	100.09	100.02
ITRON	C1S	848425	1/5/2009	100.08	99.98	100.13
ITRON	C1S	848426	1/5/2009	100.08	100.02	100.11
ITRON	C1S	848427	1/5/2009	100.08	100.06	100.11
ITRON	C1S	848428	1/5/2009	100.06	100.05	100.13
ITRON	C1S	848429	1/5/2009	100.06	99.92	100.10

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848430	1/5/2009	100.08	99.99	100.05
ITRON	C1S	848431	1/5/2009	100.06	99.94	100.11
ITRON	C1S	848432	1/5/2009	100.08	99.95	100.14
ITRON	C1S	848433	1/5/2009	100.10	99.98	100.15
ITRON	C1S	848434	1/5/2009	100.09	100.00	100.07
ITRON	C1S	848435	1/5/2009	100.06	99.94	99.97
ITRON	C1S	848436	1/5/2009	100.10	99.96	100.13
ITRON	C1S	848437	1/5/2009	100.10	100.04	99.96
ITRON	C1S	848438	1/5/2009	100.05	100.00	99.99
ITRON	C1S	848439	1/5/2009	100.09	100.00	100.06
ITRON	C1S	848440	1/5/2009	100.06	99.95	99.93
ITRON	C1S	848441	1/5/2009	100.10	100.02	100.03
ITRON	C1S	848442	1/5/2009	100.07	100.02	100.13
ITRON	C1S	848443	1/5/2009	100.05	99.96	100.05
ITRON	C1S	848444	1/5/2009	100.07	100.00	99.97
ITRON	C1S	848445	1/5/2009	100.05	99.95	100.06
ITRON	C1S	848446	1/5/2009	100.08	100.02	100.17
ITRON	C1S	848447	1/5/2009	100.10	100.13	100.20
ITRON	C1S	848448	1/5/2009	100.09	100.00	100.07
ITRON	C1S	848449	1/5/2009	100.09	99.87	100.13
ITRON	C1S	848450	1/5/2009	100.08	100.07	100.12
ITRON	C1S	848451	1/5/2009	100.07	99.98	100.08
ITRON	C1S	848452	1/5/2009	100.09	100.09	100.18
ITRON	C1S	848453	1/5/2009	100.08	100.08	100.17
ITRON	C1S	848454	1/5/2009	100.08	99.97	100.15
ITRON	C1S	848455	1/5/2009	100.07	100.05	100.10
ITRON	C1S	848456	1/5/2009	100.10	100.08	100.22
ITRON	C1S	848457	1/5/2009	100.05	99.93	100.07
ITRON	C1S	848458	1/5/2009	100.06	100.04	100.11
ITRON	C1S	848459	1/5/2009	100.08	100.09	100.14
ITRON	C1S	848460	1/5/2009	100.08	100.00	100.11
ITRON	C1S	848461	1/5/2009	100.07	100.08	100.12
ITRON	C1S	848462	1/5/2009	100.07	99.98	99.97
ITRON	C1S	848463	1/5/2009	100.10	99.95	100.24
ITRON	C1S	848464	1/5/2009	100.07	100.06	100.12
ITRON	C1S	848465	1/5/2009	100.09	99.94	100.17
ITRON	C1S	848466	1/5/2009	100.08	100.08	100.16
ITRON	C1S	848467	1/5/2009	100.08	99.94	100.04
ITRON	C1S	848468	1/5/2009	100.10	100.01	100.07
ITRON	C1S	848469	1/5/2009	100.08	99.93	100.05
ITRON	C1S	848470	1/5/2009	100.09	100.05	100.22
ITRON	C1S	848471	1/5/2009	100.06	100.00	100.03
ITRON	C1S	848472	1/5/2009	100.05	100.06	100.13
ITRON	C1S	848473	1/5/2009	100.09	100.09	100.16
ITRON	C1S	848474	1/5/2009	100.09	99.98	100.17
ITRON	C1S	848475	1/5/2009	100.10	100.08	100.18
ITRON	C1S	848476	1/5/2009	100.07	100.00	100.04

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848477	1/5/2009	100.06	100.02	100.21
ITRON	C1S	848478	1/5/2009	100.06	99.98	99.90
ITRON	C1S	848479	1/5/2009	100.10	100.06	100.09
ITRON	C1S	848480	1/5/2009	100.09	100.07	100.26
ITRON	C1S	848481	1/5/2009	100.06	100.08	100.16
ITRON	C1S	848482	1/5/2009	100.08	99.97	99.91
ITRON	C1S	848483	1/5/2009	100.10	99.99	100.22
ITRON	C1S	848484	1/5/2009	100.08	99.93	100.11
ITRON	C1S	848485	1/5/2009	100.10	99.96	100.12
ITRON	C1S	848486	1/5/2009	100.09	100.09	100.18
ITRON	C1S	848487	1/5/2009	100.07	99.90	100.06
ITRON	C1S	848488	1/5/2009	100.08	100.03	100.00
ITRON	C1S	848489	1/5/2009	100.07	99.99	100.01
ITRON	C1S	848490	1/5/2009	100.06	99.87	100.04
ITRON	C1S	848491	1/5/2009	100.07	100.02	100.09
ITRON	C1S	848492	1/5/2009	100.08	99.97	100.13
ITRON	C1S	848493	1/5/2009	100.06	99.95	99.91
ITRON	C1S	848494	1/5/2009	100.08	100.08	100.18
ITRON	C1S	848495	1/5/2009	100.06	100.06	100.15
ITRON	C1S	848496	1/5/2009	100.09	99.93	99.99
ITRON	C1S	848497	1/5/2009	100.09	100.03	100.10
ITRON	C1S	848498	1/5/2009	100.06	99.98	100.05
ITRON	C1S	848499	1/5/2009	100.06	99.91	99.98
ITRON	C1S	848500	1/5/2009	100.11	100.05	100.08
ITRON	C1S	848501	1/5/2009	100.08	99.96	100.15
ITRON	C1S	848502	1/5/2009	100.07	100.04	100.04
ITRON	C1S	848503	1/5/2009	100.08	99.92	100.11
ITRON	C1S	848504	1/5/2009	100.09	99.97	100.06
ITRON	C1S	848505	1/5/2009	100.09	99.98	100.13
ITRON	C1S	848506	1/5/2009	100.08	99.99	100.12
ITRON	C1S	848507	1/5/2009	100.09	99.97	100.12
ITRON	C1S	848508	1/5/2009	100.08	100.06	100.16
ITRON	C1S	848509	1/5/2009	100.09	99.96	100.10
ITRON	C1S	848510	1/5/2009	100.09	100.08	100.20
ITRON	C1S	848511	1/5/2009	100.11	100.09	100.21
ITRON	C1S	848512	1/5/2009	100.07	99.94	100.12
ITRON	C1S	848513	1/5/2009	100.07	99.99	99.99
ITRON	C1S	848514	1/5/2009	100.10	100.00	100.08
ITRON	C1S	848515	1/5/2009	100.10	100.01	99.92
ITRON	C1S	848516	1/5/2009	100.10	99.98	100.08
ITRON	C1S	848517	1/5/2009	100.06	99.92	99.92
ITRON	C1S	848518	1/5/2009	100.07	99.88	100.10
ITRON	C1S	848519	1/5/2009	100.09	99.97	100.11
ITRON	C1S	848520	1/5/2009	100.09	100.08	100.22
ITRON	C1S	848521	1/5/2009	100.06	100.04	100.17
ITRON	C1S	848522	1/5/2009	100.06	100.08	100.16
ITRON	C1S	848523	1/5/2009	100.06	99.99	100.00

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848524	1/5/2009	100.08	100.03	100.16
ITRON	C1S	848525	1/5/2009	100.07	99.91	100.06
ITRON	C1S	848526	1/5/2009	100.06	99.92	100.20
ITRON	C1S	848527	1/5/2009	100.05	99.92	100.05
ITRON	C1S	848528	1/5/2009	100.06	99.93	100.24
ITRON	C1S	848529	1/5/2009	100.06	99.92	100.05
ITRON	C1S	848530	1/5/2009	100.11	100.02	100.06
ITRON	C1S	848531	1/5/2009	100.07	99.89	100.00
ITRON	C1S	848532	1/5/2009	100.06	99.98	100.08
ITRON	C1S	848533	1/5/2009	100.07	99.95	100.14
ITRON	C1S	848534	1/5/2009	100.06	99.95	100.12
ITRON	C1S	848535	1/5/2009	100.08	99.96	100.05
ITRON	C1S	848536	1/5/2009	100.09	99.98	100.11
ITRON	C1S	848537	1/5/2009	100.07	99.92	100.07
ITRON	C1S	848538	1/5/2009	100.08	99.93	100.05
ITRON	C1S	848539	1/5/2009	100.07	99.99	100.05
ITRON	C1S	848540	1/5/2009	100.10	100.11	100.23
ITRON	C1S	848541	1/5/2009	100.09	99.94	100.06
ITRON	C1S	848542	1/5/2009	100.06	100.01	100.05
ITRON	C1S	848543	1/5/2009	100.09	99.90	100.10
ITRON	C1S	848544	1/5/2009	100.06	99.86	100.16
ITRON	C1S	848545	1/5/2009	100.10	100.12	100.21
ITRON	C1S	848546	1/5/2009	100.08	99.95	100.16
ITRON	C1S	848547	1/5/2009	100.09	100.06	100.20
ITRON	C1S	848548	1/5/2009	100.09	100.05	100.19
ITRON	C1S	848549	1/5/2009	100.09	100.01	100.17
ITRON	C1S	848550	1/5/2009	100.10	99.99	100.14
ITRON	C1S	848551	1/5/2009	100.09	99.91	99.99
ITRON	C1S	848552	1/5/2009	100.10	100.08	100.21
ITRON	C1S	848553	1/5/2009	100.09	99.94	100.22
ITRON	C1S	848554	1/5/2009	100.11	99.99	100.07
ITRON	C1S	848555	1/5/2009	100.10	100.00	100.05
ITRON	C1S	848556	1/5/2009	100.07	100.03	100.17
ITRON	C1S	848557	1/5/2009	100.09	100.07	100.23
ITRON	C1S	848558	1/5/2009	100.07	100.10	100.10
ITRON	C1S	848559	1/5/2009	100.10	100.07	100.05
ITRON	C1S	848560	1/5/2009	100.06	100.01	99.91
ITRON	C1S	848561	1/5/2009	100.09	99.97	100.08
ITRON	C1S	848562	1/5/2009	100.06	99.94	99.99
ITRON	C1S	848563	1/5/2009	100.06	99.95	100.11
ITRON	C1S	848564	1/5/2009	100.08	99.96	100.00
ITRON	C1S	848565	1/5/2009	100.10	100.14	100.14
ITRON	C1S	848566	1/5/2009	100.07	100.02	100.09
ITRON	C1S	848567	1/5/2009	100.06	100.03	100.15
ITRON	C1S	848568	1/5/2009	100.07	100.06	100.19
ITRON	C1S	848569	1/5/2009	100.06	100.00	99.96
ITRON	C1S	848570	1/5/2009	100.07	99.95	100.02

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848571	1/5/2009	100.09	100.04	100.21
ITRON	C1S	848572	1/5/2009	100.06	99.98	99.90
ITRON	C1S	848573	1/5/2009	100.08	100.01	100.15
ITRON	C1S	848574	1/5/2009	100.08	100.07	100.13
ITRON	C1S	848575	1/5/2009	100.09	100.02	100.03
ITRON	C1S	848576	1/5/2009	100.07	99.97	100.15
ITRON	C1S	848577	1/5/2009	100.08	99.95	100.11
ITRON	C1S	848578	1/5/2009	100.10	100.14	100.19
ITRON	C1S	848579	1/5/2009	100.10	100.04	100.22
ITRON	C1S	848580	1/5/2009	100.09	99.87	100.13
ITRON	C1S	848581	1/5/2009	100.06	99.89	100.15
ITRON	C1S	848582	1/5/2009	100.07	100.00	100.01
ITRON	C1S	848583	1/5/2009	100.09	100.05	100.15
ITRON	C1S	848584	1/5/2009	100.09	100.18	100.17
ITRON	C1S	848585	1/5/2009	100.09	100.08	100.23
ITRON	C1S	848586	1/5/2009	100.06	99.91	100.11
ITRON	C1S	848587	1/5/2009	100.11	100.14	100.24
ITRON	C1S	848588	1/5/2009	100.09	100.00	100.01
ITRON	C1S	848589	1/5/2009	100.06	100.07	100.14
ITRON	C1S	848590	1/5/2009	100.10	99.94	100.14
ITRON	C1S	848591	1/5/2009	100.09	100.00	100.16
ITRON	C1S	848592	1/5/2009	100.08	100.07	100.25
ITRON	C1S	848593	1/5/2009	100.10	99.99	100.08
ITRON	C1S	848594	1/5/2009	100.08	99.98	100.02
ITRON	C1S	848595	1/5/2009	100.06	99.85	100.12
ITRON	C1S	848596	1/5/2009	100.10	100.03	100.17
ITRON	C1S	848597	1/5/2009	100.11	100.11	100.15
ITRON	C1S	848598	1/5/2009	100.08	100.00	100.10
ITRON	C1S	848599	1/5/2009	100.08	100.08	100.13
ITRON	C1S	848600	1/5/2009	100.06	100.00	100.20
ITRON	C1S	848601	1/5/2009	100.06	100.06	100.17
ITRON	C1S	848602	1/5/2009	100.09	100.06	100.02
ITRON	C1S	848603	1/5/2009	100.10	100.02	100.01
ITRON	C1S	848604	1/5/2009	100.10	99.91	100.09
ITRON	C1S	848605	1/5/2009	100.10	100.09	100.19
ITRON	C1S	848606	1/5/2009	100.10	100.09	100.19
ITRON	C1S	848607	1/5/2009	100.06	99.90	99.98
ITRON	C1S	848608	1/5/2009	100.07	99.92	100.12
ITRON	C1S	848609	1/5/2009	100.07	100.04	100.12
ITRON	C1S	848610	1/5/2009	100.10	100.06	100.21
ITRON	C1S	848611	1/5/2009	100.08	100.00	100.08
ITRON	C1S	848612	1/5/2009	100.06	100.01	100.11
ITRON	C1S	848613	1/5/2009	100.06	99.96	100.01
ITRON	C1S	848614	1/5/2009	100.08	100.09	100.13
ITRON	C1S	848615	1/5/2009	100.09	99.97	100.11
ITRON	C1S	848616	1/5/2009	100.07	100.01	100.03
ITRON	C1S	848617	1/5/2009	100.07	100.05	100.14

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848618	1/5/2009	100.06	99.91	100.00
ITRON	C1S	848619	1/5/2009	100.08	99.98	100.23
ITRON	C1S	848620	1/5/2009	100.11	100.10	100.20
ITRON	C1S	848621	1/5/2009	100.11	100.06	100.26
ITRON	C1S	848622	1/5/2009	100.09	99.95	100.07
ITRON	C1S	848623	1/5/2009	100.10	99.97	100.08
ITRON	C1S	848624	1/5/2009	100.10	99.94	100.11
ITRON	C1S	848625	1/5/2009	100.08	99.96	100.02
ITRON	C1S	848626	1/5/2009	100.07	99.96	100.05
ITRON	C1S	848627	1/5/2009	100.07	99.92	100.06
ITRON	C1S	848628	1/5/2009	100.07	100.09	100.27
ITRON	C1S	848629	1/5/2009	100.08	99.99	100.08
ITRON	C1S	848630	1/5/2009	100.05	99.93	100.11
ITRON	C1S	848631	1/5/2009	100.06	100.07	100.13
ITRON	C1S	848632	1/5/2009	100.08	100.01	100.03
ITRON	C1S	848633	1/5/2009	100.09	99.99	100.18
ITRON	C1S	848634	1/5/2009	100.06	99.97	99.98
ITRON	C1S	848635	1/5/2009	100.10	100.04	100.02
ITRON	C1S	848636	1/5/2009	100.07	99.90	100.09
ITRON	C1S	848637	1/5/2009	100.07	99.88	100.12
ITRON	C1S	848638	1/5/2009	100.06	100.04	100.14
ITRON	C1S	848639	1/5/2009	100.09	100.02	99.97
ITRON	C1S	848640	1/5/2009	100.07	100.05	100.11
ITRON	C1S	848641	1/5/2009	100.05	99.99	100.06
ITRON	C1S	848642	1/5/2009	100.10	99.97	100.02
ITRON	C1S	848643	1/5/2009	100.09	100.01	100.16
ITRON	C1S	848644	1/5/2009	100.08	100.11	100.15
ITRON	C1S	848645	1/5/2009	100.10	100.01	99.95
ITRON	C1S	848646	1/5/2009	100.11	99.99	100.04
ITRON	C1S	848647	1/5/2009	100.10	100.11	100.22
ITRON	C1S	848648	1/5/2009	100.10	99.89	100.11
ITRON	C1S	848649	1/5/2009	100.10	100.01	100.06
ITRON	C1S	848650	1/5/2009	100.07	100.05	100.15
ITRON	C1S	848651	1/5/2009	100.06	100.01	100.10
ITRON	C1S	848652	1/5/2009	100.08	99.98	100.00
ITRON	C1S	848653	1/5/2009	100.06	100.06	100.14
ITRON	C1S	848654	1/5/2009	100.08	99.95	100.17
ITRON	C1S	848655	1/5/2009	100.09	99.99	99.89
ITRON	C1S	848656	1/5/2009	100.06	100.01	99.98
ITRON	C1S	848657	1/5/2009	100.06	100.01	100.05
ITRON	C1S	848658	1/5/2009	100.10	100.03	100.12
ITRON	C1S	848659	1/5/2009	100.08	99.92	100.08
ITRON	C1S	848660	1/5/2009	100.08	99.97	100.12
ITRON	C1S	848661	1/5/2009	100.11	100.06	100.19
ITRON	C1S	848662	1/5/2009	100.06	100.05	100.20
ITRON	C1S	848663	1/5/2009	100.09	100.05	100.21
ITRON	C1S	848664	1/5/2009	100.06	99.96	100.22

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848665	1/5/2009	100.11	100.03	100.22
ITRON	C1S	848666	1/5/2009	100.07	100.06	100.17
ITRON	C1S	848667	1/5/2009	100.08	100.01	100.01
ITRON	C1S	848668	1/5/2009	100.08	100.03	100.04
ITRON	C1S	848669	1/5/2009	100.07	99.92	100.04
ITRON	C1S	848670	1/5/2009	100.07	99.96	99.98
ITRON	C1S	848671	1/5/2009	100.07	99.99	100.07
ITRON	C1S	848672	1/5/2009	100.06	99.92	100.01
ITRON	C1S	848673	1/5/2009	100.08	100.04	100.17
ITRON	C1S	848674	1/5/2009	100.07	100.00	100.04
ITRON	C1S	848675	1/5/2009	100.08	99.90	100.00
ITRON	C1S	848676	1/5/2009	100.06	99.98	100.11
ITRON	C1S	848677	1/5/2009	100.07	99.95	100.08
ITRON	C1S	848678	1/5/2009	100.08	99.91	99.93
ITRON	C1S	848679	1/5/2009	100.07	100.09	100.23
ITRON	C1S	848680	1/5/2009	100.07	100.00	99.91
ITRON	C1S	848681	1/5/2009	100.08	99.96	100.05
ITRON	C1S	848682	1/5/2009	100.08	100.10	100.20
ITRON	C1S	848683	1/5/2009	100.06	99.91	100.04
ITRON	C1S	848684	1/5/2009	100.08	100.02	100.17
ITRON	C1S	848685	1/5/2009	100.05	99.88	100.10
ITRON	C1S	848686	1/5/2009	100.10	99.94	100.14
ITRON	C1S	848687	1/5/2009	100.06	100.06	100.14
ITRON	C1S	848688	1/5/2009	100.08	100.09	100.19
ITRON	C1S	848689	1/5/2009	100.06	100.08	100.13
ITRON	C1S	848690	1/5/2009	100.10	100.01	100.03
ITRON	C1S	848691	1/5/2009	100.10	100.14	100.20
ITRON	C1S	848692	1/5/2009	100.08	99.96	100.03
ITRON	C1S	848693	1/5/2009	100.08	99.95	100.01
ITRON	C1S	848694	1/5/2009	100.10	100.11	100.21
ITRON	C1S	848695	1/5/2009	100.06	99.90	100.02
ITRON	C1S	848696	1/5/2009	100.06	99.93	100.13
ITRON	C1S	848697	1/5/2009	100.08	99.89	100.06
ITRON	C1S	848698	1/5/2009	100.10	99.94	100.23
ITRON	C1S	848699	1/5/2009	100.05	99.91	100.08
ITRON	C1S	848700	1/5/2009	100.11	100.06	100.15
ITRON	C1S	848701	1/5/2009	100.09	100.07	100.17
ITRON	C1S	848702	1/5/2009	100.06	100.00	100.04
ITRON	C1S	848703	1/5/2009	100.08	99.89	100.15
ITRON	C1S	848704	1/5/2009	100.08	99.99	100.06
ITRON	C1S	848705	1/5/2009	100.06	100.07	100.10
ITRON	C1S	848706	1/5/2009	100.07	100.05	100.15
ITRON	C1S	848707	1/5/2009	100.08	99.94	100.21
ITRON	C1S	848708	1/5/2009	100.07	99.95	99.98
ITRON	C1S	848709	1/5/2009	100.09	99.94	100.12
ITRON	C1S	848710	1/5/2009	100.08	100.03	100.21
ITRON	C1S	848711	1/5/2009	100.07	100.00	99.94

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848712	1/5/2009	100.10	99.92	100.17
ITRON	C1S	848713	1/5/2009	100.10	100.09	100.19
ITRON	C1S	848714	1/5/2009	100.10	100.03	100.13
ITRON	C1S	848715	1/5/2009	100.09	99.94	100.12
ITRON	C1S	848716	1/5/2009	100.08	99.99	100.08
ITRON	C1S	848717	1/5/2009	100.08	100.13	100.15
ITRON	C1S	848718	1/5/2009	100.08	100.00	100.05
ITRON	C1S	848719	1/5/2009	100.06	99.95	100.16
ITRON	C1S	848720	1/5/2009	100.07	99.96	100.07
ITRON	C1S	848721	1/5/2009	100.09	100.10	100.17
ITRON	C1S	848722	1/5/2009	100.06	99.97	99.84
ITRON	C1S	848723	1/5/2009	100.11	100.10	100.22
ITRON	C1S	848724	1/5/2009	100.08	99.95	100.01
ITRON	C1S	848725	1/5/2009	100.06	100.00	100.14
ITRON	C1S	848726	1/5/2009	100.08	99.99	100.03
ITRON	C1S	848727	1/5/2009	100.10	100.10	100.17
ITRON	C1S	848728	1/5/2009	100.07	100.00	99.99
ITRON	C1S	848729	1/5/2009	100.10	99.92	100.11
ITRON	C1S	848730	1/5/2009	100.07	100.07	100.18
ITRON	C1S	848731	1/5/2009	100.09	100.01	100.00
ITRON	C1S	848732	1/5/2009	100.08	100.03	100.02
ITRON	C1S	848733	1/5/2009	100.11	100.04	100.18
ITRON	C1S	848734	1/5/2009	100.07	99.97	100.08
ITRON	C1S	848735	1/5/2009	100.06	100.00	100.16
ITRON	C1S	848736	1/5/2009	100.09	99.94	100.14
ITRON	C1S	848737	1/5/2009	100.08	100.02	100.22
ITRON	C1S	848738	1/5/2009	100.09	99.90	100.11
ITRON	C1S	848739	1/5/2009	100.06	100.02	100.14
ITRON	C1S	848740	1/5/2009	100.06	99.97	100.01
ITRON	C1S	848741	1/5/2009	100.08	100.00	100.03
ITRON	C1S	848742	1/5/2009	100.07	100.04	100.13
ITRON	C1S	848743	1/5/2009	100.09	99.96	100.06
ITRON	C1S	848744	1/5/2009	100.07	100.03	100.20
ITRON	C1S	848745	1/5/2009	100.09	100.02	100.06
ITRON	C1S	848746	1/5/2009	100.07	99.91	100.06
ITRON	C1S	848747	1/5/2009	100.09	100.06	100.21
ITRON	C1S	848748	1/5/2009	100.06	100.06	100.14
ITRON	C1S	848749	1/5/2009	100.07	100.07	100.17
ITRON	C1S	848750	1/5/2009	100.07	99.91	100.06
ITRON	C1S	848751	1/5/2009	100.08	99.98	100.07
ITRON	C1S	848752	1/5/2009	100.11	99.96	100.26
ITRON	C1S	848753	1/5/2009	100.07	99.98	99.97
ITRON	C1S	848754	1/5/2009	100.10	100.11	100.14
ITRON	C1S	848755	1/5/2009	100.09	99.93	100.09
ITRON	C1S	848756	1/5/2009	100.09	100.02	100.10
ITRON	C1S	848757	1/5/2009	100.10	99.93	100.06
ITRON	C1S	848758	1/5/2009	100.09	100.00	100.06

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848759	1/5/2009	100.08	100.04	100.11
ITRON	C1S	848760	1/5/2009	100.07	99.97	100.23
ITRON	C1S	848761	1/5/2009	100.08	100.03	100.14
ITRON	C1S	848762	1/5/2009	100.08	99.94	100.01
ITRON	C1S	848763	1/5/2009	100.07	100.01	99.98
ITRON	C1S	848764	1/5/2009	100.07	100.14	100.14
ITRON	C1S	848765	1/5/2009	100.06	99.88	100.08
ITRON	C1S	848766	1/5/2009	100.09	100.01	100.01
ITRON	C1S	848767	1/5/2009	100.09	100.06	100.00
ITRON	C1S	848768	1/5/2009	100.10	100.11	100.15
ITRON	C1S	848769	1/5/2009	100.08	100.04	100.16
ITRON	C1S	848770	1/5/2009	100.07	100.03	100.00
ITRON	C1S	848771	1/5/2009	100.08	99.93	100.18
ITRON	C1S	848772	1/5/2009	100.10	100.13	100.19
ITRON	C1S	848773	1/5/2009	100.10	99.95	100.03
ITRON	C1S	848774	1/5/2009	100.09	100.03	100.19
ITRON	C1S	848775	1/5/2009	100.10	99.97	100.00
ITRON	C1S	848776	1/5/2009	100.06	100.05	100.11
ITRON	C1S	848777	1/5/2009	100.06	100.04	99.99
ITRON	C1S	848778	1/5/2009	100.08	100.08	100.20
ITRON	C1S	848779	1/5/2009	100.06	99.94	100.12
ITRON	C1S	848780	1/5/2009	100.07	100.10	100.11
ITRON	C1S	848781	1/5/2009	100.07	100.03	100.17
ITRON	C1S	848782	1/5/2009	100.06	99.92	100.02
ITRON	C1S	848783	1/5/2009	100.08	99.89	100.00
ITRON	C1S	848784	1/5/2009	100.06	99.91	100.09
ITRON	C1S	848785	1/5/2009	100.05	100.05	100.15
ITRON	C1S	848786	1/5/2009	100.05	99.95	99.96
ITRON	C1S	848787	1/5/2009	100.09	100.08	100.20
ITRON	C1S	848788	1/5/2009	100.09	100.08	100.16
ITRON	C1S	848789	1/5/2009	100.11	99.94	100.19
ITRON	C1S	848790	1/5/2009	100.10	100.07	100.18
ITRON	C1S	848791	1/5/2009	100.06	99.90	100.10
ITRON	C1S	848792	1/5/2009	100.08	99.91	99.98
ITRON	C1S	848793	1/5/2009	100.06	99.86	100.05
ITRON	C1S	848794	1/5/2009	100.08	100.05	100.03
ITRON	C1S	848795	1/5/2009	100.06	99.95	100.01
ITRON	C1S	848796	1/5/2009	100.11	100.08	100.15
ITRON	C1S	848797	1/5/2009	100.09	99.90	100.10
ITRON	C1S	848798	1/5/2009	100.06	99.98	99.94
ITRON	C1S	848799	1/5/2009	100.06	99.95	100.13
ITRON	C1S	848800	1/5/2009	100.07	100.04	100.15
ITRON	C1S	848801	1/5/2009	100.09	100.05	100.16
ITRON	C1S	848802	1/5/2009	100.06	99.91	99.98
ITRON	C1S	848803	1/5/2009	100.10	100.02	100.02
ITRON	C1S	848804	1/5/2009	100.07	99.93	100.11
ITRON	C1S	848805	1/5/2009	100.09	100.01	100.03

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848806	1/5/2009	100.10	99.99	100.16
ITRON	C1S	848807	1/5/2009	100.06	99.97	100.03
ITRON	C1S	848808	1/5/2009	100.09	100.08	100.09
ITRON	C1S	848809	1/5/2009	100.08	100.04	100.22
ITRON	C1S	848810	1/5/2009	100.06	100.07	100.11
ITRON	C1S	848811	1/5/2009	100.09	100.02	100.08
ITRON	C1S	848812	1/5/2009	100.06	99.88	100.12
ITRON	C1S	848813	1/5/2009	100.08	100.07	100.16
ITRON	C1S	848814	1/5/2009	100.06	100.03	100.13
ITRON	C1S	848815	1/5/2009	100.09	100.05	100.27
ITRON	C1S	848816	1/5/2009	100.09	99.97	100.05
ITRON	C1S	848817	1/5/2009	100.06	100.10	100.13
ITRON	C1S	848818	1/5/2009	100.10	99.97	99.97
ITRON	C1S	848819	1/5/2009	100.06	99.92	99.87
ITRON	C1S	848820	1/5/2009	100.10	100.09	100.08
ITRON	C1S	848821	1/5/2009	100.07	100.06	100.18
ITRON	C1S	848822	1/5/2009	100.07	99.92	100.13
ITRON	C1S	848823	1/5/2009	100.08	99.95	99.97
ITRON	C1S	848824	1/5/2009	100.09	100.11	100.27
ITRON	C1S	848825	1/5/2009	100.06	100.03	100.23
ITRON	C1S	848826	1/5/2009	100.10	99.92	100.11
ITRON	C1S	848827	1/5/2009	100.10	100.07	100.20
ITRON	C1S	848828	1/5/2009	100.07	100.01	99.99
ITRON	C1S	848829	1/5/2009	100.08	100.05	100.10
ITRON	C1S	848830	1/5/2009	100.10	99.97	100.16
ITRON	C1S	848831	1/5/2009	100.07	100.00	100.13
ITRON	C1S	848832	1/5/2009	100.10	99.96	100.09
ITRON	C1S	848833	1/5/2009	100.06	100.00	100.07
ITRON	C1S	848834	1/5/2009	100.06	99.87	100.09
ITRON	C1S	848835	1/5/2009	100.08	99.95	100.11
ITRON	C1S	848836	1/5/2009	100.07	99.95	99.85
ITRON	C1S	848837	1/5/2009	100.10	100.08	100.17
ITRON	C1S	848838	1/5/2009	100.09	100.14	100.19
ITRON	C1S	848839	1/5/2009	100.10	99.98	99.89
ITRON	C1S	848840	1/5/2009	100.07	99.94	100.15
ITRON	C1S	848841	1/5/2009	100.06	100.07	100.14
ITRON	C1S	848842	1/5/2009	100.06	100.01	100.19
ITRON	C1S	848843	1/5/2009	100.10	99.99	100.08
ITRON	C1S	848844	1/5/2009	100.09	100.11	100.16
ITRON	C1S	848845	1/5/2009	100.06	99.95	100.19
ITRON	C1S	848846	1/5/2009	100.09	100.05	100.01
ITRON	C1S	848847	1/5/2009	100.08	100.06	100.19
ITRON	C1S	848848	1/5/2009	100.06	100.06	100.12
ITRON	C1S	848849	1/5/2009	100.08	99.98	100.19
ITRON	C1S	848850	1/5/2009	100.10	100.00	100.15
ITRON	C1S	848851	1/5/2009	100.08	99.88	99.98
ITRON	C1S	848852	1/5/2009	100.08	100.01	100.01

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848853	1/5/2009	100.06	100.01	100.19
ITRON	C1S	848854	1/5/2009	100.07	99.96	99.87
ITRON	C1S	848855	1/5/2009	100.05	99.89	100.04
ITRON	C1S	848856	1/5/2009	100.06	99.93	100.12
ITRON	C1S	848857	1/5/2009	100.06	99.96	99.97
ITRON	C1S	848858	1/5/2009	100.06	99.92	100.03
ITRON	C1S	848859	1/5/2009	100.07	100.12	100.17
ITRON	C1S	848860	1/5/2009	100.10	100.00	100.21
ITRON	C1S	848861	1/5/2009	100.06	99.93	100.08
ITRON	C1S	848862	1/5/2009	100.08	99.94	100.16
ITRON	C1S	848863	1/5/2009	100.10	100.01	100.11
ITRON	C1S	848864	1/5/2009	100.10	99.88	100.14
ITRON	C1S	848865	1/5/2009	100.09	99.93	100.04
ITRON	C1S	848866	1/5/2009	100.06	99.98	99.98
ITRON	C1S	848867	1/5/2009	100.09	100.03	100.19
ITRON	C1S	848868	1/5/2009	100.07	100.02	100.21
ITRON	C1S	848869	1/5/2009	100.06	100.01	100.07
ITRON	C1S	848870	1/5/2009	100.08	99.94	100.06
ITRON	C1S	848871	1/5/2009	100.10	100.00	100.06
ITRON	C1S	848872	1/5/2009	100.09	99.91	100.14
ITRON	C1S	848873	1/5/2009	100.08	100.07	100.17
ITRON	C1S	848874	1/5/2009	100.05	100.02	100.17
ITRON	C1S	848875	1/5/2009	100.10	100.11	100.04
ITRON	C1S	848876	1/5/2009	100.06	99.94	99.97
ITRON	C1S	848877	1/5/2009	100.05	100.01	100.13
ITRON	C1S	848878	1/5/2009	100.07	99.94	100.01
ITRON	C1S	848879	1/5/2009	100.05	99.93	100.01
ITRON	C1S	848880	1/5/2009	100.06	99.98	100.01
ITRON	C1S	848881	1/5/2009	100.06	100.02	100.18
ITRON	C1S	848882	1/5/2009	100.10	99.97	100.14
ITRON	C1S	848883	1/5/2009	100.06	100.04	100.20
ITRON	C1S	848884	1/5/2009	100.06	99.99	99.97
ITRON	C1S	848885	1/5/2009	100.08	99.97	100.15
ITRON	C1S	848886	1/5/2009	100.09	99.91	100.07
ITRON	C1S	848887	1/5/2009	100.08	99.98	100.20
ITRON	C1S	848888	1/5/2009	100.10	99.92	100.04
ITRON	C1S	848889	1/5/2009	100.10	100.06	100.19
ITRON	C1S	848890	1/5/2009	100.08	99.94	99.98
ITRON	C1S	848891	1/5/2009	100.09	100.09	100.15
ITRON	C1S	848892	1/5/2009	100.08	99.97	100.15
ITRON	C1S	848893	1/5/2009	100.06	99.97	100.17
ITRON	C1S	848894	1/5/2009	100.10	100.11	100.16
ITRON	C1S	848895	1/5/2009	100.08	99.98	100.03
ITRON	C1S	848896	1/5/2009	100.09	100.07	100.25
ITRON	C1S	848897	1/5/2009	100.08	100.08	100.16
ITRON	C1S	848898	1/5/2009	100.09	100.02	100.07
ITRON	C1S	848899	1/5/2009	100.06	99.94	99.87

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	848900	1/5/2009	100.08	99.91	100.15
ITRON	C1S	848901	1/5/2009	100.08	100.05	100.12
ITRON	C1S	848902	1/5/2009	100.07	100.07	100.17
ITRON	C1S	848903	1/5/2009	100.07	99.92	99.85
ITRON	C1S	848904	1/5/2009	100.09	99.91	100.18
ITRON	C1S	848905	1/5/2009	100.09	99.99	100.22
ITRON	C1S	848906	1/5/2009	100.06	99.95	100.02
ITRON	C1S	848907	1/5/2009	100.06	99.99	100.16
ITRON	C1S	848908	1/5/2009	100.09	100.03	100.16
ITRON	C1S	848909	1/5/2009	100.06	100.01	100.06
ITRON	C1S	848910	1/5/2009	100.07	99.97	100.08
ITRON	C1S	848911	1/5/2009	100.08	99.96	100.19
ITRON	C1S	848912	1/5/2009	100.06	100.00	100.18
ITRON	C1S	848913	1/5/2009	100.06	99.94	100.18
ITRON	C1S	848914	1/5/2009	100.08	100.06	100.17
ITRON	C1S	848915	1/5/2009	100.09	99.96	100.13
ITRON	C1S	848916	1/5/2009	100.09	99.98	100.09
ITRON	C1S	848917	1/5/2009	100.08	99.99	99.98
ITRON	C1S	848918	1/5/2009	100.07	99.93	99.92
ITRON	C1S	848919	1/5/2009	100.07	99.96	99.90
ITRON	C1S	848920	1/5/2009	100.09	99.89	100.03
ITRON	C1S	848921	1/5/2009	100.09	100.06	100.26
ITRON	C1S	848922	1/5/2009	100.09	100.02	100.08
ITRON	C1S	848923	1/5/2009	100.10	100.07	100.01
ITRON	C1S	848924	1/5/2009	100.06	100.07	100.21
ITRON	C1S	848925	1/5/2009	100.09	100.07	100.27
ITRON	C1S	848926	1/5/2009	100.07	99.90	100.02
ITRON	C1S	848927	1/5/2009	100.06	99.90	100.11
ITRON	C1S	848928	1/5/2009	100.07	99.92	100.12
ITRON	C1S	848929	1/5/2009	100.11	100.00	100.00
ITRON	C1S	848930	1/5/2009	100.07	100.00	100.14
ITRON	C1S	848931	1/5/2009	100.06	99.98	100.05
ITRON	C1S	848932	1/5/2009	100.05	99.91	100.02
ITRON	C1S	848933	1/5/2009	100.07	99.92	100.13
ITRON	C1S	848934	1/5/2009	100.09	100.02	100.05
ITRON	C1S	848935	1/5/2009	100.06	99.92	100.10
ITRON	C1S	848936	1/5/2009	100.05	99.89	99.97
ITRON	C1S	848937	1/5/2009	100.09	100.10	100.20
ITRON	C1S	848938	1/5/2009	100.08	99.99	100.24
ITRON	C1S	848939	1/5/2009	100.05	100.01	100.18
ITRON	C1S	848940	1/5/2009	100.06	100.02	100.13
ITRON	C1S	848941	1/5/2009	100.07	100.02	100.08
ITRON	C1S	848942	1/5/2009	100.09	99.98	100.13
ITRON	C1S	848943	1/5/2009	100.09	99.97	100.13
ITRON	C1S	848944	1/5/2009	100.08	100.05	100.21
ITRON	C1S	848945	1/5/2009	100.07	100.07	100.15
ITRON	C1S	848946	1/5/2009	100.10	100.00	100.11

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848947	1/5/2009	100.08	99.97	99.92
ITRON	C1S	848948	1/5/2009	100.10	99.90	100.17
ITRON	C1S	848949	1/5/2009	100.10	99.97	100.12
ITRON	C1S	848950	1/5/2009	100.10	99.99	100.03
ITRON	C1S	848951	1/5/2009	100.06	99.91	100.06
ITRON	C1S	848952	1/5/2009	100.06	99.89	100.03
ITRON	C1S	848953	1/5/2009	100.05	100.05	100.20
ITRON	C1S	848954	1/5/2009	100.08	100.03	100.15
ITRON	C1S	848955	1/5/2009	100.07	99.85	100.09
ITRON	C1S	848956	1/5/2009	100.07	99.97	100.15
ITRON	C1S	848957	1/5/2009	100.08	99.98	100.24
ITRON	C1S	848958	1/5/2009	100.09	100.07	100.21
ITRON	C1S	848959	1/5/2009	100.10	100.01	99.86
ITRON	C1S	848960	1/5/2009	100.08	99.95	100.15
ITRON	C1S	848961	1/5/2009	100.09	99.96	100.18
ITRON	C1S	848962	1/5/2009	100.08	99.99	100.06
ITRON	C1S	848963	1/5/2009	100.10	100.12	100.23
ITRON	C1S	848964	1/5/2009	100.06	100.08	100.22
ITRON	C1S	848965	1/5/2009	100.07	99.94	100.10
ITRON	C1S	848966	1/5/2009	100.09	99.96	100.03
ITRON	C1S	848967	1/5/2009	100.07	99.99	100.14
ITRON	C1S	848968	1/5/2009	100.08	100.00	99.95
ITRON	C1S	848969	1/5/2009	100.11	100.13	100.17
ITRON	C1S	848970	1/5/2009	100.09	100.08	100.18
ITRON	C1S	848971	1/5/2009	100.06	99.94	100.02
ITRON	C1S	848972	1/5/2009	100.09	99.96	100.00
ITRON	C1S	848973	1/5/2009	100.07	100.00	99.95
ITRON	C1S	848974	1/5/2009	100.07	99.86	100.22
ITRON	C1S	848975	1/5/2009	100.10	99.95	100.18
ITRON	C1S	848976	1/5/2009	100.08	100.02	100.20
ITRON	C1S	848977	1/5/2009	100.09	100.05	99.99
ITRON	C1S	848978	1/5/2009	100.08	100.03	100.16
ITRON	C1S	848979	1/5/2009	100.10	99.97	100.16
ITRON	C1S	848980	1/5/2009	100.07	99.96	100.03
ITRON	C1S	848981	1/5/2009	100.08	100.11	100.13
ITRON	C1S	848982	1/5/2009	100.08	100.07	100.10
ITRON	C1S	848983	1/5/2009	100.08	99.96	100.11
ITRON	C1S	848984	1/5/2009	100.09	99.90	100.22
ITRON	C1S	848985	1/5/2009	100.10	100.11	100.16
ITRON	C1S	848986	1/5/2009	100.07	99.99	99.99
ITRON	C1S	848987	1/5/2009	100.08	100.02	100.14
ITRON	C1S	848988	1/5/2009	100.05	99.96	100.00
ITRON	C1S	848989	1/5/2009	100.06	99.94	100.09
ITRON	C1S	848990	1/5/2009	100.08	99.93	100.12
ITRON	C1S	848991	1/5/2009	100.10	100.06	100.20
ITRON	C1S	848992	1/5/2009	100.10	100.10	100.14
ITRON	C1S	848993	1/5/2009	100.07	99.97	99.83

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	848994	1/5/2009	100.07	99.93	100.10
ITRON	C1S	848995	1/5/2009	100.07	100.07	100.18
ITRON	C1S	848996	1/5/2009	100.07	99.94	99.90
ITRON	C1S	848997	1/5/2009	100.06	99.93	100.10
ITRON	C1S	848998	1/5/2009	100.10	100.04	100.19
ITRON	C1S	848999	1/5/2009	100.07	100.04	100.06
ITRON	C1S	849000	1/5/2009	100.09	100.02	100.08
ITRON	C1S	849001	1/5/2009	100.09	100.03	100.01
ITRON	C1S	849002	1/5/2009	100.07	100.06	100.10
ITRON	C1S	849003	1/5/2009	100.05	100.00	100.14
ITRON	C1S	849004	1/5/2009	100.08	99.93	100.02
ITRON	C1S	849005	1/5/2009	100.10	99.97	100.05
ITRON	C1S	849006	1/5/2009	100.05	99.96	99.97
ITRON	C1S	849007	1/5/2009	100.06	100.05	100.10
ITRON	C1S	849008	1/5/2009	100.06	99.96	100.14
ITRON	C1S	849009	1/5/2009	100.11	100.03	100.03
ITRON	C1S	849010	1/5/2009	100.10	99.98	100.17
ITRON	C1S	849011	1/5/2009	100.10	100.10	100.27
ITRON	C1S	849012	1/5/2009	100.11	100.09	100.19
ITRON	C1S	849013	1/5/2009	100.09	100.11	100.15
ITRON	C1S	849014	1/5/2009	100.05	100.03	100.01
ITRON	C1S	849015	1/5/2009	100.07	100.08	100.22
ITRON	C1S	849016	1/5/2009	100.06	100.00	100.02
ITRON	C1S	849017	1/5/2009	100.08	99.92	100.14
ITRON	C1S	849018	1/5/2009	100.08	99.96	100.12
ITRON	C1S	849019	1/5/2009	100.05	100.03	99.91
ITRON	C1S	849020	1/5/2009	100.08	100.03	100.20
ITRON	C1S	849021	1/5/2009	100.10	100.03	100.05
ITRON	C1S	849022	1/5/2009	100.08	100.02	100.07
ITRON	C1S	849023	1/5/2009	100.07	99.97	100.03
ITRON	C1S	849024	1/5/2009	100.07	99.89	100.07
ITRON	C1S	849025	1/5/2009	100.09	100.07	100.17
ITRON	C1S	849026	1/5/2009	100.07	99.86	100.01
ITRON	C1S	849027	1/5/2009	100.08	99.97	100.05
ITRON	C1S	849028	1/5/2009	100.06	99.95	100.02
ITRON	C1S	849029	1/5/2009	100.08	100.00	99.99
ITRON	C1S	849030	1/5/2009	100.07	100.08	100.19
ITRON	C1S	849031	1/5/2009	100.07	99.95	100.20
ITRON	C1S	849032	1/5/2009	100.09	99.96	100.06
ITRON	C1S	849033	1/5/2009	100.06	99.92	100.16
ITRON	C1S	849034	1/5/2009	100.07	100.14	100.18
ITRON	C1S	849035	1/5/2009	100.08	99.94	100.10
ITRON	C1S	849036	1/5/2009	100.08	99.88	100.20
ITRON	C1S	849037	1/5/2009	100.06	99.86	100.08
ITRON	C1S	849038	1/5/2009	100.08	100.00	100.18
ITRON	C1S	849039	1/5/2009	100.07	100.12	100.23
ITRON	C1S	849040	1/5/2009	100.10	99.99	100.05

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849041	1/5/2009	100.09	99.98	100.02
ITRON	C1S	849042	1/5/2009	100.08	100.09	100.16
ITRON	C1S	849043	1/5/2009	100.08	99.94	100.13
ITRON	C1S	849044	1/5/2009	100.10	99.98	99.98
ITRON	C1S	849045	1/5/2009	100.07	100.10	100.25
ITRON	C1S	849046	1/5/2009	100.07	99.95	100.00
ITRON	C1S	849047	1/5/2009	100.09	99.97	100.20
ITRON	C1S	849048	1/5/2009	100.09	100.09	100.11
ITRON	C1S	849049	1/5/2009	100.08	100.07	100.26
ITRON	C1S	849050	1/5/2009	100.10	100.06	100.12
ITRON	C1S	849051	1/5/2009	100.10	100.15	100.19
ITRON	C1S	849052	1/5/2009	100.06	100.01	100.18
ITRON	C1S	849053	1/5/2009	100.05	99.90	100.08
ITRON	C1S	849054	1/5/2009	100.06	100.07	100.17
ITRON	C1S	849055	1/5/2009	100.09	100.06	100.00
ITRON	C1S	849056	1/5/2009	100.09	99.99	100.14
ITRON	C1S	849057	1/5/2009	100.10	99.99	100.09
ITRON	C1S	849058	1/5/2009	100.10	100.05	100.20
ITRON	C1S	849059	1/5/2009	100.08	100.08	100.20
ITRON	C1S	849060	1/5/2009	100.08	99.99	100.04
ITRON	C1S	849061	1/5/2009	100.10	100.00	100.06
ITRON	C1S	849062	1/5/2009	100.09	100.08	100.15
ITRON	C1S	849063	1/5/2009	100.07	100.05	100.24
ITRON	C1S	849064	1/5/2009	100.07	99.96	100.04
ITRON	C1S	849065	1/5/2009	100.09	100.02	99.93
ITRON	C1S	849066	1/5/2009	100.09	99.95	100.03
ITRON	C1S	849067	1/5/2009	100.09	99.98	100.05
ITRON	C1S	849068	1/5/2009	100.07	100.12	100.20
ITRON	C1S	849069	1/5/2009	100.06	99.97	99.98
ITRON	C1S	849070	1/5/2009	100.06	99.85	100.09
ITRON	C1S	849071	1/5/2009	100.08	100.03	100.19
ITRON	C1S	849072	1/5/2009	100.10	100.07	100.26
ITRON	C1S	849073	1/5/2009	100.05	99.90	100.22
ITRON	C1S	849074	1/5/2009	100.06	99.88	100.09
ITRON	C1S	849075	1/5/2009	100.06	100.05	100.19
ITRON	C1S	849076	1/5/2009	100.07	99.94	100.14
ITRON	C1S	849077	1/5/2009	100.05	99.99	99.99
ITRON	C1S	849078	1/5/2009	100.06	100.04	100.16
ITRON	C1S	849079	1/5/2009	100.07	99.94	100.15
ITRON	C1S	849080	1/5/2009	100.06	99.98	100.23
ITRON	C1S	849081	1/5/2009	100.08	99.90	100.15
ITRON	C1S	849082	1/5/2009	100.06	99.93	100.15
ITRON	C1S	849083	1/5/2009	100.10	100.12	100.14
ITRON	C1S	849084	1/5/2009	100.05	100.03	100.18
ITRON	C1S	849085	1/5/2009	100.07	100.01	100.14
ITRON	C1S	849086	1/5/2009	100.08	99.95	100.03
ITRON	C1S	849087	1/5/2009	100.08	99.97	100.11

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849088	1/5/2009	100.10	99.98	100.19
ITRON	C1S	849089	1/5/2009	100.08	100.08	100.19
ITRON	C1S	849090	1/5/2009	100.07	99.87	100.08
ITRON	C1S	849091	1/5/2009	100.05	99.98	100.16
ITRON	C1S	849092	1/5/2009	100.08	100.07	99.91
ITRON	C1S	849093	1/5/2009	100.10	100.06	100.21
ITRON	C1S	849094	1/5/2009	100.09	99.95	100.01
ITRON	C1S	849095	1/5/2009	100.07	99.95	100.00
ITRON	C1S	849096	1/5/2009	100.06	99.98	100.16
ITRON	C1S	849097	1/5/2009	100.09	100.01	100.01
ITRON	C1S	849098	1/5/2009	100.09	100.00	100.07
ITRON	C1S	849099	1/5/2009	100.06	99.95	99.98
ITRON	C1S	849100	1/5/2009	100.08	99.92	100.13
ITRON	C1S	849101	1/5/2009	100.07	100.07	100.13
ITRON	C1S	849102	1/5/2009	100.06	100.03	100.14
ITRON	C1S	849103	1/5/2009	100.08	99.92	100.12
ITRON	C1S	849104	1/5/2009	100.09	100.14	100.24
ITRON	C1S	849105	1/5/2009	100.06	99.89	100.19
ITRON	C1S	849106	1/5/2009	100.10	100.00	100.03
ITRON	C1S	849107	1/5/2009	100.08	100.09	100.16
ITRON	C1S	849108	1/5/2009	100.08	100.06	100.18
ITRON	C1S	849109	1/5/2009	100.10	100.00	100.07
ITRON	C1S	849110	1/5/2009	100.07	100.02	100.15
ITRON	C1S	849111	1/5/2009	100.06	99.90	100.02
ITRON	C1S	849112	1/5/2009	100.08	100.02	100.14
ITRON	C1S	849113	1/5/2009	100.10	99.89	100.11
ITRON	C1S	849114	1/5/2009	100.06	99.94	100.14
ITRON	C1S	849115	1/5/2009	100.05	99.87	99.83
ITRON	C1S	849116	1/5/2009	100.07	100.09	100.19
ITRON	C1S	849117	1/5/2009	100.06	99.89	100.12
ITRON	C1S	849118	1/5/2009	100.08	99.92	100.11
ITRON	C1S	849119	1/5/2009	100.09	100.17	100.24
ITRON	C1S	849120	1/5/2009	100.05	99.89	100.15
ITRON	C1S	849121	1/5/2009	100.09	99.96	100.11
ITRON	C1S	849122	1/5/2009	100.07	100.05	99.96
ITRON	C1S	849123	1/5/2009	100.09	100.12	100.16
ITRON	C1S	849124	1/5/2009	100.07	99.97	100.08
ITRON	C1S	849125	1/5/2009	100.06	99.96	100.08
ITRON	C1S	849126	1/5/2009	100.07	99.97	99.85
ITRON	C1S	849127	1/5/2009	100.09	100.03	100.00
ITRON	C1S	849128	1/5/2009	100.07	100.02	99.97
ITRON	C1S	849129	1/5/2009	100.09	99.95	100.15
ITRON	C1S	849130	1/5/2009	100.09	100.03	100.01
ITRON	C1S	849131	1/5/2009	100.09	100.11	100.25
ITRON	C1S	849132	1/5/2009	100.08	100.01	100.11
ITRON	C1S	849133	1/5/2009	100.06	99.91	100.13
ITRON	C1S	849134	1/5/2009	100.08	100.07	100.19

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849135	1/5/2009	100.08	100.00	100.12
ITRON	C1S	849136	1/5/2009	100.09	100.06	100.17
ITRON	C1S	849137	1/5/2009	100.08	99.97	100.03
ITRON	C1S	849138	1/5/2009	100.09	100.04	100.21
ITRON	C1S	849139	1/5/2009	100.09	100.06	100.03
ITRON	C1S	849140	1/5/2009	100.08	100.02	99.91
ITRON	C1S	849141	1/5/2009	100.06	99.92	100.03
ITRON	C1S	849142	1/5/2009	100.08	100.01	99.91
ITRON	C1S	849143	1/5/2009	100.07	99.92	100.10
ITRON	C1S	849144	1/5/2009	100.08	99.98	99.93
ITRON	C1S	849145	1/5/2009	100.06	99.97	99.99
ITRON	C1S	849146	1/5/2009	100.06	99.92	99.86
ITRON	C1S	849147	1/5/2009	100.06	100.07	100.22
ITRON	C1S	849148	1/5/2009	100.09	99.94	100.22
ITRON	C1S	849149	1/5/2009	100.08	99.98	99.98
ITRON	C1S	849150	1/5/2009	100.08	100.05	100.15
ITRON	C1S	849151	1/5/2009	100.08	100.04	100.21
ITRON	C1S	849152	1/5/2009	100.06	99.97	100.24
ITRON	C1S	849153	1/5/2009	100.08	100.01	100.00
ITRON	C1S	849154	1/5/2009	100.08	100.02	100.12
ITRON	C1S	849155	1/5/2009	100.08	99.93	100.15
ITRON	C1S	849156	1/5/2009	100.09	99.97	100.04
ITRON	C1S	849157	1/5/2009	100.08	99.94	100.22
ITRON	C1S	849158	1/5/2009	100.06	99.90	100.18
ITRON	C1S	849159	1/5/2009	100.08	100.01	100.02
ITRON	C1S	849160	1/5/2009	100.06	99.91	100.09
ITRON	C1S	849161	1/5/2009	100.06	99.91	100.02
ITRON	C1S	849162	1/5/2009	100.09	99.96	100.14
ITRON	C1S	849163	1/5/2009	100.07	99.93	100.14
ITRON	C1S	849164	1/5/2009	100.10	100.11	100.23
ITRON	C1S	849165	1/5/2009	100.05	100.03	100.14
ITRON	C1S	849166	1/5/2009	100.07	99.97	99.91
ITRON	C1S	849167	1/5/2009	100.05	99.91	99.99
ITRON	C1S	849168	1/5/2009	100.06	100.08	100.16
ITRON	C1S	849169	1/5/2009	100.07	99.91	100.18
ITRON	C1S	849170	1/5/2009	100.08	99.94	100.10
ITRON	C1S	849171	1/5/2009	100.09	100.03	100.13
ITRON	C1S	849172	1/5/2009	100.10	100.02	100.15
ITRON	C1S	849173	1/5/2009	100.10	99.93	100.01
ITRON	C1S	849174	1/5/2009	100.06	99.96	100.12
ITRON	C1S	849175	1/5/2009	100.07	99.98	100.06
ITRON	C1S	849176	1/5/2009	100.10	99.93	100.01
ITRON	C1S	849177	1/5/2009	100.06	100.02	100.05
ITRON	C1S	849178	1/5/2009	100.06	99.92	100.18
ITRON	C1S	849179	1/5/2009	100.09	99.96	100.16
ITRON	C1S	849180	1/5/2009	100.05	99.93	100.02
ITRON	C1S	849181	1/5/2009	100.09	100.09	100.16

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849182	1/5/2009	100.07	99.99	100.11
ITRON	C1S	849183	1/5/2009	100.07	100.02	100.17
ITRON	C1S	849184	1/5/2009	100.06	100.02	100.13
ITRON	C1S	849185	1/5/2009	100.08	100.00	100.00
ITRON	C1S	849186	1/5/2009	100.08	100.02	100.09
ITRON	C1S	849187	1/5/2009	100.10	99.95	100.24
ITRON	C1S	849188	1/5/2009	100.06	100.07	100.21
ITRON	C1S	849189	1/5/2009	100.10	100.03	100.17
ITRON	C1S	849190	1/5/2009	100.09	100.04	100.21
ITRON	C1S	849191	1/5/2009	100.08	99.95	99.92
ITRON	C1S	849192	1/5/2009	100.10	100.13	100.19
ITRON	C1S	849193	1/5/2009	100.08	99.99	100.11
ITRON	C1S	849194	1/5/2009	100.10	99.92	100.09
ITRON	C1S	849195	1/5/2009	100.06	100.07	100.19
ITRON	C1S	849196	1/5/2009	100.09	100.07	100.12
ITRON	C1S	849197	1/5/2009	100.09	100.06	100.21
ITRON	C1S	849198	1/5/2009	100.07	100.01	100.11
ITRON	C1S	849199	1/5/2009	100.10	100.09	100.20
ITRON	C1S	849200	1/5/2009	100.07	99.91	100.11
ITRON	C1S	849201	1/5/2009	100.07	100.01	99.93
ITRON	C1S	849202	1/5/2009	100.05	99.92	100.10
ITRON	C1S	849203	1/5/2009	100.07	99.95	100.07
ITRON	C1S	849204	1/5/2009	100.07	99.97	100.01
ITRON	C1S	849205	1/5/2009	100.08	100.07	100.21
ITRON	C1S	849206	1/5/2009	100.08	100.11	100.19
ITRON	C1S	849207	1/5/2009	100.07	99.96	100.12
ITRON	C1S	849208	1/5/2009	100.07	100.01	100.24
ITRON	C1S	849209	1/5/2009	100.07	99.90	99.98
ITRON	C1S	849210	1/5/2009	100.09	99.98	100.11
ITRON	C1S	849211	1/5/2009	100.06	99.96	100.19
ITRON	C1S	849212	1/5/2009	100.06	99.97	100.08
ITRON	C1S	849213	1/5/2009	100.08	99.89	100.19
ITRON	C1S	849214	1/5/2009	100.08	100.05	100.20
ITRON	C1S	849215	1/5/2009	100.06	100.01	100.16
ITRON	C1S	849216	1/5/2009	100.07	100.07	100.09
ITRON	C1S	849217	1/5/2009	100.07	100.00	99.94
ITRON	C1S	849218	1/5/2009	100.10	99.93	100.15
ITRON	C1S	849219	1/5/2009	100.07	99.92	100.09
ITRON	C1S	849220	1/5/2009	100.09	99.94	100.14
ITRON	C1S	849221	1/5/2009	100.06	100.02	100.01
ITRON	C1S	849222	1/5/2009	100.05	99.90	99.95
ITRON	C1S	849223	1/5/2009	100.06	99.96	100.20
ITRON	C1S	849224	1/5/2009	100.09	99.94	100.07
ITRON	C1S	849225	1/5/2009	100.10	99.98	100.05
ITRON	C1S	849226	1/5/2009	100.08	99.94	100.20
ITRON	C1S	849227	1/5/2009	100.07	99.94	100.02
ITRON	C1S	849228	1/5/2009	100.06	99.94	100.00

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849229	1/5/2009	100.10	99.99	100.08
ITRON	C1S	849230	1/5/2009	100.08	100.14	100.19
ITRON	C1S	849231	1/5/2009	100.08	100.08	100.11
ITRON	C1S	849232	1/5/2009	100.10	100.11	100.20
ITRON	C1S	849233	1/5/2009	100.09	100.02	100.15
ITRON	C1S	849234	1/5/2009	100.06	99.96	100.16
ITRON	C1S	849235	1/5/2009	100.07	99.96	100.16
ITRON	C1S	849236	1/5/2009	100.09	100.06	100.05
ITRON	C1S	849237	1/5/2009	100.07	100.04	100.13
ITRON	C1S	849238	1/5/2009	100.10	99.99	100.05
ITRON	C1S	849239	1/5/2009	100.07	99.93	100.19
ITRON	C1S	849240	1/5/2009	100.11	100.02	100.04
ITRON	C1S	849241	1/5/2009	100.06	99.93	100.02
ITRON	C1S	849242	1/5/2009	100.10	99.95	100.09
ITRON	C1S	849243	1/5/2009	100.07	99.86	99.98
ITRON	C1S	849244	1/5/2009	100.08	100.00	100.09
ITRON	C1S	849245	1/5/2009	100.09	99.99	100.21
ITRON	C1S	849246	1/5/2009	100.06	99.95	100.05
ITRON	C1S	849247	1/5/2009	100.06	99.87	100.20
ITRON	C1S	849248	1/5/2009	100.08	99.91	100.10
ITRON	C1S	849249	1/5/2009	100.05	100.07	100.10
ITRON	C1S	849250	1/5/2009	100.09	99.95	100.14
ITRON	C1S	849251	1/5/2009	100.09	99.98	100.01
ITRON	C1S	849252	1/5/2009	100.10	100.06	100.14
ITRON	C1S	849253	1/5/2009	100.07	99.92	100.07
ITRON	C1S	849254	1/5/2009	100.06	100.10	100.12
ITRON	C1S	849255	1/5/2009	100.10	99.99	99.98
ITRON	C1S	849256	1/5/2009	100.07	99.93	100.12
ITRON	C1S	849257	1/5/2009	100.07	99.91	100.11
ITRON	C1S	849258	1/5/2009	100.07	99.93	99.99
ITRON	C1S	849259	1/5/2009	100.06	100.01	100.17
ITRON	C1S	849260	1/5/2009	100.08	99.98	100.15
ITRON	C1S	849261	1/5/2009	100.07	100.05	100.00
ITRON	C1S	849262	1/5/2009	100.07	100.04	100.14
ITRON	C1S	849263	1/5/2009	100.08	100.08	100.03
ITRON	C1S	849264	1/5/2009	100.10	99.91	100.10
ITRON	C1S	849265	1/5/2009	100.10	99.95	99.98
ITRON	C1S	849266	1/5/2009	100.05	99.98	99.90
ITRON	C1S	849267	1/5/2009	100.10	100.06	100.20
ITRON	C1S	849268	1/5/2009	100.08	99.99	99.89
ITRON	C1S	849269	1/5/2009	100.08	100.11	100.14
ITRON	C1S	849270	1/5/2009	100.07	99.99	100.11
ITRON	C1S	849271	1/5/2009	100.07	99.93	100.12
ITRON	C1S	849272	1/5/2009	100.06	100.03	100.09
ITRON	C1S	849273	1/5/2009	100.10	100.06	100.22
ITRON	C1S	849274	1/5/2009	100.09	100.00	100.09
ITRON	C1S	849275	1/5/2009	100.07	99.89	100.13

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849276	1/5/2009	100.09	100.11	100.16
ITRON	C1S	849277	1/5/2009	100.08	99.91	100.10
ITRON	C1S	849278	1/5/2009	100.06	100.03	100.19
ITRON	C1S	849279	1/5/2009	100.05	99.99	100.02
ITRON	C1S	849280	1/5/2009	100.09	99.98	99.90
ITRON	C1S	849281	1/5/2009	100.09	99.97	100.09
ITRON	C1S	849282	1/5/2009	100.05	100.06	100.23
ITRON	C1S	849283	1/5/2009	100.06	99.92	100.10
ITRON	C1S	849284	1/5/2009	100.10	100.00	100.11
ITRON	C1S	849285	1/5/2009	100.07	100.06	100.21
ITRON	C1S	849286	1/5/2009	100.06	100.02	100.17
ITRON	C1S	849287	1/5/2009	100.11	100.05	100.06
ITRON	C1S	849288	1/5/2009	100.10	100.02	99.99
ITRON	C1S	849289	1/5/2009	100.08	99.99	100.14
ITRON	C1S	849290	1/5/2009	100.10	100.08	100.20
ITRON	C1S	849291	1/5/2009	100.09	99.99	99.92
ITRON	C1S	849292	1/5/2009	100.07	99.97	100.10
ITRON	C1S	849293	1/5/2009	100.07	99.95	100.10
ITRON	C1S	849294	1/5/2009	100.08	100.05	100.22
ITRON	C1S	849295	1/5/2009	100.06	99.94	100.02
ITRON	C1S	849296	1/5/2009	100.06	99.96	100.02
ITRON	C1S	849297	1/5/2009	100.10	100.09	100.14
ITRON	C1S	849298	1/5/2009	100.07	99.94	100.05
ITRON	C1S	849299	1/5/2009	100.09	100.11	100.04
ITRON	C1S	849300	1/5/2009	100.08	100.01	100.11
ITRON	C1S	849301	1/5/2009	100.08	99.95	100.17
ITRON	C1S	849302	1/5/2009	100.10	100.07	100.20
ITRON	C1S	849303	1/5/2009	100.06	100.06	100.12
ITRON	C1S	849304	1/5/2009	100.07	99.95	99.98
ITRON	C1S	849305	1/5/2009	100.07	99.95	100.09
ITRON	C1S	849306	1/5/2009	100.07	99.97	100.05
ITRON	C1S	849307	1/5/2009	100.08	99.93	99.99
ITRON	C1S	849308	1/5/2009	100.06	100.08	100.14
ITRON	C1S	849309	1/5/2009	100.08	99.97	100.00
ITRON	C1S	849310	1/5/2009	100.08	100.08	100.19
ITRON	C1S	849311	1/5/2009	100.10	99.97	100.01
ITRON	C1S	849312	1/5/2009	100.07	99.93	100.00
ITRON	C1S	849313	1/5/2009	100.05	99.97	100.13
ITRON	C1S	849314	1/5/2009	100.09	99.98	100.07
ITRON	C1S	849315	1/5/2009	100.06	99.93	100.10
ITRON	C1S	849316	1/5/2009	100.08	99.96	100.05
ITRON	C1S	849317	1/5/2009	100.10	100.06	100.20
ITRON	C1S	849318	1/5/2009	100.09	100.08	100.18
ITRON	C1S	849319	1/5/2009	100.05	99.94	99.94
ITRON	C1S	849320	1/5/2009	100.10	99.92	100.04
ITRON	C1S	849321	1/5/2009	100.05	99.98	99.88
ITRON	C1S	849322	1/5/2009	100.09	99.98	100.05

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849323	1/5/2009	100.10	100.10	99.95
ITRON	C1S	849324	1/5/2009	100.08	100.11	100.16
ITRON	C1S	849325	1/5/2009	100.07	100.10	100.14
ITRON	C1S	849326	1/5/2009	100.05	99.87	100.08
ITRON	C1S	849327	1/5/2009	100.10	99.99	100.00
ITRON	C1S	849328	1/5/2009	100.06	100.09	100.15
ITRON	C1S	849329	1/5/2009	100.08	100.01	100.13
ITRON	C1S	849330	1/5/2009	100.09	100.12	100.21
ITRON	C1S	849331	1/5/2009	100.06	99.91	100.10
ITRON	C1S	849332	1/5/2009	100.06	100.04	100.17
ITRON	C1S	849333	1/5/2009	100.06	99.98	100.08
ITRON	C1S	849334	1/5/2009	100.10	100.09	100.17
ITRON	C1S	849335	1/5/2009	100.06	99.96	100.05
ITRON	C1S	849336	1/5/2009	100.07	100.02	100.14
ITRON	C1S	849337	1/5/2009	100.09	100.05	100.13
ITRON	C1S	849338	1/5/2009	100.06	99.96	100.15
ITRON	C1S	849339	1/5/2009	100.06	100.09	100.18
ITRON	C1S	849340	1/5/2009	100.07	99.95	100.09
ITRON	C1S	849341	1/5/2009	100.09	100.11	100.20
ITRON	C1S	849342	1/5/2009	100.09	99.98	100.08
ITRON	C1S	849343	1/5/2009	100.05	99.98	100.15
ITRON	C1S	849344	1/5/2009	100.06	100.03	100.17
ITRON	C1S	849345	1/5/2009	100.09	99.96	100.02
ITRON	C1S	849346	1/5/2009	100.09	99.93	100.08
ITRON	C1S	849347	1/5/2009	100.09	100.01	100.07
ITRON	C1S	849348	1/5/2009	100.06	100.05	100.10
ITRON	C1S	849349	1/5/2009	100.05	100.01	100.15
ITRON	C1S	849350	1/5/2009	100.08	100.08	100.15
ITRON	C1S	849351	1/5/2009	100.06	99.92	100.13
ITRON	C1S	849352	1/5/2009	100.07	99.97	99.91
ITRON	C1S	849353	1/5/2009	100.08	100.06	100.21
ITRON	C1S	849354	1/5/2009	100.11	100.02	100.18
ITRON	C1S	849355	1/5/2009	100.07	99.96	100.09
ITRON	C1S	849356	1/5/2009	100.10	100.08	100.16
ITRON	C1S	849357	1/5/2009	100.08	99.90	100.12
ITRON	C1S	849358	1/5/2009	100.10	99.96	100.07
ITRON	C1S	849359	1/5/2009	100.08	100.00	100.13
ITRON	C1S	849360	1/5/2009	100.06	99.95	100.11
ITRON	C1S	849361	1/5/2009	100.07	100.08	100.19
ITRON	C1S	849362	1/5/2009	100.08	99.98	100.20
ITRON	C1S	849363	1/5/2009	100.06	99.92	100.01
ITRON	C1S	849364	1/5/2009	100.08	100.01	100.14
ITRON	C1S	849365	1/5/2009	100.09	99.99	100.17
ITRON	C1S	849366	1/5/2009	100.06	99.94	100.09
ITRON	C1S	849367	1/5/2009	100.06	99.98	99.93
ITRON	C1S	849368	1/5/2009	100.09	100.00	100.11
ITRON	C1S	849369	1/5/2009	100.06	99.99	100.00

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849370	1/5/2009	100.08	100.05	100.22
ITRON	C1S	849371	1/5/2009	100.08	100.01	100.11
ITRON	C1S	849372	1/5/2009	100.10	100.01	100.07
ITRON	C1S	849373	1/5/2009	100.09	100.12	100.21
ITRON	C1S	849374	1/5/2009	100.09	100.08	100.19
ITRON	C1S	849375	1/5/2009	100.09	99.99	100.19
ITRON	C1S	849376	1/5/2009	100.10	100.07	100.16
ITRON	C1S	849377	1/5/2009	100.06	100.11	100.17
ITRON	C1S	849378	1/5/2009	100.06	99.97	99.88
ITRON	C1S	849379	1/5/2009	100.09	99.98	100.14
ITRON	C1S	849380	1/5/2009	100.09	99.96	100.03
ITRON	C1S	849381	1/5/2009	100.06	100.04	100.16
ITRON	C1S	849382	1/5/2009	100.07	99.99	100.15
ITRON	C1S	849383	1/5/2009	100.06	99.98	100.02
ITRON	C1S	849384	1/5/2009	100.08	100.03	99.98
ITRON	C1S	849385	1/5/2009	100.10	99.85	100.13
ITRON	C1S	849386	1/5/2009	100.08	100.01	100.09
ITRON	C1S	849387	1/5/2009	100.08	99.95	100.06
ITRON	C1S	849388	1/5/2009	100.07	100.02	100.19
ITRON	C1S	849389	1/5/2009	100.07	100.05	100.17
ITRON	C1S	849390	1/5/2009	100.10	99.95	100.17
ITRON	C1S	849391	1/5/2009	100.08	100.07	100.21
ITRON	C1S	849392	1/5/2009	100.09	99.95	100.04
ITRON	C1S	849393	1/5/2009	100.10	100.02	99.92
ITRON	C1S	849394	1/5/2009	100.08	99.94	100.16
ITRON	C1S	849395	1/5/2009	100.09	100.03	100.23
ITRON	C1S	849396	1/5/2009	100.09	100.04	100.09
ITRON	C1S	849397	1/5/2009	100.06	99.92	100.10
ITRON	C1S	849398	1/5/2009	100.10	100.04	100.26
ITRON	C1S	849399	1/5/2009	100.07	99.96	100.12
ITRON	C1S	849400	1/5/2009	100.06	99.94	100.26
ITRON	C1S	849401	1/5/2009	100.10	100.03	100.01
ITRON	C1S	849402	1/5/2009	100.06	100.03	100.26
ITRON	C1S	849403	1/5/2009	100.09	99.96	100.00
ITRON	C1S	849404	1/5/2009	100.06	100.06	100.12
ITRON	C1S	849405	1/5/2009	100.07	100.03	100.10
ITRON	C1S	849406	1/5/2009	100.06	100.00	100.00
ITRON	C1S	849407	1/5/2009	100.08	99.99	100.14
ITRON	C1S	849408	1/5/2009	100.08	99.99	100.07
ITRON	C1S	849409	1/5/2009	100.07	100.00	100.12
ITRON	C1S	849410	1/5/2009	100.06	99.96	100.11
ITRON	C1S	849411	1/5/2009	100.10	99.96	100.01
ITRON	C1S	849412	1/5/2009	100.06	100.03	100.14
ITRON	C1S	849413	1/5/2009	100.06	100.08	100.19
ITRON	C1S	849414	1/5/2009	100.08	100.03	100.17
ITRON	C1S	849415	1/5/2009	100.09	100.12	100.16
ITRON	C1S	849416	1/5/2009	100.06	99.89	100.07

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849417	1/5/2009	100.08	100.03	100.05
ITRON	C1S	849418	1/5/2009	100.08	100.06	100.18
ITRON	C1S	849419	1/5/2009	100.09	99.87	100.13
ITRON	C1S	849420	1/5/2009	100.07	100.05	100.04
ITRON	C1S	849421	1/5/2009	100.10	100.05	100.21
ITRON	C1S	849422	1/5/2009	100.10	100.03	100.03
ITRON	C1S	849423	1/5/2009	100.06	99.89	100.00
ITRON	C1S	849424	1/5/2009	100.08	99.90	99.92
ITRON	C1S	849425	1/5/2009	100.06	100.02	100.21
ITRON	C1S	849426	1/5/2009	100.06	100.00	100.03
ITRON	C1S	849427	1/5/2009	100.08	100.08	100.14
ITRON	C1S	849428	1/5/2009	100.08	100.00	99.95
ITRON	C1S	849429	1/5/2009	100.08	100.09	100.16
ITRON	C1S	849430	1/5/2009	100.08	99.98	100.07
ITRON	C1S	849431	1/5/2009	100.05	100.02	100.18
ITRON	C1S	849432	1/5/2009	100.06	100.01	100.23
ITRON	C1S	849433	1/5/2009	100.08	99.91	100.20
ITRON	C1S	849434	1/5/2009	100.06	100.00	100.03
ITRON	C1S	849435	1/5/2009	100.09	99.92	100.12
ITRON	C1S	849436	1/5/2009	100.07	100.11	100.16
ITRON	C1S	849437	1/5/2009	100.09	100.08	100.19
ITRON	C1S	849438	1/5/2009	100.08	99.97	100.02
ITRON	C1S	849439	1/5/2009	100.07	99.93	100.10
ITRON	C1S	849440	1/5/2009	100.08	99.98	100.16
ITRON	C1S	849441	1/5/2009	100.10	99.93	99.90
ITRON	C1S	849442	1/5/2009	100.10	99.94	100.02
ITRON	C1S	849443	1/5/2009	100.10	99.90	100.18
ITRON	C1S	849444	1/5/2009	100.09	100.03	100.17
ITRON	C1S	849445	1/5/2009	100.07	99.96	100.20
ITRON	C1S	849446	1/5/2009	100.06	100.01	100.11
ITRON	C1S	849447	1/5/2009	100.08	99.92	100.09
ITRON	C1S	849448	1/5/2009	100.07	100.09	100.13
ITRON	C1S	849449	1/5/2009	100.06	100.00	100.03
ITRON	C1S	849450	1/5/2009	100.06	100.01	99.86
ITRON	C1S	849451	1/5/2009	100.08	99.97	100.08
ITRON	C1S	849452	1/5/2009	100.08	100.08	100.20
ITRON	C1S	849453	1/5/2009	100.09	99.88	100.21
ITRON	C1S	849454	1/5/2009	100.10	100.05	100.02
ITRON	C1S	849455	1/5/2009	100.10	99.97	100.01
ITRON	C1S	849456	1/5/2009	100.10	100.02	100.16
ITRON	C1S	849457	1/5/2009	100.06	100.08	100.20
ITRON	C1S	849458	1/5/2009	100.07	100.02	100.13
ITRON	C1S	849699	2/23/2009	100.07	99.95	100.16
ITRON	C1S	849700	2/23/2009	100.08	100.01	100.08
ITRON	C1S	849701	2/23/2009	100.06	99.89	100.05
ITRON	C1S	849702	2/23/2009	100.08	100.00	99.93
ITRON	C1S	849703	2/23/2009	100.08	100.01	100.14

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849704	2/23/2009	100.05	99.95	99.98
ITRON	C1S	849705	2/23/2009	100.07	100.06	100.08
ITRON	C1S	849706	2/23/2009	100.05	100.02	100.08
ITRON	C1S	849707	2/23/2009	100.09	100.02	100.13
ITRON	C1S	849708	2/23/2009	100.05	99.99	100.12
ITRON	C1S	849709	2/23/2009	100.06	99.94	99.97
ITRON	C1S	849710	2/23/2009	100.09	100.02	100.19
ITRON	C1S	849711	2/23/2009	100.08	100.05	100.13
ITRON	C1S	849712	2/23/2009	100.07	99.98	100.14
ITRON	C1S	849713	2/23/2009	100.10	100.03	100.14
ITRON	C1S	849714	2/23/2009	100.09	99.99	100.16
ITRON	C1S	849715	2/23/2009	100.07	99.93	100.09
ITRON	C1S	849716	2/23/2009	100.08	99.95	100.08
ITRON	C1S	849717	2/23/2009	100.09	100.11	100.14
ITRON	C1S	849718	2/23/2009	100.08	99.96	100.05
ITRON	C1S	849719	2/23/2009	100.05	99.86	99.94
ITRON	C1S	849720	2/23/2009	100.09	99.98	99.98
ITRON	C1S	849721	2/23/2009	100.06	99.96	100.15
ITRON	C1S	849722	2/23/2009	100.08	99.91	100.03
ITRON	C1S	849723	2/23/2009	100.08	100.00	100.06
ITRON	C1S	849724	2/23/2009	100.07	100.03	100.20
ITRON	C1S	849725	2/23/2009	100.05	100.09	100.06
ITRON	C1S	849726	2/23/2009	100.06	100.06	100.13
ITRON	C1S	849727	2/23/2009	100.09	100.09	100.17
ITRON	C1S	849728	2/23/2009	100.05	99.94	100.03
ITRON	C1S	849729	2/23/2009	100.08	100.04	100.17
ITRON	C1S	849730	2/23/2009	100.06	99.86	100.07
ITRON	C1S	849731	2/23/2009	100.08	100.05	100.16
ITRON	C1S	849732	2/23/2009	100.08	99.92	100.17
ITRON	C1S	849733	2/23/2009	100.07	99.98	99.98
ITRON	C1S	849734	2/23/2009	100.08	99.94	100.00
ITRON	C1S	849735	2/23/2009	100.06	99.98	100.03
ITRON	C1S	849736	2/23/2009	100.05	99.92	99.97
ITRON	C1S	849737	2/23/2009	100.06	99.97	99.92
ITRON	C1S	849738	2/23/2009	100.08	100.02	99.81
ITRON	C1S	849739	2/23/2009	100.05	99.90	100.09
ITRON	C1S	849740	2/23/2009	100.09	99.91	100.06
ITRON	C1S	849741	2/23/2009	100.08	99.87	100.06
ITRON	C1S	849742	2/23/2009	100.09	99.98	100.08
ITRON	C1S	849743	2/23/2009	100.08	100.03	100.07
ITRON	C1S	849744	2/23/2009	100.05	99.93	100.11
ITRON	C1S	849745	2/23/2009	100.07	99.89	100.06
ITRON	C1S	849746	2/23/2009	100.05	99.86	100.10
ITRON	C1S	849747	2/23/2009	100.09	100.03	100.12
ITRON	C1S	849748	2/23/2009	100.08	99.98	100.08
ITRON	C1S	849749	2/23/2009	100.09	99.92	99.98
ITRON	C1S	849750	2/23/2009	100.05	100.01	100.02

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849751	2/23/2009	100.06	100.00	100.14
ITRON	C1S	849752	2/23/2009	100.09	100.00	100.09
ITRON	C1S	849753	2/23/2009	100.05	99.89	99.98
ITRON	C1S	849754	2/23/2009	100.09	99.98	100.05
ITRON	C1S	849755	2/23/2009	100.10	99.95	100.25
ITRON	C1S	849756	2/23/2009	100.09	99.91	100.07
ITRON	C1S	849757	2/23/2009	100.09	99.97	100.05
ITRON	C1S	849758	2/23/2009	100.07	99.98	100.07
ITRON	C1S	849759	2/23/2009	100.05	99.97	100.09
ITRON	C1S	849760	2/23/2009	100.10	100.00	100.01
ITRON	C1S	849761	2/23/2009	100.09	99.98	100.12
ITRON	C1S	849762	2/23/2009	100.06	99.88	100.19
ITRON	C1S	849763	2/23/2009	100.08	100.01	99.95
ITRON	C1S	849764	2/23/2009	100.10	100.00	99.92
ITRON	C1S	849765	2/23/2009	100.08	99.94	100.00
ITRON	C1S	849766	2/23/2009	100.07	99.97	100.05
ITRON	C1S	849767	2/23/2009	100.09	100.03	100.13
ITRON	C1S	849768	2/23/2009	100.10	100.02	100.20
ITRON	C1S	849769	2/23/2009	100.06	99.96	100.10
ITRON	C1S	849770	2/23/2009	100.08	100.04	100.09
ITRON	C1S	849771	2/23/2009	100.07	100.00	100.17
ITRON	C1S	849772	2/23/2009	100.05	99.94	100.05
ITRON	C1S	849773	2/23/2009	100.10	99.95	100.10
ITRON	C1S	849774	2/23/2009	100.08	100.04	100.20
ITRON	C1S	849775	2/23/2009	100.05	99.96	100.25
ITRON	C1S	849776	2/23/2009	100.07	100.07	100.13
ITRON	C1S	849777	2/23/2009	100.08	100.00	100.05
ITRON	C1S	849778	2/23/2009	100.07	100.02	100.03
ITRON	C1S	849779	2/23/2009	100.06	99.92	99.99
ITRON	C1S	849780	2/23/2009	100.10	99.93	100.17
ITRON	C1S	849781	2/23/2009	100.10	100.03	99.95
ITRON	C1S	849782	2/23/2009	100.08	100.02	100.20
ITRON	C1S	849783	2/23/2009	100.10	99.99	100.06
ITRON	C1S	849784	2/23/2009	100.06	100.00	100.02
ITRON	C1S	849785	2/23/2009	100.08	100.11	100.14
ITRON	C1S	849786	2/23/2009	100.09	99.88	100.07
ITRON	C1S	849787	2/23/2009	100.08	100.13	100.18
ITRON	C1S	849788	2/23/2009	100.06	99.88	99.95
ITRON	C1S	849789	2/23/2009	100.05	99.96	100.08
ITRON	C1S	849790	2/23/2009	100.09	100.11	100.19
ITRON	C1S	849791	2/23/2009	100.08	99.93	100.16
ITRON	C1S	849792	2/23/2009	100.08	100.02	100.17
ITRON	C1S	849793	2/23/2009	100.09	100.06	99.89
ITRON	C1S	849794	2/23/2009	100.08	99.88	100.06
ITRON	C1S	849795	2/23/2009	100.05	99.97	100.03
ITRON	C1S	849796	2/23/2009	100.07	99.93	100.07
ITRON	C1S	849797	2/23/2009	100.08	100.03	100.19

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849798	2/23/2009	100.08	100.06	100.14
ITRON	C1S	849799	2/23/2009	100.07	100.01	100.23
ITRON	C1S	849800	2/23/2009	100.06	99.93	100.00
ITRON	C1S	849801	2/23/2009	100.06	100.08	100.14
ITRON	C1S	849802	2/23/2009	100.09	100.06	100.08
ITRON	C1S	849803	2/23/2009	100.07	100.00	100.04
ITRON	C1S	849804	2/23/2009	100.08	99.95	100.10
ITRON	C1S	849805	2/23/2009	100.07	99.94	100.07
ITRON	C1S	849806	2/23/2009	100.07	99.93	100.10
ITRON	C1S	849807	2/23/2009	100.08	100.07	100.17
ITRON	C1S	849808	2/23/2009	100.08	100.01	100.11
ITRON	C1S	849809	2/23/2009	100.09	100.07	100.11
ITRON	C1S	849810	2/23/2009	100.09	100.06	100.13
ITRON	C1S	849811	2/23/2009	100.08	100.13	100.17
ITRON	C1S	849812	2/23/2009	100.07	100.02	99.90
ITRON	C1S	849813	2/23/2009	100.07	99.99	100.08
ITRON	C1S	849814	2/23/2009	100.08	100.04	100.19
ITRON	C1S	849815	2/23/2009	100.09	99.96	99.99
ITRON	C1S	849816	2/23/2009	100.06	99.99	100.01
ITRON	C1S	849817	2/23/2009	100.10	100.09	100.20
ITRON	C1S	849818	2/23/2009	100.06	100.04	100.12
ITRON	C1S	849819	2/23/2009	100.06	100.14	100.09
ITRON	C1S	849820	2/23/2009	100.08	99.98	100.18
ITRON	C1S	849821	2/23/2009	100.05	99.90	100.10
ITRON	C1S	849822	2/23/2009	100.07	100.02	100.06
ITRON	C1S	849823	2/23/2009	100.08	100.04	100.16
ITRON	C1S	849824	2/23/2009	100.08	99.92	100.09
ITRON	C1S	849825	2/23/2009	100.09	99.93	100.03
ITRON	C1S	849826	2/23/2009	100.09	100.07	100.18
ITRON	C1S	849827	2/23/2009	100.06	100.02	99.94
ITRON	C1S	849828	2/23/2009	100.06	100.02	100.18
ITRON	C1S	849829	2/23/2009	100.07	99.94	99.87
ITRON	C1S	849830	2/23/2009	100.09	100.04	99.96
ITRON	C1S	849831	2/23/2009	100.06	99.92	100.21
ITRON	C1S	849832	2/23/2009	100.07	100.01	100.15
ITRON	C1S	849833	2/23/2009	100.05	100.01	100.15
ITRON	C1S	849834	2/23/2009	100.07	100.08	100.15
ITRON	C1S	849835	2/23/2009	100.06	99.92	99.99
ITRON	C1S	849836	2/23/2009	100.07	99.89	99.96
ITRON	C1S	849837	2/23/2009	100.06	99.95	100.05
ITRON	C1S	849838	2/23/2009	100.06	99.85	100.01
ITRON	C1S	849839	2/23/2009	100.05	99.99	100.06
ITRON	C1S	849840	2/23/2009	100.10	99.91	100.04
ITRON	C1S	849841	2/23/2009	100.10	99.99	99.99
ITRON	C1S	849842	2/23/2009	100.06	99.90	99.99
ITRON	C1S	849843	2/23/2009	100.05	100.01	99.99
ITRON	C1S	849844	2/23/2009	100.05	100.02	100.18

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849845	2/23/2009	100.08	100.06	100.20
ITRON	C1S	849846	2/23/2009	100.09	99.90	100.16
ITRON	C1S	849847	2/23/2009	100.06	99.95	100.05
ITRON	C1S	849848	2/23/2009	100.07	99.97	100.14
ITRON	C1S	849849	2/23/2009	100.06	99.92	99.96
ITRON	C1S	849850	2/23/2009	100.07	99.97	100.10
ITRON	C1S	849851	2/23/2009	100.05	99.90	100.08
ITRON	C1S	849852	2/23/2009	100.06	100.01	100.16
ITRON	C1S	849853	2/23/2009	100.09	99.93	99.89
ITRON	C1S	849854	2/23/2009	100.06	99.92	100.00
ITRON	C1S	849855	2/23/2009	100.06	99.81	100.05
ITRON	C1S	849856	2/23/2009	100.05	100.02	100.00
ITRON	C1S	849857	2/23/2009	100.06	100.01	100.14
ITRON	C1S	849858	2/23/2009	100.09	99.88	100.09
ITRON	C1S	849859	2/23/2009	100.07	99.91	100.06
ITRON	C1S	849860	2/23/2009	100.07	99.84	100.00
ITRON	C1S	849861	2/23/2009	100.06	99.95	100.09
ITRON	C1S	849862	2/23/2009	100.05	99.97	100.14
ITRON	C1S	849863	2/23/2009	100.07	100.07	100.15
ITRON	C1S	849864	2/23/2009	100.09	99.94	100.00
ITRON	C1S	849865	2/23/2009	100.07	100.01	100.11
ITRON	C1S	849866	2/23/2009	100.10	100.02	100.11
ITRON	C1S	849867	2/23/2009	100.08	100.04	100.12
ITRON	C1S	849868	2/23/2009	100.09	99.89	100.07
ITRON	C1S	849869	2/23/2009	100.06	100.05	100.11
ITRON	C1S	849870	2/23/2009	100.07	99.98	100.12
ITRON	C1S	849871	2/23/2009	100.07	99.91	100.13
ITRON	C1S	849872	2/23/2009	100.09	100.04	100.13
ITRON	C1S	849873	2/23/2009	100.07	99.87	100.11
ITRON	C1S	849874	2/23/2009	100.09	99.98	99.99
ITRON	C1S	849875	2/23/2009	100.09	99.93	100.09
ITRON	C1S	849876	2/23/2009	100.07	99.98	99.95
ITRON	C1S	849877	2/23/2009	100.08	99.94	99.98
ITRON	C1S	849878	2/23/2009	100.05	99.86	100.10
ITRON	C1S	849879	2/23/2009	100.09	99.92	100.05
ITRON	C1S	849880	2/23/2009	100.09	100.00	100.14
ITRON	C1S	849881	2/23/2009	100.05	100.06	100.03
ITRON	C1S	849882	2/23/2009	100.06	100.10	100.15
ITRON	C1S	849883	2/23/2009	100.05	100.02	100.12
ITRON	C1S	849884	2/23/2009	100.09	100.00	99.97
ITRON	C1S	849885	2/23/2009	100.08	100.04	100.08
ITRON	C1S	849886	2/23/2009	100.07	100.00	100.18
ITRON	C1S	849887	2/23/2009	100.08	100.05	100.17
ITRON	C1S	849888	2/23/2009	100.09	100.07	100.16
ITRON	C1S	849889	2/23/2009	100.06	99.96	100.02
ITRON	C1S	849890	2/23/2009	100.07	99.98	100.01
ITRON	C1S	849891	2/23/2009	100.05	99.98	100.07

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849892	2/23/2009	100.09	100.10	100.14
ITRON	C1S	849893	2/23/2009	100.09	99.95	100.01
ITRON	C1S	849894	2/23/2009	100.09	100.06	100.13
ITRON	C1S	849895	2/23/2009	100.07	100.01	100.14
ITRON	C1S	849896	2/23/2009	100.05	100.03	100.19
ITRON	C1S	849897	2/23/2009	100.09	99.95	100.09
ITRON	C1S	849898	2/23/2009	100.07	99.93	100.20
ITRON	C1S	849899	2/23/2009	100.09	99.96	100.15
ITRON	C1S	849900	2/23/2009	100.06	99.95	100.13
ITRON	C1S	849901	2/23/2009	100.06	100.04	100.14
ITRON	C1S	849902	2/23/2009	100.09	99.96	99.85
ITRON	C1S	849903	2/23/2009	100.05	99.90	99.97
ITRON	C1S	849904	2/23/2009	100.07	99.94	100.07
ITRON	C1S	849905	2/23/2009	100.09	99.99	99.98
ITRON	C1S	849906	2/23/2009	100.07	99.87	100.17
ITRON	C1S	849907	2/23/2009	100.11	100.01	100.09
ITRON	C1S	849908	2/23/2009	100.10	99.97	100.05
ITRON	C1S	849909	2/23/2009	100.08	100.10	100.16
ITRON	C1S	849910	2/23/2009	100.09	99.98	100.10
ITRON	C1S	849911	2/23/2009	100.08	100.03	100.22
ITRON	C1S	849912	2/23/2009	100.06	99.96	100.09
ITRON	C1S	849913	2/23/2009	100.06	99.89	100.07
ITRON	C1S	849914	2/23/2009	100.06	100.02	100.16
ITRON	C1S	849915	2/23/2009	100.05	99.91	100.19
ITRON	C1S	849916	2/23/2009	100.06	99.99	99.94
ITRON	C1S	849917	2/23/2009	100.07	99.92	100.12
ITRON	C1S	849918	2/23/2009	100.09	99.89	99.99
ITRON	C1S	849919	2/23/2009	100.07	99.98	99.92
ITRON	C1S	849920	2/23/2009	100.06	99.84	100.20
ITRON	C1S	849921	2/23/2009	100.08	99.97	100.10
ITRON	C1S	849922	2/23/2009	100.09	100.02	100.10
ITRON	C1S	849923	2/23/2009	100.07	99.92	100.02
ITRON	C1S	849924	2/23/2009	100.07	99.96	100.11
ITRON	C1S	849925	2/23/2009	100.06	99.88	100.01
ITRON	C1S	849926	2/23/2009	100.06	100.03	100.10
ITRON	C1S	849927	2/23/2009	100.07	99.96	100.17
ITRON	C1S	849928	2/23/2009	100.05	99.90	100.01
ITRON	C1S	849929	2/23/2009	100.10	99.98	100.04
ITRON	C1S	849930	2/23/2009	100.07	100.10	100.22
ITRON	C1S	849931	2/23/2009	100.08	99.92	100.08
ITRON	C1S	849932	2/23/2009	100.06	99.94	100.02
ITRON	C1S	849933	2/23/2009	100.07	99.92	100.11
ITRON	C1S	849934	2/23/2009	99.99	99.99	100.09
ITRON	C1S	849935	2/23/2009	100.07	100.04	100.04
ITRON	C1S	849936	2/23/2009	100.08	99.86	100.02
ITRON	C1S	849937	2/23/2009	100.06	99.93	100.06
ITRON	C1S	849938	2/23/2009	100.07	99.93	100.12

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	849939	2/23/2009	100.08	100.12	100.20
ITRON	C1S	849940	2/23/2009	100.09	99.92	100.03
ITRON	C1S	849941	2/23/2009	100.07	99.95	100.01
ITRON	C1S	849942	2/23/2009	100.06	99.90	100.14
ITRON	C1S	849943	2/23/2009	100.09	100.08	100.04
ITRON	C1S	849944	2/23/2009	100.06	99.89	100.03
ITRON	C1S	849945	2/23/2009	100.08	99.98	100.11
ITRON	C1S	849946	2/23/2009	100.06	99.84	100.09
ITRON	C1S	849947	2/23/2009	100.08	100.11	100.18
ITRON	C1S	849948	2/23/2009	100.08	100.01	99.97
ITRON	C1S	849949	2/23/2009	100.07	99.96	100.06
ITRON	C1S	849950	2/23/2009	100.08	100.08	100.14
ITRON	C1S	849951	2/23/2009	100.09	99.99	100.04
ITRON	C1S	849952	2/23/2009	100.09	100.00	100.14
ITRON	C1S	849953	2/23/2009	100.08	99.96	100.04
ITRON	C1S	849954	2/23/2009	100.09	100.08	100.18
ITRON	C1S	849955	2/23/2009	100.08	100.01	100.01
ITRON	C1S	849956	2/23/2009	100.08	100.01	99.96
ITRON	C1S	849957	2/23/2009	100.09	100.01	100.18
ITRON	C1S	849958	2/23/2009	100.06	99.96	100.03
ITRON	C1S	849959	2/23/2009	100.08	100.01	99.83
ITRON	C1S	849960	2/23/2009	100.06	99.87	100.11
ITRON	C1S	849961	2/23/2009	100.08	99.92	100.07
ITRON	C1S	849962	2/23/2009	100.09	99.95	100.00
ITRON	C1S	849963	2/23/2009	100.10	100.08	100.09
ITRON	C1S	849964	2/23/2009	100.07	100.06	100.16
ITRON	C1S	849965	2/23/2009	100.07	100.11	100.12
ITRON	C1S	849966	2/23/2009	100.05	100.03	100.08
ITRON	C1S	849967	2/23/2009	100.05	99.93	100.13
ITRON	C1S	849968	2/23/2009	100.08	100.10	100.10
ITRON	C1S	849969	2/23/2009	100.09	99.99	100.01
ITRON	C1S	849970	2/23/2009	100.08	99.99	100.19
ITRON	C1S	849971	2/23/2009	100.05	100.02	100.15
ITRON	C1S	849972	2/23/2009	100.06	100.02	100.16
ITRON	C1S	849973	2/23/2009	100.05	100.04	100.15
ITRON	C1S	849974	2/23/2009	100.07	100.03	100.19
ITRON	C1S	849975	2/23/2009	100.09	100.08	100.19
ITRON	C1S	849976	2/23/2009	100.06	99.90	100.06
ITRON	C1S	849977	2/23/2009	100.07	99.87	99.97
ITRON	C1S	849978	2/23/2009	100.09	100.04	100.18
ITRON	C1S	849979	2/23/2009	100.09	99.94	100.19
ITRON	C1S	849980	2/23/2009	100.10	100.05	100.16
ITRON	C1S	849981	2/23/2009	100.06	99.97	100.12
ITRON	C1S	849982	2/23/2009	100.11	99.96	99.90
ITRON	C1S	849983	2/23/2009	100.08	100.09	100.19
ITRON	C1S	849984	2/23/2009	100.07	100.00	100.10
ITRON	C1S	849985	2/23/2009	100.08	99.89	100.10

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	849986	2/23/2009	100.06	99.87	100.14
ITRON	C1S	849987	2/23/2009	100.08	99.90	100.01
ITRON	C1S	849988	2/23/2009	100.09	99.96	100.22
ITRON	C1S	849989	2/23/2009	100.08	99.94	100.08
ITRON	C1S	849990	2/23/2009	100.06	99.92	100.07
ITRON	C1S	849991	2/23/2009	100.10	99.95	100.04
ITRON	C1S	849992	2/23/2009	100.08	99.96	100.08
ITRON	C1S	849993	2/23/2009	100.08	100.08	100.17
ITRON	C1S	849994	2/23/2009	100.06	99.85	100.05
ITRON	C1S	849995	2/23/2009	100.05	100.08	100.19
ITRON	C1S	849996	2/23/2009	100.06	100.04	100.14
ITRON	C1S	849997	2/23/2009	100.07	100.04	100.09
ITRON	C1S	849998	2/23/2009	100.07	99.93	100.04
ITRON	C1S	849999	2/23/2009	100.08	99.93	99.88
ITRON	C1S	850000	2/23/2009	100.09	100.12	100.17
ITRON	C1S	850001	2/23/2009	100.08	100.10	99.92
ITRON	C1S	850002	2/23/2009	100.07	99.99	100.10
ITRON	C1S	850003	2/23/2009	100.11	99.94	100.19
ITRON	C1S	850004	2/23/2009	100.08	100.06	100.14
ITRON	C1S	850005	2/23/2009	100.06	100.06	100.14
ITRON	C1S	850006	2/23/2009	100.08	100.05	100.16
ITRON	C1S	850007	2/23/2009	100.10	100.09	100.23
ITRON	C1S	850008	2/23/2009	100.08	100.07	100.17
ITRON	C1S	850009	2/23/2009	100.11	99.94	100.04
ITRON	C1S	850010	2/23/2009	100.06	99.99	99.96
ITRON	C1S	850011	2/23/2009	100.05	99.97	99.86
ITRON	C1S	850012	2/23/2009	100.05	99.93	99.80
ITRON	C1S	850013	2/23/2009	100.08	99.91	100.08
ITRON	C1S	850014	2/23/2009	100.08	99.85	99.97
ITRON	C1S	850015	2/23/2009	100.07	99.99	99.93
ITRON	C1S	850016	2/23/2009	100.06	99.94	100.05
ITRON	C1S	850017	2/23/2009	100.08	99.94	99.81
ITRON	C1S	850018	2/23/2009	100.09	99.98	100.02
ITRON	C1S	850019	2/23/2009	100.06	99.93	100.15
ITRON	C1S	850020	2/23/2009	100.07	99.93	100.15
ITRON	C1S	850021	2/23/2009	100.06	100.06	100.07
ITRON	C1S	850022	2/23/2009	100.07	100.05	100.17
ITRON	C1S	850023	2/23/2009	100.08	99.98	100.17
ITRON	C1S	850024	2/23/2009	100.09	100.10	100.16
ITRON	C1S	850025	2/23/2009	100.08	100.07	100.17
ITRON	C1S	850026	2/23/2009	100.08	100.07	100.18
ITRON	C1S	850027	2/23/2009	100.09	100.07	100.15
ITRON	C1S	850028	2/23/2009	100.07	99.97	100.01
ITRON	C1S	850029	2/23/2009	100.05	99.89	100.03
ITRON	C1S	850030	2/23/2009	100.07	99.95	100.03
ITRON	C1S	850031	2/23/2009	100.08	99.98	100.04
ITRON	C1S	850032	2/23/2009	100.06	99.90	100.06

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850033	2/23/2009	100.09	100.00	99.89
ITRON	C1S	850034	2/23/2009	100.08	99.96	99.89
ITRON	C1S	850035	2/23/2009	100.07	99.95	99.92
ITRON	C1S	850036	2/23/2009	100.09	99.98	100.06
ITRON	C1S	850037	2/23/2009	100.08	99.94	100.00
ITRON	C1S	850038	2/23/2009	100.06	100.01	100.16
ITRON	C1S	850039	2/23/2009	100.08	100.07	100.13
ITRON	C1S	850040	2/23/2009	100.07	99.86	100.17
ITRON	C1S	850041	2/23/2009	100.10	100.05	100.07
ITRON	C1S	850042	2/23/2009	100.06	99.89	100.08
ITRON	C1S	850043	2/23/2009	100.07	99.94	100.05
ITRON	C1S	850044	2/23/2009	100.09	100.03	100.01
ITRON	C1S	850045	2/23/2009	100.09	99.91	100.17
ITRON	C1S	850046	2/23/2009	100.09	100.12	100.18
ITRON	C1S	850047	2/23/2009	100.10	100.12	100.14
ITRON	C1S	850048	2/23/2009	100.06	99.94	100.03
ITRON	C1S	850049	2/23/2009	100.07	100.04	100.09
ITRON	C1S	850050	2/23/2009	100.06	99.99	99.82
ITRON	C1S	850051	2/23/2009	100.07	99.97	99.82
ITRON	C1S	850052	2/23/2009	100.08	99.95	99.84
ITRON	C1S	850053	2/23/2009	100.08	100.06	99.85
ITRON	C1S	850054	2/23/2009	100.06	99.95	100.11
ITRON	C1S	850055	2/23/2009	100.06	99.96	100.07
ITRON	C1S	850056	2/23/2009	100.09	100.00	100.04
ITRON	C1S	850057	2/23/2009	100.08	99.88	100.06
ITRON	C1S	850058	2/23/2009	100.07	99.92	100.06
ITRON	C1S	850059	2/23/2009	100.06	99.93	100.01
ITRON	C1S	850060	2/23/2009	100.06	99.89	100.06
ITRON	C1S	850061	2/23/2009	100.05	100.01	100.13
ITRON	C1S	850062	2/23/2009	100.10	100.01	100.18
ITRON	C1S	850063	2/23/2009	100.08	100.04	100.07
ITRON	C1S	850064	2/23/2009	100.06	99.95	99.93
ITRON	C1S	850065	2/23/2009	100.06	100.01	99.80
ITRON	C1S	850066	2/23/2009	100.07	99.94	100.01
ITRON	C1S	850067	2/23/2009	100.07	99.86	100.10
ITRON	C1S	850068	2/23/2009	100.07	99.94	100.11
ITRON	C1S	850069	2/23/2009	100.07	99.94	99.96
ITRON	C1S	850070	2/23/2009	100.07	99.92	100.00
ITRON	C1S	850071	2/23/2009	100.08	100.06	100.12
ITRON	C1S	850072	2/23/2009	100.06	99.94	100.07
ITRON	C1S	850073	2/23/2009	100.07	99.94	100.05
ITRON	C1S	850074	2/23/2009	100.06	99.95	99.99
ITRON	C1S	850075	2/23/2009	100.06	99.90	100.07
ITRON	C1S	850076	2/23/2009	100.05	99.93	100.09
ITRON	C1S	850077	2/23/2009	100.06	99.85	100.14
ITRON	C1S	850078	2/23/2009	100.06	100.01	100.10
ITRON	C1S	850079	2/23/2009	100.08	99.87	100.21

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850080	2/23/2009	100.08	100.06	100.22
ITRON	C1S	850081	2/23/2009	100.06	100.00	100.10
ITRON	C1S	850082	2/23/2009	100.10	100.01	100.06
ITRON	C1S	850083	2/23/2009	100.06	100.05	100.16
ITRON	C1S	850084	2/23/2009	100.10	100.14	100.13
ITRON	C1S	850085	2/23/2009	100.08	99.94	100.14
ITRON	C1S	850086	2/23/2009	100.08	100.02	100.19
ITRON	C1S	850087	2/23/2009	100.07	100.04	99.98
ITRON	C1S	850088	2/23/2009	100.09	100.04	100.03
ITRON	C1S	850089	2/23/2009	100.05	99.91	100.21
ITRON	C1S	850090	2/23/2009	100.08	99.97	100.03
ITRON	C1S	850091	2/23/2009	100.06	99.97	100.23
ITRON	C1S	850092	2/23/2009	100.06	99.98	99.81
ITRON	C1S	850093	2/23/2009	100.06	100.00	100.14
ITRON	C1S	850094	2/23/2009	100.07	99.96	100.09
ITRON	C1S	850095	2/23/2009	100.06	99.88	100.13
ITRON	C1S	850096	2/23/2009	100.08	100.05	100.15
ITRON	C1S	850097	2/23/2009	100.09	100.12	100.21
ITRON	C1S	850098	2/23/2009	100.06	100.05	100.17
ITRON	C1S	850099	2/23/2009	100.06	99.87	100.07
ITRON	C1S	850100	2/23/2009	100.08	100.01	100.16
ITRON	C1S	850101	2/23/2009	100.06	100.01	100.18
ITRON	C1S	850102	2/23/2009	100.08	100.05	100.19
ITRON	C1S	850103	2/23/2009	100.05	99.89	99.98
ITRON	C1S	850104	2/23/2009	100.10	100.07	100.18
ITRON	C1S	850105	2/23/2009	100.06	99.92	100.10
ITRON	C1S	850106	2/23/2009	100.07	100.00	99.98
ITRON	C1S	850107	2/23/2009	100.09	99.98	100.09
ITRON	C1S	850108	2/23/2009	100.06	100.04	100.14
ITRON	C1S	850109	2/23/2009	100.06	99.90	100.23
ITRON	C1S	850110	2/23/2009	100.09	99.95	100.25
ITRON	C1S	850111	2/23/2009	100.05	99.97	99.83
ITRON	C1S	850112	2/23/2009	100.06	99.95	99.89
ITRON	C1S	850113	2/23/2009	100.08	99.97	99.89
ITRON	C1S	850114	2/23/2009	100.07	100.07	100.16
ITRON	C1S	850115	2/23/2009	100.07	100.09	100.09
ITRON	C1S	850116	2/23/2009	100.07	99.96	100.04
ITRON	C1S	850117	2/23/2009	100.06	100.05	100.12
ITRON	C1S	850118	2/23/2009	100.08	99.90	100.15
ITRON	C1S	850119	2/23/2009	100.07	100.02	100.12
ITRON	C1S	850120	2/23/2009	100.07	100.07	100.17
ITRON	C1S	850121	2/23/2009	100.06	99.85	100.06
ITRON	C1S	850122	2/23/2009	100.06	99.96	100.09
ITRON	C1S	850123	2/23/2009	100.10	99.88	100.15
ITRON	C1S	850124	2/23/2009	100.07	100.12	100.14
ITRON	C1S	850125	2/23/2009	100.07	100.08	100.19
ITRON	C1S	850126	2/23/2009	100.07	99.94	100.05

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850127	2/23/2009	100.10	99.94	100.13
ITRON	C1S	850128	2/23/2009	100.07	99.96	99.98
ITRON	C1S	850129	2/23/2009	100.08	100.03	99.96
ITRON	C1S	850130	2/23/2009	100.06	99.96	100.15
ITRON	C1S	850131	2/23/2009	100.08	100.04	100.15
ITRON	C1S	850132	2/23/2009	100.09	100.08	100.19
ITRON	C1S	850133	2/23/2009	100.09	99.99	100.15
ITRON	C1S	850134	2/23/2009	100.08	99.98	100.17
ITRON	C1S	850135	2/23/2009	100.09	99.94	100.21
ITRON	C1S	850136	2/23/2009	100.07	99.85	100.11
ITRON	C1S	850137	2/23/2009	100.07	100.08	100.15
ITRON	C1S	850138	2/23/2009	100.08	99.97	100.04
ITRON	C1S	850139	2/23/2009	100.06	100.08	100.21
ITRON	C1S	850140	2/23/2009	100.09	99.97	100.10
ITRON	C1S	850141	2/23/2009	100.09	99.93	100.08
ITRON	C1S	850142	2/23/2009	100.10	99.92	100.07
ITRON	C1S	850143	2/23/2009	100.05	99.94	99.98
ITRON	C1S	850144	2/23/2009	100.10	100.07	100.22
ITRON	C1S	850145	2/23/2009	100.09	99.91	100.15
ITRON	C1S	850146	2/23/2009	100.09	99.98	100.14
ITRON	C1S	850147	2/23/2009	100.06	100.02	100.16
ITRON	C1S	850148	2/23/2009	100.09	100.07	100.20
ITRON	C1S	850149	2/23/2009	100.09	100.13	100.16
ITRON	C1S	850150	2/23/2009	100.06	100.08	100.18
ITRON	C1S	850151	2/23/2009	100.07	99.96	99.92
ITRON	C1S	850152	2/23/2009	100.06	99.95	100.12
ITRON	C1S	850153	2/23/2009	100.09	100.06	100.27
ITRON	C1S	850154	2/23/2009	100.06	99.96	100.04
ITRON	C1S	850155	2/23/2009	100.05	99.95	100.10
ITRON	C1S	850156	2/23/2009	100.05	99.94	100.03
ITRON	C1S	850157	2/23/2009	100.09	99.90	100.11
ITRON	C1S	850158	2/23/2009	100.10	100.04	100.19
ITRON	C1S	850159	2/23/2009	100.10	100.11	100.26
ITRON	C1S	850160	2/23/2009	100.05	100.07	100.06
ITRON	C1S	850161	2/23/2009	100.08	99.92	100.24
ITRON	C1S	850162	2/23/2009	100.06	99.92	100.06
ITRON	C1S	850163	2/23/2009	100.08	99.91	100.05
ITRON	C1S	850164	2/23/2009	100.08	100.01	100.16
ITRON	C1S	850165	2/23/2009	100.06	99.90	100.08
ITRON	C1S	850166	2/23/2009	100.09	100.04	100.02
ITRON	C1S	850167	2/23/2009	100.07	100.05	100.14
ITRON	C1S	850168	2/23/2009	100.09	100.12	100.18
ITRON	C1S	850169	2/23/2009	100.06	99.93	100.08
ITRON	C1S	850170	2/23/2009	100.08	100.10	100.19
ITRON	C1S	850171	2/23/2009	100.10	99.96	100.26
ITRON	C1S	850172	2/23/2009	100.08	100.01	100.06
ITRON	C1S	850173	2/23/2009	100.10	100.10	100.17

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850174	2/23/2009	100.07	99.95	99.84
ITRON	C1S	850175	2/23/2009	100.08	99.97	99.88
ITRON	C1S	850176	2/23/2009	100.08	100.01	99.99
ITRON	C1S	850177	2/23/2009	100.05	100.01	100.15
ITRON	C1S	850178	2/23/2009	100.06	99.90	100.05
ITRON	C1S	850179	2/23/2009	100.08	99.94	100.11
ITRON	C1S	850180	2/23/2009	100.06	99.98	100.08
ITRON	C1S	850181	2/23/2009	100.06	99.95	100.27
ITRON	C1S	850182	2/23/2009	100.08	100.07	100.13
ITRON	C1S	850183	2/23/2009	100.08	99.93	100.05
ITRON	C1S	850184	2/23/2009	100.08	99.99	100.03
ITRON	C1S	850185	2/23/2009	100.05	99.91	100.10
ITRON	C1S	850186	2/23/2009	100.07	100.09	100.17
ITRON	C1S	850187	2/23/2009	100.06	99.96	100.07
ITRON	C1S	850188	2/23/2009	100.07	100.05	100.15
ITRON	C1S	850189	2/23/2009	100.06	99.91	100.18
ITRON	C1S	850190	2/23/2009	100.06	100.01	99.83
ITRON	C1S	850191	2/23/2009	100.09	100.07	100.19
ITRON	C1S	850192	2/23/2009	100.07	99.99	100.01
ITRON	C1S	850193	2/23/2009	100.10	99.90	100.09
ITRON	C1S	850194	2/23/2009	100.09	99.91	100.09
ITRON	C1S	850195	2/23/2009	100.08	99.92	100.03
ITRON	C1S	850196	2/23/2009	100.09	99.92	100.10
ITRON	C1S	850197	2/23/2009	100.09	99.92	100.09
ITRON	C1S	850198	2/23/2009	100.08	99.87	100.14
ITRON	C1S	850199	2/23/2009	100.08	99.95	99.99
ITRON	C1S	850200	2/23/2009	100.08	99.97	100.14
ITRON	C1S	850201	2/23/2009	100.08	99.87	100.10
ITRON	C1S	850202	2/23/2009	100.09	100.04	100.15
ITRON	C1S	850203	2/23/2009	100.05	100.08	100.15
ITRON	C1S	850204	2/23/2009	100.08	100.05	99.94
ITRON	C1S	850205	2/23/2009	100.09	100.02	100.18
ITRON	C1S	850206	2/23/2009	100.06	100.07	100.21
ITRON	C1S	850207	2/23/2009	100.09	99.99	100.17
ITRON	C1S	850208	2/23/2009	100.09	100.02	100.17
ITRON	C1S	850209	2/23/2009	100.06	99.88	100.01
ITRON	C1S	850210	2/23/2009	100.07	99.99	100.20
ITRON	C1S	850211	2/23/2009	100.06	99.92	100.03
ITRON	C1S	850212	2/23/2009	100.07	100.11	100.14
ITRON	C1S	850213	2/23/2009	100.10	99.97	100.02
ITRON	C1S	850214	2/23/2009	100.09	100.02	99.86
ITRON	C1S	850215	2/23/2009	100.07	99.97	99.86
ITRON	C1S	850216	2/23/2009	100.08	99.94	99.95
ITRON	C1S	850217	2/23/2009	100.09	100.06	100.17
ITRON	C1S	850218	2/23/2009	100.06	100.01	100.16
ITRON	C1S	850219	2/23/2009	100.08	100.07	100.17
ITRON	C1S	850220	2/23/2009	100.10	100.02	100.16

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850221	2/23/2009	100.05	99.93	100.01
ITRON	C1S	850222	2/23/2009	100.10	100.11	100.20
ITRON	C1S	850223	2/23/2009	100.07	100.05	100.18
ITRON	C1S	850224	2/23/2009	100.06	99.94	100.16
ITRON	C1S	850225	2/23/2009	100.07	99.97	100.08
ITRON	C1S	850226	2/23/2009	100.08	99.91	100.21
ITRON	C1S	850227	2/23/2009	100.08	100.03	100.14
ITRON	C1S	850228	2/23/2009	100.09	99.95	100.06
ITRON	C1S	850229	2/23/2009	100.08	99.93	100.10
ITRON	C1S	850230	2/23/2009	100.09	99.98	100.11
ITRON	C1S	850231	2/23/2009	100.08	99.95	100.12
ITRON	C1S	850232	2/23/2009	100.08	99.94	99.86
ITRON	C1S	850233	2/23/2009	100.06	100.00	99.98
ITRON	C1S	850234	2/23/2009	100.06	100.05	100.08
ITRON	C1S	850235	2/23/2009	100.07	99.89	100.05
ITRON	C1S	850236	2/23/2009	100.10	100.04	100.19
ITRON	C1S	850237	2/23/2009	100.08	100.11	100.19
ITRON	C1S	850238	2/23/2009	100.08	100.02	100.15
ITRON	C1S	850239	2/23/2009	100.08	100.10	100.14
ITRON	C1S	850240	2/23/2009	100.10	100.07	99.83
ITRON	C1S	850241	2/23/2009	100.09	100.05	100.06
ITRON	C1S	850242	2/23/2009	100.06	100.02	100.01
ITRON	C1S	850243	2/23/2009	100.08	100.06	100.20
ITRON	C1S	850244	2/23/2009	100.07	99.96	100.00
ITRON	C1S	850245	2/23/2009	100.09	99.89	100.20
ITRON	C1S	850246	2/23/2009	100.06	99.86	100.05
ITRON	C1S	850247	2/23/2009	100.07	99.91	100.05
ITRON	C1S	850248	2/23/2009	100.06	99.86	100.05
ITRON	C1S	850249	2/23/2009	100.07	99.94	100.02
ITRON	C1S	850250	2/23/2009	100.09	99.96	99.97
ITRON	C1S	850251	2/23/2009	100.11	100.07	100.17
ITRON	C1S	850252	2/23/2009	100.06	99.99	100.09
ITRON	C1S	850253	2/23/2009	100.08	100.04	100.00
ITRON	C1S	850254	2/23/2009	100.08	99.92	100.02
ITRON	C1S	850255	2/23/2009	100.07	100.06	100.16
ITRON	C1S	850256	2/23/2009	100.10	100.11	100.11
ITRON	C1S	850257	2/23/2009	100.08	100.03	100.17
ITRON	C1S	850258	2/23/2009	100.09	100.08	100.16
ITRON	C1S	850259	2/23/2009	100.06	100.02	100.19
ITRON	C1S	850260	2/23/2009	100.09	100.00	100.09
ITRON	C1S	850261	2/23/2009	100.06	99.96	100.03
ITRON	C1S	850262	2/23/2009	100.08	100.06	100.13
ITRON	C1S	850263	2/23/2009	100.05	99.96	99.95
ITRON	C1S	850264	2/23/2009	100.07	100.02	100.17
ITRON	C1S	850265	2/23/2009	100.08	99.95	99.82
ITRON	C1S	850266	2/23/2009	100.08	100.07	100.13
ITRON	C1S	850267	2/23/2009	100.06	100.05	100.14

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850268	2/23/2009	100.08	100.13	100.16
ITRON	C1S	850269	2/23/2009	100.09	99.99	100.08
ITRON	C1S	850270	2/23/2009	100.07	99.99	100.05
ITRON	C1S	850271	2/23/2009	100.05	99.87	100.23
ITRON	C1S	850272	2/23/2009	100.06	99.99	100.02
ITRON	C1S	850273	2/23/2009	100.06	99.89	100.11
ITRON	C1S	850274	2/23/2009	100.07	100.04	100.11
ITRON	C1S	850275	2/23/2009	100.09	100.06	100.14
ITRON	C1S	850276	2/23/2009	100.10	100.00	100.03
ITRON	C1S	850277	2/23/2009	100.08	99.95	100.02
ITRON	C1S	850278	2/23/2009	100.06	99.96	100.16
ITRON	C1S	850279	2/23/2009	100.06	99.99	100.05
ITRON	C1S	850280	2/23/2009	100.08	99.93	100.04
ITRON	C1S	850281	2/23/2009	100.09	99.97	99.98
ITRON	C1S	850282	2/23/2009	100.06	100.00	100.15
ITRON	C1S	850283	2/23/2009	100.09	100.02	100.16
ITRON	C1S	850284	2/23/2009	100.08	99.91	100.00
ITRON	C1S	850285	2/23/2009	100.09	99.97	99.91
ITRON	C1S	850286	2/23/2009	100.09	99.91	100.03
ITRON	C1S	850287	2/23/2009	100.08	100.00	100.02
ITRON	C1S	850288	2/23/2009	100.06	100.00	99.97
ITRON	C1S	850289	2/23/2009	100.08	99.92	100.10
ITRON	C1S	850290	2/23/2009	100.08	99.98	100.12
ITRON	C1S	850291	2/23/2009	100.07	99.89	99.99
ITRON	C1S	850292	2/23/2009	100.08	99.98	99.85
ITRON	C1S	850293	2/23/2009	100.06	99.95	99.90
ITRON	C1S	850294	2/23/2009	100.07	99.96	100.08
ITRON	C1S	850295	2/23/2009	100.09	99.95	100.19
ITRON	C1S	850296	2/23/2009	100.08	100.08	100.13
ITRON	C1S	850297	2/23/2009	100.08	99.89	100.24
ITRON	C1S	850298	2/23/2009	100.08	100.01	100.11
ITRON	C1S	850299	2/23/2009	100.10	99.95	100.10
ITRON	C1S	850300	2/23/2009	100.08	100.00	99.97
ITRON	C1S	850301	2/23/2009	100.07	100.05	99.85
ITRON	C1S	850302	2/23/2009	100.06	99.94	99.98
ITRON	C1S	850303	2/23/2009	100.08	100.03	100.10
ITRON	C1S	850304	2/23/2009	100.08	100.01	100.23
ITRON	C1S	850305	2/23/2009	100.07	99.94	100.12
ITRON	C1S	850306	2/23/2009	100.07	100.07	100.19
ITRON	C1S	850307	2/23/2009	100.07	99.92	100.16
ITRON	C1S	850308	2/23/2009	100.09	99.94	100.03
ITRON	C1S	850309	2/23/2009	100.10	100.01	100.07
ITRON	C1S	850310	2/23/2009	100.08	100.00	100.18
ITRON	C1S	850311	2/23/2009	100.09	100.03	100.16
ITRON	C1S	850312	2/23/2009	100.07	100.09	100.10
ITRON	C1S	850313	2/23/2009	100.09	100.03	99.89
ITRON	C1S	850314	2/23/2009	100.05	100.05	100.01

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850315	2/23/2009	100.08	100.08	100.13
ITRON	C1S	850316	2/23/2009	100.09	100.08	100.20
ITRON	C1S	850317	2/23/2009	100.08	100.09	100.21
ITRON	C1S	850318	2/23/2009	100.08	99.95	100.03
ITRON	C1S	850319	2/23/2009	100.07	100.04	100.12
ITRON	C1S	850320	2/23/2009	100.05	100.00	100.14
ITRON	C1S	850321	2/23/2009	100.06	99.94	100.14
ITRON	C1S	850322	2/23/2009	100.10	99.95	100.13
ITRON	C1S	850323	2/23/2009	100.10	100.01	100.03
ITRON	C1S	850324	2/23/2009	100.09	100.07	99.98
ITRON	C1S	850325	2/23/2009	100.07	100.02	100.17
ITRON	C1S	850326	2/23/2009	100.08	99.84	100.06
ITRON	C1S	850327	2/23/2009	100.09	99.95	100.11
ITRON	C1S	850328	2/23/2009	100.06	100.00	100.01
ITRON	C1S	850329	2/23/2009	100.06	99.92	100.17
ITRON	C1S	850330	2/23/2009	100.06	99.96	99.81
ITRON	C1S	850331	2/23/2009	100.10	99.88	100.17
ITRON	C1S	850332	2/23/2009	100.06	100.00	99.86
ITRON	C1S	850333	2/23/2009	100.06	99.91	100.11
ITRON	C1S	850334	2/23/2009	100.06	99.94	100.04
ITRON	C1S	850335	2/23/2009	100.06	99.91	100.03
ITRON	C1S	850336	2/23/2009	100.08	99.98	100.21
ITRON	C1S	850337	2/23/2009	100.08	99.95	99.97
ITRON	C1S	850338	2/23/2009	100.08	99.90	100.04
ITRON	C1S	850339	2/23/2009	100.10	100.03	100.19
ITRON	C1S	850340	2/23/2009	100.06	100.11	100.14
ITRON	C1S	850341	2/23/2009	100.09	99.97	100.02
ITRON	C1S	850342	2/23/2009	100.08	99.90	100.07
ITRON	C1S	850343	2/23/2009	100.05	100.05	100.15
ITRON	C1S	850344	2/23/2009	100.06	99.92	99.96
ITRON	C1S	850345	2/23/2009	100.09	99.95	100.00
ITRON	C1S	850346	2/23/2009	100.08	99.98	100.11
ITRON	C1S	850347	2/23/2009	100.06	99.91	100.02
ITRON	C1S	850348	2/23/2009	100.06	100.03	100.11
ITRON	C1S	850349	2/23/2009	100.08	99.97	100.04
ITRON	C1S	850350	2/23/2009	100.05	99.98	100.18
ITRON	C1S	850351	2/23/2009	100.07	100.00	99.82
ITRON	C1S	850352	2/23/2009	100.09	100.02	100.23
ITRON	C1S	850353	2/23/2009	100.07	100.02	99.97
ITRON	C1S	850354	2/23/2009	100.08	100.09	100.13
ITRON	C1S	850355	2/23/2009	100.08	99.94	100.08
ITRON	C1S	850356	2/23/2009	100.07	99.96	100.06
ITRON	C1S	850357	2/23/2009	100.08	99.94	99.98
ITRON	C1S	850358	2/23/2009	100.09	100.07	100.17
ITRON	C1S	850359	2/23/2009	100.08	99.96	100.07
ITRON	C1S	850360	2/23/2009	100.06	99.95	100.04
ITRON	C1S	850361	2/23/2009	100.08	100.14	100.18

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850362	2/23/2009	100.09	99.89	100.23
ITRON	C1S	850363	2/23/2009	100.08	100.02	100.09
ITRON	C1S	850364	2/23/2009	100.07	100.05	100.20
ITRON	C1S	850365	2/23/2009	100.09	100.08	100.11
ITRON	C1S	850366	2/23/2009	100.08	99.91	100.22
ITRON	C1S	850367	2/23/2009	100.09	99.96	100.10
ITRON	C1S	850368	2/23/2009	100.06	99.86	100.11
ITRON	C1S	850369	2/23/2009	100.09	100.03	100.14
ITRON	C1S	850370	2/23/2009	100.06	99.95	100.01
ITRON	C1S	850371	2/23/2009	100.08	99.97	99.94
ITRON	C1S	850372	2/23/2009	100.10	100.11	100.19
ITRON	C1S	850373	2/23/2009	100.07	99.98	99.86
ITRON	C1S	850374	2/23/2009	100.08	99.97	100.16
ITRON	C1S	850375	2/23/2009	100.05	100.07	100.16
ITRON	C1S	850376	2/23/2009	100.05	100.00	100.16
ITRON	C1S	850377	2/23/2009	100.06	100.03	100.06
ITRON	C1S	850378	2/23/2009	100.05	100.02	100.13
ITRON	C1S	850379	2/23/2009	100.06	100.14	100.12
ITRON	C1S	850380	2/23/2009	100.05	99.94	100.00
ITRON	C1S	850381	2/23/2009	100.05	99.95	100.00
ITRON	C1S	850382	2/23/2009	100.09	99.93	100.06
ITRON	C1S	850383	2/23/2009	100.08	99.97	100.11
ITRON	C1S	850384	2/23/2009	100.10	99.96	100.21
ITRON	C1S	850385	2/23/2009	100.06	100.12	100.19
ITRON	C1S	850386	2/23/2009	100.06	99.91	100.05
ITRON	C1S	850387	2/23/2009	100.09	100.05	100.02
ITRON	C1S	850388	2/23/2009	100.08	99.95	99.93
ITRON	C1S	850389	2/23/2009	100.09	99.89	100.04
ITRON	C1S	850390	2/23/2009	100.10	99.90	100.15
ITRON	C1S	850391	2/23/2009	100.06	99.93	99.83
ITRON	C1S	850392	2/23/2009	100.05	99.88	100.05
ITRON	C1S	850393	2/23/2009	100.07	99.90	100.15
ITRON	C1S	850394	2/23/2009	100.10	100.02	100.02
ITRON	C1S	850395	2/23/2009	100.08	99.91	100.07
ITRON	C1S	850396	2/23/2009	100.09	99.96	100.05
ITRON	C1S	850397	2/23/2009	100.06	100.02	99.92
ITRON	C1S	850398	2/23/2009	100.08	99.91	100.01
ITRON	C1S	850399	2/23/2009	100.08	100.05	100.12
ITRON	C1S	850400	2/23/2009	100.07	100.00	100.03
ITRON	C1S	850401	2/23/2009	100.09	100.05	100.08
ITRON	C1S	850402	2/23/2009	100.09	99.89	100.10
ITRON	C1S	850403	2/23/2009	100.06	100.01	100.15
ITRON	C1S	850404	2/23/2009	100.09	100.04	100.15
ITRON	C1S	850405	2/23/2009	100.08	100.06	100.18
ITRON	C1S	850406	2/23/2009	100.09	99.92	100.05
ITRON	C1S	850407	2/23/2009	100.08	99.97	99.86
ITRON	C1S	850408	2/23/2009	100.06	99.96	100.00

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850409	2/23/2009	100.06	99.92	99.97
ITRON	C1S	850410	2/23/2009	100.05	99.83	100.20
ITRON	C1S	850411	2/23/2009	100.05	99.97	100.06
ITRON	C1S	850412	2/23/2009	100.08	99.98	100.12
ITRON	C1S	850413	2/23/2009	100.07	100.05	100.01
ITRON	C1S	850414	2/23/2009	100.07	100.04	100.13
ITRON	C1S	850415	2/23/2009	100.08	100.09	100.10
ITRON	C1S	850416	2/23/2009	100.08	100.08	100.16
ITRON	C1S	850417	2/23/2009	100.08	100.00	99.87
ITRON	C1S	850418	2/23/2009	100.05	99.97	100.06
ITRON	C1S	850419	2/23/2009	100.08	99.92	99.99
ITRON	C1S	850420	2/23/2009	100.06	99.89	99.97
ITRON	C1S	850421	2/23/2009	100.08	100.08	100.14
ITRON	C1S	850422	2/23/2009	100.08	100.04	100.11
ITRON	C1S	850423	2/23/2009	100.05	99.94	100.02
ITRON	C1S	850424	2/23/2009	100.09	99.92	99.97
ITRON	C1S	850425	2/23/2009	100.06	100.09	100.12
ITRON	C1S	850426	2/23/2009	100.06	100.03	100.06
ITRON	C1S	850427	2/23/2009	100.07	100.05	100.12
ITRON	C1S	850428	2/23/2009	100.07	99.97	99.97
ITRON	C1S	850429	2/23/2009	100.08	100.02	100.10
ITRON	C1S	850430	2/23/2009	100.06	100.05	100.12
ITRON	C1S	850431	2/23/2009	100.08	99.98	100.14
ITRON	C1S	850432	2/23/2009	100.08	99.98	100.14
ITRON	C1S	850433	2/23/2009	100.09	99.97	99.84
ITRON	C1S	850434	2/23/2009	100.07	99.98	100.12
ITRON	C1S	850435	2/23/2009	100.10	100.01	100.15
ITRON	C1S	850436	2/23/2009	100.06	100.05	100.08
ITRON	C1S	850437	2/23/2009	100.10	99.89	100.11
ITRON	C1S	850438	2/23/2009	100.07	99.92	100.02
ITRON	C1S	850439	2/23/2009	100.09	100.05	100.15
ITRON	C1S	850440	2/23/2009	100.08	99.89	100.10
ITRON	C1S	850441	2/23/2009	100.10	100.04	100.23
ITRON	C1S	850442	2/23/2009	100.08	100.08	100.13
ITRON	C1S	850443	2/23/2009	100.08	100.03	100.08
ITRON	C1S	850444	2/23/2009	100.09	100.09	100.20
ITRON	C1S	850445	2/23/2009	100.09	100.03	100.23
ITRON	C1S	850446	2/23/2009	100.07	100.14	100.11
ITRON	C1S	850447	2/23/2009	100.09	100.00	99.88
ITRON	C1S	850448	2/23/2009	100.07	100.06	100.13
ITRON	C1S	850449	2/23/2009	100.09	100.02	99.85
ITRON	C1S	850450	2/23/2009	100.09	100.05	99.94
ITRON	C1S	850451	2/23/2009	100.08	100.12	100.12
ITRON	C1S	850452	2/23/2009	100.09	100.06	100.17
ITRON	C1S	850453	2/23/2009	100.05	100.04	100.17
ITRON	C1S	850454	2/23/2009	100.09	100.10	100.15
ITRON	C1S	850455	2/23/2009	100.08	100.08	100.16

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850456	2/23/2009	100.06	100.05	100.08
ITRON	C1S	850457	2/23/2009	100.10	100.08	100.06
ITRON	C1S	850458	2/23/2009	100.06	99.98	99.98
ITRON	C1S	850459	2/23/2009	100.08	99.86	100.12
ITRON	C1S	850460	2/23/2009	100.06	99.91	100.06
ITRON	C1S	850461	2/23/2009	100.08	100.00	100.01
ITRON	C1S	850462	2/23/2009	100.06	100.03	99.86
ITRON	C1S	850463	2/23/2009	100.05	99.97	99.93
ITRON	C1S	850464	2/23/2009	100.09	99.94	100.07
ITRON	C1S	850465	2/23/2009	100.09	100.10	100.04
ITRON	C1S	850466	2/23/2009	100.05	99.87	99.91
ITRON	C1S	850467	2/23/2009	100.08	100.06	100.16
ITRON	C1S	850468	2/23/2009	100.09	99.94	100.17
ITRON	C1S	850469	2/23/2009	100.08	99.95	100.09
ITRON	C1S	850470	2/23/2009	100.08	99.98	99.98
ITRON	C1S	850471	2/23/2009	100.09	99.95	100.05
ITRON	C1S	850472	2/23/2009	100.06	99.85	99.94
ITRON	C1S	850473	2/23/2009	100.10	99.94	100.00
ITRON	C1S	850474	2/23/2009	100.07	100.01	100.01
ITRON	C1S	850475	2/23/2009	100.09	99.98	100.26
ITRON	C1S	850476	2/23/2009	100.06	99.88	99.98
ITRON	C1S	850477	2/23/2009	100.06	99.99	100.02
ITRON	C1S	850478	2/23/2009	100.09	100.04	100.10
ITRON	C1S	850479	2/23/2009	100.06	100.04	100.14
ITRON	C1S	850480	2/23/2009	100.08	100.06	100.12
ITRON	C1S	850481	2/23/2009	100.07	99.99	100.08
ITRON	C1S	850482	2/23/2009	100.08	99.93	100.12
ITRON	C1S	850483	2/23/2009	100.09	100.12	100.23
ITRON	C1S	850484	2/23/2009	100.06	99.89	100.05
ITRON	C1S	850485	2/23/2009	100.06	99.97	100.01
ITRON	C1S	850486	2/23/2009	100.06	99.96	99.98
ITRON	C1S	850487	2/23/2009	100.08	99.89	99.98
ITRON	C1S	850488	2/23/2009	100.05	100.02	99.98
ITRON	C1S	850489	2/23/2009	100.07	99.92	99.98
ITRON	C1S	850490	2/23/2009	100.10	100.02	100.15
ITRON	C1S	850491	2/23/2009	100.09	99.92	100.08
ITRON	C1S	850492	2/23/2009	100.05	100.03	100.05
ITRON	C1S	850493	2/23/2009	100.05	99.86	100.06
ITRON	C1S	850494	2/23/2009	100.06	99.93	100.23
ITRON	C1S	850495	2/23/2009	100.05	99.96	100.03
ITRON	C1S	850496	2/23/2009	100.05	99.95	100.06
ITRON	C1S	850497	2/23/2009	100.06	99.95	100.01
ITRON	C1S	850498	2/23/2009	100.08	99.95	100.03
ITRON	C1S	850499	2/23/2009	100.08	99.94	100.07
ITRON	C1S	850500	2/23/2009	100.07	99.95	100.09
ITRON	C1S	850501	2/23/2009	100.07	99.98	100.14
ITRON	C1S	850502	2/23/2009	100.08	99.88	100.09

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850503	2/23/2009	100.06	100.00	100.00
ITRON	C1S	850504	2/23/2009	100.08	99.96	100.11
ITRON	C1S	850505	2/23/2009	100.10	100.09	100.23
ITRON	C1S	850506	2/23/2009	100.06	99.98	99.81
ITRON	C1S	850507	2/23/2009	100.07	99.98	100.09
ITRON	C1S	850508	2/23/2009	100.05	99.95	99.99
ITRON	C1S	850509	2/23/2009	100.07	99.95	99.94
ITRON	C1S	850510	2/23/2009	100.08	99.98	100.03
ITRON	C1S	850511	2/23/2009	100.07	99.89	100.08
ITRON	C1S	850512	2/23/2009	100.09	99.92	100.11
ITRON	C1S	850513	2/23/2009	100.09	99.92	100.17
ITRON	C1S	850514	2/23/2009	100.05	100.04	100.10
ITRON	C1S	850515	2/23/2009	100.08	100.06	100.17
ITRON	C1S	850516	2/23/2009	100.05	100.04	100.13
ITRON	C1S	850517	2/23/2009	100.05	100.03	100.04
ITRON	C1S	850518	2/23/2009	100.07	99.94	100.07
ITRON	C1S	850519	2/23/2009	100.08	100.06	100.14
ITRON	C1S	850520	2/23/2009	100.09	100.08	100.24
ITRON	C1S	850521	2/23/2009	100.08	99.98	100.09
ITRON	C1S	850522	2/23/2009	100.06	99.91	100.05
ITRON	C1S	850523	2/23/2009	100.08	99.96	100.04
ITRON	C1S	850524	2/23/2009	100.05	99.90	99.81
ITRON	C1S	850525	2/23/2009	100.09	99.89	100.24
ITRON	C1S	850526	2/23/2009	100.06	100.05	100.15
ITRON	C1S	850527	2/23/2009	100.09	99.90	100.25
ITRON	C1S	850528	2/23/2009	100.09	100.07	100.22
ITRON	C1S	850529	2/23/2009	100.09	99.96	100.11
ITRON	C1S	850530	2/23/2009	100.09	100.00	99.91
ITRON	C1S	850531	2/23/2009	100.09	99.91	100.11
ITRON	C1S	850532	2/23/2009	100.05	100.03	100.09
ITRON	C1S	850533	2/23/2009	100.08	99.91	100.04
ITRON	C1S	850534	2/23/2009	100.07	100.01	100.14
ITRON	C1S	850535	2/23/2009	100.09	100.10	100.13
ITRON	C1S	850536	2/23/2009	100.06	100.00	99.80
ITRON	C1S	850537	2/23/2009	100.07	99.98	100.11
ITRON	C1S	850538	2/23/2009	100.06	99.98	100.09
ITRON	C1S	850539	2/23/2009	100.09	99.95	100.14
ITRON	C1S	850540	2/23/2009	100.09	99.99	100.08
ITRON	C1S	850541	2/23/2009	100.08	99.96	100.09
ITRON	C1S	850542	2/23/2009	100.09	100.11	99.90
ITRON	C1S	850543	2/23/2009	100.07	99.98	100.12
ITRON	C1S	850544	2/23/2009	100.09	99.99	100.08
ITRON	C1S	850545	2/23/2009	100.09	99.89	99.99
ITRON	C1S	850546	2/23/2009	100.09	100.09	100.09
ITRON	C1S	850547	2/23/2009	100.06	99.98	99.87
ITRON	C1S	850548	2/23/2009	100.09	99.99	100.04
ITRON	C1S	850549	2/23/2009	100.06	99.92	100.03

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850550	2/23/2009	100.08	99.95	100.09
ITRON	C1S	850551	2/23/2009	100.09	99.94	99.94
ITRON	C1S	850552	2/23/2009	100.08	99.97	100.02
ITRON	C1S	850553	2/23/2009	100.06	99.95	99.98
ITRON	C1S	850554	2/23/2009	100.06	99.89	100.01
ITRON	C1S	850555	2/23/2009	100.05	99.95	100.07
ITRON	C1S	850556	2/23/2009	100.08	100.03	100.02
ITRON	C1S	850557	2/23/2009	100.05	99.88	99.99
ITRON	C1S	850558	2/23/2009	100.09	99.97	100.21
ITRON	C1S	850559	2/23/2009	100.06	100.04	99.83
ITRON	C1S	850560	2/23/2009	100.09	100.05	100.07
ITRON	C1S	850561	2/23/2009	100.06	99.99	100.12
ITRON	C1S	850562	2/23/2009	100.06	99.98	99.93
ITRON	C1S	850563	2/23/2009	100.08	99.94	100.07
ITRON	C1S	850564	2/23/2009	100.06	99.94	100.06
ITRON	C1S	850565	2/23/2009	100.08	99.89	99.97
ITRON	C1S	850566	2/23/2009	100.06	99.93	100.05
ITRON	C1S	850567	2/23/2009	100.07	99.92	99.81
ITRON	C1S	850568	2/23/2009	100.08	99.95	100.00
ITRON	C1S	850569	2/23/2009	100.08	99.88	100.14
ITRON	C1S	850570	2/23/2009	100.08	99.93	99.97
ITRON	C1S	850571	2/23/2009	100.06	100.04	100.13
ITRON	C1S	850572	2/23/2009	100.05	99.97	100.13
ITRON	C1S	850573	2/23/2009	100.06	99.88	100.07
ITRON	C1S	850574	2/23/2009	100.06	100.03	100.02
ITRON	C1S	850575	2/23/2009	100.09	100.02	99.94
ITRON	C1S	850576	2/23/2009	100.06	99.86	99.97
ITRON	C1S	850577	2/23/2009	100.06	99.98	100.00
ITRON	C1S	850578	2/23/2009	100.08	99.98	100.04
ITRON	C1S	850579	2/23/2009	100.09	100.02	100.15
ITRON	C1S	850580	2/23/2009	100.09	100.04	100.02
ITRON	C1S	850581	2/23/2009	100.06	99.90	100.00
ITRON	C1S	850582	2/23/2009	100.09	100.01	100.03
ITRON	C1S	850583	2/23/2009	100.06	99.94	99.83
ITRON	C1S	850584	2/23/2009	100.05	100.02	99.87
ITRON	C1S	850585	2/23/2009	100.07	100.01	99.96
ITRON	C1S	850586	2/23/2009	100.07	100.05	100.25
ITRON	C1S	850587	2/23/2009	100.07	99.95	100.09
ITRON	C1S	850588	2/23/2009	100.10	100.08	100.19
ITRON	C1S	850589	2/23/2009	100.06	100.02	100.10
ITRON	C1S	850590	2/23/2009	100.10	99.91	100.13
ITRON	C1S	850591	2/23/2009	100.10	100.03	100.11
ITRON	C1S	850592	2/23/2009	100.06	100.01	100.14
ITRON	C1S	850593	2/23/2009	100.06	99.99	100.07
ITRON	C1S	850594	2/23/2009	100.05	100.03	100.15
ITRON	C1S	850595	2/23/2009	100.10	100.00	100.13
ITRON	C1S	850596	2/23/2009	100.08	99.92	100.09

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850597	2/23/2009	100.06	99.96	100.00
ITRON	C1S	850598	2/23/2009	100.07	100.05	100.11
ITRON	C1S	850599	2/23/2009	100.07	100.10	100.21
ITRON	C1S	850600	2/23/2009	100.05	99.94	100.00
ITRON	C1S	850601	2/23/2009	100.08	99.91	100.28
ITRON	C1S	850602	2/23/2009	100.09	99.91	100.08
ITRON	C1S	850603	2/23/2009	100.06	99.96	99.98
ITRON	C1S	850604	2/23/2009	100.06	99.96	100.00
ITRON	C1S	850605	2/23/2009	100.07	100.00	100.14
ITRON	C1S	850606	2/23/2009	100.05	99.89	99.96
ITRON	C1S	850607	2/23/2009	100.10	99.90	100.08
ITRON	C1S	850608	2/23/2009	100.10	99.98	99.99
ITRON	C1S	850609	2/23/2009	100.08	99.87	100.08
ITRON	C1S	850610	2/23/2009	100.08	99.97	99.99
ITRON	C1S	850611	2/23/2009	100.07	99.90	100.07
ITRON	C1S	850612	2/23/2009	100.06	100.05	100.13
ITRON	C1S	850613	2/23/2009	100.07	100.03	100.17
ITRON	C1S	850614	2/23/2009	100.09	99.94	100.10
ITRON	C1S	850615	2/23/2009	100.09	99.95	100.02
ITRON	C1S	850616	2/23/2009	100.08	100.03	99.86
ITRON	C1S	850617	2/23/2009	100.05	100.05	100.19
ITRON	C1S	850618	2/23/2009	100.05	100.02	100.17
ITRON	C1S	850619	2/23/2009	100.08	99.88	99.92
ITRON	C1S	850620	2/23/2009	100.06	99.94	99.94
ITRON	C1S	850621	2/23/2009	100.09	100.07	100.22
ITRON	C1S	850622	2/23/2009	100.05	100.00	100.02
ITRON	C1S	850623	2/23/2009	100.06	100.01	100.02
ITRON	C1S	850624	2/23/2009	100.08	99.95	100.08
ITRON	C1S	850625	2/23/2009	100.08	99.95	100.20
ITRON	C1S	850626	2/23/2009	100.06	99.91	100.08
ITRON	C1S	850627	2/23/2009	100.07	100.05	100.08
ITRON	C1S	850628	2/23/2009	100.09	99.97	99.89
ITRON	C1S	850629	2/23/2009	100.08	99.99	100.05
ITRON	C1S	850630	2/23/2009	100.07	100.07	100.11
ITRON	C1S	850631	2/23/2009	100.09	100.14	100.13
ITRON	C1S	850632	2/23/2009	100.08	99.95	99.97
ITRON	C1S	850633	2/23/2009	100.06	99.98	100.22
ITRON	C1S	850634	2/23/2009	100.07	99.93	100.02
ITRON	C1S	850635	2/23/2009	100.08	99.93	100.06
ITRON	C1S	850636	2/23/2009	100.06	99.98	100.13
ITRON	C1S	850637	2/23/2009	100.09	99.94	100.14
ITRON	C1S	850638	2/23/2009	100.08	99.94	100.02
ITRON	C1S	850639	2/23/2009	100.09	99.90	100.21
ITRON	C1S	850640	2/23/2009	100.10	99.93	100.04
ITRON	C1S	850641	2/23/2009	100.09	99.96	100.25
ITRON	C1S	850642	2/23/2009	100.08	100.03	100.16
ITRON	C1S	850643	2/23/2009	100.09	100.06	100.13

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850644	2/23/2009	100.05	99.94	100.05
ITRON	C1S	850645	2/23/2009	100.07	99.89	100.03
ITRON	C1S	850646	2/23/2009	100.08	100.04	100.15
ITRON	C1S	850647	2/23/2009	100.09	100.10	100.13
ITRON	C1S	850648	2/23/2009	100.10	99.97	100.00
ITRON	C1S	850649	2/23/2009	100.06	99.96	100.10
ITRON	C1S	850650	2/23/2009	100.09	99.99	100.14
ITRON	C1S	850651	2/23/2009	100.09	99.99	100.00
ITRON	C1S	850652	2/23/2009	100.09	99.93	99.98
ITRON	C1S	850653	2/23/2009	100.05	100.06	100.16
ITRON	C1S	850654	2/23/2009	100.09	99.94	100.20
ITRON	C1S	850655	2/23/2009	100.09	100.06	100.09
ITRON	C1S	850656	2/23/2009	100.10	100.11	100.12
ITRON	C1S	850657	2/23/2009	100.08	99.99	100.15
ITRON	C1S	850658	2/23/2009	100.08	100.05	100.14
ITRON	C1S	850659	2/23/2009	100.06	99.90	100.09
ITRON	C1S	850660	2/23/2009	100.08	99.94	100.07
ITRON	C1S	850661	2/23/2009	100.07	99.89	100.03
ITRON	C1S	850662	2/23/2009	100.09	100.00	100.02
ITRON	C1S	850663	2/23/2009	100.10	100.09	100.19
ITRON	C1S	850664	2/23/2009	100.09	100.05	100.14
ITRON	C1S	850665	2/23/2009	100.09	100.07	100.17
ITRON	C1S	850666	2/23/2009	100.09	100.03	99.99
ITRON	C1S	850667	2/23/2009	100.08	99.95	100.00
ITRON	C1S	850668	2/23/2009	100.09	100.06	99.95
ITRON	C1S	850669	2/23/2009	100.06	100.03	99.84
ITRON	C1S	850670	2/23/2009	100.10	99.88	100.04
ITRON	C1S	850671	2/23/2009	100.05	99.87	100.09
ITRON	C1S	850672	2/23/2009	100.06	99.90	99.99
ITRON	C1S	850673	2/23/2009	100.09	100.00	100.08
ITRON	C1S	850674	2/23/2009	100.09	99.92	100.10
ITRON	C1S	850675	2/23/2009	100.08	99.96	100.16
ITRON	C1S	850676	2/23/2009	100.06	99.96	99.99
ITRON	C1S	850677	2/23/2009	100.08	100.07	100.17
ITRON	C1S	850678	2/23/2009	100.10	99.93	100.17
ITRON	C1S	850679	2/23/2009	100.07	100.01	100.09
ITRON	C1S	850680	2/23/2009	100.06	99.90	100.05
ITRON	C1S	850681	2/23/2009	100.08	99.92	100.10
ITRON	C1S	850682	2/23/2009	100.05	100.05	100.14
ITRON	C1S	850683	2/23/2009	100.07	99.92	99.95
ITRON	C1S	850684	2/23/2009	100.08	100.03	100.16
ITRON	C1S	850685	2/23/2009	100.05	99.90	100.06
ITRON	C1S	850686	2/23/2009	100.08	100.02	100.12
ITRON	C1S	850687	2/23/2009	100.09	99.98	100.15
ITRON	C1S	850688	2/23/2009	100.09	100.02	100.25
ITRON	C1S	850689	2/23/2009	100.09	99.89	100.05
ITRON	C1S	850690	2/23/2009	100.07	99.93	100.03

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850691	2/23/2009	100.07	99.93	100.14
ITRON	C1S	850692	2/23/2009	100.08	100.06	100.01
ITRON	C1S	850693	2/23/2009	100.09	99.98	100.06
ITRON	C1S	850694	2/23/2009	100.09	99.97	100.06
ITRON	C1S	850695	2/23/2009	100.05	99.90	99.99
ITRON	C1S	850696	2/23/2009	100.07	99.93	100.11
ITRON	C1S	850697	2/23/2009	100.07	99.86	100.07
ITRON	C1S	850698	2/23/2009	100.07	99.92	100.23
ITRON	C1S	850699	2/23/2009	100.07	100.04	99.99
ITRON	C1S	850700	2/23/2009	100.06	99.86	99.96
ITRON	C1S	850701	2/23/2009	100.08	99.98	100.03
ITRON	C1S	850702	2/23/2009	100.05	99.96	99.96
ITRON	C1S	850703	2/23/2009	100.08	99.95	100.06
ITRON	C1S	850704	2/23/2009	100.08	99.87	100.01
ITRON	C1S	850705	2/23/2009	100.09	99.98	100.07
ITRON	C1S	850706	2/23/2009	100.07	99.89	100.12
ITRON	C1S	850707	2/23/2009	100.09	99.94	100.06
ITRON	C1S	850708	2/23/2009	100.08	100.05	100.18
ITRON	C1S	850709	2/23/2009	100.07	99.94	100.05
ITRON	C1S	850710	2/23/2009	100.07	99.96	100.03
ITRON	C1S	850711	2/23/2009	100.05	99.95	100.02
ITRON	C1S	850712	2/23/2009	100.06	99.97	100.02
ITRON	C1S	850713	2/23/2009	100.08	99.94	100.06
ITRON	C1S	850714	2/23/2009	100.08	99.98	100.06
ITRON	C1S	850715	2/23/2009	100.08	99.95	100.11
ITRON	C1S	850716	2/23/2009	100.10	99.92	100.14
ITRON	C1S	850717	2/23/2009	100.09	99.99	100.00
ITRON	C1S	850718	2/23/2009	100.06	99.89	99.99
ITRON	C1S	850719	2/23/2009	100.06	99.92	100.05
ITRON	C1S	850720	2/23/2009	100.06	99.92	100.00
ITRON	C1S	850721	2/23/2009	100.06	99.97	100.01
ITRON	C1S	850722	2/23/2009	100.09	99.94	100.05
ITRON	C1S	850723	2/23/2009	100.09	99.93	100.15
ITRON	C1S	850724	2/23/2009	100.05	100.04	100.12
ITRON	C1S	850725	2/23/2009	100.09	100.08	100.20
ITRON	C1S	850726	2/23/2009	100.05	99.96	99.97
ITRON	C1S	850727	2/23/2009	100.07	100.00	99.99
ITRON	C1S	850728	2/23/2009	100.08	100.08	100.17
ITRON	C1S	850729	2/23/2009	100.05	99.88	100.20
ITRON	C1S	850730	2/23/2009	100.08	100.03	100.17
ITRON	C1S	850731	2/23/2009	100.08	100.10	100.16
ITRON	C1S	850732	2/23/2009	100.08	100.02	100.12
ITRON	C1S	850733	2/23/2009	100.09	99.95	100.18
ITRON	C1S	850734	2/23/2009	100.08	99.94	100.12
ITRON	C1S	850735	2/23/2009	100.07	99.96	99.95
ITRON	C1S	850736	2/23/2009	100.07	100.04	100.14
ITRON	C1S	850737	2/23/2009	100.09	100.14	100.12

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850738	2/23/2009	100.10	99.99	100.19
ITRON	C1S	850739	2/23/2009	100.08	100.02	99.97
ITRON	C1S	850740	2/23/2009	100.08	100.06	99.98
ITRON	C1S	850741	2/23/2009	100.05	99.94	99.89
ITRON	C1S	850742	2/23/2009	100.06	99.93	100.00
ITRON	C1S	850743	2/23/2009	100.05	100.04	100.11
ITRON	C1S	850744	2/23/2009	100.08	99.93	100.04
ITRON	C1S	850745	2/23/2009	100.06	99.96	99.96
ITRON	C1S	850746	2/23/2009	100.08	100.01	100.11
ITRON	C1S	850747	2/23/2009	100.06	100.05	100.16
ITRON	C1S	850748	2/23/2009	100.09	100.09	100.15
ITRON	C1S	850749	2/23/2009	100.08	100.07	100.25
ITRON	C1S	850750	2/23/2009	100.09	100.04	100.16
ITRON	C1S	850751	2/23/2009	100.09	100.05	100.22
ITRON	C1S	850752	2/23/2009	100.08	100.02	100.00
ITRON	C1S	850753	2/23/2009	100.09	100.12	100.14
ITRON	C1S	850754	2/23/2009	100.08	99.96	100.10
ITRON	C1S	850755	2/23/2009	100.07	99.96	100.05
ITRON	C1S	850756	2/23/2009	100.07	99.94	99.83
ITRON	C1S	850757	2/23/2009	100.06	100.01	100.16
ITRON	C1S	850758	2/23/2009	100.08	99.88	100.18
ITRON	C1S	850759	2/23/2009	100.09	100.02	100.14
ITRON	C1S	850760	2/23/2009	100.08	99.92	100.04
ITRON	C1S	850761	2/23/2009	100.07	99.91	99.95
ITRON	C1S	850762	2/23/2009	100.05	99.99	100.17
ITRON	C1S	850763	2/23/2009	100.10	100.01	100.17
ITRON	C1S	850764	2/23/2009	100.08	100.05	100.17
ITRON	C1S	850765	2/23/2009	100.08	100.08	100.15
ITRON	C1S	850766	2/23/2009	100.08	100.07	100.12
ITRON	C1S	850767	2/23/2009	100.07	100.04	100.16
ITRON	C1S	850768	2/23/2009	100.08	100.06	100.14
ITRON	C1S	850769	2/23/2009	100.06	99.88	100.24
ITRON	C1S	850770	2/23/2009	100.05	99.94	99.91
ITRON	C1S	850771	2/23/2009	100.05	99.93	100.22
ITRON	C1S	850772	2/23/2009	100.07	99.95	100.08
ITRON	C1S	850773	2/23/2009	100.08	99.91	100.27
ITRON	C1S	850774	2/23/2009	100.08	99.99	100.10
ITRON	C1S	850775	2/23/2009	100.10	100.05	99.89
ITRON	C1S	850776	2/23/2009	100.08	99.93	100.13
ITRON	C1S	850777	2/23/2009	100.11	99.99	99.90
ITRON	C1S	850778	2/23/2009	100.08	100.07	100.16
ITRON	C1S	850779	2/23/2009	100.10	99.99	100.11
ITRON	C1S	850780	2/23/2009	100.07	100.00	100.27
ITRON	C1S	850781	2/23/2009	100.06	99.92	100.04
ITRON	C1S	850782	2/23/2009	100.08	99.94	100.10
ITRON	C1S	850783	2/23/2009	100.06	99.90	100.19
ITRON	C1S	850784	2/23/2009	100.05	99.91	100.04

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	850785	2/23/2009	100.06	99.94	99.98
ITRON	C1S	850786	2/23/2009	100.07	99.90	100.07
ITRON	C1S	850787	2/23/2009	100.08	100.00	99.99
ITRON	C1S	850788	2/23/2009	100.06	100.03	100.11
ITRON	C1S	850789	2/23/2009	100.05	99.93	100.03
ITRON	C1S	850790	2/23/2009	100.06	99.92	99.92
ITRON	C1S	850791	2/23/2009	100.09	100.02	99.93
ITRON	C1S	850792	2/23/2009	100.08	100.04	100.04
ITRON	C1S	850793	2/23/2009	100.09	100.11	100.19
ITRON	C1S	850794	2/23/2009	100.06	100.03	100.09
ITRON	C1S	850795	2/23/2009	100.06	99.90	100.06
ITRON	C1S	850796	2/23/2009	100.07	100.03	100.02
ITRON	C1S	850797	2/23/2009	100.09	100.04	100.18
ITRON	C1S	850798	2/23/2009	100.06	100.06	100.15
ITRON	C1S	850799	2/23/2009	100.08	100.16	100.13
ITRON	C1S	850800	2/23/2009	100.08	99.91	100.17
ITRON	C1S	850801	2/23/2009	100.07	99.96	99.95
ITRON	C1S	850802	2/23/2009	100.08	99.93	100.02
ITRON	C1S	850803	2/23/2009	100.07	99.95	99.90
ITRON	C1S	850804	2/23/2009	100.08	100.06	100.10
ITRON	C1S	850805	2/23/2009	100.06	99.89	100.03
ITRON	C1S	850806	2/23/2009	100.05	99.96	99.81
ITRON	C1S	850807	2/23/2009	100.10	99.97	100.24
ITRON	C1S	850808	2/23/2009	100.05	100.05	100.13
ITRON	C1S	850809	2/23/2009	100.08	99.89	100.26
ITRON	C1S	850810	2/23/2009	100.08	99.97	100.06
ITRON	C1S	850811	2/23/2009	100.06	100.04	100.07
ITRON	C1S	850812	2/23/2009	100.08	99.94	99.86
ITRON	C1S	850813	2/23/2009	100.08	99.98	99.97
ITRON	C1S	850814	2/23/2009	100.07	99.91	100.06
ITRON	C1S	850815	2/23/2009	100.08	99.86	100.11
ITRON	C1S	850816	2/23/2009	100.08	100.07	100.12
ITRON	C1S	850817	2/23/2009	100.07	100.02	100.17
ITRON	C1S	850818	2/23/2009	100.09	100.01	100.20
ITRON	C1S	850819	2/23/2009	100.08	100.02	100.12
ITRON	C1S	850820	2/23/2009	100.05	100.07	100.07
ITRON	C1S	850821	2/23/2009	100.10	100.04	100.24
ITRON	C1S	850822	2/23/2009	100.10	100.05	100.02
ITRON	C1S	850823	2/23/2009	100.06	99.94	100.14
ITRON	C1S	850824	2/23/2009	100.08	100.09	100.14
ITRON	C1S	850825	2/23/2009	100.06	99.91	100.00
ITRON	C1S	850826	2/23/2009	100.08	100.07	100.14
ITRON	C1S	850827	2/23/2009	100.06	99.97	99.98
ITRON	C1S	850828	2/23/2009	100.06	99.98	99.98
ITRON	C1S	850829	2/23/2009	100.09	100.00	100.08
ITRON	C1S	850830	2/23/2009	100.09	100.00	99.95
ITRON	C1S	850831	2/23/2009	100.06	100.03	100.05

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850832	2/23/2009	100.08	99.88	100.14
ITRON	C1S	850833	2/23/2009	100.07	100.06	99.97
ITRON	C1S	850834	2/23/2009	100.09	99.95	100.13
ITRON	C1S	850835	2/23/2009	100.08	99.95	100.03
ITRON	C1S	850836	2/23/2009	100.09	100.05	99.97
ITRON	C1S	850837	2/23/2009	100.07	100.01	100.00
ITRON	C1S	850838	2/23/2009	100.06	99.95	100.09
ITRON	C1S	850839	2/23/2009	100.08	100.00	100.00
ITRON	C1S	850840	2/23/2009	100.06	99.86	100.13
ITRON	C1S	850841	2/23/2009	100.08	100.07	100.13
ITRON	C1S	850842	2/23/2009	100.09	99.95	100.01
ITRON	C1S	850843	2/23/2009	100.08	99.84	100.08
ITRON	C1S	850844	2/23/2009	100.06	99.97	99.99
ITRON	C1S	850845	2/23/2009	100.10	100.09	100.20
ITRON	C1S	850846	2/23/2009	100.09	99.93	100.11
ITRON	C1S	850847	2/23/2009	100.06	100.06	100.11
ITRON	C1S	850848	2/23/2009	100.07	100.00	99.95
ITRON	C1S	850849	2/23/2009	100.08	99.98	99.92
ITRON	C1S	850850	2/23/2009	100.08	99.94	100.02
ITRON	C1S	850851	2/23/2009	100.08	99.92	99.99
ITRON	C1S	850852	2/23/2009	100.09	100.05	99.85
ITRON	C1S	850853	2/23/2009	100.07	100.07	100.16
ITRON	C1S	850854	2/23/2009	100.09	100.08	100.20
ITRON	C1S	850855	2/23/2009	100.10	99.97	100.02
ITRON	C1S	850856	2/23/2009	100.08	100.05	100.03
ITRON	C1S	850857	2/23/2009	100.08	100.01	99.97
ITRON	C1S	850858	2/23/2009	100.06	100.00	100.06
ITRON	C1S	850859	2/23/2009	100.06	100.00	100.09
ITRON	C1S	850860	2/23/2009	100.06	100.00	100.12
ITRON	C1S	850861	2/23/2009	100.06	100.06	100.14
ITRON	C1S	850862	2/23/2009	100.07	99.96	100.06
ITRON	C1S	850863	2/23/2009	100.10	100.04	100.08
ITRON	C1S	850864	2/23/2009	100.06	99.95	100.01
ITRON	C1S	850865	2/23/2009	100.06	100.00	99.93
ITRON	C1S	850866	2/23/2009	100.07	99.91	100.09
ITRON	C1S	850867	2/23/2009	100.09	99.98	100.15
ITRON	C1S	850868	2/23/2009	100.07	99.91	100.05
ITRON	C1S	850869	2/23/2009	100.09	99.92	100.00
ITRON	C1S	850870	2/23/2009	100.09	99.96	100.07
ITRON	C1S	850871	2/23/2009	100.07	99.89	100.15
ITRON	C1S	850872	2/23/2009	100.08	99.89	100.04
ITRON	C1S	850873	2/23/2009	100.07	99.87	100.10
ITRON	C1S	850874	2/23/2009	100.08	99.95	100.11
ITRON	C1S	850875	2/23/2009	100.06	99.90	100.01
ITRON	C1S	850876	2/23/2009	100.07	99.94	100.08
ITRON	C1S	850877	2/23/2009	100.08	99.82	100.07
ITRON	C1S	850878	2/23/2009	100.10	100.00	99.99

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850879	2/23/2009	100.09	99.99	100.01
ITRON	C1S	850880	2/23/2009	100.10	100.04	99.95
ITRON	C1S	850881	2/23/2009	100.09	99.94	100.08
ITRON	C1S	850882	2/23/2009	100.08	99.94	100.01
ITRON	C1S	850883	2/23/2009	100.06	99.91	100.01
ITRON	C1S	850884	2/23/2009	100.09	100.07	100.16
ITRON	C1S	850885	2/23/2009	100.05	100.04	100.17
ITRON	C1S	850886	2/23/2009	100.05	99.89	100.03
ITRON	C1S	850887	2/23/2009	100.09	100.05	99.92
ITRON	C1S	850888	2/23/2009	100.06	99.95	99.99
ITRON	C1S	850889	2/23/2009	100.05	99.98	100.10
ITRON	C1S	850890	2/23/2009	100.09	100.05	100.16
ITRON	C1S	850891	2/23/2009	100.08	99.84	100.03
ITRON	C1S	850892	2/23/2009	100.09	99.92	100.01
ITRON	C1S	850893	2/23/2009	100.06	99.92	100.13
ITRON	C1S	850894	2/23/2009	100.08	100.07	100.15
ITRON	C1S	850895	2/23/2009	100.09	100.05	100.18
ITRON	C1S	850896	2/23/2009	100.09	100.01	100.14
ITRON	C1S	850897	2/23/2009	100.05	99.99	100.04
ITRON	C1S	850898	2/23/2009	100.09	99.99	100.09
ITRON	C1S	850899	2/23/2009	100.10	100.17	100.22
ITRON	C1S	850900	2/23/2009	100.09	100.06	100.18
ITRON	C1S	850901	2/23/2009	100.07	99.95	100.04
ITRON	C1S	850902	2/23/2009	100.06	99.96	100.05
ITRON	C1S	850903	2/23/2009	100.06	100.02	100.07
ITRON	C1S	850904	2/23/2009	100.08	99.94	100.10
ITRON	C1S	850905	2/23/2009	100.08	99.98	99.95
ITRON	C1S	850906	2/23/2009	100.09	100.04	100.20
ITRON	C1S	850907	2/23/2009	100.08	99.98	100.05
ITRON	C1S	850908	2/23/2009	100.06	99.94	100.03
ITRON	C1S	850909	2/23/2009	100.09	100.02	100.00
ITRON	C1S	850910	2/23/2009	100.09	100.06	100.16
ITRON	C1S	850911	2/23/2009	100.09	99.96	100.03
ITRON	C1S	850912	2/23/2009	100.10	100.03	100.00
ITRON	C1S	850913	2/23/2009	100.07	99.91	100.03
ITRON	C1S	850914	2/23/2009	100.10	100.03	100.06
ITRON	C1S	850915	2/23/2009	100.10	100.02	100.11
ITRON	C1S	850916	2/23/2009	100.10	100.04	100.12
ITRON	C1S	850917	2/23/2009	100.07	99.96	99.97
ITRON	C1S	850918	2/23/2009	100.05	99.92	99.99
ITRON	C1S	850919	2/23/2009	100.07	100.02	99.94
ITRON	C1S	850920	2/23/2009	100.07	99.94	100.16
ITRON	C1S	850921	2/23/2009	100.05	99.92	100.07
ITRON	C1S	850922	2/23/2009	100.10	99.97	100.12
ITRON	C1S	850923	2/23/2009	100.05	99.98	99.97
ITRON	C1S	850924	2/23/2009	100.08	99.93	100.13
ITRON	C1S	850925	2/23/2009	100.07	100.00	100.08

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850926	2/23/2009	100.05	99.90	99.93
ITRON	C1S	850927	2/23/2009	100.07	100.07	100.19
ITRON	C1S	850928	2/23/2009	100.06	99.95	99.98
ITRON	C1S	850929	2/23/2009	100.05	100.03	100.07
ITRON	C1S	850930	2/23/2009	100.09	99.95	100.11
ITRON	C1S	850931	2/23/2009	100.09	100.00	100.06
ITRON	C1S	850932	2/23/2009	100.07	99.96	100.01
ITRON	C1S	850933	2/23/2009	100.08	100.01	99.99
ITRON	C1S	850934	2/23/2009	100.10	100.07	100.21
ITRON	C1S	850935	2/23/2009	100.06	100.00	100.00
ITRON	C1S	850936	2/23/2009	100.09	100.07	100.16
ITRON	C1S	850937	2/23/2009	100.07	100.07	100.15
ITRON	C1S	850938	2/23/2009	100.06	99.99	100.16
ITRON	C1S	850939	2/23/2009	100.09	100.12	100.15
ITRON	C1S	850940	2/23/2009	100.05	99.92	100.08
ITRON	C1S	850941	2/23/2009	100.08	99.98	100.08
ITRON	C1S	850942	2/23/2009	100.06	100.01	100.15
ITRON	C1S	850943	2/23/2009	100.08	100.09	100.19
ITRON	C1S	850944	2/23/2009	100.08	99.94	100.13
ITRON	C1S	850945	2/23/2009	100.05	100.03	100.14
ITRON	C1S	850946	2/23/2009	100.05	100.03	100.16
ITRON	C1S	850947	2/23/2009	100.10	99.98	100.00
ITRON	C1S	850948	2/23/2009	100.08	99.99	99.89
ITRON	C1S	850949	2/23/2009	100.06	100.02	99.99
ITRON	C1S	850950	2/23/2009	100.06	99.90	100.24
ITRON	C1S	850951	2/23/2009	100.05	99.96	99.96
ITRON	C1S	850952	2/23/2009	100.06	99.98	100.01
ITRON	C1S	850953	2/23/2009	100.09	100.09	100.18
ITRON	C1S	850954	2/23/2009	100.10	99.94	100.12
ITRON	C1S	850955	2/23/2009	100.05	99.98	99.87
ITRON	C1S	850956	2/23/2009	100.10	99.93	100.16
ITRON	C1S	850957	2/23/2009	100.08	99.90	100.03
ITRON	C1S	850958	2/23/2009	100.09	100.06	100.21
ITRON	C1S	850959	2/23/2009	100.05	99.88	100.04
ITRON	C1S	850960	2/23/2009	100.08	100.02	100.19
ITRON	C1S	850961	2/23/2009	100.05	100.03	100.16
ITRON	C1S	850962	2/23/2009	100.09	99.99	100.07
ITRON	C1S	850963	2/23/2009	100.09	100.02	99.92
ITRON	C1S	850964	2/23/2009	100.08	99.86	100.11
ITRON	C1S	850965	2/23/2009	100.06	100.02	100.16
ITRON	C1S	850966	2/23/2009	100.08	100.01	100.07
ITRON	C1S	850967	2/23/2009	100.07	100.00	100.13
ITRON	C1S	850968	2/23/2009	100.06	99.98	100.00
ITRON	C1S	850969	2/23/2009	100.05	99.88	100.03
ITRON	C1S	850970	2/23/2009	100.07	100.11	100.15
ITRON	C1S	850971	2/23/2009	100.10	100.06	100.20
ITRON	C1S	850972	2/23/2009	100.09	99.99	99.92

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	850973	2/23/2009	100.09	100.09	100.15
ITRON	C1S	850974	2/23/2009	100.06	100.11	100.16
ITRON	C1S	850975	2/23/2009	100.07	99.95	100.02
ITRON	C1S	850976	2/23/2009	100.10	100.00	100.01
ITRON	C1S	850977	2/23/2009	100.07	99.96	99.97
ITRON	C1S	850978	2/23/2009	100.10	99.99	100.17
ITRON	C1S	850979	2/23/2009	100.08	100.10	100.13
ITRON	C1S	850980	2/23/2009	100.09	100.05	100.13
ITRON	C1S	850981	2/23/2009	100.10	99.91	100.16
ITRON	C1S	850982	2/23/2009	100.05	99.92	100.04
ITRON	C1S	850983	2/23/2009	100.06	99.92	100.05
ITRON	C1S	850984	2/23/2009	100.07	99.87	100.05
ITRON	C1S	850985	2/23/2009	100.06	99.93	99.91
ITRON	C1S	850986	2/23/2009	100.06	100.01	99.95
ITRON	C1S	850987	2/23/2009	100.06	100.05	100.15
ITRON	C1S	850988	2/23/2009	100.05	99.86	100.01
ITRON	C1S	850989	2/23/2009	100.09	100.08	100.18
ITRON	C1S	850990	2/23/2009	100.07	99.99	99.89
ITRON	C1S	850991	2/23/2009	100.05	100.00	99.89
ITRON	C1S	850992	2/23/2009	100.06	100.05	100.13
ITRON	C1S	850993	2/23/2009	100.08	100.06	100.15
ITRON	C1S	850994	2/23/2009	100.06	99.91	100.03
ITRON	C1S	850995	2/23/2009	100.06	100.02	100.14
ITRON	C1S	850996	2/23/2009	100.06	99.99	99.84
ITRON	C1S	850997	2/23/2009	100.07	99.94	100.03
ITRON	C1S	850998	2/23/2009	100.09	99.98	99.85
ITRON	C1S	850999	2/23/2009	100.07	99.97	100.13
ITRON	C1S	851000	2/23/2009	100.06	99.90	100.27
ITRON	C1S	851001	2/23/2009	100.06	99.97	99.86
ITRON	C1S	851002	2/23/2009	100.09	99.92	100.02
ITRON	C1S	851003	2/23/2009	100.09	100.00	100.05
ITRON	C1S	851004	2/23/2009	100.09	99.98	99.86
ITRON	C1S	851005	2/23/2009	100.09	100.07	100.22
ITRON	C1S	851006	2/23/2009	100.07	99.95	100.13
ITRON	C1S	851007	2/23/2009	100.06	99.83	99.92
ITRON	C1S	851008	2/23/2009	100.07	99.94	100.03
ITRON	C1S	851009	2/23/2009	100.05	99.97	100.08
ITRON	C1S	851010	2/23/2009	100.05	99.90	100.09
ITRON	C1S	851011	2/23/2009	100.09	99.94	100.04
ITRON	C1S	851012	2/23/2009	100.07	99.97	100.07
ITRON	C1S	851013	2/23/2009	100.06	100.06	100.12
ITRON	C1S	851014	2/23/2009	100.08	99.96	100.19
ITRON	C1S	851015	2/23/2009	100.08	100.08	100.17
ITRON	C1S	851016	2/23/2009	100.07	100.03	100.17
ITRON	C1S	851017	2/23/2009	100.08	100.09	100.13
ITRON	C1S	851018	2/23/2009	100.06	100.00	100.16
ITRON	C1S	851019	2/23/2009	100.08	100.09	100.16

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851020	2/23/2009	100.08	100.02	100.12
ITRON	C1S	851021	2/23/2009	100.08	99.97	100.17
ITRON	C1S	851022	2/23/2009	100.09	99.90	100.11
ITRON	C1S	851023	2/23/2009	100.05	100.07	100.12
ITRON	C1S	851024	2/23/2009	100.05	100.01	100.00
ITRON	C1S	851025	2/23/2009	100.08	100.01	100.09
ITRON	C1S	851026	2/23/2009	100.06	99.95	100.09
ITRON	C1S	851027	2/23/2009	100.09	99.99	99.94
ITRON	C1S	851028	2/23/2009	100.07	99.98	100.07
ITRON	C1S	851029	2/23/2009	100.07	100.06	100.15
ITRON	C1S	851030	2/23/2009	100.07	99.83	100.08
ITRON	C1S	851031	2/23/2009	100.07	100.05	100.19
ITRON	C1S	851032	2/23/2009	100.06	99.83	99.97
ITRON	C1S	851033	2/23/2009	100.07	99.95	100.00
ITRON	C1S	851034	2/23/2009	100.09	99.96	99.92
ITRON	C1S	851035	2/23/2009	100.07	99.89	100.02
ITRON	C1S	851036	2/23/2009	100.09	99.89	99.99
ITRON	C1S	851037	2/23/2009	100.09	99.93	100.07
ITRON	C1S	851038	2/23/2009	100.05	99.95	99.98
ITRON	C1S	851039	2/23/2009	100.06	100.07	100.17
ITRON	C1S	851040	2/23/2009	100.08	100.00	100.13
ITRON	C1S	851041	2/23/2009	100.05	99.98	100.13
ITRON	C1S	851042	2/23/2009	100.06	99.97	100.14
ITRON	C1S	851043	2/23/2009	100.08	100.06	100.13
ITRON	C1S	851044	2/23/2009	100.05	100.08	100.13
ITRON	C1S	851045	2/23/2009	100.08	99.97	100.00
ITRON	C1S	851046	2/23/2009	100.06	100.01	100.13
ITRON	C1S	851047	2/23/2009	100.10	99.98	100.17
ITRON	C1S	851048	2/23/2009	100.07	100.01	100.22
ITRON	C1S	851049	2/23/2009	100.08	100.03	100.14
ITRON	C1S	851050	2/23/2009	100.09	100.03	99.89
ITRON	C1S	851051	2/23/2009	100.09	100.05	100.19
ITRON	C1S	851052	2/23/2009	100.07	100.02	100.16
ITRON	C1S	851053	2/23/2009	100.10	100.03	100.08
ITRON	C1S	851054	2/23/2009	100.06	99.92	100.01
ITRON	C1S	851055	2/23/2009	100.05	99.85	99.94
ITRON	C1S	851056	2/23/2009	100.06	99.92	100.16
ITRON	C1S	851057	2/23/2009	100.08	100.02	100.20
ITRON	C1S	851058	2/23/2009	100.07	100.02	100.07
ITRON	C1S	851059	2/23/2009	100.05	99.93	100.15
ITRON	C1S	851060	2/23/2009	100.07	99.97	99.89
ITRON	C1S	851061	2/23/2009	100.08	100.01	99.88
ITRON	C1S	851062	2/23/2009	100.08	100.02	100.03
ITRON	C1S	851063	2/23/2009	100.06	99.89	99.91
ITRON	C1S	851064	2/23/2009	100.09	100.03	100.16
ITRON	C1S	851065	2/23/2009	100.08	100.07	100.15
ITRON	C1S	851066	2/23/2009	100.09	99.96	100.14

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851067	2/23/2009	100.06	99.90	100.11
ITRON	C1S	851068	2/23/2009	100.09	100.00	100.01
ITRON	C1S	851069	2/23/2009	100.05	99.95	100.07
ITRON	C1S	851070	2/23/2009	100.07	99.87	100.10
ITRON	C1S	851071	2/23/2009	100.08	99.86	100.05
ITRON	C1S	851072	2/23/2009	100.05	100.00	100.09
ITRON	C1S	851073	2/23/2009	100.07	99.94	100.00
ITRON	C1S	851074	2/23/2009	100.07	99.94	99.94
ITRON	C1S	851075	2/23/2009	100.09	99.97	100.02
ITRON	C1S	851076	2/23/2009	100.07	99.99	100.13
ITRON	C1S	851077	2/23/2009	100.08	99.91	100.06
ITRON	C1S	851078	2/23/2009	100.07	99.91	100.17
ITRON	C1S	851079	2/23/2009	100.09	99.94	100.10
ITRON	C1S	851080	2/23/2009	100.06	99.92	100.01
ITRON	C1S	851081	2/23/2009	100.08	100.02	100.18
ITRON	C1S	851082	2/23/2009	100.08	100.08	100.23
ITRON	C1S	851083	2/23/2009	100.06	99.94	100.22
ITRON	C1S	851084	2/23/2009	100.09	99.98	100.01
ITRON	C1S	851085	2/23/2009	100.07	100.02	100.12
ITRON	C1S	851086	2/23/2009	100.08	99.98	100.06
ITRON	C1S	851087	2/23/2009	100.10	100.00	100.02
ITRON	C1S	851088	2/23/2009	100.09	100.09	100.13
ITRON	C1S	851089	2/23/2009	100.10	100.02	100.14
ITRON	C1S	851090	2/23/2009	100.05	100.04	100.12
ITRON	C1S	851091	2/23/2009	100.08	100.04	100.22
ITRON	C1S	851092	2/23/2009	100.08	100.14	100.19
ITRON	C1S	851093	2/23/2009	100.09	100.06	100.14
ITRON	C1S	851094	2/23/2009	100.10	100.12	100.06
ITRON	C1S	851095	2/23/2009	100.08	99.96	100.07
ITRON	C1S	851096	2/23/2009	100.06	99.88	99.96
ITRON	C1S	851097	2/23/2009	100.10	100.15	100.17
ITRON	C1S	851098	2/23/2009	100.10	99.97	100.06
ITRON	C1S	851099	2/23/2009	100.08	99.98	100.10
ITRON	C1S	851100	2/23/2009	100.07	99.92	99.98
ITRON	C1S	851101	2/23/2009	100.06	99.95	99.97
ITRON	C1S	851102	2/23/2009	100.05	99.89	100.12
ITRON	C1S	851103	2/23/2009	100.08	99.92	100.06
ITRON	C1S	851104	2/23/2009	100.08	99.95	99.84
ITRON	C1S	851105	2/23/2009	100.08	99.96	99.93
ITRON	C1S	851106	2/23/2009	100.07	99.91	100.12
ITRON	C1S	851107	2/23/2009	100.07	99.93	100.00
ITRON	C1S	851108	2/23/2009	100.09	100.01	100.18
ITRON	C1S	851109	2/23/2009	100.09	100.08	100.23
ITRON	C1S	851110	2/23/2009	100.08	99.98	100.08
ITRON	C1S	851111	2/23/2009	100.08	100.08	100.18
ITRON	C1S	851112	2/23/2009	100.09	99.96	100.12
ITRON	C1S	851113	2/23/2009	100.05	99.91	99.95

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851114	2/23/2009	100.08	100.04	100.04
ITRON	C1S	851115	2/23/2009	100.06	99.96	99.99
ITRON	C1S	851116	2/23/2009	100.06	99.95	100.03
ITRON	C1S	851117	2/23/2009	100.09	99.94	100.13
ITRON	C1S	851118	2/23/2009	100.06	99.92	100.03
ITRON	C1S	851119	2/23/2009	100.08	99.96	100.17
ITRON	C1S	851120	2/23/2009	100.06	99.93	100.02
ITRON	C1S	851121	2/23/2009	100.09	100.04	99.84
ITRON	C1S	851122	2/23/2009	100.06	99.95	99.82
ITRON	C1S	851123	2/23/2009	100.08	100.00	99.87
ITRON	C1S	851124	2/23/2009	100.09	100.04	100.09
ITRON	C1S	851125	2/23/2009	100.06	100.01	99.96
ITRON	C1S	851126	2/23/2009	100.05	99.91	100.05
ITRON	C1S	851127	2/23/2009	100.09	99.99	100.24
ITRON	C1S	851128	2/23/2009	100.09	99.94	100.12
ITRON	C1S	851129	2/23/2009	100.06	99.92	100.04
ITRON	C1S	851130	2/23/2009	100.08	99.97	100.01
ITRON	C1S	851131	2/23/2009	100.06	99.96	100.01
ITRON	C1S	851132	2/23/2009	100.06	99.94	100.01
ITRON	C1S	851133	2/23/2009	100.08	100.06	100.14
ITRON	C1S	851134	2/23/2009	100.06	99.90	100.16
ITRON	C1S	851135	2/23/2009	100.07	100.07	100.14
ITRON	C1S	851136	2/23/2009	100.07	100.03	100.14
ITRON	C1S	851137	2/23/2009	100.06	99.97	99.98
ITRON	C1S	851138	2/23/2009	100.08	99.99	99.99
ITRON	C1S	851139	2/23/2009	100.08	99.92	100.22
ITRON	C1S	851140	2/23/2009	100.07	100.03	100.25
ITRON	C1S	851141	2/23/2009	100.05	99.91	99.97
ITRON	C1S	851142	2/23/2009	100.06	99.85	100.11
ITRON	C1S	851143	2/23/2009	100.06	100.00	99.91
ITRON	C1S	851144	2/23/2009	100.06	99.91	99.93
ITRON	C1S	851145	2/23/2009	100.09	99.95	100.13
ITRON	C1S	851146	2/23/2009	100.08	99.96	99.98
ITRON	C1S	851147	2/23/2009	100.06	99.95	99.98
ITRON	C1S	851148	2/23/2009	100.08	99.92	99.99
ITRON	C1S	851149	2/23/2009	100.06	99.98	99.97
ITRON	C1S	851150	2/23/2009	100.08	100.02	100.05
ITRON	C1S	851151	2/23/2009	100.09	100.06	100.02
ITRON	C1S	851152	2/23/2009	100.06	99.99	99.99
ITRON	C1S	851153	2/23/2009	100.08	100.05	99.87
ITRON	C1S	851154	2/23/2009	100.08	99.94	100.05
ITRON	C1S	851155	2/23/2009	100.05	100.06	100.17
ITRON	C1S	851156	2/23/2009	100.07	99.92	100.04
ITRON	C1S	851157	2/23/2009	100.09	99.95	100.11
ITRON	C1S	851158	2/23/2009	100.09	99.95	99.82
ITRON	C1S	851159	2/23/2009	100.08	99.88	100.11
ITRON	C1S	851160	2/23/2009	100.06	99.93	99.95

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851161	2/23/2009	100.09	100.06	100.17
ITRON	C1S	851162	2/23/2009	100.07	100.01	99.94
ITRON	C1S	851163	2/23/2009	100.06	100.02	100.23
ITRON	C1S	851164	2/23/2009	100.09	99.90	100.02
ITRON	C1S	851165	2/23/2009	100.09	100.00	99.90
ITRON	C1S	851166	2/23/2009	100.07	99.96	99.99
ITRON	C1S	851167	2/23/2009	100.05	99.90	100.13
ITRON	C1S	851168	2/23/2009	100.05	100.10	100.17
ITRON	C1S	851169	2/23/2009	100.08	100.00	99.90
ITRON	C1S	851170	2/23/2009	100.09	99.91	100.13
ITRON	C1S	851171	2/23/2009	100.06	99.90	100.14
ITRON	C1S	851172	2/23/2009	100.08	99.91	99.98
ITRON	C1S	851173	2/23/2009	100.09	100.03	100.17
ITRON	C1S	851174	2/23/2009	100.06	99.95	99.96
ITRON	C1S	851175	2/23/2009	100.08	99.89	100.08
ITRON	C1S	851176	2/23/2009	100.09	99.98	99.84
ITRON	C1S	851177	2/23/2009	100.09	99.96	100.13
ITRON	C1S	851178	2/23/2009	100.08	99.97	100.08
ITRON	C1S	851179	2/23/2009	100.07	100.04	100.09
ITRON	C1S	851180	2/23/2009	100.06	99.94	100.00
ITRON	C1S	851181	2/23/2009	100.08	100.01	100.12
ITRON	C1S	851182	2/23/2009	100.07	99.98	100.08
ITRON	C1S	851183	2/23/2009	100.06	100.04	100.18
ITRON	C1S	851184	2/23/2009	100.09	100.02	100.05
ITRON	C1S	851185	2/23/2009	100.08	99.98	99.99
ITRON	C1S	851186	2/23/2009	100.09	100.08	100.15
ITRON	C1S	851187	2/23/2009	100.05	99.87	99.98
ITRON	C1S	851188	2/23/2009	100.07	99.96	100.11
ITRON	C1S	851189	2/23/2009	100.07	100.08	100.13
ITRON	C1S	851190	2/23/2009	100.07	99.91	100.00
ITRON	C1S	851191	2/23/2009	100.06	99.89	100.11
ITRON	C1S	851192	2/23/2009	100.07	99.86	100.16
ITRON	C1S	851193	2/23/2009	100.09	100.09	100.17
ITRON	C1S	851194	2/23/2009	100.08	99.92	100.20
ITRON	C1S	851195	2/23/2009	100.09	99.88	100.27
ITRON	C1S	851196	2/23/2009	100.10	99.98	100.00
ITRON	C1S	851197	2/23/2009	100.09	99.87	100.10
ITRON	C1S	851198	2/23/2009	100.09	100.13	100.15
ITRON	C1S	851199	2/23/2009	100.06	99.93	99.83
ITRON	C1S	851200	2/23/2009	100.08	100.03	100.14
ITRON	C1S	851201	2/23/2009	100.10	99.85	100.19
ITRON	C1S	851202	2/23/2009	100.06	99.88	100.06
ITRON	C1S	851203	2/23/2009	100.09	99.96	99.99
ITRON	C1S	851204	2/23/2009	100.08	99.94	99.87
ITRON	C1S	851205	2/23/2009	100.06	100.02	100.10
ITRON	C1S	851206	2/23/2009	100.08	99.97	99.83
ITRON	C1S	851207	2/23/2009	100.08	99.92	100.05

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	851208	2/23/2009	100.10	99.94	99.97
ITRON	C1S	851209	2/23/2009	100.07	99.99	100.02
ITRON	C1S	851210	2/23/2009	100.08	99.90	100.08
ITRON	C1S	851211	2/23/2009	100.07	100.00	100.03
ITRON	C1S	851212	2/23/2009	100.07	99.95	100.14
ITRON	C1S	851213	2/23/2009	100.10	100.14	100.17
ITRON	C1S	851214	2/23/2009	100.07	99.91	100.12
ITRON	C1S	851215	2/23/2009	100.09	99.97	100.08
ITRON	C1S	851216	2/23/2009	100.08	100.03	99.95
ITRON	C1S	851217	2/23/2009	100.09	99.96	100.12
ITRON	C1S	851218	2/23/2009	100.05	99.97	99.83
ITRON	C1S	851219	2/23/2009	100.06	99.88	100.19
ITRON	C1S	851220	2/23/2009	100.05	99.91	100.09
ITRON	C1S	851221	2/23/2009	100.07	100.01	100.00
ITRON	C1S	851222	2/23/2009	100.07	99.83	100.12
ITRON	C1S	851223	2/23/2009	100.08	100.06	100.18
ITRON	C1S	851224	2/23/2009	100.07	99.99	100.07
ITRON	C1S	851225	2/23/2009	100.09	100.01	100.01
ITRON	C1S	851226	2/23/2009	100.06	99.99	100.11
ITRON	C1S	851227	2/23/2009	100.06	99.95	99.83
ITRON	C1S	851228	2/23/2009	100.09	99.92	100.10
ITRON	C1S	851229	2/23/2009	100.08	100.05	100.15
ITRON	C1S	851230	2/23/2009	100.08	99.98	100.15
ITRON	C1S	851231	2/23/2009	100.06	99.88	100.11
ITRON	C1S	851232	2/23/2009	100.07	100.00	99.95
ITRON	C1S	851233	2/23/2009	100.05	99.94	100.06
ITRON	C1S	851234	2/23/2009	100.09	99.94	99.97
ITRON	C1S	851235	2/23/2009	100.07	99.99	99.94
ITRON	C1S	851236	2/23/2009	100.08	99.97	100.20
ITRON	C1S	851237	2/23/2009	100.06	99.92	100.06
ITRON	C1S	851238	2/23/2009	100.05	99.88	100.02
ITRON	C1S	851239	2/23/2009	100.07	99.95	100.03
ITRON	C1S	851240	2/23/2009	100.06	99.94	100.01
ITRON	C1S	851241	2/23/2009	100.06	99.91	100.12
ITRON	C1S	851242	2/23/2009	100.08	100.03	99.89
ITRON	C1S	851243	2/23/2009	100.06	99.90	100.24
ITRON	C1S	851244	2/23/2009	100.07	99.99	99.91
ITRON	C1S	851245	2/23/2009	100.08	99.95	100.07
ITRON	C1S	851246	2/23/2009	100.10	99.96	100.09
ITRON	C1S	851247	2/23/2009	100.07	100.04	100.24
ITRON	C1S	851248	2/23/2009	100.06	100.00	100.10
ITRON	C1S	851249	2/23/2009	100.05	99.94	99.96
ITRON	C1S	851250	2/23/2009	100.09	100.10	100.19
ITRON	C1S	851251	2/23/2009	100.08	100.09	100.14
ITRON	C1S	851252	2/23/2009	100.10	100.08	100.19
ITRON	C1S	851253	2/23/2009	100.05	99.92	100.16
ITRON	C1S	851254	2/23/2009	100.09	100.11	100.21

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851255	2/23/2009	100.07	99.97	99.98
ITRON	C1S	851256	2/23/2009	100.06	99.99	100.02
ITRON	C1S	851257	2/23/2009	100.08	100.06	100.11
ITRON	C1S	851258	2/23/2009	100.09	100.09	99.99
ITRON	C1S	851259	2/23/2009	100.06	99.90	99.94
ITRON	C1S	851260	2/23/2009	100.06	100.02	100.17
ITRON	C1S	851261	2/23/2009	100.06	100.08	100.10
ITRON	C1S	851262	2/23/2009	100.07	100.03	100.16
ITRON	C1S	851263	2/23/2009	100.08	100.03	100.12
ITRON	C1S	851264	2/23/2009	100.08	100.11	100.19
ITRON	C1S	851265	2/23/2009	100.08	99.99	100.22
ITRON	C1S	851266	2/23/2009	100.06	99.92	100.02
ITRON	C1S	851267	2/23/2009	100.06	99.89	100.01
ITRON	C1S	851268	2/23/2009	100.07	100.03	99.98
ITRON	C1S	851269	2/23/2009	100.05	100.08	100.10
ITRON	C1S	851270	2/23/2009	100.06	100.01	100.14
ITRON	C1S	851271	2/23/2009	100.08	100.06	100.15
ITRON	C1S	851272	2/23/2009	100.08	99.98	99.96
ITRON	C1S	851273	2/23/2009	100.09	100.08	100.12
ITRON	C1S	851274	2/23/2009	100.08	99.89	100.00
ITRON	C1S	851275	2/23/2009	100.08	99.97	99.87
ITRON	C1S	851276	2/23/2009	100.09	99.89	100.07
ITRON	C1S	851277	2/23/2009	100.07	99.92	99.94
ITRON	C1S	851278	2/23/2009	100.08	99.96	100.11
ITRON	C1S	851279	2/23/2009	100.09	99.97	100.06
ITRON	C1S	851280	2/23/2009	100.09	99.95	100.01
ITRON	C1S	851281	2/23/2009	100.07	100.00	99.97
ITRON	C1S	851282	2/23/2009	100.06	99.95	100.04
ITRON	C1S	851283	2/23/2009	100.09	99.95	100.06
ITRON	C1S	851284	2/23/2009	100.10	99.98	100.05
ITRON	C1S	851285	2/23/2009	100.07	99.93	100.03
ITRON	C1S	851286	2/23/2009	100.07	99.95	100.01
ITRON	C1S	851287	2/23/2009	100.06	99.89	100.06
ITRON	C1S	851288	2/23/2009	100.06	99.94	100.03
ITRON	C1S	851289	2/23/2009	100.06	99.96	99.98
ITRON	C1S	851290	2/23/2009	100.06	99.82	100.07
ITRON	C1S	851291	2/23/2009	100.11	100.00	100.12
ITRON	C1S	851292	2/23/2009	100.08	99.99	100.02
ITRON	C1S	851293	2/23/2009	100.07	99.88	100.01
ITRON	C1S	851294	2/23/2009	100.09	100.09	100.12
ITRON	C1S	851295	2/23/2009	100.06	99.98	100.00
ITRON	C1S	851296	2/23/2009	100.11	99.99	100.11
ITRON	C1S	851297	2/23/2009	100.05	99.95	99.96
ITRON	C1S	851298	2/23/2009	100.09	100.04	100.03
ITRON	C1S	851299	2/23/2009	100.09	100.06	100.12
ITRON	C1S	851300	2/23/2009	100.06	99.99	100.11
ITRON	C1S	851301	2/23/2009	100.09	100.09	100.26

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851302	2/23/2009	100.05	99.98	100.19
ITRON	C1S	851303	2/23/2009	100.08	100.03	100.18
ITRON	C1S	851304	2/23/2009	100.07	99.92	100.14
ITRON	C1S	851305	2/23/2009	100.06	100.06	100.11
ITRON	C1S	851306	2/23/2009	100.08	100.05	100.18
ITRON	C1S	851307	2/23/2009	100.08	100.12	100.19
ITRON	C1S	851308	2/23/2009	100.05	99.97	99.95
ITRON	C1S	851309	2/23/2009	100.07	99.95	99.95
ITRON	C1S	851310	2/23/2009	100.06	100.00	100.06
ITRON	C1S	851311	2/23/2009	100.05	99.94	100.08
ITRON	C1S	851312	2/23/2009	100.06	99.94	99.85
ITRON	C1S	851313	2/23/2009	100.07	100.08	100.17
ITRON	C1S	851314	2/23/2009	100.10	99.92	100.14
ITRON	C1S	851315	2/23/2009	100.09	99.94	100.22
ITRON	C1S	851316	2/23/2009	100.08	99.88	100.18
ITRON	C1S	851317	2/23/2009	100.07	100.10	100.06
ITRON	C1S	851318	2/23/2009	100.06	99.95	100.08
ITRON	C1S	851319	2/23/2009	100.07	100.00	100.02
ITRON	C1S	851320	2/23/2009	100.05	100.02	100.12
ITRON	C1S	851321	2/23/2009	100.05	100.09	100.16
ITRON	C1S	851322	2/23/2009	100.08	100.08	100.18
ITRON	C1S	851323	2/23/2009	100.07	100.04	100.15
ITRON	C1S	851324	2/23/2009	100.07	100.12	100.18
ITRON	C1S	851325	2/23/2009	100.08	100.06	100.11
ITRON	C1S	851326	2/23/2009	100.06	100.04	100.15
ITRON	C1S	851327	2/23/2009	100.05	100.01	100.16
ITRON	C1S	851328	2/23/2009	100.08	100.02	100.19
ITRON	C1S	851329	2/23/2009	100.05	100.03	100.17
ITRON	C1S	851330	2/23/2009	100.07	99.92	100.08
ITRON	C1S	851331	2/23/2009	100.05	99.99	99.87
ITRON	C1S	851332	2/23/2009	100.08	99.97	100.04
ITRON	C1S	851333	2/23/2009	100.06	100.02	99.97
ITRON	C1S	851334	2/23/2009	100.06	99.91	100.15
ITRON	C1S	851335	2/23/2009	100.08	99.99	100.14
ITRON	C1S	851336	2/23/2009	100.05	99.96	100.07
ITRON	C1S	851337	2/23/2009	100.08	100.08	100.18
ITRON	C1S	851338	2/23/2009	100.06	99.89	99.90
ITRON	C1S	851339	2/23/2009	100.05	99.99	99.90
ITRON	C1S	851340	2/23/2009	100.08	99.85	100.18
ITRON	C1S	851341	2/23/2009	100.07	99.94	100.18
ITRON	C1S	851342	2/23/2009	100.10	99.98	99.98
ITRON	C1S	851343	2/23/2009	100.07	99.98	100.04
ITRON	C1S	851344	2/23/2009	100.06	99.95	100.08
ITRON	C1S	851345	2/23/2009	100.08	99.92	100.13
ITRON	C1S	851346	2/23/2009	100.08	100.01	99.98
ITRON	C1S	851347	2/23/2009	100.06	100.03	100.19
ITRON	C1S	851348	2/23/2009	100.07	99.96	100.10

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851349	2/23/2009	100.10	100.11	100.13
ITRON	C1S	851350	2/23/2009	100.09	100.04	99.98
ITRON	C1S	851351	2/23/2009	100.09	99.91	100.09
ITRON	C1S	851352	2/23/2009	100.07	99.99	100.05
ITRON	C1S	851353	2/23/2009	100.05	99.94	100.07
ITRON	C1S	851354	2/23/2009	100.06	100.05	100.13
ITRON	C1S	851355	2/23/2009	100.07	100.03	99.92
ITRON	C1S	851356	2/23/2009	100.09	99.93	99.94
ITRON	C1S	851357	2/23/2009	100.09	100.04	100.20
ITRON	C1S	851358	2/23/2009	100.08	100.02	100.04
ITRON	C1S	851359	2/23/2009	100.08	99.92	100.07
ITRON	C1S	851360	2/23/2009	100.06	100.05	100.13
ITRON	C1S	851361	2/23/2009	100.06	99.96	100.01
ITRON	C1S	851362	2/23/2009	100.08	100.05	100.21
ITRON	C1S	851363	2/23/2009	100.07	99.93	100.06
ITRON	C1S	851364	2/23/2009	100.05	99.86	100.06
ITRON	C1S	851365	2/23/2009	100.08	99.98	100.06
ITRON	C1S	851366	2/23/2009	100.09	100.09	100.22
ITRON	C1S	851367	2/23/2009	100.05	99.97	100.15
ITRON	C1S	851368	2/23/2009	100.09	99.97	99.98
ITRON	C1S	851369	2/23/2009	100.10	100.09	100.22
ITRON	C1S	851370	2/23/2009	100.06	100.00	100.16
ITRON	C1S	851371	2/23/2009	100.10	99.90	100.16
ITRON	C1S	851372	2/23/2009	100.06	99.94	100.16
ITRON	C1S	851373	2/23/2009	100.09	99.98	100.06
ITRON	C1S	851374	2/23/2009	100.09	99.94	100.00
ITRON	C1S	851375	2/23/2009	100.08	99.89	100.14
ITRON	C1S	851376	2/23/2009	100.09	99.96	100.10
ITRON	C1S	851377	2/23/2009	100.06	100.08	100.02
ITRON	C1S	851378	2/23/2009	100.07	100.01	100.19
ITRON	C1S	851379	2/23/2009	100.07	99.99	100.00
ITRON	C1S	851380	2/23/2009	100.09	100.01	100.03
ITRON	C1S	851381	2/23/2009	100.08	99.95	100.17
ITRON	C1S	851382	2/23/2009	100.08	99.94	99.98
ITRON	C1S	851383	2/23/2009	100.07	99.89	100.11
ITRON	C1S	851384	2/23/2009	100.09	99.95	100.07
ITRON	C1S	851385	2/23/2009	100.08	99.96	100.15
ITRON	C1S	851386	2/23/2009	100.08	100.00	100.13
ITRON	C1S	851387	2/23/2009	100.05	99.94	100.20
ITRON	C1S	851388	2/23/2009	100.09	100.09	100.16
ITRON	C1S	851389	2/23/2009	100.09	100.04	100.06
ITRON	C1S	851390	2/23/2009	100.09	100.00	100.17
ITRON	C1S	851391	2/23/2009	100.07	100.07	100.20
ITRON	C1S	851392	2/23/2009	100.07	100.00	100.09
ITRON	C1S	851393	2/23/2009	100.06	100.00	100.07
ITRON	C1S	851394	2/23/2009	100.06	99.94	100.01
ITRON	C1S	851395	2/23/2009	100.09	99.92	99.96

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	851396	2/23/2009	100.06	100.10	100.06
ITRON	C1S	851397	2/23/2009	100.09	99.96	100.19
ITRON	C1S	851398	2/23/2009	100.09	99.99	100.20
ITRON	C1S	851399	2/23/2009	100.06	100.00	99.97
ITRON	C1S	851400	2/23/2009	100.09	100.07	99.93
ITRON	C1S	851401	2/23/2009	100.06	99.98	100.01
ITRON	C1S	851402	2/23/2009	100.06	100.08	100.11
ITRON	C1S	851403	2/23/2009	100.08	99.99	100.05
ITRON	C1S	851404	2/23/2009	100.07	99.96	99.95
ITRON	C1S	851405	2/23/2009	100.05	99.98	99.89
ITRON	C1S	851406	2/23/2009	100.10	99.95	100.11
ITRON	C1S	851407	2/23/2009	100.05	99.83	100.12
ITRON	C1S	851408	2/23/2009	100.06	99.94	100.07
ITRON	C1S	851409	2/23/2009	100.09	100.03	100.18
ITRON	C1S	851410	2/23/2009	100.06	99.93	100.11
ITRON	C1S	851411	2/23/2009	100.05	100.07	100.06
ITRON	C1S	851412	2/23/2009	100.06	99.85	100.08
ITRON	C1S	851413	2/23/2009	100.08	99.85	100.07
ITRON	C1S	851414	2/23/2009	100.08	100.07	100.18
ITRON	C1S	851415	2/23/2009	100.06	99.92	99.93
ITRON	C1S	851416	2/23/2009	100.07	99.93	100.09
ITRON	C1S	851417	2/23/2009	100.06	100.02	100.01
ITRON	C1S	851418	2/23/2009	100.07	99.92	100.17
ITRON	C1S	851419	2/23/2009	100.06	99.92	99.91
ITRON	C1S	851420	2/23/2009	100.08	99.89	100.08
ITRON	C1S	851421	2/23/2009	100.08	99.96	100.05
ITRON	C1S	851422	2/23/2009	100.10	100.07	100.04
ITRON	C1S	851423	2/23/2009	100.06	99.90	100.04
ITRON	C1S	851424	2/23/2009	100.06	99.95	100.12
ITRON	C1S	851425	2/23/2009	100.07	99.94	99.96
ITRON	C1S	851426	2/23/2009	100.08	99.98	100.21
ITRON	C1S	851427	2/23/2009	100.09	99.98	100.12
ITRON	C1S	851428	2/23/2009	100.09	100.04	100.08
ITRON	C1S	851429	2/23/2009	100.05	99.89	100.01
ITRON	C1S	851430	2/23/2009	100.09	99.96	99.85
ITRON	C1S	851431	2/23/2009	100.07	99.99	100.04
ITRON	C1S	851432	2/23/2009	100.05	100.04	100.13
ITRON	C1S	851433	2/23/2009	100.10	99.99	100.01
ITRON	C1S	851434	2/23/2009	100.10	99.93	100.25
ITRON	C1S	851435	2/23/2009	100.08	100.05	100.04
ITRON	C1S	851436	2/23/2009	100.08	99.91	100.03
ITRON	C1S	851437	2/23/2009	100.07	99.97	100.12
ITRON	C1S	851438	2/23/2009	100.08	99.93	100.13
ITRON	C1S	851439	2/23/2009	100.08	100.09	99.97
ITRON	C1S	851440	2/23/2009	100.06	99.93	99.94
ITRON	C1S	851441	2/23/2009	100.08	99.98	100.00
ITRON	C1S	851442	2/23/2009	100.09	99.89	100.15

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851443	2/23/2009	100.06	99.92	100.09
ITRON	C1S	851444	2/23/2009	100.09	99.97	100.04
ITRON	C1S	851445	2/23/2009	100.08	99.97	99.91
ITRON	C1S	851446	2/23/2009	100.09	100.06	100.22
ITRON	C1S	851447	2/23/2009	100.07	100.03	100.21
ITRON	C1S	851448	2/23/2009	100.07	99.97	100.01
ITRON	C1S	851449	2/23/2009	100.09	100.08	100.17
ITRON	C1S	851450	2/23/2009	100.09	99.91	100.09
ITRON	C1S	851451	2/23/2009	100.06	99.98	100.11
ITRON	C1S	851452	2/23/2009	100.06	99.89	100.07
ITRON	C1S	851453	2/23/2009	100.07	100.07	100.12
ITRON	C1S	851454	2/23/2009	100.08	99.99	99.99
ITRON	C1S	851455	2/23/2009	100.06	99.99	100.16
ITRON	C1S	851456	2/23/2009	100.07	99.98	100.19
ITRON	C1S	851457	2/23/2009	100.06	100.04	100.16
ITRON	C1S	851458	2/23/2009	100.06	99.86	100.06
ITRON	C1S	851459	2/23/2009	100.07	99.92	100.19
ITRON	C1S	851460	2/23/2009	100.07	99.94	100.20
ITRON	C1S	851461	2/23/2009	100.07	100.02	100.13
ITRON	C1S	851462	2/23/2009	100.08	99.91	100.27
ITRON	C1S	851463	2/23/2009	100.05	100.04	100.15
ITRON	C1S	851464	2/23/2009	100.06	99.95	100.00
ITRON	C1S	851465	2/23/2009	100.06	99.99	100.05
ITRON	C1S	851466	2/23/2009	100.08	99.93	100.09
ITRON	C1S	851467	2/23/2009	100.07	99.97	100.04
ITRON	C1S	851468	2/23/2009	100.09	99.95	100.09
ITRON	C1S	851469	2/23/2009	100.09	99.94	100.15
ITRON	C1S	851470	2/23/2009	100.09	99.98	100.22
ITRON	C1S	851471	2/23/2009	100.09	99.98	100.24
ITRON	C1S	851472	2/23/2009	100.06	99.88	100.03
ITRON	C1S	851473	2/23/2009	100.05	99.95	99.96
ITRON	C1S	851474	2/23/2009	100.07	100.08	100.18
ITRON	C1S	851475	2/23/2009	100.06	100.09	100.11
ITRON	C1S	851476	2/23/2009	100.10	99.94	100.23
ITRON	C1S	851477	2/23/2009	100.10	99.97	100.04
ITRON	C1S	851478	2/23/2009	100.08	99.93	100.12
ITRON	C1S	851479	2/23/2009	100.09	99.97	100.09
ITRON	C1S	851480	2/23/2009	100.10	99.87	100.26
ITRON	C1S	851481	2/23/2009	100.08	99.90	100.06
ITRON	C1S	851482	2/23/2009	100.08	100.05	100.11
ITRON	C1S	851483	2/23/2009	100.07	99.94	99.98
ITRON	C1S	851484	2/23/2009	100.09	100.00	100.10
ITRON	C1S	851485	2/23/2009	100.09	99.98	100.03
ITRON	C1S	851486	2/23/2009	100.10	99.91	100.16
ITRON	C1S	851487	2/23/2009	100.05	100.02	100.13
ITRON	C1S	851488	2/23/2009	100.07	99.98	100.12
ITRON	C1S	851489	2/23/2009	100.10	99.93	100.11

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851490	2/23/2009	100.06	99.88	100.01
ITRON	C1S	851491	2/23/2009	100.09	100.13	100.14
ITRON	C1S	851492	2/23/2009	100.10	100.09	100.02
ITRON	C1S	851493	2/23/2009	100.05	99.91	100.07
ITRON	C1S	851494	2/23/2009	100.06	100.08	100.11
ITRON	C1S	851495	2/23/2009	100.09	100.04	100.13
ITRON	C1S	851496	2/23/2009	100.07	100.02	100.17
ITRON	C1S	851497	2/23/2009	100.06	100.02	100.24
ITRON	C1S	851498	2/23/2009	100.08	100.06	100.18
ITRON	C1S	851499	2/23/2009	100.09	99.96	99.96
ITRON	C1S	851500	2/23/2009	100.09	100.07	100.20
ITRON	C1S	851501	2/23/2009	100.08	100.07	100.18
ITRON	C1S	851502	2/23/2009	100.07	99.95	100.02
ITRON	C1S	851503	2/23/2009	100.06	99.91	99.87
ITRON	C1S	851504	2/23/2009	100.10	99.99	100.03
ITRON	C1S	851505	2/23/2009	100.09	100.04	99.92
ITRON	C1S	851506	2/23/2009	100.05	99.89	99.95
ITRON	C1S	851507	2/23/2009	100.05	99.92	100.11
ITRON	C1S	851508	2/23/2009	100.09	99.97	100.01
ITRON	C1S	851509	2/23/2009	100.08	100.04	100.10
ITRON	C1S	851510	2/23/2009	100.09	100.11	100.16
ITRON	C1S	851511	2/23/2009	100.08	100.08	100.09
ITRON	C1S	851512	2/23/2009	100.10	99.95	100.23
ITRON	C1S	851513	2/23/2009	100.09	99.99	100.12
ITRON	C1S	851514	2/23/2009	100.09	99.92	100.14
ITRON	C1S	851515	2/23/2009	100.08	99.89	100.00
ITRON	C1S	851516	2/23/2009	100.05	100.07	100.12
ITRON	C1S	851517	2/23/2009	100.08	99.89	100.08
ITRON	C1S	851518	2/23/2009	100.08	99.95	100.00
ITRON	C1S	851519	2/23/2009	100.07	99.95	100.22
ITRON	C1S	851520	2/23/2009	100.06	99.85	100.02
ITRON	C1S	851521	2/23/2009	100.09	99.95	100.11
ITRON	C1S	851522	2/23/2009	100.08	99.99	100.08
ITRON	C1S	851523	2/23/2009	100.07	100.04	100.16
ITRON	C1S	851524	2/23/2009	100.08	100.05	100.11
ITRON	C1S	851525	2/23/2009	100.06	99.96	100.07
ITRON	C1S	851526	2/23/2009	100.07	100.03	100.16
ITRON	C1S	851527	2/23/2009	100.07	99.92	100.23
ITRON	C1S	851528	2/23/2009	100.06	99.96	99.93
ITRON	C1S	851529	2/23/2009	100.09	100.00	100.16
ITRON	C1S	851530	2/23/2009	100.07	99.96	100.02
ITRON	C1S	851531	2/23/2009	100.10	100.10	100.17
ITRON	C1S	851532	2/23/2009	100.08	99.97	100.01
ITRON	C1S	851533	2/23/2009	100.05	100.04	100.13
ITRON	C1S	851534	2/23/2009	100.06	99.89	100.15
ITRON	C1S	851535	2/23/2009	100.06	99.85	100.08
ITRON	C1S	851536	2/23/2009	100.09	100.01	100.12

Louisville Gas Electric
New Single Phase Meters 2009

ITRON	C1S	851537	2/23/2009	100.08	99.98	100.06
ITRON	C1S	851538	2/23/2009	100.09	100.03	100.00
ITRON	C1S	851539	2/23/2009	100.09	100.06	100.03
ITRON	C1S	851540	2/23/2009	100.09	99.92	100.06
ITRON	C1S	851541	2/23/2009	100.08	99.93	100.05
ITRON	C1S	851542	2/23/2009	100.06	100.06	100.16
ITRON	C1S	851543	2/23/2009	100.09	99.95	100.07
ITRON	C1S	851544	2/23/2009	100.09	99.93	100.10
ITRON	C1S	851545	2/23/2009	100.05	100.00	100.16
ITRON	C1S	851546	2/23/2009	100.06	99.96	100.07
ITRON	C1S	851547	2/23/2009	100.08	100.06	100.16
ITRON	C1S	851548	2/23/2009	100.10	100.08	100.13
ITRON	C1S	851549	2/23/2009	100.09	100.06	100.21
ITRON	C1S	851550	2/23/2009	100.05	100.04	100.16
ITRON	C1S	851551	2/23/2009	100.05	100.03	100.11
ITRON	C1S	851552	2/23/2009	100.07	100.06	100.17
ITRON	C1S	851553	2/23/2009	100.09	100.07	100.21
ITRON	C1S	851554	2/23/2009	100.06	99.98	100.09
ITRON	C1S	851555	2/23/2009	100.07	100.03	99.83
ITRON	C1S	851556	2/23/2009	100.09	99.95	100.05
ITRON	C1S	851557	2/23/2009	100.05	99.94	99.99
ITRON	C1S	851558	2/23/2009	100.08	99.91	100.03
ITRON	C1S	851559	2/23/2009	100.08	99.95	100.00
ITRON	C1S	851560	2/23/2009	100.08	99.97	100.01
ITRON	C1S	851561	2/23/2009	100.08	99.97	99.99
ITRON	C1S	851562	2/23/2009	100.06	100.01	99.89
ITRON	C1S	851563	2/23/2009	100.10	99.97	100.12
ITRON	C1S	851564	2/23/2009	100.09	99.96	100.25
ITRON	C1S	851565	2/23/2009	100.08	99.97	100.03
ITRON	C1S	851566	2/23/2009	100.08	99.96	100.00
ITRON	C1S	851567	2/23/2009	100.07	100.00	100.21
ITRON	C1S	851568	2/23/2009	100.08	100.05	100.09
ITRON	C1S	851569	2/23/2009	100.05	99.92	99.93
ITRON	C1S	851570	2/23/2009	100.10	100.05	100.21
ITRON	C1S	851571	2/23/2009	100.08	99.89	100.01
ITRON	C1S	851572	2/23/2009	100.08	99.93	100.05
ITRON	C1S	851573	2/23/2009	100.07	99.96	99.98
ITRON	C1S	851574	2/23/2009	100.06	100.02	100.12
ITRON	C1S	851575	2/23/2009	100.07	100.05	100.19
ITRON	C1S	851576	2/23/2009	100.06	100.02	99.90
ITRON	C1S	851577	2/23/2009	100.08	100.03	99.94
ITRON	C1S	851578	2/23/2009	100.09	100.03	100.16
ITRON	C1S	851579	2/23/2009	100.08	99.92	100.13
ITRON	C1S	851580	2/23/2009	100.07	100.04	99.88
ITRON	C1S	851581	2/23/2009	100.08	99.94	100.14
ITRON	C1S	851582	2/23/2009	100.07	99.98	99.98
ITRON	C1S	851583	2/23/2009	100.08	100.06	100.14

**Louisville Gas Electric
New Single Phase Meters 2009**

ITRON	C1S	851584	2/23/2009	100.09	99.99	100.07
ITRON	C1S	851585	2/23/2009	100.06	99.89	100.19
ITRON	C1S	851586	2/23/2009	100.10	99.95	100.01
ITRON	C1S	851587	2/23/2009	100.06	99.94	100.04
ITRON	C1S	851588	2/23/2009	100.10	100.00	99.97
ITRON	C1S	851589	2/23/2009	100.07	99.87	100.01
ITRON	C1S	851590	2/23/2009	100.09	100.08	100.12
ITRON	C1S	851591	2/23/2009	100.07	99.94	100.10
ITRON	C1S	851592	2/23/2009	100.08	100.10	100.17
ITRON	C1S	851593	2/23/2009	100.09	99.93	100.11
ITRON	C1S	851594	2/23/2009	100.06	99.96	100.11
ITRON	C1S	851595	2/23/2009	100.07	100.02	100.10
ITRON	C1S	851596	2/23/2009	100.06	99.89	100.09
ITRON	C1S	851597	2/23/2009	100.06	99.93	100.00
ITRON	C1S	851598	2/23/2009	100.06	99.97	100.15
ITRON	C1S	851599	2/23/2009	100.09	99.92	100.07
ITRON	C1S	851600	2/23/2009	100.05	100.02	100.21
ITRON	C1S	851601	2/23/2009	100.09	100.02	99.87
ITRON	C1S	851602	2/23/2009	100.06	99.95	100.00
ITRON	C1S	851603	2/23/2009	100.08	99.94	100.03
ITRON	C1S	851604	2/23/2009	100.09	100.03	99.83
ITRON	C1S	851605	2/23/2009	100.09	100.07	100.25
ITRON	C1S	851606	2/23/2009	100.09	99.97	100.06
ITRON	C1S	851607	2/23/2009	100.11	100.00	100.12
ITRON	C1S	851608	2/23/2009	100.06	99.92	99.93
ITRON	C1S	851609	2/23/2009	100.05	99.96	99.93
ITRON	C1S	851610	2/23/2009	100.05	100.04	100.20
ITRON	C1S	851611	2/23/2009	100.06	99.89	100.11
ITRON	C1S	851612	2/23/2009	100.07	100.01	100.18
ITRON	C1S	851613	2/23/2009	100.10	100.07	100.14
ITRON	C1S	851614	2/23/2009	100.06	99.89	100.07
ITRON	C1S	851615	2/23/2009	100.06	100.06	100.18
ITRON	C1S	851616	2/23/2009	100.05	99.95	99.93
ITRON	C1S	851617	2/23/2009	100.08	99.94	100.11
ITRON	C1S	851618	2/23/2009	100.06	100.01	100.14
TOTAL	3840					

E.ON U.S.

**5040 Annual Report
of New Single Phase
Meters**

Dynamic Filters

Plant LG&E
 Manf. Model Number C1S; C1SR
 Calendar Month/Year 04/2009 - 12/2009

Plant	Manufacturer	Manf. Model Number	Serial Number	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
LG&E	ITRON	C1S	852107	05/21/2009	100.07	99.89	100.01	1
LG&E	ITRON	C1S	852108	05/21/2009	100.07	99.93	100.11	1
LG&E	ITRON	C1S	852109	05/21/2009	100.06	99.95	99.99	1
LG&E	ITRON	C1S	852110	05/21/2009	100.06	99.92	100.06	1
LG&E	ITRON	C1S	852111	05/21/2009	100.09	100.00	100.12	1
LG&E	ITRON	C1S	852112	05/21/2009	100.10	99.92	100.16	1
LG&E	ITRON	C1S	852113	05/21/2009	100.06	99.97	100.08	1
LG&E	ITRON	C1S	852114	05/21/2009	100.08	100.09	100.15	1
LG&E	ITRON	C1S	852115	05/21/2009	100.05	100.03	100.04	1
LG&E	ITRON	C1S	852116	05/21/2009	100.06	99.94	100.11	1
LG&E	ITRON	C1S	852117	05/21/2009	100.06	100.01	100.08	1
LG&E	ITRON	C1S	852118	05/21/2009	100.09	100.03	100.17	1
LG&E	ITRON	C1S	852119	05/21/2009	100.05	100.07	100.14	1
LG&E	ITRON	C1S	852120	05/21/2009	100.09	99.98	100.12	1
LG&E	ITRON	C1S	852121	05/21/2009	100.08	99.92	100.14	1
LG&E	ITRON	C1S	852122	05/21/2009	100.09	99.96	99.95	1
LG&E	ITRON	C1S	852123	05/21/2009	100.06	99.91	100.09	1
LG&E	ITRON	C1S	852124	05/21/2009	100.09	99.90	100.09	1
LG&E	ITRON	C1S	852125	05/21/2009	100.10	100.04	100.02	1
LG&E	ITRON	C1S	852126	05/21/2009	100.06	99.89	100.11	1
LG&E	ITRON	C1S	852127	05/21/2009	100.08	99.96	99.98	1
LG&E	ITRON	C1S	852128	05/21/2009	100.05	99.94	100.02	1
LG&E	ITRON	C1S	852129	05/21/2009	100.09	100.01	100.16	1

LG&E	ITRON	C1S	852130	05/21/2009	100.06	99.89	100.08	1
LG&E	ITRON	C1S	852131	05/21/2009	100.05	99.91	100.09	1
LG&E	ITRON	C1S	852132	05/21/2009	100.07	100.00	100.10	1
LG&E	ITRON	C1S	852133	05/21/2009	100.06	99.97	100.09	1
LG&E	ITRON	C1S	852134	05/21/2009	100.09	99.97	99.94	1
LG&E	ITRON	C1S	852135	05/21/2009	100.08	99.98	100.01	1
LG&E	ITRON	C1S	852136	05/21/2009	100.09	100.05	100.19	1
LG&E	ITRON	C1S	852137	05/21/2009	100.06	99.94	99.99	1
LG&E	ITRON	C1S	852138	05/21/2009	100.06	99.94	100.09	1
LG&E	ITRON	C1S	852139	05/21/2009	100.07	99.92	100.09	1
LG&E	ITRON	C1S	852140	05/21/2009	100.10	100.01	100.11	1
LG&E	ITRON	C1S	852141	05/21/2009	100.08	99.94	100.13	1
LG&E	ITRON	C1S	852142	05/21/2009	100.08	99.93	100.07	1
LG&E	ITRON	C1S	852143	05/21/2009	100.07	100.01	100.23	1
LG&E	ITRON	C1S	852144	05/21/2009	100.08	99.95	99.93	1
LG&E	ITRON	C1S	852145	05/21/2009	100.07	100.09	100.15	1
LG&E	ITRON	C1S	852146	05/21/2009	100.07	99.93	100.15	1
LG&E	ITRON	C1S	852147	05/21/2009	100.06	99.99	100.15	1
LG&E	ITRON	C1S	852148	05/21/2009	100.06	99.89	100.15	1
LG&E	ITRON	C1S	852149	05/21/2009	100.06	99.89	100.08	1
LG&E	ITRON	C1S	852150	05/21/2009	100.09	99.96	100.09	1
LG&E	ITRON	C1S	852151	05/21/2009	100.06	100.00	99.91	1
LG&E	ITRON	C1S	852152	05/21/2009	100.10	99.93	100.11	1
LG&E	ITRON	C1S	852153	05/21/2009	100.09	100.07	100.15	1
LG&E	ITRON	C1S	852154	05/21/2009	100.10	99.98	100.18	1
LG&E	ITRON	C1S	852155	05/21/2009	100.06	99.98	100.02	1
LG&E	ITRON	C1S	852156	05/21/2009	100.09	99.96	100.08	1
LG&E	ITRON	C1S	852157	05/21/2009	100.09	100.00	100.09	1
LG&E	ITRON	C1S	852158	05/21/2009	100.11	99.98	100.06	1
LG&E	ITRON	C1S	852159	05/21/2009	100.07	99.95	100.03	1
LG&E	ITRON	C1S	852160	05/21/2009	100.05	99.94	100.06	1
LG&E	ITRON	C1S	852161	05/21/2009	100.07	99.91	99.95	1
LG&E	ITRON	C1S	852162	05/21/2009	100.09	99.95	100.15	1
LG&E	ITRON	C1S	852163	05/21/2009	100.08	100.02	100.07	1
LG&E	ITRON	C1S	852164	05/21/2009	100.09	100.01	100.05	1

LG&E	ITRON	C1S	852165	05/21/2009	100.07	100.00	99.93	1
LG&E	ITRON	C1S	852166	05/21/2009	100.08	99.97	100.01	1
LG&E	ITRON	C1S	852167	05/21/2009	100.06	100.08	100.20	1
LG&E	ITRON	C1S	852168	05/21/2009	100.06	99.92	100.02	1
LG&E	ITRON	C1S	852169	05/21/2009	100.09	100.10	100.24	1
LG&E	ITRON	C1S	852170	05/21/2009	100.06	99.97	100.08	1
LG&E	ITRON	C1S	852171	05/21/2009	100.07	99.99	100.11	1
LG&E	ITRON	C1S	852172	05/21/2009	100.09	100.00	100.11	1
LG&E	ITRON	C1S	852173	05/21/2009	100.05	99.93	100.00	1
LG&E	ITRON	C1S	852174	05/21/2009	100.07	100.01	99.99	1
LG&E	ITRON	C1S	852175	05/21/2009	100.06	99.99	99.95	1
LG&E	ITRON	C1S	852176	05/21/2009	100.06	99.96	99.98	1
LG&E	ITRON	C1S	852177	05/21/2009	100.06	99.84	100.12	1
LG&E	ITRON	C1S	852178	05/21/2009	100.09	99.93	100.13	1
LG&E	ITRON	C1S	852179	05/21/2009	100.06	99.87	100.01	1
LG&E	ITRON	C1S	852180	05/21/2009	100.09	99.95	99.98	1
LG&E	ITRON	C1S	852181	05/21/2009	100.08	100.05	100.20	1
LG&E	ITRON	C1S	852182	05/21/2009	100.10	99.96	100.13	1
LG&E	ITRON	C1S	852183	05/21/2009	100.05	100.03	100.14	1
LG&E	ITRON	C1S	852184	05/21/2009	100.09	99.90	100.10	1
LG&E	ITRON	C1S	852185	05/21/2009	100.07	100.00	100.12	1
LG&E	ITRON	C1S	852186	05/21/2009	100.06	99.92	100.04	1
LG&E	ITRON	C1S	852187	05/21/2009	100.10	100.10	100.15	1
LG&E	ITRON	C1S	852188	05/21/2009	100.09	100.06	100.22	1
LG&E	ITRON	C1S	852189	05/21/2009	100.10	100.07	100.00	1
LG&E	ITRON	C1S	852190	05/21/2009	100.09	100.00	100.19	1
LG&E	ITRON	C1S	852191	05/21/2009	100.05	100.05	100.08	1
LG&E	ITRON	C1S	852192	05/21/2009	100.08	99.85	100.08	1
LG&E	ITRON	C1S	852193	05/21/2009	100.07	99.94	99.97	1
LG&E	ITRON	C1S	852194	05/21/2009	100.07	99.95	100.07	1
LG&E	ITRON	C1S	852195	05/21/2009	100.06	100.06	100.13	1
LG&E	ITRON	C1S	852196	05/21/2009	100.05	99.95	99.87	1
LG&E	ITRON	C1S	852197	05/21/2009	100.05	99.93	100.08	1
LG&E	ITRON	C1S	852198	05/21/2009	100.09	100.06	100.17	1
LG&E	ITRON	C1S	852199	05/21/2009	100.05	100.00	100.14	1

LG&E	ITRON	C1S	852200	05/21/2009	100.09	99.93	100.11	1
LG&E	ITRON	C1S	852201	05/21/2009	100.06	99.95	99.93	1
LG&E	ITRON	C1S	852202	05/21/2009	100.09	99.98	99.99	1
LG&E	ITRON	C1S	852203	05/21/2009	100.09	100.03	100.27	1
LG&E	ITRON	C1S	852204	05/21/2009	100.08	100.06	100.17	1
LG&E	ITRON	C1S	852205	05/21/2009	100.09	99.96	100.03	1
LG&E	ITRON	C1S	852206	05/21/2009	100.08	99.95	99.93	1
LG&E	ITRON	C1S	852207	05/21/2009	100.07	99.93	100.12	1
LG&E	ITRON	C1S	852208	05/21/2009	100.08	100.00	99.98	1
LG&E	ITRON	C1S	852209	05/21/2009	100.07	99.95	100.01	1
LG&E	ITRON	C1S	852210	05/21/2009	100.10	99.96	100.03	1
LG&E	ITRON	C1S	852211	05/21/2009	100.06	99.93	100.12	1
LG&E	ITRON	C1S	852212	05/21/2009	100.08	100.07	100.18	1
LG&E	ITRON	C1S	852213	05/21/2009	100.10	99.97	100.10	1
LG&E	ITRON	C1S	852214	05/21/2009	100.06	99.95	100.12	1
LG&E	ITRON	C1S	852215	05/21/2009	100.06	100.05	100.10	1
LG&E	ITRON	C1S	852216	05/21/2009	100.09	99.95	99.93	1
LG&E	ITRON	C1S	852217	05/21/2009	100.07	99.87	100.07	1
LG&E	ITRON	C1S	852218	05/21/2009	100.10	100.02	100.18	1
LG&E	ITRON	C1S	852219	05/21/2009	100.05	99.93	99.99	1
LG&E	ITRON	C1S	852220	05/21/2009	100.06	100.02	100.15	1
LG&E	ITRON	C1S	852221	05/21/2009	100.08	99.94	100.20	1
LG&E	ITRON	C1S	852222	05/21/2009	100.06	99.90	100.13	1
LG&E	ITRON	C1S	852223	05/21/2009	100.09	100.01	100.11	1
LG&E	ITRON	C1S	852224	05/21/2009	100.06	99.97	100.04	1
LG&E	ITRON	C1S	852225	05/21/2009	100.09	100.12	100.11	1
LG&E	ITRON	C1S	852226	05/21/2009	100.07	99.97	100.09	1
LG&E	ITRON	C1S	852227	05/21/2009	100.09	99.92	100.03	1
LG&E	ITRON	C1S	852228	05/21/2009	100.08	99.98	100.03	1
LG&E	ITRON	C1S	852229	05/21/2009	100.09	100.07	100.08	1
LG&E	ITRON	C1S	852230	05/21/2009	100.09	99.97	100.06	1
LG&E	ITRON	C1S	852231	05/21/2009	100.09	99.97	100.02	1
LG&E	ITRON	C1S	852232	05/21/2009	100.06	99.94	100.11	1
LG&E	ITRON	C1S	852233	05/21/2009	100.08	99.98	99.97	1
LG&E	ITRON	C1S	852234	05/21/2009	100.09	100.11	100.22	1

LG&E	ITRON	C1S	852235	05/21/2009	100.09	99.95	100.15	1
LG&E	ITRON	C1S	852236	05/21/2009	100.11	100.00	100.00	1
LG&E	ITRON	C1S	852237	05/21/2009	100.08	100.02	100.19	1
LG&E	ITRON	C1S	852238	05/21/2009	100.07	99.92	100.04	1
LG&E	ITRON	C1S	852239	05/21/2009	100.09	100.08	100.21	1
LG&E	ITRON	C1S	852240	05/21/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	852241	05/21/2009	100.06	100.06	100.10	1
LG&E	ITRON	C1S	852242	05/21/2009	100.09	99.95	100.16	1
LG&E	ITRON	C1S	852243	05/21/2009	100.07	99.98	100.01	1
LG&E	ITRON	C1S	852244	05/21/2009	100.06	99.82	99.95	1
LG&E	ITRON	C1S	852245	05/21/2009	100.06	100.05	100.02	1
LG&E	ITRON	C1S	852246	05/21/2009	100.07	100.02	100.05	1
LG&E	ITRON	C1S	852247	05/21/2009	100.11	99.99	100.10	1
LG&E	ITRON	C1S	852248	05/21/2009	100.10	99.96	100.04	1
LG&E	ITRON	C1S	852249	05/21/2009	100.07	100.00	100.16	1
LG&E	ITRON	C1S	852250	05/21/2009	100.06	99.92	100.04	1
LG&E	ITRON	C1S	852251	05/21/2009	100.06	99.99	100.06	1
LG&E	ITRON	C1S	852252	05/21/2009	100.06	100.02	100.21	1
LG&E	ITRON	C1S	852253	05/21/2009	100.06	99.97	100.19	1
LG&E	ITRON	C1S	852254	05/21/2009	100.09	99.92	100.01	1
LG&E	ITRON	C1S	852255	05/21/2009	100.10	100.09	100.19	1
LG&E	ITRON	C1S	852256	05/21/2009	100.10	100.00	100.07	1
LG&E	ITRON	C1S	852257	05/21/2009	100.07	99.94	100.06	1
LG&E	ITRON	C1S	852258	05/21/2009	100.08	99.94	100.04	1
LG&E	ITRON	C1S	852259	05/21/2009	100.06	99.91	100.12	1
LG&E	ITRON	C1S	852260	05/21/2009	100.05	99.85	100.13	1
LG&E	ITRON	C1S	852261	05/21/2009	100.06	100.10	100.14	1
LG&E	ITRON	C1S	852262	05/21/2009	100.09	99.94	100.01	1
LG&E	ITRON	C1S	852263	05/21/2009	100.10	100.06	100.21	1
LG&E	ITRON	C1S	852264	05/21/2009	100.09	99.88	100.10	1
LG&E	ITRON	C1S	852265	05/21/2009	100.07	99.92	100.07	1
LG&E	ITRON	C1S	852266	05/21/2009	100.09	100.04	100.04	1
LG&E	ITRON	C1S	852267	05/21/2009	100.09	100.07	100.20	1
LG&E	ITRON	C1S	852268	05/21/2009	100.06	99.93	99.89	1
LG&E	ITRON	C1S	852269	05/21/2009	100.09	99.96	100.05	1

LG&E	ITRON	CIS	852270	05/21/2009	100.08	100.01	100.13	1
LG&E	ITRON	CIS	852271	05/21/2009	100.10	99.99	99.98	1
LG&E	ITRON	CIS	852272	05/21/2009	100.08	100.05	100.05	1
LG&E	ITRON	CIS	852273	05/21/2009	100.10	99.94	100.14	1
LG&E	ITRON	CIS	852274	05/21/2009	100.08	100.04	100.11	1
LG&E	ITRON	CIS	852275	05/21/2009	100.10	100.08	100.14	1
LG&E	ITRON	CIS	852276	05/21/2009	100.08	100.02	100.14	1
LG&E	ITRON	CIS	852277	05/21/2009	100.08	99.97	99.98	1
LG&E	ITRON	CIS	852278	05/21/2009	100.08	99.93	99.99	1
LG&E	ITRON	CIS	852279	05/21/2009	100.07	99.90	100.14	1
LG&E	ITRON	CIS	852280	05/21/2009	100.08	99.90	100.16	1
LG&E	ITRON	CIS	852281	05/21/2009	100.10	100.03	100.18	1
LG&E	ITRON	CIS	852282	05/21/2009	100.07	99.96	100.09	1
LG&E	ITRON	CIS	852283	05/21/2009	100.05	100.03	100.14	1
LG&E	ITRON	CIS	852284	05/21/2009	100.08	99.89	100.09	1
LG&E	ITRON	CIS	852285	05/21/2009	100.05	99.93	100.00	1
LG&E	ITRON	CIS	852286	05/21/2009	100.10	100.10	100.20	1
LG&E	ITRON	CIS	852287	05/21/2009	100.09	100.08	100.18	1
LG&E	ITRON	CIS	852288	05/21/2009	100.08	100.06	100.12	1
LG&E	ITRON	CIS	852289	05/21/2009	100.08	100.01	100.03	1
LG&E	ITRON	CIS	852290	05/21/2009	100.06	99.94	100.03	1
LG&E	ITRON	CIS	852291	05/21/2009	100.08	99.91	100.03	1
LG&E	ITRON	CIS	852292	05/21/2009	100.06	99.97	100.14	1
LG&E	ITRON	CIS	852293	05/21/2009	100.10	99.91	100.12	1
LG&E	ITRON	CIS	852294	05/21/2009	100.10	99.97	100.15	1
LG&E	ITRON	CIS	852295	05/21/2009	100.08	99.99	100.10	1
LG&E	ITRON	CIS	852296	05/21/2009	100.09	99.96	100.08	1
LG&E	ITRON	CIS	852297	05/21/2009	100.06	99.97	100.00	1
LG&E	ITRON	CIS	852298	05/21/2009	100.05	99.96	100.06	1
LG&E	ITRON	CIS	852299	05/21/2009	100.10	100.13	100.15	1
LG&E	ITRON	CIS	852300	05/21/2009	100.09	100.03	100.13	1
LG&E	ITRON	CIS	852301	05/21/2009	100.08	99.91	100.14	1
LG&E	ITRON	CIS	852302	05/21/2009	100.07	99.99	100.00	1
LG&E	ITRON	CIS	852303	05/21/2009	100.10	100.09	100.22	1
LG&E	ITRON	CIS	852304	05/21/2009	100.07	99.95	99.97	1

LG&E	ITRON	C1S	852305	05/21/2009	100.05	100.04	100.17	1
LG&E	ITRON	C1S	852306	05/21/2009	100.07	100.01	100.13	1
LG&E	ITRON	C1S	852307	05/21/2009	100.07	99.95	99.96	1
LG&E	ITRON	C1S	852308	05/21/2009	100.08	99.99	100.05	1
LG&E	ITRON	C1S	852309	05/21/2009	100.06	99.94	99.93	1
LG&E	ITRON	C1S	852310	05/21/2009	100.08	99.93	100.06	1
LG&E	ITRON	C1S	852311	05/21/2009	100.09	100.12	100.17	1
LG&E	ITRON	C1S	852312	05/21/2009	100.09	100.03	100.14	1
LG&E	ITRON	C1S	852313	05/21/2009	100.09	100.03	100.11	1
LG&E	ITRON	C1S	852314	05/21/2009	100.09	99.98	99.95	1
LG&E	ITRON	C1S	852315	05/21/2009	100.10	99.97	100.14	1
LG&E	ITRON	C1S	852316	05/21/2009	100.08	100.00	100.01	1
LG&E	ITRON	C1S	852317	05/21/2009	100.06	99.91	99.99	1
LG&E	ITRON	C1S	852318	05/21/2009	100.09	100.08	100.09	1
LG&E	ITRON	C1S	852319	05/21/2009	100.07	99.99	100.10	1
LG&E	ITRON	C1S	852320	05/21/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1S	852321	05/21/2009	100.07	100.05	100.12	1
LG&E	ITRON	C1S	852322	05/21/2009	100.08	100.10	100.20	1
LG&E	ITRON	C1S	852323	05/21/2009	100.07	99.99	99.97	1
LG&E	ITRON	C1S	852324	05/21/2009	100.08	100.01	100.08	1
LG&E	ITRON	C1S	852325	05/21/2009	100.09	100.07	100.08	1
LG&E	ITRON	C1S	852326	05/21/2009	100.06	100.01	100.02	1
LG&E	ITRON	C1S	852327	05/21/2009	100.08	99.98	99.89	1
LG&E	ITRON	C1S	852328	05/21/2009	100.07	99.97	100.08	1
LG&E	ITRON	C1S	852329	05/21/2009	100.10	99.97	99.89	1
LG&E	ITRON	C1S	852330	05/21/2009	100.08	99.92	100.03	1
LG&E	ITRON	C1S	852331	05/21/2009	100.06	99.97	100.08	1
LG&E	ITRON	C1S	852332	05/21/2009	100.06	99.95	100.01	1
LG&E	ITRON	C1S	852333	05/21/2009	100.09	100.08	100.18	1
LG&E	ITRON	C1S	852334	05/21/2009	100.08	100.07	100.18	1
LG&E	ITRON	C1S	852335	05/21/2009	100.10	100.04	100.18	1
LG&E	ITRON	C1S	852336	05/21/2009	100.08	99.92	100.02	1
LG&E	ITRON	C1S	852337	05/21/2009	100.06	99.91	100.00	1
LG&E	ITRON	C1S	852338	05/21/2009	100.06	99.86	100.05	1
LG&E	ITRON	C1S	852339	05/21/2009	100.10	99.96	100.05	1

LG&E	ITRON	C1S	852340	05/21/2009	100.08	99.96	100.17	1
LG&E	ITRON	C1S	852341	05/21/2009	100.07	99.94	100.10	1
LG&E	ITRON	C1S	852342	05/21/2009	100.08	99.94	100.04	1
LG&E	ITRON	C1S	852343	05/21/2009	100.06	99.86	100.04	1
LG&E	ITRON	C1S	852344	05/21/2009	100.08	99.86	100.05	1
LG&E	ITRON	C1S	852345	05/21/2009	100.06	100.01	100.05	1
LG&E	ITRON	C1S	852346	05/21/2009	100.09	99.96	100.17	1
LG&E	ITRON	C1S	852347	05/21/2009	100.08	100.10	100.22	1
LG&E	ITRON	C1S	852348	05/21/2009	100.09	99.97	99.89	1
LG&E	ITRON	C1S	852349	05/21/2009	100.09	100.01	100.23	1
LG&E	ITRON	C1S	852350	05/21/2009	100.07	99.96	100.13	1
LG&E	ITRON	C1S	852351	05/21/2009	100.07	99.95	100.03	1
LG&E	ITRON	C1S	852352	05/21/2009	100.08	99.96	99.94	1
LG&E	ITRON	C1S	852353	05/21/2009	100.09	99.97	100.11	1
LG&E	ITRON	C1S	852354	05/21/2009	100.07	99.85	100.08	1
LG&E	ITRON	C1S	852355	05/21/2009	100.08	100.05	100.09	1
LG&E	ITRON	C1S	852356	05/21/2009	100.05	99.90	100.08	1
LG&E	ITRON	C1S	852357	05/21/2009	100.10	100.10	100.10	1
LG&E	ITRON	C1S	852358	05/21/2009	100.09	100.07	100.18	1
LG&E	ITRON	C1S	852359	05/21/2009	100.08	100.02	100.10	1
LG&E	ITRON	C1S	852360	05/21/2009	100.08	100.11	100.14	1
LG&E	ITRON	C1S	852361	05/21/2009	100.09	100.15	100.14	1
LG&E	ITRON	C1S	852362	05/21/2009	100.05	99.84	100.00	1
LG&E	ITRON	C1S	852363	05/21/2009	100.10	100.01	100.06	1
LG&E	ITRON	C1S	852364	05/21/2009	100.10	100.05	100.07	1
LG&E	ITRON	C1S	852365	05/21/2009	100.05	100.00	100.12	1
LG&E	ITRON	C1S	852366	05/21/2009	100.07	100.02	100.19	1
LG&E	ITRON	C1S	852367	05/21/2009	100.07	100.10	100.17	1
LG&E	ITRON	C1S	852368	05/21/2009	100.09	99.99	100.08	1
LG&E	ITRON	C1S	852369	05/21/2009	100.09	100.03	100.13	1
LG&E	ITRON	C1S	852370	05/21/2009	100.09	100.06	100.17	1
LG&E	ITRON	C1S	852371	05/21/2009	100.08	100.05	100.13	1
LG&E	ITRON	C1S	852372	05/21/2009	100.06	99.91	100.07	1
LG&E	ITRON	C1S	852373	05/21/2009	100.08	100.06	100.17	1
LG&E	ITRON	C1S	852374	05/21/2009	100.06	99.95	99.98	1

LG&E	ITRON	C1S	852375	05/21/2009	100.09	99.94	99.88	1
LG&E	ITRON	C1S	852376	05/21/2009	100.07	100.04	100.18	1
LG&E	ITRON	C1S	852377	05/21/2009	100.07	99.90	100.00	1
LG&E	ITRON	C1S	852378	05/21/2009	100.07	100.00	100.14	1
LG&E	ITRON	C1S	852379	05/21/2009	100.07	100.06	100.15	1
LG&E	ITRON	C1S	852380	05/21/2009	100.09	99.95	100.09	1
LG&E	ITRON	C1S	852381	05/21/2009	100.06	99.94	100.02	1
LG&E	ITRON	C1S	852382	05/21/2009	100.05	99.93	100.07	1
LG&E	ITRON	C1S	852383	05/21/2009	100.06	99.98	99.99	1
LG&E	ITRON	C1S	852384	05/21/2009	100.06	99.99	100.00	1
LG&E	ITRON	C1S	852385	05/21/2009	100.06	100.04	100.17	1
LG&E	ITRON	C1S	852386	05/21/2009	100.06	99.99	99.85	1
LG&E	ITRON	C1S	852387	05/21/2009	100.10	100.11	100.20	1
LG&E	ITRON	C1S	852388	05/21/2009	100.08	100.03	100.17	1
LG&E	ITRON	C1S	852389	05/21/2009	100.06	99.96	99.89	1
LG&E	ITRON	C1S	852390	05/21/2009	100.09	99.93	99.97	1
LG&E	ITRON	C1S	852391	05/21/2009	100.10	100.01	100.03	1
LG&E	ITRON	C1S	852392	05/21/2009	100.08	100.00	100.19	1
LG&E	ITRON	C1S	852393	05/21/2009	100.10	100.08	100.17	1
LG&E	ITRON	C1S	852394	05/21/2009	100.06	99.93	99.98	1
LG&E	ITRON	C1S	852395	05/21/2009	100.10	99.98	100.02	1
LG&E	ITRON	C1S	852396	05/21/2009	100.09	100.11	100.13	1
LG&E	ITRON	C1S	852397	05/21/2009	100.09	99.92	100.05	1
LG&E	ITRON	C1S	852398	05/21/2009	100.09	100.01	100.19	1
LG&E	ITRON	C1S	852399	05/21/2009	100.10	100.06	100.17	1
LG&E	ITRON	C1S	852400	05/21/2009	100.06	99.95	99.94	1
LG&E	ITRON	C1S	852401	05/21/2009	100.09	100.03	100.16	1
LG&E	ITRON	C1S	852402	05/21/2009	100.09	100.06	100.14	1
LG&E	ITRON	C1S	852403	05/21/2009	100.07	99.96	100.17	1
LG&E	ITRON	C1S	852404	05/21/2009	100.07	99.85	100.15	1
LG&E	ITRON	C1S	852405	05/21/2009	100.10	99.91	100.16	1
LG&E	ITRON	C1S	852406	05/21/2009	100.08	99.88	100.12	1
LG&E	ITRON	C1S	852407	05/21/2009	100.06	99.94	100.17	1
LG&E	ITRON	C1S	852408	05/21/2009	100.10	100.00	100.06	1
LG&E	ITRON	C1S	852409	05/21/2009	100.07	99.91	100.10	1

LG&E	ITRON	C1S	852410	05/21/2009	100.06	99.97	100.09	1
LG&E	ITRON	C1S	852411	05/21/2009	100.07	99.92	100.03	1
LG&E	ITRON	C1S	852412	05/21/2009	100.06	99.95	99.94	1
LG&E	ITRON	C1S	852413	05/21/2009	100.08	99.98	99.91	1
LG&E	ITRON	C1S	852414	05/21/2009	100.08	100.11	100.20	1
LG&E	ITRON	C1S	852415	05/21/2009	100.09	99.92	100.03	1
LG&E	ITRON	C1S	852416	05/21/2009	100.05	100.03	100.05	1
LG&E	ITRON	C1S	852417	05/21/2009	100.08	99.93	100.12	1
LG&E	ITRON	C1S	852418	05/21/2009	100.06	99.91	99.88	1
LG&E	ITRON	C1S	852419	05/21/2009	100.09	100.00	100.14	1
LG&E	ITRON	C1S	852420	05/21/2009	100.06	99.96	99.99	1
LG&E	ITRON	C1S	852421	05/21/2009	100.10	100.08	100.15	1
LG&E	ITRON	C1S	852422	05/21/2009	100.10	99.98	100.14	1
LG&E	ITRON	C1S	852423	05/21/2009	100.08	99.97	100.01	1
LG&E	ITRON	C1S	852424	05/21/2009	100.06	99.98	100.02	1
LG&E	ITRON	C1S	852425	05/21/2009	100.08	99.90	99.99	1
LG&E	ITRON	C1S	852426	05/21/2009	100.07	99.88	100.05	1
LG&E	ITRON	C1S	852427	05/21/2009	100.08	99.96	100.05	1
LG&E	ITRON	C1S	852428	05/21/2009	100.10	100.04	100.09	1
LG&E	ITRON	C1S	852429	05/21/2009	100.07	100.02	100.00	1
LG&E	ITRON	C1S	852430	05/21/2009	100.08	99.96	100.00	1
LG&E	ITRON	C1S	852431	05/21/2009	100.06	99.97	100.12	1
LG&E	ITRON	C1S	852432	05/21/2009	100.06	99.97	100.17	1
LG&E	ITRON	C1S	852433	05/21/2009	100.07	100.04	100.17	1
LG&E	ITRON	C1S	852434	05/21/2009	100.08	100.06	100.11	1
LG&E	ITRON	C1S	852435	05/21/2009	100.10	99.93	100.06	1
LG&E	ITRON	C1S	852436	05/21/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	852437	05/21/2009	100.08	100.02	100.00	1
LG&E	ITRON	C1S	852438	05/21/2009	100.07	100.07	100.21	1
LG&E	ITRON	C1S	852439	05/21/2009	100.08	99.91	100.06	1
LG&E	ITRON	C1S	852440	05/21/2009	100.10	99.97	100.14	1
LG&E	ITRON	C1S	852441	05/21/2009	100.10	100.00	100.23	1
LG&E	ITRON	C1S	852442	05/21/2009	100.08	99.93	100.07	1
LG&E	ITRON	C1S	852443	05/21/2009	100.07	99.97	100.01	1
LG&E	ITRON	C1S	852444	05/21/2009	100.05	99.96	99.97	1

LG&E	ITRON	C1S	852445	05/21/2009	100.10	100.05	100.07	1
LG&E	ITRON	C1S	852446	05/21/2009	100.10	99.95	100.22	1
LG&E	ITRON	C1S	852447	05/21/2009	100.05	100.05	100.12	1
LG&E	ITRON	C1S	852448	05/21/2009	100.11	99.90	100.10	1
LG&E	ITRON	C1S	852449	05/21/2009	100.08	100.01	100.19	1
LG&E	ITRON	C1S	852450	05/21/2009	100.05	99.98	100.06	1
LG&E	ITRON	C1S	852451	05/21/2009	100.09	100.09	100.27	1
LG&E	ITRON	C1S	852452	05/21/2009	100.09	100.04	100.23	1
LG&E	ITRON	C1S	852453	05/21/2009	100.09	99.95	100.11	1
LG&E	ITRON	C1S	852454	05/21/2009	100.07	99.94	100.01	1
LG&E	ITRON	C1S	852455	05/21/2009	100.08	100.00	99.99	1
LG&E	ITRON	C1S	852456	05/21/2009	100.07	100.05	99.95	1
LG&E	ITRON	C1S	852457	05/21/2009	100.09	100.08	100.12	1
LG&E	ITRON	C1S	852458	05/21/2009	100.10	100.02	100.19	1
LG&E	ITRON	C1S	852459	05/21/2009	100.07	100.12	100.10	1
LG&E	ITRON	C1S	852460	05/21/2009	100.07	99.99	100.13	1
LG&E	ITRON	C1S	852461	05/21/2009	100.05	99.98	100.19	1
LG&E	ITRON	C1S	852462	05/21/2009	100.08	100.00	100.12	1
LG&E	ITRON	C1S	852463	05/21/2009	100.05	99.90	100.12	1
LG&E	ITRON	C1S	852464	05/21/2009	100.09	100.04	100.14	1
LG&E	ITRON	C1S	852465	05/21/2009	100.05	99.97	100.14	1
LG&E	ITRON	C1S	852466	05/21/2009	100.07	99.94	100.11	1
LG&E	ITRON	C1S	852467	05/21/2009	100.08	99.98	100.05	1
LG&E	ITRON	C1S	852468	05/21/2009	100.05	99.96	99.89	1
LG&E	ITRON	C1S	852469	05/21/2009	100.08	100.07	100.13	1
LG&E	ITRON	C1S	852470	05/21/2009	100.06	99.99	99.97	1
LG&E	ITRON	C1S	852471	05/21/2009	100.10	100.02	99.99	1
LG&E	ITRON	C1S	852472	05/21/2009	100.06	100.14	100.18	1
LG&E	ITRON	C1S	852473	05/21/2009	100.08	100.01	100.01	1
LG&E	ITRON	C1S	852474	05/21/2009	100.07	100.11	100.22	1
LG&E	ITRON	C1S	852475	05/21/2009	100.06	99.92	100.00	1
LG&E	ITRON	C1S	852476	05/21/2009	100.06	99.92	100.06	1
LG&E	ITRON	C1S	852477	05/21/2009	100.06	99.95	100.09	1
LG&E	ITRON	C1S	852478	05/21/2009	100.06	99.90	99.97	1
LG&E	ITRON	C1S	852479	05/21/2009	100.06	100.08	100.06	1

LG&E	ITRON	C1S	852480	05/21/2009	100.08	100.08	100.08	100.22	1
LG&E	ITRON	C1S	852481	05/21/2009	100.10	99.97	100.14	1	
LG&E	ITRON	C1S	852482	05/21/2009	100.08	100.11	100.18	1	
LG&E	ITRON	C1S	852483	05/21/2009	100.09	99.98	100.10	1	
LG&E	ITRON	C1S	852484	05/21/2009	100.06	99.94	99.95	1	
LG&E	ITRON	C1S	852485	05/21/2009	100.06	100.02	100.16	1	
LG&E	ITRON	C1S	852486	05/21/2009	100.08	99.92	100.11	1	
LG&E	ITRON	C1S	852487	05/21/2009	100.08	99.97	100.12	1	
LG&E	ITRON	C1S	852488	05/21/2009	100.07	99.93	100.03	1	
LG&E	ITRON	C1S	852489	05/21/2009	100.07	99.95	99.97	1	
LG&E	ITRON	C1S	852490	05/21/2009	100.07	99.99	100.13	1	
LG&E	ITRON	C1S	852491	05/21/2009	100.10	99.96	100.08	1	
LG&E	ITRON	C1S	852492	05/21/2009	100.10	100.05	100.16	1	
LG&E	ITRON	C1S	852493	05/21/2009	100.06	99.94	100.00	1	
LG&E	ITRON	C1S	852494	05/21/2009	100.07	99.97	99.97	1	
LG&E	ITRON	C1S	852495	05/21/2009	100.08	100.04	100.20	1	
LG&E	ITRON	C1S	852496	05/21/2009	100.06	100.02	100.12	1	
LG&E	ITRON	C1S	852497	05/21/2009	100.07	100.10	100.16	1	
LG&E	ITRON	C1S	852498	05/21/2009	100.08	99.92	100.07	1	
LG&E	ITRON	C1S	852499	05/21/2009	100.08	99.93	100.13	1	
LG&E	ITRON	C1S	852500	05/21/2009	100.06	100.03	100.10	1	
LG&E	ITRON	C1S	852501	05/21/2009	100.07	100.00	100.00	1	
LG&E	ITRON	C1S	852502	05/21/2009	100.06	100.03	100.15	1	
LG&E	ITRON	C1S	852503	05/21/2009	100.08	99.90	100.10	1	
LG&E	ITRON	C1S	852504	05/21/2009	100.06	99.94	100.07	1	
LG&E	ITRON	C1S	852505	05/21/2009	100.06	100.04	100.14	1	
LG&E	ITRON	C1S	852506	05/21/2009	100.10	99.90	100.09	1	
LG&E	ITRON	C1S	852507	05/21/2009	100.06	99.88	100.05	1	
LG&E	ITRON	C1S	852508	05/21/2009	100.08	99.94	100.12	1	
LG&E	ITRON	C1S	852509	05/21/2009	100.07	99.93	100.10	1	
LG&E	ITRON	C1S	852510	05/21/2009	100.08	99.99	100.19	1	
LG&E	ITRON	C1S	852511	05/21/2009	100.06	100.08	100.17	1	
LG&E	ITRON	C1S	852512	05/21/2009	100.06	99.92	99.90	1	
LG&E	ITRON	C1S	852513	05/21/2009	100.10	100.01	100.09	1	
LG&E	ITRON	C1S	852514	05/21/2009	100.08	99.98	100.04	1	

LG&E	ITRON	C1S	852515	05/21/2009	100.07	99.93	100.09	1
LG&E	ITRON	C1S	852516	05/21/2009	100.07	100.02	100.06	1
LG&E	ITRON	C1S	852517	05/21/2009	100.05	99.93	100.05	1
LG&E	ITRON	C1S	852518	05/21/2009	100.06	99.94	100.06	1
LG&E	ITRON	C1S	852519	05/21/2009	100.08	100.01	100.06	1
LG&E	ITRON	C1S	852520	05/21/2009	100.05	100.02	100.14	1
LG&E	ITRON	C1S	852521	05/21/2009	100.09	99.95	100.12	1
LG&E	ITRON	C1S	852522	05/21/2009	100.09	99.93	100.04	1
LG&E	ITRON	C1S	852523	05/21/2009	100.09	99.91	100.16	1
LG&E	ITRON	C1S	852524	05/21/2009	100.06	99.92	100.05	1
LG&E	ITRON	C1S	852525	05/21/2009	100.08	99.91	100.08	1
LG&E	ITRON	C1S	852526	05/21/2009	100.10	100.03	99.96	1
LG&E	ITRON	C1S	852527	05/21/2009	100.07	99.98	100.14	1
LG&E	ITRON	C1S	852528	05/21/2009	100.06	99.98	100.06	1
LG&E	ITRON	C1S	852529	05/21/2009	100.06	100.08	100.14	1
LG&E	ITRON	C1S	852530	05/21/2009	100.10	99.97	100.19	1
LG&E	ITRON	C1S	852531	05/21/2009	100.09	99.91	100.11	1
LG&E	ITRON	C1S	852532	05/21/2009	100.10	100.00	100.15	1
LG&E	ITRON	C1S	852533	05/21/2009	100.06	100.11	100.13	1
LG&E	ITRON	C1S	852534	05/21/2009	100.09	99.92	100.10	1
LG&E	ITRON	C1S	852535	05/21/2009	100.07	99.92	100.05	1
LG&E	ITRON	C1S	852536	05/21/2009	100.05	100.05	100.04	1
LG&E	ITRON	C1S	852537	05/21/2009	100.05	100.03	100.17	1
LG&E	ITRON	C1S	852538	05/21/2009	100.10	100.10	100.21	1
LG&E	ITRON	C1S	852539	05/21/2009	100.09	100.01	100.06	1
LG&E	ITRON	C1S	852540	05/21/2009	100.07	100.09	100.12	1
LG&E	ITRON	C1S	852541	05/21/2009	100.08	99.98	100.05	1
LG&E	ITRON	C1S	852542	05/21/2009	100.07	99.95	100.07	1
LG&E	ITRON	C1S	852543	05/21/2009	100.07	99.91	100.13	1
LG&E	ITRON	C1S	852544	05/21/2009	100.07	100.04	100.17	1
LG&E	ITRON	C1S	852545	05/21/2009	100.10	99.91	100.16	1
LG&E	ITRON	C1S	852546	05/21/2009	100.09	100.05	100.01	1
LG&E	ITRON	C1S	852547	05/21/2009	100.09	100.05	100.15	1
LG&E	ITRON	C1S	852548	05/21/2009	100.08	100.06	100.17	1
LG&E	ITRON	C1S	852549	05/21/2009	100.08	100.01	100.08	1

LG&E	ITRON	C1S	852550	05/21/2009	100.05	100.04	100.10	1
LG&E	ITRON	C1S	852551	05/21/2009	100.06	100.07	100.17	1
LG&E	ITRON	C1S	852552	05/21/2009	100.10	100.05	100.17	1
LG&E	ITRON	C1S	852553	05/21/2009	100.09	100.00	100.06	1
LG&E	ITRON	C1S	852554	05/21/2009	100.06	99.98	100.19	1
LG&E	ITRON	C1S	852555	05/21/2009	100.06	99.90	100.08	1
LG&E	ITRON	C1S	852556	05/21/2009	100.06	99.95	100.06	1
LG&E	ITRON	C1S	852557	05/21/2009	100.05	99.86	100.12	1
LG&E	ITRON	C1S	852558	05/21/2009	100.08	100.03	100.04	1
LG&E	ITRON	C1S	852559	05/21/2009	100.08	99.94	100.03	1
LG&E	ITRON	C1S	852560	05/21/2009	100.08	99.87	100.12	1
LG&E	ITRON	C1S	852561	05/21/2009	100.08	100.08	100.20	1
LG&E	ITRON	C1S	852562	05/21/2009	100.06	99.90	100.02	1
LG&E	ITRON	C1S	852563	05/21/2009	100.10	100.01	100.00	1
LG&E	ITRON	C1S	852564	05/21/2009	100.08	100.08	100.14	1
LG&E	ITRON	C1S	852565	05/21/2009	100.08	99.96	100.12	1
LG&E	ITRON	C1S	852566	05/21/2009	100.09	100.00	100.07	1
LG&E	ITRON	C1S	852567	05/21/2009	100.06	100.02	100.15	1
LG&E	ITRON	C1S	852568	05/21/2009	100.09	99.99	99.89	1
LG&E	ITRON	C1S	852569	05/21/2009	100.08	99.94	100.03	1
LG&E	ITRON	C1S	852570	05/21/2009	100.09	100.04	100.09	1
LG&E	ITRON	C1S	852571	05/21/2009	100.06	100.01	100.12	1
LG&E	ITRON	C1S	852572	05/21/2009	100.08	100.08	100.26	1
LG&E	ITRON	C1S	852573	05/21/2009	100.06	99.91	100.06	1
LG&E	ITRON	C1S	852574	05/21/2009	100.05	100.04	100.14	1
LG&E	ITRON	C1S	852575	05/21/2009	100.09	100.11	100.17	1
LG&E	ITRON	C1S	852576	05/21/2009	100.05	99.96	100.03	1
LG&E	ITRON	C1S	852577	05/21/2009	100.09	99.94	100.15	1
LG&E	ITRON	C1S	852578	05/21/2009	100.06	100.01	99.90	1
LG&E	ITRON	C1S	852579	05/21/2009	100.07	99.96	100.05	1
LG&E	ITRON	C1S	852580	05/21/2009	100.06	99.93	99.87	1
LG&E	ITRON	C1S	852581	05/21/2009	100.07	100.03	100.07	1
LG&E	ITRON	C1S	852582	05/21/2009	100.08	99.99	100.04	1
LG&E	ITRON	C1S	852583	05/21/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	852584	05/21/2009	100.10	99.95	100.11	1

LG&E	ITRON	C1S	852585	05/21/2009	100.10	99.98	100.16	1
LG&E	ITRON	C1S	852586	05/21/2009	100.06	99.95	100.11	1
LG&E	ITRON	C1S	852587	05/21/2009	100.07	99.92	100.10	1
LG&E	ITRON	C1S	852588	05/21/2009	100.07	99.96	100.11	1
LG&E	ITRON	C1S	852589	05/21/2009	100.08	99.94	99.99	1
LG&E	ITRON	C1S	852590	05/21/2009	100.10	99.92	100.16	1
LG&E	ITRON	C1S	852591	05/21/2009	100.06	99.92	100.06	1
LG&E	ITRON	C1S	852592	05/21/2009	100.09	99.97	100.11	1
LG&E	ITRON	C1S	852593	05/21/2009	100.09	100.03	100.04	1
LG&E	ITRON	C1S	852594	05/21/2009	100.07	99.97	100.05	1
LG&E	ITRON	C1S	852595	05/21/2009	100.10	99.94	100.08	1
LG&E	ITRON	C1S	852596	05/21/2009	100.08	99.92	100.03	1
LG&E	ITRON	C1S	852597	05/21/2009	100.09	99.97	100.06	1
LG&E	ITRON	C1S	852598	05/21/2009	100.09	99.99	100.12	1
LG&E	ITRON	C1S	852599	05/21/2009	100.06	99.93	100.03	1
LG&E	ITRON	C1S	852600	05/21/2009	100.07	100.03	100.13	1
LG&E	ITRON	C1S	852601	05/21/2009	100.09	100.03	100.08	1
LG&E	ITRON	C1S	852602	05/21/2009	100.08	99.92	100.06	1
LG&E	ITRON	C1S	852603	05/21/2009	100.07	100.06	99.94	1
LG&E	ITRON	C1S	852604	05/21/2009	100.07	99.95	100.11	1
LG&E	ITRON	C1S	852605	05/21/2009	100.10	100.12	100.25	1
LG&E	ITRON	C1S	852606	05/21/2009	100.08	99.96	100.11	1
LG&E	ITRON	C1S	852607	05/21/2009	100.07	99.92	100.11	1
LG&E	ITRON	C1S	852608	05/21/2009	100.08	99.98	100.11	1
LG&E	ITRON	C1S	852609	05/21/2009	100.09	100.02	100.09	1
LG&E	ITRON	C1S	852610	05/21/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	852611	05/21/2009	100.05	99.88	100.08	1
LG&E	ITRON	C1S	852612	05/21/2009	100.08	99.97	100.07	1
LG&E	ITRON	C1S	852613	05/21/2009	100.07	100.03	100.20	1
LG&E	ITRON	C1S	852614	05/21/2009	100.08	99.91	100.06	1
LG&E	ITRON	C1S	852615	05/21/2009	100.08	99.94	99.88	1
LG&E	ITRON	C1S	852616	05/21/2009	100.07	100.00	100.15	1
LG&E	ITRON	C1S	852617	05/21/2009	100.09	100.01	99.99	1
LG&E	ITRON	C1S	852618	05/21/2009	100.05	100.00	100.08	1
LG&E	ITRON	C1S	852619	05/21/2009	100.06	99.83	100.08	1

LG&E	ITRON	C1S	852620	05/21/2009	100.05	99.96	100.12	1
LG&E	ITRON	C1S	852621	05/21/2009	100.06	99.94	99.97	1
LG&E	ITRON	C1S	852622	05/21/2009	100.06	100.00	100.22	1
LG&E	ITRON	C1S	852623	05/21/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	852624	05/21/2009	100.06	99.91	100.06	1
LG&E	ITRON	C1S	852625	05/21/2009	100.10	100.12	100.09	1
LG&E	ITRON	C1S	852626	05/21/2009	100.09	99.92	100.19	1
LG&E	ITRON	C1S	852627	05/21/2009	100.08	100.02	100.20	1
LG&E	ITRON	C1S	852628	05/21/2009	100.10	99.94	100.05	1
LG&E	ITRON	C1S	852629	05/21/2009	100.09	100.07	99.91	1
LG&E	ITRON	C1S	852630	05/21/2009	100.09	100.02	100.05	1
LG&E	ITRON	C1S	852631	05/21/2009	100.07	100.09	100.17	1
LG&E	ITRON	C1S	852632	05/21/2009	100.07	99.92	100.01	1
LG&E	ITRON	C1S	852633	05/21/2009	100.08	99.96	99.98	1
LG&E	ITRON	C1S	852634	05/21/2009	100.05	99.94	100.01	1
LG&E	ITRON	C1S	852635	05/21/2009	100.08	100.03	100.10	1
LG&E	ITRON	C1S	852636	05/21/2009	100.09	100.00	100.09	1
LG&E	ITRON	C1S	852637	05/21/2009	100.09	100.03	100.17	1
LG&E	ITRON	C1S	852638	05/21/2009	100.09	99.98	100.00	1
LG&E	ITRON	C1S	852639	05/21/2009	100.07	100.04	100.19	1
LG&E	ITRON	C1S	852640	05/21/2009	100.10	99.96	100.12	1
LG&E	ITRON	C1S	852641	05/21/2009	100.06	99.98	100.04	1
LG&E	ITRON	C1S	852642	05/21/2009	100.10	99.95	100.05	1
LG&E	ITRON	C1S	852643	05/21/2009	100.07	99.89	100.06	1
LG&E	ITRON	C1S	852644	05/21/2009	100.05	100.06	100.17	1
LG&E	ITRON	C1S	852645	05/21/2009	100.07	99.95	99.97	1
LG&E	ITRON	C1S	852646	05/21/2009	100.06	100.00	100.09	1
LG&E	ITRON	C1S	852647	05/21/2009	100.09	100.02	100.15	1
LG&E	ITRON	C1S	852648	05/21/2009	100.07	99.86	100.09	1
LG&E	ITRON	C1S	852649	05/21/2009	100.10	100.05	100.08	1
LG&E	ITRON	C1S	852650	05/21/2009	100.08	99.90	100.01	1
LG&E	ITRON	C1S	852651	05/21/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	852652	05/21/2009	100.09	99.96	100.11	1
LG&E	ITRON	C1S	852653	05/21/2009	100.10	99.95	100.15	1
LG&E	ITRON	C1S	852654	05/21/2009	100.06	99.93	100.03	1

LG&E	ITRON	C1S	852655	05/21/2009	100.09	100.05	100.17	1
LG&E	ITRON	C1S	852656	05/21/2009	100.10	100.02	100.10	1
LG&E	ITRON	C1S	852657	05/21/2009	100.08	100.01	100.02	1
LG&E	ITRON	C1S	852658	05/21/2009	100.05	99.90	99.93	1
LG&E	ITRON	C1S	852659	05/21/2009	100.10	99.96	100.07	1
LG&E	ITRON	C1S	852660	05/21/2009	100.06	100.02	99.92	1
LG&E	ITRON	C1S	852661	05/21/2009	100.05	100.01	100.09	1
LG&E	ITRON	C1S	852662	05/21/2009	100.08	99.91	100.12	1
LG&E	ITRON	C1S	852663	05/21/2009	100.08	100.05	100.00	1
LG&E	ITRON	C1S	852664	05/21/2009	100.09	99.94	99.99	1
LG&E	ITRON	C1S	852665	05/21/2009	100.07	100.06	100.12	1
LG&E	ITRON	C1S	852666	05/21/2009	100.08	99.94	100.03	1
LG&E	ITRON	C1S	852667	05/21/2009	100.10	100.02	100.04	1
LG&E	ITRON	C1S	852668	05/21/2009	100.08	100.07	100.16	1
LG&E	ITRON	C1S	852669	05/21/2009	100.06	99.96	100.05	1
LG&E	ITRON	C1S	852670	05/21/2009	100.06	99.90	100.05	1
LG&E	ITRON	C1S	852671	05/21/2009	100.06	99.91	100.05	1
LG&E	ITRON	C1S	852672	05/21/2009	100.09	100.02	100.02	1
LG&E	ITRON	C1S	852673	05/21/2009	100.09	100.12	100.22	1
LG&E	ITRON	C1S	852674	05/21/2009	100.07	100.03	100.17	1
LG&E	ITRON	C1S	852675	05/21/2009	100.05	100.08	100.11	1
LG&E	ITRON	C1S	852676	05/21/2009	100.09	99.96	100.16	1
LG&E	ITRON	C1S	852677	05/21/2009	100.07	100.09	100.18	1
LG&E	ITRON	C1S	852678	05/21/2009	100.07	99.99	100.09	1
LG&E	ITRON	C1S	852679	05/21/2009	100.06	99.98	100.02	1
LG&E	ITRON	C1S	852680	05/21/2009	100.06	99.89	100.10	1
LG&E	ITRON	C1S	852681	05/21/2009	100.08	99.94	100.00	1
LG&E	ITRON	C1S	852682	05/21/2009	100.08	100.06	100.17	1
LG&E	ITRON	C1S	852683	05/21/2009	100.08	100.03	100.03	1
LG&E	ITRON	C1S	852684	05/21/2009	100.06	100.08	100.09	1
LG&E	ITRON	C1S	852685	05/21/2009	100.09	99.98	100.11	1
LG&E	ITRON	C1S	852686	05/21/2009	100.08	99.96	100.08	1
LG&E	ITRON	C1S	852687	05/21/2009	100.06	99.96	100.03	1
LG&E	ITRON	C1S	852688	05/21/2009	100.07	99.90	100.04	1
LG&E	ITRON	C1S	852689	05/21/2009	100.09	99.89	100.12	1

LG&E	ITRON	C1S	852690	05/21/2009	100.10	100.13	100.23	1
LG&E	ITRON	C1S	852691	05/21/2009	100.06	99.92	100.08	1
LG&E	ITRON	C1S	852692	05/21/2009	100.10	99.96	100.17	1
LG&E	ITRON	C1S	852693	05/21/2009	100.06	100.01	99.91	1
LG&E	ITRON	C1S	852694	05/21/2009	100.09	99.91	100.07	1
LG&E	ITRON	C1S	852695	05/21/2009	100.10	100.04	100.19	1
LG&E	ITRON	C1S	852696	05/21/2009	100.09	100.05	100.22	1
LG&E	ITRON	C1S	852697	05/21/2009	100.06	100.06	100.13	1
LG&E	ITRON	C1S	852698	05/21/2009	100.06	99.93	100.04	1
LG&E	ITRON	C1S	852699	05/21/2009	100.08	99.94	100.11	1
LG&E	ITRON	C1S	852700	05/21/2009	100.06	100.05	100.17	1
LG&E	ITRON	C1S	852701	05/21/2009	100.07	99.91	100.04	1
LG&E	ITRON	C1S	852702	05/21/2009	100.07	100.04	100.10	1
LG&E	ITRON	C1S	852703	05/21/2009	100.08	99.95	100.10	1
LG&E	ITRON	C1S	852704	05/21/2009	100.07	100.01	100.00	1
LG&E	ITRON	C1S	852705	05/21/2009	100.09	99.92	100.14	1
LG&E	ITRON	C1S	852706	05/21/2009	100.09	100.02	100.04	1
LG&E	ITRON	C1S	852707	05/21/2009	100.08	100.07	100.19	1
LG&E	ITRON	C1S	852708	05/21/2009	100.10	99.94	100.03	1
LG&E	ITRON	C1S	852709	05/21/2009	100.06	99.91	100.06	1
LG&E	ITRON	C1S	852710	05/21/2009	100.06	99.94	99.98	1
LG&E	ITRON	C1S	852711	05/21/2009	100.09	100.01	100.02	1
LG&E	ITRON	C1S	852712	05/21/2009	100.08	100.03	100.15	1
LG&E	ITRON	C1S	852713	05/21/2009	100.09	100.02	99.99	1
LG&E	ITRON	C1S	852714	05/21/2009	100.08	99.86	100.03	1
LG&E	ITRON	C1S	852715	05/21/2009	100.09	100.01	100.06	1
LG&E	ITRON	C1S	852716	05/21/2009	100.08	100.05	100.20	1
LG&E	ITRON	C1S	852717	05/21/2009	100.06	100.00	100.03	1
LG&E	ITRON	C1S	852718	05/21/2009	100.09	99.92	100.13	1
LG&E	ITRON	C1S	852719	05/21/2009	100.08	100.06	100.18	1
LG&E	ITRON	C1S	852720	05/21/2009	100.10	99.93	99.91	1
LG&E	ITRON	C1S	852721	05/21/2009	100.06	99.94	100.01	1
LG&E	ITRON	C1S	852722	05/21/2009	100.06	99.97	100.09	1
LG&E	ITRON	C1S	852723	05/21/2009	100.09	99.99	100.08	1
LG&E	ITRON	C1S	852724	05/21/2009	100.07	99.99	100.12	1

LG&E	ITRON	C1S	852725	05/21/2009	100.06	100.06	100.19	1
LG&E	ITRON	C1S	852726	05/21/2009	100.06	99.97	99.98	1
LG&E	ITRON	C1S	852727	05/21/2009	100.08	100.01	100.03	1
LG&E	ITRON	C1S	852728	05/21/2009	100.06	99.90	100.08	1
LG&E	ITRON	C1S	852729	05/21/2009	100.08	100.01	100.18	1
LG&E	ITRON	C1S	852730	05/21/2009	100.06	99.92	99.86	1
LG&E	ITRON	C1S	852731	05/21/2009	100.10	100.00	100.12	1
LG&E	ITRON	C1S	852732	05/21/2009	100.07	100.00	99.88	1
LG&E	ITRON	C1S	852733	05/21/2009	100.06	100.04	100.13	1
LG&E	ITRON	C1S	852734	05/21/2009	100.07	99.99	100.02	1
LG&E	ITRON	C1S	852735	05/21/2009	100.06	99.97	100.05	1
LG&E	ITRON	C1S	852736	05/21/2009	100.10	100.09	100.17	1
LG&E	ITRON	C1S	852737	05/21/2009	100.06	99.92	100.07	1
LG&E	ITRON	C1S	852738	05/21/2009	100.06	99.92	100.05	1
LG&E	ITRON	C1S	852739	05/21/2009	100.07	99.87	100.10	1
LG&E	ITRON	C1S	852740	05/21/2009	100.07	99.97	100.00	1
LG&E	ITRON	C1S	852741	05/21/2009	100.09	99.93	100.12	1
LG&E	ITRON	C1S	852742	05/21/2009	100.10	99.96	100.12	1
LG&E	ITRON	C1S	852743	05/21/2009	100.06	99.94	100.07	1
LG&E	ITRON	C1S	852744	05/21/2009	100.10	100.08	100.20	1
LG&E	ITRON	C1S	852745	05/21/2009	100.07	99.99	99.96	1
LG&E	ITRON	C1S	852746	05/21/2009	100.06	99.96	100.12	1
LG&E	ITRON	C1S	852747	05/21/2009	100.10	100.05	100.16	1
LG&E	ITRON	C1S	852748	05/21/2009	100.08	100.08	100.15	1
LG&E	ITRON	C1S	852749	05/21/2009	100.07	100.07	100.11	1
LG&E	ITRON	C1S	852750	05/21/2009	100.08	99.91	100.08	1
LG&E	ITRON	C1S	852751	05/21/2009	100.06	100.08	100.15	1
LG&E	ITRON	C1S	852752	05/21/2009	100.06	99.94	100.04	1
LG&E	ITRON	C1S	852753	05/21/2009	100.08	99.89	100.04	1
LG&E	ITRON	C1S	852754	05/21/2009	100.06	99.99	100.11	1
LG&E	ITRON	C1S	852755	05/21/2009	100.08	99.94	100.08	1
LG&E	ITRON	C1S	852756	05/21/2009	100.06	99.88	100.13	1
LG&E	ITRON	C1S	852757	05/21/2009	100.08	100.10	100.10	1
LG&E	ITRON	C1S	852758	05/21/2009	100.08	100.08	100.19	1
LG&E	ITRON	C1S	852759	05/21/2009	100.05	99.97	100.11	1

LG&E	ITRON	C1S	852760	05/21/2009	100.07	100.04	100.15	1
LG&E	ITRON	C1S	852761	05/21/2009	100.09	99.97	100.05	1
LG&E	ITRON	C1S	852762	05/21/2009	100.09	100.02	99.93	1
LG&E	ITRON	C1S	852763	05/21/2009	100.09	99.86	100.05	1
LG&E	ITRON	C1S	852764	05/21/2009	100.07	99.93	100.06	1
LG&E	ITRON	C1S	852765	05/21/2009	100.09	100.05	100.07	1
LG&E	ITRON	C1S	852766	05/21/2009	100.07	100.02	100.15	1
LG&E	ITRON	C1S	852767	05/21/2009	100.06	99.98	100.00	1
LG&E	ITRON	C1S	852768	05/21/2009	100.06	99.96	99.95	1
LG&E	ITRON	C1S	852769	05/21/2009	100.08	99.89	100.07	1
LG&E	ITRON	C1S	852770	05/21/2009	100.10	99.99	100.11	1
LG&E	ITRON	C1S	852771	05/21/2009	100.09	100.09	100.24	1
LG&E	ITRON	C1S	852772	05/21/2009	100.10	99.97	100.06	1
LG&E	ITRON	C1S	852773	05/21/2009	100.09	100.02	100.12	1
LG&E	ITRON	C1S	852774	05/21/2009	100.08	99.91	100.03	1
LG&E	ITRON	C1S	852775	05/21/2009	100.10	99.99	100.00	1
LG&E	ITRON	C1S	852776	05/21/2009	100.08	99.97	100.06	1
LG&E	ITRON	C1S	852777	05/21/2009	100.10	99.97	100.09	1
LG&E	ITRON	C1S	852778	05/21/2009	100.06	100.07	100.17	1
LG&E	ITRON	C1S	852779	05/21/2009	100.07	99.92	99.99	1
LG&E	ITRON	C1S	852780	05/21/2009	100.10	99.94	100.06	1
LG&E	ITRON	C1S	852781	05/21/2009	100.06	100.11	100.11	1
LG&E	ITRON	C1S	852782	05/21/2009	100.06	99.98	100.11	1
LG&E	ITRON	C1S	852783	05/21/2009	100.06	100.12	100.17	1
LG&E	ITRON	C1S	852784	05/21/2009	100.06	99.91	99.99	1
LG&E	ITRON	C1S	852785	05/21/2009	100.10	99.92	100.14	1
LG&E	ITRON	C1S	852786	05/21/2009	100.09	99.98	100.06	1
LG&E	ITRON	C1S	852787	05/21/2009	100.07	99.97	99.99	1
LG&E	ITRON	C1S	852788	05/21/2009	100.07	99.95	100.11	1
LG&E	ITRON	C1S	852789	05/21/2009	100.09	99.97	100.13	1
LG&E	ITRON	C1S	852790	05/21/2009	100.09	99.97	100.00	1
LG&E	ITRON	C1S	852791	05/21/2009	100.05	99.93	100.13	1
LG&E	ITRON	C1S	852792	05/21/2009	100.10	100.09	100.13	1
LG&E	ITRON	C1S	852793	05/21/2009	100.08	100.07	100.17	1
LG&E	ITRON	C1S	852794	05/21/2009	100.05	99.90	100.05	1

LG&E	ITRON	C1S	852795	05/21/2009	100.10	99.91	100.12	1
LG&E	ITRON	C1S	852796	05/21/2009	100.07	99.97	99.98	1
LG&E	ITRON	C1S	852797	05/21/2009	100.09	99.91	100.12	1
LG&E	ITRON	C1S	852798	05/21/2009	100.06	100.06	100.15	1
LG&E	ITRON	C1S	852799	05/21/2009	100.09	100.08	100.12	1
LG&E	ITRON	C1S	852800	05/21/2009	100.06	99.99	100.13	1
LG&E	ITRON	C1S	852801	05/21/2009	100.06	99.98	99.97	1
LG&E	ITRON	C1S	852802	05/21/2009	100.06	99.98	99.99	1
LG&E	ITRON	C1S	852803	05/21/2009	100.07	100.02	99.97	1
LG&E	ITRON	C1S	852804	05/21/2009	100.06	99.93	100.05	1
LG&E	ITRON	C1S	852805	05/21/2009	100.07	99.90	99.95	1
LG&E	ITRON	C1S	852806	05/21/2009	100.08	99.98	100.02	1
LG&E	ITRON	C1S	852807	05/21/2009	100.09	99.98	100.08	1
LG&E	ITRON	C1S	852808	05/21/2009	100.06	99.91	100.10	1
LG&E	ITRON	C1S	852809	05/21/2009	100.09	99.90	100.07	1
LG&E	ITRON	C1S	852810	05/21/2009	100.08	100.05	100.10	1
LG&E	ITRON	C1S	852811	05/21/2009	100.08	99.92	100.07	1
LG&E	ITRON	C1S	852812	05/21/2009	100.06	100.07	100.15	1
LG&E	ITRON	C1S	852813	05/21/2009	100.09	100.10	100.22	1
LG&E	ITRON	C1S	852814	05/21/2009	100.10	100.00	100.06	1
LG&E	ITRON	C1S	852815	05/21/2009	100.09	100.05	100.14	1
LG&E	ITRON	C1S	852816	05/21/2009	100.06	100.02	100.10	1
LG&E	ITRON	C1S	852817	05/21/2009	100.06	99.97	99.95	1
LG&E	ITRON	C1S	852818	05/21/2009	100.06	99.90	99.99	1
LG&E	ITRON	C1S	852819	05/21/2009	100.06	99.94	100.09	1
LG&E	ITRON	C1S	852820	05/21/2009	100.07	100.05	100.13	1
LG&E	ITRON	C1S	852821	05/21/2009	100.09	100.01	100.15	1
LG&E	ITRON	C1S	852822	05/21/2009	100.07	99.97	100.03	1
LG&E	ITRON	C1S	852823	05/21/2009	100.06	99.99	100.09	1
LG&E	ITRON	C1S	852824	05/21/2009	100.06	99.88	100.06	1
LG&E	ITRON	C1S	852825	05/21/2009	100.08	99.97	100.12	1
LG&E	ITRON	C1S	852826	05/21/2009	100.09	99.99	99.98	1
LG&E	ITRON	C1S	852827	05/21/2009	100.07	100.00	100.01	1
LG&E	ITRON	C1S	852828	05/21/2009	100.09	99.97	100.00	1
LG&E	ITRON	C1S	852829	05/21/2009	100.10	99.99	100.17	1

LG&E	ITRON	C1S	852830	05/21/2009	100.06	100.06	100.18	1
LG&E	ITRON	C1S	852831	05/21/2009	100.08	99.98	100.13	1
LG&E	ITRON	C1S	852832	05/21/2009	100.08	99.90	100.15	1
LG&E	ITRON	C1S	852833	05/21/2009	100.07	99.98	100.04	1
LG&E	ITRON	C1S	852834	05/21/2009	100.07	99.99	100.17	1
LG&E	ITRON	C1S	852835	05/21/2009	100.06	100.04	100.14	1
LG&E	ITRON	C1S	852836	05/21/2009	100.06	100.01	100.04	1
LG&E	ITRON	C1S	852837	05/21/2009	100.08	100.07	100.17	1
LG&E	ITRON	C1S	852838	05/21/2009	100.08	99.99	99.89	1
LG&E	ITRON	C1S	852839	05/21/2009	100.07	99.97	100.01	1
LG&E	ITRON	C1S	852840	05/21/2009	100.08	100.09	100.16	1
LG&E	ITRON	C1S	852841	05/21/2009	100.09	100.13	100.12	1
LG&E	ITRON	C1S	852842	05/21/2009	100.05	100.04	99.98	1
LG&E	ITRON	C1S	852843	05/21/2009	100.07	99.95	99.93	1
LG&E	ITRON	C1S	852844	05/21/2009	100.08	100.00	100.14	1
LG&E	ITRON	C1S	852845	05/21/2009	100.08	99.94	100.07	1
LG&E	ITRON	C1S	852846	05/21/2009	100.06	99.87	100.04	1
LG&E	ITRON	C1S	852847	05/21/2009	100.07	100.01	100.01	1
LG&E	ITRON	C1S	852848	05/21/2009	100.06	99.96	100.17	1
LG&E	ITRON	C1S	852849	05/21/2009	100.09	100.02	100.10	1
LG&E	ITRON	C1S	852850	05/21/2009	100.05	99.96	100.03	1
LG&E	ITRON	C1S	852851	05/21/2009	100.08	100.08	100.23	1
LG&E	ITRON	C1S	852852	05/21/2009	100.06	100.08	100.17	1
LG&E	ITRON	C1S	852853	05/21/2009	100.08	99.95	100.03	1
LG&E	ITRON	C1S	852854	05/21/2009	100.09	99.96	99.97	1
LG&E	ITRON	C1S	852855	05/21/2009	100.09	100.00	99.92	1
LG&E	ITRON	C1S	852856	05/21/2009	100.06	99.94	99.93	1
LG&E	ITRON	C1S	852857	05/21/2009	100.05	99.92	100.02	1
LG&E	ITRON	C1S	852858	05/21/2009	100.09	99.96	100.15	1
LG&E	ITRON	C1S	852859	05/21/2009	100.07	99.97	100.04	1
LG&E	ITRON	C1S	852860	05/21/2009	100.08	99.94	100.08	1
LG&E	ITRON	C1S	852861	05/21/2009	100.06	99.97	100.14	1
LG&E	ITRON	C1S	852862	05/21/2009	100.08	99.93	100.05	1
LG&E	ITRON	C1S	852863	05/21/2009	100.09	100.04	100.05	1
LG&E	ITRON	C1S	852864	05/21/2009	100.06	99.98	100.16	1

LG&E	ITRON	C1S	852865	05/21/2009	100.08	99.95	100.12	1
LG&E	ITRON	C1S	852866	05/21/2009	100.10	100.12	100.20	1
LG&E	ITRON	C1S	852867	05/21/2009	100.10	100.04	100.21	1
LG&E	ITRON	C1S	852868	05/21/2009	100.09	100.04	100.12	1
LG&E	ITRON	C1S	852869	05/21/2009	100.09	100.08	100.15	1
LG&E	ITRON	C1S	852870	05/21/2009	100.10	100.06	100.13	1
LG&E	ITRON	C1S	852871	05/21/2009	100.06	99.97	100.11	1
LG&E	ITRON	C1S	852872	05/21/2009	100.05	100.00	99.99	1
LG&E	ITRON	C1S	852873	05/21/2009	100.07	100.08	100.11	1
LG&E	ITRON	C1S	852874	05/21/2009	100.07	99.96	100.12	1
LG&E	ITRON	C1S	852875	05/21/2009	100.07	100.05	100.01	1
LG&E	ITRON	C1S	852876	05/21/2009	100.08	100.06	100.09	1
LG&E	ITRON	C1S	852877	05/21/2009	100.10	100.05	100.17	1
LG&E	ITRON	C1S	852878	05/21/2009	100.09	100.09	100.19	1
LG&E	ITRON	C1S	852879	05/21/2009	100.09	99.96	100.01	1
LG&E	ITRON	C1S	852880	05/21/2009	100.09	100.01	100.06	1
LG&E	ITRON	C1S	852881	05/21/2009	100.09	100.02	100.06	1
LG&E	ITRON	C1S	852882	05/21/2009	100.09	99.95	100.07	1
LG&E	ITRON	C1S	852883	05/21/2009	100.08	99.94	100.04	1
LG&E	ITRON	C1S	852884	05/21/2009	100.10	99.94	100.14	1
LG&E	ITRON	C1S	852885	05/21/2009	100.06	99.95	100.07	1
LG&E	ITRON	C1S	852886	05/21/2009	100.05	99.97	99.94	1
LG&E	ITRON	C1S	852887	05/21/2009	100.10	99.97	100.12	1
LG&E	ITRON	C1S	852888	05/21/2009	100.08	99.94	100.07	1
LG&E	ITRON	C1S	852889	05/21/2009	100.09	100.00	100.06	1
LG&E	ITRON	C1S	852890	05/21/2009	100.09	99.95	100.09	1
LG&E	ITRON	C1S	852891	05/21/2009	100.10	99.97	100.09	1
LG&E	ITRON	C1S	852892	05/21/2009	100.05	100.00	100.05	1
LG&E	ITRON	C1S	852893	05/21/2009	100.07	99.93	100.11	1
LG&E	ITRON	C1S	852894	05/21/2009	100.08	100.00	100.02	1
LG&E	ITRON	C1S	852895	05/21/2009	100.09	100.00	99.97	1
LG&E	ITRON	C1S	852896	05/21/2009	100.10	100.04	100.05	1
LG&E	ITRON	C1S	852897	05/21/2009	100.06	99.94	99.95	1
LG&E	ITRON	C1S	852898	05/21/2009	100.10	99.93	100.12	1
LG&E	ITRON	C1S	852899	05/21/2009	100.08	100.07	99.93	1

LG&E	ITRON	C1S	852900	05/21/2009	100.08	99.94	100.01	1
LG&E	ITRON	C1S	852901	05/21/2009	100.09	99.95	100.18	1
LG&E	ITRON	C1S	852902	05/21/2009	100.09	100.01	100.04	1
LG&E	ITRON	C1S	852903	05/21/2009	100.10	100.02	100.01	1
LG&E	ITRON	C1S	852904	05/21/2009	100.06	99.97	100.07	1
LG&E	ITRON	C1S	852905	05/21/2009	100.08	100.06	100.14	1
LG&E	ITRON	C1S	852906	05/21/2009	100.09	100.00	100.14	1
LG&E	ITRON	C1S	852907	05/21/2009	100.06	99.96	100.11	1
LG&E	ITRON	C1S	852908	05/21/2009	100.09	100.03	100.14	1
LG&E	ITRON	C1S	852909	05/21/2009	100.09	100.11	100.11	1
LG&E	ITRON	C1S	852910	05/21/2009	100.09	100.08	100.25	1
LG&E	ITRON	C1S	852911	05/21/2009	100.10	100.00	100.06	1
LG&E	ITRON	C1S	852912	05/21/2009	100.08	100.03	100.16	1
LG&E	ITRON	C1S	852913	05/21/2009	100.09	99.99	100.13	1
LG&E	ITRON	C1S	852914	05/21/2009	100.06	99.87	100.02	1
LG&E	ITRON	C1S	852915	05/21/2009	100.08	99.91	100.05	1
LG&E	ITRON	C1S	852916	05/21/2009	100.07	99.94	100.09	1
LG&E	ITRON	C1S	852917	05/21/2009	100.10	100.00	100.08	1
LG&E	ITRON	C1S	852918	05/21/2009	100.10	99.88	100.16	1
LG&E	ITRON	C1S	852919	05/21/2009	100.06	100.02	100.09	1
LG&E	ITRON	C1S	852920	05/21/2009	100.08	100.02	99.98	1
LG&E	ITRON	C1S	852921	05/21/2009	100.11	100.03	100.14	1
LG&E	ITRON	C1S	852922	05/21/2009	100.09	100.05	100.19	1
LG&E	ITRON	C1S	852923	05/21/2009	100.08	99.92	100.10	1
LG&E	ITRON	C1S	852924	05/21/2009	100.06	100.00	100.14	1
LG&E	ITRON	C1S	852925	05/21/2009	100.08	100.02	100.16	1
LG&E	ITRON	C1S	852926	05/21/2009	100.08	99.92	100.16	1
LG&E	ITRON	C1S	852927	05/21/2009	100.07	100.07	100.14	1
LG&E	ITRON	C1S	852928	05/21/2009	100.09	100.00	100.08	1
LG&E	ITRON	C1S	852929	05/21/2009	100.10	99.94	100.08	1
LG&E	ITRON	C1S	852930	05/21/2009	100.09	100.02	100.03	1
LG&E	ITRON	C1S	852931	05/21/2009	100.08	100.11	100.15	1
LG&E	ITRON	C1S	852932	05/21/2009	100.08	99.95	99.93	1
LG&E	ITRON	C1S	852933	05/21/2009	100.09	99.96	99.89	1
LG&E	ITRON	C1S	852934	05/21/2009	100.06	100.00	100.05	1

LG&E	ITRON	C1S	852935	05/21/2009	100.07	100.07	100.09	1
LG&E	ITRON	C1S	852936	05/21/2009	100.10	99.93	100.20	1
LG&E	ITRON	C1S	852937	05/21/2009	100.09	99.93	100.06	1
LG&E	ITRON	C1S	852938	05/21/2009	100.09	99.99	99.99	1
LG&E	ITRON	C1S	852939	05/21/2009	100.10	100.02	100.09	1
LG&E	ITRON	C1S	852940	05/21/2009	100.08	99.98	100.07	1
LG&E	ITRON	C1S	852941	05/21/2009	100.08	100.06	100.21	1
LG&E	ITRON	C1S	852942	05/21/2009	100.06	99.94	100.06	1
LG&E	ITRON	C1S	852943	05/21/2009	100.09	100.13	100.15	1
LG&E	ITRON	C1S	852944	05/21/2009	100.10	99.96	99.93	1
LG&E	ITRON	C1S	852945	05/21/2009	100.10	100.01	100.04	1
LG&E	ITRON	C1S	852946	05/21/2009	100.07	99.99	100.17	1
LG&E	ITRON	C1S	852947	05/21/2009	100.07	99.98	100.01	1
LG&E	ITRON	C1S	852948	05/21/2009	100.06	100.05	100.13	1
LG&E	ITRON	C1S	852949	05/21/2009	100.08	100.04	100.15	1
LG&E	ITRON	C1S	852950	05/21/2009	100.10	100.01	100.13	1
LG&E	ITRON	C1S	852951	05/21/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1S	852952	05/21/2009	100.07	99.92	100.05	1
LG&E	ITRON	C1S	852953	05/21/2009	100.07	99.99	100.17	1
LG&E	ITRON	C1S	852954	05/21/2009	100.08	99.93	100.10	1
LG&E	ITRON	C1S	852955	05/21/2009	100.07	100.01	100.14	1
LG&E	ITRON	C1S	852956	05/21/2009	100.06	99.96	100.08	1
LG&E	ITRON	C1S	852957	05/21/2009	100.08	99.99	100.03	1
LG&E	ITRON	C1S	852958	05/21/2009	100.08	100.00	100.09	1
LG&E	ITRON	C1S	852959	05/21/2009	100.08	99.97	100.10	1
LG&E	ITRON	C1S	852960	05/21/2009	100.10	100.09	100.16	1
LG&E	ITRON	C1S	852961	05/21/2009	100.08	99.98	100.03	1
LG&E	ITRON	C1S	852962	05/21/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1S	852963	05/21/2009	100.06	99.95	100.11	1
LG&E	ITRON	C1S	852964	05/21/2009	100.09	99.92	100.12	1
LG&E	ITRON	C1S	852965	05/21/2009	100.09	100.01	100.03	1
LG&E	ITRON	C1S	852966	05/21/2009	100.09	99.95	100.07	1
LG&E	ITRON	C1S	852967	05/21/2009	100.08	100.12	100.14	1
LG&E	ITRON	C1S	852968	05/21/2009	100.10	100.02	99.99	1
LG&E	ITRON	C1S	852969	05/21/2009	100.09	100.02	100.08	1

LG&E	ITRON	C1S	852970	05/21/2009	100.10	100.05	100.19	1
LG&E	ITRON	C1S	852971	05/21/2009	100.08	99.97	99.93	1
LG&E	ITRON	C1S	852972	05/21/2009	100.06	99.87	100.12	1
LG&E	ITRON	C1S	852973	05/21/2009	100.05	100.05	100.18	1
LG&E	ITRON	C1S	852974	05/21/2009	100.10	100.06	100.15	1
LG&E	ITRON	C1S	852975	05/21/2009	100.08	99.92	100.22	1
LG&E	ITRON	C1S	852976	05/21/2009	100.07	99.98	99.97	1
LG&E	ITRON	C1S	852977	05/21/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	852978	05/21/2009	100.06	99.91	100.12	1
LG&E	ITRON	C1S	852979	05/21/2009	100.10	99.95	100.12	1
LG&E	ITRON	C1S	852980	05/21/2009	100.09	100.06	100.21	1
LG&E	ITRON	C1S	852981	05/21/2009	100.06	99.94	100.09	1
LG&E	ITRON	C1S	852982	05/21/2009	100.10	100.00	100.07	1
LG&E	ITRON	C1S	852983	05/21/2009	100.07	100.01	100.07	1
LG&E	ITRON	C1S	852984	05/21/2009	100.09	100.03	100.19	1
LG&E	ITRON	C1S	852985	05/21/2009	100.10	99.93	100.07	1
LG&E	ITRON	C1S	852986	05/21/2009	100.06	99.96	99.90	1
LG&E	ITRON	C1S	852987	05/21/2009	100.09	99.93	100.16	1
LG&E	ITRON	C1S	852988	05/21/2009	100.05	99.92	100.04	1
LG&E	ITRON	C1S	852989	05/21/2009	100.08	99.99	100.03	1
LG&E	ITRON	C1S	852990	05/21/2009	100.08	99.98	100.07	1
LG&E	ITRON	C1S	852991	05/21/2009	100.08	100.08	100.12	1
LG&E	ITRON	C1S	852992	05/21/2009	100.05	99.96	100.07	1
LG&E	ITRON	C1S	852993	05/21/2009	100.06	100.00	99.94	1
LG&E	ITRON	C1S	852994	05/21/2009	100.09	99.92	100.07	1
LG&E	ITRON	C1S	852995	05/21/2009	100.09	99.99	100.03	1
LG&E	ITRON	C1S	852996	05/21/2009	100.06	99.90	100.00	1
LG&E	ITRON	C1S	852997	05/21/2009	100.10	100.01	99.94	1
LG&E	ITRON	C1S	852998	05/21/2009	100.07	100.00	100.08	1
LG&E	ITRON	C1S	852999	05/21/2009	100.08	100.00	100.11	1
LG&E	ITRON	C1S	853000	05/21/2009	100.10	100.00	100.16	1
LG&E	ITRON	C1S	853001	05/21/2009	100.08	99.96	99.99	1
LG&E	ITRON	C1S	853002	05/21/2009	100.07	99.92	99.96	1
LG&E	ITRON	C1S	853003	05/21/2009	100.08	100.02	100.15	1
LG&E	ITRON	C1S	853004	05/21/2009	100.05	99.93	99.98	1

LG&E	ITRON	C1S	853005	05/21/2009	100.10	99.92	100.07	1
LG&E	ITRON	C1S	853006	05/21/2009	100.06	100.10	100.15	1
LG&E	ITRON	C1S	853007	05/21/2009	100.09	100.08	100.14	1
LG&E	ITRON	C1S	853008	05/21/2009	100.05	100.00	100.23	1
LG&E	ITRON	C1S	853009	05/21/2009	100.09	100.01	100.01	1
LG&E	ITRON	C1S	853010	05/21/2009	100.09	99.97	99.98	1
LG&E	ITRON	C1S	853011	05/21/2009	100.06	99.95	100.04	1
LG&E	ITRON	C1S	853012	05/21/2009	100.06	100.08	100.13	1
LG&E	ITRON	C1S	853013	05/21/2009	100.10	99.96	100.06	1
LG&E	ITRON	C1S	853014	05/21/2009	100.06	100.00	100.16	1
LG&E	ITRON	C1S	853015	05/21/2009	100.09	100.03	100.06	1
LG&E	ITRON	C1S	853016	05/21/2009	100.07	99.95	100.06	1
LG&E	ITRON	C1S	853017	05/21/2009	100.08	100.00	100.01	1
LG&E	ITRON	C1S	853018	05/21/2009	100.10	99.95	100.10	1
LG&E	ITRON	C1S	853019	05/21/2009	100.10	99.94	100.10	1
LG&E	ITRON	C1S	853020	05/21/2009	100.09	100.02	100.11	1
LG&E	ITRON	C1S	853021	05/21/2009	100.10	99.97	100.09	1
LG&E	ITRON	C1S	853022	05/21/2009	100.07	99.92	100.12	1
LG&E	ITRON	C1S	853023	05/21/2009	100.07	99.90	100.00	1
LG&E	ITRON	C1S	853024	05/21/2009	100.08	100.01	99.97	1
LG&E	ITRON	C1S	853025	05/21/2009	100.09	100.00	100.14	1
LG&E	ITRON	C1S	853026	05/21/2009	100.08	99.99	99.92	1
LG&E	ITRON	C1S	853027	05/21/2009	100.06	100.03	100.22	1
LG&E	ITRON	C1S	853028	05/21/2009	100.10	100.09	100.10	1
LG&E	ITRON	C1S	853029	05/21/2009	100.08	100.00	100.08	1
LG&E	ITRON	C1S	853030	05/21/2009	100.10	99.95	100.04	1
LG&E	ITRON	C1S	853031	05/21/2009	100.05	99.91	100.07	1
LG&E	ITRON	C1S	853032	05/21/2009	100.06	100.01	99.97	1
LG&E	ITRON	C1S	853033	05/21/2009	100.07	100.02	100.06	1
LG&E	ITRON	C1S	853034	05/21/2009	100.09	100.02	99.91	1
LG&E	ITRON	C1S	853035	05/21/2009	100.10	99.97	100.13	1
LG&E	ITRON	C1S	853036	05/21/2009	100.06	99.89	100.11	1
LG&E	ITRON	C1S	853037	05/21/2009	100.07	99.90	100.16	1
LG&E	ITRON	C1S	853038	05/21/2009	100.09	100.00	100.07	1
LG&E	ITRON	C1S	853039	05/21/2009	100.06	99.97	100.07	1

LG&E	ITRON	C1S	853040	05/21/2009	100.10	100.09	100.20	1
LG&E	ITRON	C1S	853041	05/21/2009	100.07	99.98	100.04	1
LG&E	ITRON	C1S	853042	05/21/2009	100.07	99.97	100.17	1
LG&E	ITRON	C1S	853043	05/21/2009	100.09	99.95	100.08	1
LG&E	ITRON	C1S	853044	05/21/2009	100.05	100.02	100.03	1
LG&E	ITRON	C1S	853045	05/21/2009	100.06	99.98	99.98	1
LG&E	ITRON	C1S	853046	05/21/2009	100.08	100.00	100.16	1
LG&E	ITRON	C1S	853047	05/21/2009	100.09	99.92	100.05	1
LG&E	ITRON	C1S	853048	05/21/2009	100.06	100.04	100.19	1
LG&E	ITRON	C1S	853049	05/21/2009	100.06	99.95	100.00	1
LG&E	ITRON	C1S	853050	05/21/2009	100.10	100.10	100.23	1
LG&E	ITRON	C1S	853051	05/21/2009	100.07	99.97	99.96	1
LG&E	ITRON	C1S	853052	05/21/2009	100.08	99.93	100.01	1
LG&E	ITRON	C1S	853053	05/21/2009	100.10	100.01	100.09	1
LG&E	ITRON	C1S	853054	05/21/2009	100.08	99.98	100.03	1
LG&E	ITRON	C1S	853055	05/21/2009	100.08	99.99	100.07	1
LG&E	ITRON	C1S	853056	05/21/2009	100.08	99.94	100.00	1
LG&E	ITRON	C1S	853057	05/21/2009	100.09	99.91	100.06	1
LG&E	ITRON	C1S	853058	05/21/2009	100.06	100.00	100.07	1
LG&E	ITRON	C1S	853059	05/21/2009	100.09	99.98	100.05	1
LG&E	ITRON	C1S	853060	05/21/2009	100.07	100.02	99.99	1
LG&E	ITRON	C1S	853061	05/21/2009	100.10	100.00	100.01	1
LG&E	ITRON	C1S	853062	05/21/2009	100.06	99.96	100.12	1
LG&E	ITRON	C1S	853063	05/21/2009	100.08	100.05	100.10	1
LG&E	ITRON	C1S	853064	05/21/2009	100.10	99.98	100.15	1
LG&E	ITRON	C1S	853065	05/21/2009	100.06	100.02	100.03	1
LG&E	ITRON	C1S	853066	05/21/2009	100.06	100.11	100.13	1
LG&E	ITRON	C1S	854267	08/13/2009	100.06	100.06	100.20	1
LG&E	ITRON	C1S	854268	08/13/2009	100.09	100.01	100.08	1
LG&E	ITRON	C1S	854269	08/13/2009	100.08	99.95	99.95	1
LG&E	ITRON	C1S	854270	08/13/2009	100.06	100.02	100.06	1
LG&E	ITRON	C1S	854271	08/13/2009	100.08	100.02	99.96	1
LG&E	ITRON	C1S	854272	08/13/2009	100.06	99.94	100.07	1
LG&E	ITRON	C1S	854273	08/13/2009	100.08	99.95	100.02	1
LG&E	ITRON	C1S	854274	08/13/2009	100.07	99.97	99.94	1

LG&E	ITRON	C1S	854275	08/13/2009	100.06	99.98	99.99	1
LG&E	ITRON	C1S	854276	08/13/2009	100.08	100.06	99.97	1
LG&E	ITRON	C1S	854277	08/13/2009	100.07	100.04	99.96	1
LG&E	ITRON	C1S	854278	08/13/2009	100.07	100.06	100.17	1
LG&E	ITRON	C1S	854279	08/13/2009	100.06	99.89	100.07	1
LG&E	ITRON	C1S	854280	08/13/2009	100.07	99.98	99.98	1
LG&E	ITRON	C1S	854281	08/13/2009	100.07	99.89	100.05	1
LG&E	ITRON	C1S	854282	08/13/2009	100.09	99.99	100.02	1
LG&E	ITRON	C1S	854283	08/13/2009	100.09	100.03	100.05	1
LG&E	ITRON	C1S	854284	08/13/2009	100.08	99.95	100.05	1
LG&E	ITRON	C1S	854285	08/13/2009	100.10	99.97	100.04	1
LG&E	ITRON	C1S	854286	08/13/2009	100.10	99.95	100.04	1
LG&E	ITRON	C1S	854287	08/13/2009	100.07	99.90	99.97	1
LG&E	ITRON	C1S	854288	08/13/2009	100.08	99.99	100.08	1
LG&E	ITRON	C1S	854289	08/13/2009	100.09	99.94	100.03	1
LG&E	ITRON	C1S	854290	08/13/2009	100.08	99.92	100.03	1
LG&E	ITRON	C1S	854291	08/13/2009	100.08	99.91	100.07	1
LG&E	ITRON	C1S	854292	08/13/2009	100.09	99.98	100.07	1
LG&E	ITRON	C1S	854293	08/13/2009	100.08	99.90	100.11	1
LG&E	ITRON	C1S	854294	08/13/2009	100.07	99.95	100.03	1
LG&E	ITRON	C1S	854295	08/13/2009	100.07	99.94	100.04	1
LG&E	ITRON	C1S	854296	08/13/2009	100.07	99.95	100.03	1
LG&E	ITRON	C1S	854297	08/13/2009	100.06	100.01	100.03	1
LG&E	ITRON	C1S	854298	08/13/2009	100.09	100.03	100.21	1
LG&E	ITRON	C1S	854299	08/13/2009	100.09	99.97	100.10	1
LG&E	ITRON	C1S	854300	08/13/2009	100.06	99.98	99.94	1
LG&E	ITRON	C1S	854301	08/13/2009	100.09	99.96	100.08	1
LG&E	ITRON	C1S	854302	08/13/2009	100.06	100.06	100.09	1
LG&E	ITRON	C1S	854303	08/13/2009	100.09	99.93	100.03	1
LG&E	ITRON	C1S	854304	08/13/2009	100.10	99.95	100.08	1
LG&E	ITRON	C1S	854305	08/13/2009	100.08	99.92	99.99	1
LG&E	ITRON	C1S	854306	08/13/2009	100.05	99.96	99.93	1
LG&E	ITRON	C1S	854307	08/13/2009	100.06	99.93	100.04	1
LG&E	ITRON	C1S	854308	08/13/2009	100.05	99.93	100.14	1
LG&E	ITRON	C1S	854309	08/13/2009	100.09	99.98	100.01	1

LG&E	ITRON	C1S	854310	08/13/2009	100.06	99.98	100.04	1
LG&E	ITRON	C1S	854311	08/13/2009	100.08	99.91	100.06	1
LG&E	ITRON	C1S	854312	08/13/2009	100.10	99.94	100.08	1
LG&E	ITRON	C1S	854313	08/13/2009	100.09	100.05	100.15	1
LG&E	ITRON	C1S	854314	08/13/2009	100.06	99.93	100.12	1
LG&E	ITRON	C1S	854315	08/13/2009	100.07	100.00	100.02	1
LG&E	ITRON	C1S	854316	08/13/2009	100.06	99.94	100.00	1
LG&E	ITRON	C1S	854317	08/13/2009	100.10	100.00	100.02	1
LG&E	ITRON	C1S	854318	08/13/2009	100.07	100.06	100.09	1
LG&E	ITRON	C1S	854319	08/13/2009	100.08	100.06	100.19	1
LG&E	ITRON	C1S	854320	08/13/2009	100.07	100.06	100.13	1
LG&E	ITRON	C1S	854321	08/13/2009	100.09	100.01	100.05	1
LG&E	ITRON	C1S	854322	08/13/2009	100.06	100.03	100.17	1
LG&E	ITRON	C1S	854323	08/13/2009	100.08	100.03	100.11	1
LG&E	ITRON	C1S	854324	08/13/2009	100.06	99.97	99.96	1
LG&E	ITRON	C1S	854325	08/13/2009	100.06	99.91	100.01	1
LG&E	ITRON	C1S	854326	08/13/2009	100.09	99.94	100.03	1
LG&E	ITRON	C1S	854327	08/13/2009	100.09	99.95	100.00	1
LG&E	ITRON	C1S	854328	08/13/2009	100.05	99.88	100.02	1
LG&E	ITRON	C1S	854329	08/13/2009	100.09	99.96	100.02	1
LG&E	ITRON	C1S	854330	08/13/2009	100.06	99.92	99.98	1
LG&E	ITRON	C1S	854331	08/13/2009	100.10	99.95	100.12	1
LG&E	ITRON	C1S	854332	08/13/2009	100.06	99.91	100.08	1
LG&E	ITRON	C1S	854333	08/13/2009	100.07	99.91	100.11	1
LG&E	ITRON	C1S	854334	08/13/2009	100.06	99.95	99.97	1
LG&E	ITRON	C1S	854335	08/13/2009	100.06	99.95	99.98	1
LG&E	ITRON	C1S	854336	08/13/2009	100.08	100.07	100.14	1
LG&E	ITRON	C1S	854337	08/13/2009	100.09	100.06	100.18	1
LG&E	ITRON	C1S	854338	08/13/2009	100.08	99.97	100.13	1
LG&E	ITRON	C1S	854339	08/13/2009	100.09	100.10	100.19	1
LG&E	ITRON	C1S	854340	08/13/2009	100.05	99.95	100.09	1
LG&E	ITRON	C1S	854341	08/13/2009	100.06	99.94	100.19	1
LG&E	ITRON	C1S	854342	08/13/2009	100.09	99.95	100.09	1
LG&E	ITRON	C1S	854343	08/13/2009	100.06	99.91	100.00	1
LG&E	ITRON	C1S	854344	08/13/2009	100.08	99.95	100.00	1

LG&E	ITRON	C1S	854345	08/13/2009	100.06	99.91	100.02	1
LG&E	ITRON	C1S	854346	08/13/2009	100.06	100.02	100.09	1
LG&E	ITRON	C1S	854347	08/13/2009	100.06	99.98	99.97	1
LG&E	ITRON	C1S	854348	08/13/2009	100.06	99.91	99.98	1
LG&E	ITRON	C1S	854349	08/13/2009	100.08	100.00	100.00	1
LG&E	ITRON	C1S	854350	08/13/2009	100.09	99.95	99.98	1
LG&E	ITRON	C1S	854351	08/13/2009	100.10	100.06	100.00	1
LG&E	ITRON	C1S	854352	08/13/2009	100.07	100.08	100.24	1
LG&E	ITRON	C1S	854353	08/13/2009	100.09	100.01	100.17	1
LG&E	ITRON	C1S	854354	08/13/2009	100.06	99.97	99.95	1
LG&E	ITRON	C1S	854355	08/13/2009	100.07	100.00	100.02	1
LG&E	ITRON	C1S	854356	08/13/2009	100.07	99.89	99.99	1
LG&E	ITRON	C1S	854357	08/13/2009	100.07	100.04	100.04	1
LG&E	ITRON	C1S	854358	08/13/2009	100.09	99.96	100.01	1
LG&E	ITRON	C1S	854359	08/13/2009	100.06	99.98	100.13	1
LG&E	ITRON	C1S	854360	08/13/2009	100.10	100.03	100.10	1
LG&E	ITRON	C1S	854361	08/13/2009	100.05	100.06	100.12	1
LG&E	ITRON	C1S	854362	08/13/2009	100.06	100.03	100.15	1
LG&E	ITRON	C1S	854363	08/13/2009	100.07	99.95	99.96	1
LG&E	ITRON	C1S	854364	08/13/2009	100.10	100.11	100.14	1
LG&E	ITRON	C1S	854365	08/13/2009	100.08	99.98	100.05	1
LG&E	ITRON	C1S	854366	08/13/2009	100.10	99.98	100.05	1
LG&E	ITRON	C1S	854367	08/13/2009	100.08	100.05	100.17	1
LG&E	ITRON	C1S	854368	08/13/2009	100.09	100.12	100.15	1
LG&E	ITRON	C1S	854369	08/13/2009	100.10	100.03	100.24	1
LG&E	ITRON	C1S	854370	08/13/2009	100.06	100.02	100.15	1
LG&E	ITRON	C1S	854371	08/13/2009	100.09	100.02	100.06	1
LG&E	ITRON	C1S	854372	08/13/2009	100.07	100.03	100.11	1
LG&E	ITRON	C1S	854373	08/13/2009	100.08	100.06	100.19	1
LG&E	ITRON	C1S	854374	08/13/2009	100.10	100.10	100.18	1
LG&E	ITRON	C1S	854375	08/13/2009	100.07	99.90	100.09	1
LG&E	ITRON	C1S	854376	08/13/2009	100.09	100.09	100.16	1
LG&E	ITRON	C1S	854377	08/13/2009	100.10	100.08	100.22	1
LG&E	ITRON	C1S	854378	08/13/2009	100.08	100.08	100.14	1
LG&E	ITRON	C1S	854379	08/13/2009	100.09	100.00	100.00	1

LG&E	ITRON	C1S	854380	08/13/2009	100.06	100.09	100.12	1
LG&E	ITRON	C1S	854381	08/13/2009	100.06	100.05	100.12	1
LG&E	ITRON	C1S	854382	08/13/2009	100.08	99.91	100.17	1
LG&E	ITRON	C1S	854383	08/13/2009	100.07	99.99	99.90	1
LG&E	ITRON	C1S	854384	08/13/2009	100.08	99.98	100.08	1
LG&E	ITRON	C1S	854385	08/13/2009	100.10	99.99	100.05	1
LG&E	ITRON	C1S	854386	08/13/2009	100.06	99.97	100.07	1
LG&E	ITRON	C1S	854387	08/13/2009	100.06	99.98	99.98	1
LG&E	ITRON	C1S	854388	08/13/2009	100.08	99.88	99.91	1
LG&E	ITRON	C1S	854389	08/13/2009	100.06	99.91	100.06	1
LG&E	ITRON	C1S	854390	08/13/2009	100.07	99.96	100.00	1
LG&E	ITRON	C1S	854391	08/13/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	854392	08/13/2009	100.06	99.99	100.01	1
LG&E	ITRON	C1S	854393	08/13/2009	100.08	100.10	100.16	1
LG&E	ITRON	C1S	854394	08/13/2009	100.08	99.97	100.06	1
LG&E	ITRON	C1S	854395	08/13/2009	100.08	100.05	100.19	1
LG&E	ITRON	C1S	854396	08/13/2009	100.09	100.09	100.13	1
LG&E	ITRON	C1S	854397	08/13/2009	100.07	99.94	100.06	1
LG&E	ITRON	C1S	854398	08/13/2009	100.07	100.05	100.18	1
LG&E	ITRON	C1S	854399	08/13/2009	100.09	100.16	100.21	1
LG&E	ITRON	C1S	854400	08/13/2009	100.06	100.00	100.13	1
LG&E	ITRON	C1S	854401	08/13/2009	100.09	99.98	100.05	1
LG&E	ITRON	C1S	854402	08/13/2009	100.09	100.08	100.19	1
LG&E	ITRON	C1S	854403	08/13/2009	100.08	100.05	100.18	1
LG&E	ITRON	C1S	854404	08/13/2009	100.06	100.07	100.11	1
LG&E	ITRON	C1S	854405	08/13/2009	100.08	99.97	99.99	1
LG&E	ITRON	C1S	854406	08/13/2009	100.07	99.91	100.03	1
LG&E	ITRON	C1S	854407	08/13/2009	100.05	100.08	100.18	1
LG&E	ITRON	C1S	854408	08/13/2009	100.06	99.99	100.15	1
LG&E	ITRON	C1S	854409	08/13/2009	100.10	100.00	100.04	1
LG&E	ITRON	C1S	854410	08/13/2009	100.06	99.85	100.01	1
LG&E	ITRON	C1S	854411	08/13/2009	100.09	100.13	100.15	1
LG&E	ITRON	C1S	854412	08/13/2009	100.10	99.96	100.06	1
LG&E	ITRON	C1S	854413	08/13/2009	100.07	99.99	99.93	1
LG&E	ITRON	C1S	854414	08/13/2009	100.07	99.87	100.04	1

LG&E	ITRON	C1S	854415	08/13/2009	100.05	100.00	100.03	1
LG&E	ITRON	C1S	854416	08/13/2009	100.07	99.96	100.14	1
LG&E	ITRON	C1S	854417	08/13/2009	100.10	100.00	100.04	1
LG&E	ITRON	C1S	854418	08/13/2009	100.09	100.07	100.14	1
LG&E	ITRON	C1S	854419	08/13/2009	100.09	100.05	100.20	1
LG&E	ITRON	C1S	854420	08/13/2009	100.06	100.10	100.16	1
LG&E	ITRON	C1S	854421	08/13/2009	100.10	99.99	100.08	1
LG&E	ITRON	C1S	854422	08/13/2009	100.06	99.99	100.03	1
LG&E	ITRON	C1S	854423	08/13/2009	100.09	100.04	100.12	1
LG&E	ITRON	C1S	854424	08/13/2009	100.06	99.95	100.00	1
LG&E	ITRON	C1S	854425	08/13/2009	100.07	99.94	100.00	1
LG&E	ITRON	C1S	854426	08/13/2009	100.07	99.92	100.06	1
LG&E	ITRON	C1S	854427	08/13/2009	100.06	100.07	100.10	1
LG&E	ITRON	C1S	854428	08/13/2009	100.07	100.01	100.01	1
LG&E	ITRON	C1S	854429	08/13/2009	100.08	99.94	100.12	1
LG&E	ITRON	C1S	854430	08/13/2009	100.06	100.11	100.09	1
LG&E	ITRON	C1S	854431	08/13/2009	100.10	100.01	99.99	1
LG&E	ITRON	C1S	854432	08/13/2009	100.10	99.98	100.00	1
LG&E	ITRON	C1S	854433	08/13/2009	100.09	99.98	100.10	1
LG&E	ITRON	C1S	854434	08/13/2009	100.08	100.09	100.14	1
LG&E	ITRON	C1S	854435	08/13/2009	100.08	99.93	99.98	1
LG&E	ITRON	C1S	854436	08/13/2009	100.09	100.00	100.02	1
LG&E	ITRON	C1S	854437	08/13/2009	100.07	99.94	100.04	1
LG&E	ITRON	C1S	854438	08/13/2009	100.05	99.97	100.00	1
LG&E	ITRON	C1S	854439	08/13/2009	100.08	100.06	100.14	1
LG&E	ITRON	C1S	854440	08/13/2009	100.05	99.98	100.13	1
LG&E	ITRON	C1S	854441	08/13/2009	100.06	99.97	99.99	1
LG&E	ITRON	C1S	854442	08/13/2009	100.08	100.06	100.03	1
LG&E	ITRON	C1S	854443	08/13/2009	100.06	99.99	100.07	1
LG&E	ITRON	C1S	854444	08/13/2009	100.08	99.91	99.95	1
LG&E	ITRON	C1S	854445	08/13/2009	100.06	99.92	100.06	1
LG&E	ITRON	C1S	854446	08/13/2009	100.08	99.96	100.07	1
LG&E	ITRON	C1S	854447	08/13/2009	100.09	99.95	100.04	1
LG&E	ITRON	C1S	854448	08/13/2009	100.08	100.02	100.03	1
LG&E	ITRON	C1S	854449	08/13/2009	100.08	100.10	100.10	1

LG&E	ITRON	C1S	854450	08/13/2009	100.05	100.01	100.16	1
LG&E	ITRON	C1S	854451	08/13/2009	100.08	100.10	100.15	1
LG&E	ITRON	C1S	854452	08/13/2009	100.08	99.86	100.10	1
LG&E	ITRON	C1S	854453	08/13/2009	100.07	99.90	100.09	1
LG&E	ITRON	C1S	854454	08/13/2009	100.08	100.00	100.14	1
LG&E	ITRON	C1S	854455	08/13/2009	100.09	100.11	100.18	1
LG&E	ITRON	C1S	854456	08/13/2009	100.08	100.04	100.17	1
LG&E	ITRON	C1S	854457	08/13/2009	100.06	100.00	100.13	1
LG&E	ITRON	C1S	854458	08/13/2009	100.10	100.12	100.14	1
LG&E	ITRON	C1S	854459	08/13/2009	100.08	99.99	99.98	1
LG&E	ITRON	C1S	854460	08/13/2009	100.07	99.94	99.92	1
LG&E	ITRON	C1S	854461	08/13/2009	100.06	100.09	100.09	1
LG&E	ITRON	C1S	854462	08/13/2009	100.07	100.04	100.20	1
LG&E	ITRON	C1S	854463	08/13/2009	100.10	99.97	100.15	1
LG&E	ITRON	C1S	854464	08/13/2009	100.05	100.08	100.17	1
LG&E	ITRON	C1S	854465	08/13/2009	100.09	99.91	100.10	1
LG&E	ITRON	C1S	854466	08/13/2009	100.09	99.98	100.06	1
LG&E	ITRON	C1S	854467	08/13/2009	100.09	99.91	100.02	1
LG&E	ITRON	C1S	854468	08/13/2009	100.08	99.95	99.96	1
LG&E	ITRON	C1S	854469	08/13/2009	100.09	100.06	100.05	1
LG&E	ITRON	C1S	854470	08/13/2009	100.11	99.99	100.05	1
LG&E	ITRON	C1S	854471	08/13/2009	100.09	100.07	100.19	1
LG&E	ITRON	C1S	854472	08/13/2009	100.07	99.93	100.07	1
LG&E	ITRON	C1S	854473	08/13/2009	100.05	99.95	100.06	1
LG&E	ITRON	C1S	854474	08/13/2009	100.09	100.01	100.17	1
LG&E	ITRON	C1S	854475	08/13/2009	100.06	99.90	100.07	1
LG&E	ITRON	C1S	854476	08/13/2009	100.10	100.00	100.07	1
LG&E	ITRON	C1S	854477	08/13/2009	100.06	99.97	100.05	1
LG&E	ITRON	C1S	854478	08/13/2009	100.07	99.88	99.97	1
LG&E	ITRON	C1S	854479	08/13/2009	100.09	99.95	100.08	1
LG&E	ITRON	C1S	854480	08/13/2009	100.07	99.90	100.12	1
LG&E	ITRON	C1S	854481	08/13/2009	100.09	99.94	100.06	1
LG&E	ITRON	C1S	854482	08/13/2009	100.07	99.93	99.98	1
LG&E	ITRON	C1S	854483	08/13/2009	100.08	100.02	100.04	1
LG&E	ITRON	C1S	854484	08/13/2009	100.10	100.12	100.23	1

LG&E	ITRON	C1S	854485	08/13/2009	100.07	99.95	99.92	1
LG&E	ITRON	C1S	854486	08/13/2009	100.06	100.00	100.13	1
LG&E	ITRON	C1S	854487	08/13/2009	100.09	100.09	100.13	1
LG&E	ITRON	C1S	854488	08/13/2009	100.09	100.02	100.00	1
LG&E	ITRON	C1S	854489	08/13/2009	100.06	99.85	100.11	1
LG&E	ITRON	C1S	854490	08/13/2009	100.07	100.01	100.02	1
LG&E	ITRON	C1S	854491	08/13/2009	100.07	99.93	99.94	1
LG&E	ITRON	C1S	854492	08/13/2009	100.07	99.92	100.07	1
LG&E	ITRON	C1S	854493	08/13/2009	100.09	99.93	99.96	1
LG&E	ITRON	C1S	854494	08/13/2009	100.05	100.01	100.16	1
LG&E	ITRON	C1S	854495	08/13/2009	100.08	100.04	100.03	1
LG&E	ITRON	C1S	854496	08/13/2009	100.06	99.88	100.11	1
LG&E	ITRON	C1S	854497	08/13/2009	100.09	99.93	100.05	1
LG&E	ITRON	C1S	854498	08/13/2009	100.08	99.90	100.09	1
LG&E	ITRON	C1S	854499	08/13/2009	100.09	100.00	100.24	1
LG&E	ITRON	C1S	854500	08/13/2009	100.08	100.02	100.02	1
LG&E	ITRON	C1S	854501	08/13/2009	100.07	100.06	100.17	1
LG&E	ITRON	C1S	854502	08/13/2009	100.05	100.02	100.12	1
LG&E	ITRON	C1S	854503	08/13/2009	100.08	100.02	100.15	1
LG&E	ITRON	C1S	854504	08/13/2009	100.08	100.09	100.18	1
LG&E	ITRON	C1S	854505	08/13/2009	100.09	99.98	100.18	1
LG&E	ITRON	C1S	854506	08/13/2009	100.06	100.07	100.13	1
LG&E	ITRON	C1S	854507	08/13/2009	100.06	100.00	100.19	1
LG&E	ITRON	C1S	854508	08/13/2009	100.11	100.06	100.07	1
LG&E	ITRON	C1S	854509	08/13/2009	100.08	99.93	100.05	1
LG&E	ITRON	C1S	854510	08/13/2009	100.09	100.04	100.09	1
LG&E	ITRON	C1S	854511	08/13/2009	100.05	99.96	100.02	1
LG&E	ITRON	C1S	854512	08/13/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	854513	08/13/2009	100.07	99.97	100.03	1
LG&E	ITRON	C1S	854514	08/13/2009	100.07	99.97	100.01	1
LG&E	ITRON	C1S	854515	08/13/2009	100.07	99.98	100.00	1
LG&E	ITRON	C1S	854516	08/13/2009	100.08	99.94	100.11	1
LG&E	ITRON	C1S	854517	08/13/2009	100.10	100.02	100.05	1
LG&E	ITRON	C1S	854518	08/13/2009	100.10	99.94	99.97	1
LG&E	ITRON	C1S	854519	08/13/2009	100.08	100.02	100.00	1

LG&E	ITRON	C1S	854520	08/13/2009	100.08	100.10	100.18	1
LG&E	ITRON	C1S	854521	08/13/2009	100.06	100.01	100.13	1
LG&E	ITRON	C1S	854522	08/13/2009	100.06	99.93	100.04	1
LG&E	ITRON	C1S	854523	08/13/2009	100.10	99.89	100.06	1
LG&E	ITRON	C1S	854524	08/13/2009	100.09	99.97	100.09	1
LG&E	ITRON	C1S	854525	08/13/2009	100.06	99.97	100.00	1
LG&E	ITRON	C1S	854526	08/13/2009	100.09	100.02	100.12	1
LG&E	ITRON	C1S	854527	08/13/2009	100.07	99.99	100.15	1
LG&E	ITRON	C1S	854528	08/13/2009	100.08	100.12	100.14	1
LG&E	ITRON	C1S	854529	08/13/2009	100.06	100.02	100.07	1
LG&E	ITRON	C1S	854530	08/13/2009	100.06	100.00	100.14	1
LG&E	ITRON	C1S	854531	08/13/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	854532	08/13/2009	100.10	99.99	100.06	1
LG&E	ITRON	C1S	854533	08/13/2009	100.06	100.08	100.08	1
LG&E	ITRON	C1S	854534	08/13/2009	100.09	99.97	100.02	1
LG&E	ITRON	C1S	854535	08/13/2009	100.09	99.98	100.04	1
LG&E	ITRON	C1S	854536	08/13/2009	100.08	99.95	99.93	1
LG&E	ITRON	C1S	854537	08/13/2009	100.06	99.95	99.97	1
LG&E	ITRON	C1S	854538	08/13/2009	100.07	99.96	100.06	1
LG&E	ITRON	C1S	854539	08/13/2009	100.07	99.96	100.02	1
LG&E	ITRON	C1S	854540	08/13/2009	100.06	100.07	100.13	1
LG&E	ITRON	C1S	854541	08/13/2009	100.06	100.02	100.13	1
LG&E	ITRON	C1S	854542	08/13/2009	100.10	99.99	100.06	1
LG&E	ITRON	C1S	854543	08/13/2009	100.07	99.95	99.95	1
LG&E	ITRON	C1S	854544	08/13/2009	100.10	99.94	100.02	1
LG&E	ITRON	C1S	854545	08/13/2009	100.06	100.07	100.14	1
LG&E	ITRON	C1S	854546	08/13/2009	100.10	100.04	100.09	1
LG&E	ITRON	C1S	854547	08/13/2009	100.08	99.95	100.04	1
LG&E	ITRON	C1S	854548	08/13/2009	100.10	99.90	100.02	1
LG&E	ITRON	C1S	854549	08/13/2009	100.08	99.96	100.07	1
LG&E	ITRON	C1S	854550	08/13/2009	100.06	99.91	99.98	1
LG&E	ITRON	C1S	854551	08/13/2009	100.07	99.95	100.09	1
LG&E	ITRON	C1S	854552	08/13/2009	100.05	100.00	99.98	1
LG&E	ITRON	C1S	854553	08/13/2009	100.06	99.90	100.00	1
LG&E	ITRON	C1S	854554	08/13/2009	100.05	99.97	100.15	1

LG&E	ITRON	C1S	854555	08/13/2009	100.05	100.04	100.18	1
LG&E	ITRON	C1S	854556	08/13/2009	100.08	100.09	100.18	1
LG&E	ITRON	C1S	854557	08/13/2009	100.06	100.00	99.97	1
LG&E	ITRON	C1S	854558	08/13/2009	100.09	100.00	100.15	1
LG&E	ITRON	C1S	854559	08/13/2009	100.07	99.94	100.05	1
LG&E	ITRON	C1S	854560	08/13/2009	100.09	100.01	100.15	1
LG&E	ITRON	C1S	854561	08/13/2009	100.08	100.03	100.17	1
LG&E	ITRON	C1S	854562	08/13/2009	100.06	100.03	100.13	1
LG&E	ITRON	C1S	854563	08/13/2009	100.06	100.00	99.98	1
LG&E	ITRON	C1S	854564	08/13/2009	100.09	100.01	100.14	1
LG&E	ITRON	C1S	854565	08/13/2009	100.09	100.09	100.18	1
LG&E	ITRON	C1S	854566	08/13/2009	100.08	100.12	100.17	1
LG&E	ITRON	C1S	854567	08/13/2009	100.09	100.07	100.17	1
LG&E	ITRON	C1S	854568	08/13/2009	100.08	100.00	100.18	1
LG&E	ITRON	C1S	854569	08/13/2009	100.09	100.15	100.17	1
LG&E	ITRON	C1S	854570	08/13/2009	100.07	100.06	100.13	1
LG&E	ITRON	C1S	854571	08/13/2009	100.07	100.06	100.17	1
LG&E	ITRON	C1S	854572	08/13/2009	100.06	100.07	100.16	1
LG&E	ITRON	C1S	854573	08/13/2009	100.07	99.99	99.97	1
LG&E	ITRON	C1S	854574	08/13/2009	100.07	100.04	100.15	1
LG&E	ITRON	C1S	854575	08/13/2009	100.06	100.01	100.01	1
LG&E	ITRON	C1S	854576	08/13/2009	100.07	100.03	100.19	1
LG&E	ITRON	C1S	854577	08/13/2009	100.05	100.03	100.12	1
LG&E	ITRON	C1S	854578	08/13/2009	100.07	100.04	100.08	1
LG&E	ITRON	C1S	854579	08/13/2009	100.09	100.11	100.20	1
LG&E	ITRON	C1S	854580	08/13/2009	100.05	100.04	100.16	1
LG&E	ITRON	C1S	854581	08/13/2009	100.09	100.09	100.17	1
LG&E	ITRON	C1S	854582	08/13/2009	100.07	99.93	100.13	1
LG&E	ITRON	C1S	854583	08/13/2009	100.08	100.07	100.15	1
LG&E	ITRON	C1S	854584	08/13/2009	100.10	99.98	100.03	1
LG&E	ITRON	C1S	854585	08/13/2009	100.06	100.08	100.16	1
LG&E	ITRON	C1S	854586	08/13/2009	100.07	100.07	100.12	1
LG&E	ITRON	C1S	854587	08/13/2009	100.07	100.03	100.22	1
LG&E	ITRON	C1S	854588	08/13/2009	100.07	99.98	100.20	1
LG&E	ITRON	C1S	854589	08/13/2009	100.06	99.97	100.06	1

LG&E	ITRON	C1S	854590	08/13/2009	100.08	99.97	100.08	1
LG&E	ITRON	C1S	854591	08/13/2009	100.10	100.09	100.20	1
LG&E	ITRON	C1S	854592	08/13/2009	100.09	100.06	100.04	1
LG&E	ITRON	C1S	854593	08/13/2009	100.06	100.02	100.12	1
LG&E	ITRON	C1S	854594	08/13/2009	100.07	99.97	100.07	1
LG&E	ITRON	C1S	854595	08/13/2009	100.09	100.09	100.17	1
LG&E	ITRON	C1S	854596	08/13/2009	100.06	100.05	100.18	1
LG&E	ITRON	C1S	854597	08/13/2009	100.06	100.15	100.14	1
LG&E	ITRON	C1S	854598	08/13/2009	100.07	100.05	100.12	1
LG&E	ITRON	C1S	854599	08/13/2009	100.07	100.12	100.20	1
LG&E	ITRON	C1S	854600	08/13/2009	100.10	100.09	100.10	1
LG&E	ITRON	C1S	854601	08/13/2009	100.08	100.02	100.19	1
LG&E	ITRON	C1S	854602	08/13/2009	100.08	100.12	100.05	1
LG&E	ITRON	C1S	854603	08/13/2009	100.06	100.00	100.16	1
LG&E	ITRON	C1S	854604	08/13/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	854605	08/13/2009	100.06	100.02	100.12	1
LG&E	ITRON	C1S	854606	08/13/2009	100.06	99.94	100.01	1
LG&E	ITRON	C1S	854607	08/13/2009	100.05	100.03	100.22	1
LG&E	ITRON	C1S	854608	08/13/2009	100.10	100.12	100.20	1
LG&E	ITRON	C1S	854609	08/13/2009	100.08	100.12	100.24	1
LG&E	ITRON	C1S	854610	08/13/2009	100.08	100.04	100.15	1
LG&E	ITRON	C1S	854611	08/13/2009	100.08	99.99	100.04	1
LG&E	ITRON	C1S	854612	08/13/2009	100.08	99.96	99.99	1
LG&E	ITRON	C1S	854613	08/13/2009	100.08	100.06	100.21	1
LG&E	ITRON	C1S	854614	08/13/2009	100.09	100.08	100.16	1
LG&E	ITRON	C1S	854615	08/13/2009	100.07	100.08	100.18	1
LG&E	ITRON	C1S	854616	08/13/2009	100.09	100.10	100.16	1
LG&E	ITRON	C1S	854617	08/13/2009	100.10	100.07	100.17	1
LG&E	ITRON	C1S	854618	08/13/2009	100.08	100.11	100.14	1
LG&E	ITRON	C1S	854619	08/13/2009	100.07	100.04	100.15	1
LG&E	ITRON	C1S	854620	08/13/2009	100.06	100.10	100.09	1
LG&E	ITRON	C1S	854621	08/13/2009	100.05	99.89	100.02	1
LG&E	ITRON	C1S	854622	08/13/2009	100.07	100.08	100.18	1
LG&E	ITRON	C1S	854623	08/13/2009	100.09	100.12	100.19	1
LG&E	ITRON	C1S	854624	08/13/2009	100.06	100.06	100.18	1

LG&E	ITRON	C1S	854625	08/13/2009	100.07	99.98	100.05	1
LG&E	ITRON	C1S	854626	08/13/2009	100.09	100.13	100.15	1
LG&E	ITRON	C1S	854627	08/13/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	854628	08/13/2009	100.08	100.11	100.10	1
LG&E	ITRON	C1S	854629	08/13/2009	100.09	99.93	100.08	1
LG&E	ITRON	C1S	854630	08/13/2009	100.09	100.06	100.13	1
LG&E	ITRON	C1S	854631	08/13/2009	100.05	100.07	100.22	1
LG&E	ITRON	C1S	854632	08/13/2009	100.08	100.08	100.17	1
LG&E	ITRON	C1S	854633	08/13/2009	100.07	100.06	100.17	1
LG&E	ITRON	C1S	854634	08/13/2009	100.08	99.98	100.19	1
LG&E	ITRON	C1S	854635	08/13/2009	100.08	100.08	100.09	1
LG&E	ITRON	C1S	854636	08/13/2009	100.08	100.10	100.08	1
LG&E	ITRON	C1S	854637	08/13/2009	100.08	100.15	100.17	1
LG&E	ITRON	C1S	854638	08/13/2009	100.09	100.07	100.13	1
LG&E	ITRON	C1S	854639	08/13/2009	100.08	100.03	100.10	1
LG&E	ITRON	C1S	854640	08/13/2009	100.09	100.07	100.20	1
LG&E	ITRON	C1S	854641	08/13/2009	100.10	100.01	100.03	1
LG&E	ITRON	C1S	854642	08/13/2009	100.07	100.07	100.15	1
LG&E	ITRON	C1S	854643	08/13/2009	100.08	100.06	100.11	1
LG&E	ITRON	C1S	854644	08/13/2009	100.09	100.08	100.16	1
LG&E	ITRON	C1S	854645	08/13/2009	100.10	99.90	100.16	1
LG&E	ITRON	C1S	854646	08/13/2009	100.07	99.98	100.06	1
LG&E	ITRON	C1S	854647	08/13/2009	100.09	100.11	100.14	1
LG&E	ITRON	C1S	854648	08/13/2009	100.08	99.92	99.96	1
LG&E	ITRON	C1S	854649	08/13/2009	100.05	100.05	100.08	1
LG&E	ITRON	C1S	854650	08/13/2009	100.09	100.06	100.16	1
LG&E	ITRON	C1S	854651	08/13/2009	100.09	100.10	100.17	1
LG&E	ITRON	C1S	854652	08/13/2009	100.06	100.07	100.15	1
LG&E	ITRON	C1S	854653	08/13/2009	100.09	99.96	99.95	1
LG&E	ITRON	C1S	854654	08/13/2009	100.09	100.02	100.14	1
LG&E	ITRON	C1S	854655	08/13/2009	100.10	100.14	100.13	1
LG&E	ITRON	C1S	854656	08/13/2009	100.07	100.10	100.13	1
LG&E	ITRON	C1S	854657	08/13/2009	100.06	100.13	100.12	1
LG&E	ITRON	C1S	854658	08/13/2009	100.10	100.11	100.23	1
LG&E	ITRON	C1S	854659	08/13/2009	100.08	100.00	100.05	1

LG&E	ITRON	C1S	854660	08/13/2009	100.08	100.09	100.08	1
LG&E	ITRON	C1S	854661	08/13/2009	100.07	100.01	100.14	1
LG&E	ITRON	C1S	854662	08/13/2009	100.05	99.98	100.10	1
LG&E	ITRON	C1S	854663	08/13/2009	100.05	100.03	100.13	1
LG&E	ITRON	C1S	854664	08/13/2009	100.05	99.88	99.97	1
LG&E	ITRON	C1S	854665	08/13/2009	100.06	99.94	100.00	1
LG&E	ITRON	C1S	854666	08/13/2009	100.08	100.02	100.16	1
LG&E	ITRON	C1S	854667	08/13/2009	100.07	99.96	100.15	1
LG&E	ITRON	C1S	854668	08/13/2009	100.06	99.99	100.15	1
LG&E	ITRON	C1S	854669	08/13/2009	100.05	100.05	100.08	1
LG&E	ITRON	C1S	854670	08/13/2009	100.09	100.05	100.15	1
LG&E	ITRON	C1S	854671	08/13/2009	100.07	100.01	100.16	1
LG&E	ITRON	C1S	854672	08/13/2009	100.09	100.07	100.17	1
LG&E	ITRON	C1S	854673	08/13/2009	100.07	100.06	100.16	1
LG&E	ITRON	C1S	854674	08/13/2009	100.06	100.04	100.09	1
LG&E	ITRON	C1S	854675	08/13/2009	100.08	100.02	100.10	1
LG&E	ITRON	C1S	854676	08/13/2009	100.06	99.97	100.20	1
LG&E	ITRON	C1S	854677	08/13/2009	100.06	100.08	100.12	1
LG&E	ITRON	C1S	854678	08/13/2009	100.07	99.96	100.02	1
LG&E	ITRON	C1S	854679	08/13/2009	100.09	100.08	100.09	1
LG&E	ITRON	C1S	854680	08/13/2009	100.06	100.03	100.16	1
LG&E	ITRON	C1S	854681	08/13/2009	100.05	99.95	99.98	1
LG&E	ITRON	C1S	854682	08/13/2009	100.05	100.03	100.14	1
LG&E	ITRON	C1S	854683	08/13/2009	100.08	100.07	100.17	1
LG&E	ITRON	C1S	854684	08/13/2009	100.06	100.01	99.94	1
LG&E	ITRON	C1S	854685	08/13/2009	100.08	100.05	100.21	1
LG&E	ITRON	C1S	854686	08/13/2009	100.07	100.04	100.18	1
LG&E	ITRON	C1S	854687	08/13/2009	100.07	99.96	100.02	1
LG&E	ITRON	C1S	854688	08/13/2009	100.10	100.01	100.01	1
LG&E	ITRON	C1S	854689	08/13/2009	100.05	100.07	100.03	1
LG&E	ITRON	C1S	854690	08/13/2009	100.06	100.04	100.12	1
LG&E	ITRON	C1S	854691	08/13/2009	100.08	100.05	100.10	1
LG&E	ITRON	C1S	854692	08/13/2009	100.09	100.09	100.16	1
LG&E	ITRON	C1S	854693	08/13/2009	100.10	99.98	100.03	1
LG&E	ITRON	C1S	854694	08/13/2009	100.05	99.92	100.07	1

LG&E	ITRON	C1S	854695	08/13/2009	100.09	99.98	100.03	1
LG&E	ITRON	C1S	854696	08/13/2009	100.08	99.90	100.01	1
LG&E	ITRON	C1S	854697	08/13/2009	100.10	100.05	100.16	1
LG&E	ITRON	C1S	854698	08/13/2009	100.08	99.93	100.01	1
LG&E	ITRON	C1S	854699	08/13/2009	100.07	100.06	100.14	1
LG&E	ITRON	C1S	854700	08/13/2009	100.08	99.99	100.00	1
LG&E	ITRON	C1S	854701	08/13/2009	100.06	100.02	100.16	1
LG&E	ITRON	C1S	854702	08/13/2009	100.08	100.06	100.13	1
LG&E	ITRON	C1S	854703	08/13/2009	100.08	100.14	100.16	1
LG&E	ITRON	C1S	854704	08/13/2009	100.09	99.98	100.12	1
LG&E	ITRON	C1S	854705	08/13/2009	100.10	99.91	100.04	1
LG&E	ITRON	C1S	854706	08/13/2009	100.06	99.94	100.03	1
LG&E	ITRON	C1S	854707	08/13/2009	100.09	100.08	100.17	1
LG&E	ITRON	C1S	854708	08/13/2009	100.06	99.94	100.06	1
LG&E	ITRON	C1S	854709	08/13/2009	100.09	99.89	100.09	1
LG&E	ITRON	C1S	854710	08/13/2009	100.08	100.01	100.01	1
LG&E	ITRON	C1S	854711	08/13/2009	100.08	100.01	99.99	1
LG&E	ITRON	C1S	854712	08/13/2009	100.08	100.09	100.14	1
LG&E	ITRON	C1S	854713	08/13/2009	100.08	99.92	99.98	1
LG&E	ITRON	C1S	854714	08/13/2009	100.05	100.09	100.12	1
LG&E	ITRON	C1S	854715	08/13/2009	100.10	99.93	100.08	1
LG&E	ITRON	C1S	854716	08/13/2009	100.08	100.07	100.08	1
LG&E	ITRON	C1S	854717	08/13/2009	100.09	100.09	100.16	1
LG&E	ITRON	C1S	854718	08/13/2009	100.10	100.12	100.27	1
LG&E	ITRON	C1S	854719	08/13/2009	100.08	100.00	100.17	1
LG&E	ITRON	C1S	854720	08/13/2009	100.06	99.96	100.22	1
LG&E	ITRON	C1S	854721	08/13/2009	100.08	100.03	100.25	1
LG&E	ITRON	C1S	854722	08/13/2009	100.08	100.10	100.25	1
LG&E	ITRON	C1S	854723	08/13/2009	100.05	100.07	100.14	1
LG&E	ITRON	C1S	854724	08/13/2009	100.06	100.03	100.08	1
LG&E	ITRON	C1S	854725	08/13/2009	100.08	100.07	100.16	1
LG&E	ITRON	C1S	854726	08/13/2009	100.05	100.02	100.16	1
LG&E	ITRON	C1S	854727	08/13/2009	100.06	99.95	99.95	1
LG&E	ITRON	C1S	854728	08/13/2009	100.08	100.00	100.15	1
LG&E	ITRON	C1S	854729	08/13/2009	100.09	100.13	100.16	1

LG&E	ITRON	C1S	854730	08/13/2009	100.08	99.97	99.94	1
LG&E	ITRON	C1S	854731	08/13/2009	100.09	100.03	100.13	1
LG&E	ITRON	C1S	854732	08/13/2009	100.05	99.93	100.06	1
LG&E	ITRON	C1S	854733	08/13/2009	100.09	100.04	100.24	1
LG&E	ITRON	C1S	854734	08/13/2009	100.09	99.92	100.02	1
LG&E	ITRON	C1S	854735	08/13/2009	100.06	100.06	100.12	1
LG&E	ITRON	C1S	854736	08/13/2009	100.06	99.99	100.14	1
LG&E	ITRON	C1S	854737	08/13/2009	100.05	100.03	100.07	1
LG&E	ITRON	C1S	854738	08/13/2009	100.09	100.09	100.24	1
LG&E	ITRON	C1S	854739	08/13/2009	100.07	100.02	100.27	1
LG&E	ITRON	C1S	854740	08/13/2009	100.09	100.03	100.20	1
LG&E	ITRON	C1S	854741	08/13/2009	100.10	100.14	100.13	1
LG&E	ITRON	C1S	854742	08/13/2009	100.09	100.12	100.15	1
LG&E	ITRON	C1S	854743	08/13/2009	100.08	100.10	100.14	1
LG&E	ITRON	C1S	854744	08/13/2009	100.08	100.04	100.21	1
LG&E	ITRON	C1S	854745	08/13/2009	100.08	100.00	100.02	1
LG&E	ITRON	C1S	854746	08/13/2009	100.09	100.04	100.21	1
LG&E	ITRON	C1S	854747	08/13/2009	100.07	99.85	100.01	1
LG&E	ITRON	C1S	854748	08/13/2009	100.06	99.99	100.08	1
LG&E	ITRON	C1S	854749	08/13/2009	100.05	100.04	100.11	1
LG&E	ITRON	C1S	854750	08/13/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	854751	08/13/2009	100.05	100.02	100.15	1
LG&E	ITRON	C1S	854752	08/13/2009	100.06	99.97	100.10	1
LG&E	ITRON	C1S	854753	08/13/2009	100.10	99.98	100.07	1
LG&E	ITRON	C1S	854754	08/13/2009	100.06	100.06	100.17	1
LG&E	ITRON	C1S	854755	08/13/2009	100.08	99.95	100.05	1
LG&E	ITRON	C1S	854756	08/13/2009	100.05	100.08	100.07	1
LG&E	ITRON	C1S	854757	08/13/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	854758	08/13/2009	100.11	100.12	100.21	1
LG&E	ITRON	C1S	854759	08/13/2009	100.10	100.08	100.19	1
LG&E	ITRON	C1S	854760	08/13/2009	100.08	100.03	100.20	1
LG&E	ITRON	C1S	854761	08/13/2009	100.06	100.09	100.21	1
LG&E	ITRON	C1S	854762	08/13/2009	100.06	100.03	100.09	1
LG&E	ITRON	C1S	854763	08/13/2009	100.06	100.01	100.12	1
LG&E	ITRON	C1S	854764	08/13/2009	100.09	100.12	100.08	1

LG&E	ITRON	C1S	854765	08/13/2009	100.08	99.93	100.02	1
LG&E	ITRON	C1S	854766	08/13/2009	100.09	99.94	100.05	1
LG&E	ITRON	C1S	854767	08/13/2009	100.07	99.99	100.02	1
LG&E	ITRON	C1S	854768	08/13/2009	100.08	100.08	100.22	1
LG&E	ITRON	C1S	854769	08/13/2009	100.08	100.05	100.16	1
LG&E	ITRON	C1S	854770	08/13/2009	100.06	100.04	100.11	1
LG&E	ITRON	C1S	854771	08/13/2009	100.08	99.98	100.11	1
LG&E	ITRON	C1S	854772	08/13/2009	100.06	100.03	100.13	1
LG&E	ITRON	C1S	854773	08/13/2009	100.07	100.03	100.09	1
LG&E	ITRON	C1S	854774	08/13/2009	100.06	100.00	100.11	1
LG&E	ITRON	C1S	854775	08/13/2009	100.08	100.06	100.07	1
LG&E	ITRON	C1S	854776	08/13/2009	100.06	100.06	100.10	1
LG&E	ITRON	C1S	854777	08/13/2009	100.10	100.04	100.03	1
LG&E	ITRON	C1S	854778	08/13/2009	100.10	100.03	99.99	1
LG&E	ITRON	C1S	854779	08/13/2009	100.06	99.95	100.03	1
LG&E	ITRON	C1S	854780	08/13/2009	100.05	100.00	100.12	1
LG&E	ITRON	C1S	854781	08/13/2009	100.07	99.86	100.01	1
LG&E	ITRON	C1S	854782	08/13/2009	100.08	99.92	100.04	1
LG&E	ITRON	C1S	854783	08/13/2009	100.10	100.09	100.16	1
LG&E	ITRON	C1S	854784	08/13/2009	100.08	100.05	100.13	1
LG&E	ITRON	C1S	854785	08/13/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	854786	08/13/2009	100.06	100.13	100.15	1
LG&E	ITRON	C1S	854787	08/13/2009	100.10	100.05	100.14	1
LG&E	ITRON	C1S	854788	08/13/2009	100.07	99.96	100.06	1
LG&E	ITRON	C1S	854789	08/13/2009	100.08	99.95	100.02	1
LG&E	ITRON	C1S	854790	08/13/2009	100.08	100.05	100.13	1
LG&E	ITRON	C1S	854791	08/13/2009	100.05	99.98	100.05	1
LG&E	ITRON	C1S	854792	08/13/2009	100.08	100.04	100.21	1
LG&E	ITRON	C1S	854793	08/13/2009	100.07	100.03	100.14	1
LG&E	ITRON	C1S	854794	08/13/2009	100.06	100.05	100.17	1
LG&E	ITRON	C1S	854795	08/13/2009	100.05	100.05	100.15	1
LG&E	ITRON	C1S	854796	08/13/2009	100.07	99.93	100.03	1
LG&E	ITRON	C1S	854797	08/13/2009	100.06	100.03	100.15	1
LG&E	ITRON	C1S	854798	08/13/2009	100.08	100.09	100.15	1
LG&E	ITRON	C1S	854799	08/13/2009	100.07	100.06	100.18	1

LG&E	ITRON	C1S	854800	08/13/2009	100.08	100.04	100.11	1
LG&E	ITRON	C1S	854801	08/13/2009	100.08	100.01	100.00	1
LG&E	ITRON	C1S	854802	08/13/2009	100.09	100.12	100.16	1
LG&E	ITRON	C1S	854803	08/13/2009	100.10	100.07	100.17	1
LG&E	ITRON	C1S	854804	08/13/2009	100.10	100.07	99.97	1
LG&E	ITRON	C1S	854805	08/13/2009	100.07	100.03	100.18	1
LG&E	ITRON	C1S	854806	08/13/2009	100.09	100.05	100.20	1
LG&E	ITRON	C1S	854807	08/13/2009	100.08	99.98	100.07	1
LG&E	ITRON	C1S	854808	08/13/2009	100.06	100.05	100.13	1
LG&E	ITRON	C1S	854809	08/13/2009	100.06	99.92	100.01	1
LG&E	ITRON	C1S	854810	08/13/2009	100.06	99.88	100.01	1
LG&E	ITRON	C1S	854811	08/13/2009	100.06	99.92	100.01	1
LG&E	ITRON	C1S	854812	08/13/2009	100.09	99.97	99.96	1
LG&E	ITRON	C1S	854813	08/13/2009	100.09	100.00	100.11	1
LG&E	ITRON	C1S	854814	08/13/2009	100.06	99.93	100.02	1
LG&E	ITRON	C1S	854815	08/13/2009	100.08	99.97	100.03	1
LG&E	ITRON	C1S	854816	08/13/2009	100.06	99.94	100.04	1
LG&E	ITRON	C1S	854817	08/13/2009	100.08	99.89	100.02	1
LG&E	ITRON	C1S	854818	08/13/2009	100.08	99.96	100.03	1
LG&E	ITRON	C1S	854819	08/13/2009	100.09	99.98	99.97	1
LG&E	ITRON	C1S	854820	08/13/2009	100.07	99.94	100.06	1
LG&E	ITRON	C1S	854821	08/13/2009	100.09	99.94	100.03	1
LG&E	ITRON	C1S	854822	08/13/2009	100.09	99.97	100.03	1
LG&E	ITRON	C1S	854823	08/13/2009	100.08	100.06	100.21	1
LG&E	ITRON	C1S	854824	08/13/2009	100.07	100.02	100.10	1
LG&E	ITRON	C1S	854825	08/13/2009	100.06	99.99	100.04	1
LG&E	ITRON	C1S	854826	08/13/2009	100.07	99.99	100.04	1
LG&E	ITRON	C1S	854827	08/13/2009	100.08	100.04	100.18	1
LG&E	ITRON	C1S	854828	08/13/2009	100.08	99.92	100.00	1
LG&E	ITRON	C1S	854829	08/13/2009	100.08	99.99	100.06	1
LG&E	ITRON	C1S	854830	08/13/2009	100.10	99.97	100.11	1
LG&E	ITRON	C1S	854831	08/13/2009	100.05	99.87	100.01	1
LG&E	ITRON	C1S	854832	08/13/2009	100.08	99.95	100.08	1
LG&E	ITRON	C1S	854833	08/13/2009	100.08	100.07	100.14	1
LG&E	ITRON	C1S	854834	08/13/2009	100.08	99.92	100.08	1

LG&E	ITRON	C1S	854835	08/13/2009	100.07	100.02	100.14	1
LG&E	ITRON	C1S	854836	08/13/2009	100.08	100.00	100.04	1
LG&E	ITRON	C1S	854837	08/13/2009	100.09	100.06	99.99	1
LG&E	ITRON	C1S	854838	08/13/2009	100.08	99.97	100.02	1
LG&E	ITRON	C1S	854839	08/13/2009	100.08	100.00	100.03	1
LG&E	ITRON	C1S	854840	08/13/2009	100.08	100.00	100.22	1
LG&E	ITRON	C1S	854841	08/13/2009	100.07	100.03	100.04	1
LG&E	ITRON	C1S	854842	08/13/2009	100.09	99.94	100.08	1
LG&E	ITRON	C1S	854843	08/13/2009	100.08	99.94	100.11	1
LG&E	ITRON	C1S	854844	08/13/2009	100.09	99.98	100.13	1
LG&E	ITRON	C1S	854845	08/13/2009	100.06	99.99	100.08	1
LG&E	ITRON	C1S	854846	08/13/2009	100.09	99.93	99.95	1
LG&E	ITRON	C1S	854847	08/13/2009	100.08	99.93	100.03	1
LG&E	ITRON	C1S	854848	08/13/2009	100.07	99.87	99.98	1
LG&E	ITRON	C1S	854849	08/13/2009	100.06	99.98	100.03	1
LG&E	ITRON	C1S	854850	08/13/2009	100.08	99.97	100.06	1
LG&E	ITRON	C1S	854851	08/13/2009	100.08	100.00	100.14	1
LG&E	ITRON	C1S	854852	08/13/2009	100.06	100.03	100.19	1
LG&E	ITRON	C1S	854853	08/13/2009	100.08	100.05	100.06	1
LG&E	ITRON	C1S	854854	08/13/2009	100.05	99.97	100.00	1
LG&E	ITRON	C1S	854855	08/13/2009	100.08	99.94	100.03	1
LG&E	ITRON	C1S	854856	08/13/2009	100.08	100.10	100.17	1
LG&E	ITRON	C1S	854857	08/13/2009	100.09	99.99	100.02	1
LG&E	ITRON	C1S	854858	08/13/2009	100.09	99.98	99.96	1
LG&E	ITRON	C1S	854859	08/13/2009	100.08	100.03	99.98	1
LG&E	ITRON	C1S	854860	08/13/2009	100.05	99.92	99.94	1
LG&E	ITRON	C1S	854861	08/13/2009	100.11	100.04	100.16	1
LG&E	ITRON	C1S	854862	08/13/2009	100.07	99.92	99.97	1
LG&E	ITRON	C1S	854863	08/13/2009	100.10	99.98	100.07	1
LG&E	ITRON	C1S	854864	08/13/2009	100.07	99.95	99.99	1
LG&E	ITRON	C1S	854865	08/13/2009	100.08	99.96	100.00	1
LG&E	ITRON	C1S	854866	08/13/2009	100.08	100.05	100.13	1
LG&E	ITRON	C1S	854867	08/13/2009	100.06	99.92	99.97	1
LG&E	ITRON	C1S	854868	08/13/2009	100.06	99.83	100.03	1
LG&E	ITRON	C1S	854869	08/13/2009	100.06	99.92	99.92	1

LG&E	ITRON	C1S	854870	08/13/2009	100.09	99.92	100.02	1
LG&E	ITRON	C1S	854871	08/13/2009	100.10	100.02	100.07	1
LG&E	ITRON	C1S	854872	08/13/2009	100.06	99.95	100.05	1
LG&E	ITRON	C1S	854873	08/13/2009	100.05	99.90	100.07	1
LG&E	ITRON	C1S	854874	08/13/2009	100.10	100.09	100.18	1
LG&E	ITRON	C1S	854875	08/13/2009	100.06	99.88	100.09	1
LG&E	ITRON	C1S	854876	08/13/2009	100.08	99.93	100.03	1
LG&E	ITRON	C1S	854877	08/13/2009	100.06	99.90	99.91	1
LG&E	ITRON	C1S	854878	08/13/2009	100.08	100.07	100.09	1
LG&E	ITRON	C1S	854879	08/13/2009	100.07	100.04	100.16	1
LG&E	ITRON	C1S	854880	08/13/2009	100.09	100.01	100.03	1
LG&E	ITRON	C1S	854881	08/13/2009	100.06	100.02	100.11	1
LG&E	ITRON	C1S	854882	08/13/2009	100.06	99.91	100.10	1
LG&E	ITRON	C1S	854883	08/13/2009	100.08	99.96	100.10	1
LG&E	ITRON	C1S	854884	08/13/2009	100.08	99.99	99.99	1
LG&E	ITRON	C1S	854885	08/13/2009	100.09	100.04	100.17	1
LG&E	ITRON	C1S	854886	08/13/2009	100.09	100.00	100.04	1
LG&E	ITRON	C1S	854887	08/13/2009	100.10	100.08	100.13	1
LG&E	ITRON	C1S	854888	08/13/2009	100.07	99.96	100.05	1
LG&E	ITRON	C1S	854889	08/13/2009	100.06	100.11	100.12	1
LG&E	ITRON	C1S	854890	08/13/2009	100.07	99.93	100.03	1
LG&E	ITRON	C1S	854891	08/13/2009	100.08	100.09	100.12	1
LG&E	ITRON	C1S	854892	08/13/2009	100.09	99.88	100.05	1
LG&E	ITRON	C1S	854893	08/13/2009	100.10	100.02	100.02	1
LG&E	ITRON	C1S	854894	08/13/2009	100.07	100.03	100.17	1
LG&E	ITRON	C1S	854895	08/13/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1S	854896	08/13/2009	100.07	99.96	100.00	1
LG&E	ITRON	C1S	854897	08/13/2009	100.09	99.97	99.99	1
LG&E	ITRON	C1S	854898	08/13/2009	100.09	100.02	100.10	1
LG&E	ITRON	C1S	854899	08/13/2009	100.09	100.05	100.08	1
LG&E	ITRON	C1S	854900	08/13/2009	100.06	99.99	99.94	1
LG&E	ITRON	C1S	854901	08/13/2009	100.07	99.97	100.13	1
LG&E	ITRON	C1S	854902	08/13/2009	100.08	100.09	100.19	1
LG&E	ITRON	C1S	854903	08/13/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	854904	08/13/2009	100.09	100.06	100.14	1

LG&E	ITRON	C1S	854905	08/13/2009	100.06	99.95	100.02	1
LG&E	ITRON	C1S	854906	08/13/2009	100.08	99.80	100.01	1
LG&E	ITRON	C1S	854907	08/13/2009	100.05	99.94	100.02	1
LG&E	ITRON	C1S	854908	08/13/2009	100.10	100.04	100.09	1
LG&E	ITRON	C1S	854909	08/13/2009	100.08	100.01	99.89	1
LG&E	ITRON	C1S	854910	08/13/2009	100.08	99.93	100.09	1
LG&E	ITRON	C1S	854911	08/13/2009	100.09	99.96	99.98	1
LG&E	ITRON	C1S	854912	08/13/2009	100.09	100.08	100.22	1
LG&E	ITRON	C1S	854913	08/13/2009	100.06	99.90	99.98	1
LG&E	ITRON	C1S	854914	08/13/2009	100.09	99.89	100.14	1
LG&E	ITRON	C1S	854915	08/13/2009	100.08	99.99	100.03	1
LG&E	ITRON	C1S	854916	08/13/2009	100.07	99.92	100.03	1
LG&E	ITRON	C1S	854917	08/13/2009	100.08	99.94	100.01	1
LG&E	ITRON	C1S	854918	08/13/2009	100.08	100.01	99.94	1
LG&E	ITRON	C1S	854919	08/13/2009	100.08	100.05	100.16	1
LG&E	ITRON	C1S	854920	08/13/2009	100.08	100.09	100.13	1
LG&E	ITRON	C1S	854921	08/13/2009	100.09	99.92	100.07	1
LG&E	ITRON	C1S	854922	08/13/2009	100.08	99.94	100.13	1
LG&E	ITRON	C1S	854923	08/13/2009	100.07	99.98	100.02	1
LG&E	ITRON	C1S	854924	08/13/2009	100.06	100.07	100.13	1
LG&E	ITRON	C1S	854925	08/13/2009	100.09	100.06	100.17	1
LG&E	ITRON	C1S	854926	08/13/2009	100.08	99.99	100.12	1
LG&E	ITRON	C1S	854927	08/13/2009	100.06	99.86	100.11	1
LG&E	ITRON	C1S	854928	08/13/2009	100.08	100.00	100.08	1
LG&E	ITRON	C1S	854929	08/13/2009	100.08	100.00	100.03	1
LG&E	ITRON	C1S	854930	08/13/2009	100.09	100.01	100.02	1
LG&E	ITRON	C1S	854931	08/13/2009	100.06	99.82	100.11	1
LG&E	ITRON	C1S	854932	08/13/2009	100.07	100.01	99.99	1
LG&E	ITRON	C1S	854933	08/13/2009	100.06	100.10	100.13	1
LG&E	ITRON	C1S	854934	08/13/2009	100.07	100.01	100.09	1
LG&E	ITRON	C1S	854935	08/13/2009	100.07	100.03	99.95	1
LG&E	ITRON	C1S	854936	08/13/2009	100.09	99.96	100.09	1
LG&E	ITRON	C1S	854937	08/13/2009	100.10	99.97	100.08	1
LG&E	ITRON	C1S	854938	08/13/2009	100.09	99.98	100.07	1
LG&E	ITRON	C1S	854939	08/13/2009	100.08	99.98	100.05	1

LG&E	ITRON	C1S	854940	08/13/2009	100.06	99.91	100.10	1
LG&E	ITRON	C1S	854941	08/13/2009	100.09	100.09	100.20	1
LG&E	ITRON	C1S	854942	08/13/2009	100.09	99.97	100.11	1
LG&E	ITRON	C1S	854943	08/13/2009	100.08	99.95	100.01	1
LG&E	ITRON	C1S	854944	08/13/2009	100.09	99.91	100.07	1
LG&E	ITRON	C1S	854945	08/13/2009	100.07	99.98	100.02	1
LG&E	ITRON	C1S	854946	08/13/2009	100.06	99.92	100.04	1
LG&E	ITRON	C1S	854947	08/13/2009	100.05	99.95	100.00	1
LG&E	ITRON	C1S	854948	08/13/2009	100.09	99.98	100.02	1
LG&E	ITRON	C1S	854949	08/13/2009	100.05	99.97	99.95	1
LG&E	ITRON	C1S	854950	08/13/2009	100.06	99.93	100.00	1
LG&E	ITRON	C1S	854951	08/13/2009	100.07	100.01	100.02	1
LG&E	ITRON	C1S	854952	08/13/2009	100.08	99.95	100.04	1
LG&E	ITRON	C1S	854953	08/13/2009	100.06	99.98	99.96	1
LG&E	ITRON	C1S	854954	08/13/2009	100.06	99.94	100.01	1
LG&E	ITRON	C1S	854955	08/13/2009	100.06	99.94	99.98	1
LG&E	ITRON	C1S	854956	08/13/2009	100.06	100.01	99.94	1
LG&E	ITRON	C1S	854957	08/13/2009	100.09	100.09	100.09	1
LG&E	ITRON	C1S	854958	08/13/2009	100.06	99.91	100.04	1
LG&E	ITRON	C1S	854959	08/13/2009	100.09	99.95	100.13	1
LG&E	ITRON	C1S	854960	08/13/2009	100.10	100.08	100.15	1
LG&E	ITRON	C1S	854961	08/13/2009	100.06	100.04	100.17	1
LG&E	ITRON	C1S	854962	08/13/2009	100.06	100.03	100.06	1
LG&E	ITRON	C1S	854963	08/13/2009	100.07	99.89	99.89	1
LG&E	ITRON	C1S	854964	08/13/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1S	854965	08/13/2009	100.05	100.08	100.17	1
LG&E	ITRON	C1S	854966	08/13/2009	100.08	99.92	100.11	1
LG&E	ITRON	C1S	854967	08/13/2009	100.09	100.07	100.17	1
LG&E	ITRON	C1S	854968	08/13/2009	100.10	99.93	100.01	1
LG&E	ITRON	C1S	854969	08/13/2009	100.06	99.97	99.95	1
LG&E	ITRON	C1S	854970	08/13/2009	100.08	100.03	100.13	1
LG&E	ITRON	C1S	854971	08/13/2009	100.09	99.90	100.11	1
LG&E	ITRON	C1S	854972	08/13/2009	100.07	100.02	99.99	1
LG&E	ITRON	C1S	854973	08/13/2009	100.07	100.00	99.97	1
LG&E	ITRON	C1S	854974	08/13/2009	100.06	100.02	99.96	1

LG&E	ITRON	C1S	854975	08/13/2009	100.08	99.89	100.06	1
LG&E	ITRON	C1S	854976	08/13/2009	100.05	99.89	99.90	1
LG&E	ITRON	C1S	854977	08/13/2009	100.07	99.89	99.94	1
LG&E	ITRON	C1S	854978	08/13/2009	100.05	100.04	99.95	1
LG&E	ITRON	C1S	854979	08/13/2009	100.10	99.92	100.09	1
LG&E	ITRON	C1S	854980	08/13/2009	100.08	100.10	100.20	1
LG&E	ITRON	C1S	854981	08/13/2009	100.07	100.08	100.17	1
LG&E	ITRON	C1S	854982	08/13/2009	100.07	99.92	100.11	1
LG&E	ITRON	C1S	854983	08/13/2009	100.09	99.94	100.07	1
LG&E	ITRON	C1S	854984	08/13/2009	100.06	100.05	99.95	1
LG&E	ITRON	C1S	854985	08/13/2009	100.07	99.98	100.10	1
LG&E	ITRON	C1S	854986	08/13/2009	100.08	99.92	100.09	1
LG&E	ITRON	C1S	854987	08/13/2009	100.07	100.09	100.16	1
LG&E	ITRON	C1S	854988	08/13/2009	100.06	99.96	100.13	1
LG&E	ITRON	C1S	854989	08/13/2009	100.08	99.89	100.02	1
LG&E	ITRON	C1S	854990	08/13/2009	100.08	100.05	100.05	1
LG&E	ITRON	C1S	854991	08/13/2009	100.07	99.94	99.93	1
LG&E	ITRON	C1S	854992	08/13/2009	100.07	99.88	100.04	1
LG&E	ITRON	C1S	854993	08/13/2009	100.10	100.09	100.18	1
LG&E	ITRON	C1S	854994	08/13/2009	100.07	99.91	99.98	1
LG&E	ITRON	C1S	854995	08/13/2009	100.06	99.95	99.94	1
LG&E	ITRON	C1S	854996	08/13/2009	100.09	99.99	100.04	1
LG&E	ITRON	C1S	854997	08/13/2009	100.06	99.96	99.97	1
LG&E	ITRON	C1S	854998	08/13/2009	100.08	99.94	100.16	1
LG&E	ITRON	C1S	854999	08/13/2009	100.06	99.92	100.03	1
LG&E	ITRON	C1S	855000	08/13/2009	100.09	99.92	100.10	1
LG&E	ITRON	C1S	855001	08/13/2009	100.09	99.96	100.19	1
LG&E	ITRON	C1S	855002	08/13/2009	100.08	100.00	100.08	1
LG&E	ITRON	C1S	855003	08/13/2009	100.07	99.97	100.08	1
LG&E	ITRON	C1S	855004	08/13/2009	100.07	99.92	100.10	1
LG&E	ITRON	C1S	855005	08/13/2009	100.08	99.96	99.97	1
LG&E	ITRON	C1S	855006	08/13/2009	100.09	99.93	100.06	1
LG&E	ITRON	C1S	855007	08/13/2009	100.07	100.05	100.14	1
LG&E	ITRON	C1S	855008	08/13/2009	100.06	100.02	100.00	1
LG&E	ITRON	C1S	855009	08/13/2009	100.09	100.02	100.05	1

LG&E	ITRON	C1S	855010	08/13/2009	100.07	100.03	99.99	1
LG&E	ITRON	C1S	855011	08/13/2009	100.05	99.97	99.94	1
LG&E	ITRON	C1S	855012	08/13/2009	100.10	100.06	100.20	1
LG&E	ITRON	C1S	855013	08/13/2009	100.06	99.94	99.98	1
LG&E	ITRON	C1S	855014	08/13/2009	100.07	100.13	100.14	1
LG&E	ITRON	C1S	855015	08/13/2009	100.09	100.06	100.24	1
LG&E	ITRON	C1S	855016	08/13/2009	100.09	99.99	99.98	1
LG&E	ITRON	C1S	855017	08/13/2009	100.09	99.93	100.03	1
LG&E	ITRON	C1S	855018	08/13/2009	100.08	99.93	99.94	1
LG&E	ITRON	C1S	855019	08/13/2009	100.06	99.93	100.06	1
LG&E	ITRON	C1S	855020	08/13/2009	100.05	99.94	100.06	1
LG&E	ITRON	C1S	855021	08/13/2009	100.09	99.98	99.98	1
LG&E	ITRON	C1S	855022	08/13/2009	100.10	99.94	100.08	1
LG&E	ITRON	C1S	855023	08/13/2009	100.07	99.93	99.92	1
LG&E	ITRON	C1S	855024	08/13/2009	100.08	99.99	99.97	1
LG&E	ITRON	C1S	855025	08/13/2009	100.10	100.03	100.05	1
LG&E	ITRON	C1S	855026	08/13/2009	100.08	99.99	99.96	1
LG&E	ITRON	C1S	855027	08/13/2009	100.07	99.88	100.13	1
LG&E	ITRON	C1S	855028	08/13/2009	100.08	99.99	100.00	1
LG&E	ITRON	C1S	855029	08/13/2009	100.09	99.97	100.04	1
LG&E	ITRON	C1S	855030	08/13/2009	100.05	99.93	99.99	1
LG&E	ITRON	C1S	855031	08/13/2009	100.09	99.98	100.01	1
LG&E	ITRON	C1S	855032	08/13/2009	100.06	99.93	99.94	1
LG&E	ITRON	C1S	855033	08/13/2009	100.05	99.89	99.98	1
LG&E	ITRON	C1S	855034	08/13/2009	100.07	99.98	99.99	1
LG&E	ITRON	C1S	855035	08/13/2009	100.10	100.03	100.21	1
LG&E	ITRON	C1S	855036	08/13/2009	100.09	99.91	99.97	1
LG&E	ITRON	C1S	855037	08/13/2009	100.06	99.91	100.02	1
LG&E	ITRON	C1S	855038	08/13/2009	100.08	99.94	100.09	1
LG&E	ITRON	C1S	855039	08/13/2009	100.07	100.09	100.09	1
LG&E	ITRON	C1S	855040	08/13/2009	100.09	99.97	100.04	1
LG&E	ITRON	C1S	855041	08/13/2009	100.08	100.07	100.11	1
LG&E	ITRON	C1S	855042	08/13/2009	100.10	100.01	100.02	1
LG&E	ITRON	C1S	855043	08/13/2009	100.07	100.01	100.03	1
LG&E	ITRON	C1S	855044	08/13/2009	100.10	100.10	100.20	1

LG&E	ITRON	C1S	855045	08/13/2009	100.09	100.10	100.18	1
LG&E	ITRON	C1S	855046	08/13/2009	100.06	100.03	100.19	1
LG&E	ITRON	C1S	855047	08/13/2009	100.09	100.02	100.10	1
LG&E	ITRON	C1S	855048	08/13/2009	100.07	100.00	100.11	1
LG&E	ITRON	C1S	855049	08/13/2009	100.08	100.06	100.15	1
LG&E	ITRON	C1S	855050	08/13/2009	100.06	100.05	100.06	1
LG&E	ITRON	C1S	855051	08/13/2009	100.08	99.94	100.06	1
LG&E	ITRON	C1S	855052	08/13/2009	100.05	99.96	100.06	1
LG&E	ITRON	C1S	855053	08/13/2009	100.07	99.92	99.98	1
LG&E	ITRON	C1S	855054	08/13/2009	100.05	99.99	100.10	1
LG&E	ITRON	C1S	855055	08/13/2009	100.07	100.05	100.12	1
LG&E	ITRON	C1S	855056	08/13/2009	100.06	99.92	100.00	1
LG&E	ITRON	C1S	855057	08/13/2009	100.09	99.99	100.03	1
LG&E	ITRON	C1S	855058	08/13/2009	100.06	99.95	100.00	1
LG&E	ITRON	C1S	855059	08/13/2009	100.07	100.01	100.02	1
LG&E	ITRON	C1S	855060	08/13/2009	100.09	100.03	100.04	1
LG&E	ITRON	C1S	855061	08/13/2009	100.06	99.88	99.98	1
LG&E	ITRON	C1S	855062	08/13/2009	100.09	99.98	100.04	1
LG&E	ITRON	C1S	855063	08/13/2009	100.07	99.93	100.04	1
LG&E	ITRON	C1S	855064	08/13/2009	100.05	99.93	100.03	1
LG&E	ITRON	C1S	855065	08/13/2009	100.10	100.02	100.01	1
LG&E	ITRON	C1S	855066	08/13/2009	100.06	100.03	100.19	1
LG&E	ITRON	C1S	855067	08/13/2009	100.06	100.05	100.07	1
LG&E	ITRON	C1S	855068	08/13/2009	100.10	99.93	100.11	1
LG&E	ITRON	C1S	855069	08/13/2009	100.08	99.94	99.99	1
LG&E	ITRON	C1S	855070	08/13/2009	100.08	99.99	100.00	1
LG&E	ITRON	C1S	855071	08/13/2009	100.06	99.93	100.05	1
LG&E	ITRON	C1S	855072	08/13/2009	100.10	99.97	100.05	1
LG&E	ITRON	C1S	855073	08/13/2009	100.08	100.01	100.17	1
LG&E	ITRON	C1S	855074	08/13/2009	100.05	100.00	100.06	1
LG&E	ITRON	C1S	855075	08/13/2009	100.09	99.96	100.09	1
LG&E	ITRON	C1S	855076	08/13/2009	100.08	99.97	99.98	1
LG&E	ITRON	C1S	855077	08/13/2009	100.07	100.03	100.14	1
LG&E	ITRON	C1S	855078	08/13/2009	100.09	99.95	100.11	1
LG&E	ITRON	C1S	855079	08/13/2009	100.08	100.03	100.06	1

LG&E	ITRON	C1S	855080	08/13/2009	100.08	99.90	100.03	1
LG&E	ITRON	C1S	855081	08/13/2009	100.10	100.05	100.18	1
LG&E	ITRON	C1S	855082	08/13/2009	100.05	99.97	100.12	1
LG&E	ITRON	C1S	855083	08/13/2009	100.07	99.95	99.97	1
LG&E	ITRON	C1S	855084	08/13/2009	100.08	99.91	100.03	1
LG&E	ITRON	C1S	855085	08/13/2009	100.06	100.05	100.26	1
LG&E	ITRON	C1S	855086	08/13/2009	100.08	100.13	100.19	1
LG&E	ITRON	C1S	855087	08/13/2009	100.06	99.88	100.03	1
LG&E	ITRON	C1S	855088	08/13/2009	100.06	100.05	100.16	1
LG&E	ITRON	C1S	855089	08/13/2009	100.10	99.99	100.14	1
LG&E	ITRON	C1S	855090	08/13/2009	100.08	100.05	100.15	1
LG&E	ITRON	C1S	855091	08/13/2009	100.08	99.90	100.11	1
LG&E	ITRON	C1S	855092	08/13/2009	100.06	99.95	99.97	1
LG&E	ITRON	C1S	855093	08/13/2009	100.05	99.92	100.02	1
LG&E	ITRON	C1S	855094	08/13/2009	100.07	99.97	99.96	1
LG&E	ITRON	C1S	855095	08/13/2009	100.09	99.97	99.97	1
LG&E	ITRON	C1S	855096	08/13/2009	100.10	100.00	100.09	1
LG&E	ITRON	C1S	855097	08/13/2009	100.06	99.84	100.03	1
LG&E	ITRON	C1S	855098	08/13/2009	100.10	99.96	100.09	1
LG&E	ITRON	C1S	855099	08/13/2009	100.09	99.94	99.97	1
LG&E	ITRON	C1S	855100	08/13/2009	100.08	99.95	100.03	1
LG&E	ITRON	C1S	855101	08/13/2009	100.07	99.99	99.99	1
LG&E	ITRON	C1S	855102	08/13/2009	100.07	99.92	100.06	1
LG&E	ITRON	C1S	855103	08/13/2009	100.06	99.93	99.92	1
LG&E	ITRON	C1S	855104	08/13/2009	100.10	99.98	100.06	1
LG&E	ITRON	C1S	855105	08/13/2009	100.07	99.91	100.02	1
LG&E	ITRON	C1S	855106	08/13/2009	100.09	100.04	100.00	1
LG&E	ITRON	C1S	855107	08/13/2009	100.06	99.95	99.97	1
LG&E	ITRON	C1S	855108	08/13/2009	100.10	100.01	100.22	1
LG&E	ITRON	C1S	855109	08/13/2009	100.06	99.88	100.03	1
LG&E	ITRON	C1S	855110	08/13/2009	100.06	99.87	99.97	1
LG&E	ITRON	C1S	855111	08/13/2009	100.08	99.94	100.00	1
LG&E	ITRON	C1S	855112	08/13/2009	100.09	100.01	100.03	1
LG&E	ITRON	C1S	855113	08/13/2009	100.06	99.93	99.98	1
LG&E	ITRON	C1S	855114	08/13/2009	100.07	99.95	100.00	1

LG&E	ITRON	C1S	855115	08/13/2009	100.08	100.00	100.12	1
LG&E	ITRON	C1S	855116	08/13/2009	100.09	99.94	100.07	1
LG&E	ITRON	C1S	855117	08/13/2009	100.09	99.97	100.06	1
LG&E	ITRON	C1S	855118	08/13/2009	100.06	99.88	100.08	1
LG&E	ITRON	C1S	855119	08/13/2009	100.09	100.00	100.03	1
LG&E	ITRON	C1S	855120	08/13/2009	100.07	100.00	100.18	1
LG&E	ITRON	C1S	855121	08/13/2009	100.07	99.96	99.96	1
LG&E	ITRON	C1S	855122	08/13/2009	100.09	99.99	100.01	1
LG&E	ITRON	C1S	855123	08/13/2009	100.10	100.00	99.98	1
LG&E	ITRON	C1S	855124	08/13/2009	100.07	99.96	100.04	1
LG&E	ITRON	C1S	855125	08/13/2009	100.09	99.94	100.04	1
LG&E	ITRON	C1S	855126	08/13/2009	100.06	100.04	100.10	1
LG&E	ITRON	C1S	855127	08/13/2009	100.06	99.94	100.04	1
LG&E	ITRON	C1S	855128	08/13/2009	100.10	99.94	100.03	1
LG&E	ITRON	C1S	855129	08/13/2009	100.08	99.95	100.17	1
LG&E	ITRON	C1S	855130	08/13/2009	100.07	100.07	100.22	1
LG&E	ITRON	C1S	855131	08/13/2009	100.08	100.07	100.08	1
LG&E	ITRON	C1S	855132	08/13/2009	100.08	99.96	100.01	1
LG&E	ITRON	C1S	855133	08/13/2009	100.10	99.95	99.98	1
LG&E	ITRON	C1S	855134	08/13/2009	100.09	100.04	100.14	1
LG&E	ITRON	C1S	855135	08/13/2009	100.05	100.04	100.15	1
LG&E	ITRON	C1S	855136	08/13/2009	100.10	100.02	100.12	1
LG&E	ITRON	C1S	855137	08/13/2009	100.08	100.07	100.16	1
LG&E	ITRON	C1S	855138	08/13/2009	100.07	100.03	100.23	1
LG&E	ITRON	C1S	855139	08/13/2009	100.08	100.00	100.18	1
LG&E	ITRON	C1S	855140	08/13/2009	100.09	100.08	100.11	1
LG&E	ITRON	C1S	855141	08/13/2009	100.06	100.07	100.17	1
LG&E	ITRON	C1S	855142	08/13/2009	100.09	100.12	100.25	1
LG&E	ITRON	C1S	855143	08/13/2009	100.08	100.02	100.18	1
LG&E	ITRON	C1S	855144	08/13/2009	100.09	100.07	100.14	1
LG&E	ITRON	C1S	855145	08/13/2009	100.07	100.05	99.91	1
LG&E	ITRON	C1S	855146	08/13/2009	100.08	99.91	100.04	1
LG&E	ITRON	C1S	855147	08/13/2009	100.06	99.91	100.14	1
LG&E	ITRON	C1S	855148	08/13/2009	100.09	100.00	100.16	1
LG&E	ITRON	C1S	855149	08/13/2009	100.08	100.03	100.03	1

LG&E	ITRON	C1S	855150	08/13/2009	100.09	100.06	100.17	1
LG&E	ITRON	C1S	855151	08/13/2009	100.09	100.10	100.14	1
LG&E	ITRON	C1S	855152	08/13/2009	100.08	100.10	100.21	1
LG&E	ITRON	C1S	855153	08/13/2009	100.08	100.07	100.17	1
LG&E	ITRON	C1S	855154	08/13/2009	100.07	100.01	100.13	1
LG&E	ITRON	C1S	855155	08/13/2009	100.07	99.90	99.98	1
LG&E	ITRON	C1S	855156	08/13/2009	100.06	99.90	100.01	1
LG&E	ITRON	C1S	855157	08/13/2009	100.05	99.91	99.99	1
LG&E	ITRON	C1S	855158	08/13/2009	100.07	99.93	99.93	1
LG&E	ITRON	C1S	855159	08/13/2009	100.09	100.09	100.16	1
LG&E	ITRON	C1S	855160	08/13/2009	100.04	99.96	100.12	1
LG&E	ITRON	C1S	855161	08/13/2009	100.07	99.98	100.13	1
LG&E	ITRON	C1S	855162	08/13/2009	100.08	99.91	100.09	1
LG&E	ITRON	C1S	855163	08/13/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	855164	08/13/2009	100.08	100.02	99.96	1
LG&E	ITRON	C1S	855165	08/13/2009	100.05	99.93	100.08	1
LG&E	ITRON	C1S	855166	08/13/2009	100.08	100.08	100.10	1
LG&E	ITRON	C1S	855167	08/13/2009	100.09	99.94	100.06	1
LG&E	ITRON	C1S	855168	08/13/2009	100.06	100.07	100.09	1
LG&E	ITRON	C1S	855169	08/13/2009	100.10	100.03	100.07	1
LG&E	ITRON	C1S	855170	08/13/2009	100.05	99.92	99.96	1
LG&E	ITRON	C1S	855171	08/13/2009	100.08	99.96	100.15	1
LG&E	ITRON	C1S	855172	08/13/2009	100.07	99.90	100.05	1
LG&E	ITRON	C1S	855173	08/13/2009	100.05	99.88	100.03	1
LG&E	ITRON	C1S	855174	08/13/2009	100.08	99.95	99.96	1
LG&E	ITRON	C1S	855175	08/13/2009	100.08	99.96	100.03	1
LG&E	ITRON	C1S	855176	08/13/2009	100.10	100.03	100.15	1
LG&E	ITRON	C1S	855177	08/13/2009	100.05	99.98	100.05	1
LG&E	ITRON	C1S	855178	08/13/2009	100.09	100.08	100.14	1
LG&E	ITRON	C1S	855179	08/13/2009	100.06	100.02	100.15	1
LG&E	ITRON	C1S	855180	08/13/2009	100.08	100.02	100.14	1
LG&E	ITRON	C1S	855181	08/13/2009	100.05	99.91	100.03	1
LG&E	ITRON	C1S	855182	08/13/2009	100.09	100.03	100.14	1
LG&E	ITRON	C1S	855183	08/13/2009	100.07	99.86	100.05	1
LG&E	ITRON	C1S	855184	08/13/2009	100.06	99.86	100.12	1

LG&E	ITRON	C1S	855185	08/13/2009	100.08	99.97	99.98	1
LG&E	ITRON	C1S	855186	08/13/2009	100.08	99.95	100.15	1
LG&E	ITRON	C1S	855187	08/13/2009	100.09	99.93	100.09	1
LG&E	ITRON	C1S	855188	08/13/2009	100.07	99.94	99.97	1
LG&E	ITRON	C1S	855189	08/13/2009	100.06	100.00	100.15	1
LG&E	ITRON	C1S	855190	08/13/2009	100.06	99.99	100.19	1
LG&E	ITRON	C1S	855191	08/13/2009	100.08	100.05	100.16	1
LG&E	ITRON	C1S	855192	08/13/2009	100.07	100.09	100.20	1
LG&E	ITRON	C1S	855193	08/13/2009	100.06	99.90	100.06	1
LG&E	ITRON	C1S	855194	08/13/2009	100.10	100.00	100.17	1
LG&E	ITRON	C1S	855195	08/13/2009	100.08	100.08	100.12	1
LG&E	ITRON	C1S	855196	08/13/2009	100.09	100.08	100.10	1
LG&E	ITRON	C1S	855197	08/13/2009	100.06	100.05	100.20	1
LG&E	ITRON	C1S	855198	08/13/2009	100.06	100.06	100.14	1
LG&E	ITRON	C1S	855199	08/13/2009	100.09	99.92	100.04	1
LG&E	ITRON	C1S	855200	08/13/2009	100.05	99.90	100.06	1
LG&E	ITRON	C1S	855201	08/13/2009	100.08	100.07	100.15	1
LG&E	ITRON	C1S	855202	08/13/2009	100.07	100.02	99.97	1
LG&E	ITRON	C1S	855203	08/13/2009	100.07	99.97	100.04	1
LG&E	ITRON	C1S	855204	08/13/2009	100.08	99.94	99.98	1
LG&E	ITRON	C1S	855205	08/13/2009	100.07	99.97	100.07	1
LG&E	ITRON	C1S	855206	08/13/2009	100.10	99.99	100.02	1
LG&E	ITRON	C1S	855207	08/13/2009	100.09	99.94	100.05	1
LG&E	ITRON	C1S	855208	08/13/2009	100.09	99.98	100.02	1
LG&E	ITRON	C1S	855209	08/13/2009	100.06	99.94	100.00	1
LG&E	ITRON	C1S	855210	08/13/2009	100.07	99.93	100.03	1
LG&E	ITRON	C1S	855211	08/13/2009	100.06	100.03	100.17	1
LG&E	ITRON	C1S	855212	08/13/2009	100.08	99.97	99.97	1
LG&E	ITRON	C1S	855213	08/13/2009	100.08	99.92	100.08	1
LG&E	ITRON	C1S	855214	08/13/2009	100.09	99.93	100.09	1
LG&E	ITRON	C1S	855215	08/13/2009	100.07	99.92	100.00	1
LG&E	ITRON	C1S	855216	08/13/2009	100.07	100.04	100.12	1
LG&E	ITRON	C1S	855217	08/13/2009	100.07	100.07	100.16	1
LG&E	ITRON	C1S	855218	08/13/2009	100.09	100.05	100.20	1
LG&E	ITRON	C1S	855219	08/13/2009	100.08	100.02	100.02	1

LG&E	ITRON	C1S	855220	08/13/2009	100.05	100.07	100.15	1
LG&E	ITRON	C1S	855221	08/13/2009	100.06	99.90	99.98	1
LG&E	ITRON	C1S	855222	08/13/2009	100.07	100.00	99.99	1
LG&E	ITRON	C1S	855223	08/13/2009	100.06	100.08	100.09	1
LG&E	ITRON	C1S	855224	08/13/2009	100.10	100.11	100.17	1
LG&E	ITRON	C1S	855225	08/13/2009	100.08	99.93	100.05	1
LG&E	ITRON	C1S	855226	08/13/2009	100.07	99.95	100.17	1
LG&E	ITRON	C1S	855227	08/13/2009	100.07	99.98	100.02	1
LG&E	ITRON	C1S	855228	08/13/2009	100.09	99.99	100.11	1
LG&E	ITRON	C1S	855229	08/13/2009	100.06	100.08	100.13	1
LG&E	ITRON	C1S	855230	08/13/2009	100.08	99.91	100.01	1
LG&E	ITRON	C1S	855231	08/13/2009	100.09	99.91	100.14	1
LG&E	ITRON	C1S	855232	08/13/2009	100.05	99.96	99.97	1
LG&E	ITRON	C1S	855233	08/13/2009	100.08	100.08	100.14	1
LG&E	ITRON	C1S	855234	08/13/2009	100.07	99.98	99.98	1
LG&E	ITRON	C1S	855235	08/13/2009	100.08	99.95	100.06	1
LG&E	ITRON	C1S	855236	08/13/2009	100.05	99.90	99.99	1
LG&E	ITRON	C1S	855237	08/13/2009	100.07	100.04	100.07	1
LG&E	ITRON	C1S	855238	08/13/2009	100.10	100.04	100.09	1
LG&E	ITRON	C1S	855239	08/13/2009	100.08	100.01	100.00	1
LG&E	ITRON	C1S	855240	08/13/2009	100.08	99.95	99.98	1
LG&E	ITRON	C1S	855241	08/13/2009	100.05	100.01	99.92	1
LG&E	ITRON	C1S	855242	08/13/2009	100.10	100.04	100.17	1
LG&E	ITRON	C1S	855243	08/13/2009	100.06	99.92	100.04	1
LG&E	ITRON	C1S	855244	08/13/2009	100.05	100.00	100.11	1
LG&E	ITRON	C1S	855245	08/13/2009	100.06	99.88	100.02	1
LG&E	ITRON	C1S	855246	08/13/2009	100.09	99.99	100.02	1
LG&E	ITRON	C1S	855247	08/13/2009	100.06	99.90	99.98	1
LG&E	ITRON	C1S	855248	08/13/2009	100.08	100.08	100.23	1
LG&E	ITRON	C1S	855249	08/13/2009	100.06	100.05	100.05	1
LG&E	ITRON	C1S	855250	08/13/2009	100.09	100.05	100.19	1
LG&E	ITRON	C1S	855251	08/13/2009	100.05	99.85	100.03	1
LG&E	ITRON	C1S	855252	08/13/2009	100.10	100.03	100.02	1
LG&E	ITRON	C1S	855253	08/13/2009	100.09	100.11	100.13	1
LG&E	ITRON	C1S	855254	08/13/2009	100.06	100.01	100.14	1

LG&E	ITRON	C1S	855255	08/13/2009	100.09	99.92	100.01	1
LG&E	ITRON	C1S	855256	08/13/2009	100.09	100.02	100.09	1
LG&E	ITRON	C1S	855257	08/13/2009	100.06	99.96	100.09	1
LG&E	ITRON	C1S	855258	08/13/2009	100.07	99.94	100.09	1
LG&E	ITRON	C1S	855259	08/13/2009	100.08	100.04	100.01	1
LG&E	ITRON	C1S	855260	08/13/2009	100.10	100.00	100.05	1
LG&E	ITRON	C1S	855261	08/13/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	855262	08/13/2009	100.07	99.97	100.14	1
LG&E	ITRON	C1S	855263	08/13/2009	100.06	99.99	100.05	1
LG&E	ITRON	C1S	855264	08/13/2009	100.06	99.99	99.97	1
LG&E	ITRON	C1S	855265	08/13/2009	100.06	99.90	100.01	1
LG&E	ITRON	C1S	855266	08/13/2009	100.08	100.03	100.05	1
LG&E	ITRON	C1S	855267	08/13/2009	100.07	100.01	100.08	1
LG&E	ITRON	C1S	855268	08/13/2009	100.09	99.99	100.07	1
LG&E	ITRON	C1S	855269	08/13/2009	100.06	99.99	100.08	1
LG&E	ITRON	C1S	855270	08/13/2009	100.09	100.04	100.18	1
LG&E	ITRON	C1S	855271	08/13/2009	100.08	100.00	100.17	1
LG&E	ITRON	C1S	855272	08/13/2009	100.08	100.02	100.16	1
LG&E	ITRON	C1S	855273	08/13/2009	100.09	99.87	99.97	1
LG&E	ITRON	C1S	855274	08/13/2009	100.08	100.02	100.12	1
LG&E	ITRON	C1S	855275	08/13/2009	100.08	100.09	100.15	1
LG&E	ITRON	C1S	855276	08/13/2009	100.09	100.02	100.07	1
LG&E	ITRON	C1S	855277	08/13/2009	100.06	99.93	100.02	1
LG&E	ITRON	C1S	855278	08/13/2009	100.08	99.96	100.06	1
LG&E	ITRON	C1S	855279	08/13/2009	100.07	100.07	100.17	1
LG&E	ITRON	C1S	855280	08/13/2009	100.09	99.97	100.04	1
LG&E	ITRON	C1S	855281	08/13/2009	100.08	100.08	100.11	1
LG&E	ITRON	C1S	855282	08/13/2009	100.06	99.94	99.97	1
LG&E	ITRON	C1S	855283	08/13/2009	100.06	99.99	100.05	1
LG&E	ITRON	C1S	855284	08/13/2009	100.06	99.92	100.01	1
LG&E	ITRON	C1S	855285	08/13/2009	100.05	99.97	100.05	1
LG&E	ITRON	C1S	855286	08/13/2009	100.06	100.03	100.07	1
LG&E	ITRON	C1S	855287	08/13/2009	100.05	100.07	100.18	1
LG&E	ITRON	C1S	855288	08/13/2009	100.06	100.02	100.05	1
LG&E	ITRON	C1S	855289	08/13/2009	100.10	99.97	99.92	1

LG&E	ITRON	C1S	855290	08/13/2009	100.06	99.94	100.00	1
LG&E	ITRON	C1S	855291	08/13/2009	100.10	99.90	100.06	1
LG&E	ITRON	C1S	855292	08/13/2009	100.05	99.97	100.00	1
LG&E	ITRON	C1S	855293	08/13/2009	100.09	99.94	100.04	1
LG&E	ITRON	C1S	855294	08/13/2009	100.10	99.94	100.08	1
LG&E	ITRON	C1S	855295	08/13/2009	100.10	100.01	99.99	1
LG&E	ITRON	C1S	855296	08/13/2009	100.08	100.06	100.09	1
LG&E	ITRON	C1S	855297	08/13/2009	100.08	99.96	100.03	1
LG&E	ITRON	C1S	855298	08/13/2009	100.09	99.98	100.04	1
LG&E	ITRON	C1S	855299	08/13/2009	100.05	99.97	100.05	1
LG&E	ITRON	C1S	855300	08/13/2009	100.07	99.93	99.98	1
LG&E	ITRON	C1S	855301	08/13/2009	100.07	99.92	100.14	1
LG&E	ITRON	C1S	855302	08/13/2009	100.07	99.81	100.04	1
LG&E	ITRON	C1S	855303	08/13/2009	100.07	99.96	99.90	1
LG&E	ITRON	C1S	855304	08/13/2009	100.09	100.08	100.12	1
LG&E	ITRON	C1S	855305	08/13/2009	100.05	99.91	100.01	1
LG&E	ITRON	C1S	855306	08/13/2009	100.07	100.00	100.01	1
LG&E	ITRON	C1S	855307	08/13/2009	100.10	100.03	99.94	1
LG&E	ITRON	C1S	855308	08/13/2009	100.10	99.98	100.18	1
LG&E	ITRON	C1S	855309	08/13/2009	100.09	100.03	100.02	1
LG&E	ITRON	C1S	855310	08/13/2009	100.07	100.11	100.18	1
LG&E	ITRON	C1S	855311	08/13/2009	100.09	99.94	100.10	1
LG&E	ITRON	C1S	855312	08/13/2009	100.06	100.01	100.09	1
LG&E	ITRON	C1S	855313	08/13/2009	100.09	99.98	100.08	1
LG&E	ITRON	C1S	855314	08/13/2009	100.05	99.94	100.00	1
LG&E	ITRON	C1S	855315	08/13/2009	100.05	99.93	99.88	1
LG&E	ITRON	C1S	855316	08/13/2009	100.06	100.04	100.13	1
LG&E	ITRON	C1S	855317	08/13/2009	100.07	100.01	100.01	1
LG&E	ITRON	C1S	855318	08/13/2009	100.08	99.93	99.98	1
LG&E	ITRON	C1S	855319	08/13/2009	100.07	100.06	100.15	1
LG&E	ITRON	C1S	855320	08/13/2009	100.09	100.09	100.16	1
LG&E	ITRON	C1S	855321	08/13/2009	100.07	99.99	100.03	1
LG&E	ITRON	C1S	855322	08/13/2009	100.09	99.91	100.01	1
LG&E	ITRON	C1S	855323	08/13/2009	100.07	99.93	99.98	1
LG&E	ITRON	C1S	855324	08/13/2009	100.10	99.95	100.11	1

LG&E	ITRON	C1S	855325	08/13/2009	100.05	99.92	100.00	1
LG&E	ITRON	C1S	855326	08/13/2009	100.08	99.97	100.10	1
LG&E	ITRON	C1S	855327	08/13/2009	100.07	100.09	100.03	1
LG&E	ITRON	C1S	855328	08/13/2009	100.09	100.12	100.18	1
LG&E	ITRON	C1S	855329	08/13/2009	100.09	99.98	100.08	1
LG&E	ITRON	C1S	855330	08/13/2009	100.08	100.02	99.98	1
LG&E	ITRON	C1S	855331	08/13/2009	100.08	100.08	100.20	1
LG&E	ITRON	C1S	855332	08/13/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	855333	08/13/2009	100.07	99.95	100.06	1
LG&E	ITRON	C1S	855334	08/13/2009	100.08	99.98	100.04	1
LG&E	ITRON	C1S	855335	08/13/2009	100.06	99.95	100.06	1
LG&E	ITRON	C1S	855336	08/13/2009	100.08	99.94	100.11	1
LG&E	ITRON	C1S	855337	08/13/2009	100.06	99.96	100.14	1
LG&E	ITRON	C1S	855338	08/13/2009	100.08	100.08	100.21	1
LG&E	ITRON	C1S	855339	08/13/2009	100.06	99.96	99.97	1
LG&E	ITRON	C1S	855340	08/13/2009	100.08	99.96	100.08	1
LG&E	ITRON	C1S	855341	08/13/2009	100.06	100.10	100.10	1
LG&E	ITRON	C1S	855342	08/13/2009	100.10	100.06	100.19	1
LG&E	ITRON	C1S	855343	08/13/2009	100.06	100.04	100.15	1
LG&E	ITRON	C1S	855344	08/13/2009	100.06	100.08	100.16	1
LG&E	ITRON	C1S	855345	08/13/2009	100.06	100.11	100.16	1
LG&E	ITRON	C1S	855346	08/13/2009	100.06	99.94	100.12	1
LG&E	ITRON	C1S	855347	08/13/2009	100.06	99.98	100.04	1
LG&E	ITRON	C1S	855348	08/13/2009	100.06	100.05	100.12	1
LG&E	ITRON	C1S	855349	08/13/2009	100.07	99.90	100.03	1
LG&E	ITRON	C1S	855350	08/13/2009	100.07	99.97	99.97	1
LG&E	ITRON	C1S	855351	08/13/2009	100.05	99.82	100.10	1
LG&E	ITRON	C1S	855352	08/13/2009	100.08	99.96	100.06	1
LG&E	ITRON	C1S	855353	08/13/2009	100.06	99.88	100.04	1
LG&E	ITRON	C1S	855354	08/13/2009	100.09	100.00	100.17	1
LG&E	ITRON	C1S	855355	08/13/2009	100.08	99.99	100.07	1
LG&E	ITRON	C1S	855356	08/13/2009	100.07	100.02	100.10	1
LG&E	ITRON	C1S	855357	08/13/2009	100.08	99.96	99.95	1
LG&E	ITRON	C1S	855358	08/13/2009	100.05	99.93	100.12	1
LG&E	ITRON	C1S	855359	08/13/2009	100.09	100.05	99.98	1

LG&E	ITRON	C1S	855360	08/13/2009	100.09	100.08	100.17	1
LG&E	ITRON	C1S	855361	08/13/2009	100.09	100.16	100.14	1
LG&E	ITRON	C1S	855362	08/13/2009	100.07	99.92	100.07	1
LG&E	ITRON	C1S	855363	08/13/2009	100.06	99.95	100.11	1
LG&E	ITRON	C1S	855364	08/13/2009	100.08	100.02	100.00	1
LG&E	ITRON	C1S	855365	08/13/2009	100.08	100.09	100.23	1
LG&E	ITRON	C1S	855366	08/13/2009	100.09	100.10	100.19	1
LG&E	ITRON	C1S	855367	08/13/2009	100.09	99.91	100.07	1
LG&E	ITRON	C1S	855368	08/13/2009	100.06	99.81	100.08	1
LG&E	ITRON	C1S	855369	08/13/2009	100.06	99.93	99.98	1
LG&E	ITRON	C1S	855370	08/13/2009	100.09	99.94	99.99	1
LG&E	ITRON	C1S	855371	08/13/2009	100.05	99.92	99.98	1
LG&E	ITRON	C1S	855372	08/13/2009	100.06	99.87	100.12	1
LG&E	ITRON	C1S	855373	08/13/2009	100.05	99.89	99.89	1
LG&E	ITRON	C1S	855374	08/13/2009	100.08	100.02	99.99	1
LG&E	ITRON	C1S	855375	08/13/2009	100.08	99.93	99.99	1
LG&E	ITRON	C1S	855376	08/13/2009	100.07	100.09	100.06	1
LG&E	ITRON	C1S	855377	08/13/2009	100.09	100.01	100.05	1
LG&E	ITRON	C1S	855378	08/13/2009	100.07	99.89	100.07	1
LG&E	ITRON	C1S	855379	08/13/2009	100.07	99.99	99.96	1
LG&E	ITRON	C1S	855380	08/13/2009	100.10	100.02	100.07	1
LG&E	ITRON	C1S	855381	08/13/2009	100.08	100.10	100.22	1
LG&E	ITRON	C1S	855382	08/13/2009	100.06	99.91	99.99	1
LG&E	ITRON	C1S	855383	08/13/2009	100.06	99.91	100.09	1
LG&E	ITRON	C1S	855384	08/13/2009	100.10	100.08	100.24	1
LG&E	ITRON	C1S	855385	08/13/2009	100.06	99.88	100.03	1
LG&E	ITRON	C1S	855386	08/13/2009	100.10	99.97	100.06	1
LG&E	ITRON	C1S	855387	08/13/2009	100.09	99.94	99.97	1
LG&E	ITRON	C1S	855388	08/13/2009	100.09	100.06	100.14	1
LG&E	ITRON	C1S	855389	08/13/2009	100.10	99.93	100.04	1
LG&E	ITRON	C1S	855390	08/13/2009	100.06	99.90	100.00	1
LG&E	ITRON	C1S	855391	08/13/2009	100.09	99.92	100.03	1
LG&E	ITRON	C1S	855392	08/13/2009	100.06	99.86	100.05	1
LG&E	ITRON	C1S	855393	08/13/2009	100.07	100.04	100.07	1
LG&E	ITRON	C1S	855394	08/13/2009	100.07	99.92	99.99	1

LG&E	ITRON	C1S	855395	08/13/2009	100.08	99.91	100.11	1
LG&E	ITRON	C1S	855396	08/13/2009	100.05	99.96	100.00	1
LG&E	ITRON	C1S	855397	08/13/2009	100.07	99.87	100.07	1
LG&E	ITRON	C1S	855398	08/13/2009	100.07	100.02	100.19	1
LG&E	ITRON	C1S	855399	08/13/2009	100.07	99.95	100.04	1
LG&E	ITRON	C1S	855400	08/13/2009	100.08	99.96	99.97	1
LG&E	ITRON	C1S	855401	08/13/2009	100.09	99.97	100.05	1
LG&E	ITRON	C1S	855402	08/13/2009	100.08	99.95	99.99	1
LG&E	ITRON	C1S	855403	08/13/2009	100.07	99.91	100.07	1
LG&E	ITRON	C1S	855404	08/13/2009	100.05	99.93	100.08	1
LG&E	ITRON	C1S	855405	08/13/2009	100.10	100.12	100.24	1
LG&E	ITRON	C1S	855406	08/13/2009	100.08	99.93	100.00	1
LG&E	ITRON	C1S	855407	08/13/2009	100.06	99.87	99.98	1
LG&E	ITRON	C1S	855408	08/13/2009	100.06	100.07	100.01	1
LG&E	ITRON	C1S	855409	08/13/2009	100.10	100.03	100.02	1
LG&E	ITRON	C1S	855410	08/13/2009	100.06	100.00	100.09	1
LG&E	ITRON	C1S	855411	08/13/2009	100.10	100.11	100.14	1
LG&E	ITRON	C1S	855412	08/13/2009	100.06	99.94	100.03	1
LG&E	ITRON	C1S	855413	08/13/2009	100.09	99.98	100.05	1
LG&E	ITRON	C1S	855414	08/13/2009	100.09	100.04	100.10	1
LG&E	ITRON	C1S	855415	08/13/2009	100.09	100.05	99.97	1
LG&E	ITRON	C1S	855416	08/13/2009	100.08	100.09	100.22	1
LG&E	ITRON	C1S	855417	08/13/2009	100.10	99.91	100.00	1
LG&E	ITRON	C1S	855418	08/13/2009	100.06	99.92	100.07	1
LG&E	ITRON	C1S	855419	08/13/2009	100.08	100.12	100.11	1
LG&E	ITRON	C1S	855420	08/13/2009	100.08	99.97	100.12	1
LG&E	ITRON	C1S	855421	08/13/2009	100.06	100.03	100.18	1
LG&E	ITRON	C1S	855422	08/13/2009	100.10	100.06	100.16	1
LG&E	ITRON	C1S	855423	08/13/2009	100.08	99.93	100.01	1
LG&E	ITRON	C1S	855424	08/13/2009	100.07	99.95	99.94	1
LG&E	ITRON	C1S	855425	08/13/2009	100.06	99.96	100.08	1
LG&E	ITRON	C1S	855426	08/13/2009	100.06	100.17	100.13	1
LG&E	ITRON	C1S	855427	08/13/2009	100.06	100.08	100.06	1
LG&E	ITRON	C1S	855428	08/13/2009	100.10	100.06	100.13	1
LG&E	ITRON	C1S	855429	08/13/2009	100.07	100.06	100.20	1

LG&E	ITRON	CIS	855430	08/13/2009	100.07	99.94	99.93	1
LG&E	ITRON	CIS	855431	08/13/2009	100.10	100.03	100.08	1
LG&E	ITRON	CIS	855432	08/13/2009	100.08	100.07	100.04	1
LG&E	ITRON	CIS	855433	08/13/2009	100.09	99.93	100.04	1
LG&E	ITRON	CIS	855434	08/13/2009	100.06	99.85	100.12	1
LG&E	ITRON	CIS	855435	08/13/2009	100.09	100.07	100.12	1
LG&E	ITRON	CIS	855436	08/13/2009	100.09	99.98	100.03	1
LG&E	ITRON	CIS	855437	08/13/2009	100.06	99.96	100.20	1
LG&E	ITRON	CIS	855438	08/13/2009	100.05	99.86	100.04	1
LG&E	ITRON	CIS	855439	08/13/2009	100.08	100.00	100.00	1
LG&E	ITRON	CIS	855440	08/13/2009	100.08	100.01	100.06	1
LG&E	ITRON	CIS	855441	08/13/2009	100.07	99.97	99.94	1
LG&E	ITRON	CIS	855442	08/13/2009	100.08	99.95	100.04	1
LG&E	ITRON	CIS	855443	08/13/2009	100.06	99.89	100.07	1
LG&E	ITRON	CIS	855444	08/13/2009	100.09	99.97	99.98	1
LG&E	ITRON	CIS	855445	08/13/2009	100.10	99.94	100.05	1
LG&E	ITRON	CIS	855446	08/13/2009	100.05	99.92	99.91	1
LG&E	ITRON	CIS	855447	08/13/2009	100.08	100.06	100.16	1
LG&E	ITRON	CIS	855448	08/13/2009	100.07	100.01	99.97	1
LG&E	ITRON	CIS	855449	08/13/2009	100.07	99.98	99.98	1
LG&E	ITRON	CIS	855450	08/13/2009	100.08	100.04	100.19	1
LG&E	ITRON	CIS	855451	08/13/2009	100.05	100.08	100.08	1
LG&E	ITRON	CIS	855452	08/13/2009	100.08	99.96	99.96	1
LG&E	ITRON	CIS	855453	08/13/2009	100.09	99.97	100.03	1
LG&E	ITRON	CIS	855454	08/13/2009	100.05	99.94	99.98	1
LG&E	ITRON	CIS	855455	08/13/2009	100.05	99.93	99.95	1
LG&E	ITRON	CIS	855456	08/13/2009	100.10	100.03	100.02	1
LG&E	ITRON	CIS	855457	08/13/2009	100.07	99.88	100.00	1
LG&E	ITRON	CIS	855458	08/13/2009	100.10	100.09	100.15	1
LG&E	ITRON	CIS	855459	08/13/2009	100.07	99.87	100.06	1
LG&E	ITRON	CIS	855460	08/13/2009	100.11	99.93	100.15	1
LG&E	ITRON	CIS	855461	08/13/2009	100.10	99.94	100.01	1
LG&E	ITRON	CIS	855462	08/13/2009	100.07	100.11	100.12	1
LG&E	ITRON	CIS	855463	08/13/2009	100.06	99.97	100.04	1
LG&E	ITRON	CIS	855464	08/13/2009	100.09	99.96	99.97	1

LG&E	ITRON	C1S	855465	08/13/2009	100.07	100.05	100.16	1
LG&E	ITRON	C1S	855466	08/13/2009	100.09	100.00	99.94	1
LG&E	ITRON	C1S	855467	08/13/2009	100.05	99.94	100.15	1
LG&E	ITRON	C1S	855468	08/13/2009	100.06	99.98	100.09	1
LG&E	ITRON	C1S	855469	08/13/2009	100.05	100.03	100.17	1
LG&E	ITRON	C1S	855470	08/13/2009	100.06	100.05	100.15	1
LG&E	ITRON	C1S	855471	08/13/2009	100.07	99.93	100.06	1
LG&E	ITRON	C1S	855472	08/13/2009	100.06	99.99	100.18	1
LG&E	ITRON	C1S	855473	08/13/2009	100.07	99.98	100.06	1
LG&E	ITRON	C1S	855474	08/13/2009	100.06	99.93	99.99	1
LG&E	ITRON	C1S	855475	08/13/2009	100.08	99.97	100.03	1
LG&E	ITRON	C1S	855476	08/13/2009	100.08	99.92	100.00	1
LG&E	ITRON	C1S	855477	08/13/2009	100.10	99.93	100.11	1
LG&E	ITRON	C1S	855478	08/13/2009	100.07	99.93	100.06	1
LG&E	ITRON	C1S	855479	08/13/2009	100.07	100.01	100.07	1
LG&E	ITRON	C1S	855480	08/13/2009	100.07	100.09	100.14	1
LG&E	ITRON	C1S	855481	08/13/2009	100.05	100.02	100.14	1
LG&E	ITRON	C1S	855482	08/13/2009	100.05	100.03	100.10	1
LG&E	ITRON	C1S	855483	08/13/2009	100.06	99.97	100.01	1
LG&E	ITRON	C1S	855484	08/13/2009	100.09	100.03	100.06	1
LG&E	ITRON	C1S	855485	08/13/2009	100.06	100.09	100.12	1
LG&E	ITRON	C1S	855486	08/13/2009	100.09	99.92	100.08	1
LG&E	ITRON	C1S	855487	08/13/2009	100.06	99.95	100.07	1
LG&E	ITRON	C1S	855488	08/13/2009	100.09	100.08	100.18	1
LG&E	ITRON	C1S	855489	08/13/2009	100.08	100.05	100.01	1
LG&E	ITRON	C1S	855490	08/13/2009	100.10	100.05	100.07	1
LG&E	ITRON	C1S	855491	08/13/2009	100.07	100.06	100.06	1
LG&E	ITRON	C1S	855492	08/13/2009	100.07	99.90	100.09	1
LG&E	ITRON	C1S	855493	08/13/2009	100.06	100.05	100.14	1
LG&E	ITRON	C1S	855494	08/13/2009	100.08	99.94	100.08	1
LG&E	ITRON	C1S	855495	08/13/2009	100.10	99.96	100.00	1
LG&E	ITRON	C1S	855496	08/13/2009	100.05	99.94	99.99	1
LG&E	ITRON	C1S	855497	08/13/2009	100.08	99.99	99.97	1
LG&E	ITRON	C1S	855498	08/13/2009	100.06	100.00	100.03	1
LG&E	ITRON	C1S	855499	08/13/2009	100.10	100.05	100.03	1

LG&E	ITRON	C1S	855500	08/13/2009	100.08	99.93	99.95	1
LG&E	ITRON	C1S	855501	08/13/2009	100.08	99.95	100.04	1
LG&E	ITRON	C1S	855502	08/13/2009	100.08	99.95	100.01	1
LG&E	ITRON	C1S	855503	08/13/2009	100.11	100.06	100.20	1
LG&E	ITRON	C1S	855504	08/13/2009	100.10	99.99	100.04	1
LG&E	ITRON	C1S	855505	08/13/2009	100.09	99.94	99.96	1
LG&E	ITRON	C1S	855506	08/13/2009	100.05	99.84	99.98	1
LG&E	ITRON	C1S	855507	08/13/2009	100.10	100.01	100.03	1
LG&E	ITRON	C1S	855508	08/13/2009	100.06	99.93	100.06	1
LG&E	ITRON	C1S	855509	08/13/2009	100.07	99.97	100.04	1
LG&E	ITRON	C1S	855510	08/13/2009	100.06	99.95	99.96	1
LG&E	ITRON	C1S	855511	08/13/2009	100.10	99.98	100.08	1
LG&E	ITRON	C1S	855512	08/13/2009	100.05	99.96	100.03	1
LG&E	ITRON	C1S	855513	08/13/2009	100.05	99.89	99.88	1
LG&E	ITRON	C1S	855514	08/13/2009	100.07	100.06	100.10	1
LG&E	ITRON	C1S	855515	08/13/2009	100.07	100.00	99.98	1
LG&E	ITRON	C1S	855516	08/13/2009	100.08	99.91	100.04	1
LG&E	ITRON	C1S	855517	08/13/2009	100.07	100.05	100.20	1
LG&E	ITRON	C1S	855518	08/13/2009	100.06	100.03	100.09	1
LG&E	ITRON	C1S	855519	08/13/2009	100.06	100.10	100.15	1
LG&E	ITRON	C1S	855520	08/13/2009	100.09	99.92	100.12	1
LG&E	ITRON	C1S	855521	08/13/2009	100.09	99.96	99.98	1
LG&E	ITRON	C1S	855522	08/13/2009	100.08	99.95	100.00	1
LG&E	ITRON	C1S	855523	08/13/2009	100.10	100.10	100.09	1
LG&E	ITRON	C1S	855524	08/13/2009	100.09	99.99	100.02	1
LG&E	ITRON	C1S	855525	08/13/2009	100.05	99.82	100.11	1
LG&E	ITRON	C1S	855526	08/13/2009	100.06	99.92	99.97	1
LG&E	ITRON	C1S	855527	08/13/2009	100.06	99.98	99.94	1
LG&E	ITRON	C1S	855528	08/13/2009	100.06	100.08	100.24	1
LG&E	ITRON	C1S	855529	08/13/2009	100.07	99.97	100.05	1
LG&E	ITRON	C1S	855530	08/13/2009	100.06	99.94	99.94	1
LG&E	ITRON	C1S	855531	08/13/2009	100.07	99.94	100.08	1
LG&E	ITRON	C1S	855532	08/13/2009	100.10	99.98	100.12	1
LG&E	ITRON	C1S	855533	08/13/2009	100.06	100.08	100.19	1
LG&E	ITRON	C1S	855534	08/13/2009	100.05	99.91	100.06	1

LG&E	ITRON	C1S	855535	08/13/2009	100.06	99.95	99.96	1
LG&E	ITRON	C1S	855536	08/13/2009	100.07	99.99	100.16	1
LG&E	ITRON	C1S	855537	08/13/2009	100.06	99.98	100.00	1
LG&E	ITRON	C1S	855538	08/13/2009	100.06	100.06	100.13	1
LG&E	ITRON	C1S	855539	08/13/2009	100.08	99.99	100.01	1
LG&E	ITRON	C1S	855540	08/13/2009	100.10	100.00	100.01	1
LG&E	ITRON	C1S	855541	08/13/2009	100.08	99.99	99.92	1
LG&E	ITRON	C1S	855542	08/13/2009	100.05	99.91	99.97	1
LG&E	ITRON	C1S	855543	08/13/2009	100.06	99.99	100.15	1
LG&E	ITRON	C1S	855544	08/13/2009	100.06	99.94	99.97	1
LG&E	ITRON	C1S	855545	08/13/2009	100.08	99.95	100.06	1
LG&E	ITRON	C1S	855546	08/13/2009	100.06	99.94	100.10	1
LG&E	ITRON	C1S	855547	08/13/2009	100.10	99.97	100.12	1
LG&E	ITRON	C1S	855548	08/13/2009	100.09	99.90	99.94	1
LG&E	ITRON	C1S	855549	08/13/2009	100.07	99.99	100.17	1
LG&E	ITRON	C1S	855550	08/13/2009	100.09	100.00	100.02	1
LG&E	ITRON	C1S	855551	08/13/2009	100.08	99.88	100.02	1
LG&E	ITRON	C1S	855552	08/13/2009	100.07	99.89	100.13	1
LG&E	ITRON	C1S	855553	08/13/2009	100.08	99.95	99.94	1
LG&E	ITRON	C1S	855554	08/13/2009	100.07	99.89	100.08	1
LG&E	ITRON	C1S	855555	08/13/2009	100.09	100.06	100.17	1
LG&E	ITRON	C1S	855556	08/13/2009	100.08	99.88	100.05	1
LG&E	ITRON	C1S	855557	08/13/2009	100.06	100.02	100.08	1
LG&E	ITRON	C1S	855558	08/13/2009	100.06	100.06	100.07	1
LG&E	ITRON	C1S	855559	08/13/2009	100.10	99.98	100.04	1
LG&E	ITRON	C1S	855560	08/13/2009	100.07	100.02	100.00	1
LG&E	ITRON	C1S	855561	08/13/2009	100.08	100.02	100.03	1
LG&E	ITRON	C1S	855562	08/13/2009	100.09	99.94	100.04	1
LG&E	ITRON	C1S	855563	08/13/2009	100.08	99.92	100.06	1
LG&E	ITRON	C1S	855564	08/13/2009	100.07	99.96	99.98	1
LG&E	ITRON	C1S	855565	08/13/2009	100.07	100.06	100.09	1
LG&E	ITRON	C1S	855566	08/13/2009	100.05	99.85	99.96	1
LG&E	ITRON	C1S	855567	08/13/2009	100.06	99.92	100.08	1
LG&E	ITRON	C1S	855568	08/13/2009	100.07	99.93	100.00	1
LG&E	ITRON	C1S	855569	08/13/2009	100.10	100.03	100.00	1

LG&E	ITRON	C1S	855570	08/13/2009	100.06	99.91	100.03	1
LG&E	ITRON	C1S	855571	08/13/2009	100.05	100.00	100.04	1
LG&E	ITRON	C1S	855572	08/13/2009	100.07	100.01	100.18	1
LG&E	ITRON	C1S	855573	08/13/2009	100.10	99.97	100.13	1
LG&E	ITRON	C1S	855574	08/13/2009	100.06	99.96	100.01	1
LG&E	ITRON	C1S	855575	08/13/2009	100.07	99.98	100.01	1
LG&E	ITRON	C1S	855576	08/13/2009	100.08	99.92	100.07	1
LG&E	ITRON	C1S	855577	08/13/2009	100.08	99.97	100.01	1
LG&E	ITRON	C1S	855578	08/13/2009	100.06	100.04	100.01	1
LG&E	ITRON	C1S	855579	08/13/2009	100.06	99.93	100.00	1
LG&E	ITRON	C1S	855580	08/13/2009	100.07	99.94	100.05	1
LG&E	ITRON	C1S	855581	08/13/2009	100.08	99.93	99.92	1
LG&E	ITRON	C1S	855582	08/13/2009	100.09	99.97	100.03	1
LG&E	ITRON	C1S	855583	08/13/2009	100.06	100.07	100.16	1
LG&E	ITRON	C1S	855584	08/13/2009	100.10	99.98	100.19	1
LG&E	ITRON	C1S	855585	08/13/2009	100.07	99.99	100.04	1
LG&E	ITRON	C1S	855586	08/13/2009	100.06	100.04	100.20	1
LG&E	ITRON	C1S	855587	08/13/2009	100.08	100.12	100.13	1
LG&E	ITRON	C1S	855588	08/13/2009	100.07	99.92	100.05	1
LG&E	ITRON	C1S	855589	08/13/2009	100.06	99.95	100.03	1
LG&E	ITRON	C1S	855590	08/13/2009	100.09	100.02	100.06	1
LG&E	ITRON	C1S	855591	08/13/2009	100.07	100.05	100.07	1
LG&E	ITRON	C1S	855592	08/13/2009	100.08	99.98	100.03	1
LG&E	ITRON	C1S	855593	08/13/2009	100.08	99.91	100.08	1
LG&E	ITRON	C1S	855594	08/13/2009	100.06	99.97	100.10	1
LG&E	ITRON	C1S	855595	08/13/2009	100.06	100.05	100.09	1
LG&E	ITRON	C1S	855596	08/13/2009	100.08	99.90	100.08	1
LG&E	ITRON	C1S	855597	08/13/2009	100.06	99.98	99.98	1
LG&E	ITRON	C1S	855598	08/13/2009	100.06	100.03	99.98	1
LG&E	ITRON	C1S	855599	08/13/2009	100.06	99.97	100.04	1
LG&E	ITRON	C1S	855600	08/13/2009	100.07	100.05	100.02	1
LG&E	ITRON	C1S	855601	08/13/2009	100.06	100.00	100.01	1
LG&E	ITRON	C1S	855602	08/13/2009	100.09	99.97	100.14	1
LG&E	ITRON	C1S	855603	08/13/2009	100.08	100.01	100.01	1
LG&E	ITRON	C1S	855604	08/13/2009	100.09	100.04	100.00	1

LG&E	ITRON	C1S	855605	08/13/2009	100.06	100.00	99.97	1
LG&E	ITRON	C1S	855606	08/13/2009	100.10	100.02	100.05	1
LG&E	ITRON	C1S	855607	08/13/2009	100.09	100.13	100.10	1
LG&E	ITRON	C1S	855608	08/13/2009	100.08	100.07	100.17	1
LG&E	ITRON	C1S	855609	08/13/2009	100.09	99.97	100.05	1
LG&E	ITRON	C1S	855610	08/13/2009	100.05	99.97	100.02	1
LG&E	ITRON	C1S	855611	08/13/2009	100.08	100.02	99.98	1
LG&E	ITRON	C1S	855612	08/13/2009	100.06	99.91	99.97	1
LG&E	ITRON	C1S	855613	08/13/2009	100.10	100.15	100.17	1
LG&E	ITRON	C1S	855614	08/13/2009	100.07	99.96	99.98	1
LG&E	ITRON	C1S	855615	08/13/2009	100.10	100.08	100.21	1
LG&E	ITRON	C1S	855616	08/13/2009	100.06	99.96	99.97	1
LG&E	ITRON	C1S	855617	08/13/2009	100.07	99.94	99.94	1
LG&E	ITRON	C1S	855618	08/13/2009	100.06	100.01	100.07	1
LG&E	ITRON	C1S	855619	08/13/2009	100.06	100.00	100.10	1
LG&E	ITRON	C1S	855620	08/13/2009	100.07	99.92	100.07	1
LG&E	ITRON	C1S	855621	08/13/2009	100.09	100.11	100.16	1
LG&E	ITRON	C1S	855622	08/13/2009	100.06	99.93	100.07	1
LG&E	ITRON	C1S	855623	08/13/2009	100.05	100.03	100.04	1
LG&E	ITRON	C1S	855624	08/13/2009	100.07	99.96	100.04	1
LG&E	ITRON	C1S	855625	08/13/2009	100.07	100.03	100.19	1
LG&E	ITRON	C1S	855626	08/13/2009	100.10	99.95	100.00	1
LG&E	ITRON	C1S	855627	08/13/2009	100.08	99.95	100.06	1
LG&E	ITRON	C1S	855628	08/13/2009	100.05	99.98	100.12	1
LG&E	ITRON	C1S	855629	08/13/2009	100.09	100.07	100.06	1
LG&E	ITRON	C1S	855630	08/13/2009	100.06	99.90	99.99	1
LG&E	ITRON	C1S	855631	08/13/2009	100.06	99.91	100.01	1
LG&E	ITRON	C1S	855632	08/13/2009	100.09	99.99	100.06	1
LG&E	ITRON	C1S	855633	08/13/2009	100.09	100.00	100.14	1
LG&E	ITRON	C1S	855634	08/13/2009	100.06	100.01	100.02	1
LG&E	ITRON	C1S	855635	08/13/2009	100.08	99.96	100.06	1
LG&E	ITRON	C1S	855636	08/13/2009	100.09	100.01	100.10	1
LG&E	ITRON	C1S	855637	08/13/2009	100.05	99.91	100.04	1
LG&E	ITRON	C1S	855638	08/13/2009	100.09	100.00	99.98	1
LG&E	ITRON	C1S	855639	08/13/2009	100.07	100.13	100.16	1

LG&E	ITRON	C1S	855640	08/13/2009	100.08	99.99	100.04	1
LG&E	ITRON	C1S	855641	08/13/2009	100.06	100.01	100.09	1
LG&E	ITRON	C1S	855642	08/13/2009	100.06	99.90	100.05	1
LG&E	ITRON	C1S	855643	08/13/2009	100.05	99.95	99.98	1
LG&E	ITRON	C1S	855644	08/13/2009	100.08	99.95	100.04	1
LG&E	ITRON	C1S	855645	08/13/2009	100.10	100.09	100.19	1
LG&E	ITRON	C1S	855646	08/13/2009	100.06	99.92	99.99	1
LG&E	ITRON	C1S	855647	08/13/2009	100.08	100.03	100.10	1
LG&E	ITRON	C1S	855648	08/13/2009	100.05	99.98	99.92	1
LG&E	ITRON	C1S	855649	08/13/2009	100.06	99.93	100.03	1
LG&E	ITRON	C1S	855650	08/13/2009	100.06	100.01	100.18	1
LG&E	ITRON	C1S	855651	08/13/2009	100.09	100.02	100.12	1
LG&E	ITRON	C1S	855652	08/13/2009	100.07	99.99	99.97	1
LG&E	ITRON	C1S	855653	08/13/2009	100.06	99.92	99.93	1
LG&E	ITRON	C1S	855654	08/13/2009	100.08	99.98	100.08	1
LG&E	ITRON	C1S	855655	08/13/2009	100.06	99.98	100.01	1
LG&E	ITRON	C1S	855656	08/13/2009	100.08	100.02	100.17	1
LG&E	ITRON	C1S	855657	08/13/2009	100.07	100.10	100.14	1
LG&E	ITRON	C1S	855658	08/13/2009	100.06	100.02	100.11	1
LG&E	ITRON	C1S	855659	08/13/2009	100.07	100.06	100.11	1
LG&E	ITRON	C1S	855660	08/13/2009	100.06	100.02	100.14	1
LG&E	ITRON	C1S	855661	08/13/2009	100.08	99.98	100.01	1
LG&E	ITRON	C1S	855662	08/13/2009	100.06	100.02	100.16	1
LG&E	ITRON	C1S	855663	08/13/2009	100.08	100.09	100.19	1
LG&E	ITRON	C1S	855664	08/13/2009	100.08	99.93	100.04	1
LG&E	ITRON	C1S	855665	08/13/2009	100.05	100.00	100.11	1
LG&E	ITRON	C1S	855666	08/13/2009	100.10	100.05	100.15	1
LG&E	ITRON	C1S	855667	08/13/2009	100.07	99.97	100.03	1
LG&E	ITRON	C1S	855668	08/13/2009	100.05	99.97	100.20	1
LG&E	ITRON	C1S	855669	08/13/2009	100.09	99.99	100.04	1
LG&E	ITRON	C1S	855670	08/13/2009	100.07	99.94	100.09	1
LG&E	ITRON	C1S	855671	08/13/2009	100.07	100.08	100.09	1
LG&E	ITRON	C1S	855672	08/13/2009	100.06	100.08	100.12	1
LG&E	ITRON	C1S	855673	08/13/2009	100.08	99.90	99.91	1
LG&E	ITRON	C1S	855674	08/13/2009	100.08	99.91	100.09	1

LG&E	ITRON	C1S	855675	08/13/2009	100.06	99.94	99.96	1
LG&E	ITRON	C1S	855676	08/13/2009	100.06	99.96	100.08	1
LG&E	ITRON	C1S	855677	08/13/2009	100.08	99.92	100.09	1
LG&E	ITRON	C1S	855678	08/13/2009	100.07	99.92	100.14	1
LG&E	ITRON	C1S	855679	08/13/2009	100.09	99.99	100.01	1
LG&E	ITRON	C1S	855680	08/13/2009	100.09	99.91	99.96	1
LG&E	ITRON	C1S	855681	08/13/2009	100.07	100.00	100.04	1
LG&E	ITRON	C1S	855682	08/13/2009	100.06	99.97	99.98	1
LG&E	ITRON	C1S	855683	08/13/2009	100.08	99.99	100.03	1
LG&E	ITRON	C1S	855684	08/13/2009	100.07	99.97	99.97	1
LG&E	ITRON	C1S	855685	08/13/2009	100.06	99.92	99.96	1
LG&E	ITRON	C1S	855686	08/13/2009	100.10	100.00	100.03	1
LG&E	ITRON	C1S	855687	08/13/2009	100.07	99.97	100.01	1
LG&E	ITRON	C1S	855688	08/13/2009	100.07	100.00	99.97	1
LG&E	ITRON	C1S	855689	08/13/2009	100.08	100.02	100.02	1
LG&E	ITRON	C1S	855690	08/13/2009	100.08	99.97	100.06	1
LG&E	ITRON	C1S	855691	08/13/2009	100.08	99.95	100.07	1
LG&E	ITRON	C1S	855692	08/13/2009	100.10	100.04	100.01	1
LG&E	ITRON	C1S	855693	08/13/2009	100.09	100.01	99.99	1
LG&E	ITRON	C1S	855694	08/13/2009	100.07	99.98	100.03	1
LG&E	ITRON	C1S	855695	08/13/2009	100.08	99.97	100.08	1
LG&E	ITRON	C1S	855696	08/13/2009	100.06	99.91	99.97	1
LG&E	ITRON	C1S	855697	08/13/2009	100.06	99.92	100.00	1
LG&E	ITRON	C1S	855698	08/13/2009	100.08	100.01	100.00	1
LG&E	ITRON	C1S	855699	08/13/2009	100.10	100.00	100.05	1
LG&E	ITRON	C1S	855700	08/13/2009	100.07	99.89	99.98	1
LG&E	ITRON	C1S	855701	08/13/2009	100.10	100.10	100.24	1
LG&E	ITRON	C1S	855702	08/13/2009	100.08	100.09	100.16	1
LG&E	ITRON	C1S	855703	08/13/2009	100.10	100.06	100.14	1
LG&E	ITRON	C1S	855704	08/13/2009	100.09	100.08	100.19	1
LG&E	ITRON	C1S	855705	08/13/2009	100.07	99.94	100.05	1
LG&E	ITRON	C1S	855706	08/13/2009	100.07	100.06	100.17	1
LG&E	ITRON	C1S	856211	12/09/2009	100.10	100.03	100.13	1
LG&E	ITRON	C1S	856212	12/09/2009	100.05	99.86	100.03	1
LG&E	ITRON	C1S	856213	12/09/2009	100.06	99.92	99.92	1

LG&E	ITRON	C1S	856214	12/09/2009	100.08	99.94	100.05	1
LG&E	ITRON	C1S	856215	12/09/2009	100.09	99.92	99.93	1
LG&E	ITRON	C1S	856216	12/09/2009	100.10	100.06	100.15	1
LG&E	ITRON	C1S	856217	12/09/2009	100.07	99.91	99.95	1
LG&E	ITRON	C1S	856218	12/09/2009	100.08	100.00	99.91	1
LG&E	ITRON	C1S	856219	12/09/2009	100.08	99.94	99.97	1
LG&E	ITRON	C1S	856220	12/09/2009	100.06	99.90	100.02	1
LG&E	ITRON	C1S	856221	12/09/2009	100.09	99.94	100.02	1
LG&E	ITRON	C1S	856222	12/09/2009	100.06	99.87	99.94	1
LG&E	ITRON	C1S	856223	12/09/2009	100.06	99.89	99.90	1
LG&E	ITRON	C1S	856224	12/09/2009	100.08	100.06	100.13	1
LG&E	ITRON	C1S	856225	12/09/2009	100.09	99.94	100.07	1
LG&E	ITRON	C1S	856226	12/09/2009	100.09	99.90	100.06	1
LG&E	ITRON	C1S	856227	12/09/2009	100.09	100.03	100.16	1
LG&E	ITRON	C1S	856228	12/09/2009	100.05	99.85	99.90	1
LG&E	ITRON	C1S	856229	12/09/2009	100.08	99.88	99.84	1
LG&E	ITRON	C1S	856230	12/09/2009	100.09	100.08	100.07	1
LG&E	ITRON	C1S	856231	12/09/2009	100.08	99.90	100.03	1
LG&E	ITRON	C1S	856232	12/09/2009	100.09	99.91	100.08	1
LG&E	ITRON	C1S	856233	12/09/2009	100.07	100.04	100.06	1
LG&E	ITRON	C1S	856234	12/09/2009	100.07	99.86	99.97	1
LG&E	ITRON	C1S	856235	12/09/2009	100.07	100.04	100.12	1
LG&E	ITRON	C1S	856236	12/09/2009	100.09	100.05	100.04	1
LG&E	ITRON	C1S	856237	12/09/2009	100.10	99.92	100.05	1
LG&E	ITRON	C1S	856238	12/09/2009	100.05	99.89	99.99	1
LG&E	ITRON	C1S	856239	12/09/2009	100.10	99.86	100.08	1
LG&E	ITRON	C1S	856240	12/09/2009	100.08	99.88	100.04	1
LG&E	ITRON	C1S	856241	12/09/2009	100.08	99.94	99.89	1
LG&E	ITRON	C1S	856242	12/09/2009	100.06	99.92	99.95	1
LG&E	ITRON	C1S	856243	12/09/2009	100.08	100.03	100.14	1
LG&E	ITRON	C1S	856244	12/09/2009	100.06	99.91	100.04	1
LG&E	ITRON	C1S	856245	12/09/2009	100.09	99.85	100.09	1
LG&E	ITRON	C1S	856246	12/09/2009	100.06	99.81	99.91	1
LG&E	ITRON	C1S	856247	12/09/2009	100.10	99.97	99.98	1
LG&E	ITRON	C1S	856248	12/09/2009	100.05	100.03	100.01	1

LG&E	ITRON	C1S	856249	12/09/2009	100.10	99.83	99.98	1
LG&E	ITRON	C1S	856250	12/09/2009	100.09	100.12	100.17	1
LG&E	ITRON	C1S	856251	12/09/2009	100.06	99.99	99.95	1
LG&E	ITRON	C1S	856252	12/09/2009	100.06	99.84	100.05	1
LG&E	ITRON	C1S	856253	12/09/2009	100.10	100.03	99.97	1
LG&E	ITRON	C1S	856254	12/09/2009	100.08	99.99	100.05	1
LG&E	ITRON	C1S	856255	12/09/2009	100.10	99.94	99.97	1
LG&E	ITRON	C1S	856256	12/09/2009	100.07	99.95	99.93	1
LG&E	ITRON	C1S	856257	12/09/2009	100.06	100.05	100.09	1
LG&E	ITRON	C1S	856258	12/09/2009	100.07	99.84	100.02	1
LG&E	ITRON	C1S	856259	12/09/2009	100.08	99.92	100.08	1
LG&E	ITRON	C1S	856260	12/09/2009	100.06	100.03	99.86	1
LG&E	ITRON	C1S	856261	12/09/2009	100.08	100.04	100.21	1
LG&E	ITRON	C1S	856262	12/09/2009	100.09	99.87	99.92	1
LG&E	ITRON	C1S	856263	12/09/2009	100.10	99.92	100.16	1
LG&E	ITRON	C1S	856264	12/09/2009	100.07	99.94	100.03	1
LG&E	ITRON	C1S	856265	12/09/2009	100.08	100.09	100.08	1
LG&E	ITRON	C1S	856266	12/09/2009	100.06	100.05	99.98	1
LG&E	ITRON	C1S	856267	12/09/2009	100.06	99.84	99.92	1
LG&E	ITRON	C1S	856268	12/09/2009	100.10	99.99	100.10	1
LG&E	ITRON	C1S	856269	12/09/2009	100.06	100.04	100.13	1
LG&E	ITRON	C1S	856270	12/09/2009	100.07	99.97	99.86	1
LG&E	ITRON	C1S	856271	12/09/2009	100.09	100.14	100.15	1
LG&E	ITRON	C1S	856272	12/09/2009	100.05	100.02	100.08	1
LG&E	ITRON	C1S	856273	12/09/2009	100.09	100.08	100.16	1
LG&E	ITRON	C1S	856274	12/09/2009	100.07	99.84	100.04	1
LG&E	ITRON	C1S	856275	12/09/2009	100.09	99.90	100.09	1
LG&E	ITRON	C1S	856276	12/09/2009	100.06	100.02	100.00	1
LG&E	ITRON	C1S	856277	12/09/2009	100.10	99.81	100.03	1
LG&E	ITRON	C1S	856278	12/09/2009	100.08	100.06	100.11	1
LG&E	ITRON	C1S	856279	12/09/2009	100.06	99.84	100.08	1
LG&E	ITRON	C1S	856280	12/09/2009	100.06	100.00	99.98	1
LG&E	ITRON	C1S	856281	12/09/2009	100.10	100.09	100.15	1
LG&E	ITRON	C1S	856282	12/09/2009	100.08	99.90	100.06	1
LG&E	ITRON	C1S	856283	12/09/2009	100.10	100.08	100.19	1

LG&E	ITRON	C1S	856284	12/09/2009	100.05	99.85	99.91	1
LG&E	ITRON	C1S	856285	12/09/2009	100.08	100.02	100.13	1
LG&E	ITRON	C1S	856286	12/09/2009	100.07	99.93	100.00	1
LG&E	ITRON	C1S	856287	12/09/2009	100.09	100.08	100.13	1
LG&E	ITRON	C1S	856288	12/09/2009	100.06	100.06	100.12	1
LG&E	ITRON	C1S	856289	12/09/2009	100.07	99.89	100.02	1
LG&E	ITRON	C1S	856290	12/09/2009	100.05	100.03	100.12	1
LG&E	ITRON	C1S	856291	12/09/2009	100.10	99.92	99.97	1
LG&E	ITRON	C1S	856292	12/09/2009	100.08	100.05	100.14	1
LG&E	ITRON	C1S	856293	12/09/2009	100.08	99.95	99.90	1
LG&E	ITRON	C1S	856294	12/09/2009	100.06	99.95	100.02	1
LG&E	ITRON	C1S	856295	12/09/2009	100.10	99.86	99.98	1
LG&E	ITRON	C1S	856296	12/09/2009	100.07	99.97	100.06	1
LG&E	ITRON	C1S	856297	12/09/2009	100.08	100.06	100.08	1
LG&E	ITRON	C1S	856298	12/09/2009	100.10	100.01	99.97	1
LG&E	ITRON	C1S	856299	12/09/2009	100.08	99.88	99.93	1
LG&E	ITRON	C1S	856300	12/09/2009	100.06	100.01	100.08	1
LG&E	ITRON	C1S	856301	12/09/2009	100.10	99.91	100.11	1
LG&E	ITRON	C1S	856302	12/09/2009	100.07	99.93	99.92	1
LG&E	ITRON	C1S	856303	12/09/2009	100.06	99.92	99.86	1
LG&E	ITRON	C1S	856304	12/09/2009	100.08	100.09	100.16	1
LG&E	ITRON	C1S	856305	12/09/2009	100.06	99.91	99.85	1
LG&E	ITRON	C1S	856306	12/09/2009	100.07	100.09	100.17	1
LG&E	ITRON	C1S	856307	12/09/2009	100.08	100.06	100.08	1
LG&E	ITRON	C1S	856308	12/09/2009	100.06	99.99	99.89	1
LG&E	ITRON	C1S	856309	12/09/2009	100.09	99.88	100.04	1
LG&E	ITRON	C1S	856310	12/09/2009	100.09	100.00	100.09	1
LG&E	ITRON	C1S	856311	12/09/2009	100.10	99.93	99.93	1
LG&E	ITRON	C1S	856312	12/09/2009	100.07	99.94	99.92	1
LG&E	ITRON	C1S	856313	12/09/2009	100.07	100.02	100.14	1
LG&E	ITRON	C1S	856314	12/09/2009	100.10	100.10	100.17	1
LG&E	ITRON	C1S	856315	12/09/2009	100.08	99.91	100.11	1
LG&E	ITRON	C1S	856316	12/09/2009	100.10	100.10	100.20	1
LG&E	ITRON	C1S	856317	12/09/2009	100.10	99.92	100.03	1
LG&E	ITRON	C1S	856318	12/09/2009	100.09	100.01	99.99	1

LG&E	ITRON	C1S	856319	12/09/2009	100.08	99.85	100.04	1
LG&E	ITRON	C1S	856320	12/09/2009	100.08	100.00	100.04	1
LG&E	ITRON	C1S	856321	12/09/2009	100.10	100.09	100.16	1
LG&E	ITRON	C1S	856322	12/09/2009	100.10	100.03	100.16	1
LG&E	ITRON	C1S	856323	12/09/2009	100.08	99.97	100.08	1
LG&E	ITRON	C1S	856324	12/09/2009	100.07	99.92	99.96	1
LG&E	ITRON	C1S	856325	12/09/2009	100.10	99.94	100.11	1
LG&E	ITRON	C1S	856326	12/09/2009	100.06	99.87	99.95	1
LG&E	ITRON	C1S	856327	12/09/2009	100.09	100.10	100.15	1
LG&E	ITRON	C1S	856328	12/09/2009	100.08	99.96	100.15	1
LG&E	ITRON	C1S	856329	12/09/2009	100.06	99.86	99.91	1
LG&E	ITRON	C1S	856330	12/09/2009	100.10	100.06	100.20	1
LG&E	ITRON	C1S	856331	12/09/2009	100.06	99.97	100.09	1
LG&E	ITRON	C1S	856332	12/09/2009	100.07	100.00	100.02	1
LG&E	ITRON	C1S	856333	12/09/2009	100.05	100.05	100.06	1
LG&E	ITRON	C1S	856334	12/09/2009	100.07	100.05	100.11	1
LG&E	ITRON	C1S	856335	12/09/2009	100.06	100.01	100.09	1
LG&E	ITRON	C1S	856336	12/09/2009	100.06	100.00	100.06	1
LG&E	ITRON	C1S	856337	12/09/2009	100.09	100.11	100.21	1
LG&E	ITRON	C1S	856338	12/09/2009	100.06	99.94	100.06	1
LG&E	ITRON	C1S	856339	12/09/2009	100.05	99.89	100.01	1
LG&E	ITRON	C1S	856340	12/09/2009	100.07	100.02	100.15	1
LG&E	ITRON	C1S	856341	12/09/2009	100.07	99.96	99.98	1
LG&E	ITRON	C1S	856342	12/09/2009	100.09	99.90	100.09	1
LG&E	ITRON	C1S	856343	12/09/2009	100.10	100.02	100.11	1
LG&E	ITRON	C1S	856344	12/09/2009	100.07	100.02	99.95	1
LG&E	ITRON	C1S	856345	12/09/2009	100.06	100.00	100.02	1
LG&E	ITRON	C1S	856346	12/09/2009	100.08	100.02	100.08	1
LG&E	ITRON	C1S	856347	12/09/2009	100.08	99.95	100.05	1
LG&E	ITRON	C1S	856348	12/09/2009	100.09	99.86	99.96	1
LG&E	ITRON	C1S	856349	12/09/2009	100.07	99.96	99.95	1
LG&E	ITRON	C1S	856350	12/09/2009	100.10	100.11	100.16	1
LG&E	ITRON	C1S	856351	12/09/2009	100.06	99.94	99.94	1
LG&E	ITRON	C1S	856352	12/09/2009	100.05	99.96	100.07	1
LG&E	ITRON	C1S	856353	12/09/2009	100.07	100.12	100.20	1

LG&E	ITRON	C1S	856354	12/09/2009	100.09	99.97	100.09	1
LG&E	ITRON	C1S	856355	12/09/2009	100.06	100.07	100.14	1
LG&E	ITRON	C1S	856356	12/09/2009	100.09	100.02	100.03	1
LG&E	ITRON	C1S	856357	12/09/2009	100.10	100.08	100.12	1
LG&E	ITRON	C1S	856358	12/09/2009	100.06	100.13	100.13	1
LG&E	ITRON	C1S	856359	12/09/2009	100.09	100.08	100.11	1
LG&E	ITRON	C1S	856360	12/09/2009	100.09	100.08	100.12	1
LG&E	ITRON	C1S	856361	12/09/2009	100.08	100.02	100.06	1
LG&E	ITRON	C1S	856362	12/09/2009	100.05	99.92	99.92	1
LG&E	ITRON	C1S	856363	12/09/2009	100.06	99.94	100.02	1
LG&E	ITRON	C1S	856364	12/09/2009	100.06	99.92	99.95	1
LG&E	ITRON	C1S	856365	12/09/2009	100.10	100.04	100.01	1
LG&E	ITRON	C1S	856366	12/09/2009	100.07	100.06	100.12	1
LG&E	ITRON	C1S	856367	12/09/2009	100.08	100.02	100.01	1
LG&E	ITRON	C1S	856368	12/09/2009	100.07	100.06	99.95	1
LG&E	ITRON	C1S	856369	12/09/2009	100.08	100.09	100.14	1
LG&E	ITRON	C1S	856370	12/09/2009	100.09	99.92	100.11	1
LG&E	ITRON	C1S	856371	12/09/2009	100.06	99.94	100.09	1
LG&E	ITRON	C1S	856372	12/09/2009	100.08	100.11	100.22	1
LG&E	ITRON	C1S	856373	12/09/2009	100.05	99.81	100.00	1
LG&E	ITRON	C1S	856374	12/09/2009	100.07	99.87	100.16	1
LG&E	ITRON	C1S	856375	12/09/2009	100.06	99.96	99.95	1
LG&E	ITRON	C1S	856376	12/09/2009	100.05	99.88	99.90	1
LG&E	ITRON	C1S	856377	12/09/2009	100.06	99.82	100.04	1
LG&E	ITRON	C1S	856378	12/09/2009	100.08	100.06	100.17	1
LG&E	ITRON	C1S	856379	12/09/2009	100.06	99.98	99.87	1
LG&E	ITRON	C1S	856380	12/09/2009	100.08	99.97	99.96	1
LG&E	ITRON	C1S	856381	12/09/2009	100.06	100.02	100.09	1
LG&E	ITRON	C1S	856382	12/09/2009	100.06	100.06	100.15	1
LG&E	ITRON	C1S	856383	12/09/2009	100.10	100.03	100.12	1
LG&E	ITRON	C1S	856384	12/09/2009	100.06	100.02	100.06	1
LG&E	ITRON	C1S	856385	12/09/2009	100.08	99.91	100.10	1
LG&E	ITRON	C1S	856386	12/09/2009	100.10	99.95	100.16	1
LG&E	ITRON	C1S	856387	12/09/2009	100.07	99.92	100.08	1
LG&E	ITRON	C1S	856388	12/09/2009	100.08	99.95	99.92	1

LG&E	ITRON	C1S	856389	12/09/2009	100.10	99.92	99.93	1
LG&E	ITRON	C1S	856390	12/09/2009	100.06	99.96	99.94	1
LG&E	ITRON	C1S	856391	12/09/2009	100.08	99.93	100.11	1
LG&E	ITRON	C1S	856392	12/09/2009	100.07	100.02	99.93	1
LG&E	ITRON	C1S	856393	12/09/2009	100.06	99.86	99.89	1
LG&E	ITRON	C1S	856394	12/09/2009	100.09	99.98	100.15	1
LG&E	ITRON	C1S	856395	12/09/2009	100.08	100.04	100.16	1
LG&E	ITRON	C1S	856396	12/09/2009	100.07	99.86	100.03	1
LG&E	ITRON	C1S	856397	12/09/2009	100.08	99.97	100.10	1
LG&E	ITRON	C1S	856398	12/09/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	856399	12/09/2009	100.08	99.88	99.89	1
LG&E	ITRON	C1S	856400	12/09/2009	100.06	99.85	100.00	1
LG&E	ITRON	C1S	856401	12/09/2009	100.09	100.06	100.16	1
LG&E	ITRON	C1S	856402	12/09/2009	100.06	99.99	100.09	1
LG&E	ITRON	C1S	856403	12/09/2009	100.06	99.89	100.09	1
LG&E	ITRON	C1S	856404	12/09/2009	100.07	100.06	100.10	1
LG&E	ITRON	C1S	856405	12/09/2009	100.08	99.87	100.07	1
LG&E	ITRON	C1S	856406	12/09/2009	100.07	99.83	100.04	1
LG&E	ITRON	C1S	856407	12/09/2009	100.07	99.93	100.06	1
LG&E	ITRON	C1S	856408	12/09/2009	100.08	100.09	100.10	1
LG&E	ITRON	C1S	856409	12/09/2009	100.07	100.02	100.07	1
LG&E	ITRON	C1S	856410	12/09/2009	100.06	99.86	100.05	1
LG&E	ITRON	C1S	856411	12/09/2009	100.07	100.03	99.93	1
LG&E	ITRON	C1S	856412	12/09/2009	100.09	100.03	100.01	1
LG&E	ITRON	C1S	856413	12/09/2009	100.08	99.89	99.97	1
LG&E	ITRON	C1S	856414	12/09/2009	100.07	100.08	100.19	1
LG&E	ITRON	C1S	856415	12/09/2009	100.06	99.93	99.90	1
LG&E	ITRON	C1S	856416	12/09/2009	100.08	99.95	100.03	1
LG&E	ITRON	C1S	856417	12/09/2009	100.10	99.99	99.98	1
LG&E	ITRON	C1S	856418	12/09/2009	100.08	99.91	100.06	1
LG&E	ITRON	C1S	856419	12/09/2009	100.06	99.81	100.04	1
LG&E	ITRON	C1S	856420	12/09/2009	100.07	100.03	100.09	1
LG&E	ITRON	C1S	856421	12/09/2009	100.09	100.08	100.08	1
LG&E	ITRON	C1S	856422	12/09/2009	100.07	99.85	99.99	1
LG&E	ITRON	C1S	856423	12/09/2009	100.08	100.00	99.91	1

LG&E	ITRON	C1S	856424	12/09/2009	100.05	100.02	100.08	1
LG&E	ITRON	C1S	856425	12/09/2009	100.08	100.02	100.20	1
LG&E	ITRON	C1S	856426	12/09/2009	100.08	99.94	100.00	1
LG&E	ITRON	C1S	856427	12/09/2009	100.09	100.00	100.10	1
LG&E	ITRON	C1S	856428	12/09/2009	100.09	99.83	100.03	1
LG&E	ITRON	C1S	856429	12/09/2009	100.08	100.09	100.14	1
LG&E	ITRON	C1S	856430	12/09/2009	100.10	100.00	100.19	1
LG&E	ITRON	C1S	856431	12/09/2009	100.08	100.07	100.09	1
LG&E	ITRON	C1S	856432	12/09/2009	100.06	99.98	99.95	1
LG&E	ITRON	C1S	856433	12/09/2009	100.08	100.07	100.02	1
LG&E	ITRON	C1S	856434	12/09/2009	100.08	99.87	100.08	1
LG&E	ITRON	C1S	856435	12/09/2009	100.07	99.95	99.96	1
LG&E	ITRON	C1S	856436	12/09/2009	100.06	100.05	100.05	1
LG&E	ITRON	C1S	856437	12/09/2009	100.07	100.01	99.93	1
LG&E	ITRON	C1S	856438	12/09/2009	100.07	99.95	99.90	1
LG&E	ITRON	C1S	856439	12/09/2009	100.08	100.01	99.91	1
LG&E	ITRON	C1S	856440	12/09/2009	100.09	100.00	99.95	1
LG&E	ITRON	C1S	856441	12/09/2009	100.07	99.83	99.94	1
LG&E	ITRON	C1S	856442	12/09/2009	100.06	99.97	100.01	1
LG&E	ITRON	C1S	856443	12/09/2009	100.10	100.07	100.11	1
LG&E	ITRON	C1S	856444	12/09/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1S	856445	12/09/2009	100.07	99.93	100.00	1
LG&E	ITRON	C1S	856446	12/09/2009	100.07	99.96	100.06	1
LG&E	ITRON	C1S	856447	12/09/2009	100.06	100.02	100.14	1
LG&E	ITRON	C1S	856448	12/09/2009	100.09	100.10	100.17	1
LG&E	ITRON	C1S	856449	12/09/2009	100.09	99.83	100.06	1
LG&E	ITRON	C1S	856450	12/09/2009	100.07	99.99	100.00	1
LG&E	ITRON	C1S	856451	12/09/2009	100.09	100.11	100.16	1
LG&E	ITRON	C1S	856452	12/09/2009	100.06	100.08	100.11	1
LG&E	ITRON	C1S	856453	12/09/2009	100.08	99.89	99.93	1
LG&E	ITRON	C1S	856454	12/09/2009	100.06	99.81	100.01	1
LG&E	ITRON	C1S	856455	12/09/2009	100.07	99.92	100.09	1
LG&E	ITRON	C1S	856456	12/09/2009	100.07	100.04	100.12	1
LG&E	ITRON	C1S	856457	12/09/2009	100.10	100.03	100.09	1
LG&E	ITRON	C1S	856458	12/09/2009	100.10	99.91	100.11	1

LG&E	ITRON	C1S	856459	12/09/2009	100.06	100.08	100.13	1
LG&E	ITRON	C1S	856460	12/09/2009	100.08	99.92	99.87	1
LG&E	ITRON	C1S	856461	12/09/2009	100.10	100.05	100.09	1
LG&E	ITRON	C1S	856462	12/09/2009	100.10	99.95	100.04	1
LG&E	ITRON	C1S	856463	12/09/2009	100.06	99.83	100.06	1
LG&E	ITRON	C1S	856464	12/09/2009	100.08	99.98	99.96	1
LG&E	ITRON	C1S	856465	12/09/2009	100.07	99.92	99.90	1
LG&E	ITRON	C1S	856466	12/09/2009	100.06	99.89	99.95	1
LG&E	ITRON	C1S	856467	12/09/2009	100.09	99.97	100.08	1
LG&E	ITRON	C1S	856468	12/09/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	856469	12/09/2009	100.09	100.07	100.12	1
LG&E	ITRON	C1S	856470	12/09/2009	100.07	100.03	100.05	1
LG&E	ITRON	C1S	856471	12/09/2009	100.06	99.84	100.02	1
LG&E	ITRON	C1S	856472	12/09/2009	100.10	100.08	100.05	1
LG&E	ITRON	C1S	856473	12/09/2009	100.09	99.83	100.04	1
LG&E	ITRON	C1S	856474	12/09/2009	100.09	99.88	100.15	1
LG&E	ITRON	C1S	856475	12/09/2009	100.05	100.01	100.06	1
LG&E	ITRON	C1S	856476	12/09/2009	100.07	100.02	100.15	1
LG&E	ITRON	C1S	856477	12/09/2009	100.08	99.95	99.92	1
LG&E	ITRON	C1S	856478	12/09/2009	100.08	99.84	100.02	1
LG&E	ITRON	C1S	856479	12/09/2009	100.08	99.91	99.88	1
LG&E	ITRON	C1S	856480	12/09/2009	100.07	99.95	100.18	1
LG&E	ITRON	C1S	856481	12/09/2009	100.05	99.96	100.07	1
LG&E	ITRON	C1S	856482	12/09/2009	100.09	100.06	100.20	1
LG&E	ITRON	C1S	856483	12/09/2009	100.06	99.84	99.92	1
LG&E	ITRON	C1S	856484	12/09/2009	100.10	100.06	100.14	1
LG&E	ITRON	C1S	856485	12/09/2009	100.09	100.05	99.91	1
LG&E	ITRON	C1S	856486	12/09/2009	100.07	99.93	100.05	1
LG&E	ITRON	C1S	856487	12/09/2009	100.06	99.86	100.04	1
LG&E	ITRON	C1S	856488	12/09/2009	100.09	99.91	100.01	1
LG&E	ITRON	C1S	856489	12/09/2009	100.05	99.85	99.96	1
LG&E	ITRON	C1S	856490	12/09/2009	100.10	100.11	100.21	1
LG&E	ITRON	C1S	856491	12/09/2009	100.08	100.06	100.10	1
LG&E	ITRON	C1S	856492	12/09/2009	100.09	99.90	100.06	1
LG&E	ITRON	C1S	856493	12/09/2009	100.10	100.08	100.17	1

LG&E	ITRON	C1S	856494	12/09/2009	100.08	99.99	99.86	1
LG&E	ITRON	C1S	856495	12/09/2009	100.09	100.01	99.97	1
LG&E	ITRON	C1S	856496	12/09/2009	100.06	99.90	100.04	1
LG&E	ITRON	C1S	856497	12/09/2009	100.07	99.99	100.04	1
LG&E	ITRON	C1S	856498	12/09/2009	100.09	99.96	99.97	1
LG&E	ITRON	C1S	856499	12/09/2009	100.07	99.93	100.07	1
LG&E	ITRON	C1S	856500	12/09/2009	100.09	99.98	99.99	1
LG&E	ITRON	C1S	856501	12/09/2009	100.08	100.00	100.14	1
LG&E	ITRON	C1S	856502	12/09/2009	100.09	99.97	99.96	1
LG&E	ITRON	C1S	856503	12/09/2009	100.07	100.00	99.96	1
LG&E	ITRON	C1S	856504	12/09/2009	100.09	100.06	100.16	1
LG&E	ITRON	C1S	856505	12/09/2009	100.10	100.01	100.05	1
LG&E	ITRON	C1S	856506	12/09/2009	100.10	99.90	100.07	1
LG&E	ITRON	C1S	856507	12/09/2009	100.08	99.92	99.95	1
LG&E	ITRON	C1S	856508	12/09/2009	100.09	99.98	99.95	1
LG&E	ITRON	C1S	856509	12/09/2009	100.06	100.08	100.14	1
LG&E	ITRON	C1S	856510	12/09/2009	100.06	99.87	100.06	1
LG&E	ITRON	C1S	856511	12/09/2009	100.07	100.12	100.17	1
LG&E	ITRON	C1S	856512	12/09/2009	100.09	99.94	100.08	1
LG&E	ITRON	C1S	856513	12/09/2009	100.09	99.98	100.08	1
LG&E	ITRON	C1S	856514	12/09/2009	100.06	99.91	99.89	1
LG&E	ITRON	C1S	856515	12/09/2009	100.08	99.89	99.98	1
LG&E	ITRON	C1S	856516	12/09/2009	100.10	99.94	100.06	1
LG&E	ITRON	C1S	856517	12/09/2009	100.07	100.06	100.14	1
LG&E	ITRON	C1S	856518	12/09/2009	100.06	99.97	99.90	1
LG&E	ITRON	C1S	856519	12/09/2009	100.06	100.02	100.01	1
LG&E	ITRON	C1S	856520	12/09/2009	100.05	99.86	100.05	1
LG&E	ITRON	C1S	856521	12/09/2009	100.09	100.07	100.14	1
LG&E	ITRON	C1S	856522	12/09/2009	100.07	100.13	100.08	1
LG&E	ITRON	C1S	856523	12/09/2009	100.09	100.09	100.07	1
LG&E	ITRON	C1S	856524	12/09/2009	100.09	99.93	100.08	1
LG&E	ITRON	C1S	856525	12/09/2009	100.07	100.02	99.98	1
LG&E	ITRON	C1S	856526	12/09/2009	100.08	99.93	99.95	1
LG&E	ITRON	C1S	856527	12/09/2009	100.10	100.05	100.21	1
LG&E	ITRON	C1S	856528	12/09/2009	100.06	99.92	99.97	1

LG&E	ITRON	C1S	856529	12/09/2009	100.09	100.03	100.06	1
LG&E	ITRON	C1S	856530	12/09/2009	100.09	99.97	99.95	1
LG&E	ITRON	C1S	856531	12/09/2009	100.06	99.88	100.03	1
LG&E	ITRON	C1S	856532	12/09/2009	100.06	99.87	99.96	1
LG&E	ITRON	C1S	856533	12/09/2009	100.07	100.00	100.01	1
LG&E	ITRON	C1S	856534	12/09/2009	100.05	99.85	99.85	1
LG&E	ITRON	C1S	856535	12/09/2009	100.07	100.05	100.09	1
LG&E	ITRON	C1S	856536	12/09/2009	100.08	100.09	100.11	1
LG&E	ITRON	C1S	856537	12/09/2009	100.05	99.84	100.02	1
LG&E	ITRON	C1S	856538	12/09/2009	100.06	100.01	100.05	1
LG&E	ITRON	C1S	856539	12/09/2009	100.10	99.96	99.97	1
LG&E	ITRON	C1S	856540	12/09/2009	100.08	99.90	99.95	1
LG&E	ITRON	C1S	856541	12/09/2009	100.07	99.83	99.95	1
LG&E	ITRON	C1S	856542	12/09/2009	100.05	99.95	100.07	1
LG&E	ITRON	C1S	856543	12/09/2009	100.08	100.09	100.16	1
LG&E	ITRON	C1S	856544	12/09/2009	100.10	100.05	100.13	1
LG&E	ITRON	C1S	856545	12/09/2009	100.07	100.11	100.15	1
LG&E	ITRON	C1S	856546	12/09/2009	100.08	100.06	100.14	1
LG&E	ITRON	C1S	856547	12/09/2009	100.08	100.02	100.07	1
LG&E	ITRON	C1S	856548	12/09/2009	100.08	99.91	100.04	1
LG&E	ITRON	C1S	856549	12/09/2009	100.06	100.00	100.14	1
LG&E	ITRON	C1S	856550	12/09/2009	100.08	99.98	100.00	1
LG&E	ITRON	C1S	856551	12/09/2009	100.09	100.12	100.13	1
LG&E	ITRON	C1S	856552	12/09/2009	100.10	99.85	99.98	1
LG&E	ITRON	C1S	856553	12/09/2009	100.05	99.92	99.99	1
LG&E	ITRON	C1S	856554	12/09/2009	100.11	99.94	100.15	1
LG&E	ITRON	C1S	856555	12/09/2009	100.07	99.87	100.01	1
LG&E	ITRON	C1S	856556	12/09/2009	100.09	100.00	100.05	1
LG&E	ITRON	C1S	856557	12/09/2009	100.07	100.06	100.11	1
LG&E	ITRON	C1S	856558	12/09/2009	100.10	100.09	100.15	1
LG&E	ITRON	C1S	856559	12/09/2009	100.10	99.90	99.96	1
LG&E	ITRON	C1S	856560	12/09/2009	100.08	99.89	100.05	1
LG&E	ITRON	C1S	856561	12/09/2009	100.10	99.94	100.03	1
LG&E	ITRON	C1S	856562	12/09/2009	100.10	99.96	100.09	1
LG&E	ITRON	C1S	856563	12/09/2009	100.07	100.06	100.14	1

LG&E	ITRON	C1S	856564	12/09/2009	100.10	99.83	100.01	1
LG&E	ITRON	C1S	856565	12/09/2009	100.06	99.88	100.00	1
LG&E	ITRON	C1S	856566	12/09/2009	100.08	100.04	100.15	1
LG&E	ITRON	C1S	856567	12/09/2009	100.06	99.86	100.05	1
LG&E	ITRON	C1S	856568	12/09/2009	100.08	99.81	99.99	1
LG&E	ITRON	C1S	856569	12/09/2009	100.07	99.85	100.02	1
LG&E	ITRON	C1S	856570	12/09/2009	100.08	100.09	100.24	1
LG&E	ITRON	C1S	856571	12/09/2009	100.06	100.09	100.14	1
LG&E	ITRON	C1S	856572	12/09/2009	100.07	100.09	100.18	1
LG&E	ITRON	C1S	856573	12/09/2009	100.09	99.95	99.94	1
LG&E	ITRON	C1S	856574	12/09/2009	100.08	99.96	100.11	1
LG&E	ITRON	C1S	856575	12/09/2009	100.07	100.14	100.17	1
LG&E	ITRON	C1S	856576	12/09/2009	100.09	99.91	100.09	1
LG&E	ITRON	C1S	856577	12/09/2009	100.06	99.97	99.95	1
LG&E	ITRON	C1S	856578	12/09/2009	100.06	100.06	100.08	1
LG&E	ITRON	C1S	856579	12/09/2009	100.09	100.07	100.12	1
LG&E	ITRON	C1S	856580	12/09/2009	100.07	100.02	100.08	1
LG&E	ITRON	C1S	856581	12/09/2009	100.06	99.83	99.90	1
LG&E	ITRON	C1S	856582	12/09/2009	100.10	100.02	100.10	1
LG&E	ITRON	C1S	856583	12/09/2009	100.09	99.94	100.12	1
LG&E	ITRON	C1S	856584	12/09/2009	100.06	100.03	100.14	1
LG&E	ITRON	C1S	856585	12/09/2009	100.06	100.02	100.06	1
LG&E	ITRON	C1S	856586	12/09/2009	100.10	99.89	99.92	1
LG&E	ITRON	C1S	856587	12/09/2009	100.07	100.06	100.08	1
LG&E	ITRON	C1S	856588	12/09/2009	100.07	100.06	100.07	1
LG&E	ITRON	C1S	856589	12/09/2009	100.05	99.92	99.92	1
LG&E	ITRON	C1S	856590	12/09/2009	100.06	99.82	100.07	1
LG&E	ITRON	C1S	856591	12/09/2009	100.06	99.81	99.92	1
LG&E	ITRON	C1S	856592	12/09/2009	100.06	99.87	100.05	1
LG&E	ITRON	C1S	856593	12/09/2009	100.09	100.07	100.07	1
LG&E	ITRON	C1S	856594	12/09/2009	100.09	100.05	100.19	1
LG&E	ITRON	C1S	856595	12/09/2009	100.07	99.92	99.94	1
LG&E	ITRON	C1S	856596	12/09/2009	100.10	99.95	100.07	1
LG&E	ITRON	C1S	856597	12/09/2009	100.05	99.88	99.85	1
LG&E	ITRON	C1S	856598	12/09/2009	100.06	99.98	100.08	1

LG&E	ITRON	C1S	856599	12/09/2009	100.09	100.01	100.11	1
LG&E	ITRON	C1S	856600	12/09/2009	100.06	100.05	100.10	1
LG&E	ITRON	C1S	856601	12/09/2009	100.08	100.06	100.10	1
LG&E	ITRON	C1S	856602	12/09/2009	100.09	99.91	100.02	1
LG&E	ITRON	C1S	856603	12/09/2009	100.05	99.90	99.91	1
LG&E	ITRON	C1S	856604	12/09/2009	100.08	100.10	100.16	1
LG&E	ITRON	C1S	856605	12/09/2009	100.08	99.96	99.88	1
LG&E	ITRON	C1S	856606	12/09/2009	100.07	99.96	100.17	1
LG&E	ITRON	C1S	856607	12/09/2009	100.06	100.03	99.92	1
LG&E	ITRON	C1S	856608	12/09/2009	100.08	100.00	100.02	1
LG&E	ITRON	C1S	856609	12/09/2009	100.08	100.02	100.00	1
LG&E	ITRON	C1S	856610	12/09/2009	100.10	99.94	100.15	1
LG&E	ITRON	C1S	856611	12/09/2009	100.07	99.88	100.08	1
LG&E	ITRON	C1S	856612	12/09/2009	100.07	100.13	100.11	1
LG&E	ITRON	C1S	856613	12/09/2009	100.06	100.00	100.08	1
LG&E	ITRON	C1S	856614	12/09/2009	100.07	100.03	100.11	1
LG&E	ITRON	C1S	856615	12/09/2009	100.08	99.86	100.00	1
LG&E	ITRON	C1S	856616	12/09/2009	100.09	100.02	100.11	1
LG&E	ITRON	C1S	856617	12/09/2009	100.09	99.92	99.90	1
LG&E	ITRON	C1S	856618	12/09/2009	100.08	100.07	100.12	1
LG&E	ITRON	C1S	856619	12/09/2009	100.10	99.95	99.85	1
LG&E	ITRON	C1S	856620	12/09/2009	100.09	99.84	99.98	1
LG&E	ITRON	C1S	856621	12/09/2009	100.06	99.91	99.89	1
LG&E	ITRON	C1S	856622	12/09/2009	100.07	99.92	100.11	1
LG&E	ITRON	C1S	856623	12/09/2009	100.07	99.92	100.00	1
LG&E	ITRON	C1S	856624	12/09/2009	100.07	100.02	100.19	1
LG&E	ITRON	C1S	856625	12/09/2009	100.09	100.01	99.92	1
LG&E	ITRON	C1S	856626	12/09/2009	100.09	99.84	100.08	1
LG&E	ITRON	C1S	856627	12/09/2009	100.10	100.04	100.14	1
LG&E	ITRON	C1S	856628	12/09/2009	100.08	99.94	99.89	1
LG&E	ITRON	C1S	856629	12/09/2009	100.06	99.89	99.91	1
LG&E	ITRON	C1S	856630	12/09/2009	100.06	99.95	99.86	1
LG&E	ITRON	C1S	856631	12/09/2009	100.07	99.92	100.01	1
LG&E	ITRON	C1S	856632	12/09/2009	100.06	99.93	100.12	1
LG&E	ITRON	C1S	856633	12/09/2009	100.05	99.94	99.89	1

LG&E	ITRON	C1S	856634	12/09/2009	100.10	99.89	100.11	1
LG&E	ITRON	C1S	856635	12/09/2009	100.09	100.01	100.13	1
LG&E	ITRON	C1S	856636	12/09/2009	100.09	100.11	100.17	1
LG&E	ITRON	C1S	856637	12/09/2009	100.08	100.06	100.19	1
LG&E	ITRON	C1S	856638	12/09/2009	100.05	99.90	100.00	1
LG&E	ITRON	C1S	856639	12/09/2009	100.09	100.03	100.09	1
LG&E	ITRON	C1S	856640	12/09/2009	100.06	100.11	100.12	1
LG&E	ITRON	C1S	856641	12/09/2009	100.08	99.94	100.04	1
LG&E	ITRON	C1S	856642	12/09/2009	100.10	99.85	99.99	1
LG&E	ITRON	C1S	856643	12/09/2009	100.07	100.01	99.91	1
LG&E	ITRON	C1S	856644	12/09/2009	100.07	99.99	100.14	1
LG&E	ITRON	C1S	856645	12/09/2009	100.09	99.92	100.04	1
LG&E	ITRON	C1S	856646	12/09/2009	100.07	99.93	100.14	1
LG&E	ITRON	C1S	856647	12/09/2009	100.10	99.90	100.06	1
LG&E	ITRON	C1S	856648	12/09/2009	100.07	99.92	100.02	1
LG&E	ITRON	C1S	856649	12/09/2009	100.09	99.93	99.92	1
LG&E	ITRON	C1S	856650	12/09/2009	100.09	99.93	100.05	1
LG&E	ITRON	C1S	856651	12/09/2009	100.07	100.02	100.15	1
LG&E	ITRON	C1S	856652	12/09/2009	100.07	99.88	99.94	1
LG&E	ITRON	C1S	856653	12/09/2009	100.08	100.06	100.18	1
LG&E	ITRON	C1S	856654	12/09/2009	100.06	99.93	100.04	1
LG&E	ITRON	C1S	856655	12/09/2009	100.05	99.84	99.98	1
LG&E	ITRON	C1S	856656	12/09/2009	100.07	100.04	100.10	1
LG&E	ITRON	C1S	856657	12/09/2009	100.08	100.02	100.01	1
LG&E	ITRON	C1S	856658	12/09/2009	100.08	99.90	99.99	1
LG&E	ITRON	C1S	856659	12/09/2009	100.10	100.09	100.14	1
LG&E	ITRON	C1S	856660	12/09/2009	100.06	99.94	99.91	1
LG&E	ITRON	C1S	856661	12/09/2009	100.09	99.99	100.16	1
LG&E	ITRON	C1S	856662	12/09/2009	100.06	99.98	100.07	1
LG&E	ITRON	C1S	856663	12/09/2009	100.08	100.01	100.11	1
LG&E	ITRON	C1S	856664	12/09/2009	100.09	99.91	100.16	1
LG&E	ITRON	C1S	856665	12/09/2009	100.07	99.99	100.12	1
LG&E	ITRON	C1S	856666	12/09/2009	100.07	99.86	100.03	1
LG&E	ITRON	C1S	856667	12/09/2009	100.07	100.07	100.09	1
LG&E	ITRON	C1S	856668	12/09/2009	100.06	99.83	100.12	1

LG&E	ITRON	C1S	856669	12/09/2009	100.10	99.89	99.97	1
LG&E	ITRON	C1S	856670	12/09/2009	100.06	99.96	100.00	1
LG&E	ITRON	C1S	856671	12/09/2009	100.05	99.91	99.86	1
LG&E	ITRON	C1S	856672	12/09/2009	100.07	99.98	100.03	1
LG&E	ITRON	C1S	856673	12/09/2009	100.09	100.03	100.15	1
LG&E	ITRON	C1S	856674	12/09/2009	100.06	100.08	100.10	1
LG&E	ITRON	C1S	856675	12/09/2009	100.09	100.03	100.01	1
LG&E	ITRON	C1S	856676	12/09/2009	100.06	100.02	100.07	1
LG&E	ITRON	C1S	856677	12/09/2009	100.07	99.94	100.05	1
LG&E	ITRON	C1S	856678	12/09/2009	100.10	100.15	100.19	1
LG&E	ITRON	C1S	856679	12/09/2009	100.09	99.91	100.07	1
LG&E	ITRON	C1S	856680	12/09/2009	100.08	100.01	100.13	1
LG&E	ITRON	C1S	856681	12/09/2009	100.09	99.92	99.97	1
LG&E	ITRON	C1S	856682	12/09/2009	100.08	99.98	100.00	1
LG&E	ITRON	C1S	856683	12/09/2009	100.07	99.93	100.02	1
LG&E	ITRON	C1S	856684	12/09/2009	100.07	99.85	100.01	1
LG&E	ITRON	C1S	856685	12/09/2009	100.06	99.88	99.97	1
LG&E	ITRON	C1S	856686	12/09/2009	100.09	99.90	100.09	1
LG&E	ITRON	C1S	856687	12/09/2009	100.09	100.02	100.07	1
LG&E	ITRON	C1S	856688	12/09/2009	100.10	100.07	100.10	1
LG&E	ITRON	C1S	856689	12/09/2009	100.10	100.01	100.08	1
LG&E	ITRON	C1S	856690	12/09/2009	100.08	100.07	100.16	1
LG&E	ITRON	C1SR	853355	06/18/2009	100.10	99.97	100.10	1
LG&E	ITRON	C1SR	853356	06/18/2009	100.07	100.02	99.93	1
LG&E	ITRON	C1SR	853357	06/18/2009	100.05	99.99	100.04	1
LG&E	ITRON	C1SR	853358	06/18/2009	100.07	99.87	100.07	1
LG&E	ITRON	C1SR	853359	06/18/2009	100.09	100.03	100.18	1
LG&E	ITRON	C1SR	853360	06/18/2009	100.07	100.12	100.18	1
LG&E	ITRON	C1SR	853361	06/18/2009	100.07	99.94	100.12	1
LG&E	ITRON	C1SR	853362	06/18/2009	100.08	100.03	100.02	1
LG&E	ITRON	C1SR	853363	06/18/2009	100.05	100.06	99.94	1
LG&E	ITRON	C1SR	853364	06/18/2009	100.08	100.03	100.08	1
LG&E	ITRON	C1SR	853365	06/18/2009	100.09	100.03	100.20	1
LG&E	ITRON	C1SR	853366	06/18/2009	100.08	100.12	100.11	1
LG&E	ITRON	C1SR	853367	06/18/2009	100.07	99.96	100.12	1

LG&E	ITRON	CISR	853368	06/18/2009	100.05	99.90	100.16	1
LG&E	ITRON	CISR	853369	06/18/2009	100.06	99.95	99.92	1
LG&E	ITRON	CISR	853370	06/18/2009	100.10	99.92	100.18	1
LG&E	ITRON	CISR	853371	06/18/2009	100.08	100.02	100.01	1
LG&E	ITRON	CISR	853372	06/18/2009	100.08	100.09	100.15	1
LG&E	ITRON	CISR	853373	06/18/2009	100.08	100.03	100.24	1
LG&E	ITRON	CISR	853374	06/18/2009	100.08	100.04	100.14	1
LG&E	ITRON	CISR	853375	06/18/2009	100.06	100.08	100.17	1
LG&E	ITRON	CISR	853376	06/18/2009	100.10	100.10	100.18	1
LG&E	ITRON	CISR	853377	06/18/2009	100.09	99.97	99.95	1
LG&E	ITRON	CISR	853378	06/18/2009	100.07	99.96	100.17	1
LG&E	ITRON	CISR	853379	06/18/2009	100.06	100.01	99.95	1
LG&E	ITRON	CISR	853380	06/18/2009	100.09	99.95	99.94	1
LG&E	ITRON	CISR	853381	06/18/2009	100.08	99.92	100.09	1
LG&E	ITRON	CISR	853382	06/18/2009	100.06	99.94	100.14	1
LG&E	ITRON	CISR	853383	06/18/2009	100.10	99.97	100.18	1
LG&E	ITRON	CISR	853384	06/18/2009	100.09	100.14	100.20	1
LG&E	ITRON	CISR	853385	06/18/2009	100.06	99.95	100.04	1
LG&E	ITRON	CISR	853386	06/18/2009	100.09	100.01	99.98	1
LG&E	ITRON	CISR	853387	06/18/2009	100.06	99.95	100.15	1
LG&E	ITRON	CISR	853388	06/18/2009	100.08	100.07	100.17	1
LG&E	ITRON	CISR	853389	06/18/2009	100.08	99.88	100.06	1
LG&E	ITRON	CISR	853390	06/18/2009	100.08	99.94	99.97	1
LG&E	ITRON	CISR	853391	06/18/2009	100.06	99.98	100.14	1
LG&E	ITRON	CISR	853392	06/18/2009	100.06	99.91	99.98	1
LG&E	ITRON	CISR	853393	06/18/2009	100.06	99.84	99.93	1
LG&E	ITRON	CISR	853394	06/18/2009	100.07	100.05	100.09	1
LG&E	ITRON	CISR	853395	06/18/2009	100.07	99.97	100.00	1
LG&E	ITRON	CISR	853396	06/18/2009	100.08	100.00	99.92	1
LG&E	ITRON	CISR	853397	06/18/2009	100.06	100.03	100.14	1
LG&E	ITRON	CISR	853398	06/18/2009	100.09	99.94	100.01	1
LG&E	ITRON	CISR	853399	06/18/2009	100.09	99.99	100.04	1
LG&E	ITRON	CISR	853400	06/18/2009	100.08	99.98	100.04	1
LG&E	ITRON	CISR	853401	06/18/2009	100.07	100.09	100.16	1
LG&E	ITRON	CISR	853402	06/18/2009	100.06	99.91	100.00	1

LG&E	ITRON	C1SR	853403	06/18/2009	100.09	99.91	100.18	1
LG&E	ITRON	C1SR	853404	06/18/2009	100.10	100.04	100.06	1
LG&E	ITRON	C1SR	853405	06/18/2009	100.10	100.02	100.12	1
LG&E	ITRON	C1SR	853406	06/18/2009	100.07	100.03	99.95	1
LG&E	ITRON	C1SR	853407	06/18/2009	100.10	100.00	100.03	1
LG&E	ITRON	C1SR	853408	06/18/2009	100.06	99.87	100.08	1
LG&E	ITRON	C1SR	853409	06/18/2009	100.05	99.89	100.05	1
LG&E	ITRON	C1SR	853410	06/18/2009	100.09	100.01	100.02	1
LG&E	ITRON	C1SR	853411	06/18/2009	100.09	99.90	100.13	1
LG&E	ITRON	C1SR	853412	06/18/2009	100.07	99.93	100.00	1
LG&E	ITRON	C1SR	853413	06/18/2009	100.06	100.02	99.87	1
LG&E	ITRON	C1SR	853414	06/18/2009	100.09	100.09	100.19	1
LG&E	ITRON	C1SR	853415	06/18/2009	100.06	99.91	100.11	1
LG&E	ITRON	C1SR	853416	06/18/2009	100.06	99.96	99.98	1
LG&E	ITRON	C1SR	853417	06/18/2009	100.08	99.99	100.06	1
LG&E	ITRON	C1SR	853418	06/18/2009	100.07	99.97	100.06	1
LG&E	ITRON	C1SR	853419	06/18/2009	100.08	100.00	100.03	1
LG&E	ITRON	C1SR	853420	06/18/2009	100.05	99.98	100.09	1
LG&E	ITRON	C1SR	853421	06/18/2009	100.09	100.03	100.02	1
LG&E	ITRON	C1SR	853422	06/18/2009	100.10	99.99	100.13	1
LG&E	ITRON	C1SR	853423	06/18/2009	100.07	99.96	99.92	1
LG&E	ITRON	C1SR	853424	06/18/2009	100.06	100.06	100.17	1
LG&E	ITRON	C1SR	853425	06/18/2009	100.08	100.06	100.02	1
LG&E	ITRON	C1SR	853426	06/18/2009	100.07	100.03	100.01	1
LG&E	ITRON	C1SR	853427	06/18/2009	100.06	99.93	100.00	1
LG&E	ITRON	C1SR	853428	06/18/2009	100.09	100.12	100.20	1
LG&E	ITRON	C1SR	853429	06/18/2009	100.09	100.08	100.13	1
LG&E	ITRON	C1SR	853430	06/18/2009	100.09	100.09	100.18	1
LG&E	ITRON	C1SR	853431	06/18/2009	100.09	100.04	100.13	1
LG&E	ITRON	C1SR	853432	06/18/2009	100.05	99.90	100.13	1
LG&E	ITRON	C1SR	853433	06/18/2009	100.07	99.97	99.97	1
LG&E	ITRON	C1SR	853434	06/18/2009	100.06	99.97	100.04	1
LG&E	ITRON	C1SR	853435	06/18/2009	100.08	99.97	100.10	1
LG&E	ITRON	C1SR	853436	06/18/2009	100.09	99.98	100.13	1
LG&E	ITRON	C1SR	853437	06/18/2009	100.06	99.97	100.00	1

LG&E	ITRON	C1SR	853438	06/18/2009	100.07	100.02	100.00	1
LG&E	ITRON	C1SR	853439	06/18/2009	100.06	100.06	100.15	1
LG&E	ITRON	C1SR	853440	06/18/2009	100.08	99.92	100.03	1
LG&E	ITRON	C1SR	853441	06/18/2009	100.09	100.00	100.08	1
LG&E	ITRON	C1SR	853442	06/18/2009	100.06	100.03	100.15	1
LG&E	ITRON	C1SR	853443	06/18/2009	100.09	100.04	100.16	1
LG&E	ITRON	C1SR	853444	06/18/2009	100.07	99.87	100.00	1
LG&E	ITRON	C1SR	853445	06/18/2009	100.08	99.91	100.12	1
LG&E	ITRON	C1SR	853446	06/18/2009	100.06	99.96	100.06	1
LG&E	ITRON	C1SR	853447	06/18/2009	100.06	99.90	100.04	1
LG&E	ITRON	C1SR	853448	06/18/2009	100.10	99.96	100.00	1
LG&E	ITRON	C1SR	853449	06/18/2009	100.07	99.90	100.08	1
LG&E	ITRON	C1SR	853450	06/18/2009	100.05	99.92	100.04	1
LG&E	ITRON	C1SR	853451	06/18/2009	100.08	100.00	100.15	1
LG&E	ITRON	C1SR	853452	06/18/2009	100.08	99.96	100.03	1
LG&E	ITRON	C1SR	853453	06/18/2009	100.06	100.00	100.17	1
LG&E	ITRON	C1SR	853454	06/18/2009	100.07	99.88	100.02	1
LG&E	ITRON	C1SR	853455	06/18/2009	100.07	100.03	100.14	1
LG&E	ITRON	C1SR	853456	06/18/2009	100.06	100.04	100.14	1
LG&E	ITRON	C1SR	853457	06/18/2009	100.06	99.87	100.03	1
LG&E	ITRON	C1SR	853458	06/18/2009	100.07	100.07	100.13	1
LG&E	ITRON	C1SR	853459	06/18/2009	100.09	99.95	100.06	1
LG&E	ITRON	C1SR	853460	06/18/2009	100.07	100.03	100.09	1
LG&E	ITRON	C1SR	853461	06/18/2009	100.08	100.02	100.00	1
LG&E	ITRON	C1SR	853462	06/18/2009	100.09	99.99	100.10	1
LG&E	ITRON	C1SR	853463	06/18/2009	100.07	99.93	100.14	1
LG&E	ITRON	C1SR	853464	06/18/2009	100.09	99.95	99.97	1
LG&E	ITRON	C1SR	853465	06/18/2009	100.08	99.94	99.94	1
LG&E	ITRON	C1SR	853466	06/18/2009	100.07	100.06	100.13	1
LG&E	ITRON	C1SR	853467	06/18/2009	100.08	99.99	100.14	1
LG&E	ITRON	C1SR	853468	06/18/2009	100.08	100.07	100.04	1
LG&E	ITRON	C1SR	853469	06/18/2009	100.07	99.93	99.96	1
LG&E	ITRON	C1SR	853470	06/18/2009	100.10	99.99	100.00	1
LG&E	ITRON	C1SR	853471	06/18/2009	100.09	99.96	100.19	1
LG&E	ITRON	C1SR	853472	06/18/2009	100.07	99.92	100.06	1

LG&E	ITRON	C1SR	853473	06/18/2009	100.09	99.88	99.98	1
LG&E	ITRON	C1SR	853474	06/18/2009	100.07	99.99	99.91	1
LG&E	ITRON	C1SR	853475	06/18/2009	100.08	99.92	100.04	1
LG&E	ITRON	C1SR	853476	06/18/2009	100.09	99.90	100.02	1
LG&E	ITRON	C1SR	853477	06/18/2009	100.07	100.00	99.98	1
LG&E	ITRON	C1SR	853478	06/18/2009	100.10	99.96	100.11	1
LG&E	ITRON	C1SR	853479	06/18/2009	100.08	99.91	100.09	1
LG&E	ITRON	C1SR	853480	06/18/2009	100.07	99.98	100.05	1
LG&E	ITRON	C1SR	853481	06/18/2009	100.09	99.94	100.00	1
LG&E	ITRON	C1SR	853482	06/18/2009	100.08	99.98	100.09	1
LG&E	ITRON	C1SR	853483	06/18/2009	100.10	99.94	100.01	1
LG&E	ITRON	C1SR	853484	06/18/2009	100.08	99.94	100.08	1
LG&E	ITRON	C1SR	853485	06/18/2009	100.06	100.02	99.99	1
LG&E	ITRON	C1SR	853486	06/18/2009	100.07	99.87	100.08	1
LG&E	ITRON	C1SR	853487	06/18/2009	100.09	99.96	100.08	1
LG&E	ITRON	C1SR	853488	06/18/2009	100.07	99.98	99.98	1
LG&E	ITRON	C1SR	853489	06/18/2009	100.07	99.83	100.04	1
LG&E	ITRON	C1SR	853490	06/18/2009	100.08	100.03	100.02	1
LG&E	ITRON	C1SR	853491	06/18/2009	100.09	100.07	100.15	1
LG&E	ITRON	C1SR	853492	06/18/2009	100.08	99.92	100.13	1
LG&E	ITRON	C1SR	853493	06/18/2009	100.08	100.00	100.18	1
LG&E	ITRON	C1SR	853494	06/18/2009	100.07	99.98	100.06	1
LG&E	ITRON	C1SR	853495	06/18/2009	100.06	99.82	100.10	1
LG&E	ITRON	C1SR	853496	06/18/2009	100.08	99.91	100.09	1
LG&E	ITRON	C1SR	853497	06/18/2009	100.08	100.01	100.15	1
LG&E	ITRON	C1SR	853498	06/18/2009	100.08	100.11	100.18	1
LG&E	ITRON	C1SR	853499	06/18/2009	100.06	100.07	100.11	1
LG&E	ITRON	C1SR	853500	06/18/2009	100.08	99.87	99.91	1
LG&E	ITRON	C1SR	853501	06/18/2009	100.06	100.05	100.02	1
LG&E	ITRON	C1SR	853502	06/18/2009	100.05	99.90	100.10	1
LG&E	ITRON	C1SR	853503	06/18/2009	100.07	99.97	100.22	1
LG&E	ITRON	C1SR	853504	06/18/2009	100.07	100.02	100.07	1
LG&E	ITRON	C1SR	853505	06/18/2009	100.10	99.99	100.14	1
LG&E	ITRON	C1SR	853506	06/18/2009	100.07	99.96	100.13	1
LG&E	ITRON	C1SR	853507	06/18/2009	100.09	99.99	99.98	1

LG&E	ITRON	CISR	853508	06/18/2009	100.09	99.97	100.05	1
LG&E	ITRON	CISR	853509	06/18/2009	100.06	99.96	100.12	1
LG&E	ITRON	CISR	853510	06/18/2009	100.08	100.00	100.14	1
LG&E	ITRON	CISR	853511	06/18/2009	100.09	100.06	100.14	1
LG&E	ITRON	CISR	853512	06/18/2009	100.09	99.99	100.05	1
LG&E	ITRON	CISR	853513	06/18/2009	100.06	99.97	100.16	1
LG&E	ITRON	CISR	853514	06/18/2009	100.10	100.15	100.22	1
LG&E	ITRON	CISR	853515	06/18/2009	100.09	99.99	100.01	1
LG&E	ITRON	CISR	853516	06/18/2009	100.10	100.06	100.19	1
LG&E	ITRON	CISR	853517	06/18/2009	100.07	99.95	99.96	1
LG&E	ITRON	CISR	853518	06/18/2009	100.09	99.97	100.10	1
LG&E	ITRON	CISR	853519	06/18/2009	100.07	99.85	100.07	1
LG&E	ITRON	CISR	853520	06/18/2009	100.07	99.98	100.24	1
LG&E	ITRON	CISR	853521	06/18/2009	100.07	100.05	100.02	1
LG&E	ITRON	CISR	853522	06/18/2009	100.06	100.06	100.15	1
LG&E	ITRON	CISR	853523	06/18/2009	100.09	100.11	100.15	1
LG&E	ITRON	CISR	853524	06/18/2009	100.08	99.99	100.08	1
LG&E	ITRON	CISR	853525	06/18/2009	100.06	99.92	100.08	1
LG&E	ITRON	CISR	853526	06/18/2009	100.06	99.92	100.12	1
LG&E	ITRON	CISR	853527	06/18/2009	100.07	99.92	100.10	1
LG&E	ITRON	CISR	853528	06/18/2009	100.06	99.94	100.04	1
LG&E	ITRON	CISR	853529	06/18/2009	100.06	100.01	100.13	1
LG&E	ITRON	CISR	853530	06/18/2009	100.09	99.95	100.00	1
LG&E	ITRON	CISR	853531	06/18/2009	100.10	100.09	100.24	1
LG&E	ITRON	CISR	853532	06/18/2009	100.06	99.92	100.09	1
LG&E	ITRON	CISR	853533	06/18/2009	100.09	99.92	100.06	1
LG&E	ITRON	CISR	853534	06/18/2009	100.06	99.92	100.06	1
LG&E	ITRON	CISR	853535	06/18/2009	100.06	99.89	100.09	1
LG&E	ITRON	CISR	853536	06/18/2009	100.06	100.01	99.92	1
LG&E	ITRON	CISR	853537	06/18/2009	100.09	100.10	100.14	1
LG&E	ITRON	CISR	853538	06/18/2009	100.09	100.05	100.13	1
LG&E	ITRON	CISR	853539	06/18/2009	100.06	100.04	100.15	1
LG&E	ITRON	CISR	853540	06/18/2009	100.08	100.10	100.21	1
LG&E	ITRON	CISR	853541	06/18/2009	100.06	100.09	100.13	1
LG&E	ITRON	CISR	853542	06/18/2009	100.06	99.92	99.95	1

LG&E	ITRON	C1SR	853543	06/18/2009	100.06	99.94	99.99	1
LG&E	ITRON	C1SR	853544	06/18/2009	100.07	100.06	100.07	1
LG&E	ITRON	C1SR	853545	06/18/2009	100.08	100.09	100.15	1
LG&E	ITRON	C1SR	853546	06/18/2009	100.10	100.04	100.20	1
LG&E	ITRON	C1SR	856691	12/04/2009	100.06	99.92	100.13	1
LG&E	ITRON	C1SR	856692	12/04/2009	100.06	100.02	100.13	1
LG&E	ITRON	C1SR	856693	12/04/2009	100.08	99.97	100.01	1
LG&E	ITRON	C1SR	856694	12/04/2009	100.09	100.00	100.06	1
LG&E	ITRON	C1SR	856695	12/04/2009	100.08	99.90	100.09	1
LG&E	ITRON	C1SR	856696	12/04/2009	100.10	100.10	100.19	1
LG&E	ITRON	C1SR	856697	12/04/2009	100.08	99.82	100.02	1
LG&E	ITRON	C1SR	856698	12/04/2009	100.09	99.98	100.07	1
LG&E	ITRON	C1SR	856699	12/04/2009	100.08	99.96	99.93	1
LG&E	ITRON	C1SR	856700	12/04/2009	100.07	100.09	100.18	1
LG&E	ITRON	C1SR	856701	12/04/2009	100.07	100.02	100.07	1
LG&E	ITRON	C1SR	856702	12/04/2009	100.07	99.93	100.04	1
LG&E	ITRON	C1SR	856703	12/04/2009	100.06	99.94	99.95	1
LG&E	ITRON	C1SR	856704	12/04/2009	100.09	99.89	100.03	1
LG&E	ITRON	C1SR	856705	12/04/2009	100.07	100.01	100.04	1
LG&E	ITRON	C1SR	856706	12/04/2009	100.06	100.10	100.03	1
LG&E	ITRON	C1SR	856707	12/04/2009	100.09	100.07	100.08	1
LG&E	ITRON	C1SR	856708	12/04/2009	100.10	100.03	99.97	1
LG&E	ITRON	C1SR	856709	12/04/2009	100.10	100.05	100.16	1
LG&E	ITRON	C1SR	856710	12/04/2009	100.09	99.93	100.02	1
LG&E	ITRON	C1SR	856711	12/04/2009	100.07	99.98	99.92	1
LG&E	ITRON	C1SR	856712	12/04/2009	100.08	99.97	100.05	1
LG&E	ITRON	C1SR	856713	12/04/2009	100.09	100.03	99.96	1
LG&E	ITRON	C1SR	856714	12/04/2009	100.10	100.05	100.01	1
LG&E	ITRON	C1SR	856715	12/04/2009	100.08	99.95	100.07	1
LG&E	ITRON	C1SR	856716	12/04/2009	100.08	99.85	100.04	1
LG&E	ITRON	C1SR	856717	12/04/2009	100.07	99.92	100.02	1
LG&E	ITRON	C1SR	856718	12/04/2009	100.10	99.97	100.00	1
LG&E	ITRON	C1SR	856719	12/04/2009	100.06	99.94	100.06	1
LG&E	ITRON	C1SR	856720	12/04/2009	100.10	99.90	100.04	1
LG&E	ITRON	C1SR	856721	12/04/2009	100.09	99.90	100.11	1

LG&E	ITRON	C1SR	856722	12/04/2009	100.06	100.00	100.01	1
LG&E	ITRON	C1SR	856723	12/04/2009	100.06	99.92	100.09	1
LG&E	ITRON	C1SR	856724	12/04/2009	100.08	99.95	100.04	1
LG&E	ITRON	C1SR	856725	12/04/2009	100.09	100.02	99.99	1
LG&E	ITRON	C1SR	856726	12/04/2009	100.07	99.99	100.05	1
LG&E	ITRON	C1SR	856727	12/04/2009	100.08	99.92	99.95	1
LG&E	ITRON	C1SR	856728	12/04/2009	100.07	99.99	100.06	1
LG&E	ITRON	C1SR	856729	12/04/2009	100.09	100.05	100.19	1
LG&E	ITRON	C1SR	856730	12/04/2009	100.10	99.92	100.05	1
LG&E	ITRON	C1SR	856731	12/04/2009	100.09	99.97	100.11	1
LG&E	ITRON	C1SR	856732	12/04/2009	100.06	99.91	100.04	1
LG&E	ITRON	C1SR	856733	12/04/2009	100.09	99.85	100.11	1
LG&E	ITRON	C1SR	856734	12/04/2009	100.08	99.92	100.08	1
LG&E	ITRON	C1SR	856735	12/04/2009	100.06	99.92	100.05	1
LG&E	ITRON	C1SR	856736	12/04/2009	100.08	99.98	100.09	1
LG&E	ITRON	C1SR	856737	12/04/2009	100.08	99.98	100.07	1
LG&E	ITRON	C1SR	856738	12/04/2009	100.08	99.86	100.08	1
LG&E	ITRON	C1SR	856739	12/04/2009	100.08	100.08	100.11	1
LG&E	ITRON	C1SR	856740	12/04/2009	100.08	99.81	100.08	1
LG&E	ITRON	C1SR	856741	12/04/2009	100.08	100.01	100.02	1
LG&E	ITRON	C1SR	856742	12/04/2009	100.08	100.00	100.13	1
LG&E	ITRON	C1SR	856743	12/04/2009	100.06	99.99	99.96	1
LG&E	ITRON	C1SR	856744	12/04/2009	100.06	99.95	99.91	1
LG&E	ITRON	C1SR	856745	12/04/2009	100.09	99.92	100.18	1
LG&E	ITRON	C1SR	856746	12/04/2009	100.08	100.09	100.17	1
LG&E	ITRON	C1SR	856747	12/04/2009	100.10	100.10	100.19	1
LG&E	ITRON	C1SR	856748	12/04/2009	100.08	100.10	100.11	1
LG&E	ITRON	C1SR	856749	12/04/2009	100.10	99.81	100.05	1
LG&E	ITRON	C1SR	856750	12/04/2009	100.09	100.11	100.20	1
LG&E	ITRON	C1SR	856751	12/04/2009	100.07	100.01	100.13	1
LG&E	ITRON	C1SR	856752	12/04/2009	100.09	100.07	100.20	1
LG&E	ITRON	C1SR	856753	12/04/2009	100.09	100.05	100.12	1
LG&E	ITRON	C1SR	856754	12/04/2009	100.05	100.00	100.11	1
LG&E	ITRON	C1SR	856755	12/04/2009	100.09	100.13	100.20	1
LG&E	ITRON	C1SR	856756	12/04/2009	100.09	99.92	100.03	1

LG&E	ITRON	C1SR	856757	12/04/2009	100.06	99.99	100.13	1
LG&E	ITRON	C1SR	856758	12/04/2009	100.05	99.99	100.11	1
LG&E	ITRON	C1SR	856759	12/04/2009	100.06	99.89	99.96	1
LG&E	ITRON	C1SR	856760	12/04/2009	100.09	99.94	100.16	1
LG&E	ITRON	C1SR	856761	12/04/2009	100.07	100.05	99.98	1
LG&E	ITRON	C1SR	856762	12/04/2009	100.06	99.95	99.97	1
LG&E	ITRON	C1SR	856763	12/04/2009	100.09	99.98	99.99	1
LG&E	ITRON	C1SR	856764	12/04/2009	100.08	100.06	100.07	1
LG&E	ITRON	C1SR	856765	12/04/2009	100.08	100.04	100.14	1
LG&E	ITRON	C1SR	856766	12/04/2009	100.07	99.98	100.05	1
LG&E	ITRON	C1SR	856767	12/04/2009	100.08	100.05	100.11	1
LG&E	ITRON	C1SR	856768	12/04/2009	100.06	100.00	100.15	1
LG&E	ITRON	C1SR	856769	12/04/2009	100.10	99.97	100.02	1
LG&E	ITRON	C1SR	856770	12/04/2009	100.06	99.95	99.94	1
LG&E	ITRON	C1SR	856771	12/04/2009	100.05	99.96	99.96	1
LG&E	ITRON	C1SR	856772	12/04/2009	100.09	99.94	100.03	1
LG&E	ITRON	C1SR	856773	12/04/2009	100.10	100.00	100.13	1
LG&E	ITRON	C1SR	856774	12/04/2009	100.10	99.95	99.98	1
LG&E	ITRON	C1SR	856775	12/04/2009	100.06	99.93	100.07	1
LG&E	ITRON	C1SR	856776	12/04/2009	100.05	99.99	99.98	1
LG&E	ITRON	C1SR	856777	12/04/2009	100.08	99.89	100.10	1
LG&E	ITRON	C1SR	856778	12/04/2009	100.09	99.97	100.17	1
LG&E	ITRON	C1SR	856779	12/04/2009	100.07	99.93	100.06	1
LG&E	ITRON	C1SR	856780	12/04/2009	100.06	99.89	100.04	1
LG&E	ITRON	C1SR	856781	12/04/2009	100.06	99.82	100.02	1
LG&E	ITRON	C1SR	856782	12/04/2009	100.09	100.03	100.08	1
LG&E	ITRON	C1SR	856783	12/04/2009	100.07	99.82	100.08	1
LG&E	ITRON	C1SR	856784	12/04/2009	100.09	99.88	100.06	1
LG&E	ITRON	C1SR	856785	12/04/2009	100.08	99.87	100.04	1
LG&E	ITRON	C1SR	856786	12/04/2009	100.08	100.02	99.97	1
LG&E	ITRON	C1SR	856787	12/04/2009	100.11	100.05	100.03	1
LG&E	ITRON	C1SR	856788	12/04/2009	100.07	99.90	100.06	1
LG&E	ITRON	C1SR	856789	12/04/2009	100.10	100.02	100.12	1
LG&E	ITRON	C1SR	856790	12/04/2009	100.09	100.01	99.98	1
LG&E	ITRON	C1SR	856791	12/04/2009	100.07	100.02	100.17	1

LG&E	ITRON	C1SR	856792	12/04/2009	100.10	100.04	100.20	1
LG&E	ITRON	C1SR	856793	12/04/2009	100.09	99.90	100.02	1
LG&E	ITRON	C1SR	856794	12/04/2009	100.08	99.94	99.97	1
LG&E	ITRON	C1SR	856795	12/04/2009	100.09	100.11	100.03	1
LG&E	ITRON	C1SR	856796	12/04/2009	100.08	99.98	100.14	1
LG&E	ITRON	C1SR	856797	12/04/2009	100.09	100.01	100.02	1
LG&E	ITRON	C1SR	856798	12/04/2009	100.06	99.87	100.12	1
LG&E	ITRON	C1SR	856799	12/04/2009	100.06	100.02	100.13	1
LG&E	ITRON	C1SR	856800	12/04/2009	100.08	100.14	100.19	1
LG&E	ITRON	C1SR	856801	12/04/2009	100.08	100.07	100.09	1
LG&E	ITRON	C1SR	856802	12/04/2009	100.06	99.97	99.97	1
LG&E	ITRON	C1SR	856803	12/04/2009	100.06	99.99	100.00	1
LG&E	ITRON	C1SR	856804	12/04/2009	100.10	100.03	100.14	1
LG&E	ITRON	C1SR	856805	12/04/2009	100.06	99.95	100.00	1
LG&E	ITRON	C1SR	856806	12/04/2009	100.09	99.91	100.06	1
LG&E	ITRON	C1SR	856807	12/04/2009	100.08	99.94	100.08	1
LG&E	ITRON	C1SR	856808	12/04/2009	100.10	99.89	100.05	1
LG&E	ITRON	C1SR	856809	12/04/2009	100.08	100.02	99.98	1
LG&E	ITRON	C1SR	856810	12/04/2009	100.06	100.02	100.01	1
LG&E	ITRON	C1SR	856811	12/04/2009	100.07	100.10	100.12	1
LG&E	ITRON	C1SR	856812	12/04/2009	100.06	99.88	100.02	1
LG&E	ITRON	C1SR	856813	12/04/2009	100.08	99.91	100.04	1
LG&E	ITRON	C1SR	856814	12/04/2009	100.08	100.00	100.03	1
LG&E	ITRON	C1SR	856815	12/04/2009	100.08	99.98	100.11	1
LG&E	ITRON	C1SR	856816	12/04/2009	100.10	99.85	100.01	1
LG&E	ITRON	C1SR	856817	12/04/2009	100.08	100.00	100.12	1
LG&E	ITRON	C1SR	856818	12/04/2009	100.10	99.98	100.06	1
LG&E	ITRON	C1SR	856819	12/04/2009	100.09	100.10	100.16	1
LG&E	ITRON	C1SR	856820	12/04/2009	100.11	100.09	100.08	1
LG&E	ITRON	C1SR	856821	12/04/2009	100.07	99.96	100.09	1
LG&E	ITRON	C1SR	856822	12/04/2009	100.06	100.07	100.17	1
LG&E	ITRON	C1SR	856823	12/04/2009	100.09	99.90	100.12	1
LG&E	ITRON	C1SR	856824	12/04/2009	100.08	99.89	100.01	1
LG&E	ITRON	C1SR	856825	12/04/2009	100.08	100.06	100.15	1
LG&E	ITRON	C1SR	856826	12/04/2009	100.07	99.98	100.01	1

LG&E	ITRON	C1SR	856827	12/04/2009	100.09	99.91	100.15	1
LG&E	ITRON	C1SR	856828	12/04/2009	100.08	99.99	100.05	1
LG&E	ITRON	C1SR	856829	12/04/2009	100.07	99.99	100.11	1
LG&E	ITRON	C1SR	856830	12/04/2009	100.10	99.97	100.08	1
LG&E	ITRON	C1SR	856831	12/04/2009	100.10	100.05	100.19	1
LG&E	ITRON	C1SR	856832	12/04/2009	100.05	100.03	100.14	1
LG&E	ITRON	C1SR	856833	12/04/2009	100.07	100.11	100.16	1
LG&E	ITRON	C1SR	856834	12/04/2009	100.10	99.97	100.14	1
LG&E	ITRON	C1SR	856835	12/04/2009	100.09	100.06	100.19	1
LG&E	ITRON	C1SR	856836	12/04/2009	100.08	100.04	100.15	1
LG&E	ITRON	C1SR	856837	12/04/2009	100.09	99.93	100.03	1
LG&E	ITRON	C1SR	856838	12/04/2009	100.06	99.93	100.04	1
LG&E	ITRON	C1SR	856839	12/04/2009	100.09	100.03	100.08	1
LG&E	ITRON	C1SR	856840	12/04/2009	100.07	99.97	99.99	1
LG&E	ITRON	C1SR	856841	12/04/2009	100.07	99.90	100.04	1
LG&E	ITRON	C1SR	856842	12/04/2009	100.08	99.90	100.01	1
LG&E	ITRON	C1SR	856843	12/04/2009	100.09	99.95	100.03	1
LG&E	ITRON	C1SR	856844	12/04/2009	100.09	99.93	100.21	1
LG&E	ITRON	C1SR	856845	12/04/2009	100.08	99.86	100.08	1
LG&E	ITRON	C1SR	856846	12/04/2009	100.09	99.95	100.07	1
LG&E	ITRON	C1SR	856847	12/04/2009	100.08	99.86	100.11	1
LG&E	ITRON	C1SR	856848	12/04/2009	100.05	100.07	100.19	1
LG&E	ITRON	C1SR	856849	12/04/2009	100.10	100.09	100.10	1
LG&E	ITRON	C1SR	856850	12/04/2009	100.08	99.93	100.10	1
LG&E	ITRON	C1SR	856851	12/04/2009	100.09	100.03	100.05	1
LG&E	ITRON	C1SR	856852	12/04/2009	100.08	100.04	100.08	1
LG&E	ITRON	C1SR	856853	12/04/2009	100.05	100.05	100.16	1
LG&E	ITRON	C1SR	856854	12/04/2009	100.06	99.86	100.11	1
LG&E	ITRON	C1SR	856855	12/04/2009	100.08	100.09	100.20	1
LG&E	ITRON	C1SR	856856	12/04/2009	100.08	99.97	100.13	1
LG&E	ITRON	C1SR	856857	12/04/2009	100.09	100.14	100.19	1
LG&E	ITRON	C1SR	856858	12/04/2009	100.10	100.09	100.17	1
LG&E	ITRON	C1SR	856859	12/04/2009	100.06	99.82	99.96	1
LG&E	ITRON	C1SR	856860	12/04/2009	100.08	99.91	100.03	1
LG&E	ITRON	C1SR	856861	12/04/2009	100.09	100.04	100.16	1

LG&E	ITRON	C1SR	856862	12/04/2009	100.06	99.97	100.05	1
LG&E	ITRON	C1SR	856863	12/04/2009	100.05	99.91	100.05	1
LG&E	ITRON	C1SR	856864	12/04/2009	100.08	99.98	100.15	1
LG&E	ITRON	C1SR	856865	12/04/2009	100.08	99.96	100.08	1
LG&E	ITRON	C1SR	856866	12/04/2009	100.07	100.05	100.16	1
LG&E	ITRON	C1SR	856867	12/04/2009	100.08	100.08	100.18	1
LG&E	ITRON	C1SR	856868	12/04/2009	100.09	100.01	100.04	1
LG&E	ITRON	C1SR	856869	12/04/2009	100.07	100.03	100.09	1
LG&E	ITRON	C1SR	856870	12/04/2009	100.05	99.85	100.03	1
LG&E	ITRON	C1SR	856871	12/04/2009	100.08	100.09	100.16	1
LG&E	ITRON	C1SR	856872	12/04/2009	100.09	99.97	100.05	1
LG&E	ITRON	C1SR	856873	12/04/2009	100.07	99.93	100.12	1
LG&E	ITRON	C1SR	856874	12/04/2009	100.10	100.10	100.21	1
LG&E	ITRON	C1SR	856875	12/04/2009	100.09	99.98	99.98	1
LG&E	ITRON	C1SR	856876	12/04/2009	100.06	100.00	99.97	1
LG&E	ITRON	C1SR	856877	12/04/2009	100.06	99.99	100.10	1
LG&E	ITRON	C1SR	856878	12/04/2009	100.08	99.84	100.08	1
LG&E	ITRON	C1SR	856879	12/04/2009	100.08	100.04	99.97	1
LG&E	ITRON	C1SR	856880	12/04/2009	100.05	99.93	100.02	1
LG&E	ITRON	C1SR	856881	12/04/2009	100.08	100.05	100.22	1
LG&E	ITRON	C1SR	856882	12/04/2009	100.07	100.00	100.11	1
Overall Result					100.08	99.99	100.07	3,264

ATTACHMENT
B

Sampling Test Results

LG&E
2009 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	381,117	Divided into 49 Lots
Sample Quantity	3,305	
Meters Tested	3,305	
Meters Not Tested	0	
Failed Lots	0	
Failed Lot Meters	0	

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30AC200E Model Number: CLSR (BRT) Division: 01 Sample Lot: 63
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE CL - 1

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "P" # Normal Inspection

Page 3
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
754157	100.20	754202	100.20	754300	100.00	754302	100.10
755047	100.20	755131	100.10	755146	100.10	755494	100.00
756210	100.10	756272	100.00	766771	100.10	766865	100.00
767167	100.10	767213	100.00	767238	100.00	767242	99.90
777057	100.20	777094	100.10	777152	100.00	777259	100.00
777550	100.30	777645	100.10	777683	100.10	777705	100.20
777868	100.20	777994	100.00	778229	100.20	778305	100.10
778724	100.10	779332	100.20	779613	100.10	793794	100.00
793896	100.10	793917	100.10	794042	100.20	794186	100.00
794448	100.00	794614	99.90	794726	100.02	794908	100.00
795430	100.11	795220	99.90	795243	100.10	795248	100.00
796068	100.00	795497	100.00	795511	100.10	796039	100.00
797126	100.00	796368	100.10	796588	99.90	796652	100.10
797809	100.00	797333	100.10	797374	100.10	797425	100.10
		797926	100.10	798204	100.10	798209	100.10

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7505.13
 3 Sum of Squared Measurements 751027.11
 4 Correction Factor (CF): Sum of Measurements Squared / N 751026.35
 5 Corrected Sum of Squares (SS) 0.76
 6 Variance (V) : SS/(N-1) 0.0103
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1014
 8 Sample Mean(XBAR): Sum X/N 100.07
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 19.04
 12 Quality Index Lower (QL): (XBAR-L) / S 20.39
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F25240V90AC200E Model Number: CLSR (ERT) Division: 01 Sample Lot: 64
 In Service Population: 4,316 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE CI - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
798581	100.00	798598	100.00	798614	100.30	798689	100.20	798752	100.30
798950	100.10	799073	100.10	799093	100.00	799182	100.10	799223	100.10
799409	100.10	799423	100.10	799463	100.10	799488	100.10	799492	100.20
799540	100.00	799548	100.20	799551	100.10	799570	100.20	799575	100.10
799579	100.10	799673	100.00	799690	100.10	799709	100.10	808800	100.30
808846	100.30	808958	100.10	808959	100.00	809009	100.10	809057	100.30
809181	100.20	809249	100.00	809292	100.10	809365	100.10	840401	100.20
844079	100.00	844594	100.00	845227	100.10	845257	100.00	845382	100.00
845390	100.00	845428	100.10	845443	100.20	845541	100.10	845553	100.00
845567	100.40	845591	100.00	845613	100.20	845616	100.10	845699	100.10
845773	100.00	845855	100.10	845856	100.00	845875	100.10	845884	100.10
845939	100.20	845969	100.00	846115	99.90	846182	100.20	846224	100.00
846226	100.10	846267	100.20	846338	100.00	846437	100.10	846527	100.00
846533	100.00	846558	100.10	846610	100.00	846783	100.20	846914	100.10
846916	100.00	846919	100.00	847573	100.20	847751	100.00	847765	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7507.30
- 3 Sum of Squared Measurements 751461.43
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751460.71
- 5 Corrected Sum of Squares (SS) 0.72
- 6 Variance (V) : SS/(N-1) 0.0097
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.0986
- 8 Sample Mean(XBAR) : Sum X/N 100.10
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 19.30
- 12 Quality Index Lower (QL) : (XBAR-L) / S 21.27
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: D4S Division: 01
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Sample Lot: 65
 Lot Descr: LGE D4 - 1
 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "G" # Normal Inspection

Page 5
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
366720	99.80	366850	99.40	367578	99.70	367601	99.80	371651	99.90
372080	99.80	372163	100.00	372177	99.90	372507	99.80	376309	100.20
376447	100.00	376580	100.20	376621	99.70	376905	100.00	376966	100.60
381720	101.20	381874	100.80	382032	100.30	382043	99.90	382206	100.50
386495	100.20	386893	99.50	391372	100.50	391462	100.20	391502	99.40
391950	99.80	395733	99.50	396115	99.60	400549	99.80	400606	100.00
400623	99.70	401350	99.70	401369	99.20	401424	99.80	405782	100.00
405899	99.30	406034	100.60	407373	100.10	410084	100.80	410107	99.70
410277	100.20	410655	99.70	410813	100.10	410831	100.10	410893	99.80
415085	100.00	415345	100.50	415465	100.10	415519	99.70	415584	100.20
419637	100.10	419659	99.70	419779	100.10	420123	100.50	425016	100.00
425143	99.60	425145	100.20	430998	100.50	431018	100.40	431047	100.10
431119	99.90	431474	100.40	431526	100.10	437083	100.00	437084	100.00
440875	100.10	443808	100.50	446746	99.80	446820	100.30	448092	100.10
448850	100.20	448995	100.20	449011	100.40	451953	100.30	452010	100.60

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7503.40
- Sum of Squared Measurements 750690.30
- Correction Factor (CF): Sum of Measurements Squared / N 750680.15
- Corrected Sum of Squares (SS) 10.15
- Variance (V) : SS/(N-1) 0.1371
- Estimate of Lot Standard Deviation(S): SQRT of V 0.3703
- Sample Mean(XBAR): Sum X/N 100.05
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU) : (U-XBAR) / S 5.28
- Quality Index Lower (QL) : (XBAR-L) / S 5.52
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30AC200 Model Number: D4S Division: 01
 In Service Population: 6,130 Sample Quantity: 75 Meters Tested: 75 Sample Lot: 66
 Pass/ Fail: PASS Lot Descr: LGE D4 - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
452784	100.10	453880	100.70	453934	99.90	454027	100.20	454115	100.20
454330	100.60	455021	100.10	456220	99.80	456590	100.20	458241	99.90
458250	100.00	458279	100.20	458290	100.30	458343	100.10	458390	100.50
459001	100.20	461153	99.70	461317	100.30	464260	100.60	464284	100.30
464328	100.40	464338	99.70	464417	100.40	464456	100.30	464503	100.10
464544	99.80	464599	99.90	464645	100.30	464681	100.10	464952	100.20
465335	100.20	465376	100.30	465455	100.40	465474	100.10	468615	100.20
468626	99.80	468643	100.50	468662	100.30	468845	100.30	468925	100.20
470640	99.90	470879	99.70	470985	100.20	471139	100.60	471208	100.30
472616	100.10	472770	100.50	475608	100.00	475864	99.90	478331	100.20
478540	99.50	478627	99.70	478641	100.10	479859	100.30	481729	100.30
483397	100.50	483447	99.90	483636	99.60	485515	100.00	485584	99.50
485662	100.00	485945	99.90	486562	99.80	486579	99.70	488752	100.10
488910	100.10	490532	99.80	490547	99.80	496792	100.20	497056	99.70
497227	99.80	497350	99.50	497480	99.70	497488	100.00	497575	99.30

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7505.60
- 3 Sum of Squared Measurements 751127.00
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751120.42
- 5 Corrected Sum of Squares (SS) 6.58
- 6 Variance (V) : SS/(N-1) 0.0889
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2982
- 8 Sample Mean (XBAR) : Sum X/N 100.07
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 6.46
- 12 Quality Index Lower (QL) : (XBAR-L) / S 6.96
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare p with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200E Model Number: I-210 (ERT) Division: 01
 In Service Population: 1,155 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Sample Lot: 67
 Lot Descr: LGE I210 - 1

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
832140	100.00	832275	100.00	832280	100.10	832304	100.00
832394	99.90	832396	100.10	832411	100.20	832441	100.00
832514	100.00	832517	100.10	832601	100.10	832623	100.00
832650	100.00	832652	100.00	832680	99.90	832692	100.00
832797	100.00	832803	100.00	832816	100.20	832867	100.00
832893	100.00	832911	100.10	835392	100.00	838220	100.00
838340	100.00	838416	100.10	838446	100.00	838447	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 35
- 2 Sum of Measurements: (Sum X) 3500.70
- 3 Sum of Squared Measurements 350140.17
- 4 Correction Factor (CF): Sum of Measurements Squared / N 350140.01
- 5 Corrected Sum of Squares (SS) 0.16
- 6 Variance (V) : SS/(N-1) 0.0046
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.0677
- 8 Sample Mean(XBAR): Sum X/N 100.02
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 29.23
- 12 Quality Index Lower (QL): (XBAR-L) / S 29.82
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 5.58
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Falls the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)

Device Category: F28240V15ACL100 Model Number: I-55S Division: 01
 In Service Population: 1,784 Sample Quantity: 50 Meters Tested: 50 Sample Lot: 69 Lot Descr: LGE I55- 1
 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9

Run Date: 01/05/2010

Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
239690	100.00	240832	100.30	242593	100.40	242785	100.40
242886	99.40	243764	100.60	245485	100.10	245507	100.00
245768	99.30	246136	99.80	246241	100.40	246846	100.00
247031	100.60	247193	100.50	247309	99.90	248350	100.30
248619	100.50	248741	100.40	250442	100.00	250521	100.20
251253	100.10	251654	100.10	252227	100.30	252368	100.00
253357	100.20	257417	100.00	257759	100.00	263031	99.30
263609	99.90	263625	99.50	264057	99.50	264160	99.90
264558	99.80	264658	99.60	265116	100.10	265164	99.80
265354	100.10	265447	99.90	265650	100.30	265762	100.30

INFORMATION NEEDED

- 1 Sample Size (N) 50
- 2 Sum of Measurements: (Sum X) 5004.40
- 3 Sum of Squared Measurements 500886.34
- 4 Correction Factor (CF): Sum of Measurements Squared / N 500880.39
- 5 Corrected Sum of Squares (SS) 5.95
- 6 Variance (V) : SS/(N-1) 0.1215
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3485
- 8 Sample Mean(XBAR): Sum X/N 100.09
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 5.49
- 12 Quality Index Lower (QL): (XBAR-L) / S 5.99
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF: In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 5.21
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)

Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 70
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Lot Descr: LGE I60 - 1

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10

Run Date: 01/05/2010

Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
270781	100.00	270812	99.90	271128	100.30	274570	100.20
275001	99.00	275073	100.20	275358	100.20	278832	100.30
279933	99.90	280123	99.50	281312	99.80	281585	100.00
281869	100.30	282309	99.60	282325	100.00	282421	99.70
286081	99.40	291742	100.00	291763	100.20	292286	99.90
292892	100.10	294261	100.00	295240	100.00	295838	100.20
297416	99.50	297539	100.10	297554	100.10	297600	100.10
297690	99.60	297708	100.70	298321	100.30	298572	100.10
299812	99.70	300369	99.90	303755	100.30	303874	100.20
304244	99.50	304321	99.60	304352	100.20	304446	99.60
307458	100.80	307799	100.30	311285	100.50	311767	100.00
313620	100.40	313675	100.00	313911	99.90	316315	100.60
317661	100.50	317792	99.80	317862	100.20	317870	99.10
318065	100.20	318191	100.20	319976	99.70	320049	100.10
321995	100.40	324284	100.20	324455	100.10	324932	99.90

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7501.10
- Sum of Squared Measurements 750228.71
- Correction Factor (CF): Sum of Measurements Squared / N 750220.02
- Corrected Sum of Squares (SS) 8.69
- Variance (V) : SS/(N-1) 0.1175
- Estimate of Lot Standard Deviation(S): SQRT of V 0.3428
- Sample Mean(XBAR): Sum X/N 100.01
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU) : (U-XBAR) / S 5.79
- Quality Index Lower (QL) : (XBAR-L) / S 5.88
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F25240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 71 Lot Descr: LGE I60 - 2
 In Service Population: 4,099 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "R" # Normal Inspection

Page 11
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
326685	100.40	326692	99.60	329027	99.80	329034	100.10
329407	100.30	329511	100.30	329568	100.20	331209	99.80
331341	100.00	331627	100.00	333692	100.40	334001	100.20
334170	100.20	335605	100.00	335776	100.10	335997	100.10
336267	100.40	336322	99.80	336324	100.20	336238	100.00
338357	100.30	338487	100.00	338631	100.10	338091	100.10
340343	100.30	340403	100.00	340428	99.90	340258	100.00
345061	100.20	345348	100.20	345363	100.40	343195	100.20
345767	100.10	347315	99.90	347414	100.10	345415	99.80
349827	100.20	350141	100.20	350182	99.90	347941	100.00
352345	100.20	352443	100.20	352611	100.10	350305	99.90
354387	100.20	354562	100.00	354806	100.10	352757	100.10
356919	100.70	357580	100.20	357594	100.40	355075	100.90
358878	99.90	358923	100.10	358964	100.10	357660	100.00
359402	100.00	359452	100.00	359516	100.70	358994	100.20
						359559	100.10
						359568	99.90

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7508.00
- 3 Sum of Squared Measurements 751605.98
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751600.85
- 5 Corrected Sum of Squares (SS) 5.13
- 6 Variance (V) : SS/(N-1) 0.0693
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2632
- 8 Sample Mean(XBAR) : Sum X/N 100.11
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 7.19
- 12 Quality Index Lower (QL) : (XBAR-L) / S 8.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F29240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 72 Lot Descr: LGE I70 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
361546	99.60	361579	100.00	361862	99.80	362066	100.20
363847	100.30	364282	100.10	364289	99.90	365843	99.80
366551	100.20	366605	100.00	368083	100.10	368366	100.00
370800	100.30	371013	100.10	371121	100.00	371415	100.50
372825	100.20	372864	100.10	373073	100.20	373113	100.10
373328	100.10	375290	99.80	375508	100.20	376025	100.40
377354	100.40	377534	100.00	377549	100.10	377603	100.10
377822	100.20	377961	100.40	380558	100.40	380575	100.00
380759	100.30	380863	100.10	380898	100.20	381156	100.30
382379	100.20	382571	100.20	382923	100.10	382989	100.10
383018	100.30	383234	100.40	384725	100.00	384862	100.30
385083	100.30	385217	100.30	385237	100.60	385450	100.00
387044	100.00	387144	100.20	387235	100.70	387800	100.30
390232	100.30	390281	100.30	390368	100.10	390498	100.20
390533	100.40	390552	100.00	390605	100.40	390724	100.10

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7511.60
- 3 Sum of Squared Measurements 752324.98
- 4 Correction Factor (CF): Sum of Measurements Squared / N 752321.79
- 5 Corrected Sum of Squares (SS) 3.19
- 6 Variance (V) : SS/(N-1) 0.0431
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2075
- 8 Sample Mean(XBAR): Sum X/N 100.15
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 8.89
- 12 Quality Index Lower (QL): (XBAR-L) / S 10.38
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (06/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Sample Lot: 74 Lot Descr: LGE I70 - 3
 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "F" # Normal Inspection

Page 14
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
421526	100.20	421605	100.10	421662	100.10	421695	99.80
421831	99.60	424165	100.00	424352	99.80	424447	100.30
424621	100.10	425718	100.20	425762	100.10	426084	100.10
426293	99.90	426483	100.30	429208	100.30	429333	99.90
429723	100.20	429950	99.90	429952	100.20	432212	100.20
432274	100.10	432426	100.10	432445	100.10	431983	100.10
435941	100.10	436200	100.10	436419	100.20	432503	100.00
437793	100.00	437959	100.30	438020	100.20	437599	100.00
442403	99.90	442641	100.20	442771	100.10	441396	100.00
448617	100.00	448643	100.10	449333	100.10	445013	99.90
449621	100.20	450608	100.10	450617	100.20	449483	100.10
450818	100.40	451001	99.90	451083	100.10	450652	100.50
451541	100.00	451544	100.00	452917	99.90	451143	100.00
453210	100.00	453318	100.00	455400	100.30	453038	100.20
455690	100.10	455731	99.90	455732	100.10	455460	100.20
						455955	99.80
						459332	100.00

INFORMATION NEEDED

- 1 Sample Size (N)
- 2 Sum of Measurements: (Sum X)
- 3 Sum of Squared Measurements
- 4 Correction Factor (CF): Sum of Measurements Squared / N
- 5 Corrected Sum of Squares (SS)
- 6 Variance (V) : SS/(N-1)
- 7 Estimate of Lot Standard Deviation(S): SQRT of V
- 8 Sample Mean(XBAR): Sum X/N
- 9 Upper Specification Limit (U)
- 10 Lower Specification Limit (L)
- 11 Quality Index Upper (QU): (U-XBAR) / S
- 12 Quality Index Lower (QL): (XBAR-L) / S
- 13 Estimate of Lot Percent NCF Above U (PU)
- 14 Estimate of Lot Percent NCF Below L (PL)
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL
- 16 Maximum Allowable Percent NCF (M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

75
 7505.50
 751102.03
 751100.40
 1.63
 0.0220
 0.1483
 100.07
 102.00
 98.00
 12.99
 13.98
 0.00
 0.00
 0.00
 4.83
 PASS

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F29240V30AC200 Model Number: I-705 Division: 01 Sample Lot: 75 Lot Descr: LGE I70 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "P" # Normal Inspection

Page 15
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
459503	100.20	459536	100.20	459740	100.20	459905	99.90	461476	100.10
461704	100.00	461705	99.89	461769	100.30	461895	99.70	461982	100.10
462022	99.90	462060	99.90	462195	100.30	463344	99.80	463384	100.10
463423	100.10	463791	100.30	463856	100.20	463891	99.80	464135	100.20
465932	99.80	466078	99.90	466343	100.30	466427	100.50	467157	100.20
467533	99.90	467831	100.10	471426	100.00	471571	99.90	471584	100.20
471799	100.10	472112	100.10	472238	100.10	474027	99.90	474106	99.90
474167	99.90	474177	100.00	474259	100.10	474682	99.90	474696	100.00
476683	100.00	476756	99.80	476768	100.10	476898	100.00	476926	99.70
477715	99.90	478895	100.00	478966	99.70	478998	100.20	479290	100.20
479345	100.00	479453	100.10	479612	100.00	480979	100.10	481021	100.40
481089	100.30	482429	99.30	482861	100.00	483006	100.00	483039	100.20
483191	100.10	483970	100.10	484150	100.20	484258	100.10	484548	100.20
484709	99.90	487274	100.30	487485	100.10	487541	99.80	487620	100.20
487676	100.00	487806	99.80	489225	99.70	489326	99.80	489413	99.70

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7501.59
- 3 Sum of Squared Measurements 750320.90
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750318.03
- 5 Corrected Sum of Squares (SS) 2.87
- 6 Variance (V) : SS/(N-1) 0.0388
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1969
- 8 Sample Mean(XBAR): Sum X/N 100.02
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 10.05
- 12 Quality Index Lower (QL): (XBAR-L) / S 10.27
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

75

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 76
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Lot Descr: LGE I70 - 5

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 01/05/2010

Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
489853	100.00	490667	100.20	491697	99.40	492346	100.20
492356	100.00	493233	100.00	493382	99.20	493415	100.10
493935	99.90	494000	100.00	494191	99.80	495439	99.90
495540	99.90	495699	100.00	498489	99.80	499244	100.20
499434	100.00	499516	100.10	500275	100.00	501300	100.10
501427	100.20	501487	100.10	501639	100.20	501731	99.90
501905	100.10	501949	100.20	501964	100.00	506257	99.90
506344	99.90	506348	99.70	506653	99.70	509977	100.00
510159	100.00	510160	100.30	510268	99.90	510611	100.10
510983	99.90	511102	100.00	511229	100.10	511544	100.20
511618	100.00	511750	99.80	512002	100.10	515889	100.10
516140	100.00	516214	100.00	516299	99.90	516307	100.20
518743	105.00	519926	100.20	522078	100.10	522097	100.10
522262	99.80	522409	99.90	522812	99.60	522982	99.80
524055	99.60	524077	99.90	524140	99.80	524202	100.00
						524781	99.90

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7503.65
- 3 Sum of Squared Measurements 750757.85
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750730.18
- 5 Corrected Sum of Squares (SS) 27.67
- 6 Variance (V) : SS/(N-1) 0.3740
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.6115
- 8 Sample Mean(XBAR): Sum X/N 100.05
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 3.19
- 12 Quality Index Lower (QL): (XBAR-L) / S 3.35
- 13 Estimate of Lot Percent NCF Above U (PU) 0.05
- 14 Estimate of Lot Percent NCF Below L (PL) 0.03
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.07
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 77
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE I70 - 6

Page 17
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
526600	100.10	526696	99.80	526729	100.10	526977	99.90	529156	100.10
529220	99.90	529299	100.10	529429	100.10	529459	99.90	529486	99.90
529653	100.00	529887	100.00	532892	99.90	532913	100.20	532967	99.60
533064	99.80	533301	100.40	533375	100.00	533411	99.90	533478	99.90
533530	100.00	533645	99.80	533654	99.90	533715	100.30	533755	99.90
535874	100.08	540367	100.30	540532	100.20	540692	100.00	541116	100.20
541245	100.10	541254	100.10	541677	99.80	541808	100.10	541918	100.40
541953	100.20	542031	100.10	542250	100.10	545290	100.40	551420	100.00
551865	100.40	552238	100.00	552337	100.10	552422	100.00	552550	100.20
552633	100.10	552725	100.00	552965	99.70	553131	100.30	553134	100.20
553341	100.10	553594	100.00	553681	100.00	553721	100.20	553829	100.00
553935	99.90	554243	100.00	561497	99.80	561631	100.40	561646	100.30
562026	100.30	562377	100.10	562467	100.20	562475	99.90	562660	99.70
562833	99.80	562845	99.70	562854	100.10	562911	100.30	562935	100.20
563587	100.10	563903	100.30	564180	100.00	564481	100.10	564549	100.30

INFORMATION NEEDED

1 Sample Size (N) 75

2 Sum of Measurements: (Sum X) 7504.38

3 Sum of Squared Measurements 750878.84

4 Correction Factor (CF): Sum of Measurements Squared / N 750876.26

5 Corrected Sum of Squares (SS) 2.58

6 Variance (V) : SS/(N-1) 0.0349

7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1867

8 Sample Mean (XBAR): Sum X/N 100.06

9 Upper Specification Limit (U) 102.00

10 Lower Specification Limit (L) 98.00

11 Quality Index Upper (QU): (U-XBAR) / S 10.40

12 Quality Index Lower (QL): (XBAR-L) / S 11.02

13 Estimate of Lot Percent NCF Above U (PU) 0.00

14 Estimate of Lot Percent NCF Below L (PL) 0.00

15 Total Estimate Percent NCF. In Lot (P): PU+PL 4.83

16 Maximum Allowable Percent NCF(M)

17 Acceptability Criterion: Compare P with M PASS

18 The Lot Meets the Acceptability Criterion if P <= M

19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30R200 Model Number: I-70S Division: 01 Sample Lot: 78
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE I70 - 7

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
564790	100.20	565480	100.18	565628	100.00	568282	100.20	568448	100.00
568594	100.00	568916	100.30	569388	100.10	569589	100.00	569739	99.70
569946	100.20	570066	100.10	570069	100.10	570099	100.00	570216	100.30
570331	100.20	570342	99.90	570439	99.50	570599	100.10	570727	100.20
570903	100.20	571077	100.00	571298	100.00	571357	100.00	571599	100.10
571659	100.00	572016	99.90	572165	100.10	572175	100.10	572582	100.00
572583	99.80	572617	100.00	572944	100.00	573046	100.20	573063	100.30
573365	100.00	573404	100.20	573433	99.90	573450	100.30	573673	100.10
573755	100.10	573811	100.00	573827	99.90	573997	100.00	575290	99.80
582024	100.30	582367	100.20	582499	100.00	582530	100.00	582586	100.20
582681	99.80	582701	100.00	582730	97.98	582983	100.10	582999	100.00
583056	99.70	583330	100.10	583364	100.70	583751	100.10	588544	100.10
591446	100.00	591512	99.76	591649	100.00	591899	99.90	591958	100.20
592006	100.20	592345	100.10	592400	100.10	592519	99.70	592558	100.10
592604	100.40	593086	100.00	593171	100.20	593962	100.30	594026	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7502.52
- 3 Sum of Squared Measurements 750510.73
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750504.08
- 5 Corrected Sum of Squares (SS) 6.65
- 6 Variance (V) : SS/(N-1) 0.0898
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2997
- 8 Sample Mean(XBAR): Sum X/N 100.03
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 6.56
- 12 Quality Index Lower (QL): (XBAR-L) / S 6.79
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 79
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE I70 - 8

Page 19
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
594201	100.60	594263	100.10	594937	100.00	594991	100.10
599031	99.60	599090	100.10	599147	100.00	599153	100.10
599210	100.00	603202	100.50	603476	100.00	603502	100.20
603561	100.10	603687	100.10	603923	100.20	604157	100.10
604702	99.90	604802	99.80	605037	100.00	605072	99.90
605091	100.20	605259	100.00	605634	100.20	605933	99.70
606030	99.90	606114	99.90	606226	99.90	606299	99.60
610808	99.70	610844	99.90	623595	100.10	623722	100.00
624137	99.90	624359	100.10	624427	100.30	624488	100.10
624533	100.10	624968	100.20	625141	100.30	625256	100.40
625373	100.30	625408	100.00	625538	99.60	625729	100.20
625878	100.30	625902	100.10	625992	100.20	625998	100.00
626563	99.80	626587	100.00	626637	99.90	626947	100.30
627368	100.20	627902	99.70	627939	100.00	628044	99.90
628330	100.30	628352	100.10	628501	100.20	628629	99.90

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7504.03
 3 Sum of Squared Measurements 750809.58
 4 Correction Factor (CF): Sum of Measurements Squared / N 750806.22
 5 Corrected Sum of Squares (SS) 3.36
 6 Variance (V) : SS/(N-1) 0.0454
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2131
 8 Sample Mean(XBAR): Sum X/N 100.05
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 9.13
 12 Quality Index Lower (QL): (XBAR-L) / S 9.64
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF: In Lot (P): PU+PL 4.83
 16 Maximum Allowable Percent NCF(M)
 17 Acceptability Criterion: Compare P with M
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 80 Lot Descr: LGE I70 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
629212	100.00	629395	100.10	629478	100.30	629780	100.00
629884	100.00	630235	100.40	630276	100.40	630389	100.50
630628	100.20	630947	100.20	631013	100.30	631084	100.10
631172	100.10	631233	100.10	631307	100.30	631328	100.50
631929	100.10	631937	100.10	633626	100.10	633686	100.20
640324	100.10	640356	100.00	640486	99.70	640774	100.20
641141	100.00	641236	100.20	641264	100.00	641324	100.20
642074	99.80	642235	100.00	642270	100.20	642792	100.10
642923	100.20	643129	100.00	643336	99.90	643451	100.20
643738	99.90	643925	100.10	643989	100.10	644127	100.10
644195	100.10	644261	100.20	644338	100.00	644363	100.30
644544	100.00	644828	100.10	645141	100.00	645144	100.10
645208	100.40	654251	100.00	654354	99.90	654658	99.70
654761	100.00	654885	100.10	655028	99.90	655033	100.10
655256	100.00	655424	99.70	655526	100.00	655598	99.80

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7506.60
- Sum of Squared Measurements 751322.68
- Correction Factor (CF): Sum of Measurements Squared / N 751320.58
- Corrected Sum of Squares (SS) 2.10
- Variance (V) : SS/(N-1) 0.0283
- Estimate of Lot Standard Deviation(S): SQRT of V 0.1683
- Sample Mean(XBAR): Sum X/N 100.09
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 11.36
- Quality Index Lower (QL): (XBAR-L) / S 12.41
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F28240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 81
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGS I70 - 10

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection
 Page 21
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
656202	100.10	656316	100.10	656558	100.00	656737	100.10
657934	99.90	658035	100.20	661174	99.82	677351	100.00
677817	99.70	677955	99.70	678072	99.90	678253	99.80
678311	100.00	678696	100.30	678727	100.20	678749	99.80
679124	99.90	679279	100.10	679719	100.00	679764	99.90
680096	99.90	680280	99.90	680484	99.90	680946	99.80
680976	99.80	680984	100.10	680988	100.00	681007	99.90
681115	100.00	681236	100.00	681242	100.10	681245	100.10
681453	99.70	681865	100.20	681878	99.90	681379	99.90
681968	99.90	682383	99.70	682554	99.90	681902	99.90
683132	100.10	689404	100.40	689677	100.20	682310	99.90
690072	100.10	690159	100.20	690186	100.00	689712	99.90
690718	100.60	690747	100.30	690782	99.90	690401	100.00
691140	100.00	691165	100.10	691490	100.00	690845	100.10
691776	100.00	691821	99.80	691871	100.10	691512	99.80
						692065	100.40
						692066	99.90

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7499.32
 3 Sum of Squared Measurements 749866.26
 4 Correction Factor (CF): Sum of Measurements Squared / N 749864.01
 5 Corrected Sum of Squares (SS) 2.26
 6 Variance (V) : SS/(N-1) 0.0305
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1746
 8 Sample Mean(XBAR): Sum X/N 99.99
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 11.51
 12 Quality Index Lower (QL): (XBAR-L) / S 11.40
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)

Device Category: F2S240V30AC200 Model Number: J4S

In Service Population: 10,000 Sample Quantity: 75

Division: 01

Meters Tested: 75

Sample Lot: 82

Lot Descr: LGE J4 - 1

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22

Run Date: 01/05/2010

Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
388147	99.70	388214	100.80	388455	100.60	388494	100.30
388512	99.70	388844	100.20	393245	100.00	393832	100.20
397641	99.80	397702	100.00	397962	100.20	398020	100.60
398288	99.80	398433	100.00	402798	100.20	402851	100.30
403139	100.20	407905	101.10	407965	100.50	408077	100.40
412397	100.00	412607	100.50	412840	100.40	417166	100.40
417228	100.30	417278	100.20	417655	100.40	417901	100.40
422311	100.20	422325	100.20	422409	99.70	422416	100.20
422725	100.50	422746	100.30	427433	100.00	427440	100.00
433202	99.60	433375	100.10	433677	100.20	434141	99.40
438797	100.40	438801	100.60	438819	100.10	438830	100.00
439274	99.70	439333	99.90	439344	100.10	439403	100.10
443499	99.70	446967	100.00	447074	100.30	447233	100.30
453519	99.40	453819	100.10	453859	100.40	456678	99.80
460126	99.50	460413	100.10	470139	100.60	470430	99.80
							100.40

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7509.80
- 3 Sum of Squared Measurements 751970.28
- 4 Correction Factor (CF): Sum of Measurements Squared / N 751961.28
- 5 Corrected Sum of Squares (SS) 9.00
- 6 Variance (V) : SS/(N-1) 0.1216
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3487
- 8 Sample Mean(XBAR) : Sum X/N 102.13
- 9 Upper Specification Limit (U) 98.00
- 10 Lower Specification Limit (L) 5.36
- 11 Quality Index Upper (QU): (U-XBAR) / S 6.11
- 12 Quality Index Lower (QL): (XBAR-L) / S 0.00
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 4.83
- 16 Maximum Allowable Percent NCF(M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

PASS

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 84 Lot Descr: LGR J5 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
512242	99.60	512331	100.10	512349	99.90	512477	100.00
513904	100.10	514231	99.70	514578	100.20	517367	100.10
517460	99.70	517492	100.40	517518	99.80	517627	99.80
517856	100.30	518146	99.40	518267	100.00	518410	100.20
521125	99.70	521214	99.70	521259	99.90	521298	100.00
521380	99.30	521693	100.50	521741	100.00	525771	100.10
526212	99.90	526247	100.20	526288	100.00	527069	100.20
527462	100.20	527690	100.30	528011	100.20	528243	99.90
528311	99.70	528793	100.20	528952	100.20	530018	99.00
530300	100.00	530456	100.30	530796	100.00	530946	99.40
531393	99.10	531571	100.00	531772	100.20	533781	99.90
533948	100.20	534127	100.10	534161	99.90	534276	99.80
534793	99.40	534823	99.80	534899	99.90	535011	99.60
535308	100.30	535479	99.70	535554	99.80	539402	99.90
539635	99.60	539747	100.30	539820	100.30	539863	100.40

INFORMATION NEEDED

VALUE OBTAINED

75

- Sample Size (N) 7493.58
- Sum of Measurements: (Sum X) 748724.18
- Sum of Squared Measurements 748716.55
- Correction Factor (CF): Sum of Measurements Squared / N 7.63
- Corrected Sum of Squares (SS) 0.1031
- Variance (V) : SS/(N-1) 0.3210
- Estimate of Lot Standard Deviation(S): SQRT of V 99.91
- Sample Mean(XBAR): Sum X/N 102.00
- Upper Specification Limit (U) 98.00
- Lower Specification Limit (L) 6.50
- Quality Index Upper (QU): (U-XBAR) / S 5.96
- Quality Index Lower (QL): (XBAR-L) / S 0.00
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 4.83
- Maximum Allowable Percent NCF(M)
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F25240V30AC200 Model Number: J5S Division: 01 Sample Lot: 85
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE J5 - 2

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
540218	100.30	540277	100.40	540331	100.30	543312	100.10
544268	100.50	544318	100.20	544404	99.90	544786	99.90
548765	100.00	548777	100.00	548966	99.80	549027	100.16
549124	100.20	549265	99.90	549365	99.90	549492	100.10
550187	99.80	550413	100.00	550860	100.20	551168	100.20
555829	99.90	555990	99.40	556052	100.10	556089	99.60
556361	99.80	556374	99.60	556389	99.80	556515	99.80
556940	99.90	557108	99.60	557191	100.10	557309	100.00
557332	99.60	557489	99.60	557503	99.90	557532	99.50
558000	100.10	558044	100.20	558206	100.00	558435	99.80
565660	99.80	565725	100.10	565881	100.40	565989	100.40
566252	100.10	566348	100.40	566496	100.40	566641	99.60
566901	100.00	567368	100.30	567560	100.10	567776	99.80
567978	100.00	568051	99.90	574108	100.20	579184	100.40
579376	100.30	579445	99.60	579447	100.00	579529	100.00

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7498.86
- Sum of Squared Measurements 749776.58
- Correction Factor (CF): Sum of Measurements Squared / N 749772.02
- Corrected Sum of Squares (SS) 4.56
- Variance (V) : SS/(N-1) 0.0616
- Estimate of Lot Standard Deviation(S): SQRT of V 0.2482
- Sample Mean(XBAR): Sum X/N 99.98
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 8.12
- Quality Index Lower (QL): (XBAR-L) / S 8.00
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF, In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF (M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 86 Lot Descr: IGE J5 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Page 26
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
580023	100.20	580259	99.70	580326	99.90	580517	99.80
580795	99.90	580925	99.90	581400	99.60	581534	100.30
581706	100.00	581770	99.80	581863	100.10	583921	99.70
584083	99.80	584172	99.30	584333	100.00	584580	100.20
584684	99.80	584742	100.10	584854	100.60	585136	99.80
585152	100.11	585230	100.00	585347	100.50	585541	100.10
585894	100.20	586191	100.00	586368	99.80	588868	100.70
588877	100.00	588995	100.40	589085	99.90	589215	100.30
589249	99.50	589269	100.40	589291	100.00	589568	100.10
589882	100.10	590624	99.80	590680	100.30	590965	100.20
591290	100.20	591309	100.30	591355	100.40	599589	100.20
599682	99.90	599692	99.90	599705	100.00	599882	100.40
600060	100.10	600115	100.20	600206	100.40	600462	100.10
600733	99.50	600889	100.00	601094	99.90	601459	100.20
601744	100.20	601747	100.10	602112	100.30	607630	99.90

INFORMATION NEEDED

1 Sample Size (N) 75

2 Sum of Measurements: (Sum X) 7502.91

3 Sum of Squared Measurements 750588.45

4 Correction Factor (CF): Sum of Measurements Squared / N 750582.11

5 Corrected Sum of Squares (SS) 6.34

6 Variance (V) : SS/(N-1) 0.0857

7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2927

8 Sample Mean (XBAR): Sum X/N 100.04

9 Upper Specification Limit (U) 102.00

10 Lower Specification Limit (L) 98.00

11 Quality Index Upper (QU): (U-XBAR) / S 6.70

12 Quality Index Lower (QL): (XBAR-L) / S 6.97

13 Estimate of Lot Percent NCF Above U (PU) 0.00

14 Estimate of Lot Percent NCF Below L (PL) 0.00

15 Total Estimate Percent NCF, In Lot (P): PU+PL 0.00

16 Maximum Allowable Percent NCF(M) 4.83

17 Acceptability Criterion: Compare P with M PASS

18 The Lot Meets the Acceptability Criterion if P <= M

19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 87
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE J5 - 4

Page 27
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
578664	100.20	602621	100.60	608062	100.40	608154	99.70
608523	100.40	608547	100.10	608934	100.00	609123	100.30
609514	100.20	609564	100.00	609624	100.00	609663	99.70
609808	100.00	609930	100.10	610013	100.00	610026	100.10
610149	100.30	610353	100.50	610405	99.90	633869	99.90
634107	99.90	634384	99.80	634456	99.40	634491	99.90
634700	100.00	634776	100.10	634939	100.00	635163	100.10
635193	99.60	635625	99.50	635645	99.90	635927	99.80
636306	100.30	636349	100.00	636376	99.90	636386	99.70
657529	100.10	657585	100.10	662063	99.90	662304	99.90
664001	99.60	662714	99.70	663087	99.70	663393	99.60
664748	99.90	665272	100.00	664224	99.50	664557	100.10
665488	99.90	665720	100.00	665360	99.80	665469	99.10
666301	99.70	666416	99.50	665865	99.90	665887	99.60
				666447	99.70	666620	99.50

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7495.10
 3 Sum of Squared Measurements 749026.11
 4 Correction Factor (CF): Sum of Measurements Squared / N 749020.32
 5 Corrected Sum of Squares (SS) 5.79
 6 Variance (V) : SS/(N-1) 0.0782
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2797
 8 Sample Mean(XBAR): Sum X/N 99.93
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 7.38
 12 Quality Index Lower (QL): (XBAR-L) / S 6.92
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF, In Lot (P): PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30RC200 Model Number: J5S (R200) Division: 01 Sample Lot: 88 Lot Descr: IGE J5 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection
 Page 28
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
666821	100.00	666855	99.60	667034	100.00	667101	99.40
667160	100.00	667318	100.00	667354	100.00	667392	99.70
667588	99.30	667874	100.00	667953	99.60	667971	99.60
668149	99.80	668444	99.90	668462	99.50	668487	99.60
668566	99.90	668586	100.20	668590	99.60	668741	99.70
669325	100.00	669430	100.00	669738	99.80	670601	100.00
683630	99.60	683642	99.80	683660	99.70	683714	99.60
683794	99.60	683866	99.50	683905	99.90	683915	100.20
684060	99.80	684484	99.10	684578	99.80	684610	100.30
685034	99.90	685231	100.30	685328	99.50	685455	99.80
685644	99.70	685650	100.00	686056	99.90	686235	100.10
686416	100.10	686462	100.30	686614	99.90	686986	100.00
687070	99.60	687110	99.80	687170	100.50	687294	99.80
687579	100.00	687668	99.80	687777	99.80	687997	99.70
688625	100.40	689051	99.60	692147	99.80	692348	100.50

VALUE OBTAINED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7489.60
- 3 Sum of Squared Measurements 747926.48
- 4 Correction Factor (CF): Sum of Measurements Squared / N 747921.44
- 5 Corrected Sum of Squares (SS) 5.04
- 6 Variance (V) : SS/(N-1) 0.0681
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2609
- 8 Sample Mean(XBAR): Sum X/N 99.86
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 8.20
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.13
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F25240V30AC200 Model Number: J5S (R200) Division: 01
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Lot Descr: LGE J5 - 6

Page 29
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
693117	100.10	693172	100.30	693621	100.30	693752	100.20
693962	99.80	694475	99.60	694755	100.00	695761	99.90
695853	100.00	695887	100.20	696467	100.10	696504	100.40
696824	99.90	696884	99.70	696907	100.10	697069	99.80
697327	100.40	697478	100.10	697559	99.90	697640	100.10
697734	99.90	697845	100.30	698040	100.10	698844	100.20
699122	99.70	699189	100.10	699204	100.30	699237	100.30
699401	99.60	699492	99.90	699651	99.30	699868	100.30
699988	100.00	700008	99.70	700020	99.90	700409	100.10
705977	99.80	706079	99.90	706166	100.00	706274	100.10
706573	99.80	706850	99.30	706960	100.30	707056	99.90
707203	99.90	707294	100.10	707491	99.70	707545	99.90
707617	99.10	707701	99.90	708006	99.70	708080	99.90
724158	100.30	724448	100.00	724714	100.20	724775	99.90
724866	99.10	724918	100.80	726184	99.80	726324	100.40

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7499.00
- Sum of Squared Measurements 749806.74
- Correction Factor (CF): Sum of Measurements Squared / N 749800.01
- Corrected Sum of Squares (SS) 6.73
- Variance (V) : SS/(N-1) 0.0909
- Estimate of Lot Standard Deviation(S): SQRT of V 0.3015
- Sample Mean (XBAR): Sum X/N 99.99
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 6.68
- Quality Index Lower (QL): (XBAR-L) / S 6.59
- Estimate of Lot Percent NCF Above U (FU) 0.00
- Estimate of Lot Percent NCF Below L (FL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 90
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: IGS J5 - 7

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection
 Page 30
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
726750	100.20	726899	99.60	727046	100.00	727064	99.50
727158	100.00	727257	100.30	727358	100.20	727523	99.90
727836	100.00	728089	98.80	728139	100.00	728254	99.70
728276	100.30	728682	100.30	728879	100.40	728929	99.90
729077	100.70	729137	100.30	729453	99.80	729499	99.90
730303	100.20	730387	100.10	730409	100.30	730437	100.40
730645	99.80	730646	100.10	730688	100.30	730753	100.10
731057	99.90	731067	100.30	731650	100.00	731732	99.90
731860	99.50	732027	99.80	732093	100.00	732931	99.80
733122	99.90	733344	99.60	733356	99.60	733827	99.90
734632	99.80	734693	99.40	734993	99.80	735078	100.10
735140	98.60	735158	99.80	735422	99.70	735561	99.60
735674	99.90	735696	100.00	737668	99.50	737736	100.30
737957	100.00	738027	100.20	738152	99.70	738170	100.00
738701	99.90	739164	100.00	739318	99.90	739451	100.20

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7495.90
 3 Sum of Squared Measurements 749189.41
 4 Correction Factor (CF): Sum of Measurements Squared / N 749180.22
 5 Corrected Sum of Squares (SS) 9.19
 6 Variance (V) : SS/(N-1) 0.1241
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3523
 8 Sample Mean(XBAR): Sum X/N 99.95
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU) : (U-XBAR) / S 5.83
 12 Quality Index Lower (QL) : (XBAR-L) / S 5.52
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

PASS

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30AC200 Model Number: JFS Division: 01 Sample Lot: 91
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE J5 - 8

Page 31
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
735875	99.70	736105	100.00	736245	99.80	736587	99.90
736681	99.60	736890	100.10	736962	100.20	740544	99.00
740580	99.00	740717	99.60	740864	99.40	740914	99.90
741344	100.10	741534	100.10	741780	99.70	741804	100.30
742261	99.10	743111	100.20	743197	98.20	743404	99.40
743742	99.60	743789	99.20	743917	99.80	744011	99.30
744941	99.60	745167	100.10	745316	100.00	745446	99.60
745469	99.50	745487	99.60	745929	99.70	745974	100.30
746231	100.10	746282	99.30	746312	99.70	746416	99.90
746513	99.60	746795	99.80	747143	99.80	747161	100.00
747363	98.80	747501	99.70	747643	99.30	747708	99.10
747832	99.40	747922	99.50	748020	99.80	748234	99.60
748446	99.60	748478	99.50	749014	99.20	749059	99.10
749454	100.20	749502	99.30	749591	99.60	749631	100.00
750027	99.00	750049	99.10	750108	100.10	750138	99.50

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7472.50
 3 Sum of Squared Measurements 744523.39
 4 Correction Factor (CF): Sum of Measurements Squared / N 744510.08
 5 Corrected Sum of Squares (SS) 13.31
 6 Variance (V) : SS/(N-1) 0.1798
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.4241
 8 Sample Mean(XBAR) : Sum X/N 99.63
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 5.58
 12 Quality Index Lower (QL): (XBAR-L) / S 3.85
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 92 Lot Descr: LGE J5 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Page 32
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
750795	99.20	750879	98.50	750976	99.00	750993	99.80
751032	99.50	751411	99.20	751628	99.80	751672	99.70
751729	99.60	751743	99.70	751853	99.40	751891	99.40
752359	99.40	753143	100.50	757431	99.80	757632	99.90
757814	98.80	757844	100.20	757925	99.70	757978	99.60
758204	99.40	758295	100.10	758368	100.00	758384	99.80
758796	99.30	758801	99.60	758870	100.00	759071	99.60
760045	100.10	760355	99.60	760376	99.80	760571	100.10
760840	99.60	760972	99.70	761085	100.20	761173	99.40
761435	99.10	761538	99.70	761745	99.90	761854	99.70
761974	99.60	762145	99.80	762197	99.90	762487	99.70
762590	100.00	762666	99.80	762983	99.90	763182	99.80
763789	99.60	763793	99.80	763983	99.70	763999	99.70
764098	100.00	764115	100.00	764266	99.10	764399	99.80
764644	99.95	764664	100.10	764693	99.80	764779	99.38

INFORMATION NEEDED

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
750795	99.20	750879	98.50	750976	99.00	750993	99.80
751032	99.50	751411	99.20	751628	99.80	751672	99.70
751729	99.60	751743	99.70	751853	99.40	751891	99.40
752359	99.40	753143	100.50	757431	99.80	757632	99.90
757814	98.80	757844	100.20	757925	99.70	757978	99.60
758204	99.40	758295	100.10	758368	100.00	758384	99.80
758796	99.30	758801	99.60	758870	100.00	759071	99.60
760045	100.10	760355	99.60	760376	99.80	760571	100.10
760840	99.60	760972	99.70	761085	100.20	761173	99.40
761435	99.10	761538	99.70	761745	99.90	761854	99.70
761974	99.60	762145	99.80	762197	99.90	762487	99.70
762590	100.00	762666	99.80	762983	99.90	763182	99.80
763789	99.60	763793	99.80	763983	99.70	763999	99.70
764098	100.00	764115	100.00	764266	99.10	764399	99.80
764644	99.95	764664	100.10	764693	99.80	764779	99.38

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7475.83
3 Sum of Squared Measurements	745182.14
4 Correction Factor (CF): Sum of Measurements Squared / N	745173.79
5 Corrected Sum of Squares (SS)	8.35
6 Variance (V) : SS/(N-1)	0.1128
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3359
8 Sample Mean(XBAR): Sum X/N	99.68
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.91
12 Quality Index Lower (QL): (XBAR-L) / S	5.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF: In Lot (P) : PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 93 Lot Descr: LGE J5 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Page 33
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
765061	99.50	767439	100.10	767549	99.90	767715	100.00
768016	99.90	768141	99.90	768306	100.10	768919	99.90
769552	99.60	769682	99.40	769833	100.03	769857	99.60
770056	99.90	770161	99.90	770378	99.60	770379	99.50
770529	99.90	770756	99.60	770798	100.00	771217	99.90
771490	99.80	771563	99.80	771753	99.90	771874	99.10
772408	99.80	772518	99.90	772554	99.90	772623	99.90
772685	100.30	772934	100.20	773042	100.30	773098	100.00
773202	99.80	773267	100.80	773299	99.90	773335	100.00
773719	99.80	773818	100.00	774503	100.40	773493	99.40
774756	99.90	774789	99.70	774797	99.97	774508	100.00
774888	99.80	774924	99.90	774938	99.90	774858	100.60
775205	100.00	775593	100.20	780016	100.60	775060	99.80
780213	100.10	780247	100.10	780253	100.30	780051	99.80
780961	99.30	781146	99.60	781292	100.20	780377	100.10
						781387	99.90
							99.40

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7491.60
 3 Sum of Squared Measurements 748328.40
 4 Correction Factor (CF): Sum of Measurements Squared / N 748320.94
 5 Corrected Sum of Squares (SS) 7.46
 6 Variance (V) : SS/(N-1) 0.1008
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3175
 8 Sample Mean(XBAR): Sum X/N 99.89
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 6.65
 12 Quality Index Lower (QL): (XBAR-L) / S 5.95
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Division: 01 Sample Lot: 94 Lot Descr: LGE J5 - 11
 Model Number: J5S Meters Tested: 75 Pass/ Fail: PASS
 Device Category: F25240V30AC200 Sample Quantity: 75
 In Service Population: 10,000

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
782063	99.80	782216	100.60	782307	100.60	782318	100.10
782891	99.20	783023	99.70	783194	100.00	783282	99.60
783382	99.50	783623	100.10	783703	99.70	783868	99.90
784064	99.80	784122	99.70	784406	99.40	784478	99.80
784699	100.40	784708	99.90	784882	99.80	784917	100.50
785244	100.20	785300	100.40	785897	100.00	785945	100.50
786289	100.00	786424	100.60	786476	100.30	786664	100.20
787162	100.20	787169	99.70	787208	100.30	787216	100.30
787518	100.80	787523	100.20	787590	100.50	787612	100.70
787772	99.80	787951	99.70	788093	100.10	788277	99.80
788459	99.90	788506	100.20	788579	100.20	788914	99.50
789447	99.60	789579	100.00	790018	99.40	790209	100.10
790541	99.50	790585	99.10	790697	99.40	790733	99.80
790795	99.70	790821	99.50	791056	99.90	792799	100.30
793075	99.90	793183	100.10	793390	100.40	793417	100.10

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7497.80
- 3 Sum of Squared Measurements 749569.56
- 4 Correction Factor (CF): Sum of Measurements Squared / N 749560.06
- 5 Corrected Sum of Squares (SS) 9.50
- 6 Variance (V) : SS/(N-1) 0.1283
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.3582
- 8 Sample Mean(XBAR): Sum X/N 99.97
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 5.67
- 12 Quality Index Lower (QL): (XBAR-L) / S 5.50
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF, In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF (M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 95 Lot Descr: LGE J5 - 12
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection
 Page 35
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
800703	99.20	800803	99.60	800809	98.60	800855	99.10
801002	99.90	801206	99.60	801291	100.00	801546	99.40
801819	100.00	802027	99.40	802114	99.10	802167	99.10
802449	99.40	802617	99.90	802762	98.50	802886	100.10
803124	99.50	803139	99.00	803245	99.90	803347	100.00
803546	98.80	803607	99.90	803712	99.60	803792	99.40
804014	99.40	804041	99.50	804414	100.00	804646	99.40
805030	100.00	805486	99.60	805624	100.20	805791	99.60
806039	99.80	806050	99.40	806090	98.40	806162	99.60
806449	99.40	806912	99.80	807049	99.20	807135	99.40
807266	99.40	807322	99.10	807548	99.20	807583	99.70
807999	99.10	808024	99.50	810028	99.40	810133	100.30
810314	99.40	810396	99.50	810412	99.10	810577	99.60
810872	100.30	811100	99.50	811314	99.70	811465	99.40
811702	99.10	811827	99.40	811886	100.30	811933	99.70

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7461.50
 3 Sum of Squared Measurements 742332.99
 4 Correction Factor (CF): Sum of Measurements Squared / N 742319.76
 5 Corrected Sum of Squares (SS) 13.23
 6 Variance (V) : SS/(N-1) 0.1787
 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.4228
 8 Sample Mean(XBAR): Sum X/N 99.49
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU): (U-XBAR) / S 5.94
 12 Quality Index Lower (QL): (XBAR-L) / S 3.52
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.01
 15 Total Estimate Percent NCF, In Lot (P): PU+PL 0.01
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED
 75
 7461.50
 742332.99
 742319.76
 13.23
 0.1787
 0.4228
 99.49
 102.00
 98.00
 5.94
 3.52
 0.00
 0.01
 0.01
 4.83
 PASS

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 98 Lot Descr: LGE MS - 1
 In Service Population: 8,857 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
378336	100.10	378754	99.99	380163	99.90	380253	100.30
380291	100.20	384356	100.80	384637	101.00	389433	101.10
389601	100.00	389759	100.50	389925	100.60	394149	100.50
394377	100.50	394389	100.70	394434	100.10	398786	99.90
398807	99.60	398841	100.50	398898	99.90	403535	100.30
403696	100.19	403771	100.10	403829	100.74	403976	99.90
404150	99.60	404208	100.60	404314	100.20	408687	99.90
413013	100.60	413174	99.70	413433	99.90	413641	100.60
418118	101.10	422885	100.70	423290	100.00	423472	100.40
423715	100.20	428135	100.20	428393	99.30	428611	100.40
428643	100.00	428716	99.70	428808	100.00	434837	100.00
434865	100.20	435013	100.40	435268	99.90	435560	100.10
435575	100.20	439637	99.90	440067	100.20	440072	99.70
444407	100.30	445991	99.60	446083	99.40	447495	99.60
447556	100.40	447719	99.50	450249	99.30	452070	100.20

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7512.52
 3 Sum of Squared Measurements 752520.94
 4 Correction Factor (CF): Sum of Measurements Squared / N 752506.09
 5 Corrected Sum of Squares (SS) 14.85
 6 Variance (V) : SS/(N-1) 0.2007
 7 Estimate of Lot Standard Deviation(S): SQRF of V 0.4480
 8 Sample Mean(XBAR): Sum X/N 100.17
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU) : (U-XBAR) / S 4.09
 12 Quality Index Lower (QL) : (XBAR-L) / S 4.84
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M PASS
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F25240V30AC200 Model Number: MSII Division: 01 Sample Lot: 99
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 1

Page 39
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
454388	99.50	454431	99.60	454462	100.20	454470	99.90
454696	99.60	457875	99.90	460651	100.00	460724	100.00
460800	100.60	462891	100.20	462908	100.20	462912	100.10
463143	100.30	466650	100.00	466704	100.00	466863	100.10
469365	99.70	473171	100.40	473221	100.40	473262	100.10
473369	100.30	473370	100.40	473433	99.90	477197	100.00
477486	100.00	482204	100.10	482206	99.70	482214	100.30
485020	100.00	485154	100.00	485160	99.80	485264	100.20
485386	100.30	485452	100.00	488329	100.10	488367	99.90
488384	99.60	488437	100.30	488607	99.50	491153	99.90
491402	100.20	494934	100.40	495154	100.50	495165	99.90
498241	100.00	502284	99.90	502339	99.80	502494	99.40
503947	99.70	503999	100.20	507223	99.90	507327	99.70
508472	100.50	518935	100.00	518947	100.00	519128	100.00
519377	99.90	523062	99.91	523143	99.70	523427	100.00

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7502.21
- 3 Sum of Squared Measurements 750447.74
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750442.07
- 5 Corrected Sum of Squares (SS) 5.67
- 6 Variance (V) : SS/(N-1) 0.0767
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2769
- 8 Sample Mean(XBAR) : Sum X/N 100.03
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU) : (U-XBAR) / S 7.12
- 12 Quality Index Lower (QL) : (XBAR-L) / S 7.33
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 100
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
523739	100.30	532071	99.80	532349	99.80	532665	99.60
532769	100.40	536495	99.70	536670	100.50	537098	100.30
537261	100.00	537533	100.00	537555	100.00	537693	100.00
542347	99.90	542413	99.70	542613	100.00	543107	100.10
543181	100.40	545833	100.30	545882	100.20	545915	100.20
546187	100.30	546240	100.40	546258	100.10	546520	99.90
546692	100.30	546760	100.20	546847	100.10	546895	100.20
547019	100.40	547297	99.90	547306	100.10	547336	99.90
547848	100.30	558634	100.10	558715	100.20	558954	100.10
559184	100.20	559375	100.50	559461	100.40	559665	100.26
559881	100.00	559895	100.60	559945	100.30	559990	100.30
560438	101.00	560482	100.20	560504	99.60	560833	100.20
560938	100.10	560961	100.30	561062	100.10	561068	100.40
561102	99.70	561400	100.60	575830	100.30	575914	100.40
576059	101.10	576099	100.20	576293	100.20	576430	100.20

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7513.06
- Sum of Squared Measurements 752619.75
- Correction Factor (CF): Sum of Measurements Squared / N 752614.27
- Corrected Sum of Squares (SS) 5.47
- Variance (V) : SS/(N-1) 0.0740
- Estimate of Lot Standard Deviation(S): SQRT of V 0.2720
- Sample Mean(XBAR) : Sum X/N 100.17
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU) : (U-XBAR) / S 6.71
- Quality Index Lower (QL) : (XBAR-L) / S 7.99
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- Maximum Allowable Percent NCF (M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Louisville Gas and Electric
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 101
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 3

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
576877	100.50	577150	100.30	577362	100.20	577528	100.20
577530	100.20	577743	100.50	577828	100.30	577985	100.40
578339	100.40	595958	100.40	596013	100.10	596096	99.80
596477	99.90	596550	100.30	596645	100.30	596787	100.00
596937	100.00	597007	100.30	597209	100.20	597720	99.70
597869	99.90	597905	100.10	598166	100.00	598514	99.90
598632	99.80	611646	100.20	611955	100.40	612061	100.30
612323	100.00	612738	100.50	612957	100.30	612989	99.70
613215	100.30	613283	100.20	613355	100.20	613378	100.30
613610	100.40	614051	100.30	614238	100.20	614306	99.80
614772	99.80	614837	99.70	615009	100.30	615169	100.40
615295	100.30	615353	100.30	615373	99.50	615517	100.50
615915	100.20	615920	99.80	615948	100.20	616143	99.60
616715	100.30	616824	99.80	616843	100.10	616948	100.00
617375	99.90	617388	100.30	617775	100.00	617868	100.20

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7510.50
- Sum of Squared Measurements 752106.11
- Correction Factor (CF): Sum of Measurements Squared / N 752101.47
- Corrected Sum of Squares (SS) 4.64
- Variance (V) : SS/(N-1) 0.0627
- Estimate of Lot Standard Deviation(S): SQRT of V 0.2504
- Sample Mean(XBAR): Sum X/N 100.14
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 7.43
- Quality Index Lower (QL): (XBAR-L) / S 8.55
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7510.50
- Sum of Squared Measurements 752106.11
- Correction Factor (CF): Sum of Measurements Squared / N 752101.47
- Corrected Sum of Squares (SS) 4.64
- Variance (V) : SS/(N-1) 0.0627
- Estimate of Lot Standard Deviation(S): SQRT of V 0.2504
- Sample Mean(XBAR): Sum X/N 100.14
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 7.43
- Quality Index Lower (QL): (XBAR-L) / S 8.55
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF(M) 4.83
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F28240V30AC200 Model Number: MSII Division: 01 Sample Lot: 102
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 4

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
618347	100.60	618378	99.60	618397	99.70	618403	100.40
618600	99.70	618682	99.60	618885	100.20	618968	100.10
619166	99.90	619197	100.20	619685	100.10	619727	99.50
619819	99.70	619853	100.40	620019	99.90	620177	100.20
620289	100.10	620430	99.40	620493	99.70	620568	99.70
621263	100.00	621285	99.80	621341	99.60	621403	99.50
621628	99.60	621712	99.70	621923	100.20	622022	99.90
622402	100.20	622458	99.50	622532	100.20	622626	100.10
623023	100.40	623115	99.80	623161	100.00	623244	100.20
623328	99.60	637092	100.00	637117	100.20	637273	100.10
637559	100.10	637565	100.10	637673	100.00	637853	100.41
638080	100.10	638094	99.80	638418	100.20	638556	100.15
638941	100.10	638958	100.20	639145	100.00	639153	100.10
639445	100.10	639470	100.30	645734	100.20	645750	100.10
646751	100.30	647297	100.00	647353	100.20	647593	100.20

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7502.26
- 3 Sum of Squared Measurements 750458.70
- 4 Correction Factor (CF): Sum of Measurements Squared / N 750452.07
- 5 Corrected Sum of Squares (SS) 6.63
- 6 Variance (V) : SS/(N-1) 0.0896
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2994
- 8 Sample Mean(XBAR): Sum X/N 100.03
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 6.58
- 12 Quality Index Lower (QL): (XBAR-L) / S 6.78
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 103
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 5

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection
 Page 43
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
648568	100.30	648503	99.50	648640	100.30	648790	99.80
649526	100.40	649723	100.00	649787	100.10	649836	100.10
650094	100.20	650253	100.20	650376	100.20	650488	100.30
650762	99.90	650810	100.30	650936	99.80	651057	100.20
651110	100.00	651226	100.20	651499	100.10	651547	100.30
651586	100.00	651633	100.00	651683	99.90	651708	99.70
652150	100.10	652195	99.90	652224	100.10	652307	100.00
652446	100.20	652475	100.30	652678	100.20	652949	100.40
653093	100.20	653158	99.90	653237	100.30	653349	99.80
653689	99.90	653706	100.20	653748	100.20	653778	100.10
653982	100.10	658342	100.40	658650	100.30	658765	100.30
658867	100.40	658960	100.30	659245	100.30	659541	100.50
659803	100.30	659853	100.40	660040	100.40	660044	100.50
660639	100.40	660660	100.20	671007	100.40	671113	100.40
671471	100.10	671576	100.40	671762	100.10	672383	100.20

INFORMATION NEEDED
 1 Sample Size (N) 75
 2 Sum of Measurements: (Sum X) 7512.90
 3 Sum of Squared Measurements 752585.39
 4 Correction Factor (CF): Sum of Measurements Squared / N 752582.22
 5 Corrected Sum of Squares (SS) 3.17
 6 Variance (V) : SS/(N-1) 0.0429
 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2070
 8 Sample Mean(XBAR): Sum X/N 100.17
 9 Upper Specification Limit (U) 102.00
 10 Lower Specification Limit (L) 98.00
 11 Quality Index Upper (QU) : (U-XBAR) / S 8.83
 12 Quality Index Lower (QL) : (XBAR-L) / S 10.49
 13 Estimate of Lot Percent NCF Above U (PU) 0.00
 14 Estimate of Lot Percent NCF Below L (PL) 0.00
 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
 16 Maximum Allowable Percent NCF(M) 4.83
 17 Acceptability Criterion: Compare P with M
 18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Fails the Acceptability Criterion if P > M

PASS

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 104
 In Service Population: 3,639 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS Lot Descr: LGE MSII - 6

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
672734	100.30	672765	100.10	672788	100.30	672796	100.10
672898	100.00	672971	100.30	673055	100.50	673070	100.30
673297	100.20	673413	100.30	673417	100.20	673455	100.00
673520	100.30	673539	100.10	673581	100.20	673712	100.10
673740	100.30	673917	100.20	674041	100.10	674125	100.30
674136	100.10	674154	100.20	674344	100.00	674434	100.40
674641	100.00	674668	99.90	674752	100.10	674800	100.10
674894	100.00	674903	100.10	674920	100.00	674955	100.20
675141	99.20	675170	100.30	675239	100.20	675244	100.30
675306	100.10	675417	100.20	675430	100.00	675478	100.20
675557	100.10	675592	100.10	675653	100.10	675722	100.20
675729	100.10	675786	100.00	675822	100.10	675887	99.40
675898	100.30	675942	100.30	675998	100.30	676027	100.20
676113	100.30	676116	100.30	676135	100.20	676294	100.30
676353	100.20	676425	100.30	676565	99.90	676590	100.20

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7511.00
- 3 Sum of Squared Measurements 752204.22
- 4 Correction Factor (CF): Sum of Measurements Squared / N 752201.61
- 5 Corrected Sum of Squares (SS) 2.61
- 6 Variance (V) : SS/(N-1) 0.0352
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.1877
- 8 Sample Mean(XBAR): Sum X/N 100.15
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 9.87
- 12 Quality Index Lower (QL): (XBAR-L) / S 11.44
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P) : PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MK Division: 01 Sample Lot: 105 Lot Descr: LGE MK - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45

Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
702920	100.19	702928	100.00	703019	99.80	703020	99.90
703493	99.81	703742	99.90	703792	100.30	703859	100.10
703988	99.70	704110	99.70	704618	99.90	704751	100.10
704997	99.80	705004	100.00	705161	100.10	705302	99.80
708703	99.60	708917	99.80	709163	99.60	709206	99.90
709482	99.70	709642	99.80	709771	99.90	709974	99.90
710170	99.80	710305	100.10	710355	99.90	710638	100.00
711097	99.70	711254	100.30	711276	99.50	711295	99.80
711504	99.70	711812	99.90	712075	100.00	712146	99.70
712246	99.70	712468	99.40	712579	99.80	712654	99.90
712981	100.00	713001	100.10	713027	99.80	713519	99.90
713752	99.80	714103	99.90	714128	99.80	714275	99.20
714703	99.40	714738	100.10	714775	99.90	714859	99.80
715096	99.80	715120	99.60	715128	99.50	715227	100.50
715860	99.70	716210	100.10	716304	99.80	716355	99.80

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7490.40
- 3 Sum of Squared Measurements 748084.79
- 4 Correction Factor (CF): Sum of Measurements Squared / N 748081.23
- 5 Corrected Sum of Squares (SS) 3.56
- 6 Variance (V) : SS/(N-1) 0.0482
- 7 Estimate of Lot Standard Deviation(S): SQRT of V 0.2194
- 8 Sample Mean(XBAR): Sum X/N 99.87
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 9.70
- 12 Quality Index Lower (QL): (XBAR-L) / S 8.53
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

75

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 106 Lot Descr: LGE MX - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "G" # Normal Inspection

Page 46
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
716606	99.50	717214	99.90	717247	99.60	717292	99.40	717658	100.00
717713	99.80	717722	99.70	717964	99.80	718013	99.90	718168	99.80
718329	99.60	718681	99.50	718731	99.60	718796	100.10	718815	100.10
718843	100.20	718864	99.90	718955	100.00	719002	100.20	719091	99.70
719281	99.90	719474	100.00	719538	99.80	719610	99.80	719944	99.70
720089	99.90	720267	99.80	720372	99.90	720646	99.90	720995	99.80
721063	100.00	721118	99.70	721514	99.90	721642	99.90	721727	99.90
722135	100.10	722470	100.00	722499	100.20	723004	99.50	723084	99.60
723224	100.10	723263	99.40	723268	99.80	723368	99.60	814712	100.00
814754	100.10	814777	99.70	814778	99.70	814853	100.10	814892	99.80
814994	100.20	815086	100.30	815134	100.00	815655	100.00	815771	99.80
816066	99.80	816160	100.10	816188	99.60	816252	99.90	816362	99.60
816419	100.00	816475	99.90	816687	100.30	817283	100.00	817310	100.20
817746	99.60	817809	99.70	817885	99.50	817890	100.10	817933	100.20
817947	100.10	818074	99.80	818105	100.10	818168	99.90	818178	100.00

INFORMATION NEEDED

- Sample Size (N) 75
- Sum of Measurements: (Sum X) 7490.60
- Sum of Squared Measurements 748124.76
- Correction Factor (CF): Sum of Measurements Squared / N 748121.18
- Corrected Sum of Squares (SS) 3.58
- Variance (V) : SS/(N-1) 0.0484
- Estimate of Lot Standard Deviation(S): SQRT of V 0.2200
- Sample Mean(XBAR): Sum X/N 99.87
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 9.66
- Quality Index Lower (QL): (XBAR-L) / S 8.52
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 4.83
- Maximum Allowable Percent NCF (M) PASS
- Acceptability Criterion: Compare P with M
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)
 Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 107 Lot Descr: LGE MX - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47
 Run Date: 01/05/2010
 Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
819453	99.80	819629	99.90	820045	99.90	820167	100.00
820266	100.00	820324	100.10	820497	99.90	820518	99.70
820792	100.10	821065	99.50	821078	100.00	821178	100.00
821181	99.70	821221	99.50	821551	99.60	821603	99.50
821886	99.80	822153	99.40	822164	99.90	822199	99.60
822328	100.10	822495	99.50	822537	99.40	822845	99.90
824675	99.60	824766	99.90	824926	99.40	824940	100.00
825046	99.90	825215	99.50	825320	99.70	825412	99.80
825543	99.80	825847	99.80	826099	99.90	826187	99.80
826591	100.00	826604	99.50	826719	99.70	826804	100.10
827267	99.70	827365	99.70	827525	99.90	827593	99.70
827803	99.90	827931	99.50	828006	99.80	830021	100.00
830314	100.10	830402	99.90	830499	100.00	830633	99.90
831082	100.20	831361	99.40	831505	99.80	831673	100.10
831844	99.70	836329	100.00	836557	99.70	836624	99.60

INFORMATION NEEDED

- 1 Sample Size (N) 75
- 2 Sum of Measurements: (Sum X) 7485.10
- 3 Sum of Squared Measurements 747026.17
- 4 Correction Factor (CF): Sum of Measurements Squared / N 747022.96
- 5 Corrected Sum of Squares (SS) 3.21
- 6 Variance (V) : SS/(N-1) 0.0434
- 7 Estimate of Lot Standard Deviation(S) : SQRT of V 0.2083
- 8 Sample Mean(XBAR) : Sum X/N 99.80
- 9 Upper Specification Limit (U) 102.00
- 10 Lower Specification Limit (L) 98.00
- 11 Quality Index Upper (QU): (U-XBAR) / S 10.56
- 12 Quality Index Lower (QL): (XBAR-L) / S 8.65
- 13 Estimate of Lot Percent NCF Above U (PU) 0.00
- 14 Estimate of Lot Percent NCF Below L (PL) 0.00
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- 16 Maximum Allowable Percent NCF(M) 4.83
- 17 Acceptability Criterion: Compare P with M PASS
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric

2009 Sample Test Program (04/08/2009) to (12/31/2009)

Device Category: F28240V30AC200

Model Number: MX

Sample Quantity: 50

Sample Lot: 119

Lot Descr: LGE MX - 4

In Service Population: 3,106

Meters Tested: 50

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49

Run Date: 01/05/2010

Run Time: 09:56:12 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
836852	99.90	836864	99.80	837007	99.90	837026	99.80
837142	100.00	837168	99.90	837221	99.90	837391	100.00
837683	100.00	837767	100.00	838028	100.00	838082	100.00
838114	99.90	838158	99.90	839085	99.90	839116	99.80
839332	100.00	839350	99.80	839393	100.00	839450	99.90
839560	99.90	839601	100.20	839626	99.70	839653	99.70
839759	99.90	839850	99.70	839974	100.10	839975	100.00
840135	100.00	840154	99.90	840168	100.00	840239	99.70
840335	100.00	840380	99.80	840439	100.10	840506	99.90
840715	100.10	840766	99.80	840804	99.70	840874	99.90

INFORMATION NEEDED

- Sample Size (N) 50
- Sum of Measurements: (Sum X) 4994.90
- Sum of Squared Measurements 498981.33
- Correction Factor (CF): Sum of Measurements Squared / N 498980.52
- Corrected Sum of Squares (SS) 0.81
- Variance (V) : SS/(N-1) 0.0165
- Estimate of Lot Standard Deviation(S): SQRT of V 0.1286
- Sample Mean(XBAR): Sum X/N 99.90
- Upper Specification Limit (U) 102.00
- Lower Specification Limit (L) 98.00
- Quality Index Upper (QU): (U-XBAR) / S 16.35
- Quality Index Lower (QL): (XBAR-L) / S 14.76
- Estimate of Lot Percent NCF Above U (PU) 0.00
- Estimate of Lot Percent NCF Below L (PL) 0.00
- Total Estimate Percent NCF. In Lot (P): PU+PL 0.00
- Maximum Allowable Percent NCF (M) 5.21
- Acceptability Criterion: Compare P with M PASS
- The Lot Meets the Acceptability Criterion if P <= M
- The Lot Fails the Acceptability Criterion if P > M

Louisville Gas and Electric
 2009 Sample Test Program (04/08/2009) to (12/31/2009)

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	MTRS TST	PASS/FAIL	LOT NUMBER
LGE AB1 - 1	Westinghouse	AB1	240	15	15	PASS TESTING COMPLETE	61
LGE ALF - 1	Landis + Gyr	ALF (Trilliant)	1,548	50	50	PASS TESTING COMPLETE	62
LGE CI - 1	Itron	CLSR (ERT)	10,000	75	75	PASS TESTING COMPLETE	63
LGE CI - 2	Itron	CLSR (ERT)	4,316	75	75	PASS TESTING COMPLETE	64
LGE DA - 1	Westinghouse	D4S	10,000	75	75	PASS TESTING COMPLETE	65
LGE DA - 2	Westinghouse	D4S	6,130	75	75	PASS TESTING COMPLETE	66
LGE I210 - 1	General Electric	I-210 (ERT)	1,155	35	35	PASS TESTING COMPLETE	67
LGE I50 - 1	General Electric	I-50S	1,457	50	50	PASS TESTING COMPLETE	68
LGE I55 - 1	General Electric	I-55S	1,784	50	50	PASS TESTING COMPLETE	69
LGE I60 - 1	General Electric	I-60S	10,000	75	75	PASS TESTING COMPLETE	70
LGE I60 - 2	General Electric	I-60S	4,099	75	75	PASS TESTING COMPLETE	71
LGE I70 - 1	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	72
LGE I70 - 2	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	73
LGE I70 - 3	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	74
LGE I70 - 4	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	75
LGE I70 - 5	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	76
LGE I70 - 6	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	77
LGE I70 - 7	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	78
LGE I70 - 8	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	79
LGE I70 - 9	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	80
LGE I70 - 10	General Electric	I-70S	10,000	75	75	PASS TESTING COMPLETE	81
LGE J4 - 1	Itron	J4S	10,000	75	75	PASS TESTING COMPLETE	82
LGE J4 - 2	Itron	J4S	2,468	50	50	PASS TESTING COMPLETE	83
LGE J5 - 1	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	84
LGE J5 - 2	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	85
LGE J5 - 3	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	86
LGE J5 - 4	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	87
LGE J5 - 5	Itron	J5S (R200)	10,000	75	75	PASS TESTING COMPLETE	88
LGE J5 - 6	Itron	J5S (R200)	10,000	75	75	PASS TESTING COMPLETE	89
LGE J5 - 7	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	90
LGE J5 - 8	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	91
LGE J5 - 9	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	92
LGE J5 - 10	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	93
LGE J5 - 11	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	94
LGE J5 - 12	Itron	J5S	10,000	75	75	PASS TESTING COMPLETE	95
LGE J5 - 13	Itron	J5S	1,886	50	50	PASS TESTING COMPLETE	96
LGE MQ - 1	Landis + Gyr	MQS	257	15	15	PASS TESTING COMPLETE	97
LGE MS - 1	Landis + Gyr	MS	8,857	75	75	PASS TESTING COMPLETE	98
LGE MSII - 1	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	99
LGE MSII - 2	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	100
LGE MSII - 3	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	101
LGE MSII - 4	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	102
LGE MSII - 5	Landis + Gyr	MSII	10,000	75	75	PASS TESTING COMPLETE	103
LGE MSII - 6	Landis + Gyr	MSII	3,639	75	75	PASS TESTING COMPLETE	104
LGE MX - 1	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	105
LGE MX - 2	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	106
LGE MX - 3	Landis + Gyr	MX	10,000	75	75	PASS TESTING COMPLETE	107
LGE I70 - 11	General Electric	I-70A	175	15	15	PASS TESTING COMPLETE	118
LGE MX - 4	Landis + Gyr	MX	3,106	50	50	PASS TESTING COMPLETE	119

TOTALS	381,117	3,305	3,305	49
TOTAL LOTS PASSED:				0
TOTAL LOTS FAILED:				0
METERS CANNOT TEST:				0

Report completed successfully with results.