

a PPL company

Jeff DeRouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

RECEIVED

FEB 29 2012

PUBLIC SERVICE
COMMISSION

Kentucky Utilities Company
State Regulation and Rates
220 W. Main Street
Louisville, KY 40202
www.lge-ku.com

Martin J. Reinert
Sr. Regulatory Analyst
O 502-627-4173
marty.reinert@lge-ku.com

February 29, 2012

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Kentucky Utilities Company

Dear Mr. DeRouen:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.


Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Kentucky Utilities Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2011 Statistical Sampling Test Results and Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Marty J. Reinert". The signature is written in a cursive style with a large, prominent 'M' and 'R'.

Marty J. Reinert

Cc: Kimra Cole, Engineering Director PSC

Attachments

ATTACHMENT
A

Certified Test Results

Energy LLC

5040 Annual Report of New Single Phase

Last Data Update:

02/20/2012 02:15:08

Dynamic Filters

Plant KU
Calendar Month/Year 01/2011 - 12/2011

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
KU	C1S	2012480	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012481	02/2011	01/31/2011	99.90	100.20	100.10	1
KU	C1S	2012482	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012483	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012484	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012485	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012486	02/2011	02/01/2011	100.00	100.00	99.80	1
KU	C1S	2012487	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012488	02/2011	01/27/2011	100.00	100.00	100.00	1
KU	C1S	2012489	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012490	02/2011	02/01/2011	100.00	100.10	99.90	1
KU	C1S	2012491	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012492	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012493	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012494	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012495	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2012496	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012497	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012498	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012499	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012500	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012501	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012502	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012503	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012504	02/2011	01/27/2011	100.00	100.00	99.90	1
KU	C1S	2012505	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012506	02/2011	02/01/2011	99.90	100.00	99.90	1
KU	C1S	2012507	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012508	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012509	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012510	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012511	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2012512	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012513	02/2011	01/27/2011	100.00	100.10	100.10	1
KU	C1S	2012514	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012515	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012516	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012517	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012518	02/2011	02/01/2011	100.00	100.10	99.90	1
KU	C1S	2012519	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012520	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012521	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012522	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012523	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012524	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012525	02/2011	02/01/2011	99.90	100.10	100.00	1

KU	C1S	2012526	02/2011	01/27/2011	100.00	100.00	99.90	1
KU	C1S	2012527	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012528	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2012529	02/2011	02/01/2011	100.00	99.90	99.90	1
KU	C1S	2012530	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012531	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012532	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012533	02/2011	02/01/2011	100.00	100.10	99.90	1
KU	C1S	2012534	02/2011	02/01/2011	99.90	100.00	99.90	1
KU	C1S	2012535	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012536	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012537	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012538	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012539	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012540	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012541	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012542	02/2011	02/01/2011	100.00	100.00	99.80	1
KU	C1S	2012543	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012544	02/2011	01/27/2011	100.00	100.20	100.00	1
KU	C1S	2012545	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012546	02/2011	01/27/2011	100.00	100.20	100.10	1
KU	C1S	2012547	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012548	02/2011	02/01/2011	99.90	100.00	100.10	1
KU	C1S	2012549	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012550	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012551	02/2011	02/01/2011	100.00	100.00	100.10	1
KU	C1S	2012552	02/2011	01/27/2011	100.00	99.90	100.00	1
KU	C1S	2012553	02/2011	01/27/2011	100.00	99.90	99.90	1
KU	C1S	2012554	02/2011	02/01/2011	100.00	100.00	100.10	1
KU	C1S	2012555	02/2011	02/01/2011	100.00	100.00	100.00	1

KU	C1S	2012556	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012557	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012558	02/2011	02/01/2011	100.00	100.00	100.10	1
KU	C1S	2012559	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012560	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012561	02/2011	02/01/2011	100.00	100.00	99.80	1
KU	C1S	2012562	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012563	02/2011	01/27/2011	100.00	100.00	99.80	1
KU	C1S	2012564	02/2011	02/01/2011	99.90	100.00	100.00	1
KU	C1S	2012565	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012566	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012567	02/2011	02/01/2011	99.90	100.10	99.90	1
KU	C1S	2012568	02/2011	02/01/2011	100.00	99.90	99.80	1
KU	C1S	2012569	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012570	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012571	02/2011	01/27/2011	100.00	100.10	99.90	1
KU	C1S	2012572	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012573	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012574	02/2011	01/27/2011	100.00	100.20	100.00	1
KU	C1S	2012575	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012576	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012577	02/2011	02/01/2011	100.00	100.20	100.10	1
KU	C1S	2012578	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012579	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012580	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012581	02/2011	01/27/2011	100.00	100.00	99.90	1
KU	C1S	2012582	02/2011	01/27/2011	100.00	100.00	99.80	1
KU	C1S	2012583	02/2011	01/27/2011	100.00	100.00	99.90	1
KU	C1S	2012584	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012585	02/2011	02/01/2011	100.00	100.20	100.10	1

KU	C1S	2012586	02/2011	01/27/2011	100.00	100.10	99.90	1
KU	C1S	2012587	02/2011	01/27/2011	100.00	100.20	100.00	1
KU	C1S	2012588	02/2011	02/01/2011	99.90	100.10	100.10	1
KU	C1S	2012589	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012590	02/2011	01/27/2011	99.90	100.10	99.90	1
KU	C1S	2012591	02/2011	01/27/2011	100.00	100.00	100.10	1
KU	C1S	2012592	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012593	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012594	02/2011	01/27/2011	100.00	100.20	100.00	1
KU	C1S	2012595	02/2011	01/27/2011	100.00	99.90	99.90	1
KU	C1S	2012596	02/2011	01/27/2011	100.00	100.10	100.00	1
KU	C1S	2012597	02/2011	01/27/2011	100.00	100.00	99.90	1
KU	C1S	2012598	02/2011	01/27/2011	100.00	100.00	100.00	1
KU	C1S	2012599	02/2011	02/01/2011	100.00	100.10	100.10	1
KU	C1S	2012600	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012601	02/2011	02/01/2011	99.90	100.20	100.00	1
KU	C1S	2012602	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012603	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012604	02/2011	02/01/2011	100.00	100.00	99.80	1
KU	C1S	2012605	02/2011	02/01/2011	100.00	100.20	100.10	1
KU	C1S	2012606	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012607	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2012608	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012609	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012610	02/2011	02/01/2011	100.00	100.00	100.00	1
KU	C1S	2012611	02/2011	02/01/2011	100.00	99.90	100.00	1
KU	C1S	2012612	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012613	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012614	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012615	02/2011	02/01/2011	100.00	100.10	100.00	1

KU	C1S	2012616	02/2011	02/01/2011	100.00	100.00	99.90	1
KU	C1S	2012617	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2012618	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012619	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012620	02/2011	02/01/2011	100.00	100.20	100.00	1
KU	C1S	2012621	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012622	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012623	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012624	02/2011	02/01/2011	100.00	100.10	99.90	1
KU	C1S	2012625	02/2011	02/01/2011	100.00	100.10	100.00	1
KU	C1S	2012626	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012627	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012628	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012629	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012630	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012631	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012632	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012633	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012634	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012635	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2012636	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012637	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012638	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012639	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012640	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012641	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012642	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012643	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012644	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012645	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2012646	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2012647	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012648	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012649	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012650	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012651	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2012652	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2012653	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012654	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012655	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012656	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012657	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012658	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012659	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012660	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012661	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012662	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012663	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012664	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012665	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012666	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012667	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2012668	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012669	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012670	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2012671	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012672	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012673	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012674	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012675	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2012676	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012677	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2012678	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012679	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012680	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012681	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012682	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012683	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012684	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012685	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012686	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012687	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012688	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012689	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012690	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012691	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012692	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012693	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012694	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012695	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012696	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2012697	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012698	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012699	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012700	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012701	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012702	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012703	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012704	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012705	02/2011	01/31/2011	100.00	99.90	99.90	1

KU	C1S	2012706	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012707	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012708	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012709	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012710	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012711	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012712	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012713	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012714	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012715	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012716	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012717	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012718	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012719	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012720	02/2011	01/31/2011	99.90	99.90	99.80	1
KU	C1S	2012721	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012722	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012723	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012724	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012725	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012726	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012727	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012728	02/2011	01/31/2011	99.90	99.90	100.00	1
KU	C1S	2012729	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012730	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012731	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012732	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012733	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012734	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012735	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2012736	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2012737	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2012738	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012739	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2012740	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012741	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012742	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012743	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012744	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012745	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012746	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012747	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012748	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012749	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012750	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012751	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012752	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2012753	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012754	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012755	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012756	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012757	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012758	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012759	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012760	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012761	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012762	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012763	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012764	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2012765	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2012766	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012767	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012768	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2012769	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012770	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012771	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012772	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012773	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012774	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012775	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012776	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012777	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2012778	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2012779	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012780	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012781	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012782	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012783	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012784	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012785	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012786	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012787	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012788	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2012789	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2012790	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012791	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012792	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012793	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012794	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012795	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2012796	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012797	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2012798	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012799	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012800	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012801	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012802	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012803	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012804	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2012805	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012806	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012807	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2012808	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012809	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012810	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012811	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012812	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012813	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012814	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012815	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012816	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012817	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012818	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012819	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012820	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2012821	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012822	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012823	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2012824	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012825	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2012826	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012827	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012828	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012829	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012830	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012831	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012832	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012833	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012834	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012835	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012836	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012837	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012838	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012839	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012840	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012841	02/2011	01/31/2011	99.90	100.20	100.00	1
KU	C1S	2012842	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012843	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012844	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012845	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012846	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012847	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012848	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012849	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012850	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012851	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012852	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012853	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2012854	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012855	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2012856	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012857	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012858	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012859	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012860	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012861	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012862	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012863	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012864	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012865	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012866	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012867	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012868	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012869	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012870	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012871	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012872	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012873	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012874	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012875	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2012876	02/2011	01/28/2011	100.00	100.20	99.90	1
KU	C1S	2012877	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012878	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012879	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012880	02/2011	01/31/2011	100.00	100.10	99.80	1
KU	C1S	2012881	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012882	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2012883	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012884	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012885	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2012886	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2012887	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012888	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2012889	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012890	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012891	02/2011	01/31/2011	100.00	100.10	99.80	1
KU	C1S	2012892	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012893	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012894	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012895	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012896	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012897	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012898	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012899	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012900	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012901	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012902	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012903	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012904	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012905	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012906	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012907	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012908	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2012909	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012910	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012911	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012912	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012913	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012914	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012915	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2012916	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012917	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012918	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012919	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012920	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012921	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2012922	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012923	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012924	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012925	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012926	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012927	02/2011	01/31/2011	100.00	100.10	99.80	1
KU	C1S	2012928	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012929	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012930	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012931	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012932	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012933	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2012934	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012935	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012936	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012937	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012938	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012939	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2012940	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012941	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2012942	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2012943	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012944	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2012945	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2012946	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012947	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012948	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012949	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012950	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012951	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012952	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012953	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012954	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012955	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012956	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012957	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012958	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012959	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012960	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012961	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012962	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012963	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012964	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012965	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012966	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012967	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2012968	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012969	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2012970	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012971	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012972	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2012973	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012974	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012975	02/2011	01/31/2011	100.00	100.00	100.10	1

KU	C1S	2012976	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012977	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012978	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012979	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012980	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012981	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2012982	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012983	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012984	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012985	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012986	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012987	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2012988	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012989	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012990	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2012991	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012992	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2012993	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2012994	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012995	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2012996	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012997	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2012998	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2012999	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2013000	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013001	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013002	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013003	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013004	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013005	02/2011	01/31/2011	99.90	100.00	100.10	1

KU	C1S	2013006	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013007	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013008	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013009	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013010	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013011	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013012	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013013	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013014	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013015	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013016	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013017	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013018	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013019	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013020	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013021	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013022	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2013023	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013024	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013025	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013026	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013027	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013028	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013029	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013030	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013031	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013032	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013033	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013034	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013035	02/2011	01/31/2011	100.00	100.00	100.10	1

KU	C1S	2013036	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013037	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013038	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013039	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013040	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013041	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013042	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013043	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013044	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013045	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013046	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013047	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013048	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013049	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013050	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013051	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013052	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013053	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013054	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013055	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013056	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013057	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013058	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013059	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013060	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013061	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013062	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013063	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013064	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013065	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013066	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013067	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013068	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013069	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013070	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013071	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013072	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013073	02/2011	01/31/2011	99.90	99.90	100.10	1
KU	C1S	2013074	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013075	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013076	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013077	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013078	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013079	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013080	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013081	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013082	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013083	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013084	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013085	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013086	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013087	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013088	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013089	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013090	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013091	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013092	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013093	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013094	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013095	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013096	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013097	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013098	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013099	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013100	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013101	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013102	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013103	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013104	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013105	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013106	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013107	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013108	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013109	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013110	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013111	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013112	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013113	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013114	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013115	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013116	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013117	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013118	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013119	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013120	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013121	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013122	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013123	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013124	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013125	02/2011	01/31/2011	99.90	100.10	100.00	1

KU	C1S	2013126	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013127	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013128	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013129	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013130	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013131	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013132	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013133	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013134	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013135	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013136	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013137	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013138	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013139	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013140	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013141	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013142	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013143	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013144	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013145	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013146	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013147	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013148	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013149	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013150	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013151	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013152	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013153	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2013154	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013155	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2013156	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013157	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013158	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013159	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013160	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013161	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013162	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013163	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013164	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013165	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013166	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013167	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013168	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013169	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013170	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013171	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013172	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013173	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013174	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013175	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013176	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013177	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013178	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013179	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013180	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013181	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013182	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013183	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013184	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013185	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013186	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013187	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013188	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013189	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013190	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013191	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013192	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013193	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013194	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013195	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013196	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013197	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013198	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013199	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013200	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013201	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013202	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013203	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013204	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013205	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013206	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013207	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013208	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013209	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013210	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013211	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013212	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013213	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013214	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013215	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013216	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013217	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013218	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013219	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013220	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013221	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013222	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2013223	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013224	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013225	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013226	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2013227	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013228	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013229	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013230	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013231	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013232	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013233	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013234	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013235	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013236	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013237	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2013238	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013239	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013240	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013241	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013242	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013243	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013244	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013245	02/2011	01/31/2011	100.00	100.20	100.20	1

KU	C1S	2013246	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013247	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013248	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013249	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013250	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013251	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013252	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013253	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013254	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013255	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013256	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013257	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013258	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013259	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013260	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013261	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013262	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013263	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013264	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013265	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013266	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013267	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013268	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013269	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013270	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013271	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013272	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013273	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013274	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013275	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2013276	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013277	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013278	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013279	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2013280	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013281	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013282	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013283	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013284	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013285	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013286	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013287	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013288	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013289	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013290	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013291	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013292	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013293	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013294	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013295	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013296	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013297	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013298	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013299	02/2011	01/31/2011	99.90	99.90	99.80	1
KU	C1S	2013300	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013301	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013302	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013303	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013304	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013305	02/2011	01/31/2011	100.00	100.00	100.10	1

KU	C1S	2013306	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013307	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013308	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013309	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013310	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013311	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013312	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013313	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013314	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013315	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013316	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013317	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013318	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013319	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013320	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013321	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013322	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013323	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013324	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013325	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013326	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013327	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013328	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013329	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013330	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013331	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013332	02/2011	01/31/2011	100.10	100.20	100.20	1
KU	C1S	2013333	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013334	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013335	02/2011	01/31/2011	100.00	100.00	100.00	1

KU	C1S	2013336	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013337	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013338	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013339	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013340	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013341	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013342	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013343	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013344	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013345	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013346	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013347	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013348	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013349	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013350	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013351	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013352	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013353	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013354	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2013355	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013356	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013357	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013358	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013359	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013360	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013361	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013362	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013363	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013364	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013365	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013366	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013367	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013368	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013369	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013370	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013371	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013372	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013373	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013374	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013375	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013376	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013377	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013378	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013379	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013380	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013381	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013382	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013383	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013384	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013385	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013386	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013387	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013388	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013389	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013390	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013391	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013392	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013393	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013394	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013395	02/2011	01/31/2011	100.00	100.00	100.00	1

KU	C1S	2013396	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2013397	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013398	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013399	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013400	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013401	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013402	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013403	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013404	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013405	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013406	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013407	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013408	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013409	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013410	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013411	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013412	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013413	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013414	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013415	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2013416	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013417	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013418	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013419	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013420	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013421	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013422	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013423	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013424	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2013425	02/2011	01/31/2011	100.00	100.20	100.10	1

KU	C1S	2013426	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013427	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013428	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013429	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013430	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013431	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013432	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013433	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013434	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013435	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013436	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013437	02/2011	01/31/2011	100.00	100.20	100.20	1
KU	C1S	2013438	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013439	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013440	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013441	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013442	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013443	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013444	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013445	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013446	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013447	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013448	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013449	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013450	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013451	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013452	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013453	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013454	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013455	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013456	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013457	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013458	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013459	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013460	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013461	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013462	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013463	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013464	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013465	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013466	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013467	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013468	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013469	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013470	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013471	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013472	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013473	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013474	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013475	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013476	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013477	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013478	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013479	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013480	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013481	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013482	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013483	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013484	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013485	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013486	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013487	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013488	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013489	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013490	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013491	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013492	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013493	02/2011	01/31/2011	99.90	100.00	100.20	1
KU	C1S	2013494	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013495	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013496	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013497	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013498	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013499	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013500	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013501	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013502	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013503	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013504	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013505	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013506	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013507	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013508	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013509	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013510	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013511	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013512	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013513	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013514	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013515	02/2011	01/31/2011	100.00	100.20	99.90	1

KU	C1S	2013516	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013517	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013518	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013519	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013520	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013521	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013522	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013523	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013524	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013525	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013526	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013527	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013528	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013529	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013530	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013531	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013532	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013533	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013534	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013535	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013536	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013537	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013538	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013539	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013540	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013541	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2013542	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013543	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013544	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013545	02/2011	01/31/2011	99.90	100.10	100.00	1

KU	C1S	2013546	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2013547	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013548	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013549	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013550	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013551	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013552	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013553	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013554	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013555	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013556	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013557	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013558	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013559	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013560	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013561	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013562	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013563	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013564	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013565	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013566	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013567	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013568	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013569	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013570	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013571	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013572	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013573	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013574	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013575	02/2011	01/31/2011	99.90	100.10	100.10	1

KU	C1S	2013576	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013577	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013578	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013579	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013580	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013581	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013582	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013583	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013584	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013585	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013586	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013587	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013588	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013589	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013590	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013591	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013592	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013593	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013594	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013595	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013596	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013597	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013598	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013599	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013600	02/2011	01/31/2011	99.90	100.20	100.00	1
KU	C1S	2013601	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013602	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013603	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013604	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013605	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2013606	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013607	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013608	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013609	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013610	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013611	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013612	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013613	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013614	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013615	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013616	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013617	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013618	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013619	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013620	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013621	02/2011	01/31/2011	99.90	100.20	100.00	1
KU	C1S	2013622	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013623	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013624	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013625	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013626	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013627	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013628	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013629	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013630	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013631	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013632	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013633	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013634	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013635	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2013636	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013637	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013638	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013639	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013640	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013641	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013642	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013643	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013644	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013645	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013646	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013647	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013648	02/2011	01/31/2011	100.00	99.90	100.10	1
KU	C1S	2013649	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013650	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013651	02/2011	01/31/2011	99.90	100.20	100.00	1
KU	C1S	2013652	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013653	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013654	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013655	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013656	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013657	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013658	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013659	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013660	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013661	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013662	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013663	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013664	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013665	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013666	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013667	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013668	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2013669	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2013670	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013671	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013672	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013673	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013674	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013675	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013676	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013677	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013678	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013679	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013680	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013681	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013682	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013683	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013684	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013685	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013686	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013687	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013688	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013689	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013690	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013691	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013692	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013693	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013694	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013695	02/2011	01/31/2011	100.00	100.20	100.00	1

KU	C1S	2013696	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013697	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013698	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013699	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013700	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013701	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013702	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013703	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2013704	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013705	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013706	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013707	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013708	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013709	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013710	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013711	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013712	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013713	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013714	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013715	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013716	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013717	02/2011	01/25/2011	100.00	100.10	100.10	1
KU	C1S	2013718	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013719	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013720	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013721	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013722	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013723	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013724	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013725	02/2011	01/31/2011	100.00	100.00	99.80	1

KU	C1S	2013726	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013727	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013728	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013729	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013730	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013731	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013732	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013733	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013734	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013735	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013736	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013737	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013738	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013739	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013740	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013741	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013742	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013743	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013744	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2013745	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013746	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013747	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013748	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013749	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013750	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013751	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013752	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013753	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013754	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013755	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013756	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013757	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013758	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013759	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013760	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2013761	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013762	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013763	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013764	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013765	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013766	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013767	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013768	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013769	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013770	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013771	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013772	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013773	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013774	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013775	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013776	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013777	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013778	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013779	02/2011	01/31/2011	100.00	100.00	100.20	1
KU	C1S	2013780	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013781	02/2011	01/31/2011	100.00	99.90	100.10	1
KU	C1S	2013782	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013783	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013784	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013785	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013786	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013787	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013788	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013789	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013790	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013791	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013792	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2013793	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013794	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013795	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013796	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013797	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013798	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013799	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013800	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013801	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013802	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013803	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013804	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013805	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013806	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013807	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013808	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013809	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013810	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2013811	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013812	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013813	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013814	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013815	02/2011	01/31/2011	100.00	100.10	99.90	1

KU	C1S	2013816	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013817	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013818	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013819	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013820	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013821	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013822	02/2011	01/04/2011	100.00	100.10	100.10	1
KU	C1S	2013823	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013824	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013825	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013826	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013827	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013828	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2013829	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013830	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013831	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013832	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2013833	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013834	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2013835	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013836	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013837	02/2011	10/08/2010	100.00	100.00	99.80	1
KU	C1S	2013838	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013839	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013840	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013841	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013842	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013843	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013844	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013845	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013846	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013847	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013848	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013849	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013850	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013851	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013852	02/2011	01/31/2011	99.90	99.90	100.00	1
KU	C1S	2013853	02/2011	01/31/2011	99.90	100.00	99.80	1
KU	C1S	2013854	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013855	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013856	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013857	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013858	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013859	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013860	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013861	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013862	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013863	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013864	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013865	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013866	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013867	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013868	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013869	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013870	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013871	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013872	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013873	02/2011	01/31/2011	100.00	100.20	100.20	1
KU	C1S	2013874	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013875	02/2011	01/31/2011	100.00	100.00	100.10	1

KU	C1S	2013876	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013877	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013878	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013879	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013880	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013881	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013882	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013883	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2013884	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013885	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013886	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013887	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013888	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013889	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013890	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013891	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013892	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013893	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013894	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013895	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013896	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013897	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013898	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013899	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013900	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013901	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2013902	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013903	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013904	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013905	02/2011	01/31/2011	100.00	100.00	100.00	1

KU	C1S	2013906	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013907	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013908	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013909	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013910	02/2011	01/31/2011	99.90	100.20	99.90	1
KU	C1S	2013911	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013912	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013913	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013914	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013915	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013916	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013917	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013918	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013919	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2013920	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013921	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013922	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013923	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013924	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013925	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013926	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013927	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013928	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013929	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013930	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013931	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013932	02/2011	01/31/2011	99.90	99.90	100.00	1
KU	C1S	2013933	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013934	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013935	02/2011	01/31/2011	100.00	100.00	100.10	1

KU	C1S	2013936	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013937	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013938	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013939	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013940	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013941	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013942	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013943	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013944	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013945	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013946	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013947	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013948	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013949	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013950	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013951	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013952	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013953	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013954	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013955	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013956	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2013957	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013958	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013959	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013960	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013961	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013962	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013963	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013964	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013965	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2013966	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013967	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013968	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013969	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2013970	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013971	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013972	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013973	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013974	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013975	02/2011	01/31/2011	99.90	99.90	100.00	1
KU	C1S	2013976	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013977	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013978	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013979	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013980	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013981	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013982	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2013983	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013984	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013985	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2013986	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013987	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2013988	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013989	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2013990	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2013991	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2013992	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2013993	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2013994	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013995	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2013996	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2013997	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2013998	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2013999	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014000	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014001	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014002	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2014003	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014004	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014005	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014006	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014007	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014008	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014009	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014010	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014011	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014012	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014013	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014014	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014015	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014016	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014017	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014018	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014019	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014020	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014021	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014022	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014023	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014024	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014025	02/2011	01/31/2011	99.90	100.10	100.00	1

KU	C1S	2014026	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014027	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014028	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014029	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014030	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014031	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014032	02/2011	01/31/2011	100.00	99.90	100.10	1
KU	C1S	2014033	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014034	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014035	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014036	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014037	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2014038	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014039	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014040	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014041	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014042	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014043	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014044	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014045	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014046	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014047	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014048	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014049	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014050	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014051	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014052	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014053	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014054	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014055	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2014056	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014057	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014058	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014059	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014060	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014061	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014062	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014063	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014064	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014065	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014066	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014067	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014068	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014069	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014070	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014071	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014072	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014073	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014074	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014075	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2014076	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014077	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014078	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014079	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014080	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014081	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014082	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014083	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014084	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014085	02/2011	01/31/2011	100.00	100.00	99.90	1

KU	C1S	2014086	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014087	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014088	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014089	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014090	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014091	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014092	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014093	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014094	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014095	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014096	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014097	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014098	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014099	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014100	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014101	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014102	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014103	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014104	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014105	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014106	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014107	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014108	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014109	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014110	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014111	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014112	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014113	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014114	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014115	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2014116	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014117	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014118	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014119	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014120	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014121	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014122	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014123	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014124	02/2011	01/31/2011	99.90	100.10	100.10	1
KU	C1S	2014125	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014126	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014127	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014128	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014129	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014130	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2014131	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014132	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014133	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014134	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014135	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014136	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2014137	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014138	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014139	02/2011	01/31/2011	99.90	100.00	99.90	1
KU	C1S	2014140	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014141	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014142	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014143	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014144	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014145	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2014146	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014147	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014148	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014149	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014150	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014151	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014152	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014153	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014154	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014155	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014156	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014157	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2014158	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014159	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014160	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2014161	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014162	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014163	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014164	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014165	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014166	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2014167	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014168	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014169	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014170	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014171	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014172	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2014173	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014174	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014175	02/2011	01/31/2011	100.00	100.00	100.00	1

KU	C1S	2014176	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014177	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014178	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014179	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014180	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014181	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014182	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014183	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014184	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014185	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014186	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014187	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014188	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014189	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014190	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014191	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014192	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014193	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014194	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014195	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014196	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014197	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014198	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014199	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2014200	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014201	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014202	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014203	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014204	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014205	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2014206	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014207	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014208	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014209	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014210	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014211	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014212	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014213	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014214	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014215	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014216	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014217	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014218	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014219	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014220	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014221	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014222	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014223	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014224	02/2011	01/31/2011	99.90	99.90	99.80	1
KU	C1S	2014225	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014226	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014227	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014228	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2014229	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014230	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014231	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014232	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014233	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014234	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014235	02/2011	01/31/2011	99.90	100.10	100.10	1

KU	C1S	2014236	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014237	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014238	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014239	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014240	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014241	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014242	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014243	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014244	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014245	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014246	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014247	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2014248	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014249	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014250	02/2011	01/31/2011	99.90	100.10	99.90	1
KU	C1S	2014251	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014252	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014253	02/2011	01/31/2011	100.00	99.90	100.00	1
KU	C1S	2014254	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014255	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014256	02/2011	01/31/2011	100.00	99.90	99.80	1
KU	C1S	2014257	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014258	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014259	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014260	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014261	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014262	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2014263	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014264	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014265	02/2011	01/31/2011	100.00	100.00	100.00	1

KU	C1S	2014266	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014267	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014268	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014269	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014270	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014271	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014272	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014273	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014274	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014275	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014276	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014277	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014278	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014279	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014280	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2014281	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014282	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014283	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014284	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2014285	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014286	02/2011	01/31/2011	99.90	100.00	100.10	1
KU	C1S	2014287	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014288	02/2011	01/31/2011	99.90	100.10	100.00	1
KU	C1S	2014289	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014290	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014291	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014292	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014293	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014294	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014295	02/2011	01/31/2011	100.00	100.10	100.00	1

KU	C1S	2014296	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2014297	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014298	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014299	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014300	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014301	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014302	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014303	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014304	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014305	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014306	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014307	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014308	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014309	02/2011	01/31/2011	100.00	100.10	100.20	1
KU	C1S	2014310	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014311	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014312	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014313	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014314	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014315	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014316	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014317	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014318	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014319	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014320	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014321	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014322	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014323	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014324	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014325	02/2011	01/31/2011	100.00	99.90	99.90	1

KU	C1S	2014326	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014327	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014328	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014329	02/2011	01/31/2011	99.90	99.90	99.90	1
KU	C1S	2014330	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014331	02/2011	01/31/2011	99.90	100.00	100.00	1
KU	C1S	2014332	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014333	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014334	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014335	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014336	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014337	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014338	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014339	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014340	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014341	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014342	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014343	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014344	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014345	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014346	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014347	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014348	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014349	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014350	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014351	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014352	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014353	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014354	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014355	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2014356	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014357	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014358	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014359	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014360	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014361	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014362	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014363	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014364	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014365	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014366	02/2011	01/31/2011	100.00	100.20	100.00	1
KU	C1S	2014367	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014368	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014369	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014370	02/2011	01/31/2011	100.00	100.20	100.10	1
KU	C1S	2014371	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014372	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014373	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014374	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014375	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014376	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014377	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014378	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014379	02/2011	01/31/2011	100.00	99.90	100.10	1
KU	C1S	2014380	02/2011	01/31/2011	100.00	100.10	99.90	1
KU	C1S	2014381	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014382	02/2011	01/31/2011	100.00	100.00	99.80	1
KU	C1S	2014383	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014384	02/2011	01/31/2011	100.00	100.10	100.10	1
KU	C1S	2014385	02/2011	01/31/2011	100.00	100.10	100.10	1

KU	C1S	2014386	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014387	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014388	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014389	02/2011	01/31/2011	100.00	100.10	100.00	1
KU	C1S	2014390	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014391	02/2011	01/31/2011	100.00	100.20	99.90	1
KU	C1S	2014392	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014393	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014394	02/2011	01/31/2011	100.00	100.00	100.10	1
KU	C1S	2014395	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014396	02/2011	01/31/2011	100.00	99.90	99.90	1
KU	C1S	2014397	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014398	02/2011	01/31/2011	100.00	100.00	100.00	1
KU	C1S	2014399	02/2011	01/31/2011	100.00	100.00	99.90	1
KU	C1S	2014400	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014401	03/2011	03/08/2011	99.90	100.10	100.10	1
KU	C1S	2014402	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014403	03/2011	03/08/2011	99.90	100.00	100.20	1
KU	C1S	2014404	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014405	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014406	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014407	03/2011	03/08/2011	99.90	100.00	100.20	1
KU	C1S	2014408	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014409	03/2011	03/08/2011	100.00	100.20	100.20	1
KU	C1S	2014410	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014411	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014412	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014413	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014414	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014415	03/2011	03/08/2011	100.00	100.10	100.20	1

KU	C1S	2014416	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014417	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014418	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014419	03/2011	03/08/2011	100.00	100.20	100.20	1
KU	C1S	2014420	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014421	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014422	03/2011	03/08/2011	100.00	100.20	100.20	1
KU	C1S	2014423	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014424	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014425	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014426	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014427	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014428	03/2011	03/08/2011	99.90	100.10	100.10	1
KU	C1S	2014429	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014430	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014431	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014432	03/2011	03/08/2011	99.90	100.10	100.10	1
KU	C1S	2014433	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014434	03/2011	03/08/2011	99.90	100.10	100.20	1
KU	C1S	2014435	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014436	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014437	03/2011	03/08/2011	100.00	100.10	99.90	1
KU	C1S	2014438	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014439	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014440	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014441	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014442	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014443	03/2011	03/08/2011	100.00	100.10	100.00	1
KU	C1S	2014444	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014445	03/2011	03/08/2011	100.00	100.10	100.10	1

KU	C1S	2014446	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014447	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014448	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014449	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014450	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014451	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014452	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014453	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014454	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014455	03/2011	03/08/2011	99.90	100.00	100.10	1
KU	C1S	2014456	03/2011	03/08/2011	100.00	99.90	100.10	1
KU	C1S	2014457	03/2011	03/08/2011	100.00	100.20	100.10	1
KU	C1S	2014458	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014459	03/2011	03/08/2011	99.90	100.10	100.10	1
KU	C1S	2014460	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014461	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014462	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014463	03/2011	03/08/2011	100.00	100.00	100.00	1
KU	C1S	2014464	03/2011	03/08/2011	99.90	100.10	100.20	1
KU	C1S	2014465	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014466	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014467	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014468	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014469	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014470	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014471	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014472	03/2011	03/08/2011	100.00	100.20	100.20	1
KU	C1S	2014473	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014474	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014475	03/2011	03/08/2011	100.00	100.20	100.10	1

KU	C1S	2014476	03/2011	03/08/2011	100.00	100.00	100.00	1
KU	C1S	2014477	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014478	03/2011	03/08/2011	99.90	100.10	100.20	1
KU	C1S	2014479	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014480	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014481	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014482	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014483	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014484	03/2011	03/08/2011	100.00	100.20	100.20	1
KU	C1S	2014485	03/2011	03/08/2011	99.90	100.10	100.10	1
KU	C1S	2014486	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014487	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014488	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014489	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014490	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014491	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014492	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014493	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014494	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014495	03/2011	03/08/2011	100.00	100.10	100.00	1
KU	C1S	2014496	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014497	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014498	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014499	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014500	03/2011	03/08/2011	99.90	100.00	100.10	1
KU	C1S	2014501	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014502	03/2011	03/08/2011	99.90	100.00	100.10	1
KU	C1S	2014503	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014504	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014505	03/2011	03/08/2011	99.90	100.10	100.10	1

KU	C1S	2014506	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014507	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014508	03/2011	03/08/2011	100.00	100.00	100.20	1
KU	C1S	2014509	03/2011	03/08/2011	100.00	100.10	100.00	1
KU	C1S	2014510	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014511	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014512	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014513	03/2011	03/08/2011	100.00	100.10	100.10	1
KU	C1S	2014514	03/2011	03/08/2011	100.00	100.00	100.10	1
KU	C1S	2014515	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014516	03/2011	03/08/2011	99.90	100.00	100.10	1
KU	C1S	2014517	03/2011	03/08/2011	100.00	100.10	100.00	1
KU	C1S	2014518	03/2011	03/08/2011	100.00	100.10	100.20	1
KU	C1S	2014519	03/2011	03/08/2011	100.00	100.10	100.00	1
KU	C1S	2014820	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014821	06/2011	05/02/2011	100.00	100.00	100.00	1
KU	C1S	2014822	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014823	06/2011	05/03/2011	100.00	99.90	100.00	1
KU	C1S	2014824	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014825	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014826	06/2011	05/02/2011	100.00	100.00	99.90	1
KU	C1S	2014827	06/2011	05/02/2011	100.00	100.00	99.80	1
KU	C1S	2014828	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014829	06/2011	05/02/2011	100.00	100.20	100.10	1
KU	C1S	2014830	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014831	06/2011	05/02/2011	100.00	100.00	100.00	1
KU	C1S	2014832	06/2011	05/02/2011	100.00	100.10	100.00	1
KU	C1S	2014833	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014834	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014835	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2014836	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014837	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014838	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014839	06/2011	05/02/2011	100.00	100.10	100.00	1
KU	C1S	2014840	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014841	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014842	06/2011	05/02/2011	100.00	100.20	100.00	1
KU	C1S	2014843	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2014844	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014845	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014846	06/2011	05/02/2011	100.00	100.10	100.00	1
KU	C1S	2014847	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014848	06/2011	05/02/2011	100.00	100.10	100.10	1
KU	C1S	2014849	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2014850	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014851	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014852	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2014853	06/2011	05/02/2011	100.00	100.00	100.10	1
KU	C1S	2014854	06/2011	05/02/2011	100.00	100.00	99.90	1
KU	C1S	2014855	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014856	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2014857	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014858	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014859	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014860	06/2011	05/02/2011	100.00	100.10	100.00	1
KU	C1S	2014861	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014862	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014863	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014864	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014865	06/2011	05/03/2011	100.00	100.20	100.00	1

KU	C1S	2014866	06/2011	05/02/2011	100.00	100.00	99.90	1
KU	C1S	2014867	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014868	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014869	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014870	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2014871	06/2011	05/03/2011	100.00	99.90	100.00	1
KU	C1S	2014872	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014873	06/2011	05/02/2011	100.00	100.00	99.80	1
KU	C1S	2014874	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014875	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014876	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014877	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014878	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014879	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014880	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014881	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2014882	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014883	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014884	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014885	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014886	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014887	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014888	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014889	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014890	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014891	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2014892	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2014893	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014894	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014895	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2014896	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014897	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014898	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014899	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014900	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014901	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014902	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014903	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014904	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2014905	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014906	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014907	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014908	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014909	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014910	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014911	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014912	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2014913	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014914	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2014915	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014916	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014917	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014918	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014919	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014920	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014921	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2014922	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014923	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014924	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014925	06/2011	04/27/2011	100.00	100.10	100.00	1

KU	C1S	2014926	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2014927	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014928	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2014929	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014930	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014931	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014932	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014933	06/2011	04/27/2011	99.90	100.10	100.10	1
KU	C1S	2014934	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014935	06/2011	04/27/2011	100.00	100.10	100.20	1
KU	C1S	2014936	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014937	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014938	06/2011	04/20/2011	100.00	100.10	100.10	1
KU	C1S	2014939	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014940	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014941	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2014942	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2014943	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014944	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014945	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014946	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014947	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014948	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014949	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014950	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2014951	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014952	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014953	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2014954	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014955	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2014956	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014957	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014958	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014959	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014960	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014961	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2014962	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014963	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2014964	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014965	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2014966	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014967	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014968	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014969	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014970	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2014971	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014972	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014973	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2014974	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2014975	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014976	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2014977	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2014978	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014979	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2014980	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2014981	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014982	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014983	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014984	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2014985	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2014986	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2014987	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014988	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2014989	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014990	06/2011	04/27/2011	100.00	99.90	100.00	1
KU	C1S	2014991	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2014992	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2014993	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2014994	06/2011	04/12/2011	99.90	100.00	100.00	1
KU	C1S	2014995	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2014996	06/2011	04/12/2011	100.00	100.00	99.90	1
KU	C1S	2014997	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2014998	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2014999	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015000	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015001	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015002	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015003	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015004	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015005	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015006	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015007	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015008	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015009	06/2011	04/12/2011	100.00	100.00	99.90	1
KU	C1S	2015010	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015011	06/2011	04/12/2011	99.90	100.10	100.00	1
KU	C1S	2015012	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015013	06/2011	04/12/2011	100.00	100.10	99.90	1
KU	C1S	2015014	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015015	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2015016	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015017	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015018	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015019	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015020	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015021	06/2011	04/12/2011	100.00	100.20	100.00	1
KU	C1S	2015022	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015023	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015024	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015025	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015026	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015027	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015028	06/2011	04/12/2011	100.00	100.00	99.90	1
KU	C1S	2015029	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015030	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015031	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015032	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015033	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015034	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015035	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015036	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015037	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015038	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015039	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015040	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015041	06/2011	04/12/2011	100.00	100.00	100.00	1
KU	C1S	2015042	06/2011	04/12/2011	100.00	100.00	100.10	1
KU	C1S	2015043	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015044	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015045	06/2011	04/12/2011	100.00	100.00	99.80	1

KU	C1S	2015046	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015047	06/2011	04/12/2011	100.00	100.20	100.10	1
KU	C1S	2015048	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015049	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015050	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015051	06/2011	04/12/2011	100.00	100.00	99.90	1
KU	C1S	2015052	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015053	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015054	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015055	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015056	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015057	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015058	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015059	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015060	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015061	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015062	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015063	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015064	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015065	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015066	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015067	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015068	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015069	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015070	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015071	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015072	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015073	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015074	06/2011	04/12/2011	100.00	100.00	99.90	1
KU	C1S	2015075	06/2011	04/12/2011	100.00	100.00	99.80	1

KU	C1S	2015076	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015077	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015078	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015079	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015080	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015081	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015082	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015083	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015084	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015085	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015086	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015087	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015088	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015089	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015090	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015091	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015092	06/2011	04/12/2011	100.00	100.20	100.00	1
KU	C1S	2015093	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015094	06/2011	04/12/2011	100.00	100.10	100.00	1
KU	C1S	2015095	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015096	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015097	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015098	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015099	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015100	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015101	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015102	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015103	06/2011	04/12/2011	100.00	100.10	100.10	1
KU	C1S	2015104	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015105	06/2011	05/03/2011	100.00	100.20	100.10	1

KU	C1S	2015106	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015107	06/2011	04/12/2011	100.00	100.10	100.10	1
KU	C1S	2015108	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015109	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015110	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015111	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015112	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015113	06/2011	04/12/2011	100.00	99.90	99.80	1
KU	C1S	2015114	06/2011	04/12/2011	100.00	100.00	100.00	1
KU	C1S	2015115	06/2011	04/12/2011	100.00	100.20	100.10	1
KU	C1S	2015116	06/2011	04/12/2011	100.00	100.00	100.00	1
KU	C1S	2015117	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015118	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015119	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015120	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015121	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015122	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015123	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015124	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015125	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015126	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015127	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015128	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015129	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015130	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015131	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015132	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015133	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015134	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015135	06/2011	04/27/2011	100.00	100.00	99.90	1

KU	C1S	2015136	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015137	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015138	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015139	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015140	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015141	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015142	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015143	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015144	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015145	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015146	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015147	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015148	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015149	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015150	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015151	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015152	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015153	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015154	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015155	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015156	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015157	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015158	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015159	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015160	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015161	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015162	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015163	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015164	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015165	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2015166	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015167	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015168	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015169	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015170	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015171	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015172	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015173	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015174	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015175	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015176	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015177	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015178	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015179	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015180	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015181	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015182	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015183	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015184	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015185	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015186	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015187	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015188	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015189	06/2011	04/27/2011	100.00	99.90	99.80	1
KU	C1S	2015190	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015191	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015192	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015193	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015194	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015195	06/2011	04/27/2011	100.00	100.00	99.80	1

KU	C1S	2015196	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015197	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015198	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015199	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015200	06/2011	04/27/2011	100.00	100.10	100.20	1
KU	C1S	2015201	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015202	06/2011	05/03/2011	100.00	100.10	100.20	1
KU	C1S	2015203	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015204	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015205	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015206	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015207	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015208	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015209	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015210	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015211	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015212	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015213	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015214	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015215	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015216	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015217	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015218	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015219	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015220	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015221	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015222	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015223	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015224	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015225	06/2011	04/27/2011	100.00	99.90	99.90	1

KU	C1S	2015226	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015227	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015228	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015229	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015230	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015231	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015232	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015233	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015234	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015235	06/2011	04/27/2011	99.90	100.10	100.00	1
KU	C1S	2015236	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015237	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015238	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015239	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015240	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015241	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015242	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015243	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015244	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015245	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015246	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015247	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015248	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015249	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015250	06/2011	04/27/2011	100.00	99.90	100.10	1
KU	C1S	2015251	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015252	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015253	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015254	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015255	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015256	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015257	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015258	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015259	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015260	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015261	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015262	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015263	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015264	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015265	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015266	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015267	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015268	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015269	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015270	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015271	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015272	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015273	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015274	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015275	06/2011	05/03/2011	99.90	99.90	99.80	1
KU	C1S	2015276	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015277	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015278	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015279	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015280	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015281	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015282	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015283	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015284	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015285	06/2011	04/27/2011	100.00	100.20	100.10	1

KU	C1S	2015286	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015287	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015288	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015289	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015290	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015291	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015292	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015293	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015294	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015295	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015296	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015297	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015298	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015299	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015300	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015301	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015302	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015303	06/2011	04/27/2011	99.90	99.90	99.90	1
KU	C1S	2015304	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015305	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015306	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015307	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015308	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015309	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015310	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015311	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015312	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015313	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015314	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015315	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2015316	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015317	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015318	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015319	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015320	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015321	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015322	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015323	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015324	06/2011	05/03/2011	99.90	100.20	100.00	1
KU	C1S	2015325	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015326	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015327	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015328	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015329	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015330	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015331	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015332	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015333	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015334	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015335	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015336	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015337	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015338	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015339	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015340	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015341	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015342	06/2011	05/03/2011	99.90	100.10	100.10	1
KU	C1S	2015343	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015344	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015345	06/2011	04/27/2011	100.00	100.00	100.10	1

KU	C1S	2015346	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015347	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015348	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015349	06/2011	04/27/2011	100.00	99.90	100.00	1
KU	C1S	2015350	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015351	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015352	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015353	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015354	06/2011	04/27/2011	99.90	100.10	100.10	1
KU	C1S	2015355	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015356	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015357	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015358	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015359	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015360	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015361	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015362	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015363	06/2011	05/03/2011	100.00	100.10	99.80	1
KU	C1S	2015364	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015365	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015366	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015367	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015368	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015369	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015370	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015371	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015372	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015373	06/2011	05/03/2011	99.90	100.10	100.10	1
KU	C1S	2015374	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015375	06/2011	04/27/2011	100.00	100.20	100.00	1

KU	C1S	2015376	06/2011	05/03/2011	100.00	100.10	100.20	1
KU	C1S	2015377	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015378	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015379	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015380	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015381	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015382	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015383	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015384	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015385	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015386	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015387	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015388	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015389	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015390	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015391	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015392	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015393	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015394	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015395	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015396	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015397	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015398	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015399	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015400	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015401	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015402	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015403	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015404	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015405	06/2011	05/03/2011	100.00	100.20	100.10	1

KU	C1S	2015406	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015407	06/2011	04/27/2011	100.00	99.90	100.00	1
KU	C1S	2015408	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015409	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015410	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015411	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015412	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015413	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015414	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015415	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015416	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015417	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015418	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015419	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015420	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2015421	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015422	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2015423	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015424	06/2011	05/03/2011	99.90	100.10	100.10	1
KU	C1S	2015425	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015426	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015427	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015428	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015429	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015430	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015431	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015432	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015433	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015434	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015435	06/2011	04/27/2011	100.00	100.10	100.00	1

KU	C1S	2015436	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015437	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015438	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015439	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015440	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015441	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015442	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015443	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015444	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015445	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015446	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015447	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015448	06/2011	05/02/2011	100.00	100.00	100.00	1
KU	C1S	2015449	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015450	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015451	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015452	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015453	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015454	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015455	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015456	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015457	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015458	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015459	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015460	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015461	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015462	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015463	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015464	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015465	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2015466	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015467	06/2011	04/27/2011	100.00	100.20	100.20	1
KU	C1S	2015468	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015469	06/2011	05/03/2011	100.00	100.10	99.80	1
KU	C1S	2015470	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015471	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2015472	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015473	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015474	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015475	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015476	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015477	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015478	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015479	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015480	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015481	06/2011	04/27/2011	99.90	100.00	99.80	1
KU	C1S	2015482	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015483	06/2011	04/27/2011	100.00	99.90	99.80	1
KU	C1S	2015484	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015485	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015486	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015487	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015488	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015489	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015490	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015491	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015492	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015493	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015494	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015495	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2015496	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015497	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015498	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015499	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015500	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015501	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015502	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015503	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015504	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015505	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015506	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015507	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015508	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015509	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015510	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015511	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015512	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015513	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015514	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015515	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015516	06/2011	05/03/2011	100.00	100.10	100.20	1
KU	C1S	2015517	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015518	06/2011	05/03/2011	99.90	100.00	100.00	1
KU	C1S	2015519	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015520	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015521	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015522	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015523	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015524	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015525	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2015526	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015527	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015528	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015529	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015530	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015531	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015532	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015533	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2015534	06/2011	04/27/2011	99.90	100.10	99.90	1
KU	C1S	2015535	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015536	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2015537	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015538	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015539	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015540	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015541	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015542	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015543	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015544	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015545	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015546	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015547	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015548	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015549	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015550	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015551	06/2011	04/27/2011	99.90	100.00	99.90	1
KU	C1S	2015552	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015553	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015554	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015555	06/2011	04/27/2011	100.00	100.10	100.10	1

KU	C1S	2015556	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015557	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015558	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015559	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015560	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015561	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015562	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015563	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015564	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015565	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015566	06/2011	04/27/2011	99.90	100.10	100.00	1
KU	C1S	2015567	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015568	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2015569	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015570	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015571	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015572	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015573	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015574	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015575	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015576	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015577	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015578	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015579	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015580	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015581	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015582	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015583	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015584	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015585	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2015586	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015587	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015588	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015589	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015590	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015591	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015592	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015593	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015594	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015595	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015596	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015597	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015598	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015599	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015600	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015601	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015602	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015603	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015604	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015605	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015606	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015607	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015608	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015609	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015610	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015611	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015612	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015613	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015614	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015615	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015616	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015617	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015618	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015619	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015620	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015621	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015622	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015623	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015624	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015625	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015626	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015627	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015628	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015629	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015630	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015631	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015632	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015633	06/2011	04/27/2011	100.00	99.90	100.00	1
KU	C1S	2015634	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015635	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015636	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015637	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015638	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015639	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015640	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015641	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015642	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015643	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015644	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015645	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015646	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015647	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015648	06/2011	04/27/2011	99.90	100.10	100.00	1
KU	C1S	2015649	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015650	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015651	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015652	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015653	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015654	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015655	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015656	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015657	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015658	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015659	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015660	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015661	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015662	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015663	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015664	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015665	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015666	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015667	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015668	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015669	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015670	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015671	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015672	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015673	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015674	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015675	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2015676	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015677	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015678	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015679	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015680	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015681	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015682	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015683	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015684	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015685	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015686	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015687	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015688	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2015689	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015690	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015691	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015692	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015693	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015694	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015695	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015696	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015697	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015698	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015699	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015700	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015701	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015702	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015703	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015704	06/2011	04/27/2011	100.00	99.90	99.80	1
KU	C1S	2015705	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2015706	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015707	06/2011	05/03/2011	99.90	100.00	100.00	1
KU	C1S	2015708	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2015709	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015710	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015711	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015712	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015713	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015714	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015715	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015716	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2015717	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015718	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015719	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015720	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015721	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015722	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015723	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015724	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015725	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015726	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015727	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015728	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015729	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015730	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015731	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015732	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015733	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015734	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015735	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015736	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015737	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015738	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015739	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015740	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015741	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015742	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015743	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015744	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015745	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015746	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015747	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015748	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015749	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015750	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015751	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015752	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015753	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015754	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015755	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015756	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015757	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015758	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015759	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015760	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015761	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015762	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015763	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015764	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015765	06/2011	05/03/2011	100.00	100.10	99.90	1

KU	C1S	2015766	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015767	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015768	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015769	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015770	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015771	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015772	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015773	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015774	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015775	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015776	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015777	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015778	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015779	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015780	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015781	06/2011	05/03/2011	99.90	99.90	99.90	1
KU	C1S	2015782	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015783	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015784	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015785	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015786	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015787	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015788	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015789	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015790	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015791	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015792	06/2011	05/03/2011	99.90	100.10	99.90	1
KU	C1S	2015793	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015794	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015795	06/2011	05/03/2011	99.90	100.10	99.90	1

KU	C1S	2015796	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015797	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015798	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015799	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015800	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015801	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015802	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015803	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015804	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015805	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015806	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015807	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015808	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015809	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015810	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015811	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015812	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015813	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015814	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015815	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015816	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015817	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015818	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015819	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015820	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015821	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015822	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015823	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015824	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015825	06/2011	05/03/2011	100.00	100.00	100.10	1

KU	C1S	2015826	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015827	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015828	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015829	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015830	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015831	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015832	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015833	06/2011	05/03/2011	99.90	100.00	100.00	1
KU	C1S	2015834	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015835	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015836	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015837	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015838	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015839	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015840	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015841	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015842	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015843	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015844	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015845	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015846	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015847	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015848	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015849	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015850	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015851	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015852	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015853	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015854	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015855	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015856	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015857	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015858	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015859	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2015860	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015861	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015862	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015863	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015864	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015865	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015866	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015867	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015868	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015869	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015870	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015871	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015872	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015873	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015874	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015875	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015876	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015877	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015878	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015879	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015880	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015881	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015882	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015883	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015884	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015885	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2015886	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015887	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015888	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015889	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015890	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015891	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015892	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015893	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015894	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015895	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015896	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015897	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015898	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015899	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015900	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015901	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015902	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2015903	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015904	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015905	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015906	06/2011	05/03/2011	100.00	100.20	99.90	1
KU	C1S	2015907	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2015908	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015909	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015910	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015911	06/2011	05/03/2011	100.00	99.90	100.00	1
KU	C1S	2015912	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015913	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015914	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015915	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2015916	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015917	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015918	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015919	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015920	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015921	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015922	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015923	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015924	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015925	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015926	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015927	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015928	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015929	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015930	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015931	06/2011	05/03/2011	99.90	100.00	100.00	1
KU	C1S	2015932	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015933	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015934	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015935	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015936	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015937	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015938	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015939	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015940	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015941	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015942	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015943	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015944	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015945	06/2011	05/03/2011	100.00	100.20	100.00	1

KU	C1S	2015946	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015947	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015948	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015949	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015950	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015951	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015952	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015953	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015954	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015955	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2015956	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015957	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015958	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015959	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015960	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015961	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015962	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015963	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015964	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015965	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2015966	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015967	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2015968	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2015969	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015970	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015971	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2015972	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015973	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2015974	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015975	06/2011	05/03/2011	100.00	100.10	99.90	1

KU	C1S	2015976	06/2011	05/03/2011	100.00	100.10	99.80	1
KU	C1S	2015977	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015978	06/2011	05/03/2011	100.00	100.00	100.20	1
KU	C1S	2015979	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015980	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015981	06/2011	05/03/2011	100.00	100.10	99.80	1
KU	C1S	2015982	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2015983	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015984	06/2011	04/27/2011	100.00	99.90	99.90	1
KU	C1S	2015985	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2015986	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015987	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2015988	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015989	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2015990	06/2011	04/27/2011	99.90	100.10	100.10	1
KU	C1S	2015991	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015992	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2015993	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2015994	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2015995	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2015996	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2015997	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2015998	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2015999	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016000	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2016001	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2016002	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2016003	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016004	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016005	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2016006	06/2011	04/27/2011	100.00	100.00	100.10	1
KU	C1S	2016007	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016008	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2016009	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016010	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016011	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016012	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016013	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016014	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016015	06/2011	04/27/2011	100.00	100.20	100.00	1
KU	C1S	2016016	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016017	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016018	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016019	06/2011	04/27/2011	100.00	100.10	99.90	1
KU	C1S	2016020	06/2011	04/27/2011	100.00	100.00	99.80	1
KU	C1S	2016021	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016022	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016023	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016024	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016025	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016026	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016027	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016028	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016029	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016030	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016031	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2016032	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2016033	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016034	06/2011	04/27/2011	100.00	100.10	100.00	1
KU	C1S	2016035	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2016036	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2016037	06/2011	04/27/2011	100.00	99.90	99.80	1
KU	C1S	2016038	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016039	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016040	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016041	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016042	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016043	06/2011	04/27/2011	100.00	100.20	100.20	1
KU	C1S	2016044	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016045	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016046	06/2011	04/27/2011	99.90	100.00	99.90	1
KU	C1S	2016047	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016048	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016049	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2016050	06/2011	04/27/2011	100.00	100.20	100.10	1
KU	C1S	2016051	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016052	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016053	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016054	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016055	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016056	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016057	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016058	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016059	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2016060	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016061	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016062	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016063	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016064	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016065	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2016066	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016067	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016068	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016069	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016070	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016071	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016072	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016073	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2016074	06/2011	05/03/2011	99.90	100.00	99.80	1
KU	C1S	2016075	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016076	06/2011	05/03/2011	99.90	100.10	100.00	1
KU	C1S	2016077	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016078	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016079	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016080	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016081	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016082	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016083	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016084	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016085	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016086	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016087	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016088	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016089	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016090	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016091	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016092	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2016093	06/2011	04/27/2011	100.00	100.00	100.00	1
KU	C1S	2016094	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016095	06/2011	05/03/2011	100.00	100.10	100.10	1

KU	C1S	2016096	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016097	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016098	06/2011	04/27/2011	100.00	100.10	100.20	1
KU	C1S	2016099	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016100	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016101	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016102	06/2011	04/20/2011	100.00	100.10	100.10	1
KU	C1S	2016103	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016104	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016105	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016106	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016107	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016108	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016109	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016110	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016111	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016112	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016113	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016114	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016115	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2016116	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016117	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016118	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016119	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2016120	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016121	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016122	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016123	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016124	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016125	06/2011	05/02/2011	100.00	100.10	100.00	1

KU	C1S	2016126	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016127	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016128	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016129	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016130	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016131	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016132	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016133	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016134	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016135	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016136	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016137	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016138	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016139	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016140	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016141	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016142	06/2011	05/03/2011	100.00	100.00	100.20	1
KU	C1S	2016143	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2016144	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016145	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016146	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016147	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016148	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016149	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016150	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016151	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016152	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016153	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016154	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016155	06/2011	05/03/2011	100.00	100.20	100.10	1

KU	C1S	2016156	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016157	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016158	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016159	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016160	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016161	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016162	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016163	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016164	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016165	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016166	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016167	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016168	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016169	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016170	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016171	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016172	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016173	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016174	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016175	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016176	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016177	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016178	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016179	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016180	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016181	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016182	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2016183	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016184	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016185	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2016186	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016187	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016188	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016189	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016190	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016191	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016192	06/2011	05/03/2011	100.00	100.00	100.10	1
KU	C1S	2016193	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016194	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016195	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016196	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016197	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016198	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016199	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016200	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016201	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2016202	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2016203	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016204	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016205	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016206	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016207	06/2011	05/03/2011	99.90	100.00	99.80	1
KU	C1S	2016208	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016209	06/2011	05/03/2011	99.90	100.00	99.80	1
KU	C1S	2016210	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016211	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016212	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016213	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016214	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016215	06/2011	05/03/2011	100.00	100.00	99.90	1

KU	C1S	2016216	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016217	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016218	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016219	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016220	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016221	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016222	06/2011	05/03/2011	99.90	100.20	100.00	1
KU	C1S	2016223	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016224	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016225	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016226	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016227	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016228	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016229	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016230	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016231	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016232	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016233	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016234	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016235	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016236	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016237	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016238	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016239	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016240	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016241	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016242	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016243	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016244	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016245	06/2011	05/03/2011	100.00	100.20	100.00	1

KU	C1S	2016246	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016247	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016248	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016249	06/2011	05/03/2011	100.00	99.90	99.80	1
KU	C1S	2016250	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016251	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016252	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016253	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016254	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016255	06/2011	05/03/2011	100.00	99.90	100.00	1
KU	C1S	2016256	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016257	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016258	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016259	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016260	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016261	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016262	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016263	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016264	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016265	06/2011	05/03/2011	99.90	100.10	99.90	1
KU	C1S	2016266	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016267	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016268	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016269	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016270	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016271	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016272	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016273	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016274	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016275	06/2011	05/03/2011	100.00	100.20	100.10	1

KU	C1S	2016276	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016277	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016278	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016279	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016280	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016281	06/2011	05/03/2011	99.90	100.00	99.80	1
KU	C1S	2016282	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016283	06/2011	05/03/2011	100.00	100.10	99.80	1
KU	C1S	2016284	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016285	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016286	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016287	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016288	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016289	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016290	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016291	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016292	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016293	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016294	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016295	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016296	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016297	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016298	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016299	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016300	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016301	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016302	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016303	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016304	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016305	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2016306	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016307	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016308	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016309	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016310	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016311	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016312	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016313	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016314	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016315	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016316	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016317	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016318	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016319	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016320	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016321	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016322	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016323	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016324	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016325	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016326	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016327	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016328	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016329	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016330	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016331	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016332	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016333	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016334	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016335	06/2011	05/03/2011	100.00	100.10	100.00	1

KU	C1S	2016336	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016337	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016338	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016339	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016340	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016341	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016342	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016343	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016344	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016345	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016346	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016347	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016348	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016349	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016350	06/2011	05/03/2011	100.00	100.00	99.80	1
KU	C1S	2016351	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016352	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016353	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016354	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016355	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016356	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016357	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016358	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016359	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016360	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016361	06/2011	05/03/2011	100.00	100.00	100.00	1
KU	C1S	2016362	06/2011	05/03/2011	100.00	100.10	99.90	1
KU	C1S	2016363	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016364	06/2011	05/03/2011	100.00	100.20	100.10	1
KU	C1S	2016365	06/2011	05/03/2011	100.00	100.00	100.00	1

KU	C1S	2016366	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016367	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016368	06/2011	05/03/2011	100.00	99.90	99.90	1
KU	C1S	2016369	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016370	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016371	06/2011	05/03/2011	99.90	100.00	99.90	1
KU	C1S	2016372	06/2011	04/27/2011	100.00	100.10	100.10	1
KU	C1S	2016373	06/2011	04/27/2011	100.00	100.00	99.90	1
KU	C1S	2016374	06/2011	05/03/2011	100.00	100.00	99.90	1
KU	C1S	2016375	06/2011	05/03/2011	100.00	99.90	100.00	1
KU	C1S	2016376	06/2011	05/03/2011	100.00	100.10	100.10	1
KU	C1S	2016377	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016378	06/2011	05/03/2011	100.00	100.10	100.00	1
KU	C1S	2016379	06/2011	05/03/2011	100.00	100.20	100.00	1
KU	C1S	2016680	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2016681	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016682	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016683	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2016684	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016685	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016686	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2016687	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016688	09/2011	08/04/2011	100.00	100.00	100.10	1
KU	C1S	2016689	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016690	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016691	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016692	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016693	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016694	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016695	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2016696	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016697	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016698	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016699	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2016700	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016701	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016702	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016703	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016704	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016705	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016706	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016707	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016708	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016709	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016710	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016711	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016712	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016713	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016714	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016715	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016716	09/2011	08/05/2011	100.00	99.90	100.00	1
KU	C1S	2016717	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016718	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016719	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016720	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2016721	09/2011	08/05/2011	100.00	99.90	99.80	1
KU	C1S	2016722	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2016723	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016724	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016725	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2016726	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016727	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016728	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016729	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016730	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016731	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016732	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2016733	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016734	09/2011	08/05/2011	99.90	100.10	100.00	1
KU	C1S	2016735	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2016736	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016737	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016738	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016739	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016740	09/2011	08/01/2011	100.00	100.20	99.90	1
KU	C1S	2016741	09/2011	07/25/2011	100.00	100.10	100.00	1
KU	C1S	2016742	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016743	09/2011	07/25/2011	100.00	100.10	99.90	1
KU	C1S	2016744	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016745	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2016746	09/2011	08/01/2011	100.00	100.10	99.90	1
KU	C1S	2016747	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016748	09/2011	07/25/2011	100.00	100.00	100.10	1
KU	C1S	2016749	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016750	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016751	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016752	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016753	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016754	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016755	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2016756	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016757	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016758	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016759	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016760	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016761	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016762	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016763	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016764	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016765	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016766	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016767	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016768	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016769	09/2011	08/05/2011	99.90	99.90	99.80	1
KU	C1S	2016770	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016771	09/2011	08/05/2011	99.90	100.10	100.10	1
KU	C1S	2016772	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016773	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016774	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016775	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016776	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016777	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016778	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016779	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016780	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016781	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016782	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016783	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016784	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016785	09/2011	08/05/2011	100.00	100.10	99.90	1

KU	C1S	2016786	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016787	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016788	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016789	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016790	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016791	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016792	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016793	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016794	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016795	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016796	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016797	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016798	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016799	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016800	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016801	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016802	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016803	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016804	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016805	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016806	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016807	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016808	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016809	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016810	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016811	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016812	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016813	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016814	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016815	09/2011	08/05/2011	100.00	100.10	100.10	1

KU	C1S	2016816	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016817	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016818	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016819	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016820	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016821	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016822	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016823	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016824	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016825	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016826	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016827	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016828	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016829	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016830	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016831	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016832	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016833	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016834	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016835	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016836	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016837	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016838	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016839	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016840	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016841	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016842	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016843	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016844	09/2011	08/05/2011	100.00	100.10	99.80	1
KU	C1S	2016845	09/2011	08/05/2011	100.00	100.10	100.10	1

KU	C1S	2016846	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016847	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016848	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016849	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016850	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016851	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016852	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016853	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016854	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016855	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016856	09/2011	08/05/2011	99.90	100.10	100.10	1
KU	C1S	2016857	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016858	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016859	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016860	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016861	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016862	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016863	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016864	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016865	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016866	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2016867	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016868	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016869	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016870	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016871	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016872	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016873	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016874	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2016875	09/2011	08/05/2011	100.00	100.20	99.90	1

KU	C1S	2016876	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016877	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016878	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016879	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016880	09/2011	08/05/2011	99.90	100.10	100.00	1
KU	C1S	2016881	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016882	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016883	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016884	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016885	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016886	09/2011	08/05/2011	99.90	99.90	99.90	1
KU	C1S	2016887	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016888	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016889	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016890	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016891	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016892	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016893	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016894	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016895	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2016896	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016897	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016898	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016899	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2016900	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016901	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016902	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016903	09/2011	07/26/2011	100.00	100.20	100.00	1
KU	C1S	2016904	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2016905	09/2011	08/05/2011	100.00	100.10	100.00	1

KU	C1S	2016906	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016907	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016908	09/2011	07/26/2011	100.00	100.10	100.10	1
KU	C1S	2016909	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016910	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016911	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016912	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016913	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016914	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016915	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016916	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016917	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016918	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016919	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016920	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016921	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016922	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016923	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016924	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016925	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016926	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016927	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016928	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016929	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016930	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016931	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016932	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016933	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016934	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016935	09/2011	08/05/2011	100.00	100.00	99.80	1

KU	C1S	2016936	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016937	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016938	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016939	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016940	09/2011	08/05/2011	100.00	100.20	100.20	1
KU	C1S	2016941	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016942	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016943	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016944	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016945	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016946	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016947	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016948	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016949	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016950	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016951	09/2011	07/25/2011	100.00	100.10	99.90	1
KU	C1S	2016952	09/2011	07/25/2011	100.00	100.00	99.90	1
KU	C1S	2016953	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016954	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2016955	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016956	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016957	09/2011	07/26/2011	100.00	100.00	100.00	1
KU	C1S	2016958	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016959	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016960	09/2011	07/26/2011	100.00	100.20	99.90	1
KU	C1S	2016961	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016962	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2016963	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016964	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2016965	09/2011	08/05/2011	100.00	100.10	99.90	1

KU	C1S	2016966	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016967	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016968	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2016969	09/2011	08/01/2011	100.00	100.20	100.00	1
KU	C1S	2016970	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2016971	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016972	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016973	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016974	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016975	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016976	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016977	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016978	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016979	09/2011	08/05/2011	99.90	100.10	100.00	1
KU	C1S	2016980	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016981	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2016982	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016983	09/2011	08/01/2011	100.00	100.10	99.90	1
KU	C1S	2016984	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2016985	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2016986	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016987	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016988	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016989	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016990	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2016991	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2016992	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2016993	09/2011	08/01/2011	100.00	100.20	100.00	1
KU	C1S	2016994	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016995	09/2011	08/05/2011	100.00	100.10	100.00	1

KU	C1S	2016996	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2016997	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2016998	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2016999	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017000	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017001	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017002	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017003	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017004	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017005	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017006	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017007	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017008	09/2011	08/01/2011	100.00	100.20	100.00	1
KU	C1S	2017009	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017010	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017011	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017012	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017013	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017014	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017015	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017016	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017017	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017018	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017019	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017020	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017021	09/2011	08/01/2011	100.00	100.10	99.90	1
KU	C1S	2017022	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017023	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017024	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017025	09/2011	08/05/2011	100.00	99.90	99.80	1

KU	C1S	2017026	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017027	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017028	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017029	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017030	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017031	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017032	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017033	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017034	09/2011	08/05/2011	99.90	100.00	100.00	1
KU	C1S	2017035	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017036	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017037	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017038	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017039	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017040	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017041	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017042	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017043	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017044	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017045	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017046	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017047	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017048	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017049	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017050	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017051	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017052	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017053	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017054	09/2011	08/05/2011	99.90	99.90	99.90	1
KU	C1S	2017055	09/2011	08/05/2011	100.00	100.10	100.10	1

KU	C1S	2017056	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017057	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017058	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017059	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017060	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017061	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017062	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017063	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017064	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017065	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017066	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017067	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017068	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017069	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017070	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017071	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017072	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017073	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017074	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017075	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017076	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017077	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017078	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017079	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017080	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017081	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017082	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017083	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017084	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017085	09/2011	08/05/2011	100.00	99.90	99.90	1

KU	C1S	2017086	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017087	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017088	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017089	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017090	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017091	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017092	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017093	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017094	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017095	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017096	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017097	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017098	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017099	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017100	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017101	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017102	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017103	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017104	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017105	09/2011	08/05/2011	99.90	100.10	100.10	1
KU	C1S	2017106	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017107	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017108	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017109	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017110	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017111	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017112	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017113	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017114	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017115	09/2011	08/05/2011	100.00	100.20	100.00	1

KU	C1S	2017116	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017117	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017118	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017119	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017120	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017121	09/2011	08/05/2011	100.00	99.90	99.80	1
KU	C1S	2017122	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017123	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017124	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017125	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017126	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017127	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017128	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017129	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017130	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017131	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017132	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017133	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017134	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017135	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017136	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017137	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017138	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017139	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017140	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017141	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017142	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017143	09/2011	08/05/2011	100.00	99.90	99.80	1
KU	C1S	2017144	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017145	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2017146	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017147	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017148	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017149	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017150	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017151	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017152	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017153	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017154	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017155	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017156	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017157	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017158	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017159	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017160	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017161	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017162	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017163	09/2011	08/05/2011	99.90	99.90	99.90	1
KU	C1S	2017164	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017165	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017166	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017167	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017168	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017169	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017170	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017171	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017172	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017173	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017174	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017175	09/2011	08/05/2011	100.00	100.10	100.00	1

KU	C1S	2017176	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017177	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017178	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017179	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017180	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017181	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017182	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017183	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017184	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017185	09/2011	08/01/2011	100.00	100.20	100.00	1
KU	C1S	2017186	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017187	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017188	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017189	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017190	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017191	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017192	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017193	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017194	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017195	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017196	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017197	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017198	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017199	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017200	09/2011	08/01/2011	100.00	100.10	99.90	1
KU	C1S	2017201	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017202	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017203	09/2011	08/05/2011	100.00	100.20	99.80	1
KU	C1S	2017204	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017205	09/2011	08/05/2011	100.00	100.10	99.90	1

KU	C1S	2017206	09/2011	08/05/2011	99.90	100.00	100.00	1
KU	C1S	2017207	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017208	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017209	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017210	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017211	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017212	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017213	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017214	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017215	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017216	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017217	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017218	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017219	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017220	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017221	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017222	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017223	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017224	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017225	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017226	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017227	09/2011	08/05/2011	100.00	100.20	100.20	1
KU	C1S	2017228	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017229	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017230	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017231	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017232	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017233	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017234	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017235	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2017236	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017237	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017238	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017239	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017240	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017241	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017242	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017243	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017244	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017245	09/2011	08/01/2011	100.00	100.20	100.10	1
KU	C1S	2017246	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017247	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017248	09/2011	08/01/2011	99.90	100.10	100.00	1
KU	C1S	2017249	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017250	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017251	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017252	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017253	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017254	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017255	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017256	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017257	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017258	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017259	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017260	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017261	09/2011	08/05/2011	100.00	99.90	99.80	1
KU	C1S	2017262	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017263	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017264	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017265	09/2011	08/05/2011	100.00	99.90	99.90	1

KU	C1S	2017266	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017267	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017268	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017269	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017270	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017271	09/2011	08/05/2011	100.00	100.20	100.20	1
KU	C1S	2017272	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017273	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017274	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017275	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017276	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017277	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017278	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017279	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017280	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017281	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017282	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017283	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017284	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017285	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017286	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017287	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017288	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017289	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017290	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017291	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017292	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017293	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017294	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017295	09/2011	08/04/2011	100.00	100.00	99.90	1

KU	C1S	2017296	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017297	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017298	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017299	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017300	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017301	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017302	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017303	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017304	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017305	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017306	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017307	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017308	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017309	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017310	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017311	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017312	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017313	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017314	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017315	09/2011	08/01/2011	100.00	100.10	99.90	1
KU	C1S	2017316	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017317	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017318	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017319	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017320	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017321	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017322	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017323	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017324	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017325	09/2011	08/05/2011	100.00	100.00	99.80	1

KU	C1S	2017326	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017327	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017328	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017329	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017330	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017331	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017332	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017333	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017334	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017335	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017336	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017337	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017338	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017339	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017340	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017341	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017342	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017343	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017344	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017345	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017346	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017347	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017348	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017349	09/2011	08/05/2011	100.00	99.90	99.80	1
KU	C1S	2017350	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017351	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017352	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017353	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017354	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017355	09/2011	08/05/2011	100.00	100.00	99.90	1

KU	C1S	2017356	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017357	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017358	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017359	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017360	09/2011	08/05/2011	100.00	100.10	99.80	1
KU	C1S	2017361	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017362	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017363	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017364	09/2011	08/05/2011	100.00	100.20	100.10	1
KU	C1S	2017365	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017366	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017367	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017368	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017369	09/2011	08/05/2011	100.00	100.20	100.00	1
KU	C1S	2017370	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017371	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017372	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017373	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017374	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017375	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017376	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017377	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017378	09/2011	08/05/2011	100.00	99.90	99.90	1
KU	C1S	2017379	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017380	09/2011	08/05/2011	100.00	100.00	100.10	1
KU	C1S	2017381	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017382	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017383	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017384	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017385	09/2011	08/05/2011	100.00	100.10	100.10	1

KU	C1S	2017386	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017387	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017388	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017389	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017390	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017391	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017392	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017393	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017394	09/2011	08/05/2011	100.00	100.00	99.80	1
KU	C1S	2017395	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017396	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017397	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017398	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017399	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017400	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017401	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017402	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017403	09/2011	08/01/2011	100.00	100.00	100.10	1
KU	C1S	2017404	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017405	09/2011	08/01/2011	100.00	100.10	100.20	1
KU	C1S	2017406	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017407	09/2011	08/05/2011	99.90	100.10	100.00	1
KU	C1S	2017408	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017409	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017410	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017411	09/2011	08/05/2011	100.00	100.10	100.20	1
KU	C1S	2017412	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017413	09/2011	08/01/2011	100.00	99.90	99.80	1
KU	C1S	2017414	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017415	09/2011	08/01/2011	100.00	100.20	100.00	1

KU	C1S	2017416	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017417	09/2011	08/01/2011	100.00	100.20	100.10	1
KU	C1S	2017418	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017419	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017420	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017421	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017422	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017423	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017424	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017425	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017426	09/2011	08/05/2011	100.00	100.10	99.80	1
KU	C1S	2017427	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017428	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017429	09/2011	08/05/2011	99.90	100.00	99.90	1
KU	C1S	2017430	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017431	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017432	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017433	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017434	09/2011	08/05/2011	99.90	100.10	99.90	1
KU	C1S	2017435	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017436	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017437	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017438	09/2011	08/05/2011	99.90	100.00	100.00	1
KU	C1S	2017439	09/2011	08/05/2011	100.00	100.20	99.90	1
KU	C1S	2017440	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017441	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017442	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017443	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017444	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017445	09/2011	08/05/2011	100.00	100.10	100.00	1

KU	C1S	2017446	09/2011	08/05/2011	100.00	100.00	100.00	1
KU	C1S	2017447	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017448	09/2011	08/01/2011	100.00	100.00	99.90	1
KU	C1S	2017449	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017450	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017451	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017452	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017453	09/2011	08/01/2011	100.00	100.00	100.00	1
KU	C1S	2017454	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017455	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017456	09/2011	08/05/2011	100.00	100.00	99.90	1
KU	C1S	2017457	09/2011	08/05/2011	100.00	100.10	100.10	1
KU	C1S	2017458	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017459	09/2011	08/05/2011	100.00	100.10	99.90	1
KU	C1S	2017460	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017461	09/2011	08/05/2011	100.00	100.10	100.00	1
KU	C1S	2017462	09/2011	08/01/2011	100.00	100.10	100.10	1
KU	C1S	2017463	09/2011	08/01/2011	100.00	100.20	100.00	1
KU	C1S	2017464	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017465	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017466	09/2011	08/04/2011	99.90	100.00	100.00	1
KU	C1S	2017467	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017468	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017469	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017470	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017471	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017472	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017473	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017474	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017475	09/2011	08/04/2011	100.00	100.00	99.90	1

KU	C1S	2017476	09/2011	08/04/2011	100.00	100.10	99.80	1
KU	C1S	2017477	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017478	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017479	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017480	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017481	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017482	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017483	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017484	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017485	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017486	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017487	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017488	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017489	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017490	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017491	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017492	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017493	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017494	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017495	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017496	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017497	09/2011	08/04/2011	99.90	100.00	100.00	1
KU	C1S	2017498	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017499	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017500	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017501	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017502	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017503	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017504	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017505	09/2011	08/04/2011	100.00	100.10	100.00	1

KU	C1S	2017506	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017507	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017508	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017509	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017510	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017511	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017512	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017513	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017514	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017515	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017516	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017517	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017518	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017519	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017520	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017521	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017522	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017523	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017524	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017525	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017526	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017527	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017528	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017529	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017530	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017531	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017532	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017533	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017534	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017535	09/2011	08/04/2011	100.00	100.10	99.80	1

KU	C1S	2017536	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017537	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017538	09/2011	08/04/2011	100.00	100.00	100.10	1
KU	C1S	2017539	09/2011	08/04/2011	100.00	100.20	100.20	1
KU	C1S	2017540	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017541	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017542	09/2011	08/04/2011	100.00	100.10	99.80	1
KU	C1S	2017543	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017544	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017545	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017546	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017547	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017548	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017549	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017550	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017551	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017552	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017553	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017554	09/2011	08/04/2011	100.00	100.10	99.80	1
KU	C1S	2017555	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017556	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017557	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017558	09/2011	08/04/2011	99.90	100.10	99.90	1
KU	C1S	2017559	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017560	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017561	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017562	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017563	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017564	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017565	09/2011	08/04/2011	100.00	100.10	100.00	1

KU	C1S	2017566	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017567	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017568	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017569	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017570	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017571	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017572	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017573	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017574	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017575	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017576	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017577	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017578	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017579	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017580	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017581	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017582	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017583	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017584	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017585	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017586	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017587	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017588	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017589	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017590	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017591	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017592	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017593	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017594	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017595	09/2011	08/04/2011	100.00	100.00	100.10	1

KU	C1S	2017596	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017597	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017598	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017599	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017600	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017601	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017602	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017603	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017604	09/2011	08/04/2011	99.90	100.00	99.90	1
KU	C1S	2017605	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017606	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017607	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017608	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017609	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017610	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017611	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017612	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017613	09/2011	08/04/2011	100.00	100.00	100.10	1
KU	C1S	2017614	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017615	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017616	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017617	09/2011	06/29/2011	100.00	100.00	99.80	1
KU	C1S	2017618	09/2011	06/29/2011	100.00	100.10	100.10	1
KU	C1S	2017619	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017620	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017621	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017622	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017623	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017624	09/2011	08/04/2011	100.00	100.00	100.20	1
KU	C1S	2017625	09/2011	08/04/2011	100.00	100.00	99.90	1

KU	C1S	2017626	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017627	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017628	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017629	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017630	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017631	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017632	09/2011	08/04/2011	100.00	100.00	100.10	1
KU	C1S	2017633	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017634	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017635	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017636	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017637	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017638	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017639	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017640	09/2011	08/04/2011	99.90	100.00	99.80	1
KU	C1S	2017641	09/2011	08/04/2011	99.90	100.10	99.90	1
KU	C1S	2017642	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017643	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017644	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017645	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017646	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017647	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017648	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017649	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017650	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017651	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017652	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017653	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017654	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017655	09/2011	08/04/2011	100.00	100.10	100.00	1

KU	C1S	2017656	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017657	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017658	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017659	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017660	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017661	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017662	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017663	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017664	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017665	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017666	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017667	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017668	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017669	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017670	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017671	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017672	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017673	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017674	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017675	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017676	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017677	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017678	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017679	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017680	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017681	09/2011	08/04/2011	99.90	100.20	99.90	1
KU	C1S	2017682	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017683	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017684	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017685	09/2011	08/04/2011	100.00	100.10	100.00	1

KU	C1S	2017686	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017687	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017688	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017689	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017690	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017691	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017692	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017693	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017694	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017695	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017696	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017697	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017698	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017699	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017700	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017701	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017702	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017703	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017704	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017705	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017706	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017707	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017708	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017709	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017710	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017711	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017712	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017713	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017714	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017715	09/2011	08/04/2011	100.00	100.00	100.00	1

KU	C1S	2017716	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017717	09/2011	06/23/2011	100.00	99.90	99.90	1
KU	C1S	2017718	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017719	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017720	09/2011	06/29/2011	100.00	100.10	100.10	1
KU	C1S	2017721	09/2011	06/29/2011	99.90	100.00	100.00	1
KU	C1S	2017722	09/2011	06/29/2011	100.00	100.20	100.10	1
KU	C1S	2017723	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017724	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017725	09/2011	06/23/2011	100.00	100.20	100.00	1
KU	C1S	2017726	09/2011	06/29/2011	100.00	99.90	99.80	1
KU	C1S	2017727	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017728	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017729	09/2011	06/23/2011	100.00	100.10	99.90	1
KU	C1S	2017730	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017731	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017732	09/2011	06/23/2011	100.00	100.00	100.00	1
KU	C1S	2017733	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017734	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017735	09/2011	06/23/2011	100.00	100.00	100.10	1
KU	C1S	2017736	09/2011	06/29/2011	100.00	100.10	100.10	1
KU	C1S	2017737	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017738	09/2011	06/29/2011	99.90	100.00	99.80	1
KU	C1S	2017739	09/2011	06/29/2011	100.00	99.90	99.90	1
KU	C1S	2017740	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017741	09/2011	06/23/2011	100.00	99.90	99.90	1
KU	C1S	2017742	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017743	09/2011	06/29/2011	99.90	100.10	99.90	1
KU	C1S	2017744	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017745	09/2011	06/29/2011	100.00	100.20	100.00	1

KU	C1S	2017746	09/2011	06/29/2011	100.00	99.90	100.00	1
KU	C1S	2017747	09/2011	06/29/2011	100.00	100.10	99.90	1
KU	C1S	2017748	09/2011	06/29/2011	100.00	99.90	99.90	1
KU	C1S	2017749	09/2011	06/29/2011	100.00	100.20	100.10	1
KU	C1S	2017750	09/2011	06/29/2011	100.00	100.00	99.80	1
KU	C1S	2017751	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017752	09/2011	06/29/2011	100.00	99.90	99.90	1
KU	C1S	2017753	09/2011	06/29/2011	100.00	100.00	100.10	1
KU	C1S	2017754	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017755	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017756	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017757	09/2011	06/29/2011	99.90	100.00	99.90	1
KU	C1S	2017758	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017759	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017760	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017761	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017762	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017763	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017764	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017765	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017766	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017767	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017768	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017769	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017770	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017771	09/2011	06/23/2011	100.00	100.20	100.10	1
KU	C1S	2017772	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017773	09/2011	06/23/2011	100.00	100.20	100.00	1
KU	C1S	2017774	09/2011	06/29/2011	100.00	99.90	99.90	1
KU	C1S	2017775	09/2011	06/23/2011	100.00	100.10	100.00	1

KU	C1S	2017776	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017777	09/2011	08/04/2011	100.00	100.10	100.20	1
KU	C1S	2017778	09/2011	06/29/2011	100.00	100.00	99.80	1
KU	C1S	2017779	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017780	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017781	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017782	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017783	09/2011	08/04/2011	99.90	100.00	100.00	1
KU	C1S	2017784	09/2011	06/29/2011	100.00	99.90	99.80	1
KU	C1S	2017785	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017786	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017787	09/2011	06/23/2011	99.90	100.20	100.00	1
KU	C1S	2017788	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017789	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017790	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017791	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017792	09/2011	06/23/2011	100.00	100.20	100.00	1
KU	C1S	2017793	09/2011	06/23/2011	100.00	100.20	100.10	1
KU	C1S	2017794	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017795	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017796	09/2011	06/23/2011	100.00	100.00	99.80	1
KU	C1S	2017797	09/2011	06/29/2011	100.00	100.20	100.00	1
KU	C1S	2017798	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017799	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017800	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017801	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017802	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017803	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017804	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017805	09/2011	06/23/2011	100.00	100.10	100.00	1

KU	C1S	2017806	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017807	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017808	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017809	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017810	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017811	09/2011	06/23/2011	100.00	100.10	99.90	1
KU	C1S	2017812	09/2011	06/23/2011	100.00	100.20	100.00	1
KU	C1S	2017813	09/2011	08/04/2011	100.00	100.20	99.80	1
KU	C1S	2017814	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017815	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017816	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017817	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017818	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017819	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017820	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017821	09/2011	06/23/2011	100.00	100.10	100.00	1
KU	C1S	2017822	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017823	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017824	09/2011	06/23/2011	100.00	100.00	100.00	1
KU	C1S	2017825	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017826	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017827	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017828	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017829	09/2011	06/23/2011	100.00	100.20	100.20	1
KU	C1S	2017830	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017831	09/2011	06/29/2011	100.00	99.90	99.90	1
KU	C1S	2017832	09/2011	06/29/2011	100.00	100.20	100.00	1
KU	C1S	2017833	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017834	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017835	09/2011	06/29/2011	100.00	100.00	99.90	1

KU	C1S	2017836	09/2011	06/29/2011	100.00	100.00	100.00	1
KU	C1S	2017837	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017838	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017839	09/2011	06/29/2011	100.00	100.20	100.10	1
KU	C1S	2017840	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017841	09/2011	06/23/2011	99.90	100.20	99.90	1
KU	C1S	2017842	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017843	09/2011	06/23/2011	100.00	100.00	99.80	1
KU	C1S	2017844	09/2011	06/29/2011	100.00	100.00	99.90	1
KU	C1S	2017845	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017846	09/2011	08/01/2011	100.00	100.10	100.00	1
KU	C1S	2017847	09/2011	06/29/2011	100.00	100.10	99.90	1
KU	C1S	2017848	09/2011	06/29/2011	100.00	100.20	100.00	1
KU	C1S	2017849	09/2011	06/23/2011	100.00	100.00	100.10	1
KU	C1S	2017850	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017851	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017852	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017853	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017854	09/2011	06/29/2011	100.00	100.10	100.00	1
KU	C1S	2017855	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017856	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017857	09/2011	06/23/2011	100.00	100.10	100.10	1
KU	C1S	2017858	09/2011	06/23/2011	100.00	100.00	99.90	1
KU	C1S	2017859	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017860	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017861	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017862	09/2011	08/04/2011	100.00	100.10	100.20	1
KU	C1S	2017863	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017864	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017865	09/2011	08/04/2011	100.00	100.00	100.00	1

KU	C1S	2017866	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017867	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017868	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017869	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017870	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017871	09/2011	08/04/2011	100.00	100.10	100.20	1
KU	C1S	2017872	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017873	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017874	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017875	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017876	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017877	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017878	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017879	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017880	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017881	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017882	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017883	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017884	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017885	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017886	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017887	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017888	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017889	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017890	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017891	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017892	09/2011	08/04/2011	99.90	99.90	99.90	1
KU	C1S	2017893	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017894	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017895	09/2011	08/04/2011	100.00	100.10	100.00	1

KU	C1S	2017896	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017897	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017898	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017899	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017900	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017901	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017902	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017903	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017904	09/2011	08/04/2011	100.00	100.00	100.10	1
KU	C1S	2017905	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017906	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017907	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017908	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017909	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017910	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017911	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017912	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017913	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017914	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017915	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017916	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017917	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017918	09/2011	08/04/2011	100.00	100.10	100.20	1
KU	C1S	2017919	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017920	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017921	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017922	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017923	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017924	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017925	09/2011	08/04/2011	100.00	100.10	100.10	1

KU	C1S	2017926	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017927	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017928	09/2011	08/04/2011	100.00	99.90	99.80	1
KU	C1S	2017929	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017930	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017931	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017932	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017933	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017934	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017935	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017936	09/2011	08/04/2011	99.90	99.90	99.90	1
KU	C1S	2017937	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017938	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017939	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017940	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017941	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017942	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017943	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017944	09/2011	08/04/2011	100.00	99.90	99.90	1
KU	C1S	2017945	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017946	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017947	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017948	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017949	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017950	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017951	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017952	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017953	09/2011	08/04/2011	100.00	100.20	100.00	1
KU	C1S	2017954	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017955	09/2011	08/04/2011	100.00	100.10	99.80	1

KU	C1S	2017956	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017957	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017958	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017959	09/2011	08/04/2011	100.00	100.10	100.20	1
KU	C1S	2017960	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017961	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017962	09/2011	08/04/2011	100.00	99.90	100.00	1
KU	C1S	2017963	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017964	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017965	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017966	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017967	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017968	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017969	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017970	09/2011	08/04/2011	99.90	100.00	99.90	1
KU	C1S	2017971	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017972	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017973	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017974	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017975	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017976	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017977	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017978	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017979	09/2011	08/04/2011	100.00	100.20	100.10	1
KU	C1S	2017980	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017981	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017982	09/2011	08/04/2011	100.00	100.00	99.80	1
KU	C1S	2017983	09/2011	08/04/2011	100.00	100.10	100.10	1
KU	C1S	2017984	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017985	09/2011	08/04/2011	100.00	100.00	99.90	1

KU	C1S	2017986	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017987	09/2011	08/04/2011	99.90	99.90	99.80	1
KU	C1S	2017988	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017989	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017990	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2017991	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017992	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017993	09/2011	08/04/2011	100.00	100.20	99.90	1
KU	C1S	2017994	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017995	09/2011	08/04/2011	100.00	100.00	99.90	1
KU	C1S	2017996	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017997	09/2011	08/04/2011	100.00	100.10	100.00	1
KU	C1S	2017998	09/2011	08/04/2011	100.00	100.10	99.90	1
KU	C1S	2017999	09/2011	08/04/2011	100.00	100.00	100.00	1
KU	C1S	2018000	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018001	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018002	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018003	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018004	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018005	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018006	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018007	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018008	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018009	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018010	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018011	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018012	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018013	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018014	10/2011	09/23/2011	100.00	100.10	100.00	1
KU	C1S	2018015	10/2011	09/23/2011	100.00	100.20	100.10	1

KU	C1S	2018016	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018017	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018018	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018019	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018020	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018021	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018022	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018023	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018024	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018025	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018026	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018027	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018028	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018029	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018030	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018031	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018032	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018033	10/2011	09/23/2011	100.00	100.10	100.00	1
KU	C1S	2018034	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018035	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018036	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018037	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018038	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018039	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018040	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018041	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018042	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018043	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018044	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018045	10/2011	09/23/2011	100.00	100.20	100.10	1

KU	C1S	2018046	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018047	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018048	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018049	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018050	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018051	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018052	10/2011	09/23/2011	100.00	100.10	100.00	1
KU	C1S	2018053	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018054	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018055	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018056	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018057	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018058	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018059	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018060	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018061	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018062	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018063	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018064	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018065	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018066	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018067	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018068	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018069	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018070	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018071	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018072	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018073	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018074	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018075	10/2011	09/23/2011	100.00	100.20	100.10	1

KU	C1S	2018076	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018077	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018078	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018079	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018080	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018081	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018082	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018083	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018084	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018085	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018086	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018087	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018088	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018089	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018090	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018091	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018092	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018093	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018094	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018095	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018096	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018097	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018098	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018099	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018100	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018101	10/2011	09/23/2011	100.00	100.10	100.00	1
KU	C1S	2018102	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018103	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018104	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018105	10/2011	09/23/2011	100.00	100.10	100.10	1

KU	C1S	2018106	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018107	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018108	10/2011	09/23/2011	100.00	100.10	100.10	1
KU	C1S	2018109	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018110	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018111	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018112	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018113	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018114	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018115	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018116	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018117	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018118	10/2011	09/23/2011	100.00	100.20	100.00	1
KU	C1S	2018119	10/2011	09/23/2011	100.00	100.20	100.10	1
KU	C1S	2018360	11/2011	11/11/2011	100.00	99.90	99.90	1
KU	C1S	2018361	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018362	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018363	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018364	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018365	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018366	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018367	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018368	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018369	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018370	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018371	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018372	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018373	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018374	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2018375	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018376	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018377	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018378	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018379	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018380	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018381	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018382	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018383	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018384	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018385	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018386	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018387	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018388	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018389	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018390	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2018391	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018392	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018393	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018394	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018395	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018396	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018397	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018398	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018399	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018400	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018401	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018402	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018403	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018404	11/2011	11/11/2011	100.00	100.00	100.20	1
KU	C1S	2018405	11/2011	11/11/2011	100.00	100.10	100.00	1

KU	C1S	2018406	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018407	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018408	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018409	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018410	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018411	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018412	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018413	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018414	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018415	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018416	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018417	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018418	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018419	11/2011	11/11/2011	100.00	100.20	100.20	1
KU	C1S	2018420	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018421	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018422	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018423	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018424	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018425	11/2011	11/11/2011	100.00	100.00	100.10	1
KU	C1S	2018426	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018427	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018428	11/2011	11/11/2011	100.00	100.20	100.10	1
KU	C1S	2018429	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018430	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018431	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018432	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018433	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018434	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018435	11/2011	11/11/2011	100.00	100.10	99.90	1

KU	C1S	2018436	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018437	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018438	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018439	11/2011	11/13/2011	100.00	100.10	100.10	1
KU	C1S	2018440	11/2011	11/13/2011	100.00	100.10	99.90	1
KU	C1S	2018441	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018442	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018443	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018444	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018445	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018446	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018447	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018448	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018449	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018450	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018451	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018452	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018453	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018454	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018455	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018456	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018457	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018458	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018459	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018460	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018461	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018462	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018463	11/2011	11/11/2011	100.00	100.20	99.90	1
KU	C1S	2018464	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018465	11/2011	11/15/2011	100.00	99.90	99.80	1

KU	C1S	2018466	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018467	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018468	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018469	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018470	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018471	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018472	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018473	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018474	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018475	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018476	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018477	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018478	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018479	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018480	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018481	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018482	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018483	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018484	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018485	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018486	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018487	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018488	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018489	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018490	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018491	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018492	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018493	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018494	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018495	11/2011	11/11/2011	100.00	100.10	100.00	1

KU	C1S	2018496	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018497	11/2011	11/11/2011	100.00	99.90	99.80	1
KU	C1S	2018498	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018499	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018500	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018501	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018502	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018503	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018504	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018505	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018506	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018507	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018508	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018509	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018510	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018511	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018512	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018513	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018514	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018515	11/2011	11/11/2011	100.00	100.10	99.80	1
KU	C1S	2018516	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018517	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018518	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2018519	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2018520	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018521	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018522	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018523	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018524	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018525	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018526	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018527	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018528	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018529	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2018530	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018531	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018532	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018533	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018534	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018535	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2018536	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018537	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018538	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018539	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018540	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018541	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018542	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018543	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018544	11/2011	11/13/2011	100.00	100.20	100.20	1
KU	C1S	2018545	11/2011	11/11/2011	99.90	100.10	100.00	1
KU	C1S	2018546	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018547	11/2011	11/15/2011	99.90	100.00	100.10	1
KU	C1S	2018548	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018549	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018550	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018551	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018552	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018553	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018554	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018555	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018556	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018557	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018558	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018559	11/2011	11/14/2011	100.00	100.20	100.10	1
KU	C1S	2018560	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018561	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018562	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018563	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018564	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018565	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018566	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018567	11/2011	11/11/2011	100.00	100.20	100.10	1
KU	C1S	2018568	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018569	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018570	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018571	11/2011	11/11/2011	100.00	100.00	100.10	1
KU	C1S	2018572	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018573	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018574	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018575	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018576	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018577	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018578	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018579	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2018580	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018581	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018582	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018583	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018584	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018585	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018586	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018587	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018588	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018589	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2018590	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018591	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018592	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018593	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018594	11/2011	11/11/2011	100.00	100.10	100.20	1
KU	C1S	2018595	11/2011	11/11/2011	100.00	100.20	100.20	1
KU	C1S	2018596	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018597	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018598	11/2011	11/11/2011	100.00	99.90	99.90	1
KU	C1S	2018599	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018600	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018601	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018602	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2018603	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018604	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018605	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018606	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018607	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018608	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018609	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018610	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018611	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018612	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018613	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018614	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018615	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2018616	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018617	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018618	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018619	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018620	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018621	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018622	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018623	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2018624	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018625	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018626	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018627	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018628	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018629	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018630	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018631	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018632	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018633	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018634	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018635	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018636	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018637	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018638	11/2011	11/11/2011	100.00	100.20	99.90	1
KU	C1S	2018639	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018640	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018641	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018642	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018643	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018644	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018645	11/2011	11/11/2011	100.00	100.10	100.00	1

KU	C1S	2018646	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018647	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018648	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018649	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2018650	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018651	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018652	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018653	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2018654	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018655	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018656	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018657	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018658	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018659	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018660	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2018661	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018662	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018663	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018664	11/2011	11/11/2011	100.00	100.10	100.20	1
KU	C1S	2018665	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018666	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2018667	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018668	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018669	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018670	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018671	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018672	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018673	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018674	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018675	11/2011	11/14/2011	100.00	100.10	99.80	1

KU	C1S	2018676	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018677	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018678	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018679	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018680	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018681	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018682	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018683	11/2011	11/11/2011	100.00	99.90	99.90	1
KU	C1S	2018684	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018685	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018686	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2018687	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018688	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018689	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018690	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018691	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018692	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018693	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018694	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018695	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018696	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018697	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018698	11/2011	11/11/2011	100.00	100.20	100.10	1
KU	C1S	2018699	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018700	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2018701	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2018702	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018703	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018704	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018705	11/2011	11/11/2011	99.90	100.10	100.00	1

KU	C1S	2018706	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018707	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018708	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018709	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018710	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2018711	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018712	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018713	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2018714	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018715	11/2011	11/11/2011	100.00	100.10	100.20	1
KU	C1S	2018716	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018717	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018718	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018719	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018720	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018721	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018722	11/2011	11/14/2011	99.90	99.90	99.90	1
KU	C1S	2018723	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018724	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018725	11/2011	11/14/2011	99.90	100.10	99.90	1
KU	C1S	2018726	11/2011	11/15/2011	100.00	100.20	99.80	1
KU	C1S	2018727	11/2011	11/14/2011	100.00	100.20	100.00	1
KU	C1S	2018728	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2018729	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018730	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018731	11/2011	11/13/2011	100.00	100.00	100.10	1
KU	C1S	2018732	11/2011	11/14/2011	100.00	100.00	100.10	1
KU	C1S	2018733	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2018734	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2018735	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018736	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018737	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018738	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018739	11/2011	11/13/2011	100.00	100.00	99.90	1
KU	C1S	2018740	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018741	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018742	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018743	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018744	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018745	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018746	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018747	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018748	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018749	11/2011	11/13/2011	100.00	100.10	100.00	1
KU	C1S	2018750	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018751	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018752	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018753	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018754	11/2011	11/11/2011	99.90	100.00	99.90	1
KU	C1S	2018755	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018756	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018757	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018758	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018759	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018760	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018761	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018762	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2018763	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018764	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018765	11/2011	11/11/2011	100.00	100.10	100.10	1

KU	C1S	2018766	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018767	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018768	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018769	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018770	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018771	11/2011	11/15/2011	99.90	100.10	100.10	1
KU	C1S	2018772	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018773	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018774	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018775	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018776	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018777	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018778	11/2011	11/11/2011	100.00	100.20	100.20	1
KU	C1S	2018779	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018780	11/2011	11/15/2011	99.90	99.90	99.90	1
KU	C1S	2018781	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018782	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018783	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018784	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018785	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018786	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2018787	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018788	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018789	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018790	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018791	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018792	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018793	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018794	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2018795	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2018796	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018797	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018798	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018799	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018800	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2018801	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2018802	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018803	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018804	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018805	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018806	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018807	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018808	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018809	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018810	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018811	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018812	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2018813	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018814	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018815	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018816	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018817	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018818	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018819	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018820	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018821	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018822	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018823	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018824	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018825	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018826	11/2011	11/13/2011	100.00	100.00	99.90	1
KU	C1S	2018827	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018828	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018829	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018830	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018831	11/2011	11/13/2011	100.00	100.20	100.00	1
KU	C1S	2018832	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018833	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018834	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018835	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018836	11/2011	11/13/2011	100.00	100.10	100.00	1
KU	C1S	2018837	11/2011	11/13/2011	100.00	100.10	100.00	1
KU	C1S	2018838	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018839	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018840	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018841	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018842	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018843	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2018844	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018845	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018846	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018847	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018848	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018849	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018850	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018851	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018852	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018853	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018854	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018855	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2018856	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2018857	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018858	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2018859	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018860	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018861	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018862	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018863	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018864	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018865	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018866	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018867	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018868	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018869	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018870	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018871	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018872	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2018873	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018874	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018875	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018876	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018877	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018878	11/2011	11/14/2011	100.00	100.00	100.20	1
KU	C1S	2018879	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018880	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018881	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018882	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018883	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018884	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018885	11/2011	11/15/2011	100.00	100.10	100.20	1

KU	C1S	2018886	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018887	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018888	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018889	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2018890	11/2011	11/14/2011	100.00	100.00	100.10	1
KU	C1S	2018891	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018892	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2018893	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018894	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018895	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018896	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018897	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018898	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2018899	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018900	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018901	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2018902	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018903	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2018904	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018905	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018906	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018907	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018908	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018909	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018910	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018911	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018912	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018913	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018914	11/2011	11/15/2011	100.00	99.90	100.00	1
KU	C1S	2018915	11/2011	11/15/2011	100.00	100.20	100.00	1

KU	C1S	2018916	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018917	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2018918	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018919	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018920	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018921	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018922	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018923	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018924	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2018925	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018926	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018927	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018928	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018929	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018930	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018931	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018932	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018933	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018934	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018935	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018936	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018937	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018938	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018939	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018940	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018941	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018942	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018943	11/2011	11/11/2011	99.90	100.10	99.90	1
KU	C1S	2018944	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018945	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2018946	11/2011	11/15/2011	99.90	100.20	99.90	1
KU	C1S	2018947	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018948	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2018949	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2018950	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018951	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2018952	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018953	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018954	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018955	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018956	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018957	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018958	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018959	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018960	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018961	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2018962	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018963	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018964	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018965	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2018966	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018967	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018968	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018969	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018970	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018971	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018972	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018973	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018974	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018975	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2018976	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018977	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018978	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018979	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018980	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018981	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2018982	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018983	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018984	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2018985	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018986	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018987	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2018988	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018989	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2018990	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018991	11/2011	11/15/2011	100.00	99.90	100.10	1
KU	C1S	2018992	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018993	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2018994	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2018995	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018996	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2018997	11/2011	11/15/2011	99.90	99.90	99.90	1
KU	C1S	2018998	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2018999	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019000	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019001	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019002	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019003	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019004	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019005	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019006	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019007	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019008	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019009	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019010	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019011	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019012	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019013	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019014	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019015	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019016	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019017	11/2011	11/15/2011	100.00	100.20	99.80	1
KU	C1S	2019018	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019019	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019020	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019021	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019022	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019023	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019024	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019025	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019026	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019027	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019028	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019029	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019030	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019031	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019032	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019033	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019034	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019035	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019036	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019037	11/2011	11/11/2011	100.00	100.10	100.20	1
KU	C1S	2019038	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019039	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019040	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019041	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019042	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019043	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019044	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019045	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019046	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019047	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019048	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2019049	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019050	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019051	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019052	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2019053	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019054	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019055	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019056	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019057	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019058	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019059	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019060	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019061	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019062	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019063	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019064	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019065	11/2011	11/11/2011	100.00	99.90	99.90	1

KU	C1S	2019066	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019067	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019068	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019069	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019070	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019071	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019072	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2019073	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019074	11/2011	11/13/2011	100.00	100.10	100.00	1
KU	C1S	2019075	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019076	11/2011	11/13/2011	100.00	100.00	99.90	1
KU	C1S	2019077	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2019078	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019079	11/2011	11/11/2011	100.00	99.90	100.00	1
KU	C1S	2019080	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019081	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2019082	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019083	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019084	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019085	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019086	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019087	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019088	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019089	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019090	11/2011	11/11/2011	100.00	100.10	99.80	1
KU	C1S	2019091	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2019092	11/2011	11/11/2011	100.00	100.20	99.90	1
KU	C1S	2019093	11/2011	11/11/2011	100.00	100.20	99.90	1
KU	C1S	2019094	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019095	11/2011	11/11/2011	100.00	100.10	100.20	1

KU	C1S	2019096	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019097	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019098	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019099	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019100	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2019101	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019102	11/2011	11/11/2011	100.00	99.90	99.80	1
KU	C1S	2019103	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019104	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019105	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019106	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2019107	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019108	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2019109	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019110	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019111	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019112	11/2011	11/11/2011	100.00	100.00	100.10	1
KU	C1S	2019113	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019114	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019115	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019116	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019117	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019118	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019119	11/2011	11/11/2011	100.00	100.00	100.20	1
KU	C1S	2019120	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019121	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019122	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019123	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019124	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019125	11/2011	11/15/2011	100.00	100.20	100.00	1

KU	C1S	2019126	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019127	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019128	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019129	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019130	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019131	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019132	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019133	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019134	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019135	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019136	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019137	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019138	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019139	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019140	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019141	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019142	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019143	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019144	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019145	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019146	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019147	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019148	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019149	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019150	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019151	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2019152	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019153	11/2011	11/11/2011	100.00	100.00	100.10	1
KU	C1S	2019154	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019155	11/2011	11/15/2011	100.00	100.10	100.10	1

KU	C1S	2019156	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019157	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019158	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019159	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019160	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2019161	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019162	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2019163	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2019164	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019165	11/2011	11/11/2011	100.00	100.20	100.00	1
KU	C1S	2019166	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019167	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019168	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019169	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019170	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019171	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019172	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019173	11/2011	11/11/2011	100.00	100.10	99.90	1
KU	C1S	2019174	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019175	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019176	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019177	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019178	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019179	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019180	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019181	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019182	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019183	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2019184	11/2011	11/11/2011	100.00	100.20	100.10	1
KU	C1S	2019185	11/2011	11/14/2011	100.00	100.20	100.00	1

KU	C1S	2019186	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019187	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019188	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019189	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2019190	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019191	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019192	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019193	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019194	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019195	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019196	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019197	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019198	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019199	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019200	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019201	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019202	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019203	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019204	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019205	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019206	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019207	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019208	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019209	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019210	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019211	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019212	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019213	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019214	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019215	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2019216	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019217	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019218	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019219	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019220	11/2011	11/15/2011	99.90	100.20	100.00	1
KU	C1S	2019221	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019222	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019223	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019224	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019225	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019226	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019227	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019228	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019229	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019230	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019231	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019232	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019233	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019234	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019235	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019236	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019237	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019238	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019239	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019240	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019241	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019242	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019243	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019244	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2019245	11/2011	11/11/2011	100.00	100.10	100.00	1

KU	C1S	2019246	11/2011	11/11/2011	100.00	100.20	100.10	1
KU	C1S	2019247	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019248	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019249	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019250	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019251	11/2011	11/14/2011	100.00	100.00	99.80	1
KU	C1S	2019252	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019253	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019254	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019255	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019256	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2019257	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019258	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019259	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019260	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019261	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019262	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019263	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019264	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019265	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019266	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019267	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2019268	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019269	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019270	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019271	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019272	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019273	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019274	11/2011	11/11/2011	100.00	100.00	99.80	1
KU	C1S	2019275	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2019276	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019277	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019278	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019279	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2019280	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019281	11/2011	11/14/2011	100.00	100.00	99.80	1
KU	C1S	2019282	11/2011	11/14/2011	100.00	100.10	100.30	1
KU	C1S	2019283	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019284	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019285	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019286	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019287	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019288	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019289	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019290	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019291	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019292	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019293	11/2011	11/15/2011	99.90	100.00	99.80	1
KU	C1S	2019294	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019295	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2019296	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019297	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019298	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019299	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019300	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2019301	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019302	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019303	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2019304	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019305	11/2011	11/11/2011	100.00	100.00	99.90	1

KU	C1S	2019306	11/2011	11/11/2011	100.00	100.10	100.10	1
KU	C1S	2019307	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019308	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019309	11/2011	11/11/2011	100.00	100.00	99.90	1
KU	C1S	2019310	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019311	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019312	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019313	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019314	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019315	11/2011	11/11/2011	100.00	100.10	100.00	1
KU	C1S	2019316	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019317	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019318	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019319	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019320	11/2011	11/10/2011	100.00	100.00	99.80	1
KU	C1S	2019321	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019322	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019323	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019324	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019325	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019326	11/2011	11/10/2011	100.00	100.10	99.80	1
KU	C1S	2019327	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019328	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019329	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019330	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019331	11/2011	11/10/2011	100.00	100.20	100.00	1
KU	C1S	2019332	11/2011	11/10/2011	100.00	100.20	100.10	1
KU	C1S	2019333	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019334	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019335	11/2011	11/15/2011	100.00	100.20	99.90	1

KU	C1S	2019336	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019337	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019338	11/2011	11/10/2011	100.00	100.20	99.80	1
KU	C1S	2019339	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019340	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019341	11/2011	11/10/2011	100.00	99.90	99.90	1
KU	C1S	2019342	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019343	11/2011	11/10/2011	100.00	100.10	99.80	1
KU	C1S	2019344	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019345	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019346	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019347	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019348	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019349	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019350	11/2011	11/10/2011	100.00	99.90	99.90	1
KU	C1S	2019351	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019352	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019353	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019354	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019355	11/2011	11/10/2011	100.00	99.90	99.90	1
KU	C1S	2019356	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019357	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019358	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019359	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019360	11/2011	11/10/2011	99.90	100.10	100.00	1
KU	C1S	2019361	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019362	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019363	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019364	11/2011	11/10/2011	99.90	100.00	99.90	1
KU	C1S	2019365	11/2011	11/15/2011	100.00	100.10	100.30	1

KU	C1S	2019366	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019367	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019368	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019369	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019370	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019371	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019372	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019373	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019374	11/2011	11/10/2011	100.00	100.10	99.90	1
KU	C1S	2019375	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019376	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019377	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019378	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019379	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019380	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019381	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019382	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019383	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019384	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019385	11/2011	11/10/2011	100.00	100.10	100.10	1
KU	C1S	2019386	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019387	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019388	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019389	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019390	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019391	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019392	11/2011	11/10/2011	100.00	100.10	100.10	1
KU	C1S	2019393	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019394	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019395	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019396	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019397	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019398	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019399	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019400	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019401	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019402	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019403	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019404	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019405	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019406	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019407	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019408	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019409	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019410	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019411	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019412	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019413	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019414	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019415	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019416	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019417	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019418	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019419	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019420	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019421	11/2011	11/14/2011	100.00	99.90	100.00	1
KU	C1S	2019422	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019423	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019424	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019425	11/2011	11/14/2011	100.00	100.20	100.00	1

KU	C1S	2019426	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019427	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019428	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2019429	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019430	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019431	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019432	11/2011	11/10/2011	100.00	99.90	99.90	1
KU	C1S	2019433	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019434	11/2011	11/10/2011	99.90	100.10	100.00	1
KU	C1S	2019435	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019436	11/2011	11/10/2011	100.00	100.10	99.90	1
KU	C1S	2019437	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019438	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019439	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019440	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019441	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019442	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019443	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019444	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019445	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019446	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019447	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019448	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019449	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019450	11/2011	11/10/2011	100.00	100.20	100.00	1
KU	C1S	2019451	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019452	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019453	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019454	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019455	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2019456	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019457	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019458	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019459	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019460	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019461	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019462	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019463	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019464	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019465	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019466	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019467	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019468	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019469	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019470	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019471	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019472	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019473	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019474	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019475	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019476	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019477	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2019478	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019479	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019480	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019481	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019482	11/2011	11/10/2011	100.00	100.20	100.00	1
KU	C1S	2019483	11/2011	11/10/2011	100.00	100.10	100.10	1
KU	C1S	2019484	11/2011	11/10/2011	100.00	100.00	100.10	1
KU	C1S	2019485	11/2011	11/10/2011	100.00	100.10	99.90	1

KU	C1S	2019486	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019487	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019488	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019489	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019490	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019491	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019492	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019493	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019494	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019495	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019496	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019497	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019498	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019499	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019500	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019501	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2019502	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019503	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019504	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019505	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019506	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019507	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019508	11/2011	11/10/2011	99.90	100.10	100.10	1
KU	C1S	2019509	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019510	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019511	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019512	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019513	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019514	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019515	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2019516	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019517	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019518	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019519	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019520	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019521	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019522	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019523	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019524	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019525	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019526	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019527	11/2011	11/10/2011	100.00	100.20	99.90	1
KU	C1S	2019528	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019529	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019530	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019531	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019532	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019533	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019534	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019535	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019536	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019537	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019538	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019539	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019540	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019541	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019542	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019543	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019544	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019545	11/2011	11/14/2011	100.00	100.00	99.90	1

KU	C1S	2019546	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019547	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019548	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019549	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019550	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019551	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019552	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019553	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019554	11/2011	11/15/2011	100.00	99.90	100.00	1
KU	C1S	2019555	11/2011	11/15/2011	100.00	99.90	100.00	1
KU	C1S	2019556	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019557	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019558	11/2011	11/14/2011	100.00	100.20	100.20	1
KU	C1S	2019559	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019560	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019561	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019562	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019563	11/2011	11/10/2011	100.00	100.20	99.90	1
KU	C1S	2019564	11/2011	11/10/2011	100.00	100.00	99.80	1
KU	C1S	2019565	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019566	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019567	11/2011	11/10/2011	100.00	100.10	99.90	1
KU	C1S	2019568	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019569	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019570	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019571	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019572	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019573	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019574	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019575	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2019576	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019577	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019578	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019579	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019580	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2019581	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019582	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019583	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019584	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019585	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019586	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019587	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019588	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019589	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019590	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019591	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019592	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019593	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019594	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019595	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019596	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019597	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019598	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019599	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019600	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019601	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019602	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019603	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019604	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019605	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2019606	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019607	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019608	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019609	11/2011	11/14/2011	100.00	100.20	100.00	1
KU	C1S	2019610	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019611	11/2011	11/15/2011	99.90	99.90	99.80	1
KU	C1S	2019612	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019613	11/2011	11/14/2011	100.00	100.20	100.00	1
KU	C1S	2019614	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019615	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019616	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019617	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019618	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019619	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2019620	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019621	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019622	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019623	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019624	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019625	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019626	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019627	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019628	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019629	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019630	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019631	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019632	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019633	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019634	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019635	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019636	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019637	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019638	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019639	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019640	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019641	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019642	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019643	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019644	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019645	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019646	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019647	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019648	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019649	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019650	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019651	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019652	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019653	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019654	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019655	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019656	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019657	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019658	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019659	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019660	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019661	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019662	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019663	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019664	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019665	11/2011	11/15/2011	100.00	100.10	100.10	1

KU	C1S	2019666	11/2011	11/10/2011	100.00	100.20	100.10	1
KU	C1S	2019667	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019668	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019669	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019670	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019671	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019672	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019673	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019674	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019675	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019676	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019677	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019678	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019679	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019680	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019681	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019682	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019683	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2019684	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019685	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019686	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019687	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019688	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019689	11/2011	11/10/2011	100.00	100.10	100.10	1
KU	C1S	2019690	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019691	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019692	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019693	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019694	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019695	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019696	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019697	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019698	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019699	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019700	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019701	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019702	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019703	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019704	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019705	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019706	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019707	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019708	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019709	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019710	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019711	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019712	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019713	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019714	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019715	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019716	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019717	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019718	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019719	11/2011	11/10/2011	100.00	100.20	100.00	1
KU	C1S	2019720	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019721	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019722	11/2011	11/10/2011	100.00	100.00	100.10	1
KU	C1S	2019723	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019724	11/2011	11/14/2011	100.00	100.00	99.80	1
KU	C1S	2019725	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2019726	11/2011	11/10/2011	100.00	100.10	99.90	1
KU	C1S	2019727	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019728	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019729	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019730	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019731	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019732	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019733	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019734	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019735	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019736	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019737	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019738	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019739	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019740	11/2011	11/15/2011	99.90	100.10	100.10	1
KU	C1S	2019741	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019742	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019743	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019744	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019745	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019746	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019747	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019748	11/2011	11/15/2011	100.00	100.20	99.80	1
KU	C1S	2019749	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019750	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019751	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019752	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019753	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019754	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019755	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2019756	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019757	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019758	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019759	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019760	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019761	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019762	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019763	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019764	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019765	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019766	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019767	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019768	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019769	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019770	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019771	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019772	11/2011	11/10/2011	100.00	100.00	100.00	1
KU	C1S	2019773	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019774	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019775	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2019776	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019777	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019778	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019779	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019780	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019781	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019782	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019783	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019784	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019785	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019786	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019787	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019788	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019789	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019790	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019791	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019792	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019793	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019794	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019795	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019796	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019797	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019798	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019799	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019800	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019801	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2019802	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019803	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019804	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019805	11/2011	11/10/2011	100.00	100.00	100.10	1
KU	C1S	2019806	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2019807	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019808	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019809	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019810	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019811	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019812	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019813	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019814	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019815	11/2011	11/15/2011	100.00	100.20	99.90	1

KU	C1S	2019816	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019817	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019818	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019819	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019820	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019821	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019822	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019823	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019824	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019825	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019826	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019827	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019828	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019829	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019830	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019831	11/2011	11/15/2011	100.00	100.20	100.20	1
KU	C1S	2019832	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019833	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019834	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019835	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019836	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019837	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019838	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019839	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019840	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019841	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019842	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019843	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019844	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019845	11/2011	11/15/2011	100.00	100.20	99.90	1

KU	C1S	2019846	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019847	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019848	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019849	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019850	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019851	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019852	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019853	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019854	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019855	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019856	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019857	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019858	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019859	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019860	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019861	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019862	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019863	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2019864	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019865	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019866	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019867	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019868	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019869	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019870	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019871	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019872	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019873	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019874	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019875	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2019876	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019877	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019878	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019879	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019880	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019881	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019882	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019883	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019884	11/2011	11/10/2011	100.00	100.10	99.80	1
KU	C1S	2019885	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019886	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019887	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019888	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019889	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019890	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019891	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2019892	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019893	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019894	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019895	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019896	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019897	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2019898	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019899	11/2011	11/10/2011	100.00	100.10	100.10	1
KU	C1S	2019900	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019901	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019902	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019903	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019904	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019905	11/2011	11/14/2011	100.00	100.10	100.00	1

KU	C1S	2019906	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019907	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019908	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019909	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019910	11/2011	11/14/2011	100.00	100.20	100.20	1
KU	C1S	2019911	11/2011	11/14/2011	100.00	100.10	100.20	1
KU	C1S	2019912	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019913	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019914	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019915	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019916	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019917	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019918	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019919	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2019920	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019921	11/2011	11/14/2011	100.00	100.00	99.80	1
KU	C1S	2019922	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2019923	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019924	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019925	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019926	11/2011	11/14/2011	100.00	100.20	100.00	1
KU	C1S	2019927	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019928	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019929	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019930	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2019931	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019932	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019933	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019934	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019935	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2019936	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2019937	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019938	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019939	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019940	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019941	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019942	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019943	11/2011	11/14/2011	100.00	100.20	100.00	1
KU	C1S	2019944	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019945	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019946	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019947	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019948	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019949	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2019950	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019951	11/2011	11/14/2011	100.00	100.10	100.20	1
KU	C1S	2019952	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019953	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019954	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019955	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019956	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019957	11/2011	11/15/2011	100.00	100.20	99.80	1
KU	C1S	2019958	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019959	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019960	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019961	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2019962	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019963	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019964	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019965	11/2011	11/14/2011	100.00	100.20	100.10	1

KU	C1S	2019966	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2019967	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2019968	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019969	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019970	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019971	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019972	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019973	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019974	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019975	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019976	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019977	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2019978	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019979	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019980	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2019981	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2019982	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019983	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2019984	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2019985	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019986	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019987	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2019988	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019989	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019990	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019991	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019992	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019993	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019994	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019995	11/2011	11/15/2011	100.00	100.20	100.10	1

KU	C1S	2019996	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2019997	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2019998	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2019999	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020000	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020001	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2020002	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020003	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020004	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020005	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020006	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020007	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020008	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020009	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020010	11/2011	11/15/2011	99.90	100.10	100.00	1
KU	C1S	2020011	11/2011	11/14/2011	100.00	100.00	100.20	1
KU	C1S	2020012	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020013	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020014	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2020015	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020016	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020017	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020018	11/2011	11/14/2011	100.00	100.00	100.10	1
KU	C1S	2020019	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020020	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020021	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2020022	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020023	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020024	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020025	11/2011	11/15/2011	100.00	100.00	100.00	1

KU	C1S	2020026	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020027	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020028	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2020029	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020030	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020031	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2020032	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2020033	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020034	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2020035	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020036	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020037	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2020038	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020039	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020040	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020041	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020042	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2020043	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020044	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020045	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020046	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020047	11/2011	11/14/2011	100.00	100.10	99.90	1
KU	C1S	2020048	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020049	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020050	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020051	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020052	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020053	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020054	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020055	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2020056	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020057	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020058	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020059	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020060	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020061	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020062	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020063	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020064	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020065	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020066	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020067	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020068	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020069	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020070	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020071	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020072	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020073	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020074	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2020075	11/2011	11/11/2011	100.00	100.00	100.00	1
KU	C1S	2020076	11/2011	11/14/2011	100.00	100.10	100.00	1
KU	C1S	2020077	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2020078	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020079	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020080	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020081	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020082	11/2011	11/14/2011	100.00	100.00	99.90	1
KU	C1S	2020083	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020084	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020085	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2020086	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020087	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2020088	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020089	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020090	11/2011	11/14/2011	100.00	100.10	100.10	1
KU	C1S	2020091	11/2011	11/14/2011	100.00	100.20	99.90	1
KU	C1S	2020092	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2020093	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020094	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020095	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020096	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020097	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020098	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020099	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020100	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020101	11/2011	11/14/2011	100.00	100.00	100.00	1
KU	C1S	2020102	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020103	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020104	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020105	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020106	11/2011	11/14/2011	100.00	99.90	99.90	1
KU	C1S	2020107	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2020108	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020109	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020110	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020111	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020112	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020113	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020114	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020115	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2020116	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020117	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020118	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020119	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020120	11/2011	11/15/2011	99.90	100.00	100.00	1
KU	C1S	2020121	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020122	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020123	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020124	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020125	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020126	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020127	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020128	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020129	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020130	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020131	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2020132	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2020133	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020134	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020135	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020136	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020137	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020138	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2020139	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020140	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2020141	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020142	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020143	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020144	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020145	11/2011	11/15/2011	100.00	100.10	100.00	1

KU	C1S	2020146	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020147	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020148	11/2011	11/10/2011	100.00	100.00	99.90	1
KU	C1S	2020149	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020150	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020151	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020152	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2020153	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020154	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020155	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020156	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020157	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020158	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020159	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020160	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020161	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020162	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020163	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020164	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020165	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2020166	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020167	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020168	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020169	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020170	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020171	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020172	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020173	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020174	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020175	11/2011	11/15/2011	100.00	100.20	100.10	1

KU	C1S	2020176	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020177	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020178	11/2011	11/15/2011	100.00	100.20	100.10	1
KU	C1S	2020179	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020180	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020181	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020182	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020183	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020184	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020185	11/2011	11/15/2011	100.00	100.20	99.90	1
KU	C1S	2020186	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020187	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020188	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020189	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020190	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020191	11/2011	11/15/2011	100.00	100.00	100.20	1
KU	C1S	2020192	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2020193	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020194	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020195	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020196	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020197	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2020198	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020199	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020200	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020201	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020202	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020203	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020204	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020205	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2020206	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020207	11/2011	11/15/2011	99.90	99.90	99.80	1
KU	C1S	2020208	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020209	11/2011	11/10/2011	100.00	100.10	100.00	1
KU	C1S	2020210	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020211	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020212	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020213	11/2011	11/15/2011	99.90	100.00	99.90	1
KU	C1S	2020214	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020215	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020216	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020217	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020218	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020219	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020220	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020221	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020222	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020223	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020224	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020225	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020226	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020227	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020228	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020229	11/2011	11/15/2011	100.00	100.10	100.20	1
KU	C1S	2020230	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020231	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020232	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020233	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020234	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020235	11/2011	11/15/2011	100.00	100.00	99.90	1

KU	C1S	2020236	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020237	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020238	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020239	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020240	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020241	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020242	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020243	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020244	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020245	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020246	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020247	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020248	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020249	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020250	11/2011	11/15/2011	100.00	99.90	99.80	1
KU	C1S	2020251	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020252	11/2011	11/15/2011	100.00	100.10	99.80	1
KU	C1S	2020253	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020254	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020255	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020256	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020257	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020258	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020259	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020260	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020261	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2020262	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020263	11/2011	11/15/2011	100.00	100.10	100.10	1
KU	C1S	2020264	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020265	11/2011	11/15/2011	100.00	100.10	99.90	1

KU	C1S	2020266	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020267	11/2011	11/15/2011	100.00	100.20	100.00	1
KU	C1S	2020268	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020269	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020270	11/2011	11/15/2011	100.00	99.90	99.90	1
KU	C1S	2020271	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020272	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020273	11/2011	11/15/2011	100.00	100.10	100.00	1
KU	C1S	2020274	11/2011	11/15/2011	100.00	100.00	99.90	1
KU	C1S	2020275	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2020276	11/2011	11/15/2011	100.00	100.00	100.10	1
KU	C1S	2020277	11/2011	11/15/2011	100.00	100.00	100.00	1
KU	C1S	2020278	11/2011	11/15/2011	100.00	100.10	99.90	1
KU	C1S	2020279	11/2011	11/15/2011	100.00	100.00	99.80	1
KU	C1S	2505760	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505761	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505762	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505763	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505764	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505765	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505766	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505767	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505768	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505769	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505770	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505771	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505772	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505773	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505774	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505775	10/2011	10/13/2011	100.00	100.00	99.90	1

KU	C1S	2505776	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505777	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505778	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505779	10/2011	10/13/2011	100.00	100.20	100.10	1
KU	C1S	2505780	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505781	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505782	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505783	10/2011	10/13/2011	100.00	100.00	99.80	1
KU	C1S	2505784	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505785	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505786	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505787	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505788	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505789	10/2011	10/13/2011	100.00	100.10	100.20	1
KU	C1S	2505790	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505791	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505792	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505793	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505794	10/2011	10/13/2011	100.00	100.00	100.10	1
KU	C1S	2505795	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505796	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505797	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505798	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505799	10/2011	10/13/2011	100.00	100.00	99.80	1
KU	C1S	2505800	10/2011	10/13/2011	100.00	99.90	99.90	1
KU	C1S	2505801	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505802	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505803	10/2011	10/13/2011	100.00	100.00	100.20	1
KU	C1S	2505804	10/2011	10/13/2011	100.00	99.90	99.90	1
KU	C1S	2505805	10/2011	10/13/2011	100.00	100.00	100.00	1

KU	C1S	2505806	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505807	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505808	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505809	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505810	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505811	10/2011	10/13/2011	99.90	100.10	99.90	1
KU	C1S	2505812	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505813	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505814	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505815	10/2011	10/13/2011	100.00	100.00	99.80	1
KU	C1S	2505816	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505817	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505818	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505819	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505820	10/2011	10/13/2011	100.00	100.20	100.00	1
KU	C1S	2505821	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505822	10/2011	10/13/2011	100.00	100.20	99.90	1
KU	C1S	2505823	10/2011	10/13/2011	100.00	99.90	99.90	1
KU	C1S	2505824	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505825	10/2011	10/13/2011	100.00	100.00	99.80	1
KU	C1S	2505826	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505827	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505828	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505829	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505830	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505831	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505832	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505833	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505834	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505835	10/2011	10/13/2011	100.00	100.10	100.00	1

KU	C1S	2505836	10/2011	10/13/2011	99.90	100.10	99.90	1
KU	C1S	2505837	10/2011	10/13/2011	100.00	100.20	100.00	1
KU	C1S	2505838	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505839	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505840	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505841	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505842	10/2011	10/13/2011	99.90	100.00	100.00	1
KU	C1S	2505843	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505844	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505845	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505846	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505847	10/2011	10/13/2011	100.00	100.00	100.20	1
KU	C1S	2505848	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505849	10/2011	10/13/2011	100.00	100.00	100.20	1
KU	C1S	2505850	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505851	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505852	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505853	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505854	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505855	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505856	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505857	10/2011	10/13/2011	100.00	100.20	100.00	1
KU	C1S	2505858	10/2011	10/13/2011	100.00	100.10	100.20	1
KU	C1S	2505859	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505860	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505861	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505862	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505863	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505864	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505865	10/2011	10/13/2011	100.00	100.00	99.80	1

KU	C1S	2505866	10/2011	10/13/2011	100.00	100.10	99.90	1
KU	C1S	2505867	10/2011	10/13/2011	100.00	100.00	99.80	1
KU	C1S	2505868	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505869	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505870	10/2011	10/13/2011	100.00	100.10	99.80	1
KU	C1S	2505871	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505872	10/2011	10/13/2011	100.00	100.10	100.00	1
KU	C1S	2505873	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	C1S	2505874	10/2011	10/13/2011	100.00	100.20	100.10	1
KU	C1S	2505875	10/2011	10/13/2011	100.00	100.10	99.80	1
KU	C1S	2505876	10/2011	10/13/2011	99.90	100.10	100.00	1
KU	C1S	2505877	10/2011	10/13/2011	100.00	100.10	100.10	1
KU	C1S	2505878	10/2011	10/13/2011	100.00	100.00	99.90	1
KU	C1S	2505879	10/2011	10/13/2011	100.00	100.00	100.00	1
KU	Result				100.00	100.07	99.99	7,080
Overall Result					100.00	100.07	99.99	7,080

**ATTACHMENT
B**

Sampling Test Results

KU
2011 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE		
In-Service Population	488,359	Divided into 61 Lots
Sample Quantity	4,208	
Meters Tested	4,208	
Meters Not Tested	0	
Failed Lots	1	Lot 437 (J3-1)
Failed Lot Meters	5,901	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 407 Lot Descr: KU AB1 -1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C331729	100.10	C331850	99.50	C332020	99.90	C332276	100.00	C332283	100.10
C332380	99.90	C332442	99.20	C332502	99.70	C332563	100.20	C332618	99.80
C332673	99.50	C332733	100.00	C333003	99.10	C333146	99.50	C333428	100.20
C333478	100.20	C333892	100.40	C334807	100.30	C334813	100.30	L297790	99.60
L297849	100.20	L297997	100.20	L298160	99.80	L298307	99.30	L298382	99.50
L298447	99.90	L298749	99.90	L298794	99.60	L298805	99.50	L298850	99.80
L299038	100.00	L299614	100.30	L299615	100.10	L299620	98.40	L299688	99.60
L299750	100.00	L300099	99.70	L300285	100.40	L300361	100.00	L300705	99.20
L300713	100.10	L300784	100.20	L300898	99.20	L301127	100.00	L301352	99.60
L301405	99.80	L301480	99.90	L301573	99.70	L301801	99.10	L301903	100.30
L302335	100.40	L302586	100.20	L302751	99.90	L302803	99.90	L302931	100.30
L303081	100.30	L303305	100.10	L303316	100.30	L303474	99.90	L303519	100.20
M444902	99.60	M444963	99.40	M445128	99.90	M445193	99.60	M445368	100.40
M445394	99.70	M445423	99.80	M445464	99.80	W146797	99.20	W146967	99.70
W147122	99.60	W147207	99.50	W147570	99.90	W147644	99.90	W147691	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7488.30
3 Sum of Squared Measurements	747672.65
4 Correction Factor (CF): Sum of Measurements Squared / N	747661.83
5 Corrected Sum of Squares (SS)	10.82
6 Variance (V) : SS/(N-1)	0.1463
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3825
8 Sample Mean(XBAR): Sum X/N	99.84
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.64
12 Quality Index Lower (QL): (XBAR-L) / S	4.82
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200

Model Number: AB1

Division: 01

Sample Lot: 408

Lot Descr: KU AB1 - 2

In Service Population: 6,109

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 2

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C334157	100.00	C334164	99.10	C334173	100.30	C334194	99.50	C334263	100.10
C334329	99.50	C334442	100.10	C334586	99.80	C334874	100.50	C335134	100.10
C408172	100.20	C408371	100.30	C408551	100.50	C408605	100.20	C408665	100.30
C408678	100.00	C408854	100.40	C408902	100.50	C408915	100.20	C409003	100.20
C409078	99.80	C409085	100.00	C409102	100.50	C409234	100.60	C409284	100.10
C409331	99.70	C409451	100.50	C409461	100.40	C409573	99.80	C409593	100.40
C409609	100.40	C409637	100.30	C409771	100.33	C433561	100.10	C433568	100.20
C433610	100.30	C433666	100.40	C433687	100.10	C433798	100.10	C433865	100.30
C433895	100.40	C433934	100.30	C433970	100.40	C433993	100.30	C434035	100.10
C434062	100.10	C434176	100.20	C434200	100.30	C434485	100.20	C434489	100.20
C434651	100.50	C434672	99.90	C434812	99.90	C434850	100.00	C434984	100.10
C435112	100.10	C435223	100.10	C435373	100.20	C435380	99.90	W147863	99.10
W147984	100.60	W147994	99.60	W148266	100.20	W148508	100.50	W148516	100.00
W148520	99.10	W148521	100.10	W148731	99.00	W148794	99.50	W148834	100.00
W148840	99.50	W148853	99.90	W149048	99.50	W149057	99.50	W149094	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.03
3 Sum of Squared Measurements	751016.54
4 Correction Factor (CF): Sum of Measurements Squared / N	751006.34
5 Corrected Sum of Squares (SS)	10.20
6 Variance (V) : SS/(N-1)	0.1379
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3713
8 Sample Mean (XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	5.21
12 Quality Index Lower (QL): (XBAR-L) / s	5.57
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200E Model Number: ALF Division: 01 Sample Lot: 409 Lot Descr: KU ALF - 1
 In Service Population: 11 Sample Quantity: 3 Meters Tested: 3 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
L834113	100.00	L834398	100.02	L834875	99.90				

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	3
2 Sum of Measurements: (Sum X)	299.92
3 Sum of Squared Measurements	29984.01
4 Correction Factor (CF): Sum of Measurements Squared / N	29984.00
5 Corrected Sum of Squares (SS)	0.01
6 Variance (V) : SS/(N-1)	0.0041
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0643
8 Sample Mean(XBAR) : Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	31.52
12 Quality Index Lower (QL): (XBAR-L) / S	30.69
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	7.59
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200E Model Number: C1SR Division: 01 Sample Lot: 410 Lot Descr: KU C1S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2000059	100.10	2000402	100.00	2000555	100.20	2000670	100.20	2000804	100.00
2000846	100.00	2001100	99.90	2001220	100.00	2001242	100.00	2001352	99.90
2001414	100.10	2001578	100.00	2001595	100.10	2001712	100.00	2001782	100.00
2002108	100.10	2002258	100.10	2002425	100.00	2002461	100.00	2002529	100.00
2002614	100.10	C352389	100.00	C352767	100.10	C352803	100.00	C352836	100.00
C369094	100.00	C369109	100.20	C369480	99.90	C380615	100.00	C380833	100.00
C380848	100.20	C380965	100.00	C381060	100.20	C381352	100.00	C381615	100.10
C382057	100.10	C382639	100.00	C382674	100.10	C382770	99.90	C383093	100.00
C383169	100.20	C386462	100.00	C407593	100.00	C407619	100.20	C407702	100.00
C407843	100.10	C407886	100.00	C416015	100.00	C416566	99.90	C416608	100.10
C416718	99.80	C416828	100.00	C417267	99.80	C417332	99.90	C417336	99.80
C417496	100.00	C425579	100.00	C465651	100.10	C465699	100.20	C465708	100.00
C465764	99.80	C465783	99.90	C465785	100.10	C465832	99.90	C465891	100.00
C465934	100.00	C466122	100.30	C466722	100.00	C466830	100.10	C466906	99.90
C467077	100.00	C467119	100.00	C467160	100.10	C467282	99.90	C467354	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.70
3 Sum of Squared Measurements	750340.83
4 Correction Factor (CF): Sum of Measurements Squared / N	750340.04
5 Corrected Sum of Squares (SS)	0.79
6 Variance (V) : SS/(N-1)	0.0107
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1034
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	19.12
12 Quality Index Lower (QL): (XBAR-L) / s	19.56
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 411 Lot Descr: KU C1S - 2
 In Service Population: 6,937 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2002678	100.10	2002828	100.10	2003036	100.10	2003071	100.00	2003088	100.00
2003097	100.20	2003192	100.20	2003204	100.10	2003233	100.10	2003252	100.00
2003287	100.00	2003404	100.10	2003462	100.20	2003612	100.00	2003721	100.10
2003894	100.00	2004036	100.10	2004116	100.10	2004503	100.20	2004552	100.00
2004651	100.00	2004685	100.10	2004871	100.00	2004875	100.20	2005170	100.00
2005498	100.10	2005506	100.10	2006733	100.00	2006773	99.90	2006800	100.10
2006996	100.00	2007001	100.00	2007063	99.90	2007295	99.80	2007343	100.00
2007716	99.90	2007760	100.00	2007881	99.90	2007908	100.10	2008981	99.90
2011122	99.90	2011600	100.00	2011869	99.90	2500062	100.10	2500411	100.00
2500497	100.20	2500645	100.10	2500703	100.10	2500752	100.10	2501105	99.90
2501120	100.00	2501291	100.10	2501872	100.10	2501886	100.10	2501943	99.90
2502062	100.00	2502081	100.00	2502228	100.00	2502473	100.10	C467624	100.10
C467638	99.90	C467655	100.00	C467828	99.90	C468006	100.10	C468114	100.20
C468197	100.00	C468271	100.00	C468477	100.00	C468526	100.00	C468580	100.00
C468595	100.10	C468697	99.90	C468716	100.00	C468975	100.00	C469444	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.70
3 Sum of Squared Measurements	750540.73
4 Correction Factor (CF): Sum of Measurements Squared / N	750540.10
5 Corrected Sum of Squares (SS)	0.63
6 Variance (V) : SS/(N-1)	0.0086
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0925
8 Sample Mean (XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	21.24
12 Quality Index Lower (QL): (XBAR-L) / S	22.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)
 Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 412 Lot Descr: KU D4 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C225333	100.00	C225349	99.90	C225397	99.50	C225489	99.90	C226430	100.00
C226503	100.10	C228284	100.10	C228448	99.40	C229480	99.70	C229990	100.60
C230596	99.90	C232027	100.00	C232160	100.10	C232204	99.60	C232404	99.70
C233818	100.20	C233903	100.00	C236144	99.90	C236272	100.10	C236290	100.20
C236353	100.00	C236438	100.30	C236498	100.00	C236575	100.20	C236680	100.30
C236929	100.00	L129232	99.70	L129234	99.70	L136419	99.40	L141138	99.80
M345697	99.60	M350624	100.20	M350636	100.00	M350659	99.60	M350697	99.80
M351801	100.30	M351823	99.90	M351854	99.50	M352605	100.00	M352650	100.30
M353846	98.70	M354071	99.20	M354102	99.90	M367786	99.90	M367798	100.10
M375050	100.30	M375110	99.10	M375304	100.20	M375942	100.20	M376070	99.90
M376267	99.70	M381031	100.10	M381037	99.90	W101083	100.00	W101138	99.80
W101290	100.20	W101315	100.00	W101317	100.10	W102091	100.00	W102508	100.10
W102611	100.90	W102636	99.60	W102671	100.00	W102757	100.00	W102834	99.90
W104885	100.20	W105404	99.50	W105462	100.10	W105732	99.80	W106038	99.80
W107919	100.10	W107928	99.90	W108292	99.60	W108341	100.40	W108353	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.90
3 Sum of Squared Measurements	748988.41
4 Correction Factor (CF): Sum of Measurements Squared / N	748980.35
5 Corrected Sum of Squares (SS)	8.06
6 Variance (V) : SS/(N-1)	0.1090
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3301
8 Sample Mean(XBAR) : Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.26
12 Quality Index Lower (QL): (XBAR-L) / S	5.85
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: D4S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 413
Pass/ Fail: PASS

Lot Descr: KU D4 - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7
Run Date: 01/02/2012
Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C237047	100.00	C237118	100.30	C240628	100.10	C241087	100.00	C241371	100.10
C241381	100.10	C245491	99.90	C245655	100.30	C250567	100.00	C254612	100.30
C254635	100.30	C254667	100.30	C254705	100.30	C255009	99.90	C255022	100.10
C255098	99.60	C255237	100.10	C255309	99.70	M376574	100.20	M385333	100.20
M385739	100.30	M385748	99.30	M385855	99.80	M385862	100.00	M386632	99.60
M389036	99.60	M389076	100.00	M389086	99.90	M389236	99.90	M389413	100.30
M389632	99.90	M389737	99.60	M389741	99.70	M389832	99.90	M389869	100.10
M389896	99.90	M390190	99.40	M390302	100.10	M390359	100.10	M390445	100.00
M390534	100.00	M390673	99.50	M390674	99.90	M392300	100.10	M392453	99.70
M392578	100.20	M393264	99.90	M393324	100.00	M393454	99.90	M393470	99.70
M396152	99.80	M396326	100.20	M396500	99.50	M396835	100.00	M397187	99.70
M397285	100.00	M397575	99.70	M397736	99.80	W109628	100.00	W110300	99.90
W110656	99.80	W110939	99.40	W111181	99.80	W111812	100.00	W112083	100.30
W113206	100.30	W114428	99.70	W114500	99.60	W114547	99.60	W114770	100.10
W114909	99.90	W116406	99.80	W116567	100.00	W116981	100.00	W117095	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7495.50
3 Sum of Squared Measurements	749105.07
4 Correction Factor (CF): Sum of Measurements Squared / N	749100.27
5 Corrected Sum of Squares (SS)	4.80
6 Variance (V) : SS/(N-1)	0.0649
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2547
8 Sample Mean (XBAR): Sum X/N	99.94
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.09
12 Quality Index Lower (QL): (XBAR-L) / S	7.62
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 414 Lot Descr: KU D4 - 3
 In Service Population: 8,601 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 8

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C222738	100.20	C222802	100.10	C223038	99.70	C223819	100.20	C223853	100.00
C223860	100.10	C256884	100.10	C257137	99.60	C257349	100.40	C257418	100.10
C257462	99.90	C257593	100.30	C257717	100.30	C264007	100.20	L216343	100.50
L216549	100.50	L219130	99.90	L221933	100.10	L223736	99.90	L223746	100.10
L224054	100.10	L224107	100.00	L224301	100.00	L224423	99.40	L224674	99.80
L224698	99.80	L224862	99.70	L228127	100.10	L228161	99.90	L228318	99.40
L228429	99.70	L228520	100.20	L228596	100.10	L228663	99.90	L228733	99.60
L228872	99.60	L228951	99.80	M394617	99.80	M394912	99.50	M395516	99.60
M395594	99.70	M395743	100.20	M395770	100.10	M395794	99.90	M395838	99.90
M395917	100.10	M398009	99.70	M398288	100.10	M398361	100.00	M398648	100.00
M398695	100.20	M398701	100.00	M398713	100.10	M398731	100.20	M399221	100.00
M399297	99.80	M399437	99.80	M401016	99.90	M401079	99.70	M401332	99.80
M401371	99.90	M401424	100.00	M401560	99.80	M401742	100.10	M401789	100.30
M401887	100.00	W119982	99.40	W120091	99.40	W120250	99.70	W120290	100.10
W120319	100.10	W120466	100.00	W120489	100.10	W120551	99.50	W120593	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.00
3 Sum of Squared Measurements	749205.04
4 Correction Factor (CF): Sum of Measurements Squared / N	749200.21
5 Corrected Sum of Squares (SS)	4.83
6 Variance (V) : SS/(N-1)	0.0652
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2554
8 Sample Mean(XBAR): Sum X/N	99.95
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.04
12 Quality Index Lower (QL): (XBAR-L) / S	7.62
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: D5S Division: 01 Sample Lot: 415 Lot Descr: KU D5 - 1
 In Service Population: 527 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C279727	100.00	C279730	99.80	C279745	100.20	C279838	99.40	C279844	99.70
C279872	99.60	C279889	100.00	C279909	99.70	C279948	99.10	C283442	100.20
C283445	99.70	C283455	99.70	C283520	99.80	C283576	99.00	C283608	99.70
C283630	97.20	C283646	99.60	C283664	99.60	C283665	99.60	C283668	100.30
C283687	100.10	C283704	99.70	C298900	99.60	C298921	100.20	C298935	100.40
C298939	100.10	C298941	100.30	C298944	100.10	C298954	100.40	C299019	99.50
C299022	99.60	C299084	100.00	C299107	99.90	C299135	100.10	C299145	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3492.00
3 Sum of Squared Measurements	348412.52
4 Correction Factor (CF): Sum of Measurements Squared / N	348401.83
5 Corrected Sum of Squares (SS)	10.69
6 Variance (V) : SS/(N-1)	0.3145
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.5608
8 Sample Mean(XBAR): Sum X/N	99.77
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	3.97
12 Quality Index Lower (QL): (XBAR-L) / S	3.16
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.03
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.03
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200E

Model Number: I210

Division: 01

Sample Lot: 416

Lot Descr: KU I210 - 1

In Service Population: 5,342

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C431983	99.90	C432016	100.00	C432048	99.90	C432083	99.90	C432257	100.00
C432326	99.90	C432350	99.90	C432392	99.90	C432568	100.00	C432792	100.00
C432798	100.00	C432853	99.90	C432856	100.00	C432987	99.90	C433099	100.00
C433133	100.00	C433185	99.90	C433211	100.00	C433366	100.10	C433419	99.90
C445413	100.00	C445417	100.00	C445522	100.00	C445542	100.00	C445582	100.00
C445675	100.00	C445719	100.00	C445755	99.90	C445757	100.00	C445810	100.00
C445925	99.90	C445957	99.90	C445959	99.90	C446023	99.90	C446099	100.00
C446140	100.00	C446314	100.00	C446331	99.90	C455999	100.00	C456355	100.00
C456388	99.90	C456475	100.00	C456518	99.90	C456689	99.90	C456694	100.10
C456702	100.00	C456799	100.00	C456904	100.00	C456914	100.00	C456960	99.90
C456998	100.00	C457103	100.00	C457364	100.00	C457443	99.90	C457500	99.90
C463539	100.00	C463954	100.00	C464039	99.90	C464180	100.10	C464194	100.10
C464227	99.90	C464350	100.00	C464411	100.00	C464460	100.10	C464501	100.00
C464736	100.10	C464791	100.00	C464856	100.00	C464958	100.00	C464982	100.10
C465170	100.00	C465414	100.00	C465568	100.10	C465579	100.00	C465595	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.40
3 Sum of Squared Measurements	749680.32
4 Correction Factor (CF): Sum of Measurements Squared / N	749680.03
5 Corrected Sum of Squares (SS)	0.29
6 Variance (V) : SS/(N-1)	0.0039
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0622
8 Sample Mean(XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	32.52
12 Quality Index Lower (QL): (XBAR-L) / S	31.84
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V15AC100 Model Number: I50S Division: 01 Sample Lot: 417 Lot Descr: KU I50 - 1
 In Service Population: 1,342 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C176399	100.00	C177210	100.20	C284727	99.90	C284825	99.20	L002338	100.20
L003804	99.80	L008871	100.00	L049506	99.80	L049581	100.20	L061007	99.70
L061287	99.80	L062118	99.70	L062528	100.20	L064339	99.90	L065565	100.20
L065656	99.90	L065673	100.50	L066421	100.00	L068478	100.20	L068573	99.60
L069685	100.00	L069700	100.00	L071363	100.40	L071564	99.90	L071675	99.80
L071907	99.80	L072398	99.70	L072680	100.20	L073012	99.50	L073811	100.00
L074453	100.20	L075212	100.10	W072119	100.90	W072187	100.30	W073820	100.10
W074881	100.20	W075174	100.00	W075189	100.20	W076275	100.00	W078378	100.10
W078628	100.50	W079006	100.10	W079235	100.20	W079241	100.00	W079356	100.20
W079357	99.90	W079546	99.60	W082371	100.40	W082674	100.00	W082701	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5001.30
3 Sum of Squared Measurements	500263.97
4 Correction Factor (CF): Sum of Measurements Squared / N	500260.03
5 Corrected Sum of Squares (SS)	3.94
6 Variance (V) : SS/(N-1)	0.0803
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2834
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.96
12 Quality Index Lower (QL): (XBAR-L) / S	7.15
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V15AC100 Model Number: I55S Division: 01 Sample Lot: 418 Lot Descr: KU I55 - 1
 In Service Population: 1,177 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C289945	99.70	C298297	100.10	L075969	99.60	L076206	98.90	L076251	100.00
L076360	100.10	L076396	100.00	L076700	100.20	L076810	99.90	L077410	100.00
L077540	100.20	L077903	100.20	L078116	100.10	L079255	100.40	L079325	100.60
L079664	100.00	L079936	99.90	L080980	99.80	L082107	99.90	L082127	99.80
L082383	99.90	L082795	99.90	L083226	99.90	L083339	100.20	L083877	100.00
L084323	99.50	L086292	99.50	L086316	99.30	L087038	99.80	L087441	99.80
L087488	99.80	L087950	99.90	L088590	100.00	L089317	99.50	L089844	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3495.90
3 Sum of Squared Measurements	349183.93
4 Correction Factor (CF): Sum of Measurements Squared / N	349180.48
5 Corrected Sum of Squares (SS)	3.45
6 Variance (V) : SS/(N-1)	0.1015
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3185
8 Sample Mean(XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.65
12 Quality Index Lower (QL): (XBAR-L) / S	5.91
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 419 Lot Descr: KU I60 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 13
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C203491	100.10	C203894	100.80	C203922	100.60	C204634	100.00	C206006	100.10
L000235	99.60	L001927	100.20	L003464	99.50	L004414	99.90	L004895	99.80
L006024	100.00	L006177	100.10	L007797	100.00	L008780	100.30	L009693	99.80
L009800	100.00	L010639	99.70	L010765	100.10	L011059	99.90	L012003	100.10
L014476	100.20	L014497	99.40	L015485	99.80	L016317	100.20	L018750	99.90
L087763	100.20	L090810	99.80	L090877	99.80	L091178	100.50	L091199	100.00
L091246	99.90	L091822	100.10	L092057	99.90	L092345	99.90	L092893	100.20
L093583	100.00	L094431	100.20	L094767	100.20	L095353	100.50	L095636	100.10
L095700	100.50	L095762	99.80	L096479	100.20	L097271	99.90	L097291	100.00
L097405	100.00	L097778	100.00	L097833	99.70	L098139	99.80	L098637	99.80
L098823	99.80	L099921	100.40	L100587	100.30	L100926	99.80	L101183	99.90
L101706	99.90	L101719	100.10	L102667	99.90	L102730	100.30	L102900	99.70
L103445	100.00	L103518	100.20	L103734	100.40	L104646	99.80	L104693	100.30
L104772	100.00	L104773	99.50	L105261	100.20	L105606	100.10	L105747	100.10
L105807	99.70	L106592	99.90	L106769	99.60	L106898	100.40	L107093	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.20
3 Sum of Squared Measurements	750245.22
4 Correction Factor (CF): Sum of Measurements Squared / N	750240.02
5 Corrected Sum of Squares (SS)	5.20
6 Variance (V) : SS/(N-1)	0.0703
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2651
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.48
12 Quality Index Lower (QL): (XBAR-L) / s	7.60
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 420 Lot Descr: KU I60 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 14

Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C209471	99.90	C210693	100.00	C212497	99.90	L000769	100.10	L009011	100.00
L009705	99.80	L010347	99.90	L010994	100.10	L011174	99.60	L020047	99.60
L024276	99.50	L067049	99.90	L067175	99.80	L068705	99.60	L076076	100.00
L077987	100.30	L079721	99.50	L081621	99.70	L083519	100.00	L086109	100.00
L093769	100.40	L093845	100.20	L094631	100.10	L095288	100.10	L096387	100.00
L101067	99.90	L101074	100.00	L102211	100.40	L107246	99.80	L107667	100.00
L107930	100.20	L108289	99.90	L108387	100.00	L108461	100.00	L108836	100.40
L109901	100.00	L110048	100.40	L110303	100.10	L110784	99.90	L111026	100.00
L111142	100.10	L111163	100.30	L111216	99.30	L111569	100.10	L111963	100.20
L112023	100.00	L112026	100.00	L112075	100.10	L112433	100.10	L112529	99.80
L112548	99.80	L112669	99.70	L112680	99.90	L112704	99.80	L113106	100.10
L113185	100.00	L113380	100.20	L113469	100.10	L113985	99.70	L114115	99.80
L114118	99.80	L114428	99.80	L114594	99.50	L114672	99.80	L114730	99.70
L115177	99.80	L115561	100.10	L115589	100.10	L115596	99.80	L115965	100.20
L116039	99.70	L116040	100.30	L116367	100.00	L116472	100.10	L116779	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.90
3 Sum of Squared Measurements	749383.99
4 Correction Factor (CF): Sum of Measurements Squared / N	749380.13
5 Corrected Sum of Squares (SS)	3.86
6 Variance (V) : SS/(N-1)	0.0522
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2284
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.94
12 Quality Index Lower (QL): (XBAR-L) / S	8.57
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 421 Lot Descr: KU I60 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C215151	100.10	C216654	100.60	C216752	100.50	C216805	100.40	C218743	100.30
C218840	100.30	C218925	100.60	L002755	100.40	L008710	100.00	L011229	99.70
L013481	100.20	L013863	99.80	L013967	99.90	L014396	100.10	L016678	100.10
L019928	100.10	L028874	100.30	L033308	99.90	L033396	99.70	L042292	99.90
L066145	100.10	L083109	100.10	L085214	100.10	L088563	100.20	L088944	100.00
L091618	100.30	L092478	100.30	L093763	100.00	L093901	99.80	L094662	99.70
L095546	100.20	L097937	100.30	L104153	99.90	L117067	99.80	L117174	99.90
L117202	100.00	L117669	99.90	L117762	100.10	L117972	100.00	L118028	100.00
L118328	99.80	L118687	100.10	L118794	99.70	L119011	100.30	L119087	100.00
L119482	100.30	L120025	100.00	L120029	99.90	L120164	100.20	L120210	100.10
L120526	100.10	L120773	100.10	L120777	99.70	L120927	99.90	L120996	100.20
L121047	100.20	L121224	99.90	L121522	100.00	L121665	100.40	L121877	99.80
L121943	100.00	L122515	100.10	L122935	100.40	L123146	99.90	L123518	99.90
L123767	100.00	L123939	99.90	L124066	100.10	L124142	100.20	L124315	100.30
L124378	100.20	L124380	100.00	L124400	100.00	L124658	99.90	L124922	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.30
3 Sum of Squared Measurements	751063.67
4 Correction Factor (CF): Sum of Measurements Squared / N	751060.37
5 Corrected Sum of Squares (SS)	3.30
6 Variance (V) : SS/(N-1)	0.0445
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2110
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.14
12 Quality Index Lower (QL): (XBAR-L) / S	9.81
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 422 Lot Descr: KU I60 - 4
 In Service Population: 2,144 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C219923	100.10	C219967	99.90	C220066	100.30	C220068	100.00	C220087	100.50
L013990	100.10	L099662	99.90	L101951	99.60	L103237	99.90	L103396	100.00
L125404	100.10	L125418	99.90	L125460	100.00	L125571	99.60	L125620	100.00
L125757	100.10	L125836	99.90	L125870	100.00	L125947	100.00	L126086	99.80
L126164	100.10	L126180	100.10	L126236	99.80	L126249	100.30	L126290	100.20
L126316	99.90	L126368	100.00	L126390	100.40	L126591	100.10	L126796	99.80
L126810	100.20	L126818	100.10	L126819	100.50	L127081	100.00	L127135	99.90
L127292	100.10	L127399	99.80	L127408	100.00	L127444	100.30	L127531	100.00
L127564	99.70	L127621	100.00	L127647	100.30	L127652	100.00	L127657	100.30
L127661	100.00	L268385	100.20	L268442	99.90	L268458	100.00	L268481	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5001.70
3 Sum of Squared Measurements	500341.97
4 Correction Factor (CF): Sum of Measurements Squared / N	500340.06
5 Corrected Sum of Squares (SS)	1.91
6 Variance (V) : SS/(N-1)	0.0390
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1975
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.95
12 Quality Index Lower (QL): (XBAR-L) / S	10.30
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 423 Lot Descr: KU I70 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 17
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223290	100.30	C225712	100.20	C225746	100.30	C225776	100.30	C225825	100.40
C225844	100.10	C226705	100.50	L000142	100.40	L000767	99.60	L001556	100.00
L004205	100.20	L009729	100.10	L009758	100.00	L012932	99.90	L014693	100.00
L015195	100.00	L018121	99.90	L019957	99.00	L020476	99.60	L022543	100.40
L025147	100.10	L026946	99.70	L041453	100.30	L047184	100.20	L047823	100.00
L062932	100.30	L063075	100.40	L066168	100.40	L078887	100.10	L088300	99.90
L088498	100.30	L094231	100.20	L094973	99.90	L095170	100.30	L099617	100.00
L101977	99.90	L128107	100.10	L128163	100.00	L128562	100.30	L128779	100.30
L129085	100.20	L129139	100.00	L129345	100.30	L130011	100.30	L130213	99.80
L130534	99.80	L130621	100.10	L130908	100.20	L131812	100.00	L131917	100.20
L131924	100.10	L132121	100.00	L132158	99.90	L132198	100.20	L132595	100.20
L132597	100.50	L133039	100.10	L133602	100.20	L133691	100.30	L133698	100.30
L133735	100.10	L133860	100.20	L133900	99.80	L133947	100.10	L134064	100.40
L134284	100.30	L134321	100.20	L134491	100.10	L134593	100.20	L134782	100.20
L134979	100.00	L135239	100.10	M345365	100.30	M380827	100.50	W100666	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7509.20
3 Sum of Squared Measurements	751845.34
4 Correction Factor (CF): Sum of Measurements Squared / N	751841.13
5 Corrected Sum of Squares (SS)	4.21
6 Variance (V) : SS/(N-1)	0.0569
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2386
8 Sample Mean(XBAR): Sum X/N	100.12
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.87
12 Quality Index Lower (QL): (XBAR-L) / S	8.90
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200

Model Number: I70S

Division: 01

Sample Lot: 424

Lot Descr: KU I70 - 2

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C229258	100.10	C229264	99.70	C230888	100.50	C232864	100.30	C232984	99.80
L135487	100.60	L135541	100.10	L135970	100.20	L136067	100.30	L136466	100.10
L137040	100.40	L137188	100.50	L137522	100.10	L137858	100.50	L137952	100.10
L138502	100.10	L138742	100.10	L138750	99.90	L138814	100.30	L138942	100.30
L138972	100.10	L139003	100.50	L139608	99.90	L139840	100.40	L140352	99.80
L140370	99.90	L140593	100.20	L140924	100.00	L141063	99.80	L141478	100.00
L141602	100.00	L141630	99.90	L141636	100.20	L141700	100.30	L141707	99.90
L141748	100.10	L141826	99.90	L141978	100.10	L142096	100.10	L142289	100.30
L142478	100.20	L142603	100.10	L142667	99.70	L143055	100.20	L143276	100.60
L143400	100.10	L143485	100.30	L143615	100.60	L143645	100.00	L143869	100.50
L144013	99.80	L144252	100.20	L144267	100.00	L144614	99.90	L144667	100.30
L144762	100.00	L145007	100.20	L145255	100.10	L145267	100.20	L145653	100.10
L145731	100.30	L145931	100.30	L146295	100.60	L146385	100.00	L146409	100.10
L146424	100.10	L146433	99.90	L146665	100.00	L146786	100.70	L146796	100.70
L147051	99.60	L147397	100.40	L147503	100.40	M351447	100.30	W103657	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7512.00
3 Sum of Squared Measurements	752406.38
4 Correction Factor (CF): Sum of Measurements Squared / N	752401.92
5 Corrected Sum of Squares (SS)	4.46
6 Variance (V) : SS/(N-1)	0.0603
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2455
8 Sample Mean(XBAR): Sum X/N	100.16
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.49
12 Quality Index Lower (QL): (XBAR-L) / S	8.80
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 425 Lot Descr: KU I70 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C235130	100.20	C235212	99.90	C238372	100.30	C238386	100.00	C238473	100.80
C238602	100.70	C238628	100.50	C238648	100.00	C239300	100.40	C243033	100.40
C243081	100.40	C243519	100.10	C243542	100.40	L148672	100.40	L148758	100.20
L148772	100.40	L170071	100.10	L170120	100.30	L170300	100.00	L170308	100.00
L170562	100.50	L170833	99.80	L171031	100.00	L171075	100.20	L171151	100.30
L171268	100.20	L171498	100.30	L171523	100.30	L172122	100.30	L172177	100.50
L172590	100.00	L172671	100.20	L172702	100.10	L172715	100.40	L172757	100.00
L172787	100.30	L172904	99.70	L172958	100.10	L173135	99.70	L173732	99.90
L174027	100.10	L174477	99.70	L174492	99.70	L174676	100.10	L174691	99.60
L174835	100.00	L174924	99.80	L175083	100.20	L175185	99.90	L175344	100.40
L175453	100.50	L175484	100.10	L175709	100.10	L176354	100.10	L176832	100.10
L176921	99.70	L176987	100.00	L177827	100.00	L177855	100.30	L178076	100.20
L178355	100.20	L178545	100.20	L179241	100.10	L179454	100.10	L179577	99.90
L180237	100.20	L180243	100.20	L180414	100.00	L180444	100.00	M374161	100.00
M374332	100.30	M374407	100.10	W107683	100.30	W108406	100.20	W109007	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.70
3 Sum of Squared Measurements	752145.65
4 Correction Factor (CF): Sum of Measurements Squared / N	752141.53
5 Corrected Sum of Squares (SS)	4.12
6 Variance (V) : SS/(N-1)	0.0557
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2361
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.87
12 Quality Index Lower (QL): (XBAR-L) / S	9.08
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 426 Lot Descr: KU I70 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221585	100.20	L180636	100.20	L180767	99.80	L180796	100.00	L181285	99.60
L181292	100.10	L181328	100.00	L181934	99.90	L181995	100.00	L182039	100.10
L182048	100.00	L182293	99.70	L182331	100.30	L182610	100.30	L182843	100.30
L183606	100.20	L183612	99.90	L183690	100.20	L183772	100.40	L183988	100.10
L184185	100.20	L184252	100.50	L184368	100.40	L184491	100.50	L184760	100.20
L185635	100.30	L185650	100.40	L185800	100.40	L185897	100.10	L185912	100.10
L185949	100.10	L185956	99.90	L186074	100.10	L186851	100.20	L187107	100.10
L187134	99.80	L187359	99.90	L187715	99.70	L187795	100.00	L187844	99.90
L188501	100.20	L188624	99.90	L188887	99.90	L188920	100.20	L189166	99.60
L189252	99.80	L190414	100.00	L190555	100.20	L190579	100.00	L190953	99.90
L191059	100.10	L191095	99.70	L191151	100.00	L191622	99.90	L191697	99.90
L191927	99.70	L191944	99.90	L192306	99.90	L192322	99.80	L192657	99.90
L192708	99.90	L192742	99.90	L192949	99.90	L192994	99.70	L194898	99.80
L195344	100.30	L195467	100.30	L195476	100.30	L195575	100.30	L195740	100.00
L195817	99.80	L195967	100.10	L196464	100.00	M384746	99.90	M386969	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.00
3 Sum of Squared Measurements	750603.58
4 Correction Factor (CF): Sum of Measurements Squared / N	750600.12
5 Corrected Sum of Squares (SS)	3.46
6 Variance (V) : SS/(N-1)	0.0468
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2162
8 Sample Mean (XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.06
12 Quality Index Lower (QL): (XBAR-L) / S	9.43
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 427 Lot Descr: KU I70 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C247792	100.20	C247804	100.30	C248034	100.10	C248256	99.60	C248357	100.10
C248369	100.20	C252044	100.20	C252066	100.40	C252156	100.40	C252178	100.30
C252203	100.10	L197863	100.00	L198482	99.80	L198817	100.10	L199715	100.30
L199759	99.80	L199869	100.00	L199870	100.10	L199988	100.00	L200112	99.60
L200152	99.80	L200351	99.80	L200599	100.20	L200609	99.90	L200758	100.20
L201529	100.10	L201631	99.90	L201674	99.70	L201871	99.90	L202193	100.20
L203592	99.90	L203715	99.90	L203977	99.80	L204247	99.80	L204423	100.50
L204574	100.00	L204746	99.80	L204773	99.90	L204931	99.90	L205079	100.10
L205666	100.20	L205673	99.70	L205815	100.50	L205858	100.10	L206029	99.80
L206058	100.20	L206196	99.60	L206924	99.70	L207020	100.10	L207093	99.70
L207308	99.70	L207406	99.60	L207491	99.70	L207771	100.00	L207800	100.20
L208108	100.00	L208167	100.10	L208173	100.30	L208817	100.10	L208870	100.20
L208901	100.00	L208942	100.20	L210352	100.20	L210840	100.00	L215672	99.40
M384398	100.40	M384411	99.70	M384505	100.20	M384536	100.20	W112619	99.90
W115960	100.40	W116101	100.00	W117651	100.20	W117719	100.30	W117725	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.60
3 Sum of Squared Measurements	750324.34
4 Correction Factor (CF): Sum of Measurements Squared / N	750320.03
5 Corrected Sum of Squares (SS)	4.31
6 Variance (V) : SS/(N-1)	0.0582
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2412
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.20
12 Quality Index Lower (QL): (XBAR-L) / S	8.38
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 428 Lot Descr: KU I70 - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C252392	100.50	C252512	100.70	C252856	100.40	C252872	100.20	C252908	100.40
C253138	100.20	C255588	100.10	C255833	100.10	C265496	99.90	L087786	100.30
L097075	100.20	L211755	100.20	L211856	100.20	L213039	100.50	L213112	100.10
L213363	100.10	L213572	100.00	L213631	100.40	L214265	100.20	L214320	100.20
L214545	100.00	L214622	100.30	L214817	100.10	L215500	100.00	L216100	100.20
L216736	100.30	L216998	99.90	L217392	99.90	L217623	99.90	L217692	100.10
L217863	100.30	L218101	100.30	L218217	100.00	L219434	100.00	L219747	100.10
L220114	99.70	L220506	100.20	L220617	100.10	L220884	100.20	L221027	100.10
L222170	100.10	L222218	100.00	L222256	100.00	L222557	100.50	L225118	100.20
L225122	100.10	L225201	99.90	L225297	99.90	L225301	100.50	L225322	100.00
L225450	100.10	L225547	99.90	L225622	99.80	L225733	100.10	L225763	99.90
L226125	100.10	L226180	100.00	L226181	100.10	L226234	100.10	L226291	100.30
L226369	100.30	L226385	100.10	L226457	100.30	L226462	100.30	L226583	100.10
L226731	100.20	M427373	100.20	W117780	100.20	W119160	100.00	W119307	99.90
W119467	99.90	W120726	100.20	W120790	100.20	W120936	100.10	W121175	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.50
3 Sum of Squared Measurements	752103.93
4 Correction Factor (CF): Sum of Measurements Squared / N	752101.47
5 Corrected Sum of Squares (SS)	2.46
6 Variance (V) : SS/(N-1)	0.0332
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1823
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.20
12 Quality Index Lower (QL): (XBAR-L) / S	11.74
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 429 Lot Descr: KU I70 - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C256355	100.60	C256423	100.30	C261862	100.40	C261889	100.60	C261971	100.30
C262121	100.30	C262245	100.30	C262332	100.20	C262434	100.60	C262445	100.20
C262634	100.10	C262680	100.10	C267057	100.20	C267866	100.10	L227170	100.30
L227277	100.00	L227479	100.30	L227651	100.20	L227702	100.10	L227732	100.00
L233429	100.20	L233454	100.30	L233718	100.10	L233911	100.20	L234035	99.90
L234250	100.00	L234318	100.30	L234326	99.90	L234813	99.30	L235172	99.80
L235421	99.50	L235443	100.10	L237536	100.40	L237833	100.20	L237836	100.20
L237873	100.10	L237994	100.00	L238013	100.10	L238640	99.50	L238722	100.10
L238770	99.70	L238927	99.90	L238942	100.30	L239175	100.20	L239544	99.80
L239636	99.90	L239847	100.20	L241248	100.00	L241317	104.00	L241369	100.20
L241514	100.20	L241544	99.80	L241627	99.90	M402248	100.20	M402358	100.10
M402580	100.20	M402688	100.20	M403796	100.00	M403930	100.10	M404152	100.20
M404180	99.80	M404411	100.30	M404458	100.40	M404593	100.10	M404663	100.10
M404736	100.00	M416889	100.20	M416977	100.20	W121479	100.10	W121797	100.00
W122433	100.10	W122544	100.20	W122597	100.20	W123072	100.00	W123222	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7512.40
3 Sum of Squared Measurements	752500.74
4 Correction Factor (CF): Sum of Measurements Squared / N	752482.05
5 Corrected Sum of Squares (SS)	18.69
6 Variance (V) : SS/(N-1)	0.2526
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.5026
8 Sample Mean(XBAR): Sum X/N	100.17
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	3.65
12 Quality Index Lower (QL): (XBAR-L) / S	4.31
13 Estimate of Lot Percent NCF Above U (PU)	0.01
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.01
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 430 Lot Descr: KU I70 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C271941	100.10	C272072	100.30	C272316	100.20	C272478	100.40	C272522	100.10
C272724	100.20	C276597	100.50	C277382	100.00	C277586	100.20	C281548	100.20
C281727	100.30	C281808	99.90	C281826	99.90	C281894	100.20	C282002	100.10
C287236	100.00	C287355	99.80	C287430	99.90	C287833	100.00	C287866	100.30
C290101	100.00	C290149	100.20	C290159	99.90	C290225	100.30	C290240	99.90
C290396	99.90	C290478	100.10	C290621	99.90	C290649	100.30	C290667	100.00
C290803	100.00	C290854	100.00	C290891	100.00	C290989	100.20	C291010	100.10
C291038	99.90	C292413	100.20	C292422	100.20	C292639	99.90	L242463	100.10
L242783	100.10	L244069	100.20	L244141	100.00	L244207	99.70	L244237	99.80
L244245	100.20	L244368	99.90	L244543	100.00	M420315	100.00	M420541	100.00
M420710	100.00	M420820	99.90	W123340	100.20	W123491	100.00	W124026	100.50
W124069	100.10	W124498	100.10	W124652	100.00	W124659	99.90	W125644	100.10
W126425	100.00	W126494	100.20	W126563	100.30	W127247	99.70	W127309	100.10
W127404	100.10	W127800	100.00	W128357	100.10	W128522	99.80	W129082	100.00
W129123	99.90	W129189	100.40	W130082	100.20	W130232	100.70	W130308	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.90
3 Sum of Squared Measurements	751182.97
4 Correction Factor (CF): Sum of Measurements Squared / N	751180.46
5 Corrected Sum of Squares (SS)	2.51
6 Variance (V) : SS/(N-1)	0.0339
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1840
8 Sample Mean(XBAR): Sum X/N	100.08
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.44
12 Quality Index Lower (QL): (XBAR-L) / S	11.30
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 431 Lot Descr: KU I70 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C292657	100.10	C292691	101.40	C292805	100.10	C292970	99.80	C293019	100.00
C293222	99.90	C293243	100.00	C293352	100.00	C293390	100.00	C293538	100.20
C293667	99.80	C293673	100.60	C293765	99.80	C294186	100.40	C294474	100.40
C294586	100.10	C295872	100.30	C295955	100.10	C296181	100.30	C296413	100.40
C296613	100.20	C296642	100.30	C296658	100.50	C299205	100.50	C299220	100.60
C299361	100.50	L262251	99.90	L262485	100.20	L262577	100.20	L262794	99.90
L262898	100.40	L263194	100.20	L263266	100.10	L263329	100.00	L263364	100.10
L263484	99.70	L263738	100.40	L263766	99.90	L263831	99.90	L264043	99.90
L264570	100.10	L264630	100.00	L264902	99.80	L264938	99.70	L265030	100.20
L265115	100.10	L265133	99.90	L265157	100.20	L265220	100.30	L265391	100.20
L265465	100.00	L265729	100.30	L265972	100.00	L265990	100.10	L266064	100.00
L266220	100.20	L266463	100.10	L266776	100.10	L276516	100.10	M433962	100.10
M434014	100.20	M434271	100.10	M434320	100.20	M434366	100.30	W131562	100.20
W131626	99.90	W132038	100.10	W132145	100.60	W132202	100.50	W132733	99.60
W132937	100.10	W133649	100.30	W133785	100.10	W133828	100.20	W133978	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7511.20
3 Sum of Squared Measurements	752246.78
4 Correction Factor (CF): Sum of Measurements Squared / N	752241.67
5 Corrected Sum of Squares (SS)	5.11
6 Variance (V) : SS/(N-1)	0.0690
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2627
8 Sample Mean (XBAR): Sum X/N	100.15
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.04
12 Quality Index Lower (QL): (XBAR-L) / S	8.18
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 432 Lot Descr: KU I70 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 26
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C299719	100.30	C299776	100.50	C299900	100.50	C300066	100.50	C300272	100.20
C304526	100.00	C304642	100.30	C304674	100.60	C304706	100.30	C304845	100.00
C304936	100.30	C305003	100.50	C305041	100.30	C305119	100.40	C305261	100.50
C305343	100.40	C305632	100.60	C305679	100.40	C335329	100.00	C335474	99.80
C335499	100.00	C335834	99.80	L276552	99.90	L276823	100.00	L277543	99.90
L277544	100.00	L291949	99.90	L291979	99.90	L303869	99.70	L303898	99.80
L304310	99.70	L304376	99.80	L304567	100.00	L304569	100.00	L304593	100.00
L304605	99.70	L304623	100.00	L304872	99.80	L305084	99.80	L305219	99.80
L305288	99.90	L305783	99.80	L305866	99.80	L305999	99.90	L306542	99.70
L306697	99.90	L306781	99.90	L306804	99.80	L306974	99.90	L306985	99.70
L306996	100.00	L307569	99.80	M437652	100.20	M437785	100.20	M437864	99.70
M437893	100.10	M437920	100.10	M438016	99.90	M438110	100.00	M438225	99.80
W136057	100.10	W136059	100.10	W136329	100.10	W136334	100.50	W136369	100.30
W136463	100.00	W136528	100.00	W136576	100.00	W136694	100.10	W137284	100.10
W137336	100.30	W137464	100.10	W137504	100.20	W137638	100.10	W137746	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.30
3 Sum of Squared Measurements	750864.79
4 Correction Factor (CF): Sum of Measurements Squared / N	750860.25
5 Corrected Sum of Squares (SS)	4.54
6 Variance (V) : SS/(N-1)	0.0614
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2478
8 Sample Mean(XBAR): Sum X/N	100.06
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.84
12 Quality Index Lower (QL): (XBAR-L) / s	8.30
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 433 Lot Descr: KU I70 - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value For Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 27
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C298519	99.90	C336147	99.90	C336205	100.00	C336420	99.70	C336969	99.80
C337301	99.90	C337553	99.90	C337708	99.70	C337768	100.10	C337875	100.10
C338541	99.90	C338550	100.00	C338707	99.80	C338866	100.30	C339259	100.00
C339264	99.90	C339281	99.70	C339357	99.70	C339568	99.90	C339617	99.70
C339977	100.10	C339991	99.90	C340039	100.20	C340045	100.00	C340295	100.00
C340309	99.90	C340504	99.80	C340659	99.70	C340795	100.00	C340816	100.00
C340934	100.10	C341149	100.00	C341404	99.70	C341416	100.00	C341581	99.90
C341712	99.90	C341761	100.00	C342010	100.10	C342652	100.00	C342693	99.70
C342856	99.90	C342935	99.90	C343009	99.80	C343271	99.80	C343386	100.00
C343401	99.80	C343424	100.00	C343439	99.70	C343620	99.90	C343879	99.90
C343939	99.40	C343968	99.90	C344203	99.90	C344310	99.80	C344322	100.00
C344390	99.90	C344498	99.90	C344524	100.00	L307694	99.60	L307710	99.90
L307715	99.70	L308172	99.60	L308351	99.50	L308390	99.50	L308431	99.90
L308445	100.00	L308472	99.50	L308544	99.90	L308547	99.90	L308974	99.60
L309162	99.90	L309186	99.60	L309210	99.80	M446720	99.60	M446789	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7489.80
3 Sum of Squared Measurements	747963.56
4 Correction Factor (CF): Sum of Measurements Squared / N	747961.39
5 Corrected Sum of Squares (SS)	2.17
6 Variance (V) : SS/(N-1)	0.0294
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1714
8 Sample Mean(XBAR): Sum X/N	99.86
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	12.47
12 Quality Index Lower (QL): (XBAR-L) / S	10.88
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 434 Lot Descr: KU I70 - 12
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C342174	99.40	C342356	99.70	C342363	99.50	C342410	99.90	C351910	99.90
C352026	99.90	C352031	100.20	C352097	100.30	C352204	100.10	C352241	100.20
C352352	100.00	C352357	100.20	L309870	99.60	L310043	99.80	L310312	99.90
L310547	99.70	L310766	99.90	L310801	99.90	L310912	99.90	L311520	99.90
L311536	100.00	L311623	99.90	L311628	100.00	L312127	99.90	L312197	99.90
L312387	100.20	L312939	100.10	M447141	99.80	M447145	99.80	M447149	99.80
W149334	99.40	W149342	99.60	W149451	100.00	W149641	99.90	W149649	99.80
W149925	99.90	W150186	99.50	W150264	99.60	W150572	99.70	W150788	99.90
W150903	99.90	W150940	99.70	W151085	100.10	W151100	99.90	W151219	99.90
W151269	99.80	W151336	100.10	W151601	100.00	W151734	99.90	W151920	100.10
W151965	99.80	W151984	100.00	W152042	100.10	W152078	100.00	W152162	99.60
W152165	99.90	W152191	100.10	W152205	100.00	W152312	99.90	W152458	100.10
W152623	99.90	W153068	100.30	W153647	100.10	W153789	100.00	W153913	100.00
W153933	99.90	W153989	100.00	W154038	100.30	W154125	100.20	W154185	99.90
W154286	99.80	W154411	99.70	W154423	99.80	W154469	99.80	W154480	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.30
3 Sum of Squared Measurements	748663.51
4 Correction Factor (CF): Sum of Measurements Squared / N	748660.60
5 Corrected Sum of Squares (SS)	2.91
6 Variance (V) : SS/(N-1)	0.0393
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1984
8 Sample Mean (XBAR) : Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.53
12 Quality Index Lower (QL): (XBAR-L) / S	9.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 435 Lot Descr: KU I70 - 13
 In Service Population: 650 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 29
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C298419	100.20	C298481	100.20	L268249	100.10	L268265	100.50	L268267	99.50
L268293	100.10	L268299	100.20	L268327	99.90	L268490	100.10	L268492	99.80
W155043	100.00	W155055	100.00	W155064	99.90	W155120	100.00	W155129	100.00
W155140	99.90	W155156	99.70	W155192	99.50	W155193	99.80	W155225	99.90
W155255	99.70	W155256	99.90	W155276	99.80	W155362	99.70	W155418	99.90
W155428	99.90	W155441	99.50	W155462	99.60	W155468	100.10	W155475	99.50
W155485	100.00	W155531	99.70	W155550	99.80	W155560	99.70	W155566	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3496.00
3 Sum of Squared Measurements	349202.26
4 Correction Factor (CF): Sum of Measurements Squared / N	349200.46
5 Corrected Sum of Squares (SS)	1.80
6 Variance (V) : SS/(N-1)	0.0530
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2303
8 Sample Mean (XBAR): Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.18
12 Quality Index Lower (QL): (XBAR-L) / S	8.19
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F1S120V15AC100 Model Number: JS Division: 01 Sample Lot: 436 Lot Descr: KU J - 1
 In Service Population: 33 Sample Quantity: 5 Meters Tested: 5 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 30
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
W045337	100.10	W045354	98.40	W046125	99.10	W048307	99.60	W049650	99.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	5
2 Sum of Measurements: (Sum X)	496.50
3 Sum of Squared Measurements	49304.03
4 Correction Factor (CF): Sum of Measurements Squared / N	49302.45
5 Corrected Sum of Squares (SS)	1.58
6 Variance (V) : SS/(N-1)	0.3950
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.6285
8 Sample Mean(XBAR): Sum X/N	99.30
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.30
12 Quality Index Lower (QL): (XBAR-L) / S	2.07
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	9.80
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J3S Division: 01 Sample Lot: 437 Lot Descr: KU J3 - 1
 In Service Population: 5,901 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: FAIL

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 31
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C206293	100.40	C206332	100.30	C207991	100.20	C208904	99.90	C208951	100.20
C208981	100.50	C210080	100.60	C210159	100.20	C210173	100.10	C210229	100.30
C210483	100.30	C210640	100.30	C211103	99.90	C211927	100.00	C212265	100.20
C212845	100.00	C212976	100.20	C212988	100.00	C213108	100.10	C213729	99.40
C213739	99.70	C214857	99.20	C214944	100.00	C215742	100.00	C216921	100.00
C216925	100.10	C217024	99.80	C217478	98.50	C218541	100.00	C220181	100.40
C221760	99.70	C221880	100.10	C222448	100.10	C224139	99.60	C224168	99.60
C224369	99.90	C224426	99.60	C224592	98.80	C224601	99.80	C224671	99.70
C225971	100.10	C226037	99.90	C226067	100.20	C226211	100.00	C226274	99.90
C226282	99.70	M372169	99.90	M387276	99.40	W092978	100.40	W093320	100.30
W093712	100.60	W094463	100.00	W095384	99.90	W095712	99.90	W096053	100.10
W096087	99.80	W096268	99.90	W096432	100.00	W096773	100.20	W097044	71.00
W097069	100.10	W097339	99.90	W097358	99.80	W097384	100.10	W097546	99.70
W097819	100.20	W097993	100.50	W098424	99.70	W099965	100.10	W101214	99.80
W101220	99.80	W101598	99.80	W101679	100.30	W102945	100.40	W103222	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7469.00
3 Sum of Squared Measurements	744650.28
4 Correction Factor (CF): Sum of Measurements Squared / N	743812.81
5 Corrected Sum of Squares (SS)	837.47
6 Variance (V) : SS/(N-1)	11.3171
7 Estimate of Lot Standard Deviation(S): SQRT of V	3.3641
8 Sample Mean(XBAR): Sum X/N	99.59
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	0.72
12 Quality Index Lower (QL): (XBAR-L) / S	0.47
13 Estimate of Lot Percent NCF Above U (PU)	23.61
14 Estimate of Lot Percent NCF Below L (PL)	31.96
15 Total Estimate Percent NCF. In Lot (P): PU+PL	55.57
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	FAIL
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 438 Lot Descr: KU J4 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 32
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C228747	100.20	C229010	100.10	C233264	100.10	C233412	99.90	C235509	100.60
C235526	100.30	C235550	99.50	C239555	99.70	C239764	100.20	C239818	100.20
C240044	99.90	C244100	100.30	C244145	100.60	C244303	100.20	C244681	100.20
C244697	99.70	C244720	99.90	C244752	99.80	C248831	100.10	C248948	100.30
C253312	100.50	C253402	100.20	C253512	99.60	C253772	100.60	C253897	99.60
C253899	99.70	C254014	100.20	C254104	100.00	C263048	100.10	C263063	99.50
C263072	100.30	C263369	100.10	C263409	100.20	M351994	100.00	M352270	100.70
M373879	100.50	M381508	99.60	M381776	99.50	M381932	99.70	M381937	99.70
M387867	100.00	M388263	100.10	M391918	100.50	M394070	99.70	M394180	100.20
M394195	100.00	M409083	99.50	M409395	99.60	M410769	99.80	M411199	99.80
M412660	99.70	M412693	99.80	M412718	99.30	M412766	99.70	M412931	99.70
M413027	99.90	M426574	99.50	M427049	99.30	M452919	99.50	M452992	100.20
W104918	100.30	W105540	100.20	W108700	99.60	W109463	99.90	W109506	99.50
W109919	100.40	W109935	99.60	W111436	99.80	W111726	100.10	W113300	99.90
W113543	100.20	W113569	100.00	W113802	100.40	W113826	99.90	W118000	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.70
3 Sum of Squared Measurements	749548.41
4 Correction Factor (CF): Sum of Measurements Squared / N	749540.07
5 Corrected Sum of Squares (SS)	8.34
6 Variance (V) : SS/(N-1)	0.1127
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3357
8 Sample Mean (XBAR) : Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.05
12 Quality Index Lower (QL): (XBAR-L) / s	5.87
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 439 Lot Descr: KU J4 - 2
 In Service Population: 3,702 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C263473	99.30	C263508	99.50	C263570	100.00	C263572	100.00	C263582	99.70
C263584	99.90	C263673	100.30	C263712	99.80	C263806	100.10	C267943	99.80
C267976	100.00	C267979	100.20	C268172	99.90	C268344	100.00	C268497	99.60
C268521	99.70	C268527	100.10	C268620	100.20	C268636	99.80	C268645	99.60
C268647	100.20	C268651	100.10	C268702	99.70	C268777	99.30	C268797	99.90
C268886	100.20	C268906	99.90	C268945	99.90	C268994	99.70	C269019	100.30
C342503	100.00	C351304	99.70	C351418	100.00	C351431	100.20	C351471	99.60
C351515	99.40	C351637	99.80	C351660	99.80	C351671	99.70	L240077	99.90
L240217	99.50	L240277	99.90	L240391	100.10	L240467	99.70	L240580	99.50
L240596	99.80	L241780	99.60	L241805	99.60	L241824	99.50	L241826	100.20
L241990	99.80	L242018	99.80	L242019	99.90	L242233	100.00	L242326	99.10
M415411	100.10	M415499	99.70	M415574	99.70	M415620	100.10	M415627	99.80
M415670	99.90	M415727	99.90	M415783	100.00	M415811	99.80	M415820	99.90
M415874	99.70	M415966	100.00	M416075	99.90	M416111	99.60	M416181	99.90
W122842	99.60	W122891	99.90	W123547	99.90	W123601	99.30	W123606	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7487.00
3 Sum of Squared Measurements	747406.94
4 Correction Factor (CF): Sum of Measurements Squared / N	747402.25
5 Corrected Sum of Squares (SS)	4.69
6 Variance (V) : SS/(N-1)	0.0633
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2517
8 Sample Mean(XBAR): Sum X/N	99.83
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.64
12 Quality Index Lower (QL): (XBAR-L) / S	7.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 440 Lot Descr: KU J5 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C273215	100.10	C273228	99.80	C273383	100.00	C273528	100.10	C273554	99.70
C273765	99.60	C273770	99.50	C273801	100.10	C274172	100.10	C274184	99.70
C277784	99.90	C277786	100.10	C278646	100.20	C278653	100.10	C278692	99.90
C282519	100.00	C282568	100.00	C283051	99.60	C283320	99.80	C287890	100.40
C288138	99.80	C288152	99.80	C288212	100.20	C288220	99.80	C288399	100.20
L242965	100.10	L243391	99.60	L244881	99.90	L244976	100.40	L245095	100.30
L245197	100.20	L245997	100.00	L246006	99.80	L246189	100.40	L246218	100.40
L246328	100.30	L246339	100.00	L246623	100.10	L246695	99.60	L246852	100.20
L247070	99.70	L247523	100.20	L247569	100.00	L247753	99.40	L247914	99.90
L248117	99.60	L248125	99.30	L248455	100.10	L248616	99.70	L248622	99.50
L248653	99.70	L248670	99.50	L248817	100.10	L249061	99.30	L249170	99.50
L250601	100.10	L250947	100.10	L251140	99.80	L251299	100.00	L251330	100.10
L251475	99.80	L251897	99.60	L252477	100.10	L252650	99.90	L252784	99.90
L252828	99.80	L253022	100.00	W124172	100.20	W124253	100.10	W125245	99.40
W125321	100.50	W125811	100.00	W126954	99.90	W126999	99.90	W127023	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.50
3 Sum of Squared Measurements	748906.05
4 Correction Factor (CF): Sum of Measurements Squared / N	748900.40
5 Corrected Sum of Squares (SS)	5.65
6 Variance (V) : SS/(N-1)	0.0763
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2762
8 Sample Mean(XBAR): Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.51
12 Quality Index Lower (QL): (XBAR-L) / s	6.97
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 441 Lot Descr: KU J5 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C283833	99.80	C283869	100.10	C283949	99.80	C288887	99.70	C288889	99.60
C291252	100.60	C291672	100.10	C291686	100.20	C291735	100.30	C291862	100.40
C291995	100.50	C292008	100.30	C292248	100.80	C292259	100.00	C292313	99.50
L253177	100.30	L253288	100.40	L253296	100.20	L253318	99.60	L253405	99.90
L253810	99.80	L253857	100.00	L254040	100.10	L254061	100.10	L254458	100.00
L254600	99.80	L255066	100.30	L255105	100.20	L255131	100.10	L255164	100.10
L255227	100.10	L255622	100.00	L255687	100.00	L255820	100.50	L256599	100.20
L256730	99.80	L256913	100.10	L257055	99.90	L257202	100.10	L257404	99.60
L257502	100.20	L257751	99.80	L258058	100.40	L258317	99.90	L258362	100.30
L258512	99.90	L258621	99.90	L258907	99.90	L258948	99.90	L259153	100.20
L259263	99.80	L259307	99.70	L259476	100.30	L259829	100.00	L259832	99.60
M421563	100.10	M422755	99.80	M422944	100.00	M423158	100.00	M423268	99.90
M423811	100.30	M424044	100.40	M424248	100.00	M424311	100.00	M424496	99.70
M424646	99.70	W127577	100.10	W127596	99.90	W127717	100.20	W128065	99.90
W128323	101.20	W128327	99.80	W128765	100.30	W128782	99.50	W128792	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.70
3 Sum of Squared Measurements	750746.69
4 Correction Factor (CF): Sum of Measurements Squared / N	750740.18
5 Corrected Sum of Squares (SS)	6.51
6 Variance (V) : SS/(N-1)	0.0879
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2965
8 Sample Mean(XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.58
12 Quality Index Lower (QL): (XBAR-L) / S	6.91
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 442 Lot Descr: KU J5 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 36

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C284075	99.90	C284117	100.10	C284165	100.10	C294925	100.20	C294980	100.10
C295408	100.30	C295455	100.20	C295484	99.80	C295507	100.70	C295542	100.00
C295667	100.20	C295744	100.40	C296982	99.90	C297129	100.20	C297175	99.90
C297399	99.90	C297429	100.20	C297441	99.80	C297514	100.00	C297528	99.80
C297601	99.90	C297706	99.70	C297816	99.60	C297823	99.80	C297937	99.80
C297958	99.90	L260503	99.80	L260839	99.80	L260899	99.90	L260989	99.90
L261123	99.80	L261318	99.80	L261501	99.60	L261513	99.90	L261677	100.10
L266808	99.90	L266818	100.00	L266964	100.10	L266997	100.50	L267087	100.20
L267108	100.00	L267278	100.10	L267595	99.90	L267684	99.90	L269331	99.50
L269465	99.80	M424784	100.50	M428702	100.20	M428775	100.40	M428793	100.30
M428825	100.10	M428898	100.40	M428969	99.90	M429649	100.10	M429720	100.00
M429723	100.10	M429916	100.40	M429991	100.20	M430170	100.30	M430297	99.80
M430378	99.96	M430599	99.80	M430828	100.30	M430847	99.70	M430909	100.30
M430949	100.20	M432316	100.00	M432324	100.70	W129622	99.90	W129778	100.30
W130061	100.00	W130545	100.30	W130884	99.90	W130977	100.20	W131109	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.66
3 Sum of Squared Measurements	750536.87
4 Correction Factor (CF): Sum of Measurements Squared / N	750532.09
5 Corrected Sum of Squares (SS)	4.78
6 Variance (V) : SS/(N-1)	0.0646
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2541
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.73
12 Quality Index Lower (QL): (XBAR-L) / S	8.01
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 443 Lot Descr: KU J5 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C303069	100.10	C303098	99.70	C303206	99.60	C303450	100.00	C303861	99.80
C303963	99.90	C304116	100.00	C304120	100.10	C304126	99.70	C304257	100.00
C304313	99.80	C304386	100.00	C304406	99.80	C306037	99.40	C306238	100.00
C306254	99.70	C306312	99.80	C306431	99.80	C306436	99.90	C306479	99.40
L269664	99.30	L269784	99.50	L270092	99.60	L270093	99.80	L270465	99.70
L270904	100.00	L270975	99.80	L271141	100.30	L271272	100.00	L271416	99.50
L271462	100.00	L271508	100.10	L271554	99.90	L271556	99.70	L271557	100.00
L271949	100.00	L272081	99.80	L272134	99.40	L272323	99.70	L272386	99.60
L272499	99.60	L272797	99.90	L272837	99.80	L273750	100.00	L273943	99.70
L274206	100.40	L274487	100.00	L274562	99.70	L274882	100.10	L274889	100.00
L275209	99.90	L275387	99.90	L275529	100.30	L275671	99.90	L275731	100.00
L275795	99.60	L275945	100.10	L275984	99.80	L276013	100.10	L276075	99.90
L276180	100.00	L276204	99.80	L276260	99.90	L276412	99.80	M432738	100.00
M432743	100.00	M432821	100.20	M432896	100.60	M433053	99.80	M433278	99.40
M433461	100.30	M433594	100.20	P003429	100.10	P005119	100.10	P005150	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7490.90
3 Sum of Squared Measurements	748185.55
4 Correction Factor (CF): Sum of Measurements Squared / N	748181.10
5 Corrected Sum of Squares (SS)	4.45
6 Variance (V) : SS/(N-1)	0.0601
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2451
8 Sample Mean (XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.65
12 Quality Index Lower (QL): (XBAR-L) / S	7.66
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200

Model Number: J5S

Division: 01

Sample Lot: 444

Lot Descr: KU J5 - 5

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C306519	100.00	C306625	99.70	C306753	99.90	C306980	100.10	C307418	99.70
C307619	99.90	C307910	99.80	C308026	100.10	C308154	99.70	C308171	99.80
C308177	99.50	C308334	100.90	C308534	100.00	C308547	99.70	C308764	100.10
C308930	99.80	C309211	99.80	C309307	99.60	C309396	99.90	C309462	99.90
C309522	100.20	C309572	99.80	C309798	99.90	C309862	99.90	C309946	99.70
C310245	100.20	C310535	100.20	C310560	100.00	L277584	99.90	L277749	99.60
L277803	99.40	L277858	100.00	L277928	99.50	L278073	99.90	L278427	99.50
L278566	99.50	L278699	99.80	L278750	99.60	L278924	99.90	L279047	99.80
L279111	99.50	L279301	99.60	L279727	99.80	L280334	99.50	L280347	99.80
L280416	100.00	L280502	99.60	L280516	99.80	L280533	100.00	L280778	99.80
L280987	100.20	L281060	99.50	L281082	99.80	L281085	99.80	L281414	100.10
L281652	99.90	L281654	99.50	L281670	100.10	L281966	99.70	L282015	100.00
L282184	99.80	L282249	99.70	L282549	99.50	L282666	99.60	L282790	100.20
L282807	99.80	L282844	99.60	L282876	100.00	L282902	100.10	L283266	99.80
L283281	99.70	L283384	99.80	M436947	99.90	M438642	99.90	M438720	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7487.40
3 Sum of Squared Measurements	747486.36
4 Correction Factor (CF): Sum of Measurements Squared / N	747482.12
5 Corrected Sum of Squares (SS)	4.24
6 Variance (V) : SS/(N-1)	0.0573
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2395
8 Sample Mean (XBAR): Sum X/N	99.83
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.05
12 Quality Index Lower (QL): (XBAR-L) / S	7.65
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 445 Lot Descr: KU J5 - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 39

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C310863	99.30	C310998	100.00	C311297	99.10	C311595	99.80	C311844	100.50
C311886	100.00	C312403	99.60	C312601	99.40	C312785	100.10	C312906	100.00
C313163	99.80	C313191	99.70	C313236	100.30	C313331	100.00	C313382	100.20
C313407	99.90	C313774	99.80	C313825	99.90	C313886	100.00	C313951	99.90
C314017	99.90	C314264	100.20	C314421	100.20	C314555	99.80	C314565	100.00
C314739	100.10	C314837	100.10	C314987	99.80	C315228	99.70	C315284	99.50
C315862	99.70	C315907	100.10	C315972	100.40	C316150	100.10	C316160	100.00
C316361	99.40	C316375	99.90	C316668	100.00	C316877	100.30	C317242	100.00
C317458	100.00	C317523	100.10	C317647	99.60	C317902	99.60	C317919	100.40
C317967	100.00	C318005	100.00	C318192	99.60	C318233	99.90	C318349	100.20
C318377	99.80	C318541	100.00	C318566	100.10	C318613	100.20	C318897	99.60
C318925	100.20	C319018	99.90	C319032	99.90	C319135	99.80	C319207	100.50
M437049	99.90	W138706	99.80	W138796	99.90	W138823	99.70	W139003	99.70
W139178	100.10	W139209	100.10	W139448	99.70	W139480	100.40	W139544	99.90
W139626	99.70	W139887	100.00	W139961	99.00	W140000	99.90	W140030	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.60
3 Sum of Squared Measurements	748726.64
4 Correction Factor (CF): Sum of Measurements Squared / N	748720.55
5 Corrected Sum of Squares (SS)	6.09
6 Variance (V) : SS/(N-1)	0.0823
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2870
8 Sample Mean (XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.27
12 Quality Index Lower (QL): (XBAR-L) / s	6.67
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 446 Lot Descr: KU J5 - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C319266	99.80	C319459	99.80	C319518	99.80	C319546	100.10	C319565	99.70
C319638	100.20	C320089	100.10	C320102	99.70	C320323	99.70	C320441	99.90
C325991	100.10	C326071	100.10	C326113	100.30	C326247	100.40	C326401	100.10
C326618	100.40	C326648	99.70	C326696	100.30	C326755	100.20	C326891	99.80
C327097	100.00	C327260	100.10	C327521	100.10	C327568	100.20	L284529	100.30
L284754	99.60	L285135	99.80	L285303	99.70	L285563	99.60	L285714	99.80
L285928	99.70	L285940	100.30	L286160	99.30	L286168	100.00	L286287	100.00
L286336	100.10	L286583	100.10	L286653	99.80	L286691	99.60	L286712	100.40
L287183	99.80	L287255	100.00	L287320	99.80	L287339	99.90	L287340	100.00
L287478	99.90	L287537	99.80	L291448	99.80	L291471	99.50	L291649	99.70
L291893	99.80	M439820	99.90	M439854	99.80	M439881	100.00	M439924	99.50
M440041	100.00	M440066	99.90	M440073	100.10	M440682	99.60	M440724	99.70
W140363	99.90	W140596	99.90	W140698	99.50	W140845	100.10	W140880	99.70
W141358	100.00	W141476	100.10	W141483	99.80	W141591	100.10	W141658	99.90
W141705	100.00	W141994	99.90	W142154	99.60	W142187	99.30	W142398	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.90
3 Sum of Squared Measurements	748585.09
4 Correction Factor (CF): Sum of Measurements Squared / N	748580.67
5 Corrected Sum of Squares (SS)	4.42
6 Variance (V) : SS/(N-1)	0.0597
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2443
8 Sample Mean (XBAR) : Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	8.57
12 Quality Index Lower (QL): (XBAR-L) / s	7.80
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 447 Lot Descr: KU J5 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C327650	99.90	C327861	99.60	C327985	100.00	C328049	100.00	C328317	99.90
C328528	99.40	C328556	99.40	C328681	99.70	C329109	99.50	C329539	100.00
C329645	99.70	C329727	100.20	C329773	100.00	C329798	99.70	C329811	99.80
C329812	99.60	C329868	99.80	C330012	100.10	C330062	100.00	C330207	99.70
C330336	99.80	C330618	100.00	C330619	99.80	C330633	99.70	C330740	99.90
L292486	100.00	L292514	99.80	L293063	99.70	L293083	99.80	L293227	99.60
L293433	99.90	L293495	100.10	L293590	100.10	L293749	100.10	L293757	99.90
L293851	99.60	L293917	100.00	L294261	100.00	L294381	100.00	L294400	100.00
L294505	100.40	L294555	100.40	L294564	99.90	L294641	100.10	L294695	99.80
L294774	99.70	L295025	100.00	L295281	99.80	L295367	99.80	L295492	100.10
L295625	100.00	L295861	100.40	L295995	99.60	L296239	99.90	L296444	99.90
L296451	100.20	L296870	99.90	L297154	99.70	M442611	99.70	M442918	99.80
M442952	100.00	M443121	99.80	M443271	99.90	M443313	100.50	M443373	99.80
M443479	99.80	M443515	100.20	M443691	99.60	M443992	99.90	M444067	99.90
M444110	99.80	M444261	100.20	W144790	100.70	W144807	100.70	W144860	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.80
3 Sum of Squared Measurements	748765.36
4 Correction Factor (CF): Sum of Measurements Squared / N	748760.51
5 Corrected Sum of Squares (SS)	4.85
6 Variance (V) : SS/(N-1)	0.0655
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2559
8 Sample Mean(XBAR): Sum X/N	99.92
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.14
12 Quality Index Lower (QL): (XBAR-L) / S	7.49
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200

Model Number: J5S

Division: 01

Sample Lot: 448

Lot Descr: KU J5 - 9

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C331280	99.50	C331303	99.60	C331307	99.80	C331523	99.90	C331706	100.40
C349355	99.60	C349722	99.40	C349793	99.30	C349865	99.90	C349903	99.70
C350077	100.20	C350145	99.80	C350336	99.20	C350687	99.40	C350752	99.70
C350875	99.60	C350926	98.70	C351096	100.00	C353104	99.40	C353171	99.60
C353196	99.60	C353289	99.90	C353552	100.00	C353594	99.80	C353607	99.80
C353764	100.00	C353954	100.00	C354058	99.60	L313301	99.40	L313578	99.40
L313964	99.60	L314018	99.70	L315028	99.80	L315217	98.60	L315335	99.20
L315380	100.60	L315385	100.00	L315490	100.10	L315581	99.60	L315631	99.20
L315763	100.30	L316014	98.60	L316049	100.00	L316068	99.70	L316308	99.80
L316326	99.70	L316518	99.40	L316618	99.50	L316853	100.00	L316986	99.20
L317215	99.10	L317227	99.30	L317328	100.00	M437261	100.50	M437392	100.10
M437571	100.30	M445984	100.10	M446068	100.40	M446207	100.20	M446495	100.10
W145050	100.50	W145084	99.90	W145119	100.10	W145210	100.30	W145275	100.10
W145493	99.80	W145536	100.00	W145570	100.20	W145627	99.70	W145759	100.40
W145768	99.90	W146224	99.60	W146576	100.20	W146595	100.10	W146676	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.00
3 Sum of Squared Measurements	746816.86
4 Correction Factor (CF): Sum of Measurements Squared / N	746803.41
5 Corrected Sum of Squares (SS)	13.45
6 Variance (V) : SS/(N-1)	0.1817
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4263
8 Sample Mean (XBAR) : Sum X/N	99.79
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.19
12 Quality Index Lower (QL): (XBAR-L) / S	4.19
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 449 Lot Descr: KU J5 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 43

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C354627	100.20	C354798	99.80	C354972	99.90	C354983	97.60	C355367	99.70
C355452	99.70	C355602	99.40	C355743	99.60	C355761	99.10	C355804	99.20
C355937	100.40	C355948	100.00	C356065	99.80	C356702	99.60	C356710	100.00
C356812	99.70	C357533	100.20	C357739	99.60	C357748	100.20	C358027	99.60
C358134	99.90	C358273	99.90	C358570	99.90	C358579	99.80	C359089	100.90
C359215	100.00	C359229	99.70	C359481	100.30	C359613	100.80	C359751	100.00
C359871	99.70	C359873	98.60	C359953	99.40	C360140	99.80	C360244	99.00
C360252	99.60	C360313	100.10	C360375	99.60	C360477	99.83	C360529	99.80
C360706	99.60	C360781	99.40	C360784	99.30	C360816	99.60	C360835	98.50
C361299	99.70	C361333	99.50	C361369	100.10	C361491	99.70	C361507	100.00
C361548	99.90	C361863	99.40	C361963	99.80	C361964	99.40	C362000	99.60
C362126	99.60	C362192	99.90	C362193	100.10	C362242	99.70	C362625	99.70
C362749	100.00	C363372	99.10	C363445	100.00	C363461	99.50	C363507	99.50
C363534	99.70	C363569	99.50	C363611	99.40	C363748	99.20	C364110	99.70
C364359	100.00	C364522	100.00	C364588	99.50	C364590	99.50	C364691	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7476.73
3 Sum of Squared Measurements	745368.88
4 Correction Factor (CF): Sum of Measurements Squared / N	745353.22
5 Corrected Sum of Squares (SS)	15.66
6 Variance (V) : SS/(N-1)	0.2116
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4600
8 Sample Mean(XBAR) : Sum X/N	99.69
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.02
12 Quality Index Lower (QL): (XBAR-L) / S	3.67
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.01
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.01
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J5S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 450
Pass/ Fail: PASS

Lot Descr: KU J5 - 11

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C364926	98.30	C365011	99.50	C365132	99.70	C365133	99.50	C365210	99.90
C365454	100.00	C365464	99.90	C366505	99.30	C366518	99.50	C366538	99.70
C366628	99.50	C366674	99.50	C366762	99.50	C366810	99.90	C366885	98.90
C366947	99.70	C367030	99.20	C367102	100.10	C367112	99.90	C367346	100.20
C367376	99.80	C367522	100.10	C367526	99.70	C367938	99.50	C367955	100.30
C367993	99.40	C368319	99.80	C370352	100.20	C370676	100.00	C371232	99.90
C371252	99.50	C371292	99.90	C371302	99.60	C371697	99.70	C371700	99.60
C371928	99.90	C372478	99.20	C372617	99.40	C372694	99.20	C373087	99.90
C373096	99.60	C373179	100.10	C373237	99.80	C373487	99.80	C373575	99.80
C373660	99.80	C373721	100.10	M448093	99.60	M448450	99.60	M448681	99.40
M448760	99.60	M448854	99.70	M449125	99.80	M449165	99.90	M449250	99.60
M449259	99.70	M449295	99.90	M449375	99.70	M449379	99.90	M449382	99.60
M449405	99.30	M449620	99.80	M450223	99.70	M450368	99.50	M450418	99.50
M450519	99.60	M450560	100.20	M450567	99.70	M450600	100.20	M450652	99.90
M450710	99.80	M450719	99.10	M450841	99.60	M450883	99.70	M450884	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7476.40
3 Sum of Squared Measurements	745295.00
4 Correction Factor (CF): Sum of Measurements Squared / N	745287.43
5 Corrected Sum of Squares (SS)	7.57
6 Variance (V) : SS/(N-1)	0.1023
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3199
8 Sample Mean(XBAR): Sum X/N	99.69
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.24
12 Quality Index Lower (QL): (XBAR-L) / s	5.27
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 451 Lot Descr: KU J5 - 12
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C373899	99.80	C374007	99.60	C374264	99.70	C374283	99.90	C374322	99.40
C374516	99.60	C374532	99.40	C374619	99.90	C374831	99.80	C375236	99.90
C375511	100.10	C375514	99.60	C375601	100.30	C375625	99.90	C375813	99.70
C375874	99.70	C376012	99.90	C376167	99.80	C376270	99.90	C376513	99.90
C376580	99.90	C376644	100.00	C376751	99.70	C377145	99.90	C377493	100.00
C377500	99.70	C377626	99.90	C377966	99.70	C378003	99.80	C378239	100.10
C378320	99.70	C378334	99.70	C378440	100.20	C378441	99.50	C378789	99.70
C378891	99.60	C378920	99.90	C378948	99.70	C379072	99.80	C379090	99.70
C379369	99.80	C379485	99.80	C379607	99.70	C379609	99.70	C379811	99.60
C380059	99.80	C380064	99.50	C380117	100.10	C380333	100.00	C380439	100.00
C383487	99.80	C383546	99.80	C383637	99.80	C383733	99.70	C384050	99.80
C384094	99.90	C384141	99.70	C384385	100.20	C384397	99.90	C384472	100.00
C384605	99.60	C385143	99.80	C385172	99.60	C385403	99.90	C385713	100.00
C385923	100.10	C385959	99.90	C386092	99.40	C386266	100.10	C386337	99.80
C386785	100.10	C386801	100.30	C386871	99.60	C386977	100.00	C387178	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.80
3 Sum of Squared Measurements	747365.24
4 Correction Factor (CF): Sum of Measurements Squared / N	747362.32
5 Corrected Sum of Squares (SS)	2.92
6 Variance (V) : SS/(N-1)	0.0394
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1985
8 Sample Mean(XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.96
12 Quality Index Lower (QL): (XBAR-L) / S	9.19
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J5S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 452
Pass/ Fail: PASS

Lot Descr: KU J5 - 13

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 46
Run Date: 01/02/2012
Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C387541	100.00	C387569	99.90	C387832	99.90	C387833	99.90	C387860	99.80
C387879	99.70	C387966	99.90	C387972	99.60	C387981	99.30	C388207	99.70
C388217	100.20	C388305	100.00	C388468	100.10	C388500	99.20	C388641	99.70
C388758	99.70	C388772	100.10	C388787	99.90	C388814	100.20	C388886	99.90
C389074	100.00	C389568	100.10	C390001	99.40	C390232	99.80	C390309	99.80
C391717	100.10	C391963	99.90	C392000	100.20	C392170	99.90	C392185	100.20
C392298	100.30	C392411	100.20	C392482	100.20	C392552	99.70	C392733	99.80
C392808	99.70	C393039	99.80	C393078	99.90	C393088	99.50	C393090	100.10
C393166	100.00	C393339	99.70	C393458	100.10	C393622	99.90	C394055	99.80
C394187	100.00	C394486	100.00	C394692	100.00	C394752	100.20	C394946	100.20
C394977	99.90	C395060	100.20	C395345	100.00	C395394	100.20	C395831	100.40
C395957	100.00	C395969	100.50	C396052	100.10	C396097	99.90	C396506	100.00
C396762	99.80	C396785	99.90	C396959	100.20	C397489	99.60	C397540	99.90
C398031	100.80	C398077	100.00	C398160	100.10	C398189	100.00	C398460	100.00
C398533	99.70	C398571	100.30	C398850	100.00	C398937	100.30	C399033	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.60
3 Sum of Squared Measurements	749325.20
4 Correction Factor (CF): Sum of Measurements Squared / N	749320.15
5 Corrected Sum of Squares (SS)	5.05
6 Variance (V) : SS/(N-1)	0.0682
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2611
8 Sample Mean(XBAR): Sum X/N	99.95
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.83
12 Quality Index Lower (QL): (XBAR-L) / s	7.49
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (E): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 453 Lot Descr: KU J5 - 14
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C399245	100.00	C399301	100.20	C399538	100.50	C399593	100.40	C399943	99.90
C399977	99.60	C400048	100.10	C400163	100.50	C400174	100.00	C400186	99.40
C400229	99.80	C400662	100.00	C400792	100.00	C400963	100.20	C401003	99.80
C401101	99.60	C401201	99.60	C401360	99.10	C401362	100.50	C401390	98.80
C401582	99.90	C401752	100.30	C401806	99.40	C401976	99.50	C402013	100.10
C402088	100.20	C402487	99.60	C402723	100.00	C402763	100.00	C402847	99.50
C403141	99.60	C403257	100.40	C403275	99.90	C403470	99.80	C403555	99.50
C403593	100.30	C403681	99.90	C404026	100.00	C404352	99.70	C404468	99.80
C404571	100.00	C404575	99.70	C404590	100.00	C404644	100.20	C404803	100.00
C404838	100.00	C405150	100.30	C405231	100.20	C405446	99.50	C405459	99.30
C405752	99.00	C405909	99.30	C406203	99.80	C410068	99.60	C410252	99.60
C410442	98.50	C410518	99.80	C410682	99.90	C410745	99.90	C410757	99.60
C410871	99.60	C410954	99.30	C411027	99.90	C411071	100.00	C411236	99.30
C411827	99.50	C411887	98.40	C411960	99.30	C412141	98.90	C412191	99.40
C412331	98.80	C412421	98.90	C412642	99.70	C412694	99.80	C413134	99.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7479.60
3 Sum of Squared Measurements	745940.96
4 Correction Factor (CF): Sum of Measurements Squared / N	745925.55
5 Corrected Sum of Squares (SS)	15.41
6 Variance (V) : SS/(N-1)	0.2083
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4564
8 Sample Mean (XBAR): Sum X/N	99.73
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.98
12 Quality Index Lower (QL): (XBAR-L) / S	3.79
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 454 Lot Descr: KU J5 - 15
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 48

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C413319	99.40	C413366	99.80	C413377	99.10	C413502	99.90	C413734	100.10
C413871	99.50	C414093	100.10	C414098	99.70	C414135	99.70	C414234	99.80
C414379	100.40	C414465	99.60	C414475	99.50	C414526	100.30	C414576	99.10
C414720	99.60	C414729	99.50	C414938	98.80	C415184	99.50	C415259	100.10
C415289	98.60	C415394	99.40	C415614	100.00	C415720	99.50	C415728	98.70
C417779	99.50	C418172	99.60	C418323	99.20	C418703	99.60	C418801	99.00
C418848	99.10	C418883	100.20	C418934	99.30	C418991	100.20	C419389	98.80
C419516	100.00	C419606	100.00	C420363	100.10	C420670	99.60	C420802	99.90
C420936	99.60	C421025	99.50	C421383	99.30	C421462	98.80	C421607	99.20
C421816	99.80	C421858	99.10	C421864	99.90	C422327	99.50	C422413	99.70
C422534	99.60	C422618	99.60	C422647	99.60	C422752	99.40	C422948	99.20
C423142	99.20	C423145	100.00	C423292	98.60	C423354	99.40	C423371	98.80
C423419	99.20	C423577	99.40	C423734	99.30	C423990	99.80	C424004	99.80
C424201	99.80	C424344	99.50	C424384	99.60	C424390	99.80	C424741	99.20
C424819	99.30	C424926	99.30	C425219	99.40	C425254	99.80	C425356	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7464.70
3 Sum of Squared Measurements	742968.91
4 Correction Factor (CF): Sum of Measurements Squared / N	742956.61
5 Corrected Sum of Squares (SS)	12.30
6 Variance (V) : SS/(N-1)	0.1662
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4076
8 Sample Mean(XBAR): Sum X/N	99.53
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.06
12 Quality Index Lower (QL): (XBAR-L) / s	3.75
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 455 Lot Descr: KU J5 - 16
 In Service Population: 146 Sample Quantity: 10 Meters Tested: 10 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C425388	100.00	C425400	99.60	C425406	99.90	C425424	99.90	C425464	99.60
C425467	99.90	C425484	100.00	C425486	99.80	C425487	99.80	C425497	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	10
2 Sum of Measurements: (Sum X)	998.80
3 Sum of Squared Measurements	99760.52
4 Correction Factor (CF): Sum of Measurements Squared / N	99760.14
5 Corrected Sum of Squares (SS)	0.38
6 Variance (V) : SS/(N-1)	0.0418
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2044
8 Sample Mean (XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.37
12 Quality Index Lower (QL): (XBAR-L) / S	9.20
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	7.26
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V15AC100 Model Number: MKS Division: 01 Sample Lot: 456 Lot Descr: KU MK - 1
 In Service Population: 657 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 50
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C179660	100.30	C180431	100.00	C181806	99.20	C181991	99.60	C182135	100.00
C182619	100.00	C183851	100.20	C185196	99.80	C185208	98.80	C185341	100.30
C186155	100.00	C186640	99.50	C188420	100.30	C192458	99.90	C193222	100.50
C194246	99.50	C194811	99.50	C195130	100.50	C195210	99.40	C200440	100.00
C200836	100.60	C201068	100.30	C203112	100.20	C203138	100.20	W082226	99.30
W085216	100.10	W085994	99.60	W086149	99.90	W087401	100.10	W087454	100.20
W088474	100.10	W089773	100.40	W090068	99.60	W091905	99.50	W092042	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3497.40
3 Sum of Squared Measurements	349486.04
4 Correction Factor (CF): Sum of Measurements Squared / N	349480.19
5 Corrected Sum of Squares (SS)	5.85
6 Variance (V) : SS/(N-1)	0.1720
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4147
8 Sample Mean (XBAR) : Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU) : (U-XBAR) / s	5.00
12 Quality Index Lower (QL) : (XBAR-L) / s	4.64
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P) : PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MQS Division: 01 Sample Lot: 457 Lot Descr: KU MQ - 1
 In Service Population: 4,334 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 51
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C205205	100.20	C205209	100.40	C205358	100.00	C205762	99.90	C206468	100.50
C206485	100.30	C207467	100.50	C207479	99.90	C207511	99.60	C208051	99.90
C208073	100.20	C208109	99.60	C208141	99.90	C208542	99.20	C208563	100.00
C208616	100.00	C209164	99.80	C209189	100.00	C209312	100.00	C209357	100.00
C209792	99.60	C210449	99.90	C211301	100.10	C211686	99.80	C213524	99.90
C214271	100.20	C214725	100.40	C214729	100.10	C214735	100.00	C215470	100.10
C215477	100.10	C215589	99.80	C215595	99.90	C215637	99.80	C216452	99.60
C217807	99.90	C217908	100.10	C217961	100.10	C218004	99.80	C218165	99.90
C220724	99.40	C221112	99.80	C221224	99.50	C221241	100.10	C221260	100.10
C222645	99.80	M349509	100.10	M371877	100.00	M384778	100.10	M387181	99.90
M387493	99.90	M413634	100.20	W092653	100.20	W092832	100.40	W092851	99.90
W093995	100.10	W094563	99.70	W095220	99.80	W095520	100.00	W096179	100.20
W096188	100.00	W096521	100.30	W096540	100.20	W097146	100.00	W098207	99.90
W098279	100.00	W099412	100.40	W099442	100.20	W099481	100.80	W099581	100.10
W100787	100.60	W101004	99.80	W101375	100.00	W101714	100.40	W101842	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.70
3 Sum of Squared Measurements	750145.43
4 Correction Factor (CF): Sum of Measurements Squared / N	750140.01
5 Corrected Sum of Squares (SS)	5.42
6 Variance (V) : SS/(N-1)	0.0733
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2707
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.35
12 Quality Index Lower (QL): (XBAR-L) / s	7.42
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 458 Lot Descr: KU MS - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 52
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C227120	100.30	C227309	100.50	C231195	100.40	C231244	100.10	C231262	100.30
C231283	99.80	C231564	100.70	C231676	100.60	C232478	100.30	C234720	100.30
C237283	100.70	C237716	100.00	C237939	100.30	C238053	99.80	C238230	100.30
C238255	100.60	L073212	100.10	L133426	100.00	L135674	100.00	L136155	99.80
L137665	100.40	L140002	100.10	L141397	100.00	L142861	99.70	L147959	99.90
L148091	100.30	L149256	100.00	L149264	100.00	L149545	99.80	L149616	99.60
L149631	100.20	L149642	99.90	L149714	99.70	L149842	100.10	L171802	100.10
L171952	99.80	L173301	100.00	L173624	100.90	L175856	99.60	L177108	99.90
L177273	100.00	L177341	99.80	L179716	100.00	L179828	100.10	L179961	99.80
L180029	100.00	L180041	100.10	L180073	100.00	L180080	99.60	L180091	100.30
L181469	99.80	L181488	99.50	L181564	99.20	L181622	100.00	L181657	99.80
L181697	99.70	L181832	99.70	L181897	100.10	L183050	100.30	L183223	100.10
L183266	99.80	L185147	100.00	L185205	100.20	L185367	100.50	L185376	100.30
M352826	100.40	M374491	99.70	M374541	100.10	M386361	100.20	M386486	99.90
M386918	100.10	M388790	100.40	W103340	100.50	W104762	100.20	W108802	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.50
3 Sum of Squared Measurements	751107.49
4 Correction Factor (CF): Sum of Measurements Squared / N	751100.40
5 Corrected Sum of Squares (SS)	7.09
6 Variance (V) : SS/(N-1)	0.0958
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3095
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.23
12 Quality Index Lower (QL): (XBAR-L) / s	6.70
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 459 Lot Descr: KU MS - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 53
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C242183	99.90	C242360	100.40	C242704	99.40	C242789	99.40	C242853	99.50
C246553	100.10	C246657	100.10	C246661	100.00	C246775	99.90	C246802	100.00
C246927	100.10	C247051	100.10	C247141	99.80	C247210	99.70	L186463	100.40
L186483	100.30	L186491	100.30	L186668	100.20	L186687	100.20	L188286	100.20
L188341	99.10	L189644	100.10	L189909	99.80	L190019	100.20	L193181	100.20
L193231	100.10	L193276	99.80	L193283	100.10	L193352	99.90	L193357	100.10
L193457	100.00	L193754	100.10	L194399	99.70	L194403	100.00	L197105	99.90
L197320	99.40	L198019	99.70	L198029	99.60	L198137	99.50	L199079	99.80
L200849	100.00	L201032	99.50	L201084	100.10	L201284	99.70	L201321	100.60
L202553	99.90	L202579	99.50	L202702	99.90	L202728	100.20	L202837	100.10
L202921	100.10	L206281	99.90	L206319	99.10	L208282	100.10	L208344	99.50
L208368	99.70	L208391	100.10	L208412	100.30	L208549	99.90	M384608	99.80
W110124	100.60	W110692	99.90	W111338	100.70	W111855	100.30	W111907	100.10
W112831	100.10	W112872	100.30	W115112	99.60	W115170	100.40	W115191	100.30
W115417	99.80	W115466	100.10	W115512	99.80	W115522	100.40	W115553	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.60
3 Sum of Squared Measurements	749527.90
4 Correction Factor (CF): Sum of Measurements Squared / N	749520.08
5 Corrected Sum of Squares (SS)	7.82
6 Variance (V) : SS/(N-1)	0.1057
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3251
8 Sample Mean (XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.25
12 Quality Index Lower (QL): (XBAR-L) / S	6.05
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 460 Lot Descr: KU MS - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 54
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C251104	100.30	C251136	99.70	C251309	100.10	C251350	100.50	C251772	100.20
C251884	100.00	C259019	100.30	C259164	100.20	C259167	100.20	C259542	100.20
C259699	100.20	C259914	99.90	C260055	100.00	C260065	100.30	C260431	100.50
C260502	100.40	C261158	100.20	C261254	99.90	C261518	100.30	C261539	100.10
C265698	99.80	C265747	100.00	C265757	100.50	C265912	99.70	L208613	99.90
L209535	100.20	L209538	100.20	L209565	99.70	L209824	100.00	L211230	100.00
L211272	99.60	L211312	99.80	L211361	99.90	L211420	99.80	L211541	99.90
L211575	100.20	L211597	100.00	L212724	100.60	L215745	100.10	L215762	100.40
L215796	100.70	L216000	100.10	L218468	99.90	L218469	100.10	L218476	100.10
L218478	100.20	L218492	100.00	L221080	99.70	L221394	99.90	L222647	99.90
L222776	100.20	L222814	100.00	L222844	99.80	L222865	99.90	L223103	99.60
L223155	100.40	L223322	100.00	L223349	100.00	L223412	100.00	L230834	100.20
L230894	99.70	L231321	100.00	L231549	99.70	L232406	100.30	L232580	100.50
L232722	100.00	W115648	100.20	W115825	100.20	W115906	100.50	W117166	100.10
W117297	100.10	W118459	100.10	W118540	100.30	W118813	100.10	W118831	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.40
3 Sum of Squared Measurements	751284.90
4 Correction Factor (CF): Sum of Measurements Squared / N	751280.55
5 Corrected Sum of Squares (SS)	4.35
6 Variance (V) : SS/(N-1)	0.0588
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2426
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.89
12 Quality Index Lower (QL): (XBAR-L) / S	8.60
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 461 Lot Descr: KU MS - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 55
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C266476	100.10	C266563	100.00	C266665	99.90	C266705	99.80	C270865	99.80
C270910	100.20	C270982	100.40	C270990	100.50	C271354	100.00	C271882	100.10
C275473	99.40	C275686	100.40	C275801	99.70	C275897	100.10	C276059	99.30
C276134	100.00	C276203	100.10	C276379	100.40	C276391	99.50	C276492	100.30
C279977	99.90	C280455	100.60	C280603	100.30	C280676	99.90	C280762	100.50
C280944	100.30	C280955	100.00	C285145	100.10	C285418	100.00	C285448	99.90
C285631	99.90	C286011	99.90	C286080	100.20	C286355	99.90	C286377	100.20
C286499	99.90	C286671	100.20	C289242	99.90	C289293	100.40	C289373	100.20
C289450	99.90	C289788	100.20	L236593	100.40	L236642	99.80	L236711	99.70
L236760	99.90	L236765	99.80	L236887	100.00	L236936	100.70	L237193	100.60
L238072	100.30	L238081	99.80	L238084	100.10	L238343	99.90	L240613	100.10
L240754	100.10	L240823	100.20	L241132	100.20	L243684	99.70	L243719	100.30
L243725	99.40	L243989	100.00	L244005	100.20	L245270	100.20	L245341	100.00
L245445	99.90	L245481	100.30	L245595	99.80	L245636	99.90	L245643	99.80
L259893	100.20	L259995	99.70	L260082	99.90	W124725	99.80	W124726	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.50
3 Sum of Squared Measurements	750706.11
4 Correction Factor (CF): Sum of Measurements Squared / N	750700.16
5 Corrected Sum of Squares (SS)	5.95
6 Variance (V) : SS/(N-1)	0.0804
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2835
8 Sample Mean(XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.89
12 Quality Index Lower (QL): (XBAR-L) / s	7.22
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 462 Lot Descr: KU MS - 5
 In Service Population: 3,976 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 56

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C301020	100.00	C301122	100.10	L312545	100.90	L312978	100.20	L313047	100.20
M434668	100.40	M434747	100.20	M434810	100.30	M434914	100.20	M434931	100.20
M434938	100.10	M434956	100.10	M435058	100.30	M435148	99.90	M435176	100.20
M435310	100.40	M435321	100.30	M435367	100.50	M435377	100.00	M435448	100.20
M435488	100.50	M435534	100.20	W132377	100.60	W132399	100.10	W132401	100.30
W132460	100.30	W132501	100.10	W132507	100.40	W132531	100.00	W132547	100.00
W132570	100.20	W132597	100.30	W132977	100.10	W133002	100.10	W133028	99.90
W133213	99.90	W133300	100.30	W133330	100.20	W133413	100.40	W133474	100.40
W133496	100.20	W133575	100.30	W133596	100.40	W133614	100.40	W134153	100.10
W134219	100.50	W134302	100.30	W134308	100.10	W134482	100.20	W134590	100.10
W134667	100.10	W134696	100.20	W134803	99.90	W134822	100.10	W134823	100.10
W134882	100.20	W134900	99.90	W134936	99.90	W135060	99.80	W135133	100.20
W135146	99.90	W135157	100.10	W135275	100.20	W135372	100.10	W135375	100.10
W135402	100.20	W135441	99.80	W135453	100.20	W135717	100.00	W135724	100.10
W135805	100.20	W135924	100.10	W135967	100.20	W136001	100.20	W136019	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7513.40
3 Sum of Squared Measurements	752685.02
4 Correction Factor (CF): Sum of Measurements Squared / N	752682.39
5 Corrected Sum of Squares (SS)	2.63
6 Variance (V) : SS/(N-1)	0.0355
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1884
8 Sample Mean (XBAR) : Sum X/N	100.18
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	9.67
12 Quality Index Lower (QL): (XBAR-L) / s	11.57
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 463 Lot Descr: KU MSII - 1
 In Service Population: 4,949 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 57
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C275409	100.10	C275487	100.00	C275499	99.90	C275512	100.10	C275517	100.20
C275614	100.20	C275653	99.90	C298693	100.20	C298763	99.90	C298836	100.00
C300542	100.00	C300554	100.20	C300566	100.10	C300712	100.30	C300734	100.10
C300797	100.20	C300824	100.00	C300837	100.10	C300857	100.20	C300918	99.90
C300963	100.10	C301196	100.30	C301267	100.30	C301299	100.40	C301300	100.30
C301481	100.20	C301514	100.40	C301563	100.60	C301573	100.00	C301678	100.30
C301774	99.80	C301841	100.00	C301878	100.00	C301926	100.30	C301947	100.00
C302021	100.10	C302065	100.10	C302084	99.90	C302128	100.00	C302239	100.20
C302447	99.90	C302449	100.00	C302615	100.20	C302741	100.00	L312594	99.70
L312611	100.20	L312760	100.40	M421120	100.00	M421160	100.10	M421188	99.70
M421211	99.80	M421378	100.00	M422029	100.10	M422034	100.00	M422100	100.00
M422158	99.80	M422167	100.10	M422231	100.20	M422480	100.00	M422544	99.40
M422550	100.30	M422581	100.10	M428441	99.50	M428533	100.20	M435962	100.20
M436001	100.40	M436010	100.60	M436108	100.10	M436160	100.00	M436271	100.10
M436352	100.20	M436383	100.00	M436425	99.90	M436448	99.80	M436498	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.00
3 Sum of Squared Measurements	751203.72
4 Correction Factor (CF): Sum of Measurements Squared / N	751200.48
5 Corrected Sum of Squares (SS)	3.24
6 Variance (V) : SS/(N-1)	0.0438
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2092
8 Sample Mean(XBAR): Sum X/N	100.08
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.18
12 Quality Index Lower (QL): (XBAR-L) / S	9.94
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200

Model Number: MX

Division: 01

Sample Lot: 464

Lot Descr: KU MX - 1

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 58

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C320926	99.80	C320980	100.10	C321097	100.00	C321236	100.00	C321269	99.50
C321468	100.10	C321907	100.10	C322080	100.00	C322336	100.10	C322386	100.70
C322570	100.00	C322842	100.00	C322961	99.90	C323046	99.80	C323100	99.90
C323210	100.10	C323311	99.80	C323717	99.60	C323790	99.90	C323978	100.00
C324126	99.90	C324563	100.00	C324689	101.00	C324713	100.20	C324888	99.90
C324935	100.00	C325278	99.90	C325523	100.10	C325632	100.00	C325784	99.90
L288309	100.00	L288403	99.80	L288685	99.90	L288824	100.00	L288838	100.20
L288887	99.80	L288997	99.80	L289039	100.00	L289389	100.10	L289512	100.00
L289654	99.90	L289921	99.90	L290311	100.10	L290328	100.10	L290429	99.70
L290445	100.10	L290531	99.70	L290589	100.00	L290682	99.80	L290765	100.00
L290821	100.00	L290841	100.00	L291000	99.90	L291110	99.80	L291166	99.70
L291435	99.80	M440852	99.80	M440940	99.80	M440995	99.70	M441033	99.70
M441041	100.10	M441096	100.00	M441176	99.50	M441210	99.60	M441247	100.30
M441279	99.80	M441645	100.00	M441773	100.10	M442416	100.20	W142619	99.80
W142623	100.00	W142903	99.90	W142968	99.70	W143027	99.90	W143162	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.20
3 Sum of Squared Measurements	749243.84
4 Correction Factor (CF): Sum of Measurements Squared / N	749240.19
5 Corrected Sum of Squares (SS)	3.65
6 Variance (V) : SS/(N-1)	0.0493
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2220
8 Sample Mean(XBAR): Sum X/N	99.95
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.24
12 Quality Index Lower (QL): (XBAR-L) / S	8.78
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 465 Lot Descr: KU MX - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 59
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C390735	100.10	C391011	100.20	C391047	100.00	C391084	99.60	C391161	100.10
C391558	100.00	C425994	100.20	C426013	99.90	C426054	99.50	C426148	99.80
C426186	99.50	C426235	99.70	C426262	99.70	C426588	99.90	C426799	99.20
C426806	100.00	C427180	99.70	C427186	99.90	C427225	99.70	C427503	99.90
C427565	99.90	C427650	99.80	C427891	99.90	C427914	100.10	C427963	100.20
C428384	100.00	C428474	99.60	C428504	100.00	C428618	99.90	C428834	100.20
C429046	99.90	C429175	99.90	C429195	99.90	C429269	99.90	C429308	99.90
C429313	99.70	C429337	99.60	C429452	99.90	C429462	99.50	C429906	99.80
C430449	99.60	C430490	99.70	C430741	99.90	C431014	99.90	C431093	99.30
C431148	99.70	C431149	99.70	C431319	99.90	C431464	99.70	C431499	99.70
C431639	99.70	C431786	99.90	C435509	99.60	C435740	99.60	C435819	99.90
C435833	99.70	C435964	99.60	C436236	99.50	C436425	99.90	C436903	99.60
C437157	99.60	C437190	99.60	C437238	99.80	C437243	99.70	C437291	99.70
C437579	99.80	C437592	99.60	W143227	99.70	W143250	99.90	W143510	100.20
W144027	100.30	W144147	100.50	W144184	99.80	W144201	100.00	W144293	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.80
3 Sum of Squared Measurements	747366.34
4 Correction Factor (CF): Sum of Measurements Squared / N	747362.32
5 Corrected Sum of Squares (SS)	4.02
6 Variance (V) : SS/(N-1)	0.0543
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2330
8 Sample Mean (XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.34
12 Quality Index Lower (QL): (XBAR-L) / S	7.83
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: MX
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 466
Pass/ Fail: PASS

Lot Descr: KU MX - 3

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 60

Run Date: 01/02/2012

Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C437738	99.70	C437822	99.80	C438073	99.90	C438105	99.50	C438139	99.30
C438342	99.70	C438595	99.50	C438673	99.70	C438748	99.90	C438798	99.60
C438867	99.70	C438870	99.60	C438932	99.70	C439122	99.60	C439676	99.90
C439697	99.80	C439939	100.10	C440656	99.80	C440775	100.00	C440834	100.20
C440871	99.90	C440914	99.80	C441163	99.80	C441439	99.80	C441708	100.00
C441871	99.90	C441872	99.90	C442008	99.90	C442081	99.90	C442135	99.80
C442392	100.00	C442504	99.50	C443186	99.80	C443190	100.20	C443249	99.80
C443269	100.00	C443391	99.80	C443401	99.70	C443496	100.10	C444110	99.30
C444301	99.70	C444475	99.70	C444823	99.70	C444892	99.90	C446490	99.10
C446525	99.50	C446527	99.90	C446529	99.60	C446538	99.40	C446735	99.40
C446834	99.30	C446859	99.60	C446915	99.50	C446927	99.60	C446990	99.60
C447186	99.90	C447312	99.70	C447383	99.70	C447441	99.60	C447692	99.70
C447916	99.40	C448087	99.50	C448185	99.20	C448192	99.70	C448359	99.90
C448467	99.50	C448601	99.90	C448809	99.60	C449006	99.60	C449028	99.60
C449054	99.70	C449137	99.80	C449268	99.70	C449388	99.70	C449464	99.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7478.20
3 Sum of Squared Measurements	745649.98
4 Correction Factor (CF): Sum of Measurements Squared / N	745646.34
5 Corrected Sum of Squares (SS)	3.64
6 Variance (V) : SS/(N-1)	0.0492
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2219
8 Sample Mean(XBAR): Sum X/N	99.71
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	10.32
12 Quality Index Lower (QL): (XBAR-L) / s	7.70
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: MX
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 467
Pass/ Fail: PASS

Lot Descr: KU MX - 4

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 61
Run Date: 01/02/2012
Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C449668	99.80	C449670	99.80	C449784	100.00	C449924	99.90	C449945	99.80
C450009	99.70	C450018	99.30	C450039	99.60	C450250	99.80	C450447	99.70
C450529	100.00	C450701	99.90	C450704	99.90	C451059	99.70	C451245	99.50
C451350	99.90	C451499	99.80	C451598	99.80	C451637	99.70	C451810	99.80
C451853	100.10	C451926	99.60	C452074	99.80	C452644	99.90	C452803	99.80
C452882	99.70	C452929	99.70	C453184	99.70	C453216	99.80	C453236	99.50
C453511	99.60	C453550	99.40	C453751	99.80	C454105	100.10	C454193	99.70
C454989	99.70	C455018	99.80	C455455	99.90	C455597	99.90	C455611	99.90
C455673	100.00	C455775	99.90	C455870	100.00	C455934	99.90	C457723	99.80
C457771	100.00	C457774	100.00	C457775	100.10	C457858	100.00	C457922	100.00
C458185	100.00	C458255	100.00	C458442	99.80	C458791	99.70	C458858	99.90
C458931	100.00	C459102	100.10	C459294	99.80	C459323	99.70	C459539	100.00
C459630	99.90	C459646	100.10	C459843	99.90	C460189	99.80	C460240	100.00
C460276	100.00	C460643	99.90	C460743	100.00	C460875	100.00	C461033	100.10
C461043	99.70	C461056	99.90	C461201	99.90	C461204	100.10	C461598	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7488.80
3 Sum of Squared Measurements	747763.78
4 Correction Factor (CF): Sum of Measurements Squared / N	747761.67
5 Corrected Sum of Squares (SS)	2.11
6 Variance (V) : SS/(N-1)	0.0285
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1688
8 Sample Mean(XBAR): Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	12.74
12 Quality Index Lower (QL): (XBAR-L) / S	10.97
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2011 Sample Test Program (01/01/2011) to (12/31/2011)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 468 Lot Descr: KU MX - 5
 In Service Population: 1,821 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 62
 Run Date: 01/02/2012
 Run Time: 08:10:56 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C461674	99.80	C461744	100.00	C461775	99.80	C461788	100.10	C461811	100.10
C461852	100.00	C461896	99.90	C461921	100.10	C461952	99.90	C461980	99.80
C462018	100.10	C462022	99.80	C462036	100.10	C462051	99.90	C462066	99.90
C462075	99.80	C462087	100.00	C462091	100.00	C462136	99.80	C462195	99.80
C462209	100.00	C462210	99.90	C462219	100.10	C462233	99.90	C462405	99.90
C462446	100.00	C462501	100.10	C462539	99.90	C462559	99.80	C462580	99.80
C462726	99.80	C462730	99.80	C462807	100.00	C462825	97.10	C462829	99.80
C462856	99.80	C462858	99.70	C462889	99.70	C462951	100.00	C463010	99.90
C463036	99.40	C463043	100.00	C463139	99.80	C463206	99.60	C463211	99.80
C463278	99.90	C463281	99.80	C463296	99.80	L292098	99.80	L292291	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4991.60
3 Sum of Squared Measurements	498330.00
4 Correction Factor (CF): Sum of Measurements Squared / N	498321.41
5 Corrected Sum of Squares (SS)	8.59
6 Variance (V) : SS/(N-1)	0.1753
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4187
8 Sample Mean(XBAR): Sum X/N	99.83
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.18
12 Quality Index Lower (QL): (XBAR-L) / S	4.38
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

KU MSII - 1	Landis + Gyr	MSII	4,949	75	75	PASS	TESTING COMPLETE	463
KU MX - 1	Landis + Gyr	MX	10,000	75	75	PASS	TESTING COMPLETE	464
KU MX - 2	Landis + Gyr	MX	10,000	75	75	PASS	TESTING COMPLETE	465
KU MX - 3	Landis + Gyr	MX	10,000	75	75	PASS	TESTING COMPLETE	466
KU MX - 4	Landis + Gyr	MX	10,000	75	75	PASS	TESTING COMPLETE	467
KU MX - 5	Landis + Gyr	MX	1,821	50	50	PASS	TESTING COMPLETE	468

TOTALS	488,359	4,208	4,208	
	TOTAL LOTS PASSED:			61
	TOTAL LOTS FAILED:			1
	METERS CANNOT TEST:			0

Report completed successfully with results.