



a PPL company

Jeff DeRouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

RECEIVED

FEB 28 2014

PUBLIC SERVICE
COMMISSION

**Louisville Gas and Electric
Company**
State Regulation and Rates
220 W. Main Street
Louisville, KY 40202
www.lge-ku.com

Martin J. Reinert
Sr. Regulatory Analyst
O 502-627-4173
marty.reinert@lge-ku.com

February 28, 2014

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Louisville Gas and Electric Company

Dear Mr. DeRouen:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.


Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Louisville Gas and Electric Company** submits the following:

The Certified Test Results of all new meters
received
(Attachment A)

2013 Statistical Sampling Test Results and
Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Marty J. Reinert". The signature is written in a cursive, slightly slanted style.

Marty J. Reinert

Cc: Kyle Willard, Engineering Director PSC

Attachments

ATTACHMENT
A

Certified Test Results

LG&E and KU Energy LLC

5040 Annual Report of New Single Phase Meters

Update:

02/25/2014 07:36:45

Dynamic Filters

Plant LG&E
Month/Year 01/2013 - 12/2013

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
LG&E	C1S	878528	01/2013	01/07/2013	100.070	100.000	100.1	1
LG&E	C1S	878529	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	878530	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	878531	01/2013	01/07/2013	100.080	100.020	100.1	1
LG&E	C1S	878532	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	878533	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878534	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878535	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	878536	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	878537	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	878538	01/2013	01/07/2013	100.060	100.030	100.1	1
LG&E	C1S	878539	01/2013	01/07/2013	100.090	99.900	100.2	1
LG&E	C1S	878540	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	878541	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	878542	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	878543	01/2013	01/07/2013	100.050	99.890	100.1	1
LG&E	C1S	878544	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	878545	01/2013	01/07/2013	100.090	99.960	100.0	1

LG&E	C1S	878546	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	878547	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	878548	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	878549	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	878550	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	878551	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	878552	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	878553	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	878554	01/2013	01/07/2013	100.050	99.850	100.0	1
LG&E	C1S	878555	01/2013	01/07/2013	100.050	99.920	100.2	1
LG&E	C1S	878556	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	878557	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	878558	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	878559	01/2013	01/07/2013	100.080	99.920	100.2	1
LG&E	C1S	878560	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	878561	01/2013	01/07/2013	100.060	99.850	100.0	1
LG&E	C1S	878562	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	878563	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	878564	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	878565	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	878566	01/2013	01/07/2013	100.070	100.060	100.1	1
LG&E	C1S	878567	01/2013	01/07/2013	100.090	100.070	100.0	1
LG&E	C1S	878568	01/2013	01/07/2013	100.100	99.990	100.2	1
LG&E	C1S	878569	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	878570	01/2013	01/07/2013	100.070	100.010	100.0	1
LG&E	C1S	878571	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	878572	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	878573	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	878574	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	878575	01/2013	01/07/2013	100.070	99.950	100.0	1

LG&E	C1S	878576	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	878577	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	878578	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	878579	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878580	01/2013	01/07/2013	100.050	99.870	99.9	1
LG&E	C1S	878581	01/2013	01/07/2013	100.060	99.990	100.0	1
LG&E	C1S	878582	01/2013	01/07/2013	100.050	100.000	100.0	1
LG&E	C1S	878583	01/2013	01/07/2013	100.100	99.990	100.0	1
LG&E	C1S	878584	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	878585	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	878586	01/2013	01/07/2013	100.080	100.010	100.0	1
LG&E	C1S	878587	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	878588	01/2013	01/07/2013	100.060	99.990	100.1	1
LG&E	C1S	878589	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	878590	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	878591	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	878592	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	878593	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	878594	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	878595	01/2013	01/07/2013	100.090	100.090	100.0	1
LG&E	C1S	878596	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	878597	01/2013	01/07/2013	100.060	99.870	100.0	1
LG&E	C1S	878598	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	878599	01/2013	01/07/2013	100.090	99.970	100.2	1
LG&E	C1S	878600	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878601	01/2013	01/07/2013	100.090	99.970	99.9	1
LG&E	C1S	878602	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	878603	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	878604	01/2013	01/07/2013	100.060	100.000	100.1	1
LG&E	C1S	878605	01/2013	01/07/2013	100.090	100.000	100.0	1

LG&E	C1S	878606	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878607	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	878608	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	878609	01/2013	01/07/2013	100.070	99.970	100.2	1
LG&E	C1S	878610	01/2013	01/07/2013	100.100	100.020	100.0	1
LG&E	C1S	878611	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	878612	01/2013	01/07/2013	100.100	100.000	100.2	1
LG&E	C1S	878613	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878614	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	878615	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	878616	01/2013	01/07/2013	100.090	100.010	100.1	1
LG&E	C1S	878617	01/2013	01/07/2013	100.080	99.860	100.1	1
LG&E	C1S	878618	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	878619	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	878620	01/2013	01/07/2013	100.050	99.880	100.0	1
LG&E	C1S	878621	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	878622	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	878623	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	878624	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878625	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878626	01/2013	01/07/2013	100.060	99.990	100.0	1
LG&E	C1S	878627	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	878628	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	878629	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	878630	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878631	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	878632	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	878633	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	878634	01/2013	01/07/2013	100.050	99.980	100.0	1
LG&E	C1S	878635	01/2013	01/07/2013	100.060	99.980	100.1	1

LG&E	C1S	878636	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	878637	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878638	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	878639	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878640	01/2013	01/07/2013	100.100	100.070	100.1	1
LG&E	C1S	878641	01/2013	01/07/2013	100.100	100.010	100.2	1
LG&E	C1S	878642	01/2013	01/07/2013	100.060	99.880	100.1	1
LG&E	C1S	878643	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	878644	01/2013	01/07/2013	100.080	100.020	100.0	1
LG&E	C1S	878645	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	878646	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	878647	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	878648	01/2013	01/07/2013	100.060	99.970	99.9	1
LG&E	C1S	878649	01/2013	01/07/2013	100.060	99.870	100.1	1
LG&E	C1S	878650	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	878651	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	878652	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	878653	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	878654	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878655	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	878656	01/2013	01/07/2013	100.060	99.850	100.1	1
LG&E	C1S	878657	01/2013	01/07/2013	100.080	100.020	100.1	1
LG&E	C1S	878658	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	878659	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	878660	01/2013	01/07/2013	100.050	99.970	100.1	1
LG&E	C1S	878661	01/2013	01/07/2013	100.100	100.060	100.0	1
LG&E	C1S	878662	01/2013	01/07/2013	100.100	99.990	100.0	1
LG&E	C1S	878663	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878664	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878665	01/2013	01/07/2013	100.100	99.950	100.1	1

LG&E	C1S	878666	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	878667	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	878668	01/2013	01/07/2013	100.050	99.850	100.0	1
LG&E	C1S	878669	01/2013	01/07/2013	100.080	99.840	100.1	1
LG&E	C1S	878670	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878671	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	878672	01/2013	01/07/2013	100.050	99.890	100.0	1
LG&E	C1S	878673	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	878674	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	878675	01/2013	01/07/2013	100.070	100.020	100.0	1
LG&E	C1S	878676	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	878677	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	878678	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	878679	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	878680	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878681	01/2013	01/07/2013	100.100	99.920	100.0	1
LG&E	C1S	878682	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	878683	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	878684	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	878685	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878686	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	878687	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878688	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878689	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	878690	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878691	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	878692	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	878693	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878694	01/2013	01/07/2013	100.070	99.880	100.0	1
LG&E	C1S	878695	01/2013	01/07/2013	100.100	100.030	100.1	1

LG&E	C1S	878696	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	878697	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	878698	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	878699	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	878700	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	878701	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878702	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878703	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	878704	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	878705	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	878706	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	878707	01/2013	01/07/2013	100.100	100.060	100.0	1
LG&E	C1S	878708	01/2013	01/07/2013	100.090	99.930	99.9	1
LG&E	C1S	878709	01/2013	01/07/2013	100.070	99.980	99.9	1
LG&E	C1S	878710	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	878711	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	878712	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878713	01/2013	01/07/2013	100.070	100.010	100.0	1
LG&E	C1S	878714	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878715	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	878716	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	878717	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	878718	01/2013	01/07/2013	100.100	100.040	100.1	1
LG&E	C1S	878719	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	878720	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	878721	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	878722	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	878723	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	878724	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	878725	01/2013	01/07/2013	100.080	99.980	100.0	1

LG&E	C1S	878726	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878727	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	878728	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878729	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	878730	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878731	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878732	01/2013	01/07/2013	100.080	99.920	99.9	1
LG&E	C1S	878733	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878734	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	878735	01/2013	01/07/2013	100.100	99.970	99.9	1
LG&E	C1S	878736	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	878737	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	878738	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	878739	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	878740	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	878741	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	878742	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	878743	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	878744	01/2013	01/07/2013	100.070	100.020	100.0	1
LG&E	C1S	878745	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	878746	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	878747	01/2013	01/07/2013	100.060	99.900	99.9	1
LG&E	C1S	878748	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	878749	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878750	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	878751	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	878752	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878753	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	878754	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	878755	01/2013	01/07/2013	100.070	99.950	100.0	1

LG&E	C1S	878756	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	878757	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	878758	01/2013	01/07/2013	100.050	99.980	100.1	1
LG&E	C1S	878759	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878760	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878761	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	878762	01/2013	01/07/2013	100.060	99.970	99.9	1
LG&E	C1S	878763	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	878764	01/2013	01/07/2013	100.090	100.040	100.0	1
LG&E	C1S	878765	01/2013	01/07/2013	100.100	99.950	100.0	1
LG&E	C1S	878766	01/2013	01/07/2013	100.080	100.020	100.1	1
LG&E	C1S	878767	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	878768	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878769	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	878770	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	878771	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	878772	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	878773	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	878774	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878775	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	878776	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	878777	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878778	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	878779	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	878780	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878781	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	878782	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	878783	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878784	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	878785	01/2013	01/07/2013	100.080	99.960	100.1	1

LG&E	C1S	878786	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878787	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	878788	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	878789	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	878790	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	878791	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	878792	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	878793	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878794	01/2013	01/07/2013	100.080	100.070	100.0	1
LG&E	C1S	878795	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	878796	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	878797	01/2013	01/07/2013	100.100	99.940	100.2	1
LG&E	C1S	878798	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	878799	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	878800	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	878801	01/2013	01/07/2013	100.100	100.010	100.0	1
LG&E	C1S	878802	01/2013	01/07/2013	100.100	99.910	100.1	1
LG&E	C1S	878803	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878804	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	878805	01/2013	01/07/2013	100.060	99.990	100.0	1
LG&E	C1S	878806	01/2013	01/07/2013	100.070	100.010	100.1	1
LG&E	C1S	878807	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	878808	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	878809	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	878810	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	878811	01/2013	01/07/2013	100.070	100.030	100.1	1
LG&E	C1S	878812	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	878813	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	878814	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	878815	01/2013	01/07/2013	100.070	99.940	100.1	1

LG&E	C1S	878816	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	878817	01/2013	01/07/2013	100.080	100.020	100.2	1
LG&E	C1S	878818	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878819	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	878820	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878821	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	878822	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	878823	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878824	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	878825	01/2013	01/07/2013	100.060	100.020	100.0	1
LG&E	C1S	878826	01/2013	01/07/2013	100.080	100.010	100.0	1
LG&E	C1S	878827	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	878828	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	878829	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	878830	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	878831	01/2013	01/07/2013	100.050	99.960	100.1	1
LG&E	C1S	878832	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878833	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	878834	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	878835	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	878836	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878837	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878838	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	878839	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	878840	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	878841	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	878842	01/2013	01/07/2013	100.050	99.910	100.1	1
LG&E	C1S	878843	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	878844	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878845	01/2013	01/07/2013	100.060	99.950	100.0	1

LG&E	C1S	878846	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	878847	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	878848	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	878849	01/2013	01/07/2013	100.090	100.090	100.1	1
LG&E	C1S	878850	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	878851	01/2013	01/07/2013	100.070	100.010	100.1	1
LG&E	C1S	878852	01/2013	01/07/2013	100.100	100.030	100.2	1
LG&E	C1S	878853	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	878854	01/2013	01/07/2013	100.050	99.950	100.1	1
LG&E	C1S	878855	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	878856	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	878857	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	878858	01/2013	01/07/2013	100.080	99.930	100.2	1
LG&E	C1S	878859	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	878860	01/2013	01/07/2013	100.060	100.020	100.0	1
LG&E	C1S	878861	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878862	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	878863	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	878864	01/2013	01/07/2013	100.090	100.030	100.0	1
LG&E	C1S	878865	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	878866	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	878867	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	878868	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878869	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	878870	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	878871	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878872	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	878873	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	878874	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	878875	01/2013	01/07/2013	100.100	99.990	100.0	1

LG&E	C1S	878876	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	878877	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878878	01/2013	01/07/2013	100.080	100.040	100.1	1
LG&E	C1S	878879	01/2013	01/07/2013	100.070	100.050	100.0	1
LG&E	C1S	878880	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878881	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878882	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	878883	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	878884	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	878885	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	878886	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	878887	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878888	01/2013	01/07/2013	100.070	100.000	100.1	1
LG&E	C1S	878889	01/2013	01/07/2013	100.060	100.040	100.0	1
LG&E	C1S	878890	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	878891	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	878892	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878893	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	878894	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	878895	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878896	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878897	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	878898	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	878899	01/2013	01/07/2013	100.070	100.020	100.0	1
LG&E	C1S	878900	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	878901	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	878902	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878903	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	878904	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	878905	01/2013	01/07/2013	100.090	99.950	100.0	1

LG&E	C1S	878906	01/2013	01/07/2013	100.060	99.860	100.0	1
LG&E	C1S	878907	01/2013	01/07/2013	100.080	100.030	100.0	1
LG&E	C1S	878908	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	878909	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878910	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	878911	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	878912	01/2013	01/07/2013	100.080	99.870	100.0	1
LG&E	C1S	878913	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	878914	01/2013	01/07/2013	100.100	100.020	100.0	1
LG&E	C1S	878915	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878916	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	878917	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	878918	01/2013	01/07/2013	100.060	99.990	100.1	1
LG&E	C1S	878919	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	878920	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	878921	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	878922	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	878923	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	878924	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	878925	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	878926	01/2013	01/07/2013	100.070	100.000	100.1	1
LG&E	C1S	878927	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	878928	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878929	01/2013	01/07/2013	100.050	99.860	100.0	1
LG&E	C1S	878930	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	878931	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	878932	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	878933	01/2013	01/07/2013	100.100	99.990	100.2	1
LG&E	C1S	878934	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	878935	01/2013	01/07/2013	100.100	99.990	100.1	1

LG&E	C1S	878936	01/2013	01/07/2013	100.060	99.870	100.1	1
LG&E	C1S	878937	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	878938	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	878939	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	878940	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	878941	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	878942	01/2013	01/07/2013	100.060	99.990	99.9	1
LG&E	C1S	878943	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	878944	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	878945	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	878946	01/2013	01/07/2013	100.080	100.030	100.0	1
LG&E	C1S	878947	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	878948	01/2013	01/07/2013	100.070	99.990	99.9	1
LG&E	C1S	878949	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	878950	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	878951	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	878952	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	878953	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	878954	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	878955	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	878956	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	878957	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	878958	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	878959	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	878960	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878961	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	878962	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	878963	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	878964	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	878965	01/2013	01/07/2013	100.100	100.000	100.0	1

LG&E	C1S	878966	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	878967	01/2013	01/07/2013	100.060	99.990	100.0	1
LG&E	C1S	878968	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878969	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	878970	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	878971	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	878972	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	878973	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	878974	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	878975	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	878976	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	878977	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	878978	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	878979	01/2013	01/07/2013	100.080	99.890	100.0	1
LG&E	C1S	878980	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	878981	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	878982	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	878983	01/2013	01/07/2013	100.080	100.010	100.0	1
LG&E	C1S	878984	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	878985	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	878986	01/2013	01/07/2013	100.090	99.870	100.0	1
LG&E	C1S	878987	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	878988	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	878989	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	878990	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	878991	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	878992	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	878993	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	878994	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	878995	01/2013	01/07/2013	100.060	99.920	100.1	1

LG&E	C1S	878996	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	878997	01/2013	01/07/2013	100.080	99.920	100.2	1
LG&E	C1S	878998	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	878999	01/2013	01/07/2013	100.060	100.010	100.1	1
LG&E	C1S	879000	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879001	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	879002	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879003	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879004	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879005	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879006	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879007	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879008	01/2013	01/07/2013	100.060	99.900	99.9	1
LG&E	C1S	879009	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	879010	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879011	01/2013	01/07/2013	100.100	99.900	100.2	1
LG&E	C1S	879012	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879013	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879014	01/2013	01/07/2013	100.100	99.990	100.0	1
LG&E	C1S	879015	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	879016	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879017	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879018	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879019	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	879020	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879021	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879022	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879023	01/2013	01/07/2013	100.100	99.930	100.0	1
LG&E	C1S	879024	01/2013	01/07/2013	100.100	99.910	100.0	1
LG&E	C1S	879025	01/2013	01/07/2013	100.090	99.980	100.0	1

LG&E	C1S	879026	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879027	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	879028	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879029	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879030	01/2013	01/07/2013	100.070	99.840	100.0	1
LG&E	C1S	879031	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879032	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879033	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	879034	01/2013	01/07/2013	100.080	99.900	100.1	1
LG&E	C1S	879035	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879036	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	879037	01/2013	01/07/2013	100.090	100.010	100.2	1
LG&E	C1S	879038	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879039	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879040	01/2013	01/07/2013	100.070	100.010	100.1	1
LG&E	C1S	879041	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879042	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	879043	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879044	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879045	01/2013	01/07/2013	100.060	99.990	100.1	1
LG&E	C1S	879046	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879047	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	879048	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879049	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879050	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	879051	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879052	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879053	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879054	01/2013	01/07/2013	100.070	100.000	100.1	1
LG&E	C1S	879055	01/2013	01/07/2013	100.070	99.890	100.1	1

LG&E	C1S	879056	01/2013	01/07/2013	100.100	99.930	100.0	1
LG&E	C1S	879057	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879058	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	879059	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879060	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879061	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879062	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879063	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879064	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879065	01/2013	01/07/2013	100.060	99.990	100.1	1
LG&E	C1S	879066	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	879067	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879068	01/2013	01/07/2013	100.070	99.880	100.1	1
LG&E	C1S	879069	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879070	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879071	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	879072	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	879073	01/2013	01/07/2013	100.090	100.030	100.1	1
LG&E	C1S	879074	01/2013	01/07/2013	100.080	100.040	100.1	1
LG&E	C1S	879075	01/2013	01/07/2013	100.090	100.040	100.0	1
LG&E	C1S	879076	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879077	01/2013	01/07/2013	100.050	99.880	100.0	1
LG&E	C1S	879078	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879079	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879080	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879081	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879082	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879083	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879084	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879085	01/2013	01/07/2013	100.080	99.970	100.1	1

LG&E	C1S	879086	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	879087	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879088	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879089	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	879090	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	879091	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879092	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879093	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879094	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879095	01/2013	01/07/2013	100.050	99.860	100.0	1
LG&E	C1S	879096	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879097	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879098	01/2013	01/07/2013	100.100	99.880	100.1	1
LG&E	C1S	879099	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879100	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879101	01/2013	01/07/2013	100.090	99.870	100.1	1
LG&E	C1S	879102	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	879103	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	879104	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879105	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879106	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	879107	01/2013	01/07/2013	100.090	100.050	100.1	1
LG&E	C1S	879108	01/2013	01/07/2013	100.090	100.010	100.1	1
LG&E	C1S	879109	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879110	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	879111	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	879112	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	879113	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	879114	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879115	01/2013	01/07/2013	100.050	99.890	100.0	1

LG&E	C1S	879116	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	879117	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879118	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879119	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879120	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879121	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879122	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879123	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879124	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879125	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	879126	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879127	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879128	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879129	01/2013	01/07/2013	100.070	100.020	100.1	1
LG&E	C1S	879130	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	879131	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	879132	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879133	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	879134	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	879135	01/2013	01/07/2013	100.070	100.020	100.0	1
LG&E	C1S	879136	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879137	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879138	01/2013	01/07/2013	100.050	100.010	100.0	1
LG&E	C1S	879139	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879140	01/2013	01/07/2013	100.050	99.970	100.1	1
LG&E	C1S	879141	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879142	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	879143	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879144	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879145	01/2013	01/07/2013	100.070	100.000	100.1	1

LG&E	C1S	879146	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879147	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879148	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	879149	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	879150	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879151	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879152	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	879153	01/2013	01/07/2013	100.060	99.850	100.1	1
LG&E	C1S	879154	01/2013	01/07/2013	100.080	99.900	100.1	1
LG&E	C1S	879155	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879156	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	879157	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879158	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879159	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	879160	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	879161	01/2013	01/07/2013	100.100	99.920	100.0	1
LG&E	C1S	879162	01/2013	01/07/2013	100.060	100.030	100.0	1
LG&E	C1S	879163	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879164	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	879165	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	879166	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879167	01/2013	01/07/2013	100.050	100.030	100.0	1
LG&E	C1S	879168	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879169	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879170	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879171	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879172	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	879173	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879174	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879175	01/2013	01/07/2013	100.100	100.010	100.0	1

LG&E	C1S	879176	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	879177	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879178	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	879179	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879180	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879181	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	879182	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879183	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879184	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879185	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879186	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879187	01/2013	01/07/2013	100.070	99.970	99.9	1
LG&E	C1S	879188	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879189	01/2013	01/07/2013	100.070	99.950	99.9	1
LG&E	C1S	879190	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879191	01/2013	01/07/2013	100.100	99.910	100.0	1
LG&E	C1S	879192	01/2013	01/07/2013	100.080	99.880	100.0	1
LG&E	C1S	879193	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879194	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879195	01/2013	01/07/2013	100.060	99.940	99.9	1
LG&E	C1S	879196	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879197	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879198	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879199	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	879200	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	879201	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	879202	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879203	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879204	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879205	01/2013	01/07/2013	100.060	99.930	100.0	1

LG&E	C1S	879206	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	879207	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879208	01/2013	01/07/2013	100.100	99.930	100.0	1
LG&E	C1S	879209	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	879210	01/2013	01/07/2013	100.070	99.880	100.0	1
LG&E	C1S	879211	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879212	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	879213	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879214	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879215	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879216	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879217	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	879218	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879219	01/2013	01/07/2013	100.100	99.930	100.0	1
LG&E	C1S	879220	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	879221	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	879222	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879223	01/2013	01/07/2013	100.050	99.980	100.0	1
LG&E	C1S	879224	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879225	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879226	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	879227	01/2013	01/07/2013	100.100	100.000	99.9	1
LG&E	C1S	879228	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879229	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	879230	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879231	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	879232	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	879233	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879234	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879235	01/2013	01/07/2013	100.090	99.950	100.1	1

LG&E	C1S	879236	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879237	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	879238	01/2013	01/07/2013	100.050	100.010	100.1	1
LG&E	C1S	879239	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879240	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879241	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879242	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879243	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879244	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879245	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879246	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	879247	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879248	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879249	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879250	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879251	01/2013	01/07/2013	100.080	100.040	100.0	1
LG&E	C1S	879252	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	879253	01/2013	01/07/2013	100.060	99.870	100.0	1
LG&E	C1S	879254	01/2013	01/07/2013	100.070	100.060	100.1	1
LG&E	C1S	879255	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879256	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	879257	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879258	01/2013	01/07/2013	100.050	99.840	100.0	1
LG&E	C1S	879259	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879260	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879261	01/2013	01/07/2013	100.070	99.880	100.0	1
LG&E	C1S	879262	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	879263	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879264	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879265	01/2013	01/07/2013	100.080	99.890	100.0	1

LG&E	C1S	879266	01/2013	01/07/2013	100.070	100.010	100.0	1
LG&E	C1S	879267	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	879268	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	879269	01/2013	01/07/2013	100.100	100.030	100.0	1
LG&E	C1S	879270	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879271	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879272	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879273	01/2013	01/07/2013	100.080	99.980	100.2	1
LG&E	C1S	879274	01/2013	01/07/2013	100.080	100.020	100.0	1
LG&E	C1S	879275	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879276	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879277	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879278	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879279	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879280	01/2013	01/07/2013	100.110	99.900	100.0	1
LG&E	C1S	879281	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879282	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879283	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879284	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879285	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879286	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879287	01/2013	01/07/2013	100.060	99.860	100.1	1
LG&E	C1S	879288	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879289	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879290	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879291	01/2013	01/07/2013	100.070	100.040	100.0	1
LG&E	C1S	879292	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879293	01/2013	01/07/2013	100.090	99.900	100.0	1
LG&E	C1S	879294	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879295	01/2013	01/07/2013	100.090	99.940	100.1	1

LG&E	C1S	879296	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	879297	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879298	01/2013	01/07/2013	100.050	99.880	100.1	1
LG&E	C1S	879299	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	879300	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	879301	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	879302	01/2013	01/07/2013	100.100	100.010	100.0	1
LG&E	C1S	879303	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879304	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879305	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879306	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	879307	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	879308	01/2013	01/07/2013	100.090	99.970	100.2	1
LG&E	C1S	879309	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879310	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879311	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	879312	01/2013	01/07/2013	100.100	100.060	100.1	1
LG&E	C1S	879313	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879314	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879315	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879316	01/2013	01/07/2013	100.050	100.040	100.1	1
LG&E	C1S	879317	01/2013	01/07/2013	100.090	100.010	100.1	1
LG&E	C1S	879318	01/2013	01/07/2013	100.080	100.020	100.1	1
LG&E	C1S	879319	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879320	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	879321	01/2013	01/07/2013	100.090	99.900	100.0	1
LG&E	C1S	879322	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879323	01/2013	01/07/2013	100.080	100.040	100.0	1
LG&E	C1S	879324	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	879325	01/2013	01/07/2013	100.070	99.980	100.0	1

LG&E	C1S	879326	01/2013	01/07/2013	100.080	99.870	100.1	1
LG&E	C1S	879327	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879328	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879329	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879330	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879331	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879332	01/2013	01/07/2013	100.070	99.870	100.1	1
LG&E	C1S	879333	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879334	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879335	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879336	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	879337	01/2013	01/07/2013	100.080	99.900	100.1	1
LG&E	C1S	879338	01/2013	01/07/2013	100.060	99.820	100.1	1
LG&E	C1S	879339	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879340	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879341	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	879342	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	879343	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879344	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	879345	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879346	01/2013	01/07/2013	100.100	100.020	100.0	1
LG&E	C1S	879347	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879348	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879349	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	879350	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879351	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	879352	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879353	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879354	01/2013	01/07/2013	100.050	99.890	99.9	1
LG&E	C1S	879355	01/2013	01/07/2013	100.090	99.980	100.1	1

LG&E	C1S	879356	01/2013	01/07/2013	100.090	100.030	100.1	1
LG&E	C1S	879357	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879358	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	879359	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	879360	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879361	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	879362	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879363	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879364	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879365	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879366	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879367	01/2013	01/07/2013	100.060	99.910	99.9	1
LG&E	C1S	879368	01/2013	01/07/2013	100.050	99.980	100.0	1
LG&E	C1S	879369	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879370	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879371	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879372	01/2013	01/07/2013	100.080	100.020	100.0	1
LG&E	C1S	879373	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879374	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	879375	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879376	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879377	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879378	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879379	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	879380	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	879381	01/2013	01/07/2013	100.060	99.880	100.1	1
LG&E	C1S	879382	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	879383	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	879384	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879385	01/2013	01/07/2013	100.050	99.920	99.9	1

LG&E	C1S	879386	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	879387	01/2013	01/07/2013	100.100	100.070	100.2	1
LG&E	C1S	879388	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	879389	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	879390	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	879391	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879392	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879393	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879394	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	879395	01/2013	01/07/2013	100.080	100.000	100.2	1
LG&E	C1S	879396	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879397	01/2013	01/07/2013	100.050	99.980	100.1	1
LG&E	C1S	879398	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	879399	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879400	01/2013	01/07/2013	100.100	99.950	100.0	1
LG&E	C1S	879401	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	879402	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	879403	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879404	01/2013	01/07/2013	100.050	99.980	99.9	1
LG&E	C1S	879405	01/2013	01/07/2013	100.050	99.980	100.0	1
LG&E	C1S	879406	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879407	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879408	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879409	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879410	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879411	01/2013	01/07/2013	100.080	99.920	99.9	1
LG&E	C1S	879412	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879413	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879414	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879415	01/2013	01/07/2013	100.090	99.930	100.1	1

LG&E	C1S	879416	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	879417	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879418	01/2013	01/07/2013	100.070	100.030	100.1	1
LG&E	C1S	879419	01/2013	01/07/2013	100.080	99.990	99.9	1
LG&E	C1S	879420	01/2013	01/07/2013	100.050	99.890	100.0	1
LG&E	C1S	879421	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879422	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879423	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879424	01/2013	01/07/2013	100.070	100.020	100.1	1
LG&E	C1S	879425	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879426	01/2013	01/07/2013	100.050	99.920	100.0	1
LG&E	C1S	879427	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	879428	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	879429	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879430	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879431	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879432	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879433	01/2013	01/07/2013	100.090	99.900	100.0	1
LG&E	C1S	879434	01/2013	01/07/2013	100.050	99.890	100.0	1
LG&E	C1S	879435	01/2013	01/07/2013	100.080	99.860	100.0	1
LG&E	C1S	879436	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879437	01/2013	01/07/2013	100.090	100.040	100.1	1
LG&E	C1S	879438	01/2013	01/07/2013	100.070	99.930	99.9	1
LG&E	C1S	879439	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879440	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879441	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879442	01/2013	01/07/2013	100.100	99.990	100.0	1
LG&E	C1S	879443	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879444	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879445	01/2013	01/07/2013	100.070	99.950	100.0	1

LG&E	C1S	879446	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879447	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879448	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879449	01/2013	01/07/2013	100.060	99.890	99.9	1
LG&E	C1S	879450	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	879451	01/2013	01/07/2013	100.070	100.030	100.0	1
LG&E	C1S	879452	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879453	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	879454	01/2013	01/07/2013	100.050	99.950	99.9	1
LG&E	C1S	879455	01/2013	01/07/2013	100.100	100.020	100.2	1
LG&E	C1S	879456	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879457	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	879458	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	879459	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879460	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879461	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879462	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879463	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879464	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879465	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879466	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879467	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879468	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	879469	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879470	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879471	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879472	01/2013	01/07/2013	100.080	99.920	100.2	1
LG&E	C1S	879473	01/2013	01/07/2013	100.100	99.990	100.0	1
LG&E	C1S	879474	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879475	01/2013	01/07/2013	100.070	99.960	100.0	1

LG&E	C1S	879476	01/2013	01/07/2013	100.060	99.860	100.0	1
LG&E	C1S	879477	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879478	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879479	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879480	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879481	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879482	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	879483	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879484	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879485	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879486	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879487	01/2013	01/07/2013	100.090	99.870	100.0	1
LG&E	C1S	879488	01/2013	01/07/2013	100.050	99.940	99.9	1
LG&E	C1S	879489	01/2013	01/07/2013	100.070	99.840	100.0	1
LG&E	C1S	879490	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	879491	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	879492	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	879493	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	879494	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	879495	01/2013	01/07/2013	100.050	99.870	100.0	1
LG&E	C1S	879496	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879497	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879498	01/2013	01/07/2013	100.060	99.870	99.9	1
LG&E	C1S	879499	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879500	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879501	01/2013	01/07/2013	100.100	100.030	100.0	1
LG&E	C1S	879502	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	879503	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879504	01/2013	01/07/2013	100.060	99.950	99.9	1
LG&E	C1S	879505	01/2013	01/07/2013	100.100	99.970	100.0	1

LG&E	C1S	879506	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879507	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	879508	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879509	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879510	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879511	01/2013	01/07/2013	100.090	100.030	100.1	1
LG&E	C1S	879512	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	879513	01/2013	01/07/2013	100.050	99.870	100.1	1
LG&E	C1S	879514	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	879515	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879516	01/2013	01/07/2013	100.080	99.970	99.9	1
LG&E	C1S	879517	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	879518	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879519	01/2013	01/07/2013	100.100	99.950	100.0	1
LG&E	C1S	879520	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	879521	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879522	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	879523	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	879524	01/2013	01/07/2013	100.080	100.030	99.9	1
LG&E	C1S	879525	01/2013	01/07/2013	100.070	100.080	100.0	1
LG&E	C1S	879526	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879527	01/2013	01/07/2013	100.090	100.040	100.1	1
LG&E	C1S	879528	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879529	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	879530	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879531	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879532	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879533	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879534	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879535	01/2013	01/07/2013	100.090	99.930	100.1	1

LG&E	C1S	879536	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879537	01/2013	01/07/2013	100.050	99.870	100.1	1
LG&E	C1S	879538	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879539	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	879540	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879541	01/2013	01/07/2013	100.090	100.050	100.1	1
LG&E	C1S	879542	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879543	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879544	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	879545	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	879546	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879547	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879548	01/2013	01/07/2013	100.060	99.890	100.1	1
LG&E	C1S	879549	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	879550	01/2013	01/07/2013	100.070	99.880	100.0	1
LG&E	C1S	879551	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879552	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879553	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879554	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	879555	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	879556	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	879557	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879558	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879559	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	879560	01/2013	01/07/2013	100.100	99.970	100.2	1
LG&E	C1S	879561	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879562	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879563	01/2013	01/07/2013	100.050	99.890	100.1	1
LG&E	C1S	879564	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879565	01/2013	01/07/2013	100.060	99.930	100.0	1

LG&E	C1S	879566	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	879567	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879568	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879569	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	879570	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	879571	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879572	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	879573	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879574	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	879575	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	879576	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	879577	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879578	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879579	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879580	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879581	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879582	01/2013	01/07/2013	100.090	100.030	100.1	1
LG&E	C1S	879583	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879584	01/2013	01/07/2013	100.050	100.010	100.1	1
LG&E	C1S	879585	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879586	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879587	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879588	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879589	01/2013	01/07/2013	100.060	99.930	100.2	1
LG&E	C1S	879590	01/2013	01/07/2013	100.060	99.990	99.9	1
LG&E	C1S	879591	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879592	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879593	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	879594	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879595	01/2013	01/07/2013	100.050	99.930	100.0	1

LG&E	C1S	879596	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	879597	01/2013	01/07/2013	100.100	100.020	100.0	1
LG&E	C1S	879598	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879599	01/2013	01/07/2013	100.050	99.880	100.0	1
LG&E	C1S	879600	01/2013	01/07/2013	100.050	99.950	100.1	1
LG&E	C1S	879601	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	879602	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	879603	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	879604	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	879605	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879606	01/2013	01/07/2013	100.070	100.010	100.0	1
LG&E	C1S	879607	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	879608	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879609	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	879610	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	879611	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879612	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	879613	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	879614	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879615	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	879616	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879617	01/2013	01/07/2013	100.060	99.890	99.9	1
LG&E	C1S	879618	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879619	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879620	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	879621	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879622	01/2013	01/07/2013	100.070	99.920	99.9	1
LG&E	C1S	879623	01/2013	01/07/2013	100.090	100.040	100.0	1
LG&E	C1S	879624	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	879625	01/2013	01/07/2013	100.080	99.970	100.1	1

LG&E	C1S	879626	01/2013	01/07/2013	100.100	99.990	100.2	1
LG&E	C1S	879627	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879628	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879629	01/2013	01/07/2013	100.080	99.860	100.1	1
LG&E	C1S	879630	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879631	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	879632	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879633	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879634	01/2013	01/07/2013	100.100	99.910	100.2	1
LG&E	C1S	879635	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879636	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	879637	01/2013	01/07/2013	100.050	99.890	100.0	1
LG&E	C1S	879638	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879639	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	879640	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879641	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	879642	01/2013	01/07/2013	100.050	99.960	100.1	1
LG&E	C1S	879643	01/2013	01/07/2013	100.070	100.030	100.0	1
LG&E	C1S	879644	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879645	01/2013	01/07/2013	100.050	99.860	100.1	1
LG&E	C1S	879646	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879647	01/2013	01/07/2013	100.100	99.890	100.0	1
LG&E	C1S	879648	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	879649	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	879650	01/2013	01/07/2013	100.050	99.960	100.1	1
LG&E	C1S	879651	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879652	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879653	01/2013	01/07/2013	100.100	99.870	100.1	1
LG&E	C1S	879654	01/2013	01/07/2013	100.050	99.920	100.0	1
LG&E	C1S	879655	01/2013	01/07/2013	100.060	100.030	100.2	1

LG&E	C1S	879656	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	879657	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879658	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	879659	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879660	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	879661	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	879662	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879663	01/2013	01/07/2013	100.100	99.910	100.1	1
LG&E	C1S	879664	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879665	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879666	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	879667	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	879668	01/2013	01/07/2013	100.050	99.970	100.1	1
LG&E	C1S	879669	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879670	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879671	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	879672	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879673	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879674	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879675	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	879676	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879677	01/2013	01/07/2013	100.100	99.970	99.9	1
LG&E	C1S	879678	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	879679	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879680	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	879681	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879682	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879683	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879684	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879685	01/2013	01/07/2013	100.090	99.930	100.1	1

LG&E	C1S	879686	01/2013	01/07/2013	100.060	99.880	99.9	1
LG&E	C1S	879687	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879688	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	879689	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	879690	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879691	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879692	01/2013	01/07/2013	100.070	99.880	100.0	1
LG&E	C1S	879693	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879694	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879695	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	879696	01/2013	01/07/2013	100.050	99.870	100.0	1
LG&E	C1S	879697	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879698	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879699	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879700	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879701	01/2013	01/07/2013	100.060	99.990	100.0	1
LG&E	C1S	879702	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879703	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879704	01/2013	01/07/2013	100.060	99.890	100.1	1
LG&E	C1S	879705	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	879706	01/2013	01/07/2013	100.090	100.010	100.1	1
LG&E	C1S	879707	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879708	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879709	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879710	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879711	01/2013	01/07/2013	100.090	99.910	100.0	1
LG&E	C1S	879712	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879713	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879714	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	879715	01/2013	01/07/2013	100.050	99.910	100.0	1

LG&E	C1S	879716	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879717	01/2013	01/07/2013	100.050	99.880	99.9	1
LG&E	C1S	879718	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879719	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	879720	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879721	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879722	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879723	01/2013	01/07/2013	100.080	99.900	100.1	1
LG&E	C1S	879724	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879725	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879726	01/2013	01/07/2013	100.050	99.910	100.1	1
LG&E	C1S	879727	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879728	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	879729	01/2013	01/07/2013	100.100	99.980	100.2	1
LG&E	C1S	879730	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879731	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	879732	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879733	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	879734	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	879735	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879736	01/2013	01/07/2013	100.090	99.980	100.2	1
LG&E	C1S	879737	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	879738	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879739	01/2013	01/07/2013	100.100	99.910	100.1	1
LG&E	C1S	879740	01/2013	01/07/2013	100.060	99.860	100.0	1
LG&E	C1S	879741	01/2013	01/07/2013	100.060	99.940	99.9	1
LG&E	C1S	879742	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	879743	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879744	01/2013	01/07/2013	100.070	99.890	100.1	1
LG&E	C1S	879745	01/2013	01/07/2013	100.090	99.990	100.1	1

LG&E	C1S	879746	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879747	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879748	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879749	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879750	01/2013	01/07/2013	100.090	99.970	99.9	1
LG&E	C1S	879751	01/2013	01/07/2013	100.090	100.050	100.1	1
LG&E	C1S	879752	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	879753	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879754	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879755	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879756	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	879757	01/2013	01/07/2013	100.090	99.910	100.0	1
LG&E	C1S	879758	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	879759	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	879760	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879761	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879762	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879763	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	879764	01/2013	01/07/2013	100.100	100.030	100.2	1
LG&E	C1S	879765	01/2013	01/07/2013	100.070	99.820	100.1	1
LG&E	C1S	879766	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	879767	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	879768	01/2013	01/07/2013	100.060	100.010	100.1	1
LG&E	C1S	879769	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	879770	01/2013	01/07/2013	100.100	99.990	100.1	1
LG&E	C1S	879771	01/2013	01/07/2013	100.090	99.940	99.9	1
LG&E	C1S	879772	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879773	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	879774	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879775	01/2013	01/07/2013	100.090	99.980	100.0	1

LG&E	C1S	879776	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879777	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879778	01/2013	01/07/2013	100.050	99.960	100.1	1
LG&E	C1S	879779	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879780	01/2013	01/07/2013	100.080	99.870	100.1	1
LG&E	C1S	879781	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	879782	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879783	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879784	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	879785	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879786	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879787	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879788	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879789	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	879790	01/2013	01/07/2013	100.050	99.970	100.0	1
LG&E	C1S	879791	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879792	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879793	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879794	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879795	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	879796	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	879797	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879798	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879799	01/2013	01/07/2013	100.080	100.040	100.0	1
LG&E	C1S	879800	01/2013	01/07/2013	100.100	99.950	100.0	1
LG&E	C1S	879801	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879802	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	879803	01/2013	01/07/2013	100.070	100.010	100.0	1
LG&E	C1S	879804	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879805	01/2013	01/07/2013	100.050	99.880	100.1	1

LG&E	C1S	879806	01/2013	01/07/2013	100.080	100.030	100.1	1
LG&E	C1S	879807	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	879808	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879809	01/2013	01/07/2013	100.090	99.960	100.2	1
LG&E	C1S	879810	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879811	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879812	01/2013	01/07/2013	100.080	100.020	100.0	1
LG&E	C1S	879813	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879814	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	879815	01/2013	01/07/2013	100.060	99.930	99.9	1
LG&E	C1S	879816	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879817	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879818	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879819	01/2013	01/07/2013	100.060	99.830	100.0	1
LG&E	C1S	879820	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	879821	01/2013	01/07/2013	100.080	99.890	100.0	1
LG&E	C1S	879822	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	879823	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879824	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879825	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879826	01/2013	01/07/2013	100.050	99.870	100.0	1
LG&E	C1S	879827	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879828	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	879829	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879830	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879831	01/2013	01/07/2013	100.100	100.020	100.0	1
LG&E	C1S	879832	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879833	01/2013	01/07/2013	100.080	100.020	100.1	1
LG&E	C1S	879834	01/2013	01/07/2013	100.060	99.980	100.0	1
LG&E	C1S	879835	01/2013	01/07/2013	100.060	99.900	100.0	1

LG&E	C1S	879836	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879837	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879838	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	879839	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879840	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	879841	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879842	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879843	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	879844	01/2013	01/07/2013	100.060	100.020	100.0	1
LG&E	C1S	879845	01/2013	01/07/2013	100.090	99.950	100.2	1
LG&E	C1S	879846	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	879847	01/2013	01/07/2013	100.100	99.950	100.2	1
LG&E	C1S	879848	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879849	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	879850	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	879851	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879852	01/2013	01/07/2013	100.060	99.900	99.9	1
LG&E	C1S	879853	01/2013	01/07/2013	100.090	99.990	100.0	1
LG&E	C1S	879854	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879855	01/2013	01/07/2013	100.080	99.870	100.1	1
LG&E	C1S	879856	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879857	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879858	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879859	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879860	01/2013	01/07/2013	100.050	100.000	100.0	1
LG&E	C1S	879861	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	879862	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	879863	01/2013	01/07/2013	100.050	99.890	100.1	1
LG&E	C1S	879864	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	879865	01/2013	01/07/2013	100.100	99.980	100.2	1

LG&E	C1S	879866	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879867	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879868	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	879869	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	879870	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879871	01/2013	01/07/2013	100.100	99.900	100.2	1
LG&E	C1S	879872	01/2013	01/07/2013	100.090	99.890	100.0	1
LG&E	C1S	879873	01/2013	01/07/2013	100.050	100.000	100.0	1
LG&E	C1S	879874	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879875	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879876	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	879877	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	879878	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879879	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	879880	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	879881	01/2013	01/07/2013	100.060	99.900	99.9	1
LG&E	C1S	879882	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879883	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	879884	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	879885	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	879886	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879887	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	879888	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	879889	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879890	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879891	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	879892	01/2013	01/07/2013	100.050	99.930	100.1	1
LG&E	C1S	879893	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	879894	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	879895	01/2013	01/07/2013	100.070	100.020	100.0	1

LG&E	C1S	879896	01/2013	01/07/2013	100.080	99.940	100.0
LG&E	C1S	879897	01/2013	01/07/2013	100.060	99.870	100.0
LG&E	C1S	879898	01/2013	01/07/2013	100.090	99.900	100.0
LG&E	C1S	879899	01/2013	01/07/2013	100.070	99.950	100.0
LG&E	C1S	879900	01/2013	01/07/2013	100.070	99.870	100.0
LG&E	C1S	879901	01/2013	01/07/2013	100.090	99.940	100.1
LG&E	C1S	879902	01/2013	01/07/2013	100.070	99.960	100.0
LG&E	C1S	879903	01/2013	01/07/2013	100.080	99.970	100.1
LG&E	C1S	879904	01/2013	01/07/2013	100.090	100.010	100.1
LG&E	C1S	879905	01/2013	01/07/2013	100.080	100.000	100.0
LG&E	C1S	879906	01/2013	01/07/2013	100.060	99.850	99.9
LG&E	C1S	879907	01/2013	01/07/2013	100.090	99.970	99.9
LG&E	C1S	879908	01/2013	01/07/2013	100.080	99.910	100.2
LG&E	C1S	879909	01/2013	01/07/2013	100.090	99.960	100.0
LG&E	C1S	879910	01/2013	01/07/2013	100.060	99.940	100.0
LG&E	C1S	879911	01/2013	01/07/2013	100.100	100.010	100.1
LG&E	C1S	879912	01/2013	01/07/2013	100.090	99.950	100.0
LG&E	C1S	879913	01/2013	01/07/2013	100.100	100.020	100.0
LG&E	C1S	879914	01/2013	01/07/2013	100.080	99.980	100.1
LG&E	C1S	879915	01/2013	01/07/2013	100.100	100.030	100.0
LG&E	C1S	879916	01/2013	01/07/2013	100.100	99.940	100.0
LG&E	C1S	879917	01/2013	01/07/2013	100.080	100.020	100.1
LG&E	C1S	879918	01/2013	01/07/2013	100.050	99.880	100.0
LG&E	C1S	879919	01/2013	01/07/2013	100.070	99.920	100.1
LG&E	C1S	879920	01/2013	01/07/2013	100.060	99.970	99.9
LG&E	C1S	879921	01/2013	01/07/2013	100.080	99.940	100.1
LG&E	C1S	879922	01/2013	01/07/2013	100.060	99.900	99.9
LG&E	C1S	879923	01/2013	01/07/2013	100.070	99.990	100.0
LG&E	C1S	879924	01/2013	01/07/2013	100.080	100.040	100.1
LG&E	C1S	879925	01/2013	01/07/2013	100.080	99.990	100.2

LG&E	C1S	879926	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	879927	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	879928	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	879929	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	879930	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	879931	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	879932	01/2013	01/07/2013	100.070	100.040	100.0	1
LG&E	C1S	879933	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879934	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879935	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	879936	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879937	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879938	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	879939	01/2013	01/07/2013	100.080	99.990	99.9	1
LG&E	C1S	879940	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	879941	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	879942	01/2013	01/07/2013	100.060	99.870	100.0	1
LG&E	C1S	879943	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879944	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	879945	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	879946	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	879947	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	879948	01/2013	01/07/2013	100.070	99.920	99.9	1
LG&E	C1S	879949	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	879950	01/2013	01/07/2013	100.050	99.850	100.0	1
LG&E	C1S	879951	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	879952	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879953	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	879954	01/2013	01/07/2013	100.080	100.040	100.1	1
LG&E	C1S	879955	01/2013	01/07/2013	100.090	99.910	100.1	1

LG&E	C1S	879956	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	879957	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	879958	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	879959	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	879960	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	879961	01/2013	01/07/2013	100.070	100.060	100.1	1
LG&E	C1S	879962	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	879963	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	879964	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879965	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	879966	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	879967	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	879968	01/2013	01/07/2013	100.090	99.910	100.0	1
LG&E	C1S	879969	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	879970	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	879971	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	879972	01/2013	01/07/2013	100.100	100.010	100.0	1
LG&E	C1S	879973	01/2013	01/07/2013	100.070	99.930	99.9	1
LG&E	C1S	879974	01/2013	01/07/2013	100.090	100.060	100.0	1
LG&E	C1S	879975	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	879976	01/2013	01/07/2013	100.090	100.030	100.0	1
LG&E	C1S	879977	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	879978	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	879979	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	879980	01/2013	01/07/2013	100.060	100.040	100.0	1
LG&E	C1S	879981	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	879982	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	879983	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	879984	01/2013	01/07/2013	100.050	99.890	100.1	1
LG&E	C1S	879985	01/2013	01/07/2013	100.060	99.910	100.1	1

LG&E	C1S	879986	01/2013	01/07/2013	100.080	99.890	100.0	1
LG&E	C1S	879987	01/2013	01/07/2013	100.090	99.900	100.1	1
LG&E	C1S	879988	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	879989	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	879990	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	879991	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	879992	01/2013	01/07/2013	100.100	99.940	100.0	1
LG&E	C1S	879993	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	879994	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	879995	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	879996	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	879997	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	879998	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	879999	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	880000	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	880001	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	880002	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	880003	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880004	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	880005	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	880006	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	880007	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	880008	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	880009	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880010	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	880011	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	880012	01/2013	01/07/2013	100.100	100.050	100.0	1
LG&E	C1S	880013	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880014	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	880015	01/2013	01/07/2013	100.080	100.030	100.1	1

LG&E	C1S	880016	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	880017	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	880018	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	880019	01/2013	01/07/2013	100.100	99.900	100.0	1
LG&E	C1S	880020	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	880021	01/2013	01/07/2013	100.060	99.870	100.0	1
LG&E	C1S	880022	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880023	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	880024	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	880025	01/2013	01/07/2013	100.050	99.880	100.0	1
LG&E	C1S	880026	01/2013	01/07/2013	100.060	99.960	99.9	1
LG&E	C1S	880027	01/2013	01/07/2013	100.070	99.880	100.1	1
LG&E	C1S	880028	01/2013	01/07/2013	100.100	99.940	100.2	1
LG&E	C1S	880029	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	880030	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	880031	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	880032	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	880033	01/2013	01/07/2013	100.060	99.910	99.9	1
LG&E	C1S	880034	01/2013	01/07/2013	100.090	99.870	100.1	1
LG&E	C1S	880035	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	880036	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880037	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880038	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	880039	01/2013	01/07/2013	100.100	99.970	100.0	1
LG&E	C1S	880040	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	880041	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	880042	01/2013	01/07/2013	100.090	99.910	100.0	1
LG&E	C1S	880043	01/2013	01/07/2013	100.070	100.000	100.1	1
LG&E	C1S	880044	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	880045	01/2013	01/07/2013	100.070	100.010	100.0	1

LG&E	C1S	880046	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	880047	01/2013	01/07/2013	100.060	100.030	100.1	1
LG&E	C1S	880048	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880049	01/2013	01/07/2013	100.070	99.980	100.2	1
LG&E	C1S	880050	01/2013	01/07/2013	100.090	100.010	100.2	1
LG&E	C1S	880051	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	880052	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	880053	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	880054	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	880055	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	880056	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	880057	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	880058	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	880059	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	880060	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	880061	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880062	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	880063	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880064	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	880065	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	880066	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	880067	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	880068	01/2013	01/07/2013	100.090	99.900	100.0	1
LG&E	C1S	880069	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	880070	01/2013	01/07/2013	100.080	99.890	100.1	1
LG&E	C1S	880071	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	880072	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	880073	01/2013	01/07/2013	100.050	99.810	100.1	1
LG&E	C1S	880074	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	880075	01/2013	01/07/2013	100.080	99.940	100.0	1

LG&E	C1S	880076	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	880077	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880078	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	880079	01/2013	01/07/2013	100.070	99.880	100.1	1
LG&E	C1S	880080	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	880081	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	880082	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880083	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	880084	01/2013	01/07/2013	100.090	99.900	100.0	1
LG&E	C1S	880085	01/2013	01/07/2013	100.090	99.890	100.0	1
LG&E	C1S	880086	01/2013	01/07/2013	100.090	99.920	100.0	1
LG&E	C1S	880087	01/2013	01/07/2013	100.070	99.970	100.1	1
LG&E	C1S	880088	01/2013	01/07/2013	100.090	99.970	100.0	1
LG&E	C1S	880089	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	880090	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	880091	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880092	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	880093	01/2013	01/07/2013	100.090	99.930	99.9	1
LG&E	C1S	880094	01/2013	01/07/2013	100.060	99.890	100.1	1
LG&E	C1S	880095	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	880096	01/2013	01/07/2013	100.080	99.920	100.0	1
LG&E	C1S	880097	01/2013	01/07/2013	100.070	99.880	100.1	1
LG&E	C1S	880098	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	880099	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	880100	01/2013	01/07/2013	100.100	99.910	100.1	1
LG&E	C1S	880101	01/2013	01/07/2013	100.100	99.920	100.1	1
LG&E	C1S	880102	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	880103	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	880104	01/2013	01/07/2013	100.100	100.010	100.1	1
LG&E	C1S	880105	01/2013	01/07/2013	100.090	99.910	100.0	1

LG&E	C1S	880106	01/2013	01/07/2013	100.100	99.970	100.1	1
LG&E	C1S	880107	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	880108	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880109	01/2013	01/07/2013	100.080	100.020	100.0	1
LG&E	C1S	880110	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	880111	01/2013	01/07/2013	100.100	99.900	100.0	1
LG&E	C1S	880112	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	880113	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	880114	01/2013	01/07/2013	100.060	100.000	100.1	1
LG&E	C1S	880115	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	880116	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	880117	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880118	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	880119	01/2013	01/07/2013	100.110	99.970	100.1	1
LG&E	C1S	880120	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880121	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	880122	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	880123	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	880124	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	880125	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880126	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	880127	01/2013	01/07/2013	100.050	99.920	100.0	1
LG&E	C1S	880128	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	880129	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	880130	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	880131	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	880132	01/2013	01/07/2013	100.070	99.920	100.2	1
LG&E	C1S	880133	01/2013	01/07/2013	100.060	99.870	100.0	1
LG&E	C1S	880134	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	880135	01/2013	01/07/2013	100.100	100.030	100.1	1

LG&E	C1S	880136	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	880137	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	880138	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	880139	01/2013	01/07/2013	100.090	99.960	100.2	1
LG&E	C1S	880140	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	880141	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	880142	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880143	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880144	01/2013	01/07/2013	100.070	100.000	100.0	1
LG&E	C1S	880145	01/2013	01/07/2013	100.100	100.000	100.1	1
LG&E	C1S	880146	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880147	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	880148	01/2013	01/07/2013	100.070	99.920	100.1	1
LG&E	C1S	880149	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	880150	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	880151	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880152	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	880153	01/2013	01/07/2013	100.060	99.820	100.0	1
LG&E	C1S	880154	01/2013	01/07/2013	100.060	99.960	100.0	1
LG&E	C1S	880155	01/2013	01/07/2013	100.090	99.940	100.0	1
LG&E	C1S	880156	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	880157	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	880158	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	880159	01/2013	01/07/2013	100.100	99.930	100.1	1
LG&E	C1S	880160	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	880161	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	880162	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	880163	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	880164	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	880165	01/2013	01/07/2013	100.100	99.990	100.1	1

LG&E	C1S	880166	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880167	01/2013	01/07/2013	100.090	100.010	100.0	1
LG&E	C1S	880168	01/2013	01/07/2013	100.090	99.960	100.0	1
LG&E	C1S	880169	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	880170	01/2013	01/07/2013	100.080	99.930	100.0	1
LG&E	C1S	880171	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	880172	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880173	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880174	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	880175	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	880176	01/2013	01/07/2013	100.090	100.000	100.2	1
LG&E	C1S	880177	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	880178	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	880179	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880180	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	880181	01/2013	01/07/2013	100.050	99.960	100.0	1
LG&E	C1S	880182	01/2013	01/07/2013	100.060	99.990	100.1	1
LG&E	C1S	880183	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	880184	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	880185	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880186	01/2013	01/07/2013	100.090	100.050	100.1	1
LG&E	C1S	880187	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880188	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	880189	01/2013	01/07/2013	100.080	99.980	100.1	1
LG&E	C1S	880190	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	880191	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880192	01/2013	01/07/2013	100.050	99.850	100.1	1
LG&E	C1S	880193	01/2013	01/07/2013	100.060	99.990	100.2	1
LG&E	C1S	880194	01/2013	01/07/2013	100.070	99.960	99.9	1
LG&E	C1S	880195	01/2013	01/07/2013	100.080	99.950	100.0	1

LG&E	C1S	880196	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	880197	01/2013	01/07/2013	100.100	100.040	100.0	1
LG&E	C1S	880198	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880199	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	880200	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	880201	01/2013	01/07/2013	100.080	99.890	100.0	1
LG&E	C1S	880202	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	880203	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880204	01/2013	01/07/2013	100.070	99.960	100.0	1
LG&E	C1S	880205	01/2013	01/07/2013	100.050	99.950	99.9	1
LG&E	C1S	880206	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	880207	01/2013	01/07/2013	100.060	99.950	100.0	1
LG&E	C1S	880208	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	880209	01/2013	01/07/2013	100.060	99.910	100.0	1
LG&E	C1S	880210	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880211	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	880212	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880213	01/2013	01/07/2013	100.080	100.010	100.0	1
LG&E	C1S	880214	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	880215	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	880216	01/2013	01/07/2013	100.080	99.860	100.0	1
LG&E	C1S	880217	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880218	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	880219	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	880220	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	880221	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880222	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	880223	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	880224	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	880225	01/2013	01/07/2013	100.070	99.920	100.0	1

LG&E	C1S	880226	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	880227	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880228	01/2013	01/07/2013	100.050	99.860	100.1	1
LG&E	C1S	880229	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	880230	01/2013	01/07/2013	100.060	100.000	100.1	1
LG&E	C1S	880231	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880232	01/2013	01/07/2013	100.080	99.970	100.2	1
LG&E	C1S	880233	01/2013	01/07/2013	100.070	99.920	100.0	1
LG&E	C1S	880234	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	880235	01/2013	01/07/2013	100.100	99.950	100.1	1
LG&E	C1S	880236	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880237	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	880238	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880239	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880240	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880241	01/2013	01/07/2013	100.100	99.960	100.0	1
LG&E	C1S	880242	01/2013	01/07/2013	100.080	100.000	100.1	1
LG&E	C1S	880243	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	880244	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	880245	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	880246	01/2013	01/07/2013	100.100	100.000	100.0	1
LG&E	C1S	880247	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880248	01/2013	01/07/2013	100.100	100.070	100.1	1
LG&E	C1S	880249	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	880250	01/2013	01/07/2013	100.080	99.950	100.0	1
LG&E	C1S	880251	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	880252	01/2013	01/07/2013	100.100	99.940	100.1	1
LG&E	C1S	880253	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880254	01/2013	01/07/2013	100.050	99.910	99.9	1
LG&E	C1S	880255	01/2013	01/07/2013	100.100	100.010	100.0	1

LG&E	C1S	880256	01/2013	01/07/2013	100.050	99.900	100.1	1
LG&E	C1S	880257	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	880258	01/2013	01/07/2013	100.080	99.910	100.1	1
LG&E	C1S	880259	01/2013	01/07/2013	100.090	99.950	100.0	1
LG&E	C1S	880260	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880261	01/2013	01/07/2013	100.100	100.010	100.0	1
LG&E	C1S	880262	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880263	01/2013	01/07/2013	100.070	99.900	100.1	1
LG&E	C1S	880264	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	880265	01/2013	01/07/2013	100.090	99.980	100.1	1
LG&E	C1S	880266	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880267	01/2013	01/07/2013	100.050	99.880	100.0	1
LG&E	C1S	880268	01/2013	01/07/2013	100.080	100.010	100.2	1
LG&E	C1S	880269	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880270	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	880271	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880272	01/2013	01/07/2013	100.060	100.000	100.0	1
LG&E	C1S	880273	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	880274	01/2013	01/07/2013	100.060	99.840	100.1	1
LG&E	C1S	880275	01/2013	01/07/2013	100.080	99.910	100.0	1
LG&E	C1S	880276	01/2013	01/07/2013	100.100	100.020	100.1	1
LG&E	C1S	880277	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880278	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	880279	01/2013	01/07/2013	100.080	99.910	100.2	1
LG&E	C1S	880280	01/2013	01/07/2013	100.060	99.920	100.0	1
LG&E	C1S	880281	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	880282	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880283	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	880284	01/2013	01/07/2013	100.070	99.990	100.0	1
LG&E	C1S	880285	01/2013	01/07/2013	100.100	99.920	100.1	1

LG&E	C1S	880286	01/2013	01/07/2013	100.090	99.930	100.1	1
LG&E	C1S	880287	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	880288	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	880289	01/2013	01/07/2013	100.060	99.960	99.9	1
LG&E	C1S	880290	01/2013	01/07/2013	100.060	99.960	100.1	1
LG&E	C1S	880291	01/2013	01/07/2013	100.070	99.930	99.9	1
LG&E	C1S	880292	01/2013	01/07/2013	100.080	99.940	100.2	1
LG&E	C1S	880293	01/2013	01/07/2013	100.090	99.950	100.2	1
LG&E	C1S	880294	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880295	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	880296	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	880297	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	880298	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	880299	01/2013	01/07/2013	100.060	99.900	100.1	1
LG&E	C1S	880300	01/2013	01/07/2013	100.080	99.930	100.2	1
LG&E	C1S	880301	01/2013	01/07/2013	100.060	99.940	100.0	1
LG&E	C1S	880302	01/2013	01/07/2013	100.060	99.940	100.1	1
LG&E	C1S	880303	01/2013	01/07/2013	100.060	99.980	100.1	1
LG&E	C1S	880304	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880305	01/2013	01/07/2013	100.100	99.980	100.0	1
LG&E	C1S	880306	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	880307	01/2013	01/07/2013	100.070	99.890	100.0	1
LG&E	C1S	880308	01/2013	01/07/2013	100.050	99.900	100.0	1
LG&E	C1S	880309	01/2013	01/07/2013	100.090	99.990	100.1	1
LG&E	C1S	880310	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880311	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880312	01/2013	01/07/2013	100.070	99.970	99.9	1
LG&E	C1S	880313	01/2013	01/07/2013	100.080	99.940	100.0	1
LG&E	C1S	880314	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880315	01/2013	01/07/2013	100.060	99.930	100.1	1

LG&E	C1S	880316	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	880317	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	880318	01/2013	01/07/2013	100.090	100.000	100.1	1
LG&E	C1S	880319	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880320	01/2013	01/07/2013	100.080	99.900	100.0	1
LG&E	C1S	880321	01/2013	01/07/2013	100.050	99.980	100.0	1
LG&E	C1S	880322	01/2013	01/07/2013	100.080	100.000	100.0	1
LG&E	C1S	880323	01/2013	01/07/2013	100.070	99.980	100.0	1
LG&E	C1S	880324	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880325	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	880326	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880327	01/2013	01/07/2013	100.060	99.890	100.0	1
LG&E	C1S	880328	01/2013	01/07/2013	100.050	99.940	100.0	1
LG&E	C1S	880329	01/2013	01/07/2013	100.050	100.000	100.1	1
LG&E	C1S	880330	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	880331	01/2013	01/07/2013	100.090	99.870	100.1	1
LG&E	C1S	880332	01/2013	01/07/2013	100.090	100.050	100.0	1
LG&E	C1S	880333	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	880334	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880335	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	880336	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880337	01/2013	01/07/2013	100.060	100.020	100.1	1
LG&E	C1S	880338	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880339	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	880340	01/2013	01/07/2013	100.100	99.950	100.2	1
LG&E	C1S	880341	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	880342	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	880343	01/2013	01/07/2013	100.080	100.010	100.0	1
LG&E	C1S	880344	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	880345	01/2013	01/07/2013	100.060	99.920	100.0	1

LG&E	C1S	880346	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	880347	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	880348	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	880349	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	880350	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	880351	01/2013	01/07/2013	100.070	99.930	100.1	1
LG&E	C1S	880352	01/2013	01/07/2013	100.070	99.970	100.0	1
LG&E	C1S	880353	01/2013	01/07/2013	100.050	100.060	100.1	1
LG&E	C1S	880354	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880355	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880356	01/2013	01/07/2013	100.070	99.900	100.0	1
LG&E	C1S	880357	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	880358	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	880359	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880360	01/2013	01/07/2013	100.080	99.970	100.1	1
LG&E	C1S	880361	01/2013	01/07/2013	100.080	99.990	100.1	1
LG&E	C1S	880362	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880363	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	880364	01/2013	01/07/2013	100.050	99.920	100.0	1
LG&E	C1S	880365	01/2013	01/07/2013	100.090	100.000	100.0	1
LG&E	C1S	880366	01/2013	01/07/2013	100.080	100.010	100.1	1
LG&E	C1S	880367	01/2013	01/07/2013	100.060	99.910	100.1	1
LG&E	C1S	880368	01/2013	01/07/2013	100.090	99.960	100.1	1
LG&E	C1S	880369	01/2013	01/07/2013	100.050	99.930	100.0	1
LG&E	C1S	880370	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	880371	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	880372	01/2013	01/07/2013	100.080	99.880	100.1	1
LG&E	C1S	880373	01/2013	01/07/2013	100.050	100.020	100.0	1
LG&E	C1S	880374	01/2013	01/07/2013	100.080	99.900	100.1	1
LG&E	C1S	880375	01/2013	01/07/2013	100.070	99.980	100.0	1

LG&E	C1S	880376	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	880377	01/2013	01/07/2013	100.050	99.910	100.0	1
LG&E	C1S	880378	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880379	01/2013	01/07/2013	100.070	99.940	100.0	1
LG&E	C1S	880380	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880381	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880382	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880383	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	880384	01/2013	01/07/2013	100.050	99.940	100.1	1
LG&E	C1S	880385	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880386	01/2013	01/07/2013	100.090	100.010	100.1	1
LG&E	C1S	880387	01/2013	01/07/2013	100.090	99.950	100.1	1
LG&E	C1S	880388	01/2013	01/07/2013	100.070	99.940	100.1	1
LG&E	C1S	880389	01/2013	01/07/2013	100.070	99.870	100.0	1
LG&E	C1S	880390	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	880391	01/2013	01/07/2013	100.060	99.880	100.0	1
LG&E	C1S	880392	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	880393	01/2013	01/07/2013	100.070	100.030	100.0	1
LG&E	C1S	880394	01/2013	01/07/2013	100.070	99.950	100.0	1
LG&E	C1S	880395	01/2013	01/07/2013	100.090	99.910	100.0	1
LG&E	C1S	880396	01/2013	01/07/2013	100.070	99.910	100.0	1
LG&E	C1S	880397	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880398	01/2013	01/07/2013	100.080	99.980	100.0	1
LG&E	C1S	880399	01/2013	01/07/2013	100.100	100.030	100.1	1
LG&E	C1S	880400	01/2013	01/07/2013	100.060	99.930	100.1	1
LG&E	C1S	880401	01/2013	01/07/2013	100.080	99.890	100.0	1
LG&E	C1S	880402	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880403	01/2013	01/07/2013	100.070	99.910	100.1	1
LG&E	C1S	880404	01/2013	01/07/2013	100.080	99.950	100.1	1
LG&E	C1S	880405	01/2013	01/07/2013	100.070	99.970	100.0	1

LG&E	C1S	880406	01/2013	01/07/2013	100.070	99.920	99.9	1
LG&E	C1S	880407	01/2013	01/07/2013	100.090	100.020	100.0	1
LG&E	C1S	880408	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	880409	01/2013	01/07/2013	100.080	99.990	100.0	1
LG&E	C1S	880410	01/2013	01/07/2013	100.080	99.880	100.0	1
LG&E	C1S	880411	01/2013	01/07/2013	100.070	99.860	100.0	1
LG&E	C1S	880412	01/2013	01/07/2013	100.060	99.950	100.1	1
LG&E	C1S	880413	01/2013	01/07/2013	100.070	99.980	100.1	1
LG&E	C1S	880414	01/2013	01/07/2013	100.060	99.880	100.1	1
LG&E	C1S	880415	01/2013	01/07/2013	100.090	100.020	100.1	1
LG&E	C1S	880416	01/2013	01/07/2013	100.060	99.900	100.0	1
LG&E	C1S	880417	01/2013	01/07/2013	100.070	99.990	100.1	1
LG&E	C1S	880418	01/2013	01/07/2013	100.080	99.930	100.1	1
LG&E	C1S	880419	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880420	01/2013	01/07/2013	100.080	99.970	100.0	1
LG&E	C1S	880421	01/2013	01/07/2013	100.090	99.890	100.1	1
LG&E	C1S	880422	01/2013	01/07/2013	100.070	99.950	100.1	1
LG&E	C1S	880423	01/2013	01/07/2013	100.050	100.010	100.0	1
LG&E	C1S	880424	01/2013	01/07/2013	100.060	99.970	100.1	1
LG&E	C1S	880425	01/2013	01/07/2013	100.080	99.960	100.0	1
LG&E	C1S	880426	01/2013	01/07/2013	100.080	99.960	100.1	1
LG&E	C1S	880427	01/2013	01/07/2013	100.080	99.940	100.1	1
LG&E	C1S	880428	01/2013	01/07/2013	100.060	99.930	100.0	1
LG&E	C1S	880429	01/2013	01/07/2013	100.060	99.970	99.9	1
LG&E	C1S	880430	01/2013	01/07/2013	100.090	99.980	100.0	1
LG&E	C1S	880431	01/2013	01/07/2013	100.090	99.920	100.1	1
LG&E	C1S	880432	01/2013	01/07/2013	100.090	99.940	100.1	1
LG&E	C1S	880433	01/2013	01/07/2013	100.090	99.910	100.1	1
LG&E	C1S	880434	01/2013	01/07/2013	100.080	99.920	100.1	1
LG&E	C1S	880435	01/2013	01/07/2013	100.050	99.830	100.1	1

LG&E	C1S	880436	01/2013	01/07/2013	100.060	99.920	100.1	1
LG&E	C1S	880437	01/2013	01/07/2013	100.070	100.010	100.1	1
LG&E	C1S	880438	01/2013	01/07/2013	100.090	99.930	100.0	1
LG&E	C1S	880439	01/2013	01/07/2013	100.060	99.970	100.0	1
LG&E	C1S	880440	01/2013	01/07/2013	100.090	99.970	100.1	1
LG&E	C1S	880441	01/2013	01/07/2013	100.070	99.930	100.0	1
LG&E	C1S	880442	01/2013	01/07/2013	100.100	99.960	100.1	1
LG&E	C1S	880443	01/2013	01/07/2013	100.060	99.830	99.9	1
LG&E	C1S	880444	01/2013	01/07/2013	100.100	99.980	100.1	1
LG&E	C1S	880445	01/2013	01/07/2013	100.070	99.920	100.2	1
LG&E	C1S	880446	01/2013	01/07/2013	100.050	99.950	100.0	1
LG&E	C1S	880447	01/2013	01/07/2013	100.070	99.960	100.1	1
LG&E	C1S	881492	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	881493	05/2013	05/14/2013	100.090	100.000	100.1	1
LG&E	C1S	881494	05/2013	05/14/2013	100.060	99.860	100.1	1
LG&E	C1S	881495	05/2013	05/14/2013	100.070	99.810	99.9	1
LG&E	C1S	881496	05/2013	05/14/2013	100.070	99.860	100.0	1
LG&E	C1S	881497	05/2013	05/14/2013	100.090	100.010	100.1	1
LG&E	C1S	881498	05/2013	05/14/2013	100.100	100.010	100.0	1
LG&E	C1S	881499	05/2013	05/14/2013	100.100	100.050	100.1	1
LG&E	C1S	881500	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	881501	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881502	05/2013	05/14/2013	100.070	99.970	100.1	1
LG&E	C1S	881503	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881504	05/2013	05/14/2013	100.080	99.940	100.0	1
LG&E	C1S	881505	05/2013	05/14/2013	100.080	100.000	100.0	1
LG&E	C1S	881506	05/2013	05/14/2013	100.080	100.000	100.0	1
LG&E	C1S	881507	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	881508	05/2013	05/14/2013	100.050	99.930	100.1	1
LG&E	C1S	881509	05/2013	05/14/2013	100.100	100.050	100.1	1

LG&E	C1S	881510	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881511	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	881512	05/2013	05/14/2013	100.070	99.900	99.9	1
LG&E	C1S	881513	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	881514	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881515	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881516	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881517	05/2013	05/14/2013	100.060	99.860	99.9	1
LG&E	C1S	881518	05/2013	05/14/2013	100.070	100.010	100.1	1
LG&E	C1S	881519	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881520	05/2013	05/14/2013	100.060	99.930	99.9	1
LG&E	C1S	881521	05/2013	05/14/2013	100.100	100.030	100.1	1
LG&E	C1S	881522	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	881523	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	881524	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881525	05/2013	05/14/2013	100.110	99.960	100.0	1
LG&E	C1S	881526	05/2013	05/14/2013	100.100	100.030	100.0	1
LG&E	C1S	881527	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	881528	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881529	05/2013	05/14/2013	100.090	99.930	100.1	1
LG&E	C1S	881530	05/2013	05/14/2013	100.090	99.860	100.0	1
LG&E	C1S	881531	05/2013	05/14/2013	100.060	99.990	100.0	1
LG&E	C1S	881532	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881533	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	881534	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881535	05/2013	05/14/2013	100.070	99.890	99.9	1
LG&E	C1S	881536	05/2013	05/14/2013	100.070	100.000	100.1	1
LG&E	C1S	881537	05/2013	05/14/2013	100.070	99.890	99.9	1
LG&E	C1S	881538	05/2013	05/14/2013	100.070	99.880	99.9	1
LG&E	C1S	881539	05/2013	05/14/2013	100.080	99.970	100.1	1

LG&E	C1S	881540	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	881541	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	881542	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	881543	05/2013	05/14/2013	100.080	99.840	99.9	1
LG&E	C1S	881544	05/2013	05/14/2013	100.100	99.880	100.1	1
LG&E	C1S	881545	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	881546	05/2013	05/14/2013	100.070	99.850	100.0	1
LG&E	C1S	881547	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	881548	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881549	05/2013	05/14/2013	100.050	99.970	99.9	1
LG&E	C1S	881550	05/2013	05/14/2013	100.100	99.900	99.9	1
LG&E	C1S	881551	05/2013	05/14/2013	100.060	99.910	99.9	1
LG&E	C1S	881552	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881553	05/2013	05/14/2013	100.090	99.970	100.1	1
LG&E	C1S	881554	05/2013	05/14/2013	100.070	99.860	100.0	1
LG&E	C1S	881555	05/2013	05/14/2013	100.060	99.970	100.0	1
LG&E	C1S	881556	05/2013	05/14/2013	100.100	99.970	100.0	1
LG&E	C1S	881557	05/2013	05/14/2013	100.090	99.860	100.0	1
LG&E	C1S	881558	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	881559	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	881560	05/2013	05/14/2013	100.090	99.950	99.9	1
LG&E	C1S	881561	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	881562	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	881563	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	881564	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881565	05/2013	05/14/2013	100.090	100.020	100.0	1
LG&E	C1S	881566	05/2013	05/14/2013	100.060	99.880	99.9	1
LG&E	C1S	881567	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	881568	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	881569	05/2013	05/14/2013	100.060	99.960	100.0	1

LG&E	C1S	881570	05/2013	05/14/2013	100.050	99.960	100.1	1
LG&E	C1S	881571	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881572	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	881573	05/2013	05/14/2013	100.090	99.860	100.0	1
LG&E	C1S	881574	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881575	05/2013	05/14/2013	100.090	99.960	100.0	1
LG&E	C1S	881576	05/2013	05/14/2013	100.080	99.960	100.1	1
LG&E	C1S	881577	05/2013	05/14/2013	100.070	99.960	100.1	1
LG&E	C1S	881578	05/2013	05/14/2013	100.070	100.040	100.1	1
LG&E	C1S	881579	05/2013	05/14/2013	100.050	99.960	100.0	1
LG&E	C1S	881580	05/2013	05/14/2013	100.100	99.910	100.0	1
LG&E	C1S	881581	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881582	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881583	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	881584	05/2013	05/14/2013	100.090	99.910	100.1	1
LG&E	C1S	881585	05/2013	05/14/2013	100.100	99.950	100.1	1
LG&E	C1S	881586	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881587	05/2013	05/14/2013	100.050	99.990	100.0	1
LG&E	C1S	881588	05/2013	05/14/2013	100.070	99.960	100.1	1
LG&E	C1S	881589	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	881590	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881591	05/2013	05/14/2013	100.050	99.810	100.0	1
LG&E	C1S	881592	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	881593	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	881594	05/2013	05/14/2013	100.100	99.970	100.0	1
LG&E	C1S	881595	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	881596	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	881597	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881598	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	881599	05/2013	05/14/2013	100.080	99.930	100.0	1

LG&E	C1S	881600	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	881601	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881602	05/2013	05/14/2013	100.100	99.900	99.9	1
LG&E	C1S	881603	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881604	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	881605	05/2013	05/14/2013	100.090	99.980	100.1	1
LG&E	C1S	881606	05/2013	05/14/2013	100.060	99.960	100.1	1
LG&E	C1S	881607	05/2013	05/14/2013	100.070	99.960	99.9	1
LG&E	C1S	881608	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881609	05/2013	05/14/2013	100.090	99.870	100.0	1
LG&E	C1S	881610	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881611	05/2013	05/14/2013	100.080	99.990	100.1	1
LG&E	C1S	881612	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881613	05/2013	05/14/2013	100.090	100.000	100.0	1
LG&E	C1S	881614	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881615	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	881616	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	881617	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881618	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881619	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	881620	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	881621	05/2013	05/14/2013	100.060	99.880	100.1	1
LG&E	C1S	881622	05/2013	05/14/2013	100.070	99.870	100.0	1
LG&E	C1S	881623	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	881624	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	881625	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881626	05/2013	05/14/2013	100.070	99.970	100.1	1
LG&E	C1S	881627	05/2013	05/14/2013	100.100	100.040	100.0	1
LG&E	C1S	881628	05/2013	05/14/2013	100.090	99.950	100.1	1
LG&E	C1S	881629	05/2013	05/14/2013	100.070	99.840	100.1	1

LG&E	C1S	881630	05/2013	05/14/2013	100.060	99.960	99.9	1
LG&E	C1S	881631	05/2013	05/14/2013	100.060	99.880	99.9	1
LG&E	C1S	881632	05/2013	05/14/2013	100.060	99.880	100.0	1
LG&E	C1S	881633	05/2013	05/14/2013	100.080	99.930	100.1	1
LG&E	C1S	881634	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881635	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881636	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881637	05/2013	05/14/2013	100.050	99.880	100.1	1
LG&E	C1S	881638	05/2013	05/14/2013	100.090	99.880	100.0	1
LG&E	C1S	881639	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	881640	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881641	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881642	05/2013	05/14/2013	100.100	99.890	99.9	1
LG&E	C1S	881643	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881644	05/2013	05/14/2013	100.050	99.990	100.0	1
LG&E	C1S	881645	05/2013	05/14/2013	100.100	99.880	100.0	1
LG&E	C1S	881646	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	881647	05/2013	05/14/2013	100.090	99.880	100.0	1
LG&E	C1S	881648	05/2013	05/14/2013	100.060	100.000	100.0	1
LG&E	C1S	881649	05/2013	05/14/2013	100.070	99.870	100.0	1
LG&E	C1S	881650	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	881651	05/2013	05/14/2013	100.090	99.960	100.0	1
LG&E	C1S	881652	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	881653	05/2013	05/14/2013	100.070	99.830	100.1	1
LG&E	C1S	881654	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881655	05/2013	05/14/2013	100.100	99.900	99.9	1
LG&E	C1S	881656	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881657	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	881658	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	881659	05/2013	05/14/2013	100.090	99.960	100.0	1

LG&E	C1S	881660	05/2013	05/14/2013	100.060	99.900	100.1	1
LG&E	C1S	881661	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881662	05/2013	05/14/2013	100.050	99.920	100.0	1
LG&E	C1S	881663	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881664	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881665	05/2013	05/14/2013	100.090	99.950	100.1	1
LG&E	C1S	881666	05/2013	05/14/2013	100.090	100.030	100.1	1
LG&E	C1S	881667	05/2013	05/14/2013	100.080	99.900	99.9	1
LG&E	C1S	881668	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	881669	05/2013	05/14/2013	100.080	99.950	100.1	1
LG&E	C1S	881670	05/2013	05/14/2013	100.050	99.860	99.9	1
LG&E	C1S	881671	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	881672	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	881673	05/2013	05/14/2013	100.080	99.990	100.1	1
LG&E	C1S	881674	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	881675	05/2013	05/14/2013	100.100	99.930	100.1	1
LG&E	C1S	881676	05/2013	05/14/2013	100.090	100.010	100.0	1
LG&E	C1S	881677	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	881678	05/2013	05/14/2013	100.090	99.960	100.0	1
LG&E	C1S	881679	05/2013	05/14/2013	100.100	99.980	100.1	1
LG&E	C1S	881680	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	881681	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	881682	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881683	05/2013	05/14/2013	100.090	100.020	100.1	1
LG&E	C1S	881684	05/2013	05/14/2013	100.070	99.880	100.0	1
LG&E	C1S	881685	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881686	05/2013	05/14/2013	100.080	99.940	100.0	1
LG&E	C1S	881687	05/2013	05/14/2013	100.060	99.990	99.9	1
LG&E	C1S	881688	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881689	05/2013	05/14/2013	100.080	99.990	100.1	1

LG&E	C1S	881690	05/2013	05/14/2013	100.060	99.990	100.0	1
LG&E	C1S	881691	05/2013	05/14/2013	100.100	100.010	100.1	1
LG&E	C1S	881692	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881693	05/2013	05/14/2013	100.070	99.950	100.1	1
LG&E	C1S	881694	05/2013	05/14/2013	100.060	99.920	99.9	1
LG&E	C1S	881695	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881696	05/2013	05/14/2013	100.050	99.910	100.0	1
LG&E	C1S	881697	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881698	05/2013	05/14/2013	100.070	99.970	100.0	1
LG&E	C1S	881699	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	881700	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	881701	05/2013	05/14/2013	100.070	99.910	100.1	1
LG&E	C1S	881702	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	881703	05/2013	05/14/2013	100.090	100.020	100.1	1
LG&E	C1S	881704	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	881705	05/2013	05/14/2013	100.060	99.820	100.0	1
LG&E	C1S	881706	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881707	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	881708	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881709	05/2013	05/14/2013	100.050	99.910	99.9	1
LG&E	C1S	881710	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881711	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	881712	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	881713	05/2013	05/14/2013	100.080	99.920	100.1	1
LG&E	C1S	881714	05/2013	05/14/2013	100.060	99.940	99.9	1
LG&E	C1S	881715	05/2013	05/14/2013	100.080	99.910	100.1	1
LG&E	C1S	881716	05/2013	05/14/2013	100.100	99.890	100.1	1
LG&E	C1S	881717	05/2013	05/14/2013	100.080	100.000	100.0	1
LG&E	C1S	881718	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	881719	05/2013	05/14/2013	100.080	99.920	100.0	1

LG&E	C1S	881720	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	881721	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881722	05/2013	05/14/2013	100.070	99.920	99.9	1
LG&E	C1S	881723	05/2013	05/14/2013	100.060	99.950	100.1	1
LG&E	C1S	881724	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	881725	05/2013	05/14/2013	100.060	99.900	99.9	1
LG&E	C1S	881726	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	881727	05/2013	05/14/2013	100.050	99.910	99.9	1
LG&E	C1S	881728	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	881729	05/2013	05/14/2013	100.080	100.010	100.0	1
LG&E	C1S	881730	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881731	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881732	05/2013	05/14/2013	100.050	99.910	100.0	1
LG&E	C1S	881733	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	881734	05/2013	05/14/2013	100.090	99.970	100.1	1
LG&E	C1S	881735	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881736	05/2013	05/14/2013	100.070	99.970	100.0	1
LG&E	C1S	881737	05/2013	05/14/2013	100.060	99.960	100.1	1
LG&E	C1S	881738	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	881739	05/2013	05/14/2013	100.100	99.900	100.0	1
LG&E	C1S	881740	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	881741	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	881742	05/2013	05/14/2013	100.100	99.920	100.1	1
LG&E	C1S	881743	05/2013	05/14/2013	100.100	99.990	100.1	1
LG&E	C1S	881744	05/2013	05/14/2013	100.080	99.970	99.9	1
LG&E	C1S	881745	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	881746	05/2013	05/14/2013	100.050	99.870	100.0	1
LG&E	C1S	881747	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	881748	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	881749	05/2013	05/14/2013	100.060	99.940	100.0	1

LG&E	C1S	881750	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881751	05/2013	05/14/2013	100.070	99.820	100.0	1
LG&E	C1S	881752	05/2013	05/14/2013	100.050	99.880	100.0	1
LG&E	C1S	881753	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881754	05/2013	05/14/2013	100.100	99.910	100.0	1
LG&E	C1S	881755	05/2013	05/14/2013	100.090	99.860	100.0	1
LG&E	C1S	881756	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881757	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881758	05/2013	05/14/2013	100.070	99.850	100.1	1
LG&E	C1S	881759	05/2013	05/14/2013	100.060	99.820	100.0	1
LG&E	C1S	881760	05/2013	05/14/2013	100.050	99.890	100.0	1
LG&E	C1S	881761	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	881762	05/2013	05/14/2013	100.060	99.980	100.0	1
LG&E	C1S	881763	05/2013	05/14/2013	100.080	99.890	100.1	1
LG&E	C1S	881764	05/2013	05/14/2013	100.060	99.920	99.9	1
LG&E	C1S	881765	05/2013	05/14/2013	100.100	99.970	100.0	1
LG&E	C1S	881766	05/2013	05/14/2013	100.070	99.930	100.1	1
LG&E	C1S	881767	05/2013	05/14/2013	100.070	99.940	100.1	1
LG&E	C1S	881768	05/2013	05/14/2013	100.060	99.880	99.9	1
LG&E	C1S	881769	05/2013	05/14/2013	100.090	99.990	100.1	1
LG&E	C1S	881770	05/2013	05/14/2013	100.090	100.000	100.0	1
LG&E	C1S	881771	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881772	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	881773	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	881774	05/2013	05/14/2013	100.090	100.010	100.1	1
LG&E	C1S	881775	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	881776	05/2013	05/14/2013	100.100	99.900	100.0	1
LG&E	C1S	881777	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	881778	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	881779	05/2013	05/14/2013	100.100	99.940	100.0	1

LG&E	C1S	881780	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	881781	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881782	05/2013	05/14/2013	100.100	100.010	100.0	1
LG&E	C1S	881783	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881784	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	881785	05/2013	05/14/2013	100.090	99.960	99.9	1
LG&E	C1S	881786	05/2013	05/14/2013	100.060	99.910	99.9	1
LG&E	C1S	881787	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	881788	05/2013	05/14/2013	100.060	99.960	100.1	1
LG&E	C1S	881789	05/2013	05/14/2013	100.070	100.050	100.0	1
LG&E	C1S	881790	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881791	05/2013	05/14/2013	100.080	99.940	100.0	1
LG&E	C1S	881792	05/2013	05/14/2013	100.080	99.930	100.1	1
LG&E	C1S	881793	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881794	05/2013	05/14/2013	100.070	100.010	100.1	1
LG&E	C1S	881795	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881796	05/2013	05/14/2013	100.090	99.960	100.1	1
LG&E	C1S	881797	05/2013	05/14/2013	100.100	99.980	100.1	1
LG&E	C1S	881798	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	881799	05/2013	05/14/2013	100.050	99.910	99.9	1
LG&E	C1S	881800	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	881801	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881802	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	881803	05/2013	05/14/2013	100.070	99.850	100.0	1
LG&E	C1S	881804	05/2013	05/14/2013	100.080	99.900	99.9	1
LG&E	C1S	881805	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881806	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	881807	05/2013	05/14/2013	100.070	99.880	100.0	1
LG&E	C1S	881808	05/2013	05/14/2013	100.090	99.910	100.1	1
LG&E	C1S	881809	05/2013	05/14/2013	100.060	99.930	99.9	1

LG&E	C1S	881810	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881811	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	881812	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	881813	05/2013	05/14/2013	100.060	99.910	100.1	1
LG&E	C1S	881814	05/2013	05/14/2013	100.070	100.020	100.0	1
LG&E	C1S	881815	05/2013	05/14/2013	100.060	100.000	99.9	1
LG&E	C1S	881816	05/2013	05/14/2013	100.100	99.900	100.0	1
LG&E	C1S	881817	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	881818	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881819	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	881820	05/2013	05/14/2013	100.080	99.920	100.1	1
LG&E	C1S	881821	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881822	05/2013	05/14/2013	100.080	99.910	99.9	1
LG&E	C1S	881823	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	881824	05/2013	05/14/2013	100.100	99.910	100.1	1
LG&E	C1S	881825	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881826	05/2013	05/14/2013	100.070	100.020	100.0	1
LG&E	C1S	881827	05/2013	05/14/2013	100.080	100.050	100.0	1
LG&E	C1S	881828	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881829	05/2013	05/14/2013	100.100	100.020	100.0	1
LG&E	C1S	881830	05/2013	05/14/2013	100.090	100.010	100.1	1
LG&E	C1S	881831	05/2013	05/14/2013	100.090	99.950	100.1	1
LG&E	C1S	881832	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	881833	05/2013	05/14/2013	100.080	100.020	100.0	1
LG&E	C1S	881834	05/2013	05/14/2013	100.080	99.930	100.1	1
LG&E	C1S	881835	05/2013	05/14/2013	100.100	100.000	100.1	1
LG&E	C1S	881836	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881837	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881838	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	881839	05/2013	05/14/2013	100.080	99.900	100.1	1

LG&E	C1S	881840	05/2013	05/14/2013	100.090	100.000	100.0	1
LG&E	C1S	881841	05/2013	05/14/2013	100.050	99.870	99.9	1
LG&E	C1S	881842	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	881843	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881844	05/2013	05/14/2013	100.050	99.910	100.0	1
LG&E	C1S	881845	05/2013	05/14/2013	100.100	99.880	100.1	1
LG&E	C1S	881846	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881847	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	881848	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	881849	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	881850	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881851	05/2013	05/14/2013	100.100	99.910	100.1	1
LG&E	C1S	881852	05/2013	05/14/2013	100.060	99.910	100.0	1
LG&E	C1S	881853	05/2013	05/14/2013	100.070	99.960	100.1	1
LG&E	C1S	881854	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	881855	05/2013	05/14/2013	100.060	99.910	99.9	1
LG&E	C1S	881856	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881857	05/2013	05/14/2013	100.080	99.980	100.1	1
LG&E	C1S	881858	05/2013	05/14/2013	100.080	99.980	100.1	1
LG&E	C1S	881859	05/2013	05/14/2013	100.060	99.970	100.0	1
LG&E	C1S	881860	05/2013	05/14/2013	100.050	99.930	100.0	1
LG&E	C1S	881861	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	881862	05/2013	05/14/2013	100.100	99.940	100.1	1
LG&E	C1S	881863	05/2013	05/14/2013	100.060	99.940	100.1	1
LG&E	C1S	881864	05/2013	05/14/2013	100.100	99.820	100.2	1
LG&E	C1S	881865	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881866	05/2013	05/14/2013	100.070	99.910	100.1	1
LG&E	C1S	881867	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	881868	05/2013	05/14/2013	100.060	99.970	99.9	1
LG&E	C1S	881869	05/2013	05/14/2013	100.090	100.010	100.1	1

LG&E	C1S	881870	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	881871	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881872	05/2013	05/14/2013	100.060	100.020	100.0	1
LG&E	C1S	881873	05/2013	05/14/2013	100.080	100.040	100.0	1
LG&E	C1S	881874	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881875	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	881876	05/2013	05/14/2013	100.080	99.950	100.1	1
LG&E	C1S	881877	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881878	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881879	05/2013	05/14/2013	100.060	99.810	100.0	1
LG&E	C1S	881880	05/2013	05/14/2013	100.060	99.980	100.0	1
LG&E	C1S	881881	05/2013	05/14/2013	100.100	99.920	100.1	1
LG&E	C1S	881882	05/2013	05/14/2013	100.100	100.010	100.1	1
LG&E	C1S	881883	05/2013	05/14/2013	100.080	100.070	100.0	1
LG&E	C1S	881884	05/2013	05/14/2013	100.100	99.910	100.0	1
LG&E	C1S	881885	05/2013	05/14/2013	100.090	99.960	100.0	1
LG&E	C1S	881886	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	881887	05/2013	05/14/2013	100.080	100.000	100.1	1
LG&E	C1S	881888	05/2013	05/14/2013	100.080	99.940	100.1	1
LG&E	C1S	881889	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	881890	05/2013	05/14/2013	100.080	100.020	100.1	1
LG&E	C1S	881891	05/2013	05/14/2013	100.080	99.950	99.9	1
LG&E	C1S	881892	05/2013	05/14/2013	100.050	99.960	99.9	1
LG&E	C1S	881893	05/2013	05/14/2013	100.070	99.920	100.1	1
LG&E	C1S	881894	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881895	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	881896	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	881897	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	881898	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	881899	05/2013	05/14/2013	100.080	99.920	100.0	1

LG&E	C1S	881900	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	881901	05/2013	05/14/2013	100.100	99.970	100.0	1
LG&E	C1S	881902	05/2013	05/14/2013	100.070	99.970	100.1	1
LG&E	C1S	881903	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881904	05/2013	05/14/2013	100.100	99.870	100.0	1
LG&E	C1S	881905	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	881906	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	881907	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881908	05/2013	05/14/2013	100.100	100.010	100.1	1
LG&E	C1S	881909	05/2013	05/14/2013	100.080	100.020	100.0	1
LG&E	C1S	881910	05/2013	05/14/2013	100.080	99.970	100.1	1
LG&E	C1S	881911	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	881912	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881913	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	881914	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881915	05/2013	05/14/2013	100.050	99.990	100.0	1
LG&E	C1S	881916	05/2013	05/14/2013	100.060	99.830	100.0	1
LG&E	C1S	881917	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	881918	05/2013	05/14/2013	100.100	99.990	100.1	1
LG&E	C1S	881919	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881920	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881921	05/2013	05/14/2013	100.060	99.910	100.0	1
LG&E	C1S	881922	05/2013	05/14/2013	100.090	99.890	100.1	1
LG&E	C1S	881923	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	881924	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	881925	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	881926	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881927	05/2013	05/14/2013	100.090	100.030	100.1	1
LG&E	C1S	881928	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	881929	05/2013	05/14/2013	100.070	99.860	100.0	1

LG&E	C1S	881930	05/2013	05/14/2013	100.070	99.940	100.1	1
LG&E	C1S	881931	05/2013	05/14/2013	100.080	99.920	100.1	1
LG&E	C1S	881932	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881933	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	881934	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	881935	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	881936	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881937	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	881938	05/2013	05/14/2013	100.090	99.870	100.0	1
LG&E	C1S	881939	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881940	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881941	05/2013	05/14/2013	100.050	99.880	99.9	1
LG&E	C1S	881942	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	881943	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	881944	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	881945	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	881946	05/2013	05/14/2013	100.050	99.870	100.0	1
LG&E	C1S	881947	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	881948	05/2013	05/14/2013	100.060	99.860	99.9	1
LG&E	C1S	881949	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	881950	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	881951	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	881952	05/2013	05/14/2013	100.080	99.990	99.9	1
LG&E	C1S	881953	05/2013	05/14/2013	100.050	99.920	99.9	1
LG&E	C1S	881954	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	881955	05/2013	05/14/2013	100.100	100.010	100.0	1
LG&E	C1S	881956	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	881957	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881958	05/2013	05/14/2013	100.070	99.910	99.9	1
LG&E	C1S	881959	05/2013	05/14/2013	100.080	100.010	100.1	1

LG&E	C1S	881960	05/2013	05/14/2013	100.060	99.880	100.0	1
LG&E	C1S	881961	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	881962	05/2013	05/14/2013	100.080	99.980	100.1	1
LG&E	C1S	881963	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	881964	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	881965	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	881966	05/2013	05/14/2013	100.080	99.960	99.9	1
LG&E	C1S	881967	05/2013	05/14/2013	100.080	99.970	100.1	1
LG&E	C1S	881968	05/2013	05/14/2013	100.080	99.870	100.0	1
LG&E	C1S	881969	05/2013	05/14/2013	100.070	99.970	100.0	1
LG&E	C1S	881970	05/2013	05/14/2013	100.090	100.030	100.1	1
LG&E	C1S	881971	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	881972	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	881973	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	881974	05/2013	05/14/2013	100.060	99.870	99.9	1
LG&E	C1S	881975	05/2013	05/14/2013	100.080	100.000	100.0	1
LG&E	C1S	881976	05/2013	05/14/2013	100.090	99.930	100.1	1
LG&E	C1S	881977	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	881978	05/2013	05/14/2013	100.080	99.910	100.1	1
LG&E	C1S	881979	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	881980	05/2013	05/14/2013	100.080	99.960	100.1	1
LG&E	C1S	881981	05/2013	05/14/2013	100.090	100.000	100.1	1
LG&E	C1S	881982	05/2013	05/14/2013	100.080	99.910	100.1	1
LG&E	C1S	881983	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	881984	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	881985	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	881986	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	881987	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	881988	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	881989	05/2013	05/14/2013	100.080	99.990	100.0	1

LG&E	C1S	881990	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	881991	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	881992	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	881993	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	881994	05/2013	05/14/2013	100.090	99.890	100.0	1
LG&E	C1S	881995	05/2013	05/14/2013	100.070	99.840	100.0	1
LG&E	C1S	881996	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	881997	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	881998	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	881999	05/2013	05/14/2013	100.080	100.000	99.9	1
LG&E	C1S	882000	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882001	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	882002	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	882003	05/2013	05/14/2013	100.070	99.940	100.1	1
LG&E	C1S	882004	05/2013	05/14/2013	100.070	99.830	100.0	1
LG&E	C1S	882005	05/2013	05/14/2013	100.050	99.860	100.0	1
LG&E	C1S	882006	05/2013	05/14/2013	100.070	100.030	100.0	1
LG&E	C1S	882007	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882008	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	882009	05/2013	05/14/2013	100.050	99.830	100.0	1
LG&E	C1S	882010	05/2013	05/14/2013	100.060	99.980	100.1	1
LG&E	C1S	882011	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	882012	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882013	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	882014	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	882015	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882016	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882017	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	882018	05/2013	05/14/2013	100.060	99.870	99.9	1
LG&E	C1S	882019	05/2013	05/14/2013	100.070	99.850	100.0	1

LG&E	C1S	882020	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	882021	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	882022	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882023	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	882024	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	882025	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882026	05/2013	05/14/2013	100.100	99.930	100.1	1
LG&E	C1S	882027	05/2013	05/14/2013	100.080	99.890	100.0	1
LG&E	C1S	882028	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882029	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	882030	05/2013	05/14/2013	100.070	99.880	100.0	1
LG&E	C1S	882031	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	882032	05/2013	05/14/2013	100.100	99.990	100.1	1
LG&E	C1S	882033	05/2013	05/14/2013	100.060	99.810	100.0	1
LG&E	C1S	882034	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882035	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	882036	05/2013	05/14/2013	100.070	99.930	100.1	1
LG&E	C1S	882037	05/2013	05/14/2013	100.060	99.840	100.0	1
LG&E	C1S	882038	05/2013	05/14/2013	100.050	99.890	100.0	1
LG&E	C1S	882039	05/2013	05/14/2013	100.080	99.930	100.1	1
LG&E	C1S	882040	05/2013	05/14/2013	100.060	99.850	99.9	1
LG&E	C1S	882041	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882042	05/2013	05/14/2013	100.060	99.940	99.9	1
LG&E	C1S	882043	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	882044	05/2013	05/14/2013	100.090	100.010	100.1	1
LG&E	C1S	882045	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	882046	05/2013	05/14/2013	100.080	99.940	100.0	1
LG&E	C1S	882047	05/2013	05/14/2013	100.080	99.890	100.0	1
LG&E	C1S	882048	05/2013	05/14/2013	100.070	100.030	100.0	1
LG&E	C1S	882049	05/2013	05/14/2013	100.080	99.900	99.9	1

LG&E	C1S	882050	05/2013	05/14/2013	100.100	99.890	100.0	1
LG&E	C1S	882051	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882052	05/2013	05/14/2013	100.060	99.850	100.1	1
LG&E	C1S	882053	05/2013	05/14/2013	100.070	99.900	99.9	1
LG&E	C1S	882054	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	882055	05/2013	05/14/2013	100.080	99.920	99.9	1
LG&E	C1S	882056	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	882057	05/2013	05/14/2013	100.060	99.930	100.1	1
LG&E	C1S	882058	05/2013	05/14/2013	100.050	99.930	100.0	1
LG&E	C1S	882059	05/2013	05/14/2013	100.070	99.900	100.1	1
LG&E	C1S	882060	05/2013	05/14/2013	100.060	99.930	99.9	1
LG&E	C1S	882061	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882062	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	882063	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	882064	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882065	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882066	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882067	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882068	05/2013	05/14/2013	100.080	99.890	100.0	1
LG&E	C1S	882069	05/2013	05/14/2013	100.070	99.950	99.9	1
LG&E	C1S	882070	05/2013	05/14/2013	100.090	99.850	100.0	1
LG&E	C1S	882071	05/2013	05/14/2013	100.090	99.910	99.9	1
LG&E	C1S	882072	05/2013	05/14/2013	100.100	99.900	100.1	1
LG&E	C1S	882073	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882074	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	882075	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882076	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882077	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	882078	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	882079	05/2013	05/14/2013	100.100	99.950	100.2	1

LG&E	C1S	882080	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	882081	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	882082	05/2013	05/14/2013	100.080	100.000	100.0	1
LG&E	C1S	882083	05/2013	05/14/2013	100.060	99.940	100.1	1
LG&E	C1S	882084	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	882085	05/2013	05/14/2013	100.060	99.890	100.1	1
LG&E	C1S	882086	05/2013	05/14/2013	100.080	99.960	100.1	1
LG&E	C1S	882087	05/2013	05/14/2013	100.100	99.960	100.1	1
LG&E	C1S	882088	05/2013	05/14/2013	100.070	99.870	100.0	1
LG&E	C1S	882089	05/2013	05/14/2013	100.070	99.920	99.9	1
LG&E	C1S	882090	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882091	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882092	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	882093	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	882094	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882095	05/2013	05/14/2013	100.080	99.950	100.1	1
LG&E	C1S	882096	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882097	05/2013	05/14/2013	100.090	100.010	100.1	1
LG&E	C1S	882098	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	882099	05/2013	05/14/2013	100.060	99.930	100.1	1
LG&E	C1S	882100	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	882101	05/2013	05/14/2013	100.090	100.000	100.1	1
LG&E	C1S	882102	05/2013	05/14/2013	100.070	99.980	99.9	1
LG&E	C1S	882103	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	882104	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882105	05/2013	05/14/2013	100.070	99.940	100.1	1
LG&E	C1S	882106	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	882107	05/2013	05/14/2013	100.080	99.910	100.1	1
LG&E	C1S	882108	05/2013	05/14/2013	100.100	100.030	100.0	1
LG&E	C1S	882109	05/2013	05/14/2013	100.090	99.920	100.0	1

LG&E	C1S	882110	05/2013	05/14/2013	100.090	100.000	100.1	1
LG&E	C1S	882111	05/2013	05/14/2013	100.080	99.910	100.1	1
LG&E	C1S	882112	05/2013	05/14/2013	100.080	100.010	100.0	1
LG&E	C1S	882113	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	882114	05/2013	05/14/2013	100.090	100.010	100.0	1
LG&E	C1S	882115	05/2013	05/14/2013	100.070	99.830	100.0	1
LG&E	C1S	882116	05/2013	05/14/2013	100.100	100.070	99.9	1
LG&E	C1S	882117	05/2013	05/14/2013	100.090	100.020	100.1	1
LG&E	C1S	882118	05/2013	05/14/2013	100.070	99.990	100.0	1
LG&E	C1S	882119	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	882120	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882121	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	882122	05/2013	05/14/2013	100.070	99.860	100.0	1
LG&E	C1S	882123	05/2013	05/14/2013	100.100	100.010	100.0	1
LG&E	C1S	882124	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	882125	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	882126	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882127	05/2013	05/14/2013	100.090	99.990	100.1	1
LG&E	C1S	882128	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	882129	05/2013	05/14/2013	100.090	99.980	100.1	1
LG&E	C1S	882130	05/2013	05/14/2013	100.100	99.960	100.0	1
LG&E	C1S	882131	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	882132	05/2013	05/14/2013	100.060	99.930	99.9	1
LG&E	C1S	882133	05/2013	05/14/2013	100.060	99.910	99.9	1
LG&E	C1S	882134	05/2013	05/14/2013	100.080	99.860	100.0	1
LG&E	C1S	882135	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	882136	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	882137	05/2013	05/14/2013	100.070	99.910	100.1	1
LG&E	C1S	882138	05/2013	05/14/2013	100.070	99.870	100.0	1
LG&E	C1S	882139	05/2013	05/14/2013	100.080	99.830	100.0	1

LG&E	C1S	882140	05/2013	05/14/2013	100.070	99.950	100.1	1
LG&E	C1S	882141	05/2013	05/14/2013	100.100	99.910	99.9	1
LG&E	C1S	882142	05/2013	05/14/2013	100.070	99.930	99.9	1
LG&E	C1S	882143	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	882144	05/2013	05/14/2013	100.060	99.910	99.9	1
LG&E	C1S	882145	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	882146	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882147	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	882148	05/2013	05/14/2013	100.100	99.910	100.2	1
LG&E	C1S	882149	05/2013	05/14/2013	100.080	99.930	99.9	1
LG&E	C1S	882150	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882151	05/2013	05/14/2013	100.090	99.880	100.1	1
LG&E	C1S	882152	05/2013	05/14/2013	100.060	99.890	99.9	1
LG&E	C1S	882153	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	882154	05/2013	05/14/2013	100.100	99.990	100.1	1
LG&E	C1S	882155	05/2013	05/14/2013	100.050	99.820	99.9	1
LG&E	C1S	882156	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	882157	05/2013	05/14/2013	100.070	99.880	100.0	1
LG&E	C1S	882158	05/2013	05/14/2013	100.080	99.990	99.9	1
LG&E	C1S	882159	05/2013	05/14/2013	100.100	99.890	100.0	1
LG&E	C1S	882160	05/2013	05/14/2013	100.100	99.980	100.0	1
LG&E	C1S	882161	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	882162	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	882163	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	882164	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	882165	05/2013	05/14/2013	100.060	99.810	99.9	1
LG&E	C1S	882166	05/2013	05/14/2013	100.060	99.920	99.9	1
LG&E	C1S	882167	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	882168	05/2013	05/14/2013	100.090	99.860	100.0	1
LG&E	C1S	882169	05/2013	05/14/2013	100.090	99.990	100.1	1

LG&E	C1S	882170	05/2013	05/14/2013	100.100	99.910	100.0	1
LG&E	C1S	882171	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882172	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882173	05/2013	05/14/2013	100.090	100.010	100.0	1
LG&E	C1S	882174	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	882175	05/2013	05/14/2013	100.070	99.930	100.1	1
LG&E	C1S	882176	05/2013	05/14/2013	100.050	99.910	100.1	1
LG&E	C1S	882177	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	882178	05/2013	05/14/2013	100.070	99.940	100.1	1
LG&E	C1S	882179	05/2013	05/14/2013	100.090	100.000	100.0	1
LG&E	C1S	882180	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	882181	05/2013	05/14/2013	100.100	99.920	100.0	1
LG&E	C1S	882182	05/2013	05/14/2013	100.060	99.980	100.0	1
LG&E	C1S	882183	05/2013	05/14/2013	100.070	99.890	100.0	1
LG&E	C1S	882184	05/2013	05/14/2013	100.080	99.940	100.0	1
LG&E	C1S	882185	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882186	05/2013	05/14/2013	100.100	99.980	99.9	1
LG&E	C1S	882187	05/2013	05/14/2013	100.090	99.900	100.0	1
LG&E	C1S	882188	05/2013	05/14/2013	100.080	99.960	100.1	1
LG&E	C1S	882189	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882190	05/2013	05/14/2013	100.070	99.900	100.1	1
LG&E	C1S	882191	05/2013	05/14/2013	100.070	99.900	100.1	1
LG&E	C1S	882192	05/2013	05/14/2013	100.060	99.890	99.9	1
LG&E	C1S	882193	05/2013	05/14/2013	100.090	99.990	100.0	1
LG&E	C1S	882194	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882195	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	882196	05/2013	05/14/2013	100.060	100.000	100.0	1
LG&E	C1S	882197	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882198	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	882199	05/2013	05/14/2013	100.070	99.950	100.0	1

LG&E	C1S	882200	05/2013	05/14/2013	100.090	100.000	100.0	1
LG&E	C1S	882201	05/2013	05/14/2013	100.100	99.880	100.1	1
LG&E	C1S	882202	05/2013	05/14/2013	100.070	99.900	99.9	1
LG&E	C1S	882203	05/2013	05/14/2013	100.060	99.880	100.0	1
LG&E	C1S	882204	05/2013	05/14/2013	100.080	100.010	100.0	1
LG&E	C1S	882205	05/2013	05/14/2013	100.080	99.950	99.9	1
LG&E	C1S	882206	05/2013	05/14/2013	100.100	100.000	100.0	1
LG&E	C1S	882207	05/2013	05/14/2013	100.070	99.820	100.0	1
LG&E	C1S	882208	05/2013	05/14/2013	100.080	99.950	100.1	1
LG&E	C1S	882209	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	882210	05/2013	05/14/2013	100.060	99.890	100.1	1
LG&E	C1S	882211	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882212	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882213	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882214	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	882215	05/2013	05/14/2013	100.060	99.820	100.0	1
LG&E	C1S	882216	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882217	05/2013	05/14/2013	100.090	99.840	100.1	1
LG&E	C1S	882218	05/2013	05/14/2013	100.060	99.890	99.9	1
LG&E	C1S	882219	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882220	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	882221	05/2013	05/14/2013	100.090	99.910	100.1	1
LG&E	C1S	882222	05/2013	05/14/2013	100.100	99.970	100.2	1
LG&E	C1S	882223	05/2013	05/14/2013	100.100	99.910	100.0	1
LG&E	C1S	882224	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882225	05/2013	05/14/2013	100.060	99.910	100.0	1
LG&E	C1S	882226	05/2013	05/14/2013	100.070	99.990	100.0	1
LG&E	C1S	882227	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882228	05/2013	05/14/2013	100.070	99.880	100.0	1
LG&E	C1S	882229	05/2013	05/14/2013	100.070	99.940	100.1	1

LG&E	C1S	882230	05/2013	05/14/2013	100.100	99.880	100.0	1
LG&E	C1S	882231	05/2013	05/14/2013	100.070	99.850	99.9	1
LG&E	C1S	882232	05/2013	05/14/2013	100.050	99.970	99.9	1
LG&E	C1S	882233	05/2013	05/14/2013	100.060	99.960	100.1	1
LG&E	C1S	882234	05/2013	05/14/2013	100.070	100.010	100.0	1
LG&E	C1S	882235	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	882236	05/2013	05/14/2013	100.060	99.880	100.1	1
LG&E	C1S	882237	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882238	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882239	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	882240	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	882241	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	882242	05/2013	05/14/2013	100.090	99.870	100.0	1
LG&E	C1S	882243	05/2013	05/14/2013	100.100	99.980	100.0	1
LG&E	C1S	882244	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	882245	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	882246	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	882247	05/2013	05/14/2013	100.060	99.940	99.9	1
LG&E	C1S	882248	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882249	05/2013	05/14/2013	100.090	99.980	100.0	1
LG&E	C1S	882250	05/2013	05/14/2013	100.060	99.900	100.1	1
LG&E	C1S	882251	05/2013	05/14/2013	100.100	99.870	100.0	1
LG&E	C1S	882252	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	882253	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882254	05/2013	05/14/2013	100.100	99.890	100.0	1
LG&E	C1S	882255	05/2013	05/14/2013	100.050	99.850	99.9	1
LG&E	C1S	882256	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	882257	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	882258	05/2013	05/14/2013	100.060	99.900	100.1	1
LG&E	C1S	882259	05/2013	05/14/2013	100.060	99.970	100.0	1

LG&E	C1S	882260	05/2013	05/14/2013	100.060	99.970	100.0	1
LG&E	C1S	882261	05/2013	05/14/2013	100.100	100.020	100.0	1
LG&E	C1S	882262	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882263	05/2013	05/14/2013	100.050	99.930	100.0	1
LG&E	C1S	882264	05/2013	05/14/2013	100.050	99.960	100.0	1
LG&E	C1S	882265	05/2013	05/14/2013	100.050	99.920	99.9	1
LG&E	C1S	882266	05/2013	05/14/2013	100.060	99.880	100.0	1
LG&E	C1S	882267	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882268	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882269	05/2013	05/14/2013	100.100	99.980	100.1	1
LG&E	C1S	882270	05/2013	05/14/2013	100.060	99.970	100.0	1
LG&E	C1S	882271	05/2013	05/14/2013	100.090	99.860	99.9	1
LG&E	C1S	882272	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	882273	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882274	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882275	05/2013	05/14/2013	100.070	100.000	99.9	1
LG&E	C1S	882276	05/2013	05/14/2013	100.050	99.920	100.1	1
LG&E	C1S	882277	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	882278	05/2013	05/14/2013	100.060	99.850	99.9	1
LG&E	C1S	882279	05/2013	05/14/2013	100.070	100.000	100.0	1
LG&E	C1S	882280	05/2013	05/14/2013	100.100	99.930	99.9	1
LG&E	C1S	882281	05/2013	05/14/2013	100.090	99.890	100.0	1
LG&E	C1S	882282	05/2013	05/14/2013	100.060	99.960	99.9	1
LG&E	C1S	882283	05/2013	05/14/2013	100.060	99.890	100.0	1
LG&E	C1S	882284	05/2013	05/14/2013	100.100	99.860	100.0	1
LG&E	C1S	882285	05/2013	05/14/2013	100.100	99.980	100.0	1
LG&E	C1S	882286	05/2013	05/14/2013	100.080	99.990	100.1	1
LG&E	C1S	882287	05/2013	05/14/2013	100.050	99.960	100.0	1
LG&E	C1S	882288	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882289	05/2013	05/14/2013	100.070	100.020	100.0	1

LG&E	C1S	882290	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882291	05/2013	05/14/2013	100.090	99.870	99.9	1
LG&E	C1S	882292	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	882293	05/2013	05/14/2013	100.080	99.960	100.1	1
LG&E	C1S	882294	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882295	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882296	05/2013	05/14/2013	100.090	99.910	100.0	1
LG&E	C1S	882297	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	882298	05/2013	05/14/2013	100.080	99.970	100.0	1
LG&E	C1S	882299	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882300	05/2013	05/14/2013	100.070	99.930	99.9	1
LG&E	C1S	882301	05/2013	05/14/2013	100.070	99.950	100.0	1
LG&E	C1S	882302	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	882303	05/2013	05/14/2013	100.090	99.920	100.0	1
LG&E	C1S	882304	05/2013	05/14/2013	100.100	99.910	100.1	1
LG&E	C1S	882305	05/2013	05/14/2013	100.070	99.900	100.1	1
LG&E	C1S	882306	05/2013	05/14/2013	100.100	99.960	100.1	1
LG&E	C1S	882307	05/2013	05/14/2013	100.070	99.910	99.9	1
LG&E	C1S	882308	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	882309	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882310	05/2013	05/14/2013	100.060	99.870	100.0	1
LG&E	C1S	882311	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882312	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	882313	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	882314	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882315	05/2013	05/14/2013	100.090	100.030	100.1	1
LG&E	C1S	882316	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	882317	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882318	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	882319	05/2013	05/14/2013	100.070	99.920	99.9	1

LG&E	C1S	882320	05/2013	05/14/2013	100.070	99.940	100.0	1
LG&E	C1S	882321	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	882322	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882323	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	882324	05/2013	05/14/2013	100.090	99.960	100.1	1
LG&E	C1S	882325	05/2013	05/14/2013	100.060	99.870	99.9	1
LG&E	C1S	882326	05/2013	05/14/2013	100.100	100.060	100.1	1
LG&E	C1S	882327	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	882328	05/2013	05/14/2013	100.080	99.970	100.1	1
LG&E	C1S	882329	05/2013	05/14/2013	100.090	99.880	100.0	1
LG&E	C1S	882330	05/2013	05/14/2013	100.100	99.880	100.0	1
LG&E	C1S	882331	05/2013	05/14/2013	100.060	99.970	100.1	1
LG&E	C1S	882332	05/2013	05/14/2013	100.090	99.870	100.1	1
LG&E	C1S	882333	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882334	05/2013	05/14/2013	100.060	99.930	99.9	1
LG&E	C1S	882335	05/2013	05/14/2013	100.090	99.970	100.2	1
LG&E	C1S	882336	05/2013	05/14/2013	100.070	99.880	99.9	1
LG&E	C1S	882337	05/2013	05/14/2013	100.070	99.930	100.0	1
LG&E	C1S	882338	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882339	05/2013	05/14/2013	100.100	99.970	100.0	1
LG&E	C1S	882340	05/2013	05/14/2013	100.070	99.840	99.9	1
LG&E	C1S	882341	05/2013	05/14/2013	100.100	100.000	100.2	1
LG&E	C1S	882342	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	882343	05/2013	05/14/2013	100.060	99.900	100.1	1
LG&E	C1S	882344	05/2013	05/14/2013	100.070	100.010	100.0	1
LG&E	C1S	882345	05/2013	05/14/2013	100.060	99.910	100.0	1
LG&E	C1S	882346	05/2013	05/14/2013	100.080	99.870	100.1	1
LG&E	C1S	882347	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882348	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882349	05/2013	05/14/2013	100.100	99.940	100.2	1

LG&E	C1S	882350	05/2013	05/14/2013	100.100	100.070	100.1	1
LG&E	C1S	882351	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	882352	05/2013	05/14/2013	100.060	99.930	100.1	1
LG&E	C1S	882353	05/2013	05/14/2013	100.080	99.980	100.0	1
LG&E	C1S	882354	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	882355	05/2013	05/14/2013	100.100	99.950	100.0	1
LG&E	C1S	882356	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	882357	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882358	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	882359	05/2013	05/14/2013	100.060	99.930	100.0	1
LG&E	C1S	882360	05/2013	05/14/2013	100.070	99.910	100.0	1
LG&E	C1S	882361	05/2013	05/14/2013	100.060	99.930	100.1	1
LG&E	C1S	882362	05/2013	05/14/2013	100.080	100.020	100.0	1
LG&E	C1S	882363	05/2013	05/14/2013	100.070	99.910	99.9	1
LG&E	C1S	882364	05/2013	05/14/2013	100.050	99.820	100.0	1
LG&E	C1S	882365	05/2013	05/14/2013	100.080	99.960	100.0	1
LG&E	C1S	882366	05/2013	05/14/2013	100.070	99.880	99.9	1
LG&E	C1S	882367	05/2013	05/14/2013	100.070	99.970	100.1	1
LG&E	C1S	882368	05/2013	05/14/2013	100.060	99.950	99.9	1
LG&E	C1S	882369	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882370	05/2013	05/14/2013	100.100	99.990	100.0	1
LG&E	C1S	882371	05/2013	05/14/2013	100.100	99.930	100.0	1
LG&E	C1S	882372	05/2013	05/14/2013	100.070	99.960	100.0	1
LG&E	C1S	882373	05/2013	05/14/2013	100.070	99.990	100.1	1
LG&E	C1S	882374	05/2013	05/14/2013	100.050	99.920	100.0	1
LG&E	C1S	882375	05/2013	05/14/2013	100.090	100.010	100.0	1
LG&E	C1S	882376	05/2013	05/14/2013	100.100	100.060	100.1	1
LG&E	C1S	882377	05/2013	05/14/2013	100.090	99.970	100.0	1
LG&E	C1S	882378	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882379	05/2013	05/14/2013	100.100	99.930	100.0	1

LG&E	C1S	882380	05/2013	05/14/2013	100.090	99.940	100.1	1
LG&E	C1S	882381	05/2013	05/14/2013	100.060	99.950	99.9	1
LG&E	C1S	882382	05/2013	05/14/2013	100.090	99.890	100.1	1
LG&E	C1S	882383	05/2013	05/14/2013	100.070	99.920	100.0	1
LG&E	C1S	882384	05/2013	05/14/2013	100.060	99.880	100.0	1
LG&E	C1S	882385	05/2013	05/14/2013	100.060	99.980	99.9	1
LG&E	C1S	882386	05/2013	05/14/2013	100.060	99.980	100.0	1
LG&E	C1S	882387	05/2013	05/14/2013	100.070	99.840	100.0	1
LG&E	C1S	882388	05/2013	05/14/2013	100.100	99.870	100.0	1
LG&E	C1S	882389	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	882390	05/2013	05/14/2013	100.060	99.900	100.0	1
LG&E	C1S	882391	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	882392	05/2013	05/14/2013	100.060	99.900	99.9	1
LG&E	C1S	882393	05/2013	05/14/2013	100.060	99.950	100.0	1
LG&E	C1S	882394	05/2013	05/14/2013	100.050	100.010	99.9	1
LG&E	C1S	882395	05/2013	05/14/2013	100.090	100.030	100.0	1
LG&E	C1S	882396	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	882397	05/2013	05/14/2013	100.060	99.930	99.9	1
LG&E	C1S	882398	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	882399	05/2013	05/14/2013	100.090	99.930	100.0	1
LG&E	C1S	882400	05/2013	05/14/2013	100.080	99.990	100.0	1
LG&E	C1S	882401	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	882402	05/2013	05/14/2013	100.080	99.910	100.0	1
LG&E	C1S	882403	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	882404	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882405	05/2013	05/14/2013	100.080	99.950	100.0	1
LG&E	C1S	882406	05/2013	05/14/2013	100.080	99.900	100.0	1
LG&E	C1S	882407	05/2013	05/14/2013	100.060	99.880	100.1	1
LG&E	C1S	882408	05/2013	05/14/2013	100.080	99.930	99.9	1
LG&E	C1S	882409	05/2013	05/14/2013	100.100	100.070	100.0	1

LG&E	C1S	882410	05/2013	05/14/2013	100.080	99.920	99.9	1
LG&E	C1S	882411	05/2013	05/14/2013	100.060	99.990	100.0	1
LG&E	C1S	882412	05/2013	05/14/2013	100.090	100.020	100.0	1
LG&E	C1S	882413	05/2013	05/14/2013	100.050	99.810	99.9	1
LG&E	C1S	882414	05/2013	05/14/2013	100.100	100.000	100.1	1
LG&E	C1S	882415	05/2013	05/14/2013	100.070	99.850	99.9	1
LG&E	C1S	882416	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	882417	05/2013	05/14/2013	100.070	100.020	100.1	1
LG&E	C1S	882418	05/2013	05/14/2013	100.080	99.920	100.0	1
LG&E	C1S	882419	05/2013	05/14/2013	100.060	99.980	100.0	1
LG&E	C1S	882420	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	882421	05/2013	05/14/2013	100.080	100.010	99.9	1
LG&E	C1S	882422	05/2013	05/14/2013	100.070	99.900	99.9	1
LG&E	C1S	882423	05/2013	05/14/2013	100.090	99.940	100.0	1
LG&E	C1S	882424	05/2013	05/14/2013	100.050	99.940	100.0	1
LG&E	C1S	882425	05/2013	05/14/2013	100.090	100.020	100.0	1
LG&E	C1S	882426	05/2013	05/14/2013	100.070	99.910	99.9	1
LG&E	C1S	882427	05/2013	05/14/2013	100.100	99.950	100.1	1
LG&E	C1S	882428	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882429	05/2013	05/14/2013	100.080	99.880	100.0	1
LG&E	C1S	882430	05/2013	05/14/2013	100.070	99.980	100.0	1
LG&E	C1S	882431	05/2013	05/14/2013	100.070	99.900	100.0	1
LG&E	C1S	882432	05/2013	05/14/2013	100.100	99.940	100.0	1
LG&E	C1S	882433	05/2013	05/14/2013	100.070	99.920	99.9	1
LG&E	C1S	882434	05/2013	05/14/2013	100.080	99.930	100.0	1
LG&E	C1S	882435	05/2013	05/14/2013	100.060	99.860	100.0	1
LG&E	C1S	882436	05/2013	05/14/2013	100.060	99.960	100.0	1
LG&E	C1S	882437	05/2013	05/14/2013	100.100	100.020	100.0	1
LG&E	C1S	882438	05/2013	05/14/2013	100.060	99.940	100.0	1
LG&E	C1S	882439	05/2013	05/14/2013	100.070	99.930	100.0	1

LG&E	C1S	882440	05/2013	05/14/2013	100.060	99.900	99.9	1
LG&E	C1S	882441	05/2013	05/14/2013	100.100	99.970	100.1	1
LG&E	C1S	882442	05/2013	05/14/2013	100.050	99.900	100.0	1
LG&E	C1S	882443	05/2013	05/14/2013	100.060	99.880	99.9	1
LG&E	C1S	882444	05/2013	05/14/2013	100.090	99.950	100.0	1
LG&E	C1S	882445	05/2013	05/14/2013	100.070	99.980	99.9	1
LG&E	C1S	882446	05/2013	05/14/2013	100.090	99.970	100.1	1
LG&E	C1S	882447	05/2013	05/14/2013	100.060	99.920	100.0	1
LG&E	C1S	882448	05/2013	05/14/2013	100.060	99.850	100.0	1
LG&E	C1S	882449	05/2013	05/14/2013	100.090	99.920	100.1	1
LG&E	C1S	882450	05/2013	05/14/2013	100.060	99.920	99.8	1
LG&E	C1S	882451	05/2013	05/14/2013	100.050	100.020	99.9	1
LG&E	C1S	883972	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	883973	09/2013	08/19/2013	100.090	99.990	99.9	1
LG&E	C1S	883974	09/2013	08/19/2013	100.040	99.910	100.1	1
LG&E	C1S	883975	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	883976	09/2013	08/19/2013	100.050	99.940	100.0	1
LG&E	C1S	883977	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	883978	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	883979	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	883980	09/2013	08/19/2013	100.060	99.980	100.1	1
LG&E	C1S	883981	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	883982	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	883983	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	883984	09/2013	08/19/2013	100.080	99.880	100.1	1
LG&E	C1S	883985	09/2013	08/19/2013	100.040	99.900	99.9	1
LG&E	C1S	883986	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	883987	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	883988	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	883989	09/2013	08/19/2013	100.070	99.910	99.9	1

LG&E	C1S	883990	09/2013	08/19/2013	100.100	100.000	99.9	1
LG&E	C1S	883991	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	883992	09/2013	08/19/2013	100.090	99.930	99.9	1
LG&E	C1S	883993	09/2013	08/19/2013	100.040	99.920	100.0	1
LG&E	C1S	883994	09/2013	08/19/2013	100.060	99.810	100.0	1
LG&E	C1S	883995	09/2013	08/19/2013	100.090	100.040	100.0	1
LG&E	C1S	883996	09/2013	08/19/2013	100.090	99.940	100.0	1
LG&E	C1S	883997	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	883998	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	883999	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884000	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884001	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884002	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884003	09/2013	08/19/2013	100.080	99.870	99.9	1
LG&E	C1S	884004	09/2013	08/19/2013	100.060	99.830	100.0	1
LG&E	C1S	884005	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884006	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884007	09/2013	08/19/2013	100.080	99.950	100.1	1
LG&E	C1S	884008	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884009	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884010	09/2013	08/19/2013	100.060	99.850	100.1	1
LG&E	C1S	884011	09/2013	08/19/2013	100.090	99.910	100.0	1
LG&E	C1S	884012	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884013	09/2013	08/19/2013	100.090	99.990	100.0	1
LG&E	C1S	884014	09/2013	08/19/2013	100.050	99.850	100.0	1
LG&E	C1S	884015	09/2013	08/19/2013	100.040	99.890	99.9	1
LG&E	C1S	884016	09/2013	08/19/2013	100.030	99.950	100.0	1
LG&E	C1S	884017	09/2013	08/19/2013	100.060	99.830	100.0	1
LG&E	C1S	884018	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884019	09/2013	08/19/2013	100.060	99.860	100.0	1

LG&E	C1S	884020	09/2013	08/19/2013	100.060	99.990	100.0	1
LG&E	C1S	884021	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884022	09/2013	08/19/2013	100.030	99.900	99.9	1
LG&E	C1S	884023	09/2013	08/19/2013	100.090	99.950	100.1	1
LG&E	C1S	884024	09/2013	08/19/2013	100.080	99.900	100.0	1
LG&E	C1S	884025	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884026	09/2013	08/19/2013	100.060	99.870	100.0	1
LG&E	C1S	884027	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884028	09/2013	08/19/2013	100.080	99.900	100.0	1
LG&E	C1S	884029	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884030	09/2013	08/19/2013	100.080	99.880	99.9	1
LG&E	C1S	884031	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	884032	09/2013	08/19/2013	100.060	99.890	99.9	1
LG&E	C1S	884033	09/2013	08/19/2013	100.060	99.980	100.0	1
LG&E	C1S	884034	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884035	09/2013	08/19/2013	100.050	99.940	99.9	1
LG&E	C1S	884036	09/2013	08/19/2013	100.100	99.920	99.9	1
LG&E	C1S	884037	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884038	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884039	09/2013	08/19/2013	100.090	99.930	100.0	1
LG&E	C1S	884040	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884041	09/2013	08/19/2013	100.070	99.860	99.9	1
LG&E	C1S	884042	09/2013	08/19/2013	100.090	100.020	100.0	1
LG&E	C1S	884043	09/2013	08/19/2013	100.060	99.900	99.9	1
LG&E	C1S	884044	09/2013	08/19/2013	100.080	99.950	99.9	1
LG&E	C1S	884045	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884046	09/2013	08/19/2013	100.080	99.940	100.1	1
LG&E	C1S	884047	09/2013	08/19/2013	100.060	99.860	99.9	1
LG&E	C1S	884048	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884049	09/2013	08/19/2013	100.050	99.870	100.0	1

LG&E	C1S	884050	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884051	09/2013	08/19/2013	100.030	99.890	99.9	1
LG&E	C1S	884052	09/2013	08/19/2013	100.050	99.860	100.0	1
LG&E	C1S	884053	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884054	09/2013	08/19/2013	100.030	99.920	100.0	1
LG&E	C1S	884055	09/2013	08/19/2013	100.030	99.870	100.0	1
LG&E	C1S	884056	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884057	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884058	09/2013	08/19/2013	100.030	99.910	100.0	1
LG&E	C1S	884059	09/2013	08/19/2013	100.030	99.880	100.0	1
LG&E	C1S	884060	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884061	09/2013	08/19/2013	100.080	99.990	99.9	1
LG&E	C1S	884062	09/2013	08/19/2013	100.080	99.880	100.0	1
LG&E	C1S	884063	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884064	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884065	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884066	09/2013	08/19/2013	100.030	99.870	100.0	1
LG&E	C1S	884067	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884068	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884069	09/2013	08/19/2013	100.080	99.980	100.0	1
LG&E	C1S	884070	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884071	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884072	09/2013	08/19/2013	100.100	99.970	100.1	1
LG&E	C1S	884073	09/2013	08/19/2013	100.030	99.890	100.0	1
LG&E	C1S	884074	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884075	09/2013	08/19/2013	100.100	99.990	100.0	1
LG&E	C1S	884076	09/2013	08/19/2013	100.030	99.930	100.0	1
LG&E	C1S	884077	09/2013	08/19/2013	100.100	99.920	100.1	1
LG&E	C1S	884078	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884079	09/2013	08/19/2013	100.060	99.850	100.0	1

LG&E	C1S	884080	09/2013	08/19/2013	100.060	99.840	100.0	1
LG&E	C1S	884081	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884082	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884083	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884084	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884085	09/2013	08/19/2013	100.030	99.920	99.9	1
LG&E	C1S	884086	09/2013	08/19/2013	100.040	99.840	99.9	1
LG&E	C1S	884087	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884088	09/2013	08/19/2013	100.100	99.910	100.1	1
LG&E	C1S	884089	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884090	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884091	09/2013	08/19/2013	100.090	99.910	100.1	1
LG&E	C1S	884092	09/2013	08/19/2013	100.100	99.910	100.0	1
LG&E	C1S	884093	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884094	09/2013	08/19/2013	100.080	99.890	100.1	1
LG&E	C1S	884095	09/2013	08/19/2013	100.040	99.860	100.0	1
LG&E	C1S	884096	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884097	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	884098	09/2013	08/19/2013	100.100	100.010	100.0	1
LG&E	C1S	884099	09/2013	08/19/2013	100.080	99.930	100.1	1
LG&E	C1S	884100	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884101	09/2013	08/19/2013	100.070	99.970	99.9	1
LG&E	C1S	884102	09/2013	08/19/2013	100.090	99.910	100.0	1
LG&E	C1S	884103	09/2013	08/19/2013	100.060	99.890	100.0	1
LG&E	C1S	884104	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884105	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884106	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884107	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884108	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884109	09/2013	08/19/2013	100.050	99.910	100.0	1

LG&E	C1S	884110	09/2013	08/19/2013	100.050	99.880	99.9	1
LG&E	C1S	884111	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884112	09/2013	08/19/2013	100.040	99.930	100.0	1
LG&E	C1S	884113	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884114	09/2013	08/19/2013	100.060	99.870	99.9	1
LG&E	C1S	884115	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884116	09/2013	08/19/2013	100.100	99.890	100.1	1
LG&E	C1S	884117	09/2013	08/19/2013	100.060	99.950	99.9	1
LG&E	C1S	884118	09/2013	08/19/2013	100.050	99.930	100.0	1
LG&E	C1S	884119	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884120	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884121	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884122	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884123	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884124	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884125	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884126	09/2013	08/19/2013	100.040	99.850	99.9	1
LG&E	C1S	884127	09/2013	08/19/2013	100.070	99.970	100.1	1
LG&E	C1S	884128	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884129	09/2013	08/19/2013	100.100	99.890	99.9	1
LG&E	C1S	884130	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884131	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884132	09/2013	08/19/2013	100.050	99.870	99.9	1
LG&E	C1S	884133	09/2013	08/19/2013	100.070	99.970	99.9	1
LG&E	C1S	884134	09/2013	08/19/2013	100.070	99.860	100.0	1
LG&E	C1S	884135	09/2013	08/19/2013	100.060	99.890	100.0	1
LG&E	C1S	884136	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884137	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	884138	09/2013	08/19/2013	100.030	99.880	100.0	1
LG&E	C1S	884139	09/2013	08/19/2013	100.070	99.900	100.0	1

LG&E	C1S	884140	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884141	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884142	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884143	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884144	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884145	09/2013	08/19/2013	100.070	100.000	99.9	1
LG&E	C1S	884146	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884147	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884148	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884149	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884150	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884151	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884152	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884153	09/2013	08/19/2013	100.030	99.940	99.9	1
LG&E	C1S	884154	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884155	09/2013	08/19/2013	100.070	100.000	99.9	1
LG&E	C1S	884156	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884157	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884158	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884159	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884160	09/2013	08/19/2013	100.060	99.930	99.9	1
LG&E	C1S	884161	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884162	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884163	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884164	09/2013	08/19/2013	100.040	99.930	100.0	1
LG&E	C1S	884165	09/2013	08/19/2013	100.050	99.940	100.0	1
LG&E	C1S	884166	09/2013	08/19/2013	100.090	99.890	100.0	1
LG&E	C1S	884167	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884168	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884169	09/2013	08/19/2013	100.030	99.870	99.9	1

LG&E	C1S	884170	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884171	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884172	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884173	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884174	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884175	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884176	09/2013	08/19/2013	100.080	99.980	100.0	1
LG&E	C1S	884177	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884178	09/2013	08/19/2013	100.070	99.950	99.9	1
LG&E	C1S	884179	09/2013	08/19/2013	100.090	99.930	99.9	1
LG&E	C1S	884180	09/2013	08/19/2013	100.030	99.860	100.0	1
LG&E	C1S	884181	09/2013	08/19/2013	100.070	99.930	100.1	1
LG&E	C1S	884182	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884183	09/2013	08/19/2013	100.070	99.960	100.1	1
LG&E	C1S	884184	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884185	09/2013	08/19/2013	100.080	100.000	100.0	1
LG&E	C1S	884186	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884187	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884188	09/2013	08/19/2013	100.040	99.960	100.0	1
LG&E	C1S	884189	09/2013	08/19/2013	100.080	99.970	99.9	1
LG&E	C1S	884190	09/2013	08/19/2013	100.070	99.930	100.1	1
LG&E	C1S	884191	09/2013	08/19/2013	100.100	99.960	99.9	1
LG&E	C1S	884192	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884193	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884194	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884195	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884196	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884197	09/2013	08/19/2013	100.060	99.960	99.9	1
LG&E	C1S	884198	09/2013	08/19/2013	100.060	99.910	100.1	1
LG&E	C1S	884199	09/2013	08/19/2013	100.070	99.870	100.0	1

LG&E	C1S	884200	09/2013	08/19/2013	100.080	99.870	100.0	1
LG&E	C1S	884201	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884202	09/2013	08/19/2013	100.050	99.950	99.9	1
LG&E	C1S	884203	09/2013	08/19/2013	100.100	100.000	100.0	1
LG&E	C1S	884204	09/2013	08/19/2013	100.100	99.900	100.0	1
LG&E	C1S	884205	09/2013	08/19/2013	100.100	99.950	100.0	1
LG&E	C1S	884206	09/2013	08/19/2013	100.080	99.980	100.0	1
LG&E	C1S	884207	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884208	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884209	09/2013	08/19/2013	100.060	99.960	99.9	1
LG&E	C1S	884210	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884211	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884212	09/2013	08/19/2013	100.030	99.840	99.9	1
LG&E	C1S	884213	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884214	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884215	09/2013	08/19/2013	100.040	99.920	100.0	1
LG&E	C1S	884216	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884217	09/2013	08/19/2013	100.070	99.900	99.9	1
LG&E	C1S	884218	09/2013	08/19/2013	100.070	99.980	100.0	1
LG&E	C1S	884219	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884220	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884221	09/2013	08/19/2013	100.070	99.920	99.9	1
LG&E	C1S	884222	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884223	09/2013	08/19/2013	100.080	100.070	100.0	1
LG&E	C1S	884224	09/2013	08/19/2013	100.060	99.950	99.9	1
LG&E	C1S	884225	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884226	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884227	09/2013	08/19/2013	100.080	99.900	99.9	1
LG&E	C1S	884228	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884229	09/2013	08/19/2013	100.080	99.890	100.0	1

LG&E	C1S	884230	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	884231	09/2013	08/19/2013	100.050	99.860	100.0	1
LG&E	C1S	884232	09/2013	08/19/2013	100.040	99.950	100.0	1
LG&E	C1S	884233	09/2013	08/19/2013	100.040	99.840	100.0	1
LG&E	C1S	884234	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884235	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884236	09/2013	08/19/2013	100.100	100.040	100.0	1
LG&E	C1S	884237	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884238	09/2013	08/19/2013	100.070	100.020	100.0	1
LG&E	C1S	884239	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884240	09/2013	08/19/2013	100.070	99.980	100.0	1
LG&E	C1S	884241	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884242	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884243	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884244	09/2013	08/19/2013	100.040	99.850	100.0	1
LG&E	C1S	884245	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884246	09/2013	08/19/2013	100.100	100.010	100.0	1
LG&E	C1S	884247	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884248	09/2013	08/19/2013	100.060	99.880	99.9	1
LG&E	C1S	884249	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884250	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884251	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884252	09/2013	08/19/2013	100.050	99.910	99.9	1
LG&E	C1S	884253	09/2013	08/19/2013	100.060	99.850	100.0	1
LG&E	C1S	884254	09/2013	08/19/2013	100.050	99.890	99.9	1
LG&E	C1S	884255	09/2013	08/19/2013	100.090	100.030	100.0	1
LG&E	C1S	884256	09/2013	08/19/2013	100.060	100.000	100.0	1
LG&E	C1S	884257	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884258	09/2013	08/19/2013	100.100	99.990	100.0	1
LG&E	C1S	884259	09/2013	08/19/2013	100.080	99.870	99.9	1

LG&E	C1S	884260	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884261	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884262	09/2013	08/19/2013	100.100	100.000	100.0	1
LG&E	C1S	884263	09/2013	08/19/2013	100.050	99.890	99.9	1
LG&E	C1S	884264	09/2013	08/19/2013	100.100	99.950	100.0	1
LG&E	C1S	884265	09/2013	08/19/2013	100.070	99.960	99.9	1
LG&E	C1S	884266	09/2013	08/19/2013	100.100	99.910	100.0	1
LG&E	C1S	884267	09/2013	08/19/2013	100.100	99.970	100.0	1
LG&E	C1S	884268	09/2013	08/19/2013	100.070	100.050	99.9	1
LG&E	C1S	884269	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884270	09/2013	08/19/2013	100.090	99.930	100.1	1
LG&E	C1S	884271	09/2013	08/19/2013	100.040	99.880	100.0	1
LG&E	C1S	884272	09/2013	08/19/2013	100.090	99.840	100.0	1
LG&E	C1S	884273	09/2013	08/19/2013	100.100	99.960	100.1	1
LG&E	C1S	884274	09/2013	08/19/2013	100.060	99.850	100.1	1
LG&E	C1S	884275	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884276	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884277	09/2013	08/19/2013	100.090	100.040	100.0	1
LG&E	C1S	884278	09/2013	08/19/2013	100.030	99.870	100.0	1
LG&E	C1S	884279	09/2013	08/19/2013	100.040	99.840	99.9	1
LG&E	C1S	884280	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884281	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884282	09/2013	08/19/2013	100.040	99.870	100.1	1
LG&E	C1S	884283	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884284	09/2013	08/19/2013	100.030	99.850	99.9	1
LG&E	C1S	884285	09/2013	08/19/2013	100.110	99.990	100.1	1
LG&E	C1S	884286	09/2013	08/19/2013	100.030	99.840	100.0	1
LG&E	C1S	884287	09/2013	08/19/2013	100.060	99.960	100.1	1
LG&E	C1S	884288	09/2013	08/19/2013	100.060	99.880	99.9	1
LG&E	C1S	884289	09/2013	08/19/2013	100.080	99.860	99.9	1

LG&E	C1S	884290	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884291	09/2013	08/19/2013	100.080	99.920	100.0	1
LG&E	C1S	884292	09/2013	08/19/2013	100.070	99.890	100.1	1
LG&E	C1S	884293	09/2013	08/19/2013	100.090	99.950	99.9	1
LG&E	C1S	884294	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884295	09/2013	08/19/2013	100.100	99.890	100.0	1
LG&E	C1S	884296	09/2013	08/19/2013	100.040	99.880	100.0	1
LG&E	C1S	884297	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884298	09/2013	08/19/2013	100.070	99.860	100.1	1
LG&E	C1S	884299	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884300	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884301	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884302	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884303	09/2013	08/19/2013	100.040	99.860	99.9	1
LG&E	C1S	884304	09/2013	08/19/2013	100.070	100.010	100.0	1
LG&E	C1S	884305	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884306	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884307	09/2013	08/19/2013	100.060	99.870	100.0	1
LG&E	C1S	884308	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884309	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884310	09/2013	08/19/2013	100.080	99.870	100.0	1
LG&E	C1S	884311	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884312	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884313	09/2013	08/19/2013	100.040	99.920	100.0	1
LG&E	C1S	884314	09/2013	08/19/2013	100.030	99.860	100.0	1
LG&E	C1S	884315	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884316	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884317	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884318	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884319	09/2013	08/19/2013	100.050	99.860	100.0	1

LG&E	C1S	884320	09/2013	08/19/2013	100.050	99.840	100.0	1
LG&E	C1S	884321	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884322	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884323	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884324	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884325	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884326	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884327	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884328	09/2013	08/19/2013	100.090	99.850	100.0	1
LG&E	C1S	884329	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884330	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884331	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884332	09/2013	08/19/2013	100.030	99.870	99.9	1
LG&E	C1S	884333	09/2013	08/19/2013	100.050	99.870	99.9	1
LG&E	C1S	884334	09/2013	08/19/2013	100.070	99.890	99.9	1
LG&E	C1S	884335	09/2013	08/19/2013	100.060	99.940	99.9	1
LG&E	C1S	884336	09/2013	08/19/2013	100.080	99.990	100.0	1
LG&E	C1S	884337	09/2013	08/19/2013	100.100	100.020	100.0	1
LG&E	C1S	884338	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884339	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884340	09/2013	08/19/2013	100.050	99.880	100.0	1
LG&E	C1S	884341	09/2013	08/19/2013	100.100	99.890	100.0	1
LG&E	C1S	884342	09/2013	08/19/2013	100.050	99.850	99.9	1
LG&E	C1S	884343	09/2013	08/19/2013	100.060	99.820	100.0	1
LG&E	C1S	884344	09/2013	08/19/2013	100.090	99.970	99.9	1
LG&E	C1S	884345	09/2013	08/19/2013	100.090	99.960	99.9	1
LG&E	C1S	884346	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884347	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884348	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884349	09/2013	08/19/2013	100.090	99.880	100.0	1

LG&E	C1S	884350	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884351	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884352	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884353	09/2013	08/19/2013	100.080	99.910	100.1	1
LG&E	C1S	884354	09/2013	08/19/2013	100.060	99.850	100.0	1
LG&E	C1S	884355	09/2013	08/19/2013	100.050	99.930	100.1	1
LG&E	C1S	884356	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884357	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884358	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884359	09/2013	08/19/2013	100.040	99.840	100.0	1
LG&E	C1S	884360	09/2013	08/19/2013	100.100	100.020	100.0	1
LG&E	C1S	884361	09/2013	08/19/2013	100.080	99.930	100.1	1
LG&E	C1S	884362	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884363	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884364	09/2013	08/19/2013	100.090	100.010	100.0	1
LG&E	C1S	884365	09/2013	08/19/2013	100.100	99.990	100.0	1
LG&E	C1S	884366	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	884367	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884368	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884369	09/2013	08/19/2013	100.090	99.950	100.1	1
LG&E	C1S	884370	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884371	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884372	09/2013	08/19/2013	100.100	99.980	100.1	1
LG&E	C1S	884373	09/2013	08/19/2013	100.090	99.850	100.0	1
LG&E	C1S	884374	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884375	09/2013	08/19/2013	100.060	99.990	99.9	1
LG&E	C1S	884376	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884377	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884378	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884379	09/2013	08/19/2013	100.070	99.880	100.0	1

LG&E	C1S	884380	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884381	09/2013	08/19/2013	100.070	99.890	99.9	1
LG&E	C1S	884382	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884383	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884384	09/2013	08/19/2013	100.070	99.840	99.9	1
LG&E	C1S	884385	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884386	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884387	09/2013	08/19/2013	100.090	99.890	99.9	1
LG&E	C1S	884388	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884389	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884390	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884391	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884392	09/2013	08/19/2013	100.080	99.950	100.0	1
LG&E	C1S	884393	09/2013	08/19/2013	100.080	99.850	100.1	1
LG&E	C1S	884394	09/2013	08/19/2013	100.050	99.930	100.1	1
LG&E	C1S	884395	09/2013	08/19/2013	100.040	99.930	100.0	1
LG&E	C1S	884396	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884397	09/2013	08/19/2013	100.060	99.890	99.9	1
LG&E	C1S	884398	09/2013	08/19/2013	100.080	100.000	100.0	1
LG&E	C1S	884399	09/2013	08/19/2013	100.080	99.990	100.0	1
LG&E	C1S	884400	09/2013	08/19/2013	100.100	99.990	99.9	1
LG&E	C1S	884401	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884402	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884403	09/2013	08/19/2013	100.100	99.870	100.0	1
LG&E	C1S	884404	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884405	09/2013	08/19/2013	100.070	99.930	99.9	1
LG&E	C1S	884406	09/2013	08/19/2013	100.050	99.940	99.9	1
LG&E	C1S	884407	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884408	09/2013	08/19/2013	100.060	99.900	100.1	1
LG&E	C1S	884409	09/2013	08/19/2013	100.090	99.910	100.0	1

LG&E	C1S	884410	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884411	09/2013	08/19/2013	100.070	99.900	99.9	1
LG&E	C1S	884412	09/2013	08/19/2013	100.050	99.920	99.9	1
LG&E	C1S	884413	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884414	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884415	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884416	09/2013	08/19/2013	100.030	99.910	99.9	1
LG&E	C1S	884417	09/2013	08/19/2013	100.090	99.890	100.0	1
LG&E	C1S	884418	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884419	09/2013	08/19/2013	100.070	99.900	99.9	1
LG&E	C1S	884420	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884421	09/2013	08/19/2013	100.100	99.950	100.0	1
LG&E	C1S	884422	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884423	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884424	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884425	09/2013	08/19/2013	100.070	99.850	100.0	1
LG&E	C1S	884426	09/2013	08/19/2013	100.070	99.980	100.0	1
LG&E	C1S	884427	09/2013	08/19/2013	100.050	99.920	100.0	1
LG&E	C1S	884428	09/2013	08/19/2013	100.070	99.900	100.1	1
LG&E	C1S	884429	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884430	09/2013	08/19/2013	100.050	99.880	99.9	1
LG&E	C1S	884431	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884432	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884433	09/2013	08/19/2013	100.070	99.850	100.0	1
LG&E	C1S	884434	09/2013	08/19/2013	100.050	99.900	100.1	1
LG&E	C1S	884435	09/2013	08/19/2013	100.050	99.930	100.0	1
LG&E	C1S	884436	09/2013	08/19/2013	100.050	99.970	100.0	1
LG&E	C1S	884437	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884438	09/2013	08/19/2013	100.100	99.980	100.0	1
LG&E	C1S	884439	09/2013	08/19/2013	100.070	99.960	100.1	1

LG&E	C1S	884440	09/2013	08/19/2013	100.050	99.850	100.0	1
LG&E	C1S	884441	09/2013	08/19/2013	100.080	99.980	100.0	1
LG&E	C1S	884442	09/2013	08/19/2013	100.100	99.980	100.1	1
LG&E	C1S	884443	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884444	09/2013	08/19/2013	100.090	99.890	100.1	1
LG&E	C1S	884445	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884446	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884447	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884448	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884449	09/2013	08/19/2013	100.090	99.960	100.1	1
LG&E	C1S	884450	09/2013	08/19/2013	100.090	99.930	100.0	1
LG&E	C1S	884451	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884452	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884453	09/2013	08/19/2013	100.050	99.980	100.0	1
LG&E	C1S	884454	09/2013	08/19/2013	100.040	99.880	100.0	1
LG&E	C1S	884455	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884456	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884457	09/2013	08/19/2013	100.070	99.850	100.0	1
LG&E	C1S	884458	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884459	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884460	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884461	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884462	09/2013	08/19/2013	100.080	100.000	100.0	1
LG&E	C1S	884463	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884464	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884465	09/2013	08/19/2013	100.080	99.890	100.0	1
LG&E	C1S	884466	09/2013	08/19/2013	100.060	99.980	100.1	1
LG&E	C1S	884467	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884468	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884469	09/2013	08/19/2013	100.070	99.930	100.0	1

LG&E	C1S	884470	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884471	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884472	09/2013	08/19/2013	100.060	99.990	99.9	1
LG&E	C1S	884473	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884474	09/2013	08/19/2013	100.080	99.960	100.1	1
LG&E	C1S	884475	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884476	09/2013	08/19/2013	100.080	99.920	100.0	1
LG&E	C1S	884477	09/2013	08/19/2013	100.090	99.930	100.0	1
LG&E	C1S	884478	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884479	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884480	09/2013	08/19/2013	100.080	99.950	100.0	1
LG&E	C1S	884481	09/2013	08/19/2013	100.040	99.850	100.0	1
LG&E	C1S	884482	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884483	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884484	09/2013	08/19/2013	100.060	99.850	100.0	1
LG&E	C1S	884485	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884486	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884487	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884488	09/2013	08/19/2013	100.040	99.860	100.0	1
LG&E	C1S	884489	09/2013	08/19/2013	100.040	99.930	100.0	1
LG&E	C1S	884490	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	884491	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884492	09/2013	08/19/2013	100.060	99.870	99.9	1
LG&E	C1S	884493	09/2013	08/19/2013	100.070	99.980	99.9	1
LG&E	C1S	884494	09/2013	08/19/2013	100.060	99.840	100.0	1
LG&E	C1S	884495	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884496	09/2013	08/19/2013	100.070	99.950	99.9	1
LG&E	C1S	884497	09/2013	08/19/2013	100.100	100.010	100.0	1
LG&E	C1S	884498	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884499	09/2013	08/19/2013	100.030	99.810	100.0	1

LG&E	C1S	884500	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884501	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884502	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884503	09/2013	08/19/2013	100.070	99.980	100.0	1
LG&E	C1S	884504	09/2013	08/19/2013	100.030	99.850	99.9	1
LG&E	C1S	884505	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884506	09/2013	08/19/2013	100.070	100.030	100.0	1
LG&E	C1S	884507	09/2013	08/19/2013	100.080	99.960	100.1	1
LG&E	C1S	884508	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884509	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884510	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884511	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884512	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884513	09/2013	08/19/2013	100.100	99.940	100.0	1
LG&E	C1S	884514	09/2013	08/19/2013	100.060	99.930	99.9	1
LG&E	C1S	884515	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884516	09/2013	08/19/2013	100.090	99.860	100.0	1
LG&E	C1S	884517	09/2013	08/19/2013	100.030	99.910	100.0	1
LG&E	C1S	884518	09/2013	08/19/2013	100.080	99.950	100.1	1
LG&E	C1S	884519	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884520	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884521	09/2013	08/19/2013	100.070	99.990	99.9	1
LG&E	C1S	884522	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884523	09/2013	08/19/2013	100.030	99.840	100.0	1
LG&E	C1S	884524	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884525	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884526	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884527	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884528	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884529	09/2013	08/19/2013	100.080	99.960	99.9	1

LG&E	C1S	884530	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884531	09/2013	08/19/2013	100.070	99.930	99.9	1
LG&E	C1S	884532	09/2013	08/19/2013	100.050	99.880	99.9	1
LG&E	C1S	884533	09/2013	08/19/2013	100.050	99.870	100.0	1
LG&E	C1S	884534	09/2013	08/19/2013	100.050	99.920	100.0	1
LG&E	C1S	884535	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	884536	09/2013	08/19/2013	100.090	100.000	100.1	1
LG&E	C1S	884537	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884538	09/2013	08/19/2013	100.090	99.940	100.1	1
LG&E	C1S	884539	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884540	09/2013	08/19/2013	100.080	99.880	99.9	1
LG&E	C1S	884541	09/2013	08/19/2013	100.100	99.990	100.0	1
LG&E	C1S	884542	09/2013	08/19/2013	100.090	99.990	100.0	1
LG&E	C1S	884543	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884544	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884545	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884546	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884547	09/2013	08/19/2013	100.040	99.890	99.9	1
LG&E	C1S	884548	09/2013	08/19/2013	100.060	99.910	100.1	1
LG&E	C1S	884549	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884550	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884551	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884552	09/2013	08/19/2013	100.070	99.830	100.0	1
LG&E	C1S	884553	09/2013	08/19/2013	100.050	99.920	100.0	1
LG&E	C1S	884554	09/2013	08/19/2013	100.090	99.950	100.1	1
LG&E	C1S	884555	09/2013	08/19/2013	100.080	99.990	100.0	1
LG&E	C1S	884556	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884557	09/2013	08/19/2013	100.070	100.030	100.0	1
LG&E	C1S	884558	09/2013	08/19/2013	100.090	99.910	100.1	1
LG&E	C1S	884559	09/2013	08/19/2013	100.070	99.970	100.0	1

LG&E	C1S	884560	09/2013	08/19/2013	100.050	99.900	99.9	1
LG&E	C1S	884561	09/2013	08/19/2013	100.080	100.000	100.0	1
LG&E	C1S	884562	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884563	09/2013	08/19/2013	100.030	99.860	99.9	1
LG&E	C1S	884564	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884565	09/2013	08/19/2013	100.040	99.890	99.9	1
LG&E	C1S	884566	09/2013	08/19/2013	100.050	99.910	99.9	1
LG&E	C1S	884567	09/2013	08/19/2013	100.090	99.940	100.0	1
LG&E	C1S	884568	09/2013	08/19/2013	100.050	99.880	100.0	1
LG&E	C1S	884569	09/2013	08/19/2013	100.070	99.940	99.9	1
LG&E	C1S	884570	09/2013	08/19/2013	100.060	99.900	99.9	1
LG&E	C1S	884571	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884572	09/2013	08/19/2013	100.030	99.890	100.0	1
LG&E	C1S	884573	09/2013	08/19/2013	100.060	99.940	99.9	1
LG&E	C1S	884574	09/2013	08/19/2013	100.040	99.880	99.9	1
LG&E	C1S	884575	09/2013	08/19/2013	100.110	99.970	100.0	1
LG&E	C1S	884576	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884577	09/2013	08/19/2013	100.100	99.930	100.0	1
LG&E	C1S	884578	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884579	09/2013	08/19/2013	100.060	99.990	100.0	1
LG&E	C1S	884580	09/2013	08/19/2013	100.090	100.010	100.1	1
LG&E	C1S	884581	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884582	09/2013	08/19/2013	100.060	99.970	100.0	1
LG&E	C1S	884583	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884584	09/2013	08/19/2013	100.080	99.910	99.9	1
LG&E	C1S	884585	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884586	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884587	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884588	09/2013	08/19/2013	100.040	99.970	100.0	1
LG&E	C1S	884589	09/2013	08/19/2013	100.080	99.890	100.0	1

LG&E	C1S	884590	09/2013	08/19/2013	100.070	99.890	100.0	1
LG&E	C1S	884591	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884592	09/2013	08/19/2013	100.050	99.830	100.0	1
LG&E	C1S	884593	09/2013	08/19/2013	100.080	99.990	100.1	1
LG&E	C1S	884594	09/2013	08/19/2013	100.050	99.930	100.1	1
LG&E	C1S	884595	09/2013	08/19/2013	100.070	99.950	99.9	1
LG&E	C1S	884596	09/2013	08/19/2013	100.060	99.960	99.9	1
LG&E	C1S	884597	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884598	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884599	09/2013	08/19/2013	100.060	99.970	100.0	1
LG&E	C1S	884600	09/2013	08/19/2013	100.100	99.950	100.1	1
LG&E	C1S	884601	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884602	09/2013	08/19/2013	100.080	100.010	100.0	1
LG&E	C1S	884603	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884604	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884605	09/2013	08/19/2013	100.060	99.850	100.0	1
LG&E	C1S	884606	09/2013	08/19/2013	100.090	99.930	100.1	1
LG&E	C1S	884607	09/2013	08/19/2013	100.040	99.860	100.0	1
LG&E	C1S	884608	09/2013	08/19/2013	100.070	99.970	100.1	1
LG&E	C1S	884609	09/2013	08/19/2013	100.070	99.970	100.1	1
LG&E	C1S	884610	09/2013	08/19/2013	100.070	100.020	100.1	1
LG&E	C1S	884611	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884612	09/2013	08/19/2013	100.100	99.890	100.0	1
LG&E	C1S	884613	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884614	09/2013	08/19/2013	100.100	99.930	100.1	1
LG&E	C1S	884615	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884616	09/2013	08/19/2013	100.100	99.910	100.0	1
LG&E	C1S	884617	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884618	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884619	09/2013	08/19/2013	100.070	99.910	100.0	1

LG&E	C1S	884620	09/2013	08/19/2013	100.030	99.890	100.0	1
LG&E	C1S	884621	09/2013	08/19/2013	100.050	99.930	100.0	1
LG&E	C1S	884622	09/2013	08/19/2013	100.090	99.960	99.9	1
LG&E	C1S	884623	09/2013	08/19/2013	100.060	99.980	100.0	1
LG&E	C1S	884624	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884625	09/2013	08/19/2013	100.080	99.890	100.0	1
LG&E	C1S	884626	09/2013	08/19/2013	100.080	99.950	100.0	1
LG&E	C1S	884627	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884628	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884629	09/2013	08/19/2013	100.060	99.830	100.0	1
LG&E	C1S	884630	09/2013	08/19/2013	100.040	99.850	100.0	1
LG&E	C1S	884631	09/2013	08/19/2013	100.050	99.980	100.0	1
LG&E	C1S	884632	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884633	09/2013	08/19/2013	100.070	99.990	100.0	1
LG&E	C1S	884634	09/2013	08/19/2013	100.070	99.870	100.1	1
LG&E	C1S	884635	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884636	09/2013	08/19/2013	100.030	99.890	100.0	1
LG&E	C1S	884637	09/2013	08/19/2013	100.100	99.960	100.0	1
LG&E	C1S	884638	09/2013	08/19/2013	100.050	99.900	99.9	1
LG&E	C1S	884639	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884640	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884641	09/2013	08/19/2013	100.090	99.830	100.0	1
LG&E	C1S	884642	09/2013	08/19/2013	100.060	99.890	99.9	1
LG&E	C1S	884643	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884644	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884645	09/2013	08/19/2013	100.080	99.880	99.9	1
LG&E	C1S	884646	09/2013	08/19/2013	100.040	99.850	99.9	1
LG&E	C1S	884647	09/2013	08/19/2013	100.050	99.940	100.0	1
LG&E	C1S	884648	09/2013	08/19/2013	100.090	99.900	100.0	1
LG&E	C1S	884649	09/2013	08/19/2013	100.100	99.860	100.0	1

LG&E	C1S	884650	09/2013	08/19/2013	100.040	99.820	100.0	1
LG&E	C1S	884651	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884652	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884653	09/2013	08/19/2013	100.100	99.840	100.0	1
LG&E	C1S	884654	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884655	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884656	09/2013	08/19/2013	100.070	99.880	100.0	1
LG&E	C1S	884657	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884658	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884659	09/2013	08/19/2013	100.090	99.910	100.1	1
LG&E	C1S	884660	09/2013	08/19/2013	100.080	99.920	100.0	1
LG&E	C1S	884661	09/2013	08/19/2013	100.070	99.920	99.9	1
LG&E	C1S	884662	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884663	09/2013	08/19/2013	100.090	99.880	100.0	1
LG&E	C1S	884664	09/2013	08/19/2013	100.040	99.860	100.0	1
LG&E	C1S	884665	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884666	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884667	09/2013	08/19/2013	100.070	99.940	100.0	1
LG&E	C1S	884668	09/2013	08/19/2013	100.110	99.960	100.1	1
LG&E	C1S	884669	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884670	09/2013	08/19/2013	100.050	99.890	100.0	1
LG&E	C1S	884671	09/2013	08/19/2013	100.080	99.900	100.0	1
LG&E	C1S	884672	09/2013	08/19/2013	100.070	99.840	100.0	1
LG&E	C1S	884673	09/2013	08/19/2013	100.100	99.970	100.0	1
LG&E	C1S	884674	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884675	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884676	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884677	09/2013	08/19/2013	100.100	99.920	99.9	1
LG&E	C1S	884678	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884679	09/2013	08/19/2013	100.060	99.850	99.9	1

LG&E	C1S	884680	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884681	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884682	09/2013	08/19/2013	100.090	99.930	100.0	1
LG&E	C1S	884683	09/2013	08/19/2013	100.060	99.850	99.9	1
LG&E	C1S	884684	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884685	09/2013	08/19/2013	100.080	99.910	100.0	1
LG&E	C1S	884686	09/2013	08/19/2013	100.100	99.910	99.9	1
LG&E	C1S	884687	09/2013	08/19/2013	100.040	99.940	100.0	1
LG&E	C1S	884688	09/2013	08/19/2013	100.090	99.930	99.9	1
LG&E	C1S	884689	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884690	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884691	09/2013	08/19/2013	100.030	99.870	100.0	1
LG&E	C1S	884692	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884693	09/2013	08/19/2013	100.030	99.840	100.0	1
LG&E	C1S	884694	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884695	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884696	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884697	09/2013	08/19/2013	100.070	99.820	100.0	1
LG&E	C1S	884698	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884699	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884700	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884701	09/2013	08/19/2013	100.030	99.930	100.0	1
LG&E	C1S	884702	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884703	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884704	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884705	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884706	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884707	09/2013	08/19/2013	100.040	99.850	100.0	1
LG&E	C1S	884708	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884709	09/2013	08/19/2013	100.030	99.880	100.0	1

LG&E	C1S	884710	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884711	09/2013	08/19/2013	100.040	99.880	100.0	1
LG&E	C1S	884712	09/2013	08/19/2013	100.070	99.890	100.1	1
LG&E	C1S	884713	09/2013	08/19/2013	100.040	99.920	100.0	1
LG&E	C1S	884714	09/2013	08/19/2013	100.050	99.950	100.0	1
LG&E	C1S	884715	09/2013	08/19/2013	100.030	99.870	100.1	1
LG&E	C1S	884716	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884717	09/2013	08/19/2013	100.100	99.960	100.1	1
LG&E	C1S	884718	09/2013	08/19/2013	100.090	99.940	100.0	1
LG&E	C1S	884719	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884720	09/2013	08/19/2013	100.060	99.860	100.1	1
LG&E	C1S	884721	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884722	09/2013	08/19/2013	100.090	100.020	100.0	1
LG&E	C1S	884723	09/2013	08/19/2013	100.050	99.860	100.0	1
LG&E	C1S	884724	09/2013	08/19/2013	100.040	99.900	100.0	1
LG&E	C1S	884725	09/2013	08/19/2013	100.100	99.910	100.0	1
LG&E	C1S	884726	09/2013	08/19/2013	100.080	99.950	100.0	1
LG&E	C1S	884727	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884728	09/2013	08/19/2013	100.060	99.980	100.0	1
LG&E	C1S	884729	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884730	09/2013	08/19/2013	100.030	99.940	100.0	1
LG&E	C1S	884731	09/2013	08/19/2013	100.080	99.900	99.9	1
LG&E	C1S	884732	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884733	09/2013	08/19/2013	100.080	99.890	100.0	1
LG&E	C1S	884734	09/2013	08/19/2013	100.070	99.860	100.0	1
LG&E	C1S	884735	09/2013	08/19/2013	100.060	99.880	100.1	1
LG&E	C1S	884736	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884737	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884738	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884739	09/2013	08/19/2013	100.090	99.940	100.0	1

LG&E	C1S	884740	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884741	09/2013	08/19/2013	100.100	99.980	100.0	1
LG&E	C1S	884742	09/2013	08/19/2013	100.060	99.940	99.9	1
LG&E	C1S	884743	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884744	09/2013	08/19/2013	100.050	99.900	99.9	1
LG&E	C1S	884745	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884746	09/2013	08/19/2013	100.050	99.860	100.0	1
LG&E	C1S	884747	09/2013	08/19/2013	100.090	100.000	100.0	1
LG&E	C1S	884748	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884749	09/2013	08/19/2013	100.090	99.910	100.1	1
LG&E	C1S	884750	09/2013	08/19/2013	100.030	99.890	100.0	1
LG&E	C1S	884751	09/2013	08/19/2013	100.080	99.900	100.0	1
LG&E	C1S	884752	09/2013	08/19/2013	100.080	99.900	99.9	1
LG&E	C1S	884753	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884754	09/2013	08/19/2013	100.100	99.990	99.9	1
LG&E	C1S	884755	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884756	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884757	09/2013	08/19/2013	100.080	99.920	100.0	1
LG&E	C1S	884758	09/2013	08/19/2013	100.080	99.830	100.1	1
LG&E	C1S	884759	09/2013	08/19/2013	100.090	99.940	100.0	1
LG&E	C1S	884760	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884761	09/2013	08/19/2013	100.040	99.850	100.0	1
LG&E	C1S	884762	09/2013	08/19/2013	100.090	99.890	100.0	1
LG&E	C1S	884763	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884764	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884765	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884766	09/2013	08/19/2013	100.070	99.890	99.9	1
LG&E	C1S	884767	09/2013	08/19/2013	100.080	99.940	100.1	1
LG&E	C1S	884768	09/2013	08/19/2013	100.090	99.920	100.0	1
LG&E	C1S	884769	09/2013	08/19/2013	100.060	99.800	99.9	1

LG&E	C1S	884770	09/2013	08/19/2013	100.080	99.900	100.1	1
LG&E	C1S	884771	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884772	09/2013	08/19/2013	100.030	99.920	100.0	1
LG&E	C1S	884773	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884774	09/2013	08/19/2013	100.060	99.980	99.9	1
LG&E	C1S	884775	09/2013	08/19/2013	100.090	99.960	100.0	1
LG&E	C1S	884776	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884777	09/2013	08/19/2013	100.050	99.880	99.9	1
LG&E	C1S	884778	09/2013	08/19/2013	100.050	99.940	99.9	1
LG&E	C1S	884779	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884780	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884781	09/2013	08/19/2013	100.100	100.020	99.9	1
LG&E	C1S	884782	09/2013	08/19/2013	100.050	99.880	100.0	1
LG&E	C1S	884783	09/2013	08/19/2013	100.040	99.960	100.0	1
LG&E	C1S	884784	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884785	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884786	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884787	09/2013	08/19/2013	100.060	99.910	100.0	1
LG&E	C1S	884788	09/2013	08/19/2013	100.070	99.900	99.9	1
LG&E	C1S	884789	09/2013	08/19/2013	100.050	99.840	100.0	1
LG&E	C1S	884790	09/2013	08/19/2013	100.040	99.810	100.0	1
LG&E	C1S	884791	09/2013	08/19/2013	100.080	100.010	100.0	1
LG&E	C1S	884792	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884793	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884794	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884795	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884796	09/2013	08/19/2013	100.030	99.860	99.9	1
LG&E	C1S	884797	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884798	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884799	09/2013	08/19/2013	100.060	99.910	99.9	1

LG&E	C1S	884800	09/2013	08/19/2013	100.070	99.910	100.1	1
LG&E	C1S	884801	09/2013	08/19/2013	100.090	99.910	100.0	1
LG&E	C1S	884802	09/2013	08/19/2013	100.100	99.920	100.0	1
LG&E	C1S	884803	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884804	09/2013	08/19/2013	100.100	99.940	100.0	1
LG&E	C1S	884805	09/2013	08/19/2013	100.030	99.950	100.0	1
LG&E	C1S	884806	09/2013	08/19/2013	100.040	99.910	100.0	1
LG&E	C1S	884807	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884808	09/2013	08/19/2013	100.100	99.970	100.0	1
LG&E	C1S	884809	09/2013	08/19/2013	100.080	99.910	99.9	1
LG&E	C1S	884810	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884811	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884812	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884813	09/2013	08/19/2013	100.060	99.970	100.0	1
LG&E	C1S	884814	09/2013	08/19/2013	100.080	100.010	100.0	1
LG&E	C1S	884815	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884816	09/2013	08/19/2013	100.090	100.000	100.0	1
LG&E	C1S	884817	09/2013	08/19/2013	100.060	99.850	100.0	1
LG&E	C1S	884818	09/2013	08/19/2013	100.090	99.910	100.1	1
LG&E	C1S	884819	09/2013	08/19/2013	100.060	99.870	100.0	1
LG&E	C1S	884820	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884821	09/2013	08/19/2013	100.060	99.960	100.0	1
LG&E	C1S	884822	09/2013	08/19/2013	100.070	99.910	100.1	1
LG&E	C1S	884823	09/2013	08/19/2013	100.070	99.900	100.0	1
LG&E	C1S	884824	09/2013	08/19/2013	100.040	99.900	99.9	1
LG&E	C1S	884825	09/2013	08/19/2013	100.040	99.930	100.0	1
LG&E	C1S	884826	09/2013	08/19/2013	100.040	99.980	100.1	1
LG&E	C1S	884827	09/2013	08/19/2013	100.050	99.920	99.9	1
LG&E	C1S	884828	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884829	09/2013	08/19/2013	100.040	99.920	100.1	1

LG&E	C1S	884830	09/2013	08/19/2013	100.050	99.860	100.0	1
LG&E	C1S	884831	09/2013	08/19/2013	100.060	99.860	100.0	1
LG&E	C1S	884832	09/2013	08/19/2013	100.100	99.940	100.0	1
LG&E	C1S	884833	09/2013	08/19/2013	100.050	99.880	100.0	1
LG&E	C1S	884834	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884835	09/2013	08/19/2013	100.100	99.950	99.9	1
LG&E	C1S	884836	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884837	09/2013	08/19/2013	100.040	99.940	100.0	1
LG&E	C1S	884838	09/2013	08/19/2013	100.100	99.930	99.9	1
LG&E	C1S	884839	09/2013	08/19/2013	100.060	99.930	100.0	1
LG&E	C1S	884840	09/2013	08/19/2013	100.050	99.900	100.0	1
LG&E	C1S	884841	09/2013	08/19/2013	100.030	99.840	100.0	1
LG&E	C1S	884842	09/2013	08/19/2013	100.080	99.890	100.0	1
LG&E	C1S	884843	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884844	09/2013	08/19/2013	100.080	99.900	100.1	1
LG&E	C1S	884845	09/2013	08/19/2013	100.040	99.840	100.0	1
LG&E	C1S	884846	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884847	09/2013	08/19/2013	100.090	99.990	100.0	1
LG&E	C1S	884848	09/2013	08/19/2013	100.050	99.890	99.9	1
LG&E	C1S	884849	09/2013	08/19/2013	100.100	99.890	100.1	1
LG&E	C1S	884850	09/2013	08/19/2013	100.070	99.970	100.0	1
LG&E	C1S	884851	09/2013	08/19/2013	100.070	99.920	100.0	1
LG&E	C1S	884852	09/2013	08/19/2013	100.050	99.900	99.9	1
LG&E	C1S	884853	09/2013	08/19/2013	100.080	99.930	100.0	1
LG&E	C1S	884854	09/2013	08/19/2013	100.090	99.950	100.0	1
LG&E	C1S	884855	09/2013	08/19/2013	100.050	99.890	99.9	1
LG&E	C1S	884856	09/2013	08/19/2013	100.100	99.910	100.0	1
LG&E	C1S	884857	09/2013	08/19/2013	100.060	99.890	100.0	1
LG&E	C1S	884858	09/2013	08/19/2013	100.050	99.910	100.0	1
LG&E	C1S	884859	09/2013	08/19/2013	100.050	99.880	99.9	1

LG&E	C1S	884860	09/2013	08/19/2013	100.090	99.990	100.0	1
LG&E	C1S	884861	09/2013	08/19/2013	100.070	99.870	100.0	1
LG&E	C1S	884862	09/2013	08/19/2013	100.070	99.900	100.1	1
LG&E	C1S	884863	09/2013	08/19/2013	100.030	99.900	99.9	1
LG&E	C1S	884864	09/2013	08/19/2013	100.050	99.920	99.9	1
LG&E	C1S	884865	09/2013	08/19/2013	100.060	99.950	100.0	1
LG&E	C1S	884866	09/2013	08/19/2013	100.070	99.960	100.0	1
LG&E	C1S	884867	09/2013	08/19/2013	100.070	99.910	99.9	1
LG&E	C1S	884868	09/2013	08/19/2013	100.050	99.810	99.9	1
LG&E	C1S	884869	09/2013	08/19/2013	100.060	99.870	100.0	1
LG&E	C1S	884870	09/2013	08/19/2013	100.090	99.880	99.9	1
LG&E	C1S	884871	09/2013	08/19/2013	100.060	99.940	100.0	1
LG&E	C1S	884872	09/2013	08/19/2013	100.060	99.910	99.9	1
LG&E	C1S	884873	09/2013	08/19/2013	100.100	99.930	100.1	1
LG&E	C1S	884874	09/2013	08/19/2013	100.090	99.870	100.1	1
LG&E	C1S	884875	09/2013	08/19/2013	100.060	99.840	100.1	1
LG&E	C1S	884876	09/2013	08/19/2013	100.030	99.880	100.0	1
LG&E	C1S	884877	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884878	09/2013	08/19/2013	100.090	99.830	100.0	1
LG&E	C1S	884879	09/2013	08/19/2013	100.060	99.870	100.0	1
LG&E	C1S	884880	09/2013	08/19/2013	100.080	99.910	100.1	1
LG&E	C1S	884881	09/2013	08/19/2013	100.080	99.900	100.1	1
LG&E	C1S	884882	09/2013	08/19/2013	100.100	99.880	100.1	1
LG&E	C1S	884883	09/2013	08/19/2013	100.100	99.940	100.0	1
LG&E	C1S	884884	09/2013	08/19/2013	100.070	99.910	100.0	1
LG&E	C1S	884885	09/2013	08/19/2013	100.080	100.000	100.0	1
LG&E	C1S	884886	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884887	09/2013	08/19/2013	100.060	99.920	100.0	1
LG&E	C1S	884888	09/2013	08/19/2013	100.080	99.970	100.0	1
LG&E	C1S	884889	09/2013	08/19/2013	100.070	99.870	100.0	1

LG&E	C1S	884890	09/2013	08/19/2013	100.090	100.030	100.0	1
LG&E	C1S	884891	09/2013	08/19/2013	100.070	99.930	100.0	1
LG&E	C1S	884892	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884893	09/2013	08/19/2013	100.060	99.880	100.0	1
LG&E	C1S	884894	09/2013	08/19/2013	100.040	99.870	100.0	1
LG&E	C1S	884895	09/2013	08/19/2013	100.050	99.920	100.0	1
LG&E	C1S	884896	09/2013	08/19/2013	100.060	99.930	99.9	1
LG&E	C1S	884897	09/2013	08/19/2013	100.080	99.930	100.1	1
LG&E	C1S	884898	09/2013	08/19/2013	100.060	99.970	100.0	1
LG&E	C1S	884899	09/2013	08/19/2013	100.060	99.900	99.9	1
LG&E	C1S	884900	09/2013	08/19/2013	100.090	99.890	100.0	1
LG&E	C1S	884901	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884902	09/2013	08/19/2013	100.030	99.840	99.9	1
LG&E	C1S	884903	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884904	09/2013	08/19/2013	100.080	99.950	100.0	1
LG&E	C1S	884905	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1S	884906	09/2013	08/19/2013	100.050	99.990	100.0	1
LG&E	C1S	884907	09/2013	08/19/2013	100.090	100.000	100.0	1
LG&E	C1S	884908	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884909	09/2013	08/19/2013	100.030	99.900	100.0	1
LG&E	C1S	884910	09/2013	08/19/2013	100.070	99.960	99.9	1
LG&E	C1S	884911	09/2013	08/19/2013	100.100	100.000	100.0	1
LG&E	C1S	884912	09/2013	08/19/2013	100.090	99.980	100.0	1
LG&E	C1S	884913	09/2013	08/19/2013	100.030	99.850	100.0	1
LG&E	C1S	884914	09/2013	08/19/2013	100.080	100.010	100.0	1
LG&E	C1S	884915	09/2013	08/19/2013	100.100	99.940	100.0	1
LG&E	C1S	884916	09/2013	08/19/2013	100.090	99.970	100.0	1
LG&E	C1S	884917	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884918	09/2013	08/19/2013	100.030	99.850	100.1	1
LG&E	C1S	884919	09/2013	08/19/2013	100.060	99.950	100.0	1

LG&E	C1S	884920	09/2013	08/19/2013	100.070	99.860	100.0	1
LG&E	C1S	884921	09/2013	08/19/2013	100.060	99.900	100.0	1
LG&E	C1S	884922	09/2013	08/19/2013	100.040	99.880	100.0	1
LG&E	C1S	884923	09/2013	08/19/2013	100.060	99.920	99.9	1
LG&E	C1S	884924	09/2013	08/19/2013	100.050	99.870	99.9	1
LG&E	C1S	884925	09/2013	08/19/2013	100.070	99.950	100.0	1
LG&E	C1S	884926	09/2013	08/19/2013	100.060	100.010	100.1	1
LG&E	C1S	884927	09/2013	08/19/2013	100.060	99.890	99.9	1
LG&E	C1S	884928	09/2013	08/19/2013	100.030	99.880	100.0	1
LG&E	C1S	884929	09/2013	08/19/2013	100.080	99.960	100.0	1
LG&E	C1S	884930	09/2013	08/19/2013	100.040	99.890	100.0	1
LG&E	C1S	884931	09/2013	08/19/2013	100.080	99.940	100.0	1
LG&E	C1SR	882924	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	882925	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	882926	07/2013	07/22/2013	100.050	99.940	100.0	1
LG&E	C1SR	882927	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	882928	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	882929	07/2013	07/22/2013	100.060	99.830	99.9	1
LG&E	C1SR	882930	07/2013	07/22/2013	100.090	99.890	100.0	1
LG&E	C1SR	882931	07/2013	07/22/2013	100.090	99.970	100.1	1
LG&E	C1SR	882932	07/2013	07/22/2013	100.080	99.850	100.0	1
LG&E	C1SR	882933	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	882934	07/2013	07/22/2013	100.070	100.000	100.0	1
LG&E	C1SR	882935	07/2013	07/22/2013	100.080	99.900	100.1	1
LG&E	C1SR	882936	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	882937	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	882938	07/2013	07/22/2013	100.090	99.910	100.1	1
LG&E	C1SR	882939	07/2013	07/22/2013	100.090	99.940	99.9	1
LG&E	C1SR	882940	07/2013	07/22/2013	100.070	99.950	99.9	1
LG&E	C1SR	882941	07/2013	07/22/2013	100.060	99.890	100.0	1

LG&E	C1SR	882942	07/2013	07/22/2013	100.080	99.930	100.2	1
LG&E	C1SR	882943	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	882944	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	882945	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	882946	07/2013	07/22/2013	100.070	99.900	100.1	1
LG&E	C1SR	882947	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	882948	07/2013	07/22/2013	100.090	99.880	100.0	1
LG&E	C1SR	882949	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	882950	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	882951	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	882952	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	882953	07/2013	07/22/2013	100.060	99.850	100.0	1
LG&E	C1SR	882954	07/2013	07/22/2013	100.080	99.880	100.0	1
LG&E	C1SR	882955	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	882956	07/2013	07/22/2013	100.050	99.960	100.0	1
LG&E	C1SR	882957	07/2013	07/22/2013	100.050	99.920	100.1	1
LG&E	C1SR	882958	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	882959	07/2013	07/22/2013	100.060	100.030	100.0	1
LG&E	C1SR	882960	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	882961	07/2013	07/22/2013	100.080	100.000	100.0	1
LG&E	C1SR	882962	07/2013	07/22/2013	100.060	99.910	100.1	1
LG&E	C1SR	882963	07/2013	07/22/2013	100.070	99.950	100.1	1
LG&E	C1SR	882964	07/2013	07/22/2013	100.090	99.890	99.9	1
LG&E	C1SR	882965	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	882966	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	882967	07/2013	07/22/2013	100.080	99.930	100.2	1
LG&E	C1SR	882968	07/2013	07/22/2013	100.050	99.800	100.0	1
LG&E	C1SR	882969	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	882970	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	882971	07/2013	07/22/2013	100.090	100.000	100.1	1

LG&E	C1SR	882972	07/2013	07/22/2013	100.080	99.920	99.9	1
LG&E	C1SR	882973	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	882974	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	882975	07/2013	07/22/2013	100.070	99.940	100.1	1
LG&E	C1SR	882976	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	882977	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	882978	07/2013	07/22/2013	100.050	99.940	100.0	1
LG&E	C1SR	882979	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	882980	07/2013	07/22/2013	100.050	99.900	100.0	1
LG&E	C1SR	882981	07/2013	07/22/2013	100.070	99.950	100.1	1
LG&E	C1SR	882982	07/2013	07/22/2013	100.080	100.010	99.9	1
LG&E	C1SR	882983	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	882984	07/2013	07/22/2013	100.050	99.940	99.9	1
LG&E	C1SR	882985	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	882986	07/2013	07/22/2013	100.070	99.970	99.9	1
LG&E	C1SR	882987	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	882988	07/2013	07/22/2013	100.070	99.970	100.0	1
LG&E	C1SR	882989	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	882990	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	882991	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	882992	07/2013	07/22/2013	100.080	99.900	100.1	1
LG&E	C1SR	882993	07/2013	07/22/2013	100.080	100.030	100.0	1
LG&E	C1SR	882994	07/2013	07/22/2013	100.080	99.920	100.1	1
LG&E	C1SR	882995	07/2013	07/22/2013	100.070	99.960	100.1	1
LG&E	C1SR	882996	07/2013	07/22/2013	100.060	99.870	100.1	1
LG&E	C1SR	882997	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	882998	07/2013	07/22/2013	100.070	99.930	99.9	1
LG&E	C1SR	882999	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	883000	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883001	07/2013	07/22/2013	100.060	99.960	100.0	1

LG&E	C1SR	883002	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883003	07/2013	07/22/2013	100.080	99.980	99.9	1
LG&E	C1SR	883004	07/2013	07/22/2013	100.100	100.000	100.1	1
LG&E	C1SR	883005	07/2013	07/22/2013	100.080	100.040	100.1	1
LG&E	C1SR	883006	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883007	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883008	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883009	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883010	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883011	07/2013	07/22/2013	100.060	99.910	99.9	1
LG&E	C1SR	883012	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883013	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883014	07/2013	07/22/2013	100.070	99.980	100.0	1
LG&E	C1SR	883015	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883016	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883017	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883018	07/2013	07/22/2013	100.070	100.030	100.0	1
LG&E	C1SR	883019	07/2013	07/22/2013	100.090	100.070	100.1	1
LG&E	C1SR	883020	07/2013	07/22/2013	100.070	99.890	99.9	1
LG&E	C1SR	883021	07/2013	07/22/2013	100.060	99.940	99.9	1
LG&E	C1SR	883022	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883023	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883024	07/2013	07/22/2013	100.060	100.040	100.1	1
LG&E	C1SR	883025	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883026	07/2013	07/22/2013	100.050	99.940	99.9	1
LG&E	C1SR	883027	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883028	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883029	07/2013	07/22/2013	100.050	100.000	100.0	1
LG&E	C1SR	883030	07/2013	07/22/2013	100.050	100.000	100.1	1
LG&E	C1SR	883031	07/2013	07/22/2013	100.060	99.940	100.0	1

LG&E	C1SR	883032	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883033	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883034	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883035	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	883036	07/2013	07/22/2013	100.050	99.940	99.9	1
LG&E	C1SR	883037	07/2013	07/22/2013	100.050	99.870	100.0	1
LG&E	C1SR	883038	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883039	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883040	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883041	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883042	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883043	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883044	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883045	07/2013	07/22/2013	100.050	99.880	99.9	1
LG&E	C1SR	883046	07/2013	07/22/2013	100.050	99.920	99.9	1
LG&E	C1SR	883047	07/2013	07/22/2013	100.090	99.990	100.2	1
LG&E	C1SR	883048	07/2013	07/22/2013	100.070	100.000	100.0	1
LG&E	C1SR	883049	07/2013	07/22/2013	100.090	100.040	100.0	1
LG&E	C1SR	883050	07/2013	07/22/2013	100.100	99.930	100.1	1
LG&E	C1SR	883051	07/2013	07/22/2013	100.070	99.860	100.0	1
LG&E	C1SR	883052	07/2013	07/22/2013	100.060	99.970	100.0	1
LG&E	C1SR	883053	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883054	07/2013	07/22/2013	100.060	100.000	100.1	1
LG&E	C1SR	883055	07/2013	07/22/2013	100.060	99.950	100.1	1
LG&E	C1SR	883056	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883057	07/2013	07/22/2013	100.090	100.010	100.0	1
LG&E	C1SR	883058	07/2013	07/22/2013	100.050	99.980	100.0	1
LG&E	C1SR	883059	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883060	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883061	07/2013	07/22/2013	100.090	100.000	100.1	1

LG&E	C1SR	883062	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883063	07/2013	07/22/2013	100.090	99.920	100.1	1
LG&E	C1SR	883064	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883065	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883066	07/2013	07/22/2013	100.060	99.930	100.1	1
LG&E	C1SR	883067	07/2013	07/22/2013	100.060	99.890	100.1	1
LG&E	C1SR	883068	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883069	07/2013	07/22/2013	100.070	100.010	99.9	1
LG&E	C1SR	883070	07/2013	07/22/2013	100.050	99.940	99.9	1
LG&E	C1SR	883071	07/2013	07/22/2013	100.050	99.950	99.9	1
LG&E	C1SR	883072	07/2013	07/22/2013	100.080	99.990	100.0	1
LG&E	C1SR	883073	07/2013	07/22/2013	100.090	99.980	100.0	1
LG&E	C1SR	883074	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883075	07/2013	07/22/2013	100.060	99.890	100.1	1
LG&E	C1SR	883076	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883077	07/2013	07/22/2013	100.070	99.970	99.9	1
LG&E	C1SR	883078	07/2013	07/22/2013	100.100	99.950	100.1	1
LG&E	C1SR	883079	07/2013	07/22/2013	100.080	99.960	100.2	1
LG&E	C1SR	883080	07/2013	07/22/2013	100.090	99.950	100.1	1
LG&E	C1SR	883081	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883082	07/2013	07/22/2013	100.060	100.010	100.1	1
LG&E	C1SR	883083	07/2013	07/22/2013	100.060	99.950	100.1	1
LG&E	C1SR	883084	07/2013	07/22/2013	100.100	99.970	100.1	1
LG&E	C1SR	883085	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883086	07/2013	07/22/2013	100.100	100.030	100.1	1
LG&E	C1SR	883087	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883088	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883089	07/2013	07/22/2013	100.100	100.030	100.1	1
LG&E	C1SR	883090	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883091	07/2013	07/22/2013	100.050	99.890	100.1	1

LG&E	C1SR	883092	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	883093	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883094	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	883095	07/2013	07/22/2013	100.080	100.000	99.9	1
LG&E	C1SR	883096	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883097	07/2013	07/22/2013	100.070	100.030	100.1	1
LG&E	C1SR	883098	07/2013	07/22/2013	100.080	100.000	100.0	1
LG&E	C1SR	883099	07/2013	07/22/2013	100.050	99.850	100.0	1
LG&E	C1SR	883100	07/2013	07/22/2013	100.080	99.860	100.1	1
LG&E	C1SR	883101	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883102	07/2013	07/22/2013	100.050	99.900	100.1	1
LG&E	C1SR	883103	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883104	07/2013	07/22/2013	100.050	99.810	100.0	1
LG&E	C1SR	883105	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883106	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883107	07/2013	07/22/2013	100.090	99.980	100.0	1
LG&E	C1SR	883108	07/2013	07/22/2013	100.090	99.940	100.2	1
LG&E	C1SR	883109	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883110	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883111	07/2013	07/22/2013	100.070	99.960	100.1	1
LG&E	C1SR	883112	07/2013	07/22/2013	100.080	99.990	100.1	1
LG&E	C1SR	883113	07/2013	07/22/2013	100.090	100.010	100.0	1
LG&E	C1SR	883114	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883115	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883116	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883117	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883118	07/2013	07/22/2013	100.050	99.910	100.0	1
LG&E	C1SR	883119	07/2013	07/22/2013	100.080	99.810	100.0	1
LG&E	C1SR	883120	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883121	07/2013	07/22/2013	100.080	100.000	100.1	1

LG&E	C1SR	883122	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883123	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883124	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883125	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883126	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883127	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883128	07/2013	07/22/2013	100.050	99.990	100.0	1
LG&E	C1SR	883129	07/2013	07/22/2013	100.100	99.990	100.0	1
LG&E	C1SR	883130	07/2013	07/22/2013	100.080	100.010	99.9	1
LG&E	C1SR	883131	07/2013	07/22/2013	100.090	100.020	100.1	1
LG&E	C1SR	883132	07/2013	07/22/2013	100.100	99.930	100.0	1
LG&E	C1SR	883133	07/2013	07/22/2013	100.080	100.020	100.1	1
LG&E	C1SR	883134	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883135	07/2013	07/22/2013	100.050	99.950	100.0	1
LG&E	C1SR	883136	07/2013	07/22/2013	100.070	99.990	100.1	1
LG&E	C1SR	883137	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883138	07/2013	07/22/2013	100.050	99.910	100.0	1
LG&E	C1SR	883139	07/2013	07/22/2013	100.090	99.870	100.0	1
LG&E	C1SR	883140	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883141	07/2013	07/22/2013	100.080	99.860	100.0	1
LG&E	C1SR	883142	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	883143	07/2013	07/22/2013	100.080	100.000	100.1	1
LG&E	C1SR	883144	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883145	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883146	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883147	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883148	07/2013	07/22/2013	100.070	99.990	100.0	1
LG&E	C1SR	883149	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883150	07/2013	07/22/2013	100.100	99.940	100.0	1
LG&E	C1SR	883151	07/2013	07/22/2013	100.050	99.930	100.1	1

LG&E	C1SR	883152	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883153	07/2013	07/22/2013	100.090	99.980	100.0	1
LG&E	C1SR	883154	07/2013	07/22/2013	100.090	99.890	100.0	1
LG&E	C1SR	883155	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883156	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883157	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883158	07/2013	07/22/2013	100.100	99.960	100.1	1
LG&E	C1SR	883159	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883160	07/2013	07/22/2013	100.050	100.010	100.1	1
LG&E	C1SR	883161	07/2013	07/22/2013	100.060	100.000	100.0	1
LG&E	C1SR	883162	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883163	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883164	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883165	07/2013	07/22/2013	100.060	99.970	100.1	1
LG&E	C1SR	883166	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	883167	07/2013	07/22/2013	100.050	99.860	100.0	1
LG&E	C1SR	883168	07/2013	07/22/2013	100.100	99.980	100.1	1
LG&E	C1SR	883169	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883170	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883171	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883172	07/2013	07/22/2013	100.050	99.860	100.0	1
LG&E	C1SR	883173	07/2013	07/22/2013	100.050	99.880	99.9	1
LG&E	C1SR	883174	07/2013	07/22/2013	100.090	99.990	100.1	1
LG&E	C1SR	883175	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883176	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883177	07/2013	07/22/2013	100.090	100.070	100.1	1
LG&E	C1SR	883178	07/2013	07/22/2013	100.060	99.930	100.1	1
LG&E	C1SR	883179	07/2013	07/22/2013	100.060	99.940	100.1	1
LG&E	C1SR	883180	07/2013	07/22/2013	100.050	99.960	100.1	1
LG&E	C1SR	883181	07/2013	07/22/2013	100.050	99.910	100.0	1

LG&E	C1SR	883182	07/2013	07/22/2013	100.100	100.030	100.0	1
LG&E	C1SR	883183	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883184	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883185	07/2013	07/22/2013	100.060	99.990	100.1	1
LG&E	C1SR	883186	07/2013	07/22/2013	100.080	99.910	100.0	1
LG&E	C1SR	883187	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883188	07/2013	07/22/2013	100.070	99.890	100.1	1
LG&E	C1SR	883189	07/2013	07/22/2013	100.090	99.980	99.9	1
LG&E	C1SR	883190	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883191	07/2013	07/22/2013	100.060	100.000	100.1	1
LG&E	C1SR	883192	07/2013	07/22/2013	100.050	99.870	100.0	1
LG&E	C1SR	883193	07/2013	07/22/2013	100.060	99.920	99.9	1
LG&E	C1SR	883194	07/2013	07/22/2013	100.090	100.020	100.0	1
LG&E	C1SR	883195	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883196	07/2013	07/22/2013	100.100	99.890	100.0	1
LG&E	C1SR	883197	07/2013	07/22/2013	100.100	99.950	100.0	1
LG&E	C1SR	883198	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883199	07/2013	07/22/2013	100.080	99.980	99.9	1
LG&E	C1SR	883200	07/2013	07/22/2013	100.090	99.890	100.0	1
LG&E	C1SR	883201	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883202	07/2013	07/22/2013	100.090	99.880	100.1	1
LG&E	C1SR	883203	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883204	07/2013	07/22/2013	100.070	99.960	99.9	1
LG&E	C1SR	883205	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883206	07/2013	07/22/2013	100.050	99.890	100.0	1
LG&E	C1SR	883207	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883208	07/2013	07/22/2013	100.070	99.980	99.9	1
LG&E	C1SR	883209	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883210	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	883211	07/2013	07/22/2013	100.100	99.960	100.1	1

LG&E	C1SR	883212	07/2013	07/22/2013	100.110	99.970	100.1	1
LG&E	C1SR	883213	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883214	07/2013	07/22/2013	100.100	99.940	100.1	1
LG&E	C1SR	883215	07/2013	07/22/2013	100.070	99.890	99.9	1
LG&E	C1SR	883216	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883217	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883218	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883219	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883220	07/2013	07/22/2013	100.060	99.960	99.9	1
LG&E	C1SR	883221	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883222	07/2013	07/22/2013	100.060	99.960	100.0	1
LG&E	C1SR	883223	07/2013	07/22/2013	100.060	99.960	99.9	1
LG&E	C1SR	883224	07/2013	07/22/2013	100.060	99.980	100.1	1
LG&E	C1SR	883225	07/2013	07/22/2013	100.090	99.860	100.1	1
LG&E	C1SR	883226	07/2013	07/22/2013	100.050	100.020	100.0	1
LG&E	C1SR	883227	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	883228	07/2013	07/22/2013	100.090	99.880	99.9	1
LG&E	C1SR	883229	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883230	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883231	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883232	07/2013	07/22/2013	100.090	99.890	100.1	1
LG&E	C1SR	883233	07/2013	07/22/2013	100.090	99.910	100.1	1
LG&E	C1SR	883234	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883235	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883236	07/2013	07/22/2013	100.090	99.910	100.1	1
LG&E	C1SR	883237	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883238	07/2013	07/22/2013	100.070	99.950	99.9	1
LG&E	C1SR	883239	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883240	07/2013	07/22/2013	100.090	100.060	100.1	1
LG&E	C1SR	883241	07/2013	07/22/2013	100.060	99.970	100.1	1

LG&E	C1SR	883242	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883243	07/2013	07/22/2013	100.080	99.890	99.9	1
LG&E	C1SR	883244	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883245	07/2013	07/22/2013	100.070	99.990	100.0	1
LG&E	C1SR	883246	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883247	07/2013	07/22/2013	100.060	99.940	99.9	1
LG&E	C1SR	883248	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883249	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883250	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883251	07/2013	07/22/2013	100.060	99.850	100.0	1
LG&E	C1SR	883252	07/2013	07/22/2013	100.080	99.880	100.0	1
LG&E	C1SR	883253	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883254	07/2013	07/22/2013	100.100	99.990	100.1	1
LG&E	C1SR	883255	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883256	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883257	07/2013	07/22/2013	100.080	99.940	100.2	1
LG&E	C1SR	883258	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883259	07/2013	07/22/2013	100.070	100.030	100.0	1
LG&E	C1SR	883260	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883261	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883262	07/2013	07/22/2013	100.090	99.940	100.2	1
LG&E	C1SR	883263	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883264	07/2013	07/22/2013	100.090	99.990	100.1	1
LG&E	C1SR	883265	07/2013	07/22/2013	100.050	99.930	100.0	1
LG&E	C1SR	883266	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883267	07/2013	07/22/2013	100.060	99.940	100.1	1
LG&E	C1SR	883268	07/2013	07/22/2013	100.100	99.890	100.0	1
LG&E	C1SR	883269	07/2013	07/22/2013	100.050	99.950	99.9	1
LG&E	C1SR	883270	07/2013	07/22/2013	100.090	100.040	100.1	1
LG&E	C1SR	883271	07/2013	07/22/2013	100.070	99.970	100.0	1

LG&E	C1SR	883272	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883273	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883274	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883275	07/2013	07/22/2013	100.090	99.920	100.1	1
LG&E	C1SR	883276	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883277	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883278	07/2013	07/22/2013	100.080	100.010	100.0	1
LG&E	C1SR	883279	07/2013	07/22/2013	100.050	99.960	100.0	1
LG&E	C1SR	883280	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883281	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883282	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883283	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883284	07/2013	07/22/2013	100.100	99.980	100.1	1
LG&E	C1SR	883285	07/2013	07/22/2013	100.070	99.980	100.0	1
LG&E	C1SR	883286	07/2013	07/22/2013	100.050	99.940	100.1	1
LG&E	C1SR	883287	07/2013	07/22/2013	100.080	99.890	99.9	1
LG&E	C1SR	883288	07/2013	07/22/2013	100.060	99.930	99.9	1
LG&E	C1SR	883289	07/2013	07/22/2013	100.090	100.000	100.0	1
LG&E	C1SR	883290	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883291	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883292	07/2013	07/22/2013	100.080	99.920	100.1	1
LG&E	C1SR	883293	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883294	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883295	07/2013	07/22/2013	100.100	100.070	100.1	1
LG&E	C1SR	883296	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883297	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883298	07/2013	07/22/2013	100.050	99.940	100.0	1
LG&E	C1SR	883299	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883300	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883301	07/2013	07/22/2013	100.090	99.990	100.1	1

LG&E	C1SR	883302	07/2013	07/22/2013	100.060	99.950	99.9	1
LG&E	C1SR	883303	07/2013	07/22/2013	100.100	100.020	100.0	1
LG&E	C1SR	883304	07/2013	07/22/2013	100.080	99.860	100.1	1
LG&E	C1SR	883305	07/2013	07/22/2013	100.060	99.860	99.9	1
LG&E	C1SR	883306	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883307	07/2013	07/22/2013	100.080	99.900	100.1	1
LG&E	C1SR	883308	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883309	07/2013	07/22/2013	100.090	100.030	100.1	1
LG&E	C1SR	883310	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883311	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883312	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883313	07/2013	07/22/2013	100.060	100.020	100.1	1
LG&E	C1SR	883314	07/2013	07/22/2013	100.090	100.040	100.1	1
LG&E	C1SR	883315	07/2013	07/22/2013	100.090	100.000	100.0	1
LG&E	C1SR	883316	07/2013	07/22/2013	100.080	100.010	100.1	1
LG&E	C1SR	883317	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883318	07/2013	07/22/2013	100.090	99.900	100.1	1
LG&E	C1SR	883319	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883320	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883321	07/2013	07/22/2013	100.070	99.970	100.1	1
LG&E	C1SR	883322	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883323	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883324	07/2013	07/22/2013	100.050	99.930	100.0	1
LG&E	C1SR	883325	07/2013	07/22/2013	100.070	99.950	100.1	1
LG&E	C1SR	883326	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883327	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883328	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883329	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883330	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883331	07/2013	07/22/2013	100.060	99.920	100.0	1

LG&E	C1SR	883332	07/2013	07/22/2013	100.060	99.860	99.9	1
LG&E	C1SR	883333	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883334	07/2013	07/22/2013	100.050	99.930	99.9	1
LG&E	C1SR	883335	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883336	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883337	07/2013	07/22/2013	100.050	99.910	100.1	1
LG&E	C1SR	883338	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883339	07/2013	07/22/2013	100.080	99.920	100.1	1
LG&E	C1SR	883340	07/2013	07/22/2013	100.060	99.910	100.1	1
LG&E	C1SR	883341	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883342	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883343	07/2013	07/22/2013	100.060	99.930	99.9	1
LG&E	C1SR	883344	07/2013	07/22/2013	100.060	99.950	100.1	1
LG&E	C1SR	883345	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883346	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883347	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883348	07/2013	07/22/2013	100.070	99.840	100.0	1
LG&E	C1SR	883349	07/2013	07/22/2013	100.070	99.900	99.9	1
LG&E	C1SR	883350	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883351	07/2013	07/22/2013	100.050	99.910	100.0	1
LG&E	C1SR	883352	07/2013	07/22/2013	100.070	99.940	100.1	1
LG&E	C1SR	883353	07/2013	07/22/2013	100.090	99.910	100.1	1
LG&E	C1SR	883354	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883355	07/2013	07/22/2013	100.050	99.950	99.9	1
LG&E	C1SR	883356	07/2013	07/22/2013	100.070	100.020	100.0	1
LG&E	C1SR	883357	07/2013	07/22/2013	100.090	99.970	100.1	1
LG&E	C1SR	883358	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883359	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883360	07/2013	07/22/2013	100.080	100.010	100.0	1
LG&E	C1SR	883361	07/2013	07/22/2013	100.060	99.900	99.9	1

LG&E	C1SR	883362	07/2013	07/22/2013	100.050	99.890	100.0	1
LG&E	C1SR	883363	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883364	07/2013	07/22/2013	100.060	99.970	100.0	1
LG&E	C1SR	883365	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883366	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883367	07/2013	07/22/2013	100.100	100.020	100.1	1
LG&E	C1SR	883368	07/2013	07/22/2013	100.060	99.840	100.0	1
LG&E	C1SR	883369	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883370	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883371	07/2013	07/22/2013	100.100	99.960	100.1	1
LG&E	C1SR	883372	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883373	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883374	07/2013	07/22/2013	100.100	99.940	100.1	1
LG&E	C1SR	883375	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883376	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883377	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883378	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883379	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883380	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883381	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883382	07/2013	07/22/2013	100.050	99.840	100.0	1
LG&E	C1SR	883383	07/2013	07/22/2013	100.060	99.900	99.9	1
LG&E	C1SR	883384	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883385	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883386	07/2013	07/22/2013	100.090	100.020	100.0	1
LG&E	C1SR	883387	07/2013	07/22/2013	100.080	99.990	99.9	1
LG&E	C1SR	883388	07/2013	07/22/2013	100.090	99.950	99.9	1
LG&E	C1SR	883389	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883390	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883391	07/2013	07/22/2013	100.080	99.910	100.0	1

LG&E	C1SR	883392	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883393	07/2013	07/22/2013	100.070	99.860	100.1	1
LG&E	C1SR	883394	07/2013	07/22/2013	100.100	99.920	100.1	1
LG&E	C1SR	883395	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883396	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883397	07/2013	07/22/2013	100.100	99.970	100.0	1
LG&E	C1SR	883398	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883399	07/2013	07/22/2013	100.080	99.910	100.1	1
LG&E	C1SR	883400	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883401	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883402	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883403	07/2013	07/22/2013	100.090	100.000	100.1	1
LG&E	C1SR	883404	07/2013	07/22/2013	100.050	99.890	99.9	1
LG&E	C1SR	883405	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	883406	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883407	07/2013	07/22/2013	100.080	100.010	100.1	1
LG&E	C1SR	883408	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883409	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883410	07/2013	07/22/2013	100.100	99.970	100.1	1
LG&E	C1SR	883411	07/2013	07/22/2013	100.100	99.940	100.0	1
LG&E	C1SR	883412	07/2013	07/22/2013	100.090	100.050	100.1	1
LG&E	C1SR	883413	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883414	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883415	07/2013	07/22/2013	100.080	100.020	100.0	1
LG&E	C1SR	883416	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	883417	07/2013	07/22/2013	100.050	99.950	100.0	1
LG&E	C1SR	883418	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883419	07/2013	07/22/2013	100.060	99.880	99.9	1
LG&E	C1SR	883420	07/2013	07/22/2013	100.080	99.880	100.0	1
LG&E	C1SR	883421	07/2013	07/22/2013	100.060	99.960	100.0	1

LG&E	C1SR	883422	07/2013	07/22/2013	100.050	99.930	100.0	1
LG&E	C1SR	883423	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883424	07/2013	07/22/2013	100.070	99.930	99.9	1
LG&E	C1SR	883425	07/2013	07/22/2013	100.060	99.920	99.9	1
LG&E	C1SR	883426	07/2013	07/22/2013	100.050	99.910	99.9	1
LG&E	C1SR	883427	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883428	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883429	07/2013	07/22/2013	100.080	99.850	99.9	1
LG&E	C1SR	883430	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883431	07/2013	07/22/2013	100.060	99.930	100.1	1
LG&E	C1SR	883432	07/2013	07/22/2013	100.060	99.830	99.9	1
LG&E	C1SR	883433	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883434	07/2013	07/22/2013	100.070	99.990	99.9	1
LG&E	C1SR	883435	07/2013	07/22/2013	100.080	99.990	100.0	1
LG&E	C1SR	883436	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883437	07/2013	07/22/2013	100.070	100.010	100.0	1
LG&E	C1SR	883438	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883439	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883440	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883441	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883442	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	883443	07/2013	07/22/2013	100.070	99.840	100.0	1
LG&E	C1SR	883444	07/2013	07/22/2013	100.060	99.870	100.1	1
LG&E	C1SR	883445	07/2013	07/22/2013	100.100	99.950	100.1	1
LG&E	C1SR	883446	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883447	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883448	07/2013	07/22/2013	100.100	99.910	100.1	1
LG&E	C1SR	883449	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883450	07/2013	07/22/2013	100.060	99.930	99.9	1
LG&E	C1SR	883451	07/2013	07/22/2013	100.050	99.930	99.9	1

LG&E	C1SR	883452	07/2013	07/22/2013	100.060	99.900	99.9	1
LG&E	C1SR	883453	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883454	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883455	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883456	07/2013	07/22/2013	100.080	99.980	100.1	1
LG&E	C1SR	883457	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883458	07/2013	07/22/2013	100.060	99.960	99.9	1
LG&E	C1SR	883459	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883460	07/2013	07/22/2013	100.050	99.980	100.1	1
LG&E	C1SR	883461	07/2013	07/22/2013	100.090	100.000	100.0	1
LG&E	C1SR	883462	07/2013	07/22/2013	100.070	99.940	100.1	1
LG&E	C1SR	883463	07/2013	07/22/2013	100.060	99.960	100.0	1
LG&E	C1SR	883464	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883465	07/2013	07/22/2013	100.080	99.910	100.1	1
LG&E	C1SR	883466	07/2013	07/22/2013	100.080	99.870	100.0	1
LG&E	C1SR	883467	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883468	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883469	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883470	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883471	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883472	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883473	07/2013	07/22/2013	100.070	99.880	99.9	1
LG&E	C1SR	883474	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883475	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883476	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883477	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883478	07/2013	07/22/2013	100.050	99.990	100.0	1
LG&E	C1SR	883479	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883480	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883481	07/2013	07/22/2013	100.070	99.890	100.0	1

LG&E	C1SR	883482	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883483	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883484	07/2013	07/22/2013	100.060	99.910	99.9	1
LG&E	C1SR	883485	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883486	07/2013	07/22/2013	100.050	99.940	100.0	1
LG&E	C1SR	883487	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883488	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883489	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883490	07/2013	07/22/2013	100.090	100.000	100.0	1
LG&E	C1SR	883491	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883492	07/2013	07/22/2013	100.100	99.970	100.0	1
LG&E	C1SR	883493	07/2013	07/22/2013	100.090	99.970	99.9	1
LG&E	C1SR	883494	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883495	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883496	07/2013	07/22/2013	100.060	99.940	100.1	1
LG&E	C1SR	883497	07/2013	07/22/2013	100.060	99.850	100.0	1
LG&E	C1SR	883498	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883499	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883500	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883501	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	883502	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883503	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883504	07/2013	07/22/2013	100.090	99.900	100.0	1
LG&E	C1SR	883505	07/2013	07/22/2013	100.100	99.930	100.0	1
LG&E	C1SR	883506	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883507	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883508	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883509	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883510	07/2013	07/22/2013	100.060	99.970	100.1	1
LG&E	C1SR	883511	07/2013	07/22/2013	100.070	99.910	100.0	1

LG&E	C1SR	883512	07/2013	07/22/2013	100.090	99.950	100.1	1
LG&E	C1SR	883513	07/2013	07/22/2013	100.090	100.080	100.1	1
LG&E	C1SR	883514	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883515	07/2013	07/22/2013	100.050	99.940	100.0	1
LG&E	C1SR	883516	07/2013	07/22/2013	100.060	99.890	99.8	1
LG&E	C1SR	883517	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883518	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883519	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883520	07/2013	07/22/2013	100.080	99.990	99.9	1
LG&E	C1SR	883521	07/2013	07/22/2013	100.050	99.900	100.0	1
LG&E	C1SR	883522	07/2013	07/22/2013	100.060	99.830	99.9	1
LG&E	C1SR	883523	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883524	07/2013	07/22/2013	100.070	99.980	99.9	1
LG&E	C1SR	883525	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883526	07/2013	07/22/2013	100.080	99.910	100.1	1
LG&E	C1SR	883527	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883528	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883529	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883530	07/2013	07/22/2013	100.060	99.980	100.1	1
LG&E	C1SR	883531	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883532	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883533	07/2013	07/22/2013	100.090	99.900	100.1	1
LG&E	C1SR	883534	07/2013	07/22/2013	100.080	99.910	100.0	1
LG&E	C1SR	883535	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883536	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883537	07/2013	07/22/2013	100.050	99.830	100.0	1
LG&E	C1SR	883538	07/2013	07/22/2013	100.080	99.910	99.9	1
LG&E	C1SR	883539	07/2013	07/22/2013	100.080	99.920	99.9	1
LG&E	C1SR	883540	07/2013	07/22/2013	100.060	99.920	100.1	1
LG&E	C1SR	883541	07/2013	07/22/2013	100.090	99.940	100.1	1

LG&E	C1SR	883542	07/2013	07/22/2013	100.060	99.910	99.9	1
LG&E	C1SR	883543	07/2013	07/22/2013	100.080	99.950	99.9	1
LG&E	C1SR	883544	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883545	07/2013	07/22/2013	100.090	100.010	100.0	1
LG&E	C1SR	883546	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	883547	07/2013	07/22/2013	100.100	99.940	100.0	1
LG&E	C1SR	883548	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883549	07/2013	07/22/2013	100.080	99.850	99.8	1
LG&E	C1SR	883550	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883551	07/2013	07/22/2013	100.060	99.860	100.0	1
LG&E	C1SR	883552	07/2013	07/22/2013	100.050	99.900	100.0	1
LG&E	C1SR	883553	07/2013	07/22/2013	100.080	99.910	99.9	1
LG&E	C1SR	883554	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883555	07/2013	07/22/2013	100.070	100.000	100.0	1
LG&E	C1SR	883556	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883557	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883558	07/2013	07/22/2013	100.050	99.990	100.0	1
LG&E	C1SR	883559	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883560	07/2013	07/22/2013	100.080	99.990	100.1	1
LG&E	C1SR	883561	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883562	07/2013	07/22/2013	100.060	99.960	100.0	1
LG&E	C1SR	883563	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883564	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883565	07/2013	07/22/2013	100.060	99.930	100.1	1
LG&E	C1SR	883566	07/2013	07/22/2013	100.100	99.960	100.0	1
LG&E	C1SR	883567	07/2013	07/22/2013	100.100	100.000	100.0	1
LG&E	C1SR	883568	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883569	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883570	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883571	07/2013	07/22/2013	100.090	99.940	100.1	1

LG&E	C1SR	883572	07/2013	07/22/2013	100.080	99.880	99.9	1
LG&E	C1SR	883573	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	883574	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883575	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883576	07/2013	07/22/2013	100.060	99.930	99.9	1
LG&E	C1SR	883577	07/2013	07/22/2013	100.080	99.990	100.0	1
LG&E	C1SR	883578	07/2013	07/22/2013	100.100	100.040	100.1	1
LG&E	C1SR	883579	07/2013	07/22/2013	100.100	99.970	100.0	1
LG&E	C1SR	883580	07/2013	07/22/2013	100.050	99.900	100.1	1
LG&E	C1SR	883581	07/2013	07/22/2013	100.060	99.890	99.9	1
LG&E	C1SR	883582	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883583	07/2013	07/22/2013	100.070	99.880	99.9	1
LG&E	C1SR	883584	07/2013	07/22/2013	100.100	99.920	100.0	1
LG&E	C1SR	883585	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883586	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883587	07/2013	07/22/2013	100.070	99.910	100.0	1
LG&E	C1SR	883588	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883589	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883590	07/2013	07/22/2013	100.070	99.870	99.9	1
LG&E	C1SR	883591	07/2013	07/22/2013	100.060	99.900	99.9	1
LG&E	C1SR	883592	07/2013	07/22/2013	100.050	99.880	99.9	1
LG&E	C1SR	883593	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883594	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883595	07/2013	07/22/2013	100.050	99.860	100.0	1
LG&E	C1SR	883596	07/2013	07/22/2013	100.060	99.870	100.0	1
LG&E	C1SR	883597	07/2013	07/22/2013	100.080	99.940	99.9	1
LG&E	C1SR	883598	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883599	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883600	07/2013	07/22/2013	100.080	99.910	100.0	1
LG&E	C1SR	883601	07/2013	07/22/2013	100.070	99.960	99.9	1

LG&E	C1SR	883602	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883603	07/2013	07/22/2013	100.060	99.880	99.9	1
LG&E	C1SR	883604	07/2013	07/22/2013	100.070	100.010	100.0	1
LG&E	C1SR	883605	07/2013	07/22/2013	100.080	99.910	100.0	1
LG&E	C1SR	883606	07/2013	07/22/2013	100.080	99.820	100.0	1
LG&E	C1SR	883607	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883608	07/2013	07/22/2013	100.080	99.970	99.9	1
LG&E	C1SR	883609	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883610	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883611	07/2013	07/22/2013	100.100	99.990	100.0	1
LG&E	C1SR	883612	07/2013	07/22/2013	100.070	99.950	99.9	1
LG&E	C1SR	883613	07/2013	07/22/2013	100.060	99.970	100.0	1
LG&E	C1SR	883614	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883615	07/2013	07/22/2013	100.060	99.840	100.0	1
LG&E	C1SR	883616	07/2013	07/22/2013	100.070	99.880	99.9	1
LG&E	C1SR	883617	07/2013	07/22/2013	100.080	99.950	100.0	1
LG&E	C1SR	883618	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883619	07/2013	07/22/2013	100.100	99.940	99.9	1
LG&E	C1SR	883620	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883621	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	883622	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883623	07/2013	07/22/2013	100.090	99.840	99.9	1
LG&E	C1SR	883624	07/2013	07/22/2013	100.060	99.860	100.0	1
LG&E	C1SR	883625	07/2013	07/22/2013	100.090	99.970	100.1	1
LG&E	C1SR	883626	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883627	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883628	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883629	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883630	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883631	07/2013	07/22/2013	100.080	99.940	100.1	1

LG&E	C1SR	883632	07/2013	07/22/2013	100.100	99.930	100.0	1
LG&E	C1SR	883633	07/2013	07/22/2013	100.100	99.920	100.1	1
LG&E	C1SR	883634	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883635	07/2013	07/22/2013	100.070	99.950	100.1	1
LG&E	C1SR	883636	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883637	07/2013	07/22/2013	100.090	99.970	100.1	1
LG&E	C1SR	883638	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883639	07/2013	07/22/2013	100.070	100.000	100.1	1
LG&E	C1SR	883640	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883641	07/2013	07/22/2013	100.070	99.970	100.0	1
LG&E	C1SR	883642	07/2013	07/22/2013	100.060	99.980	99.9	1
LG&E	C1SR	883643	07/2013	07/22/2013	100.100	100.000	100.0	1
LG&E	C1SR	883644	07/2013	07/22/2013	100.070	99.870	100.0	1
LG&E	C1SR	883645	07/2013	07/22/2013	100.050	99.950	100.0	1
LG&E	C1SR	883646	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883647	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883648	07/2013	07/22/2013	100.100	99.990	100.1	1
LG&E	C1SR	883649	07/2013	07/22/2013	100.050	99.910	99.9	1
LG&E	C1SR	883650	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883651	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883652	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883653	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883654	07/2013	07/22/2013	100.070	99.960	100.1	1
LG&E	C1SR	883655	07/2013	07/22/2013	100.060	99.930	99.9	1
LG&E	C1SR	883656	07/2013	07/22/2013	100.080	100.000	100.1	1
LG&E	C1SR	883657	07/2013	07/22/2013	100.080	100.020	99.9	1
LG&E	C1SR	883658	07/2013	07/22/2013	100.080	99.910	100.1	1
LG&E	C1SR	883659	07/2013	07/22/2013	100.090	99.900	100.1	1
LG&E	C1SR	883660	07/2013	07/22/2013	100.090	99.930	99.9	1
LG&E	C1SR	883661	07/2013	07/22/2013	100.080	99.910	100.0	1

LG&E	C1SR	883662	07/2013	07/22/2013	100.070	99.940	100.1	1
LG&E	C1SR	883663	07/2013	07/22/2013	100.050	99.920	100.1	1
LG&E	C1SR	883664	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883665	07/2013	07/22/2013	100.060	99.870	100.0	1
LG&E	C1SR	883666	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883667	07/2013	07/22/2013	100.080	99.970	100.1	1
LG&E	C1SR	883668	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883669	07/2013	07/22/2013	100.090	99.830	100.0	1
LG&E	C1SR	883670	07/2013	07/22/2013	100.070	99.930	100.1	1
LG&E	C1SR	883671	07/2013	07/22/2013	100.060	99.970	100.0	1
LG&E	C1SR	883672	07/2013	07/22/2013	100.100	99.920	100.0	1
LG&E	C1SR	883673	07/2013	07/22/2013	100.070	100.040	100.0	1
LG&E	C1SR	883674	07/2013	07/22/2013	100.080	99.960	99.9	1
LG&E	C1SR	883675	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883676	07/2013	07/22/2013	100.100	99.930	100.1	1
LG&E	C1SR	883677	07/2013	07/22/2013	100.060	99.870	99.9	1
LG&E	C1SR	883678	07/2013	07/22/2013	100.060	99.900	99.9	1
LG&E	C1SR	883679	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883680	07/2013	07/22/2013	100.100	99.900	100.0	1
LG&E	C1SR	883681	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883682	07/2013	07/22/2013	100.050	99.950	100.0	1
LG&E	C1SR	883683	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883684	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883685	07/2013	07/22/2013	100.080	99.990	100.1	1
LG&E	C1SR	883686	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883687	07/2013	07/22/2013	100.090	99.890	100.0	1
LG&E	C1SR	883688	07/2013	07/22/2013	100.100	99.940	100.0	1
LG&E	C1SR	883689	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	883690	07/2013	07/22/2013	100.070	99.850	100.0	1
LG&E	C1SR	883691	07/2013	07/22/2013	100.090	99.910	100.0	1

LG&E	C1SR	883692	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883693	07/2013	07/22/2013	100.050	99.930	100.1	1
LG&E	C1SR	883694	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883695	07/2013	07/22/2013	100.100	99.930	100.1	1
LG&E	C1SR	883696	07/2013	07/22/2013	100.090	99.960	100.0	1
LG&E	C1SR	883697	07/2013	07/22/2013	100.070	99.980	100.0	1
LG&E	C1SR	883698	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883699	07/2013	07/22/2013	100.070	99.890	100.1	1
LG&E	C1SR	883700	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883701	07/2013	07/22/2013	100.050	99.970	100.0	1
LG&E	C1SR	883702	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883703	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883704	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883705	07/2013	07/22/2013	100.100	99.980	100.0	1
LG&E	C1SR	883706	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883707	07/2013	07/22/2013	100.060	99.940	100.0	1
LG&E	C1SR	883708	07/2013	07/22/2013	100.070	99.980	100.0	1
LG&E	C1SR	883709	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883710	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	883711	07/2013	07/22/2013	100.090	100.010	100.1	1
LG&E	C1SR	883712	07/2013	07/22/2013	100.080	100.000	100.1	1
LG&E	C1SR	883713	07/2013	07/22/2013	100.080	99.870	100.0	1
LG&E	C1SR	883714	07/2013	07/22/2013	100.080	99.850	100.0	1
LG&E	C1SR	883715	07/2013	07/22/2013	100.070	99.970	100.1	1
LG&E	C1SR	883716	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883717	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883718	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883719	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883720	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883721	07/2013	07/22/2013	100.070	99.950	100.0	1

LG&E	C1SR	883722	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883723	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883724	07/2013	07/22/2013	100.080	100.000	100.0	1
LG&E	C1SR	883725	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883726	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883727	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883728	07/2013	07/22/2013	100.100	100.070	100.1	1
LG&E	C1SR	883729	07/2013	07/22/2013	100.070	99.900	99.9	1
LG&E	C1SR	883730	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883731	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883732	07/2013	07/22/2013	100.090	99.930	100.2	1
LG&E	C1SR	883733	07/2013	07/22/2013	100.090	99.910	100.1	1
LG&E	C1SR	883734	07/2013	07/22/2013	100.090	99.990	100.0	1
LG&E	C1SR	883735	07/2013	07/22/2013	100.080	99.950	99.9	1
LG&E	C1SR	883736	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883737	07/2013	07/22/2013	100.050	99.920	100.0	1
LG&E	C1SR	883738	07/2013	07/22/2013	100.100	99.950	100.0	1
LG&E	C1SR	883739	07/2013	07/22/2013	100.100	99.950	100.1	1
LG&E	C1SR	883740	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883741	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883742	07/2013	07/22/2013	100.080	99.870	100.0	1
LG&E	C1SR	883743	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883744	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883745	07/2013	07/22/2013	100.080	100.000	100.0	1
LG&E	C1SR	883746	07/2013	07/22/2013	100.060	99.870	100.1	1
LG&E	C1SR	883747	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883748	07/2013	07/22/2013	100.060	99.990	100.0	1
LG&E	C1SR	883749	07/2013	07/22/2013	100.070	99.970	100.0	1
LG&E	C1SR	883750	07/2013	07/22/2013	100.100	100.000	100.1	1
LG&E	C1SR	883751	07/2013	07/22/2013	100.080	99.950	100.1	1

LG&E	C1SR	883752	07/2013	07/22/2013	100.070	99.960	100.0	1
LG&E	C1SR	883753	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883754	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883755	07/2013	07/22/2013	100.060	99.940	100.1	1
LG&E	C1SR	883756	07/2013	07/22/2013	100.090	100.000	100.0	1
LG&E	C1SR	883757	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883758	07/2013	07/22/2013	100.070	99.890	100.1	1
LG&E	C1SR	883759	07/2013	07/22/2013	100.070	99.980	100.2	1
LG&E	C1SR	883760	07/2013	07/22/2013	100.070	100.010	99.9	1
LG&E	C1SR	883761	07/2013	07/22/2013	100.060	99.910	100.1	1
LG&E	C1SR	883762	07/2013	07/22/2013	100.080	99.970	100.0	1
LG&E	C1SR	883763	07/2013	07/22/2013	100.090	99.890	100.0	1
LG&E	C1SR	883764	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883765	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883766	07/2013	07/22/2013	100.080	99.940	100.1	1
LG&E	C1SR	883767	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883768	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883769	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883770	07/2013	07/22/2013	100.070	99.900	100.0	1
LG&E	C1SR	883771	07/2013	07/22/2013	100.080	99.960	100.1	1
LG&E	C1SR	883772	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883773	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883774	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883775	07/2013	07/22/2013	100.080	99.980	100.0	1
LG&E	C1SR	883776	07/2013	07/22/2013	100.050	99.920	100.1	1
LG&E	C1SR	883777	07/2013	07/22/2013	100.090	99.980	100.0	1
LG&E	C1SR	883778	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883779	07/2013	07/22/2013	100.080	100.010	100.1	1
LG&E	C1SR	883780	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883781	07/2013	07/22/2013	100.050	99.930	100.0	1

LG&E	C1SR	883782	07/2013	07/22/2013	100.070	99.890	100.0	1
LG&E	C1SR	883783	07/2013	07/22/2013	100.090	99.970	100.0	1
LG&E	C1SR	883784	07/2013	07/22/2013	100.060	99.910	100.1	1
LG&E	C1SR	883785	07/2013	07/22/2013	100.050	99.910	99.9	1
LG&E	C1SR	883786	07/2013	07/22/2013	100.060	99.950	99.9	1
LG&E	C1SR	883787	07/2013	07/22/2013	100.070	99.930	100.1	1
LG&E	C1SR	883788	07/2013	07/22/2013	100.060	99.960	100.0	1
LG&E	C1SR	883789	07/2013	07/22/2013	100.090	99.900	100.1	1
LG&E	C1SR	883790	07/2013	07/22/2013	100.070	99.940	99.9	1
LG&E	C1SR	883791	07/2013	07/22/2013	100.060	99.920	100.1	1
LG&E	C1SR	883792	07/2013	07/22/2013	100.080	99.890	100.1	1
LG&E	C1SR	883793	07/2013	07/22/2013	100.090	99.930	100.1	1
LG&E	C1SR	883794	07/2013	07/22/2013	100.100	99.920	100.1	1
LG&E	C1SR	883795	07/2013	07/22/2013	100.090	99.980	100.0	1
LG&E	C1SR	883796	07/2013	07/22/2013	100.080	99.930	99.9	1
LG&E	C1SR	883797	07/2013	07/22/2013	100.080	99.930	100.1	1
LG&E	C1SR	883798	07/2013	07/22/2013	100.070	99.940	99.9	1
LG&E	C1SR	883799	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883800	07/2013	07/22/2013	100.060	99.900	100.1	1
LG&E	C1SR	883801	07/2013	07/22/2013	100.080	99.920	99.9	1
LG&E	C1SR	883802	07/2013	07/22/2013	100.050	99.930	100.1	1
LG&E	C1SR	883803	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883804	07/2013	07/22/2013	100.080	99.960	99.9	1
LG&E	C1SR	883805	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883806	07/2013	07/22/2013	100.090	100.020	100.0	1
LG&E	C1SR	883807	07/2013	07/22/2013	100.090	99.940	100.1	1
LG&E	C1SR	883808	07/2013	07/22/2013	100.070	99.940	100.0	1
LG&E	C1SR	883809	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883810	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883811	07/2013	07/22/2013	100.060	99.950	99.9	1

LG&E	C1SR	883812	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883813	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883814	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883815	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883816	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883817	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883818	07/2013	07/22/2013	100.090	99.910	100.0	1
LG&E	C1SR	883819	07/2013	07/22/2013	100.060	99.970	100.1	1
LG&E	C1SR	883820	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883821	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883822	07/2013	07/22/2013	100.090	99.930	100.0	1
LG&E	C1SR	883823	07/2013	07/22/2013	100.060	99.970	100.0	1
LG&E	C1SR	883824	07/2013	07/22/2013	100.070	99.970	100.0	1
LG&E	C1SR	883825	07/2013	07/22/2013	100.100	99.870	100.0	1
LG&E	C1SR	883826	07/2013	07/22/2013	100.070	99.870	100.1	1
LG&E	C1SR	883827	07/2013	07/22/2013	100.060	99.960	100.0	1
LG&E	C1SR	883828	07/2013	07/22/2013	100.100	99.960	100.1	1
LG&E	C1SR	883829	07/2013	07/22/2013	100.070	99.980	100.1	1
LG&E	C1SR	883830	07/2013	07/22/2013	100.060	99.880	100.0	1
LG&E	C1SR	883831	07/2013	07/22/2013	100.050	99.920	99.9	1
LG&E	C1SR	883832	07/2013	07/22/2013	100.070	99.930	100.1	1
LG&E	C1SR	883833	07/2013	07/22/2013	100.100	99.970	100.1	1
LG&E	C1SR	883834	07/2013	07/22/2013	100.090	99.920	100.0	1
LG&E	C1SR	883835	07/2013	07/22/2013	100.060	99.950	100.1	1
LG&E	C1SR	883836	07/2013	07/22/2013	100.050	99.960	100.1	1
LG&E	C1SR	883837	07/2013	07/22/2013	100.060	99.890	100.0	1
LG&E	C1SR	883838	07/2013	07/22/2013	100.100	99.950	100.0	1
LG&E	C1SR	883839	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883840	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883841	07/2013	07/22/2013	100.060	99.960	100.0	1

LG&E	C1SR	883842	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883843	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	883844	07/2013	07/22/2013	100.080	99.880	100.1	1
LG&E	C1SR	883845	07/2013	07/22/2013	100.090	99.880	100.1	1
LG&E	C1SR	883846	07/2013	07/22/2013	100.070	99.930	100.0	1
LG&E	C1SR	883847	07/2013	07/22/2013	100.080	100.030	100.0	1
LG&E	C1SR	883848	07/2013	07/22/2013	100.070	100.010	100.1	1
LG&E	C1SR	883849	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883850	07/2013	07/22/2013	100.060	99.930	100.0	1
LG&E	C1SR	883851	07/2013	07/22/2013	100.060	99.950	100.1	1
LG&E	C1SR	883852	07/2013	07/22/2013	100.080	99.910	100.1	1
LG&E	C1SR	883853	07/2013	07/22/2013	100.070	99.910	100.1	1
LG&E	C1SR	883854	07/2013	07/22/2013	100.060	99.990	100.0	1
LG&E	C1SR	883855	07/2013	07/22/2013	100.060	99.960	99.9	1
LG&E	C1SR	883856	07/2013	07/22/2013	100.060	99.980	100.0	1
LG&E	C1SR	883857	07/2013	07/22/2013	100.070	99.880	100.0	1
LG&E	C1SR	883858	07/2013	07/22/2013	100.070	99.970	100.0	1
LG&E	C1SR	883859	07/2013	07/22/2013	100.050	99.950	100.1	1
LG&E	C1SR	883860	07/2013	07/22/2013	100.060	99.900	100.0	1
LG&E	C1SR	883861	07/2013	07/22/2013	100.080	99.880	100.0	1
LG&E	C1SR	883862	07/2013	07/22/2013	100.060	99.910	100.1	1
LG&E	C1SR	883863	07/2013	07/22/2013	100.090	99.950	100.0	1
LG&E	C1SR	883864	07/2013	07/22/2013	100.070	100.030	100.0	1
LG&E	C1SR	883865	07/2013	07/22/2013	100.090	99.960	100.1	1
LG&E	C1SR	883866	07/2013	07/22/2013	100.070	99.950	100.0	1
LG&E	C1SR	883867	07/2013	07/22/2013	100.090	99.950	100.1	1
LG&E	C1SR	883868	07/2013	07/22/2013	100.050	99.990	100.0	1
LG&E	C1SR	883869	07/2013	07/22/2013	100.060	99.850	100.0	1
LG&E	C1SR	883870	07/2013	07/22/2013	100.080	99.920	100.0	1
LG&E	C1SR	883871	07/2013	07/22/2013	100.070	99.880	99.9	1

LG&E	C1SR	883872	07/2013	07/22/2013	100.100	99.970	100.0	1
LG&E	C1SR	883873	07/2013	07/22/2013	100.080	99.950	100.1	1
LG&E	C1SR	883874	07/2013	07/22/2013	100.070	99.920	100.0	1
LG&E	C1SR	883875	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883876	07/2013	07/22/2013	100.060	99.920	100.1	1
LG&E	C1SR	883877	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883878	07/2013	07/22/2013	100.060	99.860	99.9	1
LG&E	C1SR	883879	07/2013	07/22/2013	100.080	99.990	99.9	1
LG&E	C1SR	883880	07/2013	07/22/2013	100.080	99.890	100.0	1
LG&E	C1SR	883881	07/2013	07/22/2013	100.080	99.900	100.0	1
LG&E	C1SR	883882	07/2013	07/22/2013	100.060	99.870	100.0	1
LG&E	C1SR	883883	07/2013	07/22/2013	100.070	99.860	100.0	1
LG&E	C1SR	883884	07/2013	07/22/2013	100.090	99.980	100.1	1
LG&E	C1SR	883885	07/2013	07/22/2013	100.090	100.000	100.1	1
LG&E	C1SR	883886	07/2013	07/22/2013	100.060	99.990	100.0	1
LG&E	C1SR	883887	07/2013	07/22/2013	100.060	99.920	100.0	1
LG&E	C1SR	883888	07/2013	07/22/2013	100.060	99.880	99.9	1
LG&E	C1SR	883889	07/2013	07/22/2013	100.080	99.920	100.1	1
LG&E	C1SR	883890	07/2013	07/22/2013	100.080	99.950	100.2	1
LG&E	C1SR	883891	07/2013	07/22/2013	100.080	99.930	100.0	1
LG&E	C1SR	883892	07/2013	07/22/2013	100.060	99.890	100.1	1
LG&E	C1SR	883893	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883894	07/2013	07/22/2013	100.100	99.990	100.0	1
LG&E	C1SR	883895	07/2013	07/22/2013	100.090	100.030	100.0	1
LG&E	C1SR	883896	07/2013	07/22/2013	100.080	100.010	100.1	1
LG&E	C1SR	883897	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883898	07/2013	07/22/2013	100.060	99.960	100.1	1
LG&E	C1SR	883899	07/2013	07/22/2013	100.080	99.960	100.0	1
LG&E	C1SR	883900	07/2013	07/22/2013	100.100	100.030	100.0	1
LG&E	C1SR	883901	07/2013	07/22/2013	100.060	99.880	100.0	1

LG&E	C1SR	883902	07/2013	07/22/2013	100.070	99.970	99.9	1
LG&E	C1SR	883903	07/2013	07/22/2013	100.050	99.990	100.1	1
LG&E	C1SR	883904	07/2013	07/22/2013	100.070	99.940	100.2	1
LG&E	C1SR	883905	07/2013	07/22/2013	100.050	99.960	100.1	1
LG&E	C1SR	883906	07/2013	07/22/2013	100.100	99.930	100.1	1
LG&E	C1SR	883907	07/2013	07/22/2013	100.060	99.920	99.9	1
LG&E	C1SR	883908	07/2013	07/22/2013	100.060	99.920	99.9	1
LG&E	C1SR	883909	07/2013	07/22/2013	100.080	99.920	100.2	1
LG&E	C1SR	883910	07/2013	07/22/2013	100.100	99.990	100.1	1
LG&E	C1SR	883911	07/2013	07/22/2013	100.080	99.940	100.0	1
LG&E	C1SR	883912	07/2013	07/22/2013	100.060	99.910	100.0	1
LG&E	C1SR	883913	07/2013	07/22/2013	100.080	100.020	99.9	1
LG&E	C1SR	883914	07/2013	07/22/2013	100.050	99.950	99.9	1
LG&E	C1SR	883915	07/2013	07/22/2013	100.060	99.850	100.0	1
LG&E	C1SR	883916	07/2013	07/22/2013	100.080	99.920	99.9	1
LG&E	C1SR	883917	07/2013	07/22/2013	100.090	99.940	100.0	1
LG&E	C1SR	883918	07/2013	07/22/2013	100.070	99.920	100.1	1
LG&E	C1SR	883919	07/2013	07/22/2013	100.060	99.950	100.0	1
LG&E	C1SR	883920	07/2013	07/22/2013	100.070	99.920	99.9	1
LG&E	C1SR	883921	07/2013	07/22/2013	100.070	99.890	99.9	1
LG&E	C1SR	883922	07/2013	07/22/2013	100.070	99.990	100.1	1
LG&E	C1SR	883923	07/2013	07/22/2013	100.060	99.860	99.9	1
LG&E	C1SR	883924	07/2013	07/11/2013	100.060	99.870	100.0	1
LG&E	C1SR	883925	07/2013	07/11/2013	100.050	99.830	100.0	1
LG&E	C1SR	883926	07/2013	07/11/2013	100.050	99.810	100.0	1
LG&E	C1SR	883927	07/2013	07/11/2013	100.040	99.830	99.9	1
LG&E	C1SR	883928	07/2013	07/11/2013	100.040	99.880	100.0	1
LG&E	C1SR	883929	07/2013	07/11/2013	100.050	99.890	100.0	1
LG&E	C1SR	883930	07/2013	07/11/2013	100.050	99.880	100.0	1
LG&E	C1SR	883931	07/2013	07/11/2013	100.070	99.880	100.0	1

LG&E	C1SR	883932	07/2013	07/11/2013	100.040	99.850	100.0	1
LG&E	C1SR	883933	07/2013	07/11/2013	100.050	99.840	100.0	1
LG&E	C1SR	883934	07/2013	07/11/2013	100.040	99.820	100.0	1
LG&E	C1SR	883935	07/2013	07/11/2013	100.050	99.850	100.0	1
LG&E	C1SR	883936	07/2013	07/11/2013	100.060	99.860	100.0	1
LG&E	C1SR	883937	07/2013	07/11/2013	100.040	99.860	99.9	1
LG&E	C1SR	883938	07/2013	07/11/2013	100.050	99.830	99.9	1
LG&E	C1SR	883939	07/2013	07/11/2013	100.040	99.820	99.9	1
LG&E	C1SR	883940	07/2013	07/11/2013	100.050	99.830	99.9	1
LG&E	C1SR	883941	07/2013	07/11/2013	100.050	99.850	100.0	1
LG&E	C1SR	883942	07/2013	07/11/2013	100.040	99.860	100.0	1
LG&E	C1SR	883943	07/2013	07/11/2013	100.050	99.920	100.0	1
LG&E	C1SR	883944	07/2013	07/11/2013	100.030	99.820	99.9	1
LG&E	C1SR	883945	07/2013	07/11/2013	100.050	99.870	100.0	1
LG&E	C1SR	883946	07/2013	07/11/2013	100.030	99.850	99.9	1
LG&E	C1SR	883947	07/2013	07/11/2013	100.050	99.840	100.0	1
LG&E	C1SR	883948	07/2013	07/11/2013	100.060	99.880	100.0	1
LG&E	C1SR	883949	07/2013	07/11/2013	100.040	99.850	100.0	1
LG&E	C1SR	883950	07/2013	07/11/2013	100.040	99.860	99.9	1
LG&E	C1SR	883951	07/2013	07/11/2013	100.050	99.900	100.0	1
LG&E	C1SR	883952	07/2013	07/11/2013	100.060	99.840	100.0	1
LG&E	C1SR	883953	07/2013	07/11/2013	100.030	99.850	100.0	1
LG&E	C1SR	883954	07/2013	07/11/2013	100.040	99.810	99.9	1
LG&E	C1SR	883955	07/2013	07/11/2013	100.050	99.810	99.9	1
LG&E	C1SR	883956	07/2013	07/11/2013	100.030	99.880	99.9	1
LG&E	C1SR	883957	07/2013	07/11/2013	100.060	99.860	100.0	1
LG&E	C1SR	883958	07/2013	07/11/2013	100.040	99.830	100.0	1
LG&E	C1SR	883959	07/2013	07/11/2013	100.040	99.840	99.9	1
LG&E	C1SR	883960	07/2013	07/11/2013	100.040	99.820	99.9	1
LG&E	C1SR	883961	07/2013	07/11/2013	100.070	99.920	100.0	1

LG&E	C1SR	883962	07/2013	07/11/2013	100.040	99.860	100.0	1
LG&E	C1SR	883963	07/2013	07/11/2013	100.040	99.860	100.0	1
LG&E	C1SR	883964	07/2013	07/11/2013	100.050	99.870	100.0	1
LG&E	C1SR	883965	07/2013	07/11/2013	100.050	99.850	100.0	1
LG&E	C1SR	883966	07/2013	07/11/2013	100.040	99.850	99.9	1
LG&E	C1SR	883967	07/2013	07/11/2013	100.060	99.890	100.0	1
LG&E	C1SR	883968	07/2013	07/11/2013	100.050	99.860	99.9	1
LG&E	C1SR	883969	07/2013	07/11/2013	100.040	99.840	100.0	1
LG&E	C1SR	883970	07/2013	07/11/2013	100.050	99.830	100.0	1
LG&E	C1SR	883971	07/2013	07/11/2013	100.060	99.880	99.9	1
Overall Result					X	X	X	4,888



ATTACHMENT
B

Sampling Test Results

LG&E
2013 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	383,329	Divided into 50 Lots
Sample Quantity	3,288	
Meters Tested	3,288	
Meters Not Tested	0	
Failed Lots	0	
Failed Lot Meters	0	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1177 Lot Descr: LG&E AB1 - 1
 In Service Population: 174 Sample Quantity: 15 Meters Tested: 15 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
725046	100.00	725068	99.50	725113	99.30	725145	100.30	725153	99.70
725176	99.80	725227	100.20	725232	100.50	725237	99.90	725334	100.10
725390	100.20	725414	99.90	725514	99.50	725535	100.00	725545	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	15
2 Sum of Measurements: (Sum X)	1498.60
3 Sum of Squared Measurements	149721.66
4 Correction Factor (CF): Sum of Measurements Squared / N	149720.13
5 Corrected Sum of Squares (SS)	1.53
6 Variance (V) : SS/(N-1)	0.1092
7 Estimate of Lot Standard Deviation(S): SQRT. of V	0.3305
8 Sample Mean (XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.33
12 Quality Index Lower (QL): (XBAR-L) / S	5.77
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	6.55
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E Model Number: ALF (Trilliant) Division: 01 Sample Lot: 1178 Lot Descr: LGSE ALF - 1
 In Service Population: 839 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit -- Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 2

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
833404	99.92	833544	99.98	833632	100.05	833834	99.98	833893	99.91
833900	100.10	833903	100.01	833932	100.00	834079	100.00	834120	99.97
834128	99.94	834132	100.04	834138	100.00	834190	100.04	834227	99.94
834393	99.96	834432	99.93	834478	100.01	834479	100.06	834529	100.00
834576	99.97	834603	99.95	834608	100.09	834675	100.06	834731	99.96
834743	100.01	834776	100.26	834981	100.07	834986	100.00	835068	100.05
835136	100.08	855823	100.10	863346	99.90	863402	99.90	863407	99.80

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3500.04
3 Sum of Squared Measurements	350008.22
4 Correction Factor (CF): Sum of Measurements Squared / N	350008.00
5 Corrected Sum of Squares (SS)	0.22
6 Variance (V) : SS/(N-1)	0.0064
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0800
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	24.99
12 Quality Index Lower (QL): (XBAR-L) / S	25.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E Model Number: CISR (ERT) Division: 01 Sample Lot: 1179 Lot Descr: LG&E CIS1 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
754259	100.01	754349	100.03	754372	100.02	754449	100.09	754972	100.08
755024	100.11	755128	100.00	755542	100.23	755567	100.13	755774	100.16
755848	100.17	756055	100.12	756111	100.00	756187	100.10	756398	99.90
766098	100.10	766473	100.04	766782	100.16	766842	100.06	767090	100.10
767250	100.12	767305	100.00	776596	100.06	777009	100.29	777140	100.21
777170	100.05	777248	100.22	777398	100.12	777522	100.26	777588	100.10
777590	100.11	777650	100.20	777716	100.28	777738	100.03	777757	100.12
777938	100.04	777947	100.08	778029	100.14	778301	100.14	778328	100.13
778542	100.32	779684	100.16	779691	100.15	779758	100.15	779854	100.09
793932	100.13	793979	100.13	794214	100.07	794246	100.02	794455	100.02
794676	100.01	794689	100.02	794995	100.14	795802	100.09	795851	100.05
795903	100.06	796011	100.10	796511	100.14	796762	100.06	796783	100.13
797262	100.09	797336	100.01	797388	100.04	797907	100.14	797969	100.22
798026	100.08	798181	100.26	798231	100.10	798253	100.06	798361	100.10
798498	100.02	798528	100.07	798593	100.07	798652	100.14	798693	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7507.85
3 Sum of Squared Measurements	751571.26
4 Correction Factor (CF): Sum of Measurements Squared / N	751570.82
5 Corrected Sum of Squares (SS)	0.44
6 Variance (V) : SS/(N-1)	0.0059
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0767
8 Sample Mean(XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	24.72
12 Quality Index Lower (QL): (XBAR-L) / S	27.45
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 1180 Lot Descr: LG&E C1S1 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
798886	100.19	798899	100.12	799060	100.20	799560	100.10	799594	100.00
799705	100.11	799729	99.84	809035	100.10	809151	99.95	809253	100.02
809309	100.10	843297	100.11	843453	100.08	843768	99.99	843877	99.96
843938	100.02	843970	100.09	844034	100.04	844288	99.96	844291	99.99
844433	99.96	844485	100.00	845066	100.03	845432	100.00	845485	100.06
845695	100.12	845737	99.85	845927	100.04	845965	100.00	846000	100.04
846020	100.05	846168	99.85	846195	99.80	846443	100.00	846610	100.10
846695	100.17	846806	100.07	846892	100.00	847551	100.22	847705	100.16
847831	100.17	848019	100.10	848085	100.00	848102	100.02	848413	100.13
848582	100.20	848659	100.18	848703	99.96	848707	99.75	848741	100.00
849144	100.00	849217	100.08	849360	100.00	849812	100.10	849844	100.00
849877	100.06	850056	100.17	850065	100.10	850110	100.18	850514	100.00
851251	100.13	851340	100.02	851399	100.19	851451	100.10	851499	100.04
851572	99.94	852231	100.10	852277	100.00	852467	99.95	852513	99.71
852728	100.03	852782	100.05	852861	100.06	852878	100.00	854401	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.21
3 Sum of Squared Measurements	750642.92
4 Correction Factor (CF): Sum of Measurements Squared / N	750642.14
5 Corrected Sum of Squares (SS)	0.78
6 Variance (V) : SS/(N-1)	0.0106
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1027
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper: (QU): (U-XBAR) / S	19.05
12 Quality Index Lower (QL): (XBAR-L) / S	19.89
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E (Model Number: C1S Division: 01 Sample Lot: 1181 Lot Descr: LG&E C1S1 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
854787	100.09	854980	100.00	855039	100.10	855112	100.01	855136	100.00
855542	99.90	855653	100.10	856636	100.10	857038	100.10	857299	100.07
857355	100.00	857463	100.00	857472	100.10	857514	99.81	857515	99.98
857577	100.04	857760	99.90	857765	100.12	858021	99.99	858101	99.90
858371	100.04	858443	100.00	858520	100.06	858523	99.89	858678	100.04
859732	99.98	859738	99.90	859996	100.10	860391	99.90	860539	100.10
860737	100.06	860821	100.06	860851	99.99	861361	100.14	861383	99.90
861389	100.02	861878	99.98	862150	100.07	862321	99.98	862543	100.08
862646	99.98	862723	99.97	862739	100.13	862778	100.06	863775	100.00
864092	99.94	864188	100.08	864297	100.11	865187	100.12	865229	99.80
865242	99.96	865374	99.90	865447	100.00	865602	99.87	865698	100.01
865809	100.12	865864	99.88	865865	100.05	865897	100.05	866059	99.99
866265	99.95	866480	99.88	866487	99.85	866603	99.90	866637	99.97
866679	100.05	866806	100.02	866825	99.88	867028	100.02	868793	100.08
868832	100.15	869326	100.14	869463	100.10	869489	99.99	870282	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.70
3 Sum of Squared Measurements	750140.55
4 Correction Factor (CF): Sum of Measurements Squared / N	750140.01
5 Corrected Sum of Squares (SS)	0.55
6 Variance (V) : SS/(N-1)	0.0074
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0858
8 Sample Mean (XBAR) : Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.19
12 Quality Index Lower (QL): (XBAR-L) / S	23.41
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 1182 Lot Descr: LG&E CIS1 - 4
 In Service Population: 2,088 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
870335	99.98	870338	100.10	870364	99.98	870391	100.05	870667	100.00
870669	100.00	870758	100.04	870784	100.10	870809	99.98	870840	100.07
870875	100.00	870882	100.12	870908	100.02	871141	100.00	871159	99.98
871236	100.03	871293	100.10	871370	100.00	871381	100.00	871416	99.83
871425	99.90	871429	100.00	871488	100.00	871548	100.10	871583	99.93
871632	99.98	871756	99.90	871797	100.13	871871	100.00	871872	100.10
871882	100.00	871929	100.04	876426	99.99	876451	100.00	876506	100.05
876508	100.01	876522	100.08	876548	99.97	876665	100.00	876679	100.00
876780	99.94	876802	100.00	876818	99.90	876848	99.98	876865	100.00
876878	100.03	877051	99.98	877053	100.15	877207	100.03	877314	99.89

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5000.46
3 Sum of Squared Measurements	500092.21
4 Correction Factor (CF): Sum of Measurements Squared / N	500092.00
5 Corrected Sum of Squares (SS)	0.21
6 Variance (V) : SS/(N-1)	0.0042
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0648
8 Sample Mean (XBAR) : Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU) : (U-XBAR) / S	30.74
12 Quality Index Lower (QL) : (XBAR-L) / S	31.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P) : PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2s240V30AC200E Model Number: C2SX Division: 01 Sample Lot: 1183 Lot Descr: LG&E C2SX - 1
 In Service Population: 9 Sample Quantity: 3 Meters Tested: 3 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
875884	100.06	875886	100.21	875887	99.98				

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	3
2 Sum of Measurements: (Sum X)	300.25
3 Sum of Squared Measurements	30050.05
4 Correction Factor (CF): Sum of Measurements Squared / N	30050.02
5 Corrected Sum of Squares (SS)	0.03
6 Variance (V) : SS/(N-1)	0.0136
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1168
8 Sample Mean(XBAR): Sum X/N	100.08
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	16.42
12 Quality Index Lower (QL): (XBAR-L) / s	17.84
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	7.59
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1184 Lot Descr: LG&E D4S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 8
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
366766	99.90	366804	99.90	366990	99.62	367256	100.20	367406	99.60
367585	100.00	371645	99.70	371806	99.90	372145	100.00	372301	100.10
376190	100.30	376464	100.20	377026	99.90	381563	99.80	381803	100.00
381928	99.60	382209	99.00	386335	99.30	386367	100.10	386634	99.70
386753	99.40	386780	100.40	387005	99.90	389075	99.90	391779	99.30
391857	99.70	392003	100.00	395784	99.70	396015	99.40	396109	100.20
396221	99.80	396436	99.50	400784	99.70	400923	99.90	401049	99.50
401099	100.00	401313	98.90	405432	100.10	405565	100.30	410301	100.30
410635	99.90	410654	100.30	414859	100.10	414966	100.10	415063	99.50
415115	100.10	415795	100.00	419571	100.30	419903	100.60	420209	100.10
420222	100.20	420395	100.30	423479	100.34	424802	99.90	424812	99.80
425009	99.70	425237	99.90	425410	99.50	425520	100.10	431553	99.80
431869	99.40	436901	100.10	436969	100.10	440461	100.10	440669	99.90
440817	99.80	446368	99.90	446666	99.90	446754	100.20	447806	99.80
448722	99.90	452660	100.20	456253	99.70	456539	99.80	456645	100.30

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.36
3 Sum of Squared Measurements	748480.40
4 Correction Factor (CF): Sum of Measurements Squared / N	748472.78
5 Corrected Sum of Squares (SS)	7.62
6 Variance (V) : SS/(N-1)	0.1030
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3209
8 Sample Mean(XBAR) : Sum X/N	99.90
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU) : (U-XBAR) / S	6.55
12 Quality Index Lower (QL) : (XBAR-L) / S	5.91
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1185 Lot Descr: LG&E D4S - 2
 In Service Population: 3,239 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
458185	99.60	458198	100.10	458335	100.50	458386	99.90	458543	100.50
458549	100.60	458566	100.10	461008	100.10	461323	100.00	461401	100.20
461434	100.20	464265	100.40	464461	100.20	464500	100.10	464530	99.80
464559	100.40	464648	100.00	464733	99.90	464928	100.20	465150	100.10
465230	100.20	465254	100.20	465447	100.20	465548	100.20	465563	100.20
468502	100.60	468513	100.10	468518	100.30	468580	100.10	468695	100.00
468705	100.00	468787	100.10	470681	100.10	470688	99.60	470851	100.20
470884	99.90	471012	98.70	471094	100.40	472559	99.90	472571	100.50
472638	100.60	472660	99.80	472726	100.30	472745	100.30	472806	100.20
472876	100.60	472948	100.30	475078	100.10	475082	100.10	475457	99.80
475492	100.40	475531	100.00	475541	100.20	475639	100.10	475708	99.60
475876	99.80	475904	99.60	475908	99.70	475926	100.20	478214	99.90
478304	99.80	478359	100.20	478417	99.60	478458	100.00	478461	99.20
478468	100.10	478567	99.40	481475	100.40	483274	100.00	483285	100.40
483287	99.70	483328	100.00	483431	99.90	483693	100.20	483730	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.90
3 Sum of Squared Measurements	750988.17
4 Correction Factor (CF): Sum of Measurements Squared / N	750980.32
5 Corrected Sum of Squares (SS)	7.85
6 Variance (V) : SS/(N-1)	0.1061
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3257
8 Sample Mean (XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.94
12 Quality Index Lower (QL): (XBAR-L) / S	6.34
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200E Model Number: I-210 (ERT) Division: 01 Sample Lot: 1186 Lot Descr: LG&E I210 - 2
 In Service Population: 1,130 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
832162	100.10	832180	99.96	832188	100.00	832230	100.10	832248	100.08
832271	100.00	832315	100.00	832357	100.05	832384	100.02	832420	100.05
832426	100.05	832471	100.10	832493	99.90	832582	99.90	832667	100.09
832673	100.02	832706	99.90	832714	99.96	832751	100.00	832761	99.99
832828	100.00	838192	99.96	838193	99.90	838268	100.00	838271	99.99
838275	100.03	838288	99.97	838296	100.00	838312	100.01	838327	99.96
838332	100.00	838335	99.90	838348	100.00	838350	99.94	838453	100.02

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3499.95
3 Sum of Squared Measurements	349990.12
4 Correction Factor (CF): Sum of Measurements Squared / N	349990.00
5 Corrected Sum of Squares (SS)	0.12
6 Variance (V) : SS/(N-1)	0.0034
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0582
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	34.38
12 Quality Index Lower (QL): (XBAR-L) / S	34.33
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V15AC100 Model Number: I-50S Division: 01 Sample Lot: 1187 Lot Descr: LG&E I50 - 1
 In Service Population: 1,111 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
185059	99.90	195345	100.00	197899	101.10	198282	99.80	198721	100.70
200009	100.60	204980	100.60	205504	99.70	208201	100.20	211176	100.30
211203	100.00	218534	100.10	219092	99.80	219451	100.30	219876	100.20
220054	99.90	221173	99.80	222390	100.90	223774	99.80	224310	100.00
224651	99.80	225089	99.90	226166	100.50	226323	100.10	230023	100.50
231822	100.20	232719	100.30	233477	100.70	233906	100.00	234874	100.10
235195	100.20	235839	100.00	237163	100.40	237164	100.10	237448	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3506.60
3 Sum of Squared Measurements	351325.18
4 Correction Factor (CF): Sum of Measurements Squared / N	351321.24
5 Corrected Sum of Squares (SS)	3.94
6 Variance (V) : SS/(N-1)	0.1157
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3402
8 Sample Mean(XBAR): Sum X/N	100.19
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.32
12 Quality Index Lower (QL): (XBAR-L) / S	6.43
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V15AC100 Model Number: I-55S Division: 01 Sample Lot: 1188 Lot Descr: LG&E I55 - 1
 In Service Population: 1,449 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
238338	99.80	238409	100.10	238444	101.00	238646	100.30	239523	100.20
240420	100.60	243650	100.50	244072	100.00	244108	100.60	245541	100.50
245958	100.10	246432	100.60	246658	100.70	247041	100.40	247207	100.10
247212	100.10	247218	100.40	247727	100.20	247887	100.10	248132	100.00
248237	100.40	248264	100.40	248303	100.00	248550	100.30	248762	100.60
249814	100.30	249849	100.60	251084	100.00	251708	100.60	252164	100.10
253259	100.20	253375	100.10	256714	99.80	257604	100.40	257750	100.00
257827	100.00	263048	100.14	263234	100.20	263254	100.00	263277	100.50
263424	100.10	263955	100.20	263982	100.70	264428	99.70	264542	99.90
264651	99.80	265016	100.00	265076	99.60	265574	100.10	265897	100.00

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5011.04
3 Sum of Squared Measurements	502214.65
4 Correction Factor (CF): Sum of Measurements Squared / N	502210.44
5 Corrected Sum of Squares (SS)	4.21
6 Variance (V) : SS/(N-1)	0.0860
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2932
8 Sample Mean(XBAR): Sum X/N	100.22
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.07
12 Quality Index Lower (QL): (XBAR-L) / S	7.57
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 1189 Lot Descr: LG&E I60 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 13

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
271316	100.30	271471	100.20	271720	100.00	275607	99.80	275976	99.50
278982	100.20	279558	99.60	281295	100.10	282052	99.60	282166	100.20
284738	100.20	284829	99.90	285097	100.10	285381	100.10	285903	100.30
286288	99.80	291300	100.20	291364	100.10	291470	100.20	291698	99.80
292443	100.30	292980	100.30	294325	99.40	294463	100.20	294618	99.93
294961	100.10	295237	99.80	295385	99.80	295704	99.80	295728	99.90
296018	100.20	297354	99.70	297437	100.10	297656	99.90	297662	100.00
298458	99.80	298865	99.90	299599	100.10	304241	99.90	304557	99.70
307029	100.30	307038	100.10	307469	99.10	307931	99.60	311219	100.20
311452	100.40	311728	100.60	312148	100.40	312171	100.30	312327	100.00
312356	100.20	312371	100.60	312715	99.60	312957	100.00	313117	99.60
313375	100.50	313464	100.10	313711	100.10	316984	100.40	317094	99.70
317763	100.50	317949	99.50	318000	100.20	318121	99.50	318338	99.70
319824	100.00	319931	100.10	322200	99.80	322367	100.00	324627	99.70
324927	99.60	327165	99.60	329603	99.90	331081	99.80	331957	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.63
3 Sum of Squared Measurements	749732.71
4 Correction Factor (CF): Sum of Measurements Squared / N	749726.03
5 Corrected Sum of Squares (SS)	6.69
6 Variance (V) : SS/(N-1)	0.0904
7 Estimate of Lot Standard Deviation (S): SQRT of V	0.3007
8 Sample Mean (XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.71
12 Quality Index Lower (QL): (XBAR-L) / S	6.59
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 1190 Lot Descr: LG&E I60 - 2
 In Service Population: 3,014 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 14
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
333756	100.30	333781	100.30	333996	100.00	334134	100.10	334274	100.00
334387	100.60	334401	100.00	334440	99.90	335666	99.90	335687	99.80
335770	100.00	335902	100.20	335926	100.40	335929	99.90	335986	99.90
336074	100.20	336354	100.20	336364	99.60	336419	99.90	338160	100.20
338224	100.60	338249	100.30	338399	100.00	338803	100.10	340176	100.20
340607	100.30	341020	100.10	342957	100.10	343200	100.30	343525	100.10
343594	100.10	345736	100.80	345787	100.00	350207	99.90	352048	100.10
352116	99.90	352293	100.00	352304	100.20	352344	100.10	352517	100.00
352580	99.90	352894	99.90	354362	100.20	354534	100.00	355202	100.10
357332	100.09	357811	99.90	359205	100.20	359667	100.00	359698	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5004.79
3 Sum of Squared Measurements	500960.70
4 Correction Factor (CF): Sum of Measurements Squared / N	500958.46
5 Corrected Sum of Squares (SS)	2.24
6 Variance (V) : SS/(N-1)	0.0457
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2138
8 Sample Mean (XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.91
12 Quality Index Lower (QL): (XBAR-L) / S	9.80
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1191 Lot Descr: LG&E I70 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
361255	100.20	361329	100.20	361447	100.30	361510	100.21	363439	99.74
364133	100.10	366161	100.32	366383	100.04	366567	99.76	366587	100.08
366676	99.40	368189	100.20	368280	100.10	368296	99.82	368512	99.68
368535	100.20	368697	100.28	368740	99.42	368826	100.10	370852	100.17
370894	100.20	371046	99.72	371436	100.20	371552	100.24	373135	100.40
373302	100.10	375321	100.30	375443	100.29	375663	100.61	375665	100.12
375885	100.40	377254	100.34	377327	100.31	377395	100.44	377417	100.06
377483	100.10	377866	100.21	378017	100.37	378030	100.21	378047	100.59
378064	100.31	380879	100.20	380917	100.34	380983	100.30	380989	100.36
381096	100.32	381162	100.50	381301	100.14	382333	100.49	382380	100.11
382595	100.20	382618	100.30	382624	100.89	382701	100.13	382806	100.39
382986	100.00	383092	100.04	384935	100.20	385299	100.38	385451	100.25
385550	100.30	387185	99.90	387455	100.20	387488	100.30	387506	100.08
387713	100.20	387740	100.30	390347	100.20	390556	99.84	390705	100.19
390978	99.78	390985	100.08	392054	100.00	392325	100.45	392331	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7513.30
3 Sum of Squared Measurements	752666.77
4 Correction Factor (CF): Sum of Measurements Squared / N	752662.36
5 Corrected Sum of Squares (SS)	4.41
6 Variance (V) : SS/(N-1)	0.0596
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2441
8 Sample Mean(XBAR): Sum X/N	100.18
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.47
12 Quality Index Lower (QL): (XBAR-L) / S	8.92
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1192 Lot Descr: LG&E I70 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
392675	100.10	392802	100.20	392828	100.20	392883	99.80	392941	100.40
394706	100.17	394729	100.00	395142	99.90	395299	100.08	395414	99.86
395531	100.19	396955	99.84	396973	99.92	397031	99.90	397103	100.40
397228	100.20	397354	99.70	399349	99.90	399456	100.11	399796	99.70
400028	100.10	400096	100.60	401542	100.16	401668	100.42	401718	100.20
402116	100.20	402158	100.10	402226	100.00	402319	100.22	402349	100.19
402352	100.30	402369	100.30	404563	100.20	404792	100.10	405104	100.20
405301	100.00	406485	100.38	406660	99.88	406687	100.14	406717	100.37
407128	100.00	407174	100.04	409251	100.13	409341	100.60	409450	100.50
409704	100.40	409735	100.10	411419	99.75	411515	100.30	411526	100.00
411589	100.37	411632	99.62	411677	100.39	411861	100.34	413911	100.38
413954	100.10	414051	100.20	414215	100.16	414243	100.10	414378	99.89
414559	100.75	416201	99.90	416632	100.06	416635	100.50	418753	99.90
418867	100.21	419321	100.00	419444	99.90	420998	100.03	421042	100.21
421221	100.07	421258	100.46	421380	100.40	421533	99.83	421818	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.32
3 Sum of Squared Measurements	752069.26
4 Correction Factor (CF): Sum of Measurements Squared / N	752065.42
5 Corrected Sum of Squares (SS)	3.84
6 Variance (V) : SS/(N-1)	0.0519
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2278
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.18
12 Quality Index Lower (QL): (XBAR-L) / S	9.38
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2s240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1193 Lot Descr: LG&E I70 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 17
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
423923	99.80	424272	100.45	424613	100.21	424693	99.40	424704	100.10
425832	100.01	425852	100.00	425986	100.32	426082	100.30	426113	100.09
426436	100.20	429207	100.44	429397	100.10	429569	100.37	429585	100.32
429609	100.16	432284	100.10	432295	100.10	432625	100.19	432631	99.90
432664	99.99	432834	99.80	435747	100.48	435848	100.40	436009	100.00
436034	100.36	436195	100.24	437579	100.80	437718	100.60	437782	99.98
438117	99.80	438357	100.14	438394	99.88	438473	99.85	441375	99.90
442384	100.00	442483	99.73	442539	100.34	444930	99.80	444999	100.00
445138	100.33	445519	100.02	445531	99.74	445549	99.96	445806	100.15
449159	100.14	449215	100.10	449258	100.04	449441	100.30	449443	100.22
450607	100.00	450631	100.10	451031	99.90	451252	100.20	451422	100.03
451500	99.80	455242	100.37	455306	100.30	455410	100.43	455546	100.20
455555	100.10	455672	100.12	455784	100.15	455874	100.30	456096	100.30
456180	100.12	457584	100.00	459145	99.86	459173	100.10	459249	100.15
459831	100.00	459835	99.85	459951	100.00	459960	100.10	461670	99.96

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N):	75
2 Sum of Measurements: (Sum X)	7508.09
3 Sum of Squared Measurements	751622.64
4 Correction Factor (CF): Sum of Measurements Squared / N	751618.87
5 Corrected Sum of Squares (SS)	3.76
6 Variance (V) : SS/(N-1)	0.0509
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2255
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.39
12 Quality Index Lower (QL): (XBAR-L) / S	9.35
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1194 Lot Descr: LG&E I70 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
461988	100.14	463540	100.06	463599	100.48	463785	100.00	464014	99.38
465693	100.50	466208	100.00	466237	99.92	466364	99.90	466549	100.00
467113	100.14	467272	99.80	467294	100.43	467309	100.44	467401	100.17
467478	99.90	469719	99.90	471696	99.39	471983	99.90	472048	100.19
472060	100.14	472297	100.13	473957	99.90	474092	99.70	474356	99.90
474543	99.90	474557	100.00	474641	99.90	475975	99.89	476231	99.40
476292	99.83	476294	99.90	476371	99.90	476811	100.03	476909	100.00
479021	100.22	479221	100.20	479336	100.09	479494	100.26	479506	100.13
479774	99.97	480131	100.10	481031	100.30	481107	100.30	481133	99.89
481204	99.90	481263	99.88	482521	99.50	482684	99.80	483166	99.82
483902	99.84	483985	100.09	484180	99.40	484192	100.13	484396	100.00
484436	99.83	484607	100.07	484968	99.84	487294	100.33	487297	99.90
487373	100.07	487493	100.12	487524	100.20	487561	100.39	487784	99.90
489207	100.03	489278	100.20	489445	99.70	489484	100.01	489655	99.80
489942	99.70	491026	100.10	493177	99.95	493200	99.99	493343	99.94

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7499.05
3 Sum of Squared Measurements	749814.22
4 Correction Factor (CF): Sum of Measurements Squared / N	749810.01
5 Corrected Sum of Squares (SS)	4.20
6 Variance (V) : SS/(N-1)	0.0568
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2384
8 Sample Mean (XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.44
12 Quality Index Lower (QL): (XBAR-L) / S	8.34
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1195 Lot Descr: LG&E I70 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
493596	100.15	493792	100.05	493851	100.00	495502	100.30	495690	99.79
498709	99.94	498784	100.03	498925	100.30	499022	99.90	499045	100.09
499478	100.18	500303	100.40	500953	100.12	501278	99.86	501313	100.30
501318	100.01	501463	100.15	501552	100.09	506272	99.90	506387	99.85
506480	100.20	506716	99.30	506909	99.78	510143	99.90	510180	99.91
510216	100.07	510432	100.29	510456	99.86	510637	99.80	510667	100.27
510972	99.90	511244	100.12	511497	100.01	511693	99.90	511746	100.10
511783	100.10	511789	100.00	512005	100.10	512104	100.10	512110	100.19
515946	100.00	516409	99.90	516478	99.90	519922	100.10	520095	99.90
522147	99.90	522252	99.68	522442	99.85	522822	99.70	522842	99.68
522878	99.61	524004	99.59	524018	99.73	524198	99.72	524329	99.87
524579	99.90	524583	100.10	524866	100.07	526512	100.12	526689	100.00
526843	100.10	526961	100.00	529069	100.18	529260	99.96	529309	99.90
529412	99.60	529501	100.10	529513	100.16	529581	99.94	529636	100.26
529840	100.10	532818	99.92	532889	99.90	532894	99.90	532902	99.74

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.39
3 Sum of Squared Measurements	749680.90
4 Correction Factor (CF): Sum of Measurements Squared / N	749678.03
5 Corrected Sum of Squares (SS)	2.87
6 Variance (V) : SS/(N-1)	0.0387
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1968
8 Sample Mean(XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.27
12 Quality Index Lower (QL): (XBAR-L) / S	10.06
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1196 Lot Descr: LG&E I70 - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
533251	100.10	533653	100.26	535739	100.20	535899	99.56	540456	100.14
540509	99.90	540727	100.10	540978	100.10	541228	100.20	541340	100.22
541484	100.06	541540	100.18	541623	99.78	541639	100.00	542130	100.00
542172	100.10	545610	99.80	551403	100.00	551454	99.80	551688	100.00
551731	100.17	551821	100.05	551823	99.80	551902	100.19	552075	100.00
552250	99.93	552621	100.10	552801	100.09	552851	99.70	552868	100.00
552941	100.10	553058	100.03	553103	100.15	553349	100.10	553407	100.08
553410	100.30	553460	100.38	553857	99.77	553922	100.10	553963	100.30
554258	100.00	555712	99.97	561481	100.19	562092	100.10	562373	99.90
562442	99.90	562475	99.90	562713	100.10	562948	100.12	563021	100.15
563064	100.28	563119	99.80	563171	99.99	563262	99.90	563278	100.20
563465	100.10	563503	100.10	563656	100.10	564156	100.00	564311	100.10
564764	100.10	565024	100.20	565326	100.00	565601	100.10	565621	100.00
568273	100.27	568349	100.10	568454	100.20	568584	100.02	568785	100.05
569052	99.60	569134	100.25	569143	99.94	569225	99.90	569241	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.67
3 Sum of Squared Measurements	750736.08
4 Correction Factor (CF): Sum of Measurements Squared / N	750734.18
5 Corrected Sum of Squares (SS)	1.90
6 Variance (V) : SS/(N-1)	0.0256
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1601
8 Sample Mean (XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	12.19
12 Quality Index Lower (QL): (XBAR-L) / s	12.80
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1197 Lot Descr: LG&E I70 - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One-AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
569571	99.13	569603	100.01	569636	99.79	569664	99.90	570148	100.25
570517	99.90	570593	99.89	570726	100.15	570778	100.09	570952	99.96
571050	100.10	571072	99.90	571079	99.92	571108	99.91	571278	99.90
571541	99.92	571661	100.10	571664	99.80	571702	100.10	571891	99.85
571916	100.19	572801	100.40	572894	99.99	573047	100.10	573095	100.20
573195	99.85	573306	100.00	573377	100.08	573521	100.12	573571	99.80
573813	100.10	573845	100.14	573897	100.05	573917	99.90	573947	100.00
573990	100.20	575333	100.20	582027	100.00	583266	99.90	583548	100.00
583703	100.40	583708	99.98	583808	100.10	588424	100.20	591646	100.00
591777	99.80	591920	99.70	591942	100.40	591966	100.06	591996	100.20
591999	100.06	592329	100.00	592388	100.03	592430	100.20	592528	100.30
592789	99.80	592919	100.20	593026	99.89	593210	99.96	593482	100.30
594098	99.90	594209	100.36	594225	100.22	594466	100.30	594470	100.37
594681	100.15	594750	100.20	594792	100.38	598866	100.18	599033	99.90
599120	99.84	602780	100.20	602855	100.50	602926	100.00	603269	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.77
3 Sum of Squared Measurements	750757.37
4 Correction Factor (CF): Sum of Measurements Squared / N	750754.19
5 Corrected Sum of Squares (SS)	3.19
6 Variance (V) : SS/(N-1)	0.0430
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2075
8 Sample Mean(XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.40
12 Quality Index Lower (QL): (XBAR-L) / S	9.88
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1198 Lot Descr: LG&E I70 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
603786	100.00	603988	100.20	604286	100.30	604429	100.20	604537	100.12
604683	100.30	604698	100.00	604861	100.06	604937	100.15	605006	99.92
605034	100.27	605087	100.10	605217	100.20	605265	100.19	605356	99.90
605396	100.00	605488	100.00	605502	100.40	605538	99.76	605602	99.80
605788	99.80	605836	100.01	605986	100.03	606400	100.20	606495	100.10
606522	100.00	606574	100.00	607204	99.80	623557	100.12	623726	100.15
623891	100.10	623910	100.10	623986	100.12	624155	99.90	624261	99.85
624845	100.10	624907	100.00	625031	100.15	625260	100.40	625280	100.10
625544	100.04	625601	100.30	625712	99.80	625760	100.51	625762	100.27
625787	100.16	625888	100.02	626291	99.93	626394	100.03	626546	100.10
626593	100.02	626627	100.31	626724	100.40	626757	100.10	626850	100.06
627166	99.80	627692	100.00	628030	100.00	629124	100.30	629249	100.20
629433	100.13	629478	100.49	629512	99.96	629821	100.30	629825	100.37
630047	100.10	630146	100.27	630497	100.16	630592	100.30	631252	99.70
631264	100.10	631661	100.33	631715	100.10	631926	100.40	631942	100.23

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.19
3 Sum of Squared Measurements	751641.23
4 Correction Factor (CF): Sum of Measurements Squared / N	751638.89
5 Corrected Sum of Squares (SS)	2.34
6 Variance (V) : SS/(N-1)	0.0316
7 Estimate of Lot Standard Deviation (S): SQRT of V	0.1778
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.64
12 Quality Index Lower (QL): (XBAR-L) / S	11.86
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF .In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1199 Lot Descr: LG&E I70 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
633643	100.10	639612	99.88	639639	100.40	639661	99.94	639678	100.31
639694	100.00	639872	99.99	640584	100.00	640635	100.00	640699	100.04
641085	100.07	641241	100.30	641529	100.40	641613	100.10	641699	99.70
641961	100.43	642139	100.21	642309	100.10	642403	100.17	642770	100.26
642831	100.17	642935	100.10	642968	100.10	643424	100.00	643870	100.00
643963	99.77	644180	100.06	644195	100.20	644378	100.10	644472	99.80
644725	100.21	644956	100.02	644974	100.05	644990	100.10	645095	100.10
645261	100.22	654201	95.89	654524	100.08	654641	99.84	654761	100.11
654837	100.10	654899	100.00	654920	100.00	655146	100.33	655339	99.82
655390	99.81	655406	100.08	655444	100.00	655642	99.80	655677	99.74
655940	99.90	656108	99.90	656324	99.75	656357	100.10	656423	99.98
656578	100.10	656811	100.05	656897	100.10	658046	99.90	661132	99.70
661172	99.80	661251	100.00	676905	100.16	676992	99.82	677045	100.20
677111	100.00	677128	100.06	677411	100.10	677489	100.00	677550	99.90
677563	100.24	677678	99.32	677757	99.70	678125	100.27	678345	99.74

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.79
3 Sum of Squared Measurements	749577.65
4 Correction Factor (CF): Sum of Measurements Squared / N	749558.07
5 Corrected Sum of Squares (SS)	19.59
6 Variance (V) : SS/(N-1)	0.2647
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.5145
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	3.94
12 Quality Index Lower (QL): (XBAR-L) / S	3.83
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Modal Number: I-70S Division: 01 Sample Lot: 1200 Lot Descr: LG&E I70 - 10
 In Service Population: 6,752 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
678484	99.70	678678	100.04	678691	100.19	678797	100.08	678919	100.00
678962	96.50	679038	100.40	679179	100.02	679222	99.90	679500	99.61
679553	99.91	679570	99.95	679615	99.80	679702	100.14	679718	100.60
679763	100.00	679860	100.11	679904	99.97	679956	100.00	679962	100.00
679998	100.04	680095	99.80	680161	99.65	680233	99.80	680282	99.83
680337	99.80	680597	100.00	680619	99.90	680643	99.87	680846	100.20
680932	100.00	681123	100.03	681377	100.03	681379	99.80	681425	99.86
681491	100.04	681509	99.78	681578	100.40	681620	99.81	681623	100.20
681701	100.00	681735	99.91	681811	99.60	682002	99.60	682284	99.98
682315	99.80	682344	100.00	682396	100.04	682554	99.90	682667	100.20
682854	99.92	689347	99.93	689354	100.03	689520	100.30	689537	100.20
689553	100.00	689574	100.40	689581	99.80	689914	100.00	690038	100.32
690188	100.06	690381	100.30	690411	100.07	690481	100.26	690581	100.35
690755	100.23	690862	100.10	690985	100.30	691113	100.11	691175	100.33
691590	100.62	691949	100.30	691960	100.10	692029	100.10	698567	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.92
3 Sum of Squared Measurements	749799.76
4 Correction Factor (CF): Sum of Measurements Squared / N	749784.02
5 Corrected Sum of Squares (SS)	15.74
6 Variance (V) : SS/(N-1)	0.2127
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4612
8 Sample Mean (XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.37
12 Quality Index Lower (QL): (XBAR-L) / S	4.30
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J4S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 1201
Pass/ Fail: PASS

Lot Descr: LG&E J4 - 1

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
388614	100.00	388622	99.70	388827	100.30	393319	101.00	393521	99.80
393821	99.80	393830	99.70	393859	99.80	393914	100.10	397677	100.20
398179	100.40	398282	99.70	402456	100.20	403043	99.60	403260	100.20
403275	100.40	403299	100.40	407894	100.00	407924	100.40	408001	100.60
408304	100.50	408319	100.20	412033	100.60	412071	99.80	412465	100.00
412558	100.10	417253	100.20	417400	100.50	417493	99.80	417513	99.70
417621	100.10	417726	100.20	417847	99.80	418006	99.40	422072	100.00
422141	99.40	422148	100.20	422406	100.90	422459	99.50	422550	100.00
427259	100.20	427463	99.80	427940	101.00	433629	100.10	438645	100.20
438725	99.90	438943	99.90	439201	99.90	439304	99.80	443087	100.80
443290	99.60	446846	100.20	447246	100.10	447311	99.30	449870	100.40
449972	100.00	453415	99.70	453687	100.00	453704	100.40	460322	100.20
460335	99.30	468272	99.70	468434	99.50	470082	100.30	470133	99.70
470165	99.30	470390	99.96	470401	99.60	473560	100.50	477908	100.00
477975	99.40	486178	99.49	486364	99.98	486366	100.01	492189	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.44
3 Sum of Squared Measurements	750299.32
4 Correction Factor (CF): Sum of Measurements Squared / N	750288.03
5 Corrected Sum of Squares (SS)	11.29
6 Variance (V) : SS/(N-1)	0.1526
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3907
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.07
12 Quality Index Lower (QL): (XBAR-L) / S	5.17
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1202 Lot Descr: LG&E J4 - 2
 In Service Population: 1,524 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 26

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
492957	99.85	493011	100.50	493024	99.68	496022	99.60	496042	99.70
496098	100.40	496120	99.24	496172	100.20	496178	99.70	496208	99.30
496230	99.70	496286	100.00	496363	99.57	496369	100.34	499585	99.30
499658	100.01	499697	100.10	499738	99.90	499752	99.50	499756	100.50
499775	99.70	499793	100.20	499855	99.80	499859	99.78	499868	99.60
499876	99.61	499885	99.90	499910	99.68	734146	100.18	734184	100.20
734270	100.30	740025	100.80	740027	101.10	740034	100.70	740093	100.60
740096	100.80	740106	100.50	740144	100.40	740145	100.40	740149	99.90
740193	99.90	740215	100.70	740330	100.60	740331	100.30	740357	100.80
740382	101.10	740390	100.10	740391	100.40	740425	100.70	740442	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5005.34
3 Sum of Squared Measurements	501079.82
4 Correction Factor (CF): Sum of Measurements Squared / N	501068.57
5 Corrected Sum of Squares (SS)	11.25
6 Variance (V) : SS/(N-1)	0.2296
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4791
8 Sample Mean (XBAR) : Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	3.95
12 Quality Index Lower (QL): (XBAR-L) / S	4.40
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1203 Lot Descr: LG&E J5 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

Page 27

One AQL Value for Both Upper and Lower Specification Limit Combined

Run Date: 12/31/2013

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
512304	100.00	512597	99.89	512762	100.40	512801	99.29	512859	99.45
512992	100.13	513103	99.69	513115	100.40	513807	99.40	513929	99.53
514336	100.00	514493	100.10	514536	99.97	514747	99.70	516897	100.10
517033	99.88	517248	99.41	517279	100.00	517427	99.70	517570	100.04
517700	99.99	518077	99.91	518085	99.70	518114	100.56	518238	100.00
521241	99.70	521265	99.25	521271	99.50	521544	99.20	521673	99.81
521902	99.94	525622	99.60	525955	99.19	526051	100.30	526129	99.40
526303	100.30	526383	99.86	526417	99.50	527230	99.94	527267	99.94
527717	99.89	528136	99.64	528229	100.70	528858	99.63	529983	100.12
530460	99.66	530527	99.49	530682	99.76	530761	99.92	530804	100.00
531167	99.60	531384	99.10	531490	98.30	531782	99.81	533785	99.95
534070	99.40	534230	100.03	534826	99.92	534879	99.51	534886	99.59
534964	99.90	534983	99.82	535002	99.77	535149	99.91	535238	100.08
535245	99.65	535319	99.40	539657	99.41	539909	99.44	539942	99.90
540128	100.70	540130	99.60	540211	100.00	540247	100.20	543400	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.77
3 Sum of Squared Measurements	746967.97
4 Correction Factor (CF): Sum of Measurements Squared / N	746957.09
5 Corrected Sum of Squares (SS)	10.87
6 Variance (V) : SS/(N-1)	0.1469
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3833
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.75
12 Quality Index Lower (QL): (XBAR-L) / S	4.69
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1204 Lot Descr: LG&E J5 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
543939	100.13	544272	100.14	544274	100.28	544759	100.00	544863	99.86
548624	100.20	548804	100.15	548813	99.85	549291	99.80	549365	99.70
549382	100.28	549413	99.80	549469	100.04	550485	99.00	550555	99.90
550729	100.39	551222	100.26	555724	99.59	555966	99.80	555986	99.50
556001	99.40	556317	99.74	556338	99.73	556354	99.98	556439	99.30
556465	100.03	556624	99.02	556793	100.40	557030	99.71	557091	100.10
557202	99.90	557273	99.98	557293	99.76	557597	99.67	557674	99.80
557820	99.97	558076	99.66	558112	100.10	558141	99.73	558152	99.85
558341	100.00	565829	99.51	565911	99.90	566009	99.98	566301	99.80
566645	100.00	566717	100.26	566745	99.91	566834	100.10	566848	99.70
566849	99.62	567333	99.90	567375	99.14	567545	99.67	567674	99.78
567704	100.10	567765	99.80	568103	99.70	574205	100.98	574319	99.90
579130	99.90	579144	99.75	579338	100.01	579414	100.90	579572	99.95
579900	100.50	580245	99.84	580354	99.47	580382	100.12	580538	99.90
580873	99.56	580882	100.10	581358	100.00	581467	99.90	581499	99.85

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.00
3 Sum of Squared Measurements	748409.13
4 Correction Factor (CF): Sum of Measurements Squared / N	748400.85
5 Corrected Sum of Squares (SS)	8.28
6 Variance (V) : SS/(N-1)	0.1119
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3345
8 Sample Mean (XBAR) : Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU) : (U-XBAR) / S	6.30
12 Quality Index Lower (QL) : (XBAR-L) / S	5.66
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P) : PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1205 Lot Descr: LG&E J5 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 29

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
581680	100.38	581753	100.27	584098	100.12	584370	100.29	584600	99.69
585074	99.19	585207	99.76	585322	99.80	585371	100.52	585750	100.27
585999	99.58	586054	99.70	586290	99.60	586387	99.96	586452	99.80
586503	99.60	586691	99.81	586699	100.10	586725	99.70	588573	99.77
588730	99.80	588741	100.05	588778	100.01	588847	99.73	588932	99.96
588995	100.40	589006	99.95	589390	99.96	589454	99.90	589734	100.00
590019	100.16	590364	100.17	590738	100.30	590753	100.13	591071	100.00
591178	100.18	599474	100.40	599592	100.15	599687	99.68	599698	100.36
599866	99.85	600207	99.84	600214	100.33	600484	100.60	600867	100.20
600884	100.14	600998	100.20	601007	100.40	601096	100.00	601200	99.50
601385	99.68	601404	99.92	601483	100.08	601489	99.72	601604	100.00
601772	99.95	602066	100.00	607691	100.04	607709	100.56	608098	100.10
608385	100.38	608729	99.60	608926	100.30	608946	100.15	609039	100.80
609125	99.86	609218	100.27	609233	99.90	609258	100.10	609330	99.70
609359	100.40	609534	100.00	609593	100.10	609637	100.06	609781	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.83
3 Sum of Squared Measurements	750372.22
4 Correction Factor (CF): Sum of Measurements Squared / N	750366.04
5 Corrected Sum of Squares (SS)	6.17
6 Variance (V) : SS/(N-1)	0.0834
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2888
8 Sample Mean(XBAR) : Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.84
12 Quality Index Lower (QL): (XBAR-L) / S	7.01
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1206 Lot Descr: LG&E J5 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC E1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 30

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
609995	99.70	610123	100.16	633822	99.92	633862	99.50	634030	99.71
634092	100.14	634185	99.80	634213	99.65	634448	99.62	634456	99.98
634508	99.90	634620	99.81	634655	100.01	634746	99.78	634827	100.14
634969	100.16	635050	99.61	635057	99.80	635158	100.30	635835	100.20
635891	100.17	636086	99.90	636091	99.70	636196	99.82	636220	99.70
636420	99.80	636652	100.02	657472	100.10	657676	100.13	661954	99.70
661979	99.94	662245	99.67	662472	99.80	662667	100.50	662843	99.48
662896	99.89	662937	99.93	663042	99.80	663154	99.50	663309	99.00
663577	99.70	663591	99.57	663832	99.63	663906	99.70	664003	99.80
664100	99.80	664342	99.90	664486	99.30	664656	99.60	664726	99.90
664852	100.00	664872	99.81	665107	99.63	665411	99.50	665487	99.80
665735	99.30	665739	99.80	665770	100.10	665911	99.35	666019	99.76
666022	99.79	666122	100.07	666172	100.10	666323	99.50	666345	99.30
667235	100.02	667289	99.71	667473	100.11	667825	100.08	667830	99.80
667858	99.96	667970	100.22	668941	99.57	669002	100.02	669021	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.24
3 Sum of Squared Measurements	747255.71
4 Correction Factor (CF): Sum of Measurements Squared / N	747250.52
5 Corrected Sum of Squares (SS)	5.18
6 Variance (V) : .SS/(N-1)	0.0700
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2646
8 Sample Mean (XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.25
12 Quality Index Lower (QL): (XBAR-L) / S	6.87
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J55 (R200) Division: 01 Sample Lot: 1207 Lot Descr: LG&E J5 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 31

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
669312	99.55	669550	99.40	669865	99.90	670038	99.80	670097	99.94
670157	99.60	670231	99.57	670256	99.66	670404	99.91	670612	100.00
670640	99.20	670641	99.87	683200	99.90	683258	100.35	683279	100.40
683321	100.00	683533	99.80	683765	99.70	683802	100.00	684023	99.40
684200	100.20	684419	99.20	684479	99.50	684522	99.80	684662	99.70
684806	99.90	684811	100.00	685129	99.60	685236	99.70	685258	99.93
686043	100.00	686106	100.40	686131	100.20	686284	100.20	686569	100.40
686675	99.40	686938	100.20	687214	99.70	687431	100.10	687564	99.80
688107	99.90	688319	100.30	688431	99.90	688445	99.60	688577	99.90
688794	99.80	688887	100.20	689137	99.70	692170	100.20	692399	100.40
692408	99.90	692617	100.00	692619	100.40	692963	100.10	693041	100.20
693156	99.90	693514	99.90	693740	99.80	693765	99.50	694086	100.10
694088	99.91	694241	100.30	694571	99.80	694608	100.40	694908	100.00
695266	100.00	695271	99.50	695500	100.00	695506	99.80	695771	100.10
695784	99.90	696540	99.80	696617	99.70	696622	99.90	696968	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.69
3 Sum of Squared Measurements	748544.73
4 Correction Factor (CF): Sum of Measurements Squared / N	748538.71
5 Corrected Sum of Squares (SS)	6.01
6 Variance (V) : SS/(N-1)	0.0813
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2851
8 Sample Mean(XBAR) : Sum X/N	99.90
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.36
12 Quality Index Lower (QL): (XBAR-L) / s	6.67
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1208 Lot Descr: LG&E J5 -.6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 32

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
697260	100.10	697281	100.41	697410	100.28	697669	100.09	697689	100.00
698035	99.80	698250	100.30	698891	99.50	699231	99.70	699612	99.30
699675	100.14	699810	100.00	699846	100.10	699952	100.20	700058	99.70
700466	99.95	700567	99.80	705585	99.86	705658	99.71	705753	99.80
705786	99.50	705854	99.73	705889	99.41	706036	99.87	706081	99.78
706087	99.77	706341	99.80	706354	100.00	706472	99.70	706518	99.71
706731	99.69	706797	99.89	707015	99.80	707074	99.90	707204	100.20
707284	99.88	707292	99.72	707405	99.70	707414	100.00	707624	99.90
707647	100.20	707784	99.90	708002	100.10	708144	99.40	708191	99.90
724020	100.10	724207	99.82	724653	99.60	726188	99.94	726206	100.31
726259	99.90	726449	99.84	726615	99.40	726705	100.30	726865	99.84
726871	100.20	727031	100.56	727122	99.60	727233	100.20	727822	99.33
727994	100.60	728068	99.90	728132	100.00	728171	99.80	728211	99.80
728238	100.20	728537	100.06	728557	99.80	728651	100.00	729043	100.07
729438	100.12	729447	100.30	729468	100.19	729761	100.20	729968	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.37
3 Sum of Squared Measurements	748879.97
4 Correction Factor (CF): Sum of Measurements Squared / N	748874.42
5 Corrected Sum of Squares (SS)	5.55
6 Variance (V) : SS/(N-1)	0.0750
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2738
8 Sample Mean (XBAR): Sum X/N	99.92
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.58
12 Quality Index Lower (QL): (XBAR-L) / S	7.03
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200

Model Number: J5S

Division: 01

Sample Lot: 1209

Lot Descr: LG&E J5 - 7

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
730256	99.94	730266	99.97	730273	100.10	730297	100.09	730898	100.20
730905	100.00	731074	100.08	731581	99.44	731604	99.90	731612	99.22
731672	100.25	731713	99.20	731797	100.40	732075	99.60	732148	99.95
732259	100.20	732276	99.70	732423	99.80	732468	99.58	732492	99.40
732562	99.95	732607	100.48	732759	99.90	732951	100.00	733165	99.98
733640	99.80	734005	99.64	734621	101.20	734683	99.90	734930	99.70
734986	100.10	735023	99.80	735169	100.10	735238	99.83	735351	99.72
735362	99.94	735448	99.90	735516	100.28	735620	99.60	736376	100.30
736394	100.37	736674	100.50	736683	99.80	737501	99.79	737508	99.51
737805	100.00	737928	100.19	738005	99.85	738310	100.00	738395	99.40
738492	99.50	738529	99.70	738684	100.10	738868	99.90	739059	100.50
739522	99.92	739586	99.61	739639	99.80	740511	99.58	740573	100.36
740606	99.97	741278	100.39	741461	99.63	741579	99.62	741752	99.70
741771	99.18	741785	100.00	741924	99.18	742049	99.63	742146	99.80
742245	99.51	742275	99.72	742445	99.80	743095	99.86	743397	99.96

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7491.47
3 Sum of Squared Measurements	748303.86
4 Correction Factor (CF): Sum of Measurements Squared / N	748294.97
5 Corrected Sum of Squares (SS)	8.89
6 Variance (V) : SS/(N-1)	0.1202
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3467
8 Sample Mean(XBAR): Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.10
12 Quality Index Lower (QL): (XBAR-L) / S	5.44
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: E2S240V30AC200 Model Number: J5S Division: 01. Sample Lot: 1210 Lot Descr: LG&E J5 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
743636	99.76	743652	99.92	743681	99.08	743866	99.38	743989	99.99
744322	99.12	744333	99.70	744404	99.60	744639	99.40	745000	99.80
745087	100.36	745233	100.90	745320	99.55	745395	100.10	745509	99.70
745553	100.03	745572	99.83	745586	99.40	745644	98.90	745711	99.83
745893	99.50	745900	99.06	746206	99.10	746240	99.31	746331	98.80
746387	99.60	746413	99.83	746718	99.50	746733	99.70	746738	99.26
747183	99.70	747286	99.84	747297	100.60	747505	99.40	747557	99.53
747672	99.46	747745	98.99	747929	99.44	747953	99.60	748316	99.40
748473	99.61	748858	99.34	749090	99.20	749287	99.30	749417	100.09
749448	99.34	749455	99.55	749780	99.41	749920	99.50	749944	99.73
749972	100.00	749991	99.90	750338	99.70	750421	99.44	750429	100.00
750604	99.26	751108	99.41	751662	99.69	751748	100.10	751848	99.00
751864	98.78	752062	99.20	752308	99.20	752467	99.66	752666	99.40
752745	99.80	752781	99.80	752988	99.51	753001	99.38	753092	99.62
753108	99.69	757433	99.30	757762	99.70	757837	100.04	757874	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7468.62
3 Sum of Squared Measurements	743747.95
4 Correction Factor (CF): Sum of Measurements Squared / N	743737.13
5 Corrected Sum of Squares (SS)	10.82
6 Variance (V) : SS/(N-1)	0.1462
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3824
8 Sample Mean(XBAR): Sum X/N	99.58
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.32
12 Quality Index Lower (QL): (XBAR-L) / S	4.14
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1211 Lot Descr: LG&E J5 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
758237	100.01	758378	99.60	758384	99.56	758555	99.17	758568	98.19
758844	99.50	758929	100.01	759187	100.12	759319	99.96	759720	99.40
759749	100.00	759771	100.20	759996	99.80	760344	99.21	760651	99.75
761235	99.90	761333	99.80	761446	99.40	761482	99.80	761609	100.14
761923	99.50	761981	99.23	762075	99.80	762361	99.40	762382	99.54
762558	99.79	762580	99.18	762594	99.80	762691	99.70	762749	99.70
762756	99.87	762766	99.45	763482	99.40	763600	99.90	763608	99.60
763860	99.60	763896	99.50	763905	99.60	763979	99.78	764226	99.75
764255	100.40	764750	99.40	764891	99.70	764923	99.71	764933	99.70
764983	98.80	765013	99.70	765045	99.40	767537	100.51	767628	99.59
767743	99.92	767857	99.60	768183	99.57	768488	100.40	768523	99.84
768627	99.60	768666	99.71	768702	100.10	768814	99.50	768898	99.60
769057	99.70	769102	99.61	769120	99.80	769357	100.13	769378	99.70
769573	99.51	769974	99.65	770095	99.40	770135	100.00	770330	100.00
770550	99.80	770727	99.53	770937	99.70	770946	99.90	770953	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7476.49
3 Sum of Squared Measurements	745313.97
4 Correction Factor (CF): Sum of Measurements Squared / N	745305.37
5 Corrected Sum of Squares (SS)	8.60
6 Variance (V) : SS/(N-1)	0.1162
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3409
8 Sample Mean (XBAR): Sum X/N	99.69
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.79
12 Quality Index Lower (QL): (XBAR-L) / s	4.95
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1212 Lot Descr: LG&E J5 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 36

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
771080	99.90	771094	99.70	771205	99.80	771471	99.60	771534	99.90
771659	100.20	771864	100.14	772489	99.83	772873	99.82	773023	99.99
773131	99.88	773245	99.64	773252	100.00	773340	99.80	773343	99.55
773639	99.90	773681	99.60	773710	100.00	773732	99.90	773821	99.57
773876	99.70	773981	99.60	774005	99.68	774074	99.70	774120	100.00
774217	99.65	774235	100.10	774311	99.70	774374	99.60	774401	100.05
774539	99.88	774599	99.86	774900	100.45	775098	100.00	775215	100.00
775305	100.10	775442	99.77	775511	99.70	779928	100.09	780309	99.56
780382	100.10	780731	100.40	780779	99.60	780952	99.60	781093	98.99
781105	99.62	781553	100.20	781772	100.03	781796	99.70	781961	99.50
782124	100.10	782381	99.42	782445	100.30	782450	99.44	782800	99.60
782855	99.90	782911	99.40	783008	100.03	783153	99.08	783228	100.10
783315	99.70	783783	100.00	784313	99.71	784316	100.00	784812	100.30
784821	99.80	784857	100.06	785029	100.42	792621	100.30	792710	100.00
792789	100.72	792893	100.02	793187	100.08	793319	99.90	793358	100.57

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7490.60
3 Sum of Squared Measurements	748128.21
4 Correction Factor (CF): Sum of Measurements Squared / N	748121.18
5 Corrected Sum of Squares (SS)	7.03
6 Variance (V) : SS/(N-1)	0.0950
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3082
8 Sample Mean (XBAR): Sum X/N	99.87
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.90
12 Quality Index Lower (QL): (XBAR-L) / S	6.08
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1213 Lot Descr: LG&E J5 - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
785215	100.10	785335	100.30	785463	100.00	785598	100.50	785937	100.50
785944	100.10	786023	99.90	786116	100.10	786371	100.07	786624	100.54
786808	100.40	786878	99.85	787075	100.10	787100	100.20	787151	100.00
787174	99.71	787401	100.70	787602	100.10	787649	100.30	787911	100.01
788056	99.90	788122	99.71	788387	99.90	788583	99.85	788733	100.24
788770	99.72	788783	99.60	788864	100.00	788899	99.57	789225	99.98
789238	99.43	789380	100.01	789548	99.70	789647	99.50	789701	99.54
789787	99.72	790008	100.10	790270	99.80	790342	99.40	790375	100.10
790574	99.80	790663	99.96	791090	100.00	791443	99.94	791585	99.56
800960	99.90	801030	99.64	801287	98.94	801307	99.43	801452	99.20
801471	99.40	801692	99.11	801765	99.97	801818	100.25	801863	99.55
801964	99.10	802212	99.32	802235	99.17	802243	98.82	802261	99.60
802451	99.20	802573	99.53	802610	99.60	802865	99.74	803098	100.00
803248	99.30	803323	100.30	803377	99.40	803895	99.74	804038	99.78
804070	99.51	804130	99.91	804224	99.70	804480	99.70	804489	99.44

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.76
3 Sum of Squared Measurements	746966.10
4 Correction Factor (CF): Sum of Measurements Squared / N	746955.10
5 Corrected Sum of Squares (SS)	11.00
6 Variance (V) : SS/(N-1)	0.1487
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3856
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.71
12 Quality Index Lower (QL): (XBAR-L) / S	4.66
13 Estimate of Lot Percent NCF Above U (FU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): FU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1214 Lot Descr: LG&E J5 - 12
 In Service Population: 7,776 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
804766	99.82	804834	99.70	804871	101.40	804933	99.28	805076	99.40
805138	100.00	805206	99.90	805251	100.01	805320	98.61	805373	99.10
805405	99.80	805476	99.44	805575	99.90	805807	98.50	805852	99.40
805858	99.46	805881	99.33	805908	100.45	805950	99.80	806023	99.76
806041	100.00	806118	100.11	806222	99.90	806318	99.17	806342	99.30
806486	99.77	806528	99.90	806552	99.63	806778	99.80	806882	99.50
806908	99.40	806974	100.10	806995	99.60	807384	100.19	807482	99.13
808118	98.69	808158	99.96	808217	99.80	810091	99.60	810288	98.40
810325	99.68	810386	100.03	810393	99.10	810477	99.45	810549	99.30
810717	99.30	810853	98.50	811027	98.50	811324	99.20	811545	99.32
811548	99.90	811702	100.12	811753	99.80	811759	99.10	811848	99.57
811852	99.19	811859	99.06	811891	99.80	811921	99.58	811932	99.70
812087	99.80	812163	99.50	812372	99.50	812770	99.60	812785	99.80
812812	99.60	812853	99.17	812883	99.30	812948	98.65	813135	100.00
813156	99.50	813344	98.76	813398	99.80	813563	99.40	814265	99.70

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7465.29
3 Sum of Squared Measurements	743092.10
4 Correction Factor (CF): Sum of Measurements Squared / N	743074.06
5 Corrected Sum of Squares (SS)	18.04
6 Variance (V) : SS/(N-1)	0.2438
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4937
8 Sample Mean(XBAR): Sum X/N	99.54
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.99
12 Quality Index Lower (QL): (XBAR-L) / S	3.11
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.07
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.07
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MQS Division: 01 Sample Lot: 1215 Lot Descr: LG&E MQ - 1
 In Service Population: 180 Sample Quantity: 15 Meters Tested: 15 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

Page 39

One AQL Value for Both Upper and Lower Specification Limit Combined

Run Date: 12/31/2013

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
328852	99.40	333292	99.30	333427	99.80	337768	99.90	347154	101.20
347179	99.80	351775	99.80	356454	100.10	361152	99.90	361186	100.30
365378	100.30	370012	99.80	370087	100.00	370384	99.80	374889	100.50

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	15
2 Sum of Measurements: (Sum X)	1499.90
3 Sum of Squared Measurements	149982.95
4 Correction Factor (CF): Sum of Measurements Squared / N	149980.00
5 Corrected Sum of Squares (SS)	2.95
6 Variance (V) : SS/(N-1)	0.2107
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4590
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.37
12 Quality Index Lower (QL): (XBAR-L) / S	4.34
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	6.55
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1216 Lot Descr: LG&E MS - 1
 In Service Population: 8,783 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
378520	100.10	378706	99.10	380174	100.20	380192	100.10	380333	99.80
380378	100.00	389546	99.90	389706	100.30	389816	100.60	390087	100.40
394031	100.00	394064	100.50	394177	99.90	394182	100.10	394295	100.00
398655	100.20	403869	99.80	403880	99.90	403989	100.30	404069	100.60
404123	100.30	408652	100.30	408699	100.00	408924	100.10	413558	99.50
413783	100.60	418186	101.30	418242	100.60	418311	100.60	418592	100.10
423012	99.90	423047	100.10	423220	100.70	423522	100.50	428060	100.40
428092	100.00	428220	99.73	428243	99.87	428410	99.80	428520	99.66
428783	100.10	434725	100.30	434958	99.81	435045	100.13	435182	100.15
435191	99.80	435243	99.24	435259	100.30	439436	100.15	439483	99.79
439901	100.00	444194	100.10	444198	99.60	444269	99.90	444285	100.20
444399	100.11	444400	100.10	444498	99.90	446040	99.55	446149	99.35
446212	99.90	447471	100.05	447524	99.93	447538	99.10	447540	100.10
447581	99.97	450250	99.43	452101	100.20	452278	100.00	452422	99.90
452448	99.90	507508	99.90	536273	100.20	597025	99.90	647603	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.92
3 Sum of Squared Measurements	750593.84
4 Correction Factor (CF): Sum of Measurements Squared / N	750584.11
5 Corrected Sum of Squares (SS)	9.72
6 Variance (V) : SS/(N-1)	0.1314
7 Estimate of Lot Standard Deviation (S): SQRT of V	0.3625
8 Sample Mean (XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.41
12 Quality Index Lower (QL): (XBAR-L) / S	5.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200
In Service Population: 10,000

Modal Number: MSII
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 1217
Pass/ Fail: PASS

Lot Descr: LG&E MSII - 1

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
454384	100.20	454402	100.00	454463	100.00	454761	100.00	454773	100.12
454804	99.60	457707	100.19	457782	100.30	457822	100.17	457964	100.53
458129	100.30	460545	99.73	460714	100.28	460833	100.30	462806	100.00
466633	100.30	466665	100.55	466737	100.10	466884	99.86	469289	100.30
469420	100.40	473161	100.09	473231	99.81	473395	99.94	473396	100.10
477259	100.20	477369	99.90	477591	100.40	480736	100.00	480822	100.40
482096	99.20	482158	100.10	482173	99.92	482242	99.72	482298	100.00
482302	100.07	485120	100.40	485219	99.90	488530	99.60	491279	100.29
491459	100.05	494811	100.43	495147	100.07	497891	99.91	498058	100.20
498069	99.70	498213	100.29	498241	100.20	502324	99.80	502439	100.10
502477	100.10	502847	99.99	502867	100.00	503326	100.20	503595	99.70
503624	100.10	503652	99.80	503796	99.76	504011	100.13	507269	99.89
507279	99.18	507482	99.60	507518	99.72	507743	100.30	508120	99.70
508434	100.30	508515	99.95	508602	100.10	508644	100.30	519131	100.20
519543	100.30	522991	100.06	523345	100.35	523508	100.59	523686	100.60

INFORMATION NEEDED:

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.94
3 Sum of Squared Measurements	750994.26
4 Correction Factor (CF): Sum of Measurements Squared / N	750988.33
5 Corrected Sum of Squares (SS)	5.94
6 Variance (V) : SS/(N-1)	0.0803
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2833
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	6.83
12 Quality Index Lower (QL): (XBAR-L) / s	7.29
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Balow L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1218 Lot Descr: LG&E MSII - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
532042	99.71	532123	100.10	532131	99.92	532666	100.10	535989	99.98
536088	99.80	536130	99.68	536151	99.57	536646	99.81	536741	99.82
536960	99.80	537171	99.94	537345	100.00	537362	99.94	537761	100.70
542317	100.23	542393	100.47	542399	99.94	542491	100.20	542541	99.98
542560	100.40	542662	100.21	542843	100.10	542908	100.26	542911	100.40
542954	100.00	543102	101.00	545887	100.60	545941	100.09	546091	100.07
546203	99.40	546593	100.30	546688	100.10	546977	100.30	547040	100.14
547058	100.00	547070	100.32	547438	100.02	547618	99.90	547749	100.03
547949	100.22	548212	100.00	548306	100.00	548397	100.02	548468	100.04
558653	100.09	558679	100.10	559170	100.20	559204	100.30	559370	100.10
559433	100.00	559488	100.30	559585	100.10	559814	100.27	559896	100.11
560056	100.16	560213	99.80	560326	100.42	560351	100.00	560539	100.20
560659	100.30	560735	100.10	560846	100.10	561037	100.45	561093	100.30
561094	99.99	561447	100.16	575605	100.09	575690	99.80	575755	100.04
575863	100.00	576107	100.20	576131	99.86	576723	99.94	577041	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7507.19
3 Sum of Squared Measurements	751443.09
4 Correction Factor (CF): Sum of Measurements Squared / N	751438.69
5 Corrected Sum of Squares (SS)	4.40
6 Variance (V) : SS/(N-1)	0.0594
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2438
8 Sample Mean(XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	7.81
12 Quality Index Lower (QL): (XBAR-L) / s	8.60
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1219 Lot Descr: IG&E MSII - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 43

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
577221	100.50	577259	100.33	577263	100.30	577431	100.10	577470	100.15
577551	99.97	577600	99.80	577653	100.30	577655	100.00	596069	100.16
596118	100.20	596155	99.85	596175	100.20	596232	100.18	596410	99.96
596429	100.10	596560	100.16	596846	99.81	596855	99.85	596913	100.14
596926	100.00	596942	99.98	597089	100.29	597161	100.10	597261	99.70
597462	99.90	597513	99.98	597556	100.10	597576	99.80	597589	99.95
597633	99.90	597770	100.00	597799	99.90	597946	100.50	597975	99.90
598010	100.04	598645	100.30	598693	100.03	598769	99.92	611880	100.30
611945	100.68	612123	100.10	612130	100.00	612183	100.30	612395	100.00
612630	100.30	612947	100.39	612959	100.40	613241	99.64	613297	100.28
613410	100.34	613603	100.20	613720	99.38	613765	100.30	613801	100.11
613804	100.53	613843	100.11	613906	100.09	614142	100.08	614374	100.20
614897	99.46	614903	99.80	615539	100.30	615772	100.00	615843	99.45
616388	99.93	616442	99.52	616802	99.68	616803	100.70	616858	100.66
617565	99.85	617613	100.20	618048	99.70	618495	99.57	618690	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.10
3 Sum of Squared Measurements	751026.13
4 Correction Factor (CF): Sum of Measurements Squared / N	751020.35
5 Corrected Sum of Squares (SS)	5.78
6 Variance (V) : SS/(N-1)	0.0782
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2796
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.91
12 Quality Index Lower (QL): (XBAR-L) / S	7.40
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1220 Lot Descr: LG&E MSII - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
618945	99.70	619015	99.29	619132	99.30	619210	99.38	619691	100.30
619692	100.20	619943	99.70	619967	99.60	619991	99.69	620108	99.89
620185	100.44	620187	100.41	620298	99.45	620309	100.03	620445	100.30
620512	100.36	620590	99.40	620863	100.00	621018	99.37	621107	99.90
621142	100.38	621516	99.93	622083	99.49	622101	99.60	622458	100.10
622518	100.00	622636	99.46	622731	99.79	622911	100.00	622955	99.95
622966	99.63	637434	99.76	637466	100.07	637651	100.07	637730	100.21
637822	100.10	637837	100.10	638159	100.36	638280	100.40	638533	99.96
638599	100.05	638622	100.10	638842	100.20	638877	99.72	638978	99.85
638997	100.06	639271	100.06	639298	100.18	639330	100.10	639417	99.69
639501	100.24	645553	100.10	645590	99.80	645767	100.10	645864	99.90
645999	100.10	646055	100.14	646240	100.10	646242	100.41	646343	100.10
646387	100.40	646486	99.95	646639	100.25	646827	100.10	646953	100.00
647282	100.20	647302	99.94	647814	100.00	647924	100.24	648029	99.86
648359	100.07	648749	100.08	648840	100.30	648915	100.00	649021	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.76
3 Sum of Squared Measurements	749758.28
4 Correction Factor (CF): Sum of Measurements Squared / N	749752.02
5 Corrected Sum of Squares (SS)	6.26
6 Variance (V) : SS/(N-1)	0.0845
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2908
8 Sample Mean (XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.94
12 Quality Index Lower (QL): (XBAR-L) / S	6.82
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1221 Lot Descr: LG&E MSII - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
649193	100.25	649330	100.15	649557	100.22	649597	100.01	649680	100.23
650048	100.00	650211	100.07	650265	100.30	650270	100.00	650338	100.20
650423	100.10	650517	100.03	650897	99.86	651020	100.10	651313	99.95
651424	99.96	651472	100.10	651509	100.08	651566	100.00	651730	100.23
651787	100.00	652041	100.13	652260	100.00	652272	100.03	652361	100.10
652382	100.19	652470	100.21	652626	100.15	652703	100.00	652780	100.00
653107	99.90	653243	99.97	653399	100.24	653436	99.85	653638	100.20
653640	100.00	653745	100.00	653777	100.20	653826	99.90	653999	100.38
658318	100.60	658499	100.30	658901	100.00	659115	100.02	659193	100.60
659401	100.17	659505	100.10	659628	100.42	659761	99.71	660175	100.17
660239	100.23	660327	100.22	660534	100.15	660656	100.27	660686	100.40
660913	99.90	660987	100.40	670993	100.26	671429	100.39	671478	100.11
671525	100.00	671602	100.30	672005	100.10	672053	99.90	672266	100.10
672292	100.01	672323	99.98	672339	100.20	672426	100.26	673019	100.16
673031	100.23	673093	100.11	673228	100.20	673299	100.10	673306	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7509.36
3 Sum of Squared Measurements	751875.16
4 Correction Factor (CF): Sum of Measurements Squared / N	751873.17
5 Corrected Sum of Squares (SS)	1.99
6 Variance (V) : SS/(N-1)	0.0269
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1639
8 Sample Mean(XBAR): Sum X/N	100.12
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	11.44
12 Quality Index Lower (QL): (XBAR-L) / S	12.96
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1222 Lot Descr: LG&E MSII - 6
 In Service Population: 2,649 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

Page 46

One AQL Value for Both Upper and Lower Specification Limit Combined

Run Date: 12/31/2013

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
673730	99.97	673785	100.30	673790	100.46	673824	100.11	673840	100.10
673846	100.20	673849	100.20	673983	100.00	674009	100.20	674131	100.21
674156	100.09	674206	100.10	674207	100.10	674289	100.10	674314	100.40
674367	100.35	674395	100.08	674466	99.90	674688	100.06	674747	99.92
674779	100.32	674854	99.70	674937	100.10	674998	100.06	675112	100.12
675273	100.10	675339	100.13	675357	100.06	675373	100.21	675534	100.10
675537	100.19	675561	100.06	675575	100.21	675859	100.20	675902	100.10
675914	99.90	675971	100.20	675972	99.90	676062	100.40	676079	100.19
676136	100.14	676142	100.23	676167	99.81	676189	100.17	676253	100.22
676296	100.10	676298	100.19	676467	100.20	676563	100.20	676620	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5006.36
3 Sum of Squared Measurements	501273.84
4 Correction Factor (CF): Sum of Measurements Squared / N	501272.81
5 Corrected Sum of Squares (SS)	1.03
6 Variance (V) .: SS/(N-1)	0.0211
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1452
8 Sample Mean (XBAR): Sum X/N	100.13
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	12.89
12 Quality Index Lower (QL): (XBAR-L) / S	14.65
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1223 Lot Descr: LG&E MX - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
702893	99.81	703748	99.80	703787	100.20	703875	99.90	704033	100.00
704089	99.90	704177	100.00	704432	100.20	704587	99.79	704603	100.10
704691	100.23	704959	99.30	705256	100.20	705273	99.70	708696	99.85
708719	99.84	708801	99.90	709069	100.00	709226	99.67	709434	100.40
709436	99.80	709566	99.69	709720	99.80	709734	99.52	709849	99.60
710077	99.90	710258	99.70	710673	99.97	711133	99.80	711187	99.73
711253	99.91	711393	100.04	711415	100.10	711503	99.87	711541	99.90
711732	99.51	711904	100.10	712090	99.60	712371	99.75	712583	99.60
712684	99.60	712755	99.90	712770	99.94	712953	99.66	713068	99.58
713069	99.70	713090	99.82	713098	99.60	713171	99.58	713441	100.00
713454	99.99	713518	100.40	713724	99.68	713793	99.63	713983	99.89
714073	99.80	714184	99.40	714251	99.88	714380	99.11	714734	99.90
715129	99.49	715145	99.70	715222	99.70	715524	99.73	715724	99.93
715751	100.00	715766	99.63	715814	99.91	715917	99.54	715977	99.96
716164	100.00	716328	99.70	716528	99.79	716538	99.98	716700	99.95

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.75
3 Sum of Squared Measurements	747356.26
4 Correction Factor (CF): Sum of Measurements Squared / N	747352.34
5 Corrected Sum of Squares (SS)	3.91
6 Variance (V) : SS/(N-1)	0.0529
7 Estimate of Lot Standard Deviation (S): SQRT of V	0.2300
8 Sample Mean(XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.46
12 Quality Index Lower (QL): (XBAR-L) / S	7.93
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: MX
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 1224
Pass/ Fail: PASS

Lot Descr: LG&E MX - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 48

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
716822	99.81	717135	99.91	717145	99.79	717247	99.61	717251	99.70
717327	99.59	717561	99.91	717577	99.54	717604	99.70	717665	99.80
717707	99.70	718344	99.30	718376	99.45	718567	99.84	718721	99.88
718728	99.84	718851	99.70	718953	99.98	719060	99.62	719108	100.08
719155	99.79	719173	99.83	719305	99.65	719532	99.60	719742	99.90
719767	100.00	719828	100.30	720024	99.50	720240	99.70	720311	99.92
720579	100.20	721193	99.84	721325	100.06	721349	99.82	721476	99.82
721586	99.23	721735	100.10	721901	99.88	722020	99.93	722082	99.36
722275	99.33	722324	99.90	722330	99.20	722380	99.70	722410	99.85
722443	99.94	722482	100.02	722594	99.80	722761	100.73	722769	100.30
722830	99.83	722845	100.00	723033	99.80	723215	99.44	814652	99.87
814811	99.68	815089	99.80	815224	99.51	815242	99.60	815389	99.80
815983	99.50	816051	99.45	816089	99.90	816122	99.90	816651	99.83
816752	99.50	817278	100.10	817457	99.98	817736	100.08	817790	99.90
818006	100.10	818058	99.84	819275	99.84	819324	99.80	819481	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7485.10
3 Sum of Squared Measurements	747027.85
4 Correction Factor (CF): Sum of Measurements Squared / N	747022.96
5 Corrected Sum of Squares (SS)	4.89
6 Variance (V) : SS/(N-1)	0.0661
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2572
8 Sample Mean(XBAR) : Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / s	8.55
12 Quality Index Lower (QL): (XBAR-L) / s	7.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1225 Lot Descr: LG&E MX - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49

Run Date: 12/31/2013

Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
819619	99.60	819730	99.89	819912	95.90	820110	100.10	820188	99.50
820259	100.07	820300	99.68	820538	98.80	820756	99.80	820916	100.07
820951	99.94	820966	99.90	821265	99.83	821450	99.64	821647	99.70
821760	98.80	821804	99.46	821865	99.30	821896	99.90	822057	99.23
822228	99.62	822360	99.73	822581	99.37	822615	99.70	822697	99.30
822730	99.60	822755	99.60	822847	99.71	824231	99.80	824297	99.71
824515	99.74	824586	99.54	824608	99.81	824880	99.71	824986	99.65
825219	99.82	825338	99.78	825344	98.60	825393	98.70	825531	99.73
825575	99.76	825767	99.70	826286	100.09	826306	99.70	826354	99.80
826687	99.74	826895	99.97	826952	99.87	827277	99.50	827582	99.99
827662	99.30	827756	99.76	827880	99.70	827985	99.77	830102	99.54
830119	99.86	830164	99.70	830455	99.82	830497	99.77	830575	99.51
830767	99.30	830808	99.40	830996	99.87	831093	99.05	831249	99.79
831282	99.10	831717	100.03	831797	100.00	836366	99.90	836515	99.60
836560	99.80	836854	99.96	836897	99.80	836906	100.00	837027	99.84

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7470.62
3 Sum of Squared Measurements	744156.83
4 Correction Factor (CF): Sum of Measurements Squared / N	744135.51
5 Corrected Sum of Squares (SS)	21.32
6 Variance (V) : SS/(N-1)	0.2881
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.5368
8 Sample Mean(XBAR): Sum X/N	99.61
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.46
12 Quality Index Lower (QL): (XBAR-L) / S	3.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.10
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.10
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2013 Sample Test Program (01/01/2013) to (12/31/2013)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1226 Lot Descr: LG&E MX - 4
 In Service Population: 2,612 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 50
 Run Date: 12/31/2013
 Run Time: 02:32:06 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
837437	99.80	837639	99.75	837704	100.25	837770	99.93	837847	99.60
837908	99.80	838083	99.88	838107	99.90	838123	99.90	838132	99.90
839016	99.80	839073	99.90	839209	99.90	839216	99.92	839227	99.90
839243	100.01	839268	99.70	839275	99.80	839276	99.90	839301	99.84
839341	99.64	839447	99.90	839507	99.90	839518	99.68	839567	100.00
839658	99.84	839763	99.67	839856	99.80	839926	99.84	839996	99.59
840016	99.91	840075	99.76	840106	100.12	840195	99.80	840254	99.80
840258	99.60	840297	100.00	840301	99.90	840366	99.71	840434	99.78
840452	99.90	840460	100.00	840590	100.20	840600	100.05	840622	99.79
840632	99.74	840645	99.90	840649	99.70	840701	99.62	840783	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4992.32
3 Sum of Squared Measurements	498466.19
4 Correction Factor (CF): Sum of Measurements Squared / N	498465.18
5 Corrected Sum of Squares (SS)	1.01
6 Variance (V) : SS/(N-1)	0.0206
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1434
8 Sample Mean (XBAR) : Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	15.01
12 Quality Index Lower (QL): (XBAR-L) / S	12.87
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2013 Sample Test Program (01/01/2013) to (12/31/2013)

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	SET	REMV	MTRS	TST	PASS/FAIL	LOT NUMBER
LG&E AB1 - 1	Westinghouse	AB1	174	15	0	0	15	PASS TESTING COMPLETE	1177	
LG&E ALF - 1	Landis + Gyr	ALF (Trilliant)	839	35	0	0	35	PASS TESTING COMPLETE	1178	
LG&E C1S1 - 1	Itron	C1SR (ERT)	10,000	75	0	0	75	PASS TESTING COMPLETE	1179	
LG&E C1S1 - 2	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1180	
LG&E C1S1 - 3	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1181	
LG&E C1S1 - 4	Itron	C1S	2,088	50	0	0	50	PASS TESTING COMPLETE	1182	
LG&E C2SX - 1	Itron	C2SX	9	3	0	0	3	PASS TESTING COMPLETE	1183	
LG&E D4S - 1	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1184	
LG&E D4S - 2	Westinghouse	D4S	3,239	75	0	0	75	PASS TESTING COMPLETE	1185	
LG&E I210 - 2	General Electric	I-210 (ERT)	1,130	35	0	0	35	PASS TESTING COMPLETE	1186	
LG&E I50 - 1	General Electric	I-50S	1,111	35	0	0	35	PASS TESTING COMPLETE	1187	
LG&E I55 - 1	General Electric	I-55S	1,449	50	0	0	50	PASS TESTING COMPLETE	1188	
LG&E I60 - 1	General Electric	I-60S	10,000	75	0	0	75	PASS TESTING COMPLETE	1189	
LG&E I60 - 2	General Electric	I-60S	3,014	50	0	0	50	PASS TESTING COMPLETE	1190	
LG&E I70 - 1	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1191	
LG&E I70 - 2	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1192	
LG&E I70 - 3	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1193	
LG&E I70 - 4	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1194	
LG&E I70 - 5	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1195	
LG&E I70 - 6	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1196	
LG&E I70 - 7	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1197	
LG&E I70 - 8	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1198	
LG&E I70 - 9	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1199	
LG&E I70 - 10	General Electric	I-70S	6,752	75	0	0	75	PASS TESTING COMPLETE	1200	
LG&E J4 - 1	Itron	J4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1201	
LG&E J4 - 2	Itron	J4S	1,524	50	0	0	50	PASS TESTING COMPLETE	1202	
LG&E J5 - 1	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1203	
LG&E J5 - 2	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1204	
LG&E J5 - 3	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1205	
LG&E J5 - 4	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1206	
LG&E J5 - 5	Itron	J5S (R200)	10,000	75	0	0	75	PASS TESTING COMPLETE	1207	
LG&E J5 - 6	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1208	
LG&E J5 - 7	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1209	
LG&E J5 - 8	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1210	
LG&E J5 - 9	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1211	
LG&E J5 - 10	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1212	
LG&E J5 - 11	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1213	
LG&E J5 - 12	Itron	J5S	7,776	75	0	0	75	PASS TESTING COMPLETE	1214	
LG&E MQ - 1	Landis + Gyr	MQS	180	15	0	0	15	PASS TESTING COMPLETE	1215	
LG&E MS - 1	Landis + Gyr	MS	8,783	75	0	0	75	PASS TESTING COMPLETE	1216	
LG&E MSII - 1	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1217	
LG&E MSII - 2	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1218	
LG&E MSII - 3	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1219	
LG&E MSII - 4	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1220	
LG&E MSII - 5	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1221	
LG&E MSII - 6	Landis + Gyr	MSII	2,649	50	0	0	50	PASS TESTING COMPLETE	1222	
LG&E MX - 1	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1223	
LG&E MX - 2	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1224	
LG&E MX - 3	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1225	
LG&E MX - 4	Landis + Gyr	MX	2,612	50	0	0	50	PASS TESTING COMPLETE	1226	

TOTALS 383,329 3288 0 0 3288

TOTAL LOTS PASSED: 50
 TOTAL LOTS FAILED: 0
 METERS CANNOT TEST: 0