RECEIVED
FEB 27 2015
PUBLIC SERVICE
COMMISSION

a PPL company

Jeff DeRouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

**Kentucky Utilities Company**
State Regulation and Rates
220 W. Main Street
Louisville, KY 40202
www.lge-ku.com

Martin J. Reinert
Sr. Regulatory Analyst
O 502-627-4173
marty.reinert@lge-ku.com

February 27, 2015

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22,* Case No. 2005-00276

**Annual Report – Kentucky Utilities Company**

Dear Mr. DeRouen:

The Kentucky Public Service Commission ("Commission") originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Kentucky Utilities Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2014 Statistical Sampling Test Results and Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

Marty J. Reinert

Marty J. Reinert

Cc: Kyle Willard, Engineering Director PSC

Attachments

# ATTACHMENT
# A

## Certified Test Results

## LG&E and KU Energy LLC

**5040 Annual Report of New Single Phase Meters**

**Last Data Update:**

**02/12/2015 09:20:08**

## Dynamic Filters

Plant KU
Test Date 12/31/2014

| Plant | Manf. Model Number | Serial Number | Calendar Month/Year | Test Date | As Left Full Load | As Left Light Load | As Left Power Factor | Number of records |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042316 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042317 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042318 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042319 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042320 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042321 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042322 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042323 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042324 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042325 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042326 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042327 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042328 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042329 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042330 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042331 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042332 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042333 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042334 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042335 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042336 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042337 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042338 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042339 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042340 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042341 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042342 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042343 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042344 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042345 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042346 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042347 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042348 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042349 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042350 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042351 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042352 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042353 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042354 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042355 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042356 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042357 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042358 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042359 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042360 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042361 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042362 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042363 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042364 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042365 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042366 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042367 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042368 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042369 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042370 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042371 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042372 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042373 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042374 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042375 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042376 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042377 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042378 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042379 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042380 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042381 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042382 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042383 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042384 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042385 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042386 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042387 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042388 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042389 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042390 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042391 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042392 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2042393 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042394 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042395 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042396 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2042397 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042398 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042399 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042400 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042401 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042402 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042403 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042404 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042405 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042406 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042407 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042408 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042409 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042410 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042411 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042412 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042413 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042414 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042415 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042416 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042417 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042418 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042419 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042420 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042421 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042422 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042423 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042424 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042425 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042426 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042427 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042428 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042429 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042430 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042431 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042432 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042433 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042434 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042435 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042436 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042437 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042438 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042439 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042440 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042441 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042442 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042443 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042444 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042445 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042446 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042447 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042448 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042449 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042450 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042451 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042452 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042453 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042454 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042455 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042456 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042457 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042458 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042459 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042460 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042461 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042462 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042463 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042464 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042465 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042466 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042467 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042468 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042469 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042470 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042471 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042472 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042473 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042474 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042475 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042476 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042477 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042478 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042479 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042480 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042481 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042482 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042483 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042484 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042485 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042486 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042487 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042488 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042489 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042490 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042491 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042492 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042493 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042494 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042495 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042496 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042497 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042498 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042499 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042500 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042501 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042502 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042503 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042504 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042505 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042506 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042507 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042508 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042509 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042510 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042511 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042512 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042513 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042514 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042515 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042516 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042517 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042518 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042519 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042520 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042521 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042522 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042523 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042524 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042525 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042526 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042527 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042528 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042529 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042530 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042531 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042532 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042533 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042534 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042535 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042536 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042537 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042538 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042539 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042540 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042541 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042542 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042543 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042544 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042545 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042546 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042547 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042548 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042549 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042550 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042551 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042552 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042553 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042554 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042555 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042556 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042557 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042558 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042559 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042560 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042561 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042562 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042563 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042564 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042565 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042566 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042567 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042568 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042569 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042570 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042571 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042572 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042573 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042574 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042575 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042576 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042577 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042578 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042579 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042580 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042581 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042582 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042583 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042584 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042585 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042586 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042587 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042588 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042589 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042590 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042591 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042592 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042593 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042594 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042595 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042596 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042597 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2042598 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042599 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042600 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042601 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042602 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042603 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042604 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042605 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042606 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042607 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2042608 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042609 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042610 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042611 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042612 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2042613 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042614 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042615 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042616 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042617 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042618 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042619 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042620 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042621 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042622 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042623 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042624 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042625 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042626 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042627 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042628 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042629 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042630 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042631 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042632 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042633 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042634 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042635 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042636 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042637 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042638 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042639 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042640 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042641 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042642 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042643 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042644 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042645 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042646 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042647 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042648 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042649 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042650 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042651 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042652 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042653 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042654 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042655 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042656 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042657 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042658 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042659 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042660 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042661 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042662 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042663 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042664 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042665 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042666 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042667 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042668 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042669 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042670 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042671 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042672 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042673 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042674 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042675 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042676 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042677 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042678 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042679 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042680 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042681 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042682 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042683 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042684 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042685 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042686 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042687 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042688 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042689 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042690 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042691 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042692 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042693 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042694 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042695 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042696 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042697 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042698 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042699 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042700 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042701 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042702 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042703 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042704 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042705 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042706 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042707 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042708 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042709 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042710 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042711 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042712 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042713 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042714 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042715 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042716 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042717 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042718 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042719 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042720 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042721 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042722 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042723 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042724 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042725 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042726 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042727 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042728 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042729 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042730 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2042731 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042732 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042733 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042734 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042735 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042736 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042737 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042738 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042739 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042740 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042741 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042742 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042743 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042744 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042745 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042746 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042747 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042748 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042749 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042750 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042751 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042752 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042753 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042754 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042755 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042756 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042757 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042758 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042759 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042760 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042761 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042762 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042763 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042764 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042765 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042766 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042767 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042768 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042769 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042770 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042771 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042772 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042773 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042774 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042775 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042776 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042777 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042778 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042779 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042780 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042781 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042782 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042783 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042784 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042785 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042786 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042787 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042788 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042789 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042790 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042791 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042792 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042793 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042794 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042795 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042796 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042797 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042798 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042799 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042800 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042801 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042802 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042803 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042804 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042805 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042806 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042807 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042808 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042809 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042810 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042811 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042812 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042813 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042814 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042815 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042816 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042817 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042818 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042819 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042820 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042821 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042822 | 01/2014 | 01/09/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042823 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042824 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042825 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042826 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042827 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042828 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042829 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042830 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042831 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042832 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042833 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042834 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042835 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042836 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042837 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042838 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042839 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042840 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042841 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042842 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042843 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042844 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042845 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042846 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042847 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042848 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042849 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042850 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042851 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042852 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042853 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042854 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042855 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042856 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042857 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042858 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042859 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042860 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042861 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042862 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042863 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042864 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042865 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042866 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042867 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042868 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042869 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042870 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042871 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042872 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042873 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2042874 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042875 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042876 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042877 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042878 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042879 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042880 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042881 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042882 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042883 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042884 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042885 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042886 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042887 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042888 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042889 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042890 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042891 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042892 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042893 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042894 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042895 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042896 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042897 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042898 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042899 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042900 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042901 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042902 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042903 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042904 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042905 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042906 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042907 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042908 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042909 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042910 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042911 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042912 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042913 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042914 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042915 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042916 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042917 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042918 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042919 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042920 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042921 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042922 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2042923 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042924 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042925 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042926 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042927 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042928 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042929 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042930 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042931 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042932 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042933 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042934 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042935 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042936 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042937 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042938 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042939 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042940 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042941 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042942 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042943 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042944 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042945 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042946 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042947 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042948 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042949 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042950 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042951 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042952 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042953 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042954 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042955 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042956 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2042957 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042958 | 01/2014 | 01/13/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042959 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042960 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042961 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042962 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042963 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2042964 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042965 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042966 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042967 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042968 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042969 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042970 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042971 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042972 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042973 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042974 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2042975 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042976 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042977 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042978 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042979 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042980 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042981 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042982 | 01/2014 | 01/13/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2042983 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042984 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042985 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042986 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042987 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2042988 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2042989 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042990 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042991 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042992 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042993 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042994 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042995 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2042996 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042997 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2042998 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2042999 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043000 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043001 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043002 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043003 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043004 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043005 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043006 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043007 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043008 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043009 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043010 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043011 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043012 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043013 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043014 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043015 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043016 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043017 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043018 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043019 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043020 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043021 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043022 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043023 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043024 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043025 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043026 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043027 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043028 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043029 | 01/2014 | 01/13/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043030 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043031 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043032 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043033 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043034 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043035 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043036 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043037 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043038 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043039 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043040 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043041 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043042 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043043 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043044 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043045 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043046 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043047 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043048 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043049 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043050 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043051 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043052 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043053 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043054 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043055 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043056 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043057 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043058 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043059 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043060 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043061 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043062 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043063 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043064 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043065 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043066 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043067 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043068 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043069 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043070 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043071 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043072 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043073 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043074 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043075 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043076 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043077 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043078 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043079 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043080 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043081 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043082 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043083 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043084 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043085 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043086 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043087 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043088 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043089 | 01/2014 | 01/13/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2043090 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043091 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043092 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043093 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043094 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043095 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043096 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043097 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043098 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043099 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043100 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043101 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043102 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043103 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043104 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043105 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043106 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043107 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043108 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043109 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043110 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043111 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043112 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043113 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043114 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043115 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043116 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043117 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043118 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043119 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043120 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043121 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043122 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043123 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043124 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043125 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043126 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043127 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043128 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043129 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043130 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043131 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043132 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043133 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043134 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043135 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043136 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043137 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043138 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043139 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043140 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043141 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043142 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043143 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043144 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043145 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043146 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043147 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043148 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043149 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043150 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043151 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043152 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043153 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043154 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043155 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043156 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043157 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043158 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043159 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043160 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043161 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043162 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043163 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043164 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043165 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2043166 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043167 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043168 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043169 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043170 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043171 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043172 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043173 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043174 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043175 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043176 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043177 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043178 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043179 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043180 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043181 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043182 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043183 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043184 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043185 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043186 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043187 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043188 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043189 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043190 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043191 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043192 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043193 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043194 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043195 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043196 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043197 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043198 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043199 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043200 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043201 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043202 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043203 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043204 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043205 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043206 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043207 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043208 | 01/2014 | 01/13/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043209 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043210 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043211 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043212 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043213 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043214 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043215 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043216 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043217 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043218 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043219 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043220 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043221 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043222 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043223 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043224 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043225 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043226 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043227 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043228 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043229 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043230 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043231 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043232 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043233 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043234 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043235 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043236 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043237 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043238 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043239 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043240 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043241 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043242 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043243 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043244 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043245 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043246 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043247 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043248 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043249 | 01/2014 | 01/13/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043250 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043251 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043252 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043253 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043254 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043255 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043256 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043257 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043258 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043259 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043260 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043261 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043262 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043263 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043264 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043265 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043266 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043267 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043268 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043269 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043270 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043271 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043272 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043273 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043274 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043275 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043276 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043277 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043278 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043279 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043280 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043281 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043282 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043283 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043284 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043285 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043286 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043287 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043288 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043289 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043290 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043291 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043292 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043293 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043294 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043295 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043296 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043297 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043298 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043299 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043300 | 01/2014 | 01/13/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043301 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043302 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043303 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043304 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043305 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043306 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043307 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043308 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043309 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043310 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043311 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043312 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043313 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043314 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043315 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043316 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043317 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043318 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043319 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043320 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043321 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043322 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043323 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043324 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043325 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043326 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043327 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043328 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043329 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043330 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043331 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043332 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043333 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043334 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043335 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043336 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043337 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043338 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043339 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043340 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043341 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043342 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043343 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043344 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043345 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043346 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043347 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043348 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043349 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043350 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043351 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043352 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043353 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043354 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043355 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043356 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043357 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043358 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043359 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043360 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043361 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043362 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043363 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043364 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043365 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043366 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043367 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043368 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043369 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043370 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043371 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043372 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043373 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043374 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043375 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043376 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043377 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043378 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043379 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043380 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043381 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043382 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043383 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043384 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043385 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043386 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043387 | 01/2014 | 01/13/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043388 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043389 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043390 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043391 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043392 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043393 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043394 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043395 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043396 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043397 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043398 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043399 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043400 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043401 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043402 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043403 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043404 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043405 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043406 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043407 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043408 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043409 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043410 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043411 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043412 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043413 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043414 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043415 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043416 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043417 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043418 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043419 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043420 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043421 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043422 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043423 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043424 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043425 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043426 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043427 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043428 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043429 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043430 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043431 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043432 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043433 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043434 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043435 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043436 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043437 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043438 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043439 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043440 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043441 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043442 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043443 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043444 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043445 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043446 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043447 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043448 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043449 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043450 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043451 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043452 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043453 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043454 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043455 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043456 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043457 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043458 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043459 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043460 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043461 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043462 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043463 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043464 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043465 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043466 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043467 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043468 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043469 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043470 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043471 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043472 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043473 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043474 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043475 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043476 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043477 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043478 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043479 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043480 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043481 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043482 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043483 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043484 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043485 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043486 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043487 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043488 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043489 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043490 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043491 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043492 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043493 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043494 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043495 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043496 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043497 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043498 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043499 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043500 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043501 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043502 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043503 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043504 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043505 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043506 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043507 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043508 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043509 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043510 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043511 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043512 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043513 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043514 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043515 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043516 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043517 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043518 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043519 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043520 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043521 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043522 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043523 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043524 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043525 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043526 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043527 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043528 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043529 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043530 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043531 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043532 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043533 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043534 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043535 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043536 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043537 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043538 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043539 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043540 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043541 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043542 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043543 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043544 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043545 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043546 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043547 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043548 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043549 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043550 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043551 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043552 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043553 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043554 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043555 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043556 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043557 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043558 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043559 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043560 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043561 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043562 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043563 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043564 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043565 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043566 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043567 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043568 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043569 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043570 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043571 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043572 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043573 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043574 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043575 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043576 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043577 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043578 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043579 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043580 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043581 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043582 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043583 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043584 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043585 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043586 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043587 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043588 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043589 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043590 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043591 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043592 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043593 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043594 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043595 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043596 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043597 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043598 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043599 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043600 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043601 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043602 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043603 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043604 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043605 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043606 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043607 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043608 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043609 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043610 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043611 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043612 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043613 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043614 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043615 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043616 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043617 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043618 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043619 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043620 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043621 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043622 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043623 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043624 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043625 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043626 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043627 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043628 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043629 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043630 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043631 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043632 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043633 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043634 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043635 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043636 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043637 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043638 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043639 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043640 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043641 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043642 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043643 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043644 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043645 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043646 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043647 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043648 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043649 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043650 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043651 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043652 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043653 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043654 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043655 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043656 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043657 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043658 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043659 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043660 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043661 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043662 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043663 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043664 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043665 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043666 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043667 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043668 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043669 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043670 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043671 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043672 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043673 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043674 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043675 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043676 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043677 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043678 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043679 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043680 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043681 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043682 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043683 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043684 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043685 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043686 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043687 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043688 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043689 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043690 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043691 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043692 | 01/2014 | 01/13/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043693 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043694 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043695 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043696 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043697 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043698 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043699 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043700 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043701 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043702 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043703 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043704 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043705 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043706 | 01/2014 | 01/13/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043707 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043708 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043709 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043710 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043711 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043712 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043713 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043714 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043715 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043716 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043717 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043718 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043719 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043720 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043721 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043722 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043723 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043724 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043725 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043726 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043727 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043728 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043729 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043730 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043731 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043732 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043733 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043734 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043735 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043736 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043737 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043738 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043739 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043740 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043741 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043742 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043743 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043744 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043745 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043746 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043747 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043748 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043749 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043750 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043751 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043752 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043753 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043754 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043755 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043756 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043757 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043758 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043759 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043760 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043761 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043762 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043763 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043764 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043765 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043766 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043767 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043768 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043769 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043770 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043771 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043772 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043773 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043774 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043775 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043776 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043777 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043778 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043779 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043780 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043781 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043782 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043783 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043784 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043785 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043786 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043787 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043788 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043789 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2043790 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2043791 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043792 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043793 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043794 | 01/2014 | 01/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043795 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043796 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043797 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043798 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043799 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043800 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043801 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043802 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043803 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043804 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043805 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043806 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043807 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043808 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043809 | 01/2014 | 01/09/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043810 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043811 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043812 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043813 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043814 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043815 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043816 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043817 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043818 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043819 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043820 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043821 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043822 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043823 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043824 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043825 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043826 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043827 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043828 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043829 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043830 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043831 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043832 | 01/2014 | 01/13/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043833 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043834 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043835 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043836 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043837 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043838 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043839 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043840 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043841 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043842 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043843 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043844 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043845 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043846 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043847 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043848 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043849 | 01/2014 | 01/09/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043850 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043851 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043852 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043853 | 01/2014 | 01/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043854 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043855 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043856 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043857 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043858 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043859 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043860 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043861 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043862 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043863 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043864 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043865 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043866 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043867 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043868 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043869 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043870 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043871 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043872 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043873 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043874 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043875 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043876 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043877 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043878 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043879 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043880 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043881 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043882 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043883 | 01/2014 | 01/13/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043884 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043885 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043886 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043887 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043888 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043889 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043890 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043891 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043892 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043893 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043894 | 01/2014 | 01/13/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043895 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043896 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043897 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043898 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043899 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043900 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043901 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043902 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043903 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2043904 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043905 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043906 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043907 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043908 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043909 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043910 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043911 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043912 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043913 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043914 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043915 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043916 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043917 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043918 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043919 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043920 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043921 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043922 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043923 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043924 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043925 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043926 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043927 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043928 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043929 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043930 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043931 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043932 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043933 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043934 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043935 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043936 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043937 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2043938 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2043939 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043940 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043941 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043942 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043943 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043944 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043945 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043946 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043947 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043948 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043949 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043950 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043951 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043952 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043953 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043954 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043955 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043956 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043957 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043958 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043959 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043960 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043961 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043962 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043963 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043964 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043965 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043966 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043967 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043968 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043969 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043970 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043971 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043972 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043973 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043974 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043975 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043976 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043977 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043978 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043979 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043980 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043981 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043982 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043983 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043984 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043985 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043986 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043987 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043988 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043989 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043990 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043991 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043992 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043993 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2043994 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2043995 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2043996 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2043997 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2043998 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2043999 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044000 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044001 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044002 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044003 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044004 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044005 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044006 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044007 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044008 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044009 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044010 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044011 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044012 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044013 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044014 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044015 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044016 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044017 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044018 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044019 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044020 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044021 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044022 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044023 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044024 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044025 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044026 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044027 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044028 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044029 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044030 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044031 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044032 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044033 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044034 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044035 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044036 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044037 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044038 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044039 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044040 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044041 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044042 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044043 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044044 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044045 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044046 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044047 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044048 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044049 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044050 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044051 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044052 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044053 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044054 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044055 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044056 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044057 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044058 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044059 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044060 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044061 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044062 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044063 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044064 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044065 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044066 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044067 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044068 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044069 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044070 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044071 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2044072 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044073 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044074 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044075 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044076 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044077 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044078 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044079 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044080 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044081 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044082 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044083 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2044084 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044085 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044086 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044087 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044088 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044089 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044090 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044091 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044092 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044093 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044094 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044095 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044096 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044097 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044098 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044099 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044100 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044101 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044102 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044103 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044104 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044105 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044106 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044107 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044108 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044109 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044110 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044111 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044112 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044113 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044114 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044115 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044116 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044117 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044118 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044119 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044120 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044121 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044122 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044123 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044124 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044125 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044126 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044127 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044128 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044129 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044130 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044131 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044132 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044133 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044134 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044135 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044136 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044137 | 01/2014 | 01/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044138 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044139 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044140 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044141 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044142 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044143 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044144 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044145 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044146 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044147 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044148 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044149 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044150 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044151 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044152 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044153 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044154 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044155 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044156 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044157 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044158 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044159 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044160 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044161 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044162 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044163 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044164 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044165 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044166 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044167 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044168 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044169 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044170 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044171 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044172 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044173 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044174 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044175 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044176 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044177 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044178 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044179 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044180 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044181 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044182 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044183 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044184 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044185 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044186 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044187 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044188 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044189 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044190 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044191 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044192 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044193 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044194 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044195 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044196 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044197 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044198 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044199 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044200 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044201 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044202 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044203 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044204 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044205 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044206 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044207 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044208 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044209 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044210 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044211 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044212 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044213 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044214 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044215 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044216 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044217 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044218 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044219 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044220 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044221 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044222 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044223 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044224 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044225 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044226 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044227 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044228 | 01/2014 | 01/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044229 | 01/2014 | 01/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044230 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044231 | 01/2014 | 01/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044232 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044233 | 01/2014 | 01/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044234 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044235 | 01/2014 | 01/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044644 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044645 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044646 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044647 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044648 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044649 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044650 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044651 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044652 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044653 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044654 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044655 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044656 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044657 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044658 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044659 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044660 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044661 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044662 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044663 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044664 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044665 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044666 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044667 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044668 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044669 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044670 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044671 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044672 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044673 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044674 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044675 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044676 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044677 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044678 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044679 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044680 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044681 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044682 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044683 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044684 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044685 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044686 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044687 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044688 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044689 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2044690 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044691 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044692 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044693 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044694 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044695 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044696 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044697 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044698 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044699 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044700 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044701 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044702 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044703 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044704 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044705 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044706 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044707 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044708 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044709 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044710 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044711 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044712 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044713 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044714 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044715 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044716 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044717 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044718 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044719 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044720 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044721 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044722 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044723 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044724 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044725 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044726 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044727 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2044728 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044729 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044730 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044731 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044732 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044733 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044734 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044735 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044736 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044737 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044738 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044739 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044740 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044741 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044742 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044743 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044744 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044745 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044746 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044747 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044748 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044749 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044750 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044751 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044752 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044753 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044754 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044755 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044756 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044757 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044758 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044759 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044760 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044761 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044762 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044763 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044764 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044765 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044766 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044767 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044768 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044769 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044770 | 04/2014 | 04/14/2014 | 99.900 | 99.900 | 99.9 | 1 |
| KU | C1S | 2044771 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044772 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044773 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044774 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044775 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044776 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044777 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044778 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044779 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044780 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044781 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044782 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044783 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044784 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044785 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044786 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044787 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2044788 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044789 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044790 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044791 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044792 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044793 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044794 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044795 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044796 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044797 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044798 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044799 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044800 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044801 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044802 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044803 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044804 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044805 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044806 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044807 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044808 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044809 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044810 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044811 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044812 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044813 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044814 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044815 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044816 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2044817 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044818 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044819 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044820 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044821 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044822 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044823 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044824 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044825 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044826 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2044827 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044828 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044829 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044830 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044831 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044832 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044833 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044834 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044835 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044836 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044837 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044838 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044839 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044840 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044841 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044842 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044843 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044844 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044845 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044846 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044847 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044848 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044849 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044850 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044851 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044852 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044853 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044854 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044855 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044856 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044857 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044858 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044859 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044860 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044861 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044862 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044863 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044864 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044865 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044866 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2044867 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044868 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044869 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044870 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044871 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044872 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044873 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044874 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044875 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044876 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044877 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044878 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044879 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044880 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044881 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044882 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044883 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044884 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044885 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044886 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044887 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044888 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044889 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044890 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044891 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044892 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044893 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044894 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044895 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044896 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044897 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044898 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044899 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044900 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044901 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044902 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044903 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044904 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044905 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044906 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044907 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044908 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044909 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2044910 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044911 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044912 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044913 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044914 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2044915 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044916 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044917 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044918 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044919 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044920 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2044921 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044922 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044923 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044924 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044925 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044926 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044927 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044928 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044929 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044930 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044931 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044932 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044933 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044934 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044935 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044936 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044937 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044938 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044939 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2044940 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044941 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044942 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044943 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044944 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044945 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044946 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044947 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044948 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044949 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044950 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044951 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044952 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044953 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2044954 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044955 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044956 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2044957 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2044958 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044959 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044960 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044961 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044962 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044963 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044964 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044965 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044966 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044967 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044968 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044969 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044970 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044971 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044972 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044973 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044974 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044975 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044976 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044977 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044978 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044979 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044980 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044981 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044982 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2044983 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044984 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044985 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044986 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2044987 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044988 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2044989 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044990 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044991 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044992 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044993 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2044994 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044995 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2044996 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2044997 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2044998 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2044999 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045000 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045001 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045002 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045003 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045004 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045005 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045006 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045007 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045008 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045009 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045010 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045011 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045012 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045013 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045014 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045015 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045016 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045017 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045018 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045019 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045020 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045021 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045022 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045023 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045024 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045025 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045026 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045027 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045028 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045029 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045030 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045031 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045032 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045033 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045034 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045035 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045036 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045037 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045038 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045039 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045040 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045041 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045042 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045043 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045044 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045045 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045046 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045047 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045048 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045049 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045050 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045051 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045052 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045053 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045054 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045055 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045056 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045057 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045058 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045059 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045060 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045061 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045062 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045063 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045064 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045065 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045066 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045067 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045068 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045069 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045070 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045071 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045072 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045073 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045074 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045075 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045076 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045077 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045078 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045079 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045080 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045081 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045082 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045083 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045084 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045085 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045086 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045087 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045088 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045089 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045090 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045091 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045092 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045093 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045094 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045095 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045096 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045097 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045098 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045099 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045100 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045101 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045102 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045103 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045104 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045105 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045106 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045107 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045108 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045109 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045110 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045111 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045112 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045113 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045114 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045115 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045116 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045117 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045118 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045119 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045120 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045121 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045122 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045123 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045124 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045125 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045126 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045127 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045128 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045129 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045130 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045131 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045132 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045133 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045134 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045135 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045136 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045137 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045138 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045139 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045140 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045141 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045142 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045143 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045144 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045145 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045146 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045147 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045148 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045149 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045150 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045151 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045152 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045153 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045154 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045155 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045156 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045157 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045158 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045159 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045160 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045161 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045162 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045163 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045164 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045165 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045166 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045167 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045168 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045169 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045170 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045171 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045172 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045173 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045174 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045175 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045176 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045177 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045178 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045179 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045180 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045181 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045182 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045183 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045184 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045185 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045186 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045187 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045188 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045189 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045190 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045191 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045192 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045193 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045194 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045195 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045196 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045197 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045198 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045199 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045200 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045201 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045202 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045203 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045204 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045205 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045206 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045207 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045208 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045209 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045210 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045211 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045212 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045213 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045214 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045215 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045216 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045217 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045218 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045219 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045220 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045221 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045222 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045223 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045224 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045225 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045226 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045227 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045228 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045229 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045230 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045231 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045232 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045233 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045234 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045235 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045236 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045237 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045238 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045239 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045240 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045241 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045242 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045243 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045244 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045245 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045246 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045247 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045248 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045249 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045250 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045251 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045252 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045253 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045254 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045255 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045256 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045257 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045258 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045259 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045260 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045261 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045262 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045263 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045264 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045265 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045266 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045267 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045268 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045269 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045270 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045271 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045272 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045273 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045274 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045275 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045276 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045277 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045278 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045279 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045280 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045281 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045282 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045283 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045284 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2045285 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045286 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045287 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045288 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045289 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045290 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045291 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045292 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045293 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045294 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045295 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045296 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045297 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045298 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045299 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045300 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045301 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045302 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045303 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045304 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045305 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045306 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045307 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045308 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045309 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045310 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045311 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045312 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045313 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045314 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045315 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045316 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045317 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045318 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045319 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045320 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045321 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045322 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045323 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045324 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045325 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045326 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045327 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045328 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045329 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045330 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045331 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045332 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045333 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045334 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045335 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045336 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045337 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045338 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045339 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045340 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045341 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045342 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045343 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045344 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045345 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045346 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045347 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045348 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045349 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045350 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045351 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045352 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045353 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045354 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045355 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045356 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045357 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045358 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045359 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045360 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045361 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045362 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045363 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045364 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045365 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045366 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045367 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045368 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045369 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045370 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045371 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045372 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045373 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045374 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045375 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2045376 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045377 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045378 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045379 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045380 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045381 | 04/2014 | 04/14/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045382 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045383 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045384 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045385 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045386 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045387 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2045388 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045389 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045390 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045391 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045392 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045393 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045394 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045395 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045396 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045397 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045398 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045399 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045400 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045401 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045402 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045403 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045404 | 04/2014 | 04/14/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045405 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045406 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045407 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045408 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045409 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045410 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045411 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045412 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045413 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045414 | 04/2014 | 04/14/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045415 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045416 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045417 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045418 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045419 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045420 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045421 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045422 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045423 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045424 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045425 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045426 | 04/2014 | 04/14/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045427 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045428 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045429 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045430 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045431 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045432 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045433 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045434 | 04/2014 | 04/14/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045435 | 04/2014 | 04/14/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045436 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045437 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045438 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045439 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045440 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045441 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045442 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045443 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045444 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045445 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045446 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045447 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045448 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045449 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045450 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045451 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045452 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045453 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045454 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045455 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045456 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045457 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045458 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045459 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045460 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045461 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045462 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045463 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045464 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045465 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045466 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045467 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045468 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045469 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045470 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045471 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045472 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045473 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045474 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045475 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045476 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045477 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045478 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045479 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045480 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045481 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045482 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045483 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045484 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045485 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045486 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045487 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045488 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045489 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045490 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045491 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045492 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045493 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045494 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045495 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045496 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045497 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045498 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045499 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045500 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045501 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045502 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045503 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045504 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045505 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045506 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045507 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045508 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045509 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045510 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045511 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045512 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045513 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045514 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045515 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045516 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045517 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045518 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045519 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045520 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045521 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045522 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045523 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045524 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045525 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045526 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045527 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045528 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045529 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045530 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045531 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045532 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045533 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045534 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045535 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045536 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045537 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045538 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045539 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045540 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045541 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045542 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045543 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045544 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045545 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045546 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045547 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045548 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045549 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045550 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045551 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045552 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045553 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045554 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045555 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045556 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045557 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045558 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045559 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045560 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045561 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045562 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045563 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045564 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045565 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045566 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045567 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045568 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045569 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045570 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045571 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045572 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045573 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045574 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045575 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045576 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045577 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045578 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045579 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045580 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045581 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045582 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045583 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045584 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045585 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045586 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045587 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045588 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045589 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045590 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045591 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045592 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045593 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045594 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045595 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045596 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045597 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045598 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045599 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045600 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045601 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045602 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045603 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045604 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045605 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045606 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045607 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045608 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045609 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045610 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045611 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045612 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045613 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045614 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045615 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045616 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045617 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045618 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045619 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045620 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045621 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045622 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045623 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045624 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045625 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045626 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045627 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045628 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045629 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045630 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045631 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045632 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045633 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045634 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045635 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045636 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045637 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045638 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045639 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045640 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045641 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045642 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045643 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045644 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045645 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045646 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045647 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045648 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045649 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045650 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045651 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045652 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045653 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045654 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045655 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045656 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045657 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045658 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045659 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045660 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045661 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045662 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045663 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045664 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045665 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045666 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045667 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045668 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045669 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045670 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045671 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045672 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045673 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045674 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045675 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045676 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045677 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045678 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045679 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045680 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045681 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045682 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045683 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045684 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045685 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045686 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045687 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045688 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045689 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045690 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045691 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045692 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045693 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045694 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045695 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045696 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045697 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045698 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045699 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045700 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045701 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045702 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045703 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045704 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045705 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045706 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045707 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045708 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045709 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045710 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045711 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045712 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045713 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045714 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045715 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045716 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045717 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045718 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045719 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045720 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045721 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045722 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045723 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045724 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045725 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045726 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045727 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045728 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045729 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045730 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045731 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045732 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045733 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045734 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045735 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045736 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045737 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045738 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045739 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045740 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045741 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2045742 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045743 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045744 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045745 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045746 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045747 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045748 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045749 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045750 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045751 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045752 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045753 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045754 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045755 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045756 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045757 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045758 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045759 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045760 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045761 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045762 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045763 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045764 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045765 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045766 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045767 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045768 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045769 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045770 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045771 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045772 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045773 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045774 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045775 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045776 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045777 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045778 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045779 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045780 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045781 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045782 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045783 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045784 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045785 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045786 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045787 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045788 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045789 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045790 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045791 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045792 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045793 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045794 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045795 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045796 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045797 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045798 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045799 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045800 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045801 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045802 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045803 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045804 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045805 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045806 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045807 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045808 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045809 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045810 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045811 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045812 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045813 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045814 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045815 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045816 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045817 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045818 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045819 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045820 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045821 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045822 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045823 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045824 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045825 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045826 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045827 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045828 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045829 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045830 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045831 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045832 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045833 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045834 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045835 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045836 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045837 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045838 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045839 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045840 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045841 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045842 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045843 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045844 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045845 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045846 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045847 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045848 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045849 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045850 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045851 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045852 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045853 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045854 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045855 | 04/2014 | 04/08/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045856 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045857 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045858 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045859 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045860 | 04/2014 | 04/08/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045861 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045862 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045863 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045864 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045865 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045866 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045867 | 04/2014 | 04/08/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2045868 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045869 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045870 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045871 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045872 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045873 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045874 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045875 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045876 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045877 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045878 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045879 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045880 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045881 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045882 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045883 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045884 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045885 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045886 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045887 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045888 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045889 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045890 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045891 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045892 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2045893 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045894 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045895 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045896 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045897 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045898 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045899 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045900 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045901 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045902 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045903 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045904 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045905 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045906 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045907 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045908 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045909 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045910 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045911 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045912 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045913 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045914 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045915 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045916 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045917 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045918 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045919 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045920 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045921 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045922 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045923 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045924 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045925 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045926 | 04/2014 | 04/07/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045927 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045928 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045929 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045930 | 04/2014 | 04/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045931 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045932 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045933 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045934 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045935 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045936 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045937 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045938 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045939 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045940 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045941 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2045942 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045943 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045944 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045945 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045946 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2045947 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045948 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045949 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045950 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045951 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045952 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045953 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2045954 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045955 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045956 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045957 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045958 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045959 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045960 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045961 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045962 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045963 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045964 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045965 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045966 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045967 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045968 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045969 | 04/2014 | 04/08/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045970 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045971 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045972 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045973 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045974 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2045975 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045976 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045977 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045978 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045979 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045980 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045981 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045982 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045983 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045984 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045985 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2045986 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045987 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045988 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045989 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045990 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045991 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045992 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045993 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045994 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045995 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2045996 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2045997 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2045998 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2045999 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046000 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046001 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046002 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046003 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046004 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046005 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046006 | 04/2014 | 04/08/2014 | 99.900 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046007 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046008 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046009 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046010 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046011 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046012 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046013 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046014 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046015 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046016 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046017 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046018 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046019 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046020 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046021 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046022 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046023 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046024 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046025 | 04/2014 | 04/10/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046026 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046027 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046028 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046029 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046030 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046031 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046032 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046033 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046034 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046035 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046036 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046037 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046038 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046039 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046040 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046041 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046042 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046043 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046044 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046045 | 04/2014 | 04/07/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046046 | 04/2014 | 04/07/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046047 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046048 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046049 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046050 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046051 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046052 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046053 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046054 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046055 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046056 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046057 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046058 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046059 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046060 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046061 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046062 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046063 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046064 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046065 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046066 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046067 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046068 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046069 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046070 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046071 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046072 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046073 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046074 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046075 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046076 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046077 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046078 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046079 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046080 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046081 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046082 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046083 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046084 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046085 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046086 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046087 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046088 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046089 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046090 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046091 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046092 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046093 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046094 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046095 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046096 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046097 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046098 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046099 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046100 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046101 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046102 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046103 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046104 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046105 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046106 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046107 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046108 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046109 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046110 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046111 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046112 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046113 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046114 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046115 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046116 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046117 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046118 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046119 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046120 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046121 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046122 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046123 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046124 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046125 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046126 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046127 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046128 | 04/2014 | 04/07/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046129 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046130 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046131 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046132 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046133 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046134 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046135 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046136 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046137 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046138 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046139 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046140 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046141 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046142 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046143 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046144 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046145 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046146 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046147 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046148 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046149 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046150 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046151 | 04/2014 | 04/08/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046152 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046153 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046154 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046155 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046156 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046157 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046158 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046159 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046160 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046161 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046162 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046163 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046164 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046165 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046166 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046167 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046168 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046169 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046170 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046171 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046172 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046173 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046174 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046175 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046176 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046177 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046178 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046179 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046180 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046181 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046182 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046183 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046184 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046185 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046186 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046187 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046188 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046189 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046190 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046191 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046192 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046193 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046194 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046195 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046196 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046197 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046198 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046199 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046200 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046201 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046202 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046203 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046204 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046205 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046206 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046207 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046208 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046209 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046210 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046211 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046212 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046213 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046214 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046215 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046216 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046217 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046218 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046219 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046220 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046221 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046222 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046223 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046224 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046225 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046226 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046227 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046228 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046229 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046230 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046231 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046232 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046233 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046234 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046235 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046236 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046237 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046238 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046239 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046240 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046241 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046242 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046243 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046244 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046245 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046246 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046247 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046248 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046249 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046250 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046251 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046252 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046253 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046254 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046255 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046256 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046257 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046258 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046259 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046260 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046261 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046262 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046263 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046264 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046265 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046266 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046267 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046268 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046269 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046270 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046271 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046272 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046273 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046274 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046275 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046276 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046277 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046278 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046279 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046280 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046281 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046282 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046283 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046284 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046285 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046286 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046287 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046288 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046289 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046290 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046291 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046292 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046293 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046294 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046295 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046296 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046297 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046298 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046299 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046300 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046301 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046302 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046303 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046304 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046305 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046306 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046307 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046308 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046309 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046310 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046311 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046312 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.2 | 1 |
| KU | C1S | 2046313 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046314 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046315 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046316 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046317 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046318 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046319 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046320 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046321 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046322 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046323 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046324 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046325 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046326 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046327 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046328 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046329 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046330 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046331 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046332 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046333 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046334 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046335 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046336 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046337 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046338 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046339 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046340 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046341 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046342 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046343 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046344 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046345 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046346 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046347 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046348 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046349 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046350 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046351 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046352 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046353 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046354 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046355 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046356 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046357 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046358 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046359 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046360 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046361 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046362 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046363 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046364 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046365 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046366 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046367 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046368 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046369 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046370 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046371 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046372 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046373 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046374 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046375 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046376 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046377 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046378 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046379 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046380 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046381 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046382 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046383 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046384 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046385 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046386 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046387 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046388 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046389 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046390 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046391 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046392 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046393 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046394 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046395 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046396 | 04/2014 | 04/08/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046397 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046398 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046399 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046400 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046401 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046402 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046403 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046404 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046405 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046406 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046407 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046408 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046409 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046410 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046411 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046412 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046413 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046414 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046415 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046416 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046417 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046418 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046419 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046420 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046421 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046422 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046423 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046424 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046425 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046426 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046427 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046428 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046429 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046430 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046431 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046432 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046433 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046434 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046435 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046436 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046437 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046438 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046439 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046440 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046441 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046442 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046443 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046444 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046445 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046446 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046447 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046448 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046449 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046450 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046451 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046452 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046453 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046454 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046455 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046456 | 04/2014 | 04/11/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046457 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046458 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046459 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046460 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046461 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046462 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046463 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046464 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046465 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046466 | 04/2014 | 04/07/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046467 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046468 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046469 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046470 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046471 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046472 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046473 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046474 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046475 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046476 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046477 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046478 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046479 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046480 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046481 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046482 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046483 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046484 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046485 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046486 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046487 | 04/2014 | 04/08/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046488 | 04/2014 | 04/08/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046489 | 04/2014 | 04/08/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046490 | 04/2014 | 04/08/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046491 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046492 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046493 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046494 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046495 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046496 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046497 | 04/2014 | 04/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046498 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046499 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046500 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046501 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046502 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046503 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046504 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046505 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046506 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046507 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046508 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046509 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046510 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046511 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046512 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046513 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046514 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046515 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046516 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046517 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046518 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046519 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046520 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046521 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046522 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046523 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046524 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046525 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046526 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046527 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046528 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046529 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046530 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046531 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046532 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046533 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046534 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046535 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046536 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046537 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046538 | 04/2014 | 04/11/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046539 | 04/2014 | 04/11/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046540 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046541 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046542 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046543 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046544 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046545 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046546 | 04/2014 | 04/11/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046547 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046548 | 04/2014 | 04/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046549 | 04/2014 | 04/11/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046550 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046551 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046552 | 04/2014 | 04/11/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046553 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046554 | 04/2014 | 04/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046555 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046556 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046557 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046558 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046559 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046560 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046561 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046562 | 04/2014 | 04/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046563 | 04/2014 | 04/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046564 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046565 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046566 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046567 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046568 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046569 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046570 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046571 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046572 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046573 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046574 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046575 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046576 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046577 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046578 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046579 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046580 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046581 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046582 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046583 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046584 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046585 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046586 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046587 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046588 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046589 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046590 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046591 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046592 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046593 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046594 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046595 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046596 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046597 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046598 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046599 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046600 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046601 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046602 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046603 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046604 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046605 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046606 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046607 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046608 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046609 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046610 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046611 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046612 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046613 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046614 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046615 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046616 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046617 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046618 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046619 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046620 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046621 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046622 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046623 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046624 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046625 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046626 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046627 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046628 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046629 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046630 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046631 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046632 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046633 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046634 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046635 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046636 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046637 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046638 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046639 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046640 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046641 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046642 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046643 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046644 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046645 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046646 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046647 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046648 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046649 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046650 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046651 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046652 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046653 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046654 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046655 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046656 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046657 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046658 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046659 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046660 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046661 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046662 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046663 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046664 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046665 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046666 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046667 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046668 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046669 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046670 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046671 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046672 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046673 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046674 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046675 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046676 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046677 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046678 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046679 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046680 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046681 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046682 | 06/2014 | 05/07/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046683 | 06/2014 | 05/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046684 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046685 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046686 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046687 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046688 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046689 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046690 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046691 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046692 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046693 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046694 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046695 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046696 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046697 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046698 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046699 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046700 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046701 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046702 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046703 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046704 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046705 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046706 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046707 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046708 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2046709 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046710 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046711 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046712 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046713 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046714 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046715 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046716 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046717 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046718 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046719 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046720 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046721 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046722 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046723 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046724 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046725 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046726 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046727 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046728 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046729 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046730 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046731 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046732 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046733 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046734 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046735 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046736 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046737 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046738 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046739 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046740 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046741 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046742 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046743 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046744 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046745 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046746 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046747 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046748 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046749 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046750 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046751 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046752 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046753 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046754 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046755 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046756 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046757 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046758 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046759 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046760 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046761 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046762 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046763 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046764 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046765 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046766 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046767 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046768 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046769 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046770 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046771 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046772 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046773 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046774 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046775 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046776 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046777 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046778 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046779 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046780 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046781 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046782 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046783 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046784 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046785 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046786 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046787 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046788 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046789 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046790 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046791 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046792 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046793 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046794 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046795 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046796 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046797 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046798 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046799 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046800 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046801 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046802 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046803 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046804 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046805 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046806 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046807 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046808 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046809 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046810 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046811 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046812 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046813 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046814 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046815 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046816 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046817 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046818 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046819 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046820 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046821 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046822 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046823 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046824 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046825 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046826 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046827 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046828 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046829 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046830 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046831 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046832 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046833 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046834 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046835 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046836 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046837 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046838 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046839 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046840 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046841 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046842 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046843 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046844 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046845 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046846 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046847 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046848 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046849 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046850 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046851 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046852 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046853 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046854 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046855 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 99.9 | 1 |
| KU | C1S | 2046856 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046857 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046858 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046859 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046860 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046861 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046862 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2046863 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046864 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046865 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046866 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046867 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046868 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046869 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046870 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046871 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046872 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046873 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046874 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046875 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046876 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046877 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046878 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046879 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046880 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046881 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046882 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046883 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046884 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046885 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046886 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046887 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046888 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046889 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046890 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046891 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046892 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046893 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046894 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046895 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046896 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046897 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046898 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046899 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046900 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046901 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046902 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046903 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046904 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046905 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046906 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046907 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046908 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046909 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046910 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046911 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046912 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046913 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046914 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046915 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046916 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2046917 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046918 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046919 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046920 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046921 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046922 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046923 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2046924 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046925 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2046926 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046927 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046928 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2046929 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046930 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046931 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046932 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046933 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046934 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046935 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046936 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046937 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046938 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046939 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046940 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046941 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046942 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046943 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046944 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046945 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046946 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046947 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046948 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046949 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046950 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046951 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046952 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046953 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046954 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046955 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046956 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046957 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046958 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046959 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046960 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046961 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046962 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046963 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046964 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046965 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046966 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046967 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046968 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046969 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046970 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046971 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046972 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046973 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046974 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046975 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046976 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046977 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046978 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046979 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046980 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046981 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046982 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046983 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046984 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046985 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046986 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046987 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046988 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046989 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046990 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046991 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046992 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2046993 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046994 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046995 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2046996 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2046997 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2046998 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2046999 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047000 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047001 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047002 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047003 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047004 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047005 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047006 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047007 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047008 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047009 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047010 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047011 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047012 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047013 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047014 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047015 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047016 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047017 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047018 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047019 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047020 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047021 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047022 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047023 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047024 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047025 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047026 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047027 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047028 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047029 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047030 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047031 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047032 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047033 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047034 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047035 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047036 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047037 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047038 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047039 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047040 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047041 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047042 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047043 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047044 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047045 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047046 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047047 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047048 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047049 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047050 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047051 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047052 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047053 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047054 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047055 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047056 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047057 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047058 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047059 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047060 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047061 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047062 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047063 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047064 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047065 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047066 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047067 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047068 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047069 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047070 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047071 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047072 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047073 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047074 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047075 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047076 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047077 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047078 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047079 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047080 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047081 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047082 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047083 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047084 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047085 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047086 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047087 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047088 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047089 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047090 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047091 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047092 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047093 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047094 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047095 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047096 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047097 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047098 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047099 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047100 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047101 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047102 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047103 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047104 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047105 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047106 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047107 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047108 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047109 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047110 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047111 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047112 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047113 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047114 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047115 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047116 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047117 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047118 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047119 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047120 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047121 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047122 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047123 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047124 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047125 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047126 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047127 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047128 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047129 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047130 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047131 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047132 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047133 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047134 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047135 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047136 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047137 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047138 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047139 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047140 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047141 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047142 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047143 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047144 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047145 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047146 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047147 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047148 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047149 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047150 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047151 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047152 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047153 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047154 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047155 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047156 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047157 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047158 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047159 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047160 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047161 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047162 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047163 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047164 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047165 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047166 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047167 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047168 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047169 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047170 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047171 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047172 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047173 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047174 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047175 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047176 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047177 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047178 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047179 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047180 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047181 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047182 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047183 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047184 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047185 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047186 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047187 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047188 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047189 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047190 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047191 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047192 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047193 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047194 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047195 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047196 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047197 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047198 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047199 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047200 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047201 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047202 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047203 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047204 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047205 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047206 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047207 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047208 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047209 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047210 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047211 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047212 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047213 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047214 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047215 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047216 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047217 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047218 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047219 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047220 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047221 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047222 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047223 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047224 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047225 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047226 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047227 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047228 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047229 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047230 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047231 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047232 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047233 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047234 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047235 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047236 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047237 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047238 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047239 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047240 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047241 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047242 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047243 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047244 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047245 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047246 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047247 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047248 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047249 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047250 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047251 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047252 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047253 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047254 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047255 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047256 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047257 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047258 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047259 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047260 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047261 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047262 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047263 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047264 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047265 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047266 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047267 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047268 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047269 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047270 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047271 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047272 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047273 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047274 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047275 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047276 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047277 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047278 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047279 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047280 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047281 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047282 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047283 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047284 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047285 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047286 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047287 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047288 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047289 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047290 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047291 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047292 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047293 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047294 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047295 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047296 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047297 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047298 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047299 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047300 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047301 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047302 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047303 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047304 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047305 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047306 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047307 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047308 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047309 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047310 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047311 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047312 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047313 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047314 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047315 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047316 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047317 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047318 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047319 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047320 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047321 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047322 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047323 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047324 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047325 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047326 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047327 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047328 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047329 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047330 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047331 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047332 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047333 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047334 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047335 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047336 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047337 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047338 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047339 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047340 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047341 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047342 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047343 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047344 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047345 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047346 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047347 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047348 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047349 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047350 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047351 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047352 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047353 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047354 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047355 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047356 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047357 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047358 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047359 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047360 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047361 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047362 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047363 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047364 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047365 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047366 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047367 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047368 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047369 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047370 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047371 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047372 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047373 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047374 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047375 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047376 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047377 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047378 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047379 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047380 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047381 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047382 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047383 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047384 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047385 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047386 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047387 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047388 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047389 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047390 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047391 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047392 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047393 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047394 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047395 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047396 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047397 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047398 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047399 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047400 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047401 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047402 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047403 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047404 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047405 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047406 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047407 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047408 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047409 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047410 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047411 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047412 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047413 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047414 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047415 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047416 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047417 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047418 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047419 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047420 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047421 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047422 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047423 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047424 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047425 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047426 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047427 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047428 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047429 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047430 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047431 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047432 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047433 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047434 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 99.9 | 1 |
| KU | C1S | 2047435 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047436 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047437 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047438 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047439 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047440 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047441 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047442 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047443 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047444 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047445 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047446 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047447 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047448 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047449 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047450 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047451 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047452 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047453 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047454 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047455 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047456 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047457 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047458 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047459 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047460 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047461 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047462 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047463 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047464 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047465 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047466 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047467 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047468 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047469 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047470 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047471 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047472 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047473 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047474 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047475 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047476 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047477 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047478 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047479 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047480 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047481 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047482 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047483 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047484 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047485 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047486 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047487 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047488 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047489 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047490 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047491 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047492 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047493 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047494 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047495 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047496 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047497 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047498 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047499 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047500 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047501 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047502 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047503 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047504 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047505 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047506 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047507 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047508 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047509 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047510 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047511 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047512 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047513 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047514 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047515 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047516 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047517 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047518 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047519 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047520 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047521 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047522 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047523 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047524 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047525 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047526 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047527 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047528 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047529 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047530 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047531 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047532 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047533 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047534 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047535 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047536 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047537 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047538 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047539 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047540 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047541 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047542 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047543 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047544 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047545 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047546 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047547 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047548 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047549 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047550 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047551 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047552 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047553 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047554 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047555 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047556 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047557 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047558 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047559 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047560 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047561 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047562 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047563 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047564 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047565 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047566 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047567 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047568 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047569 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047570 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047571 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047572 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047573 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047574 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047575 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047576 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047577 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047578 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047579 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047580 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047581 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047582 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047583 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047584 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047585 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047586 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047587 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047588 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047589 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047590 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047591 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047592 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047593 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047594 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047595 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047596 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047597 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047598 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047599 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047600 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047601 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047602 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047603 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047604 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047605 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047606 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047607 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047608 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047609 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047610 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047611 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047612 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047613 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047614 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047615 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047616 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047617 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047618 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047619 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047620 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047621 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047622 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047623 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047624 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047625 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047626 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047627 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047628 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047629 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047630 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047631 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047632 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047633 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047634 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047635 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047636 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047637 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047638 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047639 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047640 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047641 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047642 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047643 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047644 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047645 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047646 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047647 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047648 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047649 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047650 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047651 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047652 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047653 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047654 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047655 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047656 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047657 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047658 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047659 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047660 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047661 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047662 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047663 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047664 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047665 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047666 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047667 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047668 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047669 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047670 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047671 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047672 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047673 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047674 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047675 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047676 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047677 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047678 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047679 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047680 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047681 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047682 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047683 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047684 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047685 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047686 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047687 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047688 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047689 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047690 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047691 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047692 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047693 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047694 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047695 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047696 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047697 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047698 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047699 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047700 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047701 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047702 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047703 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047704 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047705 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047706 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047707 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047708 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047709 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047710 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047711 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047712 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047713 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047714 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047715 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047716 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047717 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047718 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047719 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047720 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047721 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047722 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047723 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047724 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047725 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047726 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047727 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047728 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047729 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047730 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047731 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047732 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047733 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047734 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047735 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047736 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047737 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047738 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047739 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047740 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047741 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047742 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047743 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047744 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047745 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047746 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047747 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047748 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047749 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047750 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047751 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047752 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047753 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047754 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047755 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047756 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047757 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047758 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2047759 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047760 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047761 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047762 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047763 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047764 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047765 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047766 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047767 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047768 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047769 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047770 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047771 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047772 | 10/2014 | 10/09/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047773 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047774 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047775 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047776 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047777 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047778 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047779 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047780 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047781 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047782 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047783 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047784 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047785 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047786 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047787 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047788 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047789 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047790 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047791 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047792 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047793 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047794 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047795 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047796 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047797 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047798 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047799 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047800 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047801 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047802 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047803 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047804 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047805 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047806 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047807 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047808 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047809 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047810 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047811 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047812 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2047813 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047814 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047815 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047816 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047817 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047818 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047819 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047820 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047821 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047822 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047823 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047824 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047825 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047826 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047827 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047828 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047829 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047830 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047831 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047832 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047833 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047834 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047835 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047836 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047837 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047838 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047839 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047840 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047841 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047842 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047843 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047844 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047845 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047846 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047847 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047848 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047849 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047850 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047851 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047852 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047853 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047854 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047855 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047856 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047857 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047858 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047859 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047860 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047861 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047862 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047863 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047864 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047865 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047866 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047867 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047868 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047869 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047870 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047871 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047872 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047873 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047874 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047875 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047876 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047877 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047878 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047879 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047880 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047881 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047882 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047883 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047884 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047885 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047886 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047887 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047888 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047889 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047890 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2047891 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047892 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047893 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047894 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047895 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047896 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047897 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047898 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047899 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047900 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047901 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047902 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047903 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047904 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047905 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2047906 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047907 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047908 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047909 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047910 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047911 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047912 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047913 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047914 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047915 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047916 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047917 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047918 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047919 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047920 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047921 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047922 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047923 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047924 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047925 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047926 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047927 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047928 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047929 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047930 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047931 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047932 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047933 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047934 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047935 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047936 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047937 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047938 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047939 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047940 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047941 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047942 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047943 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047944 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047945 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047946 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047947 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047948 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047949 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047950 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047951 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047952 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047953 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047954 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047955 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047956 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047957 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047958 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047959 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047960 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047961 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047962 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047963 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2047964 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047965 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047966 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047967 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047968 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047969 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047970 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047971 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047972 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047973 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047974 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047975 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047976 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047977 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047978 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047979 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047980 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047981 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2047982 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047983 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047984 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047985 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047986 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047987 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047988 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2047989 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047990 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2047991 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047992 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047993 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047994 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047995 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2047996 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047997 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2047998 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2047999 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048000 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048001 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048002 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048003 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048004 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048005 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048006 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048007 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048008 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048009 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048010 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048011 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048012 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048013 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048014 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048015 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048016 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048017 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048018 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048019 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048020 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048021 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048022 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048023 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048024 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048025 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048026 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048027 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048028 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048029 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048030 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048031 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048032 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048033 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048034 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048035 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048036 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048037 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048038 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048039 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048040 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048041 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048042 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048043 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048044 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048045 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048046 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048047 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048048 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048049 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048050 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048051 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048052 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048053 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048054 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048055 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048056 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048057 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048058 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048059 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048060 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048061 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048062 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048063 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048064 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048065 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048066 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048067 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048068 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048069 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048070 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048071 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048072 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048073 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048074 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048075 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048076 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048077 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048078 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048079 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048080 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048081 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048082 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048083 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048084 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048085 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048086 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048087 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048088 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048089 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048090 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048091 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048092 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048093 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048094 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048095 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048096 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048097 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048098 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048099 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048100 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048101 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048102 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048103 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048104 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048105 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048106 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048107 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048108 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048109 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048110 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048111 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048112 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048113 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048114 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048115 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048116 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048117 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048118 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048119 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048120 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048121 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048122 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048123 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048124 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048125 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048126 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048127 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048128 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048129 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048130 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048131 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048132 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048133 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048134 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048135 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048136 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048137 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048138 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048139 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048140 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048141 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048142 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048143 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048144 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048145 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048146 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048147 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048148 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048149 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048150 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048151 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048152 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048153 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048154 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048155 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048156 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048157 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048158 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048159 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048160 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048161 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048162 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048163 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048164 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048165 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048166 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048167 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048168 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048169 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048170 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048171 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048172 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048173 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048174 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048175 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048176 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048177 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048178 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048179 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048180 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048181 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048182 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048183 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048184 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048185 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048186 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2048187 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048188 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048189 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048190 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048191 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048192 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048193 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048194 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048195 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048196 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048197 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048198 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048199 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048200 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048201 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048202 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048203 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048204 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048205 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048206 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048207 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048208 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048209 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048210 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048211 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048212 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048213 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048214 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048215 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048216 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048217 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048218 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048219 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048220 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048221 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048222 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048223 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048224 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048225 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048226 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048227 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048228 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048229 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048230 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048231 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048232 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048233 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048234 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048235 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048236 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048237 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048238 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048239 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048240 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048241 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048242 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048243 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048244 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048245 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048246 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048247 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048248 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048249 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048250 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048251 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048252 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048253 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048254 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048255 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048256 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048257 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048258 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048259 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048260 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048261 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048262 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048263 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048264 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048265 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048266 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048267 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048268 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048269 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048270 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048271 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048272 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048273 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048274 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048275 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048276 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048277 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048278 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048279 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048280 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048281 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048282 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048283 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048284 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048285 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048286 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048287 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048288 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048289 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048290 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048291 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048292 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048293 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048294 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048295 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048296 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048297 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048298 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048299 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048300 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048301 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048302 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048303 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048304 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048305 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048306 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048307 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048308 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048309 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048310 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048311 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048312 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048313 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048314 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048315 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048316 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048317 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048318 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048319 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048320 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048321 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048322 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048323 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048324 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048325 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048326 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048327 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048328 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048329 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048330 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048331 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048332 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048333 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048334 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048335 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048336 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048337 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048338 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048339 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048340 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048341 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048342 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048343 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048344 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048345 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048346 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048347 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048348 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048349 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048350 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048351 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048352 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048353 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048354 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048355 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048356 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048357 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048358 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048359 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048360 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048361 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048362 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048363 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048364 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048365 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048366 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048367 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048368 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048369 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048370 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048371 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048372 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048373 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048374 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048375 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048376 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048377 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048378 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048379 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048380 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048381 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048382 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048383 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048384 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048385 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048386 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048387 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048388 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048389 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048390 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048391 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048392 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048393 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048394 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048395 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048396 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048397 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048398 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048399 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048400 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048401 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048402 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048403 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048404 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048405 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048406 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048407 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048408 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048409 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048410 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048411 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048412 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048413 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048414 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048415 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048416 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048417 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048418 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048419 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048420 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048421 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048422 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048423 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048424 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048425 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048426 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048427 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048428 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048429 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048430 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048431 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048432 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048433 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048434 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048435 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048436 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048437 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048438 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048439 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048440 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048441 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048442 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048443 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048444 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048445 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048446 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048447 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048448 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048449 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048450 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048451 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048452 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048453 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048454 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048455 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048456 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048457 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048458 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048459 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048460 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048461 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2048462 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048463 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048464 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048465 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048466 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048467 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048468 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048469 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048470 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048471 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048472 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048473 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048474 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048475 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048476 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048477 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048478 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048479 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048480 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048481 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048482 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048483 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048484 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048485 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048486 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048487 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048488 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048489 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048490 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048491 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048492 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048493 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048494 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048495 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048496 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048497 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048498 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048499 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048500 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048501 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048502 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048503 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2048504 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048505 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048506 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048507 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048508 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048509 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048510 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048511 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048512 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048513 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048514 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048515 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048516 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048517 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048518 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048519 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048520 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048521 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048522 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048523 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048524 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048525 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048526 | 10/2014 | 10/10/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2048527 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048528 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048529 | 10/2014 | 10/10/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2048530 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048531 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048532 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048533 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048534 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048535 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048536 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048537 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048538 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048539 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048540 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048541 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048542 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048543 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048544 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048545 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048546 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048547 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048548 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048549 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048550 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048551 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048552 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048553 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048554 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048555 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048556 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048557 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048558 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048559 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048560 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048561 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048562 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048563 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048564 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048565 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048566 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048567 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048568 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048569 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048570 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048571 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048572 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048573 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048574 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048575 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048576 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048577 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048578 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048579 | 10/2014 | 10/10/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048580 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048581 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048582 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048583 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048584 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048585 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048586 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048587 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048588 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048589 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048590 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048591 | 10/2014 | 10/10/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048592 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048593 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048594 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048595 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048596 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048597 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048598 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048599 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048600 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048601 | 10/2014 | 10/10/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048602 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048603 | 10/2014 | 10/10/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048752 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048753 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048754 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048755 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048756 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048757 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048758 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048759 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048760 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048761 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048762 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048763 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048764 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048765 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048766 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048767 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048768 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048769 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048770 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048771 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048772 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048773 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048774 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048775 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048776 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048777 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048778 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048779 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048780 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048781 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048782 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048783 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048784 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048785 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048786 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048787 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048788 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048789 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048790 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048791 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048792 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048793 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048794 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048795 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048796 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048797 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048798 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048799 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048800 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048801 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048802 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048803 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048804 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048805 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048806 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048807 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048808 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048809 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048810 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048811 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048812 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048813 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048814 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048815 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048816 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048817 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048818 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048819 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048820 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048821 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048822 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048823 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048824 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048825 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048826 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048827 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048828 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048829 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048830 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048831 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048832 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048833 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048834 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048835 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048836 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048837 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048838 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048839 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048840 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048841 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048842 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048843 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048844 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048845 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048846 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048847 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048848 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048849 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048850 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048851 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048852 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048853 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048854 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048855 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048856 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048857 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048858 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048859 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048860 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048861 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048862 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048863 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048864 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048865 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048866 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048867 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048868 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048869 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048870 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048871 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048872 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048873 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048874 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048875 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048876 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048877 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048878 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048879 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048880 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048881 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048882 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048883 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048884 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048885 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048886 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048887 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048888 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048889 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048890 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048891 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048892 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1S | 2048893 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048894 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048895 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048896 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048897 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048898 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048899 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048900 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048901 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2048902 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048903 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048904 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048905 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048906 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048907 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048908 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048909 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048910 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048911 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048912 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048913 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048914 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048915 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048916 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048917 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048918 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048919 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048920 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048921 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048922 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048923 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048924 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048925 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048926 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048927 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048928 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048929 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048930 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048931 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048932 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048933 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048934 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048935 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048936 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048937 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048938 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048939 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048940 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048941 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048942 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048943 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048944 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048945 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048946 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048947 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048948 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048949 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048950 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048951 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048952 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048953 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048954 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048955 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048956 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048957 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048958 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048959 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048960 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048961 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048962 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048963 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048964 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048965 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048966 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048967 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048968 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048969 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048970 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2048971 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048972 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048973 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048974 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048975 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048976 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048977 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048978 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048979 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2048980 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048981 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048982 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048983 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048984 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048985 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2048986 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048987 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048988 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048989 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2048990 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048991 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048992 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2048993 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048994 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048995 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2048996 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2048997 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048998 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2048999 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049000 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049001 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049002 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049003 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049004 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049005 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049006 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049007 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049008 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049009 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049010 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049011 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049012 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049013 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049014 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049015 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049016 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049017 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049018 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049019 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049020 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049021 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049022 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049023 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049024 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049025 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049026 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049027 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049028 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049029 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049030 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049031 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049032 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049033 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049034 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049035 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049036 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049037 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049038 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049039 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049040 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049041 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049042 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049043 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049044 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049045 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049046 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049047 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049048 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049049 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049050 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049051 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049052 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049053 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049054 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049055 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049056 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049057 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049058 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049059 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049060 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049061 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049062 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049063 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049064 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049065 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049066 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049067 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049068 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049069 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049070 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049071 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049072 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049073 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049074 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049075 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049076 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049077 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049078 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049079 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049080 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049081 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049082 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049083 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049084 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049085 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049086 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049087 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049088 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049089 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049090 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049091 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049092 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049093 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049094 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049095 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049096 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049097 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049098 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049099 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049100 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049101 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049102 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049103 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049104 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049105 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049106 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049107 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049108 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049109 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049110 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049111 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049112 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049113 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049114 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049115 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049116 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049117 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049118 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049119 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049120 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049121 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049122 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049123 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049124 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049125 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049126 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049127 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049128 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049129 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049130 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049131 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049132 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049133 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049134 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049135 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049136 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049137 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049138 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049139 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049140 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049141 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049142 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049143 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049144 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049145 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049146 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049147 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049148 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049149 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049150 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049151 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049152 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049153 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049154 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049155 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049156 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049157 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049158 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049159 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049160 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049161 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049162 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049163 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049164 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049165 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049166 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049167 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049168 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049169 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049170 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049171 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049172 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049173 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049174 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049175 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049176 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049177 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049178 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049179 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049180 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049181 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049182 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049183 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049184 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049185 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049186 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049187 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049188 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049189 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049190 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049191 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049192 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049193 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049194 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049195 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049196 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049197 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049198 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049199 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049200 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049201 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049202 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049203 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049204 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049205 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049206 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049207 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049208 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049209 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049210 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049211 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049212 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049213 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049214 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049215 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049216 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049217 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049218 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049219 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049220 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049221 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049222 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049223 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049224 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049225 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049226 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049227 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049228 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049229 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049230 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049231 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049232 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049233 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049234 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049235 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049236 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049237 | 12/2014 | 11/25/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049238 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049239 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049240 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049241 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049242 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049243 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049244 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049245 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049246 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049247 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049248 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049249 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049250 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049251 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049252 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049253 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049254 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049255 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049256 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049257 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049258 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049259 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049260 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049261 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049262 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049263 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049264 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049265 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049266 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049267 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049268 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049269 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049270 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049271 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049272 | 12/2014 | 11/26/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049273 | 12/2014 | 12/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049274 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049275 | 12/2014 | 12/06/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049276 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049277 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049278 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049279 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049280 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049281 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049282 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049283 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049284 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049285 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049286 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049287 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049288 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049289 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049290 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049291 | 12/2014 | 12/03/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049292 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049293 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049294 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049295 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049296 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049297 | 12/2014 | 12/05/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049298 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049299 | 12/2014 | 11/26/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049300 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049301 | 12/2014 | 12/01/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049302 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049303 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049304 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049305 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049306 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049307 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049308 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049309 | 12/2014 | 12/01/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049310 | 12/2014 | 12/12/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049311 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049312 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049313 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049314 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049315 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049316 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049317 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049318 | 12/2014 | 12/05/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049319 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049320 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049321 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049322 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049323 | 12/2014 | 12/15/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049324 | 12/2014 | 12/15/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049325 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049326 | 12/2014 | 12/08/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049327 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049328 | 12/2014 | 12/01/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049329 | 12/2014 | 12/15/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049330 | 12/2014 | 12/12/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049331 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049332 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049333 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049334 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049335 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049336 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049337 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049338 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049339 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049340 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049341 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049342 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049343 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049344 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049345 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049346 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049347 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049348 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049349 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049350 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049351 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049352 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049353 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049354 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049355 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049356 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049357 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049358 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049359 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049360 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049361 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049362 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049363 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049364 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049365 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049366 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049367 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049368 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049369 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049370 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049371 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049372 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049373 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049374 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049375 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049376 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049377 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049378 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049379 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049380 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049381 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049382 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049383 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049384 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049385 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049386 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049387 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049388 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049389 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049390 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049391 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049392 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049393 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049394 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049395 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049396 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049397 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049398 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049399 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049400 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049401 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049402 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049403 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049404 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049405 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049406 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049407 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049408 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049409 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049410 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049411 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049412 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049413 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049414 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049415 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049416 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049417 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049418 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049419 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049420 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049421 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049422 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049423 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049424 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049425 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049426 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049427 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049428 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049429 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049430 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049431 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049432 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049433 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049434 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049435 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049436 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049437 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049438 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049439 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049440 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049441 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049442 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049443 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049444 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049445 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049446 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049447 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049448 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049449 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049450 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049451 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049452 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049453 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049454 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049455 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049456 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049457 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049458 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049459 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049460 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049461 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049462 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049463 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049464 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049465 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049466 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049467 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049468 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049469 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049470 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049471 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049472 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049473 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049474 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049475 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049476 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049477 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049478 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049479 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049480 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049481 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049482 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049483 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049484 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049485 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049486 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049487 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049488 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049489 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049490 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049491 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049492 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049493 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049494 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049495 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049496 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049497 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049498 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049499 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049500 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049501 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049502 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049503 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049504 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049505 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049506 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049507 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049508 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049509 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049510 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049511 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049512 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049513 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049514 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049515 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049516 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049517 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049518 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049519 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049520 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049521 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049522 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049523 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049524 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049525 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049526 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049527 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049528 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049529 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049530 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049531 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049532 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049533 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049534 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049535 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049536 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049537 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049538 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049539 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049540 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049541 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049542 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049543 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049544 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049545 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049546 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049547 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049548 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049549 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049550 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049551 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049552 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049553 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049554 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049555 | 12/2014 | 12/05/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049556 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049557 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049558 | 12/2014 | 12/02/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049559 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049560 | 12/2014 | 12/06/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049561 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049562 | 12/2014 | 12/07/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049563 | 12/2014 | 12/07/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049564 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049565 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049566 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049567 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049568 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049569 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049570 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049571 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049572 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049573 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049574 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049575 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049576 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049577 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049578 | 12/2014 | 12/06/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049579 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049580 | 12/2014 | 11/26/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049581 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049582 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2049583 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049584 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049585 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049586 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049587 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049588 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049589 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049590 | 12/2014 | 12/12/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049591 | 12/2014 | 12/06/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049592 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 99.9 | 1 |
| KU | C1S | 2049593 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049594 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049595 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049596 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049597 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049598 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049599 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049600 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049601 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049602 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049603 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049604 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049605 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049606 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049607 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049608 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049609 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049610 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049611 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049612 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049613 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049614 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049615 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049616 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049617 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049618 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049619 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049620 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049621 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049622 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049623 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049624 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049625 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049626 | 12/2014 | 12/06/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049627 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049628 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049629 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049630 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049631 | 12/2014 | 12/02/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049632 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049633 | 12/2014 | 12/02/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049634 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049635 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049636 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049637 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049638 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049639 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049640 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049641 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049642 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049643 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049644 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049645 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049646 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049647 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049648 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049649 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049650 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049651 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049652 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049653 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049654 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049655 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049656 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049657 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049658 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049659 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049660 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049661 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049662 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049663 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049664 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049665 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049666 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049667 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049668 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049669 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049670 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049671 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049672 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049673 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049674 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049675 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049676 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049677 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049678 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049679 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049680 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049681 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049682 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049683 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049684 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049685 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049686 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049687 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049688 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049689 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049690 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049691 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049692 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049693 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049694 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049695 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049696 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049697 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049698 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049699 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049700 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049701 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049702 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049703 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049704 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049705 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049706 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049707 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049708 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049709 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049710 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049711 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049712 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049713 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049714 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049715 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049716 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049717 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049718 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049719 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049720 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049721 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049722 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049723 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049724 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049725 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049726 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049727 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049728 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049729 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049730 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049731 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049732 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049733 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049734 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049735 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049736 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049737 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049738 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049739 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049740 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049741 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049742 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049743 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049744 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049745 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049746 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049747 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049748 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049749 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049750 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049751 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049752 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049753 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049754 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049755 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049756 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049757 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049758 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049759 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049760 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049761 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049762 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049763 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049764 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049765 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049766 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049767 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049768 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049769 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049770 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049771 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049772 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049773 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049774 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049775 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049776 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049777 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049778 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049779 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049780 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049781 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049782 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049783 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049784 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049785 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049786 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049787 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049788 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049789 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049790 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049791 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049792 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049793 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049794 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049795 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049796 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049797 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049798 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049799 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049800 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049801 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049802 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049803 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049804 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049805 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2049806 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049807 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049808 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049809 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049810 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049811 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049812 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049813 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049814 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049815 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049816 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049817 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049818 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049819 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049820 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049821 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049822 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049823 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049824 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049825 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049826 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049827 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049828 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049829 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049830 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049831 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049832 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049833 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049834 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049835 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049836 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049837 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049838 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049839 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049840 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049841 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049842 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049843 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049844 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049845 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049846 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049847 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049848 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049849 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049850 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049851 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049852 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049853 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049854 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049855 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049856 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049857 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049858 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049859 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049860 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049861 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049862 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049863 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049864 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049865 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049866 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049867 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049868 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049869 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049870 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049871 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049872 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049873 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049874 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049875 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049876 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049877 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049878 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049879 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049880 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049881 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049882 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049883 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049884 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049885 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049886 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049887 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049888 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049889 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049890 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049891 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049892 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049893 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049894 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049895 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049896 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049897 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049898 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049899 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049900 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049901 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049902 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049903 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049904 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049905 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049906 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049907 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049908 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049909 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049910 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049911 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049912 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049913 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049914 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049915 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049916 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049917 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049918 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049919 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049920 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049921 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049922 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049923 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049924 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049925 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049926 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049927 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049928 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049929 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049930 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049931 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049932 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049933 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049934 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049935 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049936 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049937 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049938 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049939 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049940 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049941 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049942 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049943 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049944 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049945 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049946 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049947 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049948 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049949 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049950 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049951 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049952 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049953 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049954 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049955 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049956 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049957 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049958 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049959 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049960 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049961 | 12/2014 | 12/04/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049962 | 12/2014 | 12/12/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049963 | 12/2014 | 12/04/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049964 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049965 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049966 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049967 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049968 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049969 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2049970 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049971 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049972 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2049973 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049974 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049975 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049976 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049977 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049978 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049979 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049980 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049981 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049982 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049983 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049984 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049985 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049986 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049987 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2049988 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049989 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2049990 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049991 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049992 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2049993 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049994 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2049995 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2049996 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2049997 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049998 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2049999 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050000 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050001 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050002 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050003 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050004 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050005 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050006 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050007 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050008 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050009 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050010 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050011 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050012 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050013 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050014 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050015 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050016 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050017 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050018 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050019 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050020 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050021 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050022 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050023 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050024 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050025 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050026 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050027 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050028 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050029 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050030 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050031 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050032 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050033 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050034 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050035 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050036 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050037 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050038 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050039 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050040 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050041 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050042 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050043 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050044 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050045 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050046 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050047 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050048 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050049 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050050 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050051 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050052 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050053 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050054 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050055 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050056 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050057 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050058 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050059 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050060 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050061 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050062 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050063 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050064 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050065 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050066 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050067 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050068 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050069 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050070 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050071 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050072 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050073 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050074 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050075 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050076 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050077 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050078 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050079 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050080 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050081 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050082 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050083 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050084 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050085 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050086 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050087 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050088 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050089 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050090 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050091 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050092 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050093 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050094 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050095 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050096 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050097 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050098 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050099 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050100 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050101 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050102 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050103 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050104 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050105 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050106 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050107 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050108 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050109 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050110 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050111 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050112 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050113 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050114 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050115 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050116 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050117 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050118 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050119 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050120 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050121 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050122 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050123 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050124 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050125 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050126 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050127 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050128 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050129 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050130 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050131 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050132 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050133 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050134 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050135 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050136 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050137 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050138 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050139 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050140 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050141 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050142 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050143 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050144 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050145 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050146 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050147 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050148 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050149 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050150 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050151 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050152 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050153 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050154 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050155 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050156 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050157 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050158 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050159 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050160 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050161 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050162 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050163 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050164 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050165 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050166 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050167 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050168 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050169 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050170 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050171 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050172 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050173 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050174 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050175 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050176 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050177 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050178 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050179 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050180 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050181 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050182 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050183 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050184 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050185 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050186 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050187 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050188 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050189 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050190 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050191 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050192 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050193 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050194 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050195 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050196 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050197 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050198 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050199 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050200 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050201 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050202 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050203 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050204 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050205 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050206 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050207 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050208 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050209 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050210 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050211 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050212 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050213 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050214 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050215 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050216 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050217 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050218 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050219 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050220 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050221 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050222 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050223 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050224 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050225 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050226 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050227 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050228 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050229 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050230 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050231 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050232 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050233 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050234 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050235 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050236 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050237 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050238 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050239 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050240 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050241 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050242 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050243 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050244 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050245 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050246 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050247 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050248 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050249 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050250 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050251 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050252 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050253 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050254 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050255 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050256 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050257 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050258 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050259 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050260 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050261 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050262 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050263 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050264 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050265 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050266 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050267 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050268 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050269 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050270 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050271 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050272 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050273 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050274 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050275 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050276 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050277 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050278 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050279 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050280 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050281 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050282 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050283 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050284 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050285 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050286 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050287 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050288 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050289 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050290 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050291 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050292 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050293 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050294 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050295 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050296 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050297 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050298 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050299 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050300 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050301 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050302 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050303 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050304 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050305 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050306 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050307 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050308 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050309 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050310 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050311 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050312 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050313 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050314 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050315 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050316 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050317 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050318 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050319 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050320 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050321 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050322 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050323 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050324 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050325 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050326 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050327 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050328 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050329 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050330 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050331 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050332 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050333 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050334 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050335 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050336 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050337 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050338 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050339 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050340 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050341 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050342 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050343 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050344 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050345 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050346 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050347 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050348 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050349 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050350 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050351 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050352 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050353 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050354 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050355 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050356 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050357 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050358 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050359 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050360 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050361 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050362 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050363 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050364 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050365 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050366 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050367 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050368 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050369 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050370 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050371 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050372 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050373 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050374 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050375 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050376 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050377 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050378 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050379 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050380 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050381 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050382 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050383 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050384 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050385 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050386 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050387 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050388 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050389 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050390 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050391 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050392 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050393 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050394 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050395 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050396 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050397 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050398 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050399 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050400 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050401 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050402 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050403 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050404 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050405 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050406 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050407 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050408 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050409 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050410 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050411 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050412 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050413 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050414 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050415 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050416 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050417 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050418 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050419 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050420 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050421 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050422 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2050423 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050424 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050425 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050426 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050427 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050428 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050429 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050430 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050431 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050432 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050433 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050434 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050435 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050436 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050437 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050438 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050439 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050440 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050441 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050442 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050443 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050444 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050445 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050446 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050447 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050448 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050449 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050450 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050451 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050452 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050453 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050454 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050455 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050456 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050457 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050458 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050459 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050460 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050461 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050462 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050463 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050464 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050465 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050466 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050467 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050468 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050469 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050470 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050471 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050472 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050473 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050474 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050475 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050476 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050477 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050478 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050479 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050480 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050481 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050482 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050483 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050484 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050485 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050486 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050487 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050488 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050489 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050490 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050491 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050492 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050493 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050494 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050495 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050496 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050497 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050498 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050499 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050500 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050501 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050502 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050503 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050504 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050505 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050506 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050507 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050508 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050509 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050510 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050511 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050512 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050513 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050514 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050515 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050516 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050517 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050518 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050519 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050520 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050521 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050522 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050523 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050524 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050525 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050526 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050527 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050528 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050529 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050530 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050531 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050532 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050533 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050534 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050535 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1S | 2050536 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050537 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050538 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050539 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050540 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050541 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050542 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050543 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050544 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050545 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050546 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050547 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050548 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050549 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050550 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050551 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050552 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1S | 2050553 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1S | 2050554 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050555 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050556 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050557 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050558 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050559 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050560 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050561 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050562 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050563 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050564 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050565 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050566 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050567 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050568 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050569 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050570 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050571 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050572 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050573 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050574 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050575 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050576 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050577 | 12/2014 | 12/16/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050578 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050579 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050580 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050581 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050582 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050583 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050584 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050585 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050586 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050587 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050588 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050589 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050590 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050591 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050592 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050593 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050594 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050595 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050596 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050597 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050598 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050599 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050600 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050601 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050602 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050603 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050604 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050605 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050606 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050607 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050608 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050609 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050610 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050611 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050612 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050613 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050614 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050615 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050616 | 12/2014 | 12/16/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050617 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050618 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050619 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050620 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050621 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050622 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050623 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050624 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050625 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050626 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050627 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050628 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050629 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050630 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050631 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050632 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050633 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050634 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050635 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050636 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050637 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050638 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050639 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050640 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050641 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050642 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050643 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050644 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050645 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050646 | 12/2014 | 12/16/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2050647 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050648 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050649 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050650 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050651 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050652 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050653 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050654 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050655 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050656 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050657 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1S | 2050658 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050659 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050660 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050661 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050662 | 12/2014 | 12/16/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1S | 2050663 | 12/2014 | 12/16/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050664 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050665 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1S | 2050666 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1S | 2050667 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050668 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050669 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1S | 2050670 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1S | 2050671 | 12/2014 | 12/16/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508077 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508078 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508079 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508080 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508081 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508082 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508083 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508084 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508085 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508086 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508087 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508088 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508089 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508090 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508091 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508092 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508093 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508094 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508095 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508096 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508097 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508098 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508099 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508100 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508101 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508102 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508103 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508104 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508105 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508106 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508107 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508108 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508109 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508110 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508111 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508112 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508113 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508114 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508115 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508116 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508117 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508118 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508119 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508120 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508121 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508122 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508123 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508124 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508125 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508126 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508127 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508128 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508129 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508130 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508131 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508132 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508133 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508134 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508135 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508136 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508137 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508138 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508139 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508140 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508141 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508142 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508143 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508144 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2508145 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508146 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508147 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508148 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508149 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508150 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508151 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508152 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508153 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508154 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508155 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508156 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508157 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508158 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508159 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508160 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508161 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508162 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508163 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508164 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508165 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508166 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508167 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508168 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508169 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508170 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508171 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508172 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508173 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508174 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508175 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508176 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508177 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508178 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508179 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508180 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508181 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508182 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508183 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508184 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508185 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508186 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508187 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508188 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508189 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508190 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508191 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508192 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508193 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508194 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508195 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508196 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508197 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508198 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508199 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508200 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508201 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508202 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508203 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508204 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508205 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508206 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508207 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508208 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508209 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508210 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508211 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508212 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508213 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508214 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508215 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508216 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508217 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508218 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508219 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508220 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508221 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508222 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508223 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508224 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508225 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508226 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508227 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508228 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508229 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508230 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508231 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508232 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508233 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508234 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508235 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508236 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508237 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508238 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508239 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508240 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508241 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508242 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508243 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508244 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508245 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508246 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508247 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508248 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508249 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508250 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508251 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508252 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508253 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508254 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508255 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508256 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508257 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508258 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508259 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508260 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508261 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508262 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508263 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508264 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508265 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508266 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508267 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508268 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508269 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508270 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508271 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508272 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508273 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508274 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508275 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508276 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508277 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508278 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508279 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508280 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508281 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508282 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508283 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508284 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508285 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508286 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508287 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508288 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508289 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508290 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508291 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508292 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508293 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508294 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508295 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508296 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508297 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508298 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508299 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508300 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508301 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508302 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508303 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508304 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508305 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508306 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508307 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508308 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508309 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508310 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508311 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508312 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508313 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508314 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508315 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508316 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508317 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508318 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508319 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508320 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508321 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508322 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508323 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508324 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508325 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508326 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508327 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508328 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2508329 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508330 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508331 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508332 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508333 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508334 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508335 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508336 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508337 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508338 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508339 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508340 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508341 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508342 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508343 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508344 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508345 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508346 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508347 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508348 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508349 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508350 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508351 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508352 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508353 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508354 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508355 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508356 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508357 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508358 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508359 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508360 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508361 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508362 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508363 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508364 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508365 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508366 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508367 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508368 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508369 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508370 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508371 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508372 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508373 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508374 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508375 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508376 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508377 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508378 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508379 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508380 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508381 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508382 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508383 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508384 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508385 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508386 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508387 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508388 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508389 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508390 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508391 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508392 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508393 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508394 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508395 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508396 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508397 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508398 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508399 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508400 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2508401 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508402 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508403 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508404 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508405 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508406 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508407 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508408 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508409 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508410 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508411 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508412 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508413 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508414 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508415 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508416 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508417 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508418 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2508419 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508420 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508421 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508422 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508423 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508424 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508425 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508426 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508427 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508428 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508429 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508430 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508431 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508432 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508433 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508434 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508435 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508436 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508437 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508438 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508439 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508440 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508441 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508442 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508443 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508444 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508445 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508446 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2508447 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508448 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508449 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508450 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508451 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508452 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508453 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508454 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508455 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508456 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2508457 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508458 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508459 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508460 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508461 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508462 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508463 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508464 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508465 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508466 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508467 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508468 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508469 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508470 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508471 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508472 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508473 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508474 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508475 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508476 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508477 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508478 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508479 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508480 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508481 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508482 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508483 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508484 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508485 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508486 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508487 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508488 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508489 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508490 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508491 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508492 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508493 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508494 | 06/2014 | 05/22/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508495 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508496 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508497 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508498 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508499 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508500 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508501 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508502 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508503 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508504 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508505 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508506 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508507 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508508 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508509 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508510 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508511 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508512 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508513 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508514 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508515 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508516 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508517 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508518 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508519 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508520 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508521 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508522 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508523 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508524 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508525 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508526 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508527 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508528 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508529 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508530 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508531 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508532 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508533 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508534 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508535 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508536 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508537 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508538 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508539 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508540 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508541 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508542 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508543 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508544 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508545 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508546 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508547 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508548 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508549 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508550 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508551 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508552 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508553 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508554 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508555 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508556 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508557 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508558 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508559 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508560 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508561 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508562 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508563 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508564 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508565 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508566 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508567 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2508568 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508569 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508570 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508571 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508572 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508573 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508574 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508575 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508576 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508577 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508578 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508579 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508580 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508581 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508582 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508583 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508584 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508585 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508586 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508587 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508588 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508589 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508590 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508591 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508592 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508593 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508594 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508595 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508596 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508597 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508598 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508599 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508600 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508601 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508602 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508603 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508604 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508605 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508606 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508607 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508608 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508609 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508610 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508611 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508612 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508613 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508614 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508615 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508616 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508617 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508618 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508619 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508620 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508621 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508622 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508623 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508624 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508625 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508626 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508627 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508628 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508629 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508630 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508631 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508632 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508633 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508634 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508635 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508636 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508637 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508638 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508639 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508640 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508641 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508642 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508643 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508644 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508645 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508646 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508647 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508648 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508649 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508650 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508651 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508652 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508653 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508654 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508655 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508656 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508657 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508658 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508659 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508660 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508661 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508662 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508663 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508664 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508665 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508666 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508667 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508668 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508669 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508670 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508671 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508672 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508673 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508674 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508675 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508676 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508677 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508678 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508679 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508680 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508681 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508682 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508683 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508684 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508685 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508686 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508687 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508688 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508689 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508690 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508691 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508692 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508693 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508694 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508695 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508696 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508697 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508698 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508699 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508700 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508701 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508702 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508703 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508704 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508705 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508706 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508707 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508708 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508709 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508710 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508711 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508712 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508713 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508714 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508715 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508716 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508717 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508718 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508719 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508720 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508721 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508722 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508723 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508724 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508725 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508726 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508727 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508728 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508729 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508730 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508731 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508732 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508733 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508734 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508735 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508736 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508737 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508738 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508739 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508740 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508741 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508742 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508743 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508744 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508745 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2508746 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508747 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508748 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508749 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508750 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508751 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508752 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508753 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508754 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508755 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508756 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508757 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508758 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508759 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508760 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508761 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508762 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508763 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508764 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508765 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508766 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508767 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508768 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508769 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508770 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508771 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508772 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508773 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508774 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508775 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508776 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508777 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508778 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508779 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508780 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508781 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508782 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508783 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508784 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508785 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508786 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508787 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508788 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508789 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508790 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508791 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508792 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508793 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508794 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508795 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508796 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508797 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508798 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508799 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508800 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508801 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508802 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508803 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508804 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508805 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2508806 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508807 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508808 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508809 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508810 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508811 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508812 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508813 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508814 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508815 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508816 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508817 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508818 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508819 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508820 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508821 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508822 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508823 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508824 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508825 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508826 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508827 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508828 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508829 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508830 | 06/2014 | 05/22/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508831 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508832 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508833 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508834 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508835 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508836 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508837 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508838 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508839 | 06/2014 | 05/22/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508840 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508841 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508842 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508843 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508844 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508845 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508846 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508847 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508848 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508849 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508850 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508851 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508852 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508853 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508854 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508855 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508856 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508857 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508858 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508859 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508860 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508861 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508862 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508863 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508864 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508865 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508866 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508867 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508868 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508869 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508870 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2508871 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508872 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508873 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508874 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508875 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508876 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508877 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508878 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508879 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508880 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508881 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508882 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508883 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508884 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508885 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508886 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508887 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508888 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2508889 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508890 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508891 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508892 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508893 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508894 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508895 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508896 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508897 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508898 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508899 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508900 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508901 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508902 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508903 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508904 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508905 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508906 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508907 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508908 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508909 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508910 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508911 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508912 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508913 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508914 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508915 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2508916 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508917 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508918 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508919 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508920 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508921 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508922 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508923 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508924 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508925 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508926 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508927 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508928 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508929 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508930 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508931 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508932 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508933 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508934 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508935 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508936 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508937 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508938 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508939 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508940 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508941 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508942 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508943 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508944 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508945 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508946 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508947 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508948 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508949 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508950 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508951 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508952 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508953 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508954 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508955 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508956 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508957 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508958 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508959 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508960 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508961 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508962 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508963 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508964 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508965 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508966 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508967 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2508968 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508969 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508970 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508971 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508972 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508973 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508974 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508975 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508976 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508977 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508978 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508979 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508980 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508981 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508982 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2508983 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508984 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508985 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508986 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508987 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2508988 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508989 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508990 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2508991 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508992 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508993 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2508994 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508995 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508996 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2508997 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508998 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2508999 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509000 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509001 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509002 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509003 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509004 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509005 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509006 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509007 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509008 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509009 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509010 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509011 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509012 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509013 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509014 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509015 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509016 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509017 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509018 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509019 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509020 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509021 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509022 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509023 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509024 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2509025 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509026 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509027 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509028 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509029 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509030 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509031 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509032 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509033 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509034 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509035 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509036 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509037 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509038 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509039 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509040 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509041 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509042 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509043 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509044 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509045 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509046 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509047 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509048 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509049 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509050 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2509051 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509052 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509053 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509054 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509055 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509056 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509057 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509058 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509059 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509060 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509061 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509062 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509063 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509064 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509065 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2509066 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509067 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509068 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509069 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509070 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509071 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509072 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509073 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509074 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509075 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509076 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509077 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509078 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509079 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509080 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509081 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509082 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509083 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509084 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509085 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509086 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509087 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2509088 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509089 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509090 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509091 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509092 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509093 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509094 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509095 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509096 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509097 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509098 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509099 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509100 | 06/2014 | 05/23/2014 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2509101 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509102 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509103 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509104 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509105 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509106 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509107 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509108 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509109 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509110 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509111 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509112 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509113 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509114 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509115 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509116 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509117 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509118 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2509119 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509120 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509121 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509122 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509123 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509124 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509125 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509126 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509127 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509128 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509129 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509130 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509131 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509132 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509133 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509134 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509135 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509136 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509137 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509138 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509139 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509140 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509141 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509142 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509143 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509144 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509145 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509146 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509147 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509148 | 06/2014 | 05/23/2014 | 99.900 | 100.200 | 99.9 | 1 |
| KU | C1SR | 2509149 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509150 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509151 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509152 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509153 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509154 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509155 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509156 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509157 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509158 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509159 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509160 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509161 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509162 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509163 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509164 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509165 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509166 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509167 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509168 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509169 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509170 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509171 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509172 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509173 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509174 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509175 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509176 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509177 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509178 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509179 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509180 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509181 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2509182 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509183 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509184 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509185 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509186 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509187 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509188 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509189 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509190 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509191 | 06/2014 | 05/23/2014 | 99.900 | 100.000 | 100.1 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509192 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509193 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509194 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509195 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509196 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509197 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509198 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509199 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509200 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509201 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509202 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509203 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509204 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509205 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.1 | 1 |
| KU | C1SR | 2509206 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509207 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509208 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509209 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509210 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509211 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509212 | 06/2014 | 05/23/2014 | 99.900 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509213 | 06/2014 | 05/22/2014 | 100.000 | 100.100 | 100.0 | 1 |
| KU | C1SR | 2509214 | 06/2014 | 05/23/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509215 | 06/2014 | 05/22/2014 | 100.000 | 100.200 | 100.0 | 1 |
| KU | C1SR | 2509216 | 06/2014 | 05/23/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509239 | 06/2014 | 05/28/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2509240 | 06/2014 | 05/20/2014 | 100.000 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509241 | 06/2014 | 05/20/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509242 | 06/2014 | 05/28/2014 | 100.000 | 100.100 | 100.2 | 1 |
| KU | C1SR | 2509243 | 06/2014 | 05/20/2014 | 99.800 | 100.000 | 99.8 | 1 |
| KU | C1SR | 2509244 | 06/2014 | 05/20/2014 | 99.900 | 100.100 | 99.9 | 1 |
| KU | C1SR | 2509245 | 06/2014 | 05/20/2014 | 99.800 | 99.900 | 99.8 | 1 |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| KU | C1SR | 2509246 | 06/2014 | 05/28/2014 | 99.900 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509247 | 06/2014 | 05/28/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509248 | 06/2014 | 05/28/2014 | 100.000 | 100.200 | 100.2 | 1 |
| KU | C1SR | 2509249 | 06/2014 | 05/15/2014 | 100.000 | 100.100 | 100.1 | 1 |
| KU | C1SR | 2509250 | 06/2014 | 05/15/2014 | 100.000 | 100.100 | 100.1 | 1 |
| Overall Result | | | | | X | X | X | 8,952 |

# ATTACHMENT
# B

## Sampling Test Results

# KU
# 2014 SAMPLE
# ELECTRIC METER SUMMARY

**SAMPLE**

| | | |
|---|---|---|
| In-Service Population | 493,900 | Divided into 61 Lots |
| | | |
| Sample Quantity | 4,194 | |
| Meters Tested | 4,194 | |
| Meters Not Tested | 0 | |
| Failed Lots | 1 | MKS |
| Failed Lot Meters | 504 | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1239 Lot Descr: KU AB1 - 1

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C331752 | 99.60 | C331789 | 99.20 | C331868 | 99.70 | C331927 | 99.90 | C332071 | 100.00 |
| C332327 | 99.90 | C332332 | 100.10 | C332366 | 99.80 | C332370 | 99.50 | C332396 | 99.80 |
| C332768 | 100.00 | C332797 | 100.40 | C333150 | 99.80 | C333310 | 100.10 | C333335 | 99.90 |
| C333393 | 99.70 | C333555 | 100.00 | C333718 | 100.20 | C333843 | 100.20 | L297589 | 100.00 |
| L297621 | 100.30 | L297836 | 99.60 | L297864 | 99.50 | L297870 | 100.10 | L298081 | 100.00 |
| L298264 | 99.70 | L298279 | 99.10 | L298285 | 99.40 | L298361 | 98.50 | L298768 | 99.20 |
| L299323 | 99.80 | L299727 | 100.10 | L299855 | 99.80 | L299932 | 99.80 | L300432 | 100.10 |
| L300567 | 100.30 | L300635 | 99.80 | L300712 | 99.90 | L300717 | 100.30 | L300886 | 100.00 |
| L300905 | 100.20 | L301699 | 100.00 | L301951 | 99.10 | L301983 | 100.10 | L302183 | 100.10 |
| L302210 | 99.10 | L302302 | 99.90 | L302334 | 99.80 | L302472 | 100.10 | L302482 | 100.70 |
| L302641 | 98.80 | L302717 | 99.60 | L302796 | 99.30 | L303059 | 100.10 | L303139 | 100.30 |
| L303226 | 99.40 | L303452 | 100.50 | L303488 | 99.80 | L303494 | 100.10 | L303507 | 100.30 |
| M444684 | 99.50 | M445341 | 99.00 | M445427 | 99.80 | M445460 | 99.90 | M445481 | 99.50 |
| M445723 | 98.80 | M445810 | 99.40 | W146956 | 100.00 | W147003 | 100.00 | W147118 | 99.70 |
| W147199 | 99.80 | W147251 | 100.10 | W147301 | 100.00 | W147667 | 100.20 | W147873 | 100.30 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7480.40 |
| 3 | Sum of Squared Measurements | 746133.86 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 746085.12 |
| 5 | Corrected Sum of Squares (SS) | 48.74 |
| 6 | Variance (V) : SS/(N-1) | 0.6506 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.8116 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.74 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 2.79 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 2.14 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.21 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 1.51 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 1.72 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1240 Lot Descr: KU AB1 - 2

In Service Population: 5,549 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C334041 | 100.50 | C334075 | 99.90 | C334196 | 100.30 | C334319 | 100.10 | C334342 | 99.60 |
| C334423 | 99.80 | C334438 | 100.40 | C334577 | 99.80 | C334640 | 99.90 | C334661 | 99.60 |
| C334781 | 100.40 | C334872 | 100.30 | C335031 | 99.00 | C344928 | 100.40 | C408260 | 100.50 |
| C408514 | 100.40 | C408518 | 100.20 | C408601 | 100.00 | C408625 | 99.90 | C408639 | 100.50 |
| C408640 | 100.60 | C408808 | 100.60 | C408886 | 100.00 | C408915 | 99.90 | C409138 | 100.40 |
| C409231 | 99.90 | C409267 | 99.80 | C409454 | 99.70 | C409547 | 100.00 | C409571 | 100.30 |
| C409671 | 100.60 | C409719 | 100.40 | C409744 | 100.60 | C433515 | 100.20 | C433535 | 100.20 |
| C433549 | 100.10 | C433750 | 100.30 | C433905 | 100.20 | C434012 | 100.50 | C434051 | 100.00 |
| C434256 | 100.10 | C434304 | 100.10 | C434316 | 100.00 | C434369 | 99.90 | C434382 | 100.30 |
| C434403 | 99.90 | C434511 | 100.10 | C434594 | 100.10 | C434677 | 100.40 | C434712 | 100.60 |
| C434740 | 100.10 | C434751 | 100.40 | C434844 | 99.90 | C434851 | 100.00 | C434892 | 100.20 |
| C434908 | 100.20 | C435063 | 100.00 | C435079 | 100.10 | C435115 | 100.40 | C435124 | 100.30 |
| C435163 | 100.10 | C435209 | 100.10 | W148280 | 99.80 | W148361 | 99.90 | W148429 | 100.00 |
| W148496 | 99.30 | W148510 | 99.70 | W148518 | 99.80 | W148710 | 100.20 | W148751 | 99.40 |
| W148836 | 99.80 | W148897 | 100.10 | W148902 | 98.80 | W148929 | 99.90 | W148934 | 96.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7502.70 |
| 3 | Sum of Squared Measurements | 750558.91 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750540.10 |
| 5 | Corrected Sum of Squares (SS) | 18.81 |
| 6 | Variance (V) : SS/(N-1) | 0.2542 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.5042 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.04 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 3.90 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 4.04 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: ALF  Division: 01  Sample Lot: 1241  Lot Descr: KU ALF -1

In Service Population: 18  Sample Quantity: 4  Meters Tested: 4  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2505754 | 99.90 | 2506205 | 99.80 | 2506206 | 99.90 | 2506208 | 99.90 | | |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 4 |
| 2 | Sum of Measurements: (Sum X) | 399.50 |
| 3 | Sum of Squared Measurements | 39900.07 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 39900.06 |
| 5 | Corrected Sum of Squares (SS) | 0.01 |
| 6 | Variance (V) : SS/(N-1) | 0.0025 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.0500 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.88 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 90.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 42.50 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 37.50 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Peroent NCF(M) | 10.88 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: C1SR  Division: 01  Sample Lot: 1242  Lot Descr: KU C1S - 1

In Service Population: 10,000  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2000184 | 99.90 | 2000199 | 99.80 | 2000482 | 100.00 | 2001021 | 100.00 | 2001068 | 100.10 |
| 2001345 | 100.00 | 2001346 | 100.10 | 2001366 | 100.10 | 2001473 | 100.00 | 2001672 | 100.10 |
| 2001680 | 100.00 | 2002361 | 100.10 | 2002421 | 100.00 | C352448 | 100.10 | C352474 | 100.00 |
| C352672 | 100.10 | C352734 | 100.20 | C369174 | 100.00 | C369472 | 100.00 | C380617 | 100.10 |
| C380741 | 100.00 | C380929 | 100.10 | C381019 | 100.00 | C381048 | 99.70 | C381340 | 100.10 |
| C381636 | 100.10 | C381663 | 100.20 | C381690 | 100.10 | C381757 | 99.90 | C381846 | 100.00 |
| C382340 | 100.00 | C382390 | 100.20 | C382416 | 100.20 | C382417 | 100.10 | C382464 | 100.00 |
| C382511 | 100.10 | C382549 | 100.00 | C382673 | 100.00 | C382716 | 100.20 | C382745 | 100.10 |
| C382929 | 100.20 | C383063 | 100.00 | C383241 | 100.10 | C383472 | 100.00 | C407204 | 100.10 |
| C407645 | 100.00 | C407833 | 100.10 | C407874 | 99.90 | C415906 | 100.20 | C416121 | 100.00 |
| C416195 | 100.00 | C416580 | 100.40 | C416721 | 100.00 | C417005 | 100.20 | C417033 | 100.40 |
| C417060 | 100.20 | C417222 | 100.10 | C417304 | 100.20 | C417453 | 100.10 | C417560 | 100.00 |
| C465695 | 99.90 | C465953 | 100.10 | C466103 | 100.10 | C466153 | 100.00 | C466198 | 100.00 |
| C466231 | 100.00 | C466319 | 99.80 | C466386 | 100.00 | C466507 | 99.90 | C466809 | 100.10 |
| C466936 | 100.00 | C467000 | 100.20 | C467193 | 99.90 | C467195 | 100.00 | C467277 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7504.10 |
| 3 | Sum of Squared Measurements | 750821.23 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750820.22 |
| 5 | Corrected Sum of Squares (SS) | 1.01 |
| 6 | Variance (V) : SS/(N-1) | 0.0136 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1166 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.05 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 16.69 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 17.62 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: C1S  Division: 01  Sample Lot: 1243  Lot Descr: KU C1S - 2

In Service Population: 10,000  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2002612 | 100.00 | 2002678 | 99.90 | 2002715 | 100.00 | 2002777 | 100.00 | 2002837 | 100.10 |
| 2003002 | 100.10 | 2003013 | 99.90 | 2003024 | 100.10 | 2003039 | 100.10 | 2003042 | 99.90 |
| 2003190 | 100.20 | 2003379 | 100.10 | 2003460 | 100.10 | 2003647 | 100.20 | 2003669 | 100.10 |
| 2003724 | 99.90 | 2003773 | 100.10 | 2003804 | 100.10 | 2003932 | 100.00 | 2003995 | 99.90 |
| 2004058 | 100.00 | 2004421 | 100.10 | 2004554 | 100.00 | 2004675 | 99.80 | 2004795 | 99.90 |
| 2005588 | 100.00 | 2005692 | 99.90 | 2005754 | 100.00 | 2005839 | 100.00 | 2005926 | 100.00 |
| 2006104 | 100.00 | 2006121 | 100.00 | 2006133 | 100.00 | 2006419 | 99.90 | 2006527 | 100.20 |
| 2006734 | 100.10 | 2006878 | 100.00 | 2007073 | 99.90 | 2007126 | 99.80 | 2007641 | 99.90 |
| 2007696 | 100.00 | 2007729 | 99.80 | 2007757 | 99.90 | 2007856 | 100.00 | 2008169 | 99.90 |
| 2008191 | 100.00 | 2008231 | 100.00 | 2008377 | 99.80 | 2008390 | 100.10 | 2008415 | 100.20 |
| 2008466 | 100.00 | 2008474 | 100.00 | 2008786 | 100.00 | 2008789 | 99.90 | 2008803 | 100.00 |
| 2500091 | 99.90 | 2500093 | 100.00 | 2500168 | 99.90 | 2500399 | 100.00 | 2500508 | 100.00 |
| 2500542 | 100.10 | 2500919 | 100.00 | 2501115 | 100.00 | 2501258 | 100.10 | 2501361 | 100.10 |
| 2501626 | 100.00 | 2501862 | 99.90 | C467584 | 100.10 | C467934 | 100.10 | C467996 | 100.20 |
| C468406 | 100.00 | C468761 | 99.90 | C468822 | 100.10 | C469274 | 100.00 | C469293 | 99.60 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7499.90 |
| 3 | Sum of Squared Measurements | 749980.87 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749980.00 |
| 5 | Corrected Sum of Squares (SS) | 0.87 |
| 6 | Variance (V) : SS/(N-1) | 0.0118 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1084 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.00 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 18.46 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 18.43 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: C1S  Division: 01  Sample Lot: 1244  Lot Descr: KU C1S - 3

In Service Population: 10,000  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2009308 | 99.90 | 2009463 | 99.90 | 2009646 | 100.00 | 2009687 | 99.90 | 2009880 | 99.90 |
| 2009903 | 100.10 | 2010276 | 99.90 | 2010414 | 100.00 | 2010769 | 100.00 | 2011123 | 100.00 |
| 2011512 | 100.10 | 2011640 | 100.00 | 2011653 | 100.00 | 2011700 | 99.90 | 2011786 | 100.00 |
| 2011787 | 100.00 | 2011802 | 100.00 | 2011974 | 99.90 | 2012488 | 100.00 | 2012727 | 100.10 |
| 2012880 | 100.10 | 2012973 | 100.00 | 2013318 | 100.00 | 2013328 | 100.00 | 2013472 | 100.00 |
| 2013501 | 99.80 | 2013672 | 99.90 | 2013890 | 99.90 | 2013892 | 100.10 | 2014156 | 100.00 |
| 2014348 | 99.90 | 2014851 | 100.00 | 2014868 | 100.00 | 2014955 | 100.00 | 2015122 | 100.10 |
| 2015257 | 100.00 | 2015676 | 100.00 | 2015764 | 100.10 | 2015781 | 100.10 | 2015920 | 100.00 |
| 2015921 | 100.00 | 2016297 | 99.70 | 2016699 | 100.00 | 2502100 | 100.00 | 2502138 | 99.90 |
| 2502247 | 99.90 | 2502306 | 100.10 | 2502453 | 100.10 | 2502473 | 100.10 | 2502629 | 100.00 |
| 2502711 | 100.00 | 2502744 | 99.90 | 2502746 | 99.90 | 2502927 | 100.00 | 2503107 | 100.00 |
| 2503163 | 100.10 | 2503258 | 99.90 | 2503352 | 100.00 | 2503362 | 100.00 | 2503400 | 100.00 |
| 2503429 | 100.00 | 2503457 | 99.90 | 2503726 | 100.10 | 2503904 | 99.80 | 2503919 | 99.90 |
| 2503922 | 100.00 | 2504183 | 100.00 | 2504337 | 100.10 | 2504364 | 100.00 | 2504376 | 100.00 |
| 2504463 | 100.00 | 2504725 | 100.00 | 2505209 | 100.10 | 2505292 | 100.10 | 2505403 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7499.20 |
| 3 | Sum of Squared Measurements | 749840.50 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749840.01 |
| 5 | Corrected Sum of Squares (SS) | 0.49 |
| 6 | Variance (V) : SS/(N-1) | 0.0066 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.0815 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.99 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 24.67 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 24.41 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: C1S  Division: 01  Sample Lot: 1245  Lot Descr: KU C1S - 4

In Service Population: 10,000  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2017058 | 100.10 | 2017244 | 99.90 | 2017314 | 100.00 | 2017477 | 99.90 | 2017487 | 100.10 |
| 2017502 | 100.10 | 2017548 | 100.00 | 2017768 | 100.00 | 2017896 | 100.00 | 2018504 | 99.90 |
| 2018522 | 100.00 | 2018531 | 100.00 | 2018807 | 100.00 | 2018865 | 99.80 | 2019033 | 99.90 |
| 2019076 | 100.00 | 2019155 | 99.90 | 2019898 | 100.00 | 2019904 | 100.00 | 2020469 | 99.90 |
| 2020490 | 100.10 | 2020534 | 100.00 | 2020596 | 100.00 | 2020725 | 99.90 | 2021268 | 100.00 |
| 2021632 | 100.00 | 2021942 | 100.00 | 2022027 | 100.00 | 2022078 | 100.00 | 2022087 | 100.00 |
| 2022253 | 100.00 | 2022367 | 100.00 | 2022503 | 99.90 | 2022699 | 99.90 | 2022714 | 100.00 |
| 2022898 | 99.90 | 2023148 | 99.90 | 2023299 | 99.90 | 2023377 | 99.80 | 2023434 | 100.00 |
| 2023572 | 100.00 | 2023579 | 100.00 | 2023677 | 100.00 | 2023691 | 100.00 | 2023847 | 100.00 |
| 2024027 | 99.90 | 2024122 | 100.00 | 2024343 | 100.10 | 2024498 | 99.90 | 2024508 | 100.10 |
| 2025228 | 100.00 | 2026356 | 100.00 | 2026586 | 100.10 | 2026748 | 100.00 | 2026936 | 100.00 |
| 2027277 | 99.90 | 2027286 | 100.10 | 2027677 | 100.00 | 2027713 | 99.80 | 2027852 | 100.00 |
| 2028358 | 99.90 | 2028919 | 100.00 | 2028943 | 100.00 | 2028946 | 100.00 | 2028984 | 100.10 |
| 2029109 | 100.00 | 2029120 | 100.10 | 2029319 | 100.10 | 2029384 | 99.90 | 2029485 | 100.10 |
| 2029746 | 100.10 | 2029753 | 100.00 | 2029817 | 100.10 | 2029970 | 99.90 | 2505839 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7499.00 |
| 3 | Sum of Squared Measurements | 749800.44 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749800.01 |
| 5 | Corrected Sum of Squares (SS) | 0.43 |
| 6 | Variance (V) : SS/(N-1) | 0.0058 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.0759 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.99 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 26.51 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 26.16 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: C1S  Division: 01  Sample Lot: 1246  Lot Descr: KU C1S - 5

In Service Population: 5,106  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| 2030580 | 100.00 | 2030803 | 100.00 | 2030825 | 100.10 | 2031085 | 100.10 | 2031099 | 100.10 |
| 2031128 | 100.20 | 2031165 | 100.00 | 2031201 | 100.00 | 2031217 | 100.00 | 2031300 | 100.00 |
| 2031364 | 100.20 | 2031508 | 100.00 | 2031921 | 100.10 | 2032037 | 100.00 | 2032047 | 100.00 |
| 2032139 | 100.10 | 2032278 | 100.00 | 2032295 | 100.10 | 2032328 | 100.10 | 2032346 | 99.90 |
| 2032366 | 100.00 | 2032497 | 100.10 | 2032521 | 100.00 | 2032664 | 100.10 | 2032686 | 100.00 |
| 2033167 | 100.00 | 2033218 | 100.10 | 2033283 | 100.00 | 2033804 | 99.90 | 2034084 | 100.00 |
| 2034089 | 100.10 | 2034158 | 100.00 | 2034174 | 100.00 | 2034213 | 100.10 | 2034229 | 100.10 |
| 2034261 | 100.00 | 2034271 | 100.00 | 2034313 | 100.00 | 2034420 | 99.90 | 2034440 | 100.00 |
| 2034478 | 100.10 | 2034502 | 99.90 | 2034536 | 100.10 | 2034553 | 100.10 | 2034559 | 100.10 |
| 2034588 | 100.00 | 2034594 | 100.00 | 2034723 | 100.10 | 2034784 | 100.00 | 2034815 | 100.00 |
| 2034987 | 100.00 | 2034989 | 100.00 | 2035090 | 99.90 | 2035102 | 100.10 | 2035129 | 100.00 |
| 2035193 | 100.10 | 2035246 | 100.00 | 2036336 | 100.00 | 2036374 | 100.20 | 2036634 | 100.00 |
| 2037795 | 100.10 | 2038748 | 99.90 | 2038764 | 100.00 | 2039330 | 100.10 | 2039374 | 99.90 |
| 2039573 | 100.00 | 2039803 | 99.90 | 2039806 | 100.00 | 2039896 | 100.10 | 2040541 | 100.00 |
| 2041204 | 100.00 | 2041336 | 100.00 | 2506100 | 100.00 | 2506108 | 100.00 | 2506958 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7502.00 |
| 3 | Sum of Squared Measurements | 750400.44 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750400.05 |
| 5 | Corrected Sum of Squares (SS) | 0.39 |
| 6 | Variance (V) : SS/(N-1) | 0.0052 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.0723 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.03 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 27.30 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 28.04 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1247 Lot Descr: KU D4S - 1
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C222815 | 100.10 | C222851 | 100.20 | C225116 | 99.90 | C225245 | 99.40 | C225254 | 99.70 |
| C226530 | 100.00 | C226537 | 99.70 | C227509 | 99.80 | C227533 | 100.50 | C227567 | 100.20 |
| C227791 | 100.00 | C227953 | 100.30 | C228087 | 100.30 | C228644 | 100.00 | C229470 | 99.40 |
| C229551 | 100.10 | C229813 | 100.30 | C230038 | 99.90 | C230324 | 99.70 | C233835 | 100.00 |
| C233952 | 99.70 | C236018 | 100.40 | C236163 | 100.20 | C236262 | 100.00 | C236762 | 99.80 |
| C236778 | 100.10 | L026842 | 100.30 | L129190 | 99.90 | L129223 | 100.00 | L136344 | 99.80 |
| L140705 | 99.70 | L140758 | 99.90 | L141165 | 100.20 | M345682 | 100.00 | M350661 | 100.20 |
| M350731 | 99.90 | M350861 | 100.00 | M351772 | 99.90 | M351905 | 100.00 | M352610 | 99.60 |
| M353114 | 99.90 | M353147 | 99.60 | M353357 | 99.90 | M353984 | 100.20 | M367733 | 99.30 |
| M367740 | 99.50 | M367742 | 100.20 | M367972 | 100.40 | M375332 | 100.20 | M375443 | 99.30 |
| M375629 | 100.30 | M375898 | 99.80 | M375995 | 100.50 | M376120 | 100.40 | M376360 | 100.10 |
| M376556 | 99.90 | M376813 | 99.00 | M380840 | 100.40 | M380866 | 100.00 | M381027 | 99.80 |
| M386248 | 99.80 | M386859 | 100.50 | W101054 | 100.20 | W102049 | 99.90 | W102514 | 100.40 |
| W102830 | 100.10 | W103756 | 100.10 | W104174 | 100.00 | W105100 | 100.10 | W105126 | 99.50 |
| W105464 | 100.00 | W108877 | 100.20 | W109639 | 100.20 | W109658 | 100.50 | W109675 | 99.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7499.10 |
| 3 | Sum of Squared Measurements | 749827.11 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749820.01 |
| 5 | Corrected Sum of Squares (SS) | 7.10 |
| 6 | Variance (V) : SS/(N-1) | 0.0959 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3097 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.99 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.50 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.42 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1248 Lot Descr: KU D4S - 2

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C237056 | 100.00 | C237059 | 99.60 | C240829 | 100.20 | C240870 | 100.30 | C240984 | 100.00 |
| C241018 | 100.20 | C241437 | 100.00 | C241484 | 99.50 | C241675 | 99.50 | C245285 | 100.30 |
| C245438 | 100.40 | C245560 | 100.10 | C245666 | 100.00 | C245686 | 99.80 | C245829 | 100.10 |
| C250496 | 99.70 | C254341 | 99.40 | C254505 | 100.00 | C254526 | 99.80 | C254527 | 100.00 |
| C255129 | 100.30 | L216227 | 100.50 | L216539 | 100.40 | L216544 | 100.30 | L216614 | 100.40 |
| L216619 | 100.40 | M385078 | 99.90 | M385082 | 99.20 | M385174 | 100.10 | M385187 | 100.00 |
| M385329 | 100.10 | M385529 | 99.60 | M385634 | 99.50 | M385769 | 99.90 | M386611 | 100.00 |
| M386641 | 100.10 | M389170 | 99.90 | M389367 | 99.90 | M390185 | 100.10 | M390702 | 99.30 |
| M392018 | 100.20 | M392189 | 99.90 | M392442 | 100.00 | M392005 | 99.80 | M392997 | 99.90 |
| M393296 | 99.80 | M396221 | 100.10 | M396338 | 99.00 | M396348 | 100.20 | M396494 | 100.20 |
| M397128 | 100.20 | M397216 | 100.20 | M397420 | 99.20 | M397478 | 99.70 | M397484 | 100.00 |
| M397588 | 99.80 | M397894 | 99.80 | M397924 | 100.00 | M398071 | 100.30 | M398492 | 100.10 |
| M398503 | 100.00 | M398671 | 100.10 | M398690 | 99.70 | M399170 | 100.30 | M399265 | 100.40 |
| W110601 | 100.30 | W110623 | 99.80 | W111480 | 100.10 | W114445 | 100.20 | W114488 | 99.80 |
| W114680 | 99.90 | W114843 | 100.00 | W116451 | 100.20 | W116626 | 99.90 | W116833 | 99.60 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7497.50 |
| 3 | Sum of Squared Measurements | 749507.17 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749500.08 |
| 5 | Corrected Sum of Squares (SS) | 7.09 |
| 6 | Variance (V) : SS/(N-1) | 0.0958 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3095 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.97 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.57 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.36 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1249 Lot Descr: KU D4S - 3

In Service Population: 6,577 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C222774 | 100.00 | C223796 | 99.80 | C223937 | 99.70 | C223950 | 100.30 | C250377 | 100.70 |
| C256746 | 100.20 | C256890 | 100.30 | C257125 | 99.90 | C257128 | 100.30 | C257332 | 99.90 |
| C257786 | 100.80 | C263899 | 99.90 | C263960 | 100.00 | C264161 | 99.80 | L221527 | 99.90 |
| L221668 | 99.60 | L221741 | 100.00 | L221861 | 100.40 | L221951 | 99.70 | L221993 | 99.50 |
| L223814 | 99.20 | L223821 | 99.40 | L223888 | 100.20 | L223911 | 100.10 | L223983 | 100.00 |
| L224244 | 100.00 | L224329 | 99.60 | L224340 | 100.10 | L224375 | 100.30 | L224574 | 99.50 |
| L224581 | 99.50 | L224614 | 100.00 | L224658 | 100.20 | L224677 | 99.80 | L224678 | 100.30 |
| L227776 | 99.70 | L227901 | 100.00 | L227989 | 99.70 | L228368 | 100.10 | L228411 | 99.30 |
| L228873 | 100.20 | L228963 | 100.00 | L228989 | 99.90 | M394566 | 99.90 | M394720 | 100.30 |
| M394734 | 100.30 | M394787 | 100.00 | M394831 | 100.20 | M395010 | 100.40 | M395407 | 99.70 |
| M395525 | 99.50 | M395730 | 99.60 | M395988 | 100.10 | M395992 | 100.20 | M399372 | 100.00 |
| M399427 | 100.00 | M401290 | 99.80 | M401351 | 100.10 | M401429 | 99.90 | M401477 | 99.80 |
| M401569 | 100.20 | M401736 | 100.20 | M412483 | 99.90 | M427854 | 99.90 | W119607 | 99.70 |
| W119625 | 100.10 | W119745 | 100.30 | W119877 | 99.90 | W119974 | 100.40 | W120071 | 99.40 |
| W120232 | 100.40 | W120416 | 99.50 | W120457 | 100.00 | W120476 | 99.90 | W120619 | 100.20 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7497.60 |
| 3 | Sum of Squared Measurements | 749527.34 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749520.08 |
| 5 | Corrected Sum of Squares (SS) | 7.26 |
| 6 | Variance (V) : SS/(N-1) | 0.0982 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3133 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.97 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.49 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.28 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: D5S Division: 01 Sample Lot: 1250 Lot Descr: KU D5S - 1

In Service Population: 449 Sample Quantity: 25 Meters Tested: 25 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C279688 | 99.30 | C279782 | 99.70 | C279817 | 100.40 | C279827 | 100.20 | C279862 | 99.70 |
| C279949 | 99.50 | C283435 | 99.30 | C283483 | 99.60 | C283522 | 99.80 | C283562 | 99.80 |
| C283610 | 99.40 | C283694 | 100.00 | C283699 | 99.50 | C298901 | 100.20 | C298919 | 100.30 |
| C298969 | 100.40 | C298971 | 100.60 | C299015 | 100.20 | C299016 | 100.10 | C299067 | 99.50 |
| C299087 | 100.10 | C299093 | 99.80 | C299133 | 100.10 | C299166 | 100.20 | M418978 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 25 |
| 2 | Sum of Measurements: (Sum X) | 2497.60 |
| 3 | Sum of Squared Measurements | 249523.52 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 249520.23 |
| 5 | Corrected Sum of Squares (SS) | 3.29 |
| 6 | Variance (V) : SS/(N-1) | 0.1371 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3702 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.90 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 5.66 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 5.14 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.98 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200E  Model Number: I210  Division: 01  Sample Lot: 1251  Lot Descr: KU I210 - 1

In Service Population: 5,194  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C432062 | 99.90 | C432199 | 99.90 | C432360 | 100.00 | C432387 | 100.00 | C432482 | 100.00 |
| C432512 | 99.90 | C432536 | 99.90 | C432629 | 100.00 | C432726 | 99.90 | C432819 | 99.90 |
| C432889 | 99.90 | C432931 | 99.80 | C433010 | 100.00 | C433051 | 99.90 | C433192 | 100.00 |
| C433419 | 99.90 | C445402 | 100.00 | C445470 | 100.00 | C445520 | 100.00 | C445608 | 100.10 |
| C445656 | 100.00 | C445678 | 99.90 | C445692 | 100.00 | C445741 | 99.90 | C445777 | 100.00 |
| C445817 | 100.00 | C445908 | 100.00 | C446046 | 100.00 | C446103 | 100.00 | C446189 | 99.90 |
| C446201 | 99.90 | C446298 | 99.90 | C446302 | 100.00 | C446320 | 100.00 | C456459 | 100.00 |
| C456564 | 100.00 | C456615 | 100.00 | C456675 | 99.90 | C456735 | 99.97 | C456849 | 99.90 |
| C456947 | 100.00 | C456991 | 99.90 | C457101 | 99.90 | C457247 | 99.80 | C457319 | 99.90 |
| C457358 | 100.00 | C457386 | 100.00 | C457423 | 100.00 | C457595 | 99.90 | C463526 | 100.00 |
| C463528 | 99.80 | C463557 | 99.90 | C464055 | 100.00 | C464247 | 100.00 | C464257 | 100.00 |
| C464261 | 100.00 | C464271 | 100.00 | C464308 | 100.00 | C464377 | 100.00 | C464446 | 100.00 |
| C464449 | 100.10 | C464614 | 100.00 | C464756 | 99.90 | C464806 | 100.10 | C464907 | 100.00 |
| C464920 | 100.03 | C464930 | 99.90 | C465080 | 100.10 | C465179 | 99.90 | C465352 | 100.00 |
| C465453 | 100.00 | C465466 | 100.10 | C465476 | 100.00 | C465565 | 100.00 | C465591 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7497.40 |
| 3 | Sum of Squared Measurements | 749480.42 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749480.09 |
| 5 | Corrected Sum of Squares (SS) | 0.33 |
| 6 | Variance (V) : SS/(N-1) | 0.0045 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.0669 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.97 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 30.39 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 29.36 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V15AC100 Model Number: I50S Division: 01 Sample Lot: 1252 Lot Descr: KU I50 - 1

In Service Population: 1,085 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C169242 | 100.40 | C182421 | 100.20 | C182844 | 100.20 | C284749 | 100.00 | L019149 | 100.10 |
| L061653 | 99.90 | L062052 | 100.00 | L062268 | 99.70 | L062355 | 99.70 | L062392 | 100.20 |
| L063150 | 100.30 | L065078 | 99.90 | L065591 | 99.90 | L066897 | 100.20 | L066906 | 100.00 |
| L067511 | 100.00 | L070259 | 100.30 | L070542 | 99.90 | L071842 | 99.90 | L071982 | 99.40 |
| L072836 | 99.70 | L072977 | 100.10 | L073337 | 99.80 | L073342 | 99.70 | L074973 | 99.70 |
| L075209 | 100.00 | M431334 | 99.87 | W073818 | 100.00 | W075207 | 100.00 | W075249 | 100.00 |
| W078351 | 100.00 | W079012 | 100.00 | W079327 | 100.10 | W079572 | 101.10 | W082808 | 99.50 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 35 |
| 2 | Sum of Measurements: (Sum X) | 3499.77 |
| 3 | Sum of Squared Measurements | 349956.91 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 349954.00 |
| 5 | Corrected Sum of Squares (SS) | 2.91 |
| 6 | Variance (V) : SS/(N-1) | 0.0855 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2923 |
| 0 | Sample Mean(XBAR): Sum X/N | 99.99 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.86 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.82 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.58 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V15AC100 Model Number: I55S Division: 01 Sample Lot: 1253 Lot Descr: KU I55 - 1

In Service Population: 960 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C199019 | 99.60 | C200277 | 100.20 | L005532 | 100.00 | L010027 | 99.60 | L076265 | 100.00 |
| L076392 | 100.10 | L076594 | 100.30 | L076777 | 100.00 | L076828 | 100.20 | L077260 | 100.30 |
| L077945 | 100.30 | L078560 | 99.80 | L078767 | 100.00 | L079247 | 100.10 | L079920 | 100.00 |
| L080683 | 99.70 | L080737 | 99.70 | L080767 | 99.60 | L081332 | 100.00 | L082120 | 99.70 |
| L082447 | 99.80 | L082897 | 100.00 | L083253 | 99.90 | L083300 | 99.80 | L083710 | 99.60 |
| L083804 | 99.80 | L084271 | 99.60 | L085817 | 99.30 | L086320 | 99.70 | L086796 | 99.90 |
| L086995 | 99.60 | L087492 | 99.60 | L087983 | 99.50 | L089060 | 99.90 | M417382 | 100.30 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 35 |
| 2 | Sum of Measurements: (Sum X) | 3495.50 |
| 3 | Sum of Squared Measurements | 349102.87 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 349100.58 |
| 5 | Corrected Sum of Squares (SS) | 2.29 |
| 6 | Variance (V) : SS/(N-1) | 0.0674 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2596 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.87 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.20 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.21 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.58 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1254 Lot Descr: KU I60 - 1
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C203550 | 100.30 | C203717 | 100.10 | C204346 | 100.20 | C204380 | 100.60 | C204802 | 99.80 |
| C204889 | 100.30 | C205994 | 99.90 | C217686 | 100.40 | L000329 | 100.10 | L004099 | 100.10 |
| L004699 | 99.70 | L006277 | 100.00 | L006323 | 99.80 | L008918 | 100.10 | L009821 | 99.80 |
| L014348 | 100.20 | L014387 | 100.20 | L014989 | 99.90 | L018659 | 99.90 | L086208 | 100.10 |
| L090761 | 99.90 | L091096 | 100.20 | L092281 | 99.90 | L092579 | 99.70 | L092598 | 100.30 |
| L093158 | 99.90 | L093212 | 100.10 | L093549 | 99.90 | L094143 | 99.90 | L094172 | 99.50 |
| L094180 | 99.70 | L094815 | 99.70 | L096517 | 99.80 | L096802 | 100.00 | L096940 | 99.60 |
| L097408 | 100.00 | L097655 | 99.20 | L097736 | 99.90 | L097749 | 100.20 | L098481 | 99.90 |
| L098661 | 99.80 | L099409 | 100.00 | L099786 | 99.90 | L100632 | 99.90 | L100680 | 100.10 |
| L101269 | 99.90 | L101359 | 99.50 | L101395 | 100.10 | L101656 | 100.00 | L102416 | 99.90 |
| L102442 | 100.00 | L102494 | 100.00 | L102587 | 100.20 | L102663 | 99.80 | L102809 | 99.90 |
| L102856 | 100.00 | L103048 | 100.00 | L103109 | 99.60 | L103121 | 99.80 | L103731 | 100.40 |
| L103782 | 100.00 | L103884 | 100.00 | L104245 | 99.80 | L104371 | 100.00 | L104653 | 100.30 |
| L104748 | 99.90 | L104770 | 99.80 | L105259 | 99.90 | L105601 | 99.90 | L106350 | 99.70 |
| L106354 | 100.20 | L106816 | 99.80 | L106906 | 100.30 | L107112 | 99.80 | L107892 | 99.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7496.80 |
| 3 | Sum of Squared Measurements | 749364.06 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749360.14 |
| 5 | Corrected Sum of Squares (SS) | 3.92 |
| 6 | Variance (V) : SS/(N-1) | 0.0530 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2303 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.96 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.87 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.50 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1255 Lot Descr: KU I60 - 2

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C208323 | 100.40 | C209619 | 100.20 | C210784 | 100.20 | C210839 | 100.20 | C212485 | 100.30 |
| C212520 | 100.30 | C220002 | 100.30 | L000768 | 100.10 | L000796 | 99.80 | L001899 | 99.90 |
| L003720 | 100.00 | L003852 | 99.80 | L004573 | 99.80 | L004640 | 100.10 | L005270 | 99.80 |
| L007582 | 99.80 | L009099 | 100.00 | L010740 | 100.40 | L012387 | 100.00 | L014312 | 99.50 |
| L018311 | 99.60 | L033765 | 100.00 | L040088 | 99.90 | L073283 | 99.60 | L074111 | 99.40 |
| L081075 | 99.70 | L082982 | 99.60 | L088232 | 99.70 | L108284 | 99.80 | L108381 | 100.10 |
| L108717 | 100.30 | L108864 | 100.00 | L109490 | 99.90 | L109640 | 99.50 | L110007 | 99.70 |
| L110106 | 100.10 | L110244 | 99.90 | L110389 | 99.40 | L111160 | 99.70 | L111334 | 99.80 |
| L111409 | 100.00 | L111703 | 99.90 | L112090 | 100.30 | L112232 | 99.90 | L112278 | 100.20 |
| L112713 | 100.20 | L112813 | 100.00 | L113121 | 99.80 | L113252 | 100.40 | L113551 | 99.50 |
| L113723 | 99.40 | L113897 | 99.60 | L114268 | 100.00 | L114284 | 100.00 | L114804 | 99.70 |
| L114806 | 99.70 | L115518 | 100.10 | L115600 | 99.90 | L115638 | 100.30 | L115644 | 100.00 |
| L115895 | 99.90 | L116000 | 100.00 | L116491 | 100.30 | L116701 | 100.20 | L116808 | 99.50 |
| L116846 | 100.00 | L117274 | 99.90 | L117300 | 99.70 | L117301 | 99.80 | L117312 | 100.00 |
| L117363 | 99.70 | L117632 | 99.90 | L117691 | 100.10 | L117800 | 100.00 | L118213 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7494.50 |
| 3 | Sum of Squared Measurements | 748905.31 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 748900.40 |
| 5 | Corrected Sum of Squares (SS) | 4.91 |
| 6 | Variance (V) : SS/(N-1) | 0.0663 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2575 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.93 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.05 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.48 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1256 Lot Descr: KU I60 - 3
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C217785 | 100.40 | C219945 | 100.30 | L000090 | 99.90 | L004852 | 100.60 | L005941 | 100.30 |
| L006030 | 100.10 | L013372 | 99.90 | L015191 | 100.00 | L016681 | 100.10 | L024042 | 100.30 |
| L029758 | 100.10 | L042322 | 99.90 | L069557 | 100.40 | L072229 | 100.30 | L077081 | 100.10 |
| L080300 | 100.30 | L084533 | 99.90 | L086048 | 100.00 | L086963 | 100.00 | L090325 | 100.00 |
| L091637 | 99.90 | L097182 | 100.00 | L097911 | 100.30 | L098097 | 99.50 | L100795 | 100.00 |
| L118356 | 100.20 | L118549 | 100.00 | L118721 | 100.10 | L118955 | 99.70 | L119628 | 100.00 |
| L119760 | 99.80 | L119798 | 100.00 | L119991 | 100.10 | L120057 | 100.00 | L120067 | 99.70 |
| L120558 | 99.80 | L120855 | 100.50 | L121049 | 99.90 | L121274 | 100.20 | L121306 | 100.20 |
| L121331 | 99.70 | L121607 | 100.10 | L121836 | 99.70 | L121861 | 100.10 | L121920 | 99.60 |
| L122038 | 100.50 | L122153 | 99.70 | L122228 | 99.90 | L122552 | 100.00 | L122912 | 100.20 |
| L122996 | 100.00 | L123030 | 100.20 | L123073 | 100.10 | L123130 | 100.10 | L123199 | 100.00 |
| L123241 | 100.10 | L123247 | 100.10 | L123465 | 100.00 | L123848 | 99.90 | L123945 | 100.00 |
| L124035 | 100.00 | L124092 | 100.00 | L124343 | 100.40 | L124489 | 100.40 | L124703 | 99.70 |
| L124756 | 100.20 | L125790 | 100.20 | L126459 | 100.20 | L126475 | 100.00 | L126587 | 99.80 |
| L126630 | 100.30 | L126997 | 100.30 | L127117 | 99.70 | L127538 | 99.60 | L127830 | 100.20 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7503.80 |
| 3 | Sum of Squared Measurements | 750764.10 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750760.19 |
| 5 | Corrected Sum of Squares (SS) | 3.91 |
| 6 | Variance (V) : SS/(N-1) | 0.0528 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2298 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.05 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.48 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.92 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1257 Lot Descr: KU I60 - 4

In Service Population: 92 Sample Quantity: 10 Meters Tested: 10 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C298463 | 100.10 | C298466 | 100.00 | C298467 | 100.30 | L268381 | 100.00 | L268393 | 100.10 |
| L268424 | 100.30 | L268430 | 100.10 | L268437 | 99.90 | L268443 | 100.00 | L268479 | 100.20 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 10 |
| 2 | Sum of Measurements: (Sum X) | 1001.00 |
| 3 | Sum of Squared Measurements | 100200.26 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 100200.10 |
| 5 | Corrected Sum of Squares (SS) | 0.16 |
| 6 | Variance (V) : SS/(N-1) | 0.0178 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1333 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.10 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 14.25 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 15.75 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 7.26 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1258 Lot Descr: KU I70 - 1
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C225706 | 100.00 | C225766 | 99.00 | C225853 | 100.00 | C226950 | 100.40 | C227072 | 100.10 |
| C227079 | 100.00 | C229079 | 100.20 | C229094 | 100.30 | C229230 | 100.20 | L004661 | 100.00 |
| L006385 | 100.20 | L006754 | 100.20 | L009217 | 99.80 | L010785 | 100.10 | L011225 | 99.90 |
| L014730 | 100.30 | L015822 | 100.10 | L015827 | 100.20 | L016552 | 100.10 | L017270 | 99.80 |
| L020960 | 100.20 | L025259 | 100.10 | L026581 | 100.10 | L027168 | 100.10 | L027715 | 100.10 |
| L029382 | 100.00 | L034091 | 100.10 | L067764 | 100.30 | L069014 | 100.40 | L069257 | 100.20 |
| L081197 | 99.80 | L088317 | 100.10 | L093927 | 100.40 | L094302 | 100.40 | L094621 | 100.20 |
| L099031 | 99.80 | L099693 | 100.00 | L103926 | 100.10 | L127938 | 99.90 | L128249 | 100.00 |
| L128565 | 98.90 | L128745 | 100.10 | L128832 | 100.20 | L128869 | 99.80 | L128893 | 99.70 |
| L128987 | 99.60 | L129060 | 100.10 | L129835 | 100.20 | L129938 | 100.40 | L129988 | 100.00 |
| L129993 | 99.80 | L130195 | 100.30 | L130666 | 100.00 | L130729 | 99.90 | L130890 | 100.20 |
| L131322 | 100.00 | L131521 | 100.00 | L131567 | 99.90 | L131569 | 100.00 | L131619 | 100.00 |
| L132323 | 100.30 | L132488 | 100.40 | L133637 | 100.40 | L133702 | 100.50 | L133868 | 100.30 |
| L134051 | 100.00 | L134112 | 100.10 | L134168 | 100.10 | L134363 | 100.60 | L134390 | 100.20 |
| L134996 | 99.90 | L135891 | 100.10 | L227157 | 100.10 | M351430 | 99.70 | W100626 | 99.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7505.60 |
| 3 | Sum of Squared Measurements | 751124.84 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 751120.42 |
| 5 | Corrected Sum of Squares (SS) | 4.42 |
| 6 | Variance (V) : SS/(N-1) | 0.0598 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2444 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.07 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.88 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.49 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1259 Lot Descr: KU I70 - 2

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C229321 | 100.20 | C229341 | 100.30 | C230725 | 100.30 | C230758 | 99.90 | C232988 | 100.30 |
| C233073 | 100.20 | C233174 | 100.00 | C234977 | 100.20 | C238310 | 100.30 | L136551 | 100.10 |
| L136564 | 100.30 | L136620 | 100.40 | L136783 | 100.40 | L137036 | 100.10 | L137098 | 100.40 |
| L137253 | 100.40 | L137407 | 99.90 | L138393 | 100.50 | L138525 | 100.30 | L138731 | 100.00 |
| L138865 | 100.10 | L138974 | 99.80 | L139008 | 100.50 | L139089 | 100.10 | L139446 | 100.70 |
| L139624 | 100.10 | L140237 | 99.90 | L140424 | 100.30 | L140618 | 99.90 | L140948 | 100.10 |
| L141882 | 100.10 | L142080 | 100.20 | L142439 | 100.30 | L142541 | 99.80 | L142654 | 100.40 |
| L143291 | 100.30 | L143365 | 100.10 | L143839 | 100.20 | L143994 | 99.60 | L144228 | 100.30 |
| L144749 | 100.50 | L144967 | 100.40 | L145164 | 100.60 | L145313 | 100.40 | L145741 | 100.20 |
| L145795 | 100.40 | L146054 | 100.10 | L146112 | 100.50 | L146164 | 100.40 | L146299 | 100.30 |
| L146419 | 100.40 | L146492 | 100.20 | L146538 | 100.10 | L146721 | 100.30 | L146801 | 100.20 |
| L146902 | 100.10 | L146991 | 100.00 | L147158 | 99.90 | L147555 | 100.20 | L148179 | 100.19 |
| L148251 | 100.20 | L148383 | 100.10 | L148473 | 100.10 | L148841 | 100.10 | L148898 | 100.20 |
| L148929 | 100.00 | L148950 | 100.20 | L148992 | 100.40 | L149015 | 100.10 | L149157 | 100.10 |
| W104084 | 100.30 | W104448 | 100.20 | W104465 | 99.90 | W107695 | 100.10 | W107696 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7514.79 |
| 3 | Sum of Squared Measurements | 752963.82 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 752960.92 |
| 5 | Corrected Sum of Squares (SS) | 2.90 |
| 6 | Variance (V) : SS/(N-1) | 0.0392 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1979 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.20 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.11 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 11.10 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1260 Lot Descr: KU I70 - 3

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C238861 | 100.10 | C238938 | 99.70 | C239069 | 100.40 | C243177 | 100.20 | C243501 | 100.40 |
| C243670 | 100.30 | L170063 | 100.20 | L170078 | 100.40 | L170110 | 100.30 | L170347 | 99.90 |
| L170398 | 100.60 | L170596 | 99.70 | L170796 | 100.00 | L170876 | 100.60 | L170913 | 99.90 |
| L170990 | 100.20 | L171372 | 100.40 | L171465 | 100.20 | L171667 | 100.00 | L171725 | 100.10 |
| L172130 | 100.00 | L172141 | 99.90 | L172288 | 100.20 | L172350 | 100.30 | L172615 | 100.40 |
| L172710 | 100.00 | L172790 | 100.20 | L172800 | 100.50 | L173229 | 100.10 | L173900 | 100.10 |
| L173939 | 99.90 | L174180 | 100.10 | L174185 | 100.10 | L174249 | 100.20 | L174400 | 99.80 |
| L174616 | 93.90 | L174623 | 99.80 | L174928 | 99.70 | L175026 | 99.80 | L175351 | 100.50 |
| L175663 | 100.50 | L175725 | 99.70 | L176494 | 99.80 | L176504 | 100.20 | L176755 | 100.20 |
| L176772 | 99.90 | L176779 | 99.60 | L176896 | 99.80 | L177561 | 98.10 | L177623 | 99.90 |
| L177675 | 100.10 | L177687 | 99.80 | L177815 | 100.20 | L178550 | 99.90 | L179576 | 100.10 |
| L180200 | 99.90 | L180226 | 100.10 | L180420 | 100.10 | L180460 | 100.10 | L180746 | 99.90 |
| L181070 | 99.80 | L181106 | 100.20 | L181209 | 100.00 | L181301 | 99.40 | L181960 | 99.90 |
| L182058 | 99.80 | L182088 | 100.40 | L182174 | 100.20 | L182545 | 100.00 | L182561 | 100.20 |
| L183462 | 99.90 | L183756 | 100.00 | L183880 | 100.10 | W109370 | 100.20 | W109378 | 100.30 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7497.40 |
| 3 | Sum of Squared Measurements | 749525.60 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749480.09 |
| 5 | Corrected Sum of Squares (SS) | 45.51 |
| 6 | Variance (V) : SS/(N-1) | 0.6150 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.7842 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.97 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 2.59 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 2.51 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.41 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.53 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.94 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1261 Lot Descr: KU I70 - 4

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| L183998 | 100.00 | L184175 | 100.40 | L184896 | 99.90 | L185585 | 99.90 | L185825 | 99.90 |
| L185833 | 99.50 | L186040 | 99.80 | L186077 | 100.00 | L186813 | 100.00 | L186922 | 100.00 |
| L187243 | 99.90 | L187322 | 100.20 | L187339 | 100.70 | L187505 | 100.20 | L187526 | 100.20 |
| L187633 | 100.30 | L187690 | 100.00 | L187720 | 99.80 | L187738 | 100.30 | L188533 | 99.80 |
| L188599 | 99.90 | L188703 | 100.10 | L188770 | 99.90 | L188821 | 99.80 | L188960 | 99.90 |
| L189072 | 99.90 | L189092 | 99.90 | L189142 | 99.80 | L189181 | 99.90 | L189262 | 99.80 |
| L189281 | 100.00 | L189372 | 99.90 | L189564 | 99.90 | L190560 | 100.10 | L190811 | 100.30 |
| L190831 | 100.30 | L190895 | 99.70 | L191002 | 100.10 | L191278 | 99.90 | L191296 | 99.30 |
| L191486 | 99.90 | L191699 | 100.10 | L191828 | 100.00 | L191847 | 100.00 | L192146 | 100.30 |
| L192361 | 100.10 | L192482 | 100.20 | L192715 | 100.00 | L192809 | 99.90 | L192993 | 99.80 |
| L193003 | 100.10 | L194866 | 99.80 | L194981 | 99.60 | L195141 | 100.10 | L195243 | 100.40 |
| L195717 | 99.80 | L195807 | 99.90 | L195848 | 99.60 | L196047 | 100.10 | L196310 | 100.10 |
| L196349 | 100.10 | L196397 | 99.80 | L196543 | 99.70 | L196756 | 100.10 | L197540 | 100.00 |
| L197590 | 100.10 | L198579 | 99.80 | L198678 | 99.90 | L199660 | 100.00 | L199885 | 99.80 |
| L200023 | 99.90 | L200262 | 100.50 | M384398 | 100.00 | M384457 | 99.90 | M384853 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7498.50 |
| 3 | Sum of Squared Measurements | 749703.71 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749700.03 |
| 5 | Corrected Sum of Squares (SS) | 3.68 |
| 6 | Variance (V) : SS/(N-1) | 0.0497 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2230 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.98 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.06 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.88 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1262 Lot Descr: KU I70 - 5

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C247730 | 100.40 | C247841 | 100.20 | C247902 | 100.30 | C247951 | 100.30 | C248084 | 100.00 |
| C248224 | 100.30 | C248278 | 100.60 | C248448 | 100.40 | C248590 | 100.10 | C248654 | 100.60 |
| C252282 | 100.30 | C252310 | 100.50 | C252324 | 100.20 | C252357 | 100.20 | C252388 | 100.00 |
| C252593 | 100.30 | C253033 | 100.30 | L042150 | 100.00 | L201614 | 99.90 | L201970 | 100.10 |
| L202034 | 100.00 | L202177 | 100.00 | L203417 | 100.00 | L203823 | 99.70 | L203901 | 99.70 |
| L204205 | 100.00 | L204218 | 99.70 | L204299 | 100.10 | L204444 | 100.00 | L204506 | 99.70 |
| L204861 | 100.00 | L204948 | 99.90 | L205021 | 100.00 | L205286 | 99.80 | L205712 | 99.80 |
| L205730 | 99.90 | L205753 | 100.00 | L206011 | 100.10 | L206022 | 100.10 | L206027 | 99.90 |
| L206058 | 100.10 | L206153 | 100.40 | L206180 | 99.60 | L206843 | 99.80 | L206863 | 99.90 |
| L206895 | 99.70 | L206947 | 99.40 | L207453 | 100.00 | L207592 | 100.10 | L207708 | 99.90 |
| L207823 | 100.20 | L208040 | 100.20 | L208768 | 100.00 | L208779 | 100.20 | L208787 | 99.90 |
| L208877 | 100.00 | L208979 | 100.10 | L209017 | 99.70 | L210578 | 100.00 | L211856 | 100.20 |
| L211888 | 100.20 | L212026 | 99.70 | L212131 | 100.10 | L212227 | 100.10 | L213059 | 100.30 |
| L213193 | 100.40 | L213452 | 100.40 | L213655 | 100.10 | L214125 | 100.00 | L214228 | 99.90 |
| L214331 | 100.00 | W116255 | 99.80 | W116264 | 99.70 | W117511 | 100.20 | W117610 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7503.60 |
| 3 | Sum of Squared Measurements | 750724.36 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750720.17 |
| 5 | Corrected Sum of Squares (SS) | 4.19 |
| 6 | Variance (V) : SS/(N-1) | 0.0566 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2379 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.05 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.21 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.61 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1263 Lot Descr: KU I70 - 6
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C255509 | 100.10 | C255772 | 100.00 | C255801 | 100.10 | C256343 | 100.40 | C256521 | 100.70 |
| C256613 | 100.20 | C261579 | 100.70 | L214545 | 99.80 | L214666 | 100.10 | L214759 | 100.00 |
| L214889 | 99.90 | L215179 | 99.60 | L215507 | 100.00 | L216080 | 100.20 | L217036 | 100.20 |
| L217513 | 100.00 | L217728 | 100.60 | L217927 | 100.00 | L218006 | 100.00 | L218013 | 99.90 |
| L218089 | 100.20 | L218092 | 100.30 | L219516 | 100.10 | L219645 | 100.10 | L219845 | 99.90 |
| L219868 | 100.10 | L220037 | 100.20 | L220047 | 100.10 | L220291 | 100.00 | L220439 | 100.40 |
| L220656 | 100.40 | L222285 | 100.40 | L222440 | 100.20 | L224908 | 99.80 | L224971 | 100.60 |
| L224972 | 100.30 | L225081 | 100.10 | L225205 | 100.10 | L225790 | 100.00 | L226018 | 99.70 |
| L226069 | 100.20 | L226192 | 100.30 | L226511 | 100.40 | L226564 | 100.00 | L226584 | 99.60 |
| L226684 | 100.10 | L227033 | 100.10 | L227040 | 100.00 | L227606 | 99.90 | L227720 | 100.50 |
| L227721 | 100.40 | M402002 | 99.70 | M402204 | 100.30 | M402235 | 100.10 | M402245 | 100.20 |
| M402403 | 100.20 | M402480 | 100.00 | M402543 | 100.10 | M402578 | 100.00 | M403609 | 100.20 |
| M403748 | 99.90 | M404092 | 99.70 | M404199 | 99.70 | M404230 | 100.10 | M404433 | 100.30 |
| M404745 | 100.60 | M427267 | 100.10 | M427382 | 100.30 | W119031 | 99.70 | W119270 | 100.30 |
| W119276 | 100.00 | W119325 | 100.40 | W119510 | 100.60 | W120702 | 100.60 | W121112 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7510.10 |
| 3 | Sum of Squared Measurements | 752026.23 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 752021.36 |
| 5 | Corrected Sum of Squares (SS) | 4.87 |
| 6 | Variance (V) : SS/(N-1) | 0.0658 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2565 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.13 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.27 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.32 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1264 Lot Descr: KU I70 - 7

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C261703 | 100.30 | C262018 | 100.40 | C262516 | 100.00 | C267265 | 99.80 | C267350 | 100.20 |
| C267445 | 99.70 | C272111 | 100.70 | C272203 | 100.00 | C272213 | 100.20 | C272279 | 100.00 |
| C272541 | 100.00 | C272606 | 99.70 | C272851 | 99.70 | C272878 | 100.00 | C272926 | 100.00 |
| C276878 | 99.90 | C276882 | 100.20 | C277012 | 100.00 | C277014 | 100.10 | C277041 | 100.30 |
| C277125 | 100.20 | C277128 | 100.50 | C277240 | 100.10 | C277375 | 100.10 | L233722 | 100.20 |
| L233931 | 100.00 | L234099 | 100.10 | L234219 | 100.30 | L234552 | 100.20 | L234591 | 100.00 |
| L234672 | 99.60 | L235152 | 99.70 | L235237 | 99.80 | L235288 | 100.00 | L235573 | 100.10 |
| L235603 | 99.90 | L237558 | 100.00 | L237630 | 100.00 | L237843 | 100.20 | L237982 | 100.20 |
| L238615 | 99.80 | L238715 | 100.10 | L238833 | 100.00 | L238834 | 99.80 | L238910 | 100.10 |
| L239033 | 100.00 | L239176 | 100.00 | L239763 | 100.00 | L239773 | 99.90 | L239830 | 99.90 |
| L241227 | 99.60 | L241604 | 100.10 | L241714 | 100.10 | L242346 | 100.30 | L242416 | 100.10 |
| L242729 | 99.90 | L242824 | 100.00 | L242850 | 100.20 | L244320 | 100.00 | L244336 | 100.10 |
| L244344 | 100.10 | L244348 | 100.30 | L244409 | 100.00 | L244555 | 100.00 | M416901 | 99.80 |
| M416982 | 100.10 | W121584 | 99.90 | W121676 | 100.10 | W122540 | 100.10 | W122658 | 100.00 |
| W123141 | 100.10 | W123260 | 100.20 | W123438 | 100.00 | W123848 | 100.60 | W123927 | 100.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7504.50 |
| 3 | Sum of Squared Measurements | 750903.85 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750900.27 |
| 5 | Corrected Sum of Squares (SS) | 3.58 |
| 6 | Variance (V) : SS/(N-1) | 0.0484 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2200 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.06 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.82 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 9.37 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1265 Lot Descr: KU I70 - 8

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C277492 | 100.10 | C281363 | 100.30 | C281374 | 100.30 | C281860 | 100.40 | C282040 | 100.20 |
| C286803 | 100.20 | C286875 | 100.10 | C286904 | 100.20 | C287007 | 99.90 | C287109 | 100.40 |
| C287179 | 100.30 | C287702 | 100.30 | C287722 | 100.20 | C290091 | 99.80 | C290158 | 100.20 |
| C290237 | 100.10 | C290425 | 100.00 | C290587 | 100.10 | C290688 | 100.10 | C290730 | 99.80 |
| C292546 | 100.00 | C292752 | 100.10 | C292824 | 100.00 | C292948 | 100.00 | C293059 | 99.90 |
| C293271 | 100.20 | C293375 | 99.90 | C293499 | 100.20 | C293598 | 100.20 | C293705 | 100.40 |
| C294012 | 100.20 | C294025 | 100.00 | C294125 | 99.90 | C294166 | 100.30 | C294338 | 100.50 |
| L262193 | 100.30 | L262420 | 100.20 | L262791 | 100.30 | L262954 | 100.30 | L262981 | 100.30 |
| L263101 | 100.10 | L263114 | 100.30 | L263256 | 100.30 | L263606 | 99.90 | L263751 | 99.90 |
| L263787 | 100.00 | L263873 | 99.80 | L263904 | 100.30 | M420112 | 100.10 | M420289 | 99.90 |
| M420340 | 99.90 | M420707 | 99.90 | M420718 | 99.70 | M420812 | 100.20 | W124480 | 100.00 |
| W124631 | 99.90 | W124680 | 99.90 | W125485 | 99.80 | W125627 | 99.80 | W125658 | 100.10 |
| W126484 | 100.20 | W127250 | 100.10 | W127459 | 99.90 | W128359 | 100.00 | W128416 | 100.30 |
| W128434 | 99.70 | W128491 | 99.90 | W128589 | 100.00 | W129017 | 100.10 | W129328 | 99.90 |
| W129436 | 100.00 | W130346 | 100.00 | W131323 | 100.10 | W131455 | 99.90 | W131487 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7506.10 |
| 3 | Sum of Squared Measurements | 751223.03 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 751220.50 |
| 5 | Corrected Sum of Squares (SS) | 2.53 |
| 6 | Variance (V) : SS/(N-1) | 0.0342 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1850 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.08 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 10.37 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 11.25 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC20D  Model Number: I70S  Division: 01  Sample Lot: 1266  Lot Descr: KU I70 - 9
In Service Population: 10,000  Sample Quantity: 75  Meters Tested: 75  Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C294260 | 100.30 | C294263 | 100.20 | C294383 | 100.10 | C294395 | 100.00 | C294584 | 99.90 |
| C294625 | 100.00 | C295873 | 100.30 | C295911 | 100.20 | C296274 | 100.10 | C296329 | 100.10 |
| C296462 | 100.00 | C296532 | 100.00 | C296603 | 100.00 | C296686 | 100.30 | C296825 | 100.10 |
| C296826 | 100.40 | C299384 | 100.30 | C299520 | 100.30 | C299783 | 100.00 | C299960 | 100.20 |
| C299965 | 100.20 | C300182 | 100.40 | C305104 | 100.10 | C305329 | 100.50 | C305638 | 99.60 |
| C305659 | 100.40 | L264158 | 99.70 | L264234 | 100.10 | L264245 | 99.90 | L264366 | 99.90 |
| L264414 | 99.80 | L264641 | 100.00 | L265336 | 99.90 | L265352 | 100.10 | L265430 | 100.20 |
| L265447 | 100.00 | L265732 | 100.10 | L265921 | 100.10 | L266014 | 100.10 | L266115 | 100.40 |
| L266173 | 100.30 | L266765 | 100.40 | L266769 | 99.90 | L266785 | 99.80 | L276595 | 100.10 |
| L276954 | 100.20 | L277160 | 99.90 | L277173 | 100.00 | L277413 | 99.80 | L277464 | 99.80 |
| M433917 | 100.40 | M434077 | 100.10 | M434101 | 100.10 | M434104 | 100.40 | M434131 | 100.40 |
| M434146 | 100.20 | M434230 | 100.40 | M434383 | 100.20 | M434407 | 100.20 | M434450 | 100.20 |
| M438036 | 99.90 | M438038 | 99.80 | M438045 | 100.00 | M438076 | 100.30 | M438574 | 100.20 |
| W131858 | 99.80 | W131802 | 100.20 | W132685 | 100.10 | W132689 | 100.00 | W132697 | 100.10 |
| W132806 | 100.40 | W133646 | 100.40 | W133919 | 100.30 | W134014 | 100.30 | W136034 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7509.00 |
| 3 | Sum of Squared Measurements | 751804.02 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 751801.08 |
| 5 | Corrected Sum of Squares (SS) | 2.94 |
| 6 | Variance (V) : SS/(N-1) | 0.0397 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1993 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.12 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.43 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 10.64 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1267 Lot Descr: KU I70 - 10

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C298560 | 100.00 | C335295 | 99.90 | C335586 | 99.90 | C335593 | 99.80 | C335605 | 99.70 |
| C335614 | 99.60 | C335690 | 99.90 | C335695 | 99.60 | C335992 | 99.80 | C336135 | 99.90 |
| C336199 | 99.80 | C336771 | 99.70 | C336867 | 99.90 | C336991 | 99.60 | C337066 | 99.80 |
| C337099 | 99.60 | C337146 | 99.60 | C337476 | 99.80 | C337486 | 99.70 | C337545 | 99.20 |
| C337632 | 100.00 | C337648 | 100.20 | C337655 | 99.80 | C337682 | 99.70 | C337702 | 99.60 |
| C337790 | 100.00 | C337871 | 99.70 | C338314 | 99.90 | C338376 | 99.70 | C338690 | 99.70 |
| C338915 | 99.60 | C338992 | 100.10 | C339212 | 99.80 | C339426 | 99.90 | C339481 | 99.90 |
| C339502 | 99.80 | C339520 | 100.00 | C339545 | 99.80 | C339649 | 99.70 | C339714 | 99.80 |
| L291991 | 100.10 | L292087 | 100.20 | L303814 | 99.70 | L304112 | 99.90 | L304150 | 99.90 |
| L304353 | 99.90 | L304364 | 100.00 | L304458 | 99.80 | L304753 | 100.00 | L305049 | 99.60 |
| L305251 | 99.90 | L305415 | 99.80 | L305471 | 99.80 | L305475 | 99.90 | L305702 | 100.20 |
| L306167 | 99.90 | L306178 | 100.20 | L306191 | 99.80 | L306208 | 99.70 | L306335 | 100.00 |
| L306414 | 99.60 | L306668 | 99.80 | L306816 | 99.60 | L306862 | 99.60 | L306910 | 99.70 |
| L306912 | 99.70 | M446583 | 99.70 | M446709 | 99.60 | M446749 | 99.60 | W136347 | 100.00 |
| W136712 | 100.20 | W136856 | 100.00 | W137260 | 100.10 | W137381 | 100.00 | W137479 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7486.90 |
| 3 | Sum of Squared Measurements | 747384.87 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 747382.29 |
| 5 | Corrected Sum of Squares (SS) | 2.58 |
| 6 | Variance (V) : SS/(N-1) | 0.0349 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1868 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.83 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 11.64 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 9.77 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1268 Lot Descr: KU I70 - 11

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C339745 | 99.60 | C339788 | 99.90 | C340051 | 99.90 | C340183 | 99.60 | C340217 | 99.30 |
| C340317 | 99.80 | C340702 | 99.90 | C340747 | 99.90 | C340843 | 99.90 | C341038 | 99.70 |
| C341103 | 99.90 | C341286 | 100.10 | C341408 | 99.90 | C341547 | 99.70 | C341645 | 99.90 |
| C341785 | 100.00 | C341826 | 99.90 | C342115 | 99.40 | C342386 | 99.90 | C342468 | 99.90 |
| C342914 | 99.90 | C343096 | 99.80 | C343178 | 99.60 | C343285 | 99.80 | C343360 | 99.70 |
| C343369 | 99.90 | C343765 | 99.80 | C344140 | 99.60 | C344298 | 99.60 | C344488 | 99.90 |
| C351943 | 100.10 | C351982 | 100.10 | C352233 | 100.20 | C352253 | 100.00 | L307977 | 100.10 |
| L308056 | 100.00 | L308122 | 100.00 | L308241 | 99.80 | L308263 | 99.70 | L308559 | 100.00 |
| L309079 | 99.40 | L309095 | 99.80 | L309547 | 99.70 | L309719 | 99.10 | L309786 | 99.40 |
| L309821 | 99.50 | L309937 | 100.00 | L309945 | 99.40 | M446878 | 99.60 | M447066 | 99.80 |
| M447316 | 99.90 | M447336 | 99.70 | M447552 | 100.10 | M447619 | 99.80 | M447667 | 99.80 |
| M447752 | 99.40 | M447806 | 99.80 | W149201 | 99.40 | W149356 | 99.80 | W149464 | 99.40 |
| W149576 | 99.70 | W149703 | 99.60 | W149771 | 99.60 | W149877 | 99.30 | W149879 | 99.70 |
| W149928 | 99.90 | W150074 | 100.00 | W150270 | 99.40 | W150507 | 99.80 | W150582 | 99.80 |
| W150966 | 99.80 | W151064 | 99.90 | W151353 | 99.70 | W151440 | 99.70 | W151537 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7482.30 |
| 3 | Sum of Squared Measurements | 746467.93 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 746464.18 |
| 5 | Corrected Sum of Squares (SS) | 3.75 |
| 6 | Variance (V) : SS/(N-1) | 0.0507 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2252 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.76 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.93 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.83 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1269 Lot Descr: KU I70 - 12

In Service Population: 6,347 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C298430 | 99.80 | L310091 | 99.70 | L310167 | 99.50 | L310527 | 100.00 | L310628 | 99.90 |
| L310636 | 99.60 | L310701 | 99.80 | L310782 | 99.70 | L310890 | 99.50 | L310905 | 99.30 |
| L310989 | 99.90 | L311096 | 99.90 | L311225 | 99.80 | L311388 | 100.00 | L311673 | 99.60 |
| L311708 | 99.80 | L311756 | 99.80 | L311839 | 99.90 | L311964 | 99.70 | L312002 | 99.80 |
| L312038 | 100.10 | L312053 | 99.50 | L312064 | 99.80 | L312283 | 99.90 | L312636 | 100.10 |
| L312735 | 100.30 | L312815 | 100.00 | L312874 | 100.00 | L313086 | 100.30 | W151862 | 99.80 |
| W151866 | 99.90 | W151888 | 99.90 | W151974 | 100.00 | W152003 | 99.80 | W152018 | 99.90 |
| W152051 | 99.80 | W152100 | 100.10 | W152139 | 99.90 | W152266 | 100.10 | W152394 | 99.70 |
| W152397 | 99.90 | W152628 | 99.90 | W152658 | 100.00 | W152744 | 99.90 | W152747 | 99.70 |
| W152990 | 100.10 | W153001 | 100.00 | W153017 | 99.90 | W153086 | 99.80 | W153165 | 99.60 |
| W153326 | 99.60 | W153377 | 99.80 | W153516 | 99.90 | W153619 | 99.50 | W154006 | 99.60 |
| W154014 | 99.80 | W154050 | 99.80 | W154088 | 99.80 | W154234 | 100.10 | W154333 | 99.80 |
| W154483 | 100.10 | W154586 | 99.60 | W154630 | 99.90 | W154661 | 99.50 | W154665 | 99.90 |
| W154666 | 99.90 | W154748 | 100.00 | W154828 | 99.80 | W154833 | 99.90 | W154887 | 99.40 |
| W154894 | 99.30 | W155073 | 99.90 | W155157 | 99.60 | W155239 | 100.00 | W155552 | 99.50 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7486.70 |
| 3 | Sum of Squared Measurements | 747345.53 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 747342.36 |
| 5 | Corrected Sum of Squares (SS) | 3.17 |
| 6 | Variance (V) : SS/(N-1) | 0.0429 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2070 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.82 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 10.52 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.80 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1270 Lot Descr: KU J4S - 1

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results For ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C228783 | 100.00 | C235464 | 100.00 | C235525 | 100.20 | C235588 | 100.00 | C239561 | 100.40 |
| C239875 | 100.10 | C240354 | 100.20 | C244243 | 100.00 | C244246 | 100.10 | C248757 | 100.30 |
| C248901 | 100.30 | C249046 | 100.00 | C249479 | 100.20 | C249691 | 99.90 | C253396 | 99.60 |
| C253398 | 99.90 | C253523 | 99.80 | C253546 | 99.90 | C253734 | 99.70 | C253956 | 100.00 |
| C254010 | 99.90 | C254093 | 99.70 | C262835 | 99.80 | C262958 | 100.10 | C263002 | 100.20 |
| C263246 | 99.80 | C263301 | 99.70 | C263622 | 99.30 | C263674 | 99.80 | C263838 | 100.20 |
| C268184 | 99.80 | C268241 | 99.50 | M352353 | 100.00 | M352376 | 100.20 | M352402 | 99.80 |
| M374687 | 99.80 | M374932 | 100.20 | M381545 | 100.30 | M387898 | 100.30 | M388097 | 100.30 |
| M388425 | 100.10 | M390854 | 100.30 | M391160 | 99.60 | M391583 | 99.70 | M391637 | 100.20 |
| M391851 | 99.70 | M391852 | 99.90 | M393883 | 100.00 | M393924 | 99.50 | M394187 | 99.50 |
| M408825 | 100.30 | M408922 | 99.70 | M409327 | 99.90 | M410698 | 99.80 | M411251 | 99.70 |
| M412670 | 100.00 | M413008 | 99.60 | M413030 | 99.70 | M413270 | 99.60 | M426344 | 99.80 |
| M426399 | 100.10 | W103919 | 100.20 | W104269 | 99.90 | W105257 | 98.90 | W106753 | 100.20 |
| W109466 | 99.40 | W110237 | 100.40 | W110543 | 100.10 | W110810 | 99.90 | W111358 | 100.00 |
| W111959 | 99.70 | W113496 | 100.30 | W121359 | 100.10 | W122722 | 100.00 | W122795 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7495.10 |
| 3 | Sum of Squared Measurements | 749026.21 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749020.32 |
| 5 | Corrected Sum of Squares (SS) | 5.89 |
| 6 | Variance (V) : SS/(N-1) | 0.0796 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2821 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.93 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.32 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.86 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1271 Lot Descr: KU J4S - 2

In Service Population: 2,317 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C268597 | 99.60 | C268629 | 99.70 | C268662 | 100.10 | C268681 | 99.70 | C268737 | 99.80 |
| C268747 | 99.80 | C268776 | 100.10 | C268780 | 99.70 | C268831 | 99.70 | C268861 | 100.00 |
| C268863 | 99.50 | C268929 | 99.80 | C268976 | 99.50 | C268981 | 99.30 | C269042 | 100.00 |
| C342528 | 99.80 | C351314 | 100.00 | C351352 | 99.60 | C351511 | 100.10 | L240043 | 99.40 |
| L240046 | 99.60 | L240110 | 99.70 | L240156 | 99.90 | L240482 | 99.40 | L240492 | 99.80 |
| L240563 | 99.50 | L241800 | 99.70 | L241834 | 99.80 | L241927 | 99.80 | L242060 | 99.00 |
| L242142 | 99.10 | L242149 | 99.60 | L242297 | 99.40 | M415452 | 99.50 | M415458 | 99.80 |
| M415462 | 99.70 | M415467 | 99.30 | M415470 | 99.70 | M415589 | 100.20 | M415713 | 100.20 |
| M415806 | 99.30 | M415914 | 100.00 | M415929 | 99.80 | M415955 | 99.90 | M416031 | 100.00 |
| M416055 | 99.80 | M416122 | 99.70 | M416188 | 99.70 | W123580 | 99.80 | W123693 | 99.60 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 50 |
| 2 | Sum of Measurements: (Sum X) | 4985.50 |
| 3 | Sum of Squared Measurements | 497107.63 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 497104.20 |
| 5 | Corrected Sum of Squares (SS) | 3.43 |
| 6 | Variance (V) : SS/(N-1) | 0.0699 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2644 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.71 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.66 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.47 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.21 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1272 Lot Descr: RU J5S - 1

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C273321 | 100.00 | C273696 | 99.50 | C273894 | 99.90 | C273952 | 99.90 | C274140 | 99.90 |
| C277762 | 99.80 | C278161 | 100.30 | C278368 | 99.80 | C278643 | 100.40 | C278665 | 100.00 |
| C282694 | 99.70 | C282967 | 99.90 | C283069 | 100.00 | C283109 | 99.90 | C283203 | 100.10 |
| C288039 | 100.20 | C288281 | 100.20 | C288329 | 99.90 | C288905 | 99.90 | L240263 | 99.70 |
| L243045 | 100.00 | L243324 | 99.60 | L243362 | 100.20 | L244747 | 100.20 | L244864 | 99.80 |
| L244881 | 99.90 | L244950 | 100.00 | L244982 | 99.90 | L245138 | 100.10 | L246062 | 100.00 |
| L246137 | 99.70 | L246231 | 99.90 | L246503 | 99.70 | L246769 | 100.00 | L246858 | 100.20 |
| L246963 | 99.80 | L247058 | 99.60 | L247124 | 99.90 | L247318 | 99.80 | L247825 | 99.70 |
| L247931 | 99.00 | L248160 | 99.70 | L248213 | 99.80 | L248387 | 99.40 | L248562 | 99.60 |
| L248626 | 100.40 | L248937 | 99.50 | L248952 | 99.30 | L249001 | 99.90 | L250411 | 100.20 |
| L250425 | 99.80 | L250642 | 99.90 | L250669 | 99.60 | L250739 | 99.70 | L250745 | 99.70 |
| L251373 | 99.20 | L251597 | 99.90 | L251695 | 99.70 | L251762 | 100.00 | L251780 | 100.20 |
| L251873 | 100.10 | L251948 | 99.30 | L252505 | 99.50 | L252545 | 99.70 | L252776 | 100.10 |
| L253012 | 100.30 | L253121 | 99.80 | W124171 | 99.60 | W124222 | 99.90 | W124266 | 99.80 |
| W125278 | 99.50 | W125337 | 100.00 | W125754 | 99.70 | W126280 | 100.10 | W127021 | 99.30 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7488.20 |
| 3 | Sum of Squared Measurements | 747647.60 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 747641.86 |
| 5 | Corrected Sum of Squares (SS) | 5.74 |
| 6 | Variance (V) : SS/(N-1) | 0.0776 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2786 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.84 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.74 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.61 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1273 Lot Descr: KU J5S - 2
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C283765 | 99.80 | C283965 | 99.90 | C284356 | 100.10 | C284374 | 100.00 | C291237 | 100.00 |
| C291257 | 100.10 | C291643 | 100.00 | C291788 | 100.20 | C291802 | 100.20 | C291811 | 100.30 |
| C291850 | 100.10 | C291950 | 100.10 | C291983 | 99.90 | C292005 | 100.70 | C292075 | 100.40 |
| C292217 | 100.10 | C292288 | 100.20 | C292332 | 99.70 | L253458 | 100.10 | L253975 | 99.90 |
| L254004 | 99.60 | L254554 | 100.00 | L254839 | 99.20 | L255129 | 100.20 | L255171 | 100.00 |
| L256962 | 100.10 | L257211 | 100.00 | L257585 | 99.80 | L257688 | 100.30 | L257741 | 99.70 |
| L257840 | 100.10 | L257980 | 100.20 | L258022 | 99.30 | L258364 | 99.80 | L258508 | 100.30 |
| L258648 | 99.90 | L259067 | 100.10 | L259492 | 100.40 | L259553 | 99.60 | L259662 | 99.50 |
| M421672 | 99.90 | M421894 | 100.20 | M421963 | 99.90 | M422602 | 99.60 | M422789 | 100.40 |
| M422849 | 99.90 | M423083 | 99.70 | M423102 | 100.20 | M423211 | 99.80 | M423317 | 99.60 |
| M423501 | 99.80 | M423680 | 100.30 | M423952 | 100.00 | M424097 | 100.40 | M424187 | 100.50 |
| M424297 | 100.10 | M424301 | 99.90 | M424396 | 100.10 | M424427 | 99.90 | M424431 | 100.00 |
| M424718 | 99.70 | M424816 | 99.70 | M424854 | 100.30 | M424894 | 100.20 | M428807 | 99.50 |
| M429166 | 99.80 | M429215 | 100.30 | M429233 | 100.30 | M429275 | 100.30 | W127714 | 100.10 |
| W128101 | 99.98 | W128255 | 100.00 | W128871 | 99.80 | W128091 | 100.00 | W128913 | 100.40 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7500.40 |
| 3 | Sum of Squared Measurements | 750085.80 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750080.00 |
| 5 | Corrected Sum of Squares (SS) | 5.80 |
| 6 | Variance (V) : SS/(N-1) | 0.0783 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2799 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.01 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.13 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.16 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1274 Lot Descr: KU J5S - 3

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C284027 | 100.00 | C284096 | 100.00 | C284138 | 99.70 | C284168 | 100.20 | C284210 | 100.00 |
| C294666 | 100.10 | C294872 | 100.20 | C294889 | 100.10 | C295403 | 99.70 | C295514 | 100.30 |
| C297099 | 100.00 | C297289 | 100.30 | C297384 | 100.10 | C297388 | 99.80 | C297457 | 100.20 |
| C297521 | 99.70 | C297874 | 99.60 | C298081 | 100.20 | C300419 | 99.90 | L260559 | 100.10 |
| L260724 | 99.90 | L260752 | 100.10 | L260881 | 99.70 | L260961 | 100.10 | L260994 | 99.70 |
| L261154 | 100.00 | L261479 | 99.30 | L261504 | 100.00 | L262043 | 99.80 | L262057 | 100.30 |
| L262164 | 99.80 | L267092 | 99.90 | L267195 | 100.30 | L267270 | 100.10 | L267444 | 99.80 |
| L267459 | 100.20 | L267460 | 100.00 | L267624 | 99.80 | L267781 | 100.30 | L267836 | 100.30 |
| L267871 | 100.10 | L269002 | 99.70 | L269012 | 100.10 | L269020 | 99.90 | L269516 | 100.10 |
| L269537 | 100.00 | L269575 | 99.90 | L269644 | 99.70 | L269666 | 99.50 | L269710 | 100.40 |
| L269889 | 99.90 | L269995 | 100.00 | L270016 | 99.50 | L270053 | 100.00 | L270090 | 99.60 |
| L270297 | 100.10 | L270361 | 99.70 | L270656 | 99.40 | L270766 | 100.00 | M429563 | 100.00 |
| M430257 | 99.90 | M430659 | 99.60 | M430991 | 100.10 | M432167 | 100.10 | M432208 | 100.30 |
| M432243 | 100.50 | M432540 | 100.10 | M432556 | 100.10 | M432642 | 99.90 | W129610 | 99.70 |
| W129636 | 100.30 | W130729 | 100.20 | W130737 | 100.00 | W130741 | 100.50 | W131182 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7498.60 |
| 3 | Sum of Squared Measurements | 749724.70 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749720.03 |
| 5 | Corrected Sum of Squares (SS) | 4.67 |
| 6 | Variance (V) : SS/(N-1) | 0.0632 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2513 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.98 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.03 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.88 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1275 Lot Descr: KU J5S - 4

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C303093 | 100.20 | C303216 | 99.90 | C303645 | 99.90 | C303945 | 99.80 | C304301 | 99.80 |
| C304394 | 99.80 | C304449 | 99.90 | C305793 | 100.00 | C305808 | 99.50 | C305900 | 99.90 |
| C306090 | 100.00 | C306140 | 99.70 | C306761 | 100.00 | C306812 | 99.80 | C306846 | 100.20 |
| C306886 | 99.60 | C306901 | 98.90 | C306913 | 99.90 | C306952 | 99.50 | C307180 | 99.80 |
| C307227 | 99.30 | C307228 | 99.70 | C307408 | 100.00 | C307423 | 99.70 | C307544 | 99.80 |
| C307575 | 99.70 | C307648 | 99.70 | L270894 | 99.80 | L270979 | 99.90 | L271057 | 99.70 |
| L271207 | 99.90 | L271305 | 99.90 | L271307 | 100.10 | L271453 | 99.90 | L271792 | 100.40 |
| L271831 | 99.90 | L272022 | 99.50 | L272410 | 99.80 | L273465 | 100.70 | L273590 | 99.70 |
| L273624 | 100.00 | L273764 | 100.00 | L274032 | 100.40 | L274059 | 99.80 | L274135 | 99.40 |
| L274275 | 100.10 | L274324 | 99.90 | L274342 | 100.20 | L274551 | 99.90 | L274685 | 99.90 |
| L274775 | 99.90 | L274819 | 100.10 | L274962 | 100.40 | L275031 | 100.10 | L275050 | 99.60 |
| L275151 | 99.90 | L275178 | 99.70 | L275319 | 100.20 | L275521 | 99.80 | L275575 | 99.50 |
| L275579 | 99.80 | L275637 | 99.80 | L276051 | 99.80 | L276252 | 100.00 | L276389 | 99.90 |
| L276403 | 100.00 | M432975 | 100.20 | M433299 | 100.40 | M433371 | 99.70 | M433517 | 99.70 |
| P001136 | 100.10 | P005252 | 100.20 | P005261 | 100.10 | P007057 | 99.90 | P007083 | 99.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7491.40 |
| 3 | Sum of Squared Measurements | 748286.44 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 748280.99 |
| 5 | Corrected Sum of Squares (SS) | 5.45 |
| 6 | Variance (V) : SS/(N-1) | 0.0737 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2715 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.89 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.79 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.94 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1276 Lot Descr: KU J5S - 5

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C307914 | 99.80 | C308151 | 100.30 | C308167 | 99.90 | C308225 | 99.80 | C308316 | 100.20 |
| C308529 | 99.70 | C308967 | 99.60 | C308998 | 100.40 | C309015 | 99.40 | C309095 | 99.60 |
| C309176 | 99.90 | C309296 | 100.00 | C309436 | 99.90 | C309471 | 99.80 | C309569 | 100.00 |
| C309586 | 99.50 | C309706 | 100.10 | C309758 | 99.40 | C309804 | 99.90 | C309841 | 100.00 |
| C309854 | 99.60 | C309950 | 99.90 | C310114 | 99.80 | C310393 | 99.90 | C310496 | 99.50 |
| C311203 | 100.00 | C311234 | 99.80 | C311350 | 100.20 | C311474 | 99.80 | C311565 | 99.90 |
| C311667 | 100.10 | C312045 | 100.10 | L277704 | 99.70 | L277808 | 100.10 | L278470 | 99.00 |
| L278542 | 99.60 | L278879 | 100.00 | L279107 | 99.80 | L279797 | 99.90 | L279945 | 99.70 |
| L280040 | 99.80 | L280150 | 99.90 | L280171 | 99.40 | L280243 | 99.70 | L280302 | 100.70 |
| L280349 | 100.00 | L280473 | 99.90 | L280566 | 99.90 | L280632 | 99.90 | L280707 | 99.80 |
| L280879 | 99.80 | L280899 | 100.00 | L281513 | 99.70 | L281515 | 99.60 | L281841 | 100.00 |
| L282059 | 100.00 | L282133 | 99.60 | L282203 | 99.60 | L282339 | 100.00 | L282473 | 100.00 |
| L282729 | 99.90 | L282732 | 99.70 | L283126 | 100.10 | L283182 | 99.70 | L283202 | 99.90 |
| L283393 | 99.60 | L283394 | 99.90 | M438942 | 99.80 | M439008 | 100.20 | M439035 | 99.70 |
| M439082 | 100.30 | M439090 | 99.90 | M439105 | 99.90 | P003480 | 100.10 | P003481 | 99.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7489.30 |
| 3 | Sum of Squared Measurements | 747866.29 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 747861.53 |
| 5 | Corrected Sum of Squares (SS) | 4.76 |
| 6 | Variance (V) : SS/(N-1) | 0.0644 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2537 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.86 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.45 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.32 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1277 Lot Descr: KU J5S - 6

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C312445 | 99.80 | C312573 | 100.00 | C312592 | 99.90 | C312618 | 100.10 | C313187 | 99.70 |
| C313290 | 100.00 | C313422 | 99.80 | C313430 | 100.50 | C313830 | 100.00 | C313945 | 100.00 |
| C314243 | 99.70 | C314366 | 100.00 | C314406 | 100.20 | C314428 | 100.60 | C314441 | 100.10 |
| C314530 | 100.00 | C314558 | 99.70 | C314765 | 99.60 | C315126 | 99.80 | C315168 | 99.80 |
| C315229 | 100.10 | C315392 | 100.20 | C315689 | 99.70 | C315930 | 100.10 | C316079 | 100.20 |
| C316369 | 99.90 | C316430 | 100.30 | C316466 | 99.60 | C316590 | 99.70 | C316637 | 99.60 |
| C316797 | 100.00 | C316958 | 99.90 | C316973 | 99.90 | C317000 | 100.10 | C317186 | 100.00 |
| C317703 | 100.30 | C317891 | 99.90 | C318111 | 99.90 | C318364 | 99.80 | C318375 | 100.00 |
| C318519 | 99.40 | C318547 | 100.20 | C318635 | 100.10 | C318890 | 99.50 | C319020 | 100.00 |
| C319062 | 100.00 | C319611 | 99.80 | C319869 | 99.50 | C320017 | 99.80 | C320136 | 99.60 |
| C320160 | 99.90 | C320277 | 99.60 | C320310 | 99.70 | C320435 | 100.10 | L283682 | 100.00 |
| L283763 | 99.70 | L283820 | 99.80 | L283926 | 100.00 | L283938 | 99.60 | W138553 | 100.20 |
| W138814 | 100.20 | W138824 | 99.90 | W138886 | 99.90 | W139216 | 99.80 | W139249 | 99.10 |
| W139280 | 100.10 | W139326 | 99.70 | W139521 | 99.80 | W139646 | 99.80 | W139768 | 99.70 |
| W139781 | 100.40 | W140043 | 99.80 | W140198 | 99.50 | W140224 | 99.70 | W140310 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7492.50 |
| 3 | Sum of Squared Measurements | 748505.63 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 748500.75 |
| 5 | Corrected Sum of Squares (SS) | 4.88 |
| 6 | Variance (V) : SS/(N-1) | 0.0659 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2568 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.90 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.18 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.40 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1278 Lot Descr: KU J5S - 7

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C326706 | 99.30 | C326884 | 100.20 | C327074 | 100.30 | C327188 | 100.60 | C327558 | 100.70 |
| C327582 | 100.40 | C327703 | 100.10 | C327860 | 99.90 | C327868 | 100.10 | C327926 | 100.20 |
| C328041 | 99.90 | C328046 | 100.20 | C328103 | 99.90 | C328189 | 100.00 | C328255 | 99.70 |
| C328505 | 100.00 | C328570 | 100.00 | C328589 | 99.50 | C328736 | 100.50 | C328860 | 99.60 |
| C328867 | 99.40 | C328880 | 100.00 | C328988 | 100.20 | C329108 | 99.10 | C329319 | 99.60 |
| C329386 | 99.60 | L284014 | 101.70 | L284019 | 100.00 | L284044 | 99.60 | L284072 | 99.60 |
| L284114 | 99.70 | L284242 | 100.00 | L284363 | 100.00 | L284808 | 99.90 | L285009 | 100.10 |
| L285097 | 100.20 | L285106 | 99.90 | L285411 | 99.60 | L285417 | 100.30 | L285481 | 99.90 |
| L285820 | 100.40 | L285878 | 100.30 | L285886 | 99.70 | L285922 | 99.60 | L285945 | 100.40 |
| L286429 | 100.00 | L286545 | 100.10 | L286707 | 100.30 | L286734 | 99.90 | L286738 | 100.00 |
| L286997 | 99.90 | L287181 | 99.60 | L287420 | 99.80 | L291521 | 99.90 | L291600 | 99.80 |
| M439621 | 100.10 | M439760 | 99.90 | M439898 | 100.00 | M439904 | 99.60 | M439912 | 100.00 |
| M439986 | 100.20 | M440550 | 100.00 | W140534 | 100.20 | W140566 | 99.80 | W141037 | 99.70 |
| W141054 | 99.50 | W141235 | 99.90 | W141366 | 99.90 | W141493 | 99.50 | W141597 | 99.70 |
| W141833 | 99.70 | W141980 | 99.40 | W142052 | 100.10 | W142254 | 99.60 | W142255 | 99.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7495.70 |
| 3 | Sum of Squared Measurements | 749150.41 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749140.25 |
| 5 | Corrected Sum of Squares (SS) | 10.16 |
| 6 | Variance (V) : SS/(N-1) | 0.1373 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3706 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.94 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 5.55 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 5.24 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1279 Lot Descr: KU J5S - 8

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C329525 | 99.80 | C329798 | 99.60 | C329832 | 100.10 | C330393 | 100.00 | C330582 | 99.90 |
| C330598 | 99.70 | C331232 | 100.00 | L292603 | 100.10 | L293017 | 99.40 | L293189 | 99.40 |
| L293239 | 99.80 | L293291 | 100.40 | L293292 | 100.10 | L293468 | 100.00 | L293560 | 100.00 |
| L293628 | 99.90 | L293632 | 100.00 | L293641 | 100.00 | L293728 | 99.70 | L293844 | 100.00 |
| L293883 | 99.90 | L293924 | 99.80 | L293982 | 99.50 | L294012 | 99.70 | L294017 | 100.40 |
| L294202 | 99.80 | L294552 | 99.80 | L294676 | 100.30 | L294739 | 99.70 | L294975 | 99.90 |
| L295046 | 100.00 | L295055 | 99.70 | L295074 | 99.20 | L295154 | 99.60 | L295207 | 99.50 |
| L295535 | 100.00 | L295570 | 99.70 | L295628 | 100.30 | L295701 | 100.20 | L296858 | 99.90 |
| L296955 | 99.70 | L296957 | 99.90 | L297091 | 100.00 | L297520 | 99.70 | M442668 | 99.70 |
| M442734 | 100.00 | M442845 | 99.70 | M443072 | 100.10 | M443073 | 100.00 | M443078 | 100.20 |
| M443333 | 100.10 | M443879 | 100.20 | M444075 | 100.40 | M444106 | 100.10 | M444131 | 100.20 |
| M444212 | 99.90 | M444354 | 99.70 | W144784 | 100.00 | W144833 | 100.20 | W144928 | 99.70 |
| W145055 | 100.00 | W145068 | 100.00 | W145095 | 99.70 | W145107 | 100.30 | W145156 | 100.00 |
| W145268 | 100.50 | W145361 | 100.40 | W145529 | 100.10 | W145695 | 100.00 | W145854 | 100.20 |
| W146116 | 100.20 | W146243 | 99.80 | W146413 | 99.80 | W146529 | 99.90 | W146721 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7495.30 |
| 3 | Sum of Squared Measurements | 749065.23 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749060.29 |
| 5 | Corrected Sum of Squares (SS) | 4.94 |
| 6 | Variance (V) : SS/(N-1) | 0.0667 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2583 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.94 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 7.99 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.50 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1280 Lot Descr: KU J5S - 9

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C331436 | 99.80 | C331474 | 99.50 | C331569 | 99.50 | C331688 | 99.90 | C349778 | 99.30 |
| C349980 | 99.30 | C350072 | 99.90 | C350115 | 99.30 | C350161 | 100.10 | C350372 | 99.60 |
| C350858 | 99.60 | C350961 | 98.80 | C350991 | 99.40 | C351126 | 99.60 | C353707 | 99.80 |
| C353779 | 99.30 | C353804 | 99.80 | C353883 | 99.60 | C354125 | 99.60 | C354268 | 100.00 |
| C354598 | 99.90 | C354842 | 99.80 | C355271 | 99.80 | C355278 | 99.60 | C355285 | 99.60 |
| C355355 | 99.90 | C355388 | 99.40 | C355456 | 99.70 | C355480 | 99.40 | C355727 | 100.10 |
| C355791 | 99.30 | C355957 | 100.10 | C356099 | 101.10 | C356310 | 99.60 | C356526 | 99.40 |
| C356564 | 100.50 | C356610 | 99.60 | C356825 | 99.00 | C356910 | 99.50 | L268352 | 100.00 |
| L313274 | 99.80 | L313458 | 99.90 | L313656 | 100.10 | L313657 | 100.10 | L313662 | 99.20 |
| L313817 | 99.40 | L313872 | 99.50 | L313887 | 99.70 | L314187 | 99.00 | L314348 | 99.20 |
| L314414 | 99.30 | L314612 | 99.00 | L314796 | 99.70 | L314936 | 99.40 | L315052 | 100.20 |
| L315436 | 99.10 | L316294 | 99.20 | L316301 | 100.20 | L316434 | 99.20 | L316445 | 99.60 |
| L316480 | 99.20 | L316635 | 99.80 | L316726 | 99.60 | L316767 | 99.40 | L317130 | 99.00 |
| L317178 | 99.30 | L317300 | 100.20 | L317474 | 100.10 | M437550 | 100.00 | M437566 | 100.00 |
| M445966 | 99.90 | M446052 | 99.70 | M446138 | 100.10 | M446272 | 100.20 | M446318 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7474.20 |
| 3 | Sum of Squared Measurements | 744860.56 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 744848.88 |
| 5 | Corrected Sum of Squares (SS) | 11.68 |
| 6 | Variance (V) : SS/(N-1) | 0.1579 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3974 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.66 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 5.90 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 4.17 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1281 Lot Descr: KU J5S - 10

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C356991 | 100.10 | C357047 | 99.50 | C357072 | 99.40 | C357146 | 100.20 | C357612 | 99.80 |
| C357619 | 99.80 | C357909 | 99.90 | C358009 | 100.10 | C358040 | 100.20 | C358147 | 100.10 |
| C358442 | 99.90 | C358451 | 99.50 | C358464 | 99.70 | C358702 | 99.80 | C358933 | 99.70 |
| C358939 | 99.40 | C358963 | 99.80 | C359020 | 99.20 | C359292 | 100.00 | C359358 | 99.80 |
| C359629 | 100.10 | C359659 | 99.80 | C359925 | 100.40 | C360101 | 99.40 | C360146 | 99.60 |
| C360221 | 99.30 | C360308 | 99.70 | C360320 | 99.60 | C360888 | 99.90 | C360961 | 99.70 |
| C360997 | 100.20 | C361161 | 99.60 | C361163 | 100.40 | C361185 | 99.50 | C361196 | 99.40 |
| C361222 | 99.70 | C361231 | 99.50 | C361358 | 99.40 | C361363 | 99.70 | C361396 | 98.80 |
| C361430 | 99.30 | C361670 | 99.30 | C361672 | 99.90 | C362243 | 99.40 | C362912 | 99.70 |
| C363325 | 99.40 | C363386 | 99.60 | C363684 | 99.90 | C363781 | 99.00 | C363847 | 99.80 |
| C363941 | 99.80 | C363948 | 99.30 | C364270 | 99.50 | C364341 | 99.90 | C364574 | 99.30 |
| C364771 | 100.10 | C364969 | 99.70 | C365081 | 99.40 | C365174 | 99.20 | C365232 | 100.00 |
| C365277 | 99.70 | C365815 | 98.80 | C365872 | 99.90 | C365908 | 99.00 | C366213 | 99.80 |
| C366310 | 99.70 | C366377 | 99.40 | C366551 | 100.00 | C366627 | 98.70 | C366682 | 100.00 |
| C366941 | 99.60 | C367072 | 99.70 | C367114 | 99.80 | C367222 | 100.10 | C367271 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7475.10 |
| 3 | Sum of Squared Measurements | 745037.77 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 745028.27 |
| 5 | Corrected Sum of Squares (SS) | 9.50 |
| 6 | Variance (V) : SS/(N-1) | 0.1284 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3584 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.67 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.51 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 4.65 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1282 Lot Descr: KU J5S - 11

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C367655 | 99.20 | C367866 | 99.90 | C368123 | 99.90 | C368174 | 99.60 | C368191 | 99.80 |
| C368311 | 98.70 | C368467 | 100.40 | C368505 | 99.60 | C370051 | 100.00 | C370302 | 99.90 |
| C370493 | 98.90 | C370564 | 99.80 | C370675 | 100.10 | C370832 | 99.90 | C370890 | 99.60 |
| C370974 | 100.30 | C370990 | 100.00 | C371005 | 99.50 | C371122 | 99.60 | C371259 | 99.60 |
| C371463 | 99.10 | C371489 | 99.20 | C371522 | 99.60 | C371610 | 99.70 | C371755 | 99.40 |
| C371766 | 99.70 | C371987 | 99.10 | C372048 | 99.40 | C372104 | 99.70 | C372514 | 99.80 |
| C372548 | 99.20 | C372654 | 99.30 | C372701 | 99.50 | C372763 | 99.10 | C372776 | 99.60 |
| C373130 | 99.60 | C373239 | 100.10 | C373332 | 99.50 | C373806 | 99.80 | C373931 | 99.70 |
| C374265 | 99.60 | C374275 | 99.50 | C374349 | 99.80 | C374421 | 99.80 | C374604 | 99.60 |
| C374670 | 98.80 | C374722 | 99.20 | C374750 | 99.90 | C374802 | 99.90 | C374907 | 100.10 |
| C374951 | 100.20 | C375292 | 99.70 | C375536 | 100.10 | C375537 | 99.90 | C375765 | 99.70 |
| C375780 | 99.90 | C376283 | 100.00 | C376348 | 100.10 | C376361 | 100.00 | C376453 | 99.70 |
| C376455 | 100.00 | M447967 | 99.80 | M448043 | 99.70 | M448317 | 99.10 | M448604 | 99.50 |
| M448625 | 99.70 | M448745 | 99.30 | M448937 | 99.80 | M449090 | 99.50 | M449320 | 99.60 |
| M449355 | 99.90 | M449390 | 99.30 | M450368 | 99.90 | M450520 | 99.70 | M450832 | 99.40 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7474.10 |
| 3 | Sum of Squared Measurements | 744837.61 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 744828.94 |
| 5 | Corrected Sum of Squares (SS) | 8.67 |
| 6 | Variance (V) : SS/(N-1) | 0.1171 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3422 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.65 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.85 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 4.84 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1283 Lot Descr: KU J5S - 12

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C376652 | 100.10 | C376807 | 99.60 | C376866 | 100.20 | C376908 | 99.80 | C376914 | 99.90 |
| C377306 | 99.90 | C377712 | 99.90 | C377732 | 100.30 | C377753 | 100.00 | C377950 | 99.60 |
| C378091 | 99.90 | C378250 | 100.20 | C378297 | 99.90 | C378424 | 99.60 | C378519 | 99.90 |
| C378803 | 100.00 | C378812 | 99.70 | C379115 | 99.70 | C379615 | 99.60 | C379856 | 99.70 |
| C380151 | 99.70 | C380368 | 100.00 | C380521 | 99.70 | C383558 | 100.10 | C383804 | 99.80 |
| C383821 | 99.40 | C383911 | 99.90 | C384157 | 99.80 | C384219 | 99.50 | C384329 | 100.10 |
| C384762 | 99.60 | C384767 | 99.40 | C384811 | 99.80 | C384819 | 99.50 | C384968 | 100.00 |
| C385147 | 99.90 | C385230 | 99.50 | C385301 | 100.00 | C385398 | 100.00 | C385476 | 99.60 |
| C385483 | 100.00 | C385620 | 100.00 | C385738 | 100.20 | C385755 | 100.00 | C385974 | 100.00 |
| C386719 | 100.10 | C386731 | 100.30 | C387033 | 100.20 | C387037 | 99.80 | C387049 | 99.90 |
| C387067 | 99.90 | C387380 | 99.40 | C387491 | 99.80 | C387512 | 100.00 | C387885 | 99.50 |
| C387894 | 99.80 | C387902 | 99.90 | C388213 | 100.10 | C388248 | 99.70 | C388272 | 100.10 |
| C388400 | 99.90 | C388514 | 99.70 | C388643 | 99.60 | C388653 | 99.60 | C388660 | 99.90 |
| C389023 | 99.90 | C389390 | 99.90 | C389658 | 99.90 | C389765 | 99.90 | C389877 | 99.70 |
| C389968 | 99.70 | C390001 | 99.50 | C390091 | 100.10 | C390189 | 99.90 | L317770 | 99.60 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7488.30 |
| 3 | Sum of Squared Measurements | 747665.45 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 747661.83 |
| 5 | Corrected Sum of Squares (SS) | 3.62 |
| 6 | Variance (V) : SS/(N-1) | 0.0490 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2213 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.84 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.74 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 8.33 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF, In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1284 Lot Descr: KU J5S - 13

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C390530 | 100.20 | C391722 | 99.80 | C391879 | 100.00 | C391948 | 100.20 | C391951 | 100.00 |
| C392625 | 99.90 | C392633 | 99.60 | C392686 | 99.60 | C392865 | 99.80 | C392898 | 99.80 |
| C392917 | 100.10 | C393086 | 99.70 | C393240 | 100.10 | C393307 | 99.80 | C393419 | 99.60 |
| C393485 | 100.20 | C393849 | 100.00 | C393866 | 99.60 | C394135 | 100.00 | C394782 | 99.80 |
| C394949 | 100.40 | C394982 | 100.10 | C395077 | 99.90 | C395331 | 100.10 | C395618 | 100.20 |
| C395708 | 99.60 | C395718 | 99.90 | C395781 | 100.00 | C395822 | 100.20 | C396112 | 100.00 |
| C396199 | 99.90 | C396510 | 100.00 | C396541 | 99.80 | C396622 | 100.10 | C396687 | 99.60 |
| C396693 | 100.00 | C396713 | 100.10 | C396716 | 99.80 | C396756 | 99.70 | C397119 | 100.10 |
| C397154 | 100.20 | C397159 | 100.20 | C397249 | 100.50 | C397319 | 100.00 | C397645 | 99.70 |
| C397658 | 100.00 | C397793 | 99.60 | C397842 | 100.00 | C398301 | 99.70 | C398491 | 100.40 |
| C398507 | 100.70 | C398552 | 99.80 | C399113 | 99.90 | C399209 | 99.80 | C399306 | 99.50 |
| C399316 | 100.70 | C399322 | 100.40 | C399381 | 100.10 | C399647 | 100.00 | C399726 | 99.30 |
| C400051 | 100.30 | C400093 | 99.80 | C400162 | 99.70 | C400316 | 99.80 | C400597 | 100.20 |
| C400630 | 99.20 | C400780 | 99.80 | C400954 | 99.50 | C401006 | 100.70 | C401201 | 99.40 |
| C401235 | 100.80 | C401439 | 100.20 | C401528 | 99.00 | C401789 | 99.80 | C402178 | 99.80 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7495.80 |
| 3 | Sum of Squared Measurements | 749168.54 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749160.24 |
| 5 | Corrected Sum of Squares (SS) | 8.30 |
| 6 | Variance (V) : SS/(N-1) | 0.1122 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3350 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.94 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.14 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 5.80 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1285 Lot Descr: KU J5S - 14

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C402347 | 99.80 | C402497 | 99.90 | C402585 | 99.90 | C402704 | 99.50 | C402729 | 100.10 |
| C402797 | 100.10 | C403048 | 99.60 | C403080 | 100.50 | C403094 | 100.30 | C403203 | 100.10 |
| C403907 | 99.80 | C404060 | 100.50 | C404297 | 99.50 | C404336 | 99.90 | C404401 | 99.40 |
| C404528 | 100.10 | C404646 | 99.90 | C404727 | 100.00 | C405601 | 100.10 | C405872 | 98.90 |
| C405989 | 100.00 | C406169 | 99.70 | C410251 | 99.20 | C410385 | 99.60 | C410444 | 99.90 |
| C410450 | 99.60 | C410661 | 99.20 | C410973 | 100.20 | C411192 | 98.60 | C411246 | 99.30 |
| C411276 | 99.40 | C411279 | 99.40 | C411413 | 99.60 | C411629 | 99.30 | C411643 | 99.90 |
| C412404 | 99.50 | C412430 | 99.60 | C412440 | 99.80 | C412506 | 99.30 | C412510 | 99.40 |
| C412528 | 99.90 | C412543 | 99.40 | C412564 | 99.80 | C412578 | 99.00 | C412660 | 99.30 |
| C412806 | 99.70 | C412998 | 99.50 | C413060 | 99.90 | C413249 | 99.50 | C413406 | 100.10 |
| C413489 | 98.80 | C413611 | 98.80 | C413670 | 99.20 | C413701 | 100.10 | C413859 | 99.80 |
| C413926 | 99.00 | C413932 | 99.20 | C414173 | 99.30 | C414398 | 98.60 | C414414 | 99.60 |
| C414424 | 99.10 | C414536 | 99.40 | C414966 | 99.50 | C415267 | 99.50 | C415521 | 99.20 |
| C415543 | 98.80 | C415682 | 99.10 | C417805 | 99.60 | C417935 | 99.50 | C417936 | 99.50 |
| C417952 | 100.20 | C418033 | 99.40 | C418042 | 99.30 | C418094 | 99.30 | C418114 | 99.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7468.00 |
| 3 | Sum of Squared Measurements | 743626.88 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 743613.65 |
| 5 | Corrected Sum of Squares (SS) | 13.23 |
| 6 | Variance (V) : SS/(N-1) | 0.1787 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.4228 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.57 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 5.74 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 3.72 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.01 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.01 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1286 Lot Descr: KU J5S - 15
In Service Population: 7,024 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C418388 | 99.00 | C418671 | 99.30 | C418962 | 99.70 | C418966 | 99.70 | C419009 | 99.40 |
| C419018 | 98.90 | C419093 | 99.80 | C419139 | 99.00 | C419428 | 98.50 | C419453 | 98.80 |
| C419494 | 98.70 | C419783 | 99.50 | C419896 | 99.00 | C419967 | 98.90 | C420000 | 99.40 |
| C420037 | 99.60 | C420038 | 99.00 | C420089 | 98.80 | C420118 | 99.60 | C420164 | 98.20 |
| C420239 | 98.90 | C420282 | 99.00 | C420364 | 99.00 | C420403 | 100.00 | C420717 | 99.80 |
| C420733 | 99.20 | C420740 | 99.80 | C420789 | 99.50 | C421119 | 99.60 | C421123 | 99.60 |
| C421162 | 99.40 | C421367 | 99.70 | C421394 | 99.00 | C421459 | 98.70 | C421643 | 99.80 |
| C421717 | 99.20 | C421718 | 100.30 | C421729 | 99.10 | C421746 | 98.90 | C421804 | 99.30 |
| C421894 | 99.10 | C421933 | 99.80 | C422320 | 99.50 | C422533 | 99.50 | C422818 | 98.50 |
| C422852 | 99.30 | C423203 | 98.90 | C423314 | 99.40 | C423320 | 98.80 | C423406 | 99.60 |
| C423612 | 99.70 | C423694 | 100.20 | C423746 | 99.60 | C423771 | 99.60 | C423883 | 99.80 |
| C423940 | 99.70 | C423941 | 99.20 | C423948 | 99.50 | C424030 | 99.50 | C424079 | 99.30 |
| C424145 | 99.40 | C424227 | 99.60 | C424308 | 99.20 | C424447 | 99.50 | C424458 | 100.30 |
| C424485 | 99.30 | C424522 | 99.30 | C424524 | 100.10 | C424653 | 99.30 | C424768 | 99.50 |
| C424863 | 99.70 | C424923 | 99.30 | C424957 | 99.70 | C425071 | 99.40 | C425141 | 99.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7452.40 |
| 3 | Sum of Squared Measurements | 740523.22 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 740510.21 |
| 5 | Corrected Sum of Squares (SS) | 13.01 |
| 6 | Variance (V) : SS/(N-1) | 0.1758 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.4193 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.37 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.28 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 3.26 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.04 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.04 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F25240V15AC100 Model Number: MKS Division: 01 Sample Lot: 1287 Lot Descr: KU MKS - 1

In Service Population: 504 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: FAIL

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C181701 | 99.60 | C182467 | 100.10 | C185152 | 100.00 | C185796 | 101.90 | C186093 | 100.00 |
| C186121 | 100.10 | C187428 | 99.50 | C188215 | 72.60 | C190112 | 99.50 | C193073 | 100.60 |
| C194297 | 100.10 | C196425 | 99.70 | C196894 | 100.20 | C198357 | 100.20 | C198799 | 100.00 |
| C201760 | 99.60 | C202999 | 100.30 | C203047 | 100.10 | C203089 | 99.80 | C203153 | 99.80 |
| W079079 | 100.00 | W081149 | 99.80 | W082241 | 99.50 | W083766 | 99.80 | W085968 | 99.90 |
| W086168 | 99.90 | W087925 | 100.10 | W087932 | 100.70 | W088929 | 99.70 | W088988 | 99.60 |
| W088993 | 100.10 | W089100 | 100.00 | W089303 | 99.30 | W090334 | 99.90 | W091809 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 35 |
| 2 | Sum of Measurements: (Sum X) | 3471.90 |
| 3 | Sum of Squared Measurements | 345137.55 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 344402.56 |
| 5 | Corrected Sum of Squares (SS) | 734.99 |
| 6 | Variance (V) : SS/(N-1) | 21.6173 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 4.6494 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.20 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 0.60 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 0.30 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 27.53 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 38.29 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 65.82 |
| 16 | Maximum Allowable Percent NCF(M) | 5.58 |
| 17 | Acceptability Criterion: Compare P with M | FAIL |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MQS Division: 01 Sample Lot: 1288 Lot Descr: KU MQS - 1

In Service Population: 3,856 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C205357 | 100.00 | C206423 | 99.70 | C207135 | 99.70 | C207542 | 99.70 | C208095 | 100.00 |
| C208665 | 100.00 | C209080 | 100.40 | C209085 | 100.30 | C209168 | 99.50 | C209283 | 99.20 |
| C209301 | 100.00 | C209380 | 99.90 | C209425 | 100.10 | C209835 | 99.90 | C209909 | 99.60 |
| C209935 | 99.90 | C210328 | 100.10 | C210394 | 99.90 | C210423 | 99.70 | C210425 | 100.00 |
| C211265 | 100.00 | C211280 | 100.40 | C211787 | 100.10 | C212121 | 99.80 | C212716 | 100.00 |
| C213602 | 100.10 | C214615 | 100.10 | C214665 | 100.20 | C214691 | 99.90 | C215455 | 100.00 |
| C215479 | 99.90 | C215601 | 99.60 | C215629 | 99.40 | C216541 | 99.80 | C216580 | 99.40 |
| C217806 | 99.70 | C218045 | 99.60 | C218062 | 100.10 | C219177 | 99.90 | C219249 | 100.20 |
| C220839 | 100.00 | C221158 | 100.10 | C221231 | 100.10 | C222597 | 100.30 | C222613 | 99.90 |
| C223534 | 100.20 | C223650 | 100.20 | M362379 | 99.60 | M372137 | 100.00 | M380264 | 99.70 |
| M380291 | 108.20 | M381147 | 100.30 | W092443 | 99.90 | W092693 | 100.30 | W092699 | 100.20 |
| W092701 | 99.70 | W092940 | 100.10 | W094067 | 99.80 | W094111 | 100.10 | W094556 | 99.80 |
| W094621 | 100.10 | W094801 | 99.40 | W094861 | 99.40 | W094878 | 99.80 | W095133 | 99.60 |
| W095502 | 99.80 | W096509 | 100.40 | W097220 | 100.40 | W098243 | 100.20 | W098253 | 99.90 |
| W099178 | 100.30 | W099517 | 100.00 | W101413 | 99.90 | W101710 | 100.10 | W101849 | 99.50 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7503.10 |
| 3 | Sum of Squared Measurements | 750693.05 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750620.13 |
| 5 | Corrected Sum of Squares (SS) | 72.92 |
| 6 | Variance (V) : SS/(N-1) | 0.9854 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.9927 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.04 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 1.97 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 2.06 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 2.33 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 1.86 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 4.19 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1289 Lot Descr: KU MS - 1

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C224947 | 100.10 | C225035 | 99.80 | C225056 | 99.40 | C227483 | 100.30 | C227485 | 99.90 |
| C227486 | 100.00 | C231210 | 100.50 | C231334 | 100.10 | C231453 | 100.10 | C231506 | 100.40 |
| C231582 | 100.00 | C231600 | 100.10 | C231774 | 100.10 | C232541 | 100.20 | C232572 | 100.30 |
| C234616 | 99.70 | C234691 | 100.50 | C234813 | 100.00 | C237172 | 100.00 | C237393 | 100.60 |
| C238177 | 100.00 | C242126 | 100.00 | C242141 | 100.70 | C242163 | 100.10 | L132506 | 100.20 |
| L135580 | 99.70 | L138057 | 99.90 | L139205 | 100.20 | L147687 | 99.90 | L147817 | 100.20 |
| L147954 | 99.60 | L147956 | 100.50 | L149190 | 100.20 | L149253 | 99.50 | L149659 | 100.30 |
| L149794 | 99.60 | L149815 | 100.10 | L172063 | 100.10 | L172092 | 100.20 | L173512 | 99.70 |
| L176095 | 100.10 | L177141 | 100.00 | L177253 | 99.60 | L177292 | 100.20 | L177331 | 99.90 |
| L178668 | 100.30 | L178827 | 99.70 | L179635 | 99.80 | L181365 | 99.80 | L181401 | 100.10 |
| L181578 | 100.00 | L182880 | 100.00 | L182920 | 99.90 | L183176 | 100.20 | L183427 | 100.40 |
| L185178 | 100.20 | L185352 | 100.20 | L185465 | 100.00 | L185493 | 100.50 | L186212 | 100.10 |
| L188023 | 98.80 | L188095 | 99.70 | M352824 | 99.10 | M354220 | 100.10 | M374500 | 100.10 |
| M386304 | 99.20 | M388556 | 99.90 | W104714 | 100.00 | W104749 | 100.50 | W104787 | 100.00 |
| W105585 | 100.60 | W105905 | 100.10 | W106700 | 99.90 | W108118 | 100.40 | W109189 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7502.30 |
| 3 | Sum of Squared Measurements | 750468.47 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750460.07 |
| 5 | Corrected Sum of Squares (SS) | 8.40 |
| 6 | Variance (V) : SS/(N-1) | 0.1135 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3369 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.03 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 5.85 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.03 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: HS Division: 01 Sample Lot: 1290 Lot Descr: KU HS - 2

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C242391 | 100.10 | C242392 | 100.40 | C242823 | 100.30 | C242876 | 99.90 | C242905 | 100.20 |
| C246433 | 100.00 | C246557 | 99.90 | C246636 | 100.20 | C246992 | 99.60 | C247215 | 99.70 |
| C247308 | 99.80 | C247427 | 100.10 | C247450 | 100.00 | C247472 | 100.20 | L188342 | 99.90 |
| L189640 | 99.50 | L189912 | 100.00 | L189986 | 100.00 | L193328 | 100.40 | L193399 | 100.00 |
| L194107 | 99.70 | L194127 | 100.00 | L194305 | 99.70 | L194359 | 100.10 | L194529 | 100.00 |
| L194761 | 99.80 | L196958 | 99.30 | L197102 | 100.20 | L197170 | 99.90 | L197275 | 99.40 |
| L197943 | 100.20 | L198134 | 100.10 | L199002 | 99.50 | L199084 | 100.50 | L199226 | 100.00 |
| L199438 | 99.50 | L199467 | 100.30 | L199471 | 99.60 | L200870 | 100.10 | L201037 | 99.70 |
| L201368 | 99.40 | L202273 | 100.20 | L202457 | 99.60 | L202652 | 99.30 | L202859 | 100.00 |
| L203124 | 100.00 | L203193 | 100.10 | L206305 | 99.80 | L206484 | 100.00 | L206550 | 99.80 |
| L206720 | 99.90 | L208230 | 99.90 | L208553 | 100.40 | L208692 | 100.40 | L209415 | 100.20 |
| L209605 | 100.00 | L209768 | 100.30 | L209958 | 100.10 | L211151 | 100.00 | L211203 | 100.40 |
| M384581 | 99.90 | M386863 | 100.10 | M386880 | 100.10 | W109900 | 100.60 | W110121 | 100.60 |
| W110142 | 99.50 | W110181 | 100.10 | W110395 | 100.20 | W110485 | 99.90 | W110741 | 100.10 |
| W112194 | 100.60 | W115045 | 100.00 | W115122 | 100.10 | W115260 | 100.30 | W115473 | 100.50 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7500.20 |
| 3 | Sum of Squared Measurements | 750046.96 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750040.00 |
| 5 | Corrected Sum of Squares (SS) | 6.96 |
| 6 | Variance (V) : SS/(N-1) | 0.0940 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3067 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.00 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.51 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.53 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1291 Lot Descr: KU MS - 3

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C251170 | 99.90 | C251209 | 99.80 | C251222 | 99.90 | C251235 | 100.40 | C251237 | 100.30 |
| C251455 | 100.90 | C251776 | 100.20 | C251787 | 100.10 | C251795 | 100.60 | C251824 | 100.00 |
| C251886 | 100.10 | C259257 | 100.40 | C259341 | 100.00 | C259656 | 100.40 | C259709 | 100.20 |
| C259953 | 99.70 | C259971 | 100.40 | C260049 | 99.60 | C260093 | 100.20 | C260451 | 100.00 |
| C260490 | 100.10 | C260602 | 100.10 | C261144 | 100.60 | C261447 | 100.40 | C261534 | 99.80 |
| C266724 | 99.80 | L211555 | 100.00 | L212350 | 100.40 | L212652 | 99.80 | L212672 | 100.00 |
| L212771 | 99.80 | L212780 | 100.10 | L215542 | 100.30 | L215703 | 99.30 | L215727 | 100.20 |
| L215851 | 100.30 | L215923 | 100.20 | L215991 | 100.60 | L216025 | 100.00 | L216061 | 100.10 |
| L218283 | 100.10 | L218383 | 100.00 | L218557 | 99.60 | L221070 | 100.30 | L221105 | 99.70 |
| L221106 | 100.20 | L221113 | 99.90 | L221269 | 100.10 | L222765 | 100.10 | L223243 | 100.10 |
| L223599 | 99.00 | L223702 | 100.10 | L231416 | 100.10 | L231492 | 99.60 | L232402 | 100.10 |
| L232403 | 100.20 | L232665 | 99.90 | L232724 | 100.10 | L236363 | 100.40 | L236386 | 99.50 |
| L236460 | 100.20 | L236580 | 100.10 | M384214 | 100.10 | M384350 | 99.60 | W115829 | 99.90 |
| W115925 | 100.00 | W117133 | 100.10 | W117163 | 100.00 | W117247 | 100.00 | W117283 | 99.80 |
| W118483 | 100.20 | W118528 | 100.40 | W118807 | 99.90 | W118881 | 99.60 | W122335 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7504.00 |
| 3 | Sum of Squared Measurements | 750807.08 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750800.21 |
| 5 | Corrected Sum of Squares (SS) | 6.87 |
| 6 | Variance (V) : SS/(N-1) | 0.0928 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3046 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.05 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.39 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.74 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1292 Lot Descr: KU MS - 4

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C270724 | 100.20 | C270772 | 100.20 | C270810 | 100.00 | C270924 | 100.50 | C271206 | 99.90 |
| C271297 | 99.70 | C271381 | 99.90 | C271589 | 99.90 | C271704 | 100.10 | C271818 | 100.20 |
| C275463 | 100.10 | C275764 | 100.40 | C276473 | 100.00 | C280544 | 100.30 | C280550 | 100.30 |
| C280633 | 100.30 | C280682 | 100.20 | C280879 | 100.50 | C280928 | 99.90 | C284585 | 100.30 |
| C284915 | 100.30 | C284983 | 100.10 | C285261 | 100.00 | C285314 | 99.90 | C285351 | 99.80 |
| C285470 | 99.80 | C285750 | 100.00 | C285929 | 100.60 | C285997 | 99.90 | C286187 | 99.90 |
| C286396 | 100.40 | C286666 | 100.30 | C289407 | 100.80 | C298785 | 100.20 | C301015 | 100.00 |
| L236890 | 100.10 | L236924 | 100.30 | L237004 | 100.00 | L237186 | 100.70 | L237309 | 100.30 |
| L237346 | 100.10 | L238262 | 99.90 | L238311 | 100.00 | L238508 | 100.30 | L238556 | 100.00 |
| L240615 | 99.90 | L240656 | 99.90 | L240703 | 100.50 | L240759 | 100.40 | L240795 | 99.80 |
| L240798 | 99.90 | L240817 | 99.90 | L240914 | 100.10 | L240941 | 100.20 | L241093 | 100.00 |
| L241120 | 100.40 | L243582 | 100.00 | L243680 | 99.90 | L243932 | 99.80 | L245290 | 100.30 |
| L245312 | 100.00 | L245341 | 100.20 | L260175 | 100.00 | M416294 | 100.10 | M434685 | 100.10 |
| M434763 | 99.90 | W124962 | 99.80 | W126621 | 99.80 | W126681 | 101.80 | W126740 | 99.90 |
| W132513 | 100.30 | W133072 | 100.40 | W133179 | 100.20 | W133297 | 100.20 | W133585 | 100.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7511.00 |
| 3 | Sum of Squared Measurements | 752208.68 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 752201.61 |
| 5 | Corrected Sum of Squares (SS) | 7.07 |
| 6 | Variance (V) : SS/(N-1) | 0.0955 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3090 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.15 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.00 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 6.95 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1293 Lot Descr: KU MS - 5

In Service Population: 2,659 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| L292239 | 100.20 | L312436 | 100.40 | L312923 | 100.00 | L313035 | 100.30 | L313040 | 99.90 |
| M434822 | 100.10 | M434827 | 100.10 | M434877 | 100.00 | M434908 | 100.20 | M434913 | 100.00 |
| M434933 | 100.10 | M435022 | 100.00 | M435130 | 100.20 | M435136 | 100.10 | M435155 | 100.10 |
| M435328 | 100.30 | M435594 | 100.30 | W134107 | 100.10 | W134115 | 100.10 | W134224 | 100.00 |
| W134231 | 100.30 | W134324 | 100.20 | W134366 | 99.90 | W134432 | 100.00 | W134443 | 99.80 |
| W134569 | 99.70 | W134601 | 100.00 | W134653 | 100.30 | W134701 | 100.00 | W134737 | 100.00 |
| W134842 | 100.20 | W134863 | 100.00 | W134898 | 100.50 | W134911 | 99.90 | W134959 | 99.80 |
| W135004 | 100.10 | W135143 | 99.80 | W135191 | 99.90 | W135326 | 100.10 | W135394 | 100.00 |
| W135433 | 100.00 | W135457 | 99.90 | W135482 | 100.00 | W135589 | 100.10 | W135649 | 99.90 |
| W135660 | 99.90 | W135749 | 100.10 | W135857 | 99.90 | W135910 | 100.00 | W135986 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 50 |
| 2 | Sum of Measurements: (Sum X) | 5002.90 |
| 3 | Sum of Squared Measurements | 500581.47 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 500580.17 |
| 5 | Corrected Sum of Squares (SS) | 1.30 |
| 6 | Variance (V) : SS/(N-1) | 0.0266 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1630 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.06 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 11.91 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 12.63 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.21 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1294 Lot Descr: KU MSII - 1
In Service Population: 4,849 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C275444 | 100.00 | C275464 | 100.00 | C275616 | 99.60 | C298680 | 100.10 | C298706 | 100.40 |
| C298762 | 100.00 | C298843 | 100.10 | C298849 | 99.90 | C298871 | 100.00 | C300559 | 100.10 |
| C300569 | 100.20 | C300596 | 99.90 | C300634 | 100.50 | C300726 | 100.10 | C300767 | 100.00 |
| C300786 | 100.10 | C300973 | 99.90 | C300979 | 100.00 | C301202 | 100.30 | C301219 | 100.10 |
| C301320 | 100.10 | C301432 | 100.40 | C301500 | 100.20 | C301516 | 100.00 | C301532 | 99.80 |
| C301647 | 100.00 | C301711 | 100.00 | C301771 | 99.80 | C301960 | 99.90 | C301962 | 100.00 |
| C302066 | 100.10 | C302174 | 100.20 | C302199 | 100.00 | C302291 | 100.20 | C302385 | 100.20 |
| C302481 | 100.10 | C302664 | 100.10 | C302712 | 100.20 | L312597 | 99.70 | L312773 | 99.70 |
| L312847 | 100.10 | L313104 | 99.80 | M416291 | 99.50 | M416335 | 100.10 | M416526 | 99.90 |
| M416576 | 100.00 | M416588 | 99.90 | M421369 | 99.60 | M421394 | 100.10 | M422161 | 99.90 |
| M422213 | 100.10 | M422422 | 99.90 | M422463 | 100.00 | M422472 | 100.20 | M422595 | 99.90 |
| M422599 | 100.10 | M428437 | 99.90 | M428477 | 99.60 | M428582 | 100.20 | M435732 | 100.10 |
| M435890 | 100.30 | M435896 | 100.10 | M435902 | 100.10 | M436201 | 100.10 | M436242 | 100.30 |
| M436261 | 100.10 | M436304 | 100.10 | M436331 | 100.10 | M436333 | 100.00 | M436362 | 100.20 |
| M436428 | 100.10 | M436474 | 100.00 | M436497 | 100.20 | M436536 | 100.20 | M436576 | 100.10 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7502.90 |
| 3 | Sum of Squared Measurements | 750582.65 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 750580.11 |
| 5 | Corrected Sum of Squares (SS) | 2.54 |
| 6 | Variance (V) : SS/(N-1) | 0.0343 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1852 |
| 8 | Sample Mean(XBAR): Sum X/N | 100.04 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 10.59 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 11.01 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1295 Lot Descr: KU MX - 1

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C321134 | 99.80 | C321385 | 99.90 | C321651 | 99.90 | C321705 | 100.10 | C321804 | 100.00 |
| C321863 | 99.90 | C321998 | 100.00 | C322235 | 100.00 | C322255 | 100.00 | C322360 | 99.90 |
| C322748 | 100.00 | C322902 | 99.90 | C323115 | 100.00 | C323195 | 99.80 | C323257 | 100.10 |
| C323556 | 99.70 | C323560 | 100.20 | C323579 | 99.90 | C323739 | 99.90 | C323861 | 99.80 |
| C323925 | 100.10 | C324111 | 100.00 | C324311 | 99.90 | C324408 | 99.80 | C324797 | 100.00 |
| C325212 | 99.90 | C325706 | 100.20 | L288018 | 99.80 | L288107 | 100.10 | L288174 | 100.00 |
| L288243 | 100.00 | L288266 | 100.30 | L288465 | 99.90 | L288537 | 99.90 | L288604 | 99.90 |
| L288624 | 100.00 | L288639 | 100.00 | L288643 | 99.80 | L288718 | 100.20 | L288764 | 100.10 |
| L288790 | 100.20 | L288964 | 100.00 | L289090 | 99.90 | L289099 | 100.00 | L289390 | 99.90 |
| L289483 | 99.90 | L289488 | 99.70 | L289497 | 99.80 | L289561 | 100.10 | L289954 | 100.00 |
| L290159 | 99.90 | L290311 | 100.10 | L290345 | 100.00 | L290516 | 99.80 | L290618 | 99.90 |
| L290642 | 99.70 | L291157 | 99.90 | L291305 | 99.60 | L291350 | 100.00 | L291401 | 99.90 |
| L292247 | 100.20 | M440993 | 99.70 | M441058 | 99.70 | M441126 | 99.90 | M441185 | 99.90 |
| M441305 | 99.90 | M441314 | 99.90 | M441401 | 100.10 | M441417 | 100.00 | M441480 | 100.10 |
| M442332 | 100.00 | M442383 | 100.00 | M442508 | 100.10 | M442565 | 100.30 | W142922 | 99.70 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7496.50 |
| 3 | Sum of Squared Measurements | 749301.73 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 749300.16 |
| 5 | Corrected Sum of Squares (SS) | 1.57 |
| 6 | Variance (V) : SS/(N-1) | 0.0212 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1455 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.95 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 14.07 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 13.42 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1296 Lot Descr: KU MX - 2

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C390644 | 99.90 | C390752 | 99.70 | C390843 | 99.90 | C390866 | 100.20 | C390905 | 99.60 |
| C390952 | 100.00 | C391007 | 99.90 | C391328 | 99.80 | C391584 | 100.00 | C426250 | 99.60 |
| C426327 | 100.10 | C426497 | 99.90 | C426665 | 99.60 | C426675 | 99.90 | C426679 | 99.90 |
| C426730 | 98.60 | C426757 | 100.10 | C426794 | 98.90 | C426881 | 99.70 | C427256 | 99.60 |
| C427271 | 99.60 | C427455 | 99.60 | C427609 | 99.90 | C427612 | 98.50 | C427684 | 100.10 |
| C427892 | 99.80 | C427956 | 99.80 | C428077 | 99.90 | C428190 | 99.40 | C428251 | 99.70 |
| C428347 | 99.90 | C428728 | 100.00 | C428774 | 99.70 | C428833 | 99.50 | C428851 | 99.70 |
| C429001 | 99.60 | C429299 | 99.60 | C429708 | 100.10 | C430023 | 99.60 | C430046 | 99.90 |
| C430381 | 99.70 | C430610 | 99.20 | C430678 | 99.80 | C430733 | 99.60 | C430933 | 99.70 |
| C430962 | 99.70 | C431056 | 98.90 | C431236 | 99.50 | C431253 | 99.20 | C431255 | 99.70 |
| C431284 | 100.00 | C431554 | 99.50 | C431555 | 99.70 | C431636 | 99.80 | C431673 | 99.80 |
| C431812 | 99.60 | C435516 | 99.80 | C435527 | 99.30 | C435772 | 99.70 | C435800 | 99.70 |
| C436217 | 99.70 | C437285 | 99.50 | C437491 | 99.80 | C437543 | 99.50 | C437667 | 99.60 |
| C437815 | 99.50 | W143300 | 100.10 | W143757 | 100.10 | W143763 | 100.00 | W143985 | 100.10 |
| W144007 | 100.30 | W144044 | 100.40 | W144255 | 100.20 | W144286 | 100.40 | W144303 | 100.20 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7480.10 |
| 3 | Sum of Squared Measurements | 746034.37 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 746025.20 |
| 5 | Corrected Sum of Squares (SS) | 9.09 |
| 6 | Variance (V) : SS/(N-1) | 0.1228 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.3505 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.73 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 6.46 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 4.95 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities
2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1297 Lot Descr: KU MX - 3
In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection


Run Date: 01/07/2015
Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C437900 | 99.40 | C437930 | 99.60 | C437977 | 99.90 | C437987 | 99.80 | C438097 | 99.80 |
| C438227 | 99.60 | C438359 | 99.80 | C439108 | 99.60 | C439256 | 99.70 | C439279 | 99.70 |
| C439368 | 99.90 | C439399 | 100.10 | C439426 | 100.00 | C439549 | 99.80 | C439659 | 99.70 |
| C439679 | 100.20 | C439815 | 100.20 | C439877 | 99.90 | C439886 | 99.70 | C439890 | 99.90 |
| C440006 | 100.10 | C440015 | 100.00 | C440283 | 100.00 | C440378 | 99.90 | C440552 | 100.00 |
| C440576 | 100.00 | C440924 | 99.80 | C441076 | 100.00 | C441133 | 99.70 | C441262 | 99.90 |
| C441263 | 100.00 | C441602 | 99.90 | C441787 | 100.00 | C441802 | 99.70 | C442100 | 100.10 |
| C442302 | 99.90 | C442476 | 99.50 | C442502 | 99.60 | C442878 | 99.70 | C442933 | 99.90 |
| C443082 | 99.90 | C443175 | 99.90 | C443186 | 99.90 | C443191 | 100.00 | C443555 | 99.70 |
| C443620 | 99.80 | C444069 | 99.90 | C444155 | 99.50 | C444278 | 99.70 | C444724 | 99.60 |
| C444836 | 99.50 | C446472 | 99.70 | C446476 | 99.60 | C446541 | 99.50 | C446631 | 99.80 |
| C446709 | 99.50 | C446968 | 99.30 | C447427 | 99.50 | C447533 | 99.80 | C447585 | 99.70 |
| C447759 | 99.10 | C447775 | 99.30 | C447807 | 99.40 | C448399 | 99.50 | C448529 | 99.60 |
| C448624 | 99.70 | C448736 | 98.90 | C448812 | 99.61 | C449096 | 99.90 | C449145 | 99.90 |
| C449340 | 100.02 | C449415 | 99.80 | C449528 | 99.70 | C449615 | 100.00 | C449619 | 99.60 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7481.83 |
| 3 | Sum of Squared Measurements | 746374.69 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 746370.40 |
| 5 | Corrected Sum of Squares (SS) | 4.29 |
| 6 | Variance (V) : SS/(N-1) | 0.0580 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2408 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.76 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 9.31 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.30 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1298 Lot Descr: KU MX - 4

In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C449859 | 99.60 | C449921 | 98.50 | C449970 | 99.70 | C450028 | 99.60 | C450486 | 99.80 |
| C450545 | 99.70 | C450615 | 99.70 | C450659 | 99.80 | C450735 | 99.30 | C450756 | 99.80 |
| C450777 | 99.90 | C450817 | 99.90 | C450839 | 99.70 | C450887 | 99.70 | C450898 | 99.80 |
| C450905 | 99.70 | C450959 | 99.70 | C451215 | 99.90 | C451602 | 99.70 | C451711 | 99.50 |
| C451738 | 99.80 | C452017 | 99.60 | C452219 | 99.40 | C452425 | 100.50 | C452694 | 99.70 |
| C452960 | 99.50 | C453143 | 99.70 | C453275 | 99.80 | C453314 | 99.60 | C453563 | 99.70 |
| C453785 | 99.60 | C453833 | 99.80 | C453869 | 99.60 | C454147 | 99.90 | C454291 | 100.20 |
| C454351 | 100.00 | C454404 | 99.90 | C454602 | 99.30 | C454674 | 99.90 | C454687 | 99.90 |
| C455410 | 99.70 | C455590 | 99.80 | C455630 | 100.00 | C455689 | 99.80 | C457879 | 99.90 |
| C457985 | 99.70 | C458207 | 99.90 | C458234 | 99.80 | C458608 | 99.90 | C458714 | 99.60 |
| C459087 | 99.90 | C459252 | 99.90 | C459476 | 99.70 | C459481 | 99.80 | C459850 | 99.90 |
| C460001 | 99.70 | C460410 | 99.80 | C460446 | 99.60 | C460496 | 99.90 | C460546 | 99.80 |
| C460558 | 99.90 | C460697 | 100.10 | C460764 | 100.00 | C460826 | 100.00 | C460989 | 99.80 |
| C461016 | 99.70 | C461069 | 100.10 | C461103 | 99.90 | C461146 | 99.90 | C461183 | 100.10 |
| C461221 | 99.90 | C461343 | 99.80 | C461512 | 100.30 | C461722 | 100.00 | C461829 | 100.00 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 75 |
| 2 | Sum of Measurements: (Sum X) | 7484.00 |
| 3 | Sum of Squared Measurements | 746808.00 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 746803.41 |
| 5 | Corrected Sum of Squares (SS) | 4.59 |
| 6 | Variance (V) : SS/(N-1) | 0.0620 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.2490 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.79 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 8.89 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 7.18 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 4.83 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1299 Lot Descr: KU MX - 5

In Service Population: 1,314 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection



Run Date: 01/07/2015

Run Time: 03:36:55 AM

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---|---|---|---|---|---|---|---|---|---|
| C462008 | 99.90 | C462034 | 99.80 | C462057 | 100.00 | C462060 | 100.00 | C462075 | 99.80 |
| C462079 | 99.90 | C462112 | 100.10 | C462181 | 100.10 | C462205 | 100.10 | C462212 | 99.80 |
| C462242 | 100.00 | C462246 | 100.00 | C462260 | 99.80 | C462263 | 99.80 | C462342 | 99.80 |
| C462363 | 99.90 | C462442 | 99.90 | C462503 | 99.80 | C462514 | 99.80 | C462518 | 99.70 |
| C462525 | 99.90 | C462573 | 99.80 | C462610 | 99.80 | C462623 | 99.60 | C462627 | 100.10 |
| C462721 | 100.10 | C462815 | 99.70 | C462849 | 100.00 | C462855 | 99.80 | C462924 | 100.10 |
| C462946 | 100.10 | C462979 | 100.10 | C463027 | 100.10 | C463045 | 100.00 | C463060 | 100.00 |
| C463069 | 99.90 | C463071 | 99.70 | C463092 | 100.00 | C463096 | 99.80 | C463103 | 100.00 |
| C463143 | 99.80 | C463162 | 99.60 | C463176 | 99.90 | C463240 | 99.80 | C463247 | 99.90 |
| C463262 | 99.80 | C463285 | 99.20 | C463330 | 99.70 | C463331 | 99.80 | C463405 | 99.90 |

| | INFORMATION NEEDED | VALUE OBTAINED |
|---|---|---|
| 1 | Sample Size (N) | 50 |
| 2 | Sum of Measurements: (Sum X) | 4994.00 |
| 3 | Sum of Squared Measurements | 498802.14 |
| 4 | Correction Factor (CF): Sum of Measurements Squared / N | 498800.72 |
| 5 | Corrected Sum of Squares (SS) | 1.42 |
| 6 | Variance (V) : SS/(N-1) | 0.0290 |
| 7 | Estimate of Lot Standard Deviation(S): SQRT of V | 0.1702 |
| 8 | Sample Mean(XBAR): Sum X/N | 99.88 |
| 9 | Upper Specification Limit (U) | 102.00 |
| 10 | Lower Specification Limit (L) | 98.00 |
| 11 | Quality Index Upper (QU): (U-XBAR) / S | 12.45 |
| 12 | Quality Index Lower (QL): (XBAR-L) / S | 11.04 |
| 13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| 14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| 15 | Total Estimate Percent NCF. In Lot (P): PU+PL | 0.00 |
| 16 | Maximum Allowable Percent NCF(M) | 5.21 |
| 17 | Acceptability Criterion: Compare P with M | PASS |
| 18 | The Lot Meets the Acceptability Criterion if P <= M | |
| 19 | The Lot Fails the Acceptability Criterion if P > M | |

Kentucky Utilities

2014 Sample Test Program ( 01/01/2014 ) to ( 12/31/2014 )

| LOT NAME | MANUFACTURER | MODEL | IN-SERV POP | SAMP QTY | SET | REMV | MTRS TST | PASS/FAIL | LOT NUMBER |
|---|---|---|---|---|---|---|---|---|---|
| KU AB1 - 1 | Asea Brown Boveri (ABB) | AB1 | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1239 |
| KU AB1 - 2 | Asea Brown Boveri (ABB) | AB1 | 5,549 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1240 |
| KU ALF -1 | Landis + Gyr | ALF | 18 | 4 | 0 | 0 | 4 | PASS TESTING COMPLETE | 1241 |
| KU C1S - 1 | Sangamo | C1SR | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1242 |
| KU C1S - 2 | Itron | C1S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1243 |
| KU C1S - 3 | Itron | C1S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1244 |
| KU C1S - 4 | Itron | C1S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1245 |
| KU C1S - 5 | Itron | C1S | 5,106 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1246 |
| KU D4S - 1 | Westinghouse | D4S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1247 |
| KU D4S - 2 | Westinghouse | D4S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1248 |
| KU D4S - 3 | Westinghouse | D4S | 6,577 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1249 |
| KU D5S - 1 | Westinghouse | D5S | 449 | 25 | 0 | 0 | 25 | PASS TESTING COMPLETE | 1250 |
| KU I210 - 1 | General Electric | I210 | 5,194 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1251 |
| KU I50 - 1 | General Electric | I50S | 1,085 | 35 | 0 | 0 | 35 | PASS TESTING COMPLETE | 1252 |
| KU I55 - 1 | General Electric | I55S | 960 | 35 | 0 | 0 | 35 | PASS TESTING COMPLETE | 1253 |
| KU I60 - 1 | General Electric | I60S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1254 |
| KU I60 - 2 | General Electric | I60S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1255 |
| KU I60 - 3 | General Electric | I60S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1256 |
| KU I60 - 4 | General Electric | I60S | 92 | 10 | 0 | 0 | 10 | PASS TESTING COMPLETE | 1257 |
| KU I70 - 1 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1258 |
| KU I70 - 2 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1259 |
| KU I70 - 3 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1260 |
| KU I70 - 4 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1261 |
| KU I70 - 5 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1262 |
| KU I70 - 6 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1263 |
| KU I70 - 7 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1264 |
| KU I70 - 8 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1265 |
| KU I70 - 9 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1266 |
| KU I70 - 10 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1267 |
| KU I70 - 11 | General Electric | I70S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1268 |
| KU I70 - 12 | General Electric | I70S | 6,347 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1269 |
| KU J4S - 1 | Sangamo | J4S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1270 |
| KU J4S - 2 | Sangamo | J4S | 2,317 | 50 | 0 | 0 | 50 | PASS TESTING COMPLETE | 1271 |
| KU J5S - 1 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1272 |
| KU J5S - 2 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1273 |
| KU J5S - 3 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1274 |
| KU J5S - 4 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1275 |
| KU J5S - 5 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1276 |
| KU J5S - 6 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1277 |
| KU J5S - 7 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1278 |
| KU J5S - 8 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1279 |
| KU J5S - 9 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1280 |
| KU J5S - 10 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1281 |
| KU J5S - 11 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1282 |
| KU J5S - 12 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1283 |
| KU J5S - 13 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1284 |
| KU J5S - 14 | Sangamo | J5S | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1285 |
| KU J5S - 15 | Sangamo | J5S | 7,024 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1286 |
| KU MKS - 1 | Duncan | MKS | 504 | 35 | 0 | 0 | 35 | FAIL TESTING COMPLETE | 1287 |
| KU MQS - 1 | Duncan | MQS | 3,856 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1288 |
| KU MS - 1 | Duncan | MS | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1289 |
| KU MS - 2 | Duncan | MS | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1290 |
| KU MS - 3 | Duncan | MS | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1291 |
| KU MS - 4 | Duncan | MS | 10,000 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1292 |
| KU MS - 5 | Duncan | MS | 2,659 | 50 | 0 | 0 | 50 | PASS TESTING COMPLETE | 1293 |
| KU MSII - 1 | Landis + Gyr | MSII | 4,049 | 75 | 0 | 0 | 75 | PASS TESTING COMPLETE | 1294 |

| | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| KU MX - 1 | Landis + Gyr | MX | 10,000 | 75 | 0 | 0 | 75 | PASS | TESTING COMPLETE | 1295 |
| KU MX - 2 | Landis + Gyr | MX | 10,000 | 75 | 0 | 0 | 75 | PASS | TESTING COMPLETE | 1296 |
| KU MX - 3 | Landis + Gyr | MX | 10,000 | 75 | 0 | 0 | 75 | PASS | TESTING COMPLETE | 1297 |
| KU MX - 4 | Landis + Gyr | MX | 10,000 | 75 | 0 | 0 | 75 | PASS | TESTING COMPLETE | 1298 |
| KU MX - 5 | Landis + Gyr | MX | 1,314 | 50 | 0 | 0 | 50 | PASS | TESTING COMPLETE | 1299 |
| | | TOTALS | 493,900 | 4194 | 0 | 0 | 4194 | | | |

TOTAL LOTS PASSED: 60
TOTAL LOTS FAILED: 1
METERS CANNOT TEST: 0

Report completed successfully with results.