

RECEIVED

FEB 29 2016

PUBLIC SERVICE
COMMISSION



a PPL company

Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

Kentucky Utilities Company
State Regulation and Rates
220 W. Main Street
PO Box 32010
Louisville, KY 40232
www.lge-ku.com

Rick E. Lovekamp
Manager Regulatory
Affairs/Tariffs
T 502-627-3780
F 502-627-3213
Rick.lovekamp@lge-ku.com

February 29, 2016

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Kentucky Utilities Company

Dear Executive Director:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Kentucky Utilities Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2015 Statistical Sampling Test Results and Summary
(Attachment B)

Executive Director
February 29, 2016

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in blue ink, appearing to read "Rick E. Lovekamp". The signature is fluid and cursive, with the first name "Rick" being more prominent.

Rick E. Lovekamp

Attachments

ATTACHMENT
A

Certified Test Results

LG&E and KU Energy LLC

5040 Annual Report of New Single Phase Meters

Last Data Update:

02/08/2016 03:07:25

Dynamic Filters

Plant KU

Calendar M 01/2015 - 12/2015

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
KU	C1S	2048752	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2048753	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048754	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2048755	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048756	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048757	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048758	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2048759	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048760	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048761	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048762	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048763	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048764	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048765	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048766	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048767	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048768	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048769	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2048770	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048771	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048772	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048773	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048774	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048775	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048776	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048777	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048778	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048779	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2048780	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048781	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048782	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048783	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048784	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048785	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048786	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048787	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048788	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048789	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048790	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048791	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048792	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048793	01/2015	12/16/2014	100.000	100.200	100.2	1
KU	C1S	2048794	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048795	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048796	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2048797	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048798	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048799	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048800	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048801	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048802	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048803	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048804	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048805	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048806	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048807	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048808	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048809	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048810	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048811	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048812	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048813	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048814	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2048815	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048816	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048817	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048818	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048819	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048820	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048821	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2048822	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048823	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048824	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048825	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048826	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048827	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048828	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048829	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048830	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048831	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048832	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048833	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2048834	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048835	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048836	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048837	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048838	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048839	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048840	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048841	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048842	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048843	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048844	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048845	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048846	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048847	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048848	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2048849	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048850	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048851	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048852	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048853	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048854	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048855	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048856	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048857	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048858	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048859	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048860	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048861	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048862	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048863	01/2015	12/16/2014	100.000	100.200	100.1	1

KU	C1S	2048864	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048865	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048866	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048867	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048868	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048869	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048870	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048871	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048872	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048873	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048874	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048875	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048876	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048877	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048878	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048879	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048880	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048881	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048882	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048883	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048884	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048885	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048886	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048887	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2048888	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048889	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048890	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048891	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048892	01/2015	12/16/2014	100.000	100.200	100.2	1
KU	C1S	2048893	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048894	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048895	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048896	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048897	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048898	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2048899	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048900	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048901	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2048902	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048903	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048904	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048905	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2048906	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048907	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048908	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048909	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048910	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048911	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2048912	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2048913	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048914	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048915	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048916	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048917	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048918	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048919	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048920	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048921	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2048922	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048923	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048924	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048925	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048926	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048927	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048928	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048929	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048930	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048931	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048932	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2048933	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048934	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048935	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048936	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048937	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048938	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048939	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048940	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048941	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048942	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048943	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048944	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048945	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048946	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048947	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2048948	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048949	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048950	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048951	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048952	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048953	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2048954	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048955	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048956	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048957	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048958	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048959	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048960	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048961	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048962	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048963	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048964	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048965	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048966	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048967	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048968	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048969	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048970	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048971	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048972	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048973	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048974	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048975	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048976	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048977	01/2015	12/16/2014	99.900	100.200	100.1	1
KU	C1S	2048978	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048979	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2048980	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048981	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2048982	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048983	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048984	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048985	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2048986	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048987	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048988	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2048989	01/2015	12/16/2014	99.900	100.000	100.0	1

KU	C1S	2048990	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048991	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048992	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2048993	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048994	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048995	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2048996	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2048997	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048998	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2048999	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049000	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049001	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049002	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049003	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049004	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049005	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049006	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049007	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049008	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049009	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049010	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049011	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049012	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049013	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049014	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049015	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049016	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049017	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049018	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049019	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049020	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049021	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049022	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049023	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049024	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049025	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049026	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049027	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049028	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049029	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049030	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049031	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049032	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049033	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049034	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049035	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049036	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049037	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049038	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049039	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049040	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049041	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049042	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049043	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049044	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049045	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049046	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049047	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049048	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049049	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049050	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049051	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049052	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049053	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049054	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049055	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049056	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049057	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049058	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049059	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049060	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049061	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049062	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049063	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049064	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049065	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049066	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049067	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049068	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049069	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049070	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049071	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049072	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049073	01/2015	12/16/2014	100.000	100.200	100.1	1

KU	C1S	2049074	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049075	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049076	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049077	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049078	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049079	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049080	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049081	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049082	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049083	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049084	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049085	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049086	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049087	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049088	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049089	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049090	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049091	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049092	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049093	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049094	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049095	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049096	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049097	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049098	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049099	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049100	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049101	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049102	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049103	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049104	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049105	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049106	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049107	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049108	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049109	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049110	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049111	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049112	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049113	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049114	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049115	01/2015	12/16/2014	100.000	100.000	100.0	1

KU	C1S	2049116	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049117	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049118	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049119	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049120	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049121	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049122	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049123	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049124	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049125	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049126	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049127	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049128	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049129	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049130	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049131	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049132	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049133	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049134	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049135	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049136	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049137	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049138	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049139	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049140	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049141	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049142	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049143	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049144	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049145	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049146	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049147	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049148	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049149	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049150	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049151	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049152	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049153	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049154	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049155	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049156	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049157	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2049158	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049159	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049160	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049161	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049162	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049163	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049164	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049165	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049166	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049167	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049168	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049169	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049170	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049171	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049172	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049173	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049174	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049175	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049176	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049177	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049178	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049179	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049180	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049181	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049182	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049183	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049184	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049185	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049186	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049187	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049188	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049189	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049190	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049191	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049192	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049193	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049194	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049195	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049196	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049197	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049198	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049199	01/2015	12/16/2014	100.000	100.200	100.1	1

KU	C1S	2049200	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049201	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049202	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049203	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049204	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049205	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049206	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049207	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049208	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049209	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049210	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049211	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049212	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049213	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049214	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049215	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049216	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049217	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049218	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049219	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049220	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049221	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049222	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049223	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049224	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049225	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049226	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049227	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049228	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049229	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049230	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049231	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049232	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049233	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049234	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049235	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049236	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049237	01/2015	11/25/2014	100.000	100.100	100.0	1
KU	C1S	2049238	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049239	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049240	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049241	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049242	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049243	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049244	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049245	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049246	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049247	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049248	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049249	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049250	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049251	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049252	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049253	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049254	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049255	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049256	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049257	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049258	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049259	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049260	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049261	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049262	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049263	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049264	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049265	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049266	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049267	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049268	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049269	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049270	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049271	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049272	01/2015	11/26/2014	100.000	100.100	100.1	1
KU	C1S	2049273	01/2015	12/07/2014	100.000	100.100	100.0	1
KU	C1S	2049274	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049275	01/2015	12/06/2014	100.000	100.100	100.1	1
KU	C1S	2049276	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049277	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049278	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049279	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049280	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049281	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049282	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049283	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049284	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049285	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049286	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049287	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049288	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049289	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049290	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049291	01/2015	12/03/2014	99.900	100.100	100.1	1
KU	C1S	2049292	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049293	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049294	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049295	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049296	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049297	01/2015	12/05/2014	100.000	100.200	100.1	1
KU	C1S	2049298	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049299	01/2015	11/26/2014	100.000	100.100	100.0	1
KU	C1S	2049300	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049301	01/2015	12/01/2014	100.000	100.200	100.0	1
KU	C1S	2049302	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049303	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049304	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049305	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049306	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049307	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049308	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049309	01/2015	12/01/2014	100.000	100.100	100.0	1
KU	C1S	2049310	01/2015	12/12/2014	100.000	100.200	100.1	1
KU	C1S	2049311	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049312	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049313	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049314	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049315	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049316	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049317	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049318	01/2015	12/05/2014	100.000	100.100	100.1	1
KU	C1S	2049319	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049320	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049321	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049322	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049323	01/2015	12/15/2014	100.000	100.200	100.1	1
KU	C1S	2049324	01/2015	12/15/2014	99.900	100.100	99.9	1
KU	C1S	2049325	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049326	01/2015	12/08/2014	100.000	100.100	100.1	1
KU	C1S	2049327	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049328	01/2015	12/01/2014	100.000	100.200	100.0	1
KU	C1S	2049329	01/2015	12/15/2014	99.900	100.100	100.0	1
KU	C1S	2049330	01/2015	12/12/2014	100.000	100.100	100.1	1
KU	C1S	2049331	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049332	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049333	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049334	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049335	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049336	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049337	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049338	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049339	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049340	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049341	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049342	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049343	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049344	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049345	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049346	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049347	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049348	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049349	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049350	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049351	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049352	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049353	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049354	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049355	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049356	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049357	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049358	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049359	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049360	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049361	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049362	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049363	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049364	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049365	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049366	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049367	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049368	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049369	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049370	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049371	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049372	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049373	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049374	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049375	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049376	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049377	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049378	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049379	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049380	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049381	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049382	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049383	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049384	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049385	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049386	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049387	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049388	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049389	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049390	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049391	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049392	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049393	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049394	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049395	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049396	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049397	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049398	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049399	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049400	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049401	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049402	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049403	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049404	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049405	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049406	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049407	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049408	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049409	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049410	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049411	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049412	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049413	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049414	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049415	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049416	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049417	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049418	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049419	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049420	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049421	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049422	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049423	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049424	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049425	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049426	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049427	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049428	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049429	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049430	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049431	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049432	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049433	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049434	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049435	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049436	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049437	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049438	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049439	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049440	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049441	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049442	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049443	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049444	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049445	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049446	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049447	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049448	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049449	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049450	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049451	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2049494	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049495	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049496	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049497	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049498	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049499	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049500	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049501	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049502	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049503	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049504	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049505	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049506	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049507	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049508	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049509	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049510	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049511	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049512	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049513	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049514	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049515	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049516	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049517	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049518	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049519	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049520	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049521	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049522	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049523	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049524	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049525	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049526	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049527	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049528	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049529	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049530	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049531	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049532	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049533	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049534	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049535	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049536	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049537	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049538	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049539	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049540	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049541	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049542	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049543	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049544	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049545	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049546	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049547	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049548	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049549	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049550	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049551	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049552	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049553	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049554	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049555	01/2015	12/05/2014	100.000	100.100	100.1	1
KU	C1S	2049556	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049557	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049558	01/2015	12/02/2014	100.000	100.100	100.1	1
KU	C1S	2049559	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049560	01/2015	12/06/2014	100.000	100.100	100.0	1
KU	C1S	2049561	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049562	01/2015	12/07/2014	100.000	100.100	100.0	1
KU	C1S	2049563	01/2015	12/07/2014	100.000	100.100	100.1	1
KU	C1S	2049564	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049565	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049566	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049567	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049568	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049569	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049570	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049571	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049572	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049573	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049574	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049575	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049576	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049577	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049578	01/2015	12/06/2014	100.000	100.100	100.1	1
KU	C1S	2049579	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049580	01/2015	11/26/2014	100.000	100.200	100.0	1
KU	C1S	2049581	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049582	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2049583	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049584	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049585	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049586	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049587	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049588	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049589	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049590	01/2015	12/12/2014	100.000	100.200	100.0	1
KU	C1S	2049591	01/2015	12/06/2014	100.000	100.100	100.1	1
KU	C1S	2049592	01/2015	12/16/2014	100.000	100.000	99.9	1
KU	C1S	2049593	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049594	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049595	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049596	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049597	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049598	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049599	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049600	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049601	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049602	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049603	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049604	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049605	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049606	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049607	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049608	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049609	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049610	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049611	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049612	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049613	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049614	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049615	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049616	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049617	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049618	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049619	01/2015	12/16/2014	100.000	100.000	100.0	1

KU	C1S	2049620	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049621	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049622	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049623	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049624	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049625	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049626	01/2015	12/06/2014	100.000	100.100	100.1	1
KU	C1S	2049627	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049628	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049629	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049630	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049631	01/2015	12/02/2014	100.000	100.200	100.0	1
KU	C1S	2049632	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049633	01/2015	12/02/2014	100.000	100.200	100.0	1
KU	C1S	2049634	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049635	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049636	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049637	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049638	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049639	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049640	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049641	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049642	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049643	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049644	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049645	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049646	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049647	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049648	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049649	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049650	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049651	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049652	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049653	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049654	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049655	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049656	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049657	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049658	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049659	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049660	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049661	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049662	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049663	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049664	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049665	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049666	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049667	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049668	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049669	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049670	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049671	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049672	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049673	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049674	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049675	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049676	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049677	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049678	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049679	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049680	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049681	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049682	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049683	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049684	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049685	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049686	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049687	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049688	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049689	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049690	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049691	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049692	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049693	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049694	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049695	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049696	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049697	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049698	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049699	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049700	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049701	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049702	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049703	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2049704	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049705	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049706	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049707	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049708	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049709	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049710	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049711	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049712	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049713	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049714	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049715	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049716	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049717	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049718	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049719	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049720	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049721	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049722	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049723	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2049724	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049725	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049726	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049727	01/2015	12/16/2014	99.900	100.200	99.9	1
KU	C1S	2049728	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049729	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049730	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049731	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049732	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049733	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049734	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049735	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049736	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049737	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049738	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049739	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049740	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049741	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049742	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049743	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049744	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049745	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049746	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049747	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049748	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049749	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049750	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049751	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049752	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049753	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049754	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049755	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049756	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049757	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049758	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049759	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049760	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049761	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049762	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049763	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049764	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049765	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049766	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049767	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049768	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049769	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049770	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049771	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049772	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049773	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049774	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049775	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049776	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049777	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049778	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049779	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049780	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049781	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049782	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049783	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049784	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049785	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049786	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049787	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049788	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049789	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049790	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049791	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049792	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049793	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049794	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049795	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049796	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049797	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049798	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049799	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049800	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049801	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049802	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049803	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049804	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049805	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2049806	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049807	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049808	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049809	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049810	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049811	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049812	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049813	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049814	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049815	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049816	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049817	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049818	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049819	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049820	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049821	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049822	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049823	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049824	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049825	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049826	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049827	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049828	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049829	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049830	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049831	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049832	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049833	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049834	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049835	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049836	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049837	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049838	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049839	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049840	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049841	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049842	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049843	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049844	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049845	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049846	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049847	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049848	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049849	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049850	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049851	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049852	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049853	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049854	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049855	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049856	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049857	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049858	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049859	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049860	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049861	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049862	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049863	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049864	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049865	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049866	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049867	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049868	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049869	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049870	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049871	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049872	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049873	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049874	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049875	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049876	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049877	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049878	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049879	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049880	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049881	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049882	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049883	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049884	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049885	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049886	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049887	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049888	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049889	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049890	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049891	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049892	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049893	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049894	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049895	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049896	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049897	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049898	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049899	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049900	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049901	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049902	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049903	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049904	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049905	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049906	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049907	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049908	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049909	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049910	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2049911	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049912	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049913	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2049914	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049915	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049916	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049917	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049918	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049919	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049920	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049921	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049922	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049923	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049924	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049925	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049926	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049927	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049928	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049929	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049930	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049931	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049932	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049933	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2049934	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049935	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049936	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049937	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2049938	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049939	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049940	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049941	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049942	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049943	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049944	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049945	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049946	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049947	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049948	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049949	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049950	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049951	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2049952	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049953	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049954	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049955	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2049956	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049957	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049958	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049959	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049960	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049961	01/2015	12/04/2014	100.000	100.200	100.1	1
KU	C1S	2049962	01/2015	12/12/2014	100.000	100.100	100.0	1
KU	C1S	2049963	01/2015	12/04/2014	100.000	100.100	100.0	1
KU	C1S	2049964	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049965	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049966	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049967	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049968	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049969	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2049970	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049971	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049972	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2049973	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049974	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049975	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049976	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049977	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049978	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049979	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049980	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049981	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049982	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049983	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049984	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049985	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049986	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049987	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2049988	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049989	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2049990	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049991	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049992	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2049993	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049994	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049995	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2049996	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2049997	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2049998	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2049999	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050000	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050001	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050002	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050003	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050004	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050005	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050006	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050007	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050008	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050009	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050010	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050011	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050012	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050013	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050014	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050015	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050016	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050017	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050018	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050019	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050020	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050021	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050022	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050023	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050024	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050025	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050026	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050027	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050028	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050029	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050030	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050031	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050032	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050033	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050034	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050035	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050036	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050037	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050038	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050039	01/2015	12/16/2014	100.000	100.200	100.1	1

KU	C1S	2050040	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050041	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050042	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050043	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050044	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050045	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050046	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050047	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050048	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050049	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050050	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050051	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050052	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050053	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050054	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050055	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050056	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050057	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050058	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050059	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050060	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050061	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050062	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050063	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050064	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050065	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050066	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050067	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050068	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050069	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050070	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050071	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050072	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050073	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050074	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050075	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050076	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050077	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050078	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050079	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050080	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050081	01/2015	12/16/2014	100.000	100.200	100.0	1

KU	C1S	2050082	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050083	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050084	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050085	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050086	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050087	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050088	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050089	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050090	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050091	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050092	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050093	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050094	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050095	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050096	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050097	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050098	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050099	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050100	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050101	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050102	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050103	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050104	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050105	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050106	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050107	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050108	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050109	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050110	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050111	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050112	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050113	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050114	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050115	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050116	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050117	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050118	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050119	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050120	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050121	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050122	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050123	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050124	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050125	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050126	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050127	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050128	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050129	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050130	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050131	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050132	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050133	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050134	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050135	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050136	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050137	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050138	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050139	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050140	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050141	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050142	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050143	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050144	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050145	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050146	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050147	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050148	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050149	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050150	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050151	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050152	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050153	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050154	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050155	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050156	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050157	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050158	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050159	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050160	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050161	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050162	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050163	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050164	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050165	01/2015	12/16/2014	100.000	100.200	99.9	1

KU	C1S	2050166	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050167	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050168	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050169	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050170	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050171	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050172	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050173	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050174	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050175	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050176	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050177	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050178	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050179	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050180	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050181	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050182	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050183	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050184	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050185	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050186	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050187	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050188	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050189	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050190	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050191	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050192	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050193	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050194	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050195	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050196	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050197	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050198	01/2015	12/16/2014	99.900	100.000	100.1	1
KU	C1S	2050199	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050200	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050201	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050202	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050203	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050204	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050205	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050206	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050207	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050208	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050209	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050210	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050211	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050212	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050213	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050214	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050215	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050216	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050217	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050218	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050219	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050220	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050221	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050222	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050223	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050224	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050225	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050226	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050227	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050228	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050229	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050230	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050231	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050232	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050233	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050234	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050235	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050236	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050237	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050238	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050239	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050240	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050241	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050242	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050243	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050244	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050245	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050246	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050247	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050248	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050249	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050250	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050251	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050252	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050253	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050254	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050255	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050256	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050257	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050258	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050259	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050260	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050261	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050262	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050263	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050264	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050265	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050266	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050267	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050268	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050269	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050270	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050271	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050272	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050273	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050274	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050275	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050276	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050277	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050278	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050279	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050280	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050281	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050282	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050283	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050284	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050285	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050286	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050287	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050288	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2050289	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050290	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050291	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050292	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050293	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050294	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050295	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050296	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050297	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050298	01/2015	12/16/2014	99.900	100.200	100.1	1
KU	C1S	2050299	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050300	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050301	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050302	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050303	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050304	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050305	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050306	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050307	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050308	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050309	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050310	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050311	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050312	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050313	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050314	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050315	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050316	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050317	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050318	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050319	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050320	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050321	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050322	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050323	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050324	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050325	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050326	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2050327	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050328	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050329	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050330	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050331	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050332	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050333	01/2015	12/16/2014	99.900	100.100	99.9	1

KU	C1S	2050334	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050335	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050336	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050337	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050338	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050339	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050340	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050341	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050342	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050343	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050344	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050345	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050346	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050347	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050348	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050349	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050350	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050351	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050352	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050353	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050354	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050355	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050356	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050357	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050358	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050359	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050360	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050361	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050362	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050363	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050364	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050365	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050366	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050367	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050368	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050369	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050370	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050371	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050372	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050373	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050374	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050375	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2050376	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050377	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050378	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050379	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050380	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050381	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050382	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050383	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050384	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050385	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050386	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050387	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050388	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050389	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050390	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050391	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050392	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050393	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050394	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050395	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050396	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050397	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050398	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050399	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050400	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050401	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050402	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050403	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050404	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050405	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050406	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050407	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050408	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050409	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050410	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050411	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050412	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050413	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050414	01/2015	12/16/2014	99.900	100.200	99.9	1
KU	C1S	2050415	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050416	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050417	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2050418	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050419	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050420	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050421	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050422	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2050423	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050424	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050425	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050426	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050427	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050428	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050429	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2050430	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050431	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050432	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050433	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050434	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050435	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050436	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050437	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050438	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050439	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050440	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050441	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050442	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050443	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050444	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050445	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050446	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2050447	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050448	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050449	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050450	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050451	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050452	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050453	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050454	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050455	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050456	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050457	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050458	01/2015	12/16/2014	100.000	100.000	100.1	1
KU	C1S	2050459	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2050460	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050461	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050462	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050463	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050464	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050465	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050466	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050467	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050468	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050469	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050470	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050471	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050472	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050473	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050474	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050475	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050476	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050477	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050478	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050479	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050480	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050481	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050482	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050483	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050484	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050485	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050486	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050487	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050488	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050489	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050490	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050491	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050492	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050493	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050494	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050495	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050496	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050497	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050498	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050499	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050500	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050501	01/2015	12/16/2014	100.000	100.200	100.1	1

KU	C1S	2050502	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050503	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050504	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050505	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050506	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050507	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050508	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050509	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050510	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050511	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050512	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050513	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050514	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050515	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050516	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050517	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050518	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050519	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050520	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050521	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050522	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050523	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050524	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050525	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050526	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050527	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050528	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050529	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050530	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050531	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050532	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050533	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050534	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050535	01/2015	12/16/2014	100.000	100.100	100.2	1
KU	C1S	2050536	01/2015	12/16/2014	99.900	100.100	99.9	1
KU	C1S	2050537	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050538	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050539	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050540	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050541	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050542	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050543	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050544	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050545	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050546	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050547	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050548	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050549	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050550	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050551	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2050552	01/2015	12/16/2014	99.900	100.000	100.1	1
KU	C1S	2050553	01/2015	12/16/2014	100.000	100.200	99.9	1
KU	C1S	2050554	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050555	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050556	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050557	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050558	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050559	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050560	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050561	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050562	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050563	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050564	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050565	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050566	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050567	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050568	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050569	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050570	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050571	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050572	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050573	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050574	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050575	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050576	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050577	01/2015	12/16/2014	99.900	100.000	100.0	1
KU	C1S	2050578	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050579	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050580	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050581	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050582	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050583	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050584	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050585	01/2015	12/16/2014	100.000	100.100	100.1	1

KU	C1S	2050586	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050587	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050588	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050589	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050590	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050591	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050592	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050593	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050594	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050595	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050596	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050597	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050598	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050599	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050600	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050601	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050602	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050603	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050604	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050605	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050606	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050607	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050608	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050609	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050610	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050611	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050612	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050613	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050614	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050615	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050616	01/2015	12/16/2014	99.900	100.200	100.0	1
KU	C1S	2050617	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050618	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050619	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050620	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050621	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050622	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050623	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050624	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050625	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050626	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050627	01/2015	12/16/2014	100.000	100.000	100.0	1

KU	C1S	2050628	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050629	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050630	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050631	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050632	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050633	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050634	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050635	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050636	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050637	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050638	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050639	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050640	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050641	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050642	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050643	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050644	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050645	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050646	01/2015	12/16/2014	100.000	100.000	100.0	1
KU	C1S	2050647	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050648	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050649	01/2015	12/16/2014	99.900	100.100	100.1	1
KU	C1S	2050650	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050651	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050652	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050653	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050654	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050655	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050656	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050657	01/2015	12/16/2014	100.000	100.200	100.1	1
KU	C1S	2050658	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050659	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050660	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050661	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050662	01/2015	12/16/2014	100.000	100.200	100.0	1
KU	C1S	2050663	01/2015	12/16/2014	99.900	100.100	100.0	1
KU	C1S	2050664	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050665	01/2015	12/16/2014	100.000	100.100	99.9	1
KU	C1S	2050666	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050667	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050668	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2050669	01/2015	12/16/2014	100.000	100.100	100.0	1

KU	C1S	2050670	01/2015	12/16/2014	100.000	100.100	100.1	1
KU	C1S	2050671	01/2015	12/16/2014	100.000	100.100	100.0	1
KU	C1S	2051440	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051441	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051442	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051443	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051444	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051445	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051446	05/2015	04/24/2015	100.000	100.100	99.8	1
KU	C1S	2051447	05/2015	04/24/2015	100.000	100.200	99.8	1
KU	C1S	2051448	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051449	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051450	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051451	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051452	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051453	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051454	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051455	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051456	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051457	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051458	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051459	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051460	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051461	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051462	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051463	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051464	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051465	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051466	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051467	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2051468	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051469	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051470	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051471	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051472	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051473	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051474	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051475	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051476	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051477	05/2015	04/24/2015	99.900	100.100	100.1	1
KU	C1S	2051478	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051479	05/2015	04/24/2015	100.000	100.100	100.1	1

KU	C1S	2051480	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051481	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051482	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051483	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051484	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051485	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051486	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051487	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051488	05/2015	04/24/2015	100.000	100.000	100.1	1
KU	C1S	2051489	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051490	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051491	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051492	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051493	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051494	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051495	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051496	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051497	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051498	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051499	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051500	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051501	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051502	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2051503	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051504	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051505	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051506	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051507	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051508	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051509	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051510	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051511	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051512	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051513	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051514	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051515	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051516	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051517	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051518	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051519	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051520	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051521	05/2015	04/22/2015	100.000	100.100	100.0	1

KU	C1S	2051522	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051523	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051524	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051525	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051526	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051527	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051528	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051529	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051530	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051531	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051532	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051533	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051534	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051535	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051536	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051537	05/2015	04/24/2015	100.000	100.200	100.2	1
KU	C1S	2051538	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051539	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051540	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051541	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051542	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051543	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051544	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051545	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051546	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051547	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051548	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051549	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051550	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051551	05/2015	04/24/2015	100.000	100.200	100.2	1
KU	C1S	2051552	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051553	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051554	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051555	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051556	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051557	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051558	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051559	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051560	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051561	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051562	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051563	05/2015	04/24/2015	100.000	100.100	100.1	1

KU	C1S	2051606	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051607	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051608	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051609	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051610	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051611	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051612	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051613	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051614	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051615	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051616	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051617	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051618	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051619	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051620	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051621	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051622	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051623	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051624	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051625	05/2015	04/22/2015	99.900	100.200	100.0	1
KU	C1S	2051626	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051627	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051628	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051629	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051630	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051631	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051632	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051633	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051634	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051635	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051636	05/2015	04/22/2015	100.000	100.000	100.1	1
KU	C1S	2051637	05/2015	04/22/2015	99.900	100.200	100.0	1
KU	C1S	2051638	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051639	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051640	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051641	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051642	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051643	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051644	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051645	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051646	05/2015	04/22/2015	99.900	100.200	100.0	1
KU	C1S	2051647	05/2015	04/22/2015	100.000	100.100	100.1	1

KU	C1S	2051648	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051649	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051650	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051651	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051652	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051653	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051654	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051655	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051656	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051657	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051658	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051659	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051660	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051661	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051662	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2051663	05/2015	04/22/2015	100.000	100.000	100.1	1
KU	C1S	2051664	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051665	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051666	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051667	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051668	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051669	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051670	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051671	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051672	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051673	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051674	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051675	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051676	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051677	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051678	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051679	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051680	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051681	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051682	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051683	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051684	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051685	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051686	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051687	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051688	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051689	05/2015	04/22/2015	100.000	100.100	100.1	1

KU	C1S	2051690	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051691	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051692	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051693	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051694	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051695	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051696	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051697	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051698	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051699	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051700	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051701	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051702	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051703	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2051704	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051705	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051706	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051707	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051708	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051709	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051710	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051711	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051712	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051713	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051714	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051715	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051716	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051717	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051718	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051719	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051720	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051721	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051722	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051723	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051724	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051725	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051726	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051727	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051728	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051729	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051730	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051731	05/2015	04/22/2015	100.000	100.200	100.0	1

KU	C1S	2051732	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051733	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051734	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051735	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051736	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051737	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051738	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2051739	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051740	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051741	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051742	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051743	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051744	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051745	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051746	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051747	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051748	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051749	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051750	05/2015	04/22/2015	99.900	100.000	100.0	1
KU	C1S	2051751	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051752	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051753	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051754	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051755	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051756	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051757	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051758	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051759	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051760	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051761	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051762	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051763	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051764	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051765	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051766	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051767	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051768	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051769	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051770	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051771	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051772	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051773	05/2015	04/22/2015	100.000	100.200	100.1	1

KU	C1S	2051774	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051775	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051776	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051777	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051778	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051779	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051780	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051781	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051782	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051783	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2051784	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051785	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051786	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051787	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051788	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051789	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051790	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051791	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051792	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051793	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051794	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051795	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2051796	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051797	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051798	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051799	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051800	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051801	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051802	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051803	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051804	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051805	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051806	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051807	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051808	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051809	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051810	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051811	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051812	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051813	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051814	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051815	05/2015	04/22/2015	100.000	100.200	100.0	1

KU	C1S	2051816	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051817	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051818	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051819	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051820	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051821	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051822	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2051823	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051824	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051825	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051826	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051827	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051828	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051829	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051830	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051831	05/2015	04/22/2015	99.900	100.200	100.1	1
KU	C1S	2051832	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051833	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051834	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051835	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051836	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051837	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051838	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2051839	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051840	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051841	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051842	05/2015	04/22/2015	99.900	100.000	100.0	1
KU	C1S	2051843	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051844	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051845	05/2015	04/22/2015	99.900	100.200	100.0	1
KU	C1S	2051846	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2051847	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051848	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051849	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051850	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051851	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051852	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051853	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051854	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051855	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051856	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051857	05/2015	04/22/2015	100.000	100.100	100.1	1

KU	C1S	2051858	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051859	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051860	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051861	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051862	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051863	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051864	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051865	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051866	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051867	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051868	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051869	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051870	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051871	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051872	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051873	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2051874	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051875	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051876	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051877	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051878	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051879	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051880	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051881	05/2015	04/22/2015	100.000	100.000	100.1	1
KU	C1S	2051882	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051883	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2051884	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051885	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051886	05/2015	04/22/2015	99.900	100.000	100.1	1
KU	C1S	2051887	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2051888	05/2015	04/07/2015	100.000	100.100	100.1	1
KU	C1S	2051889	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051890	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2051891	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2051892	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051893	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051894	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2051895	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051896	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2051897	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051898	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051899	05/2015	04/24/2015	100.000	100.000	99.9	1

KU	C1S	2051900	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2051901	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051902	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051903	05/2015	04/24/2015	100.000	100.200	99.9	1
KU	C1S	2051904	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2051905	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051906	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051907	05/2015	04/24/2015	100.000	100.000	100.1	1
KU	C1S	2051908	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051909	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051910	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051911	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051912	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051913	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051914	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051915	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2051916	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051917	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051918	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051919	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051920	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051921	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051922	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051923	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2051924	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051925	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051926	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051927	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051928	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051929	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051930	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051931	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051932	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051933	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051934	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051935	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051936	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051937	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051938	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051939	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051940	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051941	05/2015	04/24/2015	100.000	100.200	100.0	1

KU	C1S	2051942	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051943	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051944	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051945	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051946	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051947	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051948	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051949	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051950	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051951	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051952	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051953	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051954	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051955	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051956	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051957	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2051958	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051959	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051960	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051961	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051962	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051963	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051964	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051965	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051966	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051967	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051968	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051969	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051970	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051971	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051972	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051973	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051974	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051975	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051976	05/2015	04/24/2015	100.000	100.000	100.1	1
KU	C1S	2051977	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051978	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051979	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051980	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051981	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2051982	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051983	05/2015	04/24/2015	100.000	100.200	100.0	1

KU	C1S	2051984	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051985	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2051986	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051987	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051988	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051989	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051990	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051991	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051992	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051993	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051994	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2051995	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2051996	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051997	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2051998	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2051999	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052000	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052001	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052002	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052003	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052004	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052005	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052006	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052007	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052008	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052009	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052010	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052011	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052012	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052013	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052014	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052015	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052016	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052017	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052018	05/2015	04/24/2015	100.000	100.200	100.2	1
KU	C1S	2052019	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052020	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052021	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052022	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052023	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052024	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052025	05/2015	04/24/2015	100.000	100.100	100.1	1

KU	C1S	2052026	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052027	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052028	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052029	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052030	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052031	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052032	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052033	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052034	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052035	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052036	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052037	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052038	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052039	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052040	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052041	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052042	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052043	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052044	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052045	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052046	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052047	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052048	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052049	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052050	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052051	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052052	05/2015	04/24/2015	99.900	100.100	100.1	1
KU	C1S	2052053	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052054	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052055	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052056	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052057	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052058	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052059	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052060	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052061	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052062	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052063	05/2015	04/24/2015	99.900	100.100	100.1	1
KU	C1S	2052064	05/2015	04/24/2015	99.900	100.200	100.1	1
KU	C1S	2052065	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052066	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052067	05/2015	04/24/2015	100.000	100.100	100.0	1

KU	C1S	2052068	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052069	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052070	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052071	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052072	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052073	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052074	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052075	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052076	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052077	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052078	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052079	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052080	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052081	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052082	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052083	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052084	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052085	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052086	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052087	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052088	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052089	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052090	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052091	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052092	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052093	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052094	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052095	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052096	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052097	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052098	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052099	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052100	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052101	05/2015	04/24/2015	99.900	100.200	100.1	1
KU	C1S	2052102	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052103	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052104	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052105	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052106	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052107	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052108	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052109	05/2015	04/24/2015	100.000	100.100	100.0	1

KU	C1S	2052110	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052111	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052112	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052113	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052114	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052115	05/2015	04/23/2015	99.900	100.000	100.0	1
KU	C1S	2052116	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052117	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052118	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052119	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052120	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052121	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052122	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052123	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052124	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052125	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052126	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052127	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052128	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052129	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052130	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052131	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052132	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052133	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052134	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052135	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052136	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052137	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052138	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052139	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052140	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052141	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052142	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052143	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052144	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052145	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2052146	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052147	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052148	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052149	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052150	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052151	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052152	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052153	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052154	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052155	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2052156	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052157	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052158	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052159	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052160	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052161	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052162	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052163	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052164	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052165	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052166	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052167	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052168	05/2015	04/24/2015	100.000	99.900	100.0	1
KU	C1S	2052169	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052170	05/2015	04/24/2015	100.000	100.000	100.1	1
KU	C1S	2052171	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052172	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052173	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052174	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052175	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052176	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052177	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052178	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2052179	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052180	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052181	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052182	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052183	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052184	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052185	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052186	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052187	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052188	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052189	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052190	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052191	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052192	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052193	05/2015	04/24/2015	100.000	100.100	100.0	1

KU	C1S	2052194	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052195	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052196	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052197	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052198	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052199	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052200	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052201	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052202	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052203	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052204	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052205	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052206	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052207	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052208	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052209	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052210	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052211	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052212	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052213	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052214	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052215	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052216	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052217	05/2015	04/24/2015	99.900	100.100	100.0	1
KU	C1S	2052218	05/2015	04/24/2015	99.900	100.100	100.1	1
KU	C1S	2052219	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052220	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052221	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052222	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052223	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052224	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052225	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052226	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052227	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052228	05/2015	04/23/2015	100.000	100.200	100.2	1
KU	C1S	2052229	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052230	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052231	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052232	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052233	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052234	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052235	05/2015	04/24/2015	100.000	100.200	100.0	1

KU	C1S	2052236	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052237	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052238	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052239	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052240	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052241	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052242	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052243	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052244	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052245	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052246	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052247	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052248	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052249	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052250	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052251	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052252	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052253	05/2015	04/23/2015	100.000	100.000	99.8	1
KU	C1S	2052254	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052255	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052256	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052257	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052258	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052259	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052260	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052261	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052262	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052263	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052264	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052265	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052266	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052267	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052268	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052269	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052270	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052271	05/2015	04/23/2015	100.000	100.000	100.1	1
KU	C1S	2052272	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052273	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052274	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052275	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052276	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052277	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052278	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052279	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052280	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052281	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052282	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052283	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052284	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052285	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052286	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052287	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052288	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052289	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052290	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052291	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052292	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052293	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052294	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052295	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052296	05/2015	04/23/2015	99.900	100.000	100.1	1
KU	C1S	2052297	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052298	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052299	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052300	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052301	05/2015	04/23/2015	100.000	100.200	99.9	1
KU	C1S	2052302	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052303	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052304	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052305	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052306	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2052307	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052308	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052309	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052310	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052311	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052312	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052313	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2052314	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052315	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052316	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052317	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052318	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052319	05/2015	04/24/2015	100.000	100.100	100.0	1

KU	C1S	2052320	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052321	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052322	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052323	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052324	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052325	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052326	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2052327	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2052328	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052329	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052330	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052331	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052332	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052333	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052334	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052335	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052336	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052337	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052338	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052339	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052340	05/2015	04/21/2015	100.000	100.200	100.0	1
KU	C1S	2052341	05/2015	04/21/2015	100.000	100.000	100.0	1
KU	C1S	2052342	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052343	05/2015	04/21/2015	100.000	100.200	100.0	1
KU	C1S	2052344	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052345	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052346	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052347	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052348	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052349	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2052350	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052351	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052352	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052353	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052354	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052355	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052356	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052357	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052358	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052359	05/2015	04/22/2015	99.900	100.200	100.0	1
KU	C1S	2052360	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052361	05/2015	04/22/2015	100.000	100.100	100.0	1

KU	C1S	2052362	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052363	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052364	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052365	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052366	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052367	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052368	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052369	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052370	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052371	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052372	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052373	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052374	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052375	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052376	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052377	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052378	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052379	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052380	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052381	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052382	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052383	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052384	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052385	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052386	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052387	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052388	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052389	05/2015	04/22/2015	100.000	100.200	100.2	1
KU	C1S	2052390	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052391	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052392	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052393	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052394	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052395	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052396	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052397	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052398	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052399	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052400	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052401	05/2015	04/22/2015	100.000	100.000	100.1	1
KU	C1S	2052402	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052403	05/2015	04/22/2015	100.000	100.200	100.1	1

KU	C1S	2052404	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052405	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052406	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052407	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052408	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052409	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052410	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052411	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052412	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2052413	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052414	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052415	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052416	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052417	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052418	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052419	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2052420	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2052421	05/2015	04/22/2015	100.000	100.000	100.1	1
KU	C1S	2052422	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052423	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052424	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052425	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052426	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052427	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052428	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052429	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052430	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052431	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052432	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052433	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052434	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052435	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052436	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052437	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052438	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052439	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052440	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052441	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052442	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052443	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052444	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052445	05/2015	04/21/2015	100.000	100.200	100.0	1

KU	C1S	2052446	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052447	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052448	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052449	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052450	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052451	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052452	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052453	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052454	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052455	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052456	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052457	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052458	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052459	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052460	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052461	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052462	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052463	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052464	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052465	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052466	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052467	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052468	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052469	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052470	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052471	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052472	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2052473	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052474	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052475	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052476	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052477	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052478	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052479	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052480	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052481	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052482	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052483	05/2015	04/22/2015	99.900	100.100	99.8	1
KU	C1S	2052484	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052485	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052486	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052487	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052488	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052489	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052490	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052491	05/2015	04/23/2015	100.000	100.000	99.8	1
KU	C1S	2052492	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052493	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052494	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052495	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052496	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052497	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052498	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052499	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052500	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052501	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052502	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052503	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052504	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052505	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052506	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052507	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052508	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2052509	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052510	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052511	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052512	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052513	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052514	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2052515	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052516	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052517	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052518	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052519	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052520	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052521	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052522	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052523	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052524	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052525	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052526	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052527	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052528	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052529	05/2015	04/22/2015	100.000	100.100	100.1	1

KU	C1S	2052530	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052531	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052532	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052533	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052534	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052535	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052536	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052537	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052538	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052539	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052540	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052541	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052542	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052543	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052544	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052545	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052546	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052547	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052548	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052549	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052550	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052551	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052552	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052553	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052554	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052555	05/2015	04/21/2015	-100.000	100.100	100.1	1
KU	C1S	2052556	05/2015	04/21/2015	99.900	100.000	100.0	1
KU	C1S	2052557	05/2015	04/21/2015	99.900	100.100	100.0	1
KU	C1S	2052558	05/2015	04/21/2015	99.900	100.100	100.1	1
KU	C1S	2052559	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2052560	05/2015	04/22/2015	100.000	100.200	99.9	1
KU	C1S	2052561	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052562	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052563	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052564	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052565	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052566	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052567	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052568	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052569	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052570	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052571	05/2015	04/22/2015	100.000	100.200	100.1	1

KU	C1S	2052572	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052573	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052574	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052575	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052576	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052577	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052578	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052579	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052580	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052581	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052582	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052583	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052584	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052585	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052586	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052587	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052588	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052589	05/2015	04/21/2015	99.900	100.100	100.1	1
KU	C1S	2052590	05/2015	04/21/2015	100.000	100.200	100.0	1
KU	C1S	2052591	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052592	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052593	05/2015	04/21/2015	100.000	100.000	100.1	1
KU	C1S	2052594	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052595	05/2015	04/21/2015	100.000	100.200	100.0	1
KU	C1S	2052596	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052597	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052598	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052599	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052600	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052601	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052602	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052603	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052604	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052605	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052606	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052607	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052608	05/2015	04/21/2015	100.000	100.100	100.0	1
KU	C1S	2052609	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052610	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052611	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052612	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052613	05/2015	04/22/2015	100.000	100.100	100.0	1

KU	C1S	2052614	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052615	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052616	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052617	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052618	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052619	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052620	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052621	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052622	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052623	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052624	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052625	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052626	05/2015	04/21/2015	99.900	100.100	100.0	1
KU	C1S	2052627	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052628	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052629	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052630	05/2015	04/21/2015	100.000	100.100	100.1	1
KU	C1S	2052631	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052632	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052633	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052634	05/2015	04/22/2015	100.000	100.200	100.2	1
KU	C1S	2052635	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052636	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052637	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052638	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052639	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052640	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052641	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052642	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052643	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052644	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052645	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052646	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052647	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052648	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2052649	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052650	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052651	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052652	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052653	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052654	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052655	05/2015	04/22/2015	100.000	100.200	100.2	1

KU	C1S	2052698	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052699	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052700	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052701	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052702	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052703	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052704	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052705	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052706	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052707	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052708	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052709	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052710	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052711	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052712	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052713	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052714	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052715	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052716	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052717	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052718	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052719	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052720	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052721	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052722	05/2015	04/22/2015	99.900	100.100	100.1	1
KU	C1S	2052723	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052724	05/2015	04/23/2015	100.000	99.900	100.0	1
KU	C1S	2052725	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052726	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052727	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052728	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052729	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052730	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052731	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052732	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052733	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052734	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052735	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052736	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052737	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052738	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052739	05/2015	04/23/2015	100.000	100.100	100.0	1

KU	C1S	2052740	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052741	05/2015	04/23/2015	100.000	99.900	100.0	1
KU	C1S	2052742	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052743	05/2015	04/23/2015	99.900	100.200	100.0	1
KU	C1S	2052744	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052745	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052746	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052747	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052748	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052749	05/2015	04/22/2015	99.900	100.100	100.0	1
KU	C1S	2052750	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052751	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052752	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052753	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052754	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052755	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052756	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052757	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052758	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052759	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052760	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052761	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052762	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052763	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052764	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052765	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052766	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052767	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052768	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052769	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052770	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052771	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052772	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052773	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052774	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2052775	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052776	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052777	05/2015	04/23/2015	100.000	100.000	99.9	1
KU	C1S	2052778	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052779	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052780	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052781	05/2015	04/23/2015	100.000	100.200	100.1	1

KU	C1S	2052782	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052783	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052784	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052785	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052786	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052787	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052788	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052789	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052790	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052791	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052792	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052793	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2052794	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052795	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052796	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2052797	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2052798	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052799	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2052800	05/2015	04/21/2015	100.000	100.200	100.1	1
KU	C1S	2052801	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052802	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052803	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052804	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052805	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052806	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052807	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052808	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052809	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052810	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052811	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052812	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052813	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052814	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052815	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052816	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052817	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052818	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052819	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052820	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052821	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052822	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2052823	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052824	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052825	05/2015	04/23/2015	100.000	100.100	100.2	1
KU	C1S	2052826	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052827	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052828	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052829	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052830	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052831	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052832	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052833	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052834	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052835	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052836	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052837	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052838	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052839	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052840	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052841	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052842	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052843	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052844	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052845	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052846	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052847	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052848	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052849	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052850	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052851	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052852	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052853	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052854	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052855	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052856	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052857	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052858	05/2015	04/23/2015	100.000	100.000	99.8	1
KU	C1S	2052859	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052860	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052861	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052862	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052863	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052864	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052865	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052866	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052867	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052868	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052869	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052870	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052871	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052872	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052873	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052874	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052875	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052876	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052877	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052878	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052879	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052880	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052881	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052882	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052883	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052884	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052885	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052886	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052887	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052888	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052889	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052890	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052891	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052892	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052893	05/2015	04/23/2015	100.000	100.100	99.8	1
KU	C1S	2052894	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052895	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052896	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052897	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052898	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052899	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052900	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052901	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052902	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052903	05/2015	04/23/2015	100.000	100.200	99.9	1
KU	C1S	2052904	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052905	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052906	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052907	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2052908	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052909	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052910	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052911	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052912	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052913	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052914	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052915	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052916	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052917	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052918	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052919	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052920	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052921	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052922	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052923	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052924	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052925	05/2015	04/23/2015	99.900	100.200	100.1	1
KU	C1S	2052926	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2052927	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052928	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052929	05/2015	04/23/2015	100.000	100.100	99.8	1
KU	C1S	2052930	05/2015	04/23/2015	99.900	100.000	100.0	1
KU	C1S	2052931	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052932	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052933	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052934	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052935	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052936	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052937	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052938	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052939	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052940	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052941	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052942	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052943	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052944	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052945	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052946	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052947	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052948	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2052949	05/2015	04/23/2015	100.000	100.200	100.0	1

KU	C1S	2052950	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052951	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052952	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052953	05/2015	04/23/2015	100.000	100.000	100.1	1
KU	C1S	2052954	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052955	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052956	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052957	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052958	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052959	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052960	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052961	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052962	05/2015	04/23/2015	100.000	100.100	100.2	1
KU	C1S	2052963	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052964	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052965	05/2015	04/23/2015	100.000	100.000	99.9	1
KU	C1S	2052966	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052967	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052968	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052969	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052970	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052971	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052972	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052973	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052974	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052975	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052976	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052977	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052978	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052979	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052980	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052981	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052982	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2052983	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052984	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052985	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052986	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2052987	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052988	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2052989	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2052990	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2052991	05/2015	04/23/2015	100.000	100.100	100.1	1

KU	C1S	2053034	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053035	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053036	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053037	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053038	05/2015	04/23/2015	100.000	100.000	99.9	1
KU	C1S	2053039	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053040	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053041	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053042	05/2015	04/23/2015	99.900	100.200	100.0	1
KU	C1S	2053043	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053044	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053045	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053046	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053047	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053048	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053049	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053050	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053051	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053052	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053053	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053054	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053055	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053056	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053057	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053058	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053059	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053060	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053061	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053062	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053063	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053064	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053065	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053066	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053067	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053068	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053069	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053070	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053071	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053072	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053073	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053074	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053075	05/2015	04/23/2015	100.000	100.100	100.0	1

KU	C1S	2053076	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053077	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053078	05/2015	04/23/2015	100.000	100.000	100.1	1
KU	C1S	2053079	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053080	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053081	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053082	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053083	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053084	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053085	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053086	05/2015	04/23/2015	99.900	100.100	99.9	1
KU	C1S	2053087	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053088	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053089	05/2015	04/23/2015	100.000	99.900	100.0	1
KU	C1S	2053090	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053091	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053092	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053093	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053094	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053095	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053096	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053097	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053098	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053099	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053100	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053101	05/2015	04/23/2015	100.000	99.900	100.0	1
KU	C1S	2053102	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053103	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053104	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053105	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053106	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053107	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053108	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053109	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053110	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053111	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053112	05/2015	04/23/2015	100.000	100.000	100.1	1
KU	C1S	2053113	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053114	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053115	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053116	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053117	05/2015	04/23/2015	100.000	100.000	100.0	1

KU	C1S	2053118	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053119	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053120	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053121	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053122	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053123	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053124	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053125	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053126	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053127	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053128	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053129	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053130	05/2015	04/23/2015	100.000	100.000	99.9	1
KU	C1S	2053131	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2053132	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053133	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053134	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053135	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2053136	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053137	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053138	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053139	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053140	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053141	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053142	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053143	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053144	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053145	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053146	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053147	05/2015	04/23/2015	100.000	100.000	100.1	1
KU	C1S	2053148	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053149	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053150	05/2015	04/23/2015	99.900	100.200	100.1	1
KU	C1S	2053151	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053152	05/2015	04/23/2015	100.000	100.100	100.2	1
KU	C1S	2053153	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053154	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053155	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053156	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053157	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053158	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053159	05/2015	04/23/2015	100.000	100.100	100.0	1

KU	C1S	2053160	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053161	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053162	05/2015	04/23/2015	100.000	100.200	100.2	1
KU	C1S	2053163	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2053164	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053165	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053166	05/2015	04/23/2015	99.900	100.100	100.1	1
KU	C1S	2053167	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053168	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053169	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053170	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053171	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053172	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053173	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053174	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053175	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053176	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053177	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053178	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053179	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053180	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053181	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053182	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053183	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053184	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053185	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053186	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053187	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053188	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053189	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053190	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053191	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053192	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053193	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2053194	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053195	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053196	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053197	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053198	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053199	05/2015	04/23/2015	100.000	99.900	100.1	1
KU	C1S	2053200	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053201	05/2015	04/23/2015	100.000	100.200	100.1	1

KU	C1S	2053202	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053203	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053204	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053205	05/2015	04/23/2015	100.000	100.100	99.8	1
KU	C1S	2053206	05/2015	04/23/2015	100.000	100.200	99.9	1
KU	C1S	2053207	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053208	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053209	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053210	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053211	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053212	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053213	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053214	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053215	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053216	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053217	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053218	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053219	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053220	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053221	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053222	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053223	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053224	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053225	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053226	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053227	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053228	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053229	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053230	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053231	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053232	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053233	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053234	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053235	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053236	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053237	05/2015	04/23/2015	100.000	100.200	99.9	1
KU	C1S	2053238	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053239	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053240	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053241	05/2015	04/23/2015	100.000	100.100	100.2	1
KU	C1S	2053242	05/2015	04/23/2015	100.000	100.200	99.9	1
KU	C1S	2053243	05/2015	04/23/2015	100.000	100.000	100.1	1

KU	C1S	2053244	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053245	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053246	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053247	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053248	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053249	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053250	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053251	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053252	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053253	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053254	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053255	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053256	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053257	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2053258	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053259	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053260	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053261	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053262	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2053263	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053264	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053265	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053266	05/2015	04/23/2015	100.000	100.100	99.8	1
KU	C1S	2053267	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053268	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053269	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053270	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053271	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053272	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053273	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053274	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053275	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053276	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053277	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053278	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053279	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053280	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053281	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053282	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053283	05/2015	04/22/2015	100.000	100.000	99.9	1
KU	C1S	2053284	05/2015	04/23/2015	99.900	100.100	100.0	1
KU	C1S	2053285	05/2015	04/23/2015	100.000	99.900	100.0	1

KU	C1S	2053286	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053287	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2053288	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053289	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053290	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053291	05/2015	04/22/2015	100.000	100.100	100.1	1
KU	C1S	2053292	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053293	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2053294	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053295	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053296	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053297	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053298	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053299	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053300	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053301	05/2015	04/23/2015	100.000	100.100	99.9	1
KU	C1S	2053302	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053303	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2053304	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053305	05/2015	04/22/2015	100.000	100.000	100.0	1
KU	C1S	2053306	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053307	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053308	05/2015	04/23/2015	100.000	100.200	100.1	1
KU	C1S	2053309	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053310	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053311	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053312	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053313	05/2015	04/24/2015	100.000	100.100	99.9	1
KU	C1S	2053314	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053315	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053316	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053317	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053318	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053319	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053320	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053321	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053322	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053323	05/2015	04/23/2015	100.000	100.000	99.9	1
KU	C1S	2053324	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053325	05/2015	04/24/2015	99.900	100.000	100.1	1
KU	C1S	2053326	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053327	05/2015	04/24/2015	100.000	100.200	100.1	1

KU	C1S	2053328	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2053329	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053330	05/2015	04/22/2015	100.000	100.100	99.9	1
KU	C1S	2053331	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053332	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053333	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053334	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053335	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053336	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053337	05/2015	04/22/2015	100.000	100.200	100.1	1
KU	C1S	2053338	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2053339	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053340	05/2015	04/23/2015	100.000	100.200	100.0	1
KU	C1S	2053341	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053342	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053343	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053344	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053345	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2053346	05/2015	04/23/2015	100.000	100.000	100.0	1
KU	C1S	2053347	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053348	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053349	05/2015	04/24/2015	100.000	100.200	100.1	1
KU	C1S	2053350	05/2015	04/23/2015	100.000	100.100	100.0	1
KU	C1S	2053351	05/2015	04/24/2015	100.000	100.100	100.1	1
KU	C1S	2053352	05/2015	04/22/2015	100.000	100.100	100.0	1
KU	C1S	2053353	05/2015	04/22/2015	100.000	100.200	100.0	1
KU	C1S	2053354	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053355	05/2015	04/24/2015	100.000	100.000	100.0	1
KU	C1S	2053356	05/2015	04/24/2015	100.000	100.200	100.0	1
KU	C1S	2053357	05/2015	04/24/2015	100.000	100.100	100.0	1
KU	C1S	2053358	05/2015	04/24/2015	100.000	100.100	100.2	1
KU	C1S	2053359	05/2015	04/23/2015	100.000	100.100	100.1	1
KU	C1S	2053540	09/2015	09/03/2015	100.000	100.200	100.0	1
KU	C1S	2053541	09/2015	09/03/2015	100.000	100.200	100.1	1
KU	C1S	2053542	09/2015	09/03/2015	100.000	100.200	100.1	1
KU	C1S	2053543	09/2015	09/03/2015	100.000	100.200	100.0	1
KU	C1S	2053544	09/2015	09/03/2015	100.000	100.200	100.1	1
KU	C1S	2053545	09/2015	09/03/2015	100.000	100.100	100.0	1
KU	C1S	2053546	09/2015	09/03/2015	100.000	100.100	100.0	1
KU	C1S	2053547	09/2015	09/03/2015	100.000	100.200	100.0	1
KU	C1S	2053548	09/2015	09/03/2015	100.000	100.200	100.1	1
KU	C1S	2053549	09/2015	09/03/2015	100.000	100.200	100.0	1

KU	C1S	2053632	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053633	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053634	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053635	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053636	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053637	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053638	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053639	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053640	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053641	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053642	08/2015	08/10/2015	100.000	100.100	99.9	1
KU	C1S	2053643	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053644	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053645	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053646	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053647	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053648	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053649	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053650	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053651	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053652	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053653	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053654	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053655	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053656	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053657	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053658	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053659	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053660	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053661	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053662	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053663	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053664	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053665	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053666	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053667	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053668	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053669	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053670	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053671	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053672	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053673	08/2015	08/10/2015	100.000	100.000	100.0	1

KU	C1S	2053674	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053675	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053676	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053677	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053678	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053679	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2053680	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053681	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053682	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053683	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053684	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053685	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053686	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053687	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053688	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053689	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053690	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053691	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053692	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053693	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053694	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053695	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053696	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053697	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053698	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053699	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053700	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053701	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053702	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053703	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053704	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053705	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053706	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053707	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053708	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053709	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053710	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053711	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053712	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053713	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053714	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053715	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2053716	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053717	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053718	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053719	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053720	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053721	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053722	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053723	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053724	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053725	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053726	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053727	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053728	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053729	08/2015	08/10/2015	100.000	100.000	99.9	1
KU	C1S	2053730	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053731	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053732	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053733	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053734	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053735	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053736	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053737	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053738	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053739	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053740	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053741	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053742	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053743	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053744	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053745	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053746	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053747	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053748	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053749	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053750	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053751	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053752	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053753	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053754	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053755	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053756	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053757	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2053800	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053801	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053802	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053803	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053804	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053805	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053806	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053807	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053808	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053809	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053810	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053811	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2053812	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053813	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053814	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053815	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053816	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053817	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053818	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053819	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053820	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053821	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053822	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053823	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053824	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053825	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053826	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053827	08/2015	08/10/2015	100.000	100.100	99.9	1
KU	C1S	2053828	08/2015	08/10/2015	99.900	100.200	100.0	1
KU	C1S	2053829	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053830	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053831	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053832	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053833	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053834	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053835	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053836	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053837	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053838	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053839	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053840	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053841	08/2015	08/10/2015	100.000	100.200	100.0	1

KU	C1S	2053842	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053843	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053844	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053845	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053846	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053847	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053848	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053849	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053850	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053851	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053852	08/2015	08/10/2015	100.000	100.200	100.2	1
KU	C1S	2053853	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053854	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2053855	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053856	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053857	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053858	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053859	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053860	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053861	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053862	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053863	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053864	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053865	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053866	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053867	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053868	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053869	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053870	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053871	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053872	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053873	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053874	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053875	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053876	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053877	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053878	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053879	08/2015	08/10/2015	99.900	100.100	99.9	1
KU	C1S	2053880	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053881	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053882	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053883	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2053884	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053885	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053886	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053887	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053888	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053889	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053890	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053891	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053892	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053893	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053894	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053895	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053896	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2053897	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053898	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053899	08/2015	08/10/2015	100.000	100.100	99.9	1
KU	C1S	2053900	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053901	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053902	08/2015	08/10/2015	99.900	100.000	100.0	1
KU	C1S	2053903	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053904	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053905	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053906	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053907	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053908	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2053909	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053910	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053911	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053912	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053913	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053914	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053915	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053916	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053917	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2053918	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2053919	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053920	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053921	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2053922	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053923	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2053924	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2053925	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2054052	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054053	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054054	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054055	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054056	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054057	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054058	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054059	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054060	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054061	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054062	08/2015	08/10/2015	99.900	100.000	100.0	1
KU	C1S	2054063	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054064	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054065	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2054066	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054067	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054068	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054069	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054070	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054071	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054072	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054073	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054074	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054075	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054076	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2054077	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054078	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054079	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054080	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054081	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054082	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054083	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054084	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054085	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054086	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054087	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054088	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054089	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054090	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054091	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054092	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054093	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2054094	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054095	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054096	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054097	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054098	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054099	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054100	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054101	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054102	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054103	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054104	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054105	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054106	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054107	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054108	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054109	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054110	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054111	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054112	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054113	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054114	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054115	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054116	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054117	08/2015	08/10/2015	100.000	100.100	100.2	1
KU	C1S	2054118	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054119	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054120	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054121	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054122	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054123	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054124	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054125	08/2015	08/10/2015	99.900	100.200	100.1	1
KU	C1S	2054126	08/2015	08/10/2015	100.000	100.100	99.9	1
KU	C1S	2054127	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054128	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054129	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054130	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054131	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054132	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054133	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054134	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054135	08/2015	08/10/2015	100.000	100.200	100.1	1

KU	C1S	2054220	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054221	08/2015	08/10/2015	100.000	100.200	100.2	1
KU	C1S	2054222	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054223	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054224	08/2015	08/07/2015	100.000	100.100	100.0	1
KU	C1S	2054225	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054226	08/2015	08/07/2015	100.000	100.100	100.0	1
KU	C1S	2054227	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054228	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054229	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054230	08/2015	08/10/2015	100.000	100.100	99.9	1
KU	C1S	2054231	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054232	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054233	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054234	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054235	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054236	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054237	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054238	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054239	08/2015	08/10/2015	100.000	100.100	100.2	1
KU	C1S	2054240	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054241	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054242	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054243	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054244	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054245	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054246	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054247	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054248	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054249	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054250	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054251	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054252	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054253	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054254	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054255	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054256	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054257	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054258	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054259	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054260	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054261	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2054388	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054389	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054390	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054391	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054392	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054393	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054394	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054395	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054396	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054397	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054398	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054399	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054400	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054401	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054402	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054403	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054404	08/2015	08/10/2015	100.000	100.200	100.2	1
KU	C1S	2054405	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054406	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054407	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054408	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054409	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054410	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054411	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054412	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054413	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054414	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054415	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054416	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054417	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054418	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054419	08/2015	08/10/2015	100.000	100.100	100.2	1
KU	C1S	2054420	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054421	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054422	08/2015	08/10/2015	99.900	100.100	99.9	1
KU	C1S	2054423	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054424	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054425	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054426	08/2015	08/10/2015	99.900	100.100	100.0	1
KU	C1S	2054427	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054428	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054429	08/2015	08/10/2015	100.000	100.100	100.1	1

KU	C1S	2054430	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054431	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054432	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054433	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054434	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054435	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054436	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054437	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054438	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054439	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054440	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054441	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054442	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054443	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054444	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054445	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054446	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054447	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054448	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054449	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054450	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054451	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054452	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054453	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054454	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054455	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054456	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054457	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054458	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054459	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054460	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054461	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054462	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054463	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054464	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054465	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054466	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054467	08/2015	08/10/2015	100.000	100.000	100.1	1
KU	C1S	2054468	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054469	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054470	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054471	08/2015	08/10/2015	100.000	100.100	100.0	1

KU	C1S	2054556	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054557	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054558	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054559	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054560	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054561	08/2015	08/10/2015	100.000	100.000	100.0	1
KU	C1S	2054562	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054563	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054564	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054565	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054566	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054567	08/2015	08/10/2015	99.900	100.100	100.1	1
KU	C1S	2054568	08/2015	08/10/2015	100.000	100.100	100.2	1
KU	C1S	2054569	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054570	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054571	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054572	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054573	08/2015	08/10/2015	100.000	100.100	100.2	1
KU	C1S	2054574	08/2015	08/10/2015	100.000	100.200	100.1	1
KU	C1S	2054575	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054576	08/2015	08/10/2015	100.000	100.100	100.0	1
KU	C1S	2054577	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054578	08/2015	08/10/2015	100.000	100.200	100.0	1
KU	C1S	2054579	08/2015	08/10/2015	100.000	100.100	100.1	1
KU	C1S	2054700	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2054701	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2054702	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2054703	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2054704	10/2015	10/09/2015	100.100	99.910	100.1	1
KU	C1S	2054705	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2054706	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2054707	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2054708	10/2015	10/09/2015	100.060	99.950	99.9	1
KU	C1S	2054709	10/2015	10/09/2015	100.080	99.850	100.1	1
KU	C1S	2054710	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2054711	10/2015	10/09/2015	100.090	99.880	100.1	1
KU	C1S	2054712	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054713	10/2015	10/09/2015	100.060	99.820	99.9	1
KU	C1S	2054714	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2054715	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2054716	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2054717	10/2015	10/09/2015	100.100	99.860	100.1	1

KU	C1S	2054718	10/2015	10/09/2015	100.050	99.910	99.9	1
KU	C1S	2054719	10/2015	10/09/2015	100.100	100.000	100.1	1
KU	C1S	2054720	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2054721	10/2015	10/09/2015	100.090	100.000	100.0	1
KU	C1S	2054722	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2054723	10/2015	10/09/2015	100.070	99.840	99.9	1
KU	C1S	2054724	10/2015	10/09/2015	100.090	99.940	100.1	1
KU	C1S	2054725	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054726	10/2015	10/09/2015	100.050	99.870	100.0	1
KU	C1S	2054727	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2054728	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054729	10/2015	10/09/2015	100.090	100.000	100.0	1
KU	C1S	2054730	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2054731	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2054732	10/2015	10/09/2015	100.050	99.900	99.9	1
KU	C1S	2054733	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2054734	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2054735	10/2015	10/09/2015	100.100	100.030	100.1	1
KU	C1S	2054736	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2054737	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054738	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2054739	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2054740	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2054741	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2054742	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054743	10/2015	10/09/2015	100.090	99.840	100.0	1
KU	C1S	2054744	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2054745	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2054746	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2054747	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2054748	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2054749	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054750	10/2015	10/09/2015	100.080	99.900	100.1	1
KU	C1S	2054751	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054752	10/2015	10/09/2015	100.070	99.890	99.9	1
KU	C1S	2054753	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2054754	10/2015	10/09/2015	100.090	99.920	99.9	1
KU	C1S	2054755	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054756	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2054757	10/2015	10/09/2015	100.080	99.990	100.1	1
KU	C1S	2054758	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2054759	10/2015	10/09/2015	100.080	99.900	100.1	1

KU	C1S	2054760	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2054761	10/2015	10/09/2015	100.070	99.830	99.9	1
KU	C1S	2054762	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2054763	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054764	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2054765	10/2015	10/09/2015	100.080	99.920	100.1	1
KU	C1S	2054766	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054767	10/2015	10/09/2015	100.100	99.830	100.0	1
KU	C1S	2054768	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2054769	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2054770	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2054771	10/2015	10/09/2015	100.070	99.860	100.1	1
KU	C1S	2054772	10/2015	10/09/2015	100.100	99.970	100.1	1
KU	C1S	2054773	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2054774	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054775	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2054776	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054777	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2054778	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2054779	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2054780	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2054781	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2054782	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2054783	10/2015	10/09/2015	100.090	99.900	100.1	1
KU	C1S	2054784	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2054785	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2054786	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2054787	10/2015	10/09/2015	100.090	99.990	100.1	1
KU	C1S	2054788	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2054789	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2054790	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2054791	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2054792	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2054793	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2054794	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2054795	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2054796	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2054797	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054798	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2054799	10/2015	10/09/2015	100.100	99.870	99.9	1
KU	C1S	2054800	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2054801	10/2015	10/09/2015	100.060	99.890	100.0	1

KU	C1S	2054802	10/2015	10/09/2015	100.060	99.810	100.1	1
KU	C1S	2054803	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2054804	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2054805	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2054806	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054807	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054808	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2054809	10/2015	10/09/2015	100.080	99.860	99.9	1
KU	C1S	2054810	10/2015	10/09/2015	100.090	99.960	100.1	1
KU	C1S	2054811	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2054812	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054813	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2054814	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2054815	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2054816	10/2015	10/09/2015	100.050	99.890	100.0	1
KU	C1S	2054817	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2054818	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2054819	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2054820	10/2015	10/09/2015	100.090	99.960	100.1	1
KU	C1S	2054821	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2054822	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2054823	10/2015	10/09/2015	100.100	99.820	100.1	1
KU	C1S	2054824	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054825	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054826	10/2015	10/09/2015	100.050	99.910	99.9	1
KU	C1S	2054827	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054828	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2054829	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2054830	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2054831	10/2015	10/09/2015	100.110	99.900	100.1	1
KU	C1S	2054832	10/2015	10/09/2015	100.100	99.910	100.1	1
KU	C1S	2054833	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2054834	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2054835	10/2015	10/09/2015	100.080	100.020	100.0	1
KU	C1S	2054836	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054837	10/2015	10/09/2015	100.050	99.920	100.0	1
KU	C1S	2054838	10/2015	10/09/2015	100.090	99.840	100.0	1
KU	C1S	2054839	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054840	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2054841	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2054842	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2054843	10/2015	10/09/2015	100.060	99.890	100.0	1

KU	C1S	2054844	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2054845	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2054846	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2054847	10/2015	10/09/2015	100.050	99.950	100.0	1
KU	C1S	2054848	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2054849	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2054850	10/2015	10/09/2015	100.070	99.930	100.1	1
KU	C1S	2054851	10/2015	10/09/2015	100.100	99.900	100.1	1
KU	C1S	2054852	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2054853	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2054854	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2054855	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2054856	10/2015	10/09/2015	100.070	99.960	99.9	1
KU	C1S	2054857	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2054858	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2054859	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2054860	10/2015	10/09/2015	100.090	100.000	100.0	1
KU	C1S	2054861	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2054862	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2054863	10/2015	10/09/2015	100.090	99.930	99.9	1
KU	C1S	2054864	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054865	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2054866	10/2015	10/09/2015	100.090	99.980	100.1	1
KU	C1S	2054867	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2054868	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2054869	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2054870	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2054871	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2054872	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2054873	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2054874	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2054875	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2054876	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2054877	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2054878	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2054879	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054880	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2054881	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2054882	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2054883	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2054884	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2054885	10/2015	10/09/2015	100.050	99.830	99.9	1

KU	C1S	2054886	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2054887	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2054888	10/2015	10/09/2015	100.080	99.940	99.9	1
KU	C1S	2054889	10/2015	10/09/2015	100.080	99.820	100.0	1
KU	C1S	2054890	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2054891	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2054892	10/2015	10/09/2015	100.060	99.890	99.9	1
KU	C1S	2054893	10/2015	10/09/2015	100.090	99.930	100.1	1
KU	C1S	2054894	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054895	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2054896	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2054897	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2054898	10/2015	10/09/2015	100.060	99.990	100.0	1
KU	C1S	2054899	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2054900	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2054901	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2054902	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2054903	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2054904	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054905	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2054906	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2054907	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2054908	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2054909	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2054910	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2054911	10/2015	10/09/2015	100.070	99.950	100.1	1
KU	C1S	2054912	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2054913	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2054914	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2054915	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2054916	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2054917	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2054918	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054919	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054920	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2054921	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2054922	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054923	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2054924	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2054925	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2054926	10/2015	10/09/2015	100.070	99.900	100.1	1
KU	C1S	2054927	10/2015	10/09/2015	100.070	99.830	99.9	1

KU	C1S	2054928	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2054929	10/2015	10/09/2015	100.090	99.950	99.9	1
KU	C1S	2054930	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2054931	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2054932	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2054933	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2054934	10/2015	10/09/2015	100.100	100.050	100.0	1
KU	C1S	2054935	10/2015	10/09/2015	100.060	99.900	100.1	1
KU	C1S	2054936	10/2015	10/09/2015	100.110	99.940	100.0	1
KU	C1S	2054937	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2054938	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2054939	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2054940	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2054941	10/2015	10/09/2015	100.100	99.980	100.1	1
KU	C1S	2054942	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2054943	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2054944	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2054945	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2054946	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2054947	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2054948	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2054949	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2054950	10/2015	10/09/2015	100.080	99.930	100.1	1
KU	C1S	2054951	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2054952	10/2015	10/09/2015	100.100	99.850	100.1	1
KU	C1S	2054953	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2054954	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2054955	10/2015	10/09/2015	100.090	99.910	100.1	1
KU	C1S	2054956	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2054957	10/2015	10/09/2015	100.110	99.980	100.0	1
KU	C1S	2054958	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2054959	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2054960	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2054961	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2054962	10/2015	10/09/2015	100.100	99.880	99.9	1
KU	C1S	2054963	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2054964	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2054965	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2054966	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2054967	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2054968	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2054969	10/2015	10/09/2015	100.050	99.910	100.0	1

KU	C1S	2054970	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2054971	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2054972	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2054973	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2054974	10/2015	10/09/2015	100.100	99.870	99.9	1
KU	C1S	2054975	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2054976	10/2015	10/09/2015	100.100	99.960	100.1	1
KU	C1S	2054977	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2054978	10/2015	10/09/2015	100.110	99.950	100.0	1
KU	C1S	2054979	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2054980	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2054981	10/2015	10/09/2015	100.050	99.810	100.0	1
KU	C1S	2054982	10/2015	10/09/2015	100.080	99.970	100.1	1
KU	C1S	2054983	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2054984	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2054985	10/2015	10/09/2015	100.090	99.840	100.1	1
KU	C1S	2054986	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2054987	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2054988	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2054989	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2054990	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2054991	10/2015	10/09/2015	100.050	99.800	99.9	1
KU	C1S	2054992	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2054993	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2054994	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2054995	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2054996	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2054997	10/2015	10/09/2015	100.080	99.860	99.9	1
KU	C1S	2054998	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2054999	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055000	10/2015	10/09/2015	100.060	99.950	99.9	1
KU	C1S	2055001	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055002	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055003	10/2015	10/09/2015	100.080	99.870	99.9	1
KU	C1S	2055004	10/2015	10/09/2015	100.060	99.960	99.9	1
KU	C1S	2055005	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2055006	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2055007	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2055008	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055009	10/2015	10/09/2015	100.050	99.930	99.9	1
KU	C1S	2055010	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055011	10/2015	10/09/2015	100.080	99.870	100.0	1

KU	C1S	2055012	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055013	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055014	10/2015	10/09/2015	100.090	99.830	100.0	1
KU	C1S	2055015	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055016	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055017	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055018	10/2015	10/09/2015	100.050	99.910	100.0	1
KU	C1S	2055019	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2055020	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055021	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055022	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055023	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2055024	10/2015	10/09/2015	100.080	100.000	100.0	1
KU	C1S	2055025	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055026	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2055027	10/2015	10/09/2015	100.080	99.980	99.9	1
KU	C1S	2055028	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055029	10/2015	10/09/2015	100.100	99.990	100.1	1
KU	C1S	2055030	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055031	10/2015	10/09/2015	100.060	99.930	99.9	1
KU	C1S	2055032	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055033	10/2015	10/09/2015	100.070	99.810	100.0	1
KU	C1S	2055034	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055035	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055036	10/2015	10/09/2015	100.100	99.950	99.9	1
KU	C1S	2055037	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055038	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055039	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2055040	10/2015	10/09/2015	100.060	99.980	100.0	1
KU	C1S	2055041	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055042	10/2015	10/09/2015	100.050	99.980	100.0	1
KU	C1S	2055043	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055044	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055045	10/2015	10/09/2015	100.060	99.990	100.0	1
KU	C1S	2055046	10/2015	10/09/2015	100.090	99.880	99.9	1
KU	C1S	2055047	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055048	10/2015	10/09/2015	100.090	100.000	100.0	1
KU	C1S	2055049	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055050	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055051	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055052	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055053	10/2015	10/09/2015	100.060	99.980	100.0	1

KU	C1S	2055054	10/2015	10/09/2015	100.080	99.940	99.9	1
KU	C1S	2055055	10/2015	10/09/2015	100.060	99.930	99.9	1
KU	C1S	2055056	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055057	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055058	10/2015	10/09/2015	100.050	99.860	99.9	1
KU	C1S	2055059	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055060	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055061	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055062	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055063	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055064	10/2015	10/09/2015	100.060	99.980	100.0	1
KU	C1S	2055065	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055066	10/2015	10/09/2015	100.050	99.840	99.9	1
KU	C1S	2055067	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055068	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2055069	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055070	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055071	10/2015	10/09/2015	100.100	99.980	100.1	1
KU	C1S	2055072	10/2015	10/09/2015	100.080	99.980	100.1	1
KU	C1S	2055073	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2055074	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055075	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055076	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055077	10/2015	10/09/2015	100.080	100.020	100.0	1
KU	C1S	2055078	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055079	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2055080	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055081	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055082	10/2015	10/09/2015	100.050	99.920	99.9	1
KU	C1S	2055083	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055084	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055085	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055086	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055087	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055088	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2055089	10/2015	10/09/2015	100.080	99.880	99.9	1
KU	C1S	2055090	10/2015	10/09/2015	100.090	99.830	100.0	1
KU	C1S	2055091	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055092	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055093	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055094	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055095	10/2015	10/09/2015	100.070	99.870	100.1	1

KU	C1S	2055096	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055097	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2055098	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2055099	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055100	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055101	10/2015	10/09/2015	100.090	99.900	99.9	1
KU	C1S	2055102	10/2015	10/09/2015	100.060	99.960	99.9	1
KU	C1S	2055103	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055104	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2055105	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055106	10/2015	10/09/2015	100.090	99.880	100.1	1
KU	C1S	2055107	10/2015	10/09/2015	100.070	99.830	99.9	1
KU	C1S	2055108	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055109	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055110	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055111	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055112	10/2015	10/09/2015	100.090	99.950	99.9	1
KU	C1S	2055113	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2055114	10/2015	10/09/2015	100.110	99.900	100.0	1
KU	C1S	2055115	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2055116	10/2015	10/09/2015	100.090	100.030	100.0	-1
KU	C1S	2055117	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055118	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055119	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055120	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055121	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055122	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055123	10/2015	10/09/2015	100.060	99.930	99.9	1
KU	C1S	2055124	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055125	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055126	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055127	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055128	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2055129	10/2015	10/09/2015	100.090	99.840	100.0	1
KU	C1S	2055130	10/2015	10/09/2015	100.080	99.960	99.9	1
KU	C1S	2055131	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055132	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055133	10/2015	10/09/2015	100.090	99.960	100.1	1
KU	C1S	2055134	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055135	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055136	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055137	10/2015	10/09/2015	100.060	99.880	99.9	1

KU	C1S	2055138	10/2015	10/09/2015	100.090	99.940	99.9	1
KU	C1S	2055139	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055140	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2055141	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055142	10/2015	10/09/2015	100.070	99.850	99.9	1
KU	C1S	2055143	10/2015	10/09/2015	100.070	99.850	99.9	1
KU	C1S	2055144	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055145	10/2015	10/09/2015	100.090	99.930	100.1	1
KU	C1S	2055146	10/2015	10/09/2015	100.060	99.980	99.9	1
KU	C1S	2055147	10/2015	10/09/2015	100.070	99.960	100.1	1
KU	C1S	2055148	10/2015	10/09/2015	100.100	99.970	100.1	1
KU	C1S	2055149	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055150	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055151	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055152	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2055153	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055154	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055155	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055156	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055157	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055158	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055159	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055160	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055161	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055162	10/2015	10/09/2015	100.090	99.910	100.1	1
KU	C1S	2055163	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055164	10/2015	10/09/2015	100.060	99.970	100.0	1
KU	C1S	2055165	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2055166	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055167	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2055168	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055169	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2055170	10/2015	10/09/2015	100.080	99.900	99.9	1
KU	C1S	2055171	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055172	10/2015	10/09/2015	100.100	99.960	100.1	1
KU	C1S	2055173	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055174	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2055175	10/2015	10/09/2015	100.070	99.950	99.9	1
KU	C1S	2055176	10/2015	10/09/2015	100.050	99.940	100.0	1
KU	C1S	2055177	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055178	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055179	10/2015	10/09/2015	100.070	99.850	100.0	1

KU	C1S	2055180	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055181	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2055182	10/2015	10/09/2015	100.100	100.010	100.1	1
KU	C1S	2055183	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055184	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055185	10/2015	10/09/2015	100.060	100.020	100.0	1
KU	C1S	2055186	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055187	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055188	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055189	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055190	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055191	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055192	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055193	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055194	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2055195	10/2015	10/09/2015	100.070	99.890	99.9	1
KU	C1S	2055196	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055197	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055198	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2055199	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055200	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055201	10/2015	10/09/2015	100.080	99.960	99.9	1
KU	C1S	2055202	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055203	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055204	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2055205	10/2015	10/09/2015	100.090	99.950	100.1	1
KU	C1S	2055206	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055207	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2055208	10/2015	10/09/2015	100.090	99.880	99.9	1
KU	C1S	2055209	10/2015	10/09/2015	100.070	99.990	100.0	1
KU	C1S	2055210	10/2015	10/09/2015	100.050	99.890	100.0	1
KU	C1S	2055211	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055212	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055213	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055214	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2055215	10/2015	10/09/2015	100.050	99.870	100.0	1
KU	C1S	2055216	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055217	10/2015	10/09/2015	100.090	99.960	100.1	1
KU	C1S	2055218	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055219	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055220	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055221	10/2015	10/09/2015	100.090	99.990	100.0	1

KU	C1S	2055222	10/2015	10/09/2015	100.070	99.830	100.0	1
KU	C1S	2055223	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055224	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055225	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055226	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055227	10/2015	10/09/2015	100.070	99.890	99.9	1
KU	C1S	2055228	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055229	10/2015	10/09/2015	100.100	99.900	100.1	1
KU	C1S	2055230	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055231	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055232	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055233	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055234	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055235	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055236	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055237	10/2015	10/09/2015	100.080	99.920	100.1	1
KU	C1S	2055238	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2055239	10/2015	10/09/2015	100.090	99.810	100.0	1
KU	C1S	2055240	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055241	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055242	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055243	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055244	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055245	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055246	10/2015	10/09/2015	100.100	99.810	100.0	1
KU	C1S	2055247	10/2015	10/09/2015	100.080	99.890	99.9	1
KU	C1S	2055248	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055249	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055250	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055251	10/2015	10/09/2015	100.090	99.960	100.1	1
KU	C1S	2055252	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2055253	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055254	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2055255	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2055256	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055257	10/2015	10/09/2015	100.080	99.830	99.9	1
KU	C1S	2055258	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055259	10/2015	10/09/2015	100.090	99.980	100.1	1
KU	C1S	2055260	10/2015	10/09/2015	100.100	99.820	100.0	1
KU	C1S	2055261	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055262	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2055263	10/2015	10/09/2015	100.080	99.870	100.0	1

KU	C1S	2055264	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055265	10/2015	10/09/2015	100.090	99.970	100.1	1
KU	C1S	2055266	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055267	10/2015	10/09/2015	100.050	99.870	99.9	1
KU	C1S	2055268	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2055269	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055270	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2055271	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055272	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055273	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055274	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055275	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055276	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055277	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2055278	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055279	10/2015	10/09/2015	100.080	99.950	100.1	1
KU	C1S	2055280	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2055281	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055282	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055283	10/2015	10/09/2015	100.050	99.840	99.9	1
KU	C1S	2055284	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055285	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055286	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055287	10/2015	10/09/2015	100.070	99.960	100.1	1
KU	C1S	2055288	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2055289	10/2015	10/09/2015	100.090	99.860	99.9	1
KU	C1S	2055290	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055291	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2055292	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055293	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055294	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055295	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055296	10/2015	10/09/2015	100.050	99.910	100.0	1
KU	C1S	2055297	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055298	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2055299	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055300	10/2015	10/09/2015	100.070	99.830	100.0	1
KU	C1S	2055301	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055302	10/2015	10/09/2015	100.050	99.870	99.9	1
KU	C1S	2055303	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2055304	10/2015	10/09/2015	100.100	100.000	100.1	1
KU	C1S	2055305	10/2015	10/09/2015	100.080	99.930	100.0	1

KU	C1S	2055306	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055307	10/2015	10/09/2015	100.110	99.890	100.1	1
KU	C1S	2055308	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055309	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055310	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2055311	10/2015	10/09/2015	100.090	99.980	100.1	1
KU	C1S	2055312	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055313	10/2015	10/09/2015	100.080	99.950	99.9	1
KU	C1S	2055314	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055315	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055316	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055317	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055318	10/2015	10/09/2015	100.100	99.980	100.1	1
KU	C1S	2055319	10/2015	10/09/2015	100.080	99.900	99.9	1
KU	C1S	2055320	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2055321	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2055322	10/2015	10/09/2015	100.050	99.940	100.0	1
KU	C1S	2055323	10/2015	10/09/2015	100.080	99.980	99.9	1
KU	C1S	2055324	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055325	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055326	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2055327	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055328	10/2015	10/09/2015	100.050	99.920	100.0	1
KU	C1S	2055329	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055330	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055331	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055332	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055333	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055334	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055335	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2055336	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055337	10/2015	10/09/2015	100.100	99.870	99.9	1
KU	C1S	2055338	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055339	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055340	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2055341	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055342	10/2015	10/09/2015	100.080	100.010	100.0	1
KU	C1S	2055343	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055344	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055345	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055346	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055347	10/2015	10/09/2015	100.100	99.970	100.0	1

KU	C1S	2055348	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055349	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055350	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055351	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055352	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2055353	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055354	10/2015	10/09/2015	100.080	99.910	99.9	1
KU	C1S	2055355	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055356	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055357	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055358	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055359	10/2015	10/09/2015	100.100	99.910	100.1	1
KU	C1S	2055360	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055361	10/2015	10/09/2015	100.050	99.950	100.0	1
KU	C1S	2055362	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2055363	10/2015	10/09/2015	100.080	99.930	100.1	1
KU	C1S	2055364	10/2015	10/09/2015	100.100	99.970	100.1	1
KU	C1S	2055365	10/2015	10/09/2015	100.100	99.930	100.1	1
KU	C1S	2055366	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055367	10/2015	10/09/2015	100.050	100.000	100.0	1
KU	C1S	2055368	10/2015	10/09/2015	100.060	99.900	100.1	1
KU	C1S	2055369	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055370	10/2015	10/09/2015	100.070	99.830	99.9	1
KU	C1S	2055371	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055372	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055373	10/2015	10/09/2015	100.090	99.920	99.9	1
KU	C1S	2055374	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055375	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055376	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055377	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055378	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2055379	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055380	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055381	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2055382	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055383	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055384	10/2015	10/09/2015	100.080	100.010	100.0	1
KU	C1S	2055385	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055386	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055387	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055388	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2055389	10/2015	10/09/2015	100.080	99.910	99.9	1

KU	C1S	2055390	10/2015	10/09/2015	100.050	99.830	100.0	1
KU	C1S	2055391	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055392	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055393	10/2015	10/09/2015	100.060	99.980	100.0	1
KU	C1S	2055394	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055395	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055396	10/2015	10/09/2015	100.080	100.020	100.0	1
KU	C1S	2055397	10/2015	10/09/2015	100.050	99.820	99.9	1
KU	C1S	2055398	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055399	10/2015	10/09/2015	100.100	99.850	100.0	1
KU	C1S	2055400	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2055401	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055402	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055403	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055404	10/2015	10/09/2015	100.070	100.010	100.0	1
KU	C1S	2055405	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2055406	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055407	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2055408	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055409	10/2015	10/09/2015	100.100	99.990	100.1	1
KU	C1S	2055410	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055411	10/2015	10/09/2015	100.050	99.860	100.0	1
KU	C1S	2055412	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055413	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055414	10/2015	10/09/2015	100.070	100.000	100.1	1
KU	C1S	2055415	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055416	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055417	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055418	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055419	10/2015	10/09/2015	100.090	100.010	99.9	1
KU	C1S	2055420	10/2015	10/09/2015	100.090	99.910	99.9	1
KU	C1S	2055421	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055422	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055423	10/2015	10/09/2015	100.070	99.820	100.0	1
KU	C1S	2055424	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055425	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055426	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055427	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055428	10/2015	10/09/2015	100.060	99.980	99.9	1
KU	C1S	2055429	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055430	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055431	10/2015	10/09/2015	100.080	99.950	100.0	1

KU	C1S	2055432	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2055433	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055434	10/2015	10/09/2015	100.100	99.840	100.0	1
KU	C1S	2055435	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055436	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055437	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055438	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055439	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2055440	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055441	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055442	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2055443	10/2015	10/09/2015	100.060	99.990	99.9	1
KU	C1S	2055444	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055445	10/2015	10/09/2015	100.090	99.870	100.0	1
KU	C1S	2055446	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2055447	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055448	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055449	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2055450	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055451	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055452	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2055453	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055454	10/2015	10/09/2015	100.080	99.850	100.1	1
KU	C1S	2055455	10/2015	10/09/2015	100.080	99.830	99.9	1
KU	C1S	2055456	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055457	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055458	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055459	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055460	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055461	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055462	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055463	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055464	10/2015	10/09/2015	100.100	99.840	100.0	1
KU	C1S	2055465	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055466	10/2015	10/09/2015	100.060	99.890	99.9	1
KU	C1S	2055467	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2055468	10/2015	10/09/2015	100.070	99.920	100.1	1
KU	C1S	2055469	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055470	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055471	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055472	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055473	10/2015	10/09/2015	100.080	99.920	100.0	1

KU	C1S	2055474	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2055475	10/2015	10/09/2015	100.080	99.930	100.1	1
KU	C1S	2055476	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055477	10/2015	10/09/2015	100.070	99.830	100.1	1
KU	C1S	2055478	10/2015	10/09/2015	100.100	100.040	100.0	1
KU	C1S	2055479	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055480	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055481	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055482	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2055483	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055484	10/2015	10/09/2015	100.070	99.990	100.0	1
KU	C1S	2055485	10/2015	10/09/2015	100.060	99.810	99.9	1
KU	C1S	2055486	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055487	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055488	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055489	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055490	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055491	10/2015	10/09/2015	100.100	99.900	100.1	1
KU	C1S	2055492	10/2015	10/09/2015	100.070	99.910	99.9	1
KU	C1S	2055493	10/2015	10/09/2015	100.080	99.860	100.1	1
KU	C1S	2055494	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055495	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055496	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2055497	10/2015	10/09/2015	100.080	99.880	99.9	1
KU	C1S	2055498	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055499	10/2015	10/09/2015	100.070	99.940	99.9	1
KU	C1S	2055500	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055501	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055502	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055503	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055504	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2055505	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055506	10/2015	10/09/2015	100.100	99.890	100.1	1
KU	C1S	2055507	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055508	10/2015	10/09/2015	100.050	99.920	99.9	1
KU	C1S	2055509	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055510	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055511	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055512	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055513	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2055514	10/2015	10/09/2015	100.100	99.810	100.0	1
KU	C1S	2055515	10/2015	10/09/2015	100.100	99.990	100.0	1

KU	C1S	2055516	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055517	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2055518	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055519	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2055520	10/2015	10/09/2015	100.080	99.820	100.0	1
KU	C1S	2055521	10/2015	10/09/2015	100.050	99.810	99.9	1
KU	C1S	2055522	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055523	10/2015	10/09/2015	100.080	99.820	100.0	1
KU	C1S	2055524	10/2015	10/09/2015	100.100	99.930	99.9	1
KU	C1S	2055525	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055526	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055527	10/2015	10/09/2015	100.080	99.890	100.1	1
KU	C1S	2055528	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055529	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055530	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2055531	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055532	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055533	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055534	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055535	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055536	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055537	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055538	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055539	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055540	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055541	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2055542	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055543	10/2015	10/09/2015	100.070	99.940	100.1	1
KU	C1S	2055544	10/2015	10/09/2015	100.050	99.910	100.0	1
KU	C1S	2055545	10/2015	10/09/2015	100.080	99.960	100.1	1
KU	C1S	2055546	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055547	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055548	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2055549	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055550	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2055551	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055552	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055553	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055554	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2055555	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055556	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055557	10/2015	10/09/2015	100.050	99.880	100.0	1

KU	C1S	2055558	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055559	10/2015	10/09/2015	100.090	99.990	100.1	1
KU	C1S	2055560	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055561	10/2015	10/09/2015	100.100	100.050	100.0	1
KU	C1S	2055562	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055563	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2055564	10/2015	10/09/2015	100.100	99.970	100.1	1
KU	C1S	2055565	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055566	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2055567	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055568	10/2015	10/09/2015	100.100	100.050	100.0	1
KU	C1S	2055569	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055570	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2055571	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2055572	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2055573	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055574	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055575	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2055576	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055577	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055578	10/2015	10/09/2015	100.090	99.920	99.9	1
KU	C1S	2055579	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2055580	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055581	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055582	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055583	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055584	10/2015	10/09/2015	100.070	99.830	100.0	1
KU	C1S	2055585	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055586	10/2015	10/09/2015	100.090	99.860	99.9	1
KU	C1S	2055587	10/2015	10/09/2015	100.080	99.980	99.9	1
KU	C1S	2055588	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055589	10/2015	10/09/2015	100.080	99.880	100.1	1
KU	C1S	2055590	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055591	10/2015	10/09/2015	100.070	99.800	100.0	1
KU	C1S	2055592	10/2015	10/09/2015	100.060	99.890	99.9	1
KU	C1S	2055593	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055594	10/2015	10/09/2015	100.070	99.800	99.9	1
KU	C1S	2055595	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055596	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055597	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2055598	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055599	10/2015	10/09/2015	100.070	99.930	100.0	1

KU	C1S	2055600	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055601	10/2015	10/09/2015	100.070	99.820	100.0	1
KU	C1S	2055602	10/2015	10/09/2015	100.070	99.810	99.9	1
KU	C1S	2055603	10/2015	10/09/2015	100.060	100.000	100.0	1
KU	C1S	2055604	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2055605	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2055606	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2055607	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055608	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055609	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055610	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055611	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055612	10/2015	10/09/2015	100.090	99.830	100.0	1
KU	C1S	2055613	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055614	10/2015	10/09/2015	100.050	99.830	100.0	1
KU	C1S	2055615	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055616	10/2015	10/09/2015	100.060	99.980	100.0	1
KU	C1S	2055617	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2055618	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2055619	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055620	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2055621	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2055622	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055623	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055624	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055625	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055626	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055627	10/2015	10/09/2015	100.090	99.840	100.0	1
KU	C1S	2055628	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055629	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055630	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055631	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055632	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055633	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055634	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055635	10/2015	10/09/2015	100.050	99.830	100.0	1
KU	C1S	2055636	10/2015	10/09/2015	100.100	99.850	100.0	1
KU	C1S	2055637	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2055638	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055639	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055640	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055641	10/2015	10/09/2015	100.070	99.960	99.9	1

KU	C1S	2055642	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055643	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055644	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055645	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055646	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055647	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2055648	10/2015	10/09/2015	100.100	100.040	100.0	1
KU	C1S	2055649	10/2015	10/09/2015	100.090	99.860	100.1	1
KU	C1S	2055650	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055651	10/2015	10/09/2015	100.090	99.890	100.1	1
KU	C1S	2055652	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2055653	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055654	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055655	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055656	10/2015	10/09/2015	100.070	99.830	100.0	1
KU	C1S	2055657	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055658	10/2015	10/09/2015	100.100	99.990	100.1	1
KU	C1S	2055659	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055660	10/2015	10/09/2015	100.070	99.900	100.1	1
KU	C1S	2055661	10/2015	10/09/2015	100.090	99.820	100.0	1
KU	C1S	2055662	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2055663	10/2015	10/09/2015	100.090	99.940	100.1	1
KU	C1S	2055664	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055665	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2055666	10/2015	10/09/2015	100.090	99.800	100.0	1
KU	C1S	2055667	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055668	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055669	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055670	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2055671	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055672	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055673	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055674	10/2015	10/09/2015	100.090	99.870	100.0	1
KU	C1S	2055675	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055676	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055677	10/2015	10/09/2015	100.080	99.910	99.9	1
KU	C1S	2055678	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055679	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055680	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055681	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055682	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055683	10/2015	10/09/2015	100.080	99.840	100.0	1

KU	C1S	2055684	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055685	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055686	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055687	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2055688	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055689	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2055690	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055691	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055692	10/2015	10/09/2015	100.080	100.060	100.0	1
KU	C1S	2055693	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055694	10/2015	10/09/2015	100.090	99.910	99.9	1
KU	C1S	2055695	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055696	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055697	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055698	10/2015	10/09/2015	100.060	100.000	100.0	1
KU	C1S	2055699	10/2015	10/09/2015	100.100	99.900	100.1	1
KU	C1S	2055700	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055701	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055702	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2055703	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055704	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055705	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055706	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055707	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2055708	10/2015	10/09/2015	100.080	100.010	100.1	1
KU	C1S	2055709	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2055710	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055711	10/2015	10/09/2015	100.060	99.960	99.9	1
KU	C1S	2055712	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055713	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055714	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2055715	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055716	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055717	10/2015	10/09/2015	100.100	99.930	100.1	1
KU	C1S	2055718	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2055719	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055720	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2055721	10/2015	10/09/2015	100.090	99.940	99.9	1
KU	C1S	2055722	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055723	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055724	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055725	10/2015	10/09/2015	100.100	99.950	100.1	1

KU	C1S	2055726	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055727	10/2015	10/09/2015	100.080	99.930	100.1	1
KU	C1S	2055728	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055729	10/2015	10/09/2015	100.050	99.940	100.0	1
KU	C1S	2055730	10/2015	10/09/2015	100.080	99.810	99.9	1
KU	C1S	2055731	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055732	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055733	10/2015	10/09/2015	100.080	99.940	99.9	1
KU	C1S	2055734	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055735	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055736	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055737	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2055738	10/2015	10/09/2015	100.060	99.990	100.0	1
KU	C1S	2055739	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055740	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2055741	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055742	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055743	10/2015	10/09/2015	100.070	99.810	100.0	1
KU	C1S	2055744	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055745	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055746	10/2015	10/09/2015	100.090	99.840	100.1	1
KU	C1S	2055747	10/2015	10/09/2015	100.070	99.820	100.0	1
KU	C1S	2055748	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055749	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2055750	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055751	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055752	10/2015	10/09/2015	100.090	99.800	100.0	1
KU	C1S	2055753	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055754	10/2015	10/09/2015	100.080	99.920	100.1	1
KU	C1S	2055755	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055756	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055757	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2055758	10/2015	10/09/2015	100.050	99.920	100.0	1
KU	C1S	2055759	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055760	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055761	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055762	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055763	10/2015	10/09/2015	100.090	100.020	100.0	1
KU	C1S	2055764	10/2015	10/09/2015	100.100	99.840	100.0	1
KU	C1S	2055765	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2055766	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055767	10/2015	10/09/2015	100.060	99.870	100.0	1

KU	C1S	2055768	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055769	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2055770	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055771	10/2015	10/09/2015	100.100	99.850	100.0	1
KU	C1S	2055772	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055773	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055774	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055775	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055776	10/2015	10/09/2015	100.110	99.980	100.1	1
KU	C1S	2055777	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2055778	10/2015	10/09/2015	100.100	99.850	100.0	1
KU	C1S	2055779	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055780	10/2015	10/09/2015	100.100	100.010	100.1	1
KU	C1S	2055781	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055782	10/2015	10/09/2015	100.060	99.800	100.0	1
KU	C1S	2055783	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055784	10/2015	10/09/2015	100.090	99.900	100.1	1
KU	C1S	2055785	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2055786	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2055787	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2055788	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2055789	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055790	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055791	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055792	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055793	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2055794	10/2015	10/09/2015	100.100	100.020	100.1	1
KU	C1S	2055795	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055796	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2055797	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055798	10/2015	10/09/2015	100.060	100.010	100.0	1
KU	C1S	2055799	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055800	10/2015	10/09/2015	100.080	100.010	100.0	1
KU	C1S	2055801	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055802	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2055803	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2055804	10/2015	10/09/2015	100.100	100.030	100.0	1
KU	C1S	2055805	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055806	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2055807	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055808	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2055809	10/2015	10/09/2015	100.060	99.900	100.1	1

KU	C1S	2055810	10/2015	10/09/2015	100.090	99.850	100.1	1
KU	C1S	2055811	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055812	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055813	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2055814	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2055815	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055816	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055817	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2055818	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055819	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2055820	10/2015	10/09/2015	100.070	99.900	100.1	1
KU	C1S	2055821	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055822	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055823	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2055824	10/2015	10/09/2015	100.090	99.890	99.9	1
KU	C1S	2055825	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055826	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2055827	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2055828	10/2015	10/09/2015	100.100	99.960	100.1	1
KU	C1S	2055829	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055830	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055831	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055832	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2055833	10/2015	10/09/2015	100.080	99.800	99.9	1
KU	C1S	2055834	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2055835	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055836	10/2015	10/09/2015	100.090	99.940	99.9	1
KU	C1S	2055837	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055838	10/2015	10/09/2015	100.050	99.830	99.9	1
KU	C1S	2055839	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055840	10/2015	10/09/2015	100.060	99.800	100.0	1
KU	C1S	2055841	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055842	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055843	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2055844	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055845	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2055846	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2055847	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055848	10/2015	10/09/2015	100.080	99.950	99.9	1
KU	C1S	2055849	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055850	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055851	10/2015	10/09/2015	100.090	99.930	100.0	1

KU	C1S	2055852	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055853	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055854	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055855	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055856	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2055857	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2055858	10/2015	10/09/2015	100.060	99.990	100.1	1
KU	C1S	2055859	10/2015	10/09/2015	100.050	99.910	99.9	1
KU	C1S	2055860	10/2015	10/09/2015	100.080	99.910	99.9	1
KU	C1S	2055861	10/2015	10/09/2015	100.110	99.900	100.0	1
KU	C1S	2055862	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2055863	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2055864	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055865	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055866	10/2015	10/09/2015	100.080	99.910	99.9	1
KU	C1S	2055867	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2055868	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055869	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2055870	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055871	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2055872	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055873	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2055874	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2055875	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2055876	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055877	10/2015	10/09/2015	100.050	99.810	100.1	1
KU	C1S	2055878	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055879	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2055880	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2055881	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055882	10/2015	10/09/2015	100.100	99.890	99.9	1
KU	C1S	2055883	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2055884	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055885	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2055886	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055887	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055888	10/2015	10/09/2015	100.060	99.940	99.9	1
KU	C1S	2055889	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055890	10/2015	10/09/2015	100.100	99.840	100.0	1
KU	C1S	2055891	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055892	10/2015	10/09/2015	100.100	99.900	100.1	1
KU	C1S	2055893	10/2015	10/09/2015	100.090	99.960	100.0	1

KU	C1S	2055894	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055895	10/2015	10/09/2015	100.060	99.810	99.9	1
KU	C1S	2055896	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055897	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2055898	10/2015	10/09/2015	100.090	99.870	100.0	1
KU	C1S	2055899	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2055900	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055901	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055902	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055903	10/2015	10/09/2015	100.060	99.970	99.9	1
KU	C1S	2055904	10/2015	10/09/2015	100.080	99.820	100.0	1
KU	C1S	2055905	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2055906	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2055907	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2055908	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055909	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2055910	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055911	10/2015	10/09/2015	100.100	100.040	100.1	1
KU	C1S	2055912	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2055913	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2055914	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2055915	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055916	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2055917	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2055918	10/2015	10/09/2015	100.060	99.930	99.9	1
KU	C1S	2055919	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055920	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055921	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2055922	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2055923	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2055924	10/2015	10/09/2015	100.090	99.880	99.9	1
KU	C1S	2055925	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2055926	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2055927	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2055928	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055929	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2055930	10/2015	10/09/2015	100.090	100.020	100.0	1
KU	C1S	2055931	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2055932	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2055933	10/2015	10/09/2015	100.050	99.910	99.9	1
KU	C1S	2055934	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055935	10/2015	10/09/2015	100.080	99.890	100.0	1

KU	C1S	2055936	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055937	10/2015	10/09/2015	100.070	99.890	100.1	1
KU	C1S	2055938	10/2015	10/09/2015	100.100	99.930	100.1	1
KU	C1S	2055939	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2055940	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2055941	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2055942	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2055943	10/2015	10/09/2015	100.100	99.920	100.1	1
KU	C1S	2055944	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2055945	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2055946	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2055947	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055948	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2055949	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2055950	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2055951	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2055952	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2055953	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2055954	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2055955	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2055956	10/2015	10/09/2015	100.060	99.920	100.1	1
KU	C1S	2055957	10/2015	10/09/2015	100.080	99.870	100.1	1
KU	C1S	2055958	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2055959	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2055960	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2055961	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2055962	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2055963	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2055964	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2055965	10/2015	10/09/2015	100.110	99.920	100.0	1
KU	C1S	2055966	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2055967	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2055968	10/2015	10/09/2015	100.060	99.970	100.0	1
KU	C1S	2055969	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055970	10/2015	10/09/2015	100.100	99.830	100.0	1
KU	C1S	2055971	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2055972	10/2015	10/09/2015	100.100	99.880	100.1	1
KU	C1S	2055973	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2055974	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2055975	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2055976	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2055977	10/2015	10/09/2015	100.060	99.890	100.0	1

KU	C1S	2055978	10/2015	10/09/2015	100.090	99.940	100.1	1
KU	C1S	2055979	10/2015	10/09/2015	100.050	99.870	100.0	1
KU	C1S	2055980	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055981	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2055982	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2055983	10/2015	10/09/2015	100.070	100.000	100.1	1
KU	C1S	2055984	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2055985	10/2015	10/09/2015	100.090	99.810	100.0	1
KU	C1S	2055986	10/2015	10/09/2015	100.070	99.820	100.0	1
KU	C1S	2055987	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055988	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055989	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2055990	10/2015	10/09/2015	100.080	99.940	99.9	1
KU	C1S	2055991	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2055992	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2055993	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2055994	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2055995	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2055996	10/2015	10/09/2015	100.080	99.900	99.9	1
KU	C1S	2055997	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2055998	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2055999	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056000	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2056001	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2056002	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2056003	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2056004	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056005	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2056006	10/2015	10/09/2015	100.080	99.970	99.9	1
KU	C1S	2056007	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2056008	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056009	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2056010	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056011	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2056012	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056013	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2056014	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056015	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056016	10/2015	10/09/2015	100.100	100.030	100.0	1
KU	C1S	2056017	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2056018	10/2015	10/09/2015	100.060	99.970	100.0	1
KU	C1S	2056019	10/2015	10/09/2015	100.060	99.850	100.0	1

KU	C1S	2056020	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2056021	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2056022	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056023	10/2015	10/09/2015	100.090	99.840	99.9	1
KU	C1S	2056024	10/2015	10/09/2015	100.080	99.910	100.1	1
KU	C1S	2056025	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2056026	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2056027	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056028	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2056029	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2056030	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2056031	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2056032	10/2015	10/09/2015	100.050	99.870	100.0	1
KU	C1S	2056033	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2056034	10/2015	10/09/2015	100.070	99.960	99.9	1
KU	C1S	2056035	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2056036	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2056037	10/2015	10/09/2015	100.050	99.860	100.0	1
KU	C1S	2056038	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2056039	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056040	10/2015	10/09/2015	100.050	99.970	100.0	1
KU	C1S	2056041	10/2015	10/09/2015	100.090	100.030	99.9	1
KU	C1S	2056042	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2056043	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056044	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056045	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056046	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056047	10/2015	10/09/2015	100.090	99.990	99.9	1
KU	C1S	2056048	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2056049	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056050	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2056051	10/2015	10/09/2015	100.100	99.960	99.9	1
KU	C1S	2056052	10/2015	10/09/2015	100.090	99.900	100.1	1
KU	C1S	2056053	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056054	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056055	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2056056	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056057	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2056058	10/2015	10/09/2015	100.070	99.950	100.1	1
KU	C1S	2056059	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056060	10/2015	10/09/2015	100.090	99.970	100.1	1
KU	C1S	2056061	10/2015	10/09/2015	100.070	99.880	100.0	1

KU	C1S	2056062	10/2015	10/09/2015	100.070	99.940	100.1	1
KU	C1S	2056063	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2056064	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056065	10/2015	10/09/2015	100.070	99.890	99.9	1
KU	C1S	2056066	10/2015	10/09/2015	100.080	99.920	99.9	1
KU	C1S	2056067	10/2015	10/09/2015	100.060	99.890	99.9	1
KU	C1S	2056068	10/2015	10/09/2015	100.100	99.900	99.9	1
KU	C1S	2056069	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056070	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056071	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2056072	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056073	10/2015	10/09/2015	100.080	99.980	100.0	1
KU	C1S	2056074	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2056075	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2056076	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056077	10/2015	10/09/2015	100.080	99.820	99.9	1
KU	C1S	2056078	10/2015	10/09/2015	100.080	99.980	100.0	1
KU	C1S	2056079	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056080	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2056081	10/2015	10/09/2015	100.070	100.000	100.0	1
KU	C1S	2056082	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2056083	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2056084	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056085	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056086	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056087	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056088	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2056089	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056090	10/2015	10/09/2015	100.080	99.870	99.9	1
KU	C1S	2056091	10/2015	10/09/2015	100.080	99.870	99.9	1
KU	C1S	2056092	10/2015	10/09/2015	100.070	99.830	99.9	1
KU	C1S	2056093	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2056094	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2056095	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056096	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2056097	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056098	10/2015	10/09/2015	100.100	99.850	100.0	1
KU	C1S	2056099	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056100	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2056101	10/2015	10/09/2015	100.090	99.840	99.9	1
KU	C1S	2056102	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2056103	10/2015	10/09/2015	100.080	99.930	100.0	1

KU	C1S	2056104	10/2015	10/09/2015	100.060	99.990	99.9	1
KU	C1S	2056105	10/2015	10/09/2015	100.090	99.880	99.9	1
KU	C1S	2056106	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056107	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056108	10/2015	10/09/2015	100.080	99.860	99.9	1
KU	C1S	2056109	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2056110	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056111	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056112	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056113	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2056114	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056115	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2056116	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2056117	10/2015	10/09/2015	100.100	99.890	100.1	1
KU	C1S	2056118	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2056119	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056120	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056121	10/2015	10/09/2015	100.100	99.880	99.9	1
KU	C1S	2056122	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056123	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2056124	10/2015	10/09/2015	100.050	99.890	99.9	1
KU	C1S	2056125	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056126	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056127	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056128	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056129	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2056130	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2056131	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056132	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056133	10/2015	10/09/2015	100.070	99.810	99.9	1
KU	C1S	2056134	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056135	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2056136	10/2015	10/09/2015	100.080	99.830	100.0	1
KU	C1S	2056137	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056138	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056139	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056140	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056141	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056142	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056143	10/2015	10/09/2015	100.070	99.840	100.1	1
KU	C1S	2056144	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2056145	10/2015	10/09/2015	100.060	99.800	99.9	1

KU	C1S	2056146	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2056147	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2056148	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056149	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2056150	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056151	10/2015	10/09/2015	100.100	99.880	99.9	1
KU	C1S	2056152	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056153	10/2015	10/09/2015	100.060	99.900	99.9	1
KU	C1S	2056154	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056155	10/2015	10/09/2015	100.060	99.870	99.9	1
KU	C1S	2056156	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056157	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2056158	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056159	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056160	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056161	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2056162	10/2015	10/09/2015	100.090	99.900	99.9	1
KU	C1S	2056163	10/2015	10/09/2015	100.100	99.980	100.1	1
KU	C1S	2056164	10/2015	10/09/2015	100.070	99.920	99.9	1
KU	C1S	2056165	10/2015	10/09/2015	100.080	99.980	100.0	1
KU	C1S	2056166	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056167	10/2015	10/09/2015	100.080	100.000	100.0	1
KU	C1S	2056168	10/2015	10/09/2015	100.070	99.960	99.9	1
KU	C1S	2056169	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2056170	10/2015	10/09/2015	100.100	99.820	100.1	1
KU	C1S	2056171	10/2015	10/09/2015	100.060	100.020	100.0	1
KU	C1S	2056172	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056173	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056174	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2056175	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2056176	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056177	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2056178	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056179	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056180	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2056181	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056182	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056183	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2056184	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2056185	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056186	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2056187	10/2015	10/09/2015	100.050	99.930	99.9	1

KU	C1S	2056188	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056189	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2056190	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2056191	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2056192	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2056193	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2056194	10/2015	10/09/2015	100.090	100.030	100.1	1
KU	C1S	2056195	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056196	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2056197	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056198	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056199	10/2015	10/09/2015	100.070	99.880	100.1	1
KU	C1S	2056200	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2056201	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2056202	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2056203	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2056204	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056205	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056206	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056207	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056208	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056209	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2056210	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056211	10/2015	10/09/2015	100.080	99.930	100.0	1
KU	C1S	2056212	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056213	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056214	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2056215	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056216	10/2015	10/09/2015	100.110	99.980	100.0	1
KU	C1S	2056217	10/2015	10/09/2015	100.080	99.990	99.9	1
KU	C1S	2056218	10/2015	10/09/2015	100.070	99.800	100.0	1
KU	C1S	2056219	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056220	10/2015	10/09/2015	100.110	100.010	100.0	1
KU	C1S	2056221	10/2015	10/09/2015	100.100	99.940	99.9	1
KU	C1S	2056222	10/2015	10/09/2015	100.050	99.880	99.9	1
KU	C1S	2056223	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2056224	10/2015	10/09/2015	100.080	99.880	100.1	1
KU	C1S	2056225	10/2015	10/09/2015	100.050	99.890	100.0	1
KU	C1S	2056226	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2056227	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2056228	10/2015	10/09/2015	100.090	99.850	100.1	1
KU	C1S	2056229	10/2015	10/09/2015	100.070	99.840	100.1	1

KU	C1S	2056230	10/2015	10/09/2015	100.090	99.870	100.1	1
KU	C1S	2056231	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2056232	10/2015	10/09/2015	100.070	99.920	100.1	1
KU	C1S	2056233	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056234	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2056235	10/2015	10/09/2015	100.070	99.810	100.0	1
KU	C1S	2056236	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2056237	10/2015	10/09/2015	100.080	99.970	99.9	1
KU	C1S	2056238	10/2015	10/09/2015	100.060	99.970	100.0	1
KU	C1S	2056239	10/2015	10/09/2015	100.050	99.930	100.0	1
KU	C1S	2056240	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056241	10/2015	10/09/2015	100.080	99.860	100.0	1
KU	C1S	2056242	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2056243	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056244	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056245	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056246	10/2015	10/09/2015	100.090	99.960	99.9	1
KU	C1S	2056247	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2056248	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056249	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2056250	10/2015	10/09/2015	100.090	99.890	99.9	1
KU	C1S	2056251	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2056252	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2056253	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056254	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2056255	10/2015	10/09/2015	100.070	100.010	99.9	1
KU	C1S	2056256	10/2015	10/09/2015	100.100	99.960	100.1	1
KU	C1S	2056257	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056258	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056259	10/2015	10/09/2015	100.090	99.870	100.1	1
KU	C1S	2056260	10/2015	10/09/2015	100.100	99.910	100.0	1
KU	C1S	2056261	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056262	10/2015	10/09/2015	100.100	99.850	100.1	1
KU	C1S	2056263	10/2015	10/09/2015	100.070	99.910	100.1	1
KU	C1S	2056264	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056265	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056266	10/2015	10/09/2015	100.070	99.850	99.9	1
KU	C1S	2056267	10/2015	10/09/2015	100.090	99.830	99.9	1
KU	C1S	2056268	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056269	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056270	10/2015	10/09/2015	100.100	99.810	100.0	1
KU	C1S	2056271	10/2015	10/09/2015	100.080	99.890	99.9	1

KU	C1S	2056272	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2056273	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056274	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056275	10/2015	10/09/2015	100.050	99.870	99.9	1
KU	C1S	2056276	10/2015	10/09/2015	100.050	99.890	99.9	1
KU	C1S	2056277	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056278	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2056279	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056280	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056281	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056282	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056283	10/2015	10/09/2015	100.100	99.910	100.1	1
KU	C1S	2056284	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2056285	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056286	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2056287	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2056288	10/2015	10/09/2015	100.100	99.860	99.9	1
KU	C1S	2056289	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056290	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056291	10/2015	10/09/2015	100.060	99.940	99.9	1
KU	C1S	2056292	10/2015	10/09/2015	100.090	99.870	100.0	1
KU	C1S	2056293	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2056294	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2056295	10/2015	10/09/2015	100.050	99.880	99.9	1
KU	C1S	2056296	10/2015	10/09/2015	100.090	99.850	99.9	1
KU	C1S	2056297	10/2015	10/09/2015	100.070	100.010	100.0	1
KU	C1S	2056298	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056299	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056300	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2056301	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2056302	10/2015	10/09/2015	100.100	99.840	100.0	1
KU	C1S	2056303	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2056304	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056305	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056306	10/2015	10/09/2015	100.100	99.970	100.1	1
KU	C1S	2056307	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056308	10/2015	10/09/2015	100.070	100.010	100.0	1
KU	C1S	2056309	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2056310	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2056311	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056312	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056313	10/2015	10/09/2015	100.100	99.910	100.0	1

KU	C1S	2056314	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056315	10/2015	10/09/2015	100.100	99.880	100.1	1
KU	C1S	2056316	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2056317	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2056318	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2056319	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056320	10/2015	10/09/2015	100.070	99.850	100.0	1
KU	C1S	2056321	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2056322	10/2015	10/09/2015	100.110	100.020	100.1	1
KU	C1S	2056323	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056324	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2056325	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056326	10/2015	10/09/2015	100.100	99.950	100.1	1
KU	C1S	2056327	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2056328	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2056329	10/2015	10/09/2015	100.050	99.930	100.0	1
KU	C1S	2056330	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2056331	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056332	10/2015	10/09/2015	100.050	99.800	99.9	1
KU	C1S	2056333	10/2015	10/09/2015	100.050	99.970	100.0	1
KU	C1S	2056334	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056335	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2056336	10/2015	10/09/2015	100.070	99.990	100.0	1
KU	C1S	2056337	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056338	10/2015	10/09/2015	100.080	99.840	99.9	1
KU	C1S	2056339	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056340	10/2015	10/09/2015	100.100	100.050	100.0	1
KU	C1S	2056341	10/2015	10/09/2015	100.070	99.860	100.1	1
KU	C1S	2056342	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056343	10/2015	10/09/2015	100.070	99.830	100.0	1
KU	C1S	2056344	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056345	10/2015	10/09/2015	100.060	99.850	99.9	1
KU	C1S	2056346	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056347	10/2015	10/09/2015	100.100	99.940	100.1	1
KU	C1S	2056348	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056349	10/2015	10/09/2015	100.060	99.940	100.0	1
KU	C1S	2056350	10/2015	10/09/2015	100.100	99.980	100.0	1
KU	C1S	2056351	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056352	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2056353	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056354	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056355	10/2015	10/09/2015	100.090	99.920	100.0	1

KU	C1S	2056356	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056357	10/2015	10/09/2015	100.070	99.840	99.9	1
KU	C1S	2056358	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2056359	10/2015	10/09/2015	100.070	99.870	100.1	1
KU	C1S	2056360	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056361	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056362	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2056363	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2056364	10/2015	10/09/2015	100.090	100.060	99.9	1
KU	C1S	2056365	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056366	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056367	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056368	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056369	10/2015	10/09/2015	100.100	99.870	99.9	1
KU	C1S	2056370	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056371	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2056372	10/2015	10/09/2015	100.070	99.890	99.9	1
KU	C1S	2056373	10/2015	10/09/2015	100.070	100.000	100.0	1
KU	C1S	2056374	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2056375	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056376	10/2015	10/09/2015	100.090	99.900	99.9	1
KU	C1S	2056377	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2056378	10/2015	10/09/2015	100.090	99.970	99.9	1
KU	C1S	2056379	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2056380	10/2015	10/09/2015	100.070	99.910	100.0	1
KU	C1S	2056381	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056382	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2056383	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056384	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2056385	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056386	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2056387	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056388	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2056389	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2056390	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056391	10/2015	10/09/2015	100.060	99.880	100.0	1
KU	C1S	2056392	10/2015	10/09/2015	100.100	99.920	100.0	1
KU	C1S	2056393	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056394	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056395	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2056396	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2056397	10/2015	10/09/2015	100.090	99.880	100.1	1

KU	C1S	2056398	10/2015	10/09/2015	100.100	99.830	100.0	1
KU	C1S	2056399	10/2015	10/09/2015	100.090	99.980	99.9	1
KU	C1S	2056400	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056401	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056402	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056403	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2056404	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056405	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056406	10/2015	10/09/2015	100.080	99.850	100.0	1
KU	C1S	2056407	10/2015	10/09/2015	100.080	99.880	100.1	1
KU	C1S	2056408	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2056409	10/2015	10/09/2015	100.080	99.950	100.0	1
KU	C1S	2056410	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056411	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2056412	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056413	10/2015	10/09/2015	100.070	99.870	99.9	1
KU	C1S	2056414	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2056415	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2056416	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2056417	10/2015	10/09/2015	100.050	99.900	100.1	1
KU	C1S	2056418	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056419	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2056420	10/2015	10/09/2015	100.080	99.850	99.9	1
KU	C1S	2056421	10/2015	10/09/2015	100.090	99.980	100.0	1
KU	C1S	2056422	10/2015	10/09/2015	100.100	99.840	100.1	1
KU	C1S	2056423	10/2015	10/09/2015	100.080	99.830	100.1	1
KU	C1S	2056424	10/2015	10/09/2015	100.100	100.080	100.0	1
KU	C1S	2056425	10/2015	10/09/2015	100.100	100.000	100.0	1
KU	C1S	2056426	10/2015	10/09/2015	100.100	99.960	100.0	1
KU	C1S	2056427	10/2015	10/09/2015	100.070	99.910	99.9	1
KU	C1S	2056428	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056429	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2056430	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2056431	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2056432	10/2015	10/09/2015	100.080	99.880	99.9	1
KU	C1S	2056433	10/2015	10/09/2015	100.100	99.860	100.0	1
KU	C1S	2056434	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056435	10/2015	10/09/2015	100.090	99.860	100.0	1
KU	C1S	2056436	10/2015	10/09/2015	100.070	99.800	99.9	1
KU	C1S	2056437	10/2015	10/09/2015	100.050	99.870	99.9	1
KU	C1S	2056438	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056439	10/2015	10/09/2015	100.100	99.980	100.0	1

KU	C1S	2056440	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056441	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056442	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2056443	10/2015	10/09/2015	100.090	99.930	100.0	1
KU	C1S	2056444	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2056445	10/2015	10/09/2015	100.070	99.900	100.1	1
KU	C1S	2056446	10/2015	10/09/2015	100.080	99.880	100.1	1
KU	C1S	2056447	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056448	10/2015	10/09/2015	100.060	99.840	100.0	1
KU	C1S	2056449	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056450	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056451	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056452	10/2015	10/09/2015	100.070	99.860	99.9	1
KU	C1S	2056453	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056454	10/2015	10/09/2015	100.090	99.850	100.0	1
KU	C1S	2056455	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056456	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056457	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056458	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056459	10/2015	10/09/2015	100.090	99.960	100.0	1
KU	C1S	2056460	10/2015	10/09/2015	100.060	99.950	100.0	1
KU	C1S	2056461	10/2015	10/09/2015	100.090	99.940	100.1	1
KU	C1S	2056462	10/2015	10/09/2015	100.070	99.950	100.1	1
KU	C1S	2056463	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056464	10/2015	10/09/2015	100.090	99.800	100.0	1
KU	C1S	2056465	10/2015	10/09/2015	100.060	99.940	99.9	1
KU	C1S	2056466	10/2015	10/09/2015	100.090	100.010	100.0	1
KU	C1S	2056467	10/2015	10/09/2015	100.100	99.810	100.0	1
KU	C1S	2056468	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2056469	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056470	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056471	10/2015	10/09/2015	100.060	99.880	99.9	1
KU	C1S	2056472	10/2015	10/09/2015	100.080	100.000	100.0	1
KU	C1S	2056473	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056474	10/2015	10/09/2015	100.080	99.990	100.0	1
KU	C1S	2056475	10/2015	10/09/2015	100.070	99.980	100.0	1
KU	C1S	2056476	10/2015	10/09/2015	100.100	100.020	100.0	1
KU	C1S	2056477	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056478	10/2015	10/09/2015	100.100	100.030	100.0	1
KU	C1S	2056479	10/2015	10/09/2015	100.070	99.950	100.0	1
KU	C1S	2056480	10/2015	10/09/2015	100.080	99.970	100.0	1
KU	C1S	2056481	10/2015	10/09/2015	100.070	99.870	99.9	1

KU	C1S	2056482	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2056483	10/2015	10/09/2015	100.050	99.890	99.9	1
KU	C1S	2056484	10/2015	10/09/2015	100.090	99.890	99.9	1
KU	C1S	2056485	10/2015	10/09/2015	100.070	99.960	100.0	1
KU	C1S	2056486	10/2015	10/09/2015	100.070	99.890	100.0	1
KU	C1S	2056487	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056488	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2056489	10/2015	10/09/2015	100.080	99.960	100.0	1
KU	C1S	2056490	10/2015	10/09/2015	100.100	99.880	99.9	1
KU	C1S	2056491	10/2015	10/09/2015	100.090	99.950	100.1	1
KU	C1S	2056492	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056493	10/2015	10/09/2015	100.070	99.930	100.0	1
KU	C1S	2056494	10/2015	10/09/2015	100.070	99.880	100.0	1
KU	C1S	2056495	10/2015	10/09/2015	100.080	99.980	100.0	1
KU	C1S	2056496	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2056497	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056498	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2056499	10/2015	10/09/2015	100.070	99.990	100.0	1
KU	C1S	2056500	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056501	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056502	10/2015	10/09/2015	100.070	99.940	99.9	1
KU	C1S	2056503	10/2015	10/09/2015	100.050	99.920	100.0	1
KU	C1S	2056504	10/2015	10/09/2015	100.100	99.940	100.0	1
KU	C1S	2056505	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056506	10/2015	10/09/2015	100.100	99.930	100.0	1
KU	C1S	2056507	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056508	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056509	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2056510	10/2015	10/09/2015	100.050	99.840	100.0	1
KU	C1S	2056511	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056512	10/2015	10/09/2015	100.070	99.920	100.0	1
KU	C1S	2056513	10/2015	10/09/2015	100.100	99.990	100.0	1
KU	C1S	2056514	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056515	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056516	10/2015	10/09/2015	100.100	99.930	100.1	1
KU	C1S	2056517	10/2015	10/09/2015	100.100	100.010	100.0	1
KU	C1S	2056518	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2056519	10/2015	10/09/2015	100.070	99.900	99.9	1
KU	C1S	2056520	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056521	10/2015	10/09/2015	100.050	99.900	100.0	1
KU	C1S	2056522	10/2015	10/09/2015	100.070	100.000	100.0	1
KU	C1S	2056523	10/2015	10/09/2015	100.100	99.880	99.9	1

KU	C1S	2056524	10/2015	10/09/2015	100.100	99.880	100.0	1
KU	C1S	2056525	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056526	10/2015	10/09/2015	100.080	99.920	100.0	1
KU	C1S	2056527	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056528	10/2015	10/09/2015	100.100	99.800	99.9	1
KU	C1S	2056529	10/2015	10/09/2015	100.070	99.900	100.0	1
KU	C1S	2056530	10/2015	10/09/2015	100.100	99.870	100.0	1
KU	C1S	2056531	10/2015	10/09/2015	100.060	99.820	100.0	1
KU	C1S	2056532	10/2015	10/09/2015	100.060	99.910	99.9	1
KU	C1S	2056533	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056534	10/2015	10/09/2015	100.050	99.900	99.9	1
KU	C1S	2056535	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056536	10/2015	10/09/2015	100.070	99.930	100.1	1
KU	C1S	2056537	10/2015	10/09/2015	100.080	100.000	100.0	1
KU	C1S	2056538	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2056539	10/2015	10/09/2015	100.050	99.880	100.0	1
KU	C1S	2056540	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056541	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056542	10/2015	10/09/2015	100.060	99.920	100.0	1
KU	C1S	2056543	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056544	10/2015	10/09/2015	100.090	99.860	100.1	1
KU	C1S	2056545	10/2015	10/09/2015	100.100	99.890	99.9	1
KU	C1S	2056546	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2056547	10/2015	10/09/2015	100.050	99.870	100.0	1
KU	C1S	2056548	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2056549	10/2015	10/09/2015	100.070	99.990	100.1	1
KU	C1S	2056550	10/2015	10/09/2015	100.100	99.900	100.0	1
KU	C1S	2056551	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056552	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2056553	10/2015	10/09/2015	100.060	99.860	99.9	1
KU	C1S	2056554	10/2015	10/09/2015	100.070	99.860	100.0	1
KU	C1S	2056555	10/2015	10/09/2015	100.100	99.950	100.0	1
KU	C1S	2056556	10/2015	10/09/2015	100.060	99.930	100.0	1
KU	C1S	2056557	10/2015	10/09/2015	100.060	99.930	100.1	1
KU	C1S	2056558	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2056559	10/2015	10/09/2015	100.090	99.970	100.0	1
KU	C1S	2056560	10/2015	10/09/2015	100.080	99.900	100.0	1
KU	C1S	2056561	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2056562	10/2015	10/09/2015	100.060	99.810	100.0	1
KU	C1S	2056563	10/2015	10/09/2015	100.090	99.900	100.0	1
KU	C1S	2056564	10/2015	10/09/2015	100.090	99.940	100.0	1
KU	C1S	2056565	10/2015	10/09/2015	100.090	99.970	100.0	1

KU	C1S	2056566	10/2015	10/09/2015	100.060	99.890	100.0	1
KU	C1S	2056567	10/2015	10/09/2015	100.100	99.940	99.9	1
KU	C1S	2056568	10/2015	10/09/2015	100.100	99.890	100.0	1
KU	C1S	2056569	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2056570	10/2015	10/09/2015	100.050	99.850	100.0	1
KU	C1S	2056571	10/2015	10/09/2015	100.050	99.980	100.0	1
KU	C1S	2056572	10/2015	10/09/2015	100.090	99.870	100.0	1
KU	C1S	2056573	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056574	10/2015	10/09/2015	100.080	99.840	100.0	1
KU	C1S	2056575	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056576	10/2015	10/09/2015	100.060	99.830	100.0	1
KU	C1S	2056577	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2056578	10/2015	10/09/2015	100.070	99.910	100.1	1
KU	C1S	2056579	10/2015	10/09/2015	100.080	99.890	100.0	1
KU	C1S	2056580	10/2015	10/09/2015	100.090	99.910	100.0	1
KU	C1S	2056581	10/2015	10/09/2015	100.080	99.910	100.1	1
KU	C1S	2056582	10/2015	10/09/2015	100.060	99.910	100.0	1
KU	C1S	2056583	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056584	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056585	10/2015	10/09/2015	100.080	99.810	100.0	1
KU	C1S	2056586	10/2015	10/09/2015	100.100	100.030	100.0	1
KU	C1S	2056587	10/2015	10/09/2015	100.090	99.990	100.0	1
KU	C1S	2056588	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056589	10/2015	10/09/2015	100.090	99.920	100.0	1
KU	C1S	2056590	10/2015	10/09/2015	100.070	99.880	99.9	1
KU	C1S	2056591	10/2015	10/09/2015	100.090	99.950	100.0	1
KU	C1S	2056592	10/2015	10/09/2015	100.070	99.970	100.0	1
KU	C1S	2056593	10/2015	10/09/2015	100.050	100.010	100.0	1
KU	C1S	2056594	10/2015	10/09/2015	100.070	99.930	99.9	1
KU	C1S	2056595	10/2015	10/09/2015	100.080	99.870	100.0	1
KU	C1S	2056596	10/2015	10/09/2015	100.050	99.820	100.1	1
KU	C1S	2056597	10/2015	10/09/2015	100.060	99.860	100.0	1
KU	C1S	2056598	10/2015	10/09/2015	100.080	99.880	100.0	1
KU	C1S	2056599	10/2015	10/09/2015	100.080	99.950	99.9	1
KU	C1S	2056600	10/2015	10/09/2015	100.070	99.870	100.0	1
KU	C1S	2056601	10/2015	10/09/2015	100.060	99.900	100.0	1
KU	C1S	2056602	10/2015	10/09/2015	100.060	99.870	100.0	1
KU	C1S	2056603	10/2015	10/09/2015	100.080	99.910	100.0	1
KU	C1S	2056604	10/2015	10/09/2015	100.060	99.920	99.9	1
KU	C1S	2056605	10/2015	10/09/2015	100.090	99.880	100.0	1
KU	C1S	2056606	10/2015	10/09/2015	100.070	99.840	100.0	1
KU	C1S	2056607	10/2015	10/09/2015	100.070	99.850	100.1	1

KU	C1S	2056608	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056609	10/2015	10/09/2015	100.060	99.830	99.9	1
KU	C1S	2056610	10/2015	10/09/2015	100.080	99.950	99.9	1
KU	C1S	2056611	10/2015	10/09/2015	100.080	99.940	100.0	1
KU	C1S	2056612	10/2015	10/09/2015	100.050	99.880	100.0	1
KU	C1S	2056613	10/2015	10/09/2015	100.060	99.960	100.0	1
KU	C1S	2056614	10/2015	10/09/2015	100.100	99.970	100.0	1
KU	C1S	2056615	10/2015	10/09/2015	100.060	99.850	100.0	1
KU	C1S	2056616	10/2015	10/09/2015	100.090	99.890	100.0	1
KU	C1S	2056617	10/2015	10/09/2015	100.070	99.940	100.0	1
KU	C1S	2056618	10/2015	10/09/2015	100.080	99.820	100.0	1
KU	C1S	2056619	10/2015	10/09/2015	100.060	99.840	99.9	1
KU	C1S	2056620	10/2015	10/20/2015	100.010	99.980	100.0	1
KU	C1S	2056621	10/2015	10/20/2015	100.000	99.990	100.1	1
KU	C1S	2056622	10/2015	10/20/2015	99.970	100.000	100.1	1
KU	C1S	2056623	10/2015	10/20/2015	100.010	99.930	100.1	1
KU	C1S	2056624	10/2015	10/20/2015	100.000	99.970	100.2	1
KU	C1S	2056625	10/2015	10/20/2015	99.980	99.970	100.1	1
KU	C1S	2056626	10/2015	10/20/2015	100.020	99.940	100.1	1
KU	C1S	2056627	10/2015	10/20/2015	99.990	100.000	100.1	1
KU	C1S	2056628	10/2015	10/20/2015	100.010	100.030	100.1	1
KU	C1S	2056629	10/2015	10/20/2015	100.050	99.970	100.1	1
KU	C1S	2056630	10/2015	10/20/2015	99.990	100.010	100.1	1
KU	C1S	2056631	10/2015	10/20/2015	100.000	99.960	100.1	1
KU	C1S	2056632	10/2015	10/20/2015	100.010	100.010	100.1	1
KU	C1S	2056633	10/2015	10/20/2015	99.980	99.990	100.1	1
KU	C1S	2056634	10/2015	10/20/2015	99.990	100.040	100.1	1
KU	C1S	2056635	10/2015	10/20/2015	100.020	99.940	100.1	1
KU	C1S	2056636	10/2015	10/20/2015	99.980	99.920	100.1	1
KU	C1S	2056637	10/2015	10/20/2015	100.000	99.920	100.1	1
KU	C1S	2056638	10/2015	10/20/2015	100.030	99.970	100.1	1
KU	C1S	2056639	10/2015	10/20/2015	100.010	99.920	100.1	1
KU	C1S	2056640	10/2015	10/20/2015	99.970	99.910	100.1	1
KU	C1S	2056641	10/2015	10/20/2015	99.990	99.960	100.1	1
KU	C1S	2056642	10/2015	10/20/2015	99.990	99.920	100.1	1
KU	C1S	2056643	10/2015	10/20/2015	100.020	99.990	100.1	1
KU	C1S	2056644	10/2015	10/20/2015	100.020	99.960	100.1	1
KU	C1S	2056645	10/2015	10/20/2015	100.020	99.980	100.0	1
KU	C1S	2056646	10/2015	10/20/2015	100.040	100.030	100.1	1
KU	C1S	2056647	10/2015	10/20/2015	99.950	100.000	100.1	1
KU	C1S	2056648	10/2015	10/20/2015	100.010	100.040	100.1	1
KU	C1S	2056649	10/2015	10/20/2015	99.990	99.930	100.1	1

KU	C1S	2056650	10/2015	10/20/2015	100.040	99.970	100.1	1
KU	C1S	2056651	10/2015	10/20/2015	100.040	99.960	100.1	1
KU	C1S	2056652	10/2015	10/20/2015	99.980	99.950	100.0	1
KU	C1S	2056653	10/2015	10/20/2015	99.990	99.990	100.1	1
KU	C1S	2056654	10/2015	10/20/2015	100.010	99.920	100.1	1
KU	C1S	2056655	10/2015	10/20/2015	100.040	99.960	100.1	1
KU	C1S	2056656	10/2015	10/20/2015	100.010	99.950	100.1	1
KU	C1S	2056657	10/2015	10/20/2015	100.010	99.940	100.1	1
KU	C1S	2056658	10/2015	10/20/2015	100.010	100.020	100.1	1
KU	C1S	2056659	10/2015	10/20/2015	99.990	99.950	100.1	1
KU	C1S	2056660	10/2015	10/20/2015	99.990	99.910	100.1	1
KU	C1S	2056661	10/2015	10/20/2015	100.020	99.990	100.1	1
KU	C1S	2056662	10/2015	10/20/2015	99.990	99.910	100.1	1
KU	C1S	2056663	10/2015	10/20/2015	99.970	99.930	100.1	1
KU	C1S	2056664	10/2015	10/20/2015	100.030	100.000	100.1	1
KU	C1S	2056665	10/2015	10/20/2015	99.970	100.060	100.2	1
KU	C1S	2056666	10/2015	10/20/2015	99.980	100.000	100.1	1
KU	C1S	2056667	10/2015	10/20/2015	100.010	99.990	100.0	1
KU	C1S	2056668	10/2015	10/20/2015	99.990	99.900	100.1	1
KU	C1S	2056669	10/2015	10/20/2015	99.990	99.950	100.1	1
KU	C1S	2056670	10/2015	10/20/2015	100.030	99.990	100.0	1
KU	C1S	2056671	10/2015	10/20/2015	100.000	99.980	100.1	1
KU	C1S	2056672	10/2015	10/20/2015	100.030	99.900	100.0	1
KU	C1S	2056673	10/2015	10/20/2015	100.000	99.990	100.1	1
KU	C1S	2056674	10/2015	10/20/2015	100.020	100.060	100.1	1
KU	C1S	2056675	10/2015	10/20/2015	99.950	100.000	100.1	1
KU	C1S	2056676	10/2015	10/20/2015	100.000	99.970	100.1	1
KU	C1S	2056677	10/2015	10/20/2015	100.020	99.970	100.0	1
KU	C1S	2056678	10/2015	10/20/2015	99.990	99.920	100.1	1
KU	C1S	2056679	10/2015	10/20/2015	99.990	99.970	100.1	1
KU	C1S	2056680	10/2015	10/20/2015	100.000	99.940	100.1	1
KU	C1S	2056681	10/2015	10/20/2015	99.980	99.970	100.1	1
KU	C1S	2056682	10/2015	10/20/2015	100.020	99.940	100.1	1
KU	C1S	2056683	10/2015	10/20/2015	100.020	100.000	100.1	1
KU	C1S	2056684	10/2015	10/20/2015	100.020	99.980	100.1	1
KU	C1S	2056685	10/2015	10/20/2015	100.020	99.920	100.1	1
KU	C1S	2056686	10/2015	10/20/2015	100.030	99.930	100.1	1
KU	C1S	2056687	10/2015	10/20/2015	99.980	99.940	100.1	1
KU	C1S	2056688	10/2015	10/20/2015	100.030	99.990	100.1	1
KU	C1S	2056689	10/2015	10/20/2015	99.960	100.030	100.1	1
KU	C1S	2056690	10/2015	10/20/2015	100.030	99.920	100.1	1
KU	C1S	2056691	10/2015	10/20/2015	100.020	99.940	100.1	1

KU	C1S	2056692	10/2015	10/20/2015	100.010	99.920	100.1	1
KU	C1S	2056693	10/2015	10/20/2015	100.020	100.000	100.1	1
KU	C1S	2056694	10/2015	10/20/2015	99.990	100.070	100.1	1
KU	C1S	2056695	10/2015	10/20/2015	100.030	99.920	100.0	1
KU	C1S	2056696	10/2015	10/20/2015	99.990	99.940	100.1	1
KU	C1S	2056697	10/2015	10/20/2015	100.010	99.950	100.0	1
KU	C1S	2056698	10/2015	10/20/2015	99.970	100.000	100.1	1
KU	C1S	2056699	10/2015	10/20/2015	99.990	99.950	100.1	1
KU	C1S	2056700	10/2015	10/20/2015	100.010	99.900	100.1	1
KU	C1S	2056701	10/2015	10/20/2015	100.000	99.970	100.1	1
KU	C1S	2056702	10/2015	10/20/2015	100.000	99.990	100.1	1
KU	C1S	2056703	10/2015	10/20/2015	100.010	99.900	100.1	1
KU	C1S	2056704	10/2015	10/20/2015	100.060	99.980	100.1	1
KU	C1S	2056705	10/2015	10/20/2015	100.000	99.930	100.0	1
KU	C1S	2056706	10/2015	10/20/2015	100.010	99.910	100.1	1
KU	C1S	2056707	10/2015	10/20/2015	99.990	99.930	100.1	1
KU	C1S	2056708	10/2015	10/20/2015	99.970	99.980	100.1	1
KU	C1S	2056709	10/2015	10/20/2015	99.960	99.980	100.1	1
KU	C1S	2056710	10/2015	10/20/2015	99.980	100.000	100.1	1
KU	C1S	2056711	10/2015	10/20/2015	100.000	100.010	100.1	1
KU	C1S	2056712	10/2015	10/20/2015	99.990	99.900	100.1	1
KU	C1S	2056713	10/2015	10/20/2015	100.010	99.970	100.1	1
KU	C1S	2056714	10/2015	10/20/2015	99.990	100.020	100.1	1
KU	C1S	2056715	10/2015	10/20/2015	100.010	100.000	100.1	1
KU	C1S	2056980	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2056981	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2056982	11/2015	11/02/2015	100.050	100.010	100.0	1
KU	C1S	2056983	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2056984	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2056985	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2056986	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2056987	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2056988	11/2015	11/02/2015	100.040	99.980	100.1	1
KU	C1S	2056989	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2056990	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2056991	11/2015	11/02/2015	100.010	99.980	100.0	1
KU	C1S	2056992	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2056993	11/2015	11/02/2015	100.040	100.010	100.1	1
KU	C1S	2056994	11/2015	11/02/2015	100.020	100.050	100.0	1
KU	C1S	2056995	11/2015	11/02/2015	100.030	99.990	100.1	1
KU	C1S	2056996	11/2015	11/02/2015	100.010	99.980	100.1	1
KU	C1S	2056997	11/2015	11/02/2015	100.020	99.960	100.0	1

KU	C1S	2056998	11/2015	11/02/2015	99.970	100.010	100.1	1
KU	C1S	2056999	11/2015	11/02/2015	100.000	99.940	100.0	1
KU	C1S	2057000	11/2015	11/02/2015	100.060	99.980	100.1	1
KU	C1S	2057001	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057002	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057003	11/2015	11/02/2015	100.000	99.990	100.1	1
KU	C1S	2057004	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057005	11/2015	11/02/2015	99.980	100.010	100.1	1
KU	C1S	2057006	11/2015	11/02/2015	99.970	100.000	100.1	1
KU	C1S	2057007	11/2015	11/02/2015	100.010	100.000	100.1	1
KU	C1S	2057008	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057009	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2057010	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057011	11/2015	11/02/2015	100.000	99.960	100.0	1
KU	C1S	2057012	11/2015	11/02/2015	99.990	99.990	100.1	1
KU	C1S	2057013	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057014	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057015	11/2015	11/02/2015	100.000	99.940	100.0	1
KU	C1S	2057016	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057017	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057018	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057019	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057020	11/2015	11/02/2015	99.980	100.050	100.1	1
KU	C1S	2057021	11/2015	11/02/2015	99.980	99.960	100.0	1
KU	C1S	2057022	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057023	11/2015	11/02/2015	100.050	100.030	100.1	1
KU	C1S	2057024	11/2015	11/02/2015	99.970	100.040	100.1	1
KU	C1S	2057025	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057026	11/2015	11/02/2015	100.010	99.970	100.1	1
KU	C1S	2057027	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057028	11/2015	11/02/2015	100.000	99.970	100.0	1
KU	C1S	2057029	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057030	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057031	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2057032	11/2015	11/02/2015	99.980	99.950	100.0	1
KU	C1S	2057033	11/2015	11/02/2015	99.980	99.990	100.1	1
KU	C1S	2057034	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057035	11/2015	11/02/2015	99.980	100.010	100.1	1
KU	C1S	2057036	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057037	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057038	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057039	11/2015	11/02/2015	100.030	100.030	100.1	1

KU	C1S	2057040	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057041	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057042	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057043	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057044	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057045	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057046	11/2015	11/02/2015	99.970	99.990	100.1	1
KU	C1S	2057047	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057048	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057049	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057050	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057051	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057052	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057053	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057054	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057055	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057056	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057057	11/2015	11/02/2015	100.020	99.970	100.0	1
KU	C1S	2057058	11/2015	11/02/2015	100.040	100.050	100.0	1
KU	C1S	2057059	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057060	11/2015	11/02/2015	99.970	99.970	100.0	1
KU	C1S	2057061	11/2015	11/02/2015	99.980	100.010	100.1	1
KU	C1S	2057062	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057063	11/2015	11/02/2015	99.960	100.020	100.1	1
KU	C1S	2057064	11/2015	11/02/2015	99.990	99.980	100.1	1
KU	C1S	2057065	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057066	11/2015	11/02/2015	100.030	100.040	100.1	1
KU	C1S	2057067	11/2015	11/02/2015	99.960	100.040	100.0	1
KU	C1S	2057068	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057069	11/2015	11/02/2015	99.990	99.950	100.1	1
KU	C1S	2057070	11/2015	11/02/2015	100.030	100.040	100.1	1
KU	C1S	2057071	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057072	11/2015	11/02/2015	99.970	99.970	100.0	1
KU	C1S	2057073	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057074	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057075	11/2015	11/02/2015	99.970	100.040	100.0	1
KU	C1S	2057076	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057077	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057078	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057079	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057080	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057081	11/2015	11/02/2015	99.960	100.010	100.1	1

KU	C1S	2057082	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057083	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057084	11/2015	11/02/2015	100.010	100.000	100.1	1
KU	C1S	2057085	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057086	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057087	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057088	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057089	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057090	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057091	11/2015	11/02/2015	100.050	100.020	100.0	1
KU	C1S	2057092	11/2015	11/02/2015	100.030	99.980	100.0	1
KU	C1S	2057093	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057094	11/2015	11/02/2015	100.010	100.000	100.1	1
KU	C1S	2057095	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057096	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057097	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057098	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057099	11/2015	11/02/2015	99.970	100.020	100.0	1
KU	C1S	2057100	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057101	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057102	11/2015	11/02/2015	99.960	100.010	100.2	1
KU	C1S	2057103	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057104	11/2015	11/02/2015	100.020	100.050	100.1	1
KU	C1S	2057105	11/2015	11/02/2015	100.010	99.990	100.1	1
KU	C1S	2057106	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057107	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057108	11/2015	11/02/2015	100.030	99.990	100.0	1
KU	C1S	2057109	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057110	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057111	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057112	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057113	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057114	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057115	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057116	11/2015	11/02/2015	100.010	99.980	100.0	1
KU	C1S	2057117	11/2015	11/02/2015	99.980	99.980	100.0	1
KU	C1S	2057118	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057119	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057120	11/2015	11/02/2015	100.030	100.060	100.0	1
KU	C1S	2057121	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057122	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057123	11/2015	11/02/2015	100.000	100.000	100.1	1

KU	C1S	2057124	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057125	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057126	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057127	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057128	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057129	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057130	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057131	11/2015	11/02/2015	100.040	100.010	100.1	1
KU	C1S	2057132	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057133	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057134	11/2015	11/02/2015	99.980	99.980	100.0	1
KU	C1S	2057135	11/2015	11/02/2015	100.020	100.000	100.1	1
KU	C1S	2057136	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057137	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057138	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057139	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057140	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057141	11/2015	11/02/2015	99.970	99.990	100.0	1
KU	C1S	2057142	11/2015	11/02/2015	99.970	100.030	100.1	1
KU	C1S	2057143	11/2015	11/02/2015	100.030	99.960	100.0	1
KU	C1S	2057144	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057145	11/2015	11/02/2015	99.980	100.000	100.0	1
KU	C1S	2057146	11/2015	11/02/2015	100.040	100.010	100.1	1
KU	C1S	2057147	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057148	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057149	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057150	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057151	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057152	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057153	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057154	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057155	11/2015	11/02/2015	99.970	100.030	100.0	1
KU	C1S	2057156	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057157	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057158	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057159	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057160	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057161	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057162	11/2015	11/02/2015	99.990	99.960	100.0	1
KU	C1S	2057163	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057164	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057165	11/2015	11/02/2015	100.010	100.030	100.1	1

KU	C1S	2057166	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057167	11/2015	11/02/2015	100.030	99.980	100.0	1
KU	C1S	2057168	11/2015	11/02/2015	100.040	100.040	100.0	1
KU	C1S	2057169	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057170	11/2015	11/02/2015	100.030	100.050	100.1	1
KU	C1S	2057171	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057172	11/2015	11/02/2015	99.980	100.010	100.1	1
KU	C1S	2057173	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057174	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057175	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057176	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057177	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057178	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057179	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057180	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057181	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057182	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057183	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057184	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057185	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057186	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057187	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057188	11/2015	11/02/2015	99.980	100.000	100.0	1
KU	C1S	2057189	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057190	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057191	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057192	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057193	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057194	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057195	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057196	11/2015	11/02/2015	100.010	100.000	100.1	1
KU	C1S	2057197	11/2015	11/02/2015	100.030	100.060	100.0	1
KU	C1S	2057198	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057199	11/2015	11/02/2015	99.980	100.050	100.1	1
KU	C1S	2057200	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057201	11/2015	11/02/2015	99.990	99.950	100.0	1
KU	C1S	2057202	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057203	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057204	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057205	11/2015	11/02/2015	100.000	100.060	100.0	1
KU	C1S	2057206	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057207	11/2015	11/02/2015	100.010	100.060	100.0	1

KU	C1S	2057208	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057209	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057210	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057211	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057212	11/2015	11/02/2015	100.040	100.010	100.0	1
KU	C1S	2057213	11/2015	11/02/2015	99.950	100.060	100.0	1
KU	C1S	2057214	11/2015	11/02/2015	99.960	99.990	100.0	1
KU	C1S	2057215	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057216	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057217	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057218	11/2015	11/02/2015	100.040	100.040	100.0	1
KU	C1S	2057219	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057220	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057221	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057222	11/2015	11/02/2015	100.020	100.070	100.1	1
KU	C1S	2057223	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057224	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057225	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057226	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057227	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057228	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057229	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057230	11/2015	11/02/2015	100.020	99.950	100.0	1
KU	C1S	2057231	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057232	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057233	11/2015	11/02/2015	99.970	100.060	100.1	1
KU	C1S	2057234	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057235	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057236	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057237	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057238	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057239	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057240	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057241	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057242	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057243	11/2015	11/02/2015	100.030	100.050	100.1	1
KU	C1S	2057244	11/2015	11/02/2015	100.040	100.040	100.1	1
KU	C1S	2057245	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057246	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057247	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057248	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057249	11/2015	11/02/2015	100.010	100.020	100.0	1

KU	C1S	2057250	11/2015	11/02/2015	100.030	99.990	100.1	1
KU	C1S	2057251	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057252	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057253	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057254	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057255	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057256	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057257	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057258	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057259	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057260	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057261	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057262	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057263	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057264	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057265	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057266	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057267	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057268	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057269	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057270	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057271	11/2015	11/02/2015	99.970	100.040	100.0	1
KU	C1S	2057272	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057273	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057274	11/2015	11/02/2015	99.960	100.020	100.1	1
KU	C1S	2057275	11/2015	11/02/2015	99.960	100.040	100.1	1
KU	C1S	2057276	11/2015	11/02/2015	99.980	100.000	100.0	1
KU	C1S	2057277	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057278	11/2015	11/02/2015	100.040	100.040	100.0	1
KU	C1S	2057279	11/2015	11/02/2015	99.990	99.990	100.1	1
KU	C1S	2057280	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057281	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057282	11/2015	11/02/2015	100.020	100.000	100.1	1
KU	C1S	2057283	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057284	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057285	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057286	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057287	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057288	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057289	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057290	11/2015	11/02/2015	99.970	100.060	100.1	1
KU	C1S	2057291	11/2015	11/02/2015	100.000	100.030	100.1	1

KU	C1S	2057292	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057293	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057294	11/2015	11/02/2015	99.970	100.060	100.0	1
KU	C1S	2057295	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057296	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057297	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057298	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057299	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057300	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2057301	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057302	11/2015	11/02/2015	99.980	99.980	100.0	1
KU	C1S	2057303	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057304	11/2015	11/02/2015	99.970	100.000	100.1	1
KU	C1S	2057305	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057306	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057307	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057308	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057309	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057310	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057311	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057312	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057313	11/2015	11/02/2015	100.000	100.000	100.1	1
KU	C1S	2057314	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057315	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057316	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057317	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057318	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057319	11/2015	11/02/2015	99.960	100.020	100.1	1
KU	C1S	2057320	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057321	11/2015	11/02/2015	100.000	99.980	100.1	1
KU	C1S	2057322	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057323	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057324	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057325	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057326	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057327	11/2015	11/02/2015	99.990	99.970	100.0	1
KU	C1S	2057328	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057329	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057330	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057331	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2057332	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057333	11/2015	11/02/2015	99.980	100.030	100.0	1

KU	C1S	2057334	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057335	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057336	11/2015	11/02/2015	99.980	100.050	100.1	1
KU	C1S	2057337	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057338	11/2015	11/02/2015	99.990	99.990	100.1	1
KU	C1S	2057339	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057340	11/2015	11/02/2015	100.020	100.050	100.0	1
KU	C1S	2057341	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057342	11/2015	11/02/2015	100.050	100.050	100.0	1
KU	C1S	2057343	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057344	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057345	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057346	11/2015	11/02/2015	100.030	100.030	100.1	1
KU	C1S	2057347	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057348	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057349	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057350	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057351	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057352	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057353	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057354	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057355	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057356	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057357	11/2015	11/02/2015	100.040	100.060	100.1	1
KU	C1S	2057358	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057359	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057360	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057361	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057362	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057363	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057364	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057365	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057366	11/2015	11/02/2015	100.020	100.080	100.1	1
KU	C1S	2057367	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057368	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057369	11/2015	11/02/2015	100.020	100.070	100.1	1
KU	C1S	2057370	11/2015	11/02/2015	100.030	100.070	100.0	1
KU	C1S	2057371	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057372	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057373	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057374	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057375	11/2015	11/02/2015	100.000	100.050	100.1	1

KU	C1S	2057376	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057377	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057378	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057379	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057380	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057381	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057382	11/2015	11/02/2015	99.960	100.020	100.1	1
KU	C1S	2057383	11/2015	11/02/2015	100.020	100.050	100.1	1
KU	C1S	2057384	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057385	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057386	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057387	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057388	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057389	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057390	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057391	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057392	11/2015	11/02/2015	99.980	100.000	100.0	1
KU	C1S	2057393	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057394	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057395	11/2015	11/02/2015	99.990	99.970	100.1	1
KU	C1S	2057396	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057397	11/2015	11/02/2015	99.980	100.050	100.0	1
KU	C1S	2057398	11/2015	11/02/2015	100.020	100.060	100.1	1
KU	C1S	2057399	11/2015	11/02/2015	100.020	99.960	100.0	1
KU	C1S	2057400	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057401	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057402	11/2015	11/02/2015	100.000	99.990	100.1	1
KU	C1S	2057403	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057404	11/2015	11/02/2015	100.040	100.010	100.1	1
KU	C1S	2057405	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057406	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057407	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057408	11/2015	11/02/2015	100.010	100.070	100.1	1
KU	C1S	2057409	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057410	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057411	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057412	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057413	11/2015	11/02/2015	100.030	100.090	100.0	1
KU	C1S	2057414	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057415	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057416	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057417	11/2015	11/02/2015	100.000	100.000	100.0	1

KU	C1S	2057418	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057419	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057420	11/2015	11/02/2015	100.020	100.080	100.0	1
KU	C1S	2057421	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057422	11/2015	11/02/2015	100.040	100.040	100.0	1
KU	C1S	2057423	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057424	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057425	11/2015	11/02/2015	99.960	100.040	100.1	1
KU	C1S	2057426	11/2015	11/02/2015	99.980	100.070	100.1	1
KU	C1S	2057427	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057428	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057429	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057430	11/2015	11/02/2015	99.970	100.070	100.1	1
KU	C1S	2057431	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057432	11/2015	11/02/2015	99.970	100.020	100.0	1
KU	C1S	2057433	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057434	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057435	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057436	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057437	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057438	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057439	11/2015	11/02/2015	100.040	100.030	100.1	1
KU	C1S	2057440	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057441	11/2015	11/02/2015	99.980	100.050	100.0	1
KU	C1S	2057442	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057443	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057444	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057445	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057446	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057447	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057448	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057449	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057450	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057451	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057452	11/2015	11/02/2015	99.970	100.030	100.1	1
KU	C1S	2057453	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057454	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057455	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057456	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057457	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057458	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057459	11/2015	11/02/2015	100.010	100.000	100.0	1

KU	C1S	2057460	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057461	11/2015	11/02/2015	100.020	100.060	100.1	1
KU	C1S	2057462	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057463	11/2015	11/02/2015	99.960	100.020	100.0	1
KU	C1S	2057464	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057465	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057466	11/2015	11/02/2015	100.030	99.990	100.0	1
KU	C1S	2057467	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057468	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057469	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057470	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057471	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057472	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057473	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057474	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057475	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057476	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2057477	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057478	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057479	11/2015	11/02/2015	100.030	99.980	100.0	1
KU	C1S	2057480	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057481	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057482	11/2015	11/02/2015	99.970	100.040	100.0	1
KU	C1S	2057483	11/2015	11/02/2015	100.050	100.020	100.1	1
KU	C1S	2057484	11/2015	11/02/2015	99.970	100.020	100.0	1
KU	C1S	2057485	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057486	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057487	11/2015	11/02/2015	100.040	99.990	100.0	1
KU	C1S	2057488	11/2015	11/02/2015	99.970	99.990	100.0	1
KU	C1S	2057489	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057490	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057491	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057492	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057493	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057494	11/2015	11/02/2015	99.970	100.030	100.0	1
KU	C1S	2057495	11/2015	11/02/2015	99.960	100.020	100.0	1
KU	C1S	2057496	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057497	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057498	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057499	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057500	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057501	11/2015	11/02/2015	99.930	100.010	100.0	1

KU	C1S	2057502	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057503	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057504	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057505	11/2015	11/02/2015	100.010	99.960	100.1	1
KU	C1S	2057506	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057507	11/2015	11/02/2015	100.030	100.030	100.1	1
KU	C1S	2057508	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057509	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057510	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057511	11/2015	11/02/2015	99.980	100.010	100.1	1
KU	C1S	2057512	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057513	11/2015	11/02/2015	99.990	100.070	100.0	1
KU	C1S	2057514	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057515	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057516	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057517	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057518	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057519	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057520	11/2015	11/02/2015	99.970	99.960	100.0	1
KU	C1S	2057521	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057522	11/2015	11/02/2015	99.990	99.930	100.0	1
KU	C1S	2057523	11/2015	11/02/2015	99.990	99.970	100.0	1
KU	C1S	2057524	11/2015	11/02/2015	100.030	100.000	100.1	1
KU	C1S	2057525	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057526	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057527	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057528	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057529	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057530	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057531	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057532	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057533	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057534	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057535	11/2015	11/02/2015	100.010	99.980	100.0	1
KU	C1S	2057536	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057537	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057538	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057539	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057540	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057541	11/2015	11/02/2015	99.980	100.090	100.0	1
KU	C1S	2057542	11/2015	11/02/2015	99.980	99.990	100.0	1
KU	C1S	2057543	11/2015	11/02/2015	99.980	100.040	100.0	1

KU	C1S	2057544	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057545	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057546	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057547	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057548	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057549	11/2015	11/02/2015	99.970	100.050	100.1	1
KU	C1S	2057550	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057551	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057552	11/2015	11/02/2015	99.940	100.060	100.1	1
KU	C1S	2057553	11/2015	11/02/2015	99.970	99.990	100.0	1
KU	C1S	2057554	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057555	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057556	11/2015	11/02/2015	100.040	100.030	100.0	1
KU	C1S	2057557	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057558	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057559	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057560	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057561	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057562	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057563	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057564	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057565	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057566	11/2015	11/02/2015	100.040	100.050	100.1	1
KU	C1S	2057567	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057568	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057569	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057570	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057571	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057572	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057573	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057574	11/2015	11/02/2015	100.000	100.070	100.1	1
KU	C1S	2057575	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057576	11/2015	11/02/2015	100.040	100.030	100.0	1
KU	C1S	2057577	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057578	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057579	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057580	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057581	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057582	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057583	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057584	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057585	11/2015	11/02/2015	100.020	100.040	100.1	1

KU	C1S	2057586	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057587	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057588	11/2015	11/02/2015	100.040	100.000	100.0	1
KU	C1S	2057589	11/2015	11/02/2015	100.040	99.990	100.0	1
KU	C1S	2057590	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057591	11/2015	11/02/2015	100.020	99.990	100.0	1
KU	C1S	2057592	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057593	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057594	11/2015	11/02/2015	100.000	100.010	100.1	1
KU	C1S	2057595	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057596	11/2015	11/02/2015	99.970	99.990	100.0	1
KU	C1S	2057597	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057598	11/2015	11/02/2015	99.960	100.040	100.1	1
KU	C1S	2057599	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057600	11/2015	11/02/2015	99.980	100.070	100.1	1
KU	C1S	2057601	11/2015	11/02/2015	99.960	100.050	100.0	1
KU	C1S	2057602	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057603	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057604	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057605	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057606	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057607	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057608	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057609	11/2015	11/02/2015	99.970	100.030	100.0	1
KU	C1S	2057610	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057611	11/2015	11/02/2015	99.960	100.060	100.0	1
KU	C1S	2057612	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057613	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057614	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057615	11/2015	11/02/2015	99.970	100.050	100.1	1
KU	C1S	2057616	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057617	11/2015	11/02/2015	99.970	100.000	100.0	1
KU	C1S	2057618	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057619	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057620	11/2015	11/02/2015	100.030	99.970	100.1	1
KU	C1S	2057621	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057622	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057623	11/2015	11/02/2015	100.000	100.080	100.0	1
KU	C1S	2057624	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057625	11/2015	11/02/2015	100.030	99.990	100.0	1
KU	C1S	2057626	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057627	11/2015	11/02/2015	100.020	100.000	100.0	1

KU	C1S	2057628	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057629	11/2015	11/02/2015	100.030	100.000	100.1	1
KU	C1S	2057630	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057631	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057632	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057633	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057634	11/2015	11/02/2015	99.970	100.020	100.1	1
KU	C1S	2057635	11/2015	11/02/2015	100.020	100.060	100.1	1
KU	C1S	2057636	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057637	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057638	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057639	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057640	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057641	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057642	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057643	11/2015	11/02/2015	100.050	100.010	100.1	1
KU	C1S	2057644	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057645	11/2015	11/02/2015	100.030	100.040	100.1	1
KU	C1S	2057646	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057647	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057648	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057649	11/2015	11/02/2015	100.020	100.060	100.0	1
KU	C1S	2057650	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057651	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057652	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057653	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057654	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057655	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057656	11/2015	11/02/2015	100.000	99.990	100.1	1
KU	C1S	2057657	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057658	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057659	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057660	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057661	11/2015	11/02/2015	99.970	99.960	100.0	1
KU	C1S	2057662	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057663	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057664	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057665	11/2015	11/02/2015	99.930	100.020	100.0	1
KU	C1S	2057666	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057667	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057668	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057669	11/2015	11/02/2015	99.970	99.980	100.0	1

KU	C1S	2057670	11/2015	11/02/2015	100.030	100.030	100.1	1
KU	C1S	2057671	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057672	11/2015	11/02/2015	99.980	100.000	100.1	1
KU	C1S	2057673	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057674	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057675	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057676	11/2015	11/02/2015	100.010	100.060	100.0	1
KU	C1S	2057677	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2057678	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057679	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2057680	11/2015	11/02/2015	100.010	100.060	100.1	1
KU	C1S	2057681	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057682	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057683	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057684	11/2015	11/02/2015	99.990	100.050	100.0	1
KU	C1S	2057685	11/2015	11/02/2015	99.970	100.070	100.1	1
KU	C1S	2057686	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057687	11/2015	11/02/2015	100.000	100.050	100.0	1
KU	C1S	2057688	11/2015	11/02/2015	99.960	99.970	100.0	1
KU	C1S	2057689	11/2015	11/02/2015	99.970	100.070	100.1	1
KU	C1S	2057690	11/2015	11/02/2015	100.020	99.970	100.1	1
KU	C1S	2057691	11/2015	11/02/2015	100.000	100.060	100.1	1
KU	C1S	2057692	11/2015	11/02/2015	99.970	100.070	100.0	1
KU	C1S	2057693	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057694	11/2015	11/02/2015	99.970	100.030	100.1	1
KU	C1S	2057695	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057696	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057697	11/2015	11/02/2015	100.040	100.040	100.0	1
KU	C1S	2057698	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057699	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2057700	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057701	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057702	11/2015	11/02/2015	100.010	100.050	100.0	1
KU	C1S	2057703	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057704	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057705	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057706	11/2015	11/02/2015	100.050	100.030	100.0	1
KU	C1S	2057707	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057708	11/2015	11/02/2015	99.990	100.070	100.0	1
KU	C1S	2057709	11/2015	11/02/2015	100.030	100.060	100.1	1
KU	C1S	2057710	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057711	11/2015	11/02/2015	99.970	100.010	100.1	1

KU	C1S	2057712	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057713	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057714	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057715	11/2015	11/02/2015	100.030	100.040	100.1	1
KU	C1S	2057716	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057717	11/2015	11/02/2015	100.000	100.060	100.1	1
KU	C1S	2057718	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057719	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057720	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057721	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057722	11/2015	11/02/2015	100.000	100.040	100.1	1
KU	C1S	2057723	11/2015	11/02/2015	99.970	100.050	100.0	1
KU	C1S	2057724	11/2015	11/02/2015	100.000	100.060	100.0	1
KU	C1S	2057725	11/2015	11/02/2015	100.010	100.070	100.0	1
KU	C1S	2057726	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057727	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057728	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057729	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057730	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057731	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057732	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057733	11/2015	11/02/2015	99.960	100.050	100.0	1
KU	C1S	2057734	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057735	11/2015	11/02/2015	100.030	100.000	100.0	1
KU	C1S	2057736	11/2015	11/02/2015	99.970	100.020	100.0	1
KU	C1S	2057737	11/2015	11/02/2015	99.970	100.050	100.1	1
KU	C1S	2057738	11/2015	11/02/2015	100.030	100.040	100.0	1
KU	C1S	2057739	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057740	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057741	11/2015	11/02/2015	100.010	100.060	100.1	1
KU	C1S	2057742	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057743	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057744	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057745	11/2015	11/02/2015	100.000	100.050	100.1	1
KU	C1S	2057746	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057747	11/2015	11/02/2015	100.020	100.020	100.0	1
KU	C1S	2057748	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057749	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057750	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057751	11/2015	11/02/2015	100.010	100.000	100.1	1
KU	C1S	2057752	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057753	11/2015	11/02/2015	100.020	100.030	100.1	1

KU	C1S	2057754	11/2015	11/02/2015	99.960	100.030	100.0	1
KU	C1S	2057755	11/2015	11/02/2015	100.070	100.010	100.0	1
KU	C1S	2057756	11/2015	11/02/2015	100.000	100.040	100.0	1
KU	C1S	2057757	11/2015	11/02/2015	100.020	100.030	100.0	1
KU	C1S	2057758	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057759	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057760	11/2015	11/02/2015	100.000	100.060	100.0	1
KU	C1S	2057761	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057762	11/2015	11/02/2015	100.010	100.060	100.1	1
KU	C1S	2057763	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057764	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057765	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057766	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057767	11/2015	11/02/2015	99.980	100.040	100.0	1
KU	C1S	2057768	11/2015	11/02/2015	99.980	100.000	100.1	1
KU	C1S	2057769	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057770	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057771	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057772	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057773	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057774	11/2015	11/02/2015	99.960	100.050	100.1	1
KU	C1S	2057775	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057776	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057777	11/2015	11/02/2015	100.040	100.030	100.1	1
KU	C1S	2057778	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057779	11/2015	11/02/2015	99.990	100.020	100.0	1
KU	C1S	2057780	11/2015	11/02/2015	100.000	100.070	100.1	1
KU	C1S	2057781	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057782	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057783	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057784	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057785	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057786	11/2015	11/02/2015	99.990	100.040	100.0	1
KU	C1S	2057787	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057788	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057789	11/2015	11/02/2015	100.030	100.050	100.1	1
KU	C1S	2057790	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057791	11/2015	11/02/2015	100.020	100.050	100.1	1
KU	C1S	2057792	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057793	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057794	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057795	11/2015	11/02/2015	99.990	100.000	100.0	1

KU	C1S	2057796	11/2015	11/02/2015	100.000	100.070	100.1	1
KU	C1S	2057797	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057798	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057799	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057800	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057801	11/2015	11/02/2015	99.990	100.060	100.1	1
KU	C1S	2057802	11/2015	11/02/2015	99.980	100.060	100.1	1
KU	C1S	2057803	11/2015	11/02/2015	100.020	100.040	100.1	1
KU	C1S	2057804	11/2015	11/02/2015	99.990	100.030	100.1	1
KU	C1S	2057805	11/2015	11/02/2015	100.050	100.000	100.0	1
KU	C1S	2057806	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057807	11/2015	11/02/2015	99.990	100.030	100.0	1
KU	C1S	2057808	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057809	11/2015	11/02/2015	99.970	100.070	100.0	1
KU	C1S	2057810	11/2015	11/02/2015	100.010	100.030	100.0	1
KU	C1S	2057811	11/2015	11/02/2015	100.020	100.050	100.1	1
KU	C1S	2057812	11/2015	11/02/2015	100.020	100.050	100.0	1
KU	C1S	2057813	11/2015	11/02/2015	99.970	100.010	100.0	1
KU	C1S	2057814	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057815	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057816	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057817	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057818	11/2015	11/02/2015	100.020	99.980	100.0	1
KU	C1S	2057819	11/2015	11/02/2015	99.980	100.070	100.0	1
KU	C1S	2057820	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057821	11/2015	11/02/2015	99.940	100.040	100.0	1
KU	C1S	2057822	11/2015	11/02/2015	100.030	100.020	100.1	1
KU	C1S	2057823	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057824	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057825	11/2015	11/02/2015	99.970	100.030	100.0	1
KU	C1S	2057826	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057827	11/2015	11/02/2015	100.010	100.040	100.1	1
KU	C1S	2057828	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057829	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057830	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057831	11/2015	11/02/2015	99.970	99.950	100.0	1
KU	C1S	2057832	11/2015	11/02/2015	99.990	99.980	100.0	1
KU	C1S	2057833	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057834	11/2015	11/02/2015	99.960	99.970	100.0	1
KU	C1S	2057835	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057836	11/2015	11/02/2015	100.020	100.020	100.1	1
KU	C1S	2057837	11/2015	11/02/2015	100.000	99.970	100.0	1

KU	C1S	2057838	11/2015	11/02/2015	99.970	100.030	100.1	1
KU	C1S	2057839	11/2015	11/02/2015	100.000	99.990	100.1	1
KU	C1S	2057840	11/2015	11/02/2015	100.000	100.060	100.1	1
KU	C1S	2057841	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057842	11/2015	11/02/2015	99.980	100.020	100.0	1
KU	C1S	2057843	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057844	11/2015	11/02/2015	99.970	100.050	100.0	1
KU	C1S	2057845	11/2015	11/02/2015	99.980	99.940	100.1	1
KU	C1S	2057846	11/2015	11/02/2015	100.010	99.970	100.1	1
KU	C1S	2057847	11/2015	11/02/2015	100.010	99.970	100.0	1
KU	C1S	2057848	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057849	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057850	11/2015	11/02/2015	100.010	100.020	100.1	1
KU	C1S	2057851	11/2015	11/02/2015	100.020	100.030	100.1	1
KU	C1S	2057852	11/2015	11/02/2015	100.010	100.060	100.1	1
KU	C1S	2057853	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057854	11/2015	11/02/2015	100.030	100.030	100.0	1
KU	C1S	2057855	11/2015	11/02/2015	99.980	100.040	100.1	1
KU	C1S	2057856	11/2015	11/02/2015	99.970	99.970	100.0	1
KU	C1S	2057857	11/2015	11/02/2015	100.030	100.010	100.1	1
KU	C1S	2057858	11/2015	11/02/2015	99.940	99.950	100.1	1
KU	C1S	2057859	11/2015	11/02/2015	100.050	99.970	100.0	1
KU	C1S	2057860	11/2015	11/02/2015	100.000	99.990	100.1	1
KU	C1S	2057861	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057862	11/2015	11/02/2015	99.990	99.970	100.1	1
KU	C1S	2057863	11/2015	11/02/2015	100.020	100.060	100.0	1
KU	C1S	2057864	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057865	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057866	11/2015	11/02/2015	100.020	100.040	100.0	1
KU	C1S	2057867	11/2015	11/02/2015	99.980	100.000	100.0	1
KU	C1S	2057868	11/2015	11/02/2015	100.010	100.030	100.1	1
KU	C1S	2057869	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057870	11/2015	11/02/2015	100.030	99.980	100.1	1
KU	C1S	2057871	11/2015	11/02/2015	99.990	100.010	100.0	1
KU	C1S	2057872	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057873	11/2015	11/02/2015	99.990	99.980	100.0	1
KU	C1S	2057874	11/2015	11/02/2015	100.000	99.970	100.0	1
KU	C1S	2057875	11/2015	11/02/2015	100.030	99.980	100.0	1
KU	C1S	2057876	11/2015	11/02/2015	99.990	99.940	100.0	1
KU	C1S	2057877	11/2015	11/02/2015	100.000	99.970	100.0	1
KU	C1S	2057878	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057879	11/2015	11/02/2015	99.960	100.040	100.1	1

KU	C1S	2057880	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057881	11/2015	11/02/2015	99.960	100.000	100.0	1
KU	C1S	2057882	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057883	11/2015	11/02/2015	99.990	100.010	100.1	1
KU	C1S	2057884	11/2015	11/02/2015	100.020	99.980	100.0	1
KU	C1S	2057885	11/2015	11/02/2015	99.990	100.000	100.1	1
KU	C1S	2057886	11/2015	11/02/2015	99.990	99.970	100.0	1
KU	C1S	2057887	11/2015	11/02/2015	99.990	100.020	100.1	1
KU	C1S	2057888	11/2015	11/02/2015	100.000	100.030	100.1	1
KU	C1S	2057889	11/2015	11/02/2015	99.950	100.020	100.0	1
KU	C1S	2057890	11/2015	11/02/2015	99.990	100.040	100.1	1
KU	C1S	2057891	11/2015	11/02/2015	100.010	100.010	100.1	1
KU	C1S	2057892	11/2015	11/02/2015	99.980	99.980	100.0	1
KU	C1S	2057893	11/2015	11/02/2015	99.990	99.980	100.0	1
KU	C1S	2057894	11/2015	11/02/2015	99.990	100.000	100.0	1
KU	C1S	2057895	11/2015	11/02/2015	100.000	100.010	100.0	1
KU	C1S	2057896	11/2015	11/02/2015	100.010	100.020	100.0	1
KU	C1S	2057897	11/2015	11/02/2015	99.990	99.990	100.0	1
KU	C1S	2057898	11/2015	11/02/2015	99.980	100.050	100.1	1
KU	C1S	2057899	11/2015	11/02/2015	100.020	100.000	100.0	1
KU	C1S	2057900	11/2015	11/02/2015	99.990	100.050	100.1	1
KU	C1S	2057901	11/2015	11/02/2015	100.010	100.010	100.0	1
KU	C1S	2057902	11/2015	11/02/2015	100.060	100.000	100.0	1
KU	C1S	2057903	11/2015	11/02/2015	100.000	99.980	100.0	1
KU	C1S	2057904	11/2015	11/02/2015	100.000	99.970	100.0	1
KU	C1S	2057905	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1S	2057906	11/2015	11/02/2015	100.010	99.990	100.0	1
KU	C1S	2057907	11/2015	11/02/2015	99.990	99.980	100.0	1
KU	C1S	2057908	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057909	11/2015	11/02/2015	100.010	99.980	100.0	1
KU	C1S	2057910	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057911	11/2015	11/02/2015	99.980	100.010	100.0	1
KU	C1S	2057912	11/2015	11/02/2015	99.980	100.030	100.0	1
KU	C1S	2057913	11/2015	11/02/2015	100.030	99.980	100.0	1
KU	C1S	2057914	11/2015	11/02/2015	99.970	99.990	100.0	1
KU	C1S	2057915	11/2015	11/02/2015	100.020	100.050	100.1	1
KU	C1S	2057916	11/2015	11/02/2015	99.970	99.980	100.1	1
KU	C1S	2057917	11/2015	11/02/2015	99.960	100.050	100.1	1
KU	C1S	2057918	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057919	11/2015	11/02/2015	100.020	100.060	100.1	1
KU	C1S	2057920	11/2015	11/02/2015	100.030	100.000	100.1	1
KU	C1S	2057921	11/2015	11/02/2015	99.990	100.030	100.1	1

KU	C1S	2057922	11/2015	11/02/2015	100.030	100.020	100.0	1
KU	C1S	2057923	11/2015	11/02/2015	99.990	99.980	100.0	1
KU	C1S	2057924	11/2015	11/02/2015	100.000	100.020	100.0	1
KU	C1S	2057925	11/2015	11/02/2015	100.010	100.040	100.0	1
KU	C1S	2057926	11/2015	11/02/2015	100.000	100.030	100.0	1
KU	C1S	2057927	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057928	11/2015	11/02/2015	100.020	100.010	100.1	1
KU	C1S	2057929	11/2015	11/02/2015	100.000	100.000	100.1	1
KU	C1S	2057930	11/2015	11/02/2015	99.980	100.020	100.1	1
KU	C1S	2057931	11/2015	11/02/2015	100.000	99.990	100.0	1
KU	C1S	2057932	11/2015	11/02/2015	100.020	100.010	100.0	1
KU	C1S	2057933	11/2015	11/02/2015	99.980	100.030	100.1	1
KU	C1S	2057934	11/2015	11/02/2015	100.000	99.960	100.0	1
KU	C1S	2057935	11/2015	11/02/2015	100.000	100.000	100.0	1
KU	C1S	2057936	11/2015	11/02/2015	100.030	100.010	100.0	1
KU	C1S	2057937	11/2015	11/02/2015	100.000	100.020	100.1	1
KU	C1S	2057938	11/2015	11/02/2015	100.010	100.050	100.1	1
KU	C1S	2057939	11/2015	11/02/2015	100.010	100.000	100.0	1
KU	C1SR	2509251	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509252	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509253	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509254	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509255	06/2015	05/21/2015	100.000	100.000	100.1	1
KU	C1SR	2509256	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509257	06/2015	05/21/2015	99.900	100.100	100.0	1
KU	C1SR	2509258	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509259	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509260	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509261	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509262	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509263	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509264	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509265	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509266	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509267	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509268	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509269	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509270	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509271	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509272	06/2015	05/21/2015	100.000	100.000	100.0	1
KU	C1SR	2509273	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509274	06/2015	05/21/2015	100.000	100.100	100.0	1

KU	C1SR	2509317	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509318	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509319	06/2015	05/21/2015	100.000	100.000	100.0	1
KU	C1SR	2509320	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509321	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509322	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509323	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509324	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509325	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509326	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509327	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509328	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509329	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509330	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509331	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509332	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509333	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509334	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509335	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509336	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509337	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509338	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509339	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509340	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509341	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509342	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509343	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509344	06/2015	05/21/2015	100.000	100.100	99.9	1
KU	C1SR	2509345	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509346	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509347	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509348	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509349	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509350	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509351	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509352	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509353	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509354	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509355	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509356	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509357	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509358	06/2015	05/21/2015	100.000	100.200	100.1	1

KU	C1SR	2509401	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509402	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509403	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509404	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509405	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509406	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509407	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509408	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509409	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509410	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509411	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509412	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509413	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509414	06/2015	05/21/2015	99.900	100.200	100.1	1
KU	C1SR	2509415	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509416	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509417	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509418	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509419	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509420	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509421	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509422	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509423	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509424	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509425	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509426	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509427	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509428	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509429	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509430	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509431	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509432	06/2015	05/21/2015	99.900	100.100	100.1	1
KU	C1SR	2509433	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509434	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509435	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509436	06/2015	05/21/2015	100.000	100.000	100.0	1
KU	C1SR	2509437	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509438	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509439	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509440	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509441	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509442	06/2015	05/21/2015	100.000	100.200	100.1	1

KU	C1SR	2509443	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509444	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509445	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509446	06/2015	05/21/2015	99.900	100.000	100.1	1
KU	C1SR	2509447	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509448	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509449	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509450	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509451	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509452	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509453	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509454	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509455	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509456	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509457	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509458	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509459	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509460	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509461	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509462	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509463	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509464	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509465	06/2015	05/21/2015	99.900	100.100	100.0	1
KU	C1SR	2509466	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509467	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509468	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509469	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509470	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509471	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509472	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509473	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509474	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509475	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509476	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509477	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509478	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509479	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509480	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509481	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509482	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509483	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509484	06/2015	05/21/2015	100.000	100.100	100.1	1

KU	C1SR	2509485	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509486	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509487	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509488	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509489	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509490	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509491	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509492	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509493	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509494	06/2015	05/21/2015	99.900	100.100	100.0	1
KU	C1SR	2509495	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509496	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509497	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509498	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509499	06/2015	05/21/2015	100.000	100.200	100.2	1
KU	C1SR	2509500	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509501	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509502	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509503	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509504	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509505	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509506	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509507	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509508	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509509	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509510	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509511	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509512	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509513	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509514	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509515	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509516	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509517	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509518	06/2015	05/21/2015	100.000	100.100	100.2	1
KU	C1SR	2509519	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509520	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509521	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509522	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509523	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509524	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509525	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509526	06/2015	05/21/2015	100.000	100.100	100.0	1

KU	C1SR	2509569	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509570	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509571	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509572	06/2015	05/21/2015	99.900	100.000	100.0	1
KU	C1SR	2509573	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509574	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509575	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509576	06/2015	05/21/2015	99.900	100.200	100.1	1
KU	C1SR	2509577	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509578	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509579	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509580	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509581	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509582	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509583	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509584	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509585	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509586	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509587	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509588	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509589	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509590	06/2015	05/21/2015	100.000	100.000	100.1	1
KU	C1SR	2509591	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509592	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509593	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509594	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509595	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509596	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509597	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509598	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509599	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509600	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509601	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509602	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509603	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509604	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509605	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509606	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509607	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509608	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509609	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509610	06/2015	05/21/2015	100.000	100.200	100.0	1

KU	C1SR	2509653	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509654	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509655	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509656	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509657	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509658	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509659	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509660	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509661	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509662	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509663	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509664	06/2015	05/21/2015	99.900	100.100	100.0	1
KU	C1SR	2509665	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509666	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509667	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509668	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509669	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509670	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509671	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509672	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509673	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509674	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509675	06/2015	05/21/2015	100.000	100.100	100.2	1
KU	C1SR	2509676	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509677	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509678	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509679	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509680	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509681	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509682	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509683	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509684	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509685	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509686	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509687	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509688	06/2015	05/21/2015	100.000	100.200	100.2	1
KU	C1SR	2509689	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509690	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509691	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509692	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509693	06/2015	05/21/2015	99.900	100.100	100.1	1
KU	C1SR	2509694	06/2015	05/21/2015	100.000	100.200	100.0	1

KU	C1SR	2509821	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509822	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509823	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509824	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509825	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509826	06/2015	05/21/2015	99.900	100.100	100.1	1
KU	C1SR	2509827	06/2015	05/21/2015	100.000	100.000	100.0	1
KU	C1SR	2509828	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509829	06/2015	05/21/2015	100.000	100.100	100.2	1
KU	C1SR	2509830	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509831	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509832	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509833	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509834	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509835	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509836	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509837	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509838	06/2015	05/21/2015	100.000	100.200	100.2	1
KU	C1SR	2509839	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509840	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509841	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509842	06/2015	05/21/2015	100.000	100.200	100.0	1
KU	C1SR	2509843	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509844	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509845	06/2015	05/21/2015	100.000	100.200	100.1	1
KU	C1SR	2509846	06/2015	05/21/2015	100.000	100.100	100.0	1
KU	C1SR	2509847	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509848	06/2015	05/21/2015	99.900	100.200	100.0	1
KU	C1SR	2509849	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509850	06/2015	05/21/2015	100.000	100.100	100.1	1
KU	C1SR	2509851	06/2015	05/20/2015	100.000	100.000	100.1	1
KU	C1SR	2509852	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509853	06/2015	05/20/2015	100.000	100.200	100.1	1
KU	C1SR	2509854	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509855	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509856	06/2015	05/20/2015	100.000	100.100	100.0	1
KU	C1SR	2509857	06/2015	05/20/2015	100.000	100.200	100.2	1
KU	C1SR	2509858	06/2015	05/20/2015	100.000	100.100	100.2	1
KU	C1SR	2509859	06/2015	05/20/2015	100.000	100.100	100.2	1
KU	C1SR	2509860	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509861	06/2015	05/20/2015	100.000	100.100	100.0	1
KU	C1SR	2509862	06/2015	05/20/2015	100.000	100.200	100.1	1

KU	C1SR	2509905	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509906	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509907	06/2015	05/20/2015	100.000	100.200	100.1	1
KU	C1SR	2509908	06/2015	05/20/2015	100.000	100.000	100.2	1
KU	C1SR	2509909	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509910	06/2015	05/20/2015	100.000	100.200	100.1	1
KU	C1SR	2509911	06/2015	05/20/2015	100.000	100.200	100.2	1
KU	C1SR	2509912	06/2015	05/20/2015	100.000	100.200	100.2	1
KU	C1SR	2509913	06/2015	05/20/2015	100.000	100.100	100.2	1
KU	C1SR	2509914	06/2015	05/20/2015	100.000	100.000	100.1	1
KU	C1SR	2509915	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509916	06/2015	05/20/2015	100.000	100.100	100.2	1
KU	C1SR	2509917	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509918	06/2015	05/20/2015	100.000	100.200	100.2	1
KU	C1SR	2509919	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509920	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509921	06/2015	05/20/2015	100.000	100.200	100.1	1
KU	C1SR	2509922	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509923	06/2015	05/20/2015	100.000	100.200	100.1	1
KU	C1SR	2509924	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509925	06/2015	05/20/2015	100.000	100.000	100.1	1
KU	C1SR	2509926	06/2015	05/20/2015	100.000	100.200	100.2	1
KU	C1SR	2509927	06/2015	05/20/2015	99.900	100.000	100.1	1
KU	C1SR	2509928	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C1SR	2509929	06/2015	05/20/2015	100.000	100.100	100.2	1
KU	C1SR	2509930	06/2015	05/20/2015	100.000	100.100	100.1	1
KU	C2SOS	2400120	09/2015	08/11/2015	100.000	100.000	100.1	1
KU	C2SOS	2400121	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400122	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400123	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400124	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400125	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400126	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400127	09/2015	08/11/2015	100.000	100.000	100.1	1
KU	C2SOS	2400128	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400129	09/2015	08/11/2015	100.000	100.100	100.1	1
KU	C2SOS	2400130	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400131	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400132	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400133	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400134	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400135	09/2015	08/11/2015	100.000	100.000	100.0	1

KU	C2SOS	2400136	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400137	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400138	09/2015	08/11/2015	100.000	100.100	100.0	1
KU	C2SOS	2400139	09/2015	08/11/2015	100.000	100.100	100.0	1
KU	C2SOS	2400140	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400141	09/2015	08/11/2015	100.000	100.000	100.1	1
KU	C2SOS	2400142	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400143	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400144	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400145	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400146	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400147	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400148	09/2015	07/22/2015	100.000	99.900	100.0	1
KU	C2SOS	2400149	09/2015	08/11/2015	100.000	100.100	100.0	1
KU	C2SOS	2400150	09/2015	08/11/2015	100.000	100.000	100.0	1
KU	C2SOS	2400151	09/2015	08/11/2015	100.000	100.000	100.1	1
KU	C2SOS	2400524	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400525	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400526	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400527	10/2015	10/13/2015	100.020	99.980	100.0	1
KU	C2SOS	2400528	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400529	10/2015	10/13/2015	100.020	99.980	100.0	1
KU	C2SOS	2400530	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400531	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400532	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400533	10/2015	10/13/2015	100.040	100.090	100.0	1
KU	C2SOS	2400534	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400535	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400536	10/2015	10/13/2015	100.040	99.980	100.0	1
KU	C2SOS	2400537	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400538	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400539	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400540	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400541	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400542	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400543	10/2015	10/13/2015	100.020	100.020	100.0	1
KU	C2SOS	2400544	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400545	10/2015	10/13/2015	100.040	100.020	100.0	1
KU	C2SOS	2400546	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400547	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400548	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400549	10/2015	10/13/2015	100.040	100.020	100.0	1

KU	C2SOS	2400550	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400551	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400552	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400553	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400554	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400555	10/2015	10/13/2015	100.040	100.030	100.0	1
KU	C2SOS	2400556	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400557	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400558	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400559	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400560	10/2015	10/13/2015	100.030	100.020	100.1	1
KU	C2SOS	2400561	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400562	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400563	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400564	10/2015	10/13/2015	100.020	100.070	100.1	1
KU	C2SOS	2400565	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400566	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400567	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400568	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400569	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400570	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400571	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400572	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400573	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400574	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400575	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400576	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400577	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400578	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400579	10/2015	10/13/2015	100.020	99.960	100.0	1
KU	C2SOS	2400580	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400581	10/2015	10/13/2015	100.030	100.020	100.0	1
KU	C2SOS	2400582	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400583	10/2015	10/13/2015	100.020	100.050	100.1	1
KU	C2SOS	2400584	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400585	10/2015	10/13/2015	100.020	99.940	100.0	1
KU	C2SOS	2400586	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400587	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400588	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400589	10/2015	10/13/2015	100.030	99.990	100.0	1
KU	C2SOS	2400590	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400591	10/2015	10/13/2015	100.030	99.990	100.0	1

KU	C2SOS	2400592	10/2015	10/13/2015	100.020	100.030	100.0	1
KU	C2SOS	2400593	10/2015	10/13/2015	100.040	100.000	100.0	1
KU	C2SOS	2400594	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400595	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400596	10/2015	10/13/2015	100.020	100.080	100.0	1
KU	C2SOS	2400597	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400598	10/2015	10/13/2015	100.020	99.980	100.0	1
KU	C2SOS	2400599	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400600	10/2015	10/13/2015	100.030	100.090	100.0	1
KU	C2SOS	2400601	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400602	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400603	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400604	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400605	10/2015	10/13/2015	100.020	100.070	100.0	1
KU	C2SOS	2400606	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400607	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400608	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400609	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400610	10/2015	10/13/2015	100.040	100.010	100.0	1
KU	C2SOS	2400611	10/2015	10/13/2015	100.030	100.020	100.0	1
KU	C2SOS	2400612	10/2015	10/13/2015	100.030	100.120	100.0	1
KU	C2SOS	2400613	10/2015	10/13/2015	100.040	99.950	100.0	1
KU	C2SOS	2400614	10/2015	10/13/2015	100.030	99.910	100.0	1
KU	C2SOS	2400615	10/2015	10/13/2015	100.040	99.910	100.0	1
KU	C2SOS	2400616	10/2015	10/13/2015	100.050	100.120	100.1	1
KU	C2SOS	2400617	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400618	10/2015	10/13/2015	100.030	100.070	100.1	1
KU	C2SOS	2400619	10/2015	10/13/2015	100.040	100.110	100.0	1
KU	C2SOS	2400620	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400621	10/2015	10/13/2015	100.050	100.010	100.0	1
KU	C2SOS	2400622	10/2015	10/13/2015	100.030	100.070	100.1	1
KU	C2SOS	2400623	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400624	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400625	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400626	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400627	10/2015	10/13/2015	100.040	99.950	100.0	1
KU	C2SOS	2400628	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400629	10/2015	10/13/2015	100.040	100.120	100.0	1
KU	C2SOS	2400630	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400631	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400632	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400633	10/2015	10/13/2015	100.030	99.980	100.0	1

KU	C2SOS	2400634	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400635	10/2015	10/13/2015	100.010	100.010	100.0	1
KU	C2SOS	2400636	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400637	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400638	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400639	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400640	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400641	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400642	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400643	10/2015	10/13/2015	100.030	100.010	100.0	1
KU	C2SOS	2400644	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400645	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400646	10/2015	10/13/2015	100.040	100.010	100.0	1
KU	C2SOS	2400647	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400648	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400649	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400650	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400651	10/2015	10/13/2015	100.020	100.070	100.0	1
KU	C2SOS	2400652	10/2015	10/13/2015	100.020	99.970	100.0	1
KU	C2SOS	2400653	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400654	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400655	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400656	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400657	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400658	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400659	10/2015	10/13/2015	100.040	100.010	100.0	1
KU	C2SOS	2400660	10/2015	10/13/2015	100.020	99.970	100.0	1
KU	C2SOS	2400661	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400662	10/2015	10/13/2015	100.020	100.040	100.0	1
KU	C2SOS	2400663	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400664	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400665	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400666	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400667	10/2015	10/13/2015	100.040	99.990	100.0	1
KU	C2SOS	2400668	10/2015	10/13/2015	100.030	100.020	100.0	1
KU	C2SOS	2400669	10/2015	10/13/2015	100.040	100.040	100.0	1
KU	C2SOS	2400670	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400671	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400672	10/2015	10/13/2015	100.020	99.980	100.0	1
KU	C2SOS	2400673	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400674	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400675	10/2015	10/13/2015	100.020	100.010	100.0	1

KU	C2SOS	2400676	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400677	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400678	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400679	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400680	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400681	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400682	10/2015	10/13/2015	100.030	99.960	100.0	1
KU	C2SOS	2400683	10/2015	10/13/2015	100.020	100.070	100.0	1
KU	C2SOS	2400684	10/2015	10/13/2015	100.040	99.980	100.0	1
KU	C2SOS	2400685	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400686	10/2015	10/13/2015	100.020	99.970	100.0	1
KU	C2SOS	2400687	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400688	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400689	10/2015	10/13/2015	100.030	100.090	100.0	1
KU	C2SOS	2400690	10/2015	10/13/2015	100.030	100.080	100.0	1
KU	C2SOS	2400691	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400692	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400693	10/2015	10/13/2015	100.020	100.060	100.0	1
KU	C2SOS	2400694	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400695	10/2015	10/13/2015	100.040	99.990	100.0	1
KU	C2SOS	2400696	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400697	10/2015	10/13/2015	100.030	100.020	100.0	1
KU	C2SOS	2400698	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400699	10/2015	10/13/2015	100.030	99.960	100.0	1
KU	C2SOS	2400700	10/2015	10/13/2015	100.020	100.050	100.0	1
KU	C2SOS	2400701	10/2015	10/13/2015	100.020	100.000	100.0	1
KU	C2SOS	2400702	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400703	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400704	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400705	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400706	10/2015	10/13/2015	100.040	100.030	100.0	1
KU	C2SOS	2400707	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400708	10/2015	10/13/2015	100.040	100.030	100.0	1
KU	C2SOS	2400709	10/2015	10/13/2015	100.020	99.970	100.0	1
KU	C2SOS	2400710	10/2015	10/13/2015	100.040	100.060	100.0	1
KU	C2SOS	2400711	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400712	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400713	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400714	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400715	10/2015	10/13/2015	100.020	100.110	100.0	1
KU	C2SOS	2400716	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400717	10/2015	10/13/2015	100.030	100.060	100.1	1

KU	C2SOS	2400718	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400719	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400720	10/2015	10/13/2015	100.030	100.050	100.0	1
KU	C2SOS	2400721	10/2015	10/13/2015	100.040	100.020	100.0	1
KU	C2SOS	2400722	10/2015	10/13/2015	100.030	99.960	100.0	1
KU	C2SOS	2400723	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400724	10/2015	10/13/2015	100.030	100.060	100.1	1
KU	C2SOS	2400725	10/2015	10/13/2015	100.040	100.020	100.0	1
KU	C2SOS	2400726	10/2015	10/13/2015	100.030	100.070	100.0	1
KU	C2SOS	2400727	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400728	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400729	10/2015	10/13/2015	100.030	99.990	100.0	1
KU	C2SOS	2400730	10/2015	10/13/2015	100.040	100.050	100.0	1
KU	C2SOS	2400731	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400732	10/2015	10/13/2015	100.020	99.970	100.0	1
KU	C2SOS	2400733	10/2015	10/13/2015	100.020	100.070	100.0	1
KU	C2SOS	2400734	10/2015	10/13/2015	100.030	99.990	100.0	1
KU	C2SOS	2400735	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400736	10/2015	10/13/2015	100.020	100.020	100.0	1
KU	C2SOS	2400737	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400738	10/2015	10/13/2015	100.040	100.080	100.0	1
KU	C2SOS	2400739	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400740	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400741	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400742	10/2015	10/13/2015	100.040	100.020	100.0	1
KU	C2SOS	2400743	10/2015	10/13/2015	100.040	100.000	100.0	1
KU	C2SOS	2400744	10/2015	10/13/2015	100.020	99.960	100.0	1
KU	C2SOS	2400745	10/2015	10/13/2015	100.040	100.000	100.0	1
KU	C2SOS	2400746	10/2015	10/13/2015	100.030	100.000	100.0	1
KU	C2SOS	2400747	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400748	10/2015	10/13/2015	100.030	100.030	100.0	1
KU	C2SOS	2400749	10/2015	10/13/2015	100.020	99.990	100.0	1
KU	C2SOS	2400750	10/2015	10/13/2015	100.030	100.020	100.0	1
KU	C2SOS	2400751	10/2015	10/13/2015	100.020	100.010	100.0	1
KU	C2SOS	2400752	10/2015	10/13/2015	100.030	99.980	100.0	1
KU	C2SOS	2400753	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400754	10/2015	10/13/2015	100.030	100.040	100.0	1
KU	C2SOS	2400755	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400756	10/2015	10/13/2015	100.040	100.070	100.0	1
KU	C2SOS	2400757	10/2015	10/13/2015	100.020	100.040	100.0	1
KU	C2SOS	2400758	10/2015	10/13/2015	100.030	100.060	100.0	1
KU	C2SOS	2400759	10/2015	10/13/2015	100.040	100.000	100.0	1

KU	C2SOS	2400776	11/2015	11/23/2015	100.040	100.070	100.0	1
KU	C2SOS	2400777	11/2015	11/23/2015	100.040	100.090	100.0	1
KU	C2SOS	2400778	11/2015	11/23/2015	100.050	100.060	100.0	1
KU	C2SOS	2400779	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400780	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400781	11/2015	11/23/2015	100.010	99.990	100.0	1
KU	C2SOS	2400782	11/2015	11/23/2015	100.040	100.000	100.0	1
KU	C2SOS	2400783	11/2015	11/23/2015	100.020	99.990	100.0	1
KU	C2SOS	2400784	11/2015	11/23/2015	100.030	100.070	100.1	1
KU	C2SOS	2400785	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400786	11/2015	11/23/2015	100.030	100.060	100.1	1
KU	C2SOS	2400787	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400788	11/2015	11/23/2015	100.020	100.030	100.0	1
KU	C2SOS	2400789	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400790	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400791	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400792	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400793	11/2015	11/23/2015	100.030	100.110	100.0	1
KU	C2SOS	2400794	11/2015	11/23/2015	100.030	100.120	100.1	1
KU	C2SOS	2400795	11/2015	11/23/2015	100.030	100.030	100.1	1
KU	C2SOS	2400796	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400797	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400798	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400799	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400800	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400801	11/2015	11/23/2015	100.040	100.060	100.0	1
KU	C2SOS	2400802	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400803	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400804	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400805	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400806	11/2015	11/23/2015	100.040	100.090	100.1	1
KU	C2SOS	2400807	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400808	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400809	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400810	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400811	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400812	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400813	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400814	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400815	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400816	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400817	11/2015	11/23/2015	100.030	100.070	100.0	1

KU	C2SOS	2400818	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400819	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400820	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400821	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400822	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400823	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400824	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400825	11/2015	11/23/2015	100.040	100.030	100.0	1
KU	C2SOS	2400826	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400827	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400828	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400829	11/2015	11/23/2015	100.020	99.980	100.0	1
KU	C2SOS	2400830	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400831	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400832	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400833	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400834	11/2015	11/23/2015	100.040	100.030	100.0	1
KU	C2SOS	2400835	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400836	11/2015	11/23/2015	100.030	100.050	100.1	1
KU	C2SOS	2400837	11/2015	11/23/2015	100.030	99.970	100.0	1
KU	C2SOS	2400838	11/2015	11/23/2015	100.020	100.070	100.0	1
KU	C2SOS	2400839	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400840	11/2015	11/23/2015	100.020	99.950	100.0	1
KU	C2SOS	2400841	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400842	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400843	11/2015	11/23/2015	100.020	100.060	100.0	1
KU	C2SOS	2400844	11/2015	11/23/2015	100.020	99.990	100.0	1
KU	C2SOS	2400845	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400846	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400847	11/2015	11/23/2015	100.040	100.130	100.1	1
KU	C2SOS	2400848	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400849	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400850	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400851	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400852	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400853	11/2015	11/23/2015	100.020	100.000	100.0	1
KU	C2SOS	2400854	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400855	11/2015	11/23/2015	100.020	100.070	100.0	1
KU	C2SOS	2400856	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400857	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400858	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400859	11/2015	11/23/2015	100.030	100.050	100.0	1

KU	C2SOS	2400860	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400861	11/2015	11/23/2015	100.040	100.050	100.0	1
KU	C2SOS	2400862	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400863	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400864	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400865	11/2015	11/23/2015	100.030	99.950	100.0	1
KU	C2SOS	2400866	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400867	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400868	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400869	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400870	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400871	11/2015	11/23/2015	100.040	100.060	100.0	1
KU	C2SOS	2400872	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400873	11/2015	11/23/2015	100.010	100.020	100.0	1
KU	C2SOS	2400874	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400875	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400876	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400877	11/2015	11/23/2015	100.030	100.080	100.1	1
KU	C2SOS	2400878	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400879	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400880	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400881	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400882	11/2015	11/23/2015	100.020	99.940	100.0	1
KU	C2SOS	2400883	11/2015	11/23/2015	100.020	100.070	100.0	1
KU	C2SOS	2400884	11/2015	11/23/2015	100.030	99.990	100.0	1
KU	C2SOS	2400885	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400886	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400887	11/2015	11/23/2015	100.020	100.000	100.0	1
KU	C2SOS	2400888	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400889	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400890	11/2015	11/23/2015	100.020	99.970	100.0	1
KU	C2SOS	2400891	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400892	11/2015	11/23/2015	100.020	100.070	100.0	1
KU	C2SOS	2400893	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400894	11/2015	11/23/2015	100.030	99.970	100.0	1
KU	C2SOS	2400895	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400896	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400897	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400898	11/2015	11/23/2015	100.040	99.990	100.0	1
KU	C2SOS	2400899	11/2015	11/23/2015	100.020	100.090	100.0	1
KU	C2SOS	2400900	11/2015	11/23/2015	100.040	99.990	100.0	1
KU	C2SOS	2400901	11/2015	11/23/2015	100.030	100.020	100.0	1

KU	C2SOS	2400902	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400903	11/2015	11/23/2015	100.030	99.990	100.0	1
KU	C2SOS	2400904	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400905	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400906	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400907	11/2015	11/23/2015	100.050	100.080	100.0	1
KU	C2SOS	2400908	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400909	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400910	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400911	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400912	11/2015	11/23/2015	100.040	99.990	100.0	1
KU	C2SOS	2400913	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400914	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400915	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400916	11/2015	11/23/2015	100.030	100.090	100.0	1
KU	C2SOS	2400917	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400918	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2400919	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400920	11/2015	11/23/2015	100.040	100.020	100.0	1
KU	C2SOS	2400921	11/2015	11/23/2015	100.010	100.050	100.0	1
KU	C2SOS	2400922	11/2015	11/23/2015	100.020	100.030	100.0	1
KU	C2SOS	2400923	11/2015	11/23/2015	100.040	100.030	100.0	1
KU	C2SOS	2400924	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400925	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400926	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400927	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400928	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400929	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400930	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400931	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400932	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400933	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400934	11/2015	11/23/2015	100.040	100.020	100.0	1
KU	C2SOS	2400935	11/2015	11/23/2015	100.040	100.030	100.0	1
KU	C2SOS	2400936	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400937	11/2015	11/23/2015	100.030	99.940	99.9	1
KU	C2SOS	2400938	11/2015	11/23/2015	100.030	100.070	100.1	1
KU	C2SOS	2400939	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400940	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400941	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400942	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400943	11/2015	11/23/2015	100.030	100.040	100.0	1

KU	C2SOS	2400944	11/2015	11/23/2015	100.050	99.990	100.0	1
KU	C2SOS	2400945	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400946	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400947	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400948	11/2015	11/23/2015	100.040	100.140	100.1	1
KU	C2SOS	2400949	11/2015	11/23/2015	100.030	100.020	100.0	1
KU	C2SOS	2400950	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400951	11/2015	11/23/2015	100.020	100.000	100.0	1
KU	C2SOS	2400952	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2400953	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400954	11/2015	11/23/2015	100.030	99.960	100.0	1
KU	C2SOS	2400955	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400956	11/2015	11/23/2015	100.030	99.970	100.0	1
KU	C2SOS	2400957	11/2015	11/23/2015	100.020	99.980	100.0	1
KU	C2SOS	2400958	11/2015	11/23/2015	100.030	100.070	100.1	1
KU	C2SOS	2400959	11/2015	11/23/2015	100.020	100.050	100.0	1
KU	C2SOS	2400960	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400961	11/2015	11/23/2015	100.030	100.090	100.0	1
KU	C2SOS	2400962	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400963	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400964	11/2015	11/23/2015	100.040	100.090	100.0	1
KU	C2SOS	2400965	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400966	11/2015	11/23/2015	100.030	99.910	100.0	1
KU	C2SOS	2400967	11/2015	11/23/2015	100.050	100.140	100.1	1
KU	C2SOS	2400968	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400969	11/2015	11/23/2015	100.040	100.050	100.0	1
KU	C2SOS	2400970	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400971	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2400972	11/2015	11/23/2015	100.030	100.030	100.0	1
KU	C2SOS	2400973	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400974	11/2015	11/23/2015	100.040	100.050	100.0	1
KU	C2SOS	2400975	11/2015	11/23/2015	100.040	100.090	100.0	1
KU	C2SOS	2400976	11/2015	11/23/2015	100.020	100.090	100.0	1
KU	C2SOS	2400977	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2400978	11/2015	11/23/2015	100.030	100.110	100.0	1
KU	C2SOS	2400979	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400980	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400981	11/2015	11/23/2015	100.030	100.060	100.0	1
KU	C2SOS	2400982	11/2015	11/23/2015	100.030	100.100	100.0	1
KU	C2SOS	2400983	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400984	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400985	11/2015	11/23/2015	100.030	100.020	100.0	1

KU	C2SOS	2400986	11/2015	11/23/2015	100.010	100.030	100.0	1
KU	C2SOS	2400987	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2400988	11/2015	11/23/2015	100.040	100.080	100.0	1
KU	C2SOS	2400989	11/2015	11/23/2015	100.040	100.050	100.0	1
KU	C2SOS	2400990	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	C2SOS	2400991	11/2015	11/23/2015	100.030	99.990	100.0	1
KU	C2SOS	2400992	11/2015	11/23/2015	100.030	100.110	100.0	1
KU	C2SOS	2400993	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400994	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400995	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2400996	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2400997	11/2015	11/23/2015	100.030	100.050	100.0	1
KU	C2SOS	2400998	11/2015	11/23/2015	100.040	100.040	100.0	1
KU	C2SOS	2400999	11/2015	11/23/2015	100.030	99.980	100.0	1
KU	C2SOS	2401000	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2401001	11/2015	11/23/2015	100.020	100.060	100.0	1
KU	C2SOS	2401002	11/2015	11/23/2015	100.030	99.970	100.0	1
KU	C2SOS	2401003	11/2015	11/23/2015	100.020	100.020	100.0	1
KU	C2SOS	2401004	11/2015	11/23/2015	100.030	100.000	100.0	1
KU	C2SOS	2401005	11/2015	11/23/2015	100.030	99.960	100.0	1
KU	C2SOS	2401006	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2401007	11/2015	11/23/2015	100.040	100.030	100.0	1
KU	C2SOS	2401008	11/2015	11/23/2015	100.030	99.990	100.0	1
KU	C2SOS	2401009	11/2015	11/23/2015	100.020	100.010	100.0	1
KU	C2SOS	2401010	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2401011	11/2015	11/23/2015	100.030	100.010	100.0	1
KU	C2SOS	2401012	11/2015	11/23/2015	100.040	100.100	100.1	1
KU	C2SOS	2401013	11/2015	11/23/2015	100.030	100.070	100.0	1
KU	C2SOS	2401014	11/2015	11/23/2015	100.030	100.040	100.0	1
KU	C2SOS	2401015	11/2015	11/23/2015	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2400000	08/2015	06/29/2015	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2400001	08/2015	06/29/2015	100.010	100.060	100.0	1
KU	FOCUS AXR-MESH	2400002	08/2015	06/29/2015	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2400003	08/2015	06/29/2015	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2400008	08/2015	06/29/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400009	08/2015	06/29/2015	100.040	99.950	100.1	1
KU	FOCUS AXR-MESH	2400010	08/2015	06/29/2015	100.000	99.960	99.9	1
KU	FOCUS AXR-MESH	2400011	08/2015	06/29/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400012	11/2015	08/04/2015	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2400013	11/2015	08/04/2015	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2400014	11/2015	08/04/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400015	11/2015	08/04/2015	100.020	100.000	100.1	1

KU	FOCUS AXR-MESH	2400016	11/2015	08/05/2015	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2400017	11/2015	08/05/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400018	11/2015	08/05/2015	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2400019	11/2015	08/05/2015	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2400020	11/2015	08/05/2015	100.000	99.880	100.0	1
KU	FOCUS AXR-MESH	2400021	11/2015	08/05/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400022	11/2015	08/05/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400023	11/2015	08/05/2015	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2400024	11/2015	08/05/2015	99.980	99.910	100.0	1
KU	FOCUS AXR-MESH	2400025	11/2015	08/05/2015	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2400026	11/2015	08/05/2015	100.030	99.950	100.0	1
KU	FOCUS AXR-MESH	2400027	11/2015	08/05/2015	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2400028	11/2015	08/05/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400029	11/2015	08/05/2015	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2400030	11/2015	08/05/2015	99.980	99.970	100.1	1
KU	FOCUS AXR-MESH	2400031	11/2015	08/05/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400032	11/2015	08/05/2015	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2400033	11/2015	08/05/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400034	11/2015	08/05/2015	100.000	99.920	100.0	1
KU	FOCUS AXR-MESH	2400035	11/2015	08/05/2015	99.970	99.910	100.0	1
KU	FOCUS AXR-MESH	2400036	11/2015	08/05/2015	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2400037	11/2015	08/05/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400038	11/2015	08/05/2015	100.050	100.000	100.0	1
KU	FOCUS AXR-MESH	2400039	11/2015	08/05/2015	100.010	99.970	99.9	1
KU	FOCUS AXR-MESH	2400040	11/2015	08/05/2015	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2400041	11/2015	08/05/2015	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2400042	11/2015	08/05/2015	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2400043	11/2015	08/05/2015	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2400044	11/2015	08/05/2015	100.020	99.940	100.0	1
KU	FOCUS AXR-MESH	2400045	11/2015	08/05/2015	99.980	100.000	100.0	1
KU	FOCUS AXR-MESH	2400046	11/2015	08/05/2015	99.960	99.920	100.0	1
KU	FOCUS AXR-MESH	2400047	11/2015	08/05/2015	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2400048	11/2015	08/05/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400049	11/2015	08/05/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400050	11/2015	08/05/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400051	11/2015	08/05/2015	99.990	99.980	99.9	1
KU	FOCUS AXR-MESH	2400052	11/2015	08/05/2015	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2400053	11/2015	08/05/2015	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2400054	11/2015	08/05/2015	100.040	99.960	100.1	1
KU	FOCUS AXR-MESH	2400055	11/2015	08/05/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400056	11/2015	08/05/2015	100.040	99.970	100.1	1
KU	FOCUS AXR-MESH	2400057	11/2015	08/05/2015	99.960	99.970	99.9	1

KU	FOCUS AXR-MESH	2400058	11/2015	08/05/2015	99.970	99.990	100.0	1
KU	FOCUS AXR-MESH	2400059	11/2015	08/05/2015	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2400060	11/2015	08/05/2015	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2400061	11/2015	08/05/2015	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2400062	11/2015	08/05/2015	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2400063	11/2015	08/05/2015	99.980	99.990	99.9	1
KU	FOCUS AXR-MESH	2400064	11/2015	08/05/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400065	11/2015	08/05/2015	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2400066	11/2015	08/05/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400067	11/2015	08/05/2015	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2400068	11/2015	08/05/2015	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2400069	11/2015	08/05/2015	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2400070	11/2015	08/05/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400071	11/2015	08/05/2015	99.990	99.940	99.9	1
KU	FOCUS AXR-MESH	2400072	11/2015	08/05/2015	100.010	100.010	99.9	1
KU	FOCUS AXR-MESH	2400073	11/2015	08/05/2015	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2400074	11/2015	08/05/2015	100.000	99.890	100.1	1
KU	FOCUS AXR-MESH	2400075	11/2015	08/05/2015	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2400076	11/2015	08/05/2015	99.980	99.940	99.9	1
KU	FOCUS AXR-MESH	2400077	11/2015	08/05/2015	99.960	99.930	100.0	1
KU	FOCUS AXR-MESH	2400078	11/2015	08/05/2015	100.020	99.950	100.1	1
KU	FOCUS AXR-MESH	2400079	11/2015	08/05/2015	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2400080	11/2015	08/05/2015	99.970	99.970	99.9	1
KU	FOCUS AXR-MESH	2400081	11/2015	08/05/2015	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2400082	11/2015	08/05/2015	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2400083	11/2015	08/05/2015	99.990	99.910	100.0	1
KU	FOCUS AXR-MESH	2400084	11/2015	08/05/2015	99.980	100.000	99.9	1
KU	FOCUS AXR-MESH	2400085	11/2015	08/05/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400086	11/2015	08/05/2015	99.970	99.920	100.0	1
KU	FOCUS AXR-MESH	2400087	11/2015	08/05/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400088	08/2015	06/29/2015	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2400089	08/2015	06/29/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400090	08/2015	06/29/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400091	08/2015	06/30/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400092	11/2015	08/04/2015	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2400093	11/2015	08/04/2015	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2400094	11/2015	08/04/2015	99.990	99.990	99.9	1
KU	FOCUS AXR-MESH	2400095	11/2015	08/05/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400096	11/2015	08/05/2015	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2400097	11/2015	08/05/2015	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2400098	11/2015	08/05/2015	99.980	100.000	99.9	1
KU	FOCUS AXR-MESH	2400099	11/2015	08/05/2015	100.000	99.970	100.1	1

KU	FOCUS AXR-MESH	2400100	11/2015	08/05/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400101	11/2015	08/05/2015	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2400102	11/2015	08/05/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400103	11/2015	08/05/2015	99.980	99.930	100.0	1
KU	FOCUS AXR-MESH	2400104	11/2015	08/05/2015	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2400105	11/2015	08/05/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400106	11/2015	08/05/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400107	11/2015	08/05/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400176	11/2015	10/27/2015	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2400177	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400178	11/2015	10/27/2015	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2400179	11/2015	10/27/2015	99.980	99.990	99.9	1
KU	FOCUS AXR-MESH	2400180	11/2015	10/27/2015	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2400181	11/2015	10/27/2015	99.990	99.930	100.1	1
KU	FOCUS AXR-MESH	2400182	11/2015	10/27/2015	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2400183	11/2015	10/27/2015	100.000	100.040	100.0	1
KU	FOCUS AXR-MESH	2400184	11/2015	10/27/2015	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2400185	11/2015	10/27/2015	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2400186	11/2015	10/27/2015	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2400187	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400188	11/2015	10/27/2015	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2400189	11/2015	10/27/2015	100.010	99.960	99.9	1
KU	FOCUS AXR-MESH	2400190	11/2015	10/27/2015	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2400191	11/2015	10/27/2015	100.010	99.940	100.0	1
KU	FOCUS AXR-MESH	2400192	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400193	11/2015	10/27/2015	100.000	99.920	100.0	1
KU	FOCUS AXR-MESH	2400194	11/2015	10/27/2015	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2400195	11/2015	10/27/2015	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2400196	11/2015	10/27/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400197	11/2015	10/27/2015	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2400198	11/2015	10/27/2015	99.990	99.980	100.1	1
KU	FOCUS AXR-MESH	2400199	11/2015	10/27/2015	100.040	99.950	100.1	1
KU	FOCUS AXR-MESH	2400200	11/2015	10/27/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400201	11/2015	10/27/2015	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2400202	11/2015	10/27/2015	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2400203	11/2015	10/27/2015	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2400204	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400205	11/2015	10/27/2015	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2400206	11/2015	10/27/2015	100.040	99.990	99.9	1
KU	FOCUS AXR-MESH	2400207	11/2015	10/27/2015	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2400208	11/2015	10/27/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400209	11/2015	10/27/2015	99.980	99.970	100.0	1

KU	FOCUS AXR-MESH	2400210	11/2015	10/27/2015	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2400211	11/2015	10/27/2015	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2400212	11/2015	10/27/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400213	11/2015	10/27/2015	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2400214	11/2015	10/27/2015	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2400215	11/2015	10/27/2015	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2400216	11/2015	10/27/2015	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2400217	11/2015	10/27/2015	99.970	100.000	99.9	1
KU	FOCUS AXR-MESH	2400218	11/2015	10/27/2015	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2400219	11/2015	10/27/2015	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2400220	11/2015	10/27/2015	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2400221	11/2015	10/27/2015	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2400222	11/2015	10/27/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400223	11/2015	10/27/2015	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2400224	11/2015	10/27/2015	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2400225	11/2015	10/27/2015	99.990	99.950	99.9	1
KU	FOCUS AXR-MESH	2400226	11/2015	10/27/2015	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2400227	11/2015	10/27/2015	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2400228	11/2015	10/27/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400229	11/2015	10/27/2015	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2400230	11/2015	10/27/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400231	11/2015	10/27/2015	100.050	100.000	100.0	1
KU	FOCUS AXR-MESH	2400232	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400233	11/2015	10/27/2015	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2400234	11/2015	10/27/2015	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2400235	11/2015	10/27/2015	100.010	100.040	100.0	1
KU	FOCUS AXR-MESH	2400236	11/2015	10/27/2015	100.050	100.010	100.1	1
KU	FOCUS AXR-MESH	2400237	11/2015	10/27/2015	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2400238	11/2015	10/27/2015	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2400239	11/2015	10/27/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400240	11/2015	10/27/2015	99.960	99.950	99.9	1
KU	FOCUS AXR-MESH	2400241	11/2015	10/27/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400242	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400243	11/2015	10/27/2015	100.010	100.030	100.1	1
KU	FOCUS AXR-MESH	2400244	11/2015	10/27/2015	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2400245	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400246	11/2015	10/27/2015	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2400247	11/2015	10/27/2015	100.010	100.020	100.1	1
KU	FOCUS AXR-MESH	2400248	11/2015	10/27/2015	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2400249	11/2015	10/27/2015	99.970	99.940	100.1	1
KU	FOCUS AXR-MESH	2400250	11/2015	10/27/2015	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2400251	11/2015	10/27/2015	100.010	99.940	100.0	1

KU	FOCUS AXR-MESH	2400252	11/2015	10/27/2015	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2400253	11/2015	10/27/2015	100.030	99.980	100.1	1
KU	FOCUS AXR-MESH	2400254	11/2015	10/27/2015	100.000	99.960	100.1	1
KU	FOCUS AXR-MESH	2400255	11/2015	10/27/2015	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2400256	11/2015	10/27/2015	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2400257	11/2015	10/27/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400258	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400259	11/2015	10/27/2015	99.960	99.980	99.9	1
KU	FOCUS AXR-MESH	2400260	11/2015	10/27/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400261	11/2015	10/27/2015	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2400262	11/2015	10/27/2015	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2400263	11/2015	10/27/2015	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2400264	11/2015	10/27/2015	99.960	99.990	99.9	1
KU	FOCUS AXR-MESH	2400265	11/2015	10/27/2015	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2400266	11/2015	10/28/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400267	11/2015	10/28/2015	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2400268	11/2015	10/27/2015	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2400269	11/2015	10/27/2015	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2400270	11/2015	10/27/2015	99.990	99.960	100.1	1
KU	FOCUS AXR-MESH	2400271	11/2015	10/27/2015	100.020	100.020	99.9	1
KU	FOCUS AXR-MESH	2400272	11/2015	10/27/2015	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2400273	11/2015	10/27/2015	99.970	99.970	99.9	1
KU	FOCUS AXR-MESH	2400274	11/2015	10/27/2015	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2400275	11/2015	10/27/2015	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2400276	11/2015	10/27/2015	100.050	100.030	99.9	1
KU	FOCUS AXR-MESH	2400277	11/2015	10/27/2015	100.010	100.020	100.1	1
KU	FOCUS AXR-MESH	2400278	11/2015	10/27/2015	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2400279	11/2015	10/27/2015	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2400280	11/2015	10/27/2015	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2400281	11/2015	10/27/2015	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2400282	11/2015	10/27/2015	100.040	100.010	100.1	1
KU	FOCUS AXR-MESH	2400283	11/2015	10/27/2015	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2400284	11/2015	10/27/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400285	11/2015	10/27/2015	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2400286	11/2015	10/27/2015	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2400287	11/2015	10/27/2015	100.040	100.050	100.0	1
KU	FOCUS AXR-MESH	2400288	11/2015	10/27/2015	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2400289	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400290	11/2015	10/27/2015	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2400291	11/2015	10/27/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400292	11/2015	10/27/2015	100.020	99.970	99.9	1
KU	FOCUS AXR-MESH	2400293	11/2015	10/27/2015	100.010	100.000	100.0	1

KU	FOCUS AXR-MESH	2400294	11/2015	10/27/2015	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2400295	11/2015	10/27/2015	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2400296	11/2015	10/27/2015	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2400297	11/2015	10/27/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400298	11/2015	10/27/2015	100.050	99.980	100.0	1
KU	FOCUS AXR-MESH	2400299	11/2015	10/27/2015	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2400300	11/2015	10/27/2015	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2400301	11/2015	10/27/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400302	11/2015	10/27/2015	99.980	99.950	100.1	1
KU	FOCUS AXR-MESH	2400303	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400304	11/2015	10/27/2015	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2400305	11/2015	10/27/2015	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2400306	11/2015	10/27/2015	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2400307	11/2015	10/27/2015	99.980	99.950	100.1	1
KU	FOCUS AXR-MESH	2400308	11/2015	10/27/2015	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2400309	11/2015	10/27/2015	100.020	99.930	100.1	1
KU	FOCUS AXR-MESH	2400310	11/2015	10/27/2015	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2400311	11/2015	10/27/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400312	11/2015	10/27/2015	100.060	100.050	100.0	1
KU	FOCUS AXR-MESH	2400313	11/2015	10/27/2015	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2400314	11/2015	10/27/2015	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2400315	11/2015	10/27/2015	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2400316	11/2015	10/27/2015	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2400317	11/2015	10/27/2015	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2400318	11/2015	10/27/2015	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2400319	11/2015	10/27/2015	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2400320	11/2015	10/27/2015	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2400321	11/2015	10/27/2015	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2400322	11/2015	10/27/2015	100.010	100.050	100.0	1
KU	FOCUS AXR-MESH	2400323	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400324	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400325	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400326	11/2015	10/27/2015	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2400327	11/2015	10/27/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400328	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400329	11/2015	10/27/2015	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2400330	11/2015	10/27/2015	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2400331	11/2015	10/27/2015	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2400332	11/2015	10/27/2015	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2400333	11/2015	10/27/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400334	11/2015	10/27/2015	100.000	99.990	100.1	1
KU	FOCUS AXR-MESH	2400335	11/2015	10/27/2015	99.960	99.920	100.0	1

KU	FOCUS AXR-MESH	2400336	11/2015	10/27/2015	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2400337	11/2015	10/27/2015	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2400338	11/2015	10/27/2015	100.010	99.920	100.0	1
KU	FOCUS AXR-MESH	2400339	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400340	11/2015	10/27/2015	99.990	99.960	100.1	1
KU	FOCUS AXR-MESH	2400341	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400342	11/2015	10/27/2015	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2400343	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400344	11/2015	10/27/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400345	11/2015	10/27/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400346	11/2015	10/27/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400347	11/2015	10/27/2015	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2400348	11/2015	10/27/2015	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2400349	11/2015	10/27/2015	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2400350	11/2015	10/27/2015	100.020	100.000	99.9	1
KU	FOCUS AXR-MESH	2400351	11/2015	10/27/2015	100.060	100.010	100.0	1
KU	FOCUS AXR-MESH	2400352	11/2015	10/27/2015	100.050	100.040	100.0	1
KU	FOCUS AXR-MESH	2400353	11/2015	10/27/2015	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2400354	11/2015	10/27/2015	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2400355	11/2015	10/27/2015	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2400356	11/2015	10/27/2015	99.990	99.970	99.9	1
KU	FOCUS AXR-MESH	2400357	11/2015	10/27/2015	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2400358	11/2015	10/27/2015	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2400359	11/2015	10/27/2015	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2400360	11/2015	10/27/2015	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2400361	11/2015	10/27/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400362	11/2015	10/27/2015	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2400363	11/2015	10/27/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400364	11/2015	10/27/2015	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2400365	11/2015	10/27/2015	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2400366	11/2015	10/27/2015	100.050	99.970	100.1	1
KU	FOCUS AXR-MESH	2400367	11/2015	10/27/2015	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2400368	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400369	11/2015	10/27/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400370	11/2015	10/27/2015	99.990	99.950	99.9	1
KU	FOCUS AXR-MESH	2400371	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400372	11/2015	10/27/2015	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2400373	11/2015	10/27/2015	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2400374	11/2015	10/27/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400375	11/2015	10/27/2015	100.040	99.950	100.0	1
KU	FOCUS AXR-MESH	2400376	11/2015	10/27/2015	99.970	100.000	99.9	1
KU	FOCUS AXR-MESH	2400377	11/2015	10/27/2015	99.970	99.960	99.9	1

KU	FOCUS AXR-MESH	2400378	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400379	11/2015	10/27/2015	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2400380	11/2015	10/27/2015	100.000	100.000	99.9	1
KU	FOCUS AXR-MESH	2400381	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400382	11/2015	10/27/2015	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2400383	11/2015	10/27/2015	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2400384	11/2015	10/27/2015	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2400385	11/2015	10/27/2015	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2400386	11/2015	10/27/2015	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2400387	11/2015	10/27/2015	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2400388	11/2015	10/27/2015	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2400389	11/2015	10/27/2015	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2400390	11/2015	10/27/2015	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2400391	11/2015	10/27/2015	100.000	99.960	100.1	1
KU	FOCUS AXR-MESH	2400392	11/2015	10/27/2015	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2400393	11/2015	10/27/2015	100.000	100.000	99.9	1
KU	FOCUS AXR-MESH	2400394	11/2015	10/27/2015	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2400395	11/2015	10/27/2015	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2400396	11/2015	10/27/2015	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2400397	11/2015	10/27/2015	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2400398	11/2015	10/27/2015	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2400399	11/2015	10/27/2015	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2400400	11/2015	10/27/2015	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2400401	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400402	11/2015	10/27/2015	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2400403	11/2015	10/27/2015	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2400404	11/2015	10/27/2015	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2400405	11/2015	10/27/2015	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2400406	11/2015	10/27/2015	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2400407	11/2015	10/27/2015	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2400408	11/2015	10/27/2015	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2400409	11/2015	10/27/2015	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2400410	11/2015	10/27/2015	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2400411	11/2015	10/27/2015	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2400412	11/2015	10/27/2015	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2400413	11/2015	10/27/2015	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2400414	11/2015	10/27/2015	100.030	100.030	100.0	1
KU	FOCUS AXR-MESH	2400415	11/2015	10/27/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400416	11/2015	10/27/2015	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2400417	11/2015	10/27/2015	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2400418	11/2015	10/27/2015	99.990	99.930	100.1	1
KU	FOCUS AXR-MESH	2400419	11/2015	10/27/2015	99.990	99.990	99.9	1

KU	FOCUS AXR-MESH	2400420	11/2015	10/27/2015	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2400421	11/2015	10/27/2015	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2400422	11/2015	10/27/2015	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2400423	11/2015	10/27/2015	100.010	99.920	100.0	1
KU	FOCUS AXR-MESH	2400424	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400425	11/2015	10/27/2015	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2400426	11/2015	10/27/2015	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2400427	11/2015	10/27/2015	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2400428	11/2015	10/27/2015	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2400429	11/2015	10/27/2015	100.030	99.950	100.0	1
KU	FOCUS AXR-MESH	2400430	11/2015	10/27/2015	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2400431	11/2015	10/27/2015	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2400432	11/2015	10/27/2015	100.050	99.960	100.0	1
KU	FOCUS AXR-MESH	2400433	11/2015	10/27/2015	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2400434	11/2015	10/27/2015	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2400435	11/2015	10/27/2015	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2400436	11/2015	10/27/2015	100.020	99.970	99.9	1
KU	FOCUS AXR-MESH	2400437	11/2015	10/27/2015	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2400438	11/2015	10/27/2015	100.020	99.950	100.0	1
KU	FOCUS AXR-MESH	2400439	11/2015	10/27/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400440	11/2015	10/27/2015	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2400441	11/2015	10/27/2015	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2400442	11/2015	10/27/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400443	11/2015	10/27/2015	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2400444	11/2015	10/27/2015	100.030	100.030	100.0	1
KU	FOCUS AXR-MESH	2400445	11/2015	10/27/2015	99.970	99.900	100.0	1
KU	FOCUS AXR-MESH	2400446	11/2015	10/27/2015	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2400447	11/2015	10/27/2015	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2400448	11/2015	10/27/2015	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2400449	11/2015	10/27/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400450	11/2015	10/27/2015	100.020	99.950	100.0	1
KU	FOCUS AXR-MESH	2400451	11/2015	10/27/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400452	11/2015	10/27/2015	99.970	99.990	99.9	1
KU	FOCUS AXR-MESH	2400453	11/2015	10/27/2015	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2400454	11/2015	10/27/2015	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2400455	11/2015	10/27/2015	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2400456	11/2015	10/27/2015	100.040	99.960	100.1	1
KU	FOCUS AXR-MESH	2400457	11/2015	10/27/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400458	11/2015	10/27/2015	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2400459	11/2015	10/27/2015	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2400460	11/2015	10/27/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400461	11/2015	10/27/2015	100.020	99.960	100.0	1

KU	FOCUS AXR-MESH	2400462	11/2015	10/27/2015	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2400463	11/2015	10/27/2015	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2400464	11/2015	10/27/2015	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2400465	11/2015	10/27/2015	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2400466	11/2015	10/27/2015	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2400467	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400468	11/2015	10/27/2015	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2400469	11/2015	10/27/2015	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2400470	11/2015	10/27/2015	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2400471	11/2015	10/27/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400472	11/2015	10/28/2015	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2400473	11/2015	10/28/2015	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2400474	11/2015	10/28/2015	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2400475	11/2015	10/28/2015	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2400476	11/2015	10/28/2015	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2400477	11/2015	10/28/2015	100.050	100.000	100.0	1
KU	FOCUS AXR-MESH	2400478	11/2015	10/28/2015	99.990	100.040	100.0	1
KU	FOCUS AXR-MESH	2400479	11/2015	10/28/2015	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2400480	11/2015	10/28/2015	99.960	100.010	100.0	1
KU	FOCUS AXR-MESH	2400481	11/2015	10/28/2015	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2400482	11/2015	10/28/2015	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2400483	11/2015	10/28/2015	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2400484	11/2015	10/28/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400485	11/2015	10/28/2015	100.030	100.020	100.1	1
KU	FOCUS AXR-MESH	2400486	11/2015	10/28/2015	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2400487	11/2015	10/28/2015	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2400488	11/2015	10/28/2015	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2400489	11/2015	10/28/2015	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2400490	11/2015	10/28/2015	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2400491	11/2015	10/28/2015	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2400492	11/2015	10/28/2015	100.050	100.000	100.1	1
KU	FOCUS AXR-MESH	2400493	11/2015	10/28/2015	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2400494	11/2015	10/28/2015	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2400495	11/2015	10/28/2015	99.960	99.970	99.9	1
KU	FOCUS AXR-MESH	2400496	11/2015	10/28/2015	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2400497	11/2015	10/28/2015	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2400498	11/2015	10/28/2015	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2400499	11/2015	10/28/2015	99.980	99.980	100.0	1
Overall Result								9,432

ATTACHMENT
B

Sampling Test Results

KU
2015 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE		
In-Service Population	495,578	Divided into 60 Lots
Sample Quantity	4,210	
Meters Tested	4,210	
Meters Not Tested	0	
Failed Lots	1	AB1
Failed Lot Meters	10,000	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (.12/31/2015)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1512 Lot Descr: KU AB1 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: FAIL

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C331723	99.30	C332061	98.50	C332238	99.60	C332360	100.40	C332373	100.30
C332384	99.50	C332670	99.80	C332819	98.60	C332862	98.80	C332899	65.20
C332974	99.80	C333454	99.60	C333536	100.40	C333736	100.30	C333757	99.60
C333766	98.20	C333865	99.40	C334042	99.50	C334276	99.80	C334291	99.70
L297601	99.50	L297701	99.60	L297828	99.30	L297860	100.10	L298694	99.00
L298698	98.90	L298812	99.10	L298875	99.70	L298972	98.90	L299162	99.70
L299246	99.40	L299364	99.60	L299533	100.00	L299652	100.00	L299836	99.70
L300087	100.10	L300195	99.40	L300289	99.40	L300408	99.40	L300538	99.10
L300580	99.70	L300590	99.80	L301103	98.60	L301206	100.50	L301260	99.70
L301343	99.90	L301354	99.00	L301522	99.80	L301674	98.90	L302843	98.90
M444621	99.00	M444710	100.00	M444811	100.40	M445135	100.10	M445432	100.00
M445503	100.20	M445519	100.10	M445777	100.10	W146802	99.70	W146909	99.30
W146978	99.90	W147050	99.90	W147139	99.50	W147295	97.80	W147451	99.80
W147461	99.40	W147513	100.20	W147522	99.10	W147936	97.50	W147985	100.00
W148098	100.20	W148768	99.20	W149009	100.20	W149104	99.50	W149153	99.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7431.50
3 Sum of Squared Measurements	737551.95
4 Correction Factor (CF): Sum of Measurements Squared / N	736362.56
5 Corrected Sum of Squares (SS)	1189.39
6 Variance (V) : SS/(N-1)	16.0728
7 Estimate of Lot Standard Deviation(S): SQRT of V	4.0091
8 Sample Mean(XBAR): Sum X/N	99.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	0.73
12 Quality Index Lower (QL): (XBAR-L) / S	0.30
13 Estimate of Lot Percent NCF Above U (PU)	23.31
14 Estimate of Lot Percent NCF Below L (PL)	38.25
15 Total Estimate Percent NCF. In Lot (P): PU+PL	61.56
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	FAIL
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1513 Lot Descr: KU AB1 - 2
 In Service Population: 5,185 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 2

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C333201	99.90	C333330	100.50	C333355	99.80	C334708	98.50	C334771	100.40
C334923	99.50	C335036	100.10	C335077	100.30	C335085	100.70	C335087	99.50
C335092	100.60	C335136	100.30	C335146	100.40	C408107	100.20	C408117	100.40
C408211	99.90	C408393	100.40	C408597	100.60	C408726	99.50	C409015	99.80
C409260	100.20	C409318	100.70	C409385	99.80	C409437	100.00	C409465	100.20
C409469	100.60	C409509	99.90	C409638	99.50	C409651	100.50	C409665	99.10
C409860	100.00	C409896	100.20	C409946	100.40	C433523	100.30	C433567	100.00
C433569	100.00	C433661	100.70	C433712	100.00	C433788	100.40	C433820	100.10
C433833	99.90	C433913	100.40	C433982	100.40	C434093	100.10	C434190	100.10
C434290	100.20	C434364	99.90	C434674	100.20	C434725	100.00	C434872	100.20
C435016	100.30	C435099	100.10	C435142	100.30	C435151	100.20	C435259	100.20
C435413	100.10	L302248	100.10	L302259	100.40	L302330	100.10	L302369	99.50
L302569	100.10	L302574	99.80	L302588	99.20	L302704	100.00	L302784	100.20
L302914	100.40	L303055	100.20	L303091	99.80	L303145	99.90	L303161	100.20
L303242	99.90	L303281	99.20	L303300	99.70	L303387	100.00	L303543	99.70

INFORMATION NEEDED .

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.90
3 Sum of Squared Measurements	750991.71
4 Correction Factor (CF): Sum of Measurements Squared / N	750980.32
5 Corrected Sum of Squares (SS)	11.39
6 Variance (V) : SS/(N-1)	0.1539
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3923
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.93
12 Quality Index Lower (QL): (XBAR-L) / S	5.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: ALP Division: 01 Sample Lot: 1514 Lot Descr: KU ALF - 1
 In Service Population: 38 Sample Quantity: 5 Meters Tested: 5 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2506210	100.00	2507468	100.00	2507501	100.00	2507506	99.90	2507788	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	5
2 Sum of Measurements: (Sum X)	500.00
3 Sum of Squared Measurements	50000.02
4 Correction Factor (CF): Sum of Measurements Squared / N	50000.00
5 Corrected Sum of Squares (SS)	0.02
6 Variance (V) : SS/(N-1)	0.0050
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0707
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	28.28
12 Quality Index Lower (QL): (XBAR-L) / S	28.28
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	9.80
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1SR Division: 01 Sample Lot: 1515 Lot Descr: KU C1S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2000207	100.00	2000295	100.10	2000316	99.90	2000447	100.10	2000498	100.00
2000552	100.10	2000578	100.00	2000809	99.90	2000902	100.10	2000906	100.10
2001003	100.00	2001548	100.10	2001669	100.10	2001724	100.00	2001748	100.10
2001841	100.00	2001959	100.00	2002378	100.10	2002467	100.10	C352473	100.00
C352538	100.00	C352541	99.90	C352952	100.00	C369091	100.10	C369452	100.00
C380755	99.90	C380788	100.10	C380853	100.00	C380908	100.10	C381143	100.00
C381195	99.90	C381288	100.10	C381409	100.00	C381716	100.10	C381798	100.00
C382018	100.10	C382209	100.10	C382251	100.10	C382464	100.10	C382537	100.10
C383341	100.30	C383401	100.10	C386426	100.00	C406410	100.20	C407174	100.00
C407506	100.20	C407593	100.00	C407676	99.80	C407922	100.00	C407967	100.10
C416058	100.10	C416156	100.10	C416206	100.20	C416242	99.90	C416272	100.20
C416298	99.90	C416586	100.10	C416737	99.80	C417130	100.20	C417228	100.20
C417258	100.20	C417401	100.10	C417486	100.10	C425612	99.90	C465652	100.00
C465793	100.00	C466132	100.00	C466187	99.90	C466333	100.00	C466703	99.90
C466879	99.80	C466953	100.00	C467016	100.00	L317602	100.00	L317619	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.90
3 Sum of Squared Measurements	750580.87
4 Correction Factor (CF): Sum of Measurements Squared / N	750580.11
5 Corrected Sum of Squares (SS)	0.76
6 Variance (V) : SS/(N-1)	0.0102
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1012
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	19.38
12 Quality Index Lower (QL): (XBAR-L) / S	20.14
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 1516 Lot Descr: KU CIS - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2002632	100.20	2002722	99.90	2002741	100.10	2003036	100.10	2003515	99.70
2003539	100.10	2003693	100.00	2003713	100.10	2003747	100.10	2003934	100.00
2003947	100.00	2004001	100.10	2004073	100.10	2004109	100.00	2004862	100.10
2005067	100.10	2005157	100.00	2005305	100.00	2005422	100.00	2005553	100.00
2005569	100.20	2005610	100.00	2005795	100.00	2005947	100.20	2005993	99.90
2006068	100.00	2006109	99.80	2006160	100.10	2006263	99.80	2006537	99.90
2006639	99.80	2006642	100.00	2006652	99.90	2006752	100.00	2006771	100.00
2006798	100.10	2006799	99.90	2006862	100.00	2007315	99.90	2007325	100.00
2007561	99.90	2007706	99.90	2007922	99.70	2007970	99.90	2008456	100.00
2008525	100.00	2008580	100.00	2008738	100.00	2008896	100.30	2008927	100.00
2500333	100.10	2500397	100.00	2500403	100.00	2500528	100.10	2500562	100.20
2501137	100.10	2501215	100.00	2501620	100.10	2501772	99.80	2501814	100.00
2501876	100.00	2501918	100.00	C467763	100.10	C467829	100.10	C467878	99.90
C468072	100.00	C468195	100.00	C468207	100.00	C468516	99.90	C468572	100.00
C468697	99.80	C468730	100.20	C468820	100.00	C468986	100.10	C469171	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.30
3 Sum of Squared Measurements	750060.97
4 Correction Factor (CF): Sum of Measurements Squared / N	750060.00
5 Corrected Sum of Squares (SS)	0.97
6 Variance (V) : SS/(N-1)	0.0131
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1144
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	17.44
12 Quality Index Lower (QL): (XBAR-L) / S	17.51
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 1517 Lot Descr: KU C1S - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2009099	99.90	2009123	100.00	2009194	100.00	2009282	100.00	2009681	100.00
2009710	100.10	2009829	100.00	2009831	100.00	2009941	100.10	2009950	100.00
2009973	100.00	2010032	100.00	2010330	100.00	2010636	100.20	2011103	100.00
2011771	99.90	2011889	100.00	2011995	100.00	2012038	100.10	2012128	100.10
2013047	100.00	2013140	99.90	2013389	100.00	2013429	100.00	2013634	100.10
2013712	100.10	2013852	100.10	2013916	100.00	2013932	100.00	2014025	100.10
2014149	99.90	2014302	99.90	2014435	99.90	2014896	100.00	2014930	99.90
2015177	100.00	2015207	99.90	2015677	100.00	2015690	100.00	2015868	100.00
2015869	99.90	2015894	100.00	2016047	100.00	2016285	100.00	2016366	99.70
2502180	100.00	2502370	100.00	2502375	100.00	2502611	100.00	2502647	100.20
2502698	100.10	2502708	100.10	2502810	100.00	2502879	100.00	2503167	100.10
2503169	100.00	2503213	99.90	2503246	100.00	2503513	100.00	2503557	100.00
2503618	100.10	2503623	100.10	2503637	100.20	2504005	100.10	2504014	100.10
2504030	100.10	2504128	99.90	2504392	100.10	2504632	100.10	2504693	100.00
2504737	100.00	2504866	100.00	2505061	100.10	2505065	100.00	2505690	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.10
3 Sum of Squared Measurements	750220.51
4 Correction Factor (CF): Sum of Measurements Squared / N	750220.02
5 Corrected Sum of Squares (SS)	0.49
6 Variance (V) : SS/(N-1)	0.0067
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0817
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	24.30
12 Quality Index Lower (QL): (XBAR-L) / S	24.66
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 1518 Lot Descr: KU C1S - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2016873	100.10	2016949	99.90	2017255	100.10	2017289	100.10	2017323	100.20
2017514	100.00	2017762	100.10	2017783	99.90	2017863	100.10	2017876	100.00
2017952	99.70	2018432	99.90	2018608	100.00	2018716	100.00	2018777	100.10
2018825	99.70	2019024	99.90	2019112	100.00	2019176	99.80	2019735	99.80
2019752	100.00	2019782	99.90	2019802	99.90	2019836	99.90	2019884	100.00
2019891	100.00	2020068	100.00	2020131	99.90	2020684	100.10	2021088	100.00
2021096	99.90	2021467	100.00	2021572	100.00	2021972	99.80	2022091	100.00
2022201	100.10	2022234	100.00	2022242	100.00	2022449	99.80	2022816	100.00
2022956	99.90	2023209	99.90	2023227	99.90	2023328	99.80	2023486	99.90
2023551	100.00	2023605	100.00	2023793	100.20	2023835	100.00	2023863	100.00
2023985	100.00	2024300	100.00	2024718	100.00	2025343	100.00	2025378	100.20
2025604	99.60	2025708	100.10	2025737	99.80	2025838	99.70	2025944	100.00
2026077	100.10	2026173	100.00	2026239	100.00	2026346	99.80	2026393	99.90
2026436	100.00	2026580	100.00	2026719	100.00	2026886	100.00	2027157	100.00
2027306	100.00	2027512	100.00	2027674	100.00	2505794	100.00	2505870	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.50
3 Sum of Squared Measurements	749501.07
4 Correction Factor (CF): Sum of Measurements Squared / N	749500.08
5 Corrected Sum of Squares (SS)	0.99
6 Variance (V) : SS/(N-1)	0.0133
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1155
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	17.61
12 Quality Index Lower (QL): (XBAR-L) / S	17.03
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 1519 Lot Descr: KU C1S - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 8
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2027725	100.10	2027732	100.00	2027832	100.00	2027966	100.00	2028137	100.00
2028507	100.00	2028937	100.00	2029178	100.00	2029192	100.10	2029214	100.00
2029326	99.90	2029698	100.00	2029834	100.00	2029955	100.00	2030076	100.10
2030173	100.00	2030250	100.10	2030304	100.00	2030345	100.10	2030497	100.00
2030766	100.00	2030798	100.10	2030800	100.00	2030927	100.00	2031204	100.00
2031391	100.20	2031395	100.00	2031511	99.90	2031581	100.20	2031912	100.10
2032032	100.10	2032358	100.00	2033036	100.10	2033213	99.90	2033297	100.00
2033361	100.00	2033445	99.80	2033520	99.90	2033693	100.10	2033784	100.00
2033819	99.90	2033834	99.90	2034253	99.90	2034274	100.10	2034358	100.10
2034768	99.90	2035031	99.90	2035317	100.10	2035363	100.00	2035492	100.20
2035514	100.10	2035698	99.90	2035711	100.00	2036160	100.00	2038306	100.10
2038630	100.00	2038754	100.00	2038937	100.20	2039006	100.00	2040022	100.00
2040160	100.00	2040324	100.10	2040391	100.10	2040430	100.10	2040471	100.10
2040519	100.00	2040676	100.00	2040784	100.00	2040808	100.10	2040848	100.00
2040855	100.20	2040944	100.00	2041003	100.10	2505987	99.90	2506115	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.80
3 Sum of Squared Measurements	750360.56
4 Correction Factor (CF): Sum of Measurements Squared / N	750360.04
5 Corrected Sum of Squares (SS)	0.52
6 Variance (V) : SS/(N-1)	0.0070
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0836
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.65
12 Quality Index Lower (QL): (XBAR-L) / S	24.22
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 1520 Lot Descr: KU CIS - 6
 In Service Population: 3,412 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2041355	99.90	2041392	99.90	2041440	100.00	2041450	99.90	2041500	100.10
2041697	100.10	2042338	100.00	2042379	100.00	2042407	99.90	2042552	100.00
2042554	99.90	2042725	100.00	2042791	100.10	2042824	100.00	2043312	100.00
2043408	100.10	2043429	100.00	2043447	100.10	2043540	100.00	2043758	100.00
2043775	100.00	2043919	100.00	2043927	99.90	2043950	99.90	2043971	99.90
2043975	100.00	2043981	100.10	2043999	100.00	2044159	100.00	2044233	99.90
2045397	100.00	2045436	100.00	2045438	99.90	2045632	100.10	2045982	100.00
2046039	100.00	2046220	99.90	2048550	100.00	2048554	100.00	2506376	99.90
2506456	100.00	2506474	99.90	2506481	100.10	2506596	100.10	2506627	100.00
2506628	100.10	2506678	100.10	2506697	100.00	2506859	100.00	2506878	99.90
2506952	100.00	2506963	100.10	2506974	100.10	2507007	100.00	2507013	100.10
2507085	100.00	2507115	100.20	2507145	100.00	2507240	100.10	2507247	100.00
2507293	100.10	2507302	100.10	2507315	99.90	2508404	99.80	2508467	100.00
2508505	100.00	2508577	99.80	2508609	99.90	2508646	99.90	2508926	100.00
2508969	100.00	2508981	100.00	2508991	100.00	2509167	99.90	2509195	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7499.50
3 Sum of Squared Measurements	749900.51
4 Correction Factor (CF): Sum of Measurements Squared / N	749900.00
5 Corrected Sum of Squares (SS)	0.51
6 Variance (V) : SS/(N-1)	0.0068
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0827
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	24.25
12 Quality Index Lower (QL): (XBAR-L) / S	24.09
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1521 Lot Descr: KU D4S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221956	100.20	C225361	99.80	C226346	100.30	C226403	100.20	C226412	100.10
C226456	100.30	C226582	100.00	C226657	100.30	C227611	99.80	C227777	99.80
C227779	99.90	C227880	99.60	C227945	100.30	C228195	100.10	C228200	100.30
C228498	100.10	C228500	99.90	C230563	100.10	C231884	100.00	C232151	100.10
C232169	99.50	C232271	99.70	C236363	100.40	C236398	100.10	C236538	100.30
C236626	99.90	C236908	99.80	C240613	100.00	L136281	99.80	L140818	100.00
L141207	99.70	L141215	100.00	L141220	99.40	M345557	99.10	M345755	100.30
M351074	99.20	M351814	100.50	M351829	100.30	M351919	99.80	M353494	99.10
M353925	100.40	M354174	99.90	M367240	100.20	M367497	100.40	M367502	100.00
M367503	99.70	M367534	99.50	M367662	100.20	M367695	100.10	M367903	100.50
M367933	99.40	M367946	100.00	M375020	99.90	M375580	100.10	M375661	100.00
M376094	99.60	M376142	100.30	M376482	99.90	M376590	99.40	M376988	99.90
W101282	100.20	W101543	99.60	W101943	99.90	W101960	99.50	W102537	100.10
W103770	99.50	W104167	99.90	W104854	99.60	W105115	100.10	W105162	99.60
W105387	100.20	W105446	100.00	W105973	99.80	W109655	100.30	W109678	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7495.80
3 Sum of Squared Measurements	749168.00
4 Correction Factor (CF): Sum of Measurements Squared / N	749160.24
5 Corrected Sum of Squares (SS)	7.76
6 Variance (V) : SS/(N-1)	0.1049
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3239
8 Sample Mean(XBAR): Sum X/N	99.94
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.35
12 Quality Index Lower (QL): (XBAR-L) / S	6.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1522 Lot Descr: KU D4S - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221905	100.10	C240893	99.80	C240956	99.70	C241426	100.10	C245245	100.00
C245358	99.80	C245505	100.10	C245512	99.80	C245542	99.80	C245834	99.30
C250376	99.90	C250497	99.90	C250597	100.20	C254365	99.80	C254382	100.00
C254675	100.10	C255056	100.10	C255086	99.90	C256806	99.60	C256863	100.30
L216379	99.50	L216512	100.00	L221559	99.70	L221705	99.40	M385017	99.80
M385566	100.20	M385630	99.70	M385856	99.70	M385892	99.90	M385987	100.00
M389481	99.60	M389533	99.70	M389679	99.70	M389764	100.00	M390007	99.90
M390237	99.90	M390542	100.10	M392001	99.80	M392246	100.40	M392258	100.10
M392506	99.50	M392806	99.70	M392963	100.00	M393085	99.90	M393259	99.80
M396002	99.40	M396229	100.00	M396464	99.90	M396761	99.30	M397363	99.80
M397408	100.10	M397718	100.10	M397751	99.80	M397759	99.60	M397801	99.70
M398083	100.10	M398232	100.00	M398378	100.00	M398794	100.10	M399031	100.00
M399328	100.20	W110051	99.90	W110613	99.40	W110871	100.00	W110955	99.70
W111738	99.90	W111760	100.00	W112327	100.60	W113253	99.60	W114520	99.80
W114894	99.80	W114963	100.00	W114971	99.50	W116446	99.40	W117076	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7490.30
3 Sum of Squared Measurements	748066.13
4 Correction Factor (CF): Sum of Measurements Squared / N	748061.25
5 Corrected Sum of Squares (SS)	4.88
6 Variance (V) : SS/(N-1)	0.0659
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2567
8 Sample Mean(XBAR): Sum X/N	99.87
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.30
12 Quality Index Lower (QL): (XBAR-L) / S	7.29
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1523 Lot Descr: KU D4S - 3
 In Service Population: 5,939 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223029	99.50	C223053	99.80	C223993	100.20	C256868	100.60	C257255	100.00
C257310	99.40	C257558	100.30	C257706	100.50	C264183	100.00	L218839	100.10
L219040	99.50	L219071	100.00	L219234	99.70	L219331	100.00	L221591	100.10
L221671	99.40	L221884	99.40	L221885	99.40	L221932	100.20	L223751	99.90
L223842	99.90	L223853	100.00	L224116	100.10	L224137	99.70	L224176	99.70
L224187	100.20	L224359	99.80	L224442	100.20	L224532	99.80	L224533	99.70
L224535	100.20	L224738	100.10	L224868	99.50	L228030	99.60	L228056	99.90
L228113	100.00	L228299	100.00	L228344	100.20	L228476	99.60	L228505	99.60
L228530	99.90	L228548	100.20	L228630	100.00	L228732	99.90	L229004	99.60
M394560	99.70	M394586	100.30	M394785	100.50	M394966	99.70	M394990	99.80
M395042	99.80	M395550	100.00	M395577	99.90	M395639	100.10	M395805	99.70
M401062	99.90	M401214	99.80	M401302	99.70	M401553	99.90	M401554	100.40
M401651	99.90	M401689	99.90	M401755	99.90	M401874	100.10	M401922	100.50
M401976	100.20	W119822	100.20	W119838	100.00	W119841	100.00	W119906	99.90
W119943	99.60	W120186	99.90	W120346	99.80	W120382	100.00	W120610	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.30
3 Sum of Squared Measurements	748866.03
4 Correction Factor (CF): Sum of Measurements Squared / N	748860.43
5 Corrected Sum of Squares (SS)	5.60
6 Variance (V) : SS/(N-1)	0.0756
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2750
8 Sample Mean(XBAR): Sum X/N	99.92
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.55
12 Quality Index Lower (QL): (XBAR-L) / S	7.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D5S Division: 01 Sample Lot: 1524 Lot Descr: KU D5S - 1
 In Service Population: 427 Sample Quantity: 25 Meters Tested: 25 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL - 2.5% - Inspection Level II "E" # Normal Inspection

Page 13

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C279714	100.00	C279736	100.00	C279809	99.70	C279811	100.00	C279830	99.80
C279893	99.90	C279899	99.50	C279965	99.70	C283479	99.70	C283573	99.60
C283595	99.60	C283600	99.20	C283688	100.00	C283718	99.80	C298898	99.70
C298905	99.90	C298945	99.90	C298955	100.00	C298961	99.90	C298968	99.40
C298987	100.10	C299010	100.30	C299077	99.80	C299114	100.20	C299167	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	25
2 Sum of Measurements: (Sum X)	2496.00
3 Sum of Squared Measurements	249202.32
4 Correction Factor (CF): Sum of Measurements Squared / N	249200.64
5 Corrected Sum of Squares (SS)	1.68
6 Variance (V) : SS/(N-1)	0.0700
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2646
8 Sample Mean(XBAR): Sum X/N	99.84
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.16
12 Quality Index Lower (QL): (XBAR-L) / S	6.95
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.98
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: I210 Division: 01 Sample Lot: 1525 Lot Descr: KU I210 - 1
 In Service Population: 5,096 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 14
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C432020	100.00	C432143	100.00	C432252	100.00	C432255	99.90	C432331	99.90
C432487	100.00	C432536	99.90	C432546	99.90	C432700	99.90	C432744	99.90
C432802	100.00	C432804	99.80	C432810	100.00	C432815	99.80	C432825	100.10
C432894	100.00	C432920	100.00	C432982	100.00	C433029	100.00	C433113	99.90
C433141	100.00	C433182	100.00	C433184	99.80	C433246	100.00	C433404	100.00
C433426	100.00	C445584	100.00	C445593	100.00	C445601	99.90	C445663	100.00
C445874	100.00	C445954	100.00	C446109	100.00	C446271	100.00	C446286	99.90
C446303	100.10	C455969	99.70	C456467	100.00	C456598	100.00	C456658	99.80
C456836	100.00	C456863	100.00	C456877	100.00	C456891	100.00	C457008	100.00
C457071	99.90	C457072	100.00	C457083	99.80	C457106	99.90	C457232	100.00
C457328	99.90	C457331	99.90	C457388	99.90	C457416	100.00	C457477	99.90
C463497	99.80	C463520	100.10	C463894	100.10	C463898	100.10	C464056	100.10
C464144	99.90	C464212	100.00	C464219	100.00	C464273	100.10	C464349	100.00
C464450	99.90	C464496	100.00	C464618	100.10	C464765	100.10	C464804	100.10
C465017	99.90	C465203	100.00	C465208	100.00	C465325	100.10	C465346	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.90
3 Sum of Squared Measurements	749580.63
4 Correction Factor (CF): Sum of Measurements Squared / N	749580.06
5 Corrected Sum of Squares (SS)	0.57
6 Variance (V) : SS/(N-1)	0.0077
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0879
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.08
12 Quality Index Lower (QL): (XBAR-L) / S	22.45
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V15AC100 Model Number: I50S Division: 01 Sample Lot: 1526 Lot Descr: KU I50 - 1
 In Service Population: 1,016 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C178033	100.50	C179797	100.70	C289888	99.90	C289897	100.00	C298125	100.40
L010504	99.90	L049520	100.00	L049545	99.70	L061073	100.20	L063288	100.00
L065112	99.70	L070315	99.70	L070330	100.00	L071393	99.50	L071523	99.50
L071905	99.90	L071969	100.00	L072370	99.90	L072783	100.00	L072805	100.20
L073690	99.60	L074187	100.00	L074659	98.80	L074889	99.60	L075533	100.10
L085656	100.00	W072124	100.10	W077749	100.20	W078118	100.20	W078364	100.30
W078856	99.60	W078939	100.50	W079038	100.20	W081742	99.80	W082401	100.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3499.30
3 Sum of Squared Measurements	349864.59
4 Correction Factor (CF): Sum of Measurements Squared / N	349860.01
5 Corrected Sum of Squares (SS)	4.58
6 Variance (V) : SS/(N-1)	0.1346
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3669
8 Sample Mean(XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.51
12 Quality Index Lower (QL): (XBAR-L) / S	5.40
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V15AC100 Model Number: I55S Division: 01 Sample Lot: 1527 Lot Descr: KU I55 - 1
 In Service Population: 893 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C198881	100.40	C298283	99.20	C298299	99.90	L004442	100.00	L075907	99.50
L075945	100.00	L075971	99.50	L076200	99.60	L076355	100.40	L076400	100.00
L076462	100.00	L076669	99.70	L078415	100.20	L078476	100.30	L079864	99.60
L079898	100.10	L079953	100.00	L080154	99.60	L080211	100.10	L080705	99.90
L081272	100.00	L081307	100.00	L082333	99.70	L082847	99.60	L084604	99.70
L084986	100.20	L085287	99.90	L086226	100.10	L086829	99.90	L087081	99.70
L087923	100.10	L088635	100.00	L089016	100.00	L089464	99.70	M417632	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3497.10
3 Sum of Squared Measurements	349423.05
4 Correction Factor (CF): Sum of Measurements Squared / N	349420.24
5 Corrected Sum of Squares (SS)	2.81
6 Variance (V) : SS/(N-1)	0.0826
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2875
8 Sample Mean(XBAR): Sum X/N	99.92
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.25
12 Quality Index Lower (QL): (XBAR-L) / S	6.67
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1528 Lot Descr: KU I60 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 17
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C203518	100.60	C203586	100.00	C204120	100.20	C204435	100.40	C204785	100.60
C204836	100.30	C206180	100.00	L001580	99.70	L003821	100.00	L006387	99.40
L008593	100.40	L010257	100.40	L013498	99.80	L013697	99.90	L016137	99.90
L016951	100.20	L017861	99.90	L018155	99.50	L018271	99.80	L074571	99.90
L091935	100.10	L092273	100.10	L093619	100.10	L094021	100.40	L094166	99.70
L094517	99.70	L094531	100.10	L094562	100.10	L095471	99.70	L095600	99.90
L095769	100.10	L096907	100.00	L097297	99.70	L097328	99.80	L097792	100.00
L097804	100.20	L098278	100.00	L098402	100.10	L098483	100.10	L098549	100.00
L098666	99.80	L098850	99.80	L098933	99.80	L099239	100.30	L099385	100.20
L099782	99.60	L100384	99.90	L100660	100.50	L101004	100.00	L101228	99.90
L101717	100.30	L101740	100.00	L102080	100.50	L102128	100.30	L102151	100.00
L102531	99.70	L102733	100.10	L103514	99.80	L104710	100.00	L104986	99.80
L105249	99.80	L105544	100.00	L105715	99.80	L105887	100.00	L106026	99.70
L106159	100.10	L106216	100.00	L106724	99.90	L106815	100.10	L106916	100.60
L106932	100.00	L106967	99.80	L107169	99.80	L107680	99.70	L108305	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.30
3 Sum of Squared Measurements	750064.91
4 Correction Factor (CF): Sum of Measurements Squared / N	750060.00
5 Corrected Sum of Squares (SS)	4.91
6 Variance (V) : SS/(N-1)	0.0663
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2576
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.75
12 Quality Index Lower (QL): (XBAR-L) / S	7.78
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: 160S Division: 01 Sample Lot: 1529 Lot Descr: KU I60 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C208284	100.20	C209477	100.00	C209493	100.00	C209577	99.80	C213145	100.10
C213317	100.20	L005984	100.20	L006750	100.10	L007243	99.80	L009775	99.70
L012441	99.60	L013296	100.10	L015522	99.90	L015663	100.00	L015699	100.10
L017580	100.20	L019156	100.10	L024463	99.70	L025400	100.20	L036968	99.80
L060010	99.70	L069818	99.70	L071002	99.80	L071719	99.90	L072410	99.90
L072912	99.50	L074331	99.70	L085215	99.70	L088194	99.80	L089544	100.00
L093828	99.70	L108825	99.80	L109068	100.00	L109196	99.40	L109273	100.00
L110272	100.10	L110734	99.60	L110756	99.60	L111165	100.10	L111189	99.80
L111381	100.10	L111484	99.50	L111954	100.20	L112113	99.80	L112252	100.10
L112796	99.80	L113043	100.00	L113125	99.80	L113161	99.80	L113194	100.10
L113260	100.00	L113293	99.50	L113420	99.70	L113565	100.00	L113671	99.50
L113958	99.60	L114030	100.30	L114061	100.00	L114285	100.00	L114432	99.80
L114901	99.90	L115061	100.30	L115143	99.80	L115237	99.60	L115266	100.10
L115302	100.20	L116034	100.00	L116086	99.60	L116578	99.80	L116686	100.10
L116871	100.40	L116911	99.90	L117098	99.70	L117213	100.20	L117214	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.10
3 Sum of Squared Measurements	748624.61
4 Correction Factor (CF): Sum of Measurements Squared / N	748620.63
5 Corrected Sum of Squares (SS)	3.98
6 Variance (V) : SS/(N-1)	0.0537
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2318
8 Sample Mean (XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.03
12 Quality Index Lower (QL): (XBAR-L) / S	8.23
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 1530 Lot Descr: KU I60 - 3
 In Service Population: 9,466 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C217649	100.50	C218759	100.50	C218841	100.40	C219961	100.00	L004696	99.90
L005266	100.20	L006218	99.90	L008802	100.10	L010942	99.90	L013530	99.50
L014447	100.10	L014559	99.70	L016966	99.90	L021249	100.00	L072491	100.00
L075024	100.10	L079741	99.80	L082527	99.80	L086646	99.90	L088149	99.90
L090319	99.80	L091163	100.00	L093009	99.90	L093428	100.10	L095589	99.90
L104121	100.20	L118471	99.70	L118681	100.00	L118784	100.20	L118907	99.70
L118934	100.10	L119382	99.50	L119400	99.70	L119911	99.90	L119996	100.20
L120120	100.20	L120129	99.70	L120565	100.00	L120632	100.10	L120727	100.20
L121216	99.90	L121328	100.00	L121878	99.90	L121960	100.20	L122081	100.00
L122102	100.30	L122647	100.20	L122715	100.20	L122855	100.00	L123242	100.00
L123491	100.10	L123806	100.00	L124054	100.30	L124190	100.10	L124340	100.00
L124661	100.10	L124822	99.30	L124976	100.10	L125652	99.80	L125696	99.80
L125779	100.00	L125793	99.90	L125880	100.00	L125977	99.80	L126131	100.10
L126597	100.10	L126791	100.40	L126802	100.10	L126849	100.20	L126899	100.40
L126919	100.20	L127613	99.70	L127644	100.40	L127782	100.00	L252036	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.20
3 Sum of Squared Measurements	750243.94
4 Correction Factor (CF): Sum of Measurements Squared / N	750240.02
5 Corrected Sum of Squares (SS)	3.92
6 Variance (V) : SS/(N-1)	0.0530
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2302
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.62
12 Quality Index Lower (QL): (XBAR-L) / S	8.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1531 Lot Descr: KU I70 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223186	99.90	C223421	99.80	C225655	100.00	C225742	100.10	C225826	100.40
C225887	100.30	C226861	100.00	C226883	100.20	C226927	99.90	C227083	100.20
C229170	99.70	C229437	100.40	L002239	100.10	L003911	100.20	L010540	100.60
L010712	100.30	L010957	100.60	L011639	100.00	L012624	100.50	L014273	100.20
L015180	99.80	L030242	99.90	L035792	100.30	L035984	100.30	L048462	100.30
L070714	100.20	L074329	100.00	L093753	100.50	L099137	99.90	L100802	100.00
L127976	99.80	L128122	100.20	L128496	100.10	L128648	100.00	L128725	100.20
L128767	100.10	L128775	100.00	L129477	100.30	L129683	100.20	L129883	100.00
L129985	99.60	L130023	100.20	L130263	99.70	L130587	100.00	L130914	99.90
L131229	100.20	L131336	100.30	L131398	100.10	L131559	100.20	L131628	100.30
L131897	100.10	L132008	100.20	L132112	100.50	L132308	100.30	L133170	100.20
L133813	100.50	L133994	100.30	L134090	100.50	L134509	100.00	L134534	100.00
L134562	100.50	L134578	100.00	L134645	100.10	L134934	100.00	L134940	99.90
L135048	100.00	L135061	99.90	L135398	100.00	L135494	100.20	L135830	100.10
L135865	100.10	M345430	100.30	M380828	100.60	M380974	100.30	W100694	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.60
3 Sum of Squared Measurements	752125.16
4 Correction Factor (CF): Sum of Measurements Squared / N	752121.50
5 Corrected Sum of Squares (SS)	3.66
6 Variance (V) : SS/(N-1)	0.0495
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2225
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.36
12 Quality Index Lower (QL): (XBAR-L) / S	9.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1532 Lot Descr: KU I70 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C231018	99.80	C232884	100.30	C233159	100.40	C234971	100.10	C234986	100.50
C235239	100.40	C235284	100.20	C238540	100.60	C238594	100.60	C238630	100.40
C238632	100.50	C238851	100.40	C238933	100.20	C239063	100.40	C239064	100.00
L136721	100.10	L136992	100.30	L137336	100.50	L137360	100.30	L137399	100.10
L137443	100.10	L138581	99.90	L138681	100.10	L138915	100.30	L138923	100.20
L139068	100.10	L139125	100.60	L139126	100.40	L139477	100.10	L139641	100.20
L140181	99.90	L140222	100.30	L140404	100.70	L141047	99.90	L141722	99.90
L141755	99.90	L142385	100.10	L142664	99.70	L143628	100.20	L143638	100.20
L143800	100.40	L143904	100.40	L144006	100.00	L144341	100.70	L144620	99.90
L144799	100.30	L144934	100.00	L145173	100.00	L145681	100.00	L145870	100.20
L145904	100.10	L146078	100.00	L146111	100.10	L146182	100.20	L146335	100.10
L146452	100.10	L146945	99.90	L146968	99.80	L147127	100.10	L147171	100.20
L147456	100.10	L147501	100.00	L147551	100.00	L148303	100.00	L148401	100.00
L148475	100.30	L148686	100.50	L148920	99.70	L148969	99.90	L149006	100.50
M353157	100.30	W103680	100.30	W104074	100.40	W104510	100.30	W107684	100.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7514.30
3 Sum of Squared Measurements	752866.85
4 Correction Factor (CF): Sum of Measurements Squared / N	752862.73
5 Corrected Sum of Squares (SS)	4.12
6 Variance (V) : SS/(N-1)	0.0557
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2361
8 Sample Mean(XBAR): Sum X/N	100.19
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.66
12 Quality Index Lower (QL): (XBAR-L) / S	9.28
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1533 Lot Descr: KU I70 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C239101	100.00	C239219	99.90	C239221	100.30	C239431	100.20	C243072	100.20
C243133	100.50	C243432	100.20	C243437	100.10	C243498	100.10	C243564	100.30
C243567	100.00	C243614	100.50	L170163	100.20	L170304	100.20	L170472	100.30
L170547	100.20	L171478	100.20	L171566	100.00	L171644	99.70	L172244	100.20
L172324	99.80	L173045	100.40	L173143	100.00	L173214	100.00	L173699	100.40
L173758	100.30	L173801	100.00	L173873	100.00	L173918	100.10	L173943	99.90
L174349	100.10	L174557	99.90	L174935	99.80	L174940	100.10	L175259	100.20
L175443	100.10	L175517	100.50	L175724	100.50	L176530	100.00	L177057	99.90
L177908	100.20	L178001	100.40	L178160	99.80	L178352	100.40	L179181	100.10
L179506	99.90	L179519	100.00	L179589	100.20	L180265	99.90	L180295	100.00
L180623	100.10	L180813	99.80	L181216	100.20	L181278	99.80	L182171	100.10
L182275	100.20	L182451	100.00	L182476	100.10	L182481	99.90	L182489	99.90
L182632	100.40	L183749	100.00	L183794	100.00	L183795	100.00	L183819	100.40
L183832	100.20	L183838	99.90	L184197	100.30	L184329	100.50	L184418	100.10
L184449	100.00	L184543	100.20	L184563	100.40	W109027	100.40	W109400	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7509.40
3 Sum of Squared Measurements	751884.16
4 Correction Factor (CF): Sum of Measurements Squared / N	751881.18
5 Corrected Sum of Squares (SS)	2.98
6 Variance (V) : SS/(N-1)	0.0403
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2007
8 Sample Mean(XBAR): Sum X/N	100.13
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.34
12 Quality Index Lower (QL): (XBAR-L) / S	10.59
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1534 Lot Descr: KU I70 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221333	100.60	C221356	100.10	C221403	100.30	C247530	100.30	C247918	100.50
C247957	100.40	L184873	100.20	L185728	99.10	L185829	99.80	L185946	100.10
L186882	100.20	L186990	99.90	L187239	99.70	L187296	99.80	L187297	99.90
L187303	99.80	L187416	99.70	L187562	100.00	L187573	99.60	L187678	99.80
L187692	100.00	L188671	100.00	L188754	99.70	L188839	99.90	L189075	100.10
L189102	100.00	L189208	100.10	L189430	99.80	L190300	99.60	L190743	99.70
L190836	99.70	L190871	99.60	L191220	100.20	L191223	100.20	L191251	100.00
L191451	100.20	L191668	100.10	L191691	99.30	L191997	99.80	L192038	100.00
L192181	100.10	L192187	100.10	L192197	100.20	L192276	99.70	L192672	100.00
L192743	100.20	L192751	100.00	L192785	100.20	L192984	100.00	L195175	100.00
L195429	100.30	L195770	100.00	L195874	100.00	L195881	100.00	L195897	100.00
L196065	100.40	L196153	99.70	L196392	99.90	L196494	100.00	L197542	100.00
L197546	100.10	L197814	99.70	L199674	100.20	L199957	99.90	L200178	99.70
L200276	99.40	L200355	99.90	L200441	99.70	L200539	100.20	M384416	99.90
W112608	99.80	W112649	99.80	W113904	100.00	W113969	100.10	W114255	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.40
3 Sum of Squared Measurements	749485.28
4 Correction Factor (CF): Sum of Measurements Squared / N	749480.09
5 Corrected Sum of Squares (SS)	5.19
6 Variance (V) : SS/(N-1)	0.0701
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2648
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.68
12 Quality Index Lower (QL): (XBAR-L) / S	7.42
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1535 Lot Descr: KU I70 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C248086	99.90	C248116	100.00	C248155	100.00	C248234	100.50	C248297	100.60
C248452	100.10	C248544	100.60	C252114	100.30	C252231	100.60	C252544	100.30
C253088	100.00	L070545	100.10	L200783	99.70	L200816	100.10	L201468	100.10
L202107	100.10	L202111	100.60	L203467	100.20	L203535	99.90	L203553	99.90
L203564	99.90	L203793	100.10	L204023	99.80	L204064	99.80	L204077	99.90
L204442	99.70	L204530	99.80	L204555	100.20	L204575	100.00	L204714	99.80
L204826	100.10	L205178	99.90	L205282	100.00	L205416	100.00	L206038	100.30
L206106	100.10	L207320	99.90	L207599	99.90	L207658	100.20	L207886	100.20
L207903	100.10	L207923	100.20	L208095	100.10	L208170	100.40	L209005	99.90
L209029	100.30	L209327	100.40	L210352	100.20	L210537	100.10	L210615	100.10
L210690	100.00	L210719	99.90	L210926	100.20	L210971	100.20	L212158	100.10
L213022	100.10	L213148	100.20	L213225	100.00	L214029	100.00	L214373	99.50
L214406	100.20	L214448	100.40	L214512	100.10	L214783	100.30	L214958	99.90
L215203	99.70	L215479	100.00	L215494	100.30	L216100	100.30	W115992	100.30
W116002	100.10	W116068	99.90	W116306	100.10	W117566	100.20	W117832	100.00

INFORMATION NEEDED

- 1 Sample Size (N)
- 2 Sum of Measurements: (Sum X)
- 3 Sum of Squared Measurements
- 4 Correction Factor (CF): Sum of Measurements Squared / N
- 5 Corrected Sum of Squares (SS)
- 6 Variance (V) : SS/(N-1)
- 7 Estimate of Lot Standard Deviation(S): SQRT of V
- 8 Sample Mean(XBAR): Sum X/N
- 9 Upper Specification Limit (U)
- 10 Lower Specification Limit (L)
- 11 Quality Index Upper (QU): (U-XBAR) / S
- 12 Quality Index Lower (QL): (XBAR-L) / S
- 13 Estimate of Lot Percent NCF Above U (PU)
- 14 Estimate of Lot Percent NCF Below L (PL)
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL
- 16 Maximum Allowable Percent NCF(M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

- 75
- 7507.00
- 751404.30
- 751400.65
- 3.65
- 0.0493
- 0.2220
- 100.09
- 102.00
- 98.00
- 8.59
- 9.43
- 0.00
- 0.00
- 0.00
- 4.83
- PASS

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1536 Lot Descr: KU I70 - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223110	100.20	C255720	100.00	C256071	100.00	C256287	100.30	C256366	99.90
C256497	100.40	C256499	100.50	C261626	100.40	C261701	100.10	C261815	100.40
C261876	100.40	C261927	100.40	C262377	100.30	C262398	100.30	C262518	100.10
C262640	100.20	L217132	100.10	L217158	99.80	L217196	99.70	L217277	99.70
L217352	100.10	L217756	100.30	L217791	100.20	L217815	99.90	L217897	100.20
L218001	100.00	L218205	100.20	L218256	100.20	L219529	100.00	L219558	100.10
L219630	100.10	L219773	99.90	L219853	100.20	L219900	100.00	L220267	99.80
L220633	100.20	L220983	100.20	L222272	100.30	L222441	99.80	L222563	100.20
L225401	100.10	L225627	99.80	L225634	99.30	L225762	100.10	L225767	99.80
L225903	100.10	L226219	99.70	L227200	100.30	L227305	99.80	L227409	100.40
L227566	100.00	L227601	99.90	L227698	100.20	L227709	100.20	L227744	100.10
L233499	100.20	L233546	100.20	L233555	100.40	M402038	100.40	M402260	100.10
M402365	99.70	M402392	100.20	M402394	100.10	M402558	100.10	M402771	100.10
M403730	100.00	M403839	100.40	M403841	99.90	M404064	100.50	M404322	99.90
M404700	100.00	M426733	100.30	M426761	100.20	W120813	100.50	W120950	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.20
3 Sum of Squared Measurements	751644.76
4 Correction Factor (CF): Sum of Measurements Squared / N	751640.90
5 Corrected Sum of Squares (SS)	3.86
6 Variance (V) : SS/(N-1)	0.0522
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2285
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.27
12 Quality Index Lower (QL): (XBAR-L) / S	9.23
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1537 Lot Descr: KU I70 - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 26

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221629	100.20	C223124	100.30	C262544	100.00	C266946	100.30	C267026	100.00
C267059	100.40	C267260	100.10	C267864	99.90	C271930	100.30	C272105	100.20
C272143	100.10	C272146	100.10	C272165	100.10	C272323	100.00	C272331	100.50
C272481	100.00	C272577	100.10	C272645	100.60	C272660	100.20	C272672	99.70
C272780	100.00	C273005	100.20	C273015	100.10	C273045	100.00	C273051	100.10
C276528	100.50	C276776	100.00	C276788	100.10	C277004	100.10	C277074	99.80
C277138	100.00	C277325	100.20	C277389	100.20	C277441	100.20	C277458	100.40
C281432	99.80	C281453	100.20	C281486	100.40	C281513	100.20	L233666	100.90
L233702	100.40	L233818	100.20	L234287	100.10	L234409	100.00	L234458	100.10
L234494	100.10	L235084	99.90	L235095	100.30	L235182	100.10	L235642	100.30
L237560	100.30	L237659	100.20	L238613	100.20	L238638	100.00	L239071	99.80
L239179	100.30	L239792	99.80	L239878	100.00	L242614	99.90	L244094	99.90
L244155	100.10	L244304	99.90	L244533	99.50	L244538	99.90	M416640	100.00
W122410	100.00	W122429	99.70	W122997	100.20	W123120	100.00	W123177	100.10
W124497	100.20	W125475	100.30	W125507	100.00	W125606	100.00	W125721	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.20
3 Sum of Squared Measurements	751644.40
4 Correction Factor (CF): Sum of Measurements Squared / N	751640.90
5 Corrected Sum of Squares (SS)	3.50
6 Variance (V) : SS/(N-1)	0.0473
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2176
8 Sample Mean(XBAR) : Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.69
12 Quality Index Lower (QL): (XBAR-L) / S	9.69
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1538 Lot Descr: KU I70 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 27

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C281678	100.10	C282027	100.10	C282044	100.10	C282070	100.30	C282112	99.70
C282129	100.00	C286790	99.00	C286874	100.00	C286928	100.20	C286970	100.00
C287016	100.20	C287051	100.20	C287475	99.60	C287552	99.80	C290169	99.90
C290536	100.50	C290727	100.00	C290829	100.10	C291027	100.10	C292408	100.10
C292507	100.40	C292533	100.20	C292754	100.00	C292826	99.80	C292905	100.40
C293018	100.10	C293067	100.10	C293362	100.10	C293552	99.80	C293613	100.20
C293711	100.00	C294201	100.40	C294327	100.30	C294374	100.50	C294394	100.20
C295837	100.20	C296092	100.30	L252014	100.40	L262351	100.20	L262537	100.00
L262745	100.10	L262952	100.10	L262968	100.00	L263306	100.20	L263414	100.00
L263520	100.20	L263737	99.90	L263747	100.00	L263766	99.80	L263843	100.30
M420117	99.80	M420278	99.90	M420651	99.80	M420696	99.90	M420934	99.60
W126383	100.10	W126515	99.80	W127195	100.10	W127827	100.30	W128372	99.70
W128382	99.80	W128490	100.30	W128499	100.20	W128924	100.20	W129058	99.90
W129252	100.20	W129320	100.40	W129474	100.10	W131596	100.30	W131762	100.10
W131991	100.00	W132046	100.60	W132207	100.20	W132295	99.80	W132373	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.60
3 Sum of Squared Measurements	751125.00
4 Correction Factor (CF): Sum of Measurements Squared / N	751120.42
5 Corrected Sum of Squares (SS)	4.58
6 Variance (V) : SS/(N-1)	0.0619
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2488
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.74
12 Quality Index Lower (QL): (XBAR-L) / S	8.34
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1539 Lot Descr: XU I70 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C296345	100.40	C296415	99.90	C296468	100.30	C296556	100.00	C296674	100.20
C296736	100.30	C296757	100.30	C296771	100.60	C299445	100.30	C299483	100.00
C299587	100.40	C300081	100.40	C300224	100.40	C300227	100.00	C304635	100.20
C304656	100.00	C304660	100.20	C304852	99.90	C304985	100.30	C305498	100.00
C305540	100.20	C305617	100.10	C305645	100.20	C305678	100.40	L263953	100.30
L264429	100.20	L264441	100.20	L264700	100.00	L264974	100.10	L265077	100.40
L265151	99.80	L265180	100.30	L265331	100.20	L265587	100.10	L266035	100.00
L266171	99.90	L266250	100.40	L266309	100.30	L266421	100.20	L266501	100.10
L266675	101.70	L276492	100.50	L276512	100.00	L276593	100.50	L276727	99.90
L276864	100.00	L277228	100.10	L277279	99.60	L277403	100.00	L277529	100.30
M433730	100.20	M433810	100.20	M434058	100.30	M434274	100.10	M434312	100.30
M436765	99.40	M437601	100.10	M437803	99.90	M437855	100.20	M437948	100.20
M438015	100.20	M438114	100.00	W132752	100.00	W132937	100.10	W133777	100.10
W136059	100.00	W136094	100.30	W136770	100.00	W136884	100.20	W136890	100.00
W137127	100.30	W137187	100.00	W137341	100.10	W137363	100.00	W137431	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7512.30
3 Sum of Squared Measurements	752467.35
4 Correction Factor (CF): Sum of Measurements Squared / N	752462.02
5 Corrected Sum of Squares (SS)	5.33
6 Variance (V) : SS/(N-1)	0.0721
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2684
8 Sample Mean(XBAR): Sum X/N	100.16
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.84
12 Quality Index Lower (QL): (XBAR-L) / S	8.06
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1540 Lot Descr: XU I70 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 29

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C335343	100.10	C335462	99.70	C335516	99.90	C335652	99.90	C335777	99.70
C336042	99.70	C336165	99.80	C336189	99.60	C336292	100.30	C336369	99.90
C336443	99.50	C336666	99.80	C336794	99.70	C336871	99.90	C336996	98.80
C337051	99.50	C337067	98.30	C337258	99.30	C337526	99.30	C337639	100.10
C337724	99.70	C337731	99.80	C337937	99.70	C337965	99.80	C338017	99.90
C338258	99.80	C338275	99.90	C338304	99.80	C338373	99.80	C338923	100.10
C339075	100.20	C339119	99.90	C339228	99.70	C339425	99.50	C339985	99.80
C340438	99.80	C340599	99.70	C340754	100.00	C340892	99.90	C340911	100.00
C340941	99.40	C340981	99.70	C341259	100.00	C341506	99.90	L291962	100.10
L303816	99.60	L303847	99.80	L304161	99.70	L304183	100.00	L304354	99.80
L304503	99.80	L304545	99.90	L304647	99.60	L304828	100.00	L305164	99.40
L305282	99.70	L305315	99.80	L305505	100.10	L305670	99.80	L305721	100.00
L306073	99.80	L306078	99.60	L306147	99.80	L306189	99.90	L306267	99.50
L306457	99.70	L306497	99.90	L306659	99.70	L306918	99.70	L307072	99.60
L307630	99.60	M442119	100.10	M446756	99.90	M446835	99.70	W137601	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7482.50
3 Sum of Squared Measurements	746510.39
4 Correction Factor (CF): Sum of Measurements Squared / N	746504.08
5 Corrected Sum of Squares (SS)	6.31
6 Variance (V) : SS/(N-1)	0.0852
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2919
8 Sample Mean(XBAR): Sum X/N	99.77
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.65
12 Quality Index Lower (QL): (XBAR-L) / S	6.05
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1541 Lot Descr: KU I70 - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 30
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C341526	99.90	C341557	99.70	C341984	99.30	C342052	99.80	C342195	100.10
C342243	99.80	C342342	99.70	C342463	100.00	C342578	100.00	C342692	100.20
C342846	100.10	C343177	100.10	C343343	99.70	C343515	100.00	C343542	99.70
C343665	99.60	C344101	99.70	C344255	99.70	C344376	99.60	C344494	100.10
C344564	99.60	C351865	100.00	C351989	100.10	C352210	99.70	C352355	100.30
L307844	99.90	L308187	100.00	L308471	99.70	L308473	99.60	L308594	99.60
L308693	99.70	L308713	99.70	L309030	99.40	L309100	99.40	L309237	99.00
L309371	99.80	L309373	99.20	L309458	99.70	L309617	99.60	L309756	99.40
L310398	99.80	L310418	99.90	L310456	99.50	L310516	99.90	L310611	100.10
L311297	100.00	L311410	99.90	L311455	100.20	L311842	99.60	M446902	99.60
M447117	99.90	M447173	99.80	M447527	99.90	M447577	99.80	M447768	99.60
W149475	99.70	W149626	99.60	W149886	99.90	W150094	99.70	W150250	99.40
W150492	99.10	W150558	99.70	W150678	100.00	W150754	100.00	W151100	99.80
W151104	99.70	W151118	100.00	W151245	99.90	W151299	99.90	W151306	100.00
W151313	100.00	W151327	99.80	W151357	99.80	W151485	99.60	W151552	100.00

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7483.30
3 Sum of Squared Measurements	746668.43
4 Correction Factor (CF): Sum of Measurements Squared / N	746663.72
5 Corrected Sum of Squares (SS)	4.71
6 Variance (V) : SS/(N-1)	0.0637
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2523
8 Sample Mean(XBAR): Sum X/N	99.78
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.81
12 Quality Index Lower (QL): (XBAR-L) / S	7.04
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 1542 Lot Descr: KU I70 - 12
 In Service Population: 4,594 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 31
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C298413	99.70	C298434	99.70	L191106	99.50	L268261	99.70	L268292	100.10
L311915	99.70	L311946	100.00	L312063	99.20	L312095	99.60	L312122	99.80
L312147	99.80	L312246	99.60	L312320	100.20	L312505	99.90	L312628	100.10
L312876	99.80	L312973	100.10	L313092	100.40	L313146	99.90	W151865	100.00
W151888	99.70	W151892	99.60	W152108	99.50	W152156	99.70	W152208	100.30
W152220	100.00	W152286	99.90	W152394	99.80	W152441	99.80	W152442	99.80
W152443	99.80	W152557	99.80	W152559	99.90	W152581	100.20	W152657	99.90
W152708	99.80	W152775	99.40	W152795	99.70	W152907	100.10	W152964	100.10
W152977	99.40	W153062	99.20	W153106	99.60	W153194	99.70	W153214	100.10
W153263	99.70	W153385	99.90	W153395	99.60	W153400	99.80	W153405	100.20
W153517	99.90	W153563	99.90	W153588	99.80	W153933	99.80	W154021	99.80
W154144	99.90	W154155	99.90	W154203	99.80	W154447	99.50	W154515	99.90
W154578	99.90	W154718	99.90	W154776	99.90	W154786	99.50	W154990	99.80
W155007	99.50	W155106	99.60	W155193	99.90	W155215	100.20	W155220	99.80
W155223	99.80	W155232	99.60	W155355	99.80	W155391	99.60	W155555	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7485.90
3 Sum of Squared Measurements	747186.69
4 Correction Factor (CF): Sum of Measurements Squared / N	747182.65
5 Corrected Sum of Squares (SS)	4.04
6 Variance (V) : SS/(N-1)	0.0546
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2336
8 Sample Mean(XBAR): Sum X/N	99.81
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.37
12 Quality Index Lower (QL): (XBAR-L) / S	7.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1543 Lot Descr: KU J4S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 32
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C228752	100.20	C228979	100.00	C233243	100.10	C233246	99.70	C233443	99.80
C235481	99.50	C235491	99.90	C239505	100.40	C239794	100.50	C239806	100.00
C239874	100.00	C240329	99.70	C240541	100.40	C244306	100.20	C244593	100.00
C244936	100.10	C248765	99.70	C248811	99.90	C248921	99.90	C249260	100.00
C249261	100.30	C249558	99.70	C253427	99.80	C253428	100.60	C253686	99.40
C253797	100.20	C253960	99.70	C258627	99.70	C262831	99.70	C263691	99.60
C263760	100.00	C267963	99.80	C268346	99.70	C268431	99.30	C268566	99.50
C268617	99.80	L232112	99.60	M353519	99.60	M387872	100.40	M387956	100.50
M388095	100.30	M390868	100.30	M391143	100.40	M391283	99.90	M391452	100.20
M391739	99.80	M393543	99.70	M408756	99.90	M408865	99.30	M409037	99.90
M409118	99.90	M409156	99.50	M409391	99.80	M411197	99.90	M412700	99.90
M412729	99.60	M412854	99.60	M413068	99.60	M413339	99.50	M413355	99.40
M413383	99.70	W107050	99.90	W107072	100.30	W107094	99.90	W108751	99.90
W109479	99.80	W111372	100.00	W111644	99.70	W113747	99.90	W117986	99.60
W118011	99.40	W118106	99.90	W118221	100.10	W122262	100.00	W122874	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7491.30
3 Sum of Squared Measurements	748267.65
4 Correction Factor (CF): Sum of Measurements Squared / N	748261.01
5 Corrected Sum of Squares (SS)	6.64
6 Variance (V) : SS/(N-1)	0.0897
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2996
8 Sample Mean(XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.06
12 Quality Index Lower (QL): (XBAR-L) / S	6.29
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1544 Lot Descr: KU J4S - 2
 In Service Population: 1,935 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C269032	99.60	C269038	99.90	C269053	99.70	C306719	100.20	C307725	99.90
C342501	99.80	C342509	99.60	C351190	99.70	C351317	100.10	C351322	99.30
C351402	99.70	C351423	100.10	C351436	100.40	C351584	99.90	C351636	100.10
L240038	99.70	L240053	99.90	L240105	99.70	L240150	99.60	L240204	99.80
L240225	99.60	L240379	99.70	L240413	99.90	L240444	99.90	L240448	100.10
L240523	99.90	L240584	99.70	L241928	99.80	L241999	99.80	L242026	99.80
L242050	99.90	L242126	100.10	L242266	99.20	L245786	99.80	M415604	99.80
M415705	100.10	M415711	99.80	M415738	99.60	M415823	99.70	M415827	99.80
M415886	99.70	M416021	99.60	M416032	99.70	M416179	99.90	P000590	99.70
W123556	99.40	W123563	99.10	W123619	99.70	W123622	99.80	W123780	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4989.00
3 Sum of Squared Measurements	497805.18
4 Correction Factor (CF): Sum of Measurements Squared / N	497802.42
5 Corrected Sum of Squares (SS)	2.76
6 Variance (V) : SS/(N-1)	0.0563
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2373
8 Sample Mean(XBAR): Sum X/N	99.78
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.35
12 Quality Index Lower (QL): (XBAR-L) / S	7.50
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1545 Lot Descr: KU J5S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C273258	99.60	C273309	99.70	C273342	100.20	C273444	99.50	C274018	100.10
C277688	99.70	C277874	99.50	C278019	99.60	C278189	100.00	C278292	100.00
C278401	100.20	C278426	99.70	C278541	100.10	C279405	97.50	C282320	100.10
C282500	100.50	C282516	100.50	C282618	99.80	C282753	99.50	C282820	99.90
C282835	100.00	C283189	100.20	C288218	99.70	C288380	100.40	C288501	100.20
C288509	100.30	C288644	100.10	C288703	99.80	C288745	100.00	C288941	100.00
L243162	99.90	L243471	99.80	L245997	100.00	L246543	99.90	L246565	100.50
L246800	99.80	L247101	100.00	L247259	99.60	L247261	99.90	L247385	100.30
L247623	99.50	L247852	99.60	L248130	99.60	L248279	99.90	L248662	99.90
L248884	100.50	L249158	99.70	L249198	100.00	L250596	99.40	L250859	99.10
L250861	99.80	L250866	99.30	L250867	100.20	L251444	100.10	L251506	99.40
L251531	99.60	L251684	99.70	L251755	99.90	L251793	100.00	L251808	99.50
L252479	100.10	L252750	100.00	L253473	100.00	W124218	99.80	W124297	99.90
W124300	100.20	W124362	99.80	W125391	99.80	W125453	99.50	W125833	99.20
W125917	99.80	W126046	99.80	W126086	99.90	W126939	99.80	W126971	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7488.80
3 Sum of Squared Measurements	747774.24
4 Correction Factor (CF): Sum of Measurements Squared / N	747761.67
5 Corrected Sum of Squares (SS)	12.57
6 Variance (V) : SS/(N-1)	0.1698
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4121
8 Sample Mean(XBAR): Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.22
12 Quality Index Lower (QL): (XBAR-L) / S	4.49
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1546 Lot Descr: KU J5S - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C283768	100.00	C291237	99.90	C291884	99.80	C292087	100.10	C292147	99.80
C292183	100.00	L254089	99.80	L254097	100.10	L254290	99.90	L254420	99.50
L254486	99.50	L254534	100.00	L254721	100.00	L254899	99.00	L255206	100.20
L255285	99.80	L255408	99.80	L255566	99.90	L255699	100.20	L255731	100.00
L255752	100.10	L256548	99.90	L256549	100.20	L256568	100.10	L256960	99.50
L257062	102.00	L257091	99.60	L257338	100.20	L257541	99.90	L257565	100.00
L257650	99.50	L257769	100.40	L257836	100.00	L257992	100.20	L258254	100.50
L258516	100.10	L258557	100.60	L258759	98.90	L259044	100.00	L259122	100.00
L259180	99.90	L259332	100.30	L259504	99.90	L259549	100.30	L259642	100.00
L259650	99.70	M421592	99.90	M421622	99.70	M421878	99.80	M422763	100.00
M422893	100.00	M423213	100.50	M424103	100.30	M424410	100.10	M424457	99.70
M424498	99.50	M424518	100.30	M424520	99.90	M424644	100.00	M428619	99.80
M428784	100.40	M428807	99.50	M428881	100.20	M428887	100.30	M429084	99.70
M429143	100.50	M429300	100.20	M429505	100.50	M429509	100.10	W127484	100.00
W127600	99.50	W127694	99.90	W128188	100.20	W128263	100.30	W129538	100.40

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.30
3 Sum of Squared Measurements	750071.63
4 Correction Factor (CF): Sum of Measurements Squared / N	750060.00
5 Corrected Sum of Squares (SS)	11.63
6 Variance (V) : SS/(N-1)	0.1571
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3964
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.04
12 Quality Index Lower (QL): (XBAR-L) / S	5.06
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1547 Lot Descr: KU J5S - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 36

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C284060	100.10	C284236	100.40	C294652	100.30	C294763	100.10	C294838	99.90
C294873	99.60	C295044	100.60	C295046	100.00	C295074	100.50	C295110	99.90
C295140	100.10	C295281	100.70	C295323	99.90	C295387	100.20	C295420	100.60
C295531	100.30	C295540	100.40	C295750	99.90	C297199	100.10	C297451	100.30
L260833	100.10	L260979	99.90	L260984	99.90	L260988	100.00	L261287	99.90
L261297	100.00	L261482	99.90	L261830	100.30	L261871	99.90	L261977	99.90
L262014	100.10	L262054	100.00	L266938	100.20	L267141	100.70	L267357	100.40
L267366	100.30	L267668	99.80	L267682	99.80	L267751	99.90	L267803	99.70
L267848	100.20	L269167	100.10	L269353	99.50	L269466	99.90	L269569	99.70
L269792	99.80	L269959	99.90	L269990	99.70	L270038	100.40	L270264	99.40
L270279	99.90	L270635	100.10	M430348	99.80	M430895	100.10	M430932	99.80
M432108	101.90	M432172	100.40	M432273	100.10	M432375	100.00	M432737	100.10
M432762	100.30	M432853	100.40	M433133	100.40	W129822	99.70	W129927	100.00
W129956	99.50	W130374	100.20	W130379	100.00	W130400	100.40	W130447	100.00
W130485	100.20	W130665	100.00	W130878	100.20	W130921	100.50	W130950	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7507.20
3 Sum of Squared Measurements	751449.70
4 Correction Factor (CF): Sum of Measurements Squared / N	751440.69
5 Corrected Sum of Squares (SS)	9.01
6 Variance (V) : SS/(N-1)	0.1217
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3489
8 Sample Mean(XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.46
12 Quality Index Lower (QL): (XBAR-L) / S	6.01
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1548 Lot Descr: KU J5S - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C302876	99.90	C302998	99.90	C303146	100.40	C303188	100.00	C303574	99.80
C303670	99.90	C303849	99.80	C303922	99.80	C304127	99.70	C304204	99.60
C305847	99.80	C306115	99.60	C306314	99.60	C306429	99.50	C306442	99.40
C306517	99.90	C306565	99.80	C306867	99.90	C306933	99.30	C307133	99.90
C307302	99.80	C307819	99.50	C307847	99.90	C307852	99.60	C307995	99.80
C308052	99.70	C308212	100.00	L270806	99.80	L270809	99.90	L270844	99.50
L270865	99.80	L271107	99.90	L271115	99.90	L271185	100.40	L271474	99.90
L271495	99.80	L271598	100.20	L271857	99.40	L271992	99.80	L271998	99.40
L272014	100.20	L272173	99.50	L272208	100.40	L272234	99.80	L272324	99.90
L272630	99.80	L272650	99.80	L272692	100.20	L272768	100.00	L273176	99.50
L273252	99.70	L273490	100.20	L273723	99.80	L273764	99.90	L273787	99.60
L274038	99.80	L274073	99.90	L274161	100.00	L274474	100.10	L274557	100.00
L274736	99.80	L274856	100.20	L274941	99.80	L274992	99.60	L275443	99.80
L275526	100.40	L275979	100.10	M433204	100.10	M433307	100.00	M433331	100.40
M433421	100.00	M433553	99.50	P005128	99.90	P005202	99.90	P007046	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7489.10
3 Sum of Squared Measurements	747826.25
4 Correction Factor (CF): Sum of Measurements Squared / N	747821.58
5 Corrected Sum of Squares (SS)	4.67
6 Variance (V) : SS/(N-1)	0.0631
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2511
8 Sample Mean(XBAR): Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.54
12 Quality Index Lower (QL): (XBAR-L) / S	7.39
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1549 Lot Descr: KU J5S - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C308512	100.00	C308576	100.20	C308617	99.70	C308984	100.10	C309062	99.90
C309258	99.70	C309306	99.10	C309392	99.60	C309424	100.00	C309552	99.70
C309568	100.00	C309975	99.70	C310102	99.90	C310206	100.00	C310220	99.70
C310306	100.00	C310477	99.60	C310634	99.80	C310741	99.50	C310782	99.40
C310822	100.00	C311130	100.20	C311307	100.00	C311342	100.20	C311352	99.80
C311392	99.70	C311469	99.50	C311520	100.20	C311537	99.60	C311829	100.00
C312052	100.00	C312117	100.10	C312232	100.10	C312430	99.40	C312482	99.70
C312704	99.90	L277739	99.30	L277741	99.80	L277893	99.70	L278034	99.90
L278088	99.60	L278096	99.80	L278110	99.60	L278133	100.10	L278258	99.70
L278323	99.90	L278815	100.00	L278864	100.10	L278932	100.10	L279121	100.00
L279123	99.80	L279276	99.60	L279291	99.90	L279412	99.70	L279861	100.00
L280144	99.60	L280179	100.00	L280239	99.60	L280257	100.40	L280495	99.80
L281154	99.40	L281210	100.30	L281477	99.80	L281680	99.70	L281696	100.10
L281708	99.70	L281753	99.70	L282671	100.10	L283314	99.80	L283403	99.70
L283505	100.10	M436939	100.00	M438815	99.50	M438929	99.60	M439129	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7487.20
3 Sum of Squared Measurements	747446.80
4 Correction Factor (CF): Sum of Measurements Squared / N	747442.18
5 Corrected Sum of Squares (SS)	4.62
6 Variance (V) : SS/(N-1)	0.0624
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2497
8 Sample Mean(XBAR): Sum X/N	99.83
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.69
12 Quality Index Lower (QL): (XBAR-L) / S	7.32
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1550 Lot Descr: KU J5S - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 39
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C313064	99.90	C313069	99.50	C313186	99.70	C313291	99.90	C313399	100.50
C313488	99.80	C313543	100.20	C313823	99.80	C314084	100.00	C314163	100.10
C314304	100.20	C314606	99.10	C314611	100.30	C314683	99.90	C315045	100.50
C315101	100.00	C315172	99.60	C315360	99.80	C315414	100.20	C315596	99.50
C315746	100.00	C315836	100.30	C316076	100.00	C316123	100.00	C316247	99.90
C316391	99.60	C316473	100.10	C316701	99.30	C316740	99.70	C316765	99.90
C317127	99.80	C317161	99.90	C317390	99.60	C317637	100.20	C317680	100.20
C317731	100.80	C317737	99.80	C317789	100.00	C317865	100.20	C317926	99.50
C318078	99.90	C318595	100.10	C318648	100.20	C318842	99.70	C319301	100.00
C319346	99.90	C319388	99.80	C319446	99.80	C319774	99.80	C319928	98.10
C320100	99.90	C320165	100.20	C320249	99.90	C320448	100.40	C320478	99.80
L283699	100.50	L284211	99.40	L284369	99.90	L284480	99.80	W138592	99.80
W138653	99.60	W138696	99.50	W138751	100.20	W138795	99.90	W138829	99.80
W138873	99.30	W138907	100.10	W139637	99.10	W139656	99.60	W139681	100.10
W139841	99.60	W139868	99.60	W140045	100.00	W140052	100.10	W140110	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7490.80
3 Sum of Squared Measurements	748171.72
4 Correction Factor (CF): Sum of Measurements Squared / N	748161.13
5 Corrected Sum of Squares (SS)	10.59
6 Variance (V) : SS/(N-1)	0.1431
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3783
8 Sample Mean(XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.61
12 Quality Index Lower (QL): (XBAR-L) / S	4.96
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1551 Lot Descr: KU J5S - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C326276	100.40	C326309	100.10	C326629	100.00	C326683	100.00	C326813	99.90
C326882	99.80	C327374	100.10	C327554	100.10	C327579	99.30	C327674	100.20
C327710	99.70	C327978	100.50	C328259	99.50	C328278	99.70	C328357	100.00
C328549	99.20	C328812	100.30	C328942	99.70	C328963	100.00	C328964	100.10
C329025	99.80	C329054	99.00	C329110	99.20	C329144	99.50	C329164	99.60
C329268	99.10	C329434	99.80	C329489	99.80	C329670	99.90	C329868	99.70
C330146	100.00	L284617	99.90	L284805	99.70	L285136	99.90	L285384	100.10
L285801	100.00	L285854	99.90	L285963	99.90	L286077	99.80	L286122	100.10
L286242	99.90	L286372	99.70	L286411	99.80	L286528	99.80	L286539	99.90
L286585	99.70	L286728	99.90	L286805	99.60	L287083	99.70	L287099	99.80
L287174	100.10	L287345	100.00	L287482	100.20	L287521	99.80	L291519	99.60
L291522	99.90	L291876	100.10	M439985	100.30	M440636	99.50	W140539	100.00
W140630	99.90	W140837	102.70	W140936	99.80	W141057	100.10	W141308	100.30
W141374	99.90	W141536	99.90	W141682	100.00	W141839	99.80	W141931	100.00
W141940	99.90	W141961	99.80	W142237	100.10	W142361	99.70	W142436	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.60
3 Sum of Squared Measurements	748534.40
4 Correction Factor (CF): Sum of Measurements Squared / N	748520.73
5 Corrected Sum of Squares (SS)	13.67
6 Variance (V) : SS/(N-1)	0.1847
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4298
8 Sample Mean(XBAR): Sum X/N	99.90
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.88
12 Quality Index Lower (QL): (XBAR-L) / S	4.42
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1552 Lot Descr: KU J5S - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C330324	100.20	C330380	99.80	C330400	99.50	C330437	99.20	C330671	100.10
C330727	100.30	C331223	100.40	C331356	100.20	C331479	99.70	C331632	100.20
L292509	100.00	L292557	100.10	L292682	100.00	L292747	100.30	L292820	100.40
L292914	100.20	L293088	100.40	L293236	99.90	L293444	100.00	L293774	100.40
L294050	100.30	L294075	99.80	L294121	100.20	L294291	100.20	L294381	100.00
L294810	99.70	L294845	98.90	L294903	100.40	L294934	99.50	L295053	99.70
L295295	99.90	L295456	100.10	L295482	99.70	L295899	99.70	L296059	99.60
L296261	99.60	L296298	100.00	L296910	99.70	L296964	100.00	L297016	100.00
L297494	100.10	M437328	99.80	M442718	99.50	M442726	99.90	M442991	99.90
M443023	99.90	M443059	100.20	M443489	100.30	M443940	100.20	M444108	99.60
M444156	99.40	M444229	100.10	M444297	101.50	M445991	99.60	M446140	100.10
W144533	99.30	W144699	100.00	W144780	100.30	W144839	100.40	W144968	99.50
W145008	100.20	W145030	100.00	W145066	100.50	W145199	99.70	W145267	100.30
W145459	100.00	W145522	99.90	W145564	100.10	W145792	100.10	W145799	100.20
W145804	99.60	W145969	100.30	W146128	99.80	W146554	99.80	W146716	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.80
3 Sum of Squared Measurements	749770.12
4 Correction Factor (CF): Sum of Measurements Squared / N	749760.02
5 Corrected Sum of Squares (SS)	10.10
6 Variance (V) : SS/(N-1)	0.1365
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3695
8 Sample Mean(XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.46
12 Quality Index Lower (QL): (XBAR-L) / S	5.37
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1553 Lot Descr: KU J5S - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C349419	99.50	C349763	99.30	C349771	99.50	C349878	98.90	C349997	99.50
C350010	100.10	C350030	99.10	C350134	99.30	C350162	99.40	C350180	99.00
C350387	98.80	C350777	99.10	C350828	99.70	C350878	99.90	C351085	99.40
C351091	99.30	C351109	100.30	C353269	100.00	C353477	99.30	C353526	99.10
C353594	99.90	C353733	99.50	C353757	100.00	C353975	99.80	C354012	99.70
C354123	99.30	C354154	100.10	C354500	100.50	C354534	99.90	C354867	99.20
C354901	99.70	C355119	99.10	C355433	98.80	C355765	99.30	C356129	100.00
C356547	99.50	C356646	99.40	C356690	99.50	C356755	99.50	C357074	100.00
C357078	99.70	C357165	99.70	C357264	99.80	C357752	99.70	L268350	99.70
L268379	100.00	L313203	99.90	L313282	99.70	L313424	100.00	L313531	99.70
L313547	99.70	L313626	99.60	L313734	100.30	L314161	99.50	L314245	99.70
L314289	99.80	L314327	99.70	L314347	99.30	L314693	99.20	L314717	99.60
L314807	99.50	L314878	98.70	L314886	98.90	L315030	99.20	L315641	99.60
L316220	99.70	L316283	99.20	L316499	99.40	L316545	99.40	L317184	99.10
L317233	99.00	L317391	99.30	M446343	100.20	M446424	100.30	M446474	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7467.40
3 Sum of Squared Measurements	743506.12
4 Correction Factor (CF): Sum of Measurements Squared / N	743494.17
5 Corrected Sum of Squares (SS)	11.95
6 Variance (V) : SS/(N-1)	0.1615
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4019
8 Sample Mean(XBAR): Sum X/N	99.57
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.06
12 Quality Index Lower (QL): (XBAR-L) / S	3.90
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1554 Lot Descr: KU J5S - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 43
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C357921	99.30	C358093	98.80	C358600	99.80	C358710	98.90	C358723	99.40
C358738	99.80	C358854	100.00	C359034	99.70	C359152	99.70	C359309	100.00
C359550	100.20	C359632	99.50	C359791	100.50	C359807	99.50	C359844	99.70
C359951	100.10	C360067	99.00	C360191	99.30	C360379	99.60	C360425	98.80
C360569	99.30	C360581	99.60	C360644	100.00	C360853	99.10	C360886	99.80
C360989	99.40	C361006	99.60	C361022	100.40	C361489	99.40	C361756	99.40
C361757	99.70	C361758	100.50	C361942	99.70	C362206	99.60	C362239	99.30
C362396	100.00	C362411	99.30	C362676	99.60	C362953	99.40	C363061	99.30
C363141	99.30	C363179	100.20	C363186	99.70	C363246	99.50	C363455	99.40
C363661	99.10	C363747	100.00	C364047	100.00	C364171	99.40	C364519	99.10
C364657	99.80	C364675	99.20	C364712	99.60	C364852	99.70	C365011	99.80
C365267	99.80	C365462	106.00	C365580	99.40	C365603	99.90	C365722	99.50
C366070	100.00	C366112	99.20	C366170	99.50	C366234	99.40	C366239	99.80
C366510	99.30	C366729	100.00	C367073	98.70	C367257	99.70	M448102	99.20
M448169	99.80	M448253	99.70	M448626	99.20	M448659	100.00	M448700	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7475.50
3 Sum of Squared Measurements	745159.19
4 Correction Factor (CF): Sum of Measurements Squared / N	745108.00
5 Corrected Sum of Squares (SS)	51.19
6 Variance (V) : SS/(N-1)	0.6917
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.8317
8 Sample Mean(XBAR): Sum X/N	99.67
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	2.80
12 Quality Index Lower (QL): (XBAR-L) / S	2.01
13 Estimate of Lot Percent NCF Above U (PU)	0.21
14 Estimate of Lot Percent NCF Below L (PL)	2.11
15 Total Estimate Percent NCF, In Lot (P): PU+PL	2.31
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1555 Lot Descr: KU J5S - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C367606	99.10	C367644	100.10	C368253	98.80	C368264	99.60	C368376	99.40
C370080	99.90	C370082	100.10	C370118	100.20	C370200	99.80	C370256	99.90
C370465	100.00	C370619	99.80	C370831	100.00	C370836	99.10	C371225	99.80
C371363	99.70	C371790	99.70	C371870	99.90	C371946	99.50	C372026	99.70
C372067	99.70	C372106	99.40	C372164	99.50	C372257	99.30	C372366	100.00
C372508	99.40	C372867	99.20	C372888	99.60	C372896	99.00	C373280	99.70
C373300	99.70	C373548	99.50	C373578	99.00	C373658	100.10	C373774	100.10
C373832	99.80	C373930	99.60	C374025	100.10	C374420	99.80	C374714	99.30
C374780	99.30	C374864	100.00	C374912	99.80	C374919	99.70	C375110	99.70
C375194	99.50	C375515	99.70	C375610	99.80	C375646	100.20	C375695	100.00
C375876	99.90	C375938	99.90	C375970	99.70	C376018	99.70	C376023	99.80
C376379	99.70	C376704	99.60	C376813	99.80	C376868	99.90	C377124	99.80
C377426	99.70	C377505	99.70	C377605	99.80	M449134	99.70	M449245	99.50
M449252	99.60	M449475	99.20	M449631	99.10	M449639	100.00	M450022	99.70
M450035	99.40	M450256	99.70	M450758	99.60	M450769	99.50	M450786	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7475.30
3 Sum of Squared Measurements	745074.77
4 Correction Factor (CF): Sum of Measurements Squared / N	745068.13
5 Corrected Sum of Squares (SS)	6.64
6 Variance (V) : SS/(N-1)	0.0897
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2994
8 Sample Mean(XBAR): Sum X/N	99.67
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.78
12 Quality Index Lower (QL): (XBAR-L) / S	5.58
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1556 Lot Descr: KU J5S - 12
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C377761	99.80	C377781	99.90	C378060	100.00	C378583	100.30	C378745	99.70
C378925	99.80	C379028	99.90	C379057	99.70	C379107	99.30	C379163	99.50
C379202	99.60	C379311	99.50	C379556	99.90	C379567	99.60	C379715	99.60
C379835	99.90	C380073	99.90	C380186	100.00	C380193	99.60	C380379	100.00
C380476	99.80	C383503	99.90	C383761	100.00	C383961	99.80	C384075	99.90
C384168	99.70	C384201	99.40	C384276	99.90	C384385	100.30	C384453	99.80
C384703	99.50	C385273	99.70	C385359	99.60	C385859	100.10	C385980	100.10
C386155	100.10	C386195	100.30	C386283	100.30	C386292	99.40	C386323	99.60
C386746	99.90	C386804	99.90	C386826	99.90	C386926	100.00	C387195	100.10
C387518	99.70	C387544	99.50	C387827	99.70	C388459	99.70	C388469	99.80
C388503	99.80	C388621	99.80	C388697	99.90	C388802	100.20	C388901	99.80
C388942	99.80	C389018	99.70	C389041	99.80	C389178	100.00	C389429	99.70
C389515	99.80	C389762	99.30	C389827	100.00	C389872	100.00	C390007	99.60
C390164	99.90	C390172	99.50	C390403	99.80	C390603	99.70	C391772	100.00
C391828	100.10	C391965	99.70	C391999	99.70	C392380	99.90	C392400	99.30

INFORMATION NEEDED

- 1 Sample Size (N)
- 2 Sum of Measurements: (Sum X)
- 3 Sum of Squared Measurements
- 4 Correction Factor (CF): Sum of Measurements Squared / N
- 5 Corrected Sum of Squares (SS)
- 6 Variance (V) : SS/(N-1)
- 7 Estimate of Lot Standard Deviation(S): SQRT of V
- 8 Sample Mean(XBAR): Sum X/N
- 9 Upper Specification Limit (U)
- 10 Lower Specification Limit (L)
- 11 Quality Index Upper (QU): (U-XBAR) / S
- 12 Quality Index Lower (QL): (XBAR-L) / S
- 13 Estimate of Lot Percent NCF Above U (PU)
- 14 Estimate of Lot Percent NCF Below L (PL)
- 15 Total Estimate Percent NCF. In Lot (P): PU+PL
- 16 Maximum Allowable Percent NCF(M)
- 17 Acceptability Criterion: Compare P with M
- 18 The Lot Meets the Acceptability Criterion if P <= M
- 19 The Lot Fails the Acceptability Criterion if P > M

VALUE OBTAINED

- 75
- 7485.70
- 747146.75
- 747142.73
- 4.02
- 0.0544
- 0.2332
- 99.81
- 102.00
- 98.00
- 9.39
- 7.76
- 0.00
- 0.00
- 0.00
- 4.83
- PASS

Kentucky Utilities
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1557 Lot Descr: KU J5S - 13
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 46
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C392836	99.70	C392903	99.80	C393246	99.60	C393751	99.90	C393855	99.40
C393891	100.10	C394170	99.90	C394178	99.70	C394280	100.30	C394443	99.70
C394551	99.60	C394885	100.10	C395043	100.10	C395120	100.00	C395157	100.20
C395558	100.10	C395679	100.30	C396017	99.30	C396077	99.90	C396128	100.10
C396185	100.00	C396194	100.30	C396505	100.00	C396531	100.10	C396579	99.90
C396631	100.00	C396941	100.30	C397097	100.40	C397116	99.90	C397133	100.40
C397152	100.00	C397450	99.50	C397472	100.50	C397682	100.30	C397710	99.80
C397860	99.80	C397903	100.00	C397928	100.30	C397993	100.20	C398045	99.90
C398083	100.30	C398199	99.50	C398202	99.80	C398219	100.00	C398537	100.20
C398718	100.00	C399095	100.00	C399124	100.00	C399313	100.50	C399398	99.40
C399404	99.70	C399421	99.90	C399545	100.50	C399975	99.80	C400008	101.30
C400737	99.90	C400794	100.20	C400899	99.50	C401003	99.80	C401317	99.90
C401354	99.50	C401405	99.50	C401663	99.90	C401672	99.90	C401915	99.90
C402224	99.90	C402292	100.20	C402328	99.50	C402370	100.20	C402590	99.50
C402819	99.70	C402940	100.20	C403414	100.00	C403429	99.80	L317855	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.20
3 Sum of Squared Measurements	749447.88
4 Correction Factor (CF): Sum of Measurements Squared / N	749440.10
5 Corrected Sum of Squares (SS)	7.78
6 Variance (V) : SS/(N-1)	0.1051
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3242
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.29
12 Quality Index Lower (QL): (XBAR-L) / S	6.05
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1558 Lot Descr: KU J5S - 14
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C403501	99.70	C403551	100.30	C403625	99.40	C403755	100.00	C403832	100.10
C404045	99.90	C404332	100.30	C404485	100.10	C404501	99.80	C404540	100.00
C404799	100.00	C405017	100.50	C405035	99.90	C405071	99.90	C405193	99.70
C405246	99.90	C405501	100.00	C405702	99.80	C405711	99.80	C405748	99.90
C405796	99.80	C406020	99.50	C410326	99.60	C410682	99.80	C411271	99.30
C411321	99.40	C411551	100.20	C411774	98.90	C411797	99.70	C412006	100.20
C412122	100.40	C412273	99.70	C412341	99.20	C412356	99.20	C412737	99.50
C412771	99.90	C413030	99.40	C413136	99.00	C413438	98.90	C413485	99.60
C413524	99.70	C413562	99.80	C413572	100.20	C413598	99.90	C413606	99.30
C413792	99.20	C414043	99.70	C414069	99.20	C414197	99.20	C414343	99.70
C414355	99.90	C414377	98.90	C414818	100.00	C414823	99.30	C414870	99.30
C414900	99.10	C414986	99.30	C415046	99.70	C415380	99.00	C415414	99.10
C415418	99.20	C415668	99.20	C417632	99.80	C417691	99.60	C417717	99.90
C417920	99.50	C417987	99.10	C418180	99.50	C418325	99.30	C418582	99.70
C418784	99.40	C419053	99.80	C419165	99.80	C419379	99.70	C419462	98.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7471.50
3 Sum of Squared Measurements	744323.37
4 Correction Factor (CF): Sum of Measurements Squared / N	744310.83
5 Corrected Sum of Squares (SS)	12.54
6 Variance (V) : SS/(N-1)	0.1695
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4117
8 Sample Mean(XBAR): Sum X/N	99.62
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.78
12 Quality Index Lower (QL): (XBAR-L) / S	3.94
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: JSS Division: 01 Sample Lot: 1559 Lot Descr: KU JSS - 15
 In Service Population: 5,847 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 48
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C419605	99.70	C419713	99.50	C419741	98.90	C420014	99.30	C420050	99.00
C420157	99.50	C420158	98.90	C420289	99.30	C420309	99.00	C420331	99.10
C420546	98.70	C420579	99.10	C420680	99.70	C420994	99.90	C421041	100.00
C421043	100.00	C421069	99.60	C421269	99.50	C421273	99.50	C421427	99.50
C421464	99.50	C421530	99.80	C421720	99.20	C421909	98.70	C421941	99.20
C421978	98.90	C422071	99.00	C422124	99.10	C422169	99.70	C422263	99.00
C422278	99.70	C422610	99.80	C422698	100.10	C422725	99.50	C422752	99.30
C422763	99.30	C422803	99.00	C422849	99.40	C422899	99.60	C423018	99.50
C423066	99.90	C423453	99.30	C423528	99.50	C423590	100.20	C423632	99.40
C423769	100.00	C423843	99.60	C423856	99.30	C423901	99.60	C424199	99.10
C424311	99.60	C424346	99.70	C424409	99.70	C424429	99.70	C424490	99.70
C424575	99.80	C424595	99.00	C424668	100.30	C424688	99.10	C424706	99.40
C424712	99.70	C424868	99.70	C424870	99.70	C424880	99.50	C425016	99.30
C425062	99.10	C425074	99.20	C425100	99.50	C425124	99.40	C425210	99.70
C425211	99.90	C425245	99.30	C425257	99.80	C425306	100.00	C425333	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7460.60
3 Sum of Squared Measurements	742150.12
4 Correction Factor (CF): Sum of Measurements Squared / N	742140.70
5 Corrected Sum of Squares (SS)	9.42
6 Variance (V) : SS/(N-1)	0.1273
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3568
8 Sample Mean(XBAR): Sum X/N	99.47
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.08
12 Quality Index Lower (QL): (XBAR-L) / S	4.13
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MQS Division: 01 Sample Lot: 1560 Lot Descr: KU MQ - 1
 In Service Population: 3,712 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C205185	100.00	C205636	100.20	C206515	99.40	C206599	99.90	C207050	100.10
C207109	99.90	C207431	100.00	C207472	100.00	C208129	100.60	C208162	99.80
C208212	99.80	C208519	100.10	C208589	99.90	C209311	99.90	C209823	99.90
C210361	100.00	C210366	100.00	C211247	100.30	C211268	100.20	C211675	99.90
C211733	99.80	C212081	100.10	C212206	99.90	C212770	99.90	C213542	99.70
C213678	99.90	C213688	100.10	C214302	99.90	C214620	99.80	C214631	99.50
C214644	99.90	C214646	100.10	C214654	99.60	C215536	99.10	C215590	99.70
C216551	99.80	C217856	99.80	C217865	100.10	C217963	100.10	C218105	99.80
C218169	99.90	C219114	100.20	C219157	100.10	C219220	100.20	C219289	100.00
C221183	100.10	C221202	99.80	C221287	100.00	M362287	99.70	M362473	99.70
M362649	99.40	M362770	100.10	M362823	100.00	M381107	100.70	M387069	100.70
W092812	100.50	W092961	100.00	W094975	100.10	W095172	100.10	W095481	100.00
W095509	100.10	W095553	99.40	W095974	100.20	W096184	100.00	W096513	99.70
W096517	100.00	W097136	100.20	W097303	99.90	W098219	99.90	W098266	100.20
W099401	100.00	W099473	99.20	W100303	100.30	W101037	99.60	W101696	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.90
3 Sum of Squared Measurements	749386.35
4 Correction Factor (CF): Sum of Measurements Squared / N	749380.13
5 Corrected Sum of Squares (SS)	6.22
6 Variance (V) : SS/(N-1)	0.0841
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2900
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.04
12 Quality Index Lower (QL): (XBAR-L) / S	6.75
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1561 Lot Descr: KU MS - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 50
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C225041	100.70	C227259	100.70	C227291	99.90	C227393	99.90	C211492	100.00
C232509	100.40	C232540	99.80	C234575	99.50	C234835	100.20	C237362	100.90
C237451	100.00	C237891	100.10	C238295	100.20	C242102	100.30	L133407	100.50
L133428	100.30	L138123	100.10	L140008	100.40	L144422	100.30	L147714	100.00
L148076	99.60	L149293	100.50	L149333	100.20	L149473	99.80	L149730	100.40
L171822	100.00	L171845	100.40	L171874	100.10	L171893	100.20	L173365	100.20
L176023	100.20	L177156	99.70	L177409	100.00	L178728	100.20	L178747	99.50
L178760	100.10	L179613	99.70	L179629	100.60	L179760	99.70	L181466	100.00
L181564	99.90	L181565	100.30	L181641	100.40	L181768	99.90	L183112	100.10
L183233	99.90	L183335	100.10	L185419	99.60	L185461	100.20	L185515	100.00
L186144	100.30	L186203	100.50	L186298	100.20	L186493	100.00	L186637	99.80
L186654	99.80	L187927	100.70	L187982	100.50	L188089	100.10	L188388	100.40
M345870	100.30	M352019	100.00	M352082	100.60	M374508	99.90	M386374	99.80
M386385	99.70	M388776	99.60	W103651	100.30	W104377	100.60	W104391	100.30
W105031	100.50	W105583	100.00	W108762	100.10	W109235	100.40	W109560	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.30
3 Sum of Squared Measurements	752068.53
4 Correction Factor (CF): Sum of Measurements Squared / N	752061.41
5 Corrected Sum of Squares (SS)	7.12
6 Variance (V) : SS/(N-1)	0.0962
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3101
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.01
12 Quality Index Lower (QL): (XBAR-L) / S	6.89
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1562 Lot Descr: KU MS - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 51
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C242282	100.20	C242349	100.60	C242357	100.30	C242749	100.20	C242779	99.70
C246514	100.10	C246864	99.70	C247241	99.20	C247404	100.00	C247503	99.80
L189832	99.90	L189974	100.40	L190009	99.60	L190024	100.00	L190159	100.20
L193180	100.20	L193259	100.70	L193271	100.10	L193581	99.90	L193614	100.40
L193730	99.70	L193952	99.80	L193961	100.20	L194080	100.20	L194174	99.70
L194411	100.10	L194541	100.20	L196930	99.90	L197234	99.80	L198003	99.80
L198010	100.20	L198155	99.80	L199069	99.80	L199211	100.40	L199374	99.90
L200912	99.90	L200972	100.20	L201019	99.30	L201155	100.10	L201235	100.00
L202282	99.90	L202688	99.60	L203137	100.00	L203163	99.70	L203242	100.10
L206276	99.80	L206307	99.90	L207610	99.90	L208205	99.80	L208219	99.90
L208371	99.70	L208675	99.60	L209591	100.10	L209705	99.40	L209889	100.50
L209943	100.40	L209947	99.40	L209960	100.00	L211355	100.10	L211392	100.30
L211461	100.00	M386839	99.70	W109861	99.80	W109872	100.40	W110424	99.70
W111902	98.70	W112859	100.20	W112895	100.70	W115064	100.00	W115087	100.10
W115227	100.20	W115276	100.10	W115353	100.30	W115482	99.60	W115512	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.40
3 Sum of Squared Measurements	749488.70
4 Correction Factor (CF): Sum of Measurements Squared / N	749480.09
5 Corrected Sum of Squares (SS)	8.61
6 Variance (V) : SS/(N-1)	0.1163
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3411
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.97
12 Quality Index Lower (QL): (XBAR-L) / S	5.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1563 Lot Descr: KU MS - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 52
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C251210	99.90	C251213	99.70	C251223	100.30	C251241	100.30	C251445	100.30
C251574	100.30	C251614	100.30	C251784	100.20	C251796	99.80	C251906	100.20
C259238	100.30	C259652	100.40	C259998	100.20	C260427	99.70	C260468	100.10
C260500	100.50	C260737	100.60	C260891	100.20	C261079	100.60	C261088	100.20
C261272	99.90	C261325	100.00	C265935	100.30	C266031	100.10	C266164	100.10
C266602	99.80	C266681	99.90	L212489	100.20	L212596	100.10	L212794	99.70
L212804	100.10	L212832	100.20	L215658	100.10	L215883	99.90	L215888	100.10
L216097	99.90	L218269	99.80	L218489	99.90	L218602	100.00	L218783	100.20
L221144	100.20	L221322	100.30	L221389	100.20	L222785	99.80	L222790	100.20
L222885	99.90	L223073	99.90	L223143	100.30	L223424	100.00	L223569	100.10
L223624	99.70	L231053	99.90	L231287	99.70	L232282	100.30	L232457	100.10
L236406	100.30	L236498	100.30	L236646	100.10	L236694	100.00	L236777	100.10
L236873	100.00	L236892	100.10	L237106	99.20	W115671	100.20	W117245	100.00
W117291	100.30	W118412	100.20	W118543	100.80	W118587	100.20	W118660	99.80
W118662	99.60	W118694	100.10	W118757	100.20	W118868	99.80	W122375	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.40
3 Sum of Squared Measurements	751285.26
4 Correction Factor (CF): Sum of Measurements Squared / N	751280.55
5 Corrected Sum of Squares (SS)	4.71
6 Variance (V) : SS/(N-1)	0.0637
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2524
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.59
12 Quality Index Lower (QL): (XBAR-L) / S	8.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1564 Lot Descr: KU MS - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 53
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C271309	100.40	C271764	100.00	C275431	100.30	C275729	100.40	C275750	99.80
C275800	100.10	C275823	100.00	C276216	99.90	C276503	100.30	C279978	100.00
C280231	99.60	C280381	100.10	C280389	100.10	C280425	100.20	C280472	100.50
C280684	100.10	C280748	100.30	C280952	100.10	C280953	100.10	C281076	99.90
C285042	100.60	C285322	100.00	C285547	100.00	C285667	100.00	C285732	100.00
C285877	100.10	C285881	100.10	C286032	99.80	C286083	100.00	C286238	99.60
C286371	100.00	C286469	100.00	C286479	100.20	C289511	100.20	C289559	100.30
C289598	100.30	C289617	100.00	C289655	100.30	C289999	100.40	C301132	100.00
L237196	100.20	L237248	99.90	L237301	100.10	L238298	100.20	L238340	99.50
L238555	100.30	L240652	100.00	L240771	99.90	L240784	99.90	L243819	100.00
L243862	100.20	L243869	100.10	L243908	99.90	L243958	100.00	L245297	99.90
L245313	100.40	L245658	100.10	L245678	100.20	L259958	100.20	L260061	99.40
L260081	100.20	L260086	99.80	L260261	100.00	L260302	100.00	M434731	100.10
M434870	100.00	M434966	100.30	M435009	100.00	W126811	100.30	W132621	100.20
W133137	100.30	W133219	100.60	W133248	100.10	W133293	100.30	W133376	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.60
3 Sum of Squared Measurements	751324.26
4 Correction Factor (CF): Sum of Measurements Squared / N	751320.58
5 Corrected Sum of Squares (SS)	3.68
6 Variance (V) : SS/(N-1)	0.0497
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2230
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.57
12 Quality Index Lower (QL): (XBAR-L) / S	9.36
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1565 Lot Descr: KU MS - 5
 In Service Population: 2,212 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 54

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
L312433	99.70	L312437	100.20	L312896	99.90	L312931	100.20	L312975	99.90
L312984	100.10	M435364	100.00	M435396	100.20	M435428	100.10	M435526	99.90
M435581	100.40	M435584	100.00	M435598	99.90	W134142	100.10	W134149	100.20
W134247	100.10	W134253	100.40	W134259	100.10	W134261	99.70	W134368	100.50
W134376	100.40	W134496	100.00	W134554	100.10	W134590	100.00	W134597	100.10
W134704	100.30	W134766	99.80	W134814	99.90	W134823	100.20	W134888	100.10
W134900	99.90	W134927	100.20	W134975	100.20	W135056	100.10	W135146	100.00
W135175	100.00	W135400	100.00	W135408	99.60	W135491	100.00	W135509	100.10
W135530	100.20	W135588	100.40	W135624	100.10	W135649	99.80	W135682	100.00
W135745	100.20	W135771	100.20	W135775	100.10	W135810	100.00	W135846	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5003.70
3 Sum of Squared Measurements	500741.99
4 Correction Factor (CF): Sum of Measurements Squared / N	500740.27
5 Corrected Sum of Squares (SS)	1.72
6 Variance (V) : SS/(N-1)	0.0350
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1871
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.29
12 Quality Index Lower (QL): (XBAR-L) / S	11.08
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1566 Lot Descr: KU MSII - 1
 In Service Population: 4,813 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 55
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C275470	100.00	C275472	99.70	C275565	100.00	C275630	99.80	C275946	100.00
C298637	99.90	C298751	100.30	C300573	100.00	C300627	100.40	C300667	100.10
C300706	99.70	C300754	99.90	C300785	99.90	C300804	100.00	C300806	100.00
C300918	99.90	C300989	100.00	C301252	100.10	C301319	100.10	C301512	100.20
C301558	100.30	C301621	100.20	C301640	100.10	C301782	100.30	C301814	99.80
C302019	100.10	C302075	100.20	C302091	99.80	C302142	100.00	C302171	100.20
C302267	100.20	C302290	100.20	C302311	99.90	C302434	100.10	C302503	100.20
C302734	99.50	C302807	100.30	L312839	99.90	M416225	100.20	M416301	99.80
M416346	99.80	M416374	100.10	M416387	99.70	M416394	100.30	M416419	99.90
M416443	99.90	M416544	100.20	M421116	99.90	M421244	100.10	M421344	99.70
M422003	99.90	M422016	99.90	M422120	100.30	M422130	100.10	M422173	100.10
M422318	99.50	M422373	100.20	M422387	100.00	M422445	99.70	M422497	100.00
M422515	100.00	M422541	100.20	M422546	99.80	M428473	100.30	M435648	100.30
M435718	99.70	M435721	100.10	M435747	100.30	M435768	100.10	M435799	100.10
M435878	100.20	M436128	99.90	M436160	100.10	M436444	100.10	M436573	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.80
3 Sum of Squared Measurements	750363.00
4 Correction Factor (CF): Sum of Measurements Squared / N	750360.04
5 Corrected Sum of Squares (SS)	2.96
6 Variance (V) : SS/(N-1)	0.0400
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1999
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.89
12 Quality Index Lower (QL): (XBAR-L) / S	10.13
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1567 Lot Descr: KU MX - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 56
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C320915	100.20	C320986	99.90	C321089	100.10	C321113	99.80	C321205	99.80
C321227	100.00	C321418	99.70	C321646	99.90	C321741	100.10	C321994	100.00
C322059	99.80	C322227	100.00	C322312	100.00	C322319	99.90	C322361	100.00
C322398	100.20	C322511	100.30	C322812	100.20	C322888	100.00	C322978	99.90
C323021	100.00	C323285	99.80	C323400	99.60	C323638	99.70	C324024	99.90
C324068	99.80	C324099	100.00	C324100	99.80	C324115	100.00	C324172	99.50
C324619	100.20	C324706	100.10	C324931	100.30	C325001	100.30	C325310	100.10
C325569	100.40	C325728	99.90	L288369	100.10	L288638	100.00	L288820	99.60
L288937	99.60	L288942	99.70	L289033	100.10	L289093	100.10	L289096	100.00
L289200	100.10	L289347	99.90	L289594	100.00	L289648	100.00	L289810	100.40
L290050	100.00	L290108	100.00	L290164	100.40	L290326	100.00	L290516	99.90
L290528	99.80	L290574	99.90	L290680	99.70	L290765	100.00	L290944	99.90
L291389	99.70	L292102	100.00	M441119	99.90	M441373	100.30	M441580	99.80
M441783	100.30	M441801	100.10	M442222	100.10	M442386	100.40	M442411	101.00
W142767	99.80	W142952	100.10	W143145	99.80	W143187	99.90	W143220	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7499.30
3 Sum of Squared Measurements	749864.15
4 Correction Factor (CF): Sum of Measurements Squared / N	749860.01
5 Corrected Sum of Squares (SS)	4.14
6 Variance (V) : SS/(N-1)	0.0560
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2366
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.49
12 Quality Index Lower (QL): (XBAR-L) / S	8.41
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1568 Lot Descr: KU MX - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 57
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C390666	100.10	C390959	100.00	C390990	99.80	C391342	99.80	C391398	100.00
C426156	99.00	C426310	99.90	C426365	99.60	C426440	99.90	C426708	99.40
C426752	99.00	C426825	99.50	C426967	99.70	C426968	100.20	C427043	99.60
C427101	99.80	C427190	99.00	C427237	99.50	C427259	100.00	C427281	99.80
C427315	99.30	C427354	100.10	C427426	99.70	C427444	99.70	C427564	100.10
C427834	99.80	C427844	99.70	C427871	100.10	C428183	99.70	C428266	99.80
C428354	99.50	C428397	100.00	C428433	100.00	C428451	99.70	C428466	99.60
C428654	100.00	C428689	107.10	C429084	99.70	C429495	99.70	C429524	100.00
C429639	99.50	C429880	99.20	C430188	99.50	C430512	99.30	C431020	99.70
C431034	99.70	C431078	98.60	C431123	99.80	C431243	99.10	C431286	99.30
C431335	99.50	C431394	99.60	C431480	99.40	C431522	100.00	C435706	99.70
C435817	99.60	C435893	99.90	C435905	99.60	C436889	99.50	C437010	99.50
C437196	99.90	C437301	99.70	C437517	99.90	C437587	99.70	C437730	99.80
C437733	99.70	C437860	99.50	C437950	99.40	W143275	99.70	W143282	99.70
W143428	99.90	W143437	100.20	W143579	100.50	W144051	100.00	W144170	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.70
3 Sum of Squared Measurements	747004.81
4 Correction Factor (CF): Sum of Measurements Squared / N	746943.12
5 Corrected Sum of Squares (SS)	61.69
6 Variance (V) : SS/(N-1)	0.8336
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.9130
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	2.41
12 Quality Index Lower (QL): (XBAR-L) / S	1.97
13 Estimate of Lot Percent NCF Above U (PU)	0.71
14 Estimate of Lot Percent NCF Below L (PL)	2.33
15 Total Estimate Percent NCF. In Lot (P): PU+PL	3.04
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1569 Lot Descr: KU MX - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 58
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C438151	99.70	C438380	99.70	C438570	99.50	C438626	99.70	C438738	99.50
C438749	99.50	C438754	99.90	C438909	99.70	C438982	99.60	C439209	99.90
C439383	99.90	C439432	99.60	C439473	99.70	C439524	99.90	C439525	100.00
C439727	99.80	C440025	99.60	C440472	99.70	C440777	99.90	C440885	99.90
C440903	100.00	C440966	99.70	C441172	99.80	C441235	99.80	C441388	100.10
C441499	99.80	C441546	99.80	C441774	99.60	C441892	99.70	C442286	99.80
C442306	100.10	C442336	100.10	C442381	100.00	C442627	99.70	C442639	99.60
C442641	99.60	C442759	100.00	C442767	100.00	C442937	99.90	C443279	99.70
C443562	99.30	C443602	99.40	C443609	100.10	C443921	99.50	C444249	99.80
C444335	99.40	C444344	99.50	C444449	99.60	C444501	99.80	C444563	100.00
C444571	99.70	C444723	99.50	C444824	99.90	C4446454	99.90	C447019	99.90
C447046	99.50	C447141	99.50	C447174	99.70	C447181	99.30	C447316	99.40
C447521	99.80	C447602	99.80	C447617	99.10	C447703	99.00	C447954	99.60
C448059	99.60	C448314	99.80	C448840	99.90	C448991	99.90	C449075	99.70
C449231	100.00	C449404	99.60	C449515	99.60	C449577	99.80	C449709	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7479.40
3 Sum of Squared Measurements	745889.44
4 Correction Factor (CF): Sum of Measurements Squared / N	745885.66
5 Corrected Sum of Squares (SS)	3.78
6 Variance (V) : SS/(N-1)	0.0511
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2261
8 Sample Mean(XBAR): Sum X/N	99.73
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.06
12 Quality Index Lower (QL): (XBAR-L) / S	7.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1570 Lot Descr: KU MX - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 59
 Run Date: 01/04/2016
 Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C450102	99.50	C450127	99.50	C450142	99.80	C450391	99.80	C450624	99.70
C450809	99.90	C451310	99.90	C451344	99.60	C451434	99.50	C451500	99.80
C451642	99.70	C451771	99.70	C451782	100.00	C451824	99.70	C452015	99.70
C452150	99.50	C452187	99.50	C452250	99.50	C452443	99.70	C452572	99.70
C452823	99.70	C453194	99.40	C453198	99.70	C453266	99.60	C453421	99.70
C453462	99.90	C453656	99.40	C453768	99.40	C453801	99.70	C453924	99.60
C453981	99.60	C454095	99.80	C454579	99.80	C454716	99.90	C454717	100.20
C454867	100.10	C455014	99.90	C455333	99.80	C455361	99.80	C455395	99.90
C455511	99.80	C455543	99.70	C455809	99.90	C455914	100.00	C455926	99.90
C457719	100.00	C457863	99.90	C457990	100.00	C458000	100.00	C458213	99.70
C458327	99.60	C458351	100.10	C458592	99.80	C458611	99.90	C458660	99.90
C458827	99.90	C458925	99.90	C458996	99.70	C459449	99.90	C459724	99.80
C459976	100.00	C460471	99.70	C460492	100.00	C460746	100.10	C460771	99.90
C460825	99.90	C460826	99.80	C460848	100.00	C461065	99.90	C461379	100.00
C461439	99.80	C461918	100.00	C462073	100.00	C462206	99.80	C462248	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.80
3 Sum of Squared Measurements	746965.50
4 Correction Factor (CF): Sum of Measurements Squared / N	746953.08
5 Corrected Sum of Squares (SS)	2.42
6 Variance (V) : SS/(N-1)	0.0327
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1808
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	12.18
12 Quality Index Lower (QL): (XBAR-L) / S	9.94
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1571 Lot Descr: KU MX - 5
 In Service Population: 993 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 60

Run Date: 01/04/2016

Run Time: 08:36:46 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C462393	99.90	C462407	99.90	C462432	100.10	C462443	100.20	C462475	100.00
C462487	99.60	C462500	99.70	C462508	100.00	C462551	99.90	C462602	99.80
C462650	99.80	C462653	100.00	C462661	99.80	C462719	99.60	C462736	100.00
C462788	99.70	C462844	100.00	C462852	99.60	C462887	99.80	C462930	100.00
C462932	100.10	C462949	100.00	C462984	100.00	C463002	99.90	C463116	99.90
C463206	99.70	C463218	99.40	C463237	99.90	C463275	99.80	C463283	100.90
C463299	100.10	C463319	100.20	C463325	99.80	C463358	100.00	C463373	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3497.10
3 Sum of Squared Measurements	349422.33
4 Correction Factor (CF): Sum of Measurements Squared / N	349420.24
5 Corrected Sum of Squares (SS)	2.09
6 Variance (V) : SS/(N-1)	0.0615
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2479
8 Sample Mean(XBAR): Sum X/N	99.92
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.40
12 Quality Index Lower (QL): (XBAR-L) / S	7.73
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities
2015 Sample Test Program (01/01/2015) to (12/31/2015)

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	SET	REMV	MTRS TST	PASS/FAIL	LOT NUMBER
KU AB1 - 1	Asea Brown Boveri (ABB)	AB1	10,000	75	0	0	75	FAIL TESTING COMPLETE	1512
KU AB1 - 2	Asea Brown Boveri (ABB)	AB1	5,185	75	0	0	75	PASS TESTING COMPLETE	1513
KU ALF - 1	Landis + Gyr	ALF	38	5	0	0	5	PASS TESTING COMPLETE	1514
KU C1S - 1	Sangamo	C1SR	10,000	75	0	0	75	PASS TESTING COMPLETE	1515
KU C1S - 2	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1516
KU C1S - 3	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1517
KU C1S - 4	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1518
KU C1S - 5	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1519
KU C1S - 6	Itron	C1S	3,412	75	0	0	75	PASS TESTING COMPLETE	1520
KU D4S - 1	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1521
KU D4S - 2	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1522
KU D4S - 3	Westinghouse	D4S	5,939	75	0	0	75	PASS TESTING COMPLETE	1523
KU D5S - 1	Westinghouse	D5S	427	25	0	0	25	PASS TESTING COMPLETE	1524
KU I210 - 1	General Electric	I210	5,096	75	0	0	75	PASS TESTING COMPLETE	1525
KU I50 - 1	General Electric	I50S	1,016	35	0	0	35	PASS TESTING COMPLETE	1526
KU I55 - 1	General Electric	I55S	893	35	0	0	35	PASS TESTING COMPLETE	1527
KU I60 - 1	General Electric	I60S	10,000	75	0	0	75	PASS TESTING COMPLETE	1528
KU I60 - 2	General Electric	I60S	10,000	75	0	0	75	PASS TESTING COMPLETE	1529
KU I60 - 3	General Electric	I60S	9,466	75	0	0	75	PASS TESTING COMPLETE	1530
KU I70 - 1	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1531
KU I70 - 2	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1532
KU I70 - 3	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1533
KU I70 - 4	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1534
KU I70 - 5	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1535
KU I70 - 6	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1536
KU I70 - 7	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1537
KU I70 - 8	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1538
KU I70 - 9	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1539
KU I70 - 10	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1540
KU I70 - 11	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1541
KU I70 - 12	General Electric	I70S	4,594	75	0	0	75	PASS TESTING COMPLETE	1542
KU J4S - 1	Sangamo	J4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1543
KU J4S - 2	Sangamo	J4S	1,935	50	0	0	50	PASS TESTING COMPLETE	1544
KU J5S - 1	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1545
KU J5S - 2	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1546
KU J5S - 3	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1547
KU J5S - 4	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1548
KU J5S - 5	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1549
KU J5S - 6	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1550
KU J5S - 7	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1551
KU J5S - 8	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1552
KU J5S - 9	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1553
KU J5S - 10	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1554
KU J5S - 11	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1555
KU J5S - 12	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1556
KU J5S - 13	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1557
KU J5S - 14	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1558
KU J5S - 15	Sangamo	J5S	5,847	75	0	0	75	PASS TESTING COMPLETE	1559
KU MQ - 1	Duncan	MQS	3,712	75	0	0	75	PASS TESTING COMPLETE	1560
KU MS - 1	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	1561
KU MS - 2	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	1562
KU MS - 3	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	1563
KU MS - 4	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	1564
KU MS - 5	Duncan	MS	2,212	50	0	0	50	PASS TESTING COMPLETE	1565
KU MSII - 1	Landis + Gyr	MSII	4,813	75	0	0	75	PASS TESTING COMPLETE	1566
KU MX - 1	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1567

KU MX - 2	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1568
KU MX - 3	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1569
KU MX - 4	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1570
KU MX - 5	Landis + Gyr	MX	993	35	0	0	35	PASS TESTING COMPLETE	1571

TOTALS			495,578	4210	0	0	4210		
--------	--	--	---------	------	---	---	------	--	--

TOTAL LOTS PASSED:	59
TOTAL LOTS FAILED:	1
METERS CANNOT TEST:	0

Report completed successfully with results.