

RECEIVED

FEB 29 2016

PUBLIC SERVICE
COMMISSION



a PPL company

Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

**Louisville Gas and Electric
Company**
State Regulation and Rates
220 W. Main Street
PO Box 32010
Louisville, KY 40232
www.lge-ku.com

Rick E. Lovekamp
Manager Regulatory
Affairs/Tariffs
T 502-627-3780
F 502-627-3213
Rick.lovekamp@lge-ku.com

February 29, 2016

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Louisville Gas and Electric Company

Dear Executive Director:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Louisville Gas and Electric Company** submits the following:

The Certified Test Results of all new meters
received
(Attachment A)

2015 Statistical Sampling Test Results and
Summary
Attachment B)

Executive Director
February 29, 2016

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in blue ink, appearing to read "Rick E. Lovekamp". The signature is fluid and cursive, with the first name "Rick" being the most prominent.

Rick E. Lovekamp

Attachments

ATTACHMENT
A

Certified Test Results

LG&E and KU Energy LLC

5040 Annual Report of New Single Phase Meters

Last Data Update:

02/08/2016 03:07:25

Dynamic Filters

Plant LG&E

Calendar M 01/2015 - 12/2015

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
LG&E	C1S	897834	01/2015	12/16/2014	100.080	99.820	100.0	1
LG&E	C1S	897835	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	897836	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	897837	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	897838	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	897839	01/2015	12/16/2014	100.080	99.840	100.0	1
LG&E	C1S	897840	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	897841	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	897842	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	897843	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	897844	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	897845	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	897846	01/2015	12/16/2014	100.100	99.900	100.0	1
LG&E	C1S	897847	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	897848	01/2015	12/16/2014	100.060	99.860	99.9	1
LG&E	C1S	897849	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897850	01/2015	12/16/2014	100.090	99.950	99.9	1
LG&E	C1S	897851	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	897852	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	897853	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	897854	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	897855	01/2015	12/16/2014	100.080	99.840	100.0	1
LG&E	C1S	897856	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897857	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	897858	01/2015	12/16/2014	100.100	100.000	100.0	1
LG&E	C1S	897859	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	897860	01/2015	12/16/2014	100.060	99.920	100.1	1
LG&E	C1S	897861	01/2015	12/16/2014	100.070	99.950	100.0	1

LG&E	C1S	897862	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	897863	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	897864	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	897865	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	897866	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	897867	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	897868	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	897869	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	897870	01/2015	12/16/2014	100.070	99.880	99.9	1
LG&E	C1S	897871	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	897872	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	897873	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	897874	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	897875	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	897876	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	897877	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	897878	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	897879	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	897880	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	897881	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	897882	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	897883	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	897884	01/2015	12/16/2014	100.070	99.880	99.9	1
LG&E	C1S	897885	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897886	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	897887	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	897888	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	897889	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	897890	01/2015	12/16/2014	100.060	99.940	99.9	1
LG&E	C1S	897891	01/2015	12/16/2014	100.070	99.830	100.0	1
LG&E	C1S	897892	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	897893	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	897894	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	897895	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	897896	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	897897	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	897898	01/2015	12/16/2014	100.050	99.920	100.0	1
LG&E	C1S	897899	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897900	01/2015	12/16/2014	100.080	99.980	100.1	1
LG&E	C1S	897901	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	897902	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	897903	01/2015	12/16/2014	100.070	99.860	100.0	1

LG&E	C1S	897904	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	897905	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	897906	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	897907	01/2015	12/16/2014	100.070	99.940	99.9	1
LG&E	C1S	897908	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	897909	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	897910	01/2015	12/16/2014	100.110	99.940	100.1	1
LG&E	C1S	897911	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	897912	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	897913	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897914	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	897915	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	897916	01/2015	12/16/2014	100.070	99.850	100.1	1
LG&E	C1S	897917	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	897918	01/2015	12/16/2014	100.110	99.920	100.1	1
LG&E	C1S	897919	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	897920	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	897921	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	897922	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	897923	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	897924	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	897925	01/2015	12/16/2014	100.090	99.950	99.9	1
LG&E	C1S	897926	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	897927	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	897928	01/2015	12/16/2014	100.090	100.010	100.0	1
LG&E	C1S	897929	01/2015	12/16/2014	100.100	99.970	99.9	1
LG&E	C1S	897930	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897931	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	897932	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	897933	01/2015	12/16/2014	100.080	99.870	100.1	1
LG&E	C1S	897934	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	897935	01/2015	12/16/2014	100.110	100.000	100.0	1
LG&E	C1S	897936	01/2015	12/16/2014	100.060	100.000	100.0	1
LG&E	C1S	897937	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	897938	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	897939	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	897940	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	897941	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	897942	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	897943	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	897944	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	897945	01/2015	12/16/2014	100.100	99.930	100.1	1

LG&E	C1S	897946	01/2015	12/16/2014	100.070	100.010	99.9	1
LG&E	C1S	897947	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	897948	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	897949	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	897950	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	897951	01/2015	12/16/2014	100.110	99.930	100.0	1
LG&E	C1S	897952	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	897953	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	897954	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	897955	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	897956	01/2015	12/16/2014	100.080	99.920	99.9	1
LG&E	C1S	897957	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	897958	01/2015	12/16/2014	100.070	99.990	100.0	1
LG&E	C1S	897959	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	897960	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	897961	01/2015	12/16/2014	100.080	99.810	100.0	1
LG&E	C1S	897962	01/2015	12/16/2014	100.110	99.900	100.0	1
LG&E	C1S	897963	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	897964	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	897965	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	897966	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	897967	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	897968	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	897969	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	897970	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	897971	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	897972	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	897973	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	897974	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	897975	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	897976	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	897977	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	897978	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	897979	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	897980	01/2015	12/16/2014	100.060	99.970	100.1	1
LG&E	C1S	897981	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	897982	01/2015	12/16/2014	100.110	99.870	100.0	1
LG&E	C1S	897983	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	897984	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	897985	01/2015	12/16/2014	100.070	99.950	99.9	1
LG&E	C1S	897986	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	897987	01/2015	12/16/2014	100.070	99.830	100.0	1

LG&E	C1S	897988	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	897989	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	897990	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	897991	01/2015	12/16/2014	100.080	99.860	100.1	1
LG&E	C1S	897992	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	897993	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	897994	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	897995	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	897996	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	897997	01/2015	12/16/2014	100.060	99.990	99.9	1
LG&E	C1S	897998	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	897999	01/2015	12/16/2014	100.060	99.920	99.9	1
LG&E	C1S	898000	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898001	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898002	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898003	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898004	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898005	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898006	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898007	01/2015	12/16/2014	100.060	99.820	100.0	1
LG&E	C1S	898008	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898009	01/2015	12/16/2014	100.080	100.000	100.0	1
LG&E	C1S	898010	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898011	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898012	01/2015	12/16/2014	100.080	99.870	100.1	1
LG&E	C1S	898013	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898014	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	898015	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898016	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898017	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898018	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898019	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898020	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	898021	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898022	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898023	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898024	01/2015	12/16/2014	100.100	100.020	100.0	1
LG&E	C1S	898025	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898026	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898027	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898028	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	898029	01/2015	12/16/2014	100.070	99.860	100.0	1

LG&E	C1S	898030	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	898031	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	898032	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898033	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898034	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898035	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898036	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	898037	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898038	01/2015	12/16/2014	100.080	99.970	100.1	1
LG&E	C1S	898039	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898040	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898041	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898042	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898043	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	898044	01/2015	12/16/2014	100.050	99.870	99.9	1
LG&E	C1S	898045	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898046	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898047	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898048	01/2015	12/16/2014	100.080	99.940	99.9	1
LG&E	C1S	898049	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898050	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	898051	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898052	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	898053	01/2015	12/16/2014	100.110	99.930	100.0	1
LG&E	C1S	898054	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	898055	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898056	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898057	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898058	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898059	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898060	01/2015	12/16/2014	100.110	100.020	100.0	1
LG&E	C1S	898061	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	898062	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898063	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898064	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898065	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898066	01/2015	12/16/2014	100.090	99.850	100.0	1
LG&E	C1S	898067	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898068	01/2015	12/16/2014	100.060	99.850	100.1	1
LG&E	C1S	898069	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898070	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898071	01/2015	12/16/2014	100.100	99.900	100.1	1

LG&E	C1S	898072	01/2015	12/16/2014	100.090	99.910	99.9	1
LG&E	C1S	898073	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	898074	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898075	01/2015	12/16/2014	100.110	99.900	100.0	1
LG&E	C1S	898076	01/2015	12/16/2014	100.070	99.990	100.0	1
LG&E	C1S	898077	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898078	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898079	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898080	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898081	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	898082	01/2015	12/16/2014	100.110	99.920	100.1	1
LG&E	C1S	898083	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898084	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898085	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	898086	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898087	01/2015	12/16/2014	100.060	99.960	99.9	1
LG&E	C1S	898088	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898089	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898090	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898091	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898092	01/2015	12/16/2014	100.050	99.880	100.0	1
LG&E	C1S	898093	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898094	01/2015	12/16/2014	100.060	99.920	99.9	1
LG&E	C1S	898095	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898096	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898097	01/2015	12/16/2014	100.070	99.850	100.1	1
LG&E	C1S	898098	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	898099	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898100	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	898101	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898102	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898103	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898104	01/2015	12/16/2014	100.110	99.900	100.1	1
LG&E	C1S	898105	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898106	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	898107	01/2015	12/16/2014	100.110	99.970	100.0	1
LG&E	C1S	898108	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898109	01/2015	12/16/2014	100.110	99.900	100.0	1
LG&E	C1S	898110	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	898111	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898112	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898113	01/2015	12/16/2014	100.090	99.910	100.0	1

LG&E	C1S	898114	01/2015	12/16/2014	100.100	99.940	99.9	1
LG&E	C1S	898115	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898116	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	898117	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898118	01/2015	12/16/2014	100.080	100.010	100.0	1
LG&E	C1S	898119	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	898120	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898121	01/2015	12/16/2014	100.050	99.890	100.0	1
LG&E	C1S	898122	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898123	01/2015	12/16/2014	100.090	100.030	100.0	1
LG&E	C1S	898124	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898125	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898126	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898127	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	898128	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898129	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	898130	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898131	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	898132	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898133	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898134	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898135	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898136	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	898137	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898138	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898139	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	898140	01/2015	12/16/2014	100.090	100.000	100.1	1
LG&E	C1S	898141	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898142	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	898143	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898144	01/2015	12/16/2014	100.090	99.940	99.9	1
LG&E	C1S	898145	01/2015	12/16/2014	100.070	99.870	100.1	1
LG&E	C1S	898146	01/2015	12/16/2014	100.050	99.860	100.0	1
LG&E	C1S	898147	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898148	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898149	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898150	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898151	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898152	01/2015	12/16/2014	100.110	100.010	100.0	1
LG&E	C1S	898153	01/2015	12/16/2014	100.060	99.880	99.9	1
LG&E	C1S	898154	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898155	01/2015	12/16/2014	100.110	99.940	100.1	1

LG&E	C1S	898156	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898157	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898158	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898159	01/2015	12/16/2014	100.090	100.010	100.0	1
LG&E	C1S	898160	01/2015	12/16/2014	100.100	100.000	100.1	1
LG&E	C1S	898161	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898162	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898163	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	898164	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898165	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	898166	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898167	01/2015	12/16/2014	100.090	100.000	100.1	1
LG&E	C1S	898168	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	898169	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	898170	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	898171	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898172	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898173	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	898174	01/2015	12/16/2014	100.100	100.000	100.1	1
LG&E	C1S	898175	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898176	01/2015	12/16/2014	100.070	99.960	99.9	1
LG&E	C1S	898177	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898178	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	898179	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898180	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898181	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898182	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898183	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	898184	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898185	01/2015	12/16/2014	100.090	99.890	100.0	1
LG&E	C1S	898186	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898187	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	898188	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898189	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898190	01/2015	12/16/2014	100.070	99.830	100.0	1
LG&E	C1S	898191	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	898192	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	898193	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898194	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898195	01/2015	12/16/2014	100.060	99.910	99.9	1
LG&E	C1S	898196	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	898197	01/2015	12/16/2014	100.100	99.990	100.0	1

LG&E	C1S	898198	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898199	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898200	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898201	01/2015	12/16/2014	100.110	99.930	100.1	1
LG&E	C1S	898202	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898203	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898204	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898205	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	898206	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898207	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	898208	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898209	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898210	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898211	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898212	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	898213	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898214	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898215	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898216	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898217	01/2015	12/16/2014	100.100	100.000	100.1	1
LG&E	C1S	898218	01/2015	12/16/2014	100.080	99.910	99.9	1
LG&E	C1S	898219	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898220	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898221	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	898222	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898223	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	898224	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898225	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898226	01/2015	12/16/2014	100.110	99.990	100.0	1
LG&E	C1S	898227	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898228	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898229	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898230	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898231	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898232	01/2015	12/16/2014	100.060	99.920	100.1	1
LG&E	C1S	898233	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898234	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	898235	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898236	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898237	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898238	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898239	01/2015	12/16/2014	100.090	99.920	100.0	1

LG&E	C1S	898240	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	898241	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898242	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898243	01/2015	12/16/2014	100.080	99.870	100.1	1
LG&E	C1S	898244	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898245	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898246	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898247	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898248	01/2015	12/16/2014	100.060	99.970	99.9	1
LG&E	C1S	898249	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898250	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898251	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898252	01/2015	12/16/2014	100.100	100.020	100.0	1
LG&E	C1S	898253	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898254	01/2015	12/16/2014	100.100	100.020	100.1	1
LG&E	C1S	898255	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898256	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898257	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898258	01/2015	12/16/2014	100.100	100.040	100.0	1
LG&E	C1S	898259	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898260	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898261	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898262	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	898263	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898264	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898265	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898266	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898267	01/2015	12/16/2014	100.090	100.000	100.1	1
LG&E	C1S	898268	01/2015	12/16/2014	100.050	99.910	100.0	1
LG&E	C1S	898269	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898270	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898271	01/2015	12/16/2014	100.070	99.880	100.1	1
LG&E	C1S	898272	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898273	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898274	01/2015	12/16/2014	100.110	99.970	100.0	1
LG&E	C1S	898275	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898276	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898277	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898278	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	898279	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898280	01/2015	12/16/2014	100.110	99.920	100.1	1
LG&E	C1S	898281	01/2015	12/16/2014	100.060	99.950	100.1	1

LG&E	C1S	898282	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898283	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	898284	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	898285	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898286	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898287	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	898288	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898289	01/2015	12/16/2014	100.060	99.840	100.1	1
LG&E	C1S	898290	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	898291	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898292	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	898293	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898294	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898295	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	898296	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898297	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898298	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898299	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	898300	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	898301	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898302	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898303	01/2015	12/16/2014	100.110	99.900	100.1	1
LG&E	C1S	898304	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	898305	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	898306	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	898307	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	898308	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898309	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898310	01/2015	12/16/2014	100.060	99.940	100.1	1
LG&E	C1S	898311	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898312	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	898313	01/2015	12/16/2014	100.080	99.850	100.1	1
LG&E	C1S	898314	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	898315	01/2015	12/16/2014	100.080	99.990	100.1	1
LG&E	C1S	898316	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	898317	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898318	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898319	01/2015	12/16/2014	100.080	99.860	100.1	1
LG&E	C1S	898320	01/2015	12/16/2014	100.090	100.000	99.9	1
LG&E	C1S	898321	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898322	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898323	01/2015	12/16/2014	100.080	99.900	100.0	1

LG&E	C1S	898324	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	898325	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898326	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	898327	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898328	01/2015	12/16/2014	100.110	99.930	100.1	1
LG&E	C1S	898329	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898330	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898331	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898332	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898333	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898334	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898335	01/2015	12/16/2014	100.060	99.820	100.0	1
LG&E	C1S	898336	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898337	01/2015	12/16/2014	100.070	99.940	100.1	1
LG&E	C1S	898338	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898339	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898340	01/2015	12/16/2014	100.090	99.880	100.1	1
LG&E	C1S	898341	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898342	01/2015	12/16/2014	100.070	99.990	100.0	1
LG&E	C1S	898343	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898344	01/2015	12/16/2014	100.080	99.990	100.0	1
LG&E	C1S	898345	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	898346	01/2015	12/16/2014	100.070	99.990	100.1	1
LG&E	C1S	898347	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898348	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898349	01/2015	12/16/2014	100.070	99.860	99.9	1
LG&E	C1S	898350	01/2015	12/16/2014	100.070	99.930	100.1	1
LG&E	C1S	898351	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	898352	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898353	01/2015	12/16/2014	100.100	99.940	99.9	1
LG&E	C1S	898354	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898355	01/2015	12/16/2014	100.100	100.000	100.0	1
LG&E	C1S	898356	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898357	01/2015	12/16/2014	100.060	99.880	99.9	1
LG&E	C1S	898358	01/2015	12/16/2014	100.110	99.930	100.0	1
LG&E	C1S	898359	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898360	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	898361	01/2015	12/16/2014	100.110	99.910	100.1	1
LG&E	C1S	898362	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898363	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	898364	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898365	01/2015	12/16/2014	100.060	99.920	100.0	1

LG&E	C1S	898366	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898367	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	898368	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898369	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898370	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898371	01/2015	12/16/2014	100.100	99.850	100.0	1
LG&E	C1S	898372	01/2015	12/16/2014	100.090	100.020	100.0	1
LG&E	C1S	898373	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898374	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898375	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898376	01/2015	12/16/2014	100.110	99.990	100.1	1
LG&E	C1S	898377	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898378	01/2015	12/16/2014	100.110	99.960	100.1	1
LG&E	C1S	898379	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898380	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898381	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898382	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898383	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898384	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898385	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898386	01/2015	12/16/2014	100.060	99.960	99.9	1
LG&E	C1S	898387	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898388	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898389	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898390	01/2015	12/16/2014	100.100	99.900	100.0	1
LG&E	C1S	898391	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898392	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	898393	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898394	01/2015	12/16/2014	100.070	99.830	100.0	1
LG&E	C1S	898395	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898396	01/2015	12/16/2014	100.100	99.870	100.1	1
LG&E	C1S	898397	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898398	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	898399	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	898400	01/2015	12/16/2014	100.090	99.930	99.9	1
LG&E	C1S	898401	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898402	01/2015	12/16/2014	100.060	99.980	100.0	1
LG&E	C1S	898403	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898404	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898405	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898406	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	898407	01/2015	12/16/2014	100.090	99.940	99.9	1

LG&E	C1S	898408	01/2015	12/16/2014	100.110	99.980	100.1	1
LG&E	C1S	898409	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	898410	01/2015	12/16/2014	100.070	99.920	99.9	1
LG&E	C1S	898411	01/2015	12/16/2014	100.110	99.900	100.1	1
LG&E	C1S	898412	01/2015	12/16/2014	100.110	99.940	100.1	1
LG&E	C1S	898413	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	898414	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898415	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898416	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898417	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	898418	01/2015	12/16/2014	100.110	99.890	100.0	1
LG&E	C1S	898419	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898420	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898421	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	898422	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	898423	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898424	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	898425	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	898426	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898427	01/2015	12/16/2014	100.110	100.010	100.0	1
LG&E	C1S	898428	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898429	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898430	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898431	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	898432	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	898433	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898434	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898435	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898436	01/2015	12/16/2014	100.110	99.920	100.0	1
LG&E	C1S	898437	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898438	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898439	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898440	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898441	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	898442	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898443	01/2015	12/16/2014	100.080	100.010	100.1	1
LG&E	C1S	898444	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	898445	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898446	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898447	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898448	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898449	01/2015	12/16/2014	100.080	99.970	100.0	1

LG&E	C1S	898450	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898451	01/2015	12/16/2014	100.070	99.880	100.1	1
LG&E	C1S	898452	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898453	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898454	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898455	01/2015	12/16/2014	100.100	99.870	100.0	1
LG&E	C1S	898456	01/2015	12/16/2014	100.060	99.940	99.9	1
LG&E	C1S	898457	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898458	01/2015	12/16/2014	100.060	99.820	100.0	1
LG&E	C1S	898459	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898460	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898461	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	898462	01/2015	12/16/2014	100.050	99.900	100.0	1
LG&E	C1S	898463	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898464	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898465	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	898466	01/2015	12/16/2014	100.060	99.850	100.1	1
LG&E	C1S	898467	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898468	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898469	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	898470	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	898471	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	898472	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898473	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	898474	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898475	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898476	01/2015	12/16/2014	100.070	100.010	100.0	1
LG&E	C1S	898477	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898478	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898479	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898480	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898481	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898482	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	898483	01/2015	12/16/2014	100.060	99.920	100.1	1
LG&E	C1S	898484	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	898485	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898486	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898487	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	898488	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898489	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898490	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898491	01/2015	12/16/2014	100.100	99.910	100.0	1

LG&E	C1S	898492	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898493	01/2015	12/16/2014	100.070	99.990	100.0	1
LG&E	C1S	898494	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	898495	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	898496	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	898497	01/2015	12/16/2014	100.070	99.930	100.1	1
LG&E	C1S	898498	01/2015	12/16/2014	100.050	99.920	100.0	1
LG&E	C1S	898499	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898500	01/2015	12/16/2014	100.060	99.950	99.9	1
LG&E	C1S	898501	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	898502	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898503	01/2015	12/16/2014	100.060	99.920	99.9	1
LG&E	C1S	898504	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898505	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898506	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	898507	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898508	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898509	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898510	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898511	01/2015	12/16/2014	100.100	99.890	100.0	1
LG&E	C1S	898512	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898513	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898514	01/2015	12/16/2014	100.070	99.950	100.1	1
LG&E	C1S	898515	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	898516	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	898517	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898518	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898519	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898520	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898521	01/2015	12/16/2014	100.110	99.960	100.1	1
LG&E	C1S	898522	01/2015	12/16/2014	100.050	99.900	100.0	1
LG&E	C1S	898523	01/2015	12/16/2014	100.100	99.980	100.2	1
LG&E	C1S	898524	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	898525	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	898526	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898527	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898528	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898529	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898530	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898531	01/2015	12/16/2014	100.060	99.990	100.0	1
LG&E	C1S	898532	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898533	01/2015	12/16/2014	100.070	99.860	100.1	1

LG&E	C1S	898534	01/2015	12/16/2014	100.070	99.970	100.1	1
LG&E	C1S	898535	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	898536	01/2015	12/16/2014	100.060	99.880	100.1	1
LG&E	C1S	898537	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898538	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898539	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898540	01/2015	12/16/2014	100.100	100.040	100.0	1
LG&E	C1S	898541	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	898542	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	898543	01/2015	12/16/2014	100.070	99.870	100.1	1
LG&E	C1S	898544	01/2015	12/16/2014	100.090	100.030	100.0	1
LG&E	C1S	898545	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898546	01/2015	12/16/2014	100.070	99.920	99.9	1
LG&E	C1S	898547	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	898548	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898549	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	898550	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898551	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898552	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	898553	01/2015	12/16/2014	100.070	99.950	99.9	1
LG&E	C1S	898554	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898555	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898556	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	898557	01/2015	12/16/2014	100.110	100.060	100.1	1
LG&E	C1S	898558	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898559	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898560	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	898561	01/2015	12/16/2014	100.110	99.930	100.1	1
LG&E	C1S	898562	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898563	01/2015	12/16/2014	100.060	100.000	100.0	1
LG&E	C1S	898564	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898565	01/2015	12/16/2014	100.100	99.870	100.1	1
LG&E	C1S	898566	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898567	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898568	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	898569	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898570	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	898571	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898572	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898573	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	898574	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898575	01/2015	12/16/2014	100.060	99.840	100.1	1

LG&E	C1S	898576	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898577	01/2015	12/16/2014	100.080	99.970	100.1	1
LG&E	C1S	898578	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	898579	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898580	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898581	01/2015	12/16/2014	100.060	99.950	100.1	1
LG&E	C1S	898582	01/2015	12/16/2014	100.100	100.000	100.0	1
LG&E	C1S	898583	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898584	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898585	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898586	01/2015	12/16/2014	100.070	99.950	100.1	1
LG&E	C1S	898587	01/2015	12/16/2014	100.050	99.930	100.0	1
LG&E	C1S	898588	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898589	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	898590	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898591	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898592	01/2015	12/16/2014	100.110	99.940	100.1	1
LG&E	C1S	898593	01/2015	12/16/2014	100.060	99.920	99.9	1
LG&E	C1S	898594	01/2015	12/16/2014	100.100	99.880	100.1	1
LG&E	C1S	898595	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898596	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	898597	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898598	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898599	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898600	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898601	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898602	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898603	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898604	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	898605	01/2015	12/16/2014	100.060	99.950	100.1	1
LG&E	C1S	898606	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898607	01/2015	12/16/2014	100.070	99.900	99.9	1
LG&E	C1S	898608	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898609	01/2015	12/16/2014	100.090	99.940	99.9	1
LG&E	C1S	898610	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	898611	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898612	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898613	01/2015	12/16/2014	100.060	99.860	100.1	1
LG&E	C1S	898614	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	898615	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898616	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898617	01/2015	12/16/2014	100.060	99.830	100.1	1

LG&E	C1S	898618	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	898619	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898620	01/2015	12/16/2014	100.080	99.870	100.1	1
LG&E	C1S	898621	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	898622	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	898623	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898624	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898625	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898626	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898627	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898628	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898629	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898630	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	898631	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898632	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898633	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898634	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898635	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	898636	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898637	01/2015	12/16/2014	100.070	99.980	100.1	1
LG&E	C1S	898638	01/2015	12/16/2014	100.100	99.860	100.0	1
LG&E	C1S	898639	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898640	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	898641	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898642	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898643	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	898644	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898645	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	898646	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	898647	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898648	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	898649	01/2015	12/16/2014	100.080	99.900	99.9	1
LG&E	C1S	898650	01/2015	12/16/2014	100.060	99.820	100.0	1
LG&E	C1S	898651	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	898652	01/2015	12/16/2014	100.080	99.990	100.0	1
LG&E	C1S	898653	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898654	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898655	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	898656	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898657	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898658	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898659	01/2015	12/16/2014	100.050	99.920	100.1	1

LG&E	C1S	898660	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898661	01/2015	12/16/2014	100.080	100.000	100.0	1
LG&E	C1S	898662	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898663	01/2015	12/16/2014	100.090	99.890	100.0	1
LG&E	C1S	898664	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	898665	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898666	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	898667	01/2015	12/16/2014	100.110	99.980	100.0	1
LG&E	C1S	898668	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898669	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898670	01/2015	12/16/2014	100.100	99.860	100.0	1
LG&E	C1S	898671	01/2015	12/16/2014	100.050	99.950	99.9	1
LG&E	C1S	898672	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	898673	01/2015	12/16/2014	100.080	100.000	100.0	1
LG&E	C1S	898674	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898675	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	898676	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898677	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	898678	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898679	01/2015	12/16/2014	100.100	99.900	100.0	1
LG&E	C1S	898680	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898681	01/2015	12/16/2014	100.060	99.880	100.1	1
LG&E	C1S	898682	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898683	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898684	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898685	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	898686	01/2015	12/16/2014	100.080	99.910	99.9	1
LG&E	C1S	898687	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898688	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898689	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	898690	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898691	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898692	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898693	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898694	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	898695	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898696	01/2015	12/16/2014	100.050	99.970	99.9	1
LG&E	C1S	898697	01/2015	12/16/2014	100.060	99.990	99.9	1
LG&E	C1S	898698	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898699	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898700	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	898701	01/2015	12/16/2014	100.070	99.880	100.0	1

LG&E	C1S	898702	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898703	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898704	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898705	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898706	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898707	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	898708	01/2015	12/16/2014	100.100	99.840	100.1	1
LG&E	C1S	898709	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898710	01/2015	12/16/2014	100.060	99.890	99.9	1
LG&E	C1S	898711	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	898712	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898713	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898714	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898715	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898716	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898717	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898718	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898719	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	898720	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898721	01/2015	12/16/2014	100.060	99.940	99.9	1
LG&E	C1S	898722	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	898723	01/2015	12/16/2014	100.070	99.940	99.9	1
LG&E	C1S	898724	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898725	01/2015	12/16/2014	100.060	100.000	99.9	1
LG&E	C1S	898726	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	898727	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898728	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	898729	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	898730	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898731	01/2015	12/16/2014	100.080	99.860	100.1	1
LG&E	C1S	898732	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	898733	01/2015	12/16/2014	100.050	99.850	100.0	1
LG&E	C1S	898734	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898735	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	898736	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898737	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898738	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898739	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898740	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898741	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	898742	01/2015	12/16/2014	100.060	99.890	99.9	1
LG&E	C1S	898743	01/2015	12/16/2014	100.080	99.830	100.0	1

LG&E	C1S	898744	01/2015	12/16/2014	100.080	100.020	99.9	1
LG&E	C1S	898745	01/2015	12/16/2014	100.100	99.890	100.0	1
LG&E	C1S	898746	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898747	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898748	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898749	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898750	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	898751	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898752	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	898753	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898754	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898755	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898756	01/2015	12/16/2014	100.100	100.030	100.1	1
LG&E	C1S	898757	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	898758	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	898759	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	898760	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898761	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898762	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	898763	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898764	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898765	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898766	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898767	01/2015	12/16/2014	100.070	99.820	100.0	1
LG&E	C1S	898768	01/2015	12/16/2014	100.070	99.940	100.1	1
LG&E	C1S	898769	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898770	01/2015	12/16/2014	100.080	100.020	100.0	1
LG&E	C1S	898771	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898772	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898773	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	898774	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898775	01/2015	12/16/2014	100.070	99.930	100.1	1
LG&E	C1S	898776	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	898777	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898778	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898779	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898780	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898781	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	898782	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898783	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	898784	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898785	01/2015	12/16/2014	100.080	99.910	100.0	1

LG&E	C1S	898786	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898787	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898788	01/2015	12/16/2014	100.070	99.870	100.1	1
LG&E	C1S	898789	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	898790	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898791	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898792	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	898793	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	898794	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898795	01/2015	12/16/2014	100.060	99.940	100.1	1
LG&E	C1S	898796	01/2015	12/16/2014	100.110	99.960	100.0	1
LG&E	C1S	898797	01/2015	12/16/2014	100.070	99.820	100.0	1
LG&E	C1S	898798	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	898799	01/2015	12/16/2014	100.070	99.920	99.9	1
LG&E	C1S	898800	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898801	01/2015	12/16/2014	100.090	99.970	100.1	1
LG&E	C1S	898802	01/2015	12/16/2014	100.070	99.850	100.2	1
LG&E	C1S	898803	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	898804	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898805	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898806	01/2015	12/16/2014	100.090	99.990	100.1	1
LG&E	C1S	898807	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	898808	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	898809	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898810	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898811	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898812	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898813	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	898814	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898815	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898816	01/2015	12/16/2014	100.110	99.920	100.1	1
LG&E	C1S	898817	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	898818	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898819	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898820	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	898821	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898822	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898823	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	898824	01/2015	12/16/2014	100.060	99.950	100.1	1
LG&E	C1S	898825	01/2015	12/16/2014	100.060	99.870	99.9	1
LG&E	C1S	898826	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898827	01/2015	12/16/2014	100.070	99.920	100.1	1

LG&E	C1S	898828	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898829	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898830	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898831	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	898832	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898833	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898834	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	898835	01/2015	12/16/2014	100.090	99.970	99.9	1
LG&E	C1S	898836	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898837	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898838	01/2015	12/16/2014	100.070	99.860	100.1	1
LG&E	C1S	898839	01/2015	12/16/2014	100.060	99.880	99.9	1
LG&E	C1S	898840	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	898841	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	898842	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	898843	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	898844	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898845	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	898846	01/2015	12/16/2014	100.060	99.940	100.1	1
LG&E	C1S	898847	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898848	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898849	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	898850	01/2015	12/16/2014	100.070	100.000	99.9	1
LG&E	C1S	898851	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898852	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898853	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898854	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	898855	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	898856	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	898857	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898858	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	898859	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898860	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898861	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898862	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898863	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898864	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898865	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	898866	01/2015	12/16/2014	100.100	99.920	100.0	1
LG&E	C1S	898867	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	898868	01/2015	12/16/2014	100.080	99.930	100.2	1
LG&E	C1S	898869	01/2015	12/16/2014	100.060	99.890	99.9	1

LG&E	C1S	898870	01/2015	12/16/2014	100.070	99.810	100.1	1
LG&E	C1S	898871	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	898872	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	898873	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	898874	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898875	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898876	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	898877	01/2015	12/16/2014	100.090	99.860	100.1	1
LG&E	C1S	898878	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	898879	01/2015	12/16/2014	100.080	99.920	100.2	1
LG&E	C1S	898880	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	898881	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	898882	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898883	01/2015	12/16/2014	100.070	99.880	99.9	1
LG&E	C1S	898884	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898885	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	898886	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	898887	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898888	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898889	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	898890	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898891	01/2015	12/16/2014	100.110	99.920	100.0	1
LG&E	C1S	898892	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	898893	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	898894	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898895	01/2015	12/16/2014	100.110	99.940	100.0	1
LG&E	C1S	898896	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	898897	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898898	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	898899	01/2015	12/16/2014	100.090	99.880	100.1	1
LG&E	C1S	898900	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	898901	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	898902	01/2015	12/16/2014	100.100	99.950	100.2	1
LG&E	C1S	898903	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	898904	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	898905	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	898906	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	898907	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898908	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	898909	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898910	01/2015	12/16/2014	100.090	99.870	99.9	1
LG&E	C1S	898911	01/2015	12/16/2014	100.100	99.940	100.1	1

LG&E	C1S	898912	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	898913	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	898914	01/2015	12/16/2014	100.060	99.910	100.1	1
LG&E	C1S	898915	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898916	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898917	01/2015	12/16/2014	100.070	99.880	100.1	1
LG&E	C1S	898918	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898919	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898920	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898921	01/2015	12/16/2014	100.060	99.970	100.1	1
LG&E	C1S	898922	01/2015	12/16/2014	100.080	99.930	99.9	1
LG&E	C1S	898923	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898924	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	898925	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898926	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898927	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	898928	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	898929	01/2015	12/16/2014	100.080	99.880	100.1	1
LG&E	C1S	898930	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	898931	01/2015	12/16/2014	100.110	99.980	100.1	1
LG&E	C1S	898932	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	898933	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	898934	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898935	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	898936	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	898937	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898938	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898939	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	898940	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	898941	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	898942	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898943	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	898944	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	898945	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	898946	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	898947	01/2015	12/16/2014	100.090	99.970	99.9	1
LG&E	C1S	898948	01/2015	12/16/2014	100.060	99.930	100.1	1
LG&E	C1S	898949	01/2015	12/16/2014	100.100	99.950	99.9	1
LG&E	C1S	898950	01/2015	12/16/2014	100.060	99.940	100.1	1
LG&E	C1S	898951	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	898952	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	898953	01/2015	12/16/2014	100.100	99.940	100.1	1

LG&E	C1S	898954	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	898955	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	898956	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	898957	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	898958	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	898959	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	898960	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	898961	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	898962	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	898963	01/2015	12/16/2014	100.060	99.920	100.1	1
LG&E	C1S	898964	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	898965	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898966	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	898967	01/2015	12/16/2014	100.110	100.020	100.1	1
LG&E	C1S	898968	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	898969	01/2015	12/16/2014	100.070	99.930	100.1	1
LG&E	C1S	898970	01/2015	12/16/2014	100.070	99.950	100.1	1
LG&E	C1S	898971	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	898972	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	898973	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	898974	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	898975	01/2015	12/16/2014	100.080	99.830	100.1	1
LG&E	C1S	898976	01/2015	12/16/2014	100.100	100.000	100.1	1
LG&E	C1S	898977	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	898978	01/2015	12/16/2014	100.060	99.810	100.1	1
LG&E	C1S	898979	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	898980	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	898981	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	898982	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	898983	01/2015	12/16/2014	100.090	99.890	100.0	1
LG&E	C1S	898984	01/2015	12/16/2014	100.090	100.010	100.1	1
LG&E	C1S	898985	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	898986	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	898987	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	898988	01/2015	12/16/2014	100.110	100.010	100.0	1
LG&E	C1S	898989	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	898990	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	898991	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	898992	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	898993	01/2015	12/16/2014	100.070	99.820	100.0	1
LG&E	C1S	898994	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	898995	01/2015	12/16/2014	100.070	99.940	100.1	1

LG&E	C1S	898996	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	898997	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	898998	01/2015	12/16/2014	100.070	99.870	100.1	1
LG&E	C1S	898999	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899000	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	899001	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	899002	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899003	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	899004	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899005	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899006	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899007	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899008	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899009	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899010	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	899011	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899012	01/2015	12/16/2014	100.060	99.880	99.9	1
LG&E	C1S	899013	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	899014	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	899015	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899016	01/2015	12/16/2014	100.100	100.050	100.0	1
LG&E	C1S	899017	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899018	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899019	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899020	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	899021	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899022	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899023	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899024	01/2015	12/16/2014	100.080	99.880	100.2	1
LG&E	C1S	899025	01/2015	12/16/2014	100.080	99.970	100.1	1
LG&E	C1S	899026	01/2015	12/16/2014	100.060	99.860	100.1	1
LG&E	C1S	899027	01/2015	12/16/2014	100.110	99.990	100.0	1
LG&E	C1S	899028	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	899029	01/2015	12/16/2014	100.090	99.990	100.1	1
LG&E	C1S	899030	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899031	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899032	01/2015	12/16/2014	100.110	99.980	100.0	1
LG&E	C1S	899033	01/2015	12/16/2014	100.080	99.920	99.9	1
LG&E	C1S	899034	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899035	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	899036	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899037	01/2015	12/16/2014	100.070	99.920	100.1	1

LG&E	C1S	899038	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	899039	01/2015	12/16/2014	100.080	100.010	100.0	1
LG&E	C1S	899040	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	899041	01/2015	12/16/2014	100.060	99.910	99.9	1
LG&E	C1S	899042	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899043	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899044	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	899045	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899046	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899047	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899048	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899049	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899050	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	899051	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	899052	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899053	01/2015	12/16/2014	100.060	99.910	99.9	1
LG&E	C1S	899054	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899055	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	899056	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	899057	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899058	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	899059	01/2015	12/16/2014	100.050	99.840	100.0	1
LG&E	C1S	899060	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899061	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899062	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899063	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	899064	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899065	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899066	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899067	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	899068	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	899069	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899070	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899071	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899072	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899073	01/2015	12/16/2014	100.060	99.920	100.1	1
LG&E	C1S	899074	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	899075	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	899076	01/2015	12/16/2014	100.060	99.860	100.1	1
LG&E	C1S	899077	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899078	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899079	01/2015	12/16/2014	100.060	99.920	99.9	1

LG&E	C1S	899080	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899081	01/2015	12/16/2014	100.080	99.990	99.9	1
LG&E	C1S	899082	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899083	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899084	01/2015	12/16/2014	100.100	99.890	100.0	1
LG&E	C1S	899085	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899086	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899087	01/2015	12/16/2014	100.060	99.840	100.1	1
LG&E	C1S	899088	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899089	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899090	01/2015	12/16/2014	100.080	99.990	99.9	1
LG&E	C1S	899091	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899092	01/2015	12/16/2014	100.110	99.970	100.0	1
LG&E	C1S	899093	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899094	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899095	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899096	01/2015	12/16/2014	100.080	99.980	99.9	1
LG&E	C1S	899097	01/2015	12/16/2014	100.080	99.950	99.9	1
LG&E	C1S	899098	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899099	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899100	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899101	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	899102	01/2015	12/16/2014	100.100	100.030	100.0	1
LG&E	C1S	899103	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899104	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899105	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	899106	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899107	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899108	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	899109	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899110	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	899111	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	899112	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	899113	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899114	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	899115	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899116	01/2015	12/16/2014	100.080	99.820	100.0	1
LG&E	C1S	899117	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	899118	01/2015	12/16/2014	100.070	100.000	100.1	1
LG&E	C1S	899119	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899120	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899121	01/2015	12/16/2014	100.060	99.900	100.1	1

LG&E	C1S	899122	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	899123	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899124	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	899125	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899126	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899127	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899128	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899129	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	899130	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	899131	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899132	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899133	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899134	01/2015	12/16/2014	100.100	100.000	99.9	1
LG&E	C1S	899135	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899136	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	899137	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899138	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	899139	01/2015	12/16/2014	100.110	99.920	100.1	1
LG&E	C1S	899140	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899141	01/2015	12/16/2014	100.060	99.860	100.1	1
LG&E	C1S	899142	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	899143	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	899144	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899145	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899146	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	899147	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899148	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	899149	01/2015	12/16/2014	100.050	99.860	100.0	1
LG&E	C1S	899150	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	899151	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899152	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899153	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	899154	01/2015	12/16/2014	100.070	99.880	100.1	1
LG&E	C1S	899155	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899156	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	899157	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899158	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	899159	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899160	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899161	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	899162	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899163	01/2015	12/16/2014	100.080	99.930	100.0	1

LG&E	C1S	899164	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899165	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899166	01/2015	12/16/2014	100.070	99.900	100.1	1
LG&E	C1S	899167	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899168	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	899169	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899170	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	899171	01/2015	12/16/2014	100.110	100.010	100.0	1
LG&E	C1S	899172	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899173	01/2015	12/16/2014	100.080	100.000	100.0	1
LG&E	C1S	899174	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899175	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	899176	01/2015	12/16/2014	100.070	99.980	100.1	1
LG&E	C1S	899177	01/2015	12/16/2014	100.070	99.970	100.1	1
LG&E	C1S	899178	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899179	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899180	01/2015	12/16/2014	100.110	99.980	100.0	1
LG&E	C1S	899181	01/2015	12/16/2014	100.100	100.030	100.1	1
LG&E	C1S	899182	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899183	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899184	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899185	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899186	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899187	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899188	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899189	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899190	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899191	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	899192	01/2015	12/16/2014	100.070	99.860	99.9	1
LG&E	C1S	899193	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899194	01/2015	12/16/2014	100.070	99.910	99.9	1
LG&E	C1S	899195	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899196	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899197	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899198	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899199	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899200	01/2015	12/16/2014	100.060	99.960	100.1	1
LG&E	C1S	899201	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	899202	01/2015	12/16/2014	100.100	99.850	100.1	1
LG&E	C1S	899203	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899204	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	899205	01/2015	12/16/2014	100.100	99.940	100.1	1

LG&E	C1S	899206	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	899207	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	899208	01/2015	12/16/2014	100.070	99.990	100.0	1
LG&E	C1S	899209	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899210	01/2015	12/16/2014	100.060	100.000	100.0	1
LG&E	C1S	899211	01/2015	12/16/2014	100.100	99.930	99.9	1
LG&E	C1S	899212	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899213	01/2015	12/16/2014	100.110	99.880	100.0	1
LG&E	C1S	899214	01/2015	12/16/2014	100.080	100.010	99.9	1
LG&E	C1S	899215	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899216	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899217	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899218	01/2015	12/16/2014	100.110	99.950	100.1	1
LG&E	C1S	899219	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	899220	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899221	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	899222	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899223	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	899224	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899225	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899226	01/2015	12/16/2014	100.110	99.930	100.1	1
LG&E	C1S	899227	01/2015	12/16/2014	100.110	99.910	100.1	1
LG&E	C1S	899228	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	899229	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	899230	01/2015	12/16/2014	100.090	99.810	99.9	1
LG&E	C1S	899231	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	899232	01/2015	12/16/2014	100.080	99.870	100.1	1
LG&E	C1S	899233	01/2015	12/16/2014	100.060	99.820	100.0	1
LG&E	C1S	899234	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899235	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899236	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899237	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899238	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	899239	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899240	01/2015	12/16/2014	100.050	99.810	100.0	1
LG&E	C1S	899241	01/2015	12/16/2014	100.050	99.900	100.0	1
LG&E	C1S	899242	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	899243	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	899244	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899245	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	899246	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899247	01/2015	12/16/2014	100.080	99.960	100.0	1

LG&E	C1S	899248	01/2015	12/16/2014	100.070	100.010	100.0	1
LG&E	C1S	899249	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899250	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899251	01/2015	12/16/2014	100.110	99.940	100.1	1
LG&E	C1S	899252	01/2015	12/16/2014	100.090	100.020	100.0	1
LG&E	C1S	899253	01/2015	12/16/2014	100.100	100.000	100.1	1
LG&E	C1S	899254	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899255	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899256	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899257	01/2015	12/16/2014	100.070	99.900	99.9	1
LG&E	C1S	899258	01/2015	12/16/2014	100.060	99.810	100.0	1
LG&E	C1S	899259	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	899260	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	899261	01/2015	12/16/2014	100.100	100.010	100.0	1
LG&E	C1S	899262	01/2015	12/16/2014	100.070	99.930	100.1	1
LG&E	C1S	899263	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899264	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	899265	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899266	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899267	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	899268	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	899269	01/2015	12/16/2014	100.080	99.810	100.0	1
LG&E	C1S	899270	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899271	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899272	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	899273	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899274	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899275	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899276	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	899277	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899278	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899279	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899280	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899281	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	899282	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	899283	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	899284	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899285	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	899286	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899287	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899288	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899289	01/2015	12/16/2014	100.100	99.900	100.1	1

LG&E	C1S	899290	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	899291	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	899292	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	899293	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899294	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899295	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899296	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899297	01/2015	12/16/2014	100.050	99.850	100.0	1
LG&E	C1S	899298	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899299	01/2015	12/16/2014	100.050	99.820	100.0	1
LG&E	C1S	899300	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	899301	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899302	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899303	01/2015	12/16/2014	100.060	99.840	100.1	1
LG&E	C1S	899304	01/2015	12/16/2014	100.090	99.840	100.0	1
LG&E	C1S	899305	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	899306	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	899307	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899308	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899309	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899310	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	899311	01/2015	12/16/2014	100.060	99.910	100.1	1
LG&E	C1S	899312	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	899313	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	899314	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899315	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899316	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899317	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899318	01/2015	12/16/2014	100.070	99.830	100.0	1
LG&E	C1S	899319	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899320	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899321	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899322	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	899323	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	899324	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899325	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899326	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899327	01/2015	12/16/2014	100.060	99.990	100.0	1
LG&E	C1S	899328	01/2015	12/16/2014	100.110	99.900	100.0	1
LG&E	C1S	899329	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	899330	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899331	01/2015	12/16/2014	100.070	99.940	100.0	1

LG&E	C1S	899332	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899333	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899334	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899335	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899336	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899337	01/2015	12/16/2014	100.080	99.990	100.0	1
LG&E	C1S	899338	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899339	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899340	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	899341	01/2015	12/16/2014	100.110	99.950	100.0	1
LG&E	C1S	899342	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899343	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899344	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899345	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899346	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899347	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	899348	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899349	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899350	01/2015	12/16/2014	100.110	100.000	100.0	1
LG&E	C1S	899351	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899352	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899353	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	899354	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899355	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	899356	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	899357	01/2015	12/16/2014	100.110	99.940	100.0	1
LG&E	C1S	899358	01/2015	12/16/2014	100.050	99.870	100.0	1
LG&E	C1S	899359	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	899360	01/2015	12/16/2014	100.090	99.880	100.1	1
LG&E	C1S	899361	01/2015	12/16/2014	100.100	99.840	100.0	1
LG&E	C1S	899362	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	899363	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899364	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899365	01/2015	12/16/2014	100.060	99.870	100.1	1
LG&E	C1S	899366	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	899367	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899368	01/2015	12/16/2014	100.080	99.980	99.9	1
LG&E	C1S	899369	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899370	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	899371	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899372	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899373	01/2015	12/16/2014	100.080	99.970	100.0	1

LG&E	C1S	899374	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899375	01/2015	12/16/2014	100.070	99.950	100.1	1
LG&E	C1S	899376	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899377	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899378	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899379	01/2015	12/16/2014	100.080	99.950	99.9	1
LG&E	C1S	899380	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	899381	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899382	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899383	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	899384	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	899385	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899386	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899387	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	899388	01/2015	12/16/2014	100.060	99.980	100.0	1
LG&E	C1S	899389	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	899390	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899391	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899392	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899393	01/2015	12/16/2014	100.090	99.960	100.1	1
LG&E	C1S	899394	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899395	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	899396	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	899397	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899398	01/2015	12/16/2014	100.100	100.010	100.1	1
LG&E	C1S	899399	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	899400	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899401	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899402	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899403	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	899404	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899405	01/2015	12/16/2014	100.060	99.940	99.9	1
LG&E	C1S	899406	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899407	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899408	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899409	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899410	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	899411	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899412	01/2015	12/16/2014	100.110	99.930	100.1	1
LG&E	C1S	899413	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899414	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899415	01/2015	12/16/2014	100.080	99.840	100.1	1

LG&E	C1S	899416	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	899417	01/2015	12/16/2014	100.060	99.960	100.1	1
LG&E	C1S	899418	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899419	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899420	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	899421	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899422	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899423	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899424	01/2015	12/16/2014	100.100	99.870	100.1	1
LG&E	C1S	899425	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899426	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899427	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	899428	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899429	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	899430	01/2015	12/16/2014	100.050	99.900	100.0	1
LG&E	C1S	899431	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899432	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	899433	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899434	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899435	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	899436	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899437	01/2015	12/16/2014	100.070	99.960	100.1	1
LG&E	C1S	899438	01/2015	12/16/2014	100.080	99.930	99.9	1
LG&E	C1S	899439	01/2015	12/16/2014	100.090	99.980	100.1	1
LG&E	C1S	899440	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899441	01/2015	12/16/2014	100.070	99.850	100.1	1
LG&E	C1S	899442	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	899443	01/2015	12/16/2014	100.100	99.980	100.1	1
LG&E	C1S	899444	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	899445	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899446	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899447	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899448	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899449	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899450	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899451	01/2015	12/16/2014	100.060	99.890	100.1	1
LG&E	C1S	899452	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899453	01/2015	12/16/2014	100.090	99.870	100.1	1
LG&E	C1S	899454	01/2015	12/16/2014	100.090	99.890	100.0	1
LG&E	C1S	899455	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	899456	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899457	01/2015	12/16/2014	100.090	99.960	100.0	1

LG&E	C1S	899458	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	899459	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899460	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	899461	01/2015	12/16/2014	100.090	100.000	100.0	1
LG&E	C1S	899462	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	899463	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	899464	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899465	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899466	01/2015	12/16/2014	100.060	99.910	100.0	1
LG&E	C1S	899467	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899468	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	899469	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899470	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899471	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899472	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	899473	01/2015	12/16/2014	100.110	99.980	100.1	1
LG&E	C1S	899474	01/2015	12/16/2014	100.100	99.890	100.0	1
LG&E	C1S	899475	01/2015	12/16/2014	100.060	99.970	99.9	1
LG&E	C1S	899476	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	899477	01/2015	12/16/2014	100.080	99.930	99.9	1
LG&E	C1S	899478	01/2015	12/16/2014	100.080	99.960	100.1	1
LG&E	C1S	899479	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	899480	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899481	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899482	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899483	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899484	01/2015	12/16/2014	100.100	99.940	100.1	1
LG&E	C1S	899485	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899486	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899487	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	899488	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899489	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	899490	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	899491	01/2015	12/16/2014	100.050	99.930	100.0	1
LG&E	C1S	899492	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899493	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	899494	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899495	01/2015	12/16/2014	100.080	99.940	100.0	1
LG&E	C1S	899496	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899497	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	899498	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899499	01/2015	12/16/2014	100.060	99.920	100.0	1

LG&E	C1S	899500	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899501	01/2015	12/16/2014	100.080	99.980	100.1	1
LG&E	C1S	899502	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899503	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899504	01/2015	12/16/2014	100.080	99.950	100.0	1
LG&E	C1S	899505	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899506	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	899507	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899508	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	899509	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	899510	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899511	01/2015	12/16/2014	100.100	99.930	100.2	1
LG&E	C1S	899512	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899513	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899514	01/2015	12/16/2014	100.060	99.880	99.9	1
LG&E	C1S	899515	01/2015	12/16/2014	100.070	99.910	100.0	1
LG&E	C1S	899516	01/2015	12/16/2014	100.100	99.990	100.0	1
LG&E	C1S	899517	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899518	01/2015	12/16/2014	100.060	99.980	99.9	1
LG&E	C1S	899519	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899520	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899521	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899522	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	899523	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899524	01/2015	12/16/2014	100.080	99.910	100.1	1
LG&E	C1S	899525	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899526	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	899527	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899528	01/2015	12/16/2014	100.090	99.830	99.9	1
LG&E	C1S	899529	01/2015	12/16/2014	100.090	99.990	100.0	1
LG&E	C1S	899530	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	899531	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899532	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899533	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	899534	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899535	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899536	01/2015	12/16/2014	100.070	99.880	100.0	1
LG&E	C1S	899537	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899538	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	899539	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899540	01/2015	12/16/2014	100.070	99.860	100.1	1
LG&E	C1S	899541	01/2015	12/16/2014	100.080	99.920	100.0	1

LG&E	C1S	899542	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899543	01/2015	12/16/2014	100.070	99.980	100.0	1
LG&E	C1S	899544	01/2015	12/16/2014	100.080	99.930	99.9	1
LG&E	C1S	899545	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899546	01/2015	12/16/2014	100.070	99.890	100.0	1
LG&E	C1S	899547	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899548	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899549	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899550	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899551	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899552	01/2015	12/16/2014	100.100	99.890	100.0	1
LG&E	C1S	899553	01/2015	12/16/2014	100.070	99.840	100.0	1
LG&E	C1S	899554	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899555	01/2015	12/16/2014	100.100	99.880	100.1	1
LG&E	C1S	899556	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899557	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	899558	01/2015	12/16/2014	100.090	99.890	100.0	1
LG&E	C1S	899559	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	899560	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899561	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899562	01/2015	12/16/2014	100.090	99.930	99.9	1
LG&E	C1S	899563	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	899564	01/2015	12/16/2014	100.060	99.890	100.0	1
LG&E	C1S	899565	01/2015	12/16/2014	100.080	99.950	100.1	1
LG&E	C1S	899566	01/2015	12/16/2014	100.050	99.890	99.9	1
LG&E	C1S	899567	01/2015	12/16/2014	100.080	99.930	100.1	1
LG&E	C1S	899568	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	899569	01/2015	12/16/2014	100.080	99.950	99.9	1
LG&E	C1S	899570	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899571	01/2015	12/16/2014	100.050	99.880	99.9	1
LG&E	C1S	899572	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899573	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899574	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899575	01/2015	12/16/2014	100.090	99.880	100.1	1
LG&E	C1S	899576	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	899577	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899578	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899579	01/2015	12/16/2014	100.080	99.990	99.9	1
LG&E	C1S	899580	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	899581	01/2015	12/16/2014	100.100	99.910	100.0	1
LG&E	C1S	899582	01/2015	12/16/2014	100.110	99.930	100.0	1
LG&E	C1S	899583	01/2015	12/16/2014	100.080	99.940	100.1	1

LG&E	C1S	899584	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899585	01/2015	12/16/2014	100.090	99.900	99.9	1
LG&E	C1S	899586	01/2015	12/16/2014	100.070	99.980	100.1	1
LG&E	C1S	899587	01/2015	12/16/2014	100.060	99.930	99.9	1
LG&E	C1S	899588	01/2015	12/16/2014	100.090	99.950	100.1	1
LG&E	C1S	899589	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899590	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899591	01/2015	12/16/2014	100.100	99.960	100.1	1
LG&E	C1S	899592	01/2015	12/16/2014	100.080	99.980	100.0	1
LG&E	C1S	899593	01/2015	12/16/2014	100.090	99.850	100.0	1
LG&E	C1S	899594	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899595	01/2015	12/16/2014	100.090	99.920	99.9	1
LG&E	C1S	899596	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899597	01/2015	12/16/2014	100.060	99.920	99.9	1
LG&E	C1S	899598	01/2015	12/16/2014	100.080	99.890	100.1	1
LG&E	C1S	899599	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899600	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899601	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899602	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	899603	01/2015	12/16/2014	100.100	99.930	100.1	1
LG&E	C1S	899604	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899605	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899606	01/2015	12/16/2014	100.080	99.910	100.0	1
LG&E	C1S	899607	01/2015	12/16/2014	100.060	99.860	100.0	1
LG&E	C1S	899608	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	899609	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899610	01/2015	12/16/2014	100.090	99.970	100.0	1
LG&E	C1S	899611	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899612	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899613	01/2015	12/16/2014	100.080	99.930	100.0	1
LG&E	C1S	899614	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899615	01/2015	12/16/2014	100.100	99.910	100.1	1
LG&E	C1S	899616	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	899617	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899618	01/2015	12/16/2014	100.060	99.880	100.0	1
LG&E	C1S	899619	01/2015	12/16/2014	100.050	99.910	100.0	1
LG&E	C1S	899620	01/2015	12/16/2014	100.110	100.010	100.1	1
LG&E	C1S	899621	01/2015	12/16/2014	100.100	100.000	100.0	1
LG&E	C1S	899622	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	899623	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899624	01/2015	12/16/2014	100.050	99.870	99.9	1
LG&E	C1S	899625	01/2015	12/16/2014	100.070	99.900	99.9	1

LG&E	C1S	899626	01/2015	12/16/2014	100.080	99.960	100.0	1
LG&E	C1S	899627	01/2015	12/16/2014	100.100	99.980	100.0	1
LG&E	C1S	899628	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	899629	01/2015	12/16/2014	100.100	99.890	100.1	1
LG&E	C1S	899630	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	899631	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	899632	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899633	01/2015	12/16/2014	100.080	99.970	100.1	1
LG&E	C1S	899634	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	899635	01/2015	12/16/2014	100.060	99.870	100.0	1
LG&E	C1S	899636	01/2015	12/16/2014	100.070	100.010	100.1	1
LG&E	C1S	899637	01/2015	12/16/2014	100.090	99.870	100.0	1
LG&E	C1S	899638	01/2015	12/16/2014	100.100	99.970	100.1	1
LG&E	C1S	899639	01/2015	12/16/2014	100.080	99.920	100.1	1
LG&E	C1S	899640	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899641	01/2015	12/16/2014	100.090	99.890	100.1	1
LG&E	C1S	899642	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899643	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899644	01/2015	12/16/2014	100.070	99.960	100.0	1
LG&E	C1S	899645	01/2015	12/16/2014	100.060	99.930	100.0	1
LG&E	C1S	899646	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	899647	01/2015	12/16/2014	100.070	99.920	100.0	1
LG&E	C1S	899648	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899649	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	899650	01/2015	12/16/2014	100.080	99.920	100.0	1
LG&E	C1S	899651	01/2015	12/16/2014	100.070	99.860	100.1	1
LG&E	C1S	899652	01/2015	12/16/2014	100.100	99.950	100.0	1
LG&E	C1S	899653	01/2015	12/16/2014	100.060	99.900	99.9	1
LG&E	C1S	899654	01/2015	12/16/2014	100.080	99.890	100.0	1
LG&E	C1S	899655	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899656	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899657	01/2015	12/16/2014	100.070	99.950	100.0	1
LG&E	C1S	899658	01/2015	12/16/2014	100.080	99.860	100.0	1
LG&E	C1S	899659	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899660	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899661	01/2015	12/16/2014	100.060	99.910	100.1	1
LG&E	C1S	899662	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	899663	01/2015	12/16/2014	100.080	99.890	99.9	1
LG&E	C1S	899664	01/2015	12/16/2014	100.070	99.930	100.0	1
LG&E	C1S	899665	01/2015	12/16/2014	100.060	99.970	100.0	1
LG&E	C1S	899666	01/2015	12/16/2014	100.100	99.900	99.9	1
LG&E	C1S	899667	01/2015	12/16/2014	100.090	99.900	100.0	1

LG&E	C1S	899668	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899669	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	899670	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899671	01/2015	12/16/2014	100.070	99.850	100.0	1
LG&E	C1S	899672	01/2015	12/16/2014	100.100	99.960	100.0	1
LG&E	C1S	899673	01/2015	12/16/2014	100.080	99.970	100.0	1
LG&E	C1S	899674	01/2015	12/16/2014	100.100	99.930	100.0	1
LG&E	C1S	899675	01/2015	12/16/2014	100.070	99.920	100.1	1
LG&E	C1S	899676	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899677	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899678	01/2015	12/16/2014	100.060	99.950	100.1	1
LG&E	C1S	899679	01/2015	12/16/2014	100.100	99.940	100.0	1
LG&E	C1S	899680	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	899681	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	899682	01/2015	12/16/2014	100.080	99.880	100.0	1
LG&E	C1S	899683	01/2015	12/16/2014	100.100	99.990	100.1	1
LG&E	C1S	899684	01/2015	12/16/2014	100.050	99.920	100.0	1
LG&E	C1S	899685	01/2015	12/16/2014	100.060	99.900	100.1	1
LG&E	C1S	899686	01/2015	12/16/2014	100.060	99.950	100.0	1
LG&E	C1S	899687	01/2015	12/16/2014	100.090	99.930	100.1	1
LG&E	C1S	899688	01/2015	12/16/2014	100.070	99.940	100.0	1
LG&E	C1S	899689	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	899690	01/2015	12/16/2014	100.100	100.020	100.0	1
LG&E	C1S	899691	01/2015	12/16/2014	100.060	99.940	100.0	1
LG&E	C1S	899692	01/2015	12/16/2014	100.060	99.910	100.1	1
LG&E	C1S	899693	01/2015	12/16/2014	100.060	99.850	100.0	1
LG&E	C1S	899694	01/2015	12/16/2014	100.100	99.930	99.9	1
LG&E	C1S	899695	01/2015	12/16/2014	100.060	99.940	100.1	1
LG&E	C1S	899696	01/2015	12/16/2014	100.110	99.970	100.1	1
LG&E	C1S	899697	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899698	01/2015	12/16/2014	100.070	99.910	100.1	1
LG&E	C1S	899699	01/2015	12/16/2014	100.070	99.870	100.0	1
LG&E	C1S	899700	01/2015	12/16/2014	100.110	99.920	100.0	1
LG&E	C1S	899701	01/2015	12/16/2014	100.090	99.930	100.0	1
LG&E	C1S	899702	01/2015	12/16/2014	100.090	99.940	100.1	1
LG&E	C1S	899703	01/2015	12/16/2014	100.100	99.970	100.0	1
LG&E	C1S	899704	01/2015	12/16/2014	100.070	99.890	100.1	1
LG&E	C1S	899705	01/2015	12/16/2014	100.100	99.860	100.1	1
LG&E	C1S	899706	01/2015	12/16/2014	100.100	99.980	100.2	1
LG&E	C1S	899707	01/2015	12/16/2014	100.090	99.880	100.0	1
LG&E	C1S	899708	01/2015	12/16/2014	100.090	99.940	100.0	1
LG&E	C1S	899709	01/2015	12/16/2014	100.080	99.920	100.1	1

LG&E	C1S	899710	01/2015	12/16/2014	100.090	99.910	100.0	1
LG&E	C1S	899711	01/2015	12/16/2014	100.060	99.840	99.9	1
LG&E	C1S	899712	01/2015	12/16/2014	100.090	99.950	100.0	1
LG&E	C1S	899713	01/2015	12/16/2014	100.090	99.960	100.0	1
LG&E	C1S	899714	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899715	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899716	01/2015	12/16/2014	100.070	99.970	100.0	1
LG&E	C1S	899717	01/2015	12/16/2014	100.090	99.920	100.0	1
LG&E	C1S	899718	01/2015	12/16/2014	100.100	99.900	100.0	1
LG&E	C1S	899719	01/2015	12/16/2014	100.090	99.900	100.0	1
LG&E	C1S	899720	01/2015	12/16/2014	100.070	99.860	100.0	1
LG&E	C1S	899721	01/2015	12/16/2014	100.090	99.910	100.1	1
LG&E	C1S	899722	01/2015	12/16/2014	100.100	99.950	100.1	1
LG&E	C1S	899723	01/2015	12/16/2014	100.070	99.900	100.0	1
LG&E	C1S	899724	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899725	01/2015	12/16/2014	100.110	99.910	100.1	1
LG&E	C1S	899726	01/2015	12/16/2014	100.080	99.900	100.1	1
LG&E	C1S	899727	01/2015	12/16/2014	100.060	99.830	100.0	1
LG&E	C1S	899728	01/2015	12/16/2014	100.090	99.900	100.1	1
LG&E	C1S	899729	01/2015	12/16/2014	100.060	99.960	99.9	1
LG&E	C1S	899730	01/2015	12/16/2014	100.050	99.870	100.0	1
LG&E	C1S	899731	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899732	01/2015	12/16/2014	100.090	99.860	100.0	1
LG&E	C1S	899733	01/2015	12/16/2014	100.100	99.880	100.0	1
LG&E	C1S	899734	01/2015	12/16/2014	100.060	99.900	100.0	1
LG&E	C1S	899735	01/2015	12/16/2014	100.080	99.900	100.0	1
LG&E	C1S	899736	01/2015	12/16/2014	100.080	99.850	100.0	1
LG&E	C1S	899737	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	899738	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899739	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	899740	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	899741	01/2015	12/16/2014	100.100	99.870	100.1	1
LG&E	C1S	899742	01/2015	12/16/2014	100.100	99.900	100.1	1
LG&E	C1S	899743	01/2015	12/16/2014	100.080	99.870	100.0	1
LG&E	C1S	899744	01/2015	12/16/2014	100.060	99.840	100.0	1
LG&E	C1S	899745	01/2015	12/16/2014	100.050	99.870	99.9	1
LG&E	C1S	899746	01/2015	12/16/2014	100.090	99.980	100.0	1
LG&E	C1S	899747	01/2015	12/16/2014	100.060	99.960	100.0	1
LG&E	C1S	899748	01/2015	12/16/2014	100.100	99.920	100.1	1
LG&E	C1S	899749	01/2015	12/16/2014	100.050	99.910	100.0	1
LG&E	C1S	899750	01/2015	12/16/2014	100.090	99.920	100.1	1
LG&E	C1S	899751	01/2015	12/16/2014	100.090	99.900	100.1	1

LG&E	C1S	899752	01/2015	12/16/2014	100.080	99.940	100.1	1
LG&E	C1S	899753	01/2015	12/16/2014	100.060	99.920	100.0	1
LG&E	C1S	900462	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	900463	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900464	04/2015	04/16/2015	100.060	99.840	99.9	1
LG&E	C1S	900465	04/2015	04/16/2015	100.070	99.840	100.0	1
LG&E	C1S	900466	04/2015	04/16/2015	100.060	99.900	100.1	1
LG&E	C1S	900467	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900468	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	900469	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	900470	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900471	04/2015	04/16/2015	100.070	99.910	99.9	1
LG&E	C1S	900472	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900473	04/2015	04/16/2015	100.050	99.900	100.1	1
LG&E	C1S	900474	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	900475	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900476	04/2015	04/16/2015	100.070	99.830	100.0	1
LG&E	C1S	900477	04/2015	04/16/2015	100.090	99.910	100.1	1
LG&E	C1S	900478	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900479	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900480	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	900481	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	900482	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900483	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	900484	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900485	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	900486	04/2015	04/16/2015	100.080	99.850	100.0	1
LG&E	C1S	900487	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	900488	04/2015	04/16/2015	100.100	100.020	100.0	1
LG&E	C1S	900489	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	900490	04/2015	04/16/2015	100.110	99.970	100.0	1
LG&E	C1S	900491	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900492	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	900493	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900494	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900495	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	900496	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900497	04/2015	04/16/2015	100.070	99.870	99.9	1
LG&E	C1S	900498	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	900499	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900500	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900501	04/2015	04/16/2015	100.070	99.860	100.0	1

LG&E	C1S	900502	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900503	04/2015	04/16/2015	100.070	99.960	100.1	1
LG&E	C1S	900504	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	900505	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900506	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900507	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	900508	04/2015	04/16/2015	100.050	99.960	100.0	1
LG&E	C1S	900509	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	900510	04/2015	04/16/2015	100.090	99.930	100.1	1
LG&E	C1S	900511	04/2015	04/16/2015	100.090	99.860	100.1	1
LG&E	C1S	900512	04/2015	04/16/2015	100.090	99.870	100.1	1
LG&E	C1S	900513	04/2015	04/16/2015	100.060	99.890	100.1	1
LG&E	C1S	900514	04/2015	04/16/2015	100.060	99.840	99.9	1
LG&E	C1S	900515	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	900516	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	900517	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900518	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	900519	04/2015	04/16/2015	100.050	99.860	100.0	1
LG&E	C1S	900520	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	900521	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900522	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900523	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900524	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	900525	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900526	04/2015	04/16/2015	100.090	100.030	100.0	1
LG&E	C1S	900527	04/2015	04/16/2015	100.080	99.980	100.1	1
LG&E	C1S	900528	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	900529	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	900530	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	900531	04/2015	04/16/2015	100.070	99.900	100.1	1
LG&E	C1S	900532	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	900533	04/2015	04/16/2015	100.060	99.940	99.9	1
LG&E	C1S	900534	04/2015	04/16/2015	100.070	99.840	100.0	1
LG&E	C1S	900535	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900536	04/2015	04/16/2015	100.090	99.890	100.1	1
LG&E	C1S	900537	04/2015	04/16/2015	100.100	99.880	100.0	1
LG&E	C1S	900538	04/2015	04/16/2015	100.080	99.990	100.1	1
LG&E	C1S	900539	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	900540	04/2015	04/16/2015	100.090	99.850	99.9	1
LG&E	C1S	900541	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900542	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	900543	04/2015	04/16/2015	100.060	99.880	100.0	1

LG&E	C1S	900544	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	900545	04/2015	04/16/2015	100.050	99.830	99.9	1
LG&E	C1S	900546	04/2015	04/16/2015	100.060	99.960	100.1	1
LG&E	C1S	900547	04/2015	04/16/2015	100.060	99.830	99.9	1
LG&E	C1S	900548	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900549	04/2015	04/16/2015	100.080	100.000	100.0	1
LG&E	C1S	900550	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900551	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	900552	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900553	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	900554	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	900555	04/2015	04/16/2015	100.060	99.830	100.1	1
LG&E	C1S	900556	04/2015	04/16/2015	100.090	99.920	100.1	1
LG&E	C1S	900557	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	900558	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900559	04/2015	04/16/2015	100.070	99.970	100.0	1
LG&E	C1S	900560	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	900561	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900562	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	900563	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900564	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	900565	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	900566	04/2015	04/16/2015	100.100	99.880	100.0	1
LG&E	C1S	900567	04/2015	04/16/2015	100.060	99.830	99.9	1
LG&E	C1S	900568	04/2015	04/16/2015	100.080	99.950	100.1	1
LG&E	C1S	900569	04/2015	04/16/2015	100.080	99.840	100.0	1
LG&E	C1S	900570	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900571	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900572	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900573	04/2015	04/16/2015	100.050	99.820	100.0	1
LG&E	C1S	900574	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900575	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900576	04/2015	04/16/2015	100.080	100.000	100.0	1
LG&E	C1S	900577	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	900578	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900579	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900580	04/2015	04/16/2015	100.100	100.050	100.0	1
LG&E	C1S	900581	04/2015	04/16/2015	100.090	99.910	100.1	1
LG&E	C1S	900582	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	900583	04/2015	04/16/2015	100.100	99.880	100.1	1
LG&E	C1S	900584	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900585	04/2015	04/16/2015	100.090	99.960	100.0	1

LG&E	C1S	900586	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900587	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900588	04/2015	04/16/2015	100.050	99.830	100.0	1
LG&E	C1S	900589	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900590	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	900591	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900592	04/2015	04/16/2015	100.100	99.990	100.1	1
LG&E	C1S	900593	04/2015	04/16/2015	100.090	99.920	100.1	1
LG&E	C1S	900594	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	900595	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	900596	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900597	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900598	04/2015	04/16/2015	100.080	99.820	100.0	1
LG&E	C1S	900599	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	900600	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900601	04/2015	04/16/2015	100.090	99.930	100.1	1
LG&E	C1S	900602	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	900603	04/2015	04/16/2015	100.100	99.920	100.1	1
LG&E	C1S	900604	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	900605	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	900606	04/2015	04/16/2015	100.050	99.880	100.0	1
LG&E	C1S	900607	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900608	04/2015	04/16/2015	100.070	99.870	99.9	1
LG&E	C1S	900609	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900610	04/2015	04/16/2015	100.100	99.970	100.1	1
LG&E	C1S	900611	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900612	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	900613	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900614	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900615	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900616	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	900617	04/2015	04/16/2015	100.100	99.900	100.1	1
LG&E	C1S	900618	04/2015	04/16/2015	100.060	99.850	99.9	1
LG&E	C1S	900619	04/2015	04/16/2015	100.090	99.980	100.1	1
LG&E	C1S	900620	04/2015	04/16/2015	100.100	99.930	100.1	1
LG&E	C1S	900621	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900622	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900623	04/2015	04/16/2015	100.090	100.030	100.0	1
LG&E	C1S	900624	04/2015	04/16/2015	100.050	99.860	100.1	1
LG&E	C1S	900625	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900626	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900627	04/2015	04/16/2015	100.090	99.990	100.0	1

LG&E	C1S	900628	04/2015	04/16/2015	100.080	100.000	100.1	1
LG&E	C1S	900629	04/2015	04/16/2015	100.100	100.020	100.1	1
LG&E	C1S	900630	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900631	04/2015	04/16/2015	100.060	99.810	100.1	1
LG&E	C1S	900632	04/2015	04/16/2015	100.100	99.890	100.1	1
LG&E	C1S	900633	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	900634	04/2015	04/16/2015	100.050	99.970	100.0	1
LG&E	C1S	900635	04/2015	04/16/2015	100.080	99.940	100.1	1
LG&E	C1S	900636	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	900637	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900638	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	900639	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	900640	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900641	04/2015	04/16/2015	100.070	99.980	100.1	1
LG&E	C1S	900642	04/2015	04/16/2015	100.080	100.010	100.1	1
LG&E	C1S	900643	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900644	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	900645	04/2015	04/16/2015	100.070	99.870	99.9	1
LG&E	C1S	900646	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	900647	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	900648	04/2015	04/16/2015	100.070	99.890	100.1	1
LG&E	C1S	900649	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900650	04/2015	04/16/2015	100.080	99.880	99.9	1
LG&E	C1S	900651	04/2015	04/16/2015	100.090	100.010	100.0	1
LG&E	C1S	900652	04/2015	04/16/2015	100.090	99.870	100.0	1
LG&E	C1S	900653	04/2015	04/16/2015	100.070	100.020	100.0	1
LG&E	C1S	900654	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	900655	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900656	04/2015	04/16/2015	100.070	99.930	99.9	1
LG&E	C1S	900657	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900658	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	900659	04/2015	04/16/2015	100.090	99.900	100.1	1
LG&E	C1S	900660	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900661	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	900662	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	900663	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900664	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900665	04/2015	04/16/2015	100.100	99.890	100.1	1
LG&E	C1S	900666	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	900667	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	900668	04/2015	04/16/2015	100.050	99.940	100.0	1
LG&E	C1S	900669	04/2015	04/16/2015	100.100	100.020	100.1	1

LG&E	C1S	900670	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	900671	04/2015	04/16/2015	100.090	100.050	100.0	1
LG&E	C1S	900672	04/2015	04/16/2015	100.100	99.960	100.1	1
LG&E	C1S	900673	04/2015	04/16/2015	100.100	100.020	100.0	1
LG&E	C1S	900674	04/2015	04/16/2015	100.080	99.900	100.1	1
LG&E	C1S	900675	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900676	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900677	04/2015	04/16/2015	100.070	99.930	99.9	1
LG&E	C1S	900678	04/2015	04/16/2015	100.080	99.940	100.1	1
LG&E	C1S	900679	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	900680	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900681	04/2015	04/16/2015	100.060	99.910	100.1	1
LG&E	C1S	900682	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	900683	04/2015	04/16/2015	100.060	99.890	99.9	1
LG&E	C1S	900684	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	900685	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900686	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	900687	04/2015	04/16/2015	100.100	99.890	100.0	1
LG&E	C1S	900688	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	900689	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900690	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900691	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900692	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900693	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	900694	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900695	04/2015	04/16/2015	100.080	99.910	99.9	1
LG&E	C1S	900696	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	900697	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900698	04/2015	04/16/2015	100.100	99.860	100.0	1
LG&E	C1S	900699	04/2015	04/16/2015	100.100	99.910	100.1	1
LG&E	C1S	900700	04/2015	04/16/2015	100.080	100.030	100.0	1
LG&E	C1S	900701	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	900702	04/2015	04/16/2015	100.100	99.920	100.1	1
LG&E	C1S	900703	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900704	04/2015	04/16/2015	100.090	100.010	100.1	1
LG&E	C1S	900705	04/2015	04/16/2015	100.080	99.910	100.1	1
LG&E	C1S	900706	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900707	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	900708	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900709	04/2015	04/16/2015	100.080	100.010	100.0	1
LG&E	C1S	900710	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	900711	04/2015	04/16/2015	100.070	99.890	100.0	1

LG&E	C1S	900712	04/2015	04/16/2015	100.050	99.830	100.0	1
LG&E	C1S	900713	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900714	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900715	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900716	04/2015	04/16/2015	100.090	99.870	100.1	1
LG&E	C1S	900717	04/2015	04/16/2015	100.090	99.990	100.1	1
LG&E	C1S	900718	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	900719	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900720	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	900721	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900722	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900723	04/2015	04/16/2015	100.100	99.910	100.1	1
LG&E	C1S	900724	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	900725	04/2015	04/16/2015	100.070	100.000	100.0	1
LG&E	C1S	900726	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	900727	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	900728	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900729	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900730	04/2015	04/16/2015	100.070	99.980	100.1	1
LG&E	C1S	900731	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	900732	04/2015	04/16/2015	100.060	99.960	99.9	1
LG&E	C1S	900733	04/2015	04/16/2015	100.090	100.000	100.1	1
LG&E	C1S	900734	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900735	04/2015	04/16/2015	100.060	99.830	100.0	1
LG&E	C1S	900736	04/2015	04/16/2015	100.080	99.930	99.9	1
LG&E	C1S	900737	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900738	04/2015	04/16/2015	100.070	100.000	100.0	1
LG&E	C1S	900739	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900740	04/2015	04/16/2015	100.080	99.940	100.1	1
LG&E	C1S	900741	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900742	04/2015	04/16/2015	100.100	99.990	100.1	1
LG&E	C1S	900743	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	900744	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900745	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	900746	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900747	04/2015	04/16/2015	100.050	99.890	100.0	1
LG&E	C1S	900748	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900749	04/2015	04/16/2015	100.100	99.990	100.1	1
LG&E	C1S	900750	04/2015	04/16/2015	100.060	99.930	99.9	1
LG&E	C1S	900751	04/2015	04/16/2015	100.070	99.860	100.1	1
LG&E	C1S	900752	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	900753	04/2015	04/16/2015	100.080	99.950	100.0	1

LG&E	C1S	900754	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900755	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900756	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900757	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900758	04/2015	04/16/2015	100.080	99.900	100.1	1
LG&E	C1S	900759	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900760	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	900761	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900762	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900763	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900764	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900765	04/2015	04/16/2015	100.100	99.980	100.0	1
LG&E	C1S	900766	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900767	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	900768	04/2015	04/16/2015	100.080	99.940	100.1	1
LG&E	C1S	900769	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	900770	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	900771	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	900772	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	900773	04/2015	04/16/2015	100.080	99.930	100.1	1
LG&E	C1S	900774	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900775	04/2015	04/16/2015	100.090	99.990	100.1	1
LG&E	C1S	900776	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900777	04/2015	04/16/2015	100.080	100.010	100.1	1
LG&E	C1S	900778	04/2015	04/16/2015	100.070	99.850	100.0	1
LG&E	C1S	900779	04/2015	04/16/2015	100.080	99.900	100.1	1
LG&E	C1S	900780	04/2015	04/16/2015	100.100	99.920	100.1	1
LG&E	C1S	900781	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900782	04/2015	04/16/2015	100.050	99.970	100.0	1
LG&E	C1S	900783	04/2015	04/16/2015	100.080	99.880	100.0	1
LG&E	C1S	900784	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900785	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	900786	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900787	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900788	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	900789	04/2015	04/16/2015	100.080	99.930	100.1	1
LG&E	C1S	900790	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900791	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900792	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	900793	04/2015	04/16/2015	100.100	100.040	100.0	1
LG&E	C1S	900794	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900795	04/2015	04/16/2015	100.080	99.920	100.0	1

LG&E	C1S	900796	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	900797	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	900798	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900799	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900800	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	900801	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900802	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	900803	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900804	04/2015	04/16/2015	100.070	99.950	100.1	1
LG&E	C1S	900805	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900806	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	900807	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900808	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	900809	04/2015	04/16/2015	100.080	99.980	100.1	1
LG&E	C1S	900810	04/2015	04/16/2015	100.080	99.960	99.9	1
LG&E	C1S	900811	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900812	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	900813	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900814	04/2015	04/16/2015	100.100	100.000	100.0	1
LG&E	C1S	900815	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	900816	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900817	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900818	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	900819	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	900820	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900821	04/2015	04/16/2015	100.050	99.830	100.0	1
LG&E	C1S	900822	04/2015	04/16/2015	100.070	99.880	99.9	1
LG&E	C1S	900823	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	900824	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900825	04/2015	04/16/2015	100.100	99.980	100.0	1
LG&E	C1S	900826	04/2015	04/16/2015	100.070	99.990	100.0	1
LG&E	C1S	900827	04/2015	04/16/2015	100.070	99.880	100.1	1
LG&E	C1S	900828	04/2015	04/16/2015	100.070	99.840	100.0	1
LG&E	C1S	900829	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900830	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	900831	04/2015	04/16/2015	100.100	99.920	100.1	1
LG&E	C1S	900832	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900833	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	900834	04/2015	04/16/2015	100.100	99.850	100.0	1
LG&E	C1S	900835	04/2015	04/16/2015	100.090	99.980	100.1	1
LG&E	C1S	900836	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900837	04/2015	04/16/2015	100.090	99.920	100.0	1

LG&E	C1S	900838	04/2015	04/16/2015	100.070	99.850	99.9	1
LG&E	C1S	900839	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900840	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	900841	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900842	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900843	04/2015	04/16/2015	100.080	99.910	99.9	1
LG&E	C1S	900844	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900845	04/2015	04/16/2015	100.060	99.880	100.1	1
LG&E	C1S	900846	04/2015	04/16/2015	100.100	99.960	100.1	1
LG&E	C1S	900847	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	900848	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900849	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	900850	04/2015	04/16/2015	100.080	99.970	100.1	1
LG&E	C1S	900851	04/2015	04/16/2015	100.110	100.020	100.1	1
LG&E	C1S	900852	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900853	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	900854	04/2015	04/16/2015	100.070	99.940	99.9	1
LG&E	C1S	900855	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	900856	04/2015	04/16/2015	100.070	99.890	100.1	1
LG&E	C1S	900857	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	900858	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900859	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	900860	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900861	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	900862	04/2015	04/16/2015	100.070	99.930	100.1	1
LG&E	C1S	900863	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	900864	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	900865	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	900866	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900867	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	900868	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900869	04/2015	04/16/2015	100.060	99.960	100.1	1
LG&E	C1S	900870	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	900871	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	900872	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900873	04/2015	04/16/2015	100.070	99.850	100.0	1
LG&E	C1S	900874	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900875	04/2015	04/16/2015	100.070	99.900	100.1	1
LG&E	C1S	900876	04/2015	04/16/2015	100.050	99.950	99.9	1
LG&E	C1S	900877	04/2015	04/16/2015	100.050	99.880	100.1	1
LG&E	C1S	900878	04/2015	04/16/2015	100.100	99.870	100.1	1
LG&E	C1S	900879	04/2015	04/16/2015	100.090	99.950	100.1	1

LG&E	C1S	900880	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	900881	04/2015	04/16/2015	100.070	99.930	100.1	1
LG&E	C1S	900882	04/2015	04/16/2015	100.050	99.900	99.9	1
LG&E	C1S	900883	04/2015	04/16/2015	100.060	99.970	100.0	1
LG&E	C1S	900884	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	900885	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	900886	04/2015	04/16/2015	100.100	100.000	100.1	1
LG&E	C1S	900887	04/2015	04/16/2015	100.070	99.890	99.9	1
LG&E	C1S	900888	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900889	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	900890	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	900891	04/2015	04/16/2015	100.090	99.830	100.1	1
LG&E	C1S	900892	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	900893	04/2015	04/16/2015	100.110	99.950	100.0	1
LG&E	C1S	900894	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900895	04/2015	04/16/2015	100.090	99.850	100.1	1
LG&E	C1S	900896	04/2015	04/16/2015	100.070	99.960	100.1	1
LG&E	C1S	900897	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	900898	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900899	04/2015	04/16/2015	100.080	99.970	100.1	1
LG&E	C1S	900900	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	900901	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	900902	04/2015	04/16/2015	100.050	99.920	100.0	1
LG&E	C1S	900903	04/2015	04/16/2015	100.100	99.890	100.1	1
LG&E	C1S	900904	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	900905	04/2015	04/16/2015	100.050	99.980	100.0	1
LG&E	C1S	900906	04/2015	04/16/2015	100.080	99.870	100.1	1
LG&E	C1S	900907	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900908	04/2015	04/16/2015	100.060	99.990	100.0	1
LG&E	C1S	900909	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	900910	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	900911	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	900912	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900913	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900914	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	900915	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	900916	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	900917	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900918	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900919	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900920	04/2015	04/16/2015	100.070	99.880	99.9	1
LG&E	C1S	900921	04/2015	04/16/2015	100.090	99.840	100.0	1

LG&E	C1S	900922	04/2015	04/16/2015	100.060	99.900	99.9	1
LG&E	C1S	900923	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	900924	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900925	04/2015	04/16/2015	100.050	99.940	100.0	1
LG&E	C1S	900926	04/2015	04/16/2015	100.090	99.860	99.9	1
LG&E	C1S	900927	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900928	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	900929	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	900930	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900931	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900932	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900933	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	900934	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	900935	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900936	04/2015	04/16/2015	100.090	99.880	100.0	1
LG&E	C1S	900937	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900938	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	900939	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	900940	04/2015	04/16/2015	100.060	99.910	100.1	1
LG&E	C1S	900941	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	900942	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	900943	04/2015	04/16/2015	100.050	99.980	100.0	1
LG&E	C1S	900944	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	900945	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	900946	04/2015	04/16/2015	100.090	99.960	100.1	1
LG&E	C1S	900947	04/2015	04/16/2015	100.090	99.910	100.1	1
LG&E	C1S	900948	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	900949	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	900950	04/2015	04/16/2015	100.080	99.860	100.0	1
LG&E	C1S	900951	04/2015	04/16/2015	100.060	99.940	99.9	1
LG&E	C1S	900952	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	900953	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	900954	04/2015	04/16/2015	100.100	99.860	100.0	1
LG&E	C1S	900955	04/2015	04/16/2015	100.050	99.920	100.0	1
LG&E	C1S	900956	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	900957	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	900958	04/2015	04/16/2015	100.050	99.910	100.0	1
LG&E	C1S	900959	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900960	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	900961	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	900962	04/2015	04/16/2015	100.100	99.900	100.0	1
LG&E	C1S	900963	04/2015	04/16/2015	100.100	99.960	100.1	1

LG&E	C1S	900964	04/2015	04/16/2015	100.080	99.890	100.1	1
LG&E	C1S	900965	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	900966	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	900967	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	900968	04/2015	04/16/2015	100.070	99.930	100.1	1
LG&E	C1S	900969	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900970	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	900971	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	900972	04/2015	04/16/2015	100.050	99.910	100.1	1
LG&E	C1S	900973	04/2015	04/16/2015	100.060	99.890	100.1	1
LG&E	C1S	900974	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	900975	04/2015	04/16/2015	100.070	99.880	100.1	1
LG&E	C1S	900976	04/2015	04/16/2015	100.080	99.930	100.1	1
LG&E	C1S	900977	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	900978	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	900979	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	900980	04/2015	04/16/2015	100.090	99.920	100.1	1
LG&E	C1S	900981	04/2015	04/16/2015	100.060	99.950	99.9	1
LG&E	C1S	900982	04/2015	04/16/2015	100.050	99.880	100.0	1
LG&E	C1S	900983	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	900984	04/2015	04/16/2015	100.070	100.050	100.0	1
LG&E	C1S	900985	04/2015	04/16/2015	100.050	99.880	100.0	1
LG&E	C1S	900986	04/2015	04/16/2015	100.100	99.830	100.0	1
LG&E	C1S	900987	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	900988	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	900989	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	900990	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	900991	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	900992	04/2015	04/16/2015	100.090	99.930	100.1	1
LG&E	C1S	900993	04/2015	04/16/2015	100.060	99.840	99.9	1
LG&E	C1S	900994	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	900995	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	900996	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	900997	04/2015	04/16/2015	100.050	99.940	100.1	1
LG&E	C1S	900998	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	900999	04/2015	04/16/2015	100.060	99.850	100.0	1
LG&E	C1S	901000	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901001	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	901002	04/2015	04/16/2015	100.060	99.850	100.0	1
LG&E	C1S	901003	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901004	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901005	04/2015	04/16/2015	100.050	99.960	100.0	1

LG&E	C1S	901006	04/2015	04/16/2015	100.080	99.880	100.0	1
LG&E	C1S	901007	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901008	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901009	04/2015	04/16/2015	100.090	99.940	100.1	1
LG&E	C1S	901010	04/2015	04/16/2015	100.100	99.970	100.1	1
LG&E	C1S	901011	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	901012	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901013	04/2015	04/16/2015	100.050	99.860	100.0	1
LG&E	C1S	901014	04/2015	04/16/2015	100.110	99.980	100.0	1
LG&E	C1S	901015	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901016	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901017	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901018	04/2015	04/16/2015	100.100	99.880	100.1	1
LG&E	C1S	901019	04/2015	04/16/2015	100.060	99.960	100.1	1
LG&E	C1S	901020	04/2015	04/16/2015	100.080	99.910	100.1	1
LG&E	C1S	901021	04/2015	04/16/2015	100.090	99.930	100.1	1
LG&E	C1S	901022	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901023	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901024	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	901025	04/2015	04/16/2015	100.050	99.900	99.9	1
LG&E	C1S	901026	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901027	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901028	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901029	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901030	04/2015	04/16/2015	100.080	99.990	100.0	1
LG&E	C1S	901031	04/2015	04/16/2015	100.060	99.820	100.0	1
LG&E	C1S	901032	04/2015	04/16/2015	100.100	99.860	100.0	1
LG&E	C1S	901033	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901034	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901035	04/2015	04/16/2015	100.100	99.920	100.1	1
LG&E	C1S	901036	04/2015	04/16/2015	100.100	100.000	100.0	1
LG&E	C1S	901037	04/2015	04/16/2015	100.050	99.920	100.0	1
LG&E	C1S	901038	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	901039	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	901040	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	901041	04/2015	04/16/2015	100.070	99.920	99.9	1
LG&E	C1S	901042	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	901043	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901044	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	901045	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901046	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	901047	04/2015	04/16/2015	100.060	99.860	100.0	1

LG&E	C1S	901048	04/2015	04/16/2015	100.060	99.810	100.0	1
LG&E	C1S	901049	04/2015	04/16/2015	100.070	99.960	100.1	1
LG&E	C1S	901050	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	901051	04/2015	04/16/2015	100.050	99.910	100.0	1
LG&E	C1S	901052	04/2015	04/16/2015	100.070	100.020	100.0	1
LG&E	C1S	901053	04/2015	04/16/2015	100.100	99.950	100.1	1
LG&E	C1S	901054	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901055	04/2015	04/16/2015	100.080	99.940	100.1	1
LG&E	C1S	901056	04/2015	04/16/2015	100.050	99.940	100.0	1
LG&E	C1S	901057	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901058	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901059	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901060	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901061	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901062	04/2015	04/16/2015	100.080	99.910	100.1	1
LG&E	C1S	901063	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	901064	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901065	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901066	04/2015	04/16/2015	100.050	99.860	100.0	1
LG&E	C1S	901067	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	901068	04/2015	04/16/2015	100.080	99.850	100.0	1
LG&E	C1S	901069	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901070	04/2015	04/16/2015	100.100	99.870	100.1	1
LG&E	C1S	901071	04/2015	04/16/2015	100.080	99.960	100.1	1
LG&E	C1S	901072	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901073	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	901074	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	901075	04/2015	04/16/2015	100.070	99.820	100.0	1
LG&E	C1S	901076	04/2015	04/16/2015	100.060	99.860	99.9	1
LG&E	C1S	901077	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901078	04/2015	04/16/2015	100.060	99.950	100.1	1
LG&E	C1S	901079	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901080	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	901081	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	901082	04/2015	04/16/2015	100.050	99.880	99.9	1
LG&E	C1S	901083	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901084	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901085	04/2015	04/16/2015	100.050	99.850	100.0	1
LG&E	C1S	901086	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	901087	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901088	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901089	04/2015	04/16/2015	100.060	99.860	100.0	1

LG&E	C1S	901090	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901091	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901092	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901093	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901094	04/2015	04/16/2015	100.080	99.970	100.1	1
LG&E	C1S	901095	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901096	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901097	04/2015	04/16/2015	100.060	99.850	99.9	1
LG&E	C1S	901098	04/2015	04/16/2015	100.060	99.920	100.1	1
LG&E	C1S	901099	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901100	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901101	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901102	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901103	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	901104	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901105	04/2015	04/16/2015	100.090	99.960	100.1	1
LG&E	C1S	901106	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	901107	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901108	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901109	04/2015	04/16/2015	100.060	99.950	99.9	1
LG&E	C1S	901110	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901111	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901112	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	901113	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901114	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	901115	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901116	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901117	04/2015	04/16/2015	100.090	99.850	100.0	1
LG&E	C1S	901118	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	901119	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901120	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901121	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901122	04/2015	04/16/2015	100.080	99.920	100.1	1
LG&E	C1S	901123	04/2015	04/16/2015	100.100	99.970	100.0	1
LG&E	C1S	901124	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	901125	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	901126	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901127	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901128	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901129	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	901130	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	901131	04/2015	04/16/2015	100.060	99.900	100.0	1

LG&E	C1S	901132	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	901133	04/2015	04/16/2015	100.100	99.880	100.0	1
LG&E	C1S	901134	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	901135	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	901136	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901137	04/2015	04/16/2015	100.100	99.820	100.1	1
LG&E	C1S	901138	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	901139	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901140	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901141	04/2015	04/16/2015	100.080	99.850	100.0	1
LG&E	C1S	901142	04/2015	04/16/2015	100.090	100.010	99.9	1
LG&E	C1S	901143	04/2015	04/16/2015	100.090	99.930	99.9	1
LG&E	C1S	901144	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901145	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901146	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901147	04/2015	04/16/2015	100.090	99.880	100.1	1
LG&E	C1S	901148	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901149	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901150	04/2015	04/16/2015	100.050	99.890	100.0	1
LG&E	C1S	901151	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901152	04/2015	04/16/2015	100.080	99.950	100.1	1
LG&E	C1S	901153	04/2015	04/16/2015	100.060	99.910	100.1	1
LG&E	C1S	901154	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901155	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901156	04/2015	04/16/2015	100.070	99.970	100.0	1
LG&E	C1S	901157	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901158	04/2015	04/16/2015	100.100	99.940	99.9	1
LG&E	C1S	901159	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901160	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901161	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	901162	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901163	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901164	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901165	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	901166	04/2015	04/16/2015	100.050	99.890	100.0	1
LG&E	C1S	901167	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901168	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901169	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901170	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901171	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901172	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901173	04/2015	04/16/2015	100.050	99.970	100.0	1

LG&E	C1S	901174	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	901175	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901176	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901177	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901178	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901179	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901180	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901181	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901182	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901183	04/2015	04/16/2015	100.070	99.910	99.9	1
LG&E	C1S	901184	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	901185	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901186	04/2015	04/16/2015	100.070	99.990	100.0	1
LG&E	C1S	901187	04/2015	04/16/2015	100.110	99.950	100.0	1
LG&E	C1S	901188	04/2015	04/16/2015	100.100	99.950	100.1	1
LG&E	C1S	901189	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901190	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901191	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901192	04/2015	04/16/2015	100.080	99.880	100.0	1
LG&E	C1S	901193	04/2015	04/16/2015	100.070	99.980	100.0	1
LG&E	C1S	901194	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	901195	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	901196	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	901197	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901198	04/2015	04/16/2015	100.070	99.970	100.0	1
LG&E	C1S	901199	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	901200	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901201	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901202	04/2015	04/16/2015	100.080	100.000	100.0	1
LG&E	C1S	901203	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901204	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901205	04/2015	04/16/2015	100.090	99.870	100.0	1
LG&E	C1S	901206	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901207	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901208	04/2015	04/16/2015	100.060	99.920	99.9	1
LG&E	C1S	901209	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901210	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	901211	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901212	04/2015	04/16/2015	100.060	99.930	100.1	1
LG&E	C1S	901213	04/2015	04/16/2015	100.110	99.940	100.1	1
LG&E	C1S	901214	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901215	04/2015	04/16/2015	100.060	99.950	100.0	1

LG&E	C1S	901216	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	901217	04/2015	04/16/2015	100.060	99.860	99.9	1
LG&E	C1S	901218	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901219	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901220	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	901221	04/2015	04/16/2015	100.100	99.930	100.1	1
LG&E	C1S	901222	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	901223	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901224	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901225	04/2015	04/16/2015	100.060	99.890	100.1	1
LG&E	C1S	901226	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901227	04/2015	04/16/2015	100.070	100.010	100.0	1
LG&E	C1S	901228	04/2015	04/16/2015	100.050	99.890	100.0	1
LG&E	C1S	901229	04/2015	04/16/2015	100.080	99.950	99.9	1
LG&E	C1S	901230	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901231	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901232	04/2015	04/16/2015	100.070	99.970	100.0	1
LG&E	C1S	901233	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901234	04/2015	04/16/2015	100.060	99.820	100.0	1
LG&E	C1S	901235	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	901236	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901237	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	901238	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901239	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901240	04/2015	04/16/2015	100.090	99.910	100.1	1
LG&E	C1S	901241	04/2015	04/16/2015	100.100	99.900	100.0	1
LG&E	C1S	901242	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	901243	04/2015	04/16/2015	100.060	99.920	100.1	1
LG&E	C1S	901244	04/2015	04/16/2015	100.050	99.830	100.0	1
LG&E	C1S	901245	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901246	04/2015	04/16/2015	100.060	99.950	99.9	1
LG&E	C1S	901247	04/2015	04/16/2015	100.050	99.890	99.9	1
LG&E	C1S	901248	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901249	04/2015	04/16/2015	100.080	99.840	100.0	1
LG&E	C1S	901250	04/2015	04/16/2015	100.090	99.990	100.1	1
LG&E	C1S	901251	04/2015	04/16/2015	100.060	99.890	100.1	1
LG&E	C1S	901252	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	901253	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901254	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901255	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	901256	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901257	04/2015	04/16/2015	100.070	99.970	100.0	1

LG&E	C1S	901258	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901259	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	901260	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901261	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901262	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901263	04/2015	04/16/2015	100.100	99.870	100.0	1
LG&E	C1S	901264	04/2015	04/16/2015	100.050	99.850	99.9	1
LG&E	C1S	901265	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901266	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	901267	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901268	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	901269	04/2015	04/16/2015	100.070	99.880	99.9	1
LG&E	C1S	901270	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901271	04/2015	04/16/2015	100.100	99.900	100.0	1
LG&E	C1S	901272	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901273	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901274	04/2015	04/16/2015	100.100	100.000	100.0	1
LG&E	C1S	901275	04/2015	04/16/2015	100.090	99.860	100.0	1
LG&E	C1S	901276	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901277	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901278	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901279	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901280	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901281	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901282	04/2015	04/16/2015	100.090	100.000	99.9	1
LG&E	C1S	901283	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	901284	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901285	04/2015	04/16/2015	100.050	99.920	100.0	1
LG&E	C1S	901286	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901287	04/2015	04/16/2015	100.100	99.890	100.0	1
LG&E	C1S	901288	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901289	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901290	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901291	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901292	04/2015	04/16/2015	100.070	99.860	100.0	1
LG&E	C1S	901293	04/2015	04/16/2015	100.100	100.010	100.1	1
LG&E	C1S	901294	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901295	04/2015	04/16/2015	100.100	99.930	100.1	1
LG&E	C1S	901296	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901297	04/2015	04/16/2015	100.080	99.930	100.1	1
LG&E	C1S	901298	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901299	04/2015	04/16/2015	100.070	99.930	100.0	1

LG&E	C1S	901300	04/2015	04/16/2015	100.100	99.880	100.1	1
LG&E	C1S	901301	04/2015	04/16/2015	100.060	99.850	100.0	1
LG&E	C1S	901302	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901303	04/2015	04/16/2015	100.080	99.900	100.1	1
LG&E	C1S	901304	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901305	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901306	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901307	04/2015	04/16/2015	100.090	99.990	100.1	1
LG&E	C1S	901308	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	901309	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901310	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	901311	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901312	04/2015	04/16/2015	100.090	100.010	100.0	1
LG&E	C1S	901313	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	901314	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901315	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901316	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901317	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901318	04/2015	04/16/2015	100.080	99.970	99.9	1
LG&E	C1S	901319	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	901320	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901321	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901322	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901323	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901324	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901325	04/2015	04/16/2015	100.050	99.860	100.0	1
LG&E	C1S	901326	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901327	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901328	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901329	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901330	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901331	04/2015	04/16/2015	100.090	99.850	100.0	1
LG&E	C1S	901332	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901333	04/2015	04/16/2015	100.070	99.900	100.1	1
LG&E	C1S	901334	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901335	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901336	04/2015	04/16/2015	100.100	99.880	100.1	1
LG&E	C1S	901337	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	901338	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	901339	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901340	04/2015	04/16/2015	100.080	99.900	99.9	1
LG&E	C1S	901341	04/2015	04/16/2015	100.090	99.900	100.0	1

LG&E	C1S	901342	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901343	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901344	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901345	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901346	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901347	04/2015	04/16/2015	100.060	99.890	99.9	1
LG&E	C1S	901348	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901349	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	901350	04/2015	04/16/2015	100.090	99.940	99.9	1
LG&E	C1S	901351	04/2015	04/16/2015	100.120	99.950	100.0	1
LG&E	C1S	901352	04/2015	04/16/2015	100.100	99.890	100.1	1
LG&E	C1S	901353	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901354	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901355	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901356	04/2015	04/16/2015	100.070	99.910	99.9	1
LG&E	C1S	901357	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901358	04/2015	04/16/2015	100.070	99.980	100.1	1
LG&E	C1S	901359	04/2015	04/16/2015	100.060	99.860	100.0	1
LG&E	C1S	901360	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901361	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901362	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901363	04/2015	04/16/2015	100.070	99.990	99.9	1
LG&E	C1S	901364	04/2015	04/16/2015	100.070	99.990	100.0	1
LG&E	C1S	901365	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901366	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901367	04/2015	04/16/2015	100.100	99.980	100.0	1
LG&E	C1S	901368	04/2015	04/16/2015	100.080	99.880	100.0	1
LG&E	C1S	901369	04/2015	04/16/2015	100.100	99.930	100.1	1
LG&E	C1S	901370	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901371	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901372	04/2015	04/16/2015	100.100	99.860	100.0	1
LG&E	C1S	901373	04/2015	04/16/2015	100.100	99.890	100.0	1
LG&E	C1S	901374	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901375	04/2015	04/16/2015	100.070	99.880	100.1	1
LG&E	C1S	901376	04/2015	04/16/2015	100.050	99.830	100.0	1
LG&E	C1S	901377	04/2015	04/16/2015	100.100	99.970	99.9	1
LG&E	C1S	901378	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901379	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	901380	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	901381	04/2015	04/16/2015	100.070	99.890	100.1	1
LG&E	C1S	901382	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901383	04/2015	04/16/2015	100.080	99.920	100.0	1

LG&E	C1S	901384	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901385	04/2015	04/16/2015	100.050	99.840	99.9	1
LG&E	C1S	901386	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	901387	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	901388	04/2015	04/16/2015	100.080	99.880	100.1	1
LG&E	C1S	901389	04/2015	04/16/2015	100.100	99.990	100.0	1
LG&E	C1S	901390	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901391	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901392	04/2015	04/16/2015	100.100	99.870	100.1	1
LG&E	C1S	901393	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901394	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901395	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901396	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901397	04/2015	04/16/2015	100.090	99.850	100.0	1
LG&E	C1S	901398	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901399	04/2015	04/16/2015	100.070	99.940	99.9	1
LG&E	C1S	901400	04/2015	04/16/2015	100.100	99.860	100.0	1
LG&E	C1S	901401	04/2015	04/16/2015	100.050	99.860	99.9	1
LG&E	C1S	901402	04/2015	04/16/2015	100.100	99.900	100.1	1
LG&E	C1S	901403	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901404	04/2015	04/16/2015	100.080	99.840	100.0	1
LG&E	C1S	901405	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901406	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901407	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901408	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901409	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901410	04/2015	04/16/2015	100.100	99.870	100.0	1
LG&E	C1S	901411	04/2015	04/16/2015	100.090	99.960	99.9	1
LG&E	C1S	901412	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901413	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901414	04/2015	04/16/2015	100.100	99.960	100.1	1
LG&E	C1S	901415	04/2015	04/16/2015	100.080	99.840	99.9	1
LG&E	C1S	901416	04/2015	04/16/2015	100.100	100.000	100.0	1
LG&E	C1S	901417	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901418	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901419	04/2015	04/16/2015	100.100	100.000	100.0	1
LG&E	C1S	901420	04/2015	04/16/2015	100.060	99.900	99.9	1
LG&E	C1S	901421	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901422	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901423	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901424	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901425	04/2015	04/16/2015	100.090	99.900	100.1	1

LG&E	C1S	901426	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901427	04/2015	04/16/2015	100.050	99.820	100.0	1
LG&E	C1S	901428	04/2015	04/16/2015	100.070	99.910	99.9	1
LG&E	C1S	901429	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901430	04/2015	04/16/2015	100.100	99.960	100.1	1
LG&E	C1S	901431	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901432	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901433	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901434	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901435	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901436	04/2015	04/16/2015	100.050	99.910	100.0	1
LG&E	C1S	901437	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901438	04/2015	04/16/2015	100.080	99.860	99.9	1
LG&E	C1S	901439	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901440	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901441	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901442	04/2015	04/16/2015	100.090	99.930	99.9	1
LG&E	C1S	901443	04/2015	04/16/2015	100.070	99.860	100.1	1
LG&E	C1S	901444	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	901445	04/2015	04/16/2015	100.070	99.930	99.9	1
LG&E	C1S	901446	04/2015	04/16/2015	100.070	99.910	99.9	1
LG&E	C1S	901447	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	901448	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901449	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901450	04/2015	04/16/2015	100.090	99.900	99.9	1
LG&E	C1S	901451	04/2015	04/16/2015	100.060	99.940	99.9	1
LG&E	C1S	901452	04/2015	04/16/2015	100.060	99.970	100.0	1
LG&E	C1S	901453	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901454	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901455	04/2015	04/16/2015	100.090	100.010	100.1	1
LG&E	C1S	901456	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901457	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	901458	04/2015	04/16/2015	100.060	99.860	99.9	1
LG&E	C1S	901459	04/2015	04/16/2015	100.100	99.980	100.1	1
LG&E	C1S	901460	04/2015	04/16/2015	100.100	99.880	99.9	1
LG&E	C1S	901461	04/2015	04/16/2015	100.110	99.990	100.0	1
LG&E	C1S	901462	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901463	04/2015	04/16/2015	100.060	99.940	99.9	1
LG&E	C1S	901464	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901465	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	901466	04/2015	04/16/2015	100.090	99.940	100.1	1
LG&E	C1S	901467	04/2015	04/16/2015	100.070	99.930	100.0	1

LG&E	C1S	901468	04/2015	04/16/2015	100.100	99.940	99.9	1
LG&E	C1S	901469	04/2015	04/16/2015	100.050	99.890	99.9	1
LG&E	C1S	901470	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901471	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901472	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901473	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901474	04/2015	04/16/2015	100.090	99.890	100.0	1
LG&E	C1S	901475	04/2015	04/16/2015	100.050	99.930	99.9	1
LG&E	C1S	901476	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901477	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901478	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901479	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901480	04/2015	04/16/2015	100.080	99.860	100.0	1
LG&E	C1S	901481	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	901482	04/2015	04/16/2015	100.090	99.880	100.0	1
LG&E	C1S	901483	04/2015	04/16/2015	100.100	100.010	100.0	1
LG&E	C1S	901484	04/2015	04/16/2015	100.050	99.930	100.0	1
LG&E	C1S	901485	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901486	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901487	04/2015	04/16/2015	100.070	99.920	100.1	1
LG&E	C1S	901488	04/2015	04/16/2015	100.100	100.010	100.1	1
LG&E	C1S	901489	04/2015	04/16/2015	100.080	99.920	99.9	1
LG&E	C1S	901490	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	901491	04/2015	04/16/2015	100.070	99.930	100.1	1
LG&E	C1S	901492	04/2015	04/16/2015	100.080	99.900	100.0	1
LG&E	C1S	901493	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901494	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901495	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901496	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901497	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901498	04/2015	04/16/2015	100.100	99.890	100.0	1
LG&E	C1S	901499	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901500	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901501	04/2015	04/16/2015	100.100	99.950	100.0	1
LG&E	C1S	901502	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901503	04/2015	04/16/2015	100.100	99.890	99.9	1
LG&E	C1S	901504	04/2015	04/16/2015	100.090	99.920	100.1	1
LG&E	C1S	901505	04/2015	04/16/2015	100.080	99.960	100.1	1
LG&E	C1S	901506	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901507	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	901508	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901509	04/2015	04/16/2015	100.080	99.900	100.0	1

LG&E	C1S	901510	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	901511	04/2015	04/16/2015	100.060	99.940	99.9	1
LG&E	C1S	901512	04/2015	04/16/2015	100.080	99.990	100.0	1
LG&E	C1S	901513	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901514	04/2015	04/16/2015	100.100	99.980	100.0	1
LG&E	C1S	901515	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901516	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	901517	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901518	04/2015	04/16/2015	100.080	99.950	100.0	1
LG&E	C1S	901519	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	901520	04/2015	04/16/2015	100.080	99.880	100.0	1
LG&E	C1S	901521	04/2015	04/16/2015	100.100	99.960	100.0	1
LG&E	C1S	901522	04/2015	04/16/2015	100.050	99.910	100.0	1
LG&E	C1S	901523	04/2015	04/16/2015	100.070	99.960	100.1	1
LG&E	C1S	901524	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901525	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901526	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901527	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901528	04/2015	04/16/2015	100.090	99.950	100.0	1
LG&E	C1S	901529	04/2015	04/16/2015	100.090	99.880	99.9	1
LG&E	C1S	901530	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901531	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901532	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	901533	04/2015	04/16/2015	100.060	99.900	100.1	1
LG&E	C1S	901534	04/2015	04/16/2015	100.060	99.880	99.9	1
LG&E	C1S	901535	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	901536	04/2015	04/16/2015	100.070	99.900	99.9	1
LG&E	C1S	901537	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901538	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901539	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901540	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901541	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	901542	04/2015	04/16/2015	100.050	99.870	100.0	1
LG&E	C1S	901543	04/2015	04/16/2015	100.070	99.950	100.0	1
LG&E	C1S	901544	04/2015	04/16/2015	100.090	99.970	100.1	1
LG&E	C1S	901545	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901546	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901547	04/2015	04/16/2015	100.060	99.870	100.1	1
LG&E	C1S	901548	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	901549	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901550	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901551	04/2015	04/16/2015	100.080	99.890	100.0	1

LG&E	C1S	901552	04/2015	04/16/2015	100.090	99.880	100.0	1
LG&E	C1S	901553	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	901554	04/2015	04/16/2015	100.080	99.960	100.1	1
LG&E	C1S	901555	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	901556	04/2015	04/16/2015	100.100	99.940	100.1	1
LG&E	C1S	901557	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901558	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901559	04/2015	04/16/2015	100.090	99.960	100.0	1
LG&E	C1S	901560	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	901561	04/2015	04/16/2015	100.100	99.940	100.0	1
LG&E	C1S	901562	04/2015	04/16/2015	100.060	99.870	100.0	1
LG&E	C1S	901563	04/2015	04/16/2015	100.080	99.940	100.0	1
LG&E	C1S	901564	04/2015	04/16/2015	100.100	99.880	100.0	1
LG&E	C1S	901565	04/2015	04/16/2015	100.060	99.960	99.9	1
LG&E	C1S	901566	04/2015	04/16/2015	100.090	99.850	100.0	1
LG&E	C1S	901567	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901568	04/2015	04/16/2015	100.090	99.870	100.1	1
LG&E	C1S	901569	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901570	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	901571	04/2015	04/16/2015	100.080	100.000	100.0	1
LG&E	C1S	901572	04/2015	04/16/2015	100.080	99.860	100.0	1
LG&E	C1S	901573	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901574	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901575	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901576	04/2015	04/16/2015	100.070	99.940	99.9	1
LG&E	C1S	901577	04/2015	04/16/2015	100.060	99.830	100.0	1
LG&E	C1S	901578	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901579	04/2015	04/16/2015	100.060	99.910	100.0	1
LG&E	C1S	901580	04/2015	04/16/2015	100.060	99.980	100.0	1
LG&E	C1S	901581	04/2015	04/16/2015	100.060	99.900	99.9	1
LG&E	C1S	901582	04/2015	04/16/2015	100.080	100.000	100.0	1
LG&E	C1S	901583	04/2015	04/16/2015	100.060	99.950	100.0	1
LG&E	C1S	901584	04/2015	04/16/2015	100.060	99.890	99.9	1
LG&E	C1S	901585	04/2015	04/16/2015	100.060	99.990	100.1	1
LG&E	C1S	901586	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901587	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901588	04/2015	04/16/2015	100.070	99.870	100.1	1
LG&E	C1S	901589	04/2015	04/16/2015	100.080	99.910	100.0	1
LG&E	C1S	901590	04/2015	04/16/2015	100.050	99.890	100.0	1
LG&E	C1S	901591	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901592	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901593	04/2015	04/16/2015	100.110	99.860	100.0	1

LG&E	C1S	901594	04/2015	04/16/2015	100.090	99.970	100.0	1
LG&E	C1S	901595	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901596	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901597	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901598	04/2015	04/16/2015	100.080	99.890	100.0	1
LG&E	C1S	901599	04/2015	04/16/2015	100.070	99.940	99.9	1
LG&E	C1S	901600	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901601	04/2015	04/16/2015	100.070	99.880	100.1	1
LG&E	C1S	901602	04/2015	04/16/2015	100.060	99.850	100.0	1
LG&E	C1S	901603	04/2015	04/16/2015	100.070	99.870	100.1	1
LG&E	C1S	901604	04/2015	04/16/2015	100.070	99.840	100.0	1
LG&E	C1S	901605	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901606	04/2015	04/16/2015	100.080	99.870	100.0	1
LG&E	C1S	901607	04/2015	04/16/2015	100.100	99.900	100.0	1
LG&E	C1S	901608	04/2015	04/16/2015	100.090	99.920	100.0	1
LG&E	C1S	901609	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901610	04/2015	04/16/2015	100.090	99.980	100.0	1
LG&E	C1S	901611	04/2015	04/16/2015	100.080	99.970	100.0	1
LG&E	C1S	901612	04/2015	04/16/2015	100.110	99.960	100.1	1
LG&E	C1S	901613	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901614	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901615	04/2015	04/16/2015	100.100	99.890	100.0	1
LG&E	C1S	901616	04/2015	04/16/2015	100.090	99.850	100.1	1
LG&E	C1S	901617	04/2015	04/16/2015	100.060	99.870	99.9	1
LG&E	C1S	901618	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901619	04/2015	04/16/2015	100.060	99.830	99.9	1
LG&E	C1S	901620	04/2015	04/16/2015	100.080	99.960	100.0	1
LG&E	C1S	901621	04/2015	04/16/2015	100.070	99.920	100.1	1
LG&E	C1S	901622	04/2015	04/16/2015	100.050	99.850	100.0	1
LG&E	C1S	901623	04/2015	04/16/2015	100.100	100.030	100.1	1
LG&E	C1S	901624	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	901625	04/2015	04/16/2015	100.090	99.940	100.0	1
LG&E	C1S	901626	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901627	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901628	04/2015	04/16/2015	100.080	99.890	100.1	1
LG&E	C1S	901629	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	901630	04/2015	04/16/2015	100.100	99.950	100.1	1
LG&E	C1S	901631	04/2015	04/16/2015	100.050	99.910	100.0	1
LG&E	C1S	901632	04/2015	04/16/2015	100.090	99.900	100.0	1
LG&E	C1S	901633	04/2015	04/16/2015	100.060	99.850	99.9	1
LG&E	C1S	901634	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901635	04/2015	04/16/2015	100.070	99.920	100.0	1

LG&E	C1S	901636	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901637	04/2015	04/16/2015	100.070	99.820	100.0	1
LG&E	C1S	901638	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901639	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901640	04/2015	04/16/2015	100.050	99.920	100.0	1
LG&E	C1S	901641	04/2015	04/16/2015	100.090	99.950	100.1	1
LG&E	C1S	901642	04/2015	04/16/2015	100.070	99.900	100.0	1
LG&E	C1S	901643	04/2015	04/16/2015	100.090	99.980	100.1	1
LG&E	C1S	901644	04/2015	04/16/2015	100.100	99.930	100.0	1
LG&E	C1S	901645	04/2015	04/16/2015	100.070	99.940	100.0	1
LG&E	C1S	901646	04/2015	04/16/2015	100.100	99.960	100.1	1
LG&E	C1S	901647	04/2015	04/16/2015	100.060	99.880	99.9	1
LG&E	C1S	901648	04/2015	04/16/2015	100.080	99.980	100.0	1
LG&E	C1S	901649	04/2015	04/16/2015	100.080	99.920	100.0	1
LG&E	C1S	901650	04/2015	04/16/2015	100.080	100.000	100.1	1
LG&E	C1S	901651	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901652	04/2015	04/16/2015	100.060	99.980	100.0	1
LG&E	C1S	901653	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901654	04/2015	04/16/2015	100.070	99.910	100.0	1
LG&E	C1S	901655	04/2015	04/16/2015	100.090	99.990	100.0	1
LG&E	C1S	901656	04/2015	04/16/2015	100.070	99.940	99.9	1
LG&E	C1S	901657	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	901658	04/2015	04/16/2015	100.100	99.920	100.0	1
LG&E	C1S	901659	04/2015	04/16/2015	100.060	99.840	99.9	1
LG&E	C1S	901660	04/2015	04/16/2015	100.070	99.920	100.0	1
LG&E	C1S	901661	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901662	04/2015	04/16/2015	100.060	99.970	99.9	1
LG&E	C1S	901663	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901664	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	901665	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	901666	04/2015	04/16/2015	100.090	99.960	99.9	1
LG&E	C1S	901667	04/2015	04/16/2015	100.070	99.870	100.0	1
LG&E	C1S	901668	04/2015	04/16/2015	100.050	99.900	100.0	1
LG&E	C1S	901669	04/2015	04/16/2015	100.070	99.880	100.0	1
LG&E	C1S	901670	04/2015	04/16/2015	100.060	99.960	100.0	1
LG&E	C1S	901671	04/2015	04/16/2015	100.070	99.960	100.0	1
LG&E	C1S	901672	04/2015	04/16/2015	100.100	99.900	100.1	1
LG&E	C1S	901673	04/2015	04/16/2015	100.080	99.930	100.0	1
LG&E	C1S	901674	04/2015	04/16/2015	100.090	99.930	100.0	1
LG&E	C1S	901675	04/2015	04/16/2015	100.070	99.940	100.1	1
LG&E	C1S	901676	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901677	04/2015	04/16/2015	100.060	99.990	100.0	1

LG&E	C1S	901678	04/2015	04/16/2015	100.100	99.980	100.0	1
LG&E	C1S	901679	04/2015	04/16/2015	100.060	99.940	100.0	1
LG&E	C1S	901680	04/2015	04/16/2015	100.060	99.850	99.9	1
LG&E	C1S	901681	04/2015	04/16/2015	100.100	99.870	100.1	1
LG&E	C1S	901682	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901683	04/2015	04/16/2015	100.100	99.970	100.1	1
LG&E	C1S	901684	04/2015	04/16/2015	100.100	99.870	100.0	1
LG&E	C1S	901685	04/2015	04/16/2015	100.070	99.900	100.1	1
LG&E	C1S	901686	04/2015	04/16/2015	100.060	99.920	100.0	1
LG&E	C1S	901687	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901688	04/2015	04/16/2015	100.060	99.830	100.0	1
LG&E	C1S	901689	04/2015	04/16/2015	100.100	100.080	100.0	1
LG&E	C1S	901690	04/2015	04/16/2015	100.090	99.950	99.9	1
LG&E	C1S	901691	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901692	04/2015	04/16/2015	100.060	99.910	99.9	1
LG&E	C1S	901693	04/2015	04/16/2015	100.060	99.840	100.0	1
LG&E	C1S	901694	04/2015	04/16/2015	100.060	99.920	99.9	1
LG&E	C1S	901695	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901696	04/2015	04/16/2015	100.100	99.970	100.1	1
LG&E	C1S	901697	04/2015	04/16/2015	100.060	99.890	100.0	1
LG&E	C1S	901698	04/2015	04/16/2015	100.100	99.970	100.1	1
LG&E	C1S	901699	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901700	04/2015	04/16/2015	100.070	99.930	100.0	1
LG&E	C1S	901701	04/2015	04/16/2015	100.060	99.930	100.0	1
LG&E	C1S	901702	04/2015	04/16/2015	100.090	99.910	100.0	1
LG&E	C1S	901703	04/2015	04/16/2015	100.100	99.840	100.0	1
LG&E	C1S	901704	04/2015	04/16/2015	100.100	99.910	100.0	1
LG&E	C1S	901705	04/2015	04/16/2015	100.070	99.890	100.0	1
LG&E	C1S	901706	04/2015	04/16/2015	100.060	99.900	100.0	1
LG&E	C1S	901707	04/2015	04/16/2015	100.060	99.880	100.0	1
LG&E	C1S	901708	04/2015	04/16/2015	100.080	99.870	100.1	1
LG&E	C1S	901709	04/2015	04/16/2015	100.060	99.850	100.0	1
LG&E	C1S	904078	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904079	09/2015	09/10/2015	100.050	99.920	99.9	1
LG&E	C1S	904080	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904081	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	904082	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	904083	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904084	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	904085	09/2015	09/10/2015	100.090	99.840	100.1	1
LG&E	C1S	904086	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904087	09/2015	09/10/2015	100.060	99.950	100.0	1

LG&E	C1S	904088	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	904089	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	904090	09/2015	09/10/2015	100.050	99.820	99.9	1
LG&E	C1S	904091	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904092	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904093	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	904094	09/2015	09/10/2015	100.060	99.890	99.9	1
LG&E	C1S	904095	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904096	09/2015	09/10/2015	100.070	99.980	99.9	1
LG&E	C1S	904097	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904098	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	904099	09/2015	09/10/2015	100.060	99.870	100.1	1
LG&E	C1S	904100	09/2015	09/10/2015	100.080	99.910	99.9	1
LG&E	C1S	904101	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904102	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904103	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	904104	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904105	09/2015	09/10/2015	100.090	99.840	100.1	1
LG&E	C1S	904106	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904107	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	904108	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904109	09/2015	09/10/2015	100.090	99.900	99.9	1
LG&E	C1S	904110	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904111	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	904112	09/2015	09/10/2015	100.070	99.950	100.1	1
LG&E	C1S	904113	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	904114	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	904115	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904116	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	904117	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	904118	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904119	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904120	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	904121	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	904122	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	904123	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	904124	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904125	09/2015	09/10/2015	100.050	99.830	100.0	1
LG&E	C1S	904126	09/2015	09/10/2015	100.100	99.940	99.9	1
LG&E	C1S	904127	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904128	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904129	09/2015	09/10/2015	100.060	99.940	100.0	1

LG&E	C1S	904130	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904131	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	904132	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904133	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	904134	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904135	09/2015	09/10/2015	100.080	99.950	99.9	1
LG&E	C1S	904136	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904137	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904138	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	904139	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	904140	09/2015	09/10/2015	100.100	100.020	100.0	1
LG&E	C1S	904141	09/2015	09/10/2015	100.070	99.880	100.1	1
LG&E	C1S	904142	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904143	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904144	09/2015	09/10/2015	100.060	100.010	100.0	1
LG&E	C1S	904145	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904146	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904147	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904148	09/2015	09/10/2015	100.070	99.930	100.1	1
LG&E	C1S	904149	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904150	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904151	09/2015	09/10/2015	100.090	99.900	100.1	1
LG&E	C1S	904152	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	904153	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	904154	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904155	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904156	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904157	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904158	09/2015	09/10/2015	100.100	100.030	100.0	1
LG&E	C1S	904159	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904160	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904161	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904162	09/2015	09/10/2015	100.080	99.930	100.1	1
LG&E	C1S	904163	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904164	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904165	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	904166	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	904167	09/2015	09/10/2015	100.090	99.830	100.1	1
LG&E	C1S	904168	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904169	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904170	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904171	09/2015	09/10/2015	100.100	99.940	100.0	1

LG&E	C1S	904172	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904173	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904174	09/2015	09/10/2015	100.050	99.860	99.9	1
LG&E	C1S	904175	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904176	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	904177	09/2015	09/10/2015	100.100	99.810	100.0	1
LG&E	C1S	904178	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	904179	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904180	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904181	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904182	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904183	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904184	09/2015	09/10/2015	100.050	99.990	99.9	1
LG&E	C1S	904185	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	904186	09/2015	09/10/2015	100.050	99.810	100.0	1
LG&E	C1S	904187	09/2015	09/10/2015	100.070	100.040	100.0	1
LG&E	C1S	904188	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904189	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904190	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904191	09/2015	09/10/2015	100.100	99.920	100.1	1
LG&E	C1S	904192	09/2015	09/10/2015	100.100	99.940	100.1	1
LG&E	C1S	904193	09/2015	09/10/2015	100.050	99.890	99.9	1
LG&E	C1S	904194	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904195	09/2015	09/10/2015	100.060	99.950	99.9	1
LG&E	C1S	904196	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	904197	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904198	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	904199	09/2015	09/10/2015	100.060	99.990	100.0	1
LG&E	C1S	904200	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904201	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	904202	09/2015	09/10/2015	100.070	99.830	99.9	1
LG&E	C1S	904203	09/2015	09/10/2015	100.090	100.000	100.1	1
LG&E	C1S	904204	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	904205	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904206	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904207	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904208	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	904209	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904210	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904211	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	904212	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904213	09/2015	09/10/2015	100.060	99.910	100.0	1

LG&E	C1S	904214	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904215	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904216	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	904217	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	904218	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	904219	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904220	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904221	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904222	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904223	09/2015	09/10/2015	100.070	99.850	99.9	1
LG&E	C1S	904224	09/2015	09/10/2015	100.060	99.850	99.9	1
LG&E	C1S	904225	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	904226	09/2015	09/10/2015	100.080	99.950	100.1	1
LG&E	C1S	904227	09/2015	09/10/2015	100.070	100.070	100.0	1
LG&E	C1S	904228	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904229	09/2015	09/10/2015	100.070	99.890	100.1	1
LG&E	C1S	904230	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	904231	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	904232	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	904233	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	904234	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904235	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	904236	09/2015	09/10/2015	100.080	99.900	100.1	1
LG&E	C1S	904237	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904238	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904239	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	904240	09/2015	09/10/2015	100.090	99.910	99.9	1
LG&E	C1S	904241	09/2015	09/10/2015	100.080	99.920	99.9	1
LG&E	C1S	904242	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904243	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	904244	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	904245	09/2015	09/10/2015	100.060	99.800	100.0	1
LG&E	C1S	904246	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904247	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904248	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904249	09/2015	09/10/2015	100.090	99.850	100.1	1
LG&E	C1S	904250	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904251	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904252	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	904253	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	904254	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904255	09/2015	09/10/2015	100.090	99.870	100.0	1

LG&E	C1S	904256	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904257	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904258	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	904259	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	904260	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904261	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904262	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	904263	09/2015	09/10/2015	100.090	100.000	100.1	1
LG&E	C1S	904264	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904265	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904266	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904267	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	904268	09/2015	09/10/2015	100.050	99.890	100.1	1
LG&E	C1S	904269	09/2015	09/10/2015	100.060	99.910	99.9	1
LG&E	C1S	904270	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	904271	09/2015	09/10/2015	100.060	99.910	99.9	1
LG&E	C1S	904272	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904273	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904274	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904275	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	904276	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904277	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904278	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904279	09/2015	09/10/2015	100.100	99.970	100.1	1
LG&E	C1S	904280	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904281	09/2015	09/10/2015	100.100	99.920	100.1	1
LG&E	C1S	904282	09/2015	09/10/2015	100.080	99.990	99.9	1
LG&E	C1S	904283	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904284	09/2015	09/10/2015	100.060	99.970	99.9	1
LG&E	C1S	904285	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904286	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904287	09/2015	09/10/2015	100.060	99.820	99.9	1
LG&E	C1S	904288	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904289	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904290	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904291	09/2015	09/10/2015	100.090	99.980	99.9	1
LG&E	C1S	904292	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904293	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904294	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904295	09/2015	09/10/2015	100.070	99.900	99.9	1
LG&E	C1S	904296	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904297	09/2015	09/10/2015	100.090	99.930	100.0	1

LG&E	C1S	904298	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	904299	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904300	09/2015	09/10/2015	100.070	100.060	100.0	1
LG&E	C1S	904301	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904302	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904303	09/2015	09/10/2015	100.060	99.950	99.9	1
LG&E	C1S	904304	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904305	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904306	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904307	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904308	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	904309	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904310	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904311	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	904312	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904313	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904314	09/2015	09/10/2015	100.090	99.860	100.1	1
LG&E	C1S	904315	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904316	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904317	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904318	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904319	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904320	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904321	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	904322	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904323	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	904324	09/2015	09/10/2015	100.100	99.820	100.0	1
LG&E	C1S	904325	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904326	09/2015	09/10/2015	100.070	99.810	100.1	1
LG&E	C1S	904327	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	904328	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904329	09/2015	09/10/2015	100.080	100.030	100.0	1
LG&E	C1S	904330	09/2015	09/10/2015	100.080	99.920	99.9	1
LG&E	C1S	904331	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904332	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904333	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904334	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904335	09/2015	09/10/2015	100.090	99.860	100.1	1
LG&E	C1S	904336	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904337	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904338	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	904339	09/2015	09/10/2015	100.080	99.880	100.0	1

LG&E	C1S	904340	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904341	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904342	09/2015	09/10/2015	100.100	99.970	100.1	1
LG&E	C1S	904343	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904344	09/2015	09/10/2015	100.060	99.860	99.9	1
LG&E	C1S	904345	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904346	09/2015	09/10/2015	100.050	100.010	99.9	1
LG&E	C1S	904347	09/2015	09/10/2015	100.070	99.870	99.9	1
LG&E	C1S	904348	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	904349	09/2015	09/10/2015	100.050	99.850	99.9	1
LG&E	C1S	904350	09/2015	09/10/2015	100.090	99.890	99.9	1
LG&E	C1S	904351	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904352	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904353	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904354	09/2015	09/10/2015	100.090	99.990	100.1	1
LG&E	C1S	904355	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	904356	09/2015	09/10/2015	100.100	99.880	100.0	1
LG&E	C1S	904357	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904358	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904359	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	904360	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904361	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904362	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904363	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	904364	09/2015	09/10/2015	100.090	100.020	100.1	1
LG&E	C1S	904365	09/2015	09/10/2015	100.060	99.880	99.9	1
LG&E	C1S	904366	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904367	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904368	09/2015	09/10/2015	100.100	99.950	100.0	1
LG&E	C1S	904369	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904370	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904371	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	904372	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904373	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904374	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904375	09/2015	09/10/2015	100.100	99.920	100.1	1
LG&E	C1S	904376	09/2015	09/10/2015	100.050	99.820	100.0	1
LG&E	C1S	904377	09/2015	09/10/2015	100.080	99.920	99.9	1
LG&E	C1S	904378	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	904379	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904380	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904381	09/2015	09/10/2015	100.050	99.910	100.0	1

LG&E	C1S	904382	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904383	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904384	09/2015	09/10/2015	100.080	99.920	100.1	1
LG&E	C1S	904385	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904386	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904387	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	904388	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904389	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	904390	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	904391	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	904392	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904393	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904394	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	904395	09/2015	09/10/2015	100.100	99.960	100.1	1
LG&E	C1S	904396	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904397	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904398	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904399	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904400	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	904401	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904402	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904403	09/2015	09/10/2015	100.060	99.920	99.9	1
LG&E	C1S	904404	09/2015	09/10/2015	100.060	99.800	100.0	1
LG&E	C1S	904405	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904406	09/2015	09/10/2015	100.070	99.820	100.0	1
LG&E	C1S	904407	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904408	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904409	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904410	09/2015	09/10/2015	100.090	99.980	100.1	1
LG&E	C1S	904411	09/2015	09/10/2015	100.050	100.010	100.0	1
LG&E	C1S	904412	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	904413	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904414	09/2015	09/10/2015	100.070	99.940	100.1	1
LG&E	C1S	904415	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904416	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904417	09/2015	09/10/2015	100.070	99.880	99.9	1
LG&E	C1S	904418	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904419	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904420	09/2015	09/10/2015	100.080	99.890	100.1	1
LG&E	C1S	904421	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904422	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904423	09/2015	09/10/2015	100.050	99.930	100.0	1

LG&E	C1S	904424	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904425	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904426	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	904427	09/2015	09/10/2015	100.070	100.010	100.0	1
LG&E	C1S	904428	09/2015	09/10/2015	100.060	99.890	99.9	1
LG&E	C1S	904429	09/2015	09/10/2015	100.080	99.840	100.1	1
LG&E	C1S	904430	09/2015	09/10/2015	100.100	99.960	100.1	1
LG&E	C1S	904431	09/2015	09/10/2015	100.100	99.960	100.1	1
LG&E	C1S	904432	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904433	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904434	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904435	09/2015	09/10/2015	100.080	99.810	100.1	1
LG&E	C1S	904436	09/2015	09/10/2015	100.100	99.990	100.1	1
LG&E	C1S	904437	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904438	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904439	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904440	09/2015	09/10/2015	100.070	99.820	99.9	1
LG&E	C1S	904441	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	904442	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904443	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	904444	09/2015	09/10/2015	100.080	99.990	100.1	1
LG&E	C1S	904445	09/2015	09/10/2015	100.100	100.010	100.1	1
LG&E	C1S	904446	09/2015	09/10/2015	100.100	99.990	100.1	1
LG&E	C1S	904447	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904448	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	904449	09/2015	09/10/2015	100.080	99.970	100.1	1
LG&E	C1S	904450	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904451	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904452	09/2015	09/10/2015	100.090	99.950	100.1	1
LG&E	C1S	904453	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904454	09/2015	09/10/2015	100.080	99.950	100.1	1
LG&E	C1S	904455	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	904456	09/2015	09/10/2015	100.070	99.920	100.1	1
LG&E	C1S	904457	09/2015	09/10/2015	100.060	99.930	99.9	1
LG&E	C1S	904458	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	904459	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904460	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904461	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	904462	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904463	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904464	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904465	09/2015	09/10/2015	100.050	99.860	100.0	1

LG&E	C1S	904466	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904467	09/2015	09/10/2015	100.100	99.940	100.1	1
LG&E	C1S	904468	09/2015	09/10/2015	100.070	99.910	100.1	1
LG&E	C1S	904469	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	904470	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	904471	09/2015	09/10/2015	100.060	100.020	100.0	1
LG&E	C1S	904472	09/2015	09/10/2015	100.060	100.020	100.0	1
LG&E	C1S	904473	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	904474	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904475	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	904476	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904477	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904478	09/2015	09/10/2015	100.080	99.890	100.1	1
LG&E	C1S	904479	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904480	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904481	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	904482	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	904483	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904484	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	904485	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904486	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	904487	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904488	09/2015	09/10/2015	100.090	99.810	100.0	1
LG&E	C1S	904489	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904490	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904491	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	904492	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904493	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904494	09/2015	09/10/2015	100.070	99.850	99.9	1
LG&E	C1S	904495	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904496	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	904497	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904498	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	904499	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	904500	09/2015	09/10/2015	100.090	99.880	99.9	1
LG&E	C1S	904501	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	904502	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904503	09/2015	09/10/2015	100.090	99.890	100.1	1
LG&E	C1S	904504	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904505	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904506	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904507	09/2015	09/10/2015	100.050	99.930	100.0	1

LG&E	C1S	904508	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904509	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904510	09/2015	09/10/2015	100.070	99.820	100.0	1
LG&E	C1S	904511	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904512	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904513	09/2015	09/10/2015	100.070	100.000	100.0	1
LG&E	C1S	904514	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	904515	09/2015	09/10/2015	100.100	99.960	100.1	1
LG&E	C1S	904516	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904517	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904518	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904519	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904520	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904521	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	904522	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904523	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904524	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	904525	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	904526	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904527	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904528	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904529	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904530	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904531	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	904532	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904533	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904534	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904535	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904536	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	904537	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904538	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904539	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	904540	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	904541	09/2015	09/10/2015	100.070	100.050	100.0	1
LG&E	C1S	904542	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904543	09/2015	09/10/2015	100.060	99.830	99.9	1
LG&E	C1S	904544	09/2015	09/10/2015	100.060	99.970	99.9	1
LG&E	C1S	904545	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904546	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904547	09/2015	09/10/2015	100.050	99.810	100.0	1
LG&E	C1S	904548	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904549	09/2015	09/10/2015	100.080	99.840	100.0	1

LG&E	C1S	904550	09/2015	09/10/2015	100.060	99.930	100.1	1
LG&E	C1S	904551	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904552	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904553	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904554	09/2015	09/10/2015	100.080	100.000	100.1	1
LG&E	C1S	904555	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904556	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	904557	09/2015	09/10/2015	100.070	99.810	100.0	1
LG&E	C1S	904558	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904559	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904560	09/2015	09/10/2015	100.070	99.880	99.9	1
LG&E	C1S	904561	09/2015	09/10/2015	100.100	100.030	100.0	1
LG&E	C1S	904562	09/2015	09/10/2015	100.080	100.000	99.9	1
LG&E	C1S	904563	09/2015	09/10/2015	100.070	100.020	100.0	1
LG&E	C1S	904564	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904565	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904566	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904567	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904568	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904569	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904570	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904571	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904572	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	904573	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	904574	09/2015	09/10/2015	100.080	99.920	100.1	1
LG&E	C1S	904575	09/2015	09/10/2015	100.060	99.900	99.9	1
LG&E	C1S	904576	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904577	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	904578	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904579	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904580	09/2015	09/10/2015	100.070	99.930	100.1	1
LG&E	C1S	904581	09/2015	09/10/2015	100.070	99.960	100.1	1
LG&E	C1S	904582	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904583	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904584	09/2015	09/10/2015	100.080	99.930	100.1	1
LG&E	C1S	904585	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904586	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904587	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	904588	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904589	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	904590	09/2015	09/10/2015	100.060	100.070	100.0	1
LG&E	C1S	904591	09/2015	09/10/2015	100.090	99.950	100.0	1

LG&E	C1S	904592	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904593	09/2015	09/10/2015	100.090	99.820	100.0	1
LG&E	C1S	904594	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904595	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904596	09/2015	09/10/2015	100.070	99.900	100.1	1
LG&E	C1S	904597	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	904598	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904599	09/2015	09/10/2015	100.080	99.840	99.9	1
LG&E	C1S	904600	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904601	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904602	09/2015	09/10/2015	100.060	99.810	100.1	1
LG&E	C1S	904603	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	904604	09/2015	09/10/2015	100.060	100.030	100.0	1
LG&E	C1S	904605	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	904606	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	904607	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904608	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904609	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904610	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	904611	09/2015	09/10/2015	100.070	99.910	100.1	1
LG&E	C1S	904612	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	904613	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904614	09/2015	09/10/2015	100.060	99.990	100.0	1
LG&E	C1S	904615	09/2015	09/10/2015	100.090	99.880	100.1	1
LG&E	C1S	904616	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904617	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	904618	09/2015	09/10/2015	100.060	99.970	100.1	1
LG&E	C1S	904619	09/2015	09/10/2015	100.060	99.960	100.1	1
LG&E	C1S	904620	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904621	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904622	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	904623	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904624	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	904625	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904626	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	904627	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904628	09/2015	09/10/2015	100.080	99.850	100.1	1
LG&E	C1S	904629	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904630	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904631	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	904632	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904633	09/2015	09/10/2015	100.080	99.990	100.1	1

LG&E	C1S	904634	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904635	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904636	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904637	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904638	09/2015	09/10/2015	100.100	99.880	100.1	1
LG&E	C1S	904639	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904640	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904641	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904642	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904643	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904644	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904645	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904646	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904647	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	904648	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904649	09/2015	09/10/2015	100.080	99.920	100.1	1
LG&E	C1S	904650	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904651	09/2015	09/10/2015	100.070	99.870	100.1	1
LG&E	C1S	904652	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904653	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	904654	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	904655	09/2015	09/10/2015	100.060	100.020	100.0	1
LG&E	C1S	904656	09/2015	09/10/2015	100.100	99.980	100.1	1
LG&E	C1S	904657	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904658	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904659	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904660	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904661	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	904662	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904663	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904664	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	904665	09/2015	09/10/2015	100.060	99.810	100.0	1
LG&E	C1S	904666	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	904667	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	904668	09/2015	09/10/2015	100.050	99.820	99.9	1
LG&E	C1S	904669	09/2015	09/10/2015	100.060	99.910	100.1	1
LG&E	C1S	904670	09/2015	09/10/2015	100.060	99.850	99.9	1
LG&E	C1S	904671	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904672	09/2015	09/10/2015	100.070	99.900	99.9	1
LG&E	C1S	904673	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	904674	09/2015	09/10/2015	100.050	99.950	100.1	1
LG&E	C1S	904675	09/2015	09/10/2015	100.060	99.910	100.0	1

LG&E	C1S	904676	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904677	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	904678	09/2015	09/10/2015	100.090	99.820	100.0	1
LG&E	C1S	904679	09/2015	09/10/2015	100.080	99.810	100.0	1
LG&E	C1S	904680	09/2015	09/10/2015	100.060	99.810	100.0	1
LG&E	C1S	904681	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904682	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904683	09/2015	09/10/2015	100.070	99.870	100.1	1
LG&E	C1S	904684	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904685	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904686	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	904687	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904688	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904689	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904690	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904691	09/2015	09/10/2015	100.080	99.880	99.9	1
LG&E	C1S	904692	09/2015	09/10/2015	100.060	99.820	99.9	1
LG&E	C1S	904693	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904694	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904695	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	904696	09/2015	09/10/2015	100.050	99.880	99.9	1
LG&E	C1S	904697	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904698	09/2015	09/10/2015	100.100	99.840	100.0	1
LG&E	C1S	904699	09/2015	09/10/2015	100.070	99.910	99.9	1
LG&E	C1S	904700	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904701	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	904702	09/2015	09/10/2015	100.070	99.850	99.9	1
LG&E	C1S	904703	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904704	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	904705	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904706	09/2015	09/10/2015	100.050	99.830	99.9	1
LG&E	C1S	904707	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904708	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	904709	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904710	09/2015	09/10/2015	100.080	99.940	100.1	1
LG&E	C1S	904711	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904712	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904713	09/2015	09/10/2015	100.090	100.030	100.0	1
LG&E	C1S	904714	09/2015	09/10/2015	100.090	99.880	99.9	1
LG&E	C1S	904715	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	904716	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	904717	09/2015	09/10/2015	100.070	99.860	99.9	1

LG&E	C1S	904718	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904719	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904720	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904721	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904722	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904723	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904724	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904725	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904726	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904727	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904728	09/2015	09/10/2015	100.070	99.810	100.1	1
LG&E	C1S	904729	09/2015	09/10/2015	100.090	99.880	100.1	1
LG&E	C1S	904730	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	904731	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904732	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904733	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904734	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	904735	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	904736	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	904737	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904738	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	904739	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904740	09/2015	09/10/2015	100.090	99.830	100.1	1
LG&E	C1S	904741	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	904742	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	904743	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904744	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	904745	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	904746	09/2015	09/10/2015	100.070	99.850	100.1	1
LG&E	C1S	904747	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904748	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904749	09/2015	09/10/2015	100.060	99.880	99.9	1
LG&E	C1S	904750	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	904751	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904752	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	904753	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	904754	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904755	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904756	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	904757	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904758	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	904759	09/2015	09/10/2015	100.100	99.910	100.0	1

LG&E	C1S	904760	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904761	09/2015	09/10/2015	100.060	99.820	100.1	1
LG&E	C1S	904762	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	904763	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904764	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	904765	09/2015	09/10/2015	100.100	99.950	100.0	1
LG&E	C1S	904766	09/2015	09/10/2015	100.100	100.010	100.1	1
LG&E	C1S	904767	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904768	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904769	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904770	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904771	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904772	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904773	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904774	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904775	09/2015	09/10/2015	100.070	99.870	99.9	1
LG&E	C1S	904776	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904777	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904778	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	904779	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904780	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	904781	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904782	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904783	09/2015	09/10/2015	100.060	99.870	100.1	1
LG&E	C1S	904784	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904785	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	904786	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904787	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904788	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	904789	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904790	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904791	09/2015	09/10/2015	100.100	99.840	100.1	1
LG&E	C1S	904792	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	904793	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	904794	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	904795	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	904796	09/2015	09/10/2015	100.070	99.880	99.9	1
LG&E	C1S	904797	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904798	09/2015	09/10/2015	100.100	100.000	100.0	1
LG&E	C1S	904799	09/2015	09/10/2015	100.090	99.890	100.1	1
LG&E	C1S	904800	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904801	09/2015	09/10/2015	100.050	99.910	100.1	1

LG&E	C1S	904802	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	904803	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904804	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	904805	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904806	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904807	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904808	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904809	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904810	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	904811	09/2015	09/10/2015	100.080	99.900	99.9	1
LG&E	C1S	904812	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904813	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	904814	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	904815	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904816	09/2015	09/10/2015	100.060	99.940	99.9	1
LG&E	C1S	904817	09/2015	09/10/2015	100.090	99.910	100.1	1
LG&E	C1S	904818	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904819	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904820	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904821	09/2015	09/10/2015	100.080	99.880	99.9	1
LG&E	C1S	904822	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	904823	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904824	09/2015	09/10/2015	100.060	99.830	99.9	1
LG&E	C1S	904825	09/2015	09/10/2015	100.060	99.870	100.1	1
LG&E	C1S	904826	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904827	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904828	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904829	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	904830	09/2015	09/10/2015	100.070	99.820	99.9	1
LG&E	C1S	904831	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	904832	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	904833	09/2015	09/10/2015	100.070	99.980	100.1	1
LG&E	C1S	904834	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	904835	09/2015	09/10/2015	100.070	99.940	99.9	1
LG&E	C1S	904836	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904837	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904838	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	904839	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	904840	09/2015	09/10/2015	100.070	99.830	99.9	1
LG&E	C1S	904841	09/2015	09/10/2015	100.100	99.880	100.0	1
LG&E	C1S	904842	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904843	09/2015	09/10/2015	100.070	99.950	100.0	1

LG&E	C1S	904844	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904845	09/2015	09/10/2015	100.100	99.890	100.0	1
LG&E	C1S	904846	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904847	09/2015	09/10/2015	100.100	99.900	100.1	1
LG&E	C1S	904848	09/2015	09/10/2015	100.070	99.920	100.1	1
LG&E	C1S	904849	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	904850	09/2015	09/10/2015	100.100	99.950	100.0	1
LG&E	C1S	904851	09/2015	09/10/2015	100.070	99.890	99.9	1
LG&E	C1S	904852	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	904853	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	904854	09/2015	09/10/2015	100.060	99.890	100.1	1
LG&E	C1S	904855	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	904856	09/2015	09/10/2015	100.070	100.020	100.1	1
LG&E	C1S	904857	09/2015	09/10/2015	100.070	99.800	100.0	1
LG&E	C1S	904858	09/2015	09/10/2015	100.060	99.960	100.1	1
LG&E	C1S	904859	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904860	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	904861	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	904862	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904863	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	904864	09/2015	09/10/2015	100.050	99.860	99.9	1
LG&E	C1S	904865	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904866	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904867	09/2015	09/10/2015	100.070	99.820	100.0	1
LG&E	C1S	904868	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	904869	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904870	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	904871	09/2015	09/10/2015	100.050	99.880	99.9	1
LG&E	C1S	904872	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	904873	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	904874	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904875	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904876	09/2015	09/10/2015	100.070	100.010	100.0	1
LG&E	C1S	904877	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904878	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904879	09/2015	09/10/2015	100.100	100.010	100.1	1
LG&E	C1S	904880	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	904881	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904882	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904883	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	904884	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	904885	09/2015	09/10/2015	100.050	99.960	99.9	1

LG&E	C1S	904886	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	904887	09/2015	09/10/2015	100.060	99.900	99.9	1
LG&E	C1S	904888	09/2015	09/10/2015	100.060	99.910	99.9	1
LG&E	C1S	904889	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	904890	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	904891	09/2015	09/10/2015	100.100	99.980	100.0	1
LG&E	C1S	904892	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	904893	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	904894	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	904895	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	904896	09/2015	09/10/2015	100.070	100.010	100.0	1
LG&E	C1S	904897	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	904898	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	904899	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904900	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	904901	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	904902	09/2015	09/10/2015	100.090	99.880	100.1	1
LG&E	C1S	904903	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	904904	09/2015	09/10/2015	100.100	99.990	100.1	1
LG&E	C1S	904905	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	904906	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	904907	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904908	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	904909	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	904910	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904911	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	904912	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	904913	09/2015	09/10/2015	100.060	100.020	100.0	1
LG&E	C1S	904914	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	904915	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904916	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	904917	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904918	09/2015	09/10/2015	100.070	99.880	99.9	1
LG&E	C1S	904919	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	904920	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904921	09/2015	09/10/2015	100.060	99.830	99.9	1
LG&E	C1S	904922	09/2015	09/10/2015	100.060	99.810	99.9	1
LG&E	C1S	904923	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	904924	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904925	09/2015	09/10/2015	100.050	99.880	99.9	1
LG&E	C1S	904926	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	904927	09/2015	09/10/2015	100.070	99.880	100.1	1

LG&E	C1S	904928	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	904929	09/2015	09/10/2015	100.070	99.960	100.1	1
LG&E	C1S	904930	09/2015	09/10/2015	100.060	99.840	100.1	1
LG&E	C1S	904931	09/2015	09/10/2015	100.080	100.030	100.0	1
LG&E	C1S	904932	09/2015	09/10/2015	100.050	99.940	99.9	1
LG&E	C1S	904933	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904934	09/2015	09/10/2015	100.090	99.850	99.9	1
LG&E	C1S	904935	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	904936	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	904937	09/2015	09/10/2015	100.090	99.840	100.1	1
LG&E	C1S	904938	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	904939	09/2015	09/10/2015	100.070	99.960	99.9	1
LG&E	C1S	904940	09/2015	09/10/2015	100.060	99.920	99.9	1
LG&E	C1S	904941	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	904942	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	904943	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904944	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	904945	09/2015	09/10/2015	100.080	99.970	100.1	1
LG&E	C1S	904946	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	904947	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	904948	09/2015	09/10/2015	100.100	99.890	100.1	1
LG&E	C1S	904949	09/2015	09/10/2015	100.050	99.990	99.9	1
LG&E	C1S	904950	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904951	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	904952	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	904953	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	904954	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	904955	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	904956	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	904957	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	904958	09/2015	09/10/2015	100.100	100.020	100.0	1
LG&E	C1S	904959	09/2015	09/10/2015	100.070	100.030	100.0	1
LG&E	C1S	904960	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	904961	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	904962	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	904963	09/2015	09/10/2015	100.090	100.070	100.0	1
LG&E	C1S	904964	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904965	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	904966	09/2015	09/10/2015	100.070	100.030	100.0	1
LG&E	C1S	904967	09/2015	09/10/2015	100.060	99.900	99.9	1
LG&E	C1S	904968	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	904969	09/2015	09/10/2015	100.090	99.970	100.0	1

LG&E	C1S	904970	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	904971	09/2015	09/10/2015	100.050	99.970	100.1	1
LG&E	C1S	904972	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	904973	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	904974	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	904975	09/2015	09/10/2015	100.080	99.900	100.1	1
LG&E	C1S	904976	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	904977	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	904978	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904979	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904980	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	904981	09/2015	09/10/2015	100.100	99.940	100.1	1
LG&E	C1S	904982	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904983	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	904984	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	904985	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	904986	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	904987	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	904988	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	904989	09/2015	09/10/2015	100.100	99.890	100.0	1
LG&E	C1S	904990	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	904991	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	904992	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	904993	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	904994	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	904995	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	904996	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	904997	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	904998	09/2015	09/10/2015	100.050	99.950	100.0	1
LG&E	C1S	904999	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905000	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905001	09/2015	09/10/2015	100.060	99.880	99.9	1
LG&E	C1S	905002	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	905003	09/2015	09/10/2015	100.080	99.920	100.1	1
LG&E	C1S	905004	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905005	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905006	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905007	09/2015	09/10/2015	100.090	99.860	100.1	1
LG&E	C1S	905008	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	905009	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905010	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905011	09/2015	09/10/2015	100.070	99.960	100.0	1

LG&E	C1S	905012	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905013	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905014	09/2015	09/10/2015	100.080	99.940	100.1	1
LG&E	C1S	905015	09/2015	09/10/2015	100.060	99.850	100.1	1
LG&E	C1S	905016	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905017	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	905018	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905019	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905020	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905021	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	905022	09/2015	09/10/2015	100.070	99.960	99.9	1
LG&E	C1S	905023	09/2015	09/10/2015	100.060	99.890	100.1	1
LG&E	C1S	905024	09/2015	09/10/2015	100.060	99.810	100.0	1
LG&E	C1S	905025	09/2015	09/10/2015	100.080	99.860	99.9	1
LG&E	C1S	905026	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	905027	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905028	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	905029	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	905030	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	905031	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905032	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905033	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905034	09/2015	09/10/2015	100.080	99.860	100.1	1
LG&E	C1S	905035	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905036	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905037	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905038	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905039	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905040	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905041	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905042	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	905043	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	905044	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905045	09/2015	09/10/2015	100.090	100.040	100.1	1
LG&E	C1S	905046	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	905047	09/2015	09/10/2015	100.070	99.940	99.9	1
LG&E	C1S	905048	09/2015	09/10/2015	100.070	99.850	100.1	1
LG&E	C1S	905049	09/2015	09/10/2015	100.100	100.040	100.0	1
LG&E	C1S	905050	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905051	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905052	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905053	09/2015	09/10/2015	100.070	99.890	99.9	1

LG&E	C1S	905054	09/2015	09/10/2015	100.070	99.910	100.1	1
LG&E	C1S	905055	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	905056	09/2015	09/10/2015	100.050	99.970	100.1	1
LG&E	C1S	905057	09/2015	09/10/2015	100.100	99.880	100.1	1
LG&E	C1S	905058	09/2015	09/10/2015	100.080	100.040	100.0	1
LG&E	C1S	905059	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905060	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905061	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	905062	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905063	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905064	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	905065	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905066	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905067	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905068	09/2015	09/10/2015	100.070	99.880	99.9	1
LG&E	C1S	905069	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905070	09/2015	09/10/2015	100.080	100.050	100.0	1
LG&E	C1S	905071	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	905072	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	905073	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905074	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905075	09/2015	09/10/2015	100.080	100.000	100.1	1
LG&E	C1S	905076	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	905077	09/2015	09/10/2015	100.100	100.040	100.0	1
LG&E	C1S	905078	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905079	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905080	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905081	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	905082	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	905083	09/2015	09/10/2015	100.090	99.910	100.1	1
LG&E	C1S	905084	09/2015	09/10/2015	100.070	99.950	99.9	1
LG&E	C1S	905085	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905086	09/2015	09/10/2015	100.060	99.900	100.1	1
LG&E	C1S	905087	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905088	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	905089	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	905090	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905091	09/2015	09/10/2015	100.100	100.020	100.0	1
LG&E	C1S	905092	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905093	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905094	09/2015	09/10/2015	100.060	99.890	99.9	1
LG&E	C1S	905095	09/2015	09/10/2015	100.060	99.950	100.0	1

LG&E	C1S	905096	09/2015	09/10/2015	100.080	99.910	99.9	1
LG&E	C1S	905097	09/2015	09/10/2015	100.060	99.830	99.9	1
LG&E	C1S	905098	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905099	09/2015	09/10/2015	100.070	99.960	99.9	1
LG&E	C1S	905100	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905101	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905102	09/2015	09/10/2015	100.100	100.000	100.1	1
LG&E	C1S	905103	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905104	09/2015	09/10/2015	100.090	99.950	100.1	1
LG&E	C1S	905105	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905106	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905107	09/2015	09/10/2015	100.070	99.910	100.1	1
LG&E	C1S	905108	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905109	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	905110	09/2015	09/10/2015	100.100	99.940	100.1	1
LG&E	C1S	905111	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	905112	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905113	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	905114	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905115	09/2015	09/10/2015	100.060	99.880	100.1	1
LG&E	C1S	905116	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905117	09/2015	09/10/2015	100.060	99.880	99.9	1
LG&E	C1S	905118	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	905119	09/2015	09/10/2015	100.100	100.060	100.0	1
LG&E	C1S	905120	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905121	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905122	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905123	09/2015	09/10/2015	100.100	99.870	100.0	1
LG&E	C1S	905124	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	905125	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905126	09/2015	09/10/2015	100.050	99.880	99.9	1
LG&E	C1S	905127	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	905128	09/2015	09/10/2015	100.080	99.880	100.1	1
LG&E	C1S	905129	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905130	09/2015	09/10/2015	100.080	99.950	100.1	1
LG&E	C1S	905131	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905132	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905133	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905134	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905135	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905136	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905137	09/2015	09/10/2015	100.070	99.850	100.0	1

LG&E	C1S	905138	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	905139	09/2015	09/10/2015	100.070	99.840	99.9	1
LG&E	C1S	905140	09/2015	09/10/2015	100.050	99.960	100.1	1
LG&E	C1S	905141	09/2015	09/10/2015	100.060	99.840	99.9	1
LG&E	C1S	905142	09/2015	09/10/2015	100.070	99.900	100.1	1
LG&E	C1S	905143	09/2015	09/10/2015	100.050	99.890	99.9	1
LG&E	C1S	905144	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905145	09/2015	09/10/2015	100.090	100.020	100.1	1
LG&E	C1S	905146	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905147	09/2015	09/10/2015	100.100	99.950	100.1	1
LG&E	C1S	905148	09/2015	09/10/2015	100.060	99.880	99.9	1
LG&E	C1S	905149	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905150	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905151	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905152	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905153	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905154	09/2015	09/10/2015	100.050	99.920	100.1	1
LG&E	C1S	905155	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905156	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	905157	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	905158	09/2015	09/10/2015	100.080	99.920	99.9	1
LG&E	C1S	905159	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905160	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	905161	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905162	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905163	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905164	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905165	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905166	09/2015	09/10/2015	100.080	99.870	100.1	1
LG&E	C1S	905167	09/2015	09/10/2015	100.080	100.010	100.0	1
LG&E	C1S	905168	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905169	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905170	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905171	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905172	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905173	09/2015	09/10/2015	100.100	99.950	100.1	1
LG&E	C1S	905174	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905175	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905176	09/2015	09/10/2015	100.090	100.000	100.1	1
LG&E	C1S	905177	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905178	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905179	09/2015	09/10/2015	100.060	99.920	100.1	1

LG&E	C1S	905180	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905181	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905182	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	905183	09/2015	09/10/2015	100.090	99.990	100.1	1
LG&E	C1S	905184	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905185	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905186	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905187	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905188	09/2015	09/10/2015	100.090	99.900	100.1	1
LG&E	C1S	905189	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	905190	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905191	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	905192	09/2015	09/10/2015	100.070	99.890	99.9	1
LG&E	C1S	905193	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	905194	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905195	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905196	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905197	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905198	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	905199	09/2015	09/10/2015	100.080	99.830	99.9	1
LG&E	C1S	905200	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905201	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905202	09/2015	09/10/2015	100.080	99.990	100.1	1
LG&E	C1S	905203	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905204	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905205	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905206	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905207	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905208	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905209	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905210	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905211	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905212	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	905213	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905214	09/2015	09/10/2015	100.060	99.850	99.9	1
LG&E	C1S	905215	09/2015	09/10/2015	100.100	99.940	100.1	1
LG&E	C1S	905216	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905217	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905218	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905219	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905220	09/2015	09/10/2015	100.080	99.950	100.1	1
LG&E	C1S	905221	09/2015	09/10/2015	100.060	99.900	100.0	1

LG&E	C1S	905222	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905223	09/2015	09/10/2015	100.080	100.000	99.9	1
LG&E	C1S	905224	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905225	09/2015	09/10/2015	100.100	99.860	100.0	1
LG&E	C1S	905226	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905227	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905228	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905229	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905230	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905231	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905232	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	905233	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905234	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905235	09/2015	09/10/2015	100.070	99.920	100.1	1
LG&E	C1S	905236	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905237	09/2015	09/10/2015	100.090	99.820	100.0	1
LG&E	C1S	905238	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905239	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905240	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905241	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905242	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905243	09/2015	09/10/2015	100.090	99.860	100.1	1
LG&E	C1S	905244	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905245	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905246	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905247	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905248	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905249	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905250	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905251	09/2015	09/10/2015	100.070	99.810	100.0	1
LG&E	C1S	905252	09/2015	09/10/2015	100.080	99.930	100.1	1
LG&E	C1S	905253	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905254	09/2015	09/10/2015	100.100	99.960	100.1	1
LG&E	C1S	905255	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905256	09/2015	09/10/2015	100.090	99.840	100.1	1
LG&E	C1S	905257	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905258	09/2015	09/10/2015	100.100	99.870	100.0	1
LG&E	C1S	905259	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	905260	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905261	09/2015	09/10/2015	100.050	99.820	100.0	1
LG&E	C1S	905262	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905263	09/2015	09/10/2015	100.060	99.960	100.0	1

LG&E	C1S	905264	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905265	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905266	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905267	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	905268	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905269	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905270	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905271	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	905272	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	905273	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905274	09/2015	09/10/2015	100.090	100.020	100.1	1
LG&E	C1S	905275	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905276	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905277	09/2015	09/10/2015	100.090	99.900	100.1	1
LG&E	C1S	905278	09/2015	09/10/2015	100.080	99.890	99.9	1
LG&E	C1S	905279	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905280	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905281	09/2015	09/10/2015	100.080	99.960	100.1	1
LG&E	C1S	905282	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	905283	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	905284	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905285	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905286	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905287	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905288	09/2015	09/10/2015	100.100	99.840	100.0	1
LG&E	C1S	905289	09/2015	09/10/2015	100.080	99.880	99.9	1
LG&E	C1S	905290	09/2015	09/10/2015	100.090	99.980	100.1	1
LG&E	C1S	905291	09/2015	09/10/2015	100.100	99.880	100.0	1
LG&E	C1S	905292	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	905293	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905294	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905295	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905296	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905297	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905298	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905299	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905300	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905301	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905302	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905303	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	905304	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905305	09/2015	09/10/2015	100.080	99.870	100.1	1

LG&E	C1S	905306	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	905307	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905308	09/2015	09/10/2015	100.070	100.000	100.0	1
LG&E	C1S	905309	09/2015	09/10/2015	100.050	99.960	100.0	1
LG&E	C1S	905310	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	905311	09/2015	09/10/2015	100.100	99.910	100.0	1
LG&E	C1S	905312	09/2015	09/10/2015	100.080	100.000	100.1	1
LG&E	C1S	905313	09/2015	09/10/2015	100.090	100.030	100.0	1
LG&E	C1S	905314	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	905315	09/2015	09/10/2015	100.070	99.840	100.1	1
LG&E	C1S	905316	09/2015	09/10/2015	100.080	99.910	99.9	1
LG&E	C1S	905317	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905318	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	905319	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905320	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905321	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905322	09/2015	09/10/2015	100.060	99.870	100.1	1
LG&E	C1S	905323	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	905324	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905325	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	905326	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905327	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	905328	09/2015	09/10/2015	100.080	99.960	100.1	1
LG&E	C1S	905329	09/2015	09/10/2015	100.100	99.900	100.1	1
LG&E	C1S	905330	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	905331	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905332	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	905333	09/2015	09/10/2015	100.090	99.830	100.0	1
LG&E	C1S	905334	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905335	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905336	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905337	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905338	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905339	09/2015	09/10/2015	100.080	99.940	100.1	1
LG&E	C1S	905340	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905341	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905342	09/2015	09/10/2015	100.090	99.930	99.9	1
LG&E	C1S	905343	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905344	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	905345	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905346	09/2015	09/10/2015	100.050	99.820	100.0	1
LG&E	C1S	905347	09/2015	09/10/2015	100.060	99.930	100.0	1

LG&E	C1S	905348	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905349	09/2015	09/10/2015	100.090	99.900	99.9	1
LG&E	C1S	905350	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905351	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905352	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905353	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	905354	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	905355	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	905356	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	905357	09/2015	09/10/2015	100.060	99.860	99.9	1
LG&E	C1S	905358	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905359	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905360	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	905361	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905362	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	905363	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905364	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905365	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905366	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905367	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905368	09/2015	09/10/2015	100.050	99.920	99.9	1
LG&E	C1S	905369	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905370	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905371	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	905372	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905373	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905374	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905375	09/2015	09/10/2015	100.090	100.000	100.1	1
LG&E	C1S	905376	09/2015	09/10/2015	100.060	99.930	99.9	1
LG&E	C1S	905377	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	905378	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905379	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905380	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905381	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905382	09/2015	09/10/2015	100.080	99.810	100.0	1
LG&E	C1S	905383	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	905384	09/2015	09/10/2015	100.090	99.950	100.1	1
LG&E	C1S	905385	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	905386	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905387	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905388	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905389	09/2015	09/10/2015	100.080	99.940	100.0	1

LG&E	C1S	905390	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905391	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905392	09/2015	09/10/2015	100.080	99.810	100.0	1
LG&E	C1S	905393	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905394	09/2015	09/10/2015	100.100	99.880	100.0	1
LG&E	C1S	905395	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905396	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905397	09/2015	09/10/2015	100.060	99.940	100.1	1
LG&E	C1S	905398	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905399	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905400	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905401	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905402	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905403	09/2015	09/10/2015	100.080	99.950	99.9	1
LG&E	C1S	905404	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905405	09/2015	09/10/2015	100.050	99.840	100.0	1
LG&E	C1S	905406	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905407	09/2015	09/10/2015	100.100	99.970	100.1	1
LG&E	C1S	905408	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	905409	09/2015	09/10/2015	100.050	99.960	100.0	1
LG&E	C1S	905410	09/2015	09/10/2015	100.070	99.830	99.9	1
LG&E	C1S	905411	09/2015	09/10/2015	100.060	99.860	99.9	1
LG&E	C1S	905412	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905413	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905414	09/2015	09/10/2015	100.050	99.950	100.0	1
LG&E	C1S	905415	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905416	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905417	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	905418	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905419	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905420	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905421	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905422	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905423	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905424	09/2015	09/10/2015	100.090	99.930	100.1	1
LG&E	C1S	905425	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	905426	09/2015	09/10/2015	100.050	99.870	99.9	1
LG&E	C1S	905427	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905428	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	905429	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905430	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905431	09/2015	09/10/2015	100.050	99.830	100.0	1

LG&E	C1S	905432	09/2015	09/10/2015	100.070	99.870	100.1	1
LG&E	C1S	905433	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905434	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905435	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905436	09/2015	09/10/2015	100.060	99.980	100.0	1
LG&E	C1S	905437	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905438	09/2015	09/10/2015	100.080	100.040	100.0	1
LG&E	C1S	905439	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905440	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	905441	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905442	09/2015	09/10/2015	100.100	99.860	100.0	1
LG&E	C1S	905443	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905444	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	905445	09/2015	09/10/2015	100.100	99.910	100.1	1
LG&E	C1S	905446	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905447	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	905448	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905449	09/2015	09/10/2015	100.090	99.820	100.0	1
LG&E	C1S	905450	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905451	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905452	09/2015	09/10/2015	100.090	99.840	100.1	1
LG&E	C1S	905453	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905454	09/2015	09/10/2015	100.080	100.020	100.0	1
LG&E	C1S	905455	09/2015	09/10/2015	100.060	99.850	100.0	1
LG&E	C1S	905456	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905457	09/2015	09/10/2015	100.100	100.040	99.9	1
LG&E	C1S	905458	09/2015	09/10/2015	100.090	100.020	100.0	1
LG&E	C1S	905459	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905460	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905461	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905462	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905463	09/2015	09/10/2015	100.050	99.850	99.9	1
LG&E	C1S	905464	09/2015	09/10/2015	100.070	99.890	99.9	1
LG&E	C1S	905465	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	905466	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905467	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905468	09/2015	09/10/2015	100.100	99.950	100.0	1
LG&E	C1S	905469	09/2015	09/10/2015	100.060	99.930	100.1	1
LG&E	C1S	905470	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905471	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905472	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905473	09/2015	09/10/2015	100.050	99.900	99.9	1

LG&E	C1S	905474	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905475	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905476	09/2015	09/10/2015	100.060	99.890	99.9	1
LG&E	C1S	905477	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905478	09/2015	09/10/2015	100.080	99.890	100.1	1
LG&E	C1S	905479	09/2015	09/10/2015	100.100	99.950	100.1	1
LG&E	C1S	905480	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	905481	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905482	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	905483	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905484	09/2015	09/10/2015	100.080	100.030	100.0	1
LG&E	C1S	905485	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	905486	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905487	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	905488	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905489	09/2015	09/10/2015	100.080	100.000	100.0	1
LG&E	C1S	905490	09/2015	09/10/2015	100.050	99.960	100.0	1
LG&E	C1S	905491	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	905492	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905493	09/2015	09/10/2015	100.090	99.950	99.9	1
LG&E	C1S	905494	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905495	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	905496	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905497	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	905498	09/2015	09/10/2015	100.080	99.820	100.0	1
LG&E	C1S	905499	09/2015	09/10/2015	100.070	99.920	99.9	1
LG&E	C1S	905500	09/2015	09/10/2015	100.090	99.870	99.9	1
LG&E	C1S	905501	09/2015	09/10/2015	100.050	99.810	99.9	1
LG&E	C1S	905502	09/2015	09/10/2015	100.090	99.960	100.1	1
LG&E	C1S	905503	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905504	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905505	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905506	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905507	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905508	09/2015	09/10/2015	100.100	99.980	100.1	1
LG&E	C1S	905509	09/2015	09/10/2015	100.080	100.000	100.1	1
LG&E	C1S	905510	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905511	09/2015	09/10/2015	100.090	100.010	100.1	1
LG&E	C1S	905512	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	905513	09/2015	09/10/2015	100.090	99.830	99.9	1
LG&E	C1S	905514	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905515	09/2015	09/10/2015	100.080	99.960	100.0	1

LG&E	C1S	905516	09/2015	09/10/2015	100.070	99.900	99.9	1
LG&E	C1S	905517	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905518	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	905519	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905520	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	905521	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905522	09/2015	09/10/2015	100.100	99.990	100.1	1
LG&E	C1S	905523	09/2015	09/10/2015	100.080	99.970	100.1	1
LG&E	C1S	905524	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905525	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	905526	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905527	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905528	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	905529	09/2015	09/10/2015	100.080	99.960	100.1	1
LG&E	C1S	905530	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905531	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905532	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905533	09/2015	09/10/2015	100.060	99.810	100.0	1
LG&E	C1S	905534	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905535	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905536	09/2015	09/10/2015	100.060	99.940	100.1	1
LG&E	C1S	905537	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905538	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905539	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905540	09/2015	09/10/2015	100.080	99.900	100.1	1
LG&E	C1S	905541	09/2015	09/10/2015	100.060	99.900	99.9	1
LG&E	C1S	905542	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905543	09/2015	09/10/2015	100.080	99.930	100.1	1
LG&E	C1S	905544	09/2015	09/10/2015	100.080	99.900	100.1	1
LG&E	C1S	905545	09/2015	09/10/2015	100.090	99.850	100.1	1
LG&E	C1S	905546	09/2015	09/10/2015	100.050	99.950	99.9	1
LG&E	C1S	905547	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905548	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905549	09/2015	09/10/2015	100.100	99.950	100.1	1
LG&E	C1S	905550	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	905551	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905552	09/2015	09/10/2015	100.050	99.810	100.0	1
LG&E	C1S	905553	09/2015	09/10/2015	100.060	99.830	100.1	1
LG&E	C1S	905554	09/2015	09/10/2015	100.050	99.830	99.9	1
LG&E	C1S	905555	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905556	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	905557	09/2015	09/10/2015	100.060	99.900	100.0	1

LG&E	C1S	905558	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905559	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905560	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905561	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905562	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905563	09/2015	09/10/2015	100.070	100.000	100.0	1
LG&E	C1S	905564	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905565	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905566	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905567	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	905568	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905569	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905570	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905571	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	905572	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905573	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905574	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905575	09/2015	09/10/2015	100.100	99.990	100.0	1
LG&E	C1S	905576	09/2015	09/10/2015	100.050	99.850	99.9	1
LG&E	C1S	905577	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905578	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905579	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	905580	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905581	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905582	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	905583	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905584	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905585	09/2015	09/10/2015	100.050	99.910	99.9	1
LG&E	C1S	905586	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905587	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905588	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905589	09/2015	09/10/2015	100.060	99.840	99.9	1
LG&E	C1S	905590	09/2015	09/10/2015	100.060	99.810	99.9	1
LG&E	C1S	905591	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	905592	09/2015	09/10/2015	100.050	99.860	100.0	1
LG&E	C1S	905593	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905594	09/2015	09/10/2015	100.070	99.850	99.9	1
LG&E	C1S	905595	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	905596	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905597	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	905598	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	905599	09/2015	09/10/2015	100.050	99.850	99.9	1

LG&E	C1S	905600	09/2015	09/10/2015	100.080	99.910	100.1	1
LG&E	C1S	905601	09/2015	09/10/2015	100.060	99.990	100.0	1
LG&E	C1S	905602	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905603	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	905604	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905605	09/2015	09/10/2015	100.060	99.880	100.0	1
LG&E	C1S	905606	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905607	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905608	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905609	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905610	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905611	09/2015	09/10/2015	100.070	99.850	100.1	1
LG&E	C1S	905612	09/2015	09/10/2015	100.050	99.830	100.0	1
LG&E	C1S	905613	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905614	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905615	09/2015	09/10/2015	100.090	99.950	100.1	1
LG&E	C1S	905616	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905617	09/2015	09/10/2015	100.100	100.020	100.1	1
LG&E	C1S	905618	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905619	09/2015	09/10/2015	100.090	99.850	100.1	1
LG&E	C1S	905620	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905621	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	905622	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905623	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905624	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905625	09/2015	09/10/2015	100.100	99.930	100.0	1
LG&E	C1S	905626	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	905627	09/2015	09/10/2015	100.100	100.000	100.1	1
LG&E	C1S	905628	09/2015	09/10/2015	100.060	99.810	100.0	1
LG&E	C1S	905629	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905630	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905631	09/2015	09/10/2015	100.070	99.960	100.0	1
LG&E	C1S	905632	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905633	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905634	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905635	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905636	09/2015	09/10/2015	100.070	100.030	100.0	1
LG&E	C1S	905637	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905638	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905639	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905640	09/2015	09/10/2015	100.060	99.920	99.9	1
LG&E	C1S	905641	09/2015	09/10/2015	100.080	99.910	100.0	1

LG&E	C1S	905642	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905643	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	905644	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905645	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905646	09/2015	09/10/2015	100.080	99.910	99.9	1
LG&E	C1S	905647	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	905648	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905649	09/2015	09/10/2015	100.090	99.880	100.1	1
LG&E	C1S	905650	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905651	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905652	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	905653	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	905654	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	905655	09/2015	09/10/2015	100.080	100.000	100.0	1
LG&E	C1S	905656	09/2015	09/10/2015	100.060	99.940	100.1	1
LG&E	C1S	905657	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905658	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905659	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905660	09/2015	09/10/2015	100.070	99.910	99.9	1
LG&E	C1S	905661	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905662	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905663	09/2015	09/10/2015	100.090	99.890	100.0	1
LG&E	C1S	905664	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	905665	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905666	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905667	09/2015	09/10/2015	100.070	99.830	99.9	1
LG&E	C1S	905668	09/2015	09/10/2015	100.080	99.920	100.1	1
LG&E	C1S	905669	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905670	09/2015	09/10/2015	100.100	99.840	100.0	1
LG&E	C1S	905671	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905672	09/2015	09/10/2015	100.060	100.010	100.0	1
LG&E	C1S	905673	09/2015	09/10/2015	100.050	100.000	100.0	1
LG&E	C1S	905674	09/2015	09/10/2015	100.090	100.040	100.0	1
LG&E	C1S	905675	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	905676	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905677	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905678	09/2015	09/10/2015	100.060	99.860	99.9	1
LG&E	C1S	905679	09/2015	09/10/2015	100.080	99.850	100.0	1
LG&E	C1S	905680	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905681	09/2015	09/10/2015	100.100	99.970	100.1	1
LG&E	C1S	905682	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905683	09/2015	09/10/2015	100.080	99.920	100.0	1

LG&E	C1S	905684	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905685	09/2015	09/10/2015	100.090	99.910	100.1	1
LG&E	C1S	905686	09/2015	09/10/2015	100.050	99.990	100.0	1
LG&E	C1S	905687	09/2015	09/10/2015	100.050	99.920	99.9	1
LG&E	C1S	905688	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905689	09/2015	09/10/2015	100.070	99.910	99.9	1
LG&E	C1S	905690	09/2015	09/10/2015	100.100	99.880	100.1	1
LG&E	C1S	905691	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	905692	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905693	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905694	09/2015	09/10/2015	100.050	99.930	99.9	1
LG&E	C1S	905695	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905696	09/2015	09/10/2015	100.100	99.990	100.1	1
LG&E	C1S	905697	09/2015	09/10/2015	100.050	99.860	99.9	1
LG&E	C1S	905698	09/2015	09/10/2015	100.100	99.890	100.0	1
LG&E	C1S	905699	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905700	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905701	09/2015	09/10/2015	100.060	99.960	99.9	1
LG&E	C1S	905702	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	905703	09/2015	09/10/2015	100.090	99.870	100.0	1
LG&E	C1S	905704	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905705	09/2015	09/10/2015	100.090	100.090	100.1	1
LG&E	C1S	905706	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905707	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905708	09/2015	09/10/2015	100.080	100.010	100.0	1
LG&E	C1S	905709	09/2015	09/10/2015	100.080	99.830	100.0	1
LG&E	C1S	905710	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905711	09/2015	09/10/2015	100.060	99.930	100.1	1
LG&E	C1S	905712	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905713	09/2015	09/10/2015	100.100	99.980	99.9	1
LG&E	C1S	905714	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905715	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905716	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905717	09/2015	09/10/2015	100.060	99.890	99.9	1
LG&E	C1S	905718	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905719	09/2015	09/10/2015	100.070	99.990	100.1	1
LG&E	C1S	905720	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905721	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905722	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	905723	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905724	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	905725	09/2015	09/10/2015	100.090	99.860	100.0	1

LG&E	C1S	905726	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905727	09/2015	09/10/2015	100.090	99.880	100.0	1
LG&E	C1S	905728	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905729	09/2015	09/10/2015	100.100	99.930	100.1	-1
LG&E	C1S	905730	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	905731	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905732	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905733	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905734	09/2015	09/10/2015	100.080	99.890	100.1	1
LG&E	C1S	905735	09/2015	09/10/2015	100.090	100.000	100.0	1
LG&E	C1S	905736	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905737	09/2015	09/10/2015	100.100	100.010	100.0	1
LG&E	C1S	905738	09/2015	09/10/2015	100.060	99.870	99.9	1
LG&E	C1S	905739	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	905740	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905741	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905742	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	905743	09/2015	09/10/2015	100.070	99.820	100.0	1
LG&E	C1S	905744	09/2015	09/10/2015	100.050	99.870	100.0	1
LG&E	C1S	905745	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905746	09/2015	09/10/2015	100.100	100.000	100.0	1
LG&E	C1S	905747	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905748	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905749	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	905750	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905751	09/2015	09/10/2015	100.100	99.900	100.0	1
LG&E	C1S	905752	09/2015	09/10/2015	100.080	99.840	100.0	1
LG&E	C1S	905753	09/2015	09/10/2015	100.090	100.000	100.1	1
LG&E	C1S	905754	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905755	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905756	09/2015	09/10/2015	100.100	99.870	100.0	1
LG&E	C1S	905757	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905758	09/2015	09/10/2015	100.070	99.930	100.0	1
LG&E	C1S	905759	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905760	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905761	09/2015	09/10/2015	100.050	99.980	100.0	1
LG&E	C1S	905762	09/2015	09/10/2015	100.050	99.960	100.0	1
LG&E	C1S	905763	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905764	09/2015	09/10/2015	100.080	99.860	100.0	1
LG&E	C1S	905765	09/2015	09/10/2015	100.100	99.950	100.0	1
LG&E	C1S	905766	09/2015	09/10/2015	100.100	99.980	100.1	1
LG&E	C1S	905767	09/2015	09/10/2015	100.080	99.880	100.0	1

LG&E	C1S	905768	09/2015	09/10/2015	100.060	99.830	100.0	1
LG&E	C1S	905769	09/2015	09/10/2015	100.090	99.850	100.0	1
LG&E	C1S	905770	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905771	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905772	09/2015	09/10/2015	100.080	99.870	100.1	1
LG&E	C1S	905773	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905774	09/2015	09/10/2015	100.070	99.810	100.0	1
LG&E	C1S	905775	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905776	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905777	09/2015	09/10/2015	100.100	99.970	100.0	1
LG&E	C1S	905778	09/2015	09/10/2015	100.050	99.850	100.0	1
LG&E	C1S	905779	09/2015	09/10/2015	100.080	99.820	100.0	1
LG&E	C1S	905780	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905781	09/2015	09/10/2015	100.080	99.990	100.0	1
LG&E	C1S	905782	09/2015	09/10/2015	100.060	99.910	99.9	1
LG&E	C1S	905783	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905784	09/2015	09/10/2015	100.070	99.970	100.1	1
LG&E	C1S	905785	09/2015	09/10/2015	100.080	99.910	100.0	1
LG&E	C1S	905786	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905787	09/2015	09/10/2015	100.060	99.820	100.0	1
LG&E	C1S	905788	09/2015	09/10/2015	100.090	99.840	100.0	1
LG&E	C1S	905789	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905790	09/2015	09/10/2015	100.080	99.960	100.0	1
LG&E	C1S	905791	09/2015	09/10/2015	100.100	100.030	100.0	1
LG&E	C1S	905792	09/2015	09/10/2015	100.080	99.970	100.1	1
LG&E	C1S	905793	09/2015	09/10/2015	100.050	99.890	100.0	1
LG&E	C1S	905794	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905795	09/2015	09/10/2015	100.080	99.960	100.1	1
LG&E	C1S	905796	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905797	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905798	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905799	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905800	09/2015	09/10/2015	100.090	99.920	99.9	1
LG&E	C1S	905801	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	905802	09/2015	09/10/2015	100.070	99.960	100.1	1
LG&E	C1S	905803	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	905804	09/2015	09/10/2015	100.050	99.980	100.0	1
LG&E	C1S	905805	09/2015	09/10/2015	100.090	99.950	100.1	1
LG&E	C1S	905806	09/2015	09/10/2015	100.090	99.980	100.1	1
LG&E	C1S	905807	09/2015	09/10/2015	100.070	99.960	99.9	1
LG&E	C1S	905808	09/2015	09/10/2015	100.070	100.000	100.1	1
LG&E	C1S	905809	09/2015	09/10/2015	100.080	99.960	100.0	1

LG&E	C1S	905810	09/2015	09/10/2015	100.050	99.930	100.0	1
LG&E	C1S	905811	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905812	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905813	09/2015	09/10/2015	100.070	99.950	100.1	1
LG&E	C1S	905814	09/2015	09/10/2015	100.080	99.900	99.9	1
LG&E	C1S	905815	09/2015	09/10/2015	100.050	99.940	100.0	1
LG&E	C1S	905816	09/2015	09/10/2015	100.090	99.920	100.1	1
LG&E	C1S	905817	09/2015	09/10/2015	100.070	99.890	99.9	1
LG&E	C1S	905818	09/2015	09/10/2015	100.050	99.980	100.0	1
LG&E	C1S	905819	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	905820	09/2015	09/10/2015	100.080	99.910	99.9	1
LG&E	C1S	905821	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905822	09/2015	09/10/2015	100.060	99.870	100.0	1
LG&E	C1S	905823	09/2015	09/10/2015	100.090	100.030	100.1	1
LG&E	C1S	905824	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905825	09/2015	09/10/2015	100.070	99.840	100.0	1
LG&E	C1S	905826	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	905827	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905828	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905829	09/2015	09/10/2015	100.060	99.960	100.0	1
LG&E	C1S	905830	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905831	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905832	09/2015	09/10/2015	100.080	100.060	100.1	1
LG&E	C1S	905833	09/2015	09/10/2015	100.060	99.810	99.9	1
LG&E	C1S	905834	09/2015	09/10/2015	100.060	99.990	100.0	1
LG&E	C1S	905835	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905836	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905837	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905838	09/2015	09/10/2015	100.070	99.860	99.9	1
LG&E	C1S	905839	09/2015	09/10/2015	100.090	99.930	100.0	1
LG&E	C1S	905840	09/2015	09/10/2015	100.100	100.020	100.0	1
LG&E	C1S	905841	09/2015	09/10/2015	100.100	99.900	100.1	1
LG&E	C1S	905842	09/2015	09/10/2015	100.050	99.920	100.0	1
LG&E	C1S	905843	09/2015	09/10/2015	100.090	99.940	100.1	1
LG&E	C1S	905844	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905845	09/2015	09/10/2015	100.070	99.800	100.1	1
LG&E	C1S	905846	09/2015	09/10/2015	100.070	99.970	99.9	1
LG&E	C1S	905847	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905848	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905849	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905850	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905851	09/2015	09/10/2015	100.070	99.900	100.1	1

LG&E	C1S	905852	09/2015	09/10/2015	100.070	99.940	100.1	1
LG&E	C1S	905853	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905854	09/2015	09/10/2015	100.060	99.970	100.0	1
LG&E	C1S	905855	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905856	09/2015	09/10/2015	100.090	99.820	100.0	1
LG&E	C1S	905857	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	905858	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905859	09/2015	09/10/2015	100.090	99.960	100.0	1
LG&E	C1S	905860	09/2015	09/10/2015	100.090	99.900	100.1	1
LG&E	C1S	905861	09/2015	09/10/2015	100.100	99.960	100.0	1
LG&E	C1S	905862	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905863	09/2015	09/10/2015	100.060	99.890	100.0	1
LG&E	C1S	905864	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905865	09/2015	09/10/2015	100.080	100.010	100.1	1
LG&E	C1S	905866	09/2015	09/10/2015	100.080	99.940	100.0	1
LG&E	C1S	905867	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905868	09/2015	09/10/2015	100.090	99.900	99.9	1
LG&E	C1S	905869	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905870	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905871	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905872	09/2015	09/10/2015	100.080	100.000	100.1	1
LG&E	C1S	905873	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905874	09/2015	09/10/2015	100.080	99.930	99.9	1
LG&E	C1S	905875	09/2015	09/10/2015	100.100	99.930	100.1	1
LG&E	C1S	905876	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905877	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905878	09/2015	09/10/2015	100.080	99.800	100.0	1
LG&E	C1S	905879	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	905880	09/2015	09/10/2015	100.080	99.980	100.0	1
LG&E	C1S	905881	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905882	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905883	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905884	09/2015	09/10/2015	100.070	99.970	100.0	1
LG&E	C1S	905885	09/2015	09/10/2015	100.090	100.030	100.1	1
LG&E	C1S	905886	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905887	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905888	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905889	09/2015	09/10/2015	100.080	99.920	100.0	1
LG&E	C1S	905890	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905891	09/2015	09/10/2015	100.080	100.070	100.0	1
LG&E	C1S	905892	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905893	09/2015	09/10/2015	100.060	99.890	100.0	1

LG&E	C1S	905894	09/2015	09/10/2015	100.050	99.900	100.0	1
LG&E	C1S	905895	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905896	09/2015	09/10/2015	100.100	99.910	99.9	1
LG&E	C1S	905897	09/2015	09/10/2015	100.090	99.900	99.9	1
LG&E	C1S	905898	09/2015	09/10/2015	100.080	99.950	100.0	1
LG&E	C1S	905899	09/2015	09/10/2015	100.070	99.850	100.0	1
LG&E	C1S	905900	09/2015	09/10/2015	100.080	100.040	100.0	1
LG&E	C1S	905901	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905902	09/2015	09/10/2015	100.070	99.810	100.0	1
LG&E	C1S	905903	09/2015	09/10/2015	100.080	99.920	99.9	1
LG&E	C1S	905904	09/2015	09/10/2015	100.070	99.890	100.0	1
LG&E	C1S	905905	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905906	09/2015	09/10/2015	100.100	100.000	100.1	1
LG&E	C1S	905907	09/2015	09/10/2015	100.090	99.830	100.0	1
LG&E	C1S	905908	09/2015	09/10/2015	100.080	99.930	100.0	1
LG&E	C1S	905909	09/2015	09/10/2015	100.070	99.970	100.1	1
LG&E	C1S	905910	09/2015	09/10/2015	100.070	99.890	100.1	1
LG&E	C1S	905911	09/2015	09/10/2015	100.060	99.970	99.9	1
LG&E	C1S	905912	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905913	09/2015	09/10/2015	100.100	99.920	100.1	1
LG&E	C1S	905914	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905915	09/2015	09/10/2015	100.080	99.940	100.1	1
LG&E	C1S	905916	09/2015	09/10/2015	100.080	100.000	100.0	1
LG&E	C1S	905917	09/2015	09/10/2015	100.050	99.840	99.9	1
LG&E	C1S	905918	09/2015	09/10/2015	100.090	99.970	100.1	1
LG&E	C1S	905919	09/2015	09/10/2015	100.070	99.950	100.0	1
LG&E	C1S	905920	09/2015	09/10/2015	100.090	99.980	100.0	1
LG&E	C1S	905921	09/2015	09/10/2015	100.080	99.820	100.1	1
LG&E	C1S	905922	09/2015	09/10/2015	100.090	99.920	100.0	1
LG&E	C1S	905923	09/2015	09/10/2015	100.080	99.960	100.1	1
LG&E	C1S	905924	09/2015	09/10/2015	100.060	99.940	100.0	1
LG&E	C1S	905925	09/2015	09/10/2015	100.050	99.890	99.9	1
LG&E	C1S	905926	09/2015	09/10/2015	100.060	99.820	99.8	1
LG&E	C1S	905927	09/2015	09/10/2015	100.070	99.880	100.0	1
LG&E	C1S	905928	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905929	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905930	09/2015	09/10/2015	100.100	99.890	100.0	1
LG&E	C1S	905931	09/2015	09/10/2015	100.080	99.880	100.0	1
LG&E	C1S	905932	09/2015	09/10/2015	100.090	99.990	100.0	1
LG&E	C1S	905933	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	905934	09/2015	09/10/2015	100.090	99.970	100.0	1
LG&E	C1S	905935	09/2015	09/10/2015	100.070	99.960	100.1	1

LG&E	C1S	905936	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	905937	09/2015	09/10/2015	100.060	99.850	99.9	1
LG&E	C1S	905938	09/2015	09/10/2015	100.080	99.970	99.9	1
LG&E	C1S	905939	09/2015	09/10/2015	100.070	100.020	100.0	1
LG&E	C1S	905940	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905941	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905942	09/2015	09/10/2015	100.060	99.950	100.0	1
LG&E	C1S	905943	09/2015	09/10/2015	100.060	99.920	100.0	1
LG&E	C1S	905944	09/2015	09/10/2015	100.060	100.000	100.0	1
LG&E	C1S	905945	09/2015	09/10/2015	100.050	99.910	99.9	1
LG&E	C1S	905946	09/2015	09/10/2015	100.090	100.010	100.1	1
LG&E	C1S	905947	09/2015	09/10/2015	100.060	99.860	100.0	1
LG&E	C1S	905948	09/2015	09/10/2015	100.070	99.810	99.9	1
LG&E	C1S	905949	09/2015	09/10/2015	100.090	99.860	100.0	1
LG&E	C1S	905950	09/2015	09/10/2015	100.070	99.870	100.0	1
LG&E	C1S	905951	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	905952	09/2015	09/10/2015	100.100	99.920	99.9	1
LG&E	C1S	905953	09/2015	09/10/2015	100.090	99.830	100.0	1
LG&E	C1S	905954	09/2015	09/10/2015	100.050	99.910	100.0	1
LG&E	C1S	905955	09/2015	09/10/2015	100.090	99.800	100.0	1
LG&E	C1S	905956	09/2015	09/10/2015	100.060	99.850	99.9	1
LG&E	C1S	905957	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905958	09/2015	09/10/2015	100.070	99.970	99.9	1
LG&E	C1S	905959	09/2015	09/10/2015	100.080	99.820	100.0	1
LG&E	C1S	905960	09/2015	09/10/2015	100.050	99.820	100.0	1
LG&E	C1S	905961	09/2015	09/10/2015	100.050	99.880	100.0	1
LG&E	C1S	905962	09/2015	09/10/2015	100.080	99.890	100.0	1
LG&E	C1S	905963	09/2015	09/10/2015	100.080	99.870	100.0	1
LG&E	C1S	905964	09/2015	09/10/2015	100.090	100.010	100.0	1
LG&E	C1S	905965	09/2015	09/10/2015	100.100	99.940	100.0	1
LG&E	C1S	905966	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905967	09/2015	09/10/2015	100.070	99.990	100.0	1
LG&E	C1S	905968	09/2015	09/10/2015	100.070	99.920	100.0	1
LG&E	C1S	905969	09/2015	09/10/2015	100.070	99.940	100.0	1
LG&E	C1S	905970	09/2015	09/10/2015	100.060	99.940	100.1	1
LG&E	C1S	905971	09/2015	09/10/2015	100.090	99.950	100.0	1
LG&E	C1S	905972	09/2015	09/10/2015	100.070	99.860	100.0	1
LG&E	C1S	905973	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905974	09/2015	09/10/2015	100.070	99.900	100.0	1
LG&E	C1S	905975	09/2015	09/10/2015	100.060	99.930	100.0	1
LG&E	C1S	905976	09/2015	09/10/2015	100.090	99.910	100.0	1
LG&E	C1S	905977	09/2015	09/10/2015	100.070	99.900	100.0	1

LG&E	C1S	905978	09/2015	09/10/2015	100.060	99.910	100.0	1
LG&E	C1S	905979	09/2015	09/10/2015	100.090	99.940	100.0	1
LG&E	C1S	905980	09/2015	09/10/2015	100.070	99.850	100.1	1
LG&E	C1S	905981	09/2015	09/10/2015	100.090	99.900	100.0	1
LG&E	C1S	905982	09/2015	09/10/2015	100.050	99.940	99.9	1
LG&E	C1S	905983	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905984	09/2015	09/10/2015	100.070	99.830	100.0	1
LG&E	C1S	905985	09/2015	09/10/2015	100.070	99.980	100.0	1
LG&E	C1S	905986	09/2015	09/10/2015	100.080	99.970	100.0	1
LG&E	C1S	905987	09/2015	09/10/2015	100.080	99.950	99.9	1
LG&E	C1S	905988	09/2015	09/10/2015	100.060	99.820	99.9	1
LG&E	C1S	905989	09/2015	09/10/2015	100.100	99.920	100.0	1
LG&E	C1S	905990	09/2015	09/10/2015	100.060	99.900	100.0	1
LG&E	C1S	905991	09/2015	09/10/2015	100.080	99.900	100.0	1
LG&E	C1S	905992	09/2015	09/10/2015	100.080	99.880	99.9	1
LG&E	C1S	905993	09/2015	09/10/2015	100.060	99.930	100.1	1
LG&E	C1S	905994	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1S	905995	09/2015	09/10/2015	100.070	99.860	100.1	1
LG&E	C1S	905996	09/2015	09/10/2015	100.060	99.840	100.0	1
LG&E	C1S	905997	09/2015	09/10/2015	100.070	99.910	100.0	1
LG&E	C1SR	901938	06/2015	05/21/2015	100.060	99.920	99.9	1
LG&E	C1SR	901939	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	901940	06/2015	05/21/2015	100.100	99.960	100.0	1
LG&E	C1SR	901941	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	901942	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	901943	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	901944	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	901945	06/2015	05/21/2015	100.090	99.890	100.1	1
LG&E	C1SR	901946	06/2015	05/21/2015	100.090	99.990	100.1	1
LG&E	C1SR	901947	06/2015	05/21/2015	100.090	99.910	99.9	1
LG&E	C1SR	901948	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	901949	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	901950	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	901951	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	901952	06/2015	05/21/2015	100.060	99.910	99.9	1
LG&E	C1SR	901953	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	901954	06/2015	05/21/2015	100.100	99.880	100.1	1
LG&E	C1SR	901955	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	901956	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	901957	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	901958	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	901959	06/2015	05/21/2015	100.100	99.840	100.0	1

LG&E	C1SR	901960	06/2015	05/21/2015	100.060	99.820	100.0	1
LG&E	C1SR	901961	06/2015	05/21/2015	100.060	99.880	100.1	1
LG&E	C1SR	901962	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	901963	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	901964	06/2015	05/21/2015	100.070	99.890	99.9	1
LG&E	C1SR	901965	06/2015	05/21/2015	100.090	99.950	100.1	1
LG&E	C1SR	901966	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	901967	06/2015	05/21/2015	100.050	99.900	100.0	1
LG&E	C1SR	901968	06/2015	05/21/2015	100.090	99.940	99.9	1
LG&E	C1SR	901969	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	901970	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	901971	06/2015	05/21/2015	100.090	99.870	100.0	1
LG&E	C1SR	901972	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	901973	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	901974	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	901975	06/2015	05/21/2015	100.080	99.870	100.0	1
LG&E	C1SR	901976	06/2015	05/21/2015	100.080	99.830	100.0	1
LG&E	C1SR	901977	06/2015	05/21/2015	100.100	99.890	100.0	1
LG&E	C1SR	901978	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	901979	06/2015	05/21/2015	100.070	99.820	100.0	1
LG&E	C1SR	901980	06/2015	05/21/2015	100.050	99.850	99.9	1
LG&E	C1SR	901981	06/2015	05/21/2015	100.050	99.970	100.0	1
LG&E	C1SR	901982	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	901983	06/2015	05/21/2015	100.080	100.000	100.0	1
LG&E	C1SR	901984	06/2015	05/21/2015	100.050	99.910	100.0	1
LG&E	C1SR	901985	06/2015	05/21/2015	100.100	99.840	99.9	1
LG&E	C1SR	901986	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	901987	06/2015	05/21/2015	100.060	99.860	99.9	1
LG&E	C1SR	901988	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	901989	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	901990	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	901991	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	901992	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	901993	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	901994	06/2015	05/21/2015	100.050	99.940	100.0	1
LG&E	C1SR	901995	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	901996	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	901997	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	901998	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	901999	06/2015	05/21/2015	100.060	99.840	99.9	1
LG&E	C1SR	902000	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902001	06/2015	05/21/2015	100.090	99.960	100.0	1

LG&E	C1SR	902002	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902003	06/2015	05/21/2015	100.070	100.000	99.9	1
LG&E	C1SR	902004	06/2015	05/21/2015	100.070	99.820	100.0	1
LG&E	C1SR	902005	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902006	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902007	06/2015	05/21/2015	100.070	99.960	99.9	1
LG&E	C1SR	902008	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902009	06/2015	05/21/2015	100.060	99.880	99.9	1
LG&E	C1SR	902010	06/2015	05/21/2015	100.070	99.930	99.9	1
LG&E	C1SR	902011	06/2015	05/21/2015	100.080	99.820	100.0	1
LG&E	C1SR	902012	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902013	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902014	06/2015	05/21/2015	100.090	99.980	99.9	1
LG&E	C1SR	902015	06/2015	05/21/2015	100.080	99.980	100.0	1
LG&E	C1SR	902016	06/2015	05/21/2015	100.100	99.810	100.0	1
LG&E	C1SR	902017	06/2015	05/21/2015	100.100	99.970	100.0	1
LG&E	C1SR	902018	06/2015	05/21/2015	100.100	99.890	100.0	1
LG&E	C1SR	902019	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902020	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	902021	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902022	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902023	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902024	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902025	06/2015	05/21/2015	100.050	99.880	99.9	1
LG&E	C1SR	902026	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902027	06/2015	05/21/2015	100.090	99.900	99.9	1
LG&E	C1SR	902028	06/2015	05/21/2015	100.060	99.860	99.9	1
LG&E	C1SR	902029	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902030	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902031	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902032	06/2015	05/21/2015	100.080	100.010	100.0	1
LG&E	C1SR	902033	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	902034	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902035	06/2015	05/21/2015	100.060	99.880	99.9	1
LG&E	C1SR	902036	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902037	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902038	06/2015	05/21/2015	100.100	99.960	100.0	1
LG&E	C1SR	902039	06/2015	05/21/2015	100.050	99.910	100.0	1
LG&E	C1SR	902040	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902041	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902042	06/2015	05/21/2015	100.080	99.890	99.9	1
LG&E	C1SR	902043	06/2015	05/21/2015	100.050	99.900	100.0	1

LG&E	C1SR	902044	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902045	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902046	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902047	06/2015	05/21/2015	100.050	99.850	99.9	1
LG&E	C1SR	902048	06/2015	05/21/2015	100.060	99.840	99.9	1
LG&E	C1SR	902049	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902050	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902051	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902052	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902053	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902054	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902055	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	902056	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902057	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902058	06/2015	05/21/2015	100.050	99.940	99.9	1
LG&E	C1SR	902059	06/2015	05/21/2015	100.090	100.010	100.0	1
LG&E	C1SR	902060	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902061	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902062	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902063	06/2015	05/21/2015	100.060	99.920	99.9	1
LG&E	C1SR	902064	06/2015	05/21/2015	100.060	99.820	99.9	1
LG&E	C1SR	902065	06/2015	05/21/2015	100.070	99.970	99.9	1
LG&E	C1SR	902066	06/2015	05/21/2015	100.080	99.850	99.9	1
LG&E	C1SR	902067	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902068	06/2015	05/21/2015	100.070	99.850	99.9	1
LG&E	C1SR	902069	06/2015	05/21/2015	100.080	99.930	99.9	1
LG&E	C1SR	902070	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	902071	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902072	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902073	06/2015	05/21/2015	100.050	99.900	99.9	1
LG&E	C1SR	902074	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902075	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902076	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902077	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902078	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902079	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902080	06/2015	05/21/2015	100.070	99.820	100.0	1
LG&E	C1SR	902081	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902082	06/2015	05/21/2015	100.070	99.890	100.1	1
LG&E	C1SR	902083	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902084	06/2015	05/21/2015	100.060	99.850	99.9	1
LG&E	C1SR	902085	06/2015	05/21/2015	100.100	99.870	100.0	1

LG&E	C1SR	902086	06/2015	05/21/2015	100.070	99.900	100.1	1
LG&E	C1SR	902087	06/2015	05/21/2015	100.060	99.980	100.1	1
LG&E	C1SR	902088	06/2015	05/21/2015	100.070	99.810	100.0	1
LG&E	C1SR	902089	06/2015	05/21/2015	100.100	99.880	100.0	1
LG&E	C1SR	902090	06/2015	05/21/2015	100.060	99.870	99.9	1
LG&E	C1SR	902091	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902092	06/2015	05/21/2015	100.090	100.010	100.0	1
LG&E	C1SR	902093	06/2015	05/21/2015	100.080	99.930	100.1	1
LG&E	C1SR	902094	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902095	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902096	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902097	06/2015	05/21/2015	100.100	100.040	100.0	1
LG&E	C1SR	902098	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902099	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902100	06/2015	05/21/2015	100.100	100.020	100.0	1
LG&E	C1SR	902101	06/2015	05/21/2015	100.100	99.950	100.1	1
LG&E	C1SR	902102	06/2015	05/21/2015	100.060	99.880	99.9	1
LG&E	C1SR	902103	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902104	06/2015	05/21/2015	100.050	99.910	100.0	1
LG&E	C1SR	902105	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902106	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	902107	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902108	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	902109	06/2015	05/21/2015	100.060	99.950	99.9	1
LG&E	C1SR	902110	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902111	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902112	06/2015	05/21/2015	100.050	99.890	99.9	1
LG&E	C1SR	902113	06/2015	05/21/2015	100.090	99.920	99.9	1
LG&E	C1SR	902114	06/2015	05/21/2015	100.070	99.830	99.9	1
LG&E	C1SR	902115	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902116	06/2015	05/21/2015	100.100	99.870	100.0	1
LG&E	C1SR	902117	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902118	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902119	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902120	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902121	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902122	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	902123	06/2015	05/21/2015	100.080	99.840	99.9	1
LG&E	C1SR	902124	06/2015	05/21/2015	100.080	99.980	100.1	1
LG&E	C1SR	902125	06/2015	05/21/2015	100.050	99.850	99.9	1
LG&E	C1SR	902126	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902127	06/2015	05/21/2015	100.060	99.870	100.0	1

LG&E	C1SR	902128	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902129	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902130	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902131	06/2015	05/21/2015	100.080	99.910	99.9	1
LG&E	C1SR	902132	06/2015	05/21/2015	100.070	99.900	99.9	1
LG&E	C1SR	902133	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	902134	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902135	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902136	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902137	06/2015	05/21/2015	100.060	99.870	99.9	1
LG&E	C1SR	902138	06/2015	05/21/2015	100.090	99.880	99.9	1
LG&E	C1SR	902139	06/2015	05/21/2015	100.060	99.950	99.9	1
LG&E	C1SR	902140	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902141	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902142	06/2015	05/21/2015	100.100	99.960	100.1	1
LG&E	C1SR	902143	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902144	06/2015	05/21/2015	100.100	99.960	100.0	1
LG&E	C1SR	902145	06/2015	05/21/2015	100.060	99.810	100.0	1
LG&E	C1SR	902146	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902147	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902148	06/2015	05/21/2015	100.050	99.850	100.0	1
LG&E	C1SR	902149	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902150	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902151	06/2015	05/21/2015	100.100	99.910	99.9	1
LG&E	C1SR	902152	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902153	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902154	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902155	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902156	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902157	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902158	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902159	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902160	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902161	06/2015	05/21/2015	100.090	100.020	100.0	1
LG&E	C1SR	902162	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902163	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902164	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902165	06/2015	05/21/2015	100.100	99.870	100.0	1
LG&E	C1SR	902166	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902167	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902168	06/2015	05/21/2015	100.050	99.880	99.9	1
LG&E	C1SR	902169	06/2015	05/21/2015	100.090	99.940	100.1	1

LG&E	C1SR	902170	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902171	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902172	06/2015	05/21/2015	100.100	99.940	100.1	1
LG&E	C1SR	902173	06/2015	05/21/2015	100.100	99.850	100.0	1
LG&E	C1SR	902174	06/2015	05/21/2015	100.070	100.020	100.0	1
LG&E	C1SR	902175	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902176	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902177	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902178	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902179	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902180	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902181	06/2015	05/21/2015	100.080	99.950	99.9	1
LG&E	C1SR	902182	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902183	06/2015	05/21/2015	100.070	99.860	99.9	1
LG&E	C1SR	902184	06/2015	05/21/2015	100.090	99.870	100.0	1
LG&E	C1SR	902185	06/2015	05/21/2015	100.050	99.830	99.9	1
LG&E	C1SR	902186	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902187	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902188	06/2015	05/21/2015	100.090	99.850	99.9	1
LG&E	C1SR	902189	06/2015	05/21/2015	100.080	99.970	99.9	1
LG&E	C1SR	902190	06/2015	05/21/2015	100.060	99.850	100.0	1
LG&E	C1SR	902191	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902192	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902193	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	902194	06/2015	05/21/2015	100.080	99.920	100.1	1
LG&E	C1SR	902195	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902196	06/2015	05/21/2015	100.090	99.980	99.9	1
LG&E	C1SR	902197	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902198	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902199	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902200	06/2015	05/21/2015	100.050	99.930	100.0	1
LG&E	C1SR	902201	06/2015	05/21/2015	100.100	99.870	100.1	1
LG&E	C1SR	902202	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902203	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902204	06/2015	05/21/2015	100.060	99.850	100.0	1
LG&E	C1SR	902205	06/2015	05/21/2015	100.070	99.860	99.9	1
LG&E	C1SR	902206	06/2015	05/21/2015	100.090	99.920	100.1	1
LG&E	C1SR	902207	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902208	06/2015	05/21/2015	100.070	99.990	100.0	1
LG&E	C1SR	902209	06/2015	05/21/2015	100.110	99.880	100.0	1
LG&E	C1SR	902210	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902211	06/2015	05/21/2015	100.050	99.890	100.0	1

LG&E	C1SR	902212	06/2015	05/21/2015	100.080	99.850	100.0	1
LG&E	C1SR	902213	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902214	06/2015	05/21/2015	100.050	99.960	100.0	1
LG&E	C1SR	902215	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902216	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902217	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902218	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902219	06/2015	05/21/2015	100.060	99.870	99.9	1
LG&E	C1SR	902220	06/2015	05/21/2015	100.090	99.910	100.1	1
LG&E	C1SR	902221	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902222	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902223	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902224	06/2015	05/21/2015	100.060	99.970	99.9	1
LG&E	C1SR	902225	06/2015	05/21/2015	100.100	99.990	99.9	1
LG&E	C1SR	902226	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902227	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902228	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902229	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902230	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902231	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902232	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902233	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902234	06/2015	05/21/2015	100.090	99.850	100.0	1
LG&E	C1SR	902235	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902236	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902237	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902238	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902239	06/2015	05/21/2015	100.080	99.840	100.0	1
LG&E	C1SR	902240	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902241	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902242	06/2015	05/21/2015	100.080	99.940	99.9	1
LG&E	C1SR	902243	06/2015	05/21/2015	100.070	99.830	100.0	1
LG&E	C1SR	902244	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902245	06/2015	05/21/2015	100.080	99.980	100.1	1
LG&E	C1SR	902246	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902247	06/2015	05/21/2015	100.050	99.840	100.0	1
LG&E	C1SR	902248	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902249	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	902250	06/2015	05/21/2015	100.080	99.880	100.1	1
LG&E	C1SR	902251	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902252	06/2015	05/21/2015	100.090	99.940	99.9	1
LG&E	C1SR	902253	06/2015	05/21/2015	100.090	99.890	100.0	1

LG&E	C1SR	902254	06/2015	05/21/2015	100.100	99.970	100.1	1
LG&E	C1SR	902255	06/2015	05/21/2015	100.070	99.870	99.9	1
LG&E	C1SR	902256	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902257	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902258	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902259	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	902260	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902261	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902262	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902263	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902264	06/2015	05/21/2015	100.100	99.970	100.1	1
LG&E	C1SR	902265	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902266	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902267	06/2015	05/21/2015	100.100	99.950	100.1	1
LG&E	C1SR	902268	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902269	06/2015	05/21/2015	100.060	99.820	100.0	1
LG&E	C1SR	902270	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902271	06/2015	05/21/2015	100.070	99.920	100.1	1
LG&E	C1SR	902272	06/2015	05/21/2015	100.080	99.920	100.1	1
LG&E	C1SR	902273	06/2015	05/21/2015	100.060	99.980	100.1	1
LG&E	C1SR	902274	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	902275	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902276	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	902277	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902278	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	902279	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902280	06/2015	05/21/2015	100.090	99.980	100.1	1
LG&E	C1SR	902281	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902282	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902283	06/2015	05/21/2015	100.070	99.880	100.1	1
LG&E	C1SR	902284	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902285	06/2015	05/21/2015	100.080	99.910	99.9	1
LG&E	C1SR	902286	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902287	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902288	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902289	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902290	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902291	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902292	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	902293	06/2015	05/21/2015	100.090	99.970	100.1	1
LG&E	C1SR	902294	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902295	06/2015	05/21/2015	100.100	99.880	100.0	1

LG&E	C1SR	902296	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902297	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902298	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902299	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902300	06/2015	05/21/2015	100.080	99.840	99.9	1
LG&E	C1SR	902301	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902302	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902303	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902304	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	902305	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902306	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902307	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902308	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902309	06/2015	05/21/2015	100.080	100.010	100.0	1
LG&E	C1SR	902310	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	902311	06/2015	05/21/2015	100.100	99.920	99.9	1
LG&E	C1SR	902312	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902313	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902314	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902315	06/2015	05/21/2015	100.080	99.870	99.9	1
LG&E	C1SR	902316	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902317	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	902318	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902319	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902320	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902321	06/2015	05/21/2015	100.090	99.980	100.1	1
LG&E	C1SR	902322	06/2015	05/21/2015	100.080	99.880	100.0	1
LG&E	C1SR	902323	06/2015	05/21/2015	100.070	99.840	100.0	1
LG&E	C1SR	902324	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902325	06/2015	05/21/2015	100.090	99.960	100.1	1
LG&E	C1SR	902326	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902327	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902328	06/2015	05/21/2015	100.080	99.900	100.1	1
LG&E	C1SR	902329	06/2015	05/21/2015	100.090	99.970	99.9	1
LG&E	C1SR	902330	06/2015	05/21/2015	100.050	99.930	100.0	1
LG&E	C1SR	902331	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902332	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902333	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902334	06/2015	05/21/2015	100.070	99.880	100.1	1
LG&E	C1SR	902335	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902336	06/2015	05/21/2015	100.080	99.880	100.0	1
LG&E	C1SR	902337	06/2015	05/21/2015	100.060	99.920	100.0	1

LG&E	C1SR	902338	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902339	06/2015	05/21/2015	100.080	99.980	100.0	1
LG&E	C1SR	902340	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902341	06/2015	05/21/2015	100.090	99.900	100.1	1
LG&E	C1SR	902342	06/2015	05/21/2015	100.090	100.000	100.1	1
LG&E	C1SR	902343	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902344	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902345	06/2015	05/21/2015	100.080	99.960	100.1	1
LG&E	C1SR	902346	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902347	06/2015	05/21/2015	100.070	99.830	100.1	1
LG&E	C1SR	902348	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902349	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902350	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902351	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902352	06/2015	05/21/2015	100.090	99.850	100.0	1
LG&E	C1SR	902353	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902354	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902355	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902356	06/2015	05/21/2015	100.060	99.850	100.0	1
LG&E	C1SR	902357	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902358	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902359	06/2015	05/21/2015	100.080	99.940	100.1	1
LG&E	C1SR	902360	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902361	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902362	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902363	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902364	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902365	06/2015	05/21/2015	100.050	99.930	100.0	1
LG&E	C1SR	902366	06/2015	05/21/2015	100.100	99.970	100.0	1
LG&E	C1SR	902367	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902368	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902369	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902370	06/2015	05/21/2015	100.070	99.940	100.1	1
LG&E	C1SR	902371	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902372	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902373	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902374	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902375	06/2015	05/21/2015	100.070	99.980	99.9	1
LG&E	C1SR	902376	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902377	06/2015	05/21/2015	100.070	99.810	99.9	1
LG&E	C1SR	902378	06/2015	05/21/2015	100.100	99.930	100.1	1
LG&E	C1SR	902379	06/2015	05/21/2015	100.090	100.000	100.0	1

LG&E	C1SR	902380	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902381	06/2015	05/21/2015	100.100	99.890	100.0	1
LG&E	C1SR	902382	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902383	06/2015	05/21/2015	100.060	99.920	99.8	1
LG&E	C1SR	902384	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902385	06/2015	05/21/2015	100.090	100.000	100.0	1
LG&E	C1SR	902386	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902387	06/2015	05/21/2015	100.070	99.980	100.0	1
LG&E	C1SR	902388	06/2015	05/21/2015	100.080	99.890	100.1	1
LG&E	C1SR	902389	06/2015	05/21/2015	100.060	99.960	99.9	1
LG&E	C1SR	902390	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902391	06/2015	05/21/2015	100.090	99.900	100.1	1
LG&E	C1SR	902392	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902393	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902394	06/2015	05/21/2015	100.100	100.020	100.0	1
LG&E	C1SR	902395	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902396	06/2015	05/21/2015	100.080	99.920	99.9	1
LG&E	C1SR	902397	06/2015	05/21/2015	100.080	100.000	100.0	1
LG&E	C1SR	902398	06/2015	05/21/2015	100.080	100.000	100.0	1
LG&E	C1SR	902399	06/2015	05/21/2015	100.090	99.920	99.9	1
LG&E	C1SR	902400	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902401	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902402	06/2015	05/21/2015	100.060	99.970	99.9	1
LG&E	C1SR	902403	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902404	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902405	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902406	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902407	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	902408	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902409	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902410	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902411	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902412	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902413	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902414	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902415	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902416	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902417	06/2015	05/21/2015	100.060	99.870	99.9	1
LG&E	C1SR	902418	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902419	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902420	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902421	06/2015	05/21/2015	100.080	99.880	100.0	1

LG&E	C1SR	902422	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902423	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902424	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902425	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902426	06/2015	05/21/2015	100.080	99.960	99.9	1
LG&E	C1SR	902427	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902428	06/2015	05/21/2015	100.090	100.000	100.1	1
LG&E	C1SR	902429	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902430	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	902431	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902432	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902433	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902434	06/2015	05/21/2015	100.100	99.960	100.0	1
LG&E	C1SR	902435	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902436	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902437	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902438	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902439	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902440	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902441	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	902442	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902443	06/2015	05/21/2015	100.050	99.890	99.9	1
LG&E	C1SR	902444	06/2015	05/21/2015	100.070	99.830	100.0	1
LG&E	C1SR	902445	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902446	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902447	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902448	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902449	06/2015	05/21/2015	100.050	99.900	99.9	1
LG&E	C1SR	902450	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902451	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902452	06/2015	05/21/2015	100.090	99.940	99.9	1
LG&E	C1SR	902453	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902454	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902455	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902456	06/2015	05/21/2015	100.100	99.950	99.9	1
LG&E	C1SR	902457	06/2015	05/21/2015	100.090	99.990	100.1	1
LG&E	C1SR	902458	06/2015	05/21/2015	100.050	99.910	100.0	1
LG&E	C1SR	902459	06/2015	05/21/2015	100.090	99.970	100.1	1
LG&E	C1SR	902460	06/2015	05/21/2015	100.050	99.980	100.0	1
LG&E	C1SR	902461	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902462	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902463	06/2015	05/21/2015	100.080	99.930	99.9	1

LG&E	C1SR	902464	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902465	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902466	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	902467	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902468	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902469	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902470	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902471	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902472	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902473	06/2015	05/21/2015	100.100	99.990	100.1	1
LG&E	C1SR	902474	06/2015	05/21/2015	100.050	99.840	100.0	1
LG&E	C1SR	902475	06/2015	05/21/2015	100.080	99.880	100.0	1
LG&E	C1SR	902476	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	902477	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902478	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902479	06/2015	05/21/2015	100.080	99.850	99.9	1
LG&E	C1SR	902480	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902481	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902482	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902483	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902484	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902485	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902486	06/2015	05/21/2015	100.060	99.910	99.9	1
LG&E	C1SR	902487	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902488	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	902489	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902490	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902491	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902492	06/2015	05/21/2015	100.050	99.890	99.9	1
LG&E	C1SR	902493	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902494	06/2015	05/21/2015	100.060	99.970	100.0	1
LG&E	C1SR	902495	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902496	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902497	06/2015	05/21/2015	100.060	99.950	99.9	1
LG&E	C1SR	902498	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902499	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	902500	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902501	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	902502	06/2015	05/21/2015	100.050	99.930	100.0	1
LG&E	C1SR	902503	06/2015	05/21/2015	100.100	99.970	100.0	1
LG&E	C1SR	902504	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902505	06/2015	05/21/2015	100.050	99.890	100.0	1

LG&E	C1SR	902506	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902507	06/2015	05/21/2015	100.060	99.920	99.9	1
LG&E	C1SR	902508	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902509	06/2015	05/21/2015	100.060	99.970	99.9	1
LG&E	C1SR	902510	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902511	06/2015	05/21/2015	100.090	99.850	100.1	1
LG&E	C1SR	902512	06/2015	05/21/2015	100.080	100.000	100.0	1
LG&E	C1SR	902513	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902514	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902515	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902516	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902517	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902518	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902519	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902520	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902521	06/2015	05/21/2015	100.090	99.930	99.9	1
LG&E	C1SR	902522	06/2015	05/21/2015	100.060	99.970	100.0	1
LG&E	C1SR	902523	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	902524	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902525	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902526	06/2015	05/21/2015	100.080	99.980	100.1	1
LG&E	C1SR	902527	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902528	06/2015	05/21/2015	100.100	99.930	99.9	1
LG&E	C1SR	902529	06/2015	05/21/2015	100.100	100.000	100.1	1
LG&E	C1SR	902530	06/2015	05/21/2015	100.070	99.980	100.1	1
LG&E	C1SR	902531	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902532	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902533	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902534	06/2015	05/21/2015	100.050	99.980	99.9	1
LG&E	C1SR	902535	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902536	06/2015	05/21/2015	100.080	99.910	99.9	1
LG&E	C1SR	902537	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902538	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902539	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902540	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902541	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	902542	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902543	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902544	06/2015	05/21/2015	100.080	99.980	100.0	1
LG&E	C1SR	902545	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	902546	06/2015	05/21/2015	100.050	99.940	99.9	1
LG&E	C1SR	902547	06/2015	05/21/2015	100.070	99.960	100.0	1

LG&E	C1SR	902548	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	902549	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902550	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902551	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902552	06/2015	05/21/2015	100.100	99.950	100.1	1
LG&E	C1SR	902553	06/2015	05/21/2015	100.060	99.930	99.9	1
LG&E	C1SR	902554	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902555	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902556	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902557	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902558	06/2015	05/21/2015	100.060	99.810	99.9	1
LG&E	C1SR	902559	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902560	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902561	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902562	06/2015	05/21/2015	100.090	100.020	100.0	1
LG&E	C1SR	902563	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902564	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902565	06/2015	05/21/2015	100.070	99.870	100.1	1
LG&E	C1SR	902566	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902567	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902568	06/2015	05/21/2015	100.050	99.950	100.0	1
LG&E	C1SR	902569	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902570	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902571	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902572	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902573	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902574	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902575	06/2015	05/21/2015	100.080	99.950	99.9	1
LG&E	C1SR	902576	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902577	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902578	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902579	06/2015	05/21/2015	100.090	99.950	100.1	1
LG&E	C1SR	902580	06/2015	05/21/2015	100.070	99.910	99.9	1
LG&E	C1SR	902581	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902582	06/2015	05/21/2015	100.080	99.990	100.0	1
LG&E	C1SR	902583	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902584	06/2015	05/21/2015	100.070	99.910	99.9	1
LG&E	C1SR	902585	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902586	06/2015	05/21/2015	100.080	99.920	99.9	1
LG&E	C1SR	902587	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902588	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902589	06/2015	05/21/2015	100.060	99.920	100.0	1

LG&E	C1SR	902590	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902591	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902592	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902593	06/2015	05/21/2015	100.080	99.890	99.9	1
LG&E	C1SR	902594	06/2015	05/21/2015	100.050	99.850	100.0	1
LG&E	C1SR	902595	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902596	06/2015	05/21/2015	100.070	99.950	99.9	1
LG&E	C1SR	902597	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902598	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	902599	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902600	06/2015	05/21/2015	100.070	99.870	99.9	1
LG&E	C1SR	902601	06/2015	05/21/2015	100.060	99.920	100.1	1
LG&E	C1SR	902602	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	902603	06/2015	05/21/2015	100.090	99.870	100.0	1
LG&E	C1SR	902604	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	902605	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902606	06/2015	05/21/2015	100.070	99.850	99.9	1
LG&E	C1SR	902607	06/2015	05/21/2015	100.100	99.970	100.0	1
LG&E	C1SR	902608	06/2015	05/21/2015	100.050	99.890	99.9	1
LG&E	C1SR	902609	06/2015	05/21/2015	100.090	99.990	100.1	1
LG&E	C1SR	902610	06/2015	05/21/2015	100.070	99.930	99.9	1
LG&E	C1SR	902611	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902612	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902613	06/2015	05/21/2015	100.070	99.840	100.0	1
LG&E	C1SR	902614	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902615	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902616	06/2015	05/21/2015	100.080	99.970	99.9	1
LG&E	C1SR	902617	06/2015	05/21/2015	100.100	99.980	99.9	1
LG&E	C1SR	902618	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902619	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902620	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902621	06/2015	05/21/2015	100.060	99.930	99.9	1
LG&E	C1SR	902622	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902623	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902624	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902625	06/2015	05/21/2015	100.100	99.900	100.1	1
LG&E	C1SR	902626	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	902627	06/2015	05/21/2015	100.090	99.910	99.9	1
LG&E	C1SR	902628	06/2015	05/21/2015	100.060	99.990	100.0	1
LG&E	C1SR	902629	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902630	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902631	06/2015	05/21/2015	100.080	99.900	100.1	1

LG&E	C1SR	902632	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902633	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902634	06/2015	05/21/2015	100.080	99.810	100.1	1
LG&E	C1SR	902635	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902636	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902637	06/2015	05/21/2015	100.070	99.910	99.9	1
LG&E	C1SR	902638	06/2015	05/21/2015	100.080	99.840	100.0	1
LG&E	C1SR	902639	06/2015	05/21/2015	100.090	99.840	100.1	1
LG&E	C1SR	902640	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902641	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902642	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902643	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902644	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902645	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902646	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902647	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902648	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	902649	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902650	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902651	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	902652	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902653	06/2015	05/21/2015	100.100	99.880	100.0	1
LG&E	C1SR	902654	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902655	06/2015	05/21/2015	100.100	99.890	100.0	1
LG&E	C1SR	902656	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902657	06/2015	05/21/2015	100.080	99.990	100.0	1
LG&E	C1SR	902658	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902659	06/2015	05/21/2015	100.090	100.060	100.0	1
LG&E	C1SR	902660	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	902661	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902662	06/2015	05/21/2015	100.080	99.880	99.9	1
LG&E	C1SR	902663	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902664	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	902665	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902666	06/2015	05/21/2015	100.090	99.890	99.9	1
LG&E	C1SR	902667	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902668	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902669	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902670	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902671	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902672	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902673	06/2015	05/21/2015	100.070	99.870	99.9	1

LG&E	C1SR	902674	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902675	06/2015	05/21/2015	100.070	99.860	99.9	1
LG&E	C1SR	902676	06/2015	05/21/2015	100.080	99.940	100.1	1
LG&E	C1SR	902677	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	902678	06/2015	05/21/2015	100.060	99.830	99.9	1
LG&E	C1SR	902679	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902680	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902681	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902682	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902683	06/2015	05/21/2015	100.070	99.890	99.9	1
LG&E	C1SR	902684	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902685	06/2015	05/21/2015	100.090	99.970	99.9	1
LG&E	C1SR	902686	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902687	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902688	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902689	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902690	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902691	06/2015	05/21/2015	100.070	99.840	100.0	1
LG&E	C1SR	902692	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902693	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902694	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902695	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	902696	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902697	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902698	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902699	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902700	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902701	06/2015	05/21/2015	100.080	99.870	100.0	1
LG&E	C1SR	902702	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902703	06/2015	05/21/2015	100.060	99.910	99.9	1
LG&E	C1SR	902704	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902705	06/2015	05/21/2015	100.080	99.880	100.1	1
LG&E	C1SR	902706	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	902707	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902708	06/2015	05/21/2015	100.060	99.830	100.0	1
LG&E	C1SR	902709	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902710	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902711	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902712	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902713	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902714	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902715	06/2015	05/21/2015	100.080	99.950	100.0	1

LG&E	C1SR	902716	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902717	06/2015	05/21/2015	100.100	99.830	100.0	1
LG&E	C1SR	902718	06/2015	05/21/2015	100.100	99.920	100.1	1
LG&E	C1SR	902719	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902720	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902721	06/2015	05/21/2015	100.060	99.870	99.9	1
LG&E	C1SR	902722	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902723	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	902724	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	902725	06/2015	05/21/2015	100.090	99.950	100.1	1
LG&E	C1SR	902726	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902727	06/2015	05/21/2015	100.080	99.900	99.9	1
LG&E	C1SR	902728	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	902729	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902730	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902731	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	902732	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902733	06/2015	05/21/2015	100.070	99.900	99.9	1
LG&E	C1SR	902734	06/2015	05/21/2015	100.060	99.830	100.0	1
LG&E	C1SR	902735	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902736	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902737	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902738	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	902739	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902740	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902741	06/2015	05/21/2015	100.100	99.900	99.9	1
LG&E	C1SR	902742	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902743	06/2015	05/21/2015	100.090	99.950	99.9	1
LG&E	C1SR	902744	06/2015	05/21/2015	100.080	99.910	100.1	1
LG&E	C1SR	902745	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902746	06/2015	05/21/2015	100.110	99.990	100.0	1
LG&E	C1SR	902747	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902748	06/2015	05/21/2015	100.080	99.890	99.9	1
LG&E	C1SR	902749	06/2015	05/21/2015	100.080	99.850	100.0	1
LG&E	C1SR	902750	06/2015	05/21/2015	100.050	99.840	100.0	1
LG&E	C1SR	902751	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902752	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902753	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902754	06/2015	05/21/2015	100.100	99.860	100.0	1
LG&E	C1SR	902755	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902756	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902757	06/2015	05/21/2015	100.090	99.860	100.0	1

LG&E	C1SR	902758	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902759	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902760	06/2015	05/21/2015	100.100	99.970	100.0	1
LG&E	C1SR	902761	06/2015	05/21/2015	100.080	99.840	100.0	1
LG&E	C1SR	902762	06/2015	05/21/2015	100.060	99.810	99.9	1
LG&E	C1SR	902763	06/2015	05/21/2015	100.100	99.940	100.1	1
LG&E	C1SR	902764	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902765	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902766	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902767	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902768	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902769	06/2015	05/21/2015	100.050	99.900	99.9	1
LG&E	C1SR	902770	06/2015	05/21/2015	100.080	99.850	100.0	1
LG&E	C1SR	902771	06/2015	05/21/2015	100.070	99.930	99.9	1
LG&E	C1SR	902772	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902773	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	902774	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902775	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902776	06/2015	05/21/2015	100.060	99.850	100.1	1
LG&E	C1SR	902777	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902778	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902779	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902780	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902781	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902782	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902783	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902784	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902785	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	902786	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902787	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902788	06/2015	05/21/2015	100.100	99.870	99.9	1
LG&E	C1SR	902789	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902790	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902791	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902792	06/2015	05/21/2015	100.100	99.970	100.1	1
LG&E	C1SR	902793	06/2015	05/21/2015	100.050	99.870	99.9	1
LG&E	C1SR	902794	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902795	06/2015	05/21/2015	100.090	99.970	100.1	1
LG&E	C1SR	902796	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902797	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902798	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902799	06/2015	05/21/2015	100.050	99.870	100.0	1

LG&E	C1SR	902800	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	902801	06/2015	05/21/2015	100.100	99.860	100.0	1
LG&E	C1SR	902802	06/2015	05/21/2015	100.070	99.980	100.0	1
LG&E	C1SR	902803	06/2015	05/21/2015	100.080	99.940	99.9	1
LG&E	C1SR	902804	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902805	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902806	06/2015	05/21/2015	100.080	99.980	100.0	1
LG&E	C1SR	902807	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902808	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902809	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902810	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902811	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902812	06/2015	05/21/2015	100.090	99.940	99.9	1
LG&E	C1SR	902813	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902814	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902815	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902816	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902817	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902818	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902819	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902820	06/2015	05/21/2015	100.090	99.930	100.1	1
LG&E	C1SR	902821	06/2015	05/21/2015	100.050	99.870	99.8	1
LG&E	C1SR	902822	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902823	06/2015	05/21/2015	100.100	99.920	100.1	1
LG&E	C1SR	902824	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902825	06/2015	05/21/2015	100.050	99.860	100.0	1
LG&E	C1SR	902826	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902827	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902828	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902829	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	902830	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	902831	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902832	06/2015	05/21/2015	100.090	99.850	99.9	1
LG&E	C1SR	902833	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	902834	06/2015	05/21/2015	100.090	99.890	99.9	1
LG&E	C1SR	902835	06/2015	05/21/2015	100.100	100.000	100.1	1
LG&E	C1SR	902836	06/2015	05/21/2015	100.100	99.960	100.1	1
LG&E	C1SR	902837	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902838	06/2015	05/21/2015	100.060	99.990	100.0	1
LG&E	C1SR	902839	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	902840	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902841	06/2015	05/21/2015	100.080	99.910	100.0	1

LG&E	C1SR	902842	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902843	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	902844	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902845	06/2015	05/21/2015	100.090	99.870	100.0	1
LG&E	C1SR	902846	06/2015	05/21/2015	100.090	100.020	100.1	1
LG&E	C1SR	902847	06/2015	05/21/2015	100.060	99.910	100.1	1
LG&E	C1SR	902848	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902849	06/2015	05/21/2015	100.070	99.870	99.9	1
LG&E	C1SR	902850	06/2015	05/21/2015	100.090	99.890	99.9	1
LG&E	C1SR	902851	06/2015	05/21/2015	100.070	99.850	99.9	1
LG&E	C1SR	902852	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902853	06/2015	05/21/2015	100.060	99.810	100.0	1
LG&E	C1SR	902854	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902855	06/2015	05/21/2015	100.060	100.000	100.0	1
LG&E	C1SR	902856	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902857	06/2015	05/21/2015	100.090	99.960	99.9	1
LG&E	C1SR	902858	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902859	06/2015	05/21/2015	100.060	99.970	100.0	1
LG&E	C1SR	902860	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	902861	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	902862	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	902863	06/2015	05/21/2015	100.090	99.920	99.9	1
LG&E	C1SR	902864	06/2015	05/21/2015	100.070	99.850	100.0	1
LG&E	C1SR	902865	06/2015	05/21/2015	100.100	99.860	100.0	1
LG&E	C1SR	902866	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	902867	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902868	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902869	06/2015	05/21/2015	100.070	100.000	100.0	1
LG&E	C1SR	902870	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902871	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902872	06/2015	05/21/2015	100.080	99.950	99.9	1
LG&E	C1SR	902873	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902874	06/2015	05/21/2015	100.080	99.840	100.0	1
LG&E	C1SR	902875	06/2015	05/21/2015	100.090	100.010	99.9	1
LG&E	C1SR	902876	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902877	06/2015	05/21/2015	100.070	99.940	99.9	1
LG&E	C1SR	902878	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902879	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902880	06/2015	05/21/2015	100.090	99.880	100.1	1
LG&E	C1SR	902881	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902882	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902883	06/2015	05/21/2015	100.060	99.850	100.0	1

LG&E	C1SR	902884	06/2015	05/21/2015	100.090	99.860	100.0	1
LG&E	C1SR	902885	06/2015	05/21/2015	100.100	99.940	100.1	1
LG&E	C1SR	902886	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902887	06/2015	05/21/2015	100.100	99.950	99.9	1
LG&E	C1SR	902888	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902889	06/2015	05/21/2015	100.100	99.880	100.0	1
LG&E	C1SR	902890	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902891	06/2015	05/21/2015	100.050	99.870	99.9	1
LG&E	C1SR	902892	06/2015	05/21/2015	100.090	99.930	100.1	1
LG&E	C1SR	902893	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	902894	06/2015	05/21/2015	100.090	99.960	100.1	1
LG&E	C1SR	902895	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902896	06/2015	05/21/2015	100.090	99.940	100.1	1
LG&E	C1SR	902897	06/2015	05/21/2015	100.100	99.940	99.9	1
LG&E	C1SR	902898	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	902899	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	902900	06/2015	05/21/2015	100.090	99.900	100.1	1
LG&E	C1SR	902901	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902902	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902903	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902904	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902905	06/2015	05/21/2015	100.090	100.010	100.0	1
LG&E	C1SR	902906	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	902907	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	902908	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	902909	06/2015	05/21/2015	100.050	99.930	100.1	1
LG&E	C1SR	902910	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	902911	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	902912	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902913	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	902914	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902915	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902916	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902917	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	902918	06/2015	05/21/2015	100.070	99.910	100.1	1
LG&E	C1SR	902919	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902920	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902921	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902922	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	902923	06/2015	05/21/2015	100.080	99.860	100.0	1
LG&E	C1SR	902924	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902925	06/2015	05/21/2015	100.060	99.930	100.0	1

LG&E	C1SR	902926	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	902927	06/2015	05/21/2015	100.050	99.920	99.9	1
LG&E	C1SR	902928	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902929	06/2015	05/21/2015	100.060	99.920	99.9	1
LG&E	C1SR	902930	06/2015	05/21/2015	100.090	99.950	100.1	1
LG&E	C1SR	902931	06/2015	05/21/2015	100.080	99.970	100.1	1
LG&E	C1SR	902932	06/2015	05/21/2015	100.100	100.020	100.1	1
LG&E	C1SR	902933	06/2015	05/21/2015	100.090	99.990	99.9	1
LG&E	C1SR	902934	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	902935	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	902936	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902937	06/2015	05/21/2015	100.060	100.020	100.0	1
LG&E	C1SR	902938	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	902939	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	902940	06/2015	05/21/2015	100.070	99.870	100.0	1
LG&E	C1SR	902941	06/2015	05/21/2015	100.110	99.980	100.1	1
LG&E	C1SR	902942	06/2015	05/21/2015	100.100	100.010	100.0	1
LG&E	C1SR	902943	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902944	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	902945	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902946	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	902947	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	902948	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	902949	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	902950	06/2015	05/21/2015	100.060	99.880	99.9	1
LG&E	C1SR	902951	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	902952	06/2015	05/21/2015	100.070	99.910	99.9	1
LG&E	C1SR	902953	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	902954	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902955	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902956	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	902957	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902958	06/2015	05/21/2015	100.080	99.940	99.9	1
LG&E	C1SR	902959	06/2015	05/21/2015	100.100	100.000	100.0	1
LG&E	C1SR	902960	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	902961	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	902962	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	902963	06/2015	05/21/2015	100.070	99.950	100.0	1
LG&E	C1SR	902964	06/2015	05/21/2015	100.080	99.850	100.0	1
LG&E	C1SR	902965	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902966	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	902967	06/2015	05/21/2015	100.070	99.950	100.0	1

LG&E	C1SR	902968	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	902969	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	902970	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	902971	06/2015	05/21/2015	100.060	99.990	100.0	1
LG&E	C1SR	902972	06/2015	05/21/2015	100.060	99.860	99.9	1
LG&E	C1SR	902973	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	902974	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902975	06/2015	05/21/2015	100.080	99.880	100.0	1
LG&E	C1SR	902976	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902977	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902978	06/2015	05/21/2015	100.050	99.870	100.0	1
LG&E	C1SR	902979	06/2015	05/21/2015	100.050	99.900	100.0	1
LG&E	C1SR	902980	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	902981	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902982	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	902983	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	902984	06/2015	05/21/2015	100.060	99.910	99.9	1
LG&E	C1SR	902985	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902986	06/2015	05/21/2015	100.080	99.850	100.0	1
LG&E	C1SR	902987	06/2015	05/21/2015	100.050	99.950	100.0	1
LG&E	C1SR	902988	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	902989	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	902990	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	902991	06/2015	05/21/2015	100.070	99.830	99.9	1
LG&E	C1SR	902992	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	902993	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	902994	06/2015	05/21/2015	100.060	99.860	99.9	1
LG&E	C1SR	902995	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902996	06/2015	05/21/2015	100.050	99.900	100.0	1
LG&E	C1SR	902997	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	902998	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	902999	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903000	06/2015	05/21/2015	100.070	99.880	99.9	1
LG&E	C1SR	903001	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	903002	06/2015	05/21/2015	100.050	99.900	100.1	1
LG&E	C1SR	903003	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	903004	06/2015	05/21/2015	100.060	99.890	99.9	1
LG&E	C1SR	903005	06/2015	05/21/2015	100.080	99.930	99.9	1
LG&E	C1SR	903006	06/2015	05/21/2015	100.090	99.940	100.1	1
LG&E	C1SR	903007	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	903008	06/2015	05/21/2015	100.060	99.880	99.9	1
LG&E	C1SR	903009	06/2015	05/21/2015	100.070	99.890	100.0	1

LG&E	C1SR	903010	06/2015	05/21/2015	100.050	99.960	100.0	1
LG&E	C1SR	903011	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	903012	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	903013	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	903014	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	903015	06/2015	05/21/2015	100.060	99.950	100.0	1
LG&E	C1SR	903016	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	903017	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	903018	06/2015	05/21/2015	100.070	99.840	99.9	1
LG&E	C1SR	903019	06/2015	05/21/2015	100.090	99.990	100.0	1
LG&E	C1SR	903020	06/2015	05/21/2015	100.100	99.960	100.1	1
LG&E	C1SR	903021	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	903022	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	903023	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	903024	06/2015	05/21/2015	100.050	99.880	100.0	1
LG&E	C1SR	903025	06/2015	05/21/2015	100.050	99.910	99.9	1
LG&E	C1SR	903026	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	903027	06/2015	05/21/2015	100.060	99.910	99.9	1
LG&E	C1SR	903028	06/2015	05/21/2015	100.100	99.960	100.0	1
LG&E	C1SR	903029	06/2015	05/21/2015	100.060	99.980	100.0	1
LG&E	C1SR	903030	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	903031	06/2015	05/21/2015	100.090	99.970	100.1	1
LG&E	C1SR	903032	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	903033	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	903034	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903035	06/2015	05/21/2015	100.080	99.870	99.9	1
LG&E	C1SR	903036	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	903037	06/2015	05/21/2015	100.090	99.930	100.1	1
LG&E	C1SR	903038	06/2015	05/21/2015	100.070	99.890	100.0	1
LG&E	C1SR	903039	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903040	06/2015	05/21/2015	100.090	99.890	100.0	1
LG&E	C1SR	903041	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	903042	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903043	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	903044	06/2015	05/21/2015	100.060	99.950	99.9	1
LG&E	C1SR	903045	06/2015	05/21/2015	100.070	99.910	100.1	1
LG&E	C1SR	903046	06/2015	05/21/2015	100.100	99.960	100.1	1
LG&E	C1SR	903047	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	903048	06/2015	05/21/2015	100.080	99.890	99.9	1
LG&E	C1SR	903049	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903050	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	903051	06/2015	05/21/2015	100.060	99.890	100.0	1

LG&E	C1SR	903052	06/2015	05/21/2015	100.060	99.890	100.0	1
LG&E	C1SR	903053	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	903054	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903055	06/2015	05/21/2015	100.090	99.970	100.0	1
LG&E	C1SR	903056	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903057	06/2015	05/21/2015	100.070	99.860	100.0	1
LG&E	C1SR	903058	06/2015	05/21/2015	100.060	99.840	100.0	1
LG&E	C1SR	903059	06/2015	05/21/2015	100.090	99.900	100.1	1
LG&E	C1SR	903060	06/2015	05/21/2015	100.070	99.920	100.0	1
LG&E	C1SR	903061	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	903062	06/2015	05/21/2015	100.100	99.980	100.0	1
LG&E	C1SR	903063	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	903064	06/2015	05/21/2015	100.070	99.890	100.1	1
LG&E	C1SR	903065	06/2015	05/21/2015	100.050	99.930	99.9	1
LG&E	C1SR	903066	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	903067	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	903068	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903069	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	903070	06/2015	05/21/2015	100.080	99.990	100.0	1
LG&E	C1SR	903071	06/2015	05/21/2015	100.070	99.940	100.1	1
LG&E	C1SR	903072	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	903073	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903074	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	903075	06/2015	05/21/2015	100.060	99.920	99.9	1
LG&E	C1SR	903076	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	903077	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	903078	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	903079	06/2015	05/21/2015	100.090	99.940	100.0	1
LG&E	C1SR	903080	06/2015	05/21/2015	100.090	99.910	100.0	1
LG&E	C1SR	903081	06/2015	05/21/2015	100.090	99.890	99.9	1
LG&E	C1SR	903082	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	903083	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	903084	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	903085	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C1SR	903086	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	903087	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	903088	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	903089	06/2015	05/21/2015	100.090	99.880	100.0	1
LG&E	C1SR	903090	06/2015	05/21/2015	100.080	99.870	100.0	1
LG&E	C1SR	903091	06/2015	05/21/2015	100.080	99.940	100.0	1
LG&E	C1SR	903092	06/2015	05/21/2015	100.090	99.840	100.0	1
LG&E	C1SR	903093	06/2015	05/21/2015	100.080	99.930	100.1	1

LG&E	C1SR	903094	06/2015	05/21/2015	100.090	99.930	100.1	1
LG&E	C1SR	903095	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	903096	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	903097	06/2015	05/21/2015	100.070	99.880	100.0	1
LG&E	C1SR	903098	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903099	06/2015	05/21/2015	100.060	100.020	100.0	1
LG&E	C1SR	903100	06/2015	05/21/2015	100.080	99.920	99.9	1
LG&E	C1SR	903101	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	903102	06/2015	05/21/2015	100.090	99.940	100.1	1
LG&E	C1SR	903103	06/2015	05/21/2015	100.090	99.900	100.0	1
LG&E	C1SR	903104	06/2015	05/21/2015	100.100	99.940	100.0	1
LG&E	C1SR	903105	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	903106	06/2015	05/21/2015	100.070	99.930	100.0	1
LG&E	C1SR	903107	06/2015	05/21/2015	100.060	99.860	100.0	1
LG&E	C1SR	903108	06/2015	05/21/2015	100.060	99.920	100.0	1
LG&E	C1SR	903109	06/2015	05/21/2015	100.080	99.910	99.9	1
LG&E	C1SR	903110	06/2015	05/21/2015	100.090	100.010	100.0	1
LG&E	C1SR	903111	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	903112	06/2015	05/21/2015	100.100	99.910	100.0	1
LG&E	C1SR	903113	06/2015	05/21/2015	100.090	99.940	100.1	1
LG&E	C1SR	903114	06/2015	05/21/2015	100.100	99.990	100.0	1
LG&E	C1SR	903115	06/2015	05/21/2015	100.070	99.960	100.0	1
LG&E	C1SR	903116	06/2015	05/21/2015	100.080	99.990	100.0	1
LG&E	C1SR	903117	06/2015	05/21/2015	100.060	99.960	100.0	1
LG&E	C1SR	903118	06/2015	05/21/2015	100.070	99.870	100.1	1
LG&E	C1SR	903119	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903120	06/2015	05/21/2015	100.050	99.980	99.9	1
LG&E	C1SR	903121	06/2015	05/21/2015	100.080	100.030	100.1	1
LG&E	C1SR	903122	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	903123	06/2015	05/21/2015	100.080	99.960	100.0	1
LG&E	C1SR	903124	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	903125	06/2015	05/21/2015	100.080	99.920	100.0	1
LG&E	C1SR	903126	06/2015	05/21/2015	100.060	100.010	100.0	1
LG&E	C1SR	903127	06/2015	05/21/2015	100.080	99.890	100.0	1
LG&E	C1SR	903128	06/2015	05/21/2015	100.090	99.820	100.0	1
LG&E	C1SR	903129	06/2015	05/21/2015	100.060	99.930	100.0	1
LG&E	C1SR	903130	06/2015	05/21/2015	100.100	99.920	100.0	1
LG&E	C1SR	903131	06/2015	05/21/2015	100.060	99.940	99.9	1
LG&E	C1SR	903132	06/2015	05/21/2015	100.080	99.880	100.0	1
LG&E	C1SR	903133	06/2015	05/21/2015	100.090	99.900	100.1	1
LG&E	C1SR	903134	06/2015	05/21/2015	100.060	99.910	100.0	1
LG&E	C1SR	903135	06/2015	05/21/2015	100.090	99.920	100.0	1

LG&E	C1SR	903136	06/2015	05/21/2015	100.080	99.960	100.1	1
LG&E	C1SR	903137	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	903138	06/2015	05/21/2015	100.090	99.930	100.0	1
LG&E	C1SR	903139	06/2015	05/21/2015	100.060	99.930	99.9	1
LG&E	C1SR	903140	06/2015	05/21/2015	100.070	99.900	100.0	1
LG&E	C1SR	903141	06/2015	05/21/2015	100.090	99.980	100.0	1
LG&E	C1SR	903142	06/2015	05/21/2015	100.060	99.880	100.0	1
LG&E	C1SR	903143	06/2015	05/21/2015	100.080	99.980	99.9	1
LG&E	C1SR	903144	06/2015	05/21/2015	100.090	99.880	100.1	1
LG&E	C1SR	903145	06/2015	05/21/2015	100.090	99.860	99.9	1
LG&E	C1SR	903146	06/2015	05/21/2015	100.090	99.910	100.1	1
LG&E	C1SR	903147	06/2015	05/21/2015	100.070	99.920	99.9	1
LG&E	C1SR	903148	06/2015	05/21/2015	100.070	99.980	100.0	1
LG&E	C1SR	903149	06/2015	05/21/2015	100.050	99.820	100.0	1
LG&E	C1SR	903150	06/2015	05/21/2015	100.050	99.890	100.0	1
LG&E	C1SR	903151	06/2015	05/21/2015	100.100	99.900	99.9	1
LG&E	C1SR	903152	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	903153	06/2015	05/21/2015	100.090	99.950	100.0	1
LG&E	C1SR	903154	06/2015	05/21/2015	100.070	99.970	100.0	1
LG&E	C1SR	903155	06/2015	05/21/2015	100.090	99.990	99.9	1
LG&E	C1SR	903156	06/2015	05/21/2015	100.100	99.930	100.0	1
LG&E	C1SR	903157	06/2015	05/21/2015	100.060	99.940	100.0	1
LG&E	C1SR	903158	06/2015	05/21/2015	100.070	99.960	100.1	1
LG&E	C1SR	903159	06/2015	05/21/2015	100.100	99.880	100.0	1
LG&E	C1SR	903160	06/2015	05/21/2015	100.050	99.880	99.9	1
LG&E	C1SR	903161	06/2015	05/21/2015	100.070	99.940	100.1	1
LG&E	C1SR	903162	06/2015	05/21/2015	100.060	99.900	100.0	1
LG&E	C1SR	903163	06/2015	05/21/2015	100.060	99.900	99.9	1
LG&E	C1SR	903164	06/2015	05/21/2015	100.100	99.950	100.0	1
LG&E	C1SR	903165	06/2015	05/21/2015	100.100	99.880	100.0	1
LG&E	C1SR	903166	06/2015	05/21/2015	100.070	99.860	99.9	1
LG&E	C1SR	903167	06/2015	05/21/2015	100.060	99.950	99.9	1
LG&E	C1SR	903168	06/2015	05/21/2015	100.070	99.870	99.9	1
LG&E	C1SR	903169	06/2015	05/21/2015	100.100	99.900	100.0	1
LG&E	C1SR	903170	06/2015	05/21/2015	100.080	99.900	100.0	1
LG&E	C1SR	903171	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	903172	06/2015	05/21/2015	100.050	99.920	100.0	1
LG&E	C1SR	903173	06/2015	05/21/2015	100.070	99.970	99.9	1
LG&E	C1SR	903174	06/2015	05/21/2015	100.080	99.970	100.0	1
LG&E	C1SR	903175	06/2015	05/21/2015	100.080	99.910	100.0	1
LG&E	C1SR	903176	06/2015	05/21/2015	100.080	99.950	100.0	1
LG&E	C1SR	903177	06/2015	05/21/2015	100.070	99.940	100.0	1

LG&E	C1SR	903178	06/2015	05/21/2015	100.080	99.960	100.1	1
LG&E	C1SR	903179	06/2015	05/21/2015	100.050	99.900	100.0	1
LG&E	C1SR	903180	06/2015	05/21/2015	100.090	99.960	100.0	1
LG&E	C1SR	903181	06/2015	05/21/2015	100.070	99.910	100.0	1
LG&E	C1SR	903182	06/2015	05/21/2015	100.080	99.930	100.0	1
LG&E	C1SR	903183	06/2015	05/21/2015	100.060	99.870	100.0	1
LG&E	C1SR	903184	06/2015	05/21/2015	100.070	99.940	100.0	1
LG&E	C1SR	903185	06/2015	05/21/2015	100.090	99.920	100.0	1
LG&E	C2SOS - OPENWAY CELL	908326	10/2015	10/14/2015	100.010	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908327	10/2015	10/14/2015	100.010	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908328	10/2015	10/14/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908329	10/2015	10/14/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	903698	09/2015	07/07/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	903699	09/2015	07/07/2015	100.040	100.040	100.1	1
LG&E	C2SOS - OPENWAY CELL	903700	09/2015	07/07/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	903701	09/2015	07/07/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	903702	09/2015	07/07/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	903703	09/2015	07/07/2015	100.020	100.010	100.1	1
LG&E	C2SOS - OPENWAY CELL	903704	09/2015	07/07/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	903705	09/2015	07/07/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	903706	08/2015	07/07/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	903707	08/2015	07/07/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	903708	08/2015	07/07/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	903709	08/2015	07/07/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	903710	08/2015	07/07/2015	100.020	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	903711	08/2015	07/07/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	903712	08/2015	07/07/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	903713	08/2015	07/07/2015	100.030	100.060	100.1	1
LG&E	C2SOS - OPENWAY CELL	903714	08/2015	07/07/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	903715	08/2015	07/07/2015	100.030	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	903716	08/2015	07/07/2015	100.040	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	903717	08/2015	07/07/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	903718	08/2015	07/07/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	903719	08/2015	07/07/2015	100.020	100.030	100.1	1
LG&E	C2SOS - OPENWAY CELL	903720	08/2015	07/07/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	903721	08/2015	07/07/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	903722	08/2015	07/07/2015	100.040	100.050	100.1	1
LG&E	C2SOS - OPENWAY CELL	903723	08/2015	07/07/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	903724	08/2015	07/07/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	903725	08/2015	07/07/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	903726	08/2015	07/07/2015	100.040	100.090	100.1	1
LG&E	C2SOS - OPENWAY CELL	903727	08/2015	07/07/2015	100.030	100.010	100.0	1

LG&E	C2SOS - OPENWAY CELL	903728	08/2015	07/07/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	903729	08/2015	07/07/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908086	10/2015	10/01/2015	100.020	99.930	100.0	1
LG&E	C2SOS - OPENWAY CELL	908087	10/2015	10/01/2015	100.030	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908088	10/2015	10/01/2015	100.040	99.920	100.0	1
LG&E	C2SOS - OPENWAY CELL	908089	10/2015	10/01/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908090	10/2015	10/13/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908091	10/2015	10/13/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908092	10/2015	10/13/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908093	10/2015	10/13/2015	100.040	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908094	10/2015	10/13/2015	100.030	100.130	100.1	1
LG&E	C2SOS - OPENWAY CELL	908095	10/2015	10/13/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908096	10/2015	10/13/2015	100.020	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908097	10/2015	10/13/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908098	10/2015	10/13/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908099	10/2015	10/13/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908100	10/2015	10/13/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908101	10/2015	10/13/2015	100.020	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908102	10/2015	10/13/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908103	10/2015	10/13/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908104	10/2015	10/13/2015	100.020	99.950	100.0	1
LG&E	C2SOS - OPENWAY CELL	908105	10/2015	10/13/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908106	10/2015	10/13/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908107	10/2015	10/13/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908108	10/2015	10/13/2015	100.040	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	908109	10/2015	10/13/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908110	10/2015	10/13/2015	100.030	99.930	100.0	1
LG&E	C2SOS - OPENWAY CELL	908111	10/2015	10/13/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908112	10/2015	10/13/2015	100.030	99.910	100.0	1
LG&E	C2SOS - OPENWAY CELL	908113	10/2015	10/13/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908114	10/2015	10/13/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908115	10/2015	10/13/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908116	10/2015	10/13/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908117	10/2015	10/13/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908118	10/2015	10/13/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908119	10/2015	10/13/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908120	10/2015	10/13/2015	100.010	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908121	10/2015	10/13/2015	100.040	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908122	10/2015	10/13/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908123	10/2015	10/13/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908124	10/2015	10/13/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908125	10/2015	10/13/2015	100.030	99.970	100.0	1

LG&E	C2SOS - OPENWAY CELL	908168	10/2015	10/13/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908169	10/2015	10/13/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908170	10/2015	10/13/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908171	10/2015	10/13/2015	100.040	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	908172	10/2015	10/13/2015	100.020	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908173	10/2015	10/13/2015	100.050	100.090	100.0	1
LG&E	C2SOS - OPENWAY CELL	908174	10/2015	10/13/2015	100.030	100.120	100.0	1
LG&E	C2SOS - OPENWAY CELL	908175	10/2015	10/13/2015	100.020	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908176	10/2015	10/13/2015	100.020	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908177	10/2015	10/13/2015	100.040	99.940	100.0	1
LG&E	C2SOS - OPENWAY CELL	908178	10/2015	10/13/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908179	10/2015	10/13/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908180	10/2015	10/13/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908181	10/2015	10/13/2015	100.020	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908182	10/2015	10/13/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908183	10/2015	10/13/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908184	10/2015	10/13/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908185	10/2015	10/13/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908186	10/2015	10/13/2015	100.040	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908187	10/2015	10/13/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908188	10/2015	10/13/2015	100.030	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908189	10/2015	10/13/2015	100.040	100.130	100.1	1
LG&E	C2SOS - OPENWAY CELL	908190	10/2015	10/13/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908191	10/2015	10/13/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908192	10/2015	10/13/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908193	10/2015	10/13/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908194	10/2015	10/13/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908195	10/2015	10/13/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908196	10/2015	10/13/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908197	10/2015	10/13/2015	100.050	100.140	100.1	1
LG&E	C2SOS - OPENWAY CELL	908198	10/2015	10/13/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908199	10/2015	10/13/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908200	10/2015	10/13/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908201	10/2015	10/13/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908202	10/2015	10/13/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908203	10/2015	10/13/2015	100.030	100.130	100.1	1
LG&E	C2SOS - OPENWAY CELL	908204	10/2015	10/13/2015	100.050	100.140	100.1	1
LG&E	C2SOS - OPENWAY CELL	908205	10/2015	10/13/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908206	10/2015	10/15/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908207	10/2015	10/15/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908208	10/2015	10/15/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908209	10/2015	10/15/2015	100.040	99.990	100.0	1

LG&E	C2SOS - OPENWAY CELL	908252	10/2015	10/15/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908253	10/2015	10/15/2015	100.040	100.080	100.1	1
LG&E	C2SOS - OPENWAY CELL	908254	10/2015	10/15/2015	100.050	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908255	10/2015	10/15/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908256	10/2015	10/15/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908257	10/2015	10/15/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908258	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908259	10/2015	10/15/2015	100.020	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908260	10/2015	10/15/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908261	10/2015	10/15/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908262	10/2015	10/15/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908263	10/2015	10/15/2015	100.030	100.120	100.1	1
LG&E	C2SOS - OPENWAY CELL	908264	10/2015	10/15/2015	100.020	100.060	100.1	1
LG&E	C2SOS - OPENWAY CELL	908265	10/2015	10/15/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908266	10/2015	10/15/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908267	10/2015	10/15/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908268	10/2015	10/15/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908269	10/2015	10/15/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908270	10/2015	10/15/2015	100.020	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908271	10/2015	10/15/2015	100.040	99.980	99.9	1
LG&E	C2SOS - OPENWAY CELL	908272	10/2015	10/15/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908273	10/2015	10/15/2015	100.020	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908274	10/2015	10/15/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908275	10/2015	10/15/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908276	10/2015	10/15/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908277	10/2015	10/15/2015	100.040	100.130	100.0	1
LG&E	C2SOS - OPENWAY CELL	908278	10/2015	10/15/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908279	10/2015	10/15/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908280	10/2015	10/15/2015	100.020	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908281	10/2015	10/15/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908282	10/2015	10/15/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908283	10/2015	10/15/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908284	10/2015	10/15/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908285	10/2015	10/15/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908286	10/2015	10/15/2015	100.030	100.120	100.0	1
LG&E	C2SOS - OPENWAY CELL	908287	10/2015	10/15/2015	100.020	99.960	100.0	1
LG&E	C2SOS - OPENWAY CELL	908288	10/2015	10/15/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908289	10/2015	10/15/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908290	10/2015	10/15/2015	100.040	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908291	10/2015	10/15/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908292	10/2015	10/15/2015	100.020	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908293	10/2015	10/15/2015	100.030	100.050	100.0	1

LG&E	C2SOS - OPENWAY CELL	908294	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908295	10/2015	10/15/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908296	10/2015	10/15/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908297	10/2015	10/15/2015	100.010	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908298	10/2015	10/15/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908299	10/2015	10/15/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908300	10/2015	10/15/2015	100.040	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908301	10/2015	10/15/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908302	10/2015	10/15/2015	100.020	99.910	100.0	1
LG&E	C2SOS - OPENWAY CELL	908303	10/2015	10/15/2015	100.020	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908304	10/2015	10/15/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908305	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908306	10/2015	10/15/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908307	10/2015	10/15/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908308	10/2015	10/15/2015	100.050	100.060	100.1	1
LG&E	C2SOS - OPENWAY CELL	908309	10/2015	10/15/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908310	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908311	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908312	10/2015	10/15/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908313	10/2015	10/15/2015	100.040	100.050	100.1	1
LG&E	C2SOS - OPENWAY CELL	908314	10/2015	10/15/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908315	10/2015	10/15/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908316	10/2015	10/15/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908317	10/2015	10/15/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908318	10/2015	10/15/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908319	10/2015	10/15/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908320	10/2015	10/15/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908321	10/2015	10/15/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908322	10/2015	10/15/2015	100.040	100.100	100.1	1
LG&E	C2SOS - OPENWAY CELL	908323	10/2015	10/15/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908324	10/2015	10/15/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908325	10/2015	10/15/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908330	10/2015	10/09/2015	100.030	100.110	100.0	1
LG&E	C2SOS - OPENWAY CELL	908331	10/2015	10/09/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908332	10/2015	10/09/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908333	10/2015	10/09/2015	100.030	100.140	100.0	1
LG&E	C2SOS - OPENWAY CELL	908342	11/2015	11/20/2015	100.020	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908343	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908344	11/2015	11/20/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908345	11/2015	11/20/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908346	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908347	11/2015	11/20/2015	100.030	100.020	100.0	1

LG&E	C2SOS - OPENWAY CELL	908474	11/2015	11/20/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908475	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908476	11/2015	11/20/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908477	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908478	11/2015	11/20/2015	100.040	100.090	100.1	1
LG&E	C2SOS - OPENWAY CELL	908479	11/2015	11/20/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908480	11/2015	11/20/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908481	11/2015	11/20/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908482	11/2015	11/20/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908483	11/2015	11/20/2015	100.030	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908484	11/2015	11/20/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908485	11/2015	11/20/2015	100.040	99.960	100.0	1
LG&E	C2SOS - OPENWAY CELL	908486	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908487	11/2015	11/20/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908488	11/2015	11/20/2015	100.040	100.100	100.1	1
LG&E	C2SOS - OPENWAY CELL	908489	11/2015	11/20/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908490	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908491	11/2015	11/20/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908492	11/2015	11/20/2015	100.050	100.180	100.1	1
LG&E	C2SOS - OPENWAY CELL	908493	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908494	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908495	11/2015	11/20/2015	100.020	99.990	99.9	1
LG&E	C2SOS - OPENWAY CELL	908496	11/2015	11/20/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908497	11/2015	11/20/2015	100.020	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908498	11/2015	11/20/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908499	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908500	11/2015	11/20/2015	100.020	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908501	11/2015	11/20/2015	100.030	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908502	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908503	11/2015	11/20/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908504	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908505	11/2015	11/20/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908506	11/2015	11/20/2015	100.020	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908507	11/2015	11/20/2015	100.040	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908508	11/2015	11/20/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908509	11/2015	11/20/2015	100.040	100.130	100.1	1
LG&E	C2SOS - OPENWAY CELL	908510	11/2015	11/20/2015	100.040	99.940	100.0	1
LG&E	C2SOS - OPENWAY CELL	908511	11/2015	11/20/2015	100.040	100.150	100.0	1
LG&E	C2SOS - OPENWAY CELL	908512	11/2015	11/20/2015	100.040	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908513	11/2015	11/20/2015	100.010	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908514	11/2015	11/20/2015	100.040	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908515	11/2015	11/20/2015	100.030	99.990	100.0	1

LG&E	C2SOS - OPENWAY CELL	908558	11/2015	11/20/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908559	11/2015	11/20/2015	100.030	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908560	11/2015	11/20/2015	100.050	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908561	11/2015	11/20/2015	100.040	99.920	100.0	1
LG&E	C2SOS - OPENWAY CELL	908562	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908563	11/2015	11/20/2015	100.030	100.010	100.1	1
LG&E	C2SOS - OPENWAY CELL	908564	11/2015	11/20/2015	100.050	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908565	11/2015	11/20/2015	100.030	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908566	11/2015	11/20/2015	100.040	100.110	100.1	1
LG&E	C2SOS - OPENWAY CELL	908567	11/2015	11/20/2015	100.040	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908568	11/2015	11/20/2015	100.040	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908569	11/2015	11/20/2015	100.030	100.090	100.0	1
LG&E	C2SOS - OPENWAY CELL	908570	11/2015	11/20/2015	100.050	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908571	11/2015	11/20/2015	100.040	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908572	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908573	11/2015	11/20/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908574	11/2015	11/20/2015	100.040	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	908575	11/2015	11/20/2015	100.040	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	908576	11/2015	11/20/2015	100.030	99.910	100.0	1
LG&E	C2SOS - OPENWAY CELL	908577	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908578	11/2015	11/20/2015	100.050	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908579	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908580	11/2015	11/20/2015	100.040	100.100	100.0	1
LG&E	C2SOS - OPENWAY CELL	908581	11/2015	11/20/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908582	11/2015	11/20/2015	100.040	100.120	100.1	1
LG&E	C2SOS - OPENWAY CELL	908583	11/2015	11/20/2015	100.020	100.090	100.0	1
LG&E	C2SOS - OPENWAY CELL	908584	11/2015	11/20/2015	100.030	99.960	100.0	1
LG&E	C2SOS - OPENWAY CELL	908585	11/2015	11/20/2015	100.050	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908586	11/2015	11/20/2015	100.030	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908587	11/2015	11/20/2015	100.020	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908588	11/2015	11/20/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908589	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908590	11/2015	11/20/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908591	11/2015	11/20/2015	100.040	100.090	100.0	1
LG&E	C2SOS - OPENWAY CELL	908592	11/2015	11/20/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908593	11/2015	11/20/2015	100.040	100.070	100.1	1
LG&E	C2SOS - OPENWAY CELL	908594	11/2015	11/20/2015	100.040	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908595	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908596	11/2015	11/20/2015	100.040	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908597	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908598	11/2015	11/20/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908599	11/2015	11/20/2015	100.030	100.050	100.1	1

LG&E	C2SOS - OPENWAY CELL	908642	11/2015	11/20/2015	100.040	100.120	100.1	1
LG&E	C2SOS - OPENWAY CELL	908643	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908644	11/2015	11/20/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908645	11/2015	11/20/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908646	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908647	11/2015	11/20/2015	100.020	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908648	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908649	11/2015	11/20/2015	100.030	100.110	100.0	1
LG&E	C2SOS - OPENWAY CELL	908650	11/2015	11/20/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908651	11/2015	11/20/2015	100.020	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908652	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908653	11/2015	11/20/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908654	11/2015	11/20/2015	100.020	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908655	11/2015	11/20/2015	100.030	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908656	11/2015	11/20/2015	100.040	100.110	100.1	1
LG&E	C2SOS - OPENWAY CELL	908657	11/2015	11/20/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908658	11/2015	11/20/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908659	11/2015	11/20/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908660	11/2015	11/20/2015	100.020	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908661	11/2015	11/20/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908662	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908663	11/2015	11/20/2015	100.020	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908664	11/2015	11/20/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908665	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908666	11/2015	11/20/2015	100.030	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908667	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908668	11/2015	11/20/2015	100.040	100.180	100.1	1
LG&E	C2SOS - OPENWAY CELL	908669	11/2015	11/20/2015	100.040	99.950	100.0	1
LG&E	C2SOS - OPENWAY CELL	908670	11/2015	11/20/2015	100.030	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908671	11/2015	11/20/2015	100.030	100.100	100.1	1
LG&E	C2SOS - OPENWAY CELL	908672	11/2015	11/20/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908673	11/2015	11/20/2015	100.030	100.130	100.1	1
LG&E	C2SOS - OPENWAY CELL	908674	11/2015	11/20/2015	100.040	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908675	11/2015	11/20/2015	100.030	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908676	11/2015	11/20/2015	100.030	100.010	100.0	1
LG&E	C2SOS - OPENWAY CELL	908677	11/2015	11/20/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908678	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908679	11/2015	11/20/2015	100.040	100.080	100.0	1
LG&E	C2SOS - OPENWAY CELL	908680	11/2015	11/20/2015	100.040	100.070	100.0	1
LG&E	C2SOS - OPENWAY CELL	908681	11/2015	11/20/2015	100.020	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908682	11/2015	11/20/2015	100.040	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908683	11/2015	11/20/2015	100.040	100.060	100.0	1

LG&E	C2SOS - OPENWAY CELL	908684	11/2015	11/20/2015	100.020	100.020	100.0	1
LG&E	C2SOS - OPENWAY CELL	908685	11/2015	11/20/2015	100.020	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908686	11/2015	11/20/2015	100.040	100.060	100.0	1
LG&E	C2SOS - OPENWAY CELL	908687	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908688	11/2015	11/20/2015	100.040	100.050	100.0	1
LG&E	C2SOS - OPENWAY CELL	908689	11/2015	11/20/2015	100.030	99.990	100.0	1
LG&E	C2SOS - OPENWAY CELL	908690	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908691	11/2015	11/20/2015	100.040	100.110	100.1	1
LG&E	C2SOS - OPENWAY CELL	908692	11/2015	11/20/2015	100.050	100.110	100.1	1
LG&E	C2SOS - OPENWAY CELL	908693	11/2015	11/20/2015	100.040	100.030	100.0	1
LG&E	C2SOS - OPENWAY CELL	908694	11/2015	11/20/2015	100.030	100.000	100.0	1
LG&E	C2SOS - OPENWAY CELL	908695	11/2015	11/20/2015	100.030	100.090	100.0	1
LG&E	C2SOS - OPENWAY CELL	908696	11/2015	11/20/2015	100.040	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908697	11/2015	11/20/2015	100.040	100.040	100.0	1
LG&E	C2SOS - OPENWAY CELL	908698	11/2015	11/20/2015	100.030	100.120	100.1	1
LG&E	C2SOS - OPENWAY CELL	908699	11/2015	11/20/2015	100.030	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908700	11/2015	11/20/2015	100.010	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908701	11/2015	11/20/2015	100.030	100.050	100.1	1
LG&E	C2SOS - OPENWAY CELL	908334	10/2015	10/13/2015	100.000	99.970	100.0	1
LG&E	C2SOS - OPENWAY CELL	908335	10/2015	10/13/2015	99.990	99.980	100.0	1
LG&E	C2SOS - OPENWAY CELL	908336	10/2015	10/13/2015	100.000	99.940	100.0	1
LG&E	C2SOS - OPENWAY CELL	908337	10/2015	10/13/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903218	08/2015	06/18/2015	100.010	100.050	100.0	1
LG&E	FOCUS AXR - MESH	903219	08/2015	06/18/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	903220	08/2015	06/18/2015	100.010	100.050	100.1	1
LG&E	FOCUS AXR - MESH	903221	08/2015	06/18/2015	100.000	100.000	100.1	1
LG&E	FOCUS AXR - MESH	903254	08/2015	06/25/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	903255	08/2015	06/25/2015	100.010	99.920	100.0	1
LG&E	FOCUS AXR - MESH	903256	08/2015	06/25/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903257	08/2015	06/25/2015	99.970	99.910	100.0	1
LG&E	FOCUS AXR - MESH	903258	09/2015	08/04/2015	99.960	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903259	09/2015	08/04/2015	100.050	99.980	100.1	1
LG&E	FOCUS AXR - MESH	903260	09/2015	08/04/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	903261	09/2015	08/04/2015	100.020	99.920	100.0	1
LG&E	FOCUS AXR - MESH	903262	09/2015	08/05/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	903263	09/2015	08/05/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	903264	09/2015	08/05/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	903265	09/2015	08/05/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903266	09/2015	08/05/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903267	09/2015	08/05/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	903268	09/2015	08/05/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	903269	09/2015	08/05/2015	100.040	99.980	100.0	1

LG&E	FOCUS AXR - MESH	903270	09/2015	08/05/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903271	09/2015	08/05/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	903272	09/2015	08/05/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	903273	09/2015	08/05/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903274	09/2015	08/05/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	903275	09/2015	08/05/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	903276	09/2015	08/05/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	903277	09/2015	08/05/2015	100.010	99.960	100.1	1
LG&E	FOCUS AXR - MESH	903278	09/2015	08/05/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903279	09/2015	08/05/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903280	09/2015	08/05/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903281	09/2015	08/05/2015	99.970	99.990	99.9	1
LG&E	FOCUS AXR - MESH	903282	09/2015	08/05/2015	99.960	99.990	99.9	1
LG&E	FOCUS AXR - MESH	903283	09/2015	08/05/2015	99.990	99.910	100.1	1
LG&E	FOCUS AXR - MESH	903284	09/2015	08/05/2015	99.990	99.970	99.9	1
LG&E	FOCUS AXR - MESH	903285	09/2015	08/05/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903286	09/2015	08/05/2015	99.990	99.960	99.9	1
LG&E	FOCUS AXR - MESH	903287	09/2015	08/05/2015	99.970	99.980	99.9	1
LG&E	FOCUS AXR - MESH	903288	09/2015	08/05/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903289	09/2015	08/05/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903290	09/2015	08/05/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	903291	09/2015	08/05/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	903292	09/2015	08/05/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	903293	09/2015	08/05/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	903294	09/2015	08/05/2015	100.040	100.010	99.9	1
LG&E	FOCUS AXR - MESH	903295	09/2015	08/05/2015	100.030	99.990	99.9	1
LG&E	FOCUS AXR - MESH	903296	09/2015	08/05/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903297	09/2015	08/05/2015	99.970	99.930	100.1	1
LG&E	FOCUS AXR - MESH	903298	09/2015	08/05/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903299	09/2015	08/05/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903300	09/2015	08/05/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	903301	09/2015	08/05/2015	100.040	99.960	100.1	1
LG&E	FOCUS AXR - MESH	903302	09/2015	08/05/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903303	09/2015	08/05/2015	100.040	99.970	100.1	1
LG&E	FOCUS AXR - MESH	903304	09/2015	08/05/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	903305	09/2015	08/05/2015	100.000	99.990	99.9	1
LG&E	FOCUS AXR - MESH	903306	09/2015	08/05/2015	99.990	99.960	100.1	1
LG&E	FOCUS AXR - MESH	903307	09/2015	08/05/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	903308	09/2015	08/05/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	903309	09/2015	08/05/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	903310	09/2015	08/05/2015	100.010	99.920	100.0	1
LG&E	FOCUS AXR - MESH	903311	09/2015	08/05/2015	99.990	99.970	100.0	1

LG&E	FOCUS AXR - MESH	903312	09/2015	08/05/2015	99.970	99.980	99.9	1
LG&E	FOCUS AXR - MESH	903313	09/2015	08/05/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903314	09/2015	08/05/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	903315	09/2015	08/05/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	903316	09/2015	08/05/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903317	09/2015	08/05/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	903318	09/2015	08/05/2015	100.020	99.970	99.9	1
LG&E	FOCUS AXR - MESH	903319	09/2015	08/05/2015	99.980	99.980	99.9	1
LG&E	FOCUS AXR - MESH	903320	09/2015	08/05/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	903321	09/2015	08/05/2015	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906194	09/2015	09/11/2015	99.970	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906195	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906196	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906197	09/2015	09/11/2015	100.020	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906198	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906199	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906200	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906201	09/2015	09/11/2015	100.020	100.050	99.9	1
LG&E	FOCUS AXR - MESH	906202	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906203	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906204	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906205	09/2015	09/11/2015	100.030	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906206	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906207	09/2015	09/11/2015	100.010	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906208	09/2015	09/11/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906209	09/2015	09/11/2015	100.030	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906210	09/2015	09/11/2015	100.010	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906211	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906212	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906213	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906214	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906215	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906216	09/2015	09/11/2015	100.030	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906217	09/2015	09/11/2015	99.990	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906218	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906219	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906220	09/2015	09/11/2015	99.990	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906221	09/2015	09/11/2015	100.030	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906222	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906223	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906224	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906225	09/2015	09/11/2015	99.980	99.980	100.0	1

LG&E	FOCUS AXR - MESH	906226	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906227	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906228	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906229	09/2015	09/11/2015	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906230	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906231	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906232	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906233	09/2015	09/11/2015	100.010	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906234	09/2015	09/11/2015	99.990	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906235	09/2015	09/11/2015	100.040	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906236	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906237	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906238	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906239	09/2015	09/11/2015	100.050	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906240	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906241	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906242	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906243	09/2015	09/11/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906244	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906245	09/2015	09/11/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906246	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906247	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906248	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906249	09/2015	09/11/2015	99.950	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906250	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906251	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906252	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906253	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906254	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906255	09/2015	09/11/2015	100.020	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906256	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906257	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906258	09/2015	09/11/2015	99.990	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906259	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906260	09/2015	09/11/2015	100.010	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906261	09/2015	09/11/2015	99.980	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906262	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906263	09/2015	09/11/2015	100.020	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906264	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906265	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906266	09/2015	09/11/2015	99.980	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906267	09/2015	09/11/2015	99.980	99.990	100.1	1

LG&E	FOCUS AXR - MESH	906268	09/2015	09/11/2015	100.000	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906269	09/2015	09/11/2015	100.010	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906270	09/2015	09/11/2015	99.970	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906271	09/2015	09/11/2015	100.020	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906272	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906273	09/2015	09/11/2015	99.980	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906274	09/2015	09/11/2015	99.980	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906275	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906276	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906277	09/2015	09/11/2015	100.000	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906278	09/2015	09/11/2015	100.000	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906279	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906280	09/2015	09/11/2015	100.010	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906281	09/2015	09/11/2015	100.030	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906282	09/2015	09/11/2015	100.010	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906283	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906284	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906285	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906286	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906287	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906288	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906289	09/2015	09/11/2015	100.020	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906290	09/2015	09/11/2015	100.030	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906291	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906292	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906293	09/2015	09/11/2015	100.050	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906294	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906295	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906296	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906297	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906298	09/2015	09/11/2015	100.050	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906299	09/2015	09/11/2015	100.000	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906300	09/2015	09/11/2015	99.990	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906301	09/2015	09/11/2015	99.990	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906302	09/2015	09/11/2015	99.980	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906303	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906304	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906305	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906306	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906307	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906308	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906309	09/2015	09/11/2015	100.020	99.950	100.1	1

LG&E	FOCUS AXR - MESH	906310	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906311	09/2015	09/11/2015	100.050	100.060	100.0	1
LG&E	FOCUS AXR - MESH	906312	09/2015	09/11/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906313	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906314	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906315	09/2015	09/11/2015	100.020	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906316	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906317	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906318	09/2015	09/11/2015	99.970	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906319	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906320	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906321	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906322	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906323	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906324	09/2015	09/11/2015	100.020	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906325	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906326	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906327	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906328	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906329	09/2015	09/11/2015	100.020	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906330	09/2015	09/11/2015	100.010	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906331	09/2015	09/11/2015	100.050	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906332	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906333	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906334	09/2015	09/11/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906335	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906336	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906337	09/2015	09/11/2015	99.990	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906338	09/2015	09/11/2015	100.010	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906339	09/2015	09/11/2015	99.980	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906340	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906341	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906342	09/2015	09/11/2015	100.010	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906343	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906344	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906345	09/2015	09/11/2015	99.980	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906346	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906347	09/2015	09/11/2015	100.060	100.040	100.1	1
LG&E	FOCUS AXR - MESH	906348	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906349	09/2015	09/11/2015	99.960	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906350	09/2015	09/11/2015	99.970	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906351	09/2015	09/11/2015	99.960	99.990	100.0	1

LG&E	FOCUS AXR - MESH	906352	09/2015	09/11/2015	100.030	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906353	09/2015	09/11/2015	99.980	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906354	09/2015	09/11/2015	99.990	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906355	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906356	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906357	09/2015	09/11/2015	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906358	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906359	09/2015	09/11/2015	100.000	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906360	09/2015	09/11/2015	99.960	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906361	09/2015	09/11/2015	100.000	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906362	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906363	09/2015	09/11/2015	100.020	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906364	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906365	09/2015	09/11/2015	99.970	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906366	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906367	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906368	09/2015	09/11/2015	100.010	100.050	100.0	1
LG&E	FOCUS AXR - MESH	906369	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906370	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906371	09/2015	09/11/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906372	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906373	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906374	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906375	09/2015	09/11/2015	99.970	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906376	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906377	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906378	09/2015	09/11/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906379	09/2015	09/11/2015	100.020	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906380	09/2015	09/11/2015	99.970	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906381	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906382	09/2015	09/11/2015	100.020	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906383	09/2015	09/11/2015	100.050	100.040	100.0	1
LG&E	FOCUS AXR - MESH	906384	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906385	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906386	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906387	09/2015	09/11/2015	100.020	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906388	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906389	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906390	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906391	09/2015	09/11/2015	99.980	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906392	09/2015	09/11/2015	100.000	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906393	09/2015	09/11/2015	100.010	99.990	100.1	1

LG&E	FOCUS AXR - MESH	906394	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906395	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906396	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906397	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906398	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906399	09/2015	09/11/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906400	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906401	09/2015	09/11/2015	100.050	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906402	09/2015	09/11/2015	99.980	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906403	09/2015	09/11/2015	100.030	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906404	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906405	09/2015	09/11/2015	99.990	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906406	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906407	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906408	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906409	09/2015	09/11/2015	99.970	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906410	09/2015	09/11/2015	100.010	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906411	09/2015	09/11/2015	100.060	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906412	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906413	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906414	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906415	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906416	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906417	09/2015	09/11/2015	99.960	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906418	09/2015	09/11/2015	99.960	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906419	09/2015	09/11/2015	100.020	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906420	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906421	09/2015	09/11/2015	100.040	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906422	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906423	09/2015	09/11/2015	99.970	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906424	09/2015	09/11/2015	100.010	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906425	09/2015	09/11/2015	99.980	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906426	09/2015	09/11/2015	99.990	100.020	99.9	1
LG&E	FOCUS AXR - MESH	906427	09/2015	09/11/2015	100.010	99.930	100.1	1
LG&E	FOCUS AXR - MESH	906428	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906429	09/2015	09/11/2015	100.010	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906430	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906431	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906432	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906433	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906434	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906435	09/2015	09/11/2015	100.010	99.940	100.1	1

LG&E	FOCUS AXR - MESH	906436	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906437	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906438	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906439	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906440	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906441	09/2015	09/11/2015	100.050	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906442	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906443	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906444	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906445	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906446	09/2015	09/11/2015	99.990	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906447	09/2015	09/11/2015	100.030	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906448	09/2015	09/11/2015	100.040	100.020	100.1	1
LG&E	FOCUS AXR - MESH	906449	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906450	09/2015	09/11/2015	100.020	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906451	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906452	09/2015	09/11/2015	100.010	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906453	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906454	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906455	09/2015	09/11/2015	99.960	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906456	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906457	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906458	09/2015	09/11/2015	99.970	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906459	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906460	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906461	09/2015	09/11/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906462	09/2015	09/11/2015	99.980	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906463	09/2015	09/11/2015	100.030	100.060	99.9	1
LG&E	FOCUS AXR - MESH	906464	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906465	09/2015	09/11/2015	99.980	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906466	09/2015	09/11/2015	100.030	100.060	100.0	1
LG&E	FOCUS AXR - MESH	906467	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906468	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906469	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906470	09/2015	09/11/2015	100.020	100.020	99.9	1
LG&E	FOCUS AXR - MESH	906471	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906472	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906473	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906474	09/2015	09/11/2015	100.000	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906475	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906476	09/2015	09/11/2015	99.970	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906477	09/2015	09/11/2015	99.990	99.930	100.0	1

LG&E	FOCUS AXR - MESH	906478	09/2015	09/11/2015	100.010	100.020	100.1	1
LG&E	FOCUS AXR - MESH	906479	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906480	09/2015	09/11/2015	100.010	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906481	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906482	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906483	09/2015	09/11/2015	99.980	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906484	09/2015	09/11/2015	100.020	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906485	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906486	09/2015	09/11/2015	100.000	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906487	09/2015	09/11/2015	100.000	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906488	09/2015	09/11/2015	100.000	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906489	09/2015	09/11/2015	100.010	100.050	100.0	1
LG&E	FOCUS AXR - MESH	906490	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906491	09/2015	09/11/2015	99.980	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906492	09/2015	09/11/2015	99.970	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906493	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906494	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906495	09/2015	09/11/2015	100.000	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906496	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906497	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906498	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906499	09/2015	09/11/2015	99.990	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906500	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906501	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906502	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906503	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906504	09/2015	09/11/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906505	09/2015	09/11/2015	100.010	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906506	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906507	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906508	09/2015	09/11/2015	100.000	99.910	100.1	1
LG&E	FOCUS AXR - MESH	906509	09/2015	09/11/2015	100.030	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906510	09/2015	09/11/2015	100.030	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906511	09/2015	09/11/2015	100.050	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906512	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906513	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906514	09/2015	09/11/2015	99.980	99.930	100.1	1
LG&E	FOCUS AXR - MESH	906515	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906516	09/2015	09/11/2015	100.010	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906517	09/2015	09/11/2015	99.970	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906518	09/2015	09/11/2015	100.030	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906519	09/2015	09/11/2015	100.030	99.960	100.0	1

LG&E	FOCUS AXR - MESH	906520	09/2015	09/11/2015	99.990	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906521	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906522	09/2015	09/11/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906523	09/2015	09/11/2015	99.980	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906524	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906525	09/2015	09/11/2015	99.970	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906526	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906527	09/2015	09/11/2015	100.010	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906528	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906529	09/2015	09/11/2015	99.990	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906530	09/2015	09/11/2015	100.000	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906531	09/2015	09/11/2015	99.970	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906532	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906533	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906534	09/2015	09/11/2015	100.030	100.060	100.0	1
LG&E	FOCUS AXR - MESH	906535	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906536	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906537	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906538	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906539	09/2015	09/11/2015	99.990	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906540	09/2015	09/11/2015	99.970	99.930	100.1	1
LG&E	FOCUS AXR - MESH	906541	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906542	09/2015	09/11/2015	99.990	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906543	09/2015	09/11/2015	100.000	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906544	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906545	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906546	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906547	09/2015	09/11/2015	99.990	99.910	100.1	1
LG&E	FOCUS AXR - MESH	906548	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906549	09/2015	09/11/2015	99.980	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906550	09/2015	09/11/2015	100.050	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906551	09/2015	09/11/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906552	09/2015	09/11/2015	100.010	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906553	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906554	09/2015	09/11/2015	99.980	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906555	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906556	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906557	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906558	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906559	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906560	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906561	09/2015	09/11/2015	99.980	99.990	99.9	1

LG&E	FOCUS AXR - MESH	906562	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906563	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906564	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906565	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906566	09/2015	09/11/2015	100.010	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906567	09/2015	09/11/2015	99.970	99.880	100.1	1
LG&E	FOCUS AXR - MESH	906568	09/2015	09/11/2015	100.020	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906569	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906570	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906571	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906572	09/2015	09/11/2015	100.020	100.050	100.0	1
LG&E	FOCUS AXR - MESH	906573	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906574	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906575	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906576	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906577	09/2015	09/11/2015	100.040	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906578	09/2015	09/11/2015	99.980	100.020	99.9	1
LG&E	FOCUS AXR - MESH	906579	09/2015	09/11/2015	99.970	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906580	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906581	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906582	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906583	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906584	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906585	09/2015	09/11/2015	100.040	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906586	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906587	09/2015	09/11/2015	100.020	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906588	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906589	09/2015	09/11/2015	99.980	99.930	99.9	1
LG&E	FOCUS AXR - MESH	906590	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906591	09/2015	09/11/2015	100.010	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906592	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906593	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906594	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906595	09/2015	09/11/2015	100.020	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906596	09/2015	09/11/2015	100.000	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906597	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906598	09/2015	09/11/2015	100.000	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906599	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906600	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906601	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906602	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906603	09/2015	09/11/2015	100.010	99.980	100.0	1

LG&E	FOCUS AXR - MESH	906604	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906605	09/2015	09/11/2015	100.020	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906606	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906607	09/2015	09/11/2015	100.030	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906608	09/2015	09/11/2015	100.020	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906609	09/2015	09/11/2015	100.010	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906610	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906611	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906612	09/2015	09/11/2015	100.030	100.050	99.9	1
LG&E	FOCUS AXR - MESH	906613	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906614	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906615	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906616	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906617	09/2015	09/11/2015	100.010	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906618	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906619	09/2015	09/11/2015	100.030	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906620	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906621	09/2015	09/11/2015	100.010	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906622	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906623	09/2015	09/11/2015	100.020	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906624	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906625	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906626	09/2015	09/11/2015	99.990	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906627	09/2015	09/11/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906628	09/2015	09/11/2015	100.020	100.040	100.1	1
LG&E	FOCUS AXR - MESH	906629	09/2015	09/11/2015	100.030	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906630	09/2015	09/11/2015	99.990	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906631	09/2015	09/11/2015	99.960	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906632	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906633	09/2015	09/11/2015	100.020	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906634	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906635	09/2015	09/11/2015	99.970	99.940	99.9	1
LG&E	FOCUS AXR - MESH	906636	09/2015	09/11/2015	100.010	100.020	99.9	1
LG&E	FOCUS AXR - MESH	906637	09/2015	09/11/2015	100.040	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906638	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906639	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906640	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906641	09/2015	09/11/2015	99.960	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906642	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906643	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906644	09/2015	09/11/2015	100.000	99.930	99.9	1
LG&E	FOCUS AXR - MESH	906645	09/2015	09/11/2015	99.990	99.970	100.0	1

LG&E	FOCUS AXR - MESH	906646	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906647	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906648	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906649	09/2015	09/11/2015	99.980	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906650	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906651	09/2015	09/11/2015	100.020	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906652	09/2015	09/11/2015	99.960	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906653	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906654	09/2015	09/11/2015	100.000	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906655	09/2015	09/11/2015	99.980	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906656	09/2015	09/11/2015	99.990	99.940	99.9	1
LG&E	FOCUS AXR - MESH	906657	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906658	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906659	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906660	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906661	09/2015	09/11/2015	99.990	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906662	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906663	09/2015	09/11/2015	100.030	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906664	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906665	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906666	09/2015	09/11/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906667	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906668	09/2015	09/11/2015	100.050	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906669	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906670	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906671	09/2015	09/11/2015	99.980	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906672	09/2015	09/11/2015	100.050	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906673	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906674	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906675	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906676	09/2015	09/11/2015	100.030	100.040	100.0	1
LG&E	FOCUS AXR - MESH	906677	09/2015	09/11/2015	100.020	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906678	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906679	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906680	09/2015	09/11/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906681	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906682	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906683	09/2015	09/11/2015	99.980	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906684	09/2015	09/11/2015	99.990	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906685	09/2015	09/11/2015	99.980	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906686	09/2015	09/11/2015	100.030	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906687	09/2015	09/11/2015	99.960	99.930	100.0	1

LG&E	FOCUS AXR - MESH	906688	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906689	09/2015	09/11/2015	100.020	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906690	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906691	09/2015	09/11/2015	99.970	99.880	100.0	1
LG&E	FOCUS AXR - MESH	906692	09/2015	09/11/2015	100.050	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906693	09/2015	09/11/2015	100.030	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906694	09/2015	09/11/2015	99.960	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906695	09/2015	09/11/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906696	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906697	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906698	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906699	09/2015	09/11/2015	100.020	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906700	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906701	09/2015	09/11/2015	100.030	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906702	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906703	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906704	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906705	09/2015	09/11/2015	100.060	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906706	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906707	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906708	09/2015	09/11/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906709	09/2015	09/11/2015	99.990	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906710	09/2015	09/11/2015	99.990	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906711	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906712	09/2015	09/11/2015	100.030	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906713	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906714	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906715	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906716	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906717	09/2015	09/11/2015	100.020	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906718	09/2015	09/11/2015	100.010	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906719	09/2015	09/11/2015	100.030	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906720	09/2015	09/11/2015	100.000	99.900	100.0	1
LG&E	FOCUS AXR - MESH	906721	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906722	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906723	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906724	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906725	09/2015	09/11/2015	100.000	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906726	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906727	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906728	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906729	09/2015	09/11/2015	99.960	99.930	100.0	1

LG&E	FOCUS AXR - MESH	906730	09/2015	09/11/2015	100.010	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906731	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906732	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906733	09/2015	09/11/2015	100.050	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906734	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906735	09/2015	09/11/2015	99.970	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906736	09/2015	09/11/2015	100.010	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906737	09/2015	09/11/2015	100.000	99.890	100.0	1
LG&E	FOCUS AXR - MESH	906738	09/2015	09/11/2015	100.010	100.050	99.9	1
LG&E	FOCUS AXR - MESH	906739	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906740	09/2015	09/11/2015	100.050	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906741	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906742	09/2015	09/11/2015	99.990	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906743	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906744	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906745	09/2015	09/11/2015	100.010	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906746	09/2015	09/11/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906747	09/2015	09/11/2015	100.040	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906748	09/2015	09/11/2015	100.020	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906749	09/2015	09/11/2015	99.980	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906750	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906751	09/2015	09/11/2015	100.000	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906752	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906753	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906754	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906755	09/2015	09/11/2015	100.060	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906756	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906757	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906758	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906759	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906760	09/2015	09/11/2015	99.980	99.940	99.9	1
LG&E	FOCUS AXR - MESH	906761	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906762	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906763	09/2015	09/11/2015	99.990	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906764	09/2015	09/11/2015	100.020	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906765	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906766	09/2015	09/11/2018	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906767	09/2015	09/11/2015	99.990	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906768	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906769	09/2015	09/11/2015	100.040	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906770	09/2015	09/11/2015	99.960	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906771	09/2015	09/11/2015	100.040	99.970	100.1	1

LG&E	FOCUS AXR - MESH	906772	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906773	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906774	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906775	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906776	09/2015	09/11/2015	99.990	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906777	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906778	09/2015	09/11/2015	100.030	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906779	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906780	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906781	09/2015	09/11/2015	99.960	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906782	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906783	09/2015	09/11/2015	99.950	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906784	09/2015	09/11/2015	100.020	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906785	09/2015	09/11/2015	99.980	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906786	09/2015	09/11/2015	99.970	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906787	09/2015	09/11/2015	100.020	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906788	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906789	09/2015	09/11/2015	100.020	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906790	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906791	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906792	09/2015	09/11/2015	99.970	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906793	09/2015	09/11/2015	100.030	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906794	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906795	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906796	09/2015	09/11/2015	100.010	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906797	09/2015	09/11/2015	100.020	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906798	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906799	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906800	09/2015	09/11/2015	99.990	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906801	09/2015	09/11/2015	99.960	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906802	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906803	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906804	09/2015	09/11/2015	100.010	99.940	99.9	1
LG&E	FOCUS AXR - MESH	906805	09/2015	09/11/2015	100.010	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906806	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906807	09/2015	09/11/2015	99.990	100.010	99.9	1
LG&E	FOCUS AXR - MESH	906808	09/2015	09/11/2015	100.010	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906809	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906810	09/2015	09/11/2015	99.970	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906811	09/2015	09/11/2015	99.960	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906812	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906813	09/2015	09/11/2015	100.000	99.980	100.0	1

LG&E	FOCUS AXR - MESH	906814	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906815	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906816	09/2015	09/11/2015	99.980	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906817	09/2015	09/11/2015	100.030	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906818	09/2015	09/11/2015	100.030	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906819	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906820	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906821	09/2015	09/11/2015	99.990	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906822	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906823	09/2015	09/11/2015	100.000	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906824	09/2015	09/11/2015	100.060	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906825	09/2015	09/11/2015	99.960	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906826	09/2015	09/11/2015	100.030	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906827	09/2015	09/11/2015	99.980	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906828	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906829	09/2015	09/11/2015	99.970	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906830	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906831	09/2015	09/11/2015	99.990	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906832	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906833	09/2015	09/11/2015	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906834	09/2015	09/11/2015	100.030	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906835	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906836	09/2015	09/11/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906837	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906838	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906839	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906840	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906841	09/2015	09/11/2015	100.030	99.920	100.1	1
LG&E	FOCUS AXR - MESH	906842	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906843	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906844	09/2015	09/11/2015	99.990	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906845	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906846	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906847	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906848	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906849	09/2015	09/11/2015	100.030	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906850	09/2015	09/11/2015	100.040	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906851	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906852	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906853	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906854	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906855	09/2015	09/11/2015	99.990	99.970	100.0	1

LG&E	FOCUS AXR - MESH	906856	09/2015	09/11/2015	100.010	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906857	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906858	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906859	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906860	09/2015	09/11/2015	100.020	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906861	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906862	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906863	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906864	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906865	09/2015	09/11/2015	100.040	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906866	09/2015	09/11/2015	100.010	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906867	09/2015	09/11/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906868	09/2015	09/11/2015	99.960	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906869	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906870	09/2015	09/11/2015	99.950	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906871	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906872	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906873	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906874	09/2015	09/11/2015	100.020	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906875	09/2015	09/11/2015	100.030	100.040	100.0	1
LG&E	FOCUS AXR - MESH	906876	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	906877	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906878	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906879	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906880	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906881	09/2015	09/11/2015	99.970	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906882	09/2015	09/11/2015	100.010	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906883	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906884	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906885	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906886	09/2015	09/11/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906887	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906888	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906889	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906890	09/2015	09/11/2015	99.970	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906891	09/2015	09/11/2015	100.030	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906892	09/2015	09/11/2015	100.000	99.990	99.9	1
LG&E	FOCUS AXR - MESH	906893	09/2015	09/11/2015	99.970	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906894	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906895	09/2015	09/11/2015	100.000	99.940	99.9	1
LG&E	FOCUS AXR - MESH	906896	09/2015	09/11/2015	100.030	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906897	09/2015	09/11/2015	99.970	99.960	99.9	1

LG&E	FOCUS AXR - MESH	906898	09/2015	09/11/2015	99.980	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906899	09/2015	09/11/2015	100.030	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906900	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906901	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906902	09/2015	09/11/2015	99.980	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906903	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906904	09/2015	09/11/2015	100.020	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906905	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906906	09/2015	09/11/2015	99.980	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906907	09/2015	09/11/2015	99.970	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906908	09/2015	09/11/2015	99.970	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906909	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	906910	09/2015	09/11/2015	99.980	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906911	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906912	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906913	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906914	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906915	09/2015	09/11/2015	100.040	100.030	99.9	1
LG&E	FOCUS AXR - MESH	906916	09/2015	09/11/2015	100.050	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906917	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906918	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906919	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906920	09/2015	09/11/2015	99.960	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906921	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906922	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906923	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906924	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906925	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906926	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906927	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906928	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906929	09/2015	09/11/2015	100.030	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906930	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906931	09/2015	09/11/2015	99.970	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906932	09/2015	09/11/2015	100.030	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906933	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906934	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906935	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906936	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906937	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906938	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	906939	09/2015	09/11/2015	100.000	99.960	100.0	1

LG&E	FOCUS AXR - MESH	906940	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906941	09/2015	09/11/2015	99.980	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906942	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906943	09/2015	09/11/2015	99.990	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906944	09/2015	09/11/2015	99.970	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906945	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906946	09/2015	09/11/2015	100.030	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906947	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906948	09/2015	09/11/2015	99.960	99.910	100.0	1
LG&E	FOCUS AXR - MESH	906949	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906950	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906951	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906952	09/2015	09/11/2015	100.040	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906953	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906954	09/2015	09/11/2015	99.980	99.940	100.1	1
LG&E	FOCUS AXR - MESH	906955	09/2015	09/11/2015	100.030	99.960	99.9	1
LG&E	FOCUS AXR - MESH	906956	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906957	09/2015	09/11/2015	99.970	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906958	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906959	09/2015	09/11/2015	99.990	99.950	99.9	1
LG&E	FOCUS AXR - MESH	906960	09/2015	09/11/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	906961	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906962	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906963	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906964	09/2015	09/11/2015	100.000	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906965	09/2015	09/11/2015	100.020	100.000	99.9	1
LG&E	FOCUS AXR - MESH	906966	09/2015	09/11/2015	100.040	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906967	09/2015	09/11/2015	100.010	99.920	100.0	1
LG&E	FOCUS AXR - MESH	906968	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906969	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	906970	09/2015	09/11/2015	99.990	99.900	100.1	1
LG&E	FOCUS AXR - MESH	906971	09/2015	09/11/2015	100.010	99.970	100.1	1
LG&E	FOCUS AXR - MESH	906972	09/2015	09/11/2015	100.040	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906973	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906974	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906975	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906976	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906977	09/2015	09/11/2015	100.030	99.980	100.1	1
LG&E	FOCUS AXR - MESH	906978	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	906979	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906980	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906981	09/2015	09/11/2015	100.040	100.020	100.0	1

LG&E	FOCUS AXR - MESH	906982	09/2015	09/11/2015	99.960	99.960	100.0	1
LG&E	FOCUS AXR - MESH	906983	09/2015	09/11/2015	100.000	99.930	100.1	1
LG&E	FOCUS AXR - MESH	906984	09/2015	09/11/2015	100.030	99.950	100.1	1
LG&E	FOCUS AXR - MESH	906985	09/2015	09/11/2015	100.030	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906986	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906987	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	906988	09/2015	09/11/2015	100.000	99.980	99.9	1
LG&E	FOCUS AXR - MESH	906989	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	906990	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906991	09/2015	09/11/2015	100.030	99.960	100.1	1
LG&E	FOCUS AXR - MESH	906992	09/2015	09/11/2015	100.010	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906993	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	906994	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	906995	09/2015	09/11/2015	100.040	100.010	100.1	1
LG&E	FOCUS AXR - MESH	906996	09/2015	09/11/2015	100.030	100.000	100.1	1
LG&E	FOCUS AXR - MESH	906997	09/2015	09/11/2015	100.030	100.010	100.0	1
LG&E	FOCUS AXR - MESH	906998	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	906999	09/2015	09/11/2015	99.960	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907000	09/2015	09/11/2015	100.040	100.020	99.9	1
LG&E	FOCUS AXR - MESH	907001	09/2015	09/11/2015	100.030	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907002	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907003	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907004	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907005	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907006	09/2015	09/11/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907007	09/2015	09/11/2015	100.020	100.050	100.0	1
LG&E	FOCUS AXR - MESH	907008	09/2015	09/11/2015	100.050	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907009	09/2015	09/11/2015	99.990	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907010	09/2015	09/11/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907011	09/2015	09/11/2015	99.980	99.950	99.9	1
LG&E	FOCUS AXR - MESH	907012	09/2015	09/11/2015	100.040	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907013	09/2015	09/11/2015	100.030	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907014	09/2015	09/11/2015	99.990	99.910	100.0	1
LG&E	FOCUS AXR - MESH	907015	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907016	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907017	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907018	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907019	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907020	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907021	09/2015	09/11/2015	100.020	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907022	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907023	09/2015	09/11/2015	100.000	99.990	100.0	1

LG&E	FOCUS AXR - MESH	907024	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907025	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907026	09/2015	09/11/2015	100.000	100.020	100.1	1
LG&E	FOCUS AXR - MESH	907027	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907028	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907029	09/2015	09/11/2015	100.010	100.010	100.1	1
LG&E	FOCUS AXR - MESH	907030	09/2015	09/11/2015	100.030	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907031	09/2015	09/11/2015	100.020	100.040	99.9	1
LG&E	FOCUS AXR - MESH	907032	09/2015	09/11/2015	99.970	99.950	99.9	1
LG&E	FOCUS AXR - MESH	907033	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907034	09/2015	09/11/2015	100.050	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907035	09/2015	09/11/2015	100.030	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907036	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907037	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907038	09/2015	09/11/2015	100.040	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907039	09/2015	09/11/2015	99.970	99.990	99.9	1
LG&E	FOCUS AXR - MESH	907040	09/2015	09/11/2015	100.000	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907041	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907042	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907043	09/2015	09/11/2015	100.050	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907044	09/2015	09/11/2015	99.990	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907045	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907046	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907047	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907048	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907049	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907050	09/2015	09/11/2015	100.030	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907051	09/2015	09/11/2015	99.990	100.000	99.9	1
LG&E	FOCUS AXR - MESH	907052	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907053	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907054	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907055	09/2015	09/11/2015	100.000	100.050	100.0	1
LG&E	FOCUS AXR - MESH	907056	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907057	09/2015	09/11/2015	100.000	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907058	09/2015	09/11/2015	100.050	99.980	100.2	1
LG&E	FOCUS AXR - MESH	907059	09/2015	09/11/2015	100.010	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907060	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907061	09/2015	09/11/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907062	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907063	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907064	09/2015	09/11/2015	100.000	99.930	100.1	1
LG&E	FOCUS AXR - MESH	907065	09/2015	09/11/2015	100.040	99.990	100.1	1

LG&E	FOCUS AXR - MESH	907066	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907067	09/2015	09/11/2015	100.050	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907068	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907069	09/2015	09/11/2015	100.010	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907070	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907071	09/2015	09/11/2015	100.040	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907072	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907073	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907074	09/2015	09/11/2015	100.010	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907075	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907076	09/2015	09/11/2015	99.980	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907077	09/2015	09/11/2015	100.000	99.910	100.1	1
LG&E	FOCUS AXR - MESH	907078	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907079	09/2015	09/11/2015	100.040	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907080	09/2015	09/11/2015	100.030	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907081	09/2015	09/11/2015	100.010	100.020	99.9	1
LG&E	FOCUS AXR - MESH	907082	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907083	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907084	09/2015	09/11/2015	100.000	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907085	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907086	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907087	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907088	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907089	09/2015	09/11/2015	99.990	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907090	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907091	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907092	09/2015	09/11/2015	99.980	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907093	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907094	09/2015	09/11/2015	99.990	99.930	100.1	1
LG&E	FOCUS AXR - MESH	907095	09/2015	09/11/2015	100.050	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907096	09/2015	09/11/2015	100.040	100.000	100.1	1
LG&E	FOCUS AXR - MESH	907097	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907098	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907099	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907100	09/2015	09/11/2015	100.040	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907101	09/2015	09/11/2015	99.960	99.960	99.9	1
LG&E	FOCUS AXR - MESH	907102	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907103	09/2015	09/11/2015	100.040	99.930	100.1	1
LG&E	FOCUS AXR - MESH	907104	09/2015	09/11/2015	99.970	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907105	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907106	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907107	09/2015	09/11/2015	100.010	100.020	100.0	1

LG&E	FOCUS AXR - MESH	907108	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907109	09/2015	09/11/2015	99.990	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907110	09/2015	09/11/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907111	09/2015	09/11/2015	100.020	100.010	100.1	1
LG&E	FOCUS AXR - MESH	907112	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907113	09/2015	09/11/2015	100.030	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907114	09/2015	09/11/2015	100.040	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907115	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907116	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907117	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907118	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907119	09/2015	09/11/2015	100.020	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907120	09/2015	09/11/2015	100.010	100.040	100.0	1
LG&E	FOCUS AXR - MESH	907121	09/2015	09/11/2015	100.030	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907122	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907123	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907124	09/2015	09/11/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907125	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907126	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907127	09/2015	09/11/2015	100.010	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907128	09/2015	09/11/2015	100.010	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907129	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907130	09/2015	09/11/2015	99.990	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907131	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907132	09/2015	09/11/2015	99.990	99.910	100.1	1
LG&E	FOCUS AXR - MESH	907133	09/2015	09/11/2015	100.000	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907134	09/2015	09/11/2015	99.990	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907135	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907136	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907137	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907138	09/2015	09/11/2015	99.970	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907139	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907140	09/2015	09/11/2015	99.970	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907141	09/2015	09/11/2015	100.020	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907142	09/2015	09/11/2015	99.980	100.010	99.9	1
LG&E	FOCUS AXR - MESH	907143	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907144	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907145	09/2015	09/11/2015	100.040	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907146	09/2015	09/11/2015	100.040	100.000	99.9	1
LG&E	FOCUS AXR - MESH	907147	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907148	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907149	09/2015	09/11/2015	99.990	99.960	99.9	1

LG&E	FOCUS AXR - MESH	907150	09/2015	09/11/2015	100.020	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907151	09/2015	09/11/2015	100.040	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907152	09/2015	09/11/2015	99.970	99.940	99.9	1
LG&E	FOCUS AXR - MESH	907153	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907154	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907155	09/2015	09/11/2015	100.050	100.030	99.9	1
LG&E	FOCUS AXR - MESH	907156	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907157	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907158	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907159	09/2015	09/11/2015	100.030	100.000	100.1	1
LG&E	FOCUS AXR - MESH	907160	09/2015	09/11/2015	99.970	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907161	09/2015	09/11/2015	99.960	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907162	09/2015	09/11/2015	100.040	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907163	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907164	09/2015	09/11/2015	100.000	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907165	09/2015	09/11/2015	100.030	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907166	09/2015	09/11/2015	100.000	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907167	09/2015	09/11/2015	100.030	100.040	100.0	1
LG&E	FOCUS AXR - MESH	907168	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907169	09/2015	09/11/2015	99.970	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907170	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907171	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907172	09/2015	09/11/2015	100.040	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907173	09/2015	09/11/2015	99.960	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907174	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907175	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907176	09/2015	09/11/2015	100.040	99.940	99.9	1
LG&E	FOCUS AXR - MESH	907177	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907178	09/2015	09/11/2015	99.980	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907179	09/2015	09/11/2015	100.010	99.910	100.0	1
LG&E	FOCUS AXR - MESH	907180	09/2015	09/11/2015	99.960	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907181	09/2015	09/11/2015	99.970	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907182	09/2015	09/11/2015	99.980	99.950	99.9	1
LG&E	FOCUS AXR - MESH	907183	09/2015	09/11/2015	99.990	100.000	100.2	1
LG&E	FOCUS AXR - MESH	907184	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907185	09/2015	09/11/2015	100.010	99.950	99.9	1
LG&E	FOCUS AXR - MESH	907186	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907187	09/2015	09/11/2015	100.020	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907188	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907189	09/2015	09/11/2015	100.030	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907190	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907191	09/2015	09/11/2015	100.000	100.000	100.0	1

LG&E	FOCUS AXR - MESH	907192	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907193	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907194	09/2015	09/11/2015	99.980	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907195	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907196	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907197	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907198	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907199	09/2015	09/11/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907200	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907201	09/2015	09/11/2015	99.990	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907202	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907203	09/2015	09/11/2015	100.020	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907204	09/2015	09/11/2015	100.020	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907205	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907206	09/2015	09/11/2015	99.990	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907207	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907208	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907209	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907210	09/2015	09/11/2015	99.980	99.990	99.9	1
LG&E	FOCUS AXR - MESH	907211	09/2015	09/11/2015	99.970	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907212	09/2015	09/11/2015	99.980	99.970	99.9	1
LG&E	FOCUS AXR - MESH	907213	09/2015	09/11/2015	100.000	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907214	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907215	09/2015	09/11/2015	100.000	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907216	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907217	09/2015	09/11/2015	100.000	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907218	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907219	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907220	09/2015	09/11/2015	99.990	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907221	09/2015	09/11/2015	100.000	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907222	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907223	09/2015	09/11/2015	100.030	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907224	09/2015	09/11/2015	100.010	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907225	09/2015	09/11/2015	100.010	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907226	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907227	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907228	09/2015	09/11/2015	100.000	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907229	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907230	09/2015	09/11/2015	99.990	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907231	09/2015	09/11/2015	100.010	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907232	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907233	09/2015	09/11/2015	99.970	99.980	100.0	1

LG&E	FOCUS AXR - MESH	907234	09/2015	09/11/2015	100.020	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907235	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907236	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907237	09/2015	09/11/2015	99.980	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907238	09/2015	09/11/2015	100.010	100.020	99.9	1
LG&E	FOCUS AXR - MESH	907239	09/2015	09/11/2015	99.980	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907240	09/2015	09/11/2015	99.980	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907241	09/2015	09/11/2015	99.980	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907242	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907243	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907244	09/2015	09/11/2015	100.010	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907245	09/2015	09/11/2015	99.960	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907246	09/2015	09/11/2015	100.050	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907247	09/2015	09/11/2015	100.000	99.910	100.0	1
LG&E	FOCUS AXR - MESH	907248	09/2015	09/11/2015	99.980	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907249	09/2015	09/11/2015	100.000	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907250	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907251	09/2015	09/11/2015	99.980	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907252	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907253	09/2015	09/11/2015	99.970	99.920	100.0	1
LG&E	FOCUS AXR - MESH	907254	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907255	09/2015	09/11/2015	100.050	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907256	09/2015	09/11/2015	100.000	100.010	99.9	1
LG&E	FOCUS AXR - MESH	907257	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907258	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907259	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907260	09/2015	09/11/2015	100.050	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907261	09/2015	09/11/2015	99.960	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907262	09/2015	09/11/2015	100.030	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907263	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907264	09/2015	09/11/2015	100.000	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907265	09/2015	09/11/2015	100.000	99.990	99.9	1
LG&E	FOCUS AXR - MESH	907266	09/2015	09/11/2015	99.980	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907267	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907268	09/2015	09/11/2015	100.000	99.910	100.0	1
LG&E	FOCUS AXR - MESH	907269	09/2015	09/11/2015	99.970	99.990	99.9	1
LG&E	FOCUS AXR - MESH	907270	09/2015	09/11/2015	99.970	99.910	100.1	1
LG&E	FOCUS AXR - MESH	907271	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907272	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907273	09/2015	09/11/2015	100.040	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907274	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907275	09/2015	09/11/2015	99.980	99.990	100.0	1

LG&E	FOCUS AXR - MESH	907276	09/2015	09/11/2015	100.050	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907277	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907278	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907279	09/2015	09/11/2015	100.000	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907280	09/2015	09/11/2015	100.000	100.040	100.0	1
LG&E	FOCUS AXR - MESH	907281	09/2015	09/11/2015	100.000	100.020	100.1	1
LG&E	FOCUS AXR - MESH	907282	09/2015	09/11/2015	100.000	99.940	99.9	1
LG&E	FOCUS AXR - MESH	907283	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907284	09/2015	09/11/2015	99.970	99.900	100.0	1
LG&E	FOCUS AXR - MESH	907285	09/2015	09/11/2015	100.020	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907286	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907287	09/2015	09/11/2015	100.030	100.010	99.9	1
LG&E	FOCUS AXR - MESH	907288	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907289	09/2015	09/11/2015	100.020	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907290	09/2015	09/11/2015	100.020	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907291	09/2015	09/11/2015	100.020	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907292	09/2015	09/11/2015	100.030	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907293	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907294	09/2015	09/11/2015	99.980	99.920	100.1	1
LG&E	FOCUS AXR - MESH	907295	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907296	09/2015	09/11/2015	100.010	99.950	99.9	1
LG&E	FOCUS AXR - MESH	907297	09/2015	09/11/2015	99.990	99.970	100.1	1
LG&E	FOCUS AXR - MESH	907298	09/2015	09/11/2015	100.000	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907299	09/2015	09/11/2015	100.020	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907300	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907301	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907302	09/2015	09/11/2015	99.990	99.920	100.1	1
LG&E	FOCUS AXR - MESH	907303	09/2015	09/11/2015	99.980	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907304	09/2015	09/11/2015	99.990	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907305	09/2015	09/11/2015	100.040	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907306	09/2015	09/11/2015	99.960	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907307	09/2015	09/11/2015	100.000	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907308	09/2015	09/11/2015	100.010	100.020	100.0	1
LG&E	FOCUS AXR - MESH	907309	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907310	09/2015	09/11/2015	99.970	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907311	09/2015	09/11/2015	99.980	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907312	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907313	09/2015	09/11/2015	100.000	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907314	09/2015	09/11/2015	100.020	99.940	100.0	1
LG&E	FOCUS AXR - MESH	907315	09/2015	09/11/2015	100.010	99.920	100.1	1
LG&E	FOCUS AXR - MESH	907316	09/2015	09/11/2015	100.040	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907317	09/2015	09/11/2015	99.970	99.960	100.0	1

LG&E	FOCUS AXR - MESH	907318	09/2015	09/11/2015	100.040	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907319	09/2015	09/11/2015	100.010	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907320	09/2015	09/11/2015	100.010	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907321	09/2015	09/11/2015	100.050	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907322	09/2015	09/11/2015	100.020	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907323	09/2015	09/11/2015	99.970	99.980	99.9	1
LG&E	FOCUS AXR - MESH	907324	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907325	09/2015	09/11/2015	100.020	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907326	09/2015	09/11/2015	100.000	99.940	100.1	1
LG&E	FOCUS AXR - MESH	907327	09/2015	09/11/2015	99.990	100.000	100.1	1
LG&E	FOCUS AXR - MESH	907328	09/2015	09/11/2015	100.010	100.010	100.0	1
LG&E	FOCUS AXR - MESH	907329	09/2015	09/11/2015	99.980	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907330	09/2015	09/11/2015	100.050	100.020	99.9	1
LG&E	FOCUS AXR - MESH	907331	09/2015	09/11/2015	100.030	99.990	99.9	1
LG&E	FOCUS AXR - MESH	907332	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907333	09/2015	09/11/2015	100.010	99.960	99.9	1
LG&E	FOCUS AXR - MESH	907334	09/2015	09/11/2015	100.010	100.000	99.9	1
LG&E	FOCUS AXR - MESH	907335	09/2015	09/11/2015	100.020	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907336	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907337	09/2015	09/11/2015	100.050	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907338	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907339	09/2015	09/11/2015	100.020	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907340	09/2015	09/11/2015	99.970	99.980	100.0	1
LG&E	FOCUS AXR - MESH	907341	09/2015	09/11/2015	100.000	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907342	09/2015	09/11/2015	99.990	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907343	09/2015	09/11/2015	100.040	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907344	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907345	09/2015	09/11/2015	99.980	99.960	100.1	1
LG&E	FOCUS AXR - MESH	907346	09/2015	09/11/2015	100.020	99.980	100.1	1
LG&E	FOCUS AXR - MESH	907347	09/2015	09/11/2015	100.010	99.990	100.0	1
LG&E	FOCUS AXR - MESH	907348	09/2015	09/11/2015	99.980	99.930	100.0	1
LG&E	FOCUS AXR - MESH	907349	09/2015	09/11/2015	100.020	99.910	100.1	1
LG&E	FOCUS AXR - MESH	907350	09/2015	09/11/2015	99.990	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907351	09/2015	09/11/2015	100.030	99.950	100.1	1
LG&E	FOCUS AXR - MESH	907352	09/2015	09/11/2015	100.010	99.970	100.0	1
LG&E	FOCUS AXR - MESH	907353	09/2015	09/11/2015	100.010	99.960	100.0	1
LG&E	FOCUS AXR - MESH	907354	09/2015	09/11/2015	100.050	100.030	100.0	1
LG&E	FOCUS AXR - MESH	907355	09/2015	09/11/2015	99.990	99.950	100.0	1
LG&E	FOCUS AXR - MESH	907356	09/2015	09/11/2015	100.020	99.990	100.1	1
LG&E	FOCUS AXR - MESH	907357	09/2015	09/11/2015	100.030	100.000	100.0	1
LG&E	FOCUS AXR - MESH	907358	09/2015	09/11/2015	100.020	100.040	99.9	1
LG&E	FOCUS AXR - MESH	907359	09/2015	09/11/2015	100.030	99.960	100.1	1

ATTACHMENT
B

Sampling Test Results

LG&E
2015 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE		
In-Service Population	386,829	Divided into 50 Lots
Sample Quantity	3,335	
Meters Tested	3,335	
Meters Not Tested	0	
Failed Lots	1	AB1
Failed Lot Meters	142	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1573 Lot Descr: LG&E AB1-1
 In Service Population: 142 Sample Quantity: 10 Meters Tested: 10 Pass/ Fail: FAIL

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
725079	99.50	725127	96.37	725221	99.50	725222	99.70	725306	99.70
725318	99.50	725376	99.90	725384	99.90	725567	99.80	725690	98.53

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	10
2 Sum of Measurements: (Sum X)	992.40
3 Sum of Squared Measurements	98496.33
4 Correction Factor (CF): Sum of Measurements Squared / N	98485.78
5 Corrected Sum of Squares (SS)	10.55
6 Variance (V) : SS/(N-1)	1.1724
7 Estimate of Lot Standard Deviation(S): SQRT of V	1.0828
8 Sample Mean(XBAR): Sum X/N	99.24
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	2.55
12 Quality Index Lower (QL): (XBAR-L) / S	1.15
13 Estimate of Lot Percent NCF Above U (PU)	0.02
14 Estimate of Lot Percent NCF Below L (PL)	12.34
15 Total Estimate Percent NCF. In Lot (P): PU+PL	12.36
16 Maximum Allowable Percent NCF(M)	7.26
17 Acceptability Criterion: Compare P with M	FAIL
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)
 Device Category: F2S240V30AC200E Model Number: ALF (Trilliant) Division: 01 Sample Lot: 1574 Lot Descr: LG&E ALF-1
 In Service Population: 667 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 2
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
554379	100.00	833539	100.00	833567	100.00	833667	100.00	833703	100.10
833726	100.10	833860	100.00	833896	99.96	834105	100.00	834225	100.00
834309	99.90	834337	100.00	834354	99.96	834366	100.20	834400	100.10
834450	100.00	834499	99.90	834509	100.00	834638	100.00	834681	100.00
834722	99.90	834756	100.00	834822	100.00	834864	100.00	834895	99.99
834900	100.00	834949	99.96	835110	99.90	863300	100.00	863343	100.00
863359	100.00	863395	100.00	863397	99.87	863406	99.85	863415	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3499.59
3 Sum of Squared Measurements	349918.16
4 Correction Factor (CF): Sum of Measurements Squared / N	349918.00
5 Corrected Sum of Squares (SS)	0.16
6 Variance (V) : SS/(N-1)	0.0047
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0685
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	29.37
12 Quality Index Lower (QL): (XBAR-L) / S	29.03
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1SR (ERT) Division: 01 Sample Lot: 1575 Lot Descr: LG&E C1S-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
739823	100.10	754262	100.20	754467	100.10	754482	100.10	754501	100.13
755041	100.10	755426	100.10	755809	100.10	755822	100.00	756185	100.10
756276	99.90	766254	100.20	766772	100.20	766825	100.10	766835	100.20
766896	100.10	767181	100.10	767214	100.10	776420	100.21	777079	100.20
777247	100.20	777423	100.20	777445	100.00	777502	100.10	777523	100.20
777678	100.20	777697	100.20	777818	100.10	777829	100.10	778140	100.10
778200	100.20	778575	100.18	778818	100.20	779327	100.20	779519	100.20
779684	100.20	793805	100.00	793828	100.10	794057	100.00	794408	100.00
794865	100.10	794906	100.20	794988	100.00	795081	100.20	795173	100.10
795244	100.00	795399	100.10	795455	99.99	795673	100.00	795804	100.00
795992	100.00	796001	100.00	796024	100.00	796214	100.10	796309	100.10
796460	100.20	796527	100.20	796615	100.00	796719	100.10	797335	100.10
797349	100.10	797490	100.20	797599	100.30	797819	100.10	797875	100.20
798093	100.10	798137	99.80	798212	100.10	798310	100.10	798392	100.10
798393	100.10	798564	100.00	798702	100.10	798733	100.15	798914	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.16
3 Sum of Squared Measurements	751633.45
4 Correction Factor (CF): Sum of Measurements Squared / N	751632.89
5 Corrected Sum of Squares (SS)	0.56
6 Variance (V) : SS/(N-1)	0.0075
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0869
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	21.78
12 Quality Index Lower (QL): (XBAR-L) / S	24.28
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 1576 Lot Descr: LG&E C1S-2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
799285	100.10	799297	100.00	799376	100.10	799450	100.00	799457	100.10
799500	100.20	799724	100.10	808798	100.10	809046	100.00	809056	100.20
809331	100.20	809382	100.10	843450	100.10	843543	100.00	843773	100.10
844158	100.00	844348	99.90	844412	100.10	844430	99.90	845126	100.10
845179	100.00	845284	100.10	845375	100.00	845383	100.10	845440	100.10
845590	99.90	845740	100.08	845778	99.90	845935	100.00	846065	99.90
846085	99.70	846184	99.91	846295	99.90	846317	100.20	846369	100.00
846641	100.10	846758	100.10	846842	100.00	847846	99.90	848071	99.90
848183	100.10	848227	100.00	848519	100.12	848569	100.10	848647	100.00
849063	99.90	849065	100.10	849714	100.20	849872	100.10	849882	100.00
849887	100.00	849978	100.10	850007	100.20	850110	100.10	850363	100.10
850614	100.10	850696	100.00	850712	100.10	850803	100.00	850925	100.00
850978	100.10	851055	100.00	851215	100.10	851494	100.00	852298	100.00
852336	100.00	852434	100.00	853002	99.80	853037	99.90	854389	100.00
854569	100.20	854625	99.90	854791	100.10	854992	99.90	855046	100.20

INFORMATION NEEDED	VALUE OBTAINED.
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.71
3 Sum of Squared Measurements	750542.87
4 Correction Factor (CF): Sum of Measurements Squared / N	750542.10
5 Corrected Sum of Squares (SS)	0.77
6 Variance (V) : SS/(N-1)	0.0104
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1021
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	19.24
12 Quality Index Lower (QL): (XBAR-L) / S	19.95
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 1577 Lot Descr: LG&E CIS-3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
855448	100.30	856280	100.20	856434	100.00	856705	100.00	856739	100.10
856867	100.00	856963	99.90	857177	100.00	857245	100.00	857366	100.00
857440	100.00	857472	100.00	857709	99.90	857925	100.10	858115	100.03
858348	99.90	858434	100.10	858448	99.90	858515	99.90	858523	99.83
858544	100.10	858623	100.00	858688	100.00	858720	100.00	858727	100.00
859681	100.00	860039	100.00	860249	100.00	860274	100.20	860292	100.00
860319	99.80	860435	99.90	860656	100.00	861093	99.98	861344	100.10
861909	99.99	862111	100.01	862114	100.00	862228	99.90	862407	99.90
862441	100.10	862611	100.00	862715	100.00	862750	99.90	862831	100.10
863813	100.20	863904	100.00	863957	99.90	864366	100.00	865663	100.00
865664	100.00	865733	100.10	865776	100.10	865807	100.00	865910	99.90
865915	100.00	865983	99.96	866194	100.10	866247	99.90	866284	100.10
866395	100.00	866443	99.80	866846	100.20	866916	100.00	866980	100.10
867104	100.00	867262	100.00	867314	100.10	868407	100.10	868666	100.10
868718	100.10	870382	100.00	870421	100.10	870562	100.10	870577	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.00
3 Sum of Squared Measurements	750200.67
4 Correction Factor (CF): Sum of Measurements Squared / N	750200.01
5 Corrected Sum of Squares (SS)	0.66
6 Variance (V) : SS/(N-1)	0.0089
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0943
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	21.06
12 Quality Index Lower (QL): (XBAR-L) / S	21.34
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 1578 Lot Descr: LG&E CIS-4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC 21.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
870909	100.10	870923	100.20	871095	100.00	871122	100.10	871136	100.10
871187	100.10	871196	100.00	871459	100.00	871603	100.00	871774	100.00
871822	100.10	871904	100.00	871953	99.90	872087	99.90	872131	100.10
873428	99.90	873448	100.00	873485	100.00	873782	100.10	874004	100.00
874037	100.20	874267	100.00	874303	100.10	874390	100.00	874511	99.90
875036	100.00	876621	99.90	876762	100.00	876921	100.00	877136	100.00
877160	100.00	877216	100.10	877632	100.01	877714	99.70	877825	100.14
878136	100.00	878158	100.10	878402	100.00	878433	100.00	878841	100.00
878890	100.10	878923	100.10	879083	100.00	879310	100.10	879340	99.97
879468	99.90	879682	100.00	879705	99.90	880184	100.00	880315	100.10
880317	100.10	881749	100.00	881914	100.10	881948	99.80	881972	100.00
882085	99.90	882152	99.80	882209	100.10	882929	100.00	882979	100.00
883293	100.00	883761	100.00	883804	100.00	883840	100.00	883868	100.01
883955	100.00	883969	100.00	883975	99.90	884048	100.00	884069	100.10
884179	100.00	884342	100.10	884633	99.90	884748	100.10	884753	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.73
3 Sum of Squared Measurements	750146.58
4 Correction Factor (CF): Sum of Measurements Squared / N	750146.01
5 Corrected Sum of Squares (SS)	0.57
6 Variance (V) : SS/(N-1)	0.0078
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0880
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	22.61
12 Quality Index Lower (QL): (XBAR-L) / S	22.83
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S24OV30AC200E Model Number: CIS Division: 01 Sample Lot: 1579 Lot Descr: LG&E CIS-5
 In Service Population: 3,807 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
884898	99.90	885662	100.00	885668	100.00	885743	100.00	885800	100.00
885836	100.00	885873	100.00	885881	100.10	885897	100.00	885974	100.00
886014	100.04	886017	100.10	886195	100.00	886311	100.10	886397	100.10
886496	100.10	886618	100.00	886643	100.10	886742	99.90	886768	100.10
886794	100.00	886798	100.00	886961	100.00	886983	99.80	887065	100.10
887136	100.00	887171	100.00	887177	100.03	887259	99.80	887380	100.10
887514	100.20	887614	99.80	887634	100.00	887651	100.00	887652	100.00
887710	99.90	887724	100.00	889991	100.10	890234	100.10	890331	100.10
890348	100.00	890406	100.00	890533	99.90	890614	100.20	890659	100.10
890666	100.00	890784	100.00	890863	100.00	890870	100.10	892100	100.00
892115	100.20	892119	100.10	892129	99.90	892141	99.90	892326	100.10
892431	100.00	892479	99.90	892575	100.10	892581	100.00	892724	100.00
892822	100.00	892924	99.90	892927	100.00	892935	100.00	892950	100.10
893131	99.90	893148	100.00	893160	100.00	893221	100.00	893478	99.90
893490	99.90	897422	99.90	897533	100.00	897560	100.00	897561	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.57
3 Sum of Squared Measurements	750114.55
4 Correction Factor (CF): Sum of Measurements Squared / N	750114.00
5 Corrected Sum of Squares (SS)	0.55
6 Variance (V) : SS/(N-1)	0.0074
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0861
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.15
12 Quality Index Lower (QL): (XBAR-L) / S	23.33
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1580 Lot Descr: LG&E D4S-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 8
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
366725	99.70	367005	99.70	367039	99.70	371650	100.10	371719	99.80
371932	100.00	371970	100.00	372053	100.50	372170	99.60	376200	99.90
376213	99.80	376780	100.20	376823	99.90	381718	100.00	382101	100.70
386530	99.70	386603	99.40	386723	99.80	386888	100.00	387007	100.20
389001	100.00	389063	100.00	391116	100.10	391347	100.20	391386	99.70
391757	99.70	395652	99.80	395939	100.10	395987	99.80	396028	99.60
396176	99.70	396440	99.30	400539	99.30	400587	100.10	400621	99.90
401105	99.95	404278	100.36	405968	99.30	405978	100.20	406121	100.20
406189	99.60	410381	99.90	410591	100.20	410734	99.80	410877	99.60
410885	100.20	410983	99.60	414866	100.30	415240	99.90	415334	100.07
415756	100.30	419623	100.10	420045	100.30	420515	100.40	424841	100.20
431188	99.20	431194	99.10	431238	99.00	436561	99.80	437105	100.10
446517	100.30	446561	100.50	447826	99.60	448970	100.10	451617	100.00
451875	99.80	452000	100.10	452012	100.00	453892	99.90	454325	100.30
456370	100.30	456606	100.00	456620	100.10	457302	100.20	460991	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.98
3 Sum of Squared Measurements	749004.54
4 Correction Factor (CF): Sum of Measurements Squared / N	748996.34
5 Corrected Sum of Squares (SS)	8.20
6 Variance (V) : SS/(N-1)	0.1108
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3329
8 Sample Mean(XBAR): Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.21
12 Quality Index Lower (QL): (XBAR-L) / S	5.81
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 1581 Lot Descr: LG&E D4S-2
 In Service Population: 2,660 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
461316	100.10	464263	100.00	464395	100.20	464407	99.20	464433	99.90
464627	99.90	464628	100.20	464639	100.40	464683	100.10	464686	100.30
465340	100.30	465428	99.80	465477	100.20	465565	100.30	468578	99.84
468582	100.10	468591	100.30	468666	99.70	468815	100.30	469557	100.00
469561	100.10	469845	100.30	470001	100.10	471187	99.96	471251	100.10
471280	99.70	471399	100.00	472511	100.20	472523	99.70	472565	100.30
472747	100.20	472809	100.30	475064	100.20	475530	99.80	475693	99.80
475814	100.10	475851	100.10	475879	100.10	475935	100.20	478346	99.60
478348	99.80	478409	99.70	478634	100.10	478644	100.20	479965	100.30
479989	100.00	481491	100.70	483425	99.90	483553	100.40	483705	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5003.20
3 Sum of Squared Measurements	500643.43
4 Correction Factor (CF): Sum of Measurements Squared / N	500640.20
5 Corrected Sum of Squares (SS)	3.22
6 Variance (V) : SS/(N-1)	0.0658
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2564
8 Sample Mean(XBAR): Sum X/N	100.06
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.55
12 Quality Index Lower (QL): (XBAR-L) / S	8.05
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200E Model Number: I-210 (ERT) Division: 01 Sample Lot: 1582 Lot Descr: LG&E I210-1
 In Service Population: 1,077 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
832166	100.00	832174	100.00	832194	100.00	832241	100.00	832268	100.10
832379	99.90	832400	99.90	832416	100.00	832425	100.00	832448	100.00
832570	100.00	832575	99.90	832598	99.90	832649	100.10	832656	100.00
832725	99.90	832727	100.00	832730	100.00	832776	99.80	832802	100.00
832873	100.10	832928	100.00	835374	99.97	835385	100.10	835401	100.00
838211	99.90	838253	100.00	838266	100.10	838306	99.90	838324	100.00
838346	99.70	838362	99.80	838382	99.90	838418	100.10	838450	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3499.07
3 Sum of Squared Measurements	349814.31
4 Correction Factor (CF): Sum of Measurements Squared / N	349814.02
5 Corrected Sum of Squares (SS)	0.29
6 Variance (V) : SS/(N-1)	0.0084
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0917
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	22.09
12 Quality Index Lower (QL): (XBAR-L) / S	21.51
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V15A100 Model Number: I-50S Division: 01 Sample Lot: 1583 Lot Descr: LG&E I50-1
 In Service Population: 1,011 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
185677	99.60	198758	100.50	201872	100.00	203055	100.30	204459	99.60
208568	100.30	209147	100.40	212174	99.70	213834	100.30	216087	100.20
216092	100.60	218176	98.90	219113	100.00	219398	100.40	220181	100.40
222315	100.20	222342	100.90	223548	100.10	223927	100.30	224489	100.00
224510	99.90	226804	100.00	226814	99.98	228555	99.89	230042	99.90
230470	100.20	231799	99.90	232622	100.00	233028	100.30	233943	100.10
234019	100.20	234308	100.20	235018	100.00	235279	99.60	237127	100.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3503.47
3 Sum of Squared Measurements	350698.75
4 Correction Factor (CF): Sum of Measurements Squared / N	350694.34
5 Corrected Sum of Squares (SS)	4.41
6 Variance (V) : SS/(N-1)	0.1297
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3601
8 Sample Mean(XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.28
12 Quality Index Lower (QL): (XBAR-L) / S	5.83
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V16AC100 Model Number: I-55S Division: 01 Sample Lot: 1584 Lot Descr: LG&E I55-1
 In Service Population: 1,294 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
238480	100.40	239595	100.60	242716	100.20	242819	100.00	243011	99.60
243996	100.60	244274	100.70	244285	100.40	245473	100.36	245535	100.30
245985	100.20	246221	100.20	246226	100.60	246370	100.40	246406	100.69
246812	100.40	246989	100.60	247083	100.40	247208	100.30	247359	100.60
248292	100.80	249836	100.40	250438	100.10	250624	99.70	251219	100.10
251690	100.40	251753	100.30	251794	100.20	252343	100.60	252394	100.40
256684	100.40	257407	100.00	257632	100.00	257883	100.30	263536	99.90
263677	99.60	264016	99.71	264060	99.80	264346	100.80	264363	100.30
264408	99.75	264743	100.10	264803	99.50	265087	100.10	265128	99.90
265652	100.20	265667	100.00	265836	99.80	265855	100.00	265877	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5010.51
3 Sum of Squared Measurements	502109.61
4 Correction Factor (CF): Sum of Measurements Squared / N	502104.21
5 Corrected Sum of Squares (SS)	5.40
6 Variance (V) : SS/(N-1)	0.1103
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3321
8 Sample Mean(XBAR): Sum X/N	100.21
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.39
12 Quality Index Lower (QL): (XBAR-L) / S	6.66
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 1585 Lot Descr: LG&E I60-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 13

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
269081	100.00	269135	100.20	271501	100.20	278658	100.20	279557	100.30
280734	100.10	280738	100.30	281730	100.10	281735	99.90	281987	99.90
284916	100.00	285095	99.90	285640	99.80	285833	100.00	291245	99.60
291359	100.00	292641	100.00	294309	99.90	294472	99.30	295325	99.80
295339	100.50	297334	100.80	297433	99.90	297691	99.30	298593	100.20
298832	100.30	300133	99.90	303765	99.80	303776	99.70	303850	99.60
304071	99.20	304219	99.60	304320	99.60	304574	99.50	307118	99.70
307189	99.80	307210	100.00	307238	99.80	307898	99.30	311357	100.20
311554	100.10	311753	99.50	312392	99.50	312424	99.90	312832	99.70
313253	100.30	313343	100.60	313458	99.90	313603	99.90	313604	99.90
314071	99.80	316472	100.40	316624	100.60	317167	100.50	317625	99.90
317670	99.90	317976	100.20	318181	100.30	318289	99.80	318300	99.90
319642	100.50	319862	100.20	319910	100.10	320242	100.20	320251	100.00
320435	99.90	320543	99.90	324303	100.00	324853	100.10	326380	99.80
329299	100.30	329813	99.90	329932	100.40	331376	99.80	334187	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.90
3 Sum of Squared Measurements	749587.63
4 Correction Factor (CF): Sum of Measurements Squared / N	749580.06
5 Corrected Sum of Squares (SS)	7.57
6 Variance (V) : SS/(N-1)	0.1023
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3199
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.34
12 Quality Index Lower (QL): (XBAR-L) / S	6.17
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-60S Division: 01 Sample Lot: 1586 Lot Descr: LG&E I60-2
 In Service Population: 2,539 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993 --
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 14
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
334369	100.20	334375	100.00	334453	100.80	334460	100.20	334508	99.70
334509	100.00	335893	99.90	336126	100.40	336135	99.80	336337	100.20
336484	99.90	338291	100.10	338690	100.10	338838	100.50	340793	100.40
340849	100.10	343316	100.00	343427	99.90	343574	100.00	343656	100.40
343686	100.20	344992	100.10	345086	100.00	345126	100.00	345136	100.20
345529	100.20	347939	100.20	348130	100.20	349605	99.90	349636	99.40
349710	100.00	349975	100.20	352053	99.90	352176	99.76	352453	100.00
352652	100.10	352743	99.90	354451	100.10	354753	100.04	354779	100.10
354871	100.30	355155	100.10	357449	100.10	357631	100.10	357648	100.00
357755	100.10	357866	100.10	359373	99.90	359392	100.30	359553	99.70

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5003.80
3 Sum of Squared Measurements	500762.74
4 Correction Factor (CF): Sum of Measurements Squared / N	500760.29
5 Corrected Sum of Squares (SS)	2.45
6 Variance (V) : SS/(N-1)	0.0500
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2236
8 Sample Mean(XBAR): Sum X/N	100.08
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.60
12 Quality Index Lower (QL): (XBAR-L) / S	9.28
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1587 Lot Descr: LG&E I70-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
361263	100.20	361275	99.60	362051	100.20	362146	100.10	363371	100.10
363403	100.20	363492	100.10	363629	99.90	363879	99.90	363970	99.90
364178	99.90	364180	100.10	364315	100.20	366271	99.80	366420	99.70
368082	100.10	368229	100.20	368457	100.00	368709	100.00	368739	100.10
368790	100.30	368905	100.10	370679	99.90	370762	99.40	371411	100.30
372929	100.10	373042	100.50	373098	100.60	373311	100.30	373655	99.40
375345	99.90	375454	100.50	375543	100.00	375755	100.40	375869	100.40
376058	100.30	376127	100.70	377152	100.00	377209	100.10	377296	100.10
377466	100.00	377604	100.10	377630	100.60	378023	100.60	380576	100.30
380579	100.20	380680	100.70	380691	100.60	380781	100.00	380935	100.30
381049	100.10	381176	100.20	382971	100.30	383126	100.00	383199	100.30
384758	100.30	385037	100.50	385104	100.10	385147	100.10	385149	100.10
385245	100.30	385318	100.30	385397	99.80	385584	100.30	385672	100.20
385745	100.10	385773	100.00	387143	100.20	387616	100.20	387711	100.40
387728	100.10	390661	100.00	390753	100.60	392054	100.00	392229	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7511.50
3 Sum of Squared Measurements	752306.75
4 Correction Factor (CF): Sum of Measurements Squared / N	752301.76
5 Corrected Sum of Squares (SS)	4.99
6 Variance (V) : SS/(N-1)	0.0674
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2596
8 Sample Mean(XBAR): Sum X/N	100.15
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.11
12 Quality Index Lower (QL): (XBAR-L) / S	8.30
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1588 Lot Descr: LG&E I70-2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
392638	100.00	392657	99.80	392837	100.30	392845	100.20	392884	100.10
394689	100.10	394756	100.40	394833	100.50	394844	99.90	394881	100.00
394969	100.90	395010	100.30	395023	100.40	395094	100.20	395332	100.20
395335	100.20	395523	100.00	396785	100.10	396986	100.40	397040	100.10
397365	100.00	397508	100.30	399160	100.30	399198	99.40	399243	99.90
399256	100.10	399792	100.40	399893	100.20	399930	99.60	399967	100.10
401688	100.00	401750	100.30	401996	100.00	402080	100.10	404392	100.30
404527	99.50	404653	100.10	404748	100.08	404931	100.30	404970	100.30
405141	100.20	405182	100.60	406607	100.30	406623	100.40	406802	100.00
407202	100.40	409213	100.40	409419	100.10	409704	100.50	409892	99.90
409948	100.10	409964	100.30	411391	100.27	411490	100.30	411929	99.60
413971	100.10	414275	100.20	414637	100.10	416932	100.20	416993	100.10
417015	99.90	417022	100.00	417135	100.00	418758	100.20	418958	100.00
421035	100.20	421140	100.20	421196	99.80	421255	100.00	421731	100.10
421804	100.20	423826	100.10	423850	100.30	424121	100.00	424226	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7510.55
3 Sum of Squared Measurements	752115.64
4 Correction Factor (CF): Sum of Measurements Squared / N	752111.48
5 Corrected Sum of Squares (SS)	4.16
6 Variance (V) : SS/(N-1)	0.0562
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2370
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.85
12 Quality Index Lower (QL): (XBAR-L) / S	9.03
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1589 Lot Descr: LG&E I70-3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 17

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
424307	99.80	424554	99.60	424735	100.20	425742	100.00	425941	100.10
426344	100.30	426508	100.20	426521	100.30	429038	100.40	429044	100.00
429143	100.00	429256	100.20	429522	100.00	429635	100.00	429901	100.10
432012	99.90	432094	99.90	432176	100.00	432221	99.70	432236	100.20
432239	99.80	432298	100.20	432336	100.01	432506	100.20	432550	100.20
432796	99.90	435827	100.20	435829	100.60	437593	100.10	437649	99.70
437835	99.80	437910	99.70	437945	100.10	438082	100.10	438474	99.90
441401	100.00	442375	100.30	442571	100.00	442594	99.90	442800	99.90
442811	100.10	443009	100.10	444840	100.00	445022	100.00	445032	100.00
445638	99.80	445748	100.40	445805	100.00	448230	99.90	448300	100.00
448358	99.90	448468	100.00	448508	100.10	448552	100.00	448623	100.10
449307	100.10	450659	100.10	451102	100.40	451125	100.60	455512	100.20
455564	100.10	455789	100.40	455822	100.10	455969	100.00	457664	100.20
459163	100.40	459300	100.00	459415	100.10	459476	100.30	461622	100.00
461725	100.00	461810	100.20	462062	100.30	462159	100.05	463284	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7505.46
3 Sum of Squared Measurements	751095.22
4 Correction Factor (CF): Sum of Measurements Squared / N	751092.40
5 Corrected Sum of Squares (SS)	2.83
6 Variance (V) : SS/(N-1)	0.0382
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1954
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.86
12 Quality Index Lower (QL): (XBAR-L) / S	10.61
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-708 Division: 01 Sample Lot: 1590 Lot Descr: LG&E I70-4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
463518	100.20	463916	100.10	464195	99.80	465878	100.00	465899	100.10
466215	100.00	467050	100.10	467135	100.10	467172	99.80	467190	100.10
467317	100.06	467425	100.40	467564	100.00	467584	100.30	467876	100.11
467977	100.30	471557	99.70	471662	100.00	471911	100.00	472041	100.10
472195	100.10	472223	100.10	472419	100.30	474176	99.90	474197	100.00
474214	99.90	474521	99.90	474535	100.10	474577	100.00	474834	100.10
475999	99.90	476116	100.00	476131	99.90	476253	99.90	476484	99.90
476714	99.90	476825	100.10	477096	100.19	479049	100.10	479115	100.30
479629	100.10	480935	100.10	482465	100.05	482820	99.90	482840	100.00
483025	100.10	483101	99.90	483160	100.10	483980	100.10	484151	100.00
484179	99.90	484393	100.10	484434	100.00	484482	99.90	487441	99.70
487488	100.10	487531	100.30	487621	100.00	487737	100.30	487888	101.20
488090	100.20	488182	100.00	489240	99.90	489411	100.40	489651	99.80
490623	99.60	490761	100.20	493136	100.00	493154	99.90	493290	100.10
493533	99.80	493627	100.10	493674	99.80	493828	100.10	495647	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.31
3 Sum of Squared Measurements	750665.46
4 Correction Factor (CF): Sum of Measurements Squared / N	750662.15
5 Corrected Sum of Squares (SS)	3.32
6 Variance (V) : SS/(N-1)	0.0448
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2118
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.24
12 Quality Index Lower (QL): (XBAR-L) / S	9.65
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1591 Lot Descr: LG&E I70-5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
498428	100.00	498546	100.10	498642	100.20	498739	100.10	498804	99.90
499240	100.00	500095	100.10	500098	100.10	500161	100.50	501054	100.00
501192	99.90	501368	100.20	501627	100.00	501781	100.03	501804	99.80
506066	100.20	506322	99.40	506669	100.10	506800	99.90	506934	100.10
506982	100.20	506984	99.80	507097	100.10	508692	99.60	509873	100.10
509938	100.10	509966	99.70	510336	100.00	510421	99.80	510474	100.10
510602	100.30	511291	100.10	511322	100.20	511387	100.20	511569	99.90
511638	100.00	511736	100.10	511755	99.80	511897	100.10	511950	100.10
512028	100.10	515909	100.00	516104	100.00	516491	100.10	516653	100.00
520047	99.70	522168	100.20	522263	99.70	522278	100.00	522572	100.10
522617	99.50	524296	100.00	524364	100.00	524390	99.80	524500	99.80
524582	100.10	524622	99.80	526498	100.33	526846	100.20	526852	100.27
526861	99.80	526960	100.10	529213	100.10	529308	100.00	529386	99.90
529419	100.20	529745	100.20	532928	99.80	533111	100.00	533151	99.90
533583	99.80	533694	100.00	535873	99.80	540563	99.50	540777	100.40

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.13
3 Sum of Squared Measurements	750029.07
4 Correction Factor (CF): Sum of Measurements Squared / N	750026.00
5 Corrected Sum of Squares (SS)	3.07
6 Variance (V) : SS/(N-1)	0.0415
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2038
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.81
12 Quality Index Lower (QL): (XBAR-L) / S	9.82
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1592 Lot Descr: LG&E I70-6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS/

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
540987	100.20	541566	100.00	541673	100.10	541677	99.90	542194	100.30
545498	100.00	551621	99.80	551767	99.90	551863	100.10	551899	100.00
551970	99.80	552137	100.00	552177	99.90	552319	100.00	552333	100.00
552451	100.00	552464	100.50	552784	100.00	552894	100.00	553001	100.00
553331	100.10	553543	100.20	553870	100.00	553913	99.96	554079	99.90
555401	100.00	555421	100.00	555598	100.30	555604	100.00	555702	99.80
561558	100.20	561673	100.10	561720	99.70	562011	100.10	562037	100.10
562045	100.00	562124	100.10	562436	100.00	562484	100.10	562508	100.00
562523	100.27	562594	100.30	562886	99.90	563146	99.90	563380	100.00
563670	100.00	563682	100.10	564233	100.10	564323	100.10	564449	100.00
564576	100.00	564691	100.00	564726	99.90	565385	100.10	565405	100.20
565412	100.00	568588	100.10	568606	100.00	568783	99.70	568809	100.10
568956	100.00	569064	100.10	569391	99.90	569457	100.00	569496	100.20
569561	100.00	569733	100.20	570209	100.00	570395	100.00	570422	99.80
570459	99.70	570620	100.20	570675	99.80	570721	100.30	570931	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.03
3 Sum of Squared Measurements	750407.67
4 Correction Factor (CF): Sum of Measurements Squared / N	750406.05
5 Corrected Sum of Squares (SS)	1.62
6 Variance (V) : SS/(N-1)	0.0219
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1479
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	13.34
12 Quality Index Lower (QL): (XBAR-L) / S	13.70
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1593 Lot Descr: LG&E I70-7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
570988	99.40	571005	99.54	571179	100.10	571203	100.00	571210	99.80
571254	99.90	571270	99.70	571358	99.80	571382	100.00	571657	100.00
571688	100.30	571927	99.50	572516	100.00	572548	100.00	572583	99.80
572713	99.83	572794	100.20	572809	99.90	572976	99.90	573132	99.80
573346	99.90	573678	100.00	573701	99.60	573818	99.90	573939	100.10
573950	100.00	575426	100.10	581966	100.30	582235	100.20	582278	100.23
582447	100.30	583020	100.10	583579	100.30	583609	100.00	583735	100.30
591561	100.00	591622	99.90	591645	99.90	592039	100.00	592422	100.30
592483	100.40	592605	100.10	593117	100.00	593235	100.00	593277	100.00
593328	100.40	593777	99.90	593828	100.20	593860	100.30	594074	99.70
594115	100.10	594234	100.10	594280	100.30	594351	100.60	594360	100.20
594391	100.20	594618	100.00	594979	100.20	595038	99.80	599002	100.10
602961	100.60	603352	100.10	603625	100.00	603663	100.20	603960	100.10
604084	100.10	604304	100.10	604474	100.20	604544	100.00	604660	100.40
604718	100.00	604739	99.90	605035	100.00	605140	100.20	605248	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.30
3 Sum of Squared Measurements	750663.94
4 Correction Factor (CF): Sum of Measurements Squared / N	750660.15
5 Corrected Sum of Squares (SS)	3.80
6 Variance (V) : SS/(N-1)	0.0513
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2266
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.63
12 Quality Index Lower (QL): (XBAR-L) / S	9.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1594 Lot Descr: LG&E I70-8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
605623	99.80	605946	99.90	607051	99.90	607219	99.70	623688	100.20
623743	100.36	623835	100.20	623881	100.10	623891	100.00	623905	100.20
624063	100.00	624117	100.10	624247	100.10	624430	100.30	624574	100.00
624648	99.70	625094	100.00	625358	100.30	625486	100.10	625499	100.10
625526	100.10	625579	100.10	625616	100.30	625720	100.10	625762	100.00
626042	99.90	626101	100.10	626157	100.00	626254	100.00	626661	100.20
626863	100.20	627087	100.10	627618	99.80	627697	99.80	628344	100.10
628897	99.80	629013	100.30	629174	100.00	629250	100.30	629407	100.10
629664	100.00	629671	100.20	629712	100.10	629733	100.00	629979	100.30
630136	100.10	630140	100.10	630177	100.10	630184	100.50	630368	100.30
630377	100.53	630684	100.20	630748	100.30	631028	100.10	631032	100.00
631101	100.00	631549	100.10	631722	100.12	631756	100.10	631774	100.20
631824	99.90	633658	99.90	633691	100.20	639614	100.00	639731	100.00
639738	100.60	640005	100.00	640008	99.80	640136	100.05	640618	100.30
640759	100.30	641217	99.90	641286	99.80	641382	100.00	641465	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.46
3 Sum of Squared Measurements	751294.97
4 Correction Factor (CF): Sum of Measurements Squared / N	751292.56
5 Corrected Sum of Squares (SS)	2.41
6 Variance (V) : SS/(N-1)	0.0326
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1805
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.60
12 Quality Index Lower (QL): (XBAR-L) / S	11.56
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1595 Lot Descr: LG&E I70-9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
641588	100.10	641685	100.10	641801	99.90	641864	99.80	641935	100.00
641985	100.30	642231	100.00	642289	99.70	642302	100.18	642466	100.20
642587	99.90	642843	100.30	642871	100.20	643045	100.20	643229	100.20
643678	99.90	643699	100.20	643791	100.20	644263	100.00	644274	100.20
644297	100.40	644686	100.20	645054	99.70	645152	99.80	645398	99.90
654456	100.30	654616	100.10	654640	100.20	654727	100.20	655012	99.70
655052	100.20	655273	100.00	655305	99.90	655429	99.70	655454	99.90
655529	100.30	655538	100.20	655672	99.80	655888	99.90	655950	99.70
656121	99.70	656143	99.90	656166	99.90	656218	100.10	656541	100.20
656847	99.70	656853	99.70	656918	99.60	657755	99.76	658106	100.00
676647	100.10	676758	99.90	676814	99.90	677369	99.90	677472	100.20
677544	99.70	677602	100.20	677790	100.10	678032	100.10	678255	100.30
678553	100.20	678815	99.90	679215	99.90	679391	99.80	679504	100.10
679511	99.90	679944	99.90	680194	100.00	680210	100.10	680221	99.90
680280	99.80	680291	100.00	680400	99.90	680438	99.20	680516	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7499.34
3 Sum of Squared Measurements	749871.43
4 Correction Factor (CF): Sum of Measurements Squared / N	749868.01
5 Corrected Sum of Squares (SS)	3.42
6 Variance (V) : SS/(N-1)	0.0463
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2151
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.34
12 Quality Index Lower (QL): (XBAR-L) / S	9.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: I-70S Division: 01 Sample Lot: 1596 Lot Descr: LG&E I70-10
 In Service Population: 4,700 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
680545	100.30	680582	100.10	680632	100.00	680654	100.10	680697	100.20
680850	99.80	680906	99.90	680987	99.80	681111	100.00	681114	100.29
681140	100.00	681141	99.60	681178	99.80	681251	100.00	681268	99.90
681280	99.70	681349	100.30	681389	99.80	681417	99.90	681446	100.00
681526	100.00	681552	100.30	681705	100.20	681863	100.10	681920	100.10
681963	100.00	681988	100.00	682160	100.20	682199	99.80	682307	100.00
682411	99.70	682430	100.00	682507	100.00	682529	100.40	682995	99.30
689248	100.30	689250	100.30	689274	100.20	689392	100.10	689445	100.10
689538	100.20	689638	100.30	689661	100.00	689665	100.10	689671	100.10
689714	100.20	689742	100.00	689802	99.90	689856	100.10	689875	100.20
689894	99.90	689973	100.40	690104	100.30	690123	99.90	690137	99.90
690167	100.00	690183	100.30	690323	100.10	690339	100.10	690526	99.80
690527	100.10	690552	100.00	690638	100.30	690775	100.00	690787	100.10
690822	100.10	690886	100.20	690987	99.80	690995	100.00	691011	100.00
691072	99.90	691350	100.00	691706	100.10	691935	100.30	698634	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.29
3 Sum of Squared Measurements	750660.96
4 Correction Factor (CF): Sum of Measurements Squared / N	750658.14
5 Corrected Sum of Squares (SS)	2.82
6 Variance (V) : SS/(N-1)	0.0381
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1952
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.02
12 Quality Index Lower (QL): (XBAR-L) / S	10.47
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 1597 Lot Descr: LG&E J4S-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
388058	100.30	388356	98.90	388383	99.90	388516	100.20	388822	99.40
388893	100.20	393371	99.80	393466	100.20	393544	99.80	393746	99.90
393818	100.20	397620	100.00	397690	100.00	397859	99.80	398113	98.90
402492	100.60	402508	100.00	402583	100.20	402700	99.20	402729	100.80
402736	99.90	408248	100.40	412254	100.20	412599	100.40	412837	100.40
417317	100.90	417372	100.00	417607	100.00	417620	100.00	421956	100.30
422291	100.10	422541	100.30	427211	100.42	427370	101.50	427784	100.00
427799	100.20	432967	99.90	433600	100.10	438535	100.50	439029	99.80
439221	99.90	443315	99.80	446875	100.20	446887	100.60	449864	99.90
449991	99.70	453523	100.30	453720	100.10	453836	99.80	456967	100.10
457060	99.50	457071	100.10	457124	99.70	460128	99.80	460352	100.00
460458	100.00	468321	101.70	468325	99.70	468445	100.20	468482	100.10
470255	99.60	470389	99.60	470469	99.80	473807	100.10	477744	100.00
486082	100.00	486085	99.60	486089	99.40	486185	99.70	486346	99.70
486364	99.60	492637	99.80	492791	99.40	496053	99.80	496192	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.92
3 Sum of Squared Measurements	750198.95
4 Correction Factor (CF): Sum of Measurements Squared / N	750184.01
5 Corrected Sum of Squares (SS)	14.94
6 Variance (V) : SS/(N-1)	0.2018
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4493
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.42
12 Quality Index Lower (QL): (XBAR-L) / S	4.48
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC320 Model Number: J4ES Division: 01 Sample Lot: 1598 Lot Descr: LG&E J4S-2
 In Service Population: 1,039 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 26
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
499593	99.80	499612	99.70	499620	99.70	499624	99.90	499658	100.00
499678	99.40	499701	99.60	499740	99.70	499755	100.00	499804	99.90
499838	99.80	499882	100.20	499925	99.90	502081	98.64	502099	99.80
734125	100.20	734145	99.70	734177	99.70	734201	100.00	734215	100.10
734241	100.20	734268	99.95	734279	100.80	734280	100.30	740039	100.10
740049	100.30	740129	100.10	740137	100.90	740166	99.90	740170	100.40
740225	99.80	740264	100.60	740409	100.57	740411	100.20	740422	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3499.66
3 Sum of Squared Measurements	349937.73
4 Correction Factor (CF): Sum of Measurements Squared / N	349932.00
5 Corrected Sum of Squares (SS)	5.72
6 Variance (V) : SS/(N-1)	0.1683
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4103
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.90
12 Quality Index Lower (QL): (XBAR-L) / S	4.85
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1599 Lot Descr: LG&E J5S-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 27
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
512421	99.60	512438	99.80	512510	99.90	512589	99.80	512757	99.50
512795	99.80	512814	100.10	512864	100.10	513052	99.90	513904	100.20
513949	100.20	514314	99.90	514379	99.90	514406	100.00	514473	99.70
514512	100.00	514597	99.60	517199	100.10	517391	100.30	517700	100.00
518516	99.80	518617	99.50	521447	99.90	521759	99.90	521806	99.90
521811	99.60	521884	99.50	525682	99.50	526019	99.50	526050	100.30
526054	99.90	526207	99.80	526456	100.00	527220	100.30	527429	100.40
527490	99.50	527625	99.80	527723	100.90	528507	100.00	528677	100.10
530371	99.50	530506	100.00	530632	99.40	530973	99.80	530977	99.60
531046	99.70	531344	99.90	531633	99.70	534082	100.10	534329	99.60
534482	100.10	534510	99.70	534683	99.40	534729	99.30	534935	99.70
535470	100.20	535487	100.00	535643	100.00	535650	99.90	539636	99.30
539841	100.00	540036	100.30	540178	99.60	540191	100.00	540243	99.80
540262	99.70	540332	99.60	540352	100.00	543292	100.00	543500	99.70
543708	100.40	543718	99.80	543814	100.40	543929	100.40	544034	100.20

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7491.30
3 Sum of Squared Measurements	748267.69
4 Correction Factor (CF): Sum of Measurements Squared / N	748261.01
5 Corrected Sum of Squares (SS)	6.68
6 Variance (V) : SS/(N-1)	0.0903
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3005
8 Sample Mean(XBAR): Sum X/N	99.88
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.04
12 Quality Index Lower (QL): (XBAR-L) / S	6.27
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1600 Lot Descr: LG&E J5S-2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
544415	100.30	544588	99.50	544599	100.40	544673	99.70	544746	100.70
544838	100.60	548541	99.60	548556	99.70	548834	100.00	549277	100.00
549561	99.70	549790	99.80	549817	99.80	549882	100.30	549893	99.90
550011	100.10	550090	100.20	550138	100.30	550160	100.10	550206	99.30
550211	100.30	550294	99.90	550407	99.60	550455	100.00	550611	100.10
550657	99.90	550866	100.30	550873	99.70	551120	100.40	551139	100.50
551171	100.40	556352	99.90	556531	99.40	557228	100.10	557521	99.70
558002	100.10	558077	99.78	558130	99.90	565639	99.80	565826	99.60
566117	98.70	566329	100.30	566601	99.50	567002	100.20	567468	99.70
567475	100.10	567626	99.90	567687	99.70	574036	99.80	574184	100.00
574192	100.20	579171	100.20	579400	99.70	579421	100.10	579434	99.90
579439	100.00	579455	100.30	579518	99.80	579532	99.80	579549	100.10
579675	98.40	580111	100.30	580317	100.30	580364	100.10	580418	99.70
580478	100.40	580770	100.30	580824	100.40	581009	99.90	581152	99.90
581343	100.30	581845	99.70	581887	100.40	581916	100.20	584132	99.80

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.48
3 Sum of Squared Measurements	749506.74
4 Correction Factor (CF): Sum of Measurements Squared / N	749496.08
5 Corrected Sum of Squares (SS)	10.65
6 Variance (V) : SS/(N-1)	0.1440
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3794
8 Sample Mean(XBAR) : Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.36
12 Quality Index Lower (QL): (XBAR-L) / S	5.18
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1601 Lot Descr: LG&E J5S-3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 29
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
584571	99.60	584585	99.80	584810	100.00	585082	100.10	585224	100.60
585281	99.60	585516	99.90	585593	100.00	585910	100.10	586113	100.00
586147	99.50	586217	99.30	586720	100.10	588633	99.90	588648	100.50
588713	99.90	588767	100.30	588783	99.80	588840	100.40	588892	99.80
589258	100.10	589266	99.90	589346	99.90	589648	99.80	589704	100.20
589915	99.90	590405	100.10	590532	98.50	590545	100.00	590824	99.90
590832	100.20	591267	100.80	591352	100.40	591410	100.00	599602	99.90
599653	100.20	599773	99.60	599902	99.70	600065	100.20	600122	100.50
600208	100.20	600290	100.10	600755	100.24	601033	100.20	601052	100.30
601103	100.30	601111	100.00	601136	100.60	601243	99.80	601534	100.10
601561	99.60	601636	100.00	601689	100.10	601693	99.40	601888	99.90
602082	100.60	607556	100.20	607655	100.10	607898	100.00	607913	100.10
608349	100.20	608857	100.00	608858	100.10	609130	100.30	609131	99.20
609317	100.00	609481	100.00	609488	100.30	609687	100.10	609782	100.00
609856	99.70	609879	100.00	610283	100.10	634068	99.70	634275	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.44
3 Sum of Squared Measurements	750096.70
4 Correction Factor (CF): Sum of Measurements Squared / N	750088.00
5 Corrected Sum of Squares (SS)	8.70
6 Variance (V) : SS/(N-1)	0.1175
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3428
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.82
12 Quality Index Lower (QL): (XBAR-L) / S	5.85
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015), to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1602 Lot Descr: LG&E J5S-4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 30
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
578674	100.50	634556	99.80	634621	99.60	634860	99.70	635078	100.10
635237	100.10	635359	100.10	635677	99.90	635681	99.90	635807	99.80
635926	99.90	635989	100.20	635993	99.70	636222	99.60	636244	100.10
636364	100.10	636518	99.70	657655	99.80	661905	99.90	662077	99.80
662463	99.90	662547	99.80	662768	99.90	663228	99.80	663238	99.60
663386	99.70	663545	99.80	663715	100.10	663851	99.60	663952	99.80
664059	99.20	664155	99.50	664200	99.90	664379	99.70	664592	100.00
664697	99.70	664782	99.70	664809	99.60	664863	99.90	664988	99.50
665078	99.30	665107	100.10	665226	99.70	665247	99.70	665442	99.40
665570	99.50	665788	99.60	665811	100.10	666460	100.00	666703	99.80
666709	99.60	666711	99.40	666840	99.90	666889	99.50	666982	99.80
667025	100.10	667122	99.70	667431	99.60	668014	100.20	668052	100.00
668073	99.90	668372	99.80	668680	99.80	668687	99.70	668867	99.40
669082	99.50	669099	99.70	669291	100.20	669398	99.60	669511	99.40
669697	99.70	669711	99.80	669789	99.50	669810	99.70	669966	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7483.30
3 Sum of Squared Measurements	746668.01
4 Correction Factor (CF): Sum of Measurements Squared / N	746663.72
5 Corrected Sum of Squares (SS)	4.29
6 Variance (V) : SS/(N-1)	0.0580
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2408
8 Sample Mean(XBAR): Sum X/N	99.78
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.23
12 Quality Index Lower (QL): (XBAR-L) / S	7.38
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S (R200) Division: 01 Sample Lot: 1603 Lot Descr: LG&E J5S-5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 31
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
670269	99.60	670439	100.10	670483	100.00	670531	99.80	670546	99.90
683274	100.00	683286	100.40	683350	100.00	683505	99.90	683560	100.20
683582	99.60	683867	99.50	684038	99.50	684053	100.20	684119	99.80
684476	99.29	684501	100.30	684568	100.00	684667	100.00	684864	100.30
685067	99.80	685438	99.40	685582	99.30	685802	100.20	686141	99.80
686245	100.34	686440	99.90	686644	100.10	686673	99.20	686810	100.10
686874	100.00	686889	99.30	687202	99.60	687226	100.10	687371	99.58
687477	99.80	687507	100.41	687674	99.65	687684	99.90	688093	100.00
688176	99.70	688287	99.90	688319	100.20	688333	100.20	688428	100.40
688635	99.40	689149	99.90	692174	100.10	692534	99.60	692809	100.10
692900	99.20	693111	99.90	693344	99.50	693811	100.30	693922	100.01
693956	99.80	694062	100.30	694463	99.90	694703	99.80	694954	100.00
695014	100.10	695865	99.70	696600	100.10	696958	100.00	696965	99.50
697048	100.10	697501	100.00	697553	99.80	697624	99.70	697703	99.80
697787	100.10	698155	100.30	698907	99.70	699173	100.20	699447	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7492.08
3 Sum of Squared Measurements	748423.63
4 Correction Factor (CF): Sum of Measurements Squared / N	748416.84
5 Corrected Sum of Squares (SS)	6.79
6 Variance (V) : SS/(N-1)	0.0918
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3029
8 Sample Mean(XBAR): Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.95
12 Quality Index Lower (QL): (XBAR-L) / S	6.25
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1604 Lot Descr: LG&E J5S-6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 32
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
699729	99.90	699934	100.02	700275	99.70	700584	100.00	706002	99.30
706070	99.40	706287	99.50	706424	99.70	706566	99.60	706801	99.60
707054	99.80	707196	99.90	707223	99.70	707648	99.50	707649	100.00
707686	100.10	708265	99.80	724064	100.00	724347	100.40	724519	100.00
724536	99.30	724777	99.42	724808	100.10	724814	99.50	724865	99.75
724931	99.50	726109	100.00	726304	100.10	726387	100.20	726778	99.60
726852	100.20	726866	99.90	726946	99.90	727225	99.70	727465	99.70
727969	99.40	728043	99.60	728108	100.60	728904	100.20	728936	100.20
729103	99.50	729326	100.00	729361	100.10	729404	100.00	729406	100.18
729561	100.20	729661	100.00	729683	100.20	729881	100.30	729905	100.00
730136	99.70	730254	100.50	730274	100.10	730325	100.10	730337	100.10
730412	100.00	730701	100.60	730708	100.20	730878	100.10	730890	99.70
731533	100.30	731572	99.60	731681	99.80	731825	99.50	731859	100.10
732292	99.70	732340	100.10	732407	99.60	732449	100.10	732545	100.10
732549	99.60	732562	100.00	732577	99.90	732594	100.00	732607	100.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.37
3 Sum of Squared Measurements	748681.71
4 Correction Factor (CF): Sum of Measurements Squared / N	748674.59
5 Corrected Sum of Squares (SS)	7.13
6 Variance (V) : SS/(N-1)	0.0963
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3103
8 Sample Mean(XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.73
12 Quality Index Lower (QL): (XBAR-L) / S	6.16
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF, In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1605 Lot Descr: LG&E J5S-7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
732677	100.40	732793	100.00	733601	99.70	733723	99.80	733744	100.10
733782	100.10	733822	100.30	733839	100.10	734023	100.30	734547	100.00
734752	99.75	734783	99.60	734791	99.50	734895	100.10	734906	100.10
734971	99.80	734995	99.70	735040	100.20	735102	100.10	735134	100.20
735299	99.80	735435	99.90	735450	100.00	735552	99.90	735782	99.90
735890	100.00	735943	99.90	736584	100.00	736792	99.90	737497	100.10
737627	100.60	737630	100.00	737648	100.20	737876	99.90	737972	100.00
738011	100.30	738197	99.70	739005	99.50	739144	99.80	739423	100.00
739591	99.90	739956	99.90	740568	99.40	740585	100.00	740681	99.90
740684	99.90	741167	99.70	741183	99.50	741196	98.70	741395	99.80
741772	99.80	741849	99.20	741959	99.90	742092	99.60	742192	100.30
742235	99.80	742429	99.80	743121	99.00	743130	99.90	743402	99.70
743945	99.30	744200	99.00	744346	99.70	744359	99.50	744476	99.30
744482	100.20	744522	99.60	744655	100.00	744920	99.71	744977	99.90
745051	99.80	745131	99.50	745441	99.10	745533	100.00	745696	99.00

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.56
3 Sum of Squared Measurements	747323.50
4 Correction Factor (CF): Sum of Measurements Squared / N	747314.41
5 Corrected Sum of Squares (SS)	9.09
6 Variance (V) : SS/(N-1)	0.1228
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3504
8 Sample Mean(XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.22
12 Quality Index Lower (QL): (XBAR-L) / S	5.20
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1606 Lot Descr: LG&E J5S-8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
745757	99.30	745955	99.50	746127	99.90	746241	99.70	746272	99.40
746543	99.70	746618	99.90	747025	100.00	747160	99.70	747223	99.70
747328	99.60	747540	99.90	747557	99.60	747634	99.20	747965	99.80
747985	99.92	748117	98.20	748170	98.70	748499	99.40	749216	99.20
749546	99.40	749591	99.40	749593	99.90	749867	100.40	749871	99.70
750182	99.60	750184	99.60	750351	99.00	750422	99.10	750479	100.40
750605	99.80	750823	99.70	751055	100.00	751088	99.00	751189	98.70
751192	99.60	751248	100.00	751255	98.90	751458	99.60	751480	99.20
751718	100.00	751959	99.80	752153	99.60	752168	99.30	752859	99.60
753012	100.00	753046	99.30	757440	99.00	757739	99.70	757847	99.90
757969	99.70	758044	99.10	758191	100.30	758303	99.70	758420	100.10
758535	100.20	758704	99.80	758966	100.00	759087	99.40	759220	100.50
759248	100.20	759558	101.00	759632	99.70	759724	99.80	759761	99.40
759820	99.60	759940	100.50	760035	99.90	760224	99.80	760339	99.70
760384	99.90	760397	99.30	760434	99.60	760463	100.20	760498	99.70

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7474.62
3 Sum of Squared Measurements	744947.78
4 Correction Factor (CF): Sum of Measurements Squared / N	744932.59
5 Corrected Sum of Squares (SS)	15.19
6 Variance (V) : SS/(N-1)	0.2052
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4530
8 Sample Mean(XBAR): Sum X/N	99.66
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.16
12 Quality Index Lower (QL): (XBAR-L) / S	3.67
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.01
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.01
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1607 Lot Descr: LG&E J5S-9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
760690	99.70	761222	99.80	761224	100.00	761497	99.70	761581	99.40
761615	99.70	761795	99.90	761807	99.40	761959	99.50	762025	99.80
762044	98.50	762116	99.30	762289	99.60	762426	99.20	762507	99.60
763102	99.30	763235	99.10	763302	99.40	763357	99.80	763514	99.60
763612	99.40	763999	99.50	764068	99.80	764643	99.80	764816	100.00
767646	99.70	767977	99.70	768008	99.50	768030	99.80	768409	99.70
768556	99.30	768690	99.40	768737	99.40	768826	99.80	769053	100.00
769118	100.00	769221	100.10	769293	99.80	769302	99.70	769528	100.10
769664	99.30	769732	99.20	769785	99.70	769797	99.70	769836	99.40
770214	99.90	770259	99.40	770305	99.30	770357	99.70	770576	100.10
770839	99.40	770896	99.80	771028	99.90	771054	99.70	771057	99.40
771061	99.90	771070	99.30	771130	99.70	771192	100.02	771263	100.00
771432	100.00	771571	99.70	771609	100.00	771673	100.00	771961	99.50
772011	100.10	772193	99.60	772309	100.10	772693	99.90	772872	100.10
772874	100.10	772867	99.90	773201	99.50	773260	100.20	773439	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7475.92
3 Sum of Squared Measurements	745198.63
4 Correction Factor (CF): Sum of Measurements Squared / N	745191.73
5 Corrected Sum of Squares (SS)	6.90
6 Variance (V) : SS/(N-1)	0.0932
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3053
8 Sample Mean(XBAR): Sum X/N	99.68
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.60
12 Quality Index Lower (QL): (XBAR-L) / S	5.50
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1608 Lot Descr: LG&E J5S-10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 36
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
774015	99.60	774143	99.90	774198	99.60	774234	100.30	774343	99.90
774367	99.70	774401	99.80	774418	99.70	774906	100.30	774967	100.00
774996	99.70	775003	99.90	775157	99.80	775234	100.20	775387	100.00
780078	99.90	780158	99.90	780181	99.60	780805	99.70	781147	99.90
781304	100.80	781337	99.60	781464	99.76	781553	98.20	781743	100.00
781776	100.10	781804	99.90	782022	99.80	782239	99.50	782501	99.70
782613	99.90	782739	99.50	782824	100.60	783166	99.90	783294	99.70
783480	99.40	783489	100.70	783656	100.40	783796	100.10	783801	99.90
783869	99.40	783917	99.50	784019	99.80	784034	99.70	784172	99.30
784363	100.20	784649	99.80	784673	99.80	785176	99.80	785402	99.60
785471	99.90	785496	100.10	785613	99.90	785691	99.40	785881	99.80
785910	100.30	785962	99.80	786386	100.30	786670	99.80	786683	100.10
786715	100.30	786768	100.30	786805	100.30	786937	100.00	787349	100.60
787412	100.40	787534	99.90	787559	100.00	792733	100.40	792806	100.10
792865	99.80	793149	99.70	793286	99.70	793290	99.70	793295	99.20

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7491.56
3 Sum of Squared Measurements	748323.62
4 Correction Factor (CF): Sum of Measurements Squared / N	748312.95
5 Corrected Sum of Squares (SS)	10.67
6 Variance (V) : SS/(N-1)	0.1442
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3797
8 Sample Mean(XBAR): Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.56
12 Quality Index Lower (QL): (XBAR-L) / S	4.97
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 1609 Lot Descr: LG&E J5S-11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
787746	100.10	787799	99.80	788097	100.40	788136	99.60	788137	99.60
788443	100.00	789123	100.00	789313	99.60	789528	100.20	789656	100.10
789659	100.00	790003	99.40	790016	99.60	790062	99.80	790300	99.30
790370	100.20	790434	100.10	790446	100.10	790515	99.40	790556	99.50
790574	99.90	790589	100.00	790597	100.20	790794	100.40	790827	99.70
790990	99.80	791056	99.90	791148	99.70	791174	99.90	791255	100.20
791288	99.40	800970	99.20	800973	99.50	801114	99.50	801281	99.90
801364	99.50	801432	100.00	802212	100.00	802281	99.40	802759	99.90
802786	99.50	802870	98.90	802914	99.40	803104	100.00	803273	100.00
803274	100.00	803376	99.60	803634	99.60	803666	99.90	803693	99.20
804023	99.30	804067	99.80	804377	99.70	804384	99.50	804417	100.30
804419	99.80	804452	99.20	804488	99.60	804609	99.30	804822	98.80
805089	100.00	805122	99.40	805123	99.60	805178	100.00	805406	99.60
805530	99.00	805552	99.90	805909	98.50	805937	99.30	806105	98.80
806124	98.90	806149	99.70	806258	99.10	806556	98.90	806624	99.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7474.20
3 Sum of Squared Measurements	744861.28
4 Correction Factor (CF): Sum of Measurements Squared / N	744848.88
5 Corrected Sum of Squares (SS)	12.40
6 Variance (V) : SS/(N-1)	0.1676
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4094
8 Sample Mean(XBAR): Sum X/N	99.66
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.73
12 Quality Index Lower (QL): (XBAR-L) / S	4.04
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: JSS Division: 01 Sample Lot: 1610 Lot Descr: LG&E JSS-12
 In Service Population: 5,192 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
807278	98.90	807311	99.60	807316	99.70	807350	99.40	807423	100.10
807652	100.10	807683	99.60	807716	98.50	808073	99.60	808205	99.80
809926	99.40	809927	99.20	810007	100.20	810154	99.10	810222	99.70
810382	99.40	810632	99.20	810669	99.20	810789	100.20	810819	99.60
810836	100.20	810925	100.50	810974	99.10	810996	99.40	811007	98.60
811013	99.00	811050	99.50	811057	98.90	811095	99.60	811277	98.70
811389	99.20	811472	99.90	811536	100.10	811568	99.40	811572	99.80
811584	98.80	811593	99.40	811649	99.60	811712	99.50	811838	99.20
812143	99.70	812188	99.20	812196	99.30	812205	98.60	812280	99.60
812289	99.20	812303	100.10	812316	99.90	812476	99.30	812576	99.20
812643	99.40	812678	99.50	812933	99.00	812963	99.80	813026	99.20
813119	99.60	813132	99.80	813210	99.50	813234	100.00	813255	99.80
813290	99.60	813344	100.30	813398	99.90	813439	99.70	813514	99.20
813640	99.20	813662	99.70	813686	99.70	813714	99.70	813721	99.90
814151	99.80	814250	99.70	814366	99.30	814416	98.90	814474	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7463.40
3 Sum of Squared Measurements	742711.56
4 Correction Factor (CF): Sum of Measurements Squared / N	742697.86
5 Corrected Sum of Squares (SS)	13.70
6 Variance (V) : SS/(N-1)	0.1851
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4303
8 Sample Mean(XBAR): Sum X/N	99.51
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.78
12 Quality Index Lower (QL): (XBAR-L) / S	3.51
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.01
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.01
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MQS Division: 01 Sample Lot: 1611 Lot Descr: LG&E MQS-1
 In Service Population: 147 Sample Quantity: 10 Meters Tested: 10 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 39
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
333430	100.10	337974	100.00	338014	100.40	356286	99.70	356405	100.30
356510	100.20	356517	100.20	365455	100.50	365468	100.40	370123	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	10
2 Sum of Measurements: (Sum X)	1002.20
3 Sum of Squared Measurements	100441.00
4 Correction Factor (CF): Sum of Measurements Squared / N	100440.48
5 Corrected Sum of Squares (SS)	0.52
6 Variance (V) : SS/(N-1)	0.0573
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2394
8 Sample Mean (XBAR): Sum X/N	100.22
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.43
12 Quality Index Lower (QL): (XBAR-L) / S	9.27
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	7.26
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 1612 Lot Descr: LG&E MS-1
 In Service Population: 8,441 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40 .
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
380112	99.70	384348	100.40	384617	100.80	384646	100.10	384666	100.70
389784	99.80	394296	100.30	394325	100.00	403413	99.70	403454	100.30
403457	100.00	403928	100.60	403947	100.60	404244	100.00	404330	100.40
408630	100.60	408757	100.30	408905	100.10	408966	100.00	412964	100.20
413202	100.40	413223	99.70	413301	99.90	413329	100.40	413395	100.50
413770	101.00	413800	100.60	418174	100.50	418239	100.10	418537	100.40
422890	100.00	423277	99.80	423552	101.00	423594	100.40	423665	100.40
423714	99.90	428375	99.40	428673	100.40	428721	100.20	434793	100.10
434887	100.10	435251	100.30	435474	100.20	435553	100.60	439479	100.20
439816	100.20	439944	100.30	440251	99.80	440343	99.80	444218	99.60
444302	99.60	444369	99.80	444444	99.80	444464	99.70	444491	99.60
446017	99.90	446210	101.20	446289	99.91	446314	100.00	447469	99.80
447592	100.20	447739	99.40	450127	99.40	450148	100.10	450231	100.10
450250	99.70	450370	100.20	450494	100.20	450569	99.80	450583	99.90
452217	100.10	469383	100.10	519168	100.30	531896	100.00	675954	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7509.71
3 Sum of Squared Measurements	751953.49
4 Correction Factor (CF): Sum of Measurements Squared / N	751943.26
5 Corrected Sum of Squares (SS)	10.23
6 Variance (V) : SS/(N-1)	0.1383
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3718
8 Sample Mean(XBAR): Sum X/N	100.13
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.03
12 Quality Index Lower (QL): (XBAR-L) / S	5.73
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1613 Lot Descr: LG&E MSII-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
457737	100.40	458046	100.20	460597	100.20	460616	100.12	460639	99.70
462973	100.00	466647	100.10	466696	100.30	468997	99.90	469079	99.90
469082	100.20	469443	100.60	473202	100.20	473309	99.90	473356	99.80
477124	100.22	477302	100.30	477371	100.00	477414	99.60	477448	100.30
477503	100.10	480583	100.10	480661	99.90	480803	99.60	480879	99.50
482335	99.90	482401	99.30	485073	100.20	485293	100.20	488340	100.00
488433	99.80	488435	100.30	488516	100.00	488542	100.00	491126	100.10
491132	100.00	491392	100.10	491458	100.00	494813	100.00	494875	99.90
494975	100.00	495174	100.40	498017	100.60	502218	100.20	502319	100.00
502462	100.20	502490	100.00	502728	100.10	502834	100.10	502857	100.00
503010	100.00	503350	99.90	503955	99.60	504043	100.00	507369	100.00
507392	99.70	507467	99.80	507566	99.40	507822	99.70	507888	99.90
507974	100.10	508000	100.10	508092	99.80	508372	100.00	508434	100.20
518926	100.00	519196	100.60	519515	100.00	522995	100.10	523134	100.20
523367	100.00	523595	100.20	523716	100.30	523801	100.10	531985	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.14
3 Sum of Squared Measurements	750432.56
4 Correction Factor (CF): Sum of Measurements Squared / N	750428.06
5 Corrected Sum of Squares (SS)	4.50
6 Variance (V) : SS/(N-1)	0.0608
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2466
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.99
12 Quality Index Lower (QL): (XBAR-L) / S	8.22
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1614 Lot Descr: LG&E MSII-2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
532294	100.30	532383	101.30	532429	99.90	532562	99.80	532756	99.70
536300	99.80	536418	99.50	536548	99.60	536990	100.00	537019	100.20
537358	99.90	537370	99.80	537391	99.70	537433	100.00	537437	99.50
537498	99.90	537755	99.60	542281	100.10	542413	99.80	543126	100.20
543143	99.90	545749	100.10	545836	100.30	545988	99.80	546127	100.30
546217	100.20	546270	100.60	546582	100.40	547462	100.00	547470	100.30
547519	100.10	547761	100.20	548052	100.00	548055	100.10	548336	99.90
548365	100.10	558648	100.10	558675	100.30	558960	100.80	559182	100.30
559283	100.20	559370	100.10	559470	100.20	559517	100.10	559798	100.40
559813	100.30	559820	100.20	559992	100.10	560082	100.20	560146	100.00
560178	100.00	560320	100.20	560378	100.10	560773	100.20	560859	100.00
560996	100.30	561023	99.90	561049	100.60	575708	100.20	575842	100.40
575910	100.20	576020	100.20	576033	100.40	576047	100.20	576084	99.60
576190	100.30	576472	100.00	576783	100.10	576805	100.20	577116	100.30
577155	100.20	577156	100.10	577300	100.20	577363	100.30	577449	100.40

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.80
3 Sum of Squared Measurements	751767.06
4 Correction Factor (CF): Sum of Measurements Squared / N	751761.03
5 Corrected Sum of Squares (SS)	6.03
6 Variance (V) : SS/(N-1)	0.0815
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2854
8 Sample Mean(XBAR): Sum X/N	100.12
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.60
12 Quality Index Lower (QL): (XBAR-L) / S	7.42
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1615 Lot Descr: IG&E MSII-3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 43
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
577564	100.20	577591	100.10	577793	100.20	577951	100.30	578059	100.20
578340	100.10	595927	99.70	595991	100.20	596029	100.30	596311	100.10
596379	99.80	596455	99.90	596573	100.00	597015	100.10	597023	100.40
597577	99.80	597802	100.00	597881	100.20	598054	100.30	598093	100.80
598144	100.00	598319	99.90	598483	100.00	598576	100.00	598606	100.00
598734	100.20	611585	100.00	611623	100.40	611855	100.10	611966	100.60
611992	100.40	611994	100.60	612263	100.60	612274	100.40	612596	100.30
612841	100.00	613202	100.00	613219	99.50	613323	99.40	613341	100.60
613696	100.20	613856	100.30	613860	100.20	614038	99.90	614047	100.10
614869	100.50	615175	100.30	615219	100.20	615776	100.00	615829	99.80
615884	99.90	615912	99.80	616014	100.00	616027	99.90	616190	99.80
616321	100.00	616373	100.00	616766	99.90	616891	100.10	617080	100.30
617435	100.20	617800	99.70	618022	100.10	618074	100.20	618109	99.70
618284	100.30	618399	100.30	618403	99.90	618490	100.10	618680	100.30
618783	99.80	618813	100.60	619095	99.80	619108	100.70	619300	100.00

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.60
3 Sum of Squared Measurements	,751726.48
4 Correction Factor (CF): Sum of Measurements Squared / N	751720.99
5 Corrected Sum of Squares (SS)	5.49
6 Variance (V) : SS/(N-1)	0.0742
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2725
8 Sample Mean (XBAR) :- Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.92
12 Quality Index Lower (QL): (XBAR-L) / S	7.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1616 Lot Descr: LG&E MSII-4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
619432	99.90	619437	100.07	619690	100.30	619721	99.80	619827	99.50
619859	99.10	619862	99.50	620052	99.80	620218	100.70	620697	99.90
620721	100.60	620848	100.00	620865	100.30	621038	99.60	621248	99.90
621455	100.20	621549	100.30	622083	100.00	622257	99.90	622473	99.70
622657	99.70	622845	100.40	622937	99.60	623012	100.40	623263	101.00
623350	100.16	636729	100.00	636959	99.90	636996	99.90	637352	100.40
637444	100.00	637554	100.00	637564	100.30	637572	99.80	637605	100.20
637626	100.40	638078	100.00	638136	100.10	638366	100.10	638461	100.30
638604	99.90	638683	99.90	638730	100.20	638750	100.10	638787	100.00
638893	100.00	638995	100.20	639072	100.20	639338	99.70	639450	100.20
645802	100.30	647054	100.20	647262	100.00	647483	100.30	647498	100.00
647709	100.20	647846	100.40	647964	100.30	648165	99.30	648317	100.00
648338	100.30	648541	100.00	648608	100.00	648707	100.10	648751	100.20
648760	99.90	648873	100.10	649072	100.20	649208	100.10	649367	99.40
649488	99.70	649489	100.00	649503	100.00	649543	100.00	649570	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.13
3 Sum of Squared Measurements	750633.00
4 Correction Factor (CF): Sum of Measurements Squared / N	750626.13
5 Corrected Sum of Squares (SS)	6.87
6 Variance (V) : SS/(N-1)	0.0928
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3047
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.43
12 Quality Index Lower (QL): (XBAR-L) / S	6.70
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1617 Lot Descr: LG&E MSII-5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
649847	100.20	649936	100.30	650324	100.00	650395	100.30	650621	100.10
650719	100.20	650754	100.40	650893	100.10	650942	100.10	650987	100.30
651032	100.30	651107	100.20	651180	100.20	651613	100.20	651855	100.10
651873	100.20	652231	99.80	652235	100.00	652270	99.90	652328	100.10
652453	100.00	652550	100.20	652572	100.10	652802	100.00	652809	100.10
652827	99.90	652838	100.10	652840	100.10	652891	100.40	652935	99.80
653045	100.20	653104	99.80	653299	99.90	653352	100.10	653395	100.00
653399	100.00	653572	100.12	653605	100.40	653770	100.00	653798	99.80
653828	100.00	653868	99.80	653958	100.10	654114	99.80	654158	100.20
658633	99.20	658839	100.20	658914	100.40	658988	100.60	659012	100.30
659242	100.50	659352	100.30	659455	100.20	659489	100.60	659835	100.10
660377	100.60	660832	100.20	660869	100.40	660907	100.30	671349	100.20
671462	99.90	671766	100.00	671930	100.10	672561	100.20	672585	100.10
672595	99.90	672660	100.20	672699	100.10	672965	100.10	673069	99.90
673185	100.10	673533	100.20	673980	100.00	673988	100.10	674026	100.10

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7509.02
3 Sum of Squared Measurements	751808.54
4 Correction Factor (CF): Sum of Measurements Squared / N	751805.08
5 Corrected Sum of Squares (SS)	3.46
6 Variance (V) : SS/(N-1)	0.0468
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2162
8 Sample Mean(XBAR): Sum X/N	100.12
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.69
12 Quality Index Lower (QL): (XBAR-L) / S	9.81
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MSII Division: 01 Sample Lot: 1618 Lot Descr: LG&E MSII-6
 In Service Population: 1,934 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 46

Run Date: 01/04/2016

Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
674515	100.10	674536	100.00	674620	100.20	674632	100.00	674634	100.10
674680	100.10	674735	100.30	674742	99.90	674755	100.00	674774	100.00
674783	100.10	674873	100.20	674904	100.10	674906	100.10	674942	100.20
675140	100.10	675199	100.20	675227	100.20	675257	100.30	675281	99.90
675345	99.95	675427	99.90	675445	100.20	675452	100.07	675510	100.30
675580	100.40	675632	100.20	675693	100.00	675719	100.00	675736	100.20
675882	100.30	675922	100.20	675927	100.10	675995	100.30	676006	100.30
676017	100.10	676032	100.30	676102	100.00	676193	100.10	676214	100.20
676318	100.00	676333	100.20	676356	100.10	676385	100.30	676402	100.40
676408	100.14	676451	100.10	676499	100.10	676519	100.26	676554	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5007.22
3 Sum of Squared Measurements	501445.89
4 Correction Factor (CF): Sum of Measurements Squared / N	501445.04
5 Corrected Sum of Squares (SS)	0.85
6 Variance (V) : SS/(N-1)	0.0174
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1319
8 Sample Mean(XBAR): Sum X/N	100.14
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	14.07
12 Quality Index Lower (QL): (XBAR-L) / S	16.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1619 Lot Descr: LG&E MX-1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
702715	100.00	702801	100.00	702962	100.00	703125	99.60	703453	100.10
703568	100.00	703572	99.90	703999	99.80	704124	99.80	704363	99.30
704588	99.90	704620	100.00	704635	99.70	704955	100.10	704957	99.90
705012	100.00	705204	100.00	708715	100.00	709228	99.90	709534	100.00
709809	99.80	709895	99.80	710036	99.60	710129	99.30	710139	99.40
710457	99.50	710865	100.00	710968	99.70	711025	100.40	711993	99.97
712117	100.10	712129	99.80	712151	100.00	712187	99.90	712383	99.70
712481	99.70	712508	99.40	712558	100.20	712567	99.70	712853	100.20
712855	99.70	713033	100.30	713213	100.20	713230	99.70	713326	99.60
713346	99.80	713447	99.76	713670	100.20	713931	100.10	714039	100.00
714453	99.90	714513	99.40	714555	100.00	714670	99.80	714757	100.00
714776	99.60	714887	99.90	715031	99.50	715104	99.35	715248	99.60
715289	100.00	715304	100.10	715419	99.60	715659	100.70	715671	99.50
715737	99.60	715838	99.30	715905	99.90	715912	99.70	716001	100.00
716172	99.80	716464	99.80	716630	99.20	716737	99.80	716806	99.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7486.68
3 Sum of Squared Measurements	747344.50
4 Correction Factor (CF): Sum of Measurements Squared / N	747338.37
5 Corrected Sum of Squares (SS)	6.14
6 Variance (V) : SS/(N-1)	0.0829
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2879
8 Sample Mean(XBAR): Sum X/N	99.82
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.56
12 Quality Index Lower (QL): (XBAR-L) / S	6.33
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200	Model Number: MX	Division: 01	Sample Lot: 1620	Lot Descr: LG&E MX-2
In Service Population: 10,000	Sample Quantity: 75	Meters Tested: 75	Pass/ Fail: PASS	

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 48
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
716917	99.60	717180	100.30	717407	99.70	717560	99.60	717692	99.80
717740	99.70	717891	99.70	717960	99.70	718024	99.90	718335	99.40
718379	99.70	718465	99.50	718718	100.00	718740	99.81	718751	99.90
718812	99.70	718831	99.80	718941	99.90	718968	100.10	719168	99.60
719254	99.90	719265	100.20	719356	99.90	719568	99.60	719660	99.70
719772	99.60	720093	99.30	720570	99.80	720935	99.70	720952	100.00
721038	99.60	721114	99.80	721146	99.40	721545	99.80	721860	99.80
721901	99.90	722086	99.60	722122	99.70	722212	99.70	722291	99.80
722485	99.70	722582	99.70	722685	99.90	722693	99.60	722816	99.70
723084	99.60	723366	99.90	815176	99.70	815195	99.90	815294	99.70
815317	99.30	815709	99.70	815824	99.10	816026	99.50	816238	99.50
816509	99.40	816568	99.90	816592	99.40	816720	99.90	816741	99.90
816847	99.80	817110	99.72	817234	100.00	817366	99.70	817620	99.70
817885	99.40	817956	99.80	818231	99.50	818461	99.80	818490	99.80
819335	100.00	819540	99.90	819691	99.90	819709	99.90	819729	99.00

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7479.13
3 Sum of Squared Measurements	745835.49
4 Correction Factor (CF): Sum of Measurements Squared / N	745831.81
5 Corrected Sum of Squares (SS)	3.69
6 Variance (V) : SS/(N-1)	0.0498
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2232
8 Sample Mean(XBAR): Sum X/N	99.72
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.21
12 Quality Index Lower (QL): (XBAR-L) / S	7.71
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
 2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1621 Lot Descr: LG&E MX-3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
819852	99.60	820030	99.90	820069	99.80	820128	99.60	820263	99.30
820309	100.20	820311	99.80	820322	100.00	820635	99.80	820745	99.70
820804	99.90	821053	99.60	821365	100.10	821608	99.30	821887	99.90
822044	99.70	822508	100.00	822753	99.60	823082	99.40	824405	99.80
824558	99.50	824821	99.60	825463	99.40	825524	99.60	825624	99.20
825763	99.80	825788	99.60	825795	99.80	825856	99.70	825858	99.80
825882	99.60	825906	99.90	825977	99.80	826209	99.30	826264	99.60
826270	100.00	826298	99.60	826750	99.80	826782	99.40	826838	99.60
826993	99.40	827089	99.60	827271	99.50	827308	99.10	827414	99.90
827502	99.40	827632	99.60	827873	99.70	828021	99.60	830216	99.80
830301	99.30	830488	99.60	830667	99.80	830838	99.40	831043	99.60
831140	99.80	831141	99.30	831465	100.00	831471	99.10	831660	99.40
831706	100.00	831778	99.70	831803	100.00	836591	99.80	836731	99.80
836825	99.70	836983	100.00	837056	99.90	837077	99.70	837078	99.60
837094	100.00	837215	99.60	837330	99.70	837552	99.90	837727	99.90

INFORMATION NEEDED	VALUE OBTAINED
1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7475.80
3 Sum of Squared Measurements	745172.02
4 Correction Factor (CF): Sum of Measurements Squared / N	745167.81
5 Corrected Sum of Squares (SS)	4.21
6 Variance (V) : SS/(N-1)	0.0569
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2386
8 Sample Mean(XBAR): Sum X/N	99.68
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.74
12 Quality Index Lower (QL): (XBAR-L) / S	7.03
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric

2015 Sample Test Program (01/01/2015) to (12/31/2015)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 1622 Lot Descr: LG&E MX-4
 In Service Population: 2,179 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 50
 Run Date: 01/04/2016
 Run Time: 08:37:10 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
837821	99.90	837950	99.90	838093	99.90	838094	99.90	838105	100.00
838126	99.70	838128	99.60	838996	99.50	839036	99.60	839169	99.90
839223	99.90	839252	99.70	839269	99.70	839344	99.40	839350	99.70
839354	99.70	839412	99.91	839443	100.00	839538	99.80	839596	99.90
839612	100.00	839647	99.70	839662	99.80	839689	99.70	839728	99.70
839750	100.10	839753	99.80	839844	99.50	839864	100.00	839892	99.90
839927	100.00	839959	99.80	840014	99.80	840080	99.90	840118	99.80
840126	99.90	840351	99.80	840358	99.90	840382	99.60	840421	99.90
840460	100.00	840548	99.70	840623	99.70	840641	99.90	840757	99.80
840759	99.80	840774	99.80	840791	99.70	840816	99.90	840866	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4990.21
3 Sum of Squared Measurements	498044.98
4 Correction Factor (CF): Sum of Measurements Squared / N	498043.92
5 Corrected Sum of Squares (SS)	1.06
6 Variance (V) : SS/(N-1)	0.0217
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1472
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	14.92
12 Quality Index Lower (QL): (XBAR-L) / S	12.26
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Louisville Gas and Electric
2015 Sample Test Program (01/01/2015) to (12/31/2015)

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	SET	REMV	MTRS TST	PASS/FAIL	LOT NUMBER
LG&E AB1-1	Westinghouse	AB1	142	10	0	0	10	FAIL TESTING COMPLETE	1573
LG&E ALF-1	Landis + Gyr	ALF (Trilliant)	667	35	0	0	35	PASS TESTING COMPLETE	1574
LG&E C1S-1	Itron	C1SR (ERT)	10,000	75	0	0	75	PASS TESTING COMPLETE	1575
LG&E C1S-2	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1576
LG&E C1S-3	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1577
LG&E C1S-4	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	1578
LG&E C1S-5	Itron	C1S	3,807	75	0	0	75	PASS TESTING COMPLETE	1579
LG&E D4S-1	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1580
LG&E D4S-2	Westinghouse	D4S	2,660	50	0	0	50	PASS TESTING COMPLETE	1581
LG&E I210-1	General Electric	I-210 (ERT)	1,077	35	0	0	35	PASS TESTING COMPLETE	1582
LG&E I50-1	General Electric	I-50S	1,011	35	0	0	35	PASS TESTING COMPLETE	1583
LG&E I55-1	General Electric	I-55S	1,294	50	0	0	50	PASS TESTING COMPLETE	1584
LG&E I60-1	General Electric	I-60S	10,000	75	0	0	75	PASS TESTING COMPLETE	1585
LG&E I60-2	General Electric	I-60S	2,539	50	0	0	50	PASS TESTING COMPLETE	1586
LG&E I70-1	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1587
LG&E I70-2	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1588
LG&E I70-3	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1589
LG&E I70-4	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1590
LG&E I70-5	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1591
LG&E I70-6	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1592
LG&E I70-7	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1593
LG&E I70-8	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1594
LG&E I70-9	General Electric	I-70S	10,000	75	0	0	75	PASS TESTING COMPLETE	1595
LG&E I70-10	General Electric	I-70S	4,700	75	0	0	75	PASS TESTING COMPLETE	1596
LG&E J4S-1	Itron	J4S	10,000	75	0	0	75	PASS TESTING COMPLETE	1597
LG&E J4S-2	Itron	J4ES	1,039	35	0	0	35	PASS TESTING COMPLETE	1598
LG&E J5S-1	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1599
LG&E J5S-2	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1600
LG&E J5S-3	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1601
LG&E J5S-4	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1602
LG&E J5S-5	Itron	J5S (R200)	10,000	75	0	0	75	PASS TESTING COMPLETE	1603
LG&E J5S-6	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1604
LG&E J5S-7	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1605
LG&E J5S-8	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1606
LG&E J5S-9	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1607
LG&E J5S-10	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1608
LG&E J5S-11	Itron	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	1609
LG&E J5S-12	Itron	J5S	5,192	75	0	0	75	PASS TESTING COMPLETE	1610
LG&E MQS-1	Landis + Gyr	MQS	147	10	0	0	10	PASS TESTING COMPLETE	1611
LG&E MS-1	Landis + Gyr	MS	8,441	75	0	0	75	PASS TESTING COMPLETE	1612
LG&E MSII-1	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1613
LG&E MSII-2	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1614
LG&E MSII-3	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1615
LG&E MSII-4	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1616
LG&E MSII-5	Landis + Gyr	MSII	10,000	75	0	0	75	PASS TESTING COMPLETE	1617
LG&E MSII-6	Landis + Gyr	MSII	1,934	50	0	0	50	PASS TESTING COMPLETE	1618
LG&E MX-1	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1619
LG&E MX-2	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1620
LG&E MX-3	Landis + Gyr	MX	10,000	75	0	0	75	PASS TESTING COMPLETE	1621
LG&E MX-4	Landis + Gyr	MX	2,179	50	0	0	50	PASS TESTING COMPLETE	1622
TOTALS			386,829	3335	0	0	3335		

TOTAL LOTS PASSED: 49
TOTAL LOTS FAILED: 1
METERS CANNOT TEST: 0

Report completed successfully with results.