

RECEIVED

FEB 28 2017

PUBLIC SERVICE
COMMISSION



a PPL company

Dr. Talina Mathews, Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

February 28, 2017

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Kentucky Utilities Company
State Regulation and Rates
220 W. Main Street
PO Box 32010
Louisville, KY 40232
www.lge-ku.com

Rick E. Lovekamp
Manager Regulatory
Affairs/Tariffs
T 502-627-3780
F 502-627-3213
Rick.lovekamp@lge-ku.com

Annual Report – Kentucky Utilities Company

Dear Dr. Mathews:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), Kentucky Utilities Company submits the following:

The Certified Test Results of all new meters received - (Attachment A)

2016 Statistical Sampling Test Results and Summary - (Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

Rick E. Lovekamp

ATTACHMENT
A

Certified Test Results

LG&E and KU Energy LLC

5040 Annual Report of New Single Phase Meters

Last Data Update: 02/15/2017 02:18:35

Dynamic Filters

Plant: KU

Calendar Month/Year: 01/2016 - 12/2016

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
KU	C1S	2057940	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2057941	01/2016	01/13/2016	100.010	99.960	100.0	1
KU	C1S	2057942	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2057943	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2057944	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2057945	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2057946	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2057947	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2057948	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2057949	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2057950	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2057951	01/2016	01/13/2016	99.960	99.990	100.0	1
KU	C1S	2057952	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2057953	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2057954	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2057955	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2057956	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2057957	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2057958	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2057959	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2057960	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2057961	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2057962	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2057963	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2057964	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2057965	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2057966	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2057967	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2057968	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2057969	01/2016	01/13/2016	100.030	100.080	100.1	1
KU	C1S	2057970	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2057971	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2057972	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2057973	01/2016	01/13/2016	100.000	100.010	100.0	1

KU	C1S	2057974	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2057975	01/2016	01/13/2016	100.030	100.000	100.1	1
KU	C1S	2057976	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2057977	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2057978	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2057979	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2057980	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2057981	01/2016	01/13/2016	100.020	100.070	100.1	1
KU	C1S	2057982	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2057983	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2057984	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2057985	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2057986	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2057987	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2057988	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2057989	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2057990	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2057991	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2057992	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2057993	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2057994	01/2016	01/13/2016	99.980	99.960	100.0	1
KU	C1S	2057995	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2057996	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2057997	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2057998	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2057999	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058000	01/2016	01/13/2016	99.940	100.000	100.0	1
KU	C1S	2058001	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058002	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058003	01/2016	01/13/2016	100.020	100.070	100.0	1
KU	C1S	2058004	01/2016	01/13/2016	99.980	100.060	100.0	1
KU	C1S	2058005	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058006	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2058007	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058008	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058009	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058010	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058011	01/2016	01/13/2016	100.010	100.010	100.2	1
KU	C1S	2058012	01/2016	01/13/2016	100.040	99.960	100.0	1
KU	C1S	2058013	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2058014	01/2016	01/13/2016	100.000	100.000	100.1	1
KU	C1S	2058015	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058016	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058017	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2058018	01/2016	01/13/2016	100.000	100.020	100.1	1

KU	C1S	2058019	01/2016	01/13/2016	99.990	100.000	100.1	1
KU	C1S	2058020	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058021	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058022	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058023	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058024	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058025	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058026	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2058027	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058028	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058029	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058030	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2058031	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058032	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2058033	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058034	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058035	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058036	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058037	01/2016	01/13/2016	100.000	100.060	100.0	1
KU	C1S	2058038	01/2016	01/13/2016	100.020	100.050	100.1	1
KU	C1S	2058039	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2058040	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2058041	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058042	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058043	01/2016	01/13/2016	99.970	100.010	100.1	1
KU	C1S	2058044	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058045	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058046	01/2016	01/13/2016	99.970	100.020	100.1	1
KU	C1S	2058047	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058048	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058049	01/2016	01/13/2016	100.000	100.000	100.1	1
KU	C1S	2058050	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2058051	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058052	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2058053	01/2016	01/13/2016	100.010	100.010	100.1	1
KU	C1S	2058054	01/2016	01/13/2016	100.010	100.040	100.1	1
KU	C1S	2058055	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058056	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058057	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058058	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058059	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058060	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058061	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058062	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058063	01/2016	01/13/2016	99.990	100.010	100.0	1

KU	C1S	2058064	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058065	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058066	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058067	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058068	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2058069	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058070	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058071	01/2016	01/13/2016	100.050	100.030	100.0	1
KU	C1S	2058072	01/2016	01/13/2016	99.990	100.000	100.1	1
KU	C1S	2058073	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058074	01/2016	01/13/2016	100.050	100.020	100.1	1
KU	C1S	2058075	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058076	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058077	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058078	01/2016	01/13/2016	100.020	100.030	100.1	1
KU	C1S	2058079	01/2016	01/13/2016	100.000	100.000	100.1	1
KU	C1S	2058080	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058081	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058082	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058083	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058084	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058085	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058086	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058087	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058088	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058089	01/2016	01/13/2016	99.960	100.050	100.0	1
KU	C1S	2058090	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058091	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058092	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058093	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058094	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058095	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058096	01/2016	01/13/2016	100.010	100.010	100.1	1
KU	C1S	2058097	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058098	01/2016	01/13/2016	100.050	100.010	100.0	1
KU	C1S	2058099	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058100	01/2016	01/13/2016	99.970	100.030	100.1	1
KU	C1S	2058101	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2058102	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058103	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058104	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058105	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058106	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058107	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2058108	01/2016	01/13/2016	100.000	99.990	100.0	1

KU	C1S	2058109	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058110	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058111	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058112	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058113	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058114	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058115	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058116	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058117	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058118	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2058119	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058120	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058121	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2058122	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058123	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058124	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2058125	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058126	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058127	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058128	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058129	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058130	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2058131	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058132	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058133	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058134	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058135	01/2016	01/13/2016	99.980	99.940	100.0	1
KU	C1S	2058136	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058137	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058138	01/2016	01/13/2016	99.960	99.990	100.0	1
KU	C1S	2058139	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058140	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058141	01/2016	01/13/2016	99.980	100.010	100.1	1
KU	C1S	2058142	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058143	01/2016	01/13/2016	99.970	100.020	100.1	1
KU	C1S	2058144	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2058145	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058146	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058147	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058148	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058149	01/2016	01/13/2016	100.020	100.010	100.1	1
KU	C1S	2058150	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058151	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2058152	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058153	01/2016	01/13/2016	100.000	100.000	100.1	1

KU	C1S	2058154	01/2016	01/13/2016	99.970	100.010	100.1	1
KU	C1S	2058155	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058156	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058157	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058158	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2058159	01/2016	01/13/2016	100.020	100.030	100.1	1
KU	C1S	2058160	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058161	01/2016	01/13/2016	100.020	100.030	100.1	1
KU	C1S	2058162	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058163	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2058164	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058165	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058166	01/2016	01/13/2016	100.000	99.950	100.0	1
KU	C1S	2058167	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058168	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058169	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058170	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058171	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058172	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058173	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058174	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058175	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058176	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058177	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2058178	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058179	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058180	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2058181	01/2016	01/13/2016	100.000	99.960	100.0	1
KU	C1S	2058182	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058183	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058184	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058185	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058186	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058187	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2058188	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058189	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058190	01/2016	01/13/2016	100.010	100.010	100.1	1
KU	C1S	2058191	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2058192	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058193	01/2016	01/13/2016	100.000	100.060	100.0	1
KU	C1S	2058194	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058195	01/2016	01/13/2016	99.930	99.950	100.0	1
KU	C1S	2058196	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058197	01/2016	01/13/2016	100.020	100.050	100.1	1
KU	C1S	2058198	01/2016	01/13/2016	99.970	100.010	100.0	1

KU	C1S	2058199	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058200	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058201	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058202	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058203	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058204	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058205	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2058206	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058207	01/2016	01/13/2016	99.950	99.960	100.0	1
KU	C1S	2058208	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058209	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058210	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058211	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058212	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058213	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058214	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058215	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058216	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058217	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058218	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058219	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058220	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058221	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2058222	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2058223	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058224	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058225	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058226	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058227	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058228	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058229	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2058230	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2058231	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058232	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058233	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058234	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058235	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058236	01/2016	01/13/2016	99.970	100.000	100.1	1
KU	C1S	2058237	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058238	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058239	01/2016	01/13/2016	99.980	99.970	100.0	1
KU	C1S	2058240	01/2016	01/13/2016	99.950	100.000	100.0	1
KU	C1S	2058241	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058242	01/2016	01/13/2016	100.040	99.980	100.0	1
KU	C1S	2058243	01/2016	01/13/2016	100.010	100.010	100.0	1

KU	C1S	2058244	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058245	01/2016	01/13/2016	100.020	100.030	100.1	1
KU	C1S	2058246	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058247	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058248	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058249	01/2016	01/13/2016	100.000	99.960	100.0	1
KU	C1S	2058250	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058251	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058252	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058253	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058254	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058255	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2058256	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058257	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058258	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058259	01/2016	01/13/2016	99.980	100.060	100.0	1
KU	C1S	2058260	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058261	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058262	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058263	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058264	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058265	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058266	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058267	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058268	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058269	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058270	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2058271	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2058272	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2058273	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058274	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058275	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2058276	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2058277	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058278	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058279	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058280	01/2016	01/13/2016	100.020	99.980	100.1	1
KU	C1S	2058281	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058282	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058283	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058284	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058285	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058286	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058287	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058288	01/2016	01/13/2016	99.980	100.020	100.0	1

KU	C1S	2058289	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058290	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058291	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058292	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058293	01/2016	01/13/2016	100.000	100.070	100.1	1
KU	C1S	2058294	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058295	01/2016	01/13/2016	99.980	100.040	100.1	1
KU	C1S	2058296	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058297	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2058298	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2058299	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058300	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058301	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058302	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2058303	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058304	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058305	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058306	01/2016	01/13/2016	99.960	100.010	100.0	1
KU	C1S	2058307	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2058308	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058309	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058310	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058311	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058312	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2058313	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058314	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058315	01/2016	01/13/2016	100.050	100.010	100.0	1
KU	C1S	2058316	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058317	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058318	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058319	01/2016	01/13/2016	100.030	100.020	100.1	1
KU	C1S	2058320	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058321	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058322	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2058323	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058324	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2058325	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2058326	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058327	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058328	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058329	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058330	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2058331	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058332	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058333	01/2016	01/13/2016	100.020	99.980	100.0	1

KU	C1S	2058334	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2058335	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2058336	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2058337	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2058338	01/2016	01/13/2016	100.030	100.020	100.1	1
KU	C1S	2058339	01/2016	01/13/2016	100.020	100.000	100.1	1
KU	C1S	2058340	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058341	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058342	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058343	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058344	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058345	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058346	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2058347	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058348	01/2016	01/13/2016	99.990	100.010	100.1	1
KU	C1S	2058349	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058350	01/2016	01/13/2016	100.040	99.990	100.0	1
KU	C1S	2058351	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2058352	01/2016	01/13/2016	100.030	99.970	100.0	1
KU	C1S	2058353	01/2016	01/13/2016	99.980	99.970	100.0	1
KU	C1S	2058354	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058355	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058356	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058357	01/2016	01/13/2016	100.030	99.970	100.0	1
KU	C1S	2058358	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058359	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058360	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058361	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058362	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058363	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058364	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058365	01/2016	01/13/2016	100.010	99.990	100.1	1
KU	C1S	2058366	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2058367	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058368	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058369	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058370	01/2016	01/13/2016	100.020	100.000	100.1	1
KU	C1S	2058371	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058372	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058373	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058374	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058375	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058376	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2058377	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058378	01/2016	01/13/2016	100.000	100.010	100.0	1

KU	C1S	2058379	01/2016	01/13/2016	99.980	100.020	100.1	1
KU	C1S	2058380	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058381	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058382	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058383	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058384	01/2016	01/13/2016	100.010	99.970	100.1	1
KU	C1S	2058385	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058386	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058387	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058388	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058389	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058390	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058391	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058392	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058393	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058394	01/2016	01/13/2016	99.980	100.020	100.1	1
KU	C1S	2058395	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058396	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2058397	01/2016	01/13/2016	100.050	100.020	100.1	1
KU	C1S	2058398	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058399	01/2016	01/13/2016	100.040	100.000	100.1	1
KU	C1S	2058400	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058401	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058402	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058403	01/2016	01/13/2016	99.950	100.030	100.0	1
KU	C1S	2058404	01/2016	01/13/2016	99.980	100.010	100.1	1
KU	C1S	2058405	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058406	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058407	01/2016	01/13/2016	100.010	99.990	100.1	1
KU	C1S	2058408	01/2016	01/13/2016	100.000	100.000	100.1	1
KU	C1S	2058409	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2058410	01/2016	01/13/2016	100.030	100.030	100.1	1
KU	C1S	2058411	01/2016	01/13/2016	99.960	100.030	100.0	1
KU	C1S	2058412	01/2016	01/13/2016	99.980	100.030	100.1	1
KU	C1S	2058413	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058414	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058415	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058416	01/2016	01/13/2016	99.960	100.040	100.1	1
KU	C1S	2058417	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058418	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058419	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058420	01/2016	01/13/2016	99.980	100.050	100.1	1
KU	C1S	2058421	01/2016	01/13/2016	99.960	99.980	100.0	1
KU	C1S	2058422	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058423	01/2016	01/13/2016	100.020	99.990	100.0	1

KU	C1S	2058424	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058425	01/2016	01/13/2016	99.990	100.000	100.1	1
KU	C1S	2058426	01/2016	01/13/2016	99.990	100.010	100.1	1
KU	C1S	2058427	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058428	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058429	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058430	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058431	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2058432	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058433	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058434	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058435	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2058436	01/2016	01/13/2016	100.000	100.060	100.1	1
KU	C1S	2058437	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2058438	01/2016	01/13/2016	99.980	99.970	100.1	1
KU	C1S	2058439	01/2016	01/13/2016	100.010	100.010	100.1	1
KU	C1S	2058440	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058441	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058442	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058443	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058444	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058445	01/2016	01/13/2016	99.960	99.970	100.0	1
KU	C1S	2058446	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2058447	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058448	01/2016	01/13/2016	99.980	99.970	100.1	1
KU	C1S	2058449	01/2016	01/13/2016	100.020	100.050	100.1	1
KU	C1S	2058450	01/2016	01/13/2016	100.030	100.030	100.1	1
KU	C1S	2058451	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058452	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2058453	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058454	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058455	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058456	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058457	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2058458	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058459	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058460	01/2016	01/13/2016	99.990	99.960	100.0	1
KU	C1S	2058461	01/2016	01/13/2016	100.010	99.950	100.0	1
KU	C1S	2058462	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058463	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2058464	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058465	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058466	01/2016	01/13/2016	100.010	99.960	100.0	1
KU	C1S	2058467	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2058468	01/2016	01/13/2016	100.030	100.010	100.0	1

KU	C1S	2058469	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058470	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058471	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058472	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058473	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058474	01/2016	01/13/2016	100.050	100.020	100.0	1
KU	C1S	2058475	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058476	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058477	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058478	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058479	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058480	01/2016	01/13/2016	99.950	100.040	100.0	1
KU	C1S	2058481	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058482	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058483	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058484	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058485	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058486	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058487	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058488	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2058489	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058490	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058491	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058492	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058493	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2058494	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058495	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058496	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058497	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058498	01/2016	01/13/2016	99.970	99.970	100.0	1
KU	C1S	2058499	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2058500	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058501	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058502	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058503	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058504	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058505	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058506	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058507	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058508	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058509	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058510	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058511	01/2016	01/13/2016	99.960	100.060	100.0	1
KU	C1S	2058512	01/2016	01/13/2016	100.040	100.030	100.1	1
KU	C1S	2058513	01/2016	01/13/2016	100.000	100.030	100.0	1

KU	C1S	2058514	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058515	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058516	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058517	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2058518	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058519	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058520	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058521	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058522	01/2016	01/13/2016	99.990	100.070	100.0	1
KU	C1S	2058523	01/2016	01/13/2016	100.010	100.070	100.1	1
KU	C1S	2058524	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058525	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058526	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2058527	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058528	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058529	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058530	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058531	01/2016	01/13/2016	100.050	99.990	100.0	1
KU	C1S	2058532	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058533	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058534	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058535	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058536	01/2016	01/13/2016	100.020	99.980	100.1	1
KU	C1S	2058537	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058538	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058539	01/2016	01/13/2016	99.960	100.010	100.0	1
KU	C1S	2058540	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2058541	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058542	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058543	01/2016	01/13/2016	100.020	100.050	100.1	1
KU	C1S	2058544	01/2016	01/13/2016	99.950	100.020	100.0	1
KU	C1S	2058545	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058546	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058547	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058548	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058549	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058550	01/2016	01/13/2016	100.000	100.080	100.0	1
KU	C1S	2058551	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058552	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058553	01/2016	01/13/2016	100.030	100.070	100.1	1
KU	C1S	2058554	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2058555	01/2016	01/13/2016	99.970	100.010	100.1	1
KU	C1S	2058556	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058557	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058558	01/2016	01/13/2016	100.000	99.960	100.0	1

KU	C1S	2058559	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058560	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058561	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058562	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058563	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058564	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058565	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2058566	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2058567	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058568	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058569	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058570	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058571	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058572	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058573	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058574	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058575	01/2016	01/13/2016	100.000	100.070	100.1	1
KU	C1S	2058576	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2058577	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058578	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058579	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058580	01/2016	01/13/2016	100.040	100.060	100.0	1
KU	C1S	2058581	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058582	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058583	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058584	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058585	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058586	01/2016	01/13/2016	99.980	100.040	100.1	1
KU	C1S	2058587	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058588	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058589	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058590	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058591	01/2016	01/13/2016	99.990	99.950	100.0	1
KU	C1S	2058592	01/2016	01/13/2016	100.010	100.000	100.1	1
KU	C1S	2058593	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058594	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058595	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058596	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058597	01/2016	01/13/2016	99.970	100.060	100.1	1
KU	C1S	2058598	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058599	01/2016	01/13/2016	100.020	100.040	100.1	1
KU	C1S	2058600	01/2016	01/13/2016	100.050	100.040	100.0	1
KU	C1S	2058601	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2058602	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2058603	01/2016	01/13/2016	99.970	100.030	100.0	1

KU	C1S	2058604	01/2016	01/13/2016	99.980	-100.030	100.0	1
KU	C1S	2058605	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058606	01/2016	01/13/2016	99.960	100.060	100.0	1
KU	C1S	2058607	01/2016	01/13/2016	100.030	100.050	100.1	1
KU	C1S	2058608	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058609	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058610	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058611	01/2016	01/13/2016	100.030	100.050	100.0	1
KU	C1S	2058612	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058613	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2058614	01/2016	01/13/2016	99.950	100.030	100.0	1
KU	C1S	2058615	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058616	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058617	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058618	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058619	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058620	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058621	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058622	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058623	01/2016	01/13/2016	100.020	100.060	100.0	1
KU	C1S	2058624	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2058625	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058626	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2058627	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058628	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058629	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058630	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058631	01/2016	01/13/2016	100.030	99.970	100.0	1
KU	C1S	2058632	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058633	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058634	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058635	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2058636	01/2016	01/13/2016	100.000	100.040	99.9	1
KU	C1S	2058637	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058638	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2058639	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058640	01/2016	01/13/2016	100.020	100.070	100.0	1
KU	C1S	2058641	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058642	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2058643	01/2016	01/13/2016	100.000	100.020	99.9	1
KU	C1S	2058644	01/2016	01/13/2016	100.030	100.030	100.1	1
KU	C1S	2058645	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058646	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058647	01/2016	01/13/2016	99.980	100.030	99.9	1
KU	C1S	2058648	01/2016	01/13/2016	99.990	100.000	100.0	1

KU	C1S	2058649	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058650	01/2016	01/13/2016	99.980	100.020	100.1	1
KU	C1S	2058651	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058652	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058653	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058654	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058655	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058656	01/2016	01/13/2016	99.980	99.970	100.0	1
KU	C1S	2058657	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058658	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058659	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058660	01/2016	01/13/2016	99.990	100.000	99.9	1
KU	C1S	2058661	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058662	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058663	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058664	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058665	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058666	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058667	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058668	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058669	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058670	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058671	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058672	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058673	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2058674	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2058675	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058676	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2058677	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058678	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2058679	01/2016	01/13/2016	99.980	100.040	100.1	1
KU	C1S	2058680	01/2016	01/13/2016	99.940	99.980	100.0	1
KU	C1S	2058681	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058682	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2058683	01/2016	01/13/2016	100.000	100.070	100.0	1
KU	C1S	2058684	01/2016	01/13/2016	99.980	100.010	100.1	1
KU	C1S	2058685	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058686	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058687	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058688	01/2016	01/13/2016	100.020	100.010	100.1	1
KU	C1S	2058689	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058690	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058691	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058692	01/2016	01/13/2016	100.050	100.030	100.1	1
KU	C1S	2058693	01/2016	01/13/2016	100.010	100.020	100.1	1

KU	C1S	2058694	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058695	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058696	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058697	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058698	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058699	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058700	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058701	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058702	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058703	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2058704	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058705	01/2016	01/13/2016	99.970	99.970	100.0	1
KU	C1S	2058706	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058707	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2058708	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058709	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058710	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058711	01/2016	01/13/2016	100.050	100.020	100.0	1
KU	C1S	2058712	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058713	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058714	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058715	01/2016	01/13/2016	100.050	100.010	100.0	1
KU	C1S	2058716	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058717	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058718	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2058719	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058720	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058721	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058722	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058723	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2058724	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058725	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058726	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058727	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058728	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058729	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058730	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058731	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058732	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058733	01/2016	01/13/2016	100.000	100.080	100.1	1
KU	C1S	2058734	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058735	01/2016	01/13/2016	100.050	100.000	100.0	1
KU	C1S	2058736	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058737	01/2016	01/13/2016	100.020	99.940	100.0	1
KU	C1S	2058738	01/2016	01/13/2016	99.990	100.030	100.0	1

KU	C1S	2058739	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058740	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058741	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058742	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058743	01/2016	01/13/2016	100.030	100.050	100.0	1
KU	C1S	2058744	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058745	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058746	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058747	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058748	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2058749	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058750	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058751	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058752	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058753	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058754	01/2016	01/13/2016	99.980	99.970	100.0	1
KU	C1S	2058755	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058756	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058757	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058758	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2058759	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058760	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058761	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058762	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058763	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058764	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058765	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058766	01/2016	01/13/2016	100.040	100.040	100.0	1
KU	C1S	2058767	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058768	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058769	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058770	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058771	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058772	01/2016	01/13/2016	100.030	100.020	100.1	1
KU	C1S	2058773	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058774	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058775	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058776	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058777	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2058778	01/2016	01/13/2016	99.990	100.050	100.1	1
KU	C1S	2058779	01/2016	01/13/2016	100.050	100.050	100.0	1
KU	C1S	2058780	01/2016	01/13/2016	99.960	100.030	100.0	1
KU	C1S	2058781	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058782	01/2016	01/13/2016	100.030	99.940	100.0	1
KU	C1S	2058783	01/2016	01/13/2016	100.020	100.010	100.0	1

KU	C1S	2058784	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058785	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058786	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2058787	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058788	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058789	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058790	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058791	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058792	01/2016	01/13/2016	100.000	100.070	100.1	1
KU	C1S	2058793	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058794	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058795	01/2016	01/13/2016	100.030	100.060	100.0	1
KU	C1S	2058796	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058797	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058798	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058799	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058800	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058801	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058802	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058803	01/2016	01/13/2016	100.000	100.060	100.0	1
KU	C1S	2058804	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058805	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2058806	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058807	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058808	01/2016	01/13/2016	100.000	100.060	100.1	1
KU	C1S	2058809	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058810	01/2016	01/13/2016	100.030	100.050	100.0	1
KU	C1S	2058811	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2058812	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058813	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058814	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058815	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2058816	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058817	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2058818	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058819	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058820	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2058821	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058822	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058823	01/2016	01/13/2016	100.010	100.010	100.1	1
KU	C1S	2058824	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058825	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058826	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058827	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058828	01/2016	01/13/2016	99.980	99.960	100.0	1

KU	C1S	2058829	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058830	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058831	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058832	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058833	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2058834	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058835	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058836	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2058837	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058838	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058839	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058840	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058841	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058842	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058843	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058844	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058845	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058846	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2058847	01/2016	01/13/2016	100.000	100.060	100.1	1
KU	C1S	2058848	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2058849	01/2016	01/13/2016	99.980	100.070	100.0	1
KU	C1S	2058850	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2058851	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058852	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2058853	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2058854	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2058855	01/2016	01/13/2016	100.060	100.010	100.0	1
KU	C1S	2058856	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058857	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2058858	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058859	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058860	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2058861	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058862	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058863	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058864	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2058865	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2058866	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058867	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058868	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058869	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058870	01/2016	01/13/2016	99.980	100.050	100.1	1
KU	C1S	2058871	01/2016	01/13/2016	99.970	99.970	100.0	1
KU	C1S	2058872	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058873	01/2016	01/13/2016	99.990	100.060	100.1	1

KU	C1S	2058874	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058875	01/2016	01/13/2016	100.040	99.990	100.0	1
KU	C1S	2058876	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2058877	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058878	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2058879	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058880	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058881	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058882	01/2016	01/13/2016	99.980	100.050	100.1	1
KU	C1S	2058883	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058884	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058885	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2058886	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058887	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058888	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058889	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058890	01/2016	01/13/2016	100.010	100.040	100.1	1
KU	C1S	2058891	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058892	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2058893	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058894	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2058895	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058896	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058897	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058898	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058899	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058900	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2058901	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2058902	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2058903	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058904	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2058905	01/2016	01/13/2016	99.950	100.000	100.0	1
KU	C1S	2058906	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058907	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058908	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058909	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2058910	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058911	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058912	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058913	01/2016	01/13/2016	99.990	100.050	100.1	1
KU	C1S	2058914	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2058915	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058916	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058917	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2058918	01/2016	01/13/2016	100.000	100.030	100.0	1

KU	C1S	2058919	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2058920	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2058921	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058922	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058923	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2058924	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058925	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058926	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058927	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058928	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058929	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058930	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058931	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058932	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058933	01/2016	01/13/2016	99.960	100.010	100.0	1
KU	C1S	2058934	01/2016	01/13/2016	99.970	100.030	100.1	1
KU	C1S	2058935	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2058936	01/2016	01/13/2016	99.980	100.060	100.1	1
KU	C1S	2058937	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058938	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2058939	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2058940	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2058941	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058942	01/2016	01/13/2016	100.050	99.990	100.0	1
KU	C1S	2058943	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058944	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058945	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058946	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058947	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2058948	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058949	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2058950	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058951	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058952	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058953	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2058954	01/2016	01/13/2016	99.990	99.960	100.0	1
KU	C1S	2058955	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2058956	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058957	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058958	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2058959	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2058960	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2058961	01/2016	01/13/2016	99.980	100.020	100.1	1
KU	C1S	2058962	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2058963	01/2016	01/13/2016	99.990	100.020	100.0	1

KU	C1S	2058964	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058965	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058966	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058967	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058968	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2058969	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2058970	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2058971	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2058972	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058973	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058974	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2058975	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2058976	01/2016	01/13/2016	100.040	99.990	100.0	1
KU	C1S	2058977	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2058978	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2058979	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058980	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2058981	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2058982	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2058983	01/2016	01/13/2016	99.990	99.960	100.0	1
KU	C1S	2058984	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2058985	01/2016	01/13/2016	100.040	99.980	100.0	1
KU	C1S	2058986	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2058987	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2058988	01/2016	01/13/2016	100.000	100.080	100.1	1
KU	C1S	2058989	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2058990	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2058991	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058992	01/2016	01/13/2016	99.940	100.020	100.0	1
KU	C1S	2058993	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2058994	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2058995	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058996	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2058997	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2058998	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2058999	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059000	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059001	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059002	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2059003	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059004	01/2016	01/13/2016	100.030	100.040	100.1	1
KU	C1S	2059005	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059006	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059007	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2059008	01/2016	01/13/2016	99.990	100.060	100.0	1

KU	C1S	2059009	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059010	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059011	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059012	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2059013	01/2016	01/13/2016	100.020	100.060	100.0	1
KU	C1S	2059014	01/2016	01/13/2016	100.030	100.010	100.1	1
KU	C1S	2059015	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2059016	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059017	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059018	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059019	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059020	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059021	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059022	01/2016	01/13/2016	100.060	100.020	100.0	1
KU	C1S	2059023	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059024	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059025	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059026	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059027	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059028	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059029	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2059030	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2059031	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059032	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059033	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059034	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2059035	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2059036	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059037	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059038	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059039	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059040	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059041	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059042	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059043	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059044	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059045	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059046	01/2016	01/13/2016	99.980	100.060	100.0	1
KU	C1S	2059047	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059048	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059049	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059050	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059051	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059052	01/2016	01/13/2016	100.020	100.050	100.1	1
KU	C1S	2059053	01/2016	01/13/2016	100.010	100.010	100.0	1

KU	C1S	2059054	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059055	01/2016	01/13/2016	99.960	100.050	100.0	1
KU	C1S	2059056	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2059057	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059058	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059059	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059060	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2059061	01/2016	01/13/2016	100.000	99.970	100.0	1
KU	C1S	2059062	01/2016	01/13/2016	100.040	99.990	100.0	1
KU	C1S	2059063	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059064	01/2016	01/13/2016	100.050	99.980	100.0	1
KU	C1S	2059065	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059066	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059067	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059068	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059069	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059070	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2059071	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059072	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059073	01/2016	01/13/2016	100.030	100.050	100.0	1
KU	C1S	2059074	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059075	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059076	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059077	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2059078	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059079	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059080	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059081	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059082	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059083	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059084	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059085	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059086	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059087	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059088	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059089	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059090	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059091	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059092	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059093	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059094	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059095	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059096	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059097	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059098	01/2016	01/13/2016	100.020	100.020	100.0	1

KU	C1S	2059099	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059100	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059101	01/2016	01/13/2016	100.000	99.980	100.1	1
KU	C1S	2059102	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059103	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059104	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2059105	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059106	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059107	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059108	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059109	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059110	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059111	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059112	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059113	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059114	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059115	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059116	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059117	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2059118	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059119	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059120	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059121	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059122	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059123	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059124	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059125	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059126	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059127	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059128	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059129	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059130	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059131	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059132	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059133	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059134	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059135	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059136	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059137	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059138	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059139	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059140	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059141	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2059142	01/2016	01/13/2016	99.990	99.960	100.0	1
KU	C1S	2059143	01/2016	01/13/2016	99.990	100.040	100.0	1

KU	C1S	2059144	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059145	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059146	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059147	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059148	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059149	01/2016	01/13/2016	99.950	99.970	100.0	1
KU	C1S	2059150	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059151	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059152	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059153	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2059154	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059155	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059156	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059157	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059158	01/2016	01/13/2016	99.990	100.000	100.1	1
KU	C1S	2059159	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059160	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059161	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059162	01/2016	01/13/2016	100.040	100.020	100.1	1
KU	C1S	2059163	01/2016	01/13/2016	100.030	100.000	100.1	1
KU	C1S	2059164	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059165	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2059166	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059167	01/2016	01/13/2016	100.010	99.960	100.0	1
KU	C1S	2059168	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059169	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059170	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2059171	01/2016	01/13/2016	100.040	100.020	100.1	1
KU	C1S	2059172	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2059173	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059174	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2059175	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059176	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059177	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059178	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059179	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059180	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059181	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059182	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2059183	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059184	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2059185	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059186	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2059187	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059188	01/2016	01/13/2016	100.010	99.960	100.0	1

KU	C1S	2059189	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2059190	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059191	01/2016	01/13/2016	100.000	100.000	100.1	1
KU	C1S	2059192	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059193	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059194	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059195	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059196	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059197	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059198	01/2016	01/13/2016	100.040	100.040	100.0	1
KU	C1S	2059199	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059200	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2059201	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059202	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059203	01/2016	01/13/2016	99.980	99.990	100.1	1
KU	C1S	2059204	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059205	01/2016	01/13/2016	100.070	100.030	100.1	1
KU	C1S	2059206	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059207	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059208	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059209	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059210	01/2016	01/13/2016	99.940	100.000	100.0	1
KU	C1S	2059211	01/2016	01/13/2016	99.980	99.950	100.0	1
KU	C1S	2059212	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059213	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2059214	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059215	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059216	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059217	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059218	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059219	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059220	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059221	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059222	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059223	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059224	01/2016	01/13/2016	99.960	99.980	100.0	1
KU	C1S	2059225	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059226	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059227	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059228	01/2016	01/13/2016	99.990	100.010	100.1	1
KU	C1S	2059229	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059230	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059231	01/2016	01/13/2016	100.050	100.020	100.0	1
KU	C1S	2059232	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059233	01/2016	01/13/2016	99.990	99.990	100.0	1

KU	C1S	2059234	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059235	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059236	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059237	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059238	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059239	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059240	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2059241	01/2016	01/13/2016	100.030	99.950	100.0	1
KU	C1S	2059242	01/2016	01/13/2016	99.990	100.010	100.1	1
KU	C1S	2059243	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059244	01/2016	01/13/2016	100.000	99.950	100.0	1
KU	C1S	2059245	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059246	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059247	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059248	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059249	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2059250	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059251	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2059252	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059253	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059254	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059255	01/2016	01/13/2016	100.060	100.040	100.1	1
KU	C1S	2059256	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059257	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059258	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059259	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2059260	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2059261	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059262	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059263	01/2016	01/13/2016	100.030	100.050	100.0	1
KU	C1S	2059264	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059265	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059266	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2059267	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059268	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059269	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059270	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2059271	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059272	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059273	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2059274	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059275	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059276	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059277	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059278	01/2016	01/13/2016	99.960	99.960	100.0	1

KU	C1S	2059279	01/2016	01/13/2016	100.030	100.000	100.1	1
KU	C1S	2059280	01/2016	01/13/2016	100.030	100.060	100.1	1
KU	C1S	2059281	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059282	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2059283	01/2016	01/13/2016	99.960	100.050	100.0	1
KU	C1S	2059284	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059285	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059286	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059287	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2059288	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059289	01/2016	01/13/2016	99.950	100.010	100.0	1
KU	C1S	2059290	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059291	01/2016	01/13/2016	99.980	100.040	100.1	1
KU	C1S	2059292	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059293	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059294	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059295	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059296	01/2016	01/13/2016	100.020	100.040	100.1	1
KU	C1S	2059297	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059298	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2059299	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059300	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059301	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059302	01/2016	01/13/2016	99.960	99.980	100.0	1
KU	C1S	2059303	01/2016	01/13/2016	99.970	100.000	100.1	1
KU	C1S	2059304	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2059305	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059306	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059307	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2059308	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2059309	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059310	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059311	01/2016	01/13/2016	100.000	99.960	100.0	1
KU	C1S	2059312	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2059313	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059314	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059315	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059316	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059317	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059318	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059319	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059320	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059321	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059322	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059323	01/2016	01/13/2016	100.020	100.060	100.1	1

KU	C1S	2059324	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059325	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2059326	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059327	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059328	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2059329	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059330	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059331	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059332	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059333	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059334	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059335	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059336	01/2016	01/13/2016	99.960	99.980	100.0	1
KU	C1S	2059337	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059338	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059339	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059340	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059341	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059342	01/2016	01/13/2016	100.010	100.040	100.1	1
KU	C1S	2059343	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059344	01/2016	01/13/2016	99.960	99.990	100.0	1
KU	C1S	2059345	01/2016	01/13/2016	100.030	100.050	100.1	1
KU	C1S	2059346	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2059347	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059348	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059349	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059350	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059351	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059352	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2059353	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2059354	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059355	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059356	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059357	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059358	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059359	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059360	01/2016	01/13/2016	99.950	100.030	100.0	1
KU	C1S	2059361	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059362	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059363	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2059364	01/2016	01/13/2016	99.990	100.090	100.0	1
KU	C1S	2059365	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059366	01/2016	01/13/2016	100.000	100.050	100.1	1
KU	C1S	2059367	01/2016	01/13/2016	100.040	100.060	100.0	1
KU	C1S	2059368	01/2016	01/13/2016	100.000	100.010	100.0	1

KU	C1S	2059369	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059370	01/2016	01/13/2016	100.020	100.050	100.0	1
KU	C1S	2059371	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059372	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2059373	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059374	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2059375	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059376	01/2016	01/13/2016	99.960	100.050	100.0	1
KU	C1S	2059377	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2059378	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059379	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059380	01/2016	01/13/2016	99.950	99.990	100.0	1
KU	C1S	2059381	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2059382	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059383	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059384	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059385	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059386	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059387	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059388	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059389	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059390	01/2016	01/13/2016	100.010	100.040	100.1	1
KU	C1S	2059391	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059392	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2059393	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059394	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059395	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059396	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2059397	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059398	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059399	01/2016	01/13/2016	99.990	99.970	100.0	1
KU	C1S	2059400	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059401	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2059402	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059403	01/2016	01/13/2016	100.030	100.030	100.1	1
KU	C1S	2059404	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059405	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059406	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059407	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059408	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2059409	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059410	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059411	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059412	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059413	01/2016	01/13/2016	100.020	99.990	99.9	1

KU	C1S	2059414	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059415	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059416	01/2016	01/13/2016	99.990	100.040	100.1	1
KU	C1S	2059417	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059418	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059419	01/2016	01/13/2016	100.020	100.020	100.1	1
KU	C1S	2059420	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059421	01/2016	01/13/2016	100.000	99.960	100.0	1
KU	C1S	2059422	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059423	01/2016	01/13/2016	99.960	100.000	100.0	1
KU	C1S	2059424	01/2016	01/13/2016	99.980	100.000	99.9	1
KU	C1S	2059425	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059426	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2059427	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059428	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059429	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059430	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059431	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059432	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059433	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059434	01/2016	01/13/2016	99.980	100.010	99.9	1
KU	C1S	2059435	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2059436	01/2016	01/13/2016	100.040	99.980	100.0	1
KU	C1S	2059437	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059438	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059439	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2059440	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059441	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059442	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2059443	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059444	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059445	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059446	01/2016	01/13/2016	99.990	100.010	100.1	1
KU	C1S	2059447	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059448	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059449	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059450	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059451	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059452	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059453	01/2016	01/13/2016	100.030	100.020	100.1	1
KU	C1S	2059454	01/2016	01/13/2016	100.000	100.020	100.1	1
KU	C1S	2059455	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2059456	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059457	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059458	01/2016	01/13/2016	99.990	100.020	100.0	1

KU	C1S	2059459	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059460	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059461	01/2016	01/13/2016	99.980	100.040	100.1	1
KU	C1S	2059462	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059463	01/2016	01/13/2016	99.960	100.030	100.1	1
KU	C1S	2059464	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059465	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059466	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059467	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059468	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059469	01/2016	01/13/2016	100.030	99.990	100.0	1
KU	C1S	2059470	01/2016	01/13/2016	99.970	100.030	100.1	1
KU	C1S	2059471	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059472	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059473	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059474	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059475	01/2016	01/13/2016	99.980	99.980	100.0	1
KU	C1S	2059476	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059477	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059478	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059479	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059480	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059481	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059482	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2059483	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2059484	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059485	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059486	01/2016	01/13/2016	99.990	100.050	100.1	1
KU	C1S	2059487	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059488	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059489	01/2016	01/13/2016	99.960	100.030	100.0	1
KU	C1S	2059490	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059491	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2059492	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2059493	01/2016	01/13/2016	100.010	100.060	100.1	1
KU	C1S	2059494	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059495	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059496	01/2016	01/13/2016	100.000	100.010	100.1	1
KU	C1S	2059497	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059498	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059499	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059500	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059501	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059502	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059503	01/2016	01/13/2016	100.020	100.020	100.0	1

KU	C1S	2059504	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059505	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059506	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059507	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059508	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059509	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059510	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059511	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059512	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059513	01/2016	01/13/2016	100.060	100.020	100.0	1
KU	C1S	2059514	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059515	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2059516	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059517	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059518	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059519	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059520	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059521	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059522	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059523	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059524	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059525	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059526	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059527	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059528	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059529	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059530	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059531	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059532	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059533	01/2016	01/13/2016	100.020	99.970	100.0	1
KU	C1S	2059534	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059535	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059536	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2059537	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059538	01/2016	01/13/2016	100.010	99.970	100.0	1
KU	C1S	2059539	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059540	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059541	01/2016	01/13/2016	99.980	100.050	100.0	1
KU	C1S	2059542	01/2016	01/13/2016	99.950	99.980	100.0	1
KU	C1S	2059543	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059544	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059545	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059546	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2059547	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059548	01/2016	01/13/2016	99.970	100.040	100.0	1

KU	C1S	2059549	01/2016	01/13/2016	100.020	100.060	100.1	1
KU	C1S	2059550	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059551	01/2016	01/13/2016	99.960	99.980	100.0	1
KU	C1S	2059552	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059553	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059554	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059555	01/2016	01/13/2016	100.000	100.030	100.1	1
KU	C1S	2059556	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2059557	01/2016	01/13/2016	100.050	99.980	100.0	1
KU	C1S	2059558	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059559	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059560	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059561	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059562	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059563	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059564	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059565	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059566	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059567	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059568	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059569	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059570	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059571	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059572	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2059573	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059574	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059575	01/2016	01/13/2016	100.030	100.030	100.0	1
KU	C1S	2059576	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059577	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059578	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059579	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059580	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059581	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059582	01/2016	01/13/2016	99.980	100.000	100.1	1
KU	C1S	2059583	01/2016	01/13/2016	99.990	100.050	100.1	1
KU	C1S	2059584	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059585	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059586	01/2016	01/13/2016	100.030	100.010	100.0	1
KU	C1S	2059587	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059588	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059589	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059590	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059591	01/2016	01/13/2016	100.040	100.000	100.0	1
KU	C1S	2059592	01/2016	01/13/2016	100.040	100.020	100.1	1
KU	C1S	2059593	01/2016	01/13/2016	100.030	100.030	100.0	1

KU	C1S	2059594	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059595	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2059596	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059597	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059598	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059599	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059600	01/2016	01/13/2016	99.950	100.020	100.0	1
KU	C1S	2059601	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059602	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059603	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059604	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059605	01/2016	01/13/2016	99.970	100.020	100.0	1
KU	C1S	2059606	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2059607	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059608	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059609	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059610	01/2016	01/13/2016	99.970	100.030	100.0	1
KU	C1S	2059611	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059612	01/2016	01/13/2016	100.020	100.030	100.0	1
KU	C1S	2059613	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059614	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059615	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059616	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059617	01/2016	01/13/2016	100.020	99.980	100.0	1
KU	C1S	2059618	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059619	01/2016	01/13/2016	100.000	100.060	100.0	1
KU	C1S	2059620	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059621	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059622	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059623	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059624	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059625	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059626	01/2016	01/13/2016	99.950	100.040	100.0	1
KU	C1S	2059627	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059628	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059629	01/2016	01/13/2016	100.040	100.020	100.0	1
KU	C1S	2059630	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2059631	01/2016	01/13/2016	100.040	100.070	100.0	1
KU	C1S	2059632	01/2016	01/13/2016	100.000	100.070	100.0	1
KU	C1S	2059633	01/2016	01/13/2016	100.010	100.000	100.1	1
KU	C1S	2059634	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059635	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059636	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059637	01/2016	01/13/2016	99.970	99.980	100.0	1
KU	C1S	2059638	01/2016	01/13/2016	99.970	100.020	100.0	1

KU	C1S	2059639	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2059640	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059641	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059642	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059643	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059644	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059645	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2059646	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059647	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059648	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059649	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059650	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059651	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059652	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059653	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059654	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059655	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059656	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059657	01/2016	01/13/2016	100.050	100.030	100.0	1
KU	C1S	2059658	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059659	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059660	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059661	01/2016	01/13/2016	100.000	100.070	100.0	1
KU	C1S	2059662	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059663	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059664	01/2016	01/13/2016	100.030	100.040	100.0	1
KU	C1S	2059665	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2059666	01/2016	01/13/2016	99.950	100.040	100.0	1
KU	C1S	2059667	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2059668	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059669	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059670	01/2016	01/13/2016	99.980	100.010	100.0	1
KU	C1S	2059671	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059672	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059673	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059674	01/2016	01/13/2016	99.990	100.030	100.1	1
KU	C1S	2059675	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059676	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059677	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059678	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059679	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059680	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059681	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059682	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059683	01/2016	01/13/2016	100.000	100.000	100.0	1

KU	C1S	2059684	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059685	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059686	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059687	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059688	01/2016	01/13/2016	100.040	99.980	100.0	1
KU	C1S	2059689	01/2016	01/13/2016	100.010	100.030	100.1	1
KU	C1S	2059690	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059691	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059692	01/2016	01/13/2016	100.020	99.990	100.0	1
KU	C1S	2059693	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059694	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059695	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059696	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059697	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059698	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059699	01/2016	01/13/2016	100.010	99.950	100.0	1
KU	C1S	2059700	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059701	01/2016	01/13/2016	100.020	100.040	100.1	1
KU	C1S	2059702	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059703	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059704	01/2016	01/13/2016	99.990	100.010	100.0	1
KU	C1S	2059705	01/2016	01/13/2016	100.010	99.990	100.0	1
KU	C1S	2059706	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059707	01/2016	01/13/2016	99.990	100.000	100.1	1
KU	C1S	2059708	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059709	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059710	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059711	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059712	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059713	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2059714	01/2016	01/13/2016	100.000	100.070	100.0	1
KU	C1S	2059715	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059716	01/2016	01/13/2016	100.000	100.070	100.0	1
KU	C1S	2059717	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059718	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059719	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059720	01/2016	01/13/2016	100.000	99.990	100.0	1
KU	C1S	2059721	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059722	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059723	01/2016	01/13/2016	99.960	100.010	100.0	1
KU	C1S	2059724	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059725	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059726	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059727	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059728	01/2016	01/13/2016	100.000	100.050	100.0	1

KU	C1S	2059729	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2059730	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059731	01/2016	01/13/2016	99.970	99.970	100.0	1
KU	C1S	2059732	01/2016	01/13/2016	100.030	100.020	100.1	1
KU	C1S	2059733	01/2016	01/13/2016	99.980	99.970	100.0	1
KU	C1S	2059734	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059735	01/2016	01/13/2016	99.970	100.080	100.0	1
KU	C1S	2059736	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059737	01/2016	01/13/2016	100.010	100.020	100.1	1
KU	C1S	2059738	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059739	01/2016	01/13/2016	100.010	99.980	100.0	1
KU	C1S	2059740	01/2016	01/13/2016	100.030	99.980	100.0	1
KU	C1S	2059741	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059742	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059743	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059744	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059745	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059746	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059747	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059748	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059749	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059750	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059751	01/2016	01/13/2016	99.980	100.020	100.0	1
KU	C1S	2059752	01/2016	01/13/2016	100.040	100.010	100.0	1
KU	C1S	2059753	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2059754	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059755	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059756	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059757	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059758	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059759	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059760	01/2016	01/13/2016	99.990	99.980	100.0	1
KU	C1S	2059761	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059762	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059763	01/2016	01/13/2016	99.990	100.050	100.0	1
KU	C1S	2059764	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059765	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059766	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059767	01/2016	01/13/2016	100.020	100.060	100.0	1
KU	C1S	2059768	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059769	01/2016	01/13/2016	100.000	100.020	100.0	1
KU	C1S	2059770	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059771	01/2016	01/13/2016	100.050	100.030	100.0	1
KU	C1S	2059772	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059773	01/2016	01/13/2016	100.020	100.020	100.0	1

KU	C1S	2059774	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059775	01/2016	01/13/2016	100.000	99.960	100.0	1
KU	C1S	2059776	01/2016	01/13/2016	99.990	100.040	100.0	1
KU	C1S	2059777	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059778	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059779	01/2016	01/13/2016	100.000	100.030	100.0	1
KU	C1S	2059780	01/2016	01/13/2016	99.990	99.990	99.9	1
KU	C1S	2059781	01/2016	01/13/2016	100.000	100.000	100.0	1
KU	C1S	2059782	01/2016	01/13/2016	99.970	100.040	100.0	1
KU	C1S	2059783	01/2016	01/13/2016	100.020	100.000	100.0	1
KU	C1S	2059784	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059785	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059786	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059787	01/2016	01/13/2016	99.980	99.990	100.0	1
KU	C1S	2059788	01/2016	01/13/2016	100.030	100.060	100.0	1
KU	C1S	2059789	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059790	01/2016	01/13/2016	99.990	100.060	100.0	1
KU	C1S	2059791	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059792	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2059793	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059794	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059795	01/2016	01/13/2016	100.010	100.050	100.0	1
KU	C1S	2059796	01/2016	01/13/2016	100.030	100.050	100.1	1
KU	C1S	2059797	01/2016	01/13/2016	99.990	100.060	100.1	1
KU	C1S	2059798	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059799	01/2016	01/13/2016	100.020	100.040	100.0	1
KU	C1S	2059800	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059801	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059802	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059803	01/2016	01/13/2016	99.950	100.040	100.0	1
KU	C1S	2059804	01/2016	01/13/2016	99.990	100.020	100.0	1
KU	C1S	2059805	01/2016	01/13/2016	99.950	100.010	100.0	1
KU	C1S	2059806	01/2016	01/13/2016	100.010	100.050	100.1	1
KU	C1S	2059807	01/2016	01/13/2016	99.970	100.010	100.0	1
KU	C1S	2059808	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059809	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059810	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059811	01/2016	01/13/2016	100.040	100.030	100.0	1
KU	C1S	2059812	01/2016	01/13/2016	99.950	99.980	100.0	1
KU	C1S	2059813	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059814	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059815	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059816	01/2016	01/13/2016	100.030	100.020	100.0	1
KU	C1S	2059817	01/2016	01/13/2016	100.010	100.020	100.0	1
KU	C1S	2059818	01/2016	01/13/2016	100.000	100.000	100.0	1

KU	C1S	2059819	01/2016	01/13/2016	100.000	100.040	100.1	1
KU	C1S	2059820	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2059821	01/2016	01/13/2016	99.990	100.020	100.1	1
KU	C1S	2059822	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059823	01/2016	01/13/2016	100.000	100.050	100.0	1
KU	C1S	2059824	01/2016	01/13/2016	100.040	100.050	100.0	1
KU	C1S	2059825	01/2016	01/13/2016	100.050	100.050	100.0	1
KU	C1S	2059826	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059827	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059828	01/2016	01/13/2016	100.000	99.980	100.0	1
KU	C1S	2059829	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059830	01/2016	01/13/2016	99.990	99.990	100.0	1
KU	C1S	2059831	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059832	01/2016	01/13/2016	99.980	100.030	100.0	1
KU	C1S	2059833	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059834	01/2016	01/13/2016	99.970	100.010	100.1	1
KU	C1S	2059835	01/2016	01/13/2016	100.020	100.020	100.0	1
KU	C1S	2059836	01/2016	01/13/2016	100.020	99.960	100.0	1
KU	C1S	2059837	01/2016	01/13/2016	99.960	100.010	100.0	1
KU	C1S	2059838	01/2016	01/13/2016	100.010	100.010	100.0	1
KU	C1S	2059839	01/2016	01/13/2016	100.020	100.010	100.0	1
KU	C1S	2059840	01/2016	01/13/2016	100.030	100.000	100.0	1
KU	C1S	2059841	01/2016	01/13/2016	99.960	100.020	100.0	1
KU	C1S	2059842	01/2016	01/13/2016	99.990	100.050	100.1	1
KU	C1S	2059843	01/2016	01/13/2016	99.990	100.030	100.0	1
KU	C1S	2059844	01/2016	01/13/2016	100.010	100.040	100.0	1
KU	C1S	2059845	01/2016	01/13/2016	99.970	100.000	100.0	1
KU	C1S	2059846	01/2016	01/13/2016	100.010	100.060	100.0	1
KU	C1S	2059847	01/2016	01/13/2016	100.010	100.000	100.0	1
KU	C1S	2059848	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059849	01/2016	01/13/2016	99.960	99.940	100.0	1
KU	C1S	2059850	01/2016	01/13/2016	99.980	100.040	100.0	1
KU	C1S	2059851	01/2016	01/13/2016	100.000	100.040	100.0	1
KU	C1S	2059852	01/2016	01/13/2016	100.010	100.000	100.1	1
KU	C1S	2059853	01/2016	01/13/2016	100.010	100.030	100.0	1
KU	C1S	2059854	01/2016	01/13/2016	99.990	100.000	100.0	1
KU	C1S	2059855	01/2016	01/13/2016	100.050	99.980	100.0	1
KU	C1S	2059856	01/2016	01/13/2016	100.000	100.010	100.0	1
KU	C1S	2059857	01/2016	01/13/2016	99.980	100.000	100.0	1
KU	C1S	2059858	01/2016	01/13/2016	100.020	100.060	100.1	1
KU	C1S	2059859	01/2016	01/13/2016	99.970	99.990	100.0	1
KU	C1S	2059860	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2059861	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059862	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2059863	02/2016	02/09/2016	100.000	100.000	100.0	1

KU	C1S	2059864	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2059865	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2059866	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2059867	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2059868	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059869	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2059870	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2059871	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2059872	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2059873	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2059874	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2059875	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2059876	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2059877	02/2016	02/09/2016	99.990	99.950	100.0	1
KU	C1S	2059878	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2059879	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059880	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2059881	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	C1S	2059882	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2059883	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2059884	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2059885	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2059886	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2059887	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2059888	02/2016	02/09/2016	100.000	100.020	100.1	1
KU	C1S	2059889	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059890	02/2016	02/09/2016	99.990	99.970	100.0	1
KU	C1S	2059891	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059892	02/2016	02/09/2016	99.980	99.960	100.0	1
KU	C1S	2059893	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059894	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2059895	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2059896	02/2016	02/09/2016	99.970	99.980	100.0	1
KU	C1S	2059897	02/2016	02/09/2016	99.970	99.950	100.0	1
KU	C1S	2059898	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059899	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2059900	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2059901	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2059902	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2059903	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059904	02/2016	02/09/2016	99.940	99.990	100.0	1
KU	C1S	2059905	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2059906	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2059907	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2059908	02/2016	02/09/2016	99.950	100.010	100.0	1

KU	C1S	2059909	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2059910	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2059911	02/2016	02/09/2016	100.010	100.010	100.1	1
KU	C1S	2059912	02/2016	02/09/2016	100.010	99.990	100.1	1
KU	C1S	2059913	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2059914	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2059915	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2059916	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059917	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059918	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059919	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2059920	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2059921	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2059922	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059923	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059924	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2059925	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2059926	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059927	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2059928	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2059929	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2059930	02/2016	02/09/2016	100.030	99.960	100.0	1
KU	C1S	2059931	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2059932	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2059933	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2059934	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2059935	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059936	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	C1S	2059937	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059938	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059939	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059940	02/2016	02/09/2016	100.010	100.040	99.9	1
KU	C1S	2059941	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2059942	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2059943	02/2016	02/09/2016	99.990	99.960	100.0	1
KU	C1S	2059944	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2059945	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2059946	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059947	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2059948	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059949	02/2016	02/09/2016	99.980	100.000	100.1	1
KU	C1S	2059950	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059951	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2059952	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2059953	02/2016	02/09/2016	99.980	100.030	100.0	1

KU	C1S	2059954	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2059955	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2059956	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059957	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2059958	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2059959	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2059960	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2059961	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2059962	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2059963	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2059964	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2059965	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059966	02/2016	02/09/2016	99.980	99.970	100.0	1
KU	C1S	2059967	02/2016	02/09/2016	99.940	100.030	100.0	1
KU	C1S	2059968	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2059969	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2059970	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2059971	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2059972	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2059973	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2059974	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2059975	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2059976	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2059977	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2059978	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2059979	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2059980	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2059981	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2059982	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2059983	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2059984	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2059985	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2059986	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2059987	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2059988	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2059989	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2059990	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2059991	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	C1S	2059992	02/2016	02/09/2016	100.030	99.950	100.0	1
KU	C1S	2059993	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2059994	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2059995	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2059996	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2059997	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2059998	02/2016	02/09/2016	99.980	100.070	100.0	1

KU	C1S	2059999	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060000	02/2016	02/09/2016	99.990	99.960	100.0	1
KU	C1S	2060001	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060002	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060003	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2060004	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060005	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060006	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060007	02/2016	02/09/2016	99.990	99.950	100.0	1
KU	C1S	2060008	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060009	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2060010	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060011	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060012	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060013	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060014	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2060015	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060016	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060017	02/2016	02/09/2016	100.000	100.080	100.0	1
KU	C1S	2060018	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060019	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060020	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060021	02/2016	02/09/2016	99.980	100.070	100.0	1
KU	C1S	2060022	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060023	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2060024	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060025	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060026	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060027	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060028	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060029	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060030	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2060031	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060032	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060033	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2060034	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2060035	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060036	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060037	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060038	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060039	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060040	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060041	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060042	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060043	02/2016	02/09/2016	100.020	100.050	100.0	1

KU	C1S	2060044	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060045	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060046	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060047	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060048	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2060049	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060050	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060051	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060052	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060053	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060054	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060055	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060056	02/2016	02/09/2016	99.940	100.040	100.1	1
KU	C1S	2060057	02/2016	02/09/2016	100.020	99.960	100.0	1
KU	C1S	2060058	02/2016	02/09/2016	100.050	100.060	100.1	1
KU	C1S	2060059	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060060	02/2016	02/09/2016	100.020	100.000	100.1	1
KU	C1S	2060061	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2060062	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060063	02/2016	02/09/2016	99.970	99.960	100.0	1
KU	C1S	2060064	02/2016	02/09/2016	99.980	100.090	100.1	1
KU	C1S	2060065	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2060066	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060067	02/2016	02/09/2016	100.000	99.950	100.0	1
KU	C1S	2060068	02/2016	02/09/2016	100.010	100.070	100.0	1
KU	C1S	2060069	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060070	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060071	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060072	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060073	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060074	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060075	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060076	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060077	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060078	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060079	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060080	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060081	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060082	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060083	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060084	02/2016	02/09/2016	99.990	100.060	100.1	1
KU	C1S	2060085	02/2016	02/09/2016	100.040	100.040	100.0	1
KU	C1S	2060086	02/2016	02/09/2016	99.970	100.060	100.0	1
KU	C1S	2060087	02/2016	02/09/2016	99.940	100.040	100.0	1
KU	C1S	2060088	02/2016	02/09/2016	99.980	100.030	100.0	1

KU	C1S	2060089	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060090	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060091	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060092	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060093	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060094	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060095	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2060096	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060097	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060098	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060099	02/2016	02/09/2016	100.010	100.060	100.0	1
KU	C1S	2060100	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060101	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060102	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2060103	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060104	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060105	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060106	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2060107	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2060108	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060109	02/2016	02/09/2016	100.040	100.070	100.0	1
KU	C1S	2060110	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060111	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060112	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060113	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060114	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2060115	02/2016	02/09/2016	100.020	100.060	100.0	1
KU	C1S	2060116	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060117	02/2016	02/09/2016	100.010	100.060	100.0	1
KU	C1S	2060118	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060119	02/2016	02/09/2016	100.010	100.080	100.1	1
KU	C1S	2060120	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2060121	02/2016	02/09/2016	100.040	100.050	100.0	1
KU	C1S	2060122	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060123	02/2016	02/09/2016	100.020	100.060	100.0	1
KU	C1S	2060124	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060125	02/2016	02/09/2016	100.040	100.070	100.0	1
KU	C1S	2060126	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060127	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060128	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060129	02/2016	02/09/2016	100.000	100.000	100.1	1
KU	C1S	2060130	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060131	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060132	02/2016	02/09/2016	100.020	100.080	100.0	1
KU	C1S	2060133	02/2016	02/09/2016	99.990	100.020	100.0	1

KU	C1S	2060134	02/2016	02/09/2016	100.050	100.010	100.0	1
KU	C1S	2060135	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060136	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060137	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060138	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060139	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060140	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060141	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060142	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060143	02/2016	02/09/2016	99.970	100.010	100.1	1
KU	C1S	2060144	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060145	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060146	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060147	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060148	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060149	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060150	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060151	02/2016	02/09/2016	100.050	100.010	100.0	1
KU	C1S	2060152	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060153	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060154	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060155	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060156	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060157	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060158	02/2016	02/09/2016	99.990	100.010	100.1	1
KU	C1S	2060159	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	C1S	2060160	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060161	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060162	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060163	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060164	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060165	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060166	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060167	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060168	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060169	02/2016	02/09/2016	99.950	100.060	100.1	1
KU	C1S	2060170	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060171	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2060172	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060173	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060174	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2060175	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060176	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060177	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060178	02/2016	02/09/2016	100.000	100.000	100.0	1

KU	C1S	2060179	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060180	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060181	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060182	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060183	02/2016	02/09/2016	99.960	100.020	100.1	1
KU	C1S	2060184	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060185	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060186	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060187	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060188	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060189	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060190	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060191	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060192	02/2016	02/09/2016	100.050	100.030	100.0	1
KU	C1S	2060193	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060194	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060195	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060196	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060197	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060198	02/2016	02/09/2016	99.990	100.010	100.1	1
KU	C1S	2060199	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060200	02/2016	02/09/2016	100.000	100.070	100.1	1
KU	C1S	2060201	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060202	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060203	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060204	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060205	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060206	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060207	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060208	02/2016	02/09/2016	99.960	100.000	100.1	1
KU	C1S	2060209	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060210	02/2016	02/09/2016	100.040	100.020	100.0	1
KU	C1S	2060211	02/2016	02/09/2016	100.010	100.060	100.0	1
KU	C1S	2060212	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060213	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2060214	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060215	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060216	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060217	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060218	02/2016	02/09/2016	99.980	100.010	100.1	1
KU	C1S	2060219	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060220	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2060221	02/2016	02/09/2016	100.000	99.920	100.0	1
KU	C1S	2060222	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060223	02/2016	02/09/2016	99.990	100.040	100.0	1

KU	C1S	2060224	02/2016	02/09/2016	100.020	100.060	100.0	1
KU	C1S	2060225	02/2016	02/09/2016	100.020	100.020	100.1	1
KU	C1S	2060226	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060227	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060228	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060229	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060230	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060231	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060232	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060233	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060234	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060235	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060236	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060237	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060238	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060239	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060240	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060241	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060242	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060243	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060244	02/2016	02/09/2016	99.990	99.970	100.0	1
KU	C1S	2060245	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060246	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060247	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060248	02/2016	02/09/2016	100.010	100.000	100.1	1
KU	C1S	2060249	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060250	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2060251	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060252	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060253	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060254	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060255	02/2016	02/09/2016	100.020	100.070	100.0	1
KU	C1S	2060256	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060257	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2060258	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060259	02/2016	02/09/2016	100.040	100.030	100.0	1
KU	C1S	2060260	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060261	02/2016	02/09/2016	99.970	100.020	100.1	1
KU	C1S	2060262	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060263	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060264	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060265	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2060266	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060267	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2060268	02/2016	02/09/2016	100.000	99.980	100.0	1

KU	C1S	2060269	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2060270	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060271	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060272	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060273	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060274	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060275	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060276	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060277	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2060278	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060279	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060280	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060281	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060282	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060283	02/2016	02/09/2016	99.950	100.020	100.1	1
KU	C1S	2060284	02/2016	02/09/2016	100.040	100.020	100.0	1
KU	C1S	2060285	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060286	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060287	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060288	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060289	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060290	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060291	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060292	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060293	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060294	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2060295	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060296	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060297	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2060298	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060299	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060300	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2060301	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060302	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060303	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060304	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060305	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2060306	02/2016	02/09/2016	100.060	100.060	100.0	1
KU	C1S	2060307	02/2016	02/09/2016	99.960	100.000	100.0	1
KU	C1S	2060308	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060309	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060310	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060311	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2060312	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060313	02/2016	02/09/2016	100.000	100.000	100.0	1

KU	C1S	2060314	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060315	02/2016	02/09/2016	100.050	100.050	100.0	1
KU	C1S	2060316	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060317	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060318	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060319	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2060320	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060321	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060322	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060323	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060324	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060325	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2060326	02/2016	02/09/2016	100.040	100.010	100.0	1
KU	C1S	2060327	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060328	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060329	02/2016	02/09/2016	99.960	100.050	100.1	1
KU	C1S	2060330	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060331	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060332	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060333	02/2016	02/09/2016	100.020	100.020	100.1	1
KU	C1S	2060334	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060335	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060336	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060337	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2060338	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060339	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060340	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060341	02/2016	02/09/2016	100.050	99.980	100.0	1
KU	C1S	2060342	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060343	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060344	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060345	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060346	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060347	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060348	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060349	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060350	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060351	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2060352	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060353	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2060354	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060355	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060356	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060357	02/2016	02/09/2016	99.970	100.050	100.1	1
KU	C1S	2060358	02/2016	02/09/2016	99.990	100.030	100.1	1

KU	C1S	2060359	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060360	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060361	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060362	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060363	02/2016	02/09/2016	100.040	100.070	100.0	1
KU	C1S	2060364	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060365	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2060366	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060367	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060368	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060369	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060370	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060371	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060372	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060373	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2060374	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060375	02/2016	02/09/2016	100.050	100.020	100.0	1
KU	C1S	2060376	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060377	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060378	02/2016	02/09/2016	99.960	100.040	100.0	1
KU	C1S	2060379	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060380	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060381	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060382	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2060383	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060384	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060385	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060386	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060387	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060388	02/2016	02/09/2016	99.950	100.010	100.0	1
KU	C1S	2060389	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060390	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2060391	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060392	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060393	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2060394	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060395	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060396	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060397	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060398	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060399	02/2016	02/09/2016	99.960	100.000	100.0	1
KU	C1S	2060400	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060401	02/2016	02/09/2016	99.960	99.990	100.0	1
KU	C1S	2060402	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060403	02/2016	02/09/2016	100.040	100.070	100.0	1

KU	C1S	2060404	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060405	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060406	02/2016	02/09/2016	100.040	100.010	100.0	1
KU	C1S	2060407	02/2016	02/09/2016	100.040	100.070	100.0	1
KU	C1S	2060408	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060409	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060410	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060411	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2060412	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060413	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060414	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060415	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060416	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060417	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060418	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060419	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060420	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060421	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060422	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2060423	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060424	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060425	02/2016	02/09/2016	100.000	100.020	100.1	1
KU	C1S	2060426	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060427	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060428	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060429	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060430	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060431	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060432	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060433	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060434	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060435	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060436	02/2016	02/09/2016	99.970	99.950	100.0	1
KU	C1S	2060437	02/2016	02/09/2016	100.000	99.950	100.0	1
KU	C1S	2060438	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2060439	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060440	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060441	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060442	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2060443	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060444	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060445	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060446	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060447	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060448	02/2016	02/09/2016	100.000	99.990	100.0	1

KU	C1S	2060449	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060450	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060451	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060452	02/2016	02/09/2016	100.010	99.960	100.0	1
KU	C1S	2060453	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060454	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060455	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060456	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060457	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060458	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060459	02/2016	02/09/2016	100.030	100.070	100.1	1
KU	C1S	2060460	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2060461	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060462	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2060463	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2060464	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060465	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2060466	02/2016	02/09/2016	100.020	100.010	100.1	1
KU	C1S	2060467	02/2016	02/09/2016	99.970	100.050	100.1	1
KU	C1S	2060468	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060469	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060470	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060471	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060472	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060473	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060474	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060475	02/2016	02/09/2016	99.960	99.950	100.0	1
KU	C1S	2060476	02/2016	02/09/2016	99.980	100.070	100.1	1
KU	C1S	2060477	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060478	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060479	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060480	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2060481	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060482	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2060483	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2060484	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060485	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060486	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060487	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060488	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2060489	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060490	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060491	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060492	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060493	02/2016	02/09/2016	100.000	100.050	100.0	1

KU	C1S	2060494	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060495	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060496	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060497	02/2016	02/09/2016	99.980	100.060	100.1	1
KU	C1S	2060498	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060499	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060500	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060501	02/2016	02/09/2016	99.990	99.930	100.0	1
KU	C1S	2060502	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2060503	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060504	02/2016	02/09/2016	99.970	100.020	100.1	1
KU	C1S	2060505	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060506	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060507	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060508	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060509	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060510	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060511	02/2016	02/09/2016	100.030	100.060	100.1	1
KU	C1S	2060512	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060513	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060514	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060515	02/2016	02/09/2016	100.010	100.080	100.0	1
KU	C1S	2060516	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060517	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060518	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060519	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060520	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060521	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060522	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060523	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060524	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060525	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060526	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2060527	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060528	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060529	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060530	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060531	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060532	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060533	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060534	02/2016	02/09/2016	100.020	100.070	100.0	1
KU	C1S	2060535	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2060536	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060537	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060538	02/2016	02/09/2016	100.010	100.030	100.0	1

2060539	CIS	KU	02/2016	02/09/2016	99.990	100.000	100.0	1
2060540	CIS	KU	02/2016	02/09/2016	100.000	100.060	100.1	1
2060541	CIS	KU	02/2016	02/09/2016	99.980	100.000	100.0	1
2060542	CIS	KU	02/2016	02/09/2016	100.080	99.980	100.0	1
2060543	CIS	KU	02/2016	02/09/2016	100.000	100.060	100.0	1
2060544	CIS	KU	02/2016	02/09/2016	99.950	99.990	100.0	1
2060545	CIS	KU	02/2016	02/09/2016	100.030	100.060	100.0	1
2060546	CIS	KU	02/2016	02/09/2016	100.000	100.040	100.1	1
2060547	CIS	KU	02/2016	02/09/2016	99.990	100.050	100.0	1
2060548	CIS	KU	02/2016	02/09/2016	100.010	100.070	100.1	1
2060549	CIS	KU	02/2016	02/09/2016	100.050	99.950	100.0	1
2060550	CIS	KU	02/2016	02/09/2016	100.000	100.040	100.1	1
2060551	CIS	KU	02/2016	02/09/2016	99.980	100.020	100.1	1
2060552	CIS	KU	02/2016	02/09/2016	99.970	100.030	100.0	1
2060553	CIS	KU	02/2016	02/09/2016	100.040	99.980	100.0	1
2060554	CIS	KU	02/2016	02/09/2016	99.990	100.040	100.0	1
2060555	CIS	KU	02/2016	02/09/2016	100.020	100.060	100.1	1
2060556	CIS	KU	02/2016	02/09/2016	100.000	100.030	100.0	1
2060557	CIS	KU	02/2016	02/09/2016	99.990	100.010	100.0	1
2060558	CIS	KU	02/2016	02/09/2016	99.980	99.950	100.0	1
2060559	CIS	KU	02/2016	02/09/2016	100.000	100.000	100.0	1
2060560	CIS	KU	02/2016	02/09/2016	99.980	100.000	100.0	1
2060561	CIS	KU	02/2016	02/09/2016	100.010	100.040	100.0	1
2060562	CIS	KU	02/2016	02/09/2016	99.990	100.050	100.0	1
2060563	CIS	KU	02/2016	02/09/2016	100.030	100.010	100.0	1
2060564	CIS	KU	02/2016	02/09/2016	99.990	100.030	100.0	1
2060565	CIS	KU	02/2016	02/09/2016	99.990	100.030	100.0	1
2060566	CIS	KU	02/2016	02/09/2016	100.030	99.980	100.0	1
2060567	CIS	KU	02/2016	02/09/2016	99.980	100.000	100.0	1
2060568	CIS	KU	02/2016	02/09/2016	99.980	99.990	100.0	1
2060569	CIS	KU	02/2016	02/09/2016	99.980	99.990	100.0	1
2060570	CIS	KU	02/2016	02/09/2016	100.010	100.030	100.0	1
2060571	CIS	KU	02/2016	02/09/2016	99.980	100.020	100.0	1
2060572	CIS	KU	02/2016	02/09/2016	99.960	100.060	100.0	1
2060573	CIS	KU	02/2016	02/09/2016	100.020	100.020	100.0	1
2060574	CIS	KU	02/2016	02/09/2016	100.000	100.040	100.0	1
2060575	CIS	KU	02/2016	02/09/2016	99.980	100.060	100.1	1
2060576	CIS	KU	02/2016	02/09/2016	99.970	100.010	100.0	1
2060577	CIS	KU	02/2016	02/09/2016	100.040	100.000	100.0	1
2060578	CIS	KU	02/2016	02/09/2016	100.030	99.970	100.0	1
2060579	CIS	KU	02/2016	02/09/2016	100.000	99.980	100.0	1
2060580	CIS	KU	02/2016	02/09/2016	100.010	100.040	100.0	1
2060581	CIS	KU	02/2016	02/09/2016	100.020	100.010	100.0	1
2060582	CIS	KU	02/2016	02/09/2016	99.970	100.020	100.0	1
2060583	CIS	KU	02/2016	02/09/2016	100.000	100.020	100.0	1

KU	C1S	2060584	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060585	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060586	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2060587	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060588	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060589	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2060590	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060591	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2060592	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060593	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2060594	02/2016	02/09/2016	100.070	100.040	100.1	1
KU	C1S	2060595	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060596	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2060597	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2060598	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060599	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060600	02/2016	02/09/2016	99.970	100.060	100.1	1
KU	C1S	2060601	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060602	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060603	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060604	02/2016	02/09/2016	100.020	100.070	100.0	1
KU	C1S	2060605	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060606	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060607	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060608	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060609	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060610	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060611	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060612	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2060613	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060614	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060615	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060616	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060617	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060618	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060619	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060620	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060621	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060622	02/2016	02/09/2016	100.000	99.990	100.1	1
KU	C1S	2060623	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060624	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060625	02/2016	02/09/2016	99.960	100.040	100.0	1
KU	C1S	2060626	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060627	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060628	02/2016	02/09/2016	100.010	99.970	100.0	1

KU	C1S	2060629	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060630	02/2016	02/09/2016	99.980	100.060	100.1	1
KU	C1S	2060631	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060632	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060633	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060634	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060635	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	C1S	2060636	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060637	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060638	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060639	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060640	02/2016	02/09/2016	100.030	99.970	100.0	1
KU	C1S	2060641	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060642	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060643	02/2016	02/09/2016	100.010	99.940	100.0	1
KU	C1S	2060644	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060645	02/2016	02/09/2016	100.010	100.010	100.1	1
KU	C1S	2060646	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2060647	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2060648	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060649	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060650	02/2016	02/09/2016	100.040	100.060	100.0	1
KU	C1S	2060651	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060652	02/2016	02/09/2016	99.990	100.070	100.1	1
KU	C1S	2060653	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060654	02/2016	02/09/2016	100.030	100.070	100.1	1
KU	C1S	2060655	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060656	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2060657	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060658	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2060659	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060660	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2060661	02/2016	02/09/2016	99.990	100.080	100.0	1
KU	C1S	2060662	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060663	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060664	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060665	02/2016	02/09/2016	99.970	100.020	100.1	1
KU	C1S	2060666	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2060667	02/2016	02/09/2016	99.960	99.970	100.0	1
KU	C1S	2060668	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2060669	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060670	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060671	02/2016	02/09/2016	100.040	100.040	100.0	1
KU	C1S	2060672	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060673	02/2016	02/09/2016	99.990	100.040	100.0	1

KU	C1S	2060674	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	C1S	2060675	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060676	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	C1S	2060677	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060678	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060679	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2060680	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060681	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060682	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060683	02/2016	02/09/2016	100.010	99.960	100.0	1
KU	C1S	2060684	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060685	02/2016	02/09/2016	99.970	100.060	100.0	1
KU	C1S	2060686	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060687	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060688	02/2016	02/09/2016	99.960	100.070	100.1	1
KU	C1S	2060689	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060690	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060691	02/2016	02/09/2016	99.940	100.030	100.0	1
KU	C1S	2060692	02/2016	02/09/2016	99.990	100.080	100.1	1
KU	C1S	2060693	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060694	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060695	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2060696	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2060697	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2060698	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060699	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060700	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2060701	02/2016	02/09/2016	99.990	100.070	100.0	1
KU	C1S	2060702	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060703	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060704	02/2016	02/09/2016	100.010	99.960	100.0	1
KU	C1S	2060705	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060706	02/2016	02/09/2016	100.020	100.060	100.0	1
KU	C1S	2060707	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2060708	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2060709	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060710	02/2016	02/09/2016	100.050	100.000	100.0	1
KU	C1S	2060711	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060712	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060713	02/2016	02/09/2016	100.020	100.070	100.0	1
KU	C1S	2060714	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2060715	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060716	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2060717	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060718	02/2016	02/09/2016	100.010	100.060	100.0	1

KU	C1S	2060719	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2060720	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060721	02/2016	02/09/2016	100.030	99.970	100.0	1
KU	C1S	2060722	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060723	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060724	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060725	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060726	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2060727	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060728	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2060729	02/2016	02/09/2016	100.020	100.000	100.1	1
KU	C1S	2060730	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060731	02/2016	02/09/2016	99.980	100.070	100.1	1
KU	C1S	2060732	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	C1S	2060733	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2060734	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060735	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060736	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060737	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060738	02/2016	02/09/2016	99.970	100.050	100.1	1
KU	C1S	2060739	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060740	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060741	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060742	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060743	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060744	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060745	02/2016	02/09/2016	100.040	100.000	100.1	1
KU	C1S	2060746	02/2016	02/09/2016	100.050	100.020	100.0	1
KU	C1S	2060747	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060748	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2060749	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2060750	02/2016	02/09/2016	99.960	100.000	100.0	1
KU	C1S	2060751	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2060752	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2060753	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060754	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060755	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060756	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2060757	02/2016	02/09/2016	100.020	100.020	100.1	1
KU	C1S	2060758	02/2016	02/09/2016	99.980	100.040	100.1	1
KU	C1S	2060759	02/2016	02/09/2016	99.970	100.060	100.0	1
KU	C1S	2060760	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060761	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060762	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2060763	02/2016	02/09/2016	99.990	100.060	100.0	1

KU	C1S	2060764	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060765	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060766	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060767	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060768	02/2016	02/09/2016	100.050	100.000	100.0	1
KU	C1S	2060769	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2060770	02/2016	02/09/2016	99.960	100.060	100.1	1
KU	C1S	2060771	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060772	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060773	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060774	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060775	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060776	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060777	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060778	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060779	02/2016	02/09/2016	100.050	100.000	100.0	1
KU	C1S	2060780	02/2016	02/09/2016	99.950	100.010	100.0	1
KU	C1S	2060781	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060782	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060783	02/2016	02/09/2016	100.010	100.060	100.0	1
KU	C1S	2060784	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060785	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2060786	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060787	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2060788	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060789	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060790	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2060791	02/2016	02/09/2016	99.990	100.080	100.0	1
KU	C1S	2060792	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060793	02/2016	02/09/2016	100.070	100.010	100.0	1
KU	C1S	2060794	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060795	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060796	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060797	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060798	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060799	02/2016	02/09/2016	100.010	100.070	100.0	1
KU	C1S	2060800	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060801	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060802	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060803	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060804	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060805	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060806	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060807	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060808	02/2016	02/09/2016	100.050	100.050	100.0	1

KU	C1S	2060809	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060810	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060811	02/2016	02/09/2016	99.960	100.030	100.0	1
KU	C1S	2060812	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060813	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2060814	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060815	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2060816	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060817	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060818	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060819	02/2016	02/09/2016	99.950	100.060	100.0	1
KU	C1S	2060820	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060821	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060822	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060823	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060824	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2060825	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060826	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060827	02/2016	02/09/2016	100.060	100.010	100.0	1
KU	C1S	2060828	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060829	02/2016	02/09/2016	100.060	100.000	100.0	1
KU	C1S	2060830	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060831	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060832	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060833	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060834	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060835	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060836	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2060837	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060838	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060839	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060840	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060841	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060842	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2060843	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060844	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060845	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2060846	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060847	02/2016	02/09/2016	99.960	99.990	100.0	1
KU	C1S	2060848	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060849	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060850	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060851	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2060852	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060853	02/2016	02/09/2016	100.010	100.020	100.0	1

KU	C1S	2060854	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060855	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060856	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060857	02/2016	02/09/2016	99.970	100.040	100.1	1
KU	C1S	2060858	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2060859	02/2016	02/09/2016	100.010	100.000	100.1	1
KU	C1S	2060860	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060861	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2060862	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060863	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060864	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060865	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060866	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2060867	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060868	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060869	02/2016	02/09/2016	100.040	100.020	100.0	1
KU	C1S	2060870	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060871	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060872	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060873	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060874	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2060875	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060876	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2060877	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2060878	02/2016	02/09/2016	100.000	100.020	100.1	1
KU	C1S	2060879	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060880	02/2016	02/09/2016	99.980	100.010	100.1	1
KU	C1S	2060881	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2060882	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060883	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060884	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060885	02/2016	02/09/2016	99.960	100.030	100.1	1
KU	C1S	2060886	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2060887	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060888	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2060889	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2060890	02/2016	02/09/2016	100.020	100.020	100.1	1
KU	C1S	2060891	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060892	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060893	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2060894	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060895	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060896	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060897	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2060898	02/2016	02/09/2016	99.970	100.010	100.0	1

KU	C1S	2060899	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	C1S	2060900	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060901	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2060902	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060903	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2060904	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2060905	02/2016	02/09/2016	99.980	100.090	100.1	1
KU	C1S	2060906	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060907	02/2016	02/09/2016	100.040	100.060	100.1	1
KU	C1S	2060908	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060909	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060910	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060911	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2060912	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060913	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060914	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060915	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060916	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060917	02/2016	02/09/2016	100.010	100.010	100.1	1
KU	C1S	2060918	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2060919	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2060920	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060921	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060922	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2060923	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2060924	02/2016	02/09/2016	100.030	100.020	100.1	1
KU	C1S	2060925	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2060926	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060927	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060928	02/2016	02/09/2016	100.050	100.010	100.0	1
KU	C1S	2060929	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2060930	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060931	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060932	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060933	02/2016	02/09/2016	100.040	100.040	100.0	1
KU	C1S	2060934	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060935	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2060936	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060937	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060938	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2060939	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060940	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2060941	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060942	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2060943	02/2016	02/09/2016	100.030	100.030	100.0	1

KU	C1S	2060944	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2060945	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2060946	02/2016	02/09/2016	99.940	100.040	100.0	1
KU	C1S	2060947	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2060948	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060949	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2060950	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060951	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060952	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2060953	02/2016	02/09/2016	100.030	99.950	100.0	1
KU	C1S	2060954	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060955	02/2016	02/09/2016	100.020	99.970	100.1	1
KU	C1S	2060956	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060957	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060958	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2060959	02/2016	02/09/2016	99.980	99.970	100.0	1
KU	C1S	2060960	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060961	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060962	02/2016	02/09/2016	100.040	100.060	100.0	1
KU	C1S	2060963	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2060964	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060965	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2060966	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2060967	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2060968	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060969	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060970	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2060971	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2060972	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2060973	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	C1S	2060974	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2060975	02/2016	02/09/2016	99.980	100.040	100.1	1
KU	C1S	2060976	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060977	02/2016	02/09/2016	99.970	100.070	100.0	1
KU	C1S	2060978	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2060979	02/2016	02/09/2016	100.050	100.030	100.0	1
KU	C1S	2060980	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2060981	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2060982	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2060983	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2060984	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2060985	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2060986	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060987	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2060988	02/2016	02/09/2016	99.990	100.000	100.0	1

KU	C1S	2060989	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2060990	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2060991	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2060992	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2060993	02/2016	02/09/2016	100.060	100.010	100.0	1
KU	C1S	2060994	02/2016	02/09/2016	100.050	100.040	100.1	1
KU	C1S	2060995	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2060996	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2060997	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2060998	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2060999	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061000	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061001	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2061002	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061003	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2061004	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061005	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061006	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061007	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061008	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061009	02/2016	02/09/2016	100.060	100.020	100.0	1
KU	C1S	2061010	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2061011	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061012	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061013	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061014	02/2016	02/09/2016	99.950	100.020	100.0	1
KU	C1S	2061015	02/2016	02/09/2016	100.050	100.030	100.0	1
KU	C1S	2061016	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061017	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061018	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061019	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2061020	02/2016	02/09/2016	100.000	100.000	100.1	1
KU	C1S	2061021	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061022	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061023	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061024	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061025	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061026	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061027	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061028	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061029	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061030	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061031	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061032	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061033	02/2016	02/09/2016	99.980	100.010	100.1	1

KU	C1S	2061034	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061035	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061036	02/2016	02/09/2016	99.950	99.990	100.0	1
KU	C1S	2061037	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061038	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2061039	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061040	02/2016	02/09/2016	100.000	99.920	100.0	1
KU	C1S	2061041	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2061042	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2061043	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061044	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061045	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061046	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061047	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061048	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061049	02/2016	02/09/2016	99.990	99.960	100.0	1
KU	C1S	2061050	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061051	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061052	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061053	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061054	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2061055	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061056	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061057	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061058	02/2016	02/09/2016	99.980	100.040	100.1	1
KU	C1S	2061059	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061060	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061061	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061062	02/2016	02/09/2016	99.960	100.060	100.1	1
KU	C1S	2061063	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2061064	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061065	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061066	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061067	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061068	02/2016	02/09/2016	100.040	100.020	100.0	1
KU	C1S	2061069	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061070	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061071	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061072	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061073	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061074	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061075	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061076	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061077	02/2016	02/09/2016	99.960	99.990	100.0	1
KU	C1S	2061078	02/2016	02/09/2016	100.020	100.060	100.1	1

KU	C1S	2061079	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061080	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2061081	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061082	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061083	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061084	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061085	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061086	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061087	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061088	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061089	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2061090	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061091	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2061092	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061093	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2061094	02/2016	02/09/2016	100.000	99.990	100.1	1
KU	C1S	2061095	02/2016	02/09/2016	99.960	100.050	100.1	1
KU	C1S	2061096	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2061097	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061098	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061099	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061100	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061101	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061102	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061103	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061104	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061105	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061106	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061107	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061108	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2061109	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061110	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061111	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061112	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061113	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061114	02/2016	02/09/2016	99.990	100.000	100.1	1
KU	C1S	2061115	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061116	02/2016	02/09/2016	100.050	100.040	100.0	1
KU	C1S	2061117	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061118	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061119	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061120	02/2016	02/09/2016	99.990	100.060	100.1	1
KU	C1S	2061121	02/2016	02/09/2016	100.040	100.050	100.1	1
KU	C1S	2061122	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061123	02/2016	02/09/2016	100.030	100.070	100.1	1

KU	C1S	2061124	02/2016	02/09/2016	99.980	100.070	100.0	1
KU	C1S	2061125	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2061126	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061127	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2061128	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061129	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	C1S	2061130	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2061131	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061132	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061133	02/2016	02/09/2016	100.000	100.000	100.1	1
KU	C1S	2061134	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061135	02/2016	02/09/2016	99.950	99.940	100.0	1
KU	C1S	2061136	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061137	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061138	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061139	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061140	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061141	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2061142	02/2016	02/09/2016	99.960	99.960	100.0	1
KU	C1S	2061143	02/2016	02/09/2016	100.040	100.070	100.0	1
KU	C1S	2061144	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061145	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061146	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061147	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061148	02/2016	02/09/2016	99.980	100.020	100.1	1
KU	C1S	2061149	02/2016	02/09/2016	100.040	100.020	100.0	1
KU	C1S	2061150	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2061151	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061152	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2061153	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061154	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2061155	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061156	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061157	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061158	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061159	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2061160	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2061161	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061162	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061163	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061164	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061165	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061166	02/2016	02/09/2016	99.990	100.060	100.1	1
KU	C1S	2061167	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061168	02/2016	02/09/2016	99.990	100.020	100.1	1

KU	C1S	2061169	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061170	02/2016	02/09/2016	100.060	100.000	100.0	1
KU	C1S	2061171	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061172	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2061173	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061174	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061175	02/2016	02/09/2016	100.030	100.070	100.0	1
KU	C1S	2061176	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2061177	02/2016	02/09/2016	100.040	100.050	100.1	1
KU	C1S	2061178	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	C1S	2061179	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061180	02/2016	02/09/2016	100.010	99.950	99.9	1
KU	C1S	2061181	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061182	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061183	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061184	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061185	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061186	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061187	02/2016	02/09/2016	100.020	100.070	100.1	1
KU	C1S	2061188	02/2016	02/09/2016	99.950	100.010	100.0	1
KU	C1S	2061189	02/2016	02/09/2016	100.050	100.060	100.0	1
KU	C1S	2061190	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061191	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2061192	02/2016	02/09/2016	99.970	100.050	100.1	1
KU	C1S	2061193	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2061194	02/2016	02/09/2016	99.970	100.030	100.0	1
KU	C1S	2061195	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061196	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2061197	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2061198	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061199	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2061200	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061201	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2061202	02/2016	02/09/2016	100.000	100.070	100.1	1
KU	C1S	2061203	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2061204	02/2016	02/09/2016	100.020	100.020	100.1	1
KU	C1S	2061205	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061206	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061207	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061208	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061209	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061210	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061211	02/2016	02/09/2016	99.990	100.070	100.1	1
KU	C1S	2061212	02/2016	02/09/2016	99.980	100.050	100.1	1
KU	C1S	2061213	02/2016	02/09/2016	99.960	100.020	100.1	1

KU	CIS	2061214	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	CIS	2061215	02/2016	02/09/2016	99.980	99.970	100.0	1
KU	CIS	2061216	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	CIS	2061217	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	CIS	2061218	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	CIS	2061219	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	CIS	2061220	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	CIS	2061221	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	CIS	2061222	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	CIS	2061223	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	CIS	2061224	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	CIS	2061225	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	CIS	2061226	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	CIS	2061227	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	CIS	2061228	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	CIS	2061229	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	CIS	2061230	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	CIS	2061231	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	CIS	2061232	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	CIS	2061233	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	CIS	2061234	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	CIS	2061235	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	CIS	2061236	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	CIS	2061237	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	CIS	2061238	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	CIS	2061239	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	CIS	2061240	02/2016	02/09/2016	99.960	100.050	100.0	1
KU	CIS	2061241	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	CIS	2061242	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	CIS	2061243	02/2016	02/09/2016	100.030	100.040	100.1	1
KU	CIS	2061244	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	CIS	2061245	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	CIS	2061246	02/2016	02/09/2016	99.980	100.060	100.0	1
KU	CIS	2061247	02/2016	02/09/2016	99.990	99.950	100.0	1
KU	CIS	2061248	02/2016	02/09/2016	100.000	100.060	100.0	1
KU	CIS	2061249	02/2016	02/09/2016	100.020	100.080	100.0	1
KU	CIS	2061250	02/2016	02/09/2016	100.030	100.020	100.0	1
KU	CIS	2061251	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	CIS	2061252	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	CIS	2061253	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	CIS	2061254	02/2016	02/09/2016	99.960	100.050	100.0	1
KU	CIS	2061255	02/2016	02/09/2016	99.970	100.040	100.1	1
KU	CIS	2061256	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	CIS	2061257	02/2016	02/09/2016	100.010	100.090	100.0	1
KU	CIS	2061258	02/2016	02/09/2016	100.020	100.060	100.0	1

KU	C1S	2061259	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061260	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2061261	02/2016	02/09/2016	100.020	100.090	100.0	1
KU	C1S	2061262	02/2016	02/09/2016	100.030	100.020	100.1	1
KU	C1S	2061263	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061264	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061265	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061266	02/2016	02/09/2016	100.030	100.020	100.1	1
KU	C1S	2061267	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061268	02/2016	02/09/2016	100.010	100.060	100.0	1
KU	C1S	2061269	02/2016	02/09/2016	100.020	99.930	100.0	1
KU	C1S	2061270	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061271	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061272	02/2016	02/09/2016	100.030	99.980	100.0	1
KU	C1S	2061273	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061274	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2061275	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061276	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061277	02/2016	02/09/2016	100.000	100.070	100.1	1
KU	C1S	2061278	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061279	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061280	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061281	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061282	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061283	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061284	02/2016	02/09/2016	99.980	100.010	100.1	1
KU	C1S	2061285	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061286	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2061287	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061288	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2061289	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2061290	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061291	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061292	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061293	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061294	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2061295	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061296	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061297	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061298	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061299	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061300	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2061301	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061302	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061303	02/2016	02/09/2016	100.000	100.020	100.0	1

KU	C1S	2061304	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061305	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061306	02/2016	02/09/2016	99.960	100.030	100.0	1
KU	C1S	2061307	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2061308	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2061309	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061310	02/2016	02/09/2016	99.970	99.980	100.0	1
KU	C1S	2061311	02/2016	02/09/2016	100.030	100.040	100.1	1
KU	C1S	2061312	02/2016	02/09/2016	99.960	100.060	100.0	1
KU	C1S	2061313	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061314	02/2016	02/09/2016	100.000	100.000	100.1	1
KU	C1S	2061315	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061316	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061317	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061318	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2061319	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061320	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061321	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061322	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061323	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061324	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061325	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061326	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061327	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061328	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2061329	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061330	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061331	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061332	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061333	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061334	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2061335	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2061336	02/2016	02/09/2016	100.010	99.990	100.1	1
KU	C1S	2061337	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061338	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061339	02/2016	02/09/2016	99.980	100.090	100.1	1
KU	C1S	2061340	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061341	02/2016	02/09/2016	100.030	100.070	100.0	1
KU	C1S	2061342	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061343	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061344	02/2016	02/09/2016	100.010	100.050	100.1	1
KU	C1S	2061345	02/2016	02/09/2016	100.050	99.980	100.0	1
KU	C1S	2061346	02/2016	02/09/2016	99.980	100.070	100.1	1
KU	C1S	2061347	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061348	02/2016	02/09/2016	99.980	100.010	100.0	1

KU	C1S	2061349	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061350	02/2016	02/09/2016	100.010	100.070	100.0	1
KU	C1S	2061351	02/2016	02/09/2016	100.050	100.060	100.0	1
KU	C1S	2061352	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2061353	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061354	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061355	02/2016	02/09/2016	99.980	100.060	100.1	1
KU	C1S	2061356	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061357	02/2016	02/09/2016	100.000	100.020	100.1	1
KU	C1S	2061358	02/2016	02/09/2016	99.990	100.040	100.1	1
KU	C1S	2061359	02/2016	02/09/2016	100.030	100.000	100.1	1
KU	C1S	2061360	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2061361	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061362	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2061363	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061364	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061365	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061366	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061367	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061368	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061369	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061370	02/2016	02/09/2016	99.970	100.010	100.0	1
KU	C1S	2061371	02/2016	02/09/2016	100.050	100.020	100.1	1
KU	C1S	2061372	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061373	02/2016	02/09/2016	99.980	100.060	100.1	1
KU	C1S	2061374	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061375	02/2016	02/09/2016	99.990	100.010	100.1	1
KU	C1S	2061376	02/2016	02/09/2016	100.020	100.070	100.1	1
KU	C1S	2061377	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2061378	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061379	02/2016	02/09/2016	99.980	100.020	100.1	1
KU	C1S	2061380	02/2016	02/09/2016	100.040	100.040	100.1	1
KU	C1S	2061381	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061382	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061383	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061384	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061385	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2061386	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061387	02/2016	02/09/2016	100.010	99.960	100.0	1
KU	C1S	2061388	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061389	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061390	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061391	02/2016	02/09/2016	100.010	100.070	100.0	1
KU	C1S	2061392	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061393	02/2016	02/09/2016	100.010	100.020	100.0	1

KU	C1S	2061394	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061395	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061396	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061397	02/2016	02/09/2016	100.050	100.010	100.1	1
KU	C1S	2061398	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061399	02/2016	02/09/2016	99.960	100.000	100.0	1
KU	C1S	2061400	02/2016	02/09/2016	99.950	99.980	100.0	1
KU	C1S	2061401	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061402	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061403	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061404	02/2016	02/09/2016	100.020	99.990	100.0	1
KU	C1S	2061405	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061406	02/2016	02/09/2016	99.990	100.070	100.0	1
KU	C1S	2061407	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061408	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	C1S	2061409	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2061410	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061411	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061412	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061413	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2061414	02/2016	02/09/2016	99.950	100.040	100.0	1
KU	C1S	2061415	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061416	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2061417	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061418	02/2016	02/09/2016	100.040	100.030	100.0	1
KU	C1S	2061419	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061420	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061421	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2061422	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061423	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061424	02/2016	02/09/2016	99.980	100.050	100.1	1
KU	C1S	2061425	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061426	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061427	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061428	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061429	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061430	02/2016	02/09/2016	100.010	100.070	100.0	1
KU	C1S	2061431	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2061432	02/2016	02/09/2016	100.030	100.030	100.1	1
KU	C1S	2061433	02/2016	02/09/2016	99.950	100.050	100.1	1
KU	C1S	2061434	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061435	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061436	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061437	02/2016	02/09/2016	100.000	100.050	100.1	1
KU	C1S	2061438	02/2016	02/09/2016	99.980	100.040	100.0	1

KU	C1S	2061439	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2061440	02/2016	02/09/2016	99.980	100.000	100.1	1
KU	C1S	2061441	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061442	02/2016	02/09/2016	99.980	100.050	100.1	1
KU	C1S	2061443	02/2016	02/09/2016	99.990	100.050	100.0	1
KU	C1S	2061444	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061445	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061446	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061447	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061448	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061449	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2061450	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061451	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061452	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2061453	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2061454	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2061455	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061456	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061457	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2061458	02/2016	02/09/2016	100.040	100.050	100.1	1
KU	C1S	2061459	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2061460	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2061461	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061462	02/2016	02/09/2016	99.970	100.030	100.1	1
KU	C1S	2061463	02/2016	02/09/2016	99.980	100.000	100.1	1
KU	C1S	2061464	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061465	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061466	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061467	02/2016	02/09/2016	100.000	100.020	100.1	1
KU	C1S	2061468	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061469	02/2016	02/09/2016	99.970	99.950	100.0	1
KU	C1S	2061470	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061471	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061472	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061473	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061474	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061475	02/2016	02/09/2016	100.060	100.020	100.1	1
KU	C1S	2061476	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061477	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061478	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2061479	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061480	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061481	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061482	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061483	02/2016	02/09/2016	100.000	100.010	100.0	1

KU	C1S	2061484	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061485	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2061486	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061487	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061488	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061489	02/2016	02/09/2016	99.980	99.980	100.1	1
KU	C1S	2061490	02/2016	02/09/2016	100.030	99.980	100.1	1
KU	C1S	2061491	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061492	02/2016	02/09/2016	100.040	100.010	100.0	1
KU	C1S	2061493	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061494	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2061495	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061496	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061497	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061498	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061499	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061500	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061501	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061502	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061503	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061504	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2061505	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061506	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061507	02/2016	02/09/2016	99.970	100.050	100.1	1
KU	C1S	2061508	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061509	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061510	02/2016	02/09/2016	100.020	100.030	100.1	1
KU	C1S	2061511	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061512	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061513	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061514	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2061515	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061516	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061517	02/2016	02/09/2016	99.990	100.030	100.0	1
KU	C1S	2061518	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061519	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061520	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061521	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061522	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061523	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	C1S	2061524	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061525	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061526	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061527	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061528	02/2016	02/09/2016	100.020	100.030	100.1	1

KU	C1S	2061529	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061530	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061531	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061532	02/2016	02/09/2016	100.010	100.060	100.1	1
KU	C1S	2061533	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061534	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061535	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061536	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061537	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061538	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061539	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061540	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061541	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061542	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061543	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061544	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061545	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061546	02/2016	02/09/2016	100.000	99.940	100.0	1
KU	C1S	2061547	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2061548	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061549	02/2016	02/09/2016	99.970	99.990	100.0	1
KU	C1S	2061550	02/2016	02/09/2016	99.960	100.020	100.0	1
KU	C1S	2061551	02/2016	02/09/2016	99.980	100.040	100.0	1
KU	C1S	2061552	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061553	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061554	02/2016	02/09/2016	99.960	99.980	100.0	1
KU	C1S	2061555	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061556	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061557	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061558	02/2016	02/09/2016	100.000	100.040	100.1	1
KU	C1S	2061559	02/2016	02/09/2016	100.030	100.060	100.0	1
KU	C1S	2061560	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061561	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061562	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061563	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061564	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061565	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2061566	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2061567	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061568	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061569	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061570	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061571	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061572	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061573	02/2016	02/09/2016	100.010	100.020	100.0	1

KU	C1S	2061574	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061575	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061576	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061577	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061578	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061579	02/2016	02/09/2016	100.020	100.000	100.1	1
KU	C1S	2061580	02/2016	02/09/2016	99.960	100.070	100.0	1
KU	C1S	2061581	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061582	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2061583	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061584	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061585	02/2016	02/09/2016	100.010	100.080	100.0	1
KU	C1S	2061586	02/2016	02/09/2016	100.030	99.960	100.0	1
KU	C1S	2061587	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061588	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2061589	02/2016	02/09/2016	100.010	99.980	100.0	1
KU	C1S	2061590	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061591	02/2016	02/09/2016	99.960	100.050	100.0	1
KU	C1S	2061592	02/2016	02/09/2016	99.950	99.990	100.0	1
KU	C1S	2061593	02/2016	02/09/2016	100.010	99.970	100.0	1
KU	C1S	2061594	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061595	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061596	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061597	02/2016	02/09/2016	100.020	100.060	100.0	1
KU	C1S	2061598	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061599	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061600	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061601	02/2016	02/09/2016	100.010	100.040	100.1	1
KU	C1S	2061602	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061603	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061604	02/2016	02/09/2016	100.040	100.040	100.1	1
KU	C1S	2061605	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2061606	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061607	02/2016	02/09/2016	99.980	100.000	100.0	1
KU	C1S	2061608	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061609	02/2016	02/09/2016	100.020	100.050	100.1	1
KU	C1S	2061610	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061611	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061612	02/2016	02/09/2016	99.990	100.020	100.0	1
KU	C1S	2061613	02/2016	02/09/2016	99.990	99.990	100.0	1
KU	C1S	2061614	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061615	02/2016	02/09/2016	99.990	99.970	100.0	1
KU	C1S	2061616	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061617	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061618	02/2016	02/09/2016	100.020	100.020	100.0	1

KU	C1S	2061619	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061620	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061621	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061622	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2061623	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061624	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061625	02/2016	02/09/2016	99.970	99.980	100.0	1
KU	C1S	2061626	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061627	02/2016	02/09/2016	99.990	99.990	100.1	1
KU	C1S	2061628	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2061629	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	C1S	2061630	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061631	02/2016	02/09/2016	100.040	100.000	100.0	1
KU	C1S	2061632	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061633	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061634	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061635	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061636	02/2016	02/09/2016	100.030	99.990	100.0	1
KU	C1S	2061637	02/2016	02/09/2016	99.980	100.030	100.0	1
KU	C1S	2061638	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061639	02/2016	02/09/2016	100.030	100.050	100.0	1
KU	C1S	2061640	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061641	02/2016	02/09/2016	100.040	99.990	100.0	1
KU	C1S	2061642	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061643	02/2016	02/09/2016	99.970	99.960	100.0	1
KU	C1S	2061644	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2061645	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061646	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2061647	02/2016	02/09/2016	99.980	100.020	100.0	1
KU	C1S	2061648	02/2016	02/09/2016	99.960	100.040	100.1	1
KU	C1S	2061649	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061650	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061651	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061652	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061653	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061654	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061655	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061656	02/2016	02/09/2016	99.990	99.980	100.0	1
KU	C1S	2061657	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061658	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2061659	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061660	02/2016	02/09/2016	100.010	100.040	100.0	1
KU	C1S	2061661	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061662	02/2016	02/09/2016	100.020	100.000	100.0	1
KU	C1S	2061663	02/2016	02/09/2016	100.000	100.030	100.0	1

KU	C1S	2061664	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061665	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2061666	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061667	02/2016	02/09/2016	100.020	100.010	100.0	1
KU	C1S	2061668	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061669	02/2016	02/09/2016	99.970	100.040	100.1	1
KU	C1S	2061670	02/2016	02/09/2016	100.000	100.000	100.1	1
KU	C1S	2061671	02/2016	02/09/2016	100.010	100.030	100.0	1
KU	C1S	2061672	02/2016	02/09/2016	100.020	100.050	100.0	1
KU	C1S	2061673	02/2016	02/09/2016	100.010	100.020	100.1	1
KU	C1S	2061674	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061675	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061676	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061677	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061678	02/2016	02/09/2016	100.000	100.010	100.0	1
KU	C1S	2061679	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061680	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061681	02/2016	02/09/2016	99.970	100.040	100.1	1
KU	C1S	2061682	02/2016	02/09/2016	99.980	99.980	100.0	1
KU	C1S	2061683	02/2016	02/09/2016	100.030	100.000	100.0	1
KU	C1S	2061684	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061685	02/2016	02/09/2016	100.010	100.030	100.1	1
KU	C1S	2061686	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061687	02/2016	02/09/2016	100.020	100.040	100.0	1
KU	C1S	2061688	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061689	02/2016	02/09/2016	99.970	100.040	100.0	1
KU	C1S	2061690	02/2016	02/09/2016	100.030	100.040	100.0	1
KU	C1S	2061691	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061692	02/2016	02/09/2016	100.030	100.030	100.0	1
KU	C1S	2061693	02/2016	02/09/2016	99.980	100.010	100.0	1
KU	C1S	2061694	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061695	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061696	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061697	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061698	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061699	02/2016	02/09/2016	99.990	100.010	100.1	1
KU	C1S	2061700	02/2016	02/09/2016	100.020	100.030	100.0	1
KU	C1S	2061701	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061702	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061703	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2061704	02/2016	02/09/2016	99.980	100.010	100.1	1
KU	C1S	2061705	02/2016	02/09/2016	99.970	100.020	100.0	1
KU	C1S	2061706	02/2016	02/09/2016	100.040	100.030	100.0	1
KU	C1S	2061707	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061708	02/2016	02/09/2016	100.010	99.990	100.0	1

KU	C1S	2061709	02/2016	02/09/2016	100.000	100.070	100.0	1
KU	C1S	2061710	02/2016	02/09/2016	100.010	100.000	100.1	1
KU	C1S	2061711	02/2016	02/09/2016	99.980	100.020	100.1	1
KU	C1S	2061712	02/2016	02/09/2016	100.000	99.960	100.0	1
KU	C1S	2061713	02/2016	02/09/2016	100.000	100.010	100.1	1
KU	C1S	2061714	02/2016	02/09/2016	100.000	100.040	100.0	1
KU	C1S	2061715	02/2016	02/09/2016	100.000	99.980	100.0	1
KU	C1S	2061716	02/2016	02/09/2016	99.950	99.990	100.0	1
KU	C1S	2061717	02/2016	02/09/2016	99.990	100.010	100.1	1
KU	C1S	2061718	02/2016	02/09/2016	99.990	100.000	100.0	1
KU	C1S	2061719	02/2016	02/09/2016	100.030	100.010	100.0	1
KU	C1S	2061720	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061721	02/2016	02/09/2016	99.990	100.040	100.0	1
KU	C1S	2061722	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061723	02/2016	02/09/2016	99.950	99.990	100.0	1
KU	C1S	2061724	02/2016	02/09/2016	100.010	100.050	100.0	1
KU	C1S	2061725	02/2016	02/09/2016	99.980	100.070	100.1	1
KU	C1S	2061726	02/2016	02/09/2016	100.000	100.060	100.1	1
KU	C1S	2061727	02/2016	02/09/2016	100.010	100.070	100.1	1
KU	C1S	2061728	02/2016	02/09/2016	100.040	100.050	100.1	1
KU	C1S	2061729	02/2016	02/09/2016	100.000	100.030	100.0	1
KU	C1S	2061730	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061731	02/2016	02/09/2016	99.970	99.970	100.0	1
KU	C1S	2061732	02/2016	02/09/2016	100.030	99.960	100.0	1
KU	C1S	2061733	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061734	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061735	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061736	02/2016	02/09/2016	100.000	99.970	100.0	1
KU	C1S	2061737	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061738	02/2016	02/09/2016	100.020	100.020	100.0	1
KU	C1S	2061739	02/2016	02/09/2016	99.970	100.050	100.0	1
KU	C1S	2061740	02/2016	02/09/2016	100.030	100.070	100.1	1
KU	C1S	2061741	02/2016	02/09/2016	100.020	99.980	100.0	1
KU	C1S	2061742	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061743	02/2016	02/09/2016	99.960	100.000	100.0	1
KU	C1S	2061744	02/2016	02/09/2016	99.960	99.990	100.0	1
KU	C1S	2061745	02/2016	02/09/2016	99.960	99.990	100.0	1
KU	C1S	2061746	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061747	02/2016	02/09/2016	99.990	100.020	100.1	1
KU	C1S	2061748	02/2016	02/09/2016	100.020	100.040	100.1	1
KU	C1S	2061749	02/2016	02/09/2016	99.980	100.020	100.1	1
KU	C1S	2061750	02/2016	02/09/2016	100.030	99.980	100.1	1
KU	C1S	2061751	02/2016	02/09/2016	99.970	99.980	100.0	1
KU	C1S	2061752	02/2016	02/09/2016	99.980	100.030	100.1	1
KU	C1S	2061753	02/2016	02/09/2016	100.020	100.030	100.0	1

KU	C1S	2061754	02/2016	02/09/2016	100.010	99.990	100.0	1
KU	C1S	2061755	02/2016	02/09/2016	100.020	100.060	100.1	1
KU	C1S	2061756	02/2016	02/09/2016	99.960	100.010	100.0	1
KU	C1S	2061757	02/2016	02/09/2016	100.010	100.010	100.1	1
KU	C1S	2061758	02/2016	02/09/2016	99.990	100.060	100.0	1
KU	C1S	2061759	02/2016	02/09/2016	100.000	99.990	100.0	1
KU	C1S	2061760	02/2016	02/09/2016	99.980	100.050	100.1	1
KU	C1S	2061761	02/2016	02/09/2016	100.020	99.970	100.0	1
KU	C1S	2061762	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061763	02/2016	02/09/2016	100.010	100.020	100.0	1
KU	C1S	2061764	02/2016	02/09/2016	100.000	100.000	100.0	1
KU	C1S	2061765	02/2016	02/09/2016	100.000	100.030	100.1	1
KU	C1S	2061766	02/2016	02/09/2016	100.000	100.050	100.0	1
KU	C1S	2061767	02/2016	02/09/2016	100.010	100.000	100.0	1
KU	C1S	2061768	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2061769	02/2016	02/09/2016	99.990	99.970	100.0	1
KU	C1S	2061770	02/2016	02/09/2016	99.980	99.990	100.0	1
KU	C1S	2061771	02/2016	02/09/2016	99.960	99.980	100.1	1
KU	C1S	2061772	02/2016	02/09/2016	99.970	100.000	100.0	1
KU	C1S	2061773	02/2016	02/09/2016	99.990	100.010	100.0	1
KU	C1S	2061774	02/2016	02/09/2016	99.990	100.030	100.1	1
KU	C1S	2061775	02/2016	02/09/2016	100.020	99.940	100.0	1
KU	C1S	2061776	02/2016	02/09/2016	99.990	100.050	100.1	1
KU	C1S	2061777	02/2016	02/09/2016	99.980	100.050	100.0	1
KU	C1S	2061778	02/2016	02/09/2016	100.010	100.010	100.0	1
KU	C1S	2061779	02/2016	02/09/2016	100.000	100.020	100.0	1
KU	C1S	2061780	03/2016	03/15/2016	99.990	99.970	100.1	1
KU	C1S	2061781	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061782	03/2016	03/15/2016	99.980	99.990	100.0	1
KU	C1S	2061783	03/2016	03/15/2016	99.990	99.950	100.0	1
KU	C1S	2061784	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061785	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061786	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061787	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061788	03/2016	03/15/2016	99.980	100.000	100.1	1
KU	C1S	2061789	03/2016	03/15/2016	99.990	100.010	100.0	1
KU	C1S	2061790	03/2016	03/15/2016	99.990	99.960	100.0	1
KU	C1S	2061791	03/2016	03/15/2016	99.990	99.970	100.0	1
KU	C1S	2061792	03/2016	03/15/2016	99.990	100.030	100.0	1
KU	C1S	2061793	03/2016	03/15/2016	99.970	100.000	100.0	1
KU	C1S	2061794	03/2016	03/15/2016	99.990	99.990	100.1	1
KU	C1S	2061795	03/2016	03/15/2016	99.990	100.000	100.1	1
KU	C1S	2061796	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061797	03/2016	03/15/2016	99.990	99.970	100.0	1
KU	C1S	2061798	03/2016	03/15/2016	99.980	99.960	100.0	1

KU	C1S	2061799	03/2016	03/15/2016	99.970	100.000	100.0	1
KU	C1S	2061800	03/2016	03/15/2016	99.970	100.010	100.0	1
KU	C1S	2061801	03/2016	03/15/2016	99.960	100.030	99.9	1
KU	C1S	2061802	03/2016	03/15/2016	99.970	99.980	100.0	1
KU	C1S	2061803	03/2016	03/15/2016	99.990	100.020	100.1	1
KU	C1S	2061804	03/2016	03/15/2016	99.970	99.950	100.0	1
KU	C1S	2061805	03/2016	03/15/2016	99.980	99.970	100.1	1
KU	C1S	2061806	03/2016	03/15/2016	99.970	99.980	100.1	1
KU	C1S	2061807	03/2016	03/15/2016	99.980	100.020	100.0	1
KU	C1S	2061808	03/2016	03/15/2016	99.970	99.970	100.0	1
KU	C1S	2061809	03/2016	03/15/2016	100.010	100.070	100.1	1
KU	C1S	2061810	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061811	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061812	03/2016	03/15/2016	99.980	99.960	100.1	1
KU	C1S	2061813	03/2016	03/15/2016	99.970	99.980	100.0	1
KU	C1S	2061814	03/2016	03/15/2016	99.990	100.000	100.0	1
KU	C1S	2061815	03/2016	03/15/2016	99.970	99.960	100.1	1
KU	C1S	2061816	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061817	03/2016	03/15/2016	99.970	99.960	100.0	1
KU	C1S	2061818	03/2016	03/15/2016	99.980	100.040	100.0	1
KU	C1S	2061819	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061820	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061821	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061822	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061823	03/2016	03/15/2016	99.970	99.970	100.0	1
KU	C1S	2061824	03/2016	03/15/2016	99.970	99.990	100.0	1
KU	C1S	2061825	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061826	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061827	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061828	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061829	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061830	03/2016	03/15/2016	99.990	100.000	100.1	1
KU	C1S	2061831	03/2016	03/15/2016	99.990	99.970	100.1	1
KU	C1S	2061832	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061833	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061834	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061835	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061836	03/2016	03/15/2016	99.980	99.980	100.1	1
KU	C1S	2061837	03/2016	03/15/2016	99.990	99.970	100.1	1
KU	C1S	2061838	03/2016	03/15/2016	99.980	99.990	100.0	1
KU	C1S	2061839	03/2016	03/15/2016	99.970	99.960	100.0	1
KU	C1S	2061840	03/2016	03/15/2016	99.970	99.960	100.0	1
KU	C1S	2061841	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061842	03/2016	03/15/2016	99.990	100.000	100.0	1
KU	C1S	2061843	03/2016	03/15/2016	99.990	99.960	100.0	1

KU	C1S	2061844	03/2016	03/15/2016	99.980	99.980	100.1	1
KU	C1S	2061845	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061846	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061847	03/2016	03/15/2016	99.970	99.980	100.0	1
KU	C1S	2061848	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061849	03/2016	03/15/2016	99.980	99.950	100.0	1
KU	C1S	2061850	03/2016	03/15/2016	99.990	99.980	100.1	1
KU	C1S	2061851	03/2016	03/15/2016	99.970	99.950	100.0	1
KU	C1S	2061852	03/2016	03/15/2016	99.980	100.010	100.1	1
KU	C1S	2061853	03/2016	03/15/2016	99.980	99.960	100.0	1
KU	C1S	2061854	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061855	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061856	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2061857	03/2016	03/15/2016	99.990	100.000	100.0	1
KU	C1S	2061858	03/2016	03/15/2016	99.980	100.010	100.0	1
KU	C1S	2061859	03/2016	03/15/2016	99.980	99.990	100.1	1
KU	C1S	2061860	03/2016	03/15/2016	99.990	99.980	100.1	1
KU	C1S	2061861	03/2016	03/15/2016	99.980	99.950	100.0	1
KU	C1S	2061862	03/2016	03/15/2016	99.980	99.990	100.1	1
KU	C1S	2061863	03/2016	03/15/2016	99.990	99.960	100.1	1
KU	C1S	2061864	03/2016	03/15/2016	99.980	100.010	100.0	1
KU	C1S	2061865	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061866	03/2016	03/15/2016	99.970	99.950	100.0	1
KU	C1S	2061867	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061868	03/2016	03/15/2016	99.980	99.990	100.1	1
KU	C1S	2061869	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061870	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061871	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061872	03/2016	03/15/2016	99.970	99.970	100.0	1
KU	C1S	2061873	03/2016	03/15/2016	99.980	99.990	100.0	1
KU	C1S	2061874	03/2016	03/15/2016	99.980	100.010	100.0	1
KU	C1S	2061875	03/2016	03/15/2016	99.990	99.960	100.0	1
KU	C1S	2061876	03/2016	03/15/2016	99.980	99.970	100.0	1
KU	C1S	2061877	03/2016	03/15/2016	99.990	99.970	100.0	1
KU	C1S	2061878	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061879	03/2016	03/15/2016	99.970	99.970	100.0	1
KU	C1S	2061880	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061881	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061882	03/2016	03/15/2016	99.970	99.950	99.9	1
KU	C1S	2061883	03/2016	03/15/2016	99.980	99.990	100.0	1
KU	C1S	2061884	03/2016	03/15/2016	99.970	99.980	100.0	1
KU	C1S	2061885	03/2016	03/15/2016	99.990	100.060	100.0	1
KU	C1S	2061886	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061887	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061888	03/2016	03/15/2016	99.990	99.980	99.9	1

KU	C1S	2061889	03/2016	03/15/2016	99.970	99.990	100.1	1
KU	C1S	2061890	03/2016	03/15/2016	99.980	99.990	100.0	1
KU	C1S	2061891	03/2016	03/15/2016	99.980	99.980	100.1	1
KU	C1S	2061892	03/2016	03/15/2016	99.980	100.030	100.1	1
KU	C1S	2061893	03/2016	03/15/2016	99.990	99.990	100.0	1
KU	C1S	2061894	03/2016	03/15/2016	99.990	100.000	99.9	1
KU	C1S	2061895	03/2016	03/15/2016	99.970	100.000	100.0	1
KU	C1S	2061896	03/2016	03/15/2016	99.990	99.980	100.0	1
KU	C1S	2061897	03/2016	03/15/2016	99.980	100.010	100.0	1
KU	C1S	2061898	03/2016	03/15/2016	99.980	100.000	100.0	1
KU	C1S	2061899	03/2016	03/15/2016	99.980	99.980	100.0	1
KU	C1S	2062020	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062021	03/2016	03/08/2016	100.010	100.070	100.0	1
KU	C1S	2062022	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062023	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062024	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062025	03/2016	03/08/2016	100.040	99.990	100.0	1
KU	C1S	2062026	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062027	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062028	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062029	03/2016	03/08/2016	100.030	100.050	100.0	1
KU	C1S	2062030	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062031	03/2016	03/08/2016	99.970	100.030	100.1	1
KU	C1S	2062032	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062033	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062034	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062035	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062036	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062037	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062038	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2062039	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062040	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062041	03/2016	03/08/2016	100.000	100.070	100.1	1
KU	C1S	2062042	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062043	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062044	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062045	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062046	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062047	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062048	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2062049	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062050	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2062051	03/2016	03/08/2016	99.980	100.040	100.1	1
KU	C1S	2062052	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062053	03/2016	03/08/2016	100.030	100.010	100.0	1

KU	C1S	2062054	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2062055	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062056	03/2016	03/08/2016	99.970	99.980	99.9	1
KU	C1S	2062057	03/2016	03/08/2016	99.970	100.050	100.0	1
KU	C1S	2062058	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062059	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062060	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062061	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2062062	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062063	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062064	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062065	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062066	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062067	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062068	03/2016	03/08/2016	99.990	100.020	100.1	1
KU	C1S	2062069	03/2016	03/08/2016	100.020	100.060	100.1	1
KU	C1S	2062070	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062071	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062072	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062073	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062074	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062075	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062076	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2062077	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062078	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062079	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062080	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062081	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062082	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2062083	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062084	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062085	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2062086	03/2016	03/08/2016	100.010	100.040	100.1	1
KU	C1S	2062087	03/2016	03/08/2016	100.040	100.040	100.0	1
KU	C1S	2062088	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062089	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062090	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062091	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062092	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062093	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062094	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2062095	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062096	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062097	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2062098	03/2016	03/08/2016	100.000	100.030	100.1	1

KU	C1S	2062099	03/2016	03/08/2016	100.010	100.050	100.1	1
KU	C1S	2062100	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062101	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062102	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062103	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062104	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062105	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062106	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062107	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2062108	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062109	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2062110	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062111	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2062112	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062113	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062114	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062115	03/2016	03/08/2016	100.030	99.920	99.9	1
KU	C1S	2062116	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062117	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062118	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062119	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062120	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062121	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062122	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062123	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062124	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062125	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062126	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062127	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2062128	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062129	03/2016	03/08/2016	99.990	99.930	100.0	1
KU	C1S	2062130	03/2016	03/08/2016	99.960	99.970	100.0	1
KU	C1S	2062131	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062132	03/2016	03/08/2016	100.060	99.980	100.0	1
KU	C1S	2062133	03/2016	03/08/2016	100.000	99.920	100.0	1
KU	C1S	2062134	03/2016	03/08/2016	99.970	99.960	100.0	1
KU	C1S	2062135	03/2016	03/08/2016	100.010	99.910	100.0	1
KU	C1S	2062136	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062137	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062138	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062139	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2062140	03/2016	03/08/2016	99.970	99.940	100.0	1
KU	C1S	2062141	03/2016	03/08/2016	100.000	99.930	100.0	1
KU	C1S	2062142	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062143	03/2016	03/08/2016	99.990	99.950	100.0	1

KU	C1S	2062144	03/2016	03/08/2016	99.980	99.950	99.9	1
KU	C1S	2062145	03/2016	03/08/2016	100.030	99.950	100.0	1
KU	C1S	2062146	03/2016	03/08/2016	100.040	99.960	100.0	1
KU	C1S	2062147	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062148	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062149	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062150	03/2016	03/08/2016	100.030	99.960	100.0	1
KU	C1S	2062151	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062152	03/2016	03/08/2016	100.020	99.930	100.0	1
KU	C1S	2062153	03/2016	03/08/2016	100.000	100.070	100.0	1
KU	C1S	2062154	03/2016	03/08/2016	100.040	100.050	100.1	1
KU	C1S	2062155	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062156	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062157	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062158	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062159	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062160	03/2016	03/08/2016	99.980	99.930	100.0	1
KU	C1S	2062161	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062162	03/2016	03/08/2016	100.020	100.040	100.1	1
KU	C1S	2062163	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062164	03/2016	03/08/2016	100.020	99.960	100.0	1
KU	C1S	2062165	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2062166	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062167	03/2016	03/08/2016	100.000	99.930	99.9	1
KU	C1S	2062168	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062169	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062170	03/2016	03/08/2016	99.980	99.940	100.0	1
KU	C1S	2062171	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062172	03/2016	03/08/2016	99.960	100.040	100.0	1
KU	C1S	2062173	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2062174	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062175	03/2016	03/08/2016	99.990	100.020	100.1	1
KU	C1S	2062176	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2062177	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062178	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062179	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062180	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062181	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062182	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062183	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062184	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062185	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062186	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062187	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062188	03/2016	03/08/2016	100.010	100.000	100.0	1

KU	C1S	2062189	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062190	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062191	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062192	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2062193	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2062194	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062195	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062196	03/2016	03/08/2016	100.040	99.980	100.0	1
KU	C1S	2062197	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062198	03/2016	03/08/2016	100.030	100.040	100.0	1
KU	C1S	2062199	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062200	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062201	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062202	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062203	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062204	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062205	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062206	03/2016	03/08/2016	100.020	100.030	100.1	1
KU	C1S	2062207	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062208	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062209	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2062210	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2062211	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062212	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062213	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062214	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062215	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062216	03/2016	03/08/2016	99.950	100.010	100.0	1
KU	C1S	2062217	03/2016	03/08/2016	100.020	99.970	99.9	1
KU	C1S	2062218	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062219	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062220	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062221	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062222	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062223	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062224	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062225	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2062226	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2062227	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062228	03/2016	03/08/2016	100.020	100.000	99.9	1
KU	C1S	2062229	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062230	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062231	03/2016	03/08/2016	100.010	100.040	100.1	1
KU	C1S	2062232	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062233	03/2016	03/08/2016	100.030	100.060	100.0	1

KU	C1S	2062234	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2062235	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062236	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062237	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2062238	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062239	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062240	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062241	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2062242	03/2016	03/08/2016	99.950	100.000	100.0	1
KU	C1S	2062243	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062244	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062245	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062246	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062247	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062248	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2062249	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062250	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062251	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2062252	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062253	03/2016	03/08/2016	99.960	100.010	100.0	1
KU	C1S	2062254	03/2016	03/08/2016	100.030	100.010	100.1	1
KU	C1S	2062255	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062256	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2062257	03/2016	03/08/2016	99.960	99.990	99.9	1
KU	C1S	2062258	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062259	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062260	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2062261	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062262	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062263	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062264	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062265	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2062266	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062267	03/2016	03/08/2016	100.020	100.040	100.1	1
KU	C1S	2062268	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062269	03/2016	03/08/2016	99.990	99.990	99.9	1
KU	C1S	2062270	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062271	03/2016	03/08/2016	99.970	99.920	100.0	1
KU	C1S	2062272	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062273	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062274	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062275	03/2016	03/08/2016	100.020	100.060	100.1	1
KU	C1S	2062276	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062277	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2062278	03/2016	03/08/2016	99.990	99.980	100.0	1

KU	C1S	2062279	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062280	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062281	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062282	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2062283	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062284	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062285	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062286	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062287	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062288	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2062289	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062290	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2062291	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062292	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062293	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062294	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062295	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062296	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062297	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062298	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062299	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062300	03/2016	03/08/2016	99.960	99.990	100.0	1
KU	C1S	2062301	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062302	03/2016	03/08/2016	100.010	100.080	100.1	1
KU	C1S	2062303	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062304	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062305	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2062306	03/2016	03/08/2016	100.030	100.050	100.1	1
KU	C1S	2062307	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2062308	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062309	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062310	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062311	03/2016	03/08/2016	100.000	99.910	100.0	1
KU	C1S	2062312	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062313	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062314	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062315	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062316	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062317	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062318	03/2016	03/08/2016	100.050	100.070	100.0	1
KU	C1S	2062319	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062320	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062321	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2062322	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062323	03/2016	03/08/2016	99.980	100.000	100.0	1

KU	C1S	2062324	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062325	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062326	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062327	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062328	03/2016	03/08/2016	100.020	100.010	100.1	1
KU	C1S	2062329	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062330	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062331	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062332	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062333	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062334	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062335	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062336	03/2016	03/08/2016	99.980	100.080	100.1	1
KU	C1S	2062337	03/2016	03/08/2016	100.000	100.060	100.1	1
KU	C1S	2062338	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062339	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062340	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062341	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062342	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2062343	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062344	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062345	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062346	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062347	03/2016	03/08/2016	99.970	100.060	100.1	1
KU	C1S	2062348	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062349	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062350	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062351	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2062352	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062353	03/2016	03/08/2016	99.950	100.030	100.1	1
KU	C1S	2062354	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062355	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062356	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062357	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2062358	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062359	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062360	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062361	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2062362	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062363	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062364	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2062365	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062366	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062367	03/2016	03/08/2016	99.970	100.070	100.0	1
KU	C1S	2062368	03/2016	03/08/2016	100.010	100.020	100.0	1

KU	C1S	2062369	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062370	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062371	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062372	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062373	03/2016	03/08/2016	100.020	100.050	100.0	1
KU	C1S	2062374	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062375	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062376	03/2016	03/08/2016	100.030	100.030	100.1	1
KU	C1S	2062377	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062378	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2062379	03/2016	03/08/2016	100.000	100.050	100.1	1
KU	C1S	2062380	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062381	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2062382	03/2016	03/08/2016	100.020	100.030	100.1	1
KU	C1S	2062383	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062384	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062385	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062386	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2062387	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062388	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2062389	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062390	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062391	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062392	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062393	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062394	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062395	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062396	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2062397	03/2016	03/08/2016	100.030	100.040	100.0	1
KU	C1S	2062398	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062399	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062400	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062401	03/2016	03/08/2016	99.960	99.960	99.9	1
KU	C1S	2062402	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062403	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062404	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2062405	03/2016	03/08/2016	99.990	100.070	100.0	1
KU	C1S	2062406	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062407	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2062408	03/2016	03/08/2016	99.960	99.970	100.0	1
KU	C1S	2062409	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062410	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062411	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062412	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2062413	03/2016	03/08/2016	100.010	100.020	100.0	1

KU	C1S	2062414	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062415	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062416	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062417	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062418	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062419	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062420	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062421	03/2016	03/08/2016	99.980	100.040	100.1	1
KU	C1S	2062422	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062423	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2062424	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062425	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062426	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062427	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062428	03/2016	03/08/2016	99.990	100.020	100.1	1
KU	C1S	2062429	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062430	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062431	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062432	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062433	03/2016	03/08/2016	100.040	100.040	100.1	1
KU	C1S	2062434	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2062435	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062436	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062437	03/2016	03/08/2016	99.970	100.040	100.1	1
KU	C1S	2062438	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062439	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062440	03/2016	03/08/2016	100.020	100.060	100.1	1
KU	C1S	2062441	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062442	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062443	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062444	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062445	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062446	03/2016	03/08/2016	99.960	100.010	100.0	1
KU	C1S	2062447	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062448	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062449	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062450	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062451	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062452	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2062453	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062454	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062455	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062456	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062457	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062458	03/2016	03/08/2016	100.000	100.000	100.0	1

KU	C1S	2062459	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062460	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2062461	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062462	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062463	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062464	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062465	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062466	03/2016	03/08/2016	100.010	100.040	100.1	1
KU	C1S	2062467	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062468	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062469	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062470	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062471	03/2016	03/08/2016	100.010	100.010	100.1	1
KU	C1S	2062472	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062473	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062474	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2062475	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062476	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2062477	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062478	03/2016	03/08/2016	100.050	99.980	100.0	1
KU	C1S	2062479	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062480	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062481	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062482	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062483	03/2016	03/08/2016	100.000	99.940	100.0	1
KU	C1S	2062484	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062485	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062486	03/2016	03/08/2016	99.990	99.900	99.9	1
KU	C1S	2062487	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062488	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062489	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062490	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062491	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2062492	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062493	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2062494	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2062495	03/2016	03/08/2016	100.020	100.080	100.1	1
KU	C1S	2062496	03/2016	03/08/2016	100.060	100.080	100.1	1
KU	C1S	2062497	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062498	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2062499	03/2016	03/08/2016	99.960	100.020	100.0	1
KU	C1S	2062500	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062501	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062502	03/2016	03/08/2016	100.000	100.070	100.1	1
KU	C1S	2062503	03/2016	03/08/2016	99.980	100.010	100.0	1

KU	C1S	2062504	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2062505	03/2016	03/08/2016	99.960	100.010	100.0	1
KU	C1S	2062506	03/2016	03/08/2016	100.000	100.070	100.1	1
KU	C1S	2062507	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062508	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062509	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062510	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2062511	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062512	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2062513	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062514	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062515	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062516	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062517	03/2016	03/08/2016	100.020	100.020	100.1	1
KU	C1S	2062518	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062519	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062520	03/2016	03/08/2016	99.960	100.020	100.0	1
KU	C1S	2062521	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062522	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2062523	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062524	03/2016	03/08/2016	100.020	100.020	100.1	1
KU	C1S	2062525	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062526	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062527	03/2016	03/08/2016	99.960	99.980	99.9	1
KU	C1S	2062528	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062529	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062530	03/2016	03/08/2016	100.010	100.050	100.1	1
KU	C1S	2062531	03/2016	03/08/2016	99.990	100.030	100.1	1
KU	C1S	2062532	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062533	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2062534	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062535	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062536	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062537	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062538	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2062539	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062540	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062541	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2062542	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062543	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062544	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062545	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062546	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062547	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062548	03/2016	03/08/2016	99.990	100.030	100.0	1

KU	C1S	2062549	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062550	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062551	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062552	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062553	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062554	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062555	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062556	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062557	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062558	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2062559	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062560	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2062561	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062562	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2062563	03/2016	03/08/2016	99.970	100.060	100.1	1
KU	C1S	2062564	03/2016	03/08/2016	100.020	100.020	100.1	1
KU	C1S	2062565	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062566	03/2016	03/08/2016	99.990	100.060	100.1	1
KU	C1S	2062567	03/2016	03/08/2016	99.970	100.010	100.1	1
KU	C1S	2062568	03/2016	03/08/2016	99.990	100.020	100.1	1
KU	C1S	2062569	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062570	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062571	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062572	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062573	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062574	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062575	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2062576	03/2016	03/08/2016	100.020	100.050	100.1	1
KU	C1S	2062577	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062578	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062579	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062580	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062581	03/2016	03/08/2016	99.960	100.080	100.1	1
KU	C1S	2062582	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062583	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062584	03/2016	03/08/2016	99.990	100.030	100.1	1
KU	C1S	2062585	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062586	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062587	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062588	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062589	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062590	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062591	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062592	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062593	03/2016	03/08/2016	99.990	100.020	100.0	1

KU	C1S	2062594	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062595	03/2016	03/08/2016	100.020	100.020	100.1	1
KU	C1S	2062596	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062597	03/2016	03/08/2016	100.050	100.000	100.0	1
KU	C1S	2062598	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062599	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062600	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062601	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2062602	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062603	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062604	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062605	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062606	03/2016	03/08/2016	100.030	100.030	100.1	1
KU	C1S	2062607	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062608	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062609	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062610	03/2016	03/08/2016	99.980	100.060	100.0	1
KU	C1S	2062611	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062612	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062613	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062614	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062615	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062616	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062617	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062618	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062619	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062620	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062621	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2062622	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062623	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062624	03/2016	03/08/2016	99.970	99.950	100.0	1
KU	C1S	2062625	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062626	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062627	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2062628	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062629	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062630	03/2016	03/08/2016	99.980	99.940	100.0	1
KU	C1S	2062631	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062632	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062633	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062634	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062635	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062636	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062637	03/2016	03/08/2016	100.060	99.980	100.0	1
KU	C1S	2062638	03/2016	03/08/2016	99.980	100.030	100.0	1

KU	C1S	2062639	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062640	03/2016	03/08/2016	99.980	99.950	100.0	1
KU	C1S	2062641	03/2016	03/08/2016	99.970	100.010	100.1	1
KU	C1S	2062642	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2062643	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2062644	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2062645	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062646	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2062647	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2062648	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2062649	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062650	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2062651	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062652	03/2016	03/08/2016	100.040	99.990	100.0	1
KU	C1S	2062653	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062654	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062655	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062656	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062657	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062658	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2062659	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2062660	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062661	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062662	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062663	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062664	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062665	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062666	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2062667	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062668	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062669	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062670	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062671	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2062672	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062673	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062674	03/2016	03/08/2016	99.980	99.950	100.0	1
KU	C1S	2062675	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062676	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062677	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2062678	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062679	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062680	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062681	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062682	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062683	03/2016	03/08/2016	99.990	100.010	100.0	1

KU	C1S	2062684	03/2016	03/08/2016	100.010	99.910	100.0	1
KU	C1S	2062685	03/2016	03/08/2016	99.970	100.010	100.1	1
KU	C1S	2062686	03/2016	03/08/2016	100.010	100.020	100.1	1
KU	C1S	2062687	03/2016	03/08/2016	100.020	99.990	100.1	1
KU	C1S	2062688	03/2016	03/08/2016	99.990	99.930	100.0	1
KU	C1S	2062689	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062690	03/2016	03/08/2016	99.990	100.030	100.1	1
KU	C1S	2062691	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062692	03/2016	03/08/2016	100.020	99.940	100.0	1
KU	C1S	2062693	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062694	03/2016	03/08/2016	99.960	100.010	100.0	1
KU	C1S	2062695	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2062696	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2062697	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062698	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2062699	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062700	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062701	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062702	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062703	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062704	03/2016	03/08/2016	100.020	99.940	100.0	1
KU	C1S	2062705	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062706	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062707	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062708	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062709	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2062710	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062711	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062712	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062713	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062714	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062715	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062716	03/2016	03/08/2016	99.990	99.900	100.0	1
KU	C1S	2062717	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2062718	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062719	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062720	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062721	03/2016	03/08/2016	99.990	99.950	100.0	1
KU	C1S	2062722	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062723	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062724	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062725	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2062726	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062727	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062728	03/2016	03/08/2016	100.000	100.030	100.0	1

KU	C1S	2062729	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062730	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062731	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2062732	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062733	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062734	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062735	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062736	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062737	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062738	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062739	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062740	03/2016	03/08/2016	100.020	99.970	99.9	1
KU	C1S	2062741	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062742	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062743	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062744	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2062745	03/2016	03/08/2016	99.950	99.980	100.0	1
KU	C1S	2062746	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2062747	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062748	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2062749	03/2016	03/08/2016	100.020	99.960	100.0	1
KU	C1S	2062750	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2062751	03/2016	03/08/2016	100.050	100.010	100.0	1
KU	C1S	2062752	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062753	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062754	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062755	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062756	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062757	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062758	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062759	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062760	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062761	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062762	03/2016	03/08/2016	100.020	99.970	99.9	1
KU	C1S	2062763	03/2016	03/08/2016	100.020	99.960	100.0	1
KU	C1S	2062764	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2062765	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2062766	03/2016	03/08/2016	99.980	100.010	99.9	1
KU	C1S	2062767	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2062768	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2062769	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062770	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2062771	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062772	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062773	03/2016	03/08/2016	100.030	100.040	100.1	1

KU	C1S	2062774	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2062775	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062776	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062777	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062778	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062779	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062780	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062781	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062782	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2062783	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2062784	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2062785	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062786	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062787	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062788	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2062789	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062790	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062791	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062792	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2062793	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062794	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062795	03/2016	03/08/2016	99.960	100.030	100.0	1
KU	C1S	2062796	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2062797	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062798	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2062799	03/2016	03/08/2016	99.980	99.940	100.0	1
KU	C1S	2062800	03/2016	03/08/2016	100.000	99.930	99.9	1
KU	C1S	2062801	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2062802	03/2016	03/08/2016	100.020	100.010	99.9	1
KU	C1S	2062803	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062804	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062805	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062806	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062807	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062808	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062809	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062810	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2062811	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062812	03/2016	03/08/2016	100.000	99.940	100.0	1
KU	C1S	2062813	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062814	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062815	03/2016	03/08/2016	99.990	100.070	100.0	1
KU	C1S	2062816	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2062817	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062818	03/2016	03/08/2016	100.020	100.060	100.0	1

KU	C1S	2062819	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2062820	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062821	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062822	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062823	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062824	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2062825	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062826	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062827	03/2016	03/08/2016	100.050	100.020	100.1	1
KU	C1S	2062828	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062829	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062830	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062831	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062832	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062833	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062834	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062835	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2062836	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062837	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062838	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062839	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062840	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2062841	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2062842	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062843	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062844	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062845	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062846	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062847	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062848	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2062849	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062850	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062851	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062852	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062853	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062854	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2062855	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062856	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062857	03/2016	03/08/2016	99.980	100.020	100.1	1
KU	C1S	2062858	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062859	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062860	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2062861	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062862	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062863	03/2016	03/08/2016	100.020	99.970	100.1	1

KU	C1S	2062864	03/2016	03/08/2016	99.940	100.050	100.0	1
KU	C1S	2062865	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062866	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2062867	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062868	03/2016	03/08/2016	100.060	100.040	100.0	1
KU	C1S	2062869	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062870	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2062871	03/2016	03/08/2016	99.960	100.070	100.0	1
KU	C1S	2062872	03/2016	03/08/2016	99.970	100.050	100.0	1
KU	C1S	2062873	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2062874	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062875	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062876	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2062877	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062878	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2062879	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2062880	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2062881	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2062882	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062883	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062884	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2062885	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062886	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062887	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062888	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062889	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062890	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062891	03/2016	03/08/2016	99.990	99.960	99.9	1
KU	C1S	2062892	03/2016	03/08/2016	100.030	99.980	99.9	1
KU	C1S	2062893	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2062894	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062895	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062896	03/2016	03/08/2016	100.020	99.980	99.9	1
KU	C1S	2062897	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062898	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2062899	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062900	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062901	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2062902	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2062903	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062904	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2062905	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2062906	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2062907	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2062908	03/2016	03/08/2016	100.020	100.000	100.1	1

KU	C1S	2062909	03/2016	03/08/2016	99.960	100.030	100.0	1
KU	C1S	2062910	03/2016	03/08/2016	100.010	99.870	99.9	1
KU	C1S	2062911	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2062912	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062913	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2062914	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2062915	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062916	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2062917	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062918	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2062919	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062920	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2062921	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062922	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062923	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2062924	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2062925	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2062926	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062927	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2062928	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062929	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062930	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2062931	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2062932	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2062933	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2062934	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2062935	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2062936	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062937	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2062938	03/2016	03/08/2016	100.040	100.040	100.0	1
KU	C1S	2062939	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2062940	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2062941	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2062942	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2062943	03/2016	03/08/2016	100.020	100.060	100.1	1
KU	C1S	2062944	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2062945	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2062946	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2062947	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2062948	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2062949	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2062950	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2062951	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2062952	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2062953	03/2016	03/08/2016	100.000	100.050	100.0	1

2062954	CIS	KU	03/2016	03/08/2016	100.020	100.070	100.1	1
2062955	CIS	KU	03/2016	03/08/2016	100.000	100.000	100.0	1
2062956	CIS	KU	03/2016	03/08/2016	100.030	100.050	100.0	1
2062957	CIS	KU	03/2016	03/08/2016	100.010	100.050	100.0	1
2062958	CIS	KU	03/2016	03/08/2016	100.020	99.950	100.0	1
2062959	CIS	KU	03/2016	03/08/2016	100.000	100.000	100.0	1
2062960	CIS	KU	03/2016	03/08/2016	100.040	99.970	100.0	1
2062961	CIS	KU	03/2016	03/08/2016	99.970	100.000	100.0	1
2062962	CIS	KU	03/2016	03/08/2016	99.990	100.040	100.0	1
2062963	CIS	KU	03/2016	03/08/2016	99.990	99.990	100.0	1
2062964	CIS	KU	03/2016	03/08/2016	100.020	100.020	100.0	1
2062965	CIS	KU	03/2016	03/08/2016	99.990	100.030	100.0	1
2062966	CIS	KU	03/2016	03/08/2016	100.010	100.030	100.0	1
2062967	CIS	KU	03/2016	03/08/2016	99.990	100.030	100.1	1
2062968	CIS	KU	03/2016	03/08/2016	99.990	100.000	100.0	1
2062969	CIS	KU	03/2016	03/08/2016	99.990	100.050	100.0	1
2062970	CIS	KU	03/2016	03/08/2016	100.010	100.020	100.0	1
2062971	CIS	KU	03/2016	03/08/2016	100.010	99.980	100.0	1
2062972	CIS	KU	03/2016	03/08/2016	99.990	99.990	100.0	1
2062973	CIS	KU	03/2016	03/08/2016	100.000	99.970	100.0	1
2062974	CIS	KU	03/2016	03/08/2016	100.010	100.080	100.1	1
2062975	CIS	KU	03/2016	03/08/2016	100.010	100.000	100.0	1
2062976	CIS	KU	03/2016	03/08/2016	100.010	100.020	100.0	1
2062977	CIS	KU	03/2016	03/08/2016	99.990	100.040	100.0	1
2062978	CIS	KU	03/2016	03/08/2016	100.000	100.000	100.0	1
2062979	CIS	KU	03/2016	03/08/2016	99.990	100.000	100.0	1
2062980	CIS	KU	03/2016	03/08/2016	100.040	100.030	100.0	1
2062981	CIS	KU	03/2016	03/08/2016	100.010	100.090	100.1	1
2062982	CIS	KU	03/2016	03/08/2016	100.010	100.010	100.0	1
2062983	CIS	KU	03/2016	03/08/2016	100.000	99.990	100.0	1
2062984	CIS	KU	03/2016	03/08/2016	99.990	100.090	100.0	1
2062985	CIS	KU	03/2016	03/08/2016	100.010	100.040	100.1	1
2062986	CIS	KU	03/2016	03/08/2016	99.980	100.010	100.0	1
2062987	CIS	KU	03/2016	03/08/2016	100.000	100.020	100.1	1
2062988	CIS	KU	03/2016	03/08/2016	100.010	100.050	100.0	1
2062989	CIS	KU	03/2016	03/08/2016	99.970	99.960	99.9	1
2062990	CIS	KU	03/2016	03/08/2016	100.030	100.060	100.0	1
2062991	CIS	KU	03/2016	03/08/2016	99.970	99.990	100.0	1
2062992	CIS	KU	03/2016	03/08/2016	100.010	100.020	99.9	1
2062993	CIS	KU	03/2016	03/08/2016	100.030	99.960	100.0	1
2062994	CIS	KU	03/2016	03/08/2016	99.990	99.960	100.0	1
2062995	CIS	KU	03/2016	03/08/2016	100.010	100.000	100.0	1
2062996	CIS	KU	03/2016	03/08/2016	100.030	100.020	100.1	1
2062997	CIS	KU	03/2016	03/08/2016	99.990	100.010	100.0	1
2062998	CIS	KU	03/2016	03/08/2016	100.000	100.040	100.0	1

KU	C1S	2062999	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063000	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063001	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063002	03/2016	03/08/2016	99.970	100.060	100.1	1
KU	C1S	2063003	03/2016	03/08/2016	99.950	100.040	100.0	1
KU	C1S	2063004	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063005	03/2016	03/08/2016	100.020	100.050	100.1	1
KU	C1S	2063006	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063007	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063008	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063009	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063010	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063011	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063012	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063013	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063014	03/2016	03/08/2016	99.960	100.040	100.0	1
KU	C1S	2063015	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063016	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063017	03/2016	03/08/2016	99.950	100.030	100.0	1
KU	C1S	2063018	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063019	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063020	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2063021	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063022	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063023	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063024	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063025	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063026	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063027	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063028	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063029	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2063030	03/2016	03/08/2016	100.000	100.040	100.1	1
KU	C1S	2063031	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2063032	03/2016	03/08/2016	100.060	100.060	100.0	1
KU	C1S	2063033	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2063034	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063035	03/2016	03/08/2016	99.960	99.980	100.0	1
KU	C1S	2063036	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063037	03/2016	03/08/2016	100.000	100.060	100.1	1
KU	C1S	2063038	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063039	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063040	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063041	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063042	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063043	03/2016	03/08/2016	100.030	100.040	100.0	1

KU	C1S	2063044	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063045	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063046	03/2016	03/08/2016	99.970	100.030	100.1	1
KU	C1S	2063047	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063048	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063049	03/2016	03/08/2016	100.020	100.030	100.1	1
KU	C1S	2063050	03/2016	03/08/2016	99.980	100.000	100.1	1
KU	C1S	2063051	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063052	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063053	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2063054	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063055	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063056	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063057	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063058	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063059	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063060	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063061	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063062	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063063	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063064	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063065	03/2016	03/08/2016	100.000	100.070	100.0	1
KU	C1S	2063066	03/2016	03/08/2016	99.970	99.970	100.0	1
KU	C1S	2063067	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2063068	03/2016	03/08/2016	99.970	100.030	100.1	1
KU	C1S	2063069	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2063070	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063071	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063072	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063073	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063074	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063075	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063076	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063077	03/2016	03/08/2016	100.010	100.090	100.1	1
KU	C1S	2063078	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063079	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063080	03/2016	03/08/2016	100.000	100.000	100.1	1
KU	C1S	2063081	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063082	03/2016	03/08/2016	99.980	100.050	100.1	1
KU	C1S	2063083	03/2016	03/08/2016	100.010	100.000	100.1	1
KU	C1S	2063084	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063085	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063086	03/2016	03/08/2016	100.030	100.030	100.1	1
KU	C1S	2063087	03/2016	03/08/2016	99.970	100.040	100.1	1
KU	C1S	2063088	03/2016	03/08/2016	99.980	100.040	100.0	1

KU	C1S	2063089	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063090	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063091	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063092	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063093	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063094	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063095	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063096	03/2016	03/08/2016	99.950	100.000	100.0	1
KU	C1S	2063097	03/2016	03/08/2016	99.960	100.010	100.1	1
KU	C1S	2063098	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063099	03/2016	03/08/2016	100.010	100.070	100.0	1
KU	C1S	2063100	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063101	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063102	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063103	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063104	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063105	03/2016	03/08/2016	100.040	99.990	100.0	1
KU	C1S	2063106	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063107	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063108	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063109	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2063110	03/2016	03/08/2016	99.990	100.020	100.1	1
KU	C1S	2063111	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063112	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063113	03/2016	03/08/2016	100.010	100.040	100.1	1
KU	C1S	2063114	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063115	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063116	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2063117	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063118	03/2016	03/08/2016	99.980	100.020	100.1	1
KU	C1S	2063119	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2063120	03/2016	03/08/2016	99.980	100.060	100.1	1
KU	C1S	2063121	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2063122	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2063123	03/2016	03/08/2016	100.000	100.070	100.0	1
KU	C1S	2063124	03/2016	03/08/2016	100.040	100.090	100.1	1
KU	C1S	2063125	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2063126	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063127	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063128	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2063129	03/2016	03/08/2016	99.990	100.080	100.0	1
KU	C1S	2063130	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063131	03/2016	03/08/2016	99.970	99.970	100.0	1
KU	C1S	2063132	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063133	03/2016	03/08/2016	99.990	100.020	100.0	1

KU	C1S	2063134	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063135	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063136	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2063137	03/2016	03/08/2016	100.010	100.010	100.1	1
KU	C1S	2063138	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063139	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2063140	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063141	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2063142	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063143	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063144	03/2016	03/08/2016	99.970	99.960	100.0	1
KU	C1S	2063145	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063146	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063147	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063148	03/2016	03/08/2016	100.010	99.970	99.9	1
KU	C1S	2063149	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063150	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063151	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063152	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063153	03/2016	03/08/2016	100.020	100.040	100.1	1
KU	C1S	2063154	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063155	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063156	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063157	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063158	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063159	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063160	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063161	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063162	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063163	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063164	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063165	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063166	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063167	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2063168	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063169	03/2016	03/08/2016	100.000	100.070	100.0	1
KU	C1S	2063170	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063171	03/2016	03/08/2016	100.020	100.080	100.1	1
KU	C1S	2063172	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063173	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063174	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063175	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063176	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063177	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063178	03/2016	03/08/2016	100.020	100.010	100.0	1

KU	C1S	2063179	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063180	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063181	03/2016	03/08/2016	99.970	100.060	100.0	1
KU	C1S	2063182	03/2016	03/08/2016	99.980	100.070	100.1	1
KU	C1S	2063183	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063184	03/2016	03/08/2016	99.990	100.070	100.0	1
KU	C1S	2063185	03/2016	03/08/2016	99.940	100.020	100.0	1
KU	C1S	2063186	03/2016	03/08/2016	100.040	99.940	100.0	1
KU	C1S	2063187	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063188	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063189	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063190	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063191	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063192	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063193	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063194	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063195	03/2016	03/08/2016	100.010	100.040	100.1	1
KU	C1S	2063196	03/2016	03/08/2016	100.020	99.960	100.0	1
KU	C1S	2063197	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063198	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063199	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063200	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063201	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063202	03/2016	03/08/2016	100.020	100.050	100.0	1
KU	C1S	2063203	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063204	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063205	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063206	03/2016	03/08/2016	100.050	99.990	100.0	1
KU	C1S	2063207	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063208	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063209	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063210	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063211	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063212	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063213	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063214	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063215	03/2016	03/08/2016	99.960	100.030	100.0	1
KU	C1S	2063216	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2063217	03/2016	03/08/2016	100.000	100.040	100.1	1
KU	C1S	2063218	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063219	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063220	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063221	03/2016	03/08/2016	100.030	100.050	100.1	1
KU	C1S	2063222	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063223	03/2016	03/08/2016	100.010	100.030	100.0	1

KU	C1S	2063224	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063225	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063226	03/2016	03/08/2016	100.020	100.060	100.1	1
KU	C1S	2063227	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063228	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063229	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063230	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063231	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063232	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063233	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063234	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063235	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2063236	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2063237	03/2016	03/08/2016	99.950	100.020	100.1	1
KU	C1S	2063238	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063239	03/2016	03/08/2016	100.020	100.040	100.1	1
KU	C1S	2063240	03/2016	03/08/2016	100.000	100.010	100.1	1
KU	C1S	2063241	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063242	03/2016	03/08/2016	100.000	100.040	100.1	1
KU	C1S	2063243	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063244	03/2016	03/08/2016	99.980	100.060	100.1	1
KU	C1S	2063245	03/2016	03/08/2016	100.020	100.040	100.1	1
KU	C1S	2063246	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2063247	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063248	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063249	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063250	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063251	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2063252	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063253	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063254	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063255	03/2016	03/08/2016	100.040	100.030	100.1	1
KU	C1S	2063256	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063257	03/2016	03/08/2016	100.000	99.970	99.9	1
KU	C1S	2063258	03/2016	03/08/2016	100.010	100.080	100.0	1
KU	C1S	2063259	03/2016	03/08/2016	100.040	100.080	100.1	1
KU	C1S	2063260	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063261	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063262	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2063263	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063264	03/2016	03/08/2016	100.040	100.020	100.0	1
KU	C1S	2063265	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063266	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2063267	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2063268	03/2016	03/08/2016	100.000	100.040	100.1	1

KU	C1S	2063269	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2063270	03/2016	03/08/2016	100.020	100.050	100.1	1
KU	C1S	2063271	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063272	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2063273	03/2016	03/08/2016	99.940	100.030	100.0	1
KU	C1S	2063274	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063275	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063276	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063277	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063278	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063279	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063280	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2063281	03/2016	03/08/2016	100.000	100.080	100.0	1
KU	C1S	2063282	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063283	03/2016	03/08/2016	99.950	100.030	100.0	1
KU	C1S	2063284	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063285	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063286	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063287	03/2016	03/08/2016	100.020	100.000	100.1	1
KU	C1S	2063288	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063289	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063290	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063291	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063292	03/2016	03/08/2016	100.020	100.020	99.9	1
KU	C1S	2063293	03/2016	03/08/2016	100.030	99.980	100.0	1
KU	C1S	2063294	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2063295	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063296	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063297	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063298	03/2016	03/08/2016	100.030	99.990	100.0	1
KU	C1S	2063299	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063300	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063301	03/2016	03/08/2016	99.960	100.070	100.0	1
KU	C1S	2063302	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063303	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063304	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063305	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063306	03/2016	03/08/2016	100.070	100.030	100.0	1
KU	C1S	2063307	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063308	03/2016	03/08/2016	100.000	100.050	100.1	1
KU	C1S	2063309	03/2016	03/08/2016	100.020	100.050	100.1	1
KU	C1S	2063310	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063311	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063312	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063313	03/2016	03/08/2016	100.020	100.020	100.0	1

KU	C1S	2063314	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063315	03/2016	03/08/2016	99.990	100.070	100.0	1
KU	C1S	2063316	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063317	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063318	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063319	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063320	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063321	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2063322	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063323	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063324	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063325	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063326	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063327	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2063328	03/2016	03/08/2016	99.980	100.060	100.0	1
KU	C1S	2063329	03/2016	03/08/2016	100.030	100.070	100.0	1
KU	C1S	2063330	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2063331	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063332	03/2016	03/08/2016	100.020	99.990	100.1	1
KU	C1S	2063333	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063334	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2063335	03/2016	03/08/2016	99.990	99.950	99.9	1
KU	C1S	2063336	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063337	03/2016	03/08/2016	99.970	100.070	100.0	1
KU	C1S	2063338	03/2016	03/08/2016	99.990	100.110	100.1	1
KU	C1S	2063339	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063340	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2063341	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063342	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063343	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063344	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063345	03/2016	03/08/2016	99.980	100.080	100.1	1
KU	C1S	2063346	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063347	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063348	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063349	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063350	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063351	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063352	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063353	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063354	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063355	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063356	03/2016	03/08/2016	99.990	100.090	100.1	1
KU	C1S	2063357	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063358	03/2016	03/08/2016	99.990	100.010	100.0	1

KU	C1S	2063359	03/2016	03/08/2016	99.960	99.990	100.0	1
KU	C1S	2063360	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063361	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063362	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2063363	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063364	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063365	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2063366	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063367	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2063368	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063369	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063370	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063371	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063372	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063373	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063374	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063375	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2063376	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063377	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2063378	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2063379	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063380	03/2016	03/08/2016	99.950	100.040	100.0	1
KU	C1S	2063381	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2063382	03/2016	03/08/2016	99.970	100.020	100.1	1
KU	C1S	2063383	03/2016	03/08/2016	99.960	100.000	100.0	1
KU	C1S	2063384	03/2016	03/08/2016	99.960	100.030	100.0	1
KU	C1S	2063385	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063386	03/2016	03/08/2016	100.000	99.990	100.1	1
KU	C1S	2063387	03/2016	03/08/2016	99.980	99.950	99.9	1
KU	C1S	2063388	03/2016	03/08/2016	99.990	100.060	100.1	1
KU	C1S	2063389	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063390	03/2016	03/08/2016	100.020	100.080	100.1	1
KU	C1S	2063391	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063392	03/2016	03/08/2016	100.010	100.070	100.0	1
KU	C1S	2063393	03/2016	03/08/2016	99.990	100.060	100.1	1
KU	C1S	2063394	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063395	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063396	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063397	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2063398	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063399	03/2016	03/08/2016	99.980	100.060	100.0	1
KU	C1S	2063400	03/2016	03/08/2016	99.980	100.060	100.1	1
KU	C1S	2063401	03/2016	03/08/2016	99.990	100.060	100.1	1
KU	C1S	2063402	03/2016	03/08/2016	100.030	100.090	100.1	1
KU	C1S	2063403	03/2016	03/08/2016	100.000	99.970	99.9	1

KU	C1S	2063404	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063405	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063406	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063407	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2063408	03/2016	03/08/2016	100.020	100.030	100.1	1
KU	C1S	2063409	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063410	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063411	03/2016	03/08/2016	100.020	100.050	100.1	1
KU	C1S	2063412	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063413	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063414	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063415	03/2016	03/08/2016	100.000	100.090	100.1	1
KU	C1S	2063416	03/2016	03/08/2016	100.010	100.050	100.1	1
KU	C1S	2063417	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063418	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063419	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2063420	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063421	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063422	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063423	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063424	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063425	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063426	03/2016	03/08/2016	100.040	100.050	100.1	1
KU	C1S	2063427	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063428	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063429	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063430	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2063431	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063432	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063433	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063434	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063435	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2063436	03/2016	03/08/2016	99.990	99.950	100.0	1
KU	C1S	2063437	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063438	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2063439	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2063440	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063441	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063442	03/2016	03/08/2016	100.010	99.940	100.0	1
KU	C1S	2063443	03/2016	03/08/2016	99.990	100.060	100.1	1
KU	C1S	2063444	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2063445	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2063446	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063447	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063448	03/2016	03/08/2016	100.000	99.990	100.0	1

KU	C1S	2063449	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2063450	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063451	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063452	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063453	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2063454	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063455	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063456	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063457	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063458	03/2016	03/08/2016	100.030	100.060	100.0	1
KU	C1S	2063459	03/2016	03/08/2016	99.940	100.020	100.0	1
KU	C1S	2063460	03/2016	03/08/2016	100.010	99.960	100.0	1
KU	C1S	2063461	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063462	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063463	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063464	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063465	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063466	03/2016	03/08/2016	100.000	100.070	100.0	1
KU	C1S	2063467	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063468	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063469	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063470	03/2016	03/08/2016	100.010	100.060	100.1	1
KU	C1S	2063471	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063472	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063473	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063474	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063475	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063476	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063477	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2063478	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063479	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063480	03/2016	03/08/2016	99.990	100.080	100.0	1
KU	C1S	2063481	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063482	03/2016	03/08/2016	99.930	100.030	100.0	1
KU	C1S	2063483	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063484	03/2016	03/08/2016	99.980	100.070	100.1	1
KU	C1S	2063485	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063486	03/2016	03/08/2016	100.020	100.020	100.1	1
KU	C1S	2063487	03/2016	03/08/2016	100.010	99.980	100.1	1
KU	C1S	2063488	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063489	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2063490	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2063491	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063492	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063493	03/2016	03/08/2016	99.980	100.010	100.0	1

KU	C1S	2063494	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2063495	03/2016	03/08/2016	100.010	100.070	100.1	1
KU	C1S	2063496	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063497	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2063498	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063499	03/2016	03/08/2016	100.010	99.950	100.0	1
KU	C1S	2063500	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063501	03/2016	03/08/2016	100.040	100.040	100.1	1
KU	C1S	2063502	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063503	03/2016	03/08/2016	100.010	99.970	99.9	1
KU	C1S	2063504	03/2016	03/08/2016	99.980	100.070	100.1	1
KU	C1S	2063505	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063506	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2063507	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063508	03/2016	03/08/2016	100.050	100.040	100.1	1
KU	C1S	2063509	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063510	03/2016	03/08/2016	100.020	100.030	100.1	1
KU	C1S	2063511	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063512	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2063513	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063514	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063515	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063516	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063517	03/2016	03/08/2016	99.990	100.000	100.1	1
KU	C1S	2063518	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063519	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063520	03/2016	03/08/2016	99.970	100.040	100.1	1
KU	C1S	2063521	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2063522	03/2016	03/08/2016	99.970	100.000	100.0	1
KU	C1S	2063523	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063524	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063525	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063526	03/2016	03/08/2016	100.030	100.070	100.1	1
KU	C1S	2063527	03/2016	03/08/2016	100.030	100.050	100.0	1
KU	C1S	2063528	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063529	03/2016	03/08/2016	99.960	100.010	100.0	1
KU	C1S	2063530	03/2016	03/08/2016	99.970	99.920	99.9	1
KU	C1S	2063531	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2063532	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063533	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063534	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063535	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063536	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063537	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2063538	03/2016	03/08/2016	100.010	100.030	100.0	1

KU	C1S	2063539	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063540	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063541	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063542	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2063543	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063544	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063545	03/2016	03/08/2016	100.030	99.970	100.0	1
KU	C1S	2063546	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063547	03/2016	03/08/2016	99.970	99.930	99.9	1
KU	C1S	2063548	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2063549	03/2016	03/08/2016	100.040	100.030	100.1	1
KU	C1S	2063550	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063551	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2063552	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063553	03/2016	03/08/2016	100.000	99.970	100.0	1
KU	C1S	2063554	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063555	03/2016	03/08/2016	99.970	99.950	100.0	1
KU	C1S	2063556	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063557	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063558	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063559	03/2016	03/08/2016	99.960	100.030	100.0	1
KU	C1S	2063560	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063561	03/2016	03/08/2016	99.980	99.970	99.9	1
KU	C1S	2063562	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063563	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2063564	03/2016	03/08/2016	99.970	100.070	100.1	1
KU	C1S	2063565	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063566	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063567	03/2016	03/08/2016	99.970	100.060	100.1	1
KU	C1S	2063568	03/2016	03/08/2016	99.980	100.070	100.1	1
KU	C1S	2063569	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063570	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063571	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2063572	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063573	03/2016	03/08/2016	100.000	99.940	100.0	1
KU	C1S	2063574	03/2016	03/08/2016	100.030	99.900	100.0	1
KU	C1S	2063575	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063576	03/2016	03/08/2016	100.000	100.020	100.1	1
KU	C1S	2063577	03/2016	03/08/2016	99.970	99.970	99.9	1
KU	C1S	2063578	03/2016	03/08/2016	99.990	100.080	100.0	1
KU	C1S	2063579	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063580	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063581	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063582	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2063583	03/2016	03/08/2016	99.970	99.990	100.0	1

KU	C1S	2063584	03/2016	03/08/2016	99.980	99.940	100.0	1
KU	C1S	2063585	03/2016	03/08/2016	100.010	100.050	100.1	1
KU	C1S	2063586	03/2016	03/08/2016	100.030	100.040	100.0	1
KU	C1S	2063587	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063588	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063589	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2063590	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063591	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063592	03/2016	03/08/2016	99.990	100.030	100.1	1
KU	C1S	2063593	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063594	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063595	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063596	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063597	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063598	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063599	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2063600	03/2016	03/08/2016	99.970	100.050	100.1	1
KU	C1S	2063601	03/2016	03/08/2016	99.990	100.010	100.1	1
KU	C1S	2063602	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063603	03/2016	03/08/2016	100.020	100.070	100.1	1
KU	C1S	2063604	03/2016	03/08/2016	99.970	100.020	100.0	1
KU	C1S	2063605	03/2016	03/08/2016	100.010	100.070	100.0	1
KU	C1S	2063606	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2063607	03/2016	03/08/2016	100.000	100.060	100.1	1
KU	C1S	2063608	03/2016	03/08/2016	99.990	100.000	100.1	1
KU	C1S	2063609	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063610	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063611	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2063612	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063613	03/2016	03/08/2016	99.960	99.990	100.0	1
KU	C1S	2063614	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063615	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063616	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063617	03/2016	03/08/2016	100.020	99.950	100.0	1
KU	C1S	2063618	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063619	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063620	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063621	03/2016	03/08/2016	100.040	100.040	100.1	1
KU	C1S	2063622	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063623	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063624	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2063625	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2063626	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063627	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2063628	03/2016	03/08/2016	99.990	99.990	100.0	1

KU	C1S	2063629	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063630	03/2016	03/08/2016	100.040	100.000	100.0	1
KU	C1S	2063631	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063632	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063633	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2063634	03/2016	03/08/2016	100.000	100.070	100.1	1
KU	C1S	2063635	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063636	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063637	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063638	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063639	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063640	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063641	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063642	03/2016	03/08/2016	100.020	99.940	100.0	1
KU	C1S	2063643	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063644	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2063645	03/2016	03/08/2016	100.010	100.030	100.0	1
KU	C1S	2063646	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063647	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063648	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2063649	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063650	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063651	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063652	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063653	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063654	03/2016	03/08/2016	99.970	100.070	100.1	1
KU	C1S	2063655	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2063656	03/2016	03/08/2016	99.990	99.930	100.0	1
KU	C1S	2063657	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063658	03/2016	03/08/2016	99.970	100.010	100.0	1
KU	C1S	2063659	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063660	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063661	03/2016	03/08/2016	99.950	100.020	100.0	1
KU	C1S	2063662	03/2016	03/08/2016	100.000	100.050	100.1	1
KU	C1S	2063663	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063664	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063665	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063666	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063667	03/2016	03/08/2016	100.000	100.070	100.1	1
KU	C1S	2063668	03/2016	03/08/2016	99.950	99.990	100.0	1
KU	C1S	2063669	03/2016	03/08/2016	100.010	100.090	100.1	1
KU	C1S	2063670	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063671	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063672	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063673	03/2016	03/08/2016	100.000	100.050	100.1	1

KU	C1S	2063674	03/2016	03/08/2016	99.990	100.040	100.1	1
KU	C1S	2063675	03/2016	03/08/2016	99.970	100.040	100.0	1
KU	C1S	2063676	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063677	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063678	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063679	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063680	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063681	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063682	03/2016	03/08/2016	100.010	100.050	100.0	1
KU	C1S	2063683	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063684	03/2016	03/08/2016	99.980	99.970	100.0	1
KU	C1S	2063685	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063686	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063687	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063688	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063689	03/2016	03/08/2016	99.970	99.970	100.0	1
KU	C1S	2063690	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063691	03/2016	03/08/2016	99.980	100.050	100.0	1
KU	C1S	2063692	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063693	03/2016	03/08/2016	100.030	99.950	100.0	1
KU	C1S	2063694	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063695	03/2016	03/08/2016	99.990	100.060	100.0	1
KU	C1S	2063696	03/2016	03/08/2016	100.000	100.040	100.1	1
KU	C1S	2063697	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063698	03/2016	03/08/2016	100.030	100.070	100.0	1
KU	C1S	2063699	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063700	03/2016	03/08/2016	100.020	99.990	100.0	1
KU	C1S	2063701	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063702	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063703	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063704	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063705	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063706	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063707	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063708	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063709	03/2016	03/08/2016	100.010	99.970	100.0	1
KU	C1S	2063710	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063711	03/2016	03/08/2016	100.000	100.000	99.9	1
KU	C1S	2063712	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063713	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063714	03/2016	03/08/2016	99.970	100.010	99.9	1
KU	C1S	2063715	03/2016	03/08/2016	100.040	99.990	100.0	1
KU	C1S	2063716	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063717	03/2016	03/08/2016	99.980	99.960	100.0	1
KU	C1S	2063718	03/2016	03/08/2016	99.990	100.010	100.0	1

KU	C1S	2063719	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063720	03/2016	03/08/2016	100.010	100.020	100.1	1
KU	C1S	2063721	03/2016	03/08/2016	100.030	100.020	100.1	1
KU	C1S	2063722	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063723	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063724	03/2016	03/08/2016	100.010	100.010	100.1	1
KU	C1S	2063725	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063726	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063727	03/2016	03/08/2016	100.000	99.990	99.9	1
KU	C1S	2063728	03/2016	03/08/2016	100.000	100.060	100.0	1
KU	C1S	2063729	03/2016	03/08/2016	100.020	99.950	100.0	1
KU	C1S	2063730	03/2016	03/08/2016	100.000	100.000	99.9	1
KU	C1S	2063731	03/2016	03/08/2016	100.010	100.050	100.1	1
KU	C1S	2063732	03/2016	03/08/2016	100.020	99.970	100.0	1
KU	C1S	2063733	03/2016	03/08/2016	100.010	99.940	99.9	1
KU	C1S	2063734	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2063735	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2063736	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063737	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063738	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063739	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063740	03/2016	03/08/2016	100.030	100.050	100.0	1
KU	C1S	2063741	03/2016	03/08/2016	100.000	100.070	99.8	1
KU	C1S	2063742	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063743	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063744	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063745	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063746	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063747	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063748	03/2016	03/08/2016	99.970	100.050	100.1	1
KU	C1S	2063749	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063750	03/2016	03/08/2016	100.010	99.980	100.0	1
KU	C1S	2063751	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063752	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063753	03/2016	03/08/2016	99.990	100.050	100.1	1
KU	C1S	2063754	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2063755	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063756	03/2016	03/08/2016	100.000	99.980	100.0	1
KU	C1S	2063757	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063758	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063759	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063760	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063761	03/2016	03/08/2016	100.020	100.040	100.0	1
KU	C1S	2063762	03/2016	03/08/2016	100.000	100.050	100.0	1
KU	C1S	2063763	03/2016	03/08/2016	100.000	100.040	100.0	1

KU	C1S	2063764	03/2016	03/08/2016	100.030	100.010	100.0	1
KU	C1S	2063765	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2063766	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2063767	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063768	03/2016	03/08/2016	100.020	100.030	100.0	1
KU	C1S	2063769	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063770	03/2016	03/08/2016	99.980	100.020	100.1	1
KU	C1S	2063771	03/2016	03/08/2016	100.000	99.970	99.9	1
KU	C1S	2063772	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063773	03/2016	03/08/2016	100.000	99.950	100.0	1
KU	C1S	2063774	03/2016	03/08/2016	100.050	99.970	99.9	1
KU	C1S	2063775	03/2016	03/08/2016	100.020	99.960	99.9	1
KU	C1S	2063776	03/2016	03/08/2016	99.980	100.060	100.1	1
KU	C1S	2063777	03/2016	03/08/2016	99.980	100.020	100.0	1
KU	C1S	2063778	03/2016	03/08/2016	99.980	99.960	99.9	1
KU	C1S	2063779	03/2016	03/08/2016	100.010	100.000	99.9	1
KU	C1S	2063780	03/2016	03/08/2016	99.990	99.990	99.9	1
KU	C1S	2063781	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063782	03/2016	03/08/2016	100.000	100.010	100.0	1
KU	C1S	2063783	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2063784	03/2016	03/08/2016	100.010	100.010	99.9	1
KU	C1S	2063785	03/2016	03/08/2016	99.990	100.000	100.1	1
KU	C1S	2063786	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063787	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063788	03/2016	03/08/2016	99.980	99.950	100.0	1
KU	C1S	2063789	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063790	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063791	03/2016	03/08/2016	99.970	99.980	100.0	1
KU	C1S	2063792	03/2016	03/08/2016	99.980	100.000	100.0	1
KU	C1S	2063793	03/2016	03/08/2016	99.990	99.980	99.9	1
KU	C1S	2063794	03/2016	03/08/2016	99.970	100.000	100.1	1
KU	C1S	2063795	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063796	03/2016	03/08/2016	99.980	100.050	100.1	1
KU	C1S	2063797	03/2016	03/08/2016	99.990	99.960	99.9	1
KU	C1S	2063798	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063799	03/2016	03/08/2016	100.030	100.050	100.0	1
KU	C1S	2063800	03/2016	03/08/2016	100.020	100.050	100.0	1
KU	C1S	2063801	03/2016	03/08/2016	100.010	100.000	100.0	1
KU	C1S	2063802	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063803	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063804	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063805	03/2016	03/08/2016	99.990	99.960	100.0	1
KU	C1S	2063806	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063807	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063808	03/2016	03/08/2016	100.000	100.020	100.0	1

KU	C1S	2063809	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063810	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063811	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063812	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2063813	03/2016	03/08/2016	99.990	100.000	100.0	1
KU	C1S	2063814	03/2016	03/08/2016	100.000	99.960	100.0	1
KU	C1S	2063815	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063816	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063817	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2063818	03/2016	03/08/2016	99.980	100.030	100.0	1
KU	C1S	2063819	03/2016	03/08/2016	99.970	100.030	100.0	1
KU	C1S	2063820	03/2016	03/08/2016	100.030	100.030	100.0	1
KU	C1S	2063821	03/2016	03/08/2016	100.040	100.030	100.1	1
KU	C1S	2063822	03/2016	03/08/2016	99.990	99.980	100.0	1
KU	C1S	2063823	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063824	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2063825	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063826	03/2016	03/08/2016	100.020	100.020	100.0	1
KU	C1S	2063827	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2063828	03/2016	03/08/2016	100.010	100.020	100.0	1
KU	C1S	2063829	03/2016	03/08/2016	100.020	100.010	100.0	1
KU	C1S	2063830	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063831	03/2016	03/08/2016	100.010	100.000	99.8	1
KU	C1S	2063832	03/2016	03/08/2016	100.030	100.000	100.0	1
KU	C1S	2063833	03/2016	03/08/2016	100.040	99.990	100.0	1
KU	C1S	2063834	03/2016	03/08/2016	100.000	100.030	100.0	1
KU	C1S	2063835	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063836	03/2016	03/08/2016	99.990	100.080	100.0	1
KU	C1S	2063837	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063838	03/2016	03/08/2016	99.980	100.030	100.1	1
KU	C1S	2063839	03/2016	03/08/2016	100.010	100.030	100.1	1
KU	C1S	2063840	03/2016	03/08/2016	99.990	100.080	100.0	1
KU	C1S	2063841	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063842	03/2016	03/08/2016	99.990	100.030	100.0	1
KU	C1S	2063843	03/2016	03/08/2016	100.040	99.980	99.9	1
KU	C1S	2063844	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063845	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2063846	03/2016	03/08/2016	99.990	100.030	100.1	1
KU	C1S	2063847	03/2016	03/08/2016	100.040	100.020	99.9	1
KU	C1S	2063848	03/2016	03/08/2016	100.010	100.040	100.0	1
KU	C1S	2063849	03/2016	03/08/2016	100.040	100.030	100.0	1
KU	C1S	2063850	03/2016	03/08/2016	100.000	99.990	100.0	1
KU	C1S	2063851	03/2016	03/08/2016	99.980	99.950	99.9	1
KU	C1S	2063852	03/2016	03/08/2016	100.000	100.000	99.9	1
KU	C1S	2063853	03/2016	03/08/2016	99.960	100.010	99.9	1

KU	C1S	2063854	03/2016	03/08/2016	100.020	99.950	99.9	1
KU	C1S	2063855	03/2016	03/08/2016	100.000	100.040	100.0	1
KU	C1S	2063856	03/2016	03/08/2016	99.990	99.990	100.0	1
KU	C1S	2063857	03/2016	03/08/2016	100.030	99.980	99.9	1
KU	C1S	2063858	03/2016	03/08/2016	99.970	99.990	100.0	1
KU	C1S	2063859	03/2016	03/08/2016	99.970	100.050	100.0	1
KU	C1S	2063860	03/2016	03/08/2016	99.980	100.020	100.1	1
KU	C1S	2063861	03/2016	03/08/2016	99.990	100.010	100.0	1
KU	C1S	2063862	03/2016	03/08/2016	99.970	100.010	100.1	1
KU	C1S	2063863	03/2016	03/08/2016	99.990	100.020	99.9	1
KU	C1S	2063864	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2063865	03/2016	03/08/2016	100.030	100.090	100.0	1
KU	C1S	2063866	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063867	03/2016	03/08/2016	100.000	100.020	100.0	1
KU	C1S	2063868	03/2016	03/08/2016	99.990	99.970	100.0	1
KU	C1S	2063869	03/2016	03/08/2016	100.010	100.030	99.9	1
KU	C1S	2063870	03/2016	03/08/2016	100.020	99.980	100.0	1
KU	C1S	2063871	03/2016	03/08/2016	100.010	100.010	100.0	1
KU	C1S	2063872	03/2016	03/08/2016	99.980	100.010	100.0	1
KU	C1S	2063873	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063874	03/2016	03/08/2016	99.990	100.020	100.0	1
KU	C1S	2063875	03/2016	03/08/2016	99.980	99.990	100.0	1
KU	C1S	2063876	03/2016	03/08/2016	100.020	100.070	100.0	1
KU	C1S	2063877	03/2016	03/08/2016	100.020	100.000	100.0	1
KU	C1S	2063878	03/2016	03/08/2016	99.990	100.070	100.1	1
KU	C1S	2063879	03/2016	03/08/2016	100.030	100.040	100.0	1
KU	C1S	2063880	03/2016	03/08/2016	100.000	100.050	100.1	1
KU	C1S	2063881	03/2016	03/08/2016	100.000	100.050	99.9	1
KU	C1S	2063882	03/2016	03/08/2016	99.970	100.080	100.0	1
KU	C1S	2063883	03/2016	03/08/2016	99.990	100.040	100.0	1
KU	C1S	2063884	03/2016	03/08/2016	100.000	100.000	100.0	1
KU	C1S	2063885	03/2016	03/08/2016	100.020	100.060	100.0	1
KU	C1S	2063886	03/2016	03/08/2016	100.010	99.990	100.0	1
KU	C1S	2063887	03/2016	03/08/2016	99.990	100.050	100.0	1
KU	C1S	2063888	03/2016	03/08/2016	99.980	99.980	100.0	1
KU	C1S	2063889	03/2016	03/08/2016	100.010	100.060	100.0	1
KU	C1S	2063890	03/2016	03/08/2016	100.030	100.060	100.1	1
KU	C1S	2063891	03/2016	03/08/2016	99.960	100.030	100.1	1
KU	C1S	2063892	03/2016	03/08/2016	100.000	100.030	100.1	1
KU	C1S	2063893	03/2016	03/08/2016	99.960	100.050	100.0	1
KU	C1S	2063894	03/2016	03/08/2016	100.030	100.020	100.0	1
KU	C1S	2063895	03/2016	03/08/2016	99.980	100.040	100.0	1
KU	C1S	2063896	03/2016	03/08/2016	99.990	99.980	99.9	1
KU	C1S	2063897	03/2016	03/08/2016	100.040	99.990	99.9	1
KU	C1S	2063898	03/2016	03/08/2016	99.990	100.070	100.1	1

KU	C1S	2063899	03/2016	03/08/2016	100.060	100.010	100.0	100.0	1
KU	C1S	2063900	03/2016	03/08/2016	100.010	100.060	100.0	100.0	1
KU	C1S	2063901	03/2016	03/08/2016	99.980	100.020	100.0	100.0	1
KU	C1S	2063902	03/2016	03/08/2016	100.000	100.010	100.0	100.0	1
KU	C1S	2063903	03/2016	03/08/2016	100.020	100.050	100.0	100.0	1
KU	C1S	2063904	03/2016	03/08/2016	100.000	100.020	100.0	100.0	1
KU	C1S	2063905	03/2016	03/08/2016	100.000	99.980	100.0	100.0	1
KU	C1S	2063906	03/2016	03/08/2016	99.990	100.000	100.0	100.0	1
KU	C1S	2063907	03/2016	03/08/2016	100.000	100.030	100.0	100.0	1
KU	C1S	2063908	03/2016	03/08/2016	99.970	100.040	100.0	100.0	1
KU	C1S	2063909	03/2016	03/08/2016	100.010	99.980	100.0	100.0	1
KU	C1S	2063910	03/2016	03/08/2016	99.970	99.980	100.0	100.0	1
KU	C1S	2063911	03/2016	03/08/2016	100.020	100.000	100.0	100.0	1
KU	C1S	2063912	03/2016	03/08/2016	100.000	100.040	100.1	100.1	1
KU	C1S	2063913	03/2016	03/08/2016	100.020	100.050	100.1	100.1	1
KU	C1S	2063914	03/2016	03/08/2016	100.010	100.040	100.0	100.0	1
KU	C1S	2063915	03/2016	03/08/2016	99.980	100.000	100.0	100.0	1
KU	C1S	2063916	03/2016	03/08/2016	100.010	100.080	100.0	100.0	1
KU	C1S	2063917	03/2016	03/08/2016	100.000	100.000	100.0	100.0	1
KU	C1S	2063918	03/2016	03/08/2016	100.000	100.060	100.1	100.1	1
KU	C1S	2063919	03/2016	03/08/2016	100.020	100.030	100.0	100.0	1
KU	C1S	2063920	03/2016	03/08/2016	99.990	100.030	100.0	100.0	1
KU	C1S	2063921	03/2016	03/08/2016	100.000	100.010	100.1	100.1	1
KU	C1S	2063922	03/2016	03/08/2016	100.010	100.030	100.0	100.0	1
KU	C1S	2063923	03/2016	03/08/2016	99.990	100.040	100.0	100.0	1
KU	C1S	2063924	03/2016	03/08/2016	99.990	100.050	100.0	100.0	1
KU	C1S	2063925	03/2016	03/08/2016	100.010	100.050	100.1	100.1	1
KU	C1S	2063926	03/2016	03/08/2016	99.990	100.060	100.0	100.0	1
KU	C1S	2063927	03/2016	03/08/2016	100.000	100.040	100.0	100.0	1
KU	C1S	2063928	03/2016	03/08/2016	100.010	100.000	99.9	99.9	1
KU	C1S	2063929	03/2016	03/08/2016	100.010	99.970	99.8	99.8	1
KU	C1S	2063930	03/2016	03/08/2016	100.010	100.000	100.0	100.0	1
KU	C1S	2063931	03/2016	03/08/2016	99.990	99.940	99.9	99.9	1
KU	C1S	2063932	03/2016	03/08/2016	100.010	100.020	100.0	100.0	1
KU	C1S	2063933	03/2016	03/08/2016	99.980	100.060	100.1	100.1	1
KU	C1S	2063934	03/2016	03/08/2016	99.950	100.060	100.1	100.1	1
KU	C1S	2063935	03/2016	03/08/2016	100.000	100.020	100.0	100.0	1
KU	C1S	2063936	03/2016	03/08/2016	100.010	100.000	99.9	99.9	1
KU	C1S	2063937	03/2016	03/08/2016	100.010	100.000	100.0	100.0	1
KU	C1S	2063938	03/2016	03/08/2016	100.000	100.000	99.9	99.9	1
KU	C1S	2063939	03/2016	03/08/2016	99.970	100.050	100.1	100.1	1
KU	C1S	2064060	04/2016	04/14/2016	99.980	100.000	100.0	100.0	1
KU	C1S	2064061	04/2016	04/14/2016	100.010	99.970	100.0	100.0	1
KU	C1S	2064062	04/2016	04/14/2016	99.990	99.990	100.0	100.0	1
KU	C1S	2064063	04/2016	04/14/2016	100.010	100.010	100.0	100.0	1

KU	C1S	2064064	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064065	04/2016	04/14/2016	100.030	100.050	100.0	1
KU	C1S	2064066	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064067	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064068	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064069	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064070	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064071	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064072	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2064073	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064074	04/2016	04/14/2016	99.980	100.060	100.1	1
KU	C1S	2064075	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064076	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064077	04/2016	04/14/2016	99.960	100.010	100.0	1
KU	C1S	2064078	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064079	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064080	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064081	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064082	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064083	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064084	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064085	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064086	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064087	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064088	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064089	04/2016	04/14/2016	99.980	99.940	100.0	1
KU	C1S	2064090	04/2016	04/14/2016	99.970	100.010	100.1	1
KU	C1S	2064091	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2064092	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2064093	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064094	04/2016	04/14/2016	100.030	99.970	100.0	1
KU	C1S	2064095	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2064096	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064097	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064098	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064099	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2064100	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064101	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064102	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064103	04/2016	04/14/2016	99.960	99.970	100.0	1
KU	C1S	2064104	04/2016	04/14/2016	100.030	100.060	100.1	1
KU	C1S	2064105	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2064106	04/2016	04/14/2016	100.000	100.020	100.1	1
KU	C1S	2064107	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064108	04/2016	04/14/2016	100.000	99.980	100.0	1

KU	C1S	2064109	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2064110	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064111	04/2016	04/14/2016	100.010	99.950	100.0	1
KU	C1S	2064112	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064113	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064114	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064115	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064116	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064117	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064118	04/2016	04/14/2016	100.030	100.050	100.1	1
KU	C1S	2064119	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2064120	04/2016	04/14/2016	100.050	99.960	100.0	1
KU	C1S	2064121	04/2016	04/14/2016	99.950	100.000	100.0	1
KU	C1S	2064122	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064123	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064124	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064125	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064126	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064127	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064128	04/2016	04/14/2016	100.000	99.940	100.0	1
KU	C1S	2064129	04/2016	04/14/2016	99.980	100.030	100.1	1
KU	C1S	2064130	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064131	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2064132	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064133	04/2016	04/14/2016	100.030	99.970	100.0	1
KU	C1S	2064134	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064135	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2064136	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064137	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064138	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064139	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064140	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064141	04/2016	04/14/2016	99.970	99.980	100.0	1
KU	C1S	2064142	04/2016	04/14/2016	100.000	100.000	100.1	1
KU	C1S	2064143	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064144	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064145	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064146	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064147	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064148	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064149	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064150	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064151	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2064152	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064153	04/2016	04/14/2016	99.970	99.990	100.0	1

KU	C1S	2064154	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064155	04/2016	04/14/2016	100.030	99.970	100.0	1
KU	C1S	2064156	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2064157	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2064158	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064159	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064160	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064161	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064162	04/2016	04/14/2016	100.000	99.860	99.9	1
KU	C1S	2064163	04/2016	04/14/2016	100.030	99.950	100.0	1
KU	C1S	2064164	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2064165	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064166	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064167	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2064168	04/2016	04/14/2016	99.980	99.930	99.9	1
KU	C1S	2064169	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064170	04/2016	04/14/2016	99.990	100.000	100.1	1
KU	C1S	2064171	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064172	04/2016	04/14/2016	99.960	100.000	100.0	1
KU	C1S	2064173	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064174	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064175	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064176	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064177	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2064178	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064179	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064180	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064181	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064182	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064183	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2064184	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064185	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064186	04/2016	04/14/2016	99.950	100.000	100.0	1
KU	C1S	2064187	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2064188	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064189	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064190	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064191	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064192	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064193	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064194	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064195	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064196	04/2016	04/14/2016	100.020	100.010	100.1	1
KU	C1S	2064197	04/2016	04/14/2016	100.030	99.960	100.0	1
KU	C1S	2064198	04/2016	04/14/2016	99.980	99.980	100.0	1

KU	C1S	2064199	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064200	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2064201	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064202	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064203	04/2016	04/14/2016	99.950	99.990	100.0	1
KU	C1S	2064204	04/2016	04/14/2016	100.020	100.000	100.1	1
KU	C1S	2064205	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2064206	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064207	04/2016	04/14/2016	99.990	99.990	100.1	1
KU	C1S	2064208	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2064209	04/2016	04/14/2016	99.970	99.980	100.0	1
KU	C1S	2064210	04/2016	04/14/2016	99.960	99.990	100.0	1
KU	C1S	2064211	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064212	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064213	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064214	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2064215	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064216	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064217	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064218	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064219	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064220	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2064221	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064222	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064223	04/2016	04/14/2016	99.990	100.050	100.1	1
KU	C1S	2064224	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2064225	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064226	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064227	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2064228	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064229	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064230	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064231	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064232	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064233	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064234	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064235	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064236	04/2016	04/14/2016	99.990	99.970	99.9	1
KU	C1S	2064237	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2064238	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064239	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064240	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064241	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064242	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064243	04/2016	04/14/2016	99.970	100.020	100.1	1

KU	C1S	2064244	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2064245	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064246	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064247	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064248	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064249	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064250	04/2016	04/14/2016	99.970	100.030	100.1	1
KU	C1S	2064251	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064252	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064253	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064254	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064255	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064256	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064257	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064258	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064259	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064260	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064261	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2064262	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064263	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2064264	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064265	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064266	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064267	04/2016	04/14/2016	100.050	100.020	100.0	1
KU	C1S	2064268	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064269	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064270	04/2016	04/14/2016	99.960	99.960	100.0	1
KU	C1S	2064271	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064272	04/2016	04/14/2016	99.950	99.960	100.0	1
KU	C1S	2064273	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064274	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064275	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064276	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064277	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064278	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064279	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064280	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064281	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064282	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064283	04/2016	04/14/2016	99.960	99.980	100.0	1
KU	C1S	2064284	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064285	04/2016	04/14/2016	99.960	100.020	100.0	1
KU	C1S	2064286	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064287	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064288	04/2016	04/14/2016	99.980	100.010	100.0	1

KU	C1S	2064289	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064290	04/2016	04/14/2016	99.960	100.010	100.0	1
KU	C1S	2064291	04/2016	04/14/2016	99.990	100.000	100.1	1
KU	C1S	2064292	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064293	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064294	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064295	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2064296	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064297	04/2016	04/14/2016	100.020	100.020	100.1	1
KU	C1S	2064298	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064299	04/2016	04/14/2016	100.030	99.960	100.0	1
KU	C1S	2064300	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064301	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064302	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064303	04/2016	04/14/2016	100.020	99.950	100.0	1
KU	C1S	2064304	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064305	04/2016	04/14/2016	100.030	100.060	100.1	1
KU	C1S	2064306	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2064307	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064308	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2064309	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064310	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064311	04/2016	04/14/2016	100.050	100.010	100.0	1
KU	C1S	2064312	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064313	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064314	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064315	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064316	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064317	04/2016	04/14/2016	100.060	100.010	100.0	1
KU	C1S	2064318	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064319	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064320	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064321	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064322	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064323	04/2016	04/14/2016	99.970	100.040	100.1	1
KU	C1S	2064324	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2064325	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064326	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064327	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064328	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064329	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064330	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064331	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064332	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064333	04/2016	04/14/2016	99.980	99.960	100.0	1

KU	C1S	2064334	04/2016	04/14/2016	99.990	99.940	100.0	1
KU	C1S	2064335	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064336	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064337	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2064338	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064339	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064340	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064341	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064342	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2064343	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2064344	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2064345	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064346	04/2016	04/14/2016	100.050	99.980	100.0	1
KU	C1S	2064347	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064348	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064349	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2064350	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064351	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064352	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2064353	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064354	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064355	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064356	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064357	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064358	04/2016	04/14/2016	100.010	99.980	100.1	1
KU	C1S	2064359	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064360	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064361	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2064362	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2064363	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064364	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064365	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064366	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2064367	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2064368	04/2016	04/14/2016	99.960	100.030	100.1	1
KU	C1S	2064369	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2064370	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2064371	04/2016	04/14/2016	100.030	99.960	100.0	1
KU	C1S	2064372	04/2016	04/14/2016	100.050	100.000	100.0	1
KU	C1S	2064373	04/2016	04/14/2016	100.020	99.940	99.9	1
KU	C1S	2064374	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064375	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064376	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064377	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064378	04/2016	04/14/2016	100.000	99.970	100.0	1

1	100.0	99.950	99.960	04/14/2016	04/2016	2064423	CIS	KU
1	100.0	100.000	99.980	04/14/2016	04/2016	2064422	CIS	KU
1	100.0	99.980	100.040	04/14/2016	04/2016	2064421	CIS	KU
1	100.0	99.980	100.000	04/14/2016	04/2016	2064420	CIS	KU
1	100.0	100.000	100.000	04/14/2016	04/2016	2064419	CIS	KU
1	100.0	99.990	100.020	04/14/2016	04/2016	2064418	CIS	KU
1	100.0	100.020	100.000	04/14/2016	04/2016	2064417	CIS	KU
1	100.0	99.980	100.000	04/14/2016	04/2016	2064416	CIS	KU
1	100.0	100.040	100.040	04/14/2016	04/2016	2064415	CIS	KU
1	100.0	99.990	99.980	04/14/2016	04/2016	2064414	CIS	KU
1	100.0	99.970	99.990	04/14/2016	04/2016	2064413	CIS	KU
1	100.0	100.020	100.010	04/14/2016	04/2016	2064412	CIS	KU
1	100.0	100.020	100.000	04/14/2016	04/2016	2064411	CIS	KU
1	100.0	100.030	100.010	04/14/2016	04/2016	2064410	CIS	KU
1	100.0	99.960	100.020	04/14/2016	04/2016	2064409	CIS	KU
1	100.1	100.000	100.010	04/14/2016	04/2016	2064408	CIS	KU
1	100.0	100.010	100.020	04/14/2016	04/2016	2064407	CIS	KU
1	100.0	100.020	99.990	04/14/2016	04/2016	2064406	CIS	KU
1	100.0	100.000	100.010	04/14/2016	04/2016	2064405	CIS	KU
1	100.0	99.970	100.020	04/14/2016	04/2016	2064404	CIS	KU
1	100.0	99.980	100.000	04/14/2016	04/2016	2064403	CIS	KU
1	100.0	99.950	99.980	04/14/2016	04/2016	2064402	CIS	KU
1	100.0	100.020	100.000	04/14/2016	04/2016	2064401	CIS	KU
1	100.0	99.990	100.000	04/14/2016	04/2016	2064400	CIS	KU
1	100.0	99.990	100.000	04/14/2016	04/2016	2064399	CIS	KU
1	100.0	99.990	100.030	04/14/2016	04/2016	2064398	CIS	KU
1	100.0	100.000	99.990	04/14/2016	04/2016	2064397	CIS	KU
1	100.0	99.980	100.010	04/14/2016	04/2016	2064396	CIS	KU
1	100.0	100.020	100.050	04/14/2016	04/2016	2064395	CIS	KU
1	100.0	99.990	100.000	04/14/2016	04/2016	2064394	CIS	KU
1	100.0	100.010	99.990	04/14/2016	04/2016	2064393	CIS	KU
1	100.0	100.030	100.000	04/14/2016	04/2016	2064392	CIS	KU
1	100.0	100.000	100.020	04/14/2016	04/2016	2064391	CIS	KU
1	100.0	100.010	100.010	04/14/2016	04/2016	2064390	CIS	KU
1	100.0	100.000	100.000	04/14/2016	04/2016	2064389	CIS	KU
1	100.0	99.970	100.030	04/14/2016	04/2016	2064388	CIS	KU
1	100.0	99.970	100.020	04/14/2016	04/2016	2064387	CIS	KU
1	100.0	99.980	100.020	04/14/2016	04/2016	2064386	CIS	KU
1	100.0	100.010	99.980	04/14/2016	04/2016	2064385	CIS	KU
1	100.0	100.030	100.030	04/14/2016	04/2016	2064384	CIS	KU
1	100.0	99.990	100.020	04/14/2016	04/2016	2064383	CIS	KU
1	100.0	99.940	100.010	04/14/2016	04/2016	2064382	CIS	KU
1	100.0	100.000	99.980	04/14/2016	04/2016	2064381	CIS	KU
1	100.0	99.970	100.020	04/14/2016	04/2016	2064380	CIS	KU
1	100.0	100.010	100.050	04/14/2016	04/2016	2064379	CIS	KU

KU	C1S	2064424	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2064425	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064426	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064427	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064428	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064429	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064430	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064431	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064432	04/2016	04/14/2016	99.980	100.050	100.0	1
KU	C1S	2064433	04/2016	04/14/2016	99.980	100.070	100.0	1
KU	C1S	2064434	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064435	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064436	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2064437	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064438	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064439	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064440	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064441	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064442	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064443	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064444	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064445	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064446	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064447	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064448	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064449	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064450	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064451	04/2016	04/14/2016	100.030	100.040	100.1	1
KU	C1S	2064452	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2064453	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064454	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064455	04/2016	04/14/2016	99.990	99.990	99.9	1
KU	C1S	2064456	04/2016	04/14/2016	100.000	100.000	100.1	1
KU	C1S	2064457	04/2016	04/14/2016	100.030	100.020	100.1	1
KU	C1S	2064458	04/2016	04/14/2016	99.980	99.930	100.0	1
KU	C1S	2064459	04/2016	04/14/2016	99.960	100.030	100.0	1
KU	C1S	2064460	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064461	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064462	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2064463	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064464	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064465	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064466	04/2016	04/14/2016	100.050	99.980	100.0	1
KU	C1S	2064467	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064468	04/2016	04/14/2016	99.990	100.010	100.0	1

KU	C1S	2064469	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2064470	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064471	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064472	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064473	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064474	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2064475	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064476	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064477	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064478	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064479	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064480	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064481	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2064482	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2064483	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064484	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064485	04/2016	04/14/2016	100.020	99.950	100.0	1
KU	C1S	2064486	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2064487	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064488	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064489	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064490	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064491	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2064492	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064493	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2064494	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064495	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064496	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064497	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064498	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064499	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064500	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064501	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064502	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064503	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064504	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064505	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064506	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064507	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2064508	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2064509	04/2016	04/14/2016	99.960	99.990	100.0	1
KU	C1S	2064510	04/2016	04/14/2016	99.990	99.950	100.0	1
KU	C1S	2064511	04/2016	04/14/2016	100.050	100.010	100.0	1
KU	C1S	2064512	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064513	04/2016	04/14/2016	100.010	100.030	100.1	1

KU	C1S	2064514	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064515	04/2016	04/14/2016	99.960	99.980	100.0	1
KU	C1S	2064516	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064517	04/2016	04/14/2016	99.980	100.070	100.1	1
KU	C1S	2064518	04/2016	04/14/2016	100.020	100.050	100.1	1
KU	C1S	2064519	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064520	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2064521	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064522	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064523	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064524	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064525	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064526	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064527	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064528	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064529	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064530	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064531	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064532	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064533	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064534	04/2016	04/14/2016	99.960	99.990	100.0	1
KU	C1S	2064535	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064536	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064537	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064538	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064539	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064540	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064541	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064542	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064543	04/2016	04/14/2016	99.950	99.970	100.0	1
KU	C1S	2064544	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064545	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2064546	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064547	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064548	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064549	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064550	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064551	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064552	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064553	04/2016	04/14/2016	99.960	99.980	100.0	1
KU	C1S	2064554	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064555	04/2016	04/14/2016	99.990	100.010	100.1	1
KU	C1S	2064556	04/2016	04/14/2016	100.030	99.970	100.0	1
KU	C1S	2064557	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2064558	04/2016	04/14/2016	100.030	100.050	100.0	1

KU	C1S	2064559	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064560	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064561	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064562	04/2016	04/14/2016	99.960	100.050	100.1	1
KU	C1S	2064563	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064564	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064565	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064566	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064567	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2064568	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064569	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064570	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064571	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064572	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2064573	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2064574	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064575	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2064576	04/2016	04/14/2016	100.000	99.930	100.0	1
KU	C1S	2064577	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064578	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064579	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064580	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064581	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064582	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064583	04/2016	04/14/2016	100.020	99.950	100.0	1
KU	C1S	2064584	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064585	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064586	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064587	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064588	04/2016	04/14/2016	100.030	99.970	99.9	1
KU	C1S	2064589	04/2016	04/14/2016	100.020	99.970	100.1	1
KU	C1S	2064590	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2064591	04/2016	04/14/2016	99.960	99.980	100.1	1
KU	C1S	2064592	04/2016	04/14/2016	100.020	99.940	100.0	1
KU	C1S	2064593	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064594	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064595	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064596	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064597	04/2016	04/14/2016	100.020	99.980	99.9	1
KU	C1S	2064598	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064599	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064600	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2064601	04/2016	04/14/2016	100.000	99.960	99.9	1
KU	C1S	2064602	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064603	04/2016	04/14/2016	99.950	100.020	100.0	1

KU	C1S	2064604	04/2016	04/14/2016	99.990	100.020	100.1	1
KU	C1S	2064605	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064606	04/2016	04/14/2016	99.940	99.990	100.0	1
KU	C1S	2064607	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2064608	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064609	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064610	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064611	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064612	04/2016	04/14/2016	100.000	100.010	100.1	1
KU	C1S	2064613	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064614	04/2016	04/14/2016	99.980	99.950	100.0	1
KU	C1S	2064615	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064616	04/2016	04/14/2016	100.040	100.020	100.1	1
KU	C1S	2064617	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064618	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064619	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064620	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064621	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064622	04/2016	04/14/2016	100.030	100.010	100.1	1
KU	C1S	2064623	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064624	04/2016	04/14/2016	100.040	100.040	100.1	1
KU	C1S	2064625	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064626	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064627	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064628	04/2016	04/14/2016	100.050	99.990	100.0	1
KU	C1S	2064629	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2064630	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064631	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064632	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064633	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2064634	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064635	04/2016	04/14/2016	99.990	100.050	100.1	1
KU	C1S	2064636	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2064637	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064638	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064639	04/2016	04/14/2016	100.010	100.000	100.1	1
KU	C1S	2064640	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064641	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064642	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064643	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2064644	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064645	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064646	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2064647	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064648	04/2016	04/14/2016	99.980	100.010	100.0	1

KU	C1S	2064649	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064650	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064651	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064652	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064653	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064654	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064655	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064656	04/2016	04/14/2016	100.030	100.020	100.1	1
KU	C1S	2064657	04/2016	04/14/2016	100.020	100.050	100.1	1
KU	C1S	2064658	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064659	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064660	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2064661	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064662	04/2016	04/14/2016	99.980	100.050	100.0	1
KU	C1S	2064663	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064664	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064665	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2064666	04/2016	04/14/2016	100.000	100.010	100.1	1
KU	C1S	2064667	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064668	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2064669	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2064670	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064671	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064672	04/2016	04/14/2016	100.010	99.960	100.0	1
KU	C1S	2064673	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064674	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064675	04/2016	04/14/2016	99.990	100.060	100.1	1
KU	C1S	2064676	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064677	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064678	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064679	04/2016	04/14/2016	99.980	100.030	100.1	1
KU	C1S	2064680	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064681	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064682	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064683	04/2016	04/14/2016	99.950	99.980	100.0	1
KU	C1S	2064684	04/2016	04/14/2016	99.970	100.050	100.0	1
KU	C1S	2064685	04/2016	04/14/2016	99.990	100.020	100.1	1
KU	C1S	2064686	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064687	04/2016	04/14/2016	99.970	100.010	100.1	1
KU	C1S	2064688	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064689	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2064690	04/2016	04/14/2016	100.020	100.030	100.1	1
KU	C1S	2064691	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064692	04/2016	04/14/2016	100.020	100.010	100.1	1
KU	C1S	2064693	04/2016	04/14/2016	100.010	100.010	100.0	1

KU	C1S	2064694	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064695	04/2016	04/14/2016	99.970	100.010	100.1	1
KU	C1S	2064696	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064697	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064698	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064699	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064700	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064701	04/2016	04/14/2016	100.010	100.020	100.1	1
KU	C1S	2064702	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064703	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064704	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064705	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064706	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064707	04/2016	04/14/2016	100.040	100.010	100.1	1
KU	C1S	2064708	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064709	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064710	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064711	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064712	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064713	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064714	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064715	04/2016	04/14/2016	99.950	100.030	100.0	1
KU	C1S	2064716	04/2016	04/14/2016	99.950	100.000	100.0	1
KU	C1S	2064717	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064718	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2064719	04/2016	04/14/2016	99.950	100.010	100.0	1
KU	C1S	2064720	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064721	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2064722	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064723	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064724	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064725	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064726	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064727	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064728	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2064729	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064730	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2064731	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064732	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2064733	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064734	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064735	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064736	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064737	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064738	04/2016	04/14/2016	99.990	100.030	100.0	1

KU	C1S	2064739	04/2016	04/14/2016	100.050	100.030	100.0	1
KU	C1S	2064740	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064741	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064742	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064743	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064744	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064745	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064746	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064747	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2064748	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064749	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064750	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064751	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064752	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064753	04/2016	04/14/2016	100.010	100.000	100.1	1
KU	C1S	2064754	04/2016	04/14/2016	100.000	100.000	100.1	1
KU	C1S	2064755	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064756	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064757	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2064758	04/2016	04/14/2016	100.020	100.030	100.1	1
KU	C1S	2064759	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064760	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064761	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2064762	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064763	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064764	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064765	04/2016	04/14/2016	99.970	100.030	100.1	1
KU	C1S	2064766	04/2016	04/14/2016	100.000	99.950	100.0	1
KU	C1S	2064767	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064768	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064769	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2064770	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064771	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064772	04/2016	04/14/2016	99.970	100.050	100.1	1
KU	C1S	2064773	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064774	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064775	04/2016	04/14/2016	99.970	100.020	100.1	1
KU	C1S	2064776	04/2016	04/14/2016	100.010	99.960	100.1	1
KU	C1S	2064777	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2064778	04/2016	04/14/2016	100.020	100.020	100.1	1
KU	C1S	2064779	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064780	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064781	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064782	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2064783	04/2016	04/14/2016	99.980	100.010	100.0	1

KU	C1S	2064784	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064785	04/2016	04/14/2016	99.990	100.010	100.1	1
KU	C1S	2064786	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064787	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064788	04/2016	04/14/2016	99.990	100.010	100.1	1
KU	C1S	2064789	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064790	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064791	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2064792	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2064793	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064794	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064795	04/2016	04/14/2016	99.980	99.990	100.1	1
KU	C1S	2064796	04/2016	04/14/2016	100.000	100.050	100.1	1
KU	C1S	2064797	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064798	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2064799	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064800	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064801	04/2016	04/14/2016	99.980	100.010	100.1	1
KU	C1S	2064802	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2064803	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064804	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064805	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064806	04/2016	04/14/2016	100.020	100.030	100.1	1
KU	C1S	2064807	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064808	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2064809	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064810	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064811	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064812	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064813	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2064814	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064815	04/2016	04/14/2016	99.980	100.090	100.1	1
KU	C1S	2064816	04/2016	04/14/2016	100.030	100.020	100.1	1
KU	C1S	2064817	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064818	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064819	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2064820	04/2016	04/14/2016	100.010	100.060	100.0	1
KU	C1S	2064821	04/2016	04/14/2016	99.990	100.010	100.1	1
KU	C1S	2064822	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064823	04/2016	04/14/2016	99.960	100.020	100.1	1
KU	C1S	2064824	04/2016	04/14/2016	99.960	100.050	100.1	1
KU	C1S	2064825	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064826	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064827	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064828	04/2016	04/14/2016	100.000	99.990	100.0	1

KU	C1S	2064829	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2064830	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064831	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064832	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064833	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064834	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2064835	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064836	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2064837	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064838	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064839	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064840	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064841	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064842	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064843	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064844	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064845	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2064846	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2064847	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064848	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064849	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064850	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064851	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064852	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064853	04/2016	04/14/2016	99.950	100.000	100.1	1
KU	C1S	2064854	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064855	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064856	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2064857	04/2016	04/14/2016	99.960	99.970	99.9	1
KU	C1S	2064858	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2064859	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2064860	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064861	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064862	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2064863	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064864	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064865	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064866	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064867	04/2016	04/14/2016	99.950	100.020	100.0	1
KU	C1S	2064868	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064869	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064870	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064871	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064872	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064873	04/2016	04/14/2016	100.000	100.020	100.1	1

KU	C1S	2064874	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064875	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2064876	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064877	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064878	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2064879	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064880	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064881	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2064882	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064883	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064884	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064885	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2064886	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2064887	04/2016	04/14/2016	99.960	100.010	100.0	1
KU	C1S	2064888	04/2016	04/14/2016	99.980	99.930	100.0	1
KU	C1S	2064889	04/2016	04/14/2016	99.990	100.070	100.1	1
KU	C1S	2064890	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064891	04/2016	04/14/2016	99.960	100.070	100.1	1
KU	C1S	2064892	04/2016	04/14/2016	100.020	100.030	100.1	1
KU	C1S	2064893	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064894	04/2016	04/14/2016	100.000	100.060	100.0	1
KU	C1S	2064895	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064896	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064897	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2064898	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2064899	04/2016	04/14/2016	99.970	99.990	100.1	1
KU	C1S	2064900	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064901	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064902	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2064903	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2064904	04/2016	04/14/2016	100.010	100.060	100.1	1
KU	C1S	2064905	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064906	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2064907	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064908	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2064909	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2064910	04/2016	04/14/2016	100.050	99.980	100.0	1
KU	C1S	2064911	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2064912	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064913	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2064914	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2064915	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2064916	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064917	04/2016	04/14/2016	99.960	100.060	100.0	1
KU	C1S	2064918	04/2016	04/14/2016	100.020	100.030	100.0	1

KU	C1S	2064919	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064920	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064921	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064922	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2064923	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2064924	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064925	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064926	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2064927	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2064928	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2064929	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2064930	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2064931	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064932	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064933	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064934	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064935	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064936	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064937	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2064938	04/2016	04/14/2016	100.020	100.020	100.1	1
KU	C1S	2064939	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2064940	04/2016	04/14/2016	100.010	99.950	100.0	1
KU	C1S	2064941	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2064942	04/2016	04/14/2016	99.980	100.010	100.1	1
KU	C1S	2064943	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2064944	04/2016	04/14/2016	100.070	100.010	100.0	1
KU	C1S	2064945	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2064946	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2064947	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2064948	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064949	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064950	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2064951	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2064952	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2064953	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2064954	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2064955	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064956	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064957	04/2016	04/14/2016	100.010	100.020	100.1	1
KU	C1S	2064958	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2064959	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064960	04/2016	04/14/2016	100.020	100.020	100.1	1
KU	C1S	2064961	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2064962	04/2016	04/14/2016	99.960	100.050	100.0	1
KU	C1S	2064963	04/2016	04/14/2016	100.010	100.020	100.1	1

KU	C1S	2064964	04/2016	04/14/2016	100.000	100.020	100.1	1
KU	C1S	2064965	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2064966	04/2016	04/14/2016	100.030	100.040	100.1	1
KU	C1S	2064967	04/2016	04/14/2016	99.970	100.040	100.0	1
KU	C1S	2064968	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2064969	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2064970	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064971	04/2016	04/14/2016	100.020	100.050	100.1	1
KU	C1S	2064972	04/2016	04/14/2016	100.000	100.050	100.1	1
KU	C1S	2064973	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064974	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2064975	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2064976	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064977	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2064978	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2064979	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064980	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2064981	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2064982	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2064983	04/2016	04/14/2016	100.000	100.070	100.1	1
KU	C1S	2064984	04/2016	04/14/2016	99.970	99.970	100.0	1
KU	C1S	2064985	04/2016	04/14/2016	99.960	100.020	100.0	1
KU	C1S	2064986	04/2016	04/14/2016	99.960	100.010	100.1	1
KU	C1S	2064987	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064988	04/2016	04/14/2016	100.010	99.940	100.0	1
KU	C1S	2064989	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2064990	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2064991	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2064992	04/2016	04/14/2016	100.030	99.960	100.0	1
KU	C1S	2064993	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2064994	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2064995	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2064996	04/2016	04/14/2016	100.040	100.040	100.0	1
KU	C1S	2064997	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2064998	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2064999	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2065000	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2065001	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065002	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065003	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065004	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065005	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2065006	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065007	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065008	04/2016	04/14/2016	100.030	100.000	100.0	1

KU	C1S	2065009	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065010	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065011	04/2016	04/14/2016	100.030	100.070	100.1	1
KU	C1S	2065012	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065013	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065014	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065015	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065016	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065017	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065018	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065019	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065020	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065021	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2065022	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065023	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065024	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065025	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065026	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065027	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065028	04/2016	04/14/2016	100.040	100.040	100.0	1
KU	C1S	2065029	04/2016	04/14/2016	99.970	100.030	100.1	1
KU	C1S	2065030	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065031	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065032	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065033	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065034	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065035	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065036	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065037	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065038	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2065039	04/2016	04/14/2016	100.040	100.040	100.0	1
KU	C1S	2065040	04/2016	04/14/2016	100.040	100.030	100.1	1
KU	C1S	2065041	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065042	04/2016	04/14/2016	100.010	100.070	100.0	1
KU	C1S	2065043	04/2016	04/14/2016	100.050	100.000	100.0	1
KU	C1S	2065044	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065045	04/2016	04/14/2016	99.960	100.010	100.0	1
KU	C1S	2065046	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065047	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2065048	04/2016	04/14/2016	99.960	100.030	100.0	1
KU	C1S	2065049	04/2016	04/14/2016	100.010	100.020	99.9	1
KU	C1S	2065050	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2065051	04/2016	04/14/2016	99.960	100.020	100.0	1
KU	C1S	2065052	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065053	04/2016	04/14/2016	99.980	100.010	100.0	1

KU	C1S	2065054	04/2016	04/14/2016	100.000	100.010	100.1	1
KU	C1S	2065055	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065056	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065057	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065058	04/2016	04/14/2016	100.030	100.010	100.1	1
KU	C1S	2065059	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2065060	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2065061	04/2016	04/14/2016	100.010	100.070	100.1	1
KU	C1S	2065062	04/2016	04/14/2016	99.970	100.030	100.1	1
KU	C1S	2065063	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065064	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065065	04/2016	04/14/2016	100.050	100.000	100.0	1
KU	C1S	2065066	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065067	04/2016	04/14/2016	99.990	100.000	100.1	1
KU	C1S	2065068	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065069	04/2016	04/14/2016	99.970	100.040	100.1	1
KU	C1S	2065070	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065071	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065072	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065073	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065074	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065075	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065076	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065077	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065078	04/2016	04/14/2016	99.960	100.010	100.0	1
KU	C1S	2065079	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065080	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2065081	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065082	04/2016	04/14/2016	99.990	100.020	100.1	1
KU	C1S	2065083	04/2016	04/14/2016	100.020	100.040	100.0	1
KU	C1S	2065084	04/2016	04/14/2016	99.970	100.060	100.0	1
KU	C1S	2065085	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065086	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065087	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065088	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065089	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065090	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065091	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065092	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2065093	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065094	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065095	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065096	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2065097	04/2016	04/14/2016	99.970	100.050	100.0	1
KU	C1S	2065098	04/2016	04/14/2016	99.950	99.960	100.0	1

1	100.0	100.030	100.000	04/14/2016	04/2016	2065143	CIS	KU
1	100.0	99.980	99.980	04/14/2016	04/2016	2065142	CIS	KU
1	100.1	100.010	99.990	04/14/2016	04/2016	2065141	CIS	KU
1	100.0	99.980	99.960	04/14/2016	04/2016	2065140	CIS	KU
1	100.1	100.010	100.030	04/14/2016	04/2016	2065139	CIS	KU
1	100.0	99.990	99.980	04/14/2016	04/2016	2065138	CIS	KU
1	100.0	100.020	100.010	04/14/2016	04/2016	2065137	CIS	KU
1	100.0	100.000	100.000	04/14/2016	04/2016	2065136	CIS	KU
1	100.0	100.030	100.010	04/14/2016	04/2016	2065135	CIS	KU
1	100.0	99.960	100.000	04/14/2016	04/2016	2065134	CIS	KU
1	100.0	100.010	99.980	04/14/2016	04/2016	2065133	CIS	KU
1	100.0	100.030	100.000	04/14/2016	04/2016	2065132	CIS	KU
1	100.0	100.020	100.020	04/14/2016	04/2016	2065131	CIS	KU
1	100.0	99.960	99.980	04/14/2016	04/2016	2065130	CIS	KU
1	100.0	100.030	100.000	04/14/2016	04/2016	2065129	CIS	KU
1	100.0	99.990	100.010	04/14/2016	04/2016	2065128	CIS	KU
1	100.0	99.990	100.000	04/14/2016	04/2016	2065127	CIS	KU
1	100.1	100.020	100.020	04/14/2016	04/2016	2065126	CIS	KU
1	100.0	99.960	99.990	04/14/2016	04/2016	2065125	CIS	KU
1	100.0	100.010	100.000	04/14/2016	04/2016	2065124	CIS	KU
1	100.0	100.000	100.000	04/14/2016	04/2016	2065123	CIS	KU
1	100.0	99.970	100.000	04/14/2016	04/2016	2065122	CIS	KU
1	100.0	100.010	100.020	04/14/2016	04/2016	2065121	CIS	KU
1	100.0	99.960	100.000	04/14/2016	04/2016	2065120	CIS	KU
1	100.0	100.030	99.990	04/14/2016	04/2016	2065119	CIS	KU
1	100.0	100.020	99.980	04/14/2016	04/2016	2065118	CIS	KU
1	100.0	100.030	99.970	04/14/2016	04/2016	2065117	CIS	KU
1	100.0	99.990	100.000	04/14/2016	04/2016	2065116	CIS	KU
1	100.0	100.000	100.000	04/14/2016	04/2016	2065115	CIS	KU
1	100.0	100.010	100.010	04/14/2016	04/2016	2065114	CIS	KU
1	100.0	100.030	100.020	04/14/2016	04/2016	2065113	CIS	KU
1	100.0	100.030	100.000	04/14/2016	04/2016	2065112	CIS	KU
1	100.0	100.040	99.980	04/14/2016	04/2016	2065111	CIS	KU
1	100.0	99.990	100.020	04/14/2016	04/2016	2065110	CIS	KU
1	100.0	100.030	99.990	04/14/2016	04/2016	2065109	CIS	KU
1	100.0	99.980	99.980	04/14/2016	04/2016	2065108	CIS	KU
1	100.0	100.000	100.010	04/14/2016	04/2016	2065107	CIS	KU
1	100.1	100.030	100.000	04/14/2016	04/2016	2065106	CIS	KU
1	100.0	100.030	99.980	04/14/2016	04/2016	2065105	CIS	KU
1	100.0	99.980	100.000	04/14/2016	04/2016	2065104	CIS	KU
1	100.0	100.000	100.030	04/14/2016	04/2016	2065103	CIS	KU
1	100.0	100.040	100.000	04/14/2016	04/2016	2065102	CIS	KU
1	100.0	99.990	99.960	04/14/2016	04/2016	2065101	CIS	KU
1	100.1	100.080	100.010	04/14/2016	04/2016	2065100	CIS	KU
1	100.0	99.990	99.950	04/14/2016	04/2016	2065099	CIS	KU

KU	C1S	2065144	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065145	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2065146	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065147	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2065148	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065149	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065150	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065151	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065152	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065153	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2065154	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065155	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2065156	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065157	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065158	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2065159	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065160	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065161	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065162	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065163	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2065164	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2065165	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065166	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065167	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2065168	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065169	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2065170	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2065171	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065172	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065173	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065174	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2065175	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065176	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065177	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065178	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065179	04/2016	04/14/2016	100.040	100.030	100.0	1
KU	C1S	2065180	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065181	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065182	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065183	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065184	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2065185	04/2016	04/14/2016	99.970	99.970	100.0	1
KU	C1S	2065186	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065187	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065188	04/2016	04/14/2016	99.970	99.980	100.0	1

KU	C1S	2065189	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065190	04/2016	04/14/2016	100.030	100.010	100.1	1
KU	C1S	2065191	04/2016	04/14/2016	100.030	100.010	100.1	1
KU	C1S	2065192	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065193	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065194	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065195	04/2016	04/14/2016	100.030	100.040	100.1	1
KU	C1S	2065196	04/2016	04/14/2016	100.020	99.960	100.0	1
KU	C1S	2065197	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2065198	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2065199	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065200	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2065201	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2065202	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065203	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065204	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2065205	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2065206	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2065207	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065208	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065209	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065210	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2065211	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065212	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065213	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065214	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065215	04/2016	04/14/2016	100.020	100.000	100.1	1
KU	C1S	2065216	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2065217	04/2016	04/14/2016	99.960	99.950	100.0	1
KU	C1S	2065218	04/2016	04/14/2016	100.060	99.990	100.1	1
KU	C1S	2065219	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065220	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065221	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2065222	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065223	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065224	04/2016	04/14/2016	100.050	100.010	100.0	1
KU	C1S	2065225	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065226	04/2016	04/14/2016	99.990	99.940	100.0	1
KU	C1S	2065227	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065228	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065229	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065230	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2065231	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065232	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065233	04/2016	04/14/2016	99.980	100.000	100.0	1

KU	C1S	2065234	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065235	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065236	04/2016	04/14/2016	100.040	100.000	100.0	1
KU	C1S	2065237	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2065238	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065239	04/2016	04/14/2016	99.990	100.080	100.1	1
KU	C1S	2065240	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065241	04/2016	04/14/2016	100.050	100.000	100.0	1
KU	C1S	2065242	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2065243	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2065244	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065245	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065246	04/2016	04/14/2016	99.970	100.050	100.0	1
KU	C1S	2065247	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065248	04/2016	04/14/2016	99.980	99.980	100.0	1
KU	C1S	2065249	04/2016	04/14/2016	99.990	99.940	100.0	1
KU	C1S	2065250	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065251	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065252	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065253	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065254	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065255	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065256	04/2016	04/14/2016	100.040	99.940	100.0	1
KU	C1S	2065257	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2065258	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065259	04/2016	04/14/2016	99.950	100.020	100.0	1
KU	C1S	2065260	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065261	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065262	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065263	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065264	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2065265	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065266	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065267	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065268	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065269	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2065270	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065271	04/2016	04/14/2016	100.040	99.980	100.0	1
KU	C1S	2065272	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2065273	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065274	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065275	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065276	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065277	04/2016	04/14/2016	100.050	100.000	100.0	1
KU	C1S	2065278	04/2016	04/14/2016	100.000	99.990	100.0	1

KU	C1S	2065279	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065280	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2065281	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065282	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065283	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065284	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065285	04/2016	04/14/2016	100.020	100.060	100.0	1
KU	C1S	2065286	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2065287	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065288	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065289	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065290	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2065291	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065292	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065293	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065294	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065295	04/2016	04/14/2016	100.070	99.990	100.0	1
KU	C1S	2065296	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065297	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065298	04/2016	04/14/2016	100.000	100.050	100.1	1
KU	C1S	2065299	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065300	04/2016	04/14/2016	99.980	100.050	100.0	1
KU	C1S	2065301	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065302	04/2016	04/14/2016	99.960	100.000	100.0	1
KU	C1S	2065303	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065304	04/2016	04/14/2016	99.940	100.030	100.0	1
KU	C1S	2065305	04/2016	04/14/2016	99.960	99.990	100.0	1
KU	C1S	2065306	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065307	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065308	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065309	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065310	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065311	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065312	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065313	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2065314	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2065315	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065316	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065317	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065318	04/2016	04/14/2016	100.000	100.050	100.0	1
KU	C1S	2065319	04/2016	04/14/2016	100.030	100.050	100.1	1
KU	C1S	2065320	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065321	04/2016	04/14/2016	100.020	100.020	100.1	1
KU	C1S	2065322	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065323	04/2016	04/14/2016	100.010	100.010	100.0	1

KU	C1S	2065324	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065325	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065326	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065327	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065328	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065329	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065330	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065331	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2065332	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065333	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2065334	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065335	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065336	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065337	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065338	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065339	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065340	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2065341	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065342	04/2016	04/14/2016	100.020	100.060	100.1	1
KU	C1S	2065343	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065344	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065345	04/2016	04/14/2016	100.030	100.050	100.0	1
KU	C1S	2065346	04/2016	04/14/2016	100.020	99.980	100.0	1
KU	C1S	2065347	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2065348	04/2016	04/14/2016	100.020	100.050	100.0	1
KU	C1S	2065349	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065350	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065351	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065352	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2065353	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065354	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2065355	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065356	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065357	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065358	04/2016	04/14/2016	99.970	100.060	100.1	1
KU	C1S	2065359	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065360	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065361	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065362	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065363	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065364	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065365	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065366	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065367	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065368	04/2016	04/14/2016	100.020	99.990	100.0	1

KU	C1S	2065369	04/2016	04/14/2016	99.960	100.030	100.0	1
KU	C1S	2065370	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2065371	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065372	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065373	04/2016	04/14/2016	99.970	100.040	100.0	1
KU	C1S	2065374	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065375	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065376	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065377	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065378	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065379	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065380	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065381	04/2016	04/14/2016	99.950	100.000	100.0	1
KU	C1S	2065382	04/2016	04/14/2016	100.040	100.000	100.0	1
KU	C1S	2065383	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065384	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065385	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065386	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2065387	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065388	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065389	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065390	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065391	04/2016	04/14/2016	99.990	100.050	100.1	1
KU	C1S	2065392	04/2016	04/14/2016	99.990	99.950	100.0	1
KU	C1S	2065393	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065394	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065395	04/2016	04/14/2016	100.010	100.020	100.1	1
KU	C1S	2065396	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2065397	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065398	04/2016	04/14/2016	100.030	100.030	100.1	1
KU	C1S	2065399	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065400	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065401	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065402	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065403	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065404	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065405	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065406	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065407	04/2016	04/14/2016	100.000	100.040	100.0	1
KU	C1S	2065408	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065409	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065410	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065411	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065412	04/2016	04/14/2016	99.970	100.050	100.0	1
KU	C1S	2065413	04/2016	04/14/2016	100.000	99.980	100.0	1

KU	C1S	2065414	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065415	04/2016	04/14/2016	100.050	99.980	100.0	1
KU	C1S	2065416	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2065417	04/2016	04/14/2016	100.000	100.000	100.1	1
KU	C1S	2065418	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065419	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065420	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065421	04/2016	04/14/2016	99.970	99.980	100.0	1
KU	C1S	2065422	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065423	04/2016	04/14/2016	99.950	100.010	100.0	1
KU	C1S	2065424	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065425	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065426	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065427	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065428	04/2016	04/14/2016	100.030	99.990	100.0	1
KU	C1S	2065429	04/2016	04/14/2016	100.000	99.970	100.1	1
KU	C1S	2065430	04/2016	04/14/2016	100.030	100.040	100.1	1
KU	C1S	2065431	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065432	04/2016	04/14/2016	100.040	100.020	100.0	1
KU	C1S	2065433	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065434	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065435	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065436	04/2016	04/14/2016	99.950	99.990	100.0	1
KU	C1S	2065437	04/2016	04/14/2016	100.010	100.050	100.1	1
KU	C1S	2065438	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065439	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065440	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065441	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065442	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065443	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065444	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065445	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2065446	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065447	04/2016	04/14/2016	99.950	100.010	100.0	1
KU	C1S	2065448	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065449	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065450	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2065451	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065452	04/2016	04/14/2016	99.970	99.960	100.0	1
KU	C1S	2065453	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065454	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065455	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065456	04/2016	04/14/2016	99.950	100.050	100.0	1
KU	C1S	2065457	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2065458	04/2016	04/14/2016	100.020	100.000	100.0	1

KU	C1S	2065459	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2065460	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2065461	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065462	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065463	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065464	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065465	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065466	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065467	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065468	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065469	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065470	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065471	04/2016	04/14/2016	100.020	100.050	100.0	1
KU	C1S	2065472	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2065473	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065474	04/2016	04/14/2016	100.020	99.950	100.0	1
KU	C1S	2065475	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065476	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065477	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065478	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065479	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065480	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065481	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065482	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065483	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2065484	04/2016	04/14/2016	100.020	100.060	100.1	1
KU	C1S	2065485	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065486	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065487	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065488	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065489	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065490	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065491	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065492	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2065493	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065494	04/2016	04/14/2016	100.020	100.050	100.1	1
KU	C1S	2065495	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065496	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065497	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065498	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065499	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065500	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065501	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065502	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065503	04/2016	04/14/2016	99.950	100.040	100.0	1

KU	C1S	2065504	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065505	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065506	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2065507	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065508	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065509	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065510	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065511	04/2016	04/14/2016	99.980	99.960	100.0	1
KU	C1S	2065512	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065513	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065514	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2065515	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065516	04/2016	04/14/2016	99.980	100.030	100.1	1
KU	C1S	2065517	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065518	04/2016	04/14/2016	100.000	100.020	100.1	1
KU	C1S	2065519	04/2016	04/14/2016	100.030	100.040	100.0	1
KU	C1S	2065520	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065521	04/2016	04/14/2016	99.960	99.990	100.0	1
KU	C1S	2065522	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065523	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065524	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2065525	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065526	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2065527	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065528	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065529	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065530	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065531	04/2016	04/14/2016	99.960	100.040	100.0	1
KU	C1S	2065532	04/2016	04/14/2016	99.990	100.010	100.1	1
KU	C1S	2065533	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065534	04/2016	04/14/2016	99.960	100.050	100.1	1
KU	C1S	2065535	04/2016	04/14/2016	99.990	99.950	100.0	1
KU	C1S	2065536	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065537	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2065538	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065539	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065540	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065541	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065542	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2065543	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065544	04/2016	04/14/2016	100.050	99.980	100.0	1
KU	C1S	2065545	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2065546	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2065547	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065548	04/2016	04/14/2016	100.020	99.990	100.0	1

KU	C1S	2065549	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065550	04/2016	04/14/2016	100.000	100.060	100.1	1
KU	C1S	2065551	04/2016	04/14/2016	100.020	99.960	100.1	1
KU	C1S	2065552	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065553	04/2016	04/14/2016	99.970	100.030	100.0	1
KU	C1S	2065554	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2065555	04/2016	04/14/2016	99.950	100.030	100.1	1
KU	C1S	2065556	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065557	04/2016	04/14/2016	100.030	99.980	100.0	1
KU	C1S	2065558	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065559	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065560	04/2016	04/14/2016	99.990	100.060	100.1	1
KU	C1S	2065561	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2065562	04/2016	04/14/2016	100.010	100.020	100.1	1
KU	C1S	2065563	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065564	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065565	04/2016	04/14/2016	99.980	100.020	100.1	1
KU	C1S	2065566	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065567	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065568	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065569	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065570	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2065571	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065572	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065573	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065574	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065575	04/2016	04/14/2016	100.010	100.010	100.1	1
KU	C1S	2065576	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065577	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2065578	04/2016	04/14/2016	100.010	100.020	100.1	1
KU	C1S	2065579	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065580	04/2016	04/14/2016	99.990	100.020	100.1	1
KU	C1S	2065581	04/2016	04/14/2016	100.020	100.060	100.1	1
KU	C1S	2065582	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065583	04/2016	04/14/2016	99.980	99.990	100.1	1
KU	C1S	2065584	04/2016	04/14/2016	100.000	100.040	100.1	1
KU	C1S	2065585	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2065586	04/2016	04/14/2016	100.000	100.010	100.1	1
KU	C1S	2065587	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065588	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2065589	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065590	04/2016	04/14/2016	100.040	99.990	100.0	1
KU	C1S	2065591	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065592	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065593	04/2016	04/14/2016	100.010	100.000	100.1	1

KU	C1S	2065594	04/2016	04/14/2016	99.960	99.980	100.0	1
KU	C1S	2065595	04/2016	04/14/2016	100.000	100.000	100.1	1
KU	C1S	2065596	04/2016	04/14/2016	100.030	100.030	100.0	1
KU	C1S	2065597	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2065598	04/2016	04/14/2016	100.000	99.990	100.0	1
KU	C1S	2065599	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065600	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065601	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065602	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065603	04/2016	04/14/2016	100.030	99.970	100.0	1
KU	C1S	2065604	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065605	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065606	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065607	04/2016	04/14/2016	100.010	100.040	100.1	1
KU	C1S	2065608	04/2016	04/14/2016	100.000	100.020	100.0	1
KU	C1S	2065609	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2065610	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065611	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065612	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065613	04/2016	04/14/2016	100.030	100.010	100.0	1
KU	C1S	2065614	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065615	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065616	04/2016	04/14/2016	99.980	100.020	100.0	1
KU	C1S	2065617	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065618	04/2016	04/14/2016	99.990	100.000	100.1	1
KU	C1S	2065619	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065620	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065621	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065622	04/2016	04/14/2016	99.980	100.030	100.1	1
KU	C1S	2065623	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065624	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065625	04/2016	04/14/2016	99.990	100.040	100.1	1
KU	C1S	2065626	04/2016	04/14/2016	99.980	100.010	100.1	1
KU	C1S	2065627	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2065628	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065629	04/2016	04/14/2016	99.990	100.050	100.0	1
KU	C1S	2065630	04/2016	04/14/2016	99.960	100.020	100.0	1
KU	C1S	2065631	04/2016	04/14/2016	100.010	100.060	100.1	1
KU	C1S	2065632	04/2016	04/14/2016	99.980	100.040	100.0	1
KU	C1S	2065633	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065634	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065635	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065636	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065637	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065638	04/2016	04/14/2016	99.980	100.000	100.0	1

KU	C1S	2065639	04/2016	04/14/2016	100.020	99.970	100.0	1
KU	C1S	2065640	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065641	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065642	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065643	04/2016	04/14/2016	99.980	99.970	100.0	1
KU	C1S	2065644	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065645	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2065646	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065647	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065648	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065649	04/2016	04/14/2016	99.960	99.970	100.0	1
KU	C1S	2065650	04/2016	04/14/2016	100.010	100.030	100.0	1
KU	C1S	2065651	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065652	04/2016	04/14/2016	99.990	100.050	100.1	1
KU	C1S	2065653	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065654	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065655	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065656	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065657	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065658	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065659	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065660	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2065661	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065662	04/2016	04/14/2016	100.020	100.020	100.0	1
KU	C1S	2065663	04/2016	04/14/2016	99.980	100.050	100.1	1
KU	C1S	2065664	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065665	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2065666	04/2016	04/14/2016	99.980	100.010	100.0	1
KU	C1S	2065667	04/2016	04/14/2016	99.990	100.020	100.0	1
KU	C1S	2065668	04/2016	04/14/2016	99.960	100.020	100.0	1
KU	C1S	2065669	04/2016	04/14/2016	100.000	100.030	100.1	1
KU	C1S	2065670	04/2016	04/14/2016	100.010	100.020	100.0	1
KU	C1S	2065671	04/2016	04/14/2016	99.980	99.950	100.0	1
KU	C1S	2065672	04/2016	04/14/2016	100.020	100.010	100.1	1
KU	C1S	2065673	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065674	04/2016	04/14/2016	100.000	99.950	100.0	1
KU	C1S	2065675	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2065676	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065677	04/2016	04/14/2016	100.030	100.020	100.0	1
KU	C1S	2065678	04/2016	04/14/2016	100.000	99.960	100.0	1
KU	C1S	2065679	04/2016	04/14/2016	99.970	99.970	100.0	1
KU	C1S	2065680	04/2016	04/14/2016	100.000	100.020	100.1	1
KU	C1S	2065681	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065682	04/2016	04/14/2016	99.970	100.010	100.0	1
KU	C1S	2065683	04/2016	04/14/2016	99.980	99.960	100.0	1

KU	C1S	2065684	04/2016	04/14/2016	100.050	99.990	100.0	1
KU	C1S	2065685	04/2016	04/14/2016	100.020	100.000	100.0	1
KU	C1S	2065686	04/2016	04/14/2016	100.000	99.980	100.0	1
KU	C1S	2065687	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065688	04/2016	04/14/2016	100.010	100.050	100.0	1
KU	C1S	2065689	04/2016	04/14/2016	100.010	100.000	100.0	1
KU	C1S	2065690	04/2016	04/14/2016	100.000	99.970	100.0	1
KU	C1S	2065691	04/2016	04/14/2016	100.020	100.040	100.1	1
KU	C1S	2065692	04/2016	04/14/2016	99.990	99.990	100.0	1
KU	C1S	2065693	04/2016	04/14/2016	100.020	100.030	100.0	1
KU	C1S	2065694	04/2016	04/14/2016	100.020	100.010	100.0	1
KU	C1S	2065695	04/2016	04/14/2016	99.990	100.040	100.0	1
KU	C1S	2065696	04/2016	04/14/2016	100.010	99.970	100.0	1
KU	C1S	2065697	04/2016	04/14/2016	100.000	100.000	100.0	1
KU	C1S	2065698	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2065699	04/2016	04/14/2016	100.030	100.010	100.1	1
KU	C1S	2065700	04/2016	04/14/2016	100.030	100.000	100.0	1
KU	C1S	2065701	04/2016	04/14/2016	100.050	100.030	100.0	1
KU	C1S	2065702	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065703	04/2016	04/14/2016	99.970	99.980	100.0	1
KU	C1S	2065704	04/2016	04/14/2016	99.970	100.020	100.0	1
KU	C1S	2065705	04/2016	04/14/2016	99.990	100.030	100.1	1
KU	C1S	2065706	04/2016	04/14/2016	99.980	100.040	100.1	1
KU	C1S	2065707	04/2016	04/14/2016	100.010	99.990	100.1	1
KU	C1S	2065708	04/2016	04/14/2016	99.980	99.990	100.0	1
KU	C1S	2065709	04/2016	04/14/2016	99.990	100.030	100.0	1
KU	C1S	2065710	04/2016	04/14/2016	99.980	100.030	100.0	1
KU	C1S	2065711	04/2016	04/14/2016	99.990	99.980	100.0	1
KU	C1S	2065712	04/2016	04/14/2016	99.970	100.040	100.0	1
KU	C1S	2065713	04/2016	04/14/2016	100.020	99.990	100.0	1
KU	C1S	2065714	04/2016	04/14/2016	100.010	100.010	100.0	1
KU	C1S	2065715	04/2016	04/14/2016	99.990	100.000	100.0	1
KU	C1S	2065716	04/2016	04/14/2016	99.970	99.990	100.0	1
KU	C1S	2065717	04/2016	04/14/2016	99.980	100.080	100.1	1
KU	C1S	2065718	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065719	04/2016	04/14/2016	99.970	100.000	100.0	1
KU	C1S	2065720	04/2016	04/14/2016	99.970	100.050	100.0	1
KU	C1S	2065721	04/2016	04/14/2016	99.980	100.000	100.0	1
KU	C1S	2065722	04/2016	04/14/2016	99.990	99.970	100.0	1
KU	C1S	2065723	04/2016	04/14/2016	99.990	100.080	100.1	1
KU	C1S	2065724	04/2016	04/14/2016	100.040	100.040	100.1	1
KU	C1S	2065725	04/2016	04/14/2016	100.040	100.010	100.0	1
KU	C1S	2065726	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065727	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065728	04/2016	04/14/2016	100.050	100.010	100.0	1

KU	C1S	2065729	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065730	04/2016	04/14/2016	100.000	100.030	100.0	1
KU	C1S	2065731	04/2016	04/14/2016	100.010	100.040	100.0	1
KU	C1S	2065732	04/2016	04/14/2016	99.990	99.960	100.0	1
KU	C1S	2065733	04/2016	04/14/2016	100.010	99.980	100.0	1
KU	C1S	2065734	04/2016	04/14/2016	100.000	100.070	100.1	1
KU	C1S	2065735	04/2016	04/14/2016	100.000	100.010	100.0	1
KU	C1S	2065736	04/2016	04/14/2016	100.000	100.060	100.0	1
KU	C1S	2065737	04/2016	04/14/2016	100.010	99.990	100.0	1
KU	C1S	2065738	04/2016	04/14/2016	100.010	100.030	100.1	1
KU	C1S	2065739	04/2016	04/14/2016	99.990	100.010	100.0	1
KU	C1S	2065860	05/2016	05/10/2016	100.010	99.990	100.1	1
KU	C1S	2065861	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2065862	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2065863	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2065864	05/2016	05/10/2016	100.020	99.990	100.1	1
KU	C1S	2065865	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2065866	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2065867	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2065868	05/2016	05/10/2016	100.040	99.990	100.0	1
KU	C1S	2065869	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2065870	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065871	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2065872	05/2016	05/10/2016	99.970	100.000	100.1	1
KU	C1S	2065873	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2065874	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2065875	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2065876	05/2016	05/10/2016	100.050	99.990	100.0	1
KU	C1S	2065877	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2065878	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2065879	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2065880	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2065881	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2065882	05/2016	05/10/2016	99.980	100.070	100.1	1
KU	C1S	2065883	05/2016	05/10/2016	100.040	100.040	100.1	1
KU	C1S	2065884	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2065885	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2065886	05/2016	05/10/2016	100.050	99.980	100.0	1
KU	C1S	2065887	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2065888	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2065889	05/2016	05/10/2016	99.970	100.050	100.1	1
KU	C1S	2065890	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2065891	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2065892	05/2016	05/10/2016	99.960	99.950	100.0	1
KU	C1S	2065893	05/2016	05/10/2016	100.010	99.980	100.0	1

KU	C1S	2065894	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2065895	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2065896	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065897	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2065898	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2065899	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2065900	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2065901	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2065902	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2065903	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2065904	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2065905	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2065906	05/2016	05/10/2016	99.970	100.050	100.0	1
KU	C1S	2065907	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2065908	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2065909	05/2016	05/10/2016	99.990	99.950	100.0	1
KU	C1S	2065910	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2065911	05/2016	05/10/2016	100.030	99.960	100.0	1
KU	C1S	2065912	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2065913	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2065914	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065915	05/2016	05/10/2016	99.980	99.930	100.0	1
KU	C1S	2065916	05/2016	05/10/2016	99.960	99.980	100.0	1
KU	C1S	2065917	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2065918	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2065919	05/2016	05/10/2016	99.960	99.990	100.1	1
KU	C1S	2065920	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2065921	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2065922	05/2016	05/10/2016	99.980	99.950	99.9	1
KU	C1S	2065923	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2065924	05/2016	05/10/2016	100.030	99.980	100.1	1
KU	C1S	2065925	05/2016	05/10/2016	99.970	99.940	100.0	1
KU	C1S	2065926	05/2016	05/10/2016	99.990	99.940	100.0	1
KU	C1S	2065927	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2065928	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2065929	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065930	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2065931	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2065932	05/2016	05/10/2016	99.990	99.950	100.0	1
KU	C1S	2065933	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2065934	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2065935	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065936	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2065937	05/2016	05/10/2016	99.980	99.950	100.0	1
KU	C1S	2065938	05/2016	05/10/2016	100.020	100.030	100.0	1

KU	C1S	2065939	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2065940	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2065941	05/2016	05/10/2016	99.940	99.940	100.0	1
KU	C1S	2065942	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2065943	05/2016	05/10/2016	100.000	100.060	100.0	1
KU	C1S	2065944	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2065945	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2065946	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2065947	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2065948	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2065949	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2065950	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2065951	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2065952	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2065953	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2065954	05/2016	05/10/2016	99.950	100.030	100.0	1
KU	C1S	2065955	05/2016	05/10/2016	99.970	100.040	100.1	1
KU	C1S	2065956	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2065957	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2065958	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2065959	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2065960	05/2016	05/10/2016	100.000	100.070	100.1	1
KU	C1S	2065961	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2065962	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2065963	05/2016	05/10/2016	99.980	99.920	100.0	1
KU	C1S	2065964	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2065965	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2065966	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2065967	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2065968	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2065969	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2065970	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2065971	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2065972	05/2016	05/10/2016	99.990	99.960	100.1	1
KU	C1S	2065973	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2065974	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2065975	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2065976	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2065977	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2065978	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2065979	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2065980	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2065981	05/2016	05/10/2016	100.060	99.980	100.0	1
KU	C1S	2065982	05/2016	05/10/2016	100.040	99.960	100.0	1
KU	C1S	2065983	05/2016	05/10/2016	99.990	99.950	100.0	1

KU	C1S	2065984	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2065985	05/2016	05/10/2016	99.990	99.930	100.0	1
KU	C1S	2065986	05/2016	05/10/2016	100.040	100.020	100.1	1
KU	C1S	2065987	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2065988	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2065989	05/2016	05/10/2016	99.970	100.020	100.1	1
KU	C1S	2065990	05/2016	05/10/2016	100.050	99.980	100.0	1
KU	C1S	2065991	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2065992	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2065993	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2065994	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2065995	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2065996	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2065997	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2065998	05/2016	05/10/2016	99.960	100.020	100.1	1
KU	C1S	2065999	05/2016	05/10/2016	100.010	99.940	100.0	1
KU	C1S	2066000	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066001	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066002	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066003	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066004	05/2016	05/10/2016	99.990	99.980	100.1	1
KU	C1S	2066005	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2066006	05/2016	05/10/2016	100.040	100.050	100.1	1
KU	C1S	2066007	05/2016	05/10/2016	99.950	100.010	100.1	1
KU	C1S	2066008	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066009	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066010	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066011	05/2016	05/10/2016	100.030	100.010	100.1	1
KU	C1S	2066012	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2066013	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066014	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066015	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2066016	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2066017	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2066018	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066019	05/2016	05/10/2016	100.000	99.950	100.0	1
KU	C1S	2066020	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066021	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066022	05/2016	05/10/2016	99.980	99.990	100.1	1
KU	C1S	2066023	05/2016	05/10/2016	99.970	100.000	100.1	1
KU	C1S	2066024	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066025	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066026	05/2016	05/10/2016	100.040	99.930	100.0	1
KU	C1S	2066027	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066028	05/2016	05/10/2016	100.020	99.930	100.0	1

KU	C1S	2066029	05/2016	05/10/2016	100.000	100.000	100.1	1
KU	C1S	2066030	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066031	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066032	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2066033	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066034	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066035	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066036	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066037	05/2016	05/10/2016	100.000	99.950	100.0	1
KU	C1S	2066038	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066039	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066040	05/2016	05/10/2016	99.980	99.950	100.0	1
KU	C1S	2066041	05/2016	05/10/2016	99.970	100.040	100.1	1
KU	C1S	2066042	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066043	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066044	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066045	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066046	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066047	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2066048	05/2016	05/10/2016	100.050	100.040	100.1	1
KU	C1S	2066049	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066050	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066051	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066052	05/2016	05/10/2016	99.960	99.980	100.0	1
KU	C1S	2066053	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2066054	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066055	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066056	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2066057	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066058	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066059	05/2016	05/10/2016	100.000	100.000	100.1	1
KU	C1S	2066060	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2066061	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066062	05/2016	05/10/2016	100.030	100.000	100.1	1
KU	C1S	2066063	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2066064	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066065	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066066	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066067	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066068	05/2016	05/10/2016	99.960	99.990	100.0	1
KU	C1S	2066069	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066070	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066071	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066072	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066073	05/2016	05/10/2016	100.010	99.990	100.0	1

KU	C1S	2066074	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066075	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066076	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2066077	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066078	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2066079	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066080	05/2016	05/10/2016	99.970	100.010	100.1	1
KU	C1S	2066081	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066082	05/2016	05/10/2016	100.030	100.070	100.1	1
KU	C1S	2066083	05/2016	05/10/2016	99.980	100.050	100.0	1
KU	C1S	2066084	05/2016	05/10/2016	99.980	99.970	100.1	1
KU	C1S	2066085	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066086	05/2016	05/10/2016	100.030	99.950	100.0	1
KU	C1S	2066087	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066088	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066089	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066090	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2066091	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066092	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066093	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2066094	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066095	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066096	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066097	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066098	05/2016	05/10/2016	99.990	100.080	100.1	1
KU	C1S	2066099	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066100	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2066101	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066102	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066103	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066104	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066105	05/2016	05/10/2016	99.980	100.060	100.0	1
KU	C1S	2066106	05/2016	05/10/2016	100.010	99.990	100.1	1
KU	C1S	2066107	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066108	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066109	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066110	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2066111	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2066112	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066113	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2066114	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066115	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066116	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066117	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066118	05/2016	05/10/2016	99.990	99.970	100.0	1

KU	C1S	2066119	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066120	05/2016	05/10/2016	100.000	99.930	100.0	1
KU	C1S	2066121	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066122	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066123	05/2016	05/10/2016	99.960	99.980	100.0	1
KU	C1S	2066124	05/2016	05/10/2016	99.990	100.070	100.1	1
KU	C1S	2066125	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066126	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2066127	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066128	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066129	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066130	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066131	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2066132	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066133	05/2016	05/10/2016	100.050	100.030	100.1	1
KU	C1S	2066134	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066135	05/2016	05/10/2016	99.990	100.070	100.1	1
KU	C1S	2066136	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066137	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2066138	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066139	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2066140	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066141	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2066142	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2066143	05/2016	05/10/2016	100.000	99.940	100.0	1
KU	C1S	2066144	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066145	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066146	05/2016	05/10/2016	99.980	100.060	100.1	1
KU	C1S	2066147	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066148	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066149	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066150	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066151	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2066152	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066153	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066154	05/2016	05/10/2016	100.050	100.040	100.0	1
KU	C1S	2066155	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2066156	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066157	05/2016	05/10/2016	100.040	100.050	100.0	1
KU	C1S	2066158	05/2016	05/10/2016	100.030	100.070	100.1	1
KU	C1S	2066159	05/2016	05/10/2016	99.980	100.060	100.1	1
KU	C1S	2066160	05/2016	05/10/2016	99.980	100.040	100.0	1
KU	C1S	2066161	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066162	05/2016	05/10/2016	100.020	100.060	100.0	1
KU	C1S	2066163	05/2016	05/10/2016	99.970	100.000	100.0	1

KU	C1S	2066164	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066165	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2066166	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066167	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066168	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2066169	05/2016	05/10/2016	99.960	100.020	100.1	1
KU	C1S	2066170	05/2016	05/10/2016	99.960	100.040	100.0	1
KU	C1S	2066171	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066172	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066173	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066174	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066175	05/2016	05/10/2016	100.000	100.060	100.1	1
KU	C1S	2066176	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2066177	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066178	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066179	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066180	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066181	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2066182	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2066183	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066184	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2066185	05/2016	05/10/2016	99.990	100.080	100.1	1
KU	C1S	2066186	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2066187	05/2016	05/10/2016	100.030	100.050	100.1	1
KU	C1S	2066188	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066189	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066190	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2066191	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066192	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066193	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066194	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066195	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066196	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066197	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2066198	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066199	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066200	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066201	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066202	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2066203	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2066204	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066205	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066206	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066207	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066208	05/2016	05/10/2016	99.970	100.010	100.1	1

KU	C1S	2066209	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066210	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066211	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066212	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066213	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066214	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2066215	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066216	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066217	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066218	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066219	05/2016	05/10/2016	100.030	99.990	100.0	1
KU	C1S	2066220	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066221	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066222	05/2016	05/10/2016	100.010	100.080	100.0	1
KU	C1S	2066223	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2066224	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066225	05/2016	05/10/2016	99.980	100.040	100.0	1
KU	C1S	2066226	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2066227	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066228	05/2016	05/10/2016	99.960	100.040	100.0	1
KU	C1S	2066229	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066230	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066231	05/2016	05/10/2016	99.970	100.050	100.1	1
KU	C1S	2066232	05/2016	05/10/2016	99.980	100.040	100.0	1
KU	C1S	2066233	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066234	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066235	05/2016	05/10/2016	99.960	100.020	100.1	1
KU	C1S	2066236	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066237	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066238	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066239	05/2016	05/10/2016	100.040	100.050	100.1	1
KU	C1S	2066240	05/2016	05/10/2016	100.030	100.050	100.0	1
KU	C1S	2066241	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066242	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2066243	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066244	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066245	05/2016	05/10/2016	100.000	100.070	100.1	1
KU	C1S	2066246	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2066247	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066248	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066249	05/2016	05/10/2016	100.010	100.060	100.0	1
KU	C1S	2066250	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066251	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066252	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066253	05/2016	05/10/2016	100.030	100.020	100.0	1

KU	C1S	2066254	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066255	05/2016	05/10/2016	99.980	100.060	100.1	1
KU	C1S	2066256	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066257	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066258	05/2016	05/10/2016	100.040	100.000	100.0	1
KU	C1S	2066259	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066260	05/2016	05/10/2016	100.040	100.020	100.0	1
KU	C1S	2066261	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066262	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066263	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066264	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066265	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066266	05/2016	05/10/2016	100.040	100.090	100.1	1
KU	C1S	2066267	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066268	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066269	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066270	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066271	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2066272	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066273	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066274	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066275	05/2016	05/10/2016	99.960	100.050	100.0	1
KU	C1S	2066276	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2066277	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066278	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066279	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066280	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066281	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2066282	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066283	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066284	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066285	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066286	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066287	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2066288	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066289	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066290	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066291	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066292	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066293	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2066294	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066295	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066296	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066297	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066298	05/2016	05/10/2016	100.010	100.030	100.1	1

KU	C1S	2066299	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066300	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066301	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066302	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066303	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066304	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066305	05/2016	05/10/2016	100.010	100.090	100.1	1
KU	C1S	2066306	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066307	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066308	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066309	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066310	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066311	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2066312	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066313	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2066314	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066315	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066316	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066317	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066318	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066319	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066320	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066321	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066322	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066323	05/2016	05/10/2016	100.010	99.990	100.1	1
KU	C1S	2066324	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066325	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066326	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066327	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066328	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066329	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066330	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2066331	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066332	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066333	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2066334	05/2016	05/10/2016	99.990	100.090	100.1	1
KU	C1S	2066335	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066336	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066337	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066338	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066339	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066340	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2066341	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2066342	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066343	05/2016	05/10/2016	100.000	99.950	100.0	1

KU	C1S	2066344	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066345	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066346	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066347	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066348	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066349	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2066350	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066351	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066352	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066353	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2066354	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2066355	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066356	05/2016	05/10/2016	100.020	99.990	100.1	1
KU	C1S	2066357	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066358	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2066359	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066360	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2066361	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066362	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2066363	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2066364	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066365	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066366	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066367	05/2016	05/10/2016	100.040	100.060	100.1	1
KU	C1S	2066368	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066369	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2066370	05/2016	05/10/2016	99.950	100.050	100.1	1
KU	C1S	2066371	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2066372	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066373	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066374	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066375	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066376	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066377	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066378	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066379	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066380	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2066381	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066382	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066383	05/2016	05/10/2016	100.040	99.980	100.0	1
KU	C1S	2066384	05/2016	05/10/2016	99.970	100.050	100.0	1
KU	C1S	2066385	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066386	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066387	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2066388	05/2016	05/10/2016	99.990	100.020	100.1	1

KU	C1S	2066389	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066390	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066391	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066392	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066393	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2066394	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066395	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066396	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066397	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066398	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066399	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066400	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066401	05/2016	05/10/2016	100.050	99.980	100.0	1
KU	C1S	2066402	05/2016	05/10/2016	100.010	100.080	100.1	1
KU	C1S	2066403	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066404	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066405	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066406	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066407	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066408	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066409	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066410	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066411	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066412	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066413	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066414	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066415	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066416	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066417	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066418	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066419	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066420	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066421	05/2016	05/10/2016	99.980	100.040	100.0	1
KU	C1S	2066422	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2066423	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066424	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066425	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066426	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066427	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066428	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066429	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066430	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2066431	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066432	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066433	05/2016	05/10/2016	99.970	100.020	100.0	1

KU	C1S	2066434	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066435	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066436	05/2016	05/10/2016	99.970	99.960	100.0	1
KU	C1S	2066437	05/2016	05/10/2016	99.980	99.990	100.1	1
KU	C1S	2066438	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066439	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066440	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066441	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066442	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2066443	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066444	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066445	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066446	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066447	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066448	05/2016	05/10/2016	99.960	99.980	100.0	1
KU	C1S	2066449	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066450	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2066451	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066452	05/2016	05/10/2016	100.030	99.990	100.1	1
KU	C1S	2066453	05/2016	05/10/2016	99.980	100.010	99.9	1
KU	C1S	2066454	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066455	05/2016	05/10/2016	99.960	100.030	100.0	1
KU	C1S	2066456	05/2016	05/10/2016	100.030	99.960	100.0	1
KU	C1S	2066457	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066458	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066459	05/2016	05/10/2016	100.020	99.950	100.0	1
KU	C1S	2066460	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066461	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066462	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066463	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2066464	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066465	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066466	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066467	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066468	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066469	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066470	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2066471	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066472	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066473	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066474	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066475	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066476	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066477	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066478	05/2016	05/10/2016	100.000	100.010	100.1	1

KU	C1S	2066479	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066480	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066481	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2066482	05/2016	05/10/2016	100.010	99.930	100.0	1
KU	C1S	2066483	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066484	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066485	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066486	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066487	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066488	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066489	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066490	05/2016	05/10/2016	99.970	99.940	100.0	1
KU	C1S	2066491	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066492	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066493	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066494	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2066495	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2066496	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066497	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066498	05/2016	05/10/2016	100.030	99.990	100.0	1
KU	C1S	2066499	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066500	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066501	05/2016	05/10/2016	100.030	99.980	100.0	1
KU	C1S	2066502	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066503	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066504	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066505	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066506	05/2016	05/10/2016	100.000	99.950	99.9	1
KU	C1S	2066507	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066508	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066509	05/2016	05/10/2016	100.030	99.960	100.0	1
KU	C1S	2066510	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066511	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2066512	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066513	05/2016	05/10/2016	100.050	100.030	100.0	1
KU	C1S	2066514	05/2016	05/10/2016	100.030	99.950	100.0	1
KU	C1S	2066515	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2066516	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066517	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066518	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066519	05/2016	05/10/2016	100.020	99.980	99.9	1
KU	C1S	2066520	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066521	05/2016	05/10/2016	100.050	100.020	100.0	1
KU	C1S	2066522	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066523	05/2016	05/10/2016	99.980	99.980	100.0	1

KU	C1S	2066524	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066525	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2066526	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066527	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066528	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066529	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066530	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066531	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2066532	05/2016	05/10/2016	100.030	100.040	100.1	1
KU	C1S	2066533	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066534	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2066535	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066536	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066537	05/2016	05/10/2016	100.080	99.950	100.0	1
KU	C1S	2066538	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066539	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066540	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066541	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066542	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066543	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066544	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2066545	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066546	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066547	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066548	05/2016	05/10/2016	100.000	100.060	100.0	1
KU	C1S	2066549	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066550	05/2016	05/10/2016	100.030	99.960	100.0	1
KU	C1S	2066551	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066552	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066553	05/2016	05/10/2016	99.960	100.000	100.0	1
KU	C1S	2066554	05/2016	05/10/2016	100.000	100.060	100.0	1
KU	C1S	2066555	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066556	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066557	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2066558	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2066559	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2066560	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2066561	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066562	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066563	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066564	05/2016	05/10/2016	99.970	100.050	100.1	1
KU	C1S	2066565	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066566	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066567	05/2016	05/10/2016	99.980	99.990	100.1	1
KU	C1S	2066568	05/2016	05/10/2016	100.030	100.000	100.0	1

KU	C1S	2066569	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066570	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066571	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066572	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066573	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066574	05/2016	05/10/2016	100.040	100.000	100.0	1
KU	C1S	2066575	05/2016	05/10/2016	100.000	99.940	100.0	1
KU	C1S	2066576	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066577	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066578	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066579	05/2016	05/10/2016	99.970	99.940	99.9	1
KU	C1S	2066580	05/2016	05/10/2016	99.960	100.010	100.0	1
KU	C1S	2066581	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066582	05/2016	05/10/2016	100.040	100.040	100.1	1
KU	C1S	2066583	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066584	05/2016	05/10/2016	100.010	99.970	100.0	1
KU	C1S	2066585	05/2016	05/10/2016	100.030	100.050	100.0	1
KU	C1S	2066586	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066587	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066588	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2066589	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066590	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066591	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066592	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066593	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066594	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066595	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066596	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066597	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066598	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066599	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066600	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066601	05/2016	05/10/2016	99.970	99.960	100.0	1
KU	C1S	2066602	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066603	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2066604	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066605	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066606	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2066607	05/2016	05/10/2016	100.020	99.990	99.9	1
KU	C1S	2066608	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2066609	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066610	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066611	05/2016	05/10/2016	99.980	100.070	100.1	1
KU	C1S	2066612	05/2016	05/10/2016	99.960	100.050	100.0	1
KU	C1S	2066613	05/2016	05/10/2016	99.980	100.040	100.0	1

KU	C1S	2066614	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066615	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066616	05/2016	05/10/2016	99.950	100.020	100.0	1
KU	C1S	2066617	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066618	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066619	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2066620	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2066621	05/2016	05/10/2016	100.000	99.980	100.1	1
KU	C1S	2066622	05/2016	05/10/2016	99.980	100.000	100.1	1
KU	C1S	2066623	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2066624	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2066625	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066626	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066627	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066628	05/2016	05/10/2016	99.940	99.980	100.0	1
KU	C1S	2066629	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066630	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066631	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066632	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066633	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066634	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2066635	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066636	05/2016	05/10/2016	99.980	100.000	100.1	1
KU	C1S	2066637	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2066638	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2066639	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2066640	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2066641	05/2016	05/10/2016	99.970	100.010	100.1	1
KU	C1S	2066642	05/2016	05/10/2016	100.010	99.970	100.0	1
KU	C1S	2066643	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066644	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066645	05/2016	05/10/2016	99.950	100.000	100.0	1
KU	C1S	2066646	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066647	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066648	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066649	05/2016	05/10/2016	99.970	99.990	100.1	1
KU	C1S	2066650	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2066651	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066652	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066653	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2066654	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066655	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066656	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066657	05/2016	05/10/2016	100.030	99.990	100.1	1
KU	C1S	2066658	05/2016	05/10/2016	100.000	100.040	100.1	1

KU	C1S	2066659	05/2016	05/10/2016	100.020	99.950	100.0	1
KU	C1S	2066660	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066661	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066662	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066663	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2066664	05/2016	05/10/2016	99.950	99.960	100.0	1
KU	C1S	2066665	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066666	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066667	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066668	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066669	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066670	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2066671	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066672	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066673	05/2016	05/10/2016	100.040	99.980	100.0	1
KU	C1S	2066674	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066675	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066676	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066677	05/2016	05/10/2016	100.000	99.950	100.0	1
KU	C1S	2066678	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066679	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066680	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066681	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2066682	05/2016	05/10/2016	100.000	100.000	100.1	1
KU	C1S	2066683	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066684	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066685	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066686	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2066687	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066688	05/2016	05/10/2016	99.980	99.990	100.1	1
KU	C1S	2066689	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066690	05/2016	05/10/2016	99.970	99.960	100.0	1
KU	C1S	2066691	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066692	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066693	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066694	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066695	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2066696	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066697	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066698	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066699	05/2016	05/10/2016	99.980	100.000	100.1	1
KU	C1S	2066700	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066701	05/2016	05/10/2016	100.040	100.020	100.0	1
KU	C1S	2066702	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066703	05/2016	05/10/2016	100.010	99.980	100.0	1

KU	C1S	2066704	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066705	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066706	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2066707	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066708	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066709	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2066710	05/2016	05/10/2016	100.050	100.020	100.0	1
KU	C1S	2066711	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2066712	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066713	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066714	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066715	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2066716	05/2016	05/10/2016	100.000	100.070	100.1	1
KU	C1S	2066717	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066718	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066719	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066720	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2066721	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066722	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066723	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066724	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2066725	05/2016	05/10/2016	99.980	100.000	100.1	1
KU	C1S	2066726	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066727	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066728	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2066729	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2066730	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066731	05/2016	05/10/2016	100.000	99.980	100.1	1
KU	C1S	2066732	05/2016	05/10/2016	100.030	100.050	100.1	1
KU	C1S	2066733	05/2016	05/10/2016	99.960	99.940	100.0	1
KU	C1S	2066734	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066735	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066736	05/2016	05/10/2016	99.990	100.060	100.0	1
KU	C1S	2066737	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066738	05/2016	05/10/2016	99.950	99.980	100.0	1
KU	C1S	2066739	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2066740	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2066741	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2066742	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066743	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2066744	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066745	05/2016	05/10/2016	99.960	100.010	100.0	1
KU	C1S	2066746	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066747	05/2016	05/10/2016	99.950	100.040	100.0	1
KU	C1S	2066748	05/2016	05/10/2016	99.980	100.050	100.0	1

KU	C1S	2066749	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066750	05/2016	05/10/2016	100.030	100.040	100.1	1
KU	C1S	2066751	05/2016	05/10/2016	99.980	100.090	100.1	1
KU	C1S	2066752	05/2016	05/10/2016	100.050	100.050	100.0	1
KU	C1S	2066753	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066754	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066755	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2066756	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2066757	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066758	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066759	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066760	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066761	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066762	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066763	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2066764	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066765	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066766	05/2016	05/10/2016	100.010	100.070	100.1	1
KU	C1S	2066767	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066768	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2066769	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066770	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066771	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066772	05/2016	05/10/2016	100.010	99.950	100.1	1
KU	C1S	2066773	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066774	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2066775	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2066776	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066777	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066778	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066779	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066780	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066781	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2066782	05/2016	05/10/2016	100.000	99.980	100.1	1
KU	C1S	2066783	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066784	05/2016	05/10/2016	100.040	99.970	100.0	1
KU	C1S	2066785	05/2016	05/10/2016	99.960	99.990	100.0	1
KU	C1S	2066786	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066787	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066788	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066789	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066790	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066791	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066792	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066793	05/2016	05/10/2016	100.010	99.990	100.0	1

KU	C1S	2066794	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066795	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066796	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066797	05/2016	05/10/2016	99.970	100.050	100.1	1
KU	C1S	2066798	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066799	05/2016	05/10/2016	100.000	100.000	100.1	1
KU	C1S	2066800	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066801	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2066802	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2066803	05/2016	05/10/2016	99.960	99.940	100.0	1
KU	C1S	2066804	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2066805	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2066806	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066807	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2066808	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066809	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2066810	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2066811	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066812	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2066813	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066814	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2066815	05/2016	05/10/2016	99.970	100.060	100.0	1
KU	C1S	2066816	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2066817	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066818	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066819	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066820	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2066821	05/2016	05/10/2016	99.970	100.000	100.1	1
KU	C1S	2066822	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2066823	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066824	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2066825	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066826	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2066827	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066828	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2066829	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066830	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066831	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066832	05/2016	05/10/2016	100.050	99.970	100.1	1
KU	C1S	2066833	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2066834	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2066835	05/2016	05/10/2016	100.040	99.980	100.0	1
KU	C1S	2066836	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066837	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066838	05/2016	05/10/2016	99.980	100.030	100.0	1

KU	C1S	2066839	05/2016	05/10/2016	99.980	100.000	100.1	1
KU	C1S	2066840	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2066841	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2066842	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066843	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066844	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066845	05/2016	05/10/2016	100.050	100.020	100.0	1
KU	C1S	2066846	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066847	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066848	05/2016	05/10/2016	99.960	99.960	100.0	1
KU	C1S	2066849	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066850	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066851	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066852	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066853	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066854	05/2016	05/10/2016	100.020	100.000	100.1	1
KU	C1S	2066855	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2066856	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066857	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2066858	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066859	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066860	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2066861	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066862	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2066863	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066864	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066865	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2066866	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066867	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2066868	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066869	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2066870	05/2016	05/10/2016	100.030	100.050	100.1	1
KU	C1S	2066871	05/2016	05/10/2016	99.960	99.940	100.0	1
KU	C1S	2066872	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2066873	05/2016	05/10/2016	100.010	99.970	100.0	1
KU	C1S	2066874	05/2016	05/10/2016	100.030	100.060	100.1	1
KU	C1S	2066875	05/2016	05/10/2016	100.000	100.060	100.1	1
KU	C1S	2066876	05/2016	05/10/2016	100.030	99.950	100.0	1
KU	C1S	2066877	05/2016	05/10/2016	100.010	99.950	100.0	1
KU	C1S	2066878	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066879	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2066880	05/2016	05/10/2016	99.990	99.950	100.0	1
KU	C1S	2066881	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066882	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066883	05/2016	05/10/2016	100.030	99.990	100.0	1

KU	C1S	2066884	05/2016	05/10/2016	100.030	99.960	100.0	1
KU	C1S	2066885	05/2016	05/10/2016	100.000	99.930	100.0	1
KU	C1S	2066886	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2066887	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2066888	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2066889	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066890	05/2016	05/10/2016	99.970	99.960	100.0	1
KU	C1S	2066891	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066892	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066893	05/2016	05/10/2016	100.030	100.000	100.1	1
KU	C1S	2066894	05/2016	05/10/2016	100.000	100.060	100.1	1
KU	C1S	2066895	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066896	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2066897	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2066898	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066899	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2066900	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2066901	05/2016	05/10/2016	99.980	100.040	100.0	1
KU	C1S	2066902	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2066903	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2066904	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2066905	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066906	05/2016	05/10/2016	100.040	100.020	100.0	1
KU	C1S	2066907	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066908	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2066909	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2066910	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066911	05/2016	05/10/2016	99.960	99.960	100.0	1
KU	C1S	2066912	05/2016	05/10/2016	100.020	99.950	100.0	1
KU	C1S	2066913	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2066914	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2066915	05/2016	05/10/2016	100.060	99.950	100.0	1
KU	C1S	2066916	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2066917	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2066918	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2066919	05/2016	05/10/2016	100.000	100.000	100.1	1
KU	C1S	2066920	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2066921	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2066922	05/2016	05/10/2016	100.040	100.050	100.1	1
KU	C1S	2066923	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066924	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2066925	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2066926	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2066927	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066928	05/2016	05/10/2016	100.000	100.040	100.1	1

KU	C1S	2066929	05/2016	05/10/2016	99.990	100.070	100.1	1
KU	C1S	2066930	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2066931	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066932	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066933	05/2016	05/10/2016	100.000	100.060	100.1	1
KU	C1S	2066934	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2066935	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2066936	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2066937	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2066938	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2066939	05/2016	05/10/2016	99.950	99.960	100.0	1
KU	C1S	2066940	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2066941	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2066942	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2066943	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2066944	05/2016	05/10/2016	99.990	99.940	100.0	1
KU	C1S	2066945	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2066946	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2066947	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2066948	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2066949	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2066950	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066951	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2066952	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2066953	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2066954	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066955	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2066956	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066957	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066958	05/2016	05/10/2016	100.010	99.950	100.0	1
KU	C1S	2066959	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2066960	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2066961	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066962	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2066963	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2066964	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2066965	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2066966	05/2016	05/10/2016	99.980	99.930	100.0	1
KU	C1S	2066967	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2066968	05/2016	05/10/2016	100.000	100.070	100.1	1
KU	C1S	2066969	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2066970	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2066971	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2066972	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2066973	05/2016	05/10/2016	99.980	99.930	100.0	1

KU	C1S	2066974	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2066975	05/2016	05/10/2016	99.980	99.920	100.0	1
KU	C1S	2066976	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066977	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2066978	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2066979	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2066980	05/2016	05/10/2016	100.060	99.960	100.1	1
KU	C1S	2066981	05/2016	05/10/2016	100.030	99.980	100.0	1
KU	C1S	2066982	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2066983	05/2016	05/10/2016	100.030	100.060	100.1	1
KU	C1S	2066984	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066985	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066986	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2066987	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2066988	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2066989	05/2016	05/10/2016	99.970	100.020	100.1	1
KU	C1S	2066990	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2066991	05/2016	05/10/2016	100.030	100.080	100.1	1
KU	C1S	2066992	05/2016	05/10/2016	100.020	100.000	100.1	1
KU	C1S	2066993	05/2016	05/10/2016	100.020	99.970	100.1	1
KU	C1S	2066994	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2066995	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2066996	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2066997	05/2016	05/10/2016	100.040	100.060	100.1	1
KU	C1S	2066998	05/2016	05/10/2016	100.020	99.950	100.0	1
KU	C1S	2066999	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067000	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067001	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067002	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2067003	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067004	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067005	05/2016	05/10/2016	99.940	100.020	100.0	1
KU	C1S	2067006	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067007	05/2016	05/10/2016	100.050	100.030	100.1	1
KU	C1S	2067008	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2067009	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067010	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067011	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2067012	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067013	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2067014	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2067015	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2067016	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067017	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2067018	05/2016	05/10/2016	100.000	100.040	100.1	1

KU	C1S	2067019	05/2016	05/10/2016	100.000	100.060	100.0	1
KU	C1S	2067020	05/2016	05/10/2016	99.950	99.960	100.0	1
KU	C1S	2067021	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067022	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067023	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067024	05/2016	05/10/2016	100.070	100.000	100.0	1
KU	C1S	2067025	05/2016	05/10/2016	100.050	99.990	100.0	1
KU	C1S	2067026	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2067027	05/2016	05/10/2016	99.960	100.030	100.0	1
KU	C1S	2067028	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067029	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067030	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2067031	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2067032	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067033	05/2016	05/10/2016	100.040	99.980	100.1	1
KU	C1S	2067034	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2067035	05/2016	05/10/2016	100.020	100.060	100.0	1
KU	C1S	2067036	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067037	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067038	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067039	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067040	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067041	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067042	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067043	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067044	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067045	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2067046	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2067047	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2067048	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067049	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067050	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2067051	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067052	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067053	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067054	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2067055	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067056	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067057	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067058	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067059	05/2016	05/10/2016	100.010	99.970	100.0	1
KU	C1S	2067060	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2067061	05/2016	05/10/2016	99.980	100.090	100.1	1
KU	C1S	2067062	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067063	05/2016	05/10/2016	99.990	100.020	100.0	1

KU	C1S	2067064	05/2016	05/10/2016	99.960	100.040	100.0	1
KU	C1S	2067065	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2067066	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067067	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067068	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067069	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067070	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2067071	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067072	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2067073	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2067074	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2067075	05/2016	05/10/2016	99.970	99.960	100.0	1
KU	C1S	2067076	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067077	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067078	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067079	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2067080	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2067081	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067082	05/2016	05/10/2016	100.040	99.980	100.0	1
KU	C1S	2067083	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067084	05/2016	05/10/2016	100.030	99.950	100.0	1
KU	C1S	2067085	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067086	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2067087	05/2016	05/10/2016	99.980	100.050	100.0	1
KU	C1S	2067088	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2067089	05/2016	05/10/2016	100.020	100.080	100.1	1
KU	C1S	2067090	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067091	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2067092	05/2016	05/10/2016	99.980	100.060	100.0	1
KU	C1S	2067093	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2067094	05/2016	05/10/2016	99.980	100.070	100.1	1
KU	C1S	2067095	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067096	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067097	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067098	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067099	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067100	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067101	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067102	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2067103	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067104	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067105	05/2016	05/10/2016	99.960	99.960	100.0	1
KU	C1S	2067106	05/2016	05/10/2016	100.040	100.020	100.0	1
KU	C1S	2067107	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067108	05/2016	05/10/2016	99.990	100.030	100.0	1

KU	C1S	2067109	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067110	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067111	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2067112	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2067113	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067114	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067115	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067116	05/2016	05/10/2016	100.010	100.080	100.1	1
KU	C1S	2067117	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2067118	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067119	05/2016	05/10/2016	99.960	100.060	100.0	1
KU	C1S	2067120	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2067121	05/2016	05/10/2016	100.030	99.990	100.1	1
KU	C1S	2067122	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067123	05/2016	05/10/2016	100.030	100.010	100.1	1
KU	C1S	2067124	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067125	05/2016	05/10/2016	100.040	100.040	100.0	1
KU	C1S	2067126	05/2016	05/10/2016	100.040	100.050	100.1	1
KU	C1S	2067127	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2067128	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067129	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067130	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2067131	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2067132	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067133	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067134	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2067135	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067136	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067137	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067138	05/2016	05/10/2016	100.020	99.970	100.1	1
KU	C1S	2067139	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067140	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2067141	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067142	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2067143	05/2016	05/10/2016	99.990	100.060	100.0	1
KU	C1S	2067144	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067145	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067146	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067147	05/2016	05/10/2016	100.030	100.060	100.1	1
KU	C1S	2067148	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067149	05/2016	05/10/2016	99.980	100.080	100.1	1
KU	C1S	2067150	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2067151	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067152	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2067153	05/2016	05/10/2016	99.980	100.040	100.1	1

KU	C1S	2067154	05/2016	05/10/2016	100.030	100.040	100.1	1
KU	C1S	2067155	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067156	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2067157	05/2016	05/10/2016	99.980	100.060	100.0	1
KU	C1S	2067158	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2067159	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067160	05/2016	05/10/2016	99.970	100.040	100.0	1
KU	C1S	2067161	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067162	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067163	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067164	05/2016	05/10/2016	100.010	100.080	100.1	1
KU	C1S	2067165	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2067166	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067167	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2067168	05/2016	05/10/2016	99.990	100.070	100.1	1
KU	C1S	2067169	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067170	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067171	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2067172	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067173	05/2016	05/10/2016	100.030	100.060	100.1	1
KU	C1S	2067174	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2067175	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2067176	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2067177	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067178	05/2016	05/10/2016	100.030	100.040	100.0	1
KU	C1S	2067179	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067180	05/2016	05/10/2016	100.010	100.040	100.0	1
KU	C1S	2067181	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067182	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067183	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067184	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067185	05/2016	05/10/2016	99.960	100.010	100.0	1
KU	C1S	2067186	05/2016	05/10/2016	99.970	100.040	100.1	1
KU	C1S	2067187	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2067188	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067189	05/2016	05/10/2016	99.950	99.970	100.0	1
KU	C1S	2067190	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067191	05/2016	05/10/2016	99.980	100.030	100.0	1
KU	C1S	2067192	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067193	05/2016	05/10/2016	100.040	99.950	100.0	1
KU	C1S	2067194	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2067195	05/2016	05/10/2016	100.010	100.050	100.0	1
KU	C1S	2067196	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2067197	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067198	05/2016	05/10/2016	99.990	100.010	100.0	1

KU	C1S	2067199	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067200	05/2016	05/10/2016	100.030	100.040	100.1	1
KU	C1S	2067201	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067202	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067203	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067204	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067205	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2067206	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2067207	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067208	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067209	05/2016	05/10/2016	100.050	99.990	100.0	1
KU	C1S	2067210	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067211	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067212	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067213	05/2016	05/10/2016	99.970	100.010	100.1	1
KU	C1S	2067214	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067215	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067216	05/2016	05/10/2016	99.960	99.970	100.0	1
KU	C1S	2067217	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2067218	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2067219	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2067220	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067221	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2067222	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067223	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2067224	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067225	05/2016	05/10/2016	100.040	100.030	100.1	1
KU	C1S	2067226	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067227	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2067228	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067229	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2067230	05/2016	05/10/2016	100.030	100.060	100.0	1
KU	C1S	2067231	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067232	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067233	05/2016	05/10/2016	99.970	100.000	100.1	1
KU	C1S	2067234	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067235	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2067236	05/2016	05/10/2016	99.970	100.030	100.0	1
KU	C1S	2067237	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067238	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067239	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067240	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2067241	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067242	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2067243	05/2016	05/10/2016	99.990	100.010	100.0	1

KU	C1S	2067244	05/2016	05/10/2016	100.030	99.980	100.0	1
KU	C1S	2067245	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067246	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067247	05/2016	05/10/2016	100.060	100.040	100.1	1
KU	C1S	2067248	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067249	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2067250	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067251	05/2016	05/10/2016	100.020	99.940	100.0	1
KU	C1S	2067252	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067253	05/2016	05/10/2016	100.050	100.000	100.0	1
KU	C1S	2067254	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067255	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067256	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067257	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2067258	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067259	05/2016	05/10/2016	99.960	100.030	100.1	1
KU	C1S	2067260	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067261	05/2016	05/10/2016	100.020	99.950	100.0	1
KU	C1S	2067262	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067263	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067264	05/2016	05/10/2016	100.060	100.000	100.0	1
KU	C1S	2067265	05/2016	05/10/2016	99.970	100.000	100.0	1
KU	C1S	2067266	05/2016	05/10/2016	100.030	100.020	100.1	1
KU	C1S	2067267	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067268	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2067269	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2067270	05/2016	05/10/2016	99.980	99.960	100.0	1
KU	C1S	2067271	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067272	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067273	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067274	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2067275	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067276	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2067277	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067278	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067279	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067280	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2067281	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067282	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067283	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067284	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2067285	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067286	05/2016	05/10/2016	99.970	100.020	100.1	1
KU	C1S	2067287	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067288	05/2016	05/10/2016	99.990	100.000	100.1	1

KU	C1S	2067289	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067290	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2067291	05/2016	05/10/2016	100.040	99.990	100.0	1
KU	C1S	2067292	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2067293	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067294	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067295	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067296	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067297	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2067298	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067299	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067300	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067301	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2067302	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067303	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067304	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067305	05/2016	05/10/2016	99.980	100.060	100.1	1
KU	C1S	2067306	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2067307	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067308	05/2016	05/10/2016	99.990	100.070	100.1	1
KU	C1S	2067309	05/2016	05/10/2016	99.970	100.040	100.1	1
KU	C1S	2067310	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067311	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067312	05/2016	05/10/2016	99.960	99.980	100.0	1
KU	C1S	2067313	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067314	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067315	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067316	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067317	05/2016	05/10/2016	99.980	99.980	100.1	1
KU	C1S	2067318	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067319	05/2016	05/10/2016	99.970	100.050	100.0	1
KU	C1S	2067320	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067321	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067322	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067323	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067324	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067325	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067326	05/2016	05/10/2016	99.990	100.000	100.1	1
KU	C1S	2067327	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067328	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2067329	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067330	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067331	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2067332	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067333	05/2016	05/10/2016	100.000	100.020	100.1	1

KU	C1S	2067334	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067335	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2067336	05/2016	05/10/2016	100.030	100.060	100.0	1
KU	C1S	2067337	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067338	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067339	05/2016	05/10/2016	100.030	100.060	100.1	1
KU	C1S	2067340	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067341	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067342	05/2016	05/10/2016	99.960	100.020	100.1	1
KU	C1S	2067343	05/2016	05/10/2016	100.030	99.990	100.0	1
KU	C1S	2067344	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067345	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067346	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2067347	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067348	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067349	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067350	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067351	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2067352	05/2016	05/10/2016	99.970	100.060	100.1	1
KU	C1S	2067353	05/2016	05/10/2016	99.970	100.050	100.1	1
KU	C1S	2067354	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067355	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2067356	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067357	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067358	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067359	05/2016	05/10/2016	100.040	99.950	100.0	1
KU	C1S	2067360	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2067361	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067362	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067363	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2067364	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067365	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2067366	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2067367	05/2016	05/10/2016	99.960	100.050	100.0	1
KU	C1S	2067368	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067369	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067370	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2067371	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067372	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067373	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067374	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067375	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067376	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067377	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067378	05/2016	05/10/2016	100.000	100.020	100.0	1

KU	C1S	2067379	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067380	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067381	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067382	05/2016	05/10/2016	99.970	100.040	100.1	1
KU	C1S	2067383	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067384	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2067385	05/2016	05/10/2016	100.000	100.070	100.1	1
KU	C1S	2067386	05/2016	05/10/2016	99.960	100.030	100.0	1
KU	C1S	2067387	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067388	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067389	05/2016	05/10/2016	100.020	100.070	100.1	1
KU	C1S	2067390	05/2016	05/10/2016	100.030	100.070	100.1	1
KU	C1S	2067391	05/2016	05/10/2016	99.980	100.050	100.1	1
KU	C1S	2067392	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2067393	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2067394	05/2016	05/10/2016	99.970	99.980	99.9	1
KU	C1S	2067395	05/2016	05/10/2016	100.030	99.990	100.1	1
KU	C1S	2067396	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2067397	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067398	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2067399	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067400	05/2016	05/10/2016	99.990	99.950	100.0	1
KU	C1S	2067401	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067402	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067403	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2067404	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067405	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067406	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067407	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067408	05/2016	05/10/2016	99.960	100.040	100.0	1
KU	C1S	2067409	05/2016	05/10/2016	99.960	100.020	100.0	1
KU	C1S	2067410	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067411	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067412	05/2016	05/10/2016	100.000	99.900	99.9	1
KU	C1S	2067413	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067414	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067415	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2067416	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067417	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067418	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067419	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067420	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067421	05/2016	05/10/2016	99.990	99.950	100.0	1
KU	C1S	2067422	05/2016	05/10/2016	100.030	100.020	100.1	1
KU	C1S	2067423	05/2016	05/10/2016	99.990	100.000	100.0	1

KU	C1S	2067424	05/2016	05/10/2016	100.010	99.940	100.0	1
KU	C1S	2067425	05/2016	05/10/2016	100.030	99.990	100.0	1
KU	C1S	2067426	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067427	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067428	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067429	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067430	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067431	05/2016	05/10/2016	100.070	99.990	100.0	1
KU	C1S	2067432	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2067433	05/2016	05/10/2016	100.040	99.980	100.0	1
KU	C1S	2067434	05/2016	05/10/2016	100.010	99.960	100.0	1
KU	C1S	2067435	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067436	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067437	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2067438	05/2016	05/10/2016	100.040	100.010	100.1	1
KU	C1S	2067439	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2067440	05/2016	05/10/2016	100.000	99.990	100.1	1
KU	C1S	2067441	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067442	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067443	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067444	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067445	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067446	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067447	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067448	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067449	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2067450	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067451	05/2016	05/10/2016	99.960	100.010	100.0	1
KU	C1S	2067452	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067453	05/2016	05/10/2016	100.040	100.010	100.0	1
KU	C1S	2067454	05/2016	05/10/2016	100.030	100.020	100.0	1
KU	C1S	2067455	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067456	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067457	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067458	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067459	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067460	05/2016	05/10/2016	100.030	99.990	100.0	1
KU	C1S	2067461	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2067462	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067463	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067464	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067465	05/2016	05/10/2016	100.060	99.960	100.0	1
KU	C1S	2067466	05/2016	05/10/2016	100.000	100.040	100.0	1
KU	C1S	2067467	05/2016	05/10/2016	99.980	100.050	100.0	1
KU	C1S	2067468	05/2016	05/10/2016	100.000	100.020	100.0	1

KU	C1S	2067469	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067470	05/2016	05/10/2016	100.030	99.970	100.0	1
KU	C1S	2067471	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067472	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067473	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2067474	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067475	05/2016	05/10/2016	99.960	99.990	100.0	1
KU	C1S	2067476	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067477	05/2016	05/10/2016	99.980	99.980	99.9	1
KU	C1S	2067478	05/2016	05/10/2016	100.030	100.050	100.0	1
KU	C1S	2067479	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2067480	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067481	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067482	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067483	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067484	05/2016	05/10/2016	99.970	100.030	100.1	1
KU	C1S	2067485	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2067486	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067487	05/2016	05/10/2016	99.950	99.970	100.0	1
KU	C1S	2067488	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067489	05/2016	05/10/2016	100.030	100.000	100.1	1
KU	C1S	2067490	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067491	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067492	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067493	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067494	05/2016	05/10/2016	100.000	100.090	100.0	1
KU	C1S	2067495	05/2016	05/10/2016	100.000	99.940	100.0	1
KU	C1S	2067496	05/2016	05/10/2016	100.000	99.930	100.0	1
KU	C1S	2067497	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067498	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067499	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067500	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067501	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2067502	05/2016	05/10/2016	99.950	100.050	100.1	1
KU	C1S	2067503	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067504	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067505	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2067506	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067507	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067508	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067509	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2067510	05/2016	05/10/2016	100.060	100.020	100.1	1
KU	C1S	2067511	05/2016	05/10/2016	99.940	99.980	100.0	1
KU	C1S	2067512	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067513	05/2016	05/10/2016	100.000	100.010	100.1	1

KU	C1S	2067514	05/2016	05/10/2016	99.970	99.940	100.0	1
KU	C1S	2067515	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067516	05/2016	05/10/2016	100.020	100.010	100.0	1
KU	C1S	2067517	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067518	05/2016	05/10/2016	100.020	100.030	100.1	1
KU	C1S	2067519	05/2016	05/10/2016	100.010	99.970	100.0	1
KU	C1S	2067520	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2067521	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067522	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067523	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067524	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2067525	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067526	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2067527	05/2016	05/10/2016	99.970	99.970	100.0	1
KU	C1S	2067528	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067529	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2067530	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067531	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067532	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2067533	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067534	05/2016	05/10/2016	99.950	99.990	100.0	1
KU	C1S	2067535	05/2016	05/10/2016	99.990	99.940	100.0	1
KU	C1S	2067536	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067537	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067538	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067539	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067540	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067541	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067542	05/2016	05/10/2016	99.960	99.990	100.0	1
KU	C1S	2067543	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2067544	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2067545	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067546	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2067547	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2067548	05/2016	05/10/2016	100.030	100.000	100.0	1
KU	C1S	2067549	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067550	05/2016	05/10/2016	99.970	100.010	100.0	1
KU	C1S	2067551	05/2016	05/10/2016	100.020	99.920	99.9	1
KU	C1S	2067552	05/2016	05/10/2016	100.040	100.030	100.0	1
KU	C1S	2067553	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067554	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067555	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2067556	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067557	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067558	05/2016	05/10/2016	100.050	100.040	100.0	1

KU	C1S	2067559	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067560	05/2016	05/10/2016	100.030	100.010	100.1	1
KU	C1S	2067561	05/2016	05/10/2016	100.000	100.020	100.0	1
KU	C1S	2067562	05/2016	05/10/2016	100.020	100.000	100.1	1
KU	C1S	2067563	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2067564	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067565	05/2016	05/10/2016	99.950	100.060	100.1	1
KU	C1S	2067566	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067567	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067568	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2067569	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067570	05/2016	05/10/2016	100.030	100.010	100.1	1
KU	C1S	2067571	05/2016	05/10/2016	99.950	100.000	100.0	1
KU	C1S	2067572	05/2016	05/10/2016	100.010	100.010	100.1	1
KU	C1S	2067573	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2067574	05/2016	05/10/2016	100.040	99.990	100.0	1
KU	C1S	2067575	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2067576	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067577	05/2016	05/10/2016	100.040	100.000	100.0	1
KU	C1S	2067578	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067579	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2067580	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067581	05/2016	05/10/2016	100.040	100.040	100.0	1
KU	C1S	2067582	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067583	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067584	05/2016	05/10/2016	99.980	99.990	100.0	1
KU	C1S	2067585	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2067586	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067587	05/2016	05/10/2016	100.010	99.950	100.0	1
KU	C1S	2067588	05/2016	05/10/2016	99.990	100.020	100.1	1
KU	C1S	2067589	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067590	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067591	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2067592	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067593	05/2016	05/10/2016	100.010	99.980	100.1	1
KU	C1S	2067594	05/2016	05/10/2016	100.020	100.010	100.1	1
KU	C1S	2067595	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2067596	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067597	05/2016	05/10/2016	100.040	99.980	100.1	1
KU	C1S	2067598	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067599	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067600	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2067601	05/2016	05/10/2016	100.040	100.020	100.0	1
KU	C1S	2067602	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067603	05/2016	05/10/2016	99.970	99.990	100.0	1

KU	C1S	2067604	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067605	05/2016	05/10/2016	99.980	100.030	100.1	1
KU	C1S	2067606	05/2016	05/10/2016	100.010	99.980	100.1	1
KU	C1S	2067607	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067608	05/2016	05/10/2016	99.980	100.020	100.0	1
KU	C1S	2067609	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067610	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2067611	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067612	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067613	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067614	05/2016	05/10/2016	99.990	99.960	100.1	1
KU	C1S	2067615	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2067616	05/2016	05/10/2016	99.960	99.990	100.0	1
KU	C1S	2067617	05/2016	05/10/2016	100.030	100.010	100.1	1
KU	C1S	2067618	05/2016	05/10/2016	100.000	99.970	100.0	1
KU	C1S	2067619	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067620	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067621	05/2016	05/10/2016	100.030	100.020	100.1	1
KU	C1S	2067622	05/2016	05/10/2016	99.990	100.040	100.1	1
KU	C1S	2067623	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067624	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2067625	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067626	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067627	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067628	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067629	05/2016	05/10/2016	99.960	100.000	100.0	1
KU	C1S	2067630	05/2016	05/10/2016	100.060	99.980	100.0	1
KU	C1S	2067631	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067632	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067633	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2067634	05/2016	05/10/2016	100.010	99.990	100.1	1
KU	C1S	2067635	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067636	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2067637	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067638	05/2016	05/10/2016	100.040	99.990	100.1	1
KU	C1S	2067639	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067640	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067641	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2067642	05/2016	05/10/2016	100.030	100.070	100.1	1
KU	C1S	2067643	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067644	05/2016	05/10/2016	100.040	100.040	100.1	1
KU	C1S	2067645	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067646	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2067647	05/2016	05/10/2016	99.980	100.000	100.0	1
KU	C1S	2067648	05/2016	05/10/2016	99.970	100.040	100.0	1

KU	C1S	2067649	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2067650	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067651	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067652	05/2016	05/10/2016	100.010	100.050	100.1	1
KU	C1S	2067653	05/2016	05/10/2016	99.990	100.060	100.1	1
KU	C1S	2067654	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067655	05/2016	05/10/2016	100.000	100.060	100.1	1
KU	C1S	2067656	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067657	05/2016	05/10/2016	100.020	100.040	100.0	1
KU	C1S	2067658	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2067659	05/2016	05/10/2016	100.020	100.060	100.1	1
KU	C1S	2067660	05/2016	05/10/2016	100.010	99.980	100.1	1
KU	C1S	2067661	05/2016	05/10/2016	100.040	100.050	100.0	1
KU	C1S	2067662	05/2016	05/10/2016	100.030	100.030	100.1	1
KU	C1S	2067663	05/2016	05/10/2016	99.980	100.080	100.1	1
KU	C1S	2067664	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067665	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2067666	05/2016	05/10/2016	100.010	100.070	100.1	1
KU	C1S	2067667	05/2016	05/10/2016	100.020	100.030	100.0	1
KU	C1S	2067668	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067669	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067670	05/2016	05/10/2016	99.980	100.060	100.0	1
KU	C1S	2067671	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067672	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067673	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2067674	05/2016	05/10/2016	100.000	100.020	100.1	1
KU	C1S	2067675	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067676	05/2016	05/10/2016	99.980	100.070	100.1	1
KU	C1S	2067677	05/2016	05/10/2016	99.990	100.050	100.0	1
KU	C1S	2067678	05/2016	05/10/2016	100.000	100.060	100.0	1
KU	C1S	2067679	05/2016	05/10/2016	100.020	100.050	100.0	1
KU	C1S	2067680	05/2016	05/10/2016	100.030	100.050	100.1	1
KU	C1S	2067681	05/2016	05/10/2016	99.990	100.020	100.0	1
KU	C1S	2067682	05/2016	05/10/2016	99.980	100.010	100.1	1
KU	C1S	2067683	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067684	05/2016	05/10/2016	100.000	100.050	100.1	1
KU	C1S	2067685	05/2016	05/10/2016	100.070	99.970	100.0	1
KU	C1S	2067686	05/2016	05/10/2016	99.980	100.020	100.1	1
KU	C1S	2067687	05/2016	05/10/2016	99.980	100.040	100.1	1
KU	C1S	2067688	05/2016	05/10/2016	99.960	100.000	100.0	1
KU	C1S	2067689	05/2016	05/10/2016	99.960	100.030	100.1	1
KU	C1S	2067690	05/2016	05/10/2016	100.010	100.030	100.0	1
KU	C1S	2067691	05/2016	05/10/2016	100.020	100.020	100.0	1
KU	C1S	2067692	05/2016	05/10/2016	100.010	100.060	100.1	1
KU	C1S	2067693	05/2016	05/10/2016	100.000	100.010	100.1	1

KU	C1S	2067694	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067695	05/2016	05/10/2016	100.000	100.030	100.0	1
KU	C1S	2067696	05/2016	05/10/2016	100.010	100.000	100.1	1
KU	C1S	2067697	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2067698	05/2016	05/10/2016	100.010	100.100	100.1	1
KU	C1S	2067699	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067700	05/2016	05/10/2016	100.040	99.980	100.1	1
KU	C1S	2067701	05/2016	05/10/2016	99.990	99.980	100.0	1
KU	C1S	2067702	05/2016	05/10/2016	99.980	99.990	100.1	1
KU	C1S	2067703	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067704	05/2016	05/10/2016	100.000	100.000	100.0	1
KU	C1S	2067705	05/2016	05/10/2016	100.040	99.990	100.0	1
KU	C1S	2067706	05/2016	05/10/2016	100.010	100.010	100.0	1
KU	C1S	2067707	05/2016	05/10/2016	99.980	99.970	100.0	1
KU	C1S	2067708	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067709	05/2016	05/10/2016	100.010	100.030	100.1	1
KU	C1S	2067710	05/2016	05/10/2016	100.010	100.020	100.1	1
KU	C1S	2067711	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2067712	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067713	05/2016	05/10/2016	99.990	99.990	100.0	1
KU	C1S	2067714	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067715	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067716	05/2016	05/10/2016	100.010	100.040	100.1	1
KU	C1S	2067717	05/2016	05/10/2016	99.990	100.000	100.0	1
KU	C1S	2067718	05/2016	05/10/2016	100.020	99.980	100.1	1
KU	C1S	2067719	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067720	05/2016	05/10/2016	99.990	100.030	100.0	1
KU	C1S	2067721	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067722	05/2016	05/10/2016	100.000	100.050	100.0	1
KU	C1S	2067723	05/2016	05/10/2016	100.010	100.060	100.0	1
KU	C1S	2067724	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067725	05/2016	05/10/2016	99.980	99.980	100.1	1
KU	C1S	2067726	05/2016	05/10/2016	100.010	100.020	100.0	1
KU	C1S	2067727	05/2016	05/10/2016	100.010	99.980	100.0	1
KU	C1S	2067728	05/2016	05/10/2016	99.970	100.020	100.1	1
KU	C1S	2067729	05/2016	05/10/2016	100.040	100.020	100.1	1
KU	C1S	2067730	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067731	05/2016	05/10/2016	99.970	99.990	100.0	1
KU	C1S	2067732	05/2016	05/10/2016	99.990	99.990	100.1	1
KU	C1S	2067733	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067734	05/2016	05/10/2016	99.990	100.030	100.1	1
KU	C1S	2067735	05/2016	05/10/2016	99.990	100.010	100.0	1
KU	C1S	2067736	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067737	05/2016	05/10/2016	100.020	99.960	100.0	1
KU	C1S	2067738	05/2016	05/10/2016	100.020	100.030	100.1	1

KU	C1S	2067739	05/2016	05/10/2016	100.020	100.040	100.1	1
KU	C1S	2067740	05/2016	05/10/2016	99.990	100.010	100.1	1
KU	C1S	2067741	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2067742	05/2016	05/10/2016	100.010	100.070	100.0	1
KU	C1S	2067743	05/2016	05/10/2016	100.000	100.040	100.1	1
KU	C1S	2067744	05/2016	05/10/2016	99.960	100.010	100.1	1
KU	C1S	2067745	05/2016	05/10/2016	100.050	99.960	100.0	1
KU	C1S	2067746	05/2016	05/10/2016	99.990	100.050	100.1	1
KU	C1S	2067747	05/2016	05/10/2016	100.000	99.980	100.0	1
KU	C1S	2067748	05/2016	05/10/2016	100.030	100.030	100.0	1
KU	C1S	2067749	05/2016	05/10/2016	100.020	99.980	100.0	1
KU	C1S	2067750	05/2016	05/10/2016	100.040	100.040	100.0	1
KU	C1S	2067751	05/2016	05/10/2016	100.020	99.990	100.0	1
KU	C1S	2067752	05/2016	05/10/2016	100.000	99.960	100.0	1
KU	C1S	2067753	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067754	05/2016	05/10/2016	100.020	99.970	100.0	1
KU	C1S	2067755	05/2016	05/10/2016	99.990	100.040	100.0	1
KU	C1S	2067756	05/2016	05/10/2016	99.980	99.980	100.0	1
KU	C1S	2067757	05/2016	05/10/2016	100.020	100.020	100.1	1
KU	C1S	2067758	05/2016	05/10/2016	99.960	100.030	100.0	1
KU	C1S	2067759	05/2016	05/10/2016	100.000	100.010	100.0	1
KU	C1S	2067760	05/2016	05/10/2016	100.030	100.010	100.0	1
KU	C1S	2067761	05/2016	05/10/2016	100.020	100.050	100.1	1
KU	C1S	2067762	05/2016	05/10/2016	99.990	99.960	100.0	1
KU	C1S	2067763	05/2016	05/10/2016	100.020	100.000	100.0	1
KU	C1S	2067764	05/2016	05/10/2016	99.970	100.020	100.0	1
KU	C1S	2067765	05/2016	05/10/2016	100.000	99.990	100.0	1
KU	C1S	2067766	05/2016	05/10/2016	99.990	99.970	100.0	1
KU	C1S	2067767	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2067768	05/2016	05/10/2016	99.970	99.980	100.0	1
KU	C1S	2067769	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067770	05/2016	05/10/2016	100.000	100.030	100.1	1
KU	C1S	2067771	05/2016	05/10/2016	100.000	100.070	100.0	1
KU	C1S	2067772	05/2016	05/10/2016	100.030	100.050	100.0	1
KU	C1S	2067773	05/2016	05/10/2016	100.010	100.000	100.0	1
KU	C1S	2067774	05/2016	05/10/2016	100.000	100.070	100.0	1
KU	C1S	2067775	05/2016	05/10/2016	100.010	99.990	100.0	1
KU	C1S	2067776	05/2016	05/10/2016	99.970	100.010	100.1	1
KU	C1S	2067777	05/2016	05/10/2016	100.000	100.010	100.1	1
KU	C1S	2067778	05/2016	05/10/2016	100.020	100.000	100.1	1
KU	C1S	2067779	05/2016	05/10/2016	99.980	100.010	100.0	1
KU	C1S	2068020	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068021	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068022	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068023	07/2016	07/22/2016	100.000	100.030	100.1	1

KU	C1S	2068024	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068025	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068026	07/2016	07/22/2016	100.010	100.030	100.0	1
KU	C1S	2068027	07/2016	07/22/2016	100.030	100.020	100.1	1
KU	C1S	2068028	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068029	07/2016	07/22/2016	99.960	100.010	100.0	1
KU	C1S	2068030	07/2016	07/22/2016	100.000	99.990	100.1	1
KU	C1S	2068031	07/2016	07/22/2016	100.050	99.990	100.0	1
KU	C1S	2068032	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068033	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068034	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068035	07/2016	07/22/2016	99.980	100.050	100.1	1
KU	C1S	2068036	07/2016	07/22/2016	100.010	100.080	100.1	1
KU	C1S	2068037	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068038	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068039	07/2016	07/22/2016	99.970	100.030	100.1	1
KU	C1S	2068040	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068041	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068042	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068043	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068044	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068045	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068046	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068047	07/2016	07/22/2016	100.010	100.030	100.0	1
KU	C1S	2068048	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068049	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068050	07/2016	07/22/2016	100.030	100.000	100.0	1
KU	C1S	2068051	07/2016	07/22/2016	100.010	99.990	100.1	1
KU	C1S	2068052	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068053	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068054	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068055	07/2016	07/22/2016	99.980	100.030	100.1	1
KU	C1S	2068056	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068057	07/2016	07/22/2016	100.020	100.010	100.1	1
KU	C1S	2068058	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068059	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068060	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068061	07/2016	07/22/2016	100.030	100.010	100.1	1
KU	C1S	2068062	07/2016	07/22/2016	100.000	100.020	100.1	1
KU	C1S	2068063	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068064	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068065	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068066	07/2016	07/22/2016	99.950	99.980	100.0	1
KU	C1S	2068067	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068068	07/2016	07/22/2016	100.010	99.980	100.1	1

KU	C1S	2068069	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068070	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068071	07/2016	07/22/2016	100.010	100.000	100.1	1
KU	C1S	2068072	07/2016	07/22/2016	99.990	100.050	100.1	1
KU	C1S	2068073	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068074	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068075	07/2016	07/22/2016	100.020	100.040	100.1	1
KU	C1S	2068076	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068077	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068078	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068079	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068080	07/2016	07/22/2016	99.960	99.970	100.0	1
KU	C1S	2068081	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068082	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068083	07/2016	07/22/2016	100.020	100.020	100.1	1
KU	C1S	2068084	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068085	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068086	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068087	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068088	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068089	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068090	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068091	07/2016	07/22/2016	99.950	100.060	100.1	1
KU	C1S	2068092	07/2016	07/22/2016	100.040	100.000	100.1	1
KU	C1S	2068093	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068094	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068095	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068096	07/2016	07/22/2016	100.000	100.050	100.1	1
KU	C1S	2068097	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068098	07/2016	07/22/2016	100.020	100.030	100.1	1
KU	C1S	2068099	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068100	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068101	07/2016	07/22/2016	100.030	100.020	100.1	1
KU	C1S	2068102	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068103	07/2016	07/22/2016	99.950	100.020	100.0	1
KU	C1S	2068104	07/2016	07/22/2016	99.970	100.030	100.0	1
KU	C1S	2068105	07/2016	07/22/2016	100.010	100.080	100.1	1
KU	C1S	2068106	07/2016	07/22/2016	100.010	100.040	100.0	1
KU	C1S	2068107	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068108	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068109	07/2016	07/22/2016	99.960	99.960	100.0	1
KU	C1S	2068110	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068111	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068112	07/2016	07/22/2016	100.020	99.970	100.0	1
KU	C1S	2068113	07/2016	07/22/2016	100.000	100.010	100.0	1

KU	C1S	2068114	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068115	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068116	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068117	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068118	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068119	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068120	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068121	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068122	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068123	07/2016	07/22/2016	99.970	100.030	100.1	1
KU	C1S	2068124	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068125	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068126	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068127	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068128	07/2016	07/22/2016	99.960	99.990	100.0	1
KU	C1S	2068129	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068130	07/2016	07/22/2016	100.030	100.070	100.1	1
KU	C1S	2068131	07/2016	07/22/2016	99.980	100.050	100.1	1
KU	C1S	2068132	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068133	07/2016	07/22/2016	100.000	100.050	100.1	1
KU	C1S	2068134	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068135	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068136	07/2016	07/22/2016	99.980	100.060	100.1	1
KU	C1S	2068137	07/2016	07/22/2016	100.040	100.060	100.1	1
KU	C1S	2068138	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068139	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068140	07/2016	07/22/2016	99.960	99.980	100.1	1
KU	C1S	2068141	07/2016	07/22/2016	99.990	100.010	100.1	1
KU	C1S	2068142	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068143	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068144	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068145	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068146	07/2016	07/22/2016	99.960	100.020	100.1	1
KU	C1S	2068147	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068148	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068149	07/2016	07/22/2016	100.030	100.010	100.1	1
KU	C1S	2068150	07/2016	07/22/2016	99.970	100.050	100.0	1
KU	C1S	2068151	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068152	07/2016	07/22/2016	100.040	100.040	100.1	1
KU	C1S	2068153	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068154	07/2016	07/22/2016	100.050	100.030	100.1	1
KU	C1S	2068155	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068156	07/2016	07/22/2016	100.020	100.050	100.0	1
KU	C1S	2068157	07/2016	07/22/2016	100.000	100.040	100.1	1
KU	C1S	2068158	07/2016	07/22/2016	99.990	99.980	100.0	1

KU	C1S	2068159	07/2016	07/22/2016	99.980	100.040	100.1	1
KU	C1S	2068160	07/2016	07/22/2016	100.000	100.050	100.1	1
KU	C1S	2068161	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068162	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068163	07/2016	07/22/2016	99.970	99.940	100.0	1
KU	C1S	2068164	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068165	07/2016	07/22/2016	100.020	100.050	100.1	1
KU	C1S	2068166	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068167	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068168	07/2016	07/22/2016	99.990	100.030	100.1	1
KU	C1S	2068169	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068170	07/2016	07/22/2016	100.040	100.000	100.0	1
KU	C1S	2068171	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068172	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068173	07/2016	07/22/2016	100.010	100.040	100.0	1
KU	C1S	2068174	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068175	07/2016	07/22/2016	100.010	99.930	100.0	1
KU	C1S	2068176	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068177	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068178	07/2016	07/22/2016	99.960	100.000	100.0	1
KU	C1S	2068179	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068180	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068181	07/2016	07/22/2016	99.980	99.950	100.0	1
KU	C1S	2068182	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068183	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068184	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068185	07/2016	07/22/2016	100.010	99.930	100.0	1
KU	C1S	2068186	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068187	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068188	07/2016	07/22/2016	100.030	99.970	100.0	1
KU	C1S	2068189	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068190	07/2016	07/22/2016	100.000	100.050	100.0	1
KU	C1S	2068191	07/2016	07/22/2016	100.000	100.050	100.1	1
KU	C1S	2068192	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068193	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068194	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068195	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068196	07/2016	07/22/2016	99.960	100.010	100.0	1
KU	C1S	2068197	07/2016	07/22/2016	100.020	100.020	100.1	1
KU	C1S	2068198	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068199	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068200	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068201	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068202	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068203	07/2016	07/22/2016	100.040	100.040	100.1	1

KU	C1S	2068204	07/2016	07/22/2016	99.980	99.990	100.1	1
KU	C1S	2068205	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068206	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068207	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068208	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068209	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068210	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068211	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068212	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068213	07/2016	07/22/2016	100.020	99.970	100.0	1
KU	C1S	2068214	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068215	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068216	07/2016	07/22/2016	100.030	99.970	100.0	1
KU	C1S	2068217	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068218	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068219	07/2016	07/22/2016	100.010	99.950	100.1	1
KU	C1S	2068220	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068221	07/2016	07/22/2016	99.970	100.040	100.0	1
KU	C1S	2068222	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068223	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068224	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068225	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068226	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068227	07/2016	07/22/2016	100.000	100.020	100.1	1
KU	C1S	2068228	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068229	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068230	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068231	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068232	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068233	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068234	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068235	07/2016	07/22/2016	99.970	100.020	100.0	1
KU	C1S	2068236	07/2016	07/22/2016	100.040	99.990	100.0	1
KU	C1S	2068237	07/2016	07/22/2016	100.010	99.950	100.0	1
KU	C1S	2068238	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068239	07/2016	07/22/2016	99.970	99.970	100.1	1
KU	C1S	2068240	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068241	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068242	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068243	07/2016	07/22/2016	99.960	99.980	100.0	1
KU	C1S	2068244	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068245	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068246	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068247	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068248	07/2016	07/22/2016	99.930	99.970	100.0	1

KU	C1S	2068249	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068250	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068251	07/2016	07/22/2016	99.980	100.050	100.0	1
KU	C1S	2068252	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068253	07/2016	07/22/2016	100.010	100.010	100.1	1
KU	C1S	2068254	07/2016	07/22/2016	100.010	99.970	100.1	1
KU	C1S	2068255	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068256	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068257	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068258	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068259	07/2016	07/22/2016	99.970	99.980	100.0	1
KU	C1S	2068260	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068261	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068262	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068263	07/2016	07/22/2016	100.000	99.950	100.0	1
KU	C1S	2068264	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068265	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068266	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068267	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068268	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068269	07/2016	07/22/2016	100.030	100.000	100.0	1
KU	C1S	2068270	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068271	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068272	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068273	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068274	07/2016	07/22/2016	100.040	99.950	100.0	1
KU	C1S	2068275	07/2016	07/22/2016	99.950	100.020	100.1	1
KU	C1S	2068276	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068277	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068278	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068279	07/2016	07/22/2016	100.000	100.020	100.1	1
KU	C1S	2068280	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068281	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068282	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068283	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068284	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068285	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068286	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068287	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068288	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068289	07/2016	07/22/2016	99.970	99.980	100.0	1
KU	C1S	2068290	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068291	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068292	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068293	07/2016	07/22/2016	100.000	100.020	100.0	1

KU	C1S	2068294	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068295	07/2016	07/22/2016	100.000	99.940	100.0	1
KU	C1S	2068296	07/2016	07/22/2016	100.030	100.000	100.1	1
KU	C1S	2068297	07/2016	07/22/2016	99.970	99.950	100.0	1
KU	C1S	2068298	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068299	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068300	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068301	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068302	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068303	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068304	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068305	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068306	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068307	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068308	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068309	07/2016	07/22/2016	100.030	100.000	100.0	1
KU	C1S	2068310	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068311	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068312	07/2016	07/22/2016	100.000	99.950	100.0	1
KU	C1S	2068313	07/2016	07/22/2016	99.950	99.990	100.0	1
KU	C1S	2068314	07/2016	07/22/2016	100.020	99.950	100.0	1
KU	C1S	2068315	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068316	07/2016	07/22/2016	100.010	99.930	100.0	1
KU	C1S	2068317	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068318	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068319	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068320	07/2016	07/22/2016	99.990	99.990	100.1	1
KU	C1S	2068321	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068322	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068323	07/2016	07/22/2016	100.040	99.950	100.0	1
KU	C1S	2068324	07/2016	07/22/2016	100.010	99.980	100.1	1
KU	C1S	2068325	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068326	07/2016	07/22/2016	99.980	100.030	100.1	1
KU	C1S	2068327	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068328	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068329	07/2016	07/22/2016	99.960	99.970	100.0	1
KU	C1S	2068330	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068331	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068332	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068333	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068334	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068335	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068336	07/2016	07/22/2016	100.020	100.030	100.1	1
KU	C1S	2068337	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068338	07/2016	07/22/2016	99.990	99.960	100.0	1

KU	C1S	2068339	07/2016	07/22/2016	100.020	99.970	100.0	1
KU	C1S	2068340	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068341	07/2016	07/22/2016	100.030	99.980	100.1	1
KU	C1S	2068342	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068343	07/2016	07/22/2016	99.950	99.980	100.1	1
KU	C1S	2068344	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068345	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068346	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068347	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068348	07/2016	07/22/2016	99.960	99.900	100.0	1
KU	C1S	2068349	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068350	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068351	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068352	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068353	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068354	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068355	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068356	07/2016	07/22/2016	100.030	99.960	100.0	1
KU	C1S	2068357	07/2016	07/22/2016	99.980	100.030	100.0	1
KU	C1S	2068358	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068359	07/2016	07/22/2016	100.040	99.960	100.0	1
KU	C1S	2068360	07/2016	07/22/2016	100.020	100.000	100.1	1
KU	C1S	2068361	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068362	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068363	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068364	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068365	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068366	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068367	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068368	07/2016	07/22/2016	100.040	99.970	100.0	1
KU	C1S	2068369	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068370	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068371	07/2016	07/22/2016	99.970	100.000	100.0	1
KU	C1S	2068372	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068373	07/2016	07/22/2016	100.000	99.990	100.1	1
KU	C1S	2068374	07/2016	07/22/2016	99.980	99.950	100.0	1
KU	C1S	2068375	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068376	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068377	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068378	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068379	07/2016	07/22/2016	99.990	100.030	100.1	1
KU	C1S	2068380	07/2016	07/22/2016	100.040	100.040	100.1	1
KU	C1S	2068381	07/2016	07/22/2016	100.030	100.020	100.1	1
KU	C1S	2068382	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068383	07/2016	07/22/2016	100.010	100.000	100.0	1

KU	C1S	2068384	07/2016	07/22/2016	99.970	100.000	100.0	1
KU	C1S	2068385	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068386	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068387	07/2016	07/22/2016	100.020	99.940	100.0	1
KU	C1S	2068388	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068389	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068390	07/2016	07/22/2016	99.990	100.070	100.1	1
KU	C1S	2068391	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068392	07/2016	07/22/2016	99.990	100.040	100.0	1
KU	C1S	2068393	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068394	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068395	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068396	07/2016	07/22/2016	100.010	100.040	100.0	1
KU	C1S	2068397	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068398	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068399	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068400	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068401	07/2016	07/22/2016	100.030	100.000	100.1	1
KU	C1S	2068402	07/2016	07/22/2016	100.030	100.010	100.1	1
KU	C1S	2068403	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068404	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068405	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068406	07/2016	07/22/2016	99.960	99.990	100.1	1
KU	C1S	2068407	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068408	07/2016	07/22/2016	100.050	100.000	100.0	1
KU	C1S	2068409	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068410	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068411	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068412	07/2016	07/22/2016	99.970	100.000	100.1	1
KU	C1S	2068413	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068414	07/2016	07/22/2016	100.010	100.040	100.1	1
KU	C1S	2068415	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068416	07/2016	07/22/2016	100.020	100.030	100.1	1
KU	C1S	2068417	07/2016	07/22/2016	100.060	100.020	100.0	1
KU	C1S	2068418	07/2016	07/22/2016	99.960	99.970	100.1	1
KU	C1S	2068419	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068420	07/2016	07/22/2016	100.020	99.950	100.0	1
KU	C1S	2068421	07/2016	07/22/2016	100.010	99.990	100.1	1
KU	C1S	2068422	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068423	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068424	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068425	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068426	07/2016	07/22/2016	100.040	99.970	100.0	1
KU	C1S	2068427	07/2016	07/22/2016	100.010	99.990	100.1	1
KU	C1S	2068428	07/2016	07/22/2016	100.050	99.970	100.0	1

KU	C1S	2068429	07/2016	07/22/2016	99.970	100.010	100.1	1
KU	C1S	2068430	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068431	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068432	07/2016	07/22/2016	99.970	99.980	100.0	1
KU	C1S	2068433	07/2016	07/22/2016	100.020	100.040	100.1	1
KU	C1S	2068434	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068435	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068436	07/2016	07/22/2016	100.030	99.970	100.0	1
KU	C1S	2068437	07/2016	07/22/2016	100.030	100.000	100.0	1
KU	C1S	2068438	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068439	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068440	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068441	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068442	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068443	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068444	07/2016	07/22/2016	99.970	100.020	100.0	1
KU	C1S	2068445	07/2016	07/22/2016	99.970	100.020	100.1	1
KU	C1S	2068446	07/2016	07/22/2016	99.980	100.030	100.1	1
KU	C1S	2068447	07/2016	07/22/2016	100.010	99.950	100.0	1
KU	C1S	2068448	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068449	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068450	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068451	07/2016	07/22/2016	99.990	100.020	100.1	1
KU	C1S	2068452	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068453	07/2016	07/22/2016	100.030	99.950	100.0	1
KU	C1S	2068454	07/2016	07/22/2016	100.050	100.000	100.0	1
KU	C1S	2068455	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068456	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068457	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068458	07/2016	07/22/2016	100.030	100.010	100.1	1
KU	C1S	2068459	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068460	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068461	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068462	07/2016	07/22/2016	99.980	99.940	100.0	1
KU	C1S	2068463	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068464	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068465	07/2016	07/22/2016	100.060	99.990	100.1	1
KU	C1S	2068466	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068467	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068468	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068469	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068470	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068471	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068472	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068473	07/2016	07/22/2016	100.000	99.990	100.1	1

KU	C1S	2068474	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068475	07/2016	07/22/2016	100.010	99.950	100.0	1
KU	C1S	2068476	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068477	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068478	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068479	07/2016	07/22/2016	99.970	100.010	100.1	1
KU	C1S	2068480	07/2016	07/22/2016	99.960	99.970	100.0	1
KU	C1S	2068481	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068482	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068483	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068484	07/2016	07/22/2016	99.990	100.060	100.1	1
KU	C1S	2068485	07/2016	07/22/2016	100.030	100.030	100.1	1
KU	C1S	2068486	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068487	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068488	07/2016	07/22/2016	99.950	100.010	100.0	1
KU	C1S	2068489	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068490	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068491	07/2016	07/22/2016	100.040	99.990	100.1	1
KU	C1S	2068492	07/2016	07/22/2016	99.960	100.030	100.1	1
KU	C1S	2068493	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068494	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068495	07/2016	07/22/2016	100.010	100.030	100.0	1
KU	C1S	2068496	07/2016	07/22/2016	99.990	99.950	100.0	1
KU	C1S	2068497	07/2016	07/22/2016	99.990	99.950	100.0	1
KU	C1S	2068498	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068499	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068500	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068501	07/2016	07/22/2016	99.980	99.990	100.0	1
KU	C1S	2068502	07/2016	07/22/2016	100.010	100.000	100.1	1
KU	C1S	2068503	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068504	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068505	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068506	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068507	07/2016	07/22/2016	100.030	99.960	100.0	1
KU	C1S	2068508	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068509	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068510	07/2016	07/22/2016	99.960	100.000	100.0	1
KU	C1S	2068511	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068512	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068513	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068514	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068515	07/2016	07/22/2016	99.980	99.950	100.0	1
KU	C1S	2068516	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068517	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068518	07/2016	07/22/2016	99.950	99.990	100.0	1

KU	C1S	2068519	07/2016	07/22/2016	100.020	99.970	100.0	1
KU	C1S	2068520	07/2016	07/22/2016	100.020	100.050	100.0	1
KU	C1S	2068521	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068522	07/2016	07/22/2016	100.030	99.960	100.0	1
KU	C1S	2068523	07/2016	07/22/2016	100.020	99.930	100.0	1
KU	C1S	2068524	07/2016	07/22/2016	99.980	99.980	100.1	1
KU	C1S	2068525	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068526	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068527	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068528	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068529	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068530	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068531	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068532	07/2016	07/22/2016	100.020	100.020	100.1	1
KU	C1S	2068533	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068534	07/2016	07/22/2016	99.990	99.940	100.0	1
KU	C1S	2068535	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068536	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068537	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068538	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068539	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068540	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068541	07/2016	07/22/2016	100.030	99.960	100.0	1
KU	C1S	2068542	07/2016	07/22/2016	100.000	100.010	100.1	1
KU	C1S	2068543	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068544	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068545	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068546	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068547	07/2016	07/22/2016	100.020	99.970	100.0	1
KU	C1S	2068548	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068549	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068550	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068551	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068552	07/2016	07/22/2016	99.970	100.020	100.1	1
KU	C1S	2068553	07/2016	07/22/2016	99.970	100.020	100.0	1
KU	C1S	2068554	07/2016	07/22/2016	100.000	100.020	100.1	1
KU	C1S	2068555	07/2016	07/22/2016	100.000	100.050	100.1	1
KU	C1S	2068556	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068557	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068558	07/2016	07/22/2016	99.990	99.950	100.0	1
KU	C1S	2068559	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068560	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068561	07/2016	07/22/2016	100.060	100.020	100.1	1
KU	C1S	2068562	07/2016	07/22/2016	100.010	100.040	100.1	1
KU	C1S	2068563	07/2016	07/22/2016	99.990	100.020	100.0	1

KU	C1S	2068564	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068565	07/2016	07/22/2016	99.980	99.980	100.1	1
KU	C1S	2068566	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068567	07/2016	07/22/2016	99.950	99.980	100.1	1
KU	C1S	2068568	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068569	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068570	07/2016	07/22/2016	100.030	99.930	100.0	1
KU	C1S	2068571	07/2016	07/22/2016	100.030	99.940	100.0	1
KU	C1S	2068572	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068573	07/2016	07/22/2016	100.060	99.970	100.1	1
KU	C1S	2068574	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068575	07/2016	07/22/2016	99.980	99.930	100.0	1
KU	C1S	2068576	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068577	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068578	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068579	07/2016	07/22/2016	100.020	100.000	100.1	1
KU	C1S	2068580	07/2016	07/22/2016	100.020	100.000	100.1	1
KU	C1S	2068581	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068582	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068583	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068584	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068585	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068586	07/2016	07/22/2016	100.010	99.970	100.1	1
KU	C1S	2068587	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068588	07/2016	07/22/2016	99.980	100.040	100.0	1
KU	C1S	2068589	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068590	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068591	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068592	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068593	07/2016	07/22/2016	99.980	99.980	100.1	1
KU	C1S	2068594	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068595	07/2016	07/22/2016	100.040	100.000	100.0	1
KU	C1S	2068596	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068597	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068598	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068599	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068600	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068601	07/2016	07/22/2016	100.000	99.940	100.0	1
KU	C1S	2068602	07/2016	07/22/2016	100.000	100.030	100.1	1
KU	C1S	2068603	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068604	07/2016	07/22/2016	99.970	100.030	100.0	1
KU	C1S	2068605	07/2016	07/22/2016	99.980	100.040	100.0	1
KU	C1S	2068606	07/2016	07/22/2016	100.000	99.960	100.0	1
KU	C1S	2068607	07/2016	07/22/2016	100.000	100.040	100.1	1
KU	C1S	2068608	07/2016	07/22/2016	100.000	100.000	100.0	1

KU	C1S	2068609	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068610	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068611	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068612	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068613	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068614	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068615	07/2016	07/22/2016	100.000	100.070	100.1	1
KU	C1S	2068616	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068617	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068618	07/2016	07/22/2016	99.970	100.060	100.1	1
KU	C1S	2068619	07/2016	07/22/2016	100.010	100.040	100.0	1
KU	C1S	2068620	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068621	07/2016	07/22/2016	99.970	99.950	100.0	1
KU	C1S	2068622	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068623	07/2016	07/22/2016	99.970	99.980	100.0	1
KU	C1S	2068624	07/2016	07/22/2016	100.010	100.070	100.0	1
KU	C1S	2068625	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068626	07/2016	07/22/2016	100.040	100.000	100.0	1
KU	C1S	2068627	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068628	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068629	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068630	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068631	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068632	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068633	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068634	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068635	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068636	07/2016	07/22/2016	100.030	99.960	100.0	1
KU	C1S	2068637	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068638	07/2016	07/22/2016	99.970	100.000	100.0	1
KU	C1S	2068639	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068640	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068641	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068642	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068643	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068644	07/2016	07/22/2016	99.980	100.030	100.1	1
KU	C1S	2068645	07/2016	07/22/2016	99.970	99.990	100.0	1
KU	C1S	2068646	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068647	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068648	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068649	07/2016	07/22/2016	100.020	100.020	100.1	1
KU	C1S	2068650	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068651	07/2016	07/22/2016	99.960	100.020	100.0	1
KU	C1S	2068652	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068653	07/2016	07/22/2016	99.990	99.990	100.1	1

KU	C1S	2068654	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068655	07/2016	07/22/2016	99.980	100.030	100.0	1
KU	C1S	2068656	07/2016	07/22/2016	100.020	100.030	100.1	1
KU	C1S	2068657	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068658	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068659	07/2016	07/22/2016	100.030	100.020	100.0	1
KU	C1S	2068660	07/2016	07/22/2016	100.030	100.040	100.0	1
KU	C1S	2068661	07/2016	07/22/2016	100.010	100.060	100.0	1
KU	C1S	2068662	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068663	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068664	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068665	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068666	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068667	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068668	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068669	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068670	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068671	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068672	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068673	07/2016	07/22/2016	99.990	99.970	100.1	1
KU	C1S	2068674	07/2016	07/22/2016	100.020	99.930	100.0	1
KU	C1S	2068675	07/2016	07/22/2016	100.000	99.990	100.1	1
KU	C1S	2068676	07/2016	07/22/2016	100.050	99.950	100.0	1
KU	C1S	2068677	07/2016	07/22/2016	99.980	99.970	100.0	1
KU	C1S	2068678	07/2016	07/22/2016	100.020	100.000	100.1	1
KU	C1S	2068679	07/2016	07/22/2016	99.980	99.970	100.0	1
KU	C1S	2068680	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068681	07/2016	07/22/2016	100.040	99.980	100.0	1
KU	C1S	2068682	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068683	07/2016	07/22/2016	99.960	100.010	100.0	1
KU	C1S	2068684	07/2016	07/22/2016	99.990	100.020	100.0	1
KU	C1S	2068685	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068686	07/2016	07/22/2016	100.030	99.980	100.0	1
KU	C1S	2068687	07/2016	07/22/2016	100.010	99.970	100.0	1
KU	C1S	2068688	07/2016	07/22/2016	99.990	99.990	100.0	1
KU	C1S	2068689	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068690	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068691	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068692	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068693	07/2016	07/22/2016	100.020	100.010	100.1	1
KU	C1S	2068694	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068695	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068696	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068697	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068698	07/2016	07/22/2016	99.970	100.010	100.1	1

KU	C1S	2068699	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068700	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068701	07/2016	07/22/2016	100.000	100.010	100.1	1
KU	C1S	2068702	07/2016	07/22/2016	99.970	99.990	100.1	1
KU	C1S	2068703	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068704	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068705	07/2016	07/22/2016	100.020	100.060	100.1	1
KU	C1S	2068706	07/2016	07/22/2016	99.990	100.010	100.1	1
KU	C1S	2068707	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068708	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068709	07/2016	07/22/2016	99.980	100.040	100.1	1
KU	C1S	2068710	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068711	07/2016	07/22/2016	100.000	100.000	100.1	1
KU	C1S	2068712	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068713	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068714	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068715	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068716	07/2016	07/22/2016	99.990	100.000	100.0	1
KU	C1S	2068717	07/2016	07/22/2016	100.020	99.960	100.0	1
KU	C1S	2068718	07/2016	07/22/2016	100.040	100.020	100.0	1
KU	C1S	2068719	07/2016	07/22/2016	100.060	100.010	100.0	1
KU	C1S	2068720	07/2016	07/22/2016	99.980	100.030	100.0	1
KU	C1S	2068721	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068722	07/2016	07/22/2016	100.010	100.000	100.1	1
KU	C1S	2068723	07/2016	07/22/2016	99.970	100.000	100.0	1
KU	C1S	2068724	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068725	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068726	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068727	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068728	07/2016	07/22/2016	100.040	100.000	100.1	1
KU	C1S	2068729	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068730	07/2016	07/22/2016	100.040	99.980	100.0	1
KU	C1S	2068731	07/2016	07/22/2016	99.990	100.030	100.1	1
KU	C1S	2068732	07/2016	07/22/2016	100.020	100.020	100.0	1
KU	C1S	2068733	07/2016	07/22/2016	99.990	99.960	100.0	1
KU	C1S	2068734	07/2016	07/22/2016	99.970	99.960	100.0	1
KU	C1S	2068735	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068736	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068737	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068738	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068739	07/2016	07/22/2016	99.970	100.030	100.0	1
KU	C1S	2068740	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068741	07/2016	07/22/2016	100.020	100.040	100.0	1
KU	C1S	2068742	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068743	07/2016	07/22/2016	100.010	100.010	100.0	1

KU	C1S	2068744	07/2016	07/22/2016	99.980	99.960	100.0	1
KU	C1S	2068745	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068746	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068747	07/2016	07/22/2016	99.950	100.000	100.0	1
KU	C1S	2068748	07/2016	07/22/2016	100.010	99.960	100.0	1
KU	C1S	2068749	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068750	07/2016	07/22/2016	100.030	100.030	100.1	1
KU	C1S	2068751	07/2016	07/22/2016	99.990	100.040	100.1	1
KU	C1S	2068752	07/2016	07/22/2016	100.030	99.970	100.0	1
KU	C1S	2068753	07/2016	07/22/2016	99.970	100.000	100.0	1
KU	C1S	2068754	07/2016	07/22/2016	100.020	100.000	100.0	1
KU	C1S	2068755	07/2016	07/22/2016	100.030	100.060	100.0	1
KU	C1S	2068756	07/2016	07/22/2016	100.030	100.020	100.1	1
KU	C1S	2068757	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068758	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068759	07/2016	07/22/2016	99.980	100.040	100.1	1
KU	C1S	2068760	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068761	07/2016	07/22/2016	100.000	100.010	100.1	1
KU	C1S	2068762	07/2016	07/22/2016	100.000	100.010	100.1	1
KU	C1S	2068763	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068764	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068765	07/2016	07/22/2016	99.980	100.040	100.0	1
KU	C1S	2068766	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068767	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068768	07/2016	07/22/2016	100.000	99.980	100.1	1
KU	C1S	2068769	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068770	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068771	07/2016	07/22/2016	99.960	99.990	100.0	1
KU	C1S	2068772	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068773	07/2016	07/22/2016	99.960	100.030	100.0	1
KU	C1S	2068774	07/2016	07/22/2016	99.960	100.020	100.0	1
KU	C1S	2068775	07/2016	07/22/2016	100.030	100.010	100.0	1
KU	C1S	2068776	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068777	07/2016	07/22/2016	100.000	100.020	100.1	1
KU	C1S	2068778	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068779	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068780	07/2016	07/22/2016	100.000	100.040	100.0	1
KU	C1S	2068781	07/2016	07/22/2016	99.960	99.980	100.0	1
KU	C1S	2068782	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068783	07/2016	07/22/2016	100.000	100.000	100.0	1
KU	C1S	2068784	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068785	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068786	07/2016	07/22/2016	99.980	100.060	100.1	1
KU	C1S	2068787	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068788	07/2016	07/22/2016	100.010	100.040	100.1	1

KU	C1S	2068789	07/2016	07/22/2016	99.980	100.040	100.0	1
KU	C1S	2068790	07/2016	07/22/2016	99.970	99.970	100.0	1
KU	C1S	2068791	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068792	07/2016	07/22/2016	100.020	99.990	100.0	1
KU	C1S	2068793	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068794	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068795	07/2016	07/22/2016	100.000	99.970	100.0	1
KU	C1S	2068796	07/2016	07/22/2016	100.030	99.990	100.0	1
KU	C1S	2068797	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068798	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068799	07/2016	07/22/2016	99.950	100.020	100.1	1
KU	C1S	2068800	07/2016	07/22/2016	99.970	99.980	100.0	1
KU	C1S	2068801	07/2016	07/22/2016	99.990	99.950	100.0	1
KU	C1S	2068802	07/2016	07/22/2016	100.020	100.070	100.1	1
KU	C1S	2068803	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068804	07/2016	07/22/2016	100.030	100.020	100.1	1
KU	C1S	2068805	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068806	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068807	07/2016	07/22/2016	99.980	100.010	100.1	1
KU	C1S	2068808	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068809	07/2016	07/22/2016	99.990	100.040	100.0	1
KU	C1S	2068810	07/2016	07/22/2016	99.990	100.030	100.1	1
KU	C1S	2068811	07/2016	07/22/2016	99.970	100.010	100.0	1
KU	C1S	2068812	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068813	07/2016	07/22/2016	99.990	100.030	100.0	1
KU	C1S	2068814	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068815	07/2016	07/22/2016	99.970	100.020	100.0	1
KU	C1S	2068816	07/2016	07/22/2016	100.020	100.020	100.0	1
KU	C1S	2068817	07/2016	07/22/2016	100.000	100.030	100.0	1
KU	C1S	2068818	07/2016	07/22/2016	99.980	99.980	100.0	1
KU	C1S	2068819	07/2016	07/22/2016	99.970	100.030	100.0	1
KU	C1S	2068820	07/2016	07/22/2016	100.010	100.040	100.1	1
KU	C1S	2068821	07/2016	07/22/2016	99.980	100.010	100.0	1
KU	C1S	2068822	07/2016	07/22/2016	100.010	99.990	100.0	1
KU	C1S	2068823	07/2016	07/22/2016	99.990	100.000	100.1	1
KU	C1S	2068824	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068825	07/2016	07/22/2016	99.990	99.970	100.0	1
KU	C1S	2068826	07/2016	07/22/2016	99.970	100.020	100.1	1
KU	C1S	2068827	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068828	07/2016	07/22/2016	100.010	100.010	100.1	1
KU	C1S	2068829	07/2016	07/22/2016	99.970	100.030	100.0	1
KU	C1S	2068830	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068831	07/2016	07/22/2016	99.980	100.020	100.1	1
KU	C1S	2068832	07/2016	07/22/2016	99.980	100.030	100.0	1
KU	C1S	2068833	07/2016	07/22/2016	100.010	100.000	100.0	1

KU	C1S	2068834	07/2016	07/22/2016	100.010	100.010	100.0	1
KU	C1S	2068835	07/2016	07/22/2016	100.000	100.020	100.0	1
KU	C1S	2068836	07/2016	07/22/2016	99.980	100.000	100.0	1
KU	C1S	2068837	07/2016	07/22/2016	100.010	100.030	100.1	1
KU	C1S	2068838	07/2016	07/22/2016	99.980	100.020	100.0	1
KU	C1S	2068839	07/2016	07/22/2016	99.990	99.980	100.0	1
KU	C1S	2068840	07/2016	07/22/2016	100.020	100.030	100.0	1
KU	C1S	2068841	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068842	07/2016	07/22/2016	100.000	99.990	100.0	1
KU	C1S	2068843	07/2016	07/22/2016	100.020	100.010	100.0	1
KU	C1S	2068844	07/2016	07/22/2016	100.010	99.950	100.0	1
KU	C1S	2068845	07/2016	07/22/2016	100.010	100.040	100.1	1
KU	C1S	2068846	07/2016	07/22/2016	100.010	100.020	100.1	1
KU	C1S	2068847	07/2016	07/22/2016	99.990	100.010	100.0	1
KU	C1S	2068848	07/2016	07/22/2016	99.980	99.990	100.1	1
KU	C1S	2068849	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068850	07/2016	07/22/2016	99.980	99.970	100.0	1
KU	C1S	2068851	07/2016	07/22/2016	100.020	100.030	100.1	1
KU	C1S	2068852	07/2016	07/22/2016	99.960	99.990	100.0	1
KU	C1S	2068853	07/2016	07/22/2016	100.000	99.980	100.0	1
KU	C1S	2068854	07/2016	07/22/2016	100.020	99.980	100.0	1
KU	C1S	2068855	07/2016	07/22/2016	100.010	99.980	100.0	1
KU	C1S	2068856	07/2016	07/22/2016	100.010	100.000	100.0	1
KU	C1S	2068857	07/2016	07/22/2016	100.000	99.970	100.1	1
KU	C1S	2068858	07/2016	07/22/2016	100.000	100.010	100.0	1
KU	C1S	2068859	07/2016	07/22/2016	100.010	100.020	100.0	1
KU	C1S	2068860	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2068861	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2068862	09/2016	09/21/2016	99.950	100.000	100.0	1
KU	C1S	2068863	09/2016	09/21/2016	100.030	100.040	100.1	1
KU	C1S	2068864	09/2016	09/21/2016	99.950	100.030	100.0	1
KU	C1S	2068865	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2068866	09/2016	09/21/2016	99.980	99.930	100.0	1
KU	C1S	2068867	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2068868	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2068869	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2068870	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068871	09/2016	09/21/2016	99.990	100.020	100.1	1
KU	C1S	2068872	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2068873	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2068874	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2068875	09/2016	09/21/2016	100.040	99.950	100.0	1
KU	C1S	2068876	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2068877	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2068878	09/2016	09/21/2016	100.000	100.000	100.0	1

KU	C1S	2068879	09/2016	09/21/2016	100.040	99.990	100.0	1
KU	C1S	2068880	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2068881	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2068882	09/2016	09/21/2016	100.050	100.000	100.1	1
KU	C1S	2068883	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2068884	09/2016	09/21/2016	100.020	100.010	100.1	1
KU	C1S	2068885	09/2016	09/21/2016	100.060	100.010	100.1	1
KU	C1S	2068886	09/2016	09/21/2016	100.030	99.940	100.0	1
KU	C1S	2068887	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2068888	09/2016	09/21/2016	100.040	99.960	100.1	1
KU	C1S	2068889	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2068890	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2068891	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2068892	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2068893	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2068894	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2068895	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2068896	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2068897	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2068898	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2068899	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2068900	09/2016	09/21/2016	100.020	99.940	100.0	1
KU	C1S	2068901	09/2016	09/21/2016	100.000	100.040	100.1	1
KU	C1S	2068902	09/2016	09/21/2016	100.000	100.010	100.1	1
KU	C1S	2068903	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2068904	09/2016	09/21/2016	100.000	99.980	100.1	1
KU	C1S	2068905	09/2016	09/21/2016	99.960	99.980	100.1	1
KU	C1S	2068906	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2068907	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2068908	09/2016	09/21/2016	99.960	99.990	100.1	1
KU	C1S	2068909	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068910	09/2016	09/21/2016	100.040	99.960	100.1	1
KU	C1S	2068911	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2068912	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2068913	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2068914	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2068915	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2068916	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2068917	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2068918	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2068919	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2068920	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2068921	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2068922	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2068923	09/2016	09/21/2016	100.000	100.010	100.0	1

KU	C1S	2068924	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2068925	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2068926	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2068927	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2068928	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2068929	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2068930	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2068931	09/2016	09/21/2016	100.010	99.960	100.1	1
KU	C1S	2068932	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2068933	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2068934	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2068935	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2068936	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2068937	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2068938	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2068939	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068940	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2068941	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2068942	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2068943	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068944	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2068945	09/2016	09/21/2016	100.000	99.990	100.1	1
KU	C1S	2068946	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2068947	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2068948	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2068949	09/2016	09/21/2016	100.000	99.990	100.1	1
KU	C1S	2068950	09/2016	09/21/2016	100.020	100.040	100.0	1
KU	C1S	2068951	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2068952	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2068953	09/2016	09/21/2016	100.010	99.980	100.1	1
KU	C1S	2068954	09/2016	09/21/2016	99.950	99.980	100.1	1
KU	C1S	2068955	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2068956	09/2016	09/21/2016	100.030	100.000	100.1	1
KU	C1S	2068957	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2068958	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2068959	09/2016	09/21/2016	100.030	100.030	100.1	1
KU	C1S	2068960	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2068961	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068962	09/2016	09/21/2016	100.040	99.960	100.0	1
KU	C1S	2068963	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2068964	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2068965	09/2016	09/21/2016	100.020	99.900	100.0	1
KU	C1S	2068966	09/2016	09/21/2016	100.050	99.970	100.0	1
KU	C1S	2068967	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2068968	09/2016	09/21/2016	99.990	99.950	100.0	1

KU	C1S	2068969	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2068970	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2068971	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2068972	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2068973	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2068974	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2068975	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2068976	09/2016	09/21/2016	100.020	99.930	100.0	1
KU	C1S	2068977	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2068978	09/2016	09/21/2016	100.020	99.990	100.1	1
KU	C1S	2068979	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2068980	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2068981	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2068982	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2068983	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2068984	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2068985	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2068986	09/2016	09/21/2016	99.990	100.030	100.1	1
KU	C1S	2068987	09/2016	09/21/2016	99.980	99.990	100.1	1
KU	C1S	2068988	09/2016	09/21/2016	100.040	100.030	100.0	1
KU	C1S	2068989	09/2016	09/21/2016	99.960	99.980	100.0	1
KU	C1S	2068990	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2068991	09/2016	09/21/2016	99.990	99.940	100.0	1
KU	C1S	2068992	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2068993	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2068994	09/2016	09/21/2016	100.020	99.930	100.0	1
KU	C1S	2068995	09/2016	09/21/2016	99.960	99.990	100.0	1
KU	C1S	2068996	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2068997	09/2016	09/21/2016	100.040	100.050	100.1	1
KU	C1S	2068998	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2068999	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069000	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069001	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069002	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069003	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069004	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069005	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069006	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069007	09/2016	09/21/2016	100.040	99.990	100.1	1
KU	C1S	2069008	09/2016	09/21/2016	100.020	100.030	100.1	1
KU	C1S	2069009	09/2016	09/21/2016	100.000	100.030	100.1	1
KU	C1S	2069010	09/2016	09/21/2016	99.990	100.030	100.0	1
KU	C1S	2069011	09/2016	09/21/2016	100.040	100.010	100.0	1
KU	C1S	2069012	09/2016	09/21/2016	100.040	100.000	100.0	1
KU	C1S	2069013	09/2016	09/21/2016	100.000	100.000	100.0	1

KU	C1S	2069014	09/2016	09/21/2016	100.040	99.970	100.0	1
KU	C1S	2069015	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069016	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069017	09/2016	09/21/2016	99.990	100.040	100.1	1
KU	C1S	2069018	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069019	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069020	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069021	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069022	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069023	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069024	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069025	09/2016	09/21/2016	100.030	99.990	100.1	1
KU	C1S	2069026	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069027	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069028	09/2016	09/21/2016	99.980	100.030	100.0	1
KU	C1S	2069029	09/2016	09/21/2016	100.060	99.960	100.0	1
KU	C1S	2069030	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069031	09/2016	09/21/2016	99.970	100.020	100.0	1
KU	C1S	2069032	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069033	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069034	09/2016	09/21/2016	99.960	100.000	100.0	1
KU	C1S	2069035	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069036	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2069037	09/2016	09/21/2016	99.990	99.940	100.0	1
KU	C1S	2069038	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069039	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069040	09/2016	09/21/2016	99.980	100.050	100.1	1
KU	C1S	2069041	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069042	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069043	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069044	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069045	09/2016	09/21/2016	99.980	100.030	100.1	1
KU	C1S	2069046	09/2016	09/21/2016	100.060	99.970	100.0	1
KU	C1S	2069047	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069048	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069049	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069050	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069051	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069052	09/2016	09/21/2016	99.960	99.970	100.0	1
KU	C1S	2069053	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069054	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069055	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069056	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069057	09/2016	09/21/2016	100.040	100.010	100.1	1
KU	C1S	2069058	09/2016	09/21/2016	99.980	100.000	100.0	1

2069059	09/2016	09/2016	99.990	100.030	100.010	100.0	1
2069060	09/2016	09/2016	100.030	100.000	100.000	100.0	1
2069061	09/2016	09/2016	99.970	100.030	100.1	100.1	1
2069062	09/2016	09/2016	99.980	99.980	100.030	100.0	1
2069063	09/2016	09/2016	99.980	100.010	100.010	100.0	1
2069064	09/2016	09/2016	99.960	100.010	100.010	100.1	1
2069065	09/2016	09/2016	100.030	100.030	99.950	100.0	1
2069066	09/2016	09/2016	100.000	100.000	99.970	100.0	1
2069067	09/2016	09/2016	99.980	100.000	100.000	100.0	1
2069068	09/2016	09/2016	99.980	99.980	99.950	100.0	1
2069069	09/2016	09/2016	99.980	99.980	99.960	100.0	1
2069070	09/2016	09/2016	100.020	100.020	100.000	100.0	1
2069071	09/2016	09/2016	100.020	100.000	99.970	100.0	1
2069072	09/2016	09/2016	100.000	100.000	100.010	100.0	1
2069073	09/2016	09/2016	99.990	99.990	99.930	100.0	1
2069074	09/2016	09/2016	100.040	100.040	99.960	100.0	1
2069075	09/2016	09/2016	99.990	100.010	100.010	100.0	1
2069076	09/2016	09/2016	99.990	100.040	100.040	100.0	1
2069077	09/2016	09/2016	99.980	99.980	99.970	100.0	1
2069078	09/2016	09/2016	100.020	100.020	99.980	100.0	1
2069079	09/2016	09/2016	100.000	100.000	99.990	100.0	1
2069080	09/2016	09/2016	100.010	100.010	100.020	100.1	1
2069081	09/2016	09/2016	100.010	100.010	100.010	100.0	1
2069082	09/2016	09/2016	99.980	99.980	99.990	100.0	1
2069083	09/2016	09/2016	100.010	100.010	100.030	100.1	1
2069084	09/2016	09/2016	99.990	99.990	99.980	100.0	1
2069085	09/2016	09/2016	100.030	100.030	100.020	100.1	1
2069086	09/2016	09/2016	99.990	99.990	99.980	100.0	1
2069087	09/2016	09/2016	99.990	100.000	100.000	100.0	1
2069088	09/2016	09/2016	100.030	100.030	99.960	100.0	1
2069089	09/2016	09/2016	99.980	100.020	100.020	100.0	1
2069090	09/2016	09/2016	100.010	100.010	100.000	100.0	1
2069091	09/2016	09/2016	100.010	100.010	99.980	100.0	1
2069092	09/2016	09/2016	100.020	100.020	100.010	100.0	1
2069093	09/2016	09/2016	100.030	100.030	100.000	100.0	1
2069094	09/2016	09/2016	100.010	100.010	99.970	100.0	1
2069095	09/2016	09/2016	100.010	100.010	100.010	100.0	1
2069096	09/2016	09/2016	100.000	100.000	99.990	100.0	1
2069097	09/2016	09/2016	100.000	100.000	99.980	100.0	1
2069098	09/2016	09/2016	100.030	100.030	100.010	100.0	1
2069099	09/2016	09/2016	99.940	100.000	100.000	100.0	1
2069100	09/2016	09/2016	99.990	99.990	99.990	100.0	1
2069101	09/2016	09/2016	99.990	99.990	100.040	100.0	1
2069102	09/2016	09/2016	99.980	99.980	99.990	100.0	1
2069103	09/2016	09/2016	100.030	100.030	100.010	100.0	1

KU	C1S	2069104	09/2016	09/21/2016	100.010	99.980	100.1	1
KU	C1S	2069105	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069106	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069107	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069108	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2069109	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069110	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069111	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069112	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069113	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069114	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069115	09/2016	09/21/2016	100.040	100.010	100.1	1
KU	C1S	2069116	09/2016	09/21/2016	100.010	100.000	100.1	1
KU	C1S	2069117	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069118	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069119	09/2016	09/21/2016	100.000	100.000	100.1	1
KU	C1S	2069120	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2069121	09/2016	09/21/2016	100.020	100.020	100.1	1
KU	C1S	2069122	09/2016	09/21/2016	99.970	100.010	100.0	1
KU	C1S	2069123	09/2016	09/21/2016	99.980	100.040	100.1	1
KU	C1S	2069124	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069125	09/2016	09/21/2016	100.060	100.040	100.1	1
KU	C1S	2069126	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2069127	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069128	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069129	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069130	09/2016	09/21/2016	100.000	100.040	100.1	1
KU	C1S	2069131	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069132	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069133	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069134	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069135	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069136	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069137	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069138	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069139	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069140	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069141	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069142	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069143	09/2016	09/21/2016	100.030	100.020	100.0	1
KU	C1S	2069144	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069145	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069146	09/2016	09/21/2016	100.000	100.030	100.0	1
KU	C1S	2069147	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069148	09/2016	09/21/2016	99.980	100.000	100.0	1

KU	C1S	2069149	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069150	09/2016	09/21/2016	100.030	100.020	100.0	1
KU	C1S	2069151	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2069152	09/2016	09/21/2016	100.000	100.000	100.1	1
KU	C1S	2069153	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069154	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069155	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069156	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069157	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069158	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069159	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069160	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069161	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069162	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069163	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069164	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069165	09/2016	09/21/2016	99.990	100.020	100.1	1
KU	C1S	2069166	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069167	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069168	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069169	09/2016	09/21/2016	99.990	100.030	100.1	1
KU	C1S	2069170	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069171	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069172	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069173	09/2016	09/21/2016	99.990	99.970	100.1	1
KU	C1S	2069174	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069175	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069176	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069177	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069178	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069179	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069180	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069181	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069182	09/2016	09/21/2016	100.030	99.950	100.0	1
KU	C1S	2069183	09/2016	09/21/2016	100.000	100.030	100.1	1
KU	C1S	2069184	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069185	09/2016	09/21/2016	100.000	100.030	100.0	1
KU	C1S	2069186	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069187	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069188	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069189	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069190	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069191	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069192	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069193	09/2016	09/21/2016	100.000	99.970	100.0	1

KU	C1S	2069194	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069195	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069196	09/2016	09/21/2016	99.980	99.950	99.9	1
KU	C1S	2069197	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069198	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069199	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069200	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069201	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069202	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069203	09/2016	09/21/2016	100.020	100.040	100.0	1
KU	C1S	2069204	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069205	09/2016	09/21/2016	100.040	99.950	100.0	1
KU	C1S	2069206	09/2016	09/21/2016	99.950	100.010	100.1	1
KU	C1S	2069207	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069208	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069209	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069210	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069211	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069212	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2069213	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069214	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069215	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069216	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069217	09/2016	09/21/2016	99.980	100.040	100.0	1
KU	C1S	2069218	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069219	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069220	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069221	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069222	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069223	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069224	09/2016	09/21/2016	100.040	100.000	100.0	1
KU	C1S	2069225	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069226	09/2016	09/21/2016	99.970	99.940	100.0	1
KU	C1S	2069227	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069228	09/2016	09/21/2016	100.050	99.930	100.0	1
KU	C1S	2069229	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069230	09/2016	09/21/2016	100.010	100.040	100.0	1
KU	C1S	2069231	09/2016	09/21/2016	100.020	100.020	100.1	1
KU	C1S	2069232	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069233	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069234	09/2016	09/21/2016	100.030	99.980	100.0	1
KU	C1S	2069235	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069236	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069237	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069238	09/2016	09/21/2016	99.950	100.000	100.0	1

KU	C1S	2069239	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069240	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069241	09/2016	09/21/2016	100.040	99.970	100.0	1
KU	C1S	2069242	09/2016	09/21/2016	100.040	100.020	100.1	1
KU	C1S	2069243	09/2016	09/21/2016	100.030	99.980	100.0	1
KU	C1S	2069244	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069245	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069246	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069247	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069248	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069249	09/2016	09/21/2016	100.000	100.010	100.1	1
KU	C1S	2069250	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069251	09/2016	09/21/2016	100.030	99.980	100.0	1
KU	C1S	2069252	09/2016	09/21/2016	99.970	100.010	100.0	1
KU	C1S	2069253	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069254	09/2016	09/21/2016	100.020	99.940	100.0	1
KU	C1S	2069255	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069256	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069257	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069258	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069259	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069260	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069261	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069262	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069263	09/2016	09/21/2016	99.970	100.010	100.0	1
KU	C1S	2069264	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069265	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069266	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069267	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069268	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069269	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069270	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069271	09/2016	09/21/2016	100.010	100.010	100.1	1
KU	C1S	2069272	09/2016	09/21/2016	100.000	100.010	100.1	1
KU	C1S	2069273	09/2016	09/21/2016	100.020	100.040	100.1	1
KU	C1S	2069274	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069275	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069276	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069277	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069278	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069279	09/2016	09/21/2016	100.040	100.010	100.0	1
KU	C1S	2069280	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069281	09/2016	09/21/2016	99.960	99.990	100.1	1
KU	C1S	2069282	09/2016	09/21/2016	99.950	99.980	100.0	1
KU	C1S	2069283	09/2016	09/21/2016	100.010	99.990	100.0	1

KU	C1S	2069284	09/2016	09/21/2016	99.980	99.930	100.0	1
KU	C1S	2069285	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069286	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069287	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069288	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069289	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069290	09/2016	09/21/2016	99.990	99.980	100.1	1
KU	C1S	2069291	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069292	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2069293	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069294	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069295	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069296	09/2016	09/21/2016	99.990	99.900	100.0	1
KU	C1S	2069297	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069298	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2069299	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069300	09/2016	09/21/2016	100.060	100.010	100.0	1
KU	C1S	2069301	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069302	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069303	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069304	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069305	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069306	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069307	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069308	09/2016	09/21/2016	100.040	99.970	100.0	1
KU	C1S	2069309	09/2016	09/21/2016	99.960	100.000	100.0	1
KU	C1S	2069310	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2069311	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069312	09/2016	09/21/2016	100.010	99.980	100.1	1
KU	C1S	2069313	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069314	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069315	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069316	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069317	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069318	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069319	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069320	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069321	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069322	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069323	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069324	09/2016	09/21/2016	100.030	100.020	100.0	1
KU	C1S	2069325	09/2016	09/21/2016	99.980	100.050	100.1	1
KU	C1S	2069326	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069327	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069328	09/2016	09/21/2016	99.990	99.990	100.1	1

KU	C1S	2069329	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069330	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069331	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069332	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069333	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2069334	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069335	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069336	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069337	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069338	09/2016	09/21/2016	100.040	99.960	100.0	1
KU	C1S	2069339	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069340	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069341	09/2016	09/21/2016	100.040	99.950	100.0	1
KU	C1S	2069342	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069343	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069344	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069345	09/2016	09/21/2016	99.950	100.010	100.1	1
KU	C1S	2069346	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069347	09/2016	09/21/2016	100.000	100.050	100.1	1
KU	C1S	2069348	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069349	09/2016	09/21/2016	99.990	100.020	100.1	1
KU	C1S	2069350	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069351	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069352	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2069353	09/2016	09/21/2016	100.000	100.030	100.0	1
KU	C1S	2069354	09/2016	09/21/2016	100.040	99.990	100.0	1
KU	C1S	2069355	09/2016	09/21/2016	100.000	99.940	100.0	1
KU	C1S	2069356	09/2016	09/21/2016	99.960	99.980	100.0	1
KU	C1S	2069357	09/2016	09/21/2016	99.970	100.020	100.1	1
KU	C1S	2069358	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069359	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069360	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069361	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069362	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069363	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069364	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069365	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069366	09/2016	09/21/2016	100.020	100.030	100.0	1
KU	C1S	2069367	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069368	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069369	09/2016	09/21/2016	100.020	99.940	100.0	1
KU	C1S	2069370	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069371	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069372	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069373	09/2016	09/21/2016	99.980	99.970	100.0	1

KU	C1S	2069374	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069375	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069376	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069377	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069378	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069379	09/2016	09/21/2016	99.950	100.020	100.0	1
KU	C1S	2069380	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069381	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069382	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069383	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069384	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069385	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069386	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2069387	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069388	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069389	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069390	09/2016	09/21/2016	99.970	100.020	100.0	1
KU	C1S	2069391	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069392	09/2016	09/21/2016	99.950	99.990	100.0	1
KU	C1S	2069393	09/2016	09/21/2016	100.010	100.030	100.0	1
KU	C1S	2069394	09/2016	09/21/2016	99.970	100.010	100.0	1
KU	C1S	2069395	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069396	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069397	09/2016	09/21/2016	99.960	100.010	100.0	1
KU	C1S	2069398	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069399	09/2016	09/21/2016	99.960	100.010	100.0	1
KU	C1S	2069400	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069401	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069402	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069403	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069404	09/2016	09/21/2016	99.970	99.990	100.1	1
KU	C1S	2069405	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069406	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069407	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069408	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069409	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069410	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069411	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069412	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069413	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069414	09/2016	09/21/2016	99.980	100.030	100.1	1
KU	C1S	2069415	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069416	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069417	09/2016	09/21/2016	100.040	100.040	100.1	1
KU	C1S	2069418	09/2016	09/21/2016	100.010	100.000	100.0	1

KU	C1S	2069419	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069420	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069421	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069422	09/2016	09/21/2016	100.020	99.990	100.1	1
KU	C1S	2069423	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069424	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069425	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069426	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069427	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069428	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069429	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069430	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069431	09/2016	09/21/2016	99.960	99.990	100.0	1
KU	C1S	2069432	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069433	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069434	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069435	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069436	09/2016	09/21/2016	100.000	100.010	100.1	1
KU	C1S	2069437	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069438	09/2016	09/21/2016	100.020	99.930	99.9	1
KU	C1S	2069439	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069440	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069441	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069442	09/2016	09/21/2016	100.030	100.030	100.1	1
KU	C1S	2069443	09/2016	09/21/2016	100.010	100.010	100.1	1
KU	C1S	2069444	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069445	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069446	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069447	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069448	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069449	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069450	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069451	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069452	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069453	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069454	09/2016	09/21/2016	100.010	100.000	100.1	1
KU	C1S	2069455	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069456	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069457	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069458	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069459	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069460	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069461	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2069462	09/2016	09/21/2016	100.010	100.030	100.0	1
KU	C1S	2069463	09/2016	09/21/2016	100.010	99.980	100.0	1

KU	C1S	2069464	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069465	09/2016	09/21/2016	100.000	100.000	100.1	1
KU	C1S	2069466	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069467	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069468	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069469	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069470	09/2016	09/21/2016	99.960	99.990	100.0	1
KU	C1S	2069471	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069472	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069473	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069474	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069475	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069476	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069477	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069478	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2069479	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069480	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069481	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069482	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2069483	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069484	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069485	09/2016	09/21/2016	100.010	100.010	100.1	1
KU	C1S	2069486	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069487	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069488	09/2016	09/21/2016	99.970	100.010	100.0	1
KU	C1S	2069489	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2069490	09/2016	09/21/2016	99.970	100.000	100.1	1
KU	C1S	2069491	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069492	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069493	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069494	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069495	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069496	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069497	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069498	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069499	09/2016	09/21/2016	99.980	100.020	100.1	1
KU	C1S	2069500	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069501	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069502	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069503	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069504	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069505	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069506	09/2016	09/21/2016	100.030	100.030	100.0	1
KU	C1S	2069507	09/2016	09/21/2016	100.030	99.950	100.0	1
KU	C1S	2069508	09/2016	09/21/2016	100.030	100.010	100.0	1

KU	C1S	2069509	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069510	09/2016	09/21/2016	100.000	99.960	100.1	1
KU	C1S	2069511	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069512	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069513	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069514	09/2016	09/21/2016	99.990	100.030	100.0	1
KU	C1S	2069515	09/2016	09/21/2016	99.990	99.920	100.0	1
KU	C1S	2069516	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069517	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069518	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069519	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069520	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069521	09/2016	09/21/2016	99.990	100.090	100.1	1
KU	C1S	2069522	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069523	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069524	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069525	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069526	09/2016	09/21/2016	100.050	99.930	100.0	1
KU	C1S	2069527	09/2016	09/21/2016	100.020	100.020	100.1	1
KU	C1S	2069528	09/2016	09/21/2016	100.020	100.030	100.1	1
KU	C1S	2069529	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069530	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069531	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069532	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069533	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2069534	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069535	09/2016	09/21/2016	100.000	99.990	100.1	1
KU	C1S	2069536	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069537	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069538	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069539	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069540	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069541	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2069542	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069543	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069544	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069545	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069546	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069547	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069548	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069549	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069550	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069551	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069552	09/2016	09/21/2016	99.990	99.940	100.0	1
KU	C1S	2069553	09/2016	09/21/2016	100.010	100.000	100.0	1

KU	C1S	2069554	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069555	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069556	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069557	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069558	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069559	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069560	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069561	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069562	09/2016	09/21/2016	100.040	100.020	100.0	1
KU	C1S	2069563	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069564	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069565	09/2016	09/21/2016	100.010	100.000	100.1	1
KU	C1S	2069566	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069567	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069568	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069569	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069570	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069571	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069572	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2069573	09/2016	09/21/2016	99.970	100.020	100.0	1
KU	C1S	2069574	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069575	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069576	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069577	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069578	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069579	09/2016	09/21/2016	100.020	100.010	100.1	1
KU	C1S	2069580	09/2016	09/21/2016	100.040	99.990	100.0	1
KU	C1S	2069581	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069582	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069583	09/2016	09/21/2016	99.960	99.970	100.0	1
KU	C1S	2069584	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069585	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069586	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069587	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069588	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069589	09/2016	09/21/2016	99.980	100.010	100.1	1
KU	C1S	2069590	09/2016	09/21/2016	100.030	99.960	100.1	1
KU	C1S	2069591	09/2016	09/21/2016	100.050	99.990	100.0	1
KU	C1S	2069592	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069593	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069594	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069595	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069596	09/2016	09/21/2016	100.030	100.020	100.0	1
KU	C1S	2069597	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069598	09/2016	09/21/2016	99.980	100.000	100.0	1

KU	C1S	2069599	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069600	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069601	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069602	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069603	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069604	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2069605	09/2016	09/21/2016	100.010	100.000	100.1	1
KU	C1S	2069606	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069607	09/2016	09/21/2016	100.040	99.940	100.0	1
KU	C1S	2069608	09/2016	09/21/2016	99.980	99.980	100.1	1
KU	C1S	2069609	09/2016	09/21/2016	100.030	100.000	100.1	1
KU	C1S	2069610	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069611	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069612	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069613	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069614	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069615	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069616	09/2016	09/21/2016	100.030	99.970	100.1	1
KU	C1S	2069617	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069618	09/2016	09/21/2016	99.970	99.990	100.1	1
KU	C1S	2069619	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069620	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069621	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069622	09/2016	09/21/2016	100.020	99.940	100.0	1
KU	C1S	2069623	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069624	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069625	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069626	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069627	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069628	09/2016	09/21/2016	100.010	99.990	100.1	1
KU	C1S	2069629	09/2016	09/21/2016	99.980	100.030	100.0	1
KU	C1S	2069630	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069631	09/2016	09/21/2016	99.970	99.990	100.1	1
KU	C1S	2069632	09/2016	09/21/2016	99.950	100.020	100.1	1
KU	C1S	2069633	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069634	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069635	09/2016	09/21/2016	100.050	100.010	100.0	1
KU	C1S	2069636	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069637	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069638	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069639	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069640	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069641	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069642	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2069643	09/2016	09/21/2016	100.010	99.980	100.0	1

KU	C1S	2069644	09/2016	09/21/2016	99.960	100.040	100.0	1
KU	C1S	2069645	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069646	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069647	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069648	09/2016	09/21/2016	99.990	99.980	100.1	1
KU	C1S	2069649	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069650	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069651	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069652	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069653	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069654	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069655	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069656	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069657	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069658	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069659	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069660	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069661	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069662	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069663	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069664	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069665	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069666	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069667	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069668	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069669	09/2016	09/21/2016	99.940	99.970	100.0	1
KU	C1S	2069670	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069671	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069672	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069673	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069674	09/2016	09/21/2016	100.010	99.930	100.0	1
KU	C1S	2069675	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069676	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069677	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069678	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069679	09/2016	09/21/2016	100.030	99.950	100.0	1
KU	C1S	2069680	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069681	09/2016	09/21/2016	99.990	99.940	100.0	1
KU	C1S	2069682	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069683	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069684	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069685	09/2016	09/21/2016	99.980	100.040	100.1	1
KU	C1S	2069686	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069687	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069688	09/2016	09/21/2016	100.000	99.950	100.0	1

KU	C1S	2069689	09/2016	09/21/2016	100.010	100.030	100.0	1
KU	C1S	2069690	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069691	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069692	09/2016	09/21/2016	99.960	99.940	100.0	1
KU	C1S	2069693	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069694	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069695	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069696	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069697	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069698	09/2016	09/21/2016	100.010	100.000	100.1	1
KU	C1S	2069699	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069700	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069701	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069702	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069703	09/2016	09/21/2016	99.990	100.040	100.1	1
KU	C1S	2069704	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069705	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069706	09/2016	09/21/2016	100.030	99.930	100.0	1
KU	C1S	2069707	09/2016	09/21/2016	99.970	99.930	100.0	1
KU	C1S	2069708	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069709	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069710	09/2016	09/21/2016	100.000	100.000	100.1	1
KU	C1S	2069711	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069712	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069713	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069714	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069715	09/2016	09/21/2016	99.950	99.970	100.0	1
KU	C1S	2069716	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069717	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069718	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069719	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069720	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069721	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069722	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069723	09/2016	09/21/2016	99.960	99.960	100.0	1
KU	C1S	2069724	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069725	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069726	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069727	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069728	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069729	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2069730	09/2016	09/21/2016	100.040	100.020	100.0	1
KU	C1S	2069731	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069732	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069733	09/2016	09/21/2016	100.040	99.980	100.0	1

KU	C1S	2069734	09/2016	09/21/2016	100.020	100.060	100.1	1
KU	C1S	2069735	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069736	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069737	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069738	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069739	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069740	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069741	09/2016	09/21/2016	100.000	99.940	100.0	1
KU	C1S	2069742	09/2016	09/21/2016	100.040	100.020	100.0	1
KU	C1S	2069743	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069744	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069745	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069746	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069747	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069748	09/2016	09/21/2016	99.990	100.020	100.1	1
KU	C1S	2069749	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069750	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069751	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069752	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069753	09/2016	09/21/2016	100.020	100.030	100.0	1
KU	C1S	2069754	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069755	09/2016	09/21/2016	100.000	100.040	100.1	1
KU	C1S	2069756	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069757	09/2016	09/21/2016	100.000	99.920	100.0	1
KU	C1S	2069758	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069759	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069760	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069761	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069762	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069763	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069764	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069765	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069766	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069767	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069768	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069769	09/2016	09/21/2016	100.030	100.030	100.0	1
KU	C1S	2069770	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069771	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2069772	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069773	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069774	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069775	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2069776	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069777	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2069778	09/2016	09/21/2016	99.990	100.030	100.0	1

KU	C1S	2069779	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069780	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069781	09/2016	09/21/2016	100.000	99.940	100.0	1
KU	C1S	2069782	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069783	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069784	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069785	09/2016	09/21/2016	100.010	99.940	99.9	1
KU	C1S	2069786	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069787	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069788	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069789	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069790	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069791	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069792	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069793	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069794	09/2016	09/21/2016	99.970	100.040	100.1	1
KU	C1S	2069795	09/2016	09/21/2016	100.010	100.010	100.1	1
KU	C1S	2069796	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069797	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069798	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069799	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069800	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069801	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069802	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069803	09/2016	09/21/2016	100.040	100.000	100.0	1
KU	C1S	2069804	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069805	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069806	09/2016	09/21/2016	100.020	99.930	100.0	1
KU	C1S	2069807	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069808	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069809	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069810	09/2016	09/21/2016	100.000	100.030	100.0	1
KU	C1S	2069811	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069812	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069813	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069814	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069815	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069816	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2069817	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069818	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069819	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2069820	09/2016	09/21/2016	100.010	99.950	100.0	1
KU	C1S	2069821	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069822	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069823	09/2016	09/21/2016	100.030	100.020	100.0	1

KU	C1S	2069824	09/2016	09/21/2016	99.980	99.950	100.0	1
KU	C1S	2069825	09/2016	09/21/2016	100.010	100.030	100.0	1
KU	C1S	2069826	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069827	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069828	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069829	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069830	09/2016	09/21/2016	99.970	100.030	100.1	1
KU	C1S	2069831	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069832	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069833	09/2016	09/21/2016	100.010	100.040	100.1	1
KU	C1S	2069834	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069835	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069836	09/2016	09/21/2016	100.030	99.950	100.0	1
KU	C1S	2069837	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069838	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069839	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069840	09/2016	09/21/2016	99.960	100.010	100.0	1
KU	C1S	2069841	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069842	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2069843	09/2016	09/21/2016	100.020	100.030	100.0	1
KU	C1S	2069844	09/2016	09/21/2016	100.000	100.000	100.1	1
KU	C1S	2069845	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069846	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069847	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2069848	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069849	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069850	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069851	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069852	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069853	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069854	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2069855	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069856	09/2016	09/21/2016	99.980	99.930	100.0	1
KU	C1S	2069857	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069858	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069859	09/2016	09/21/2016	100.020	100.030	100.1	1
KU	C1S	2069860	09/2016	09/21/2016	100.000	99.990	100.1	1
KU	C1S	2069861	09/2016	09/21/2016	99.970	100.020	100.0	1
KU	C1S	2069862	09/2016	09/21/2016	100.030	100.010	100.1	1
KU	C1S	2069863	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069864	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069865	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069866	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069867	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069868	09/2016	09/21/2016	100.000	99.990	100.0	1

KU	C1S	2069869	09/2016	09/21/2016	99.990	100.030	100.1	1
KU	C1S	2069870	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069871	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069872	09/2016	09/21/2016	99.990	100.030	100.0	1
KU	C1S	2069873	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2069874	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2069875	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069876	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2069877	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069878	09/2016	09/21/2016	100.060	100.020	100.1	1
KU	C1S	2069879	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069880	09/2016	09/21/2016	100.020	100.030	100.0	1
KU	C1S	2069881	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069882	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2069883	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2069884	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069885	09/2016	09/21/2016	99.960	99.960	100.1	1
KU	C1S	2069886	09/2016	09/21/2016	100.000	100.020	100.1	1
KU	C1S	2069887	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069888	09/2016	09/21/2016	99.960	99.990	100.0	1
KU	C1S	2069889	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2069890	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069891	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069892	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069893	09/2016	09/21/2016	99.980	99.990	100.1	1
KU	C1S	2069894	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069895	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069896	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069897	09/2016	09/21/2016	99.970	100.030	100.0	1
KU	C1S	2069898	09/2016	09/21/2016	100.030	100.000	100.1	1
KU	C1S	2069899	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069900	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069901	09/2016	09/21/2016	100.040	100.020	100.0	1
KU	C1S	2069902	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2069903	09/2016	09/21/2016	100.010	100.020	100.1	1
KU	C1S	2069904	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2069905	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069906	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069907	09/2016	09/21/2016	100.000	100.010	100.1	1
KU	C1S	2069908	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069909	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2069910	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2069911	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069912	09/2016	09/21/2016	100.020	100.000	100.1	1
KU	C1S	2069913	09/2016	09/21/2016	99.990	100.020	100.0	1

KU	C1S	2069914	09/2016	09/21/2016	99.990	100.010	100.1	1
KU	C1S	2069915	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069916	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069917	09/2016	09/21/2016	100.010	100.040	100.0	1
KU	C1S	2069918	09/2016	09/21/2016	99.960	99.970	100.0	1
KU	C1S	2069919	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069920	09/2016	09/21/2016	100.030	100.020	100.1	1
KU	C1S	2069921	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2069922	09/2016	09/21/2016	99.950	100.000	100.0	1
KU	C1S	2069923	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069924	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069925	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069926	09/2016	09/21/2016	100.030	99.990	100.0	1
KU	C1S	2069927	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2069928	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069929	09/2016	09/21/2016	100.000	100.020	100.0	1
KU	C1S	2069930	09/2016	09/21/2016	99.970	100.010	100.1	1
KU	C1S	2069931	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2069932	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069933	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069934	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069935	09/2016	09/21/2016	100.000	99.950	100.0	1
KU	C1S	2069936	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069937	09/2016	09/21/2016	100.000	100.000	100.0	1
KU	C1S	2069938	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069939	09/2016	09/21/2016	99.990	100.020	100.0	1
KU	C1S	2069940	09/2016	09/21/2016	99.950	99.970	100.0	1
KU	C1S	2069941	09/2016	09/21/2016	99.990	99.930	100.0	1
KU	C1S	2069942	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069943	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069944	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069945	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2069946	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2069947	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069948	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069949	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069950	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069951	09/2016	09/21/2016	99.980	100.010	100.0	1
KU	C1S	2069952	09/2016	09/21/2016	100.010	99.980	100.1	1
KU	C1S	2069953	09/2016	09/21/2016	100.050	99.990	100.0	1
KU	C1S	2069954	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069955	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069956	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069957	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2069958	09/2016	09/21/2016	100.020	99.970	100.0	1

KU	C1S	2069959	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2069960	09/2016	09/21/2016	100.000	100.010	100.0	1
KU	C1S	2069961	09/2016	09/21/2016	99.960	100.000	100.1	1
KU	C1S	2069962	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2069963	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069964	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2069965	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069966	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069967	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2069968	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069969	09/2016	09/21/2016	100.010	100.020	100.0	1
KU	C1S	2069970	09/2016	09/21/2016	100.030	99.980	100.0	1
KU	C1S	2069971	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2069972	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2069973	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069974	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069975	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2069976	09/2016	09/21/2016	100.020	100.020	100.1	1
KU	C1S	2069977	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2069978	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2069979	09/2016	09/21/2016	99.970	99.980	100.0	1
KU	C1S	2069980	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2069981	09/2016	09/21/2016	99.980	100.000	100.1	1
KU	C1S	2069982	09/2016	09/21/2016	100.030	99.980	100.0	1
KU	C1S	2069983	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2069984	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069985	09/2016	09/21/2016	99.970	100.000	100.1	1
KU	C1S	2069986	09/2016	09/21/2016	100.010	99.940	100.0	1
KU	C1S	2069987	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2069988	09/2016	09/21/2016	99.990	99.970	100.0	1
KU	C1S	2069989	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2069990	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2069991	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069992	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2069993	09/2016	09/21/2016	99.980	99.970	100.0	1
KU	C1S	2069994	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2069995	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2069996	09/2016	09/21/2016	99.990	99.980	99.9	1
KU	C1S	2069997	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2069998	09/2016	09/21/2016	100.050	99.980	100.0	1
KU	C1S	2069999	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2070000	09/2016	09/21/2016	99.970	99.990	100.0	1
KU	C1S	2070001	09/2016	09/21/2016	100.040	100.000	100.0	1
KU	C1S	2070002	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2070003	09/2016	09/21/2016	100.040	100.010	100.0	1

KU	C1S	2070004	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2070005	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070006	09/2016	09/21/2016	100.000	99.930	100.0	1
KU	C1S	2070007	09/2016	09/21/2016	100.030	100.020	100.0	1
KU	C1S	2070008	09/2016	09/21/2016	100.030	100.010	100.1	1
KU	C1S	2070009	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2070010	09/2016	09/21/2016	99.990	99.990	100.0	1
KU	C1S	2070011	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2070012	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070013	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070014	09/2016	09/21/2016	99.990	99.930	100.0	1
KU	C1S	2070015	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2070016	09/2016	09/21/2016	100.020	99.970	100.0	1
KU	C1S	2070017	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070018	09/2016	09/21/2016	99.970	100.000	100.0	1
KU	C1S	2070019	09/2016	09/21/2016	100.030	99.970	100.0	1
KU	C1S	2070020	09/2016	09/21/2016	100.010	99.960	100.0	1
KU	C1S	2070021	09/2016	09/21/2016	99.990	99.990	100.1	1
KU	C1S	2070022	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2070023	09/2016	09/21/2016	100.000	99.910	100.0	1
KU	C1S	2070024	09/2016	09/21/2016	99.990	100.000	100.1	1
KU	C1S	2070025	09/2016	09/21/2016	99.980	99.950	99.9	1
KU	C1S	2070026	09/2016	09/21/2016	99.980	100.020	100.0	1
KU	C1S	2070027	09/2016	09/21/2016	99.960	99.990	100.0	1
KU	C1S	2070028	09/2016	09/21/2016	100.030	99.960	100.0	1
KU	C1S	2070029	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070030	09/2016	09/21/2016	99.960	99.970	100.0	1
KU	C1S	2070031	09/2016	09/21/2016	100.010	99.970	100.0	1
KU	C1S	2070032	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070033	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070034	09/2016	09/21/2016	100.020	100.000	100.0	1
KU	C1S	2070035	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2070036	09/2016	09/21/2016	99.970	99.970	100.0	1
KU	C1S	2070037	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070038	09/2016	09/21/2016	100.010	100.010	100.0	1
KU	C1S	2070039	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2070040	09/2016	09/21/2016	100.050	100.010	100.0	1
KU	C1S	2070041	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070042	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2070043	09/2016	09/21/2016	99.990	99.960	100.0	1
KU	C1S	2070044	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2070045	09/2016	09/21/2016	100.010	100.000	100.0	1
KU	C1S	2070046	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2070047	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070048	09/2016	09/21/2016	99.950	100.000	100.0	1

KU	C1S	2070049	09/2016	09/21/2016	99.980	99.990	100.0	1
KU	C1S	2070050	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070051	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2070052	09/2016	09/21/2016	100.000	99.960	100.0	1
KU	C1S	2070053	09/2016	09/21/2016	100.030	99.950	100.0	1
KU	C1S	2070054	09/2016	09/21/2016	99.980	99.960	100.0	1
KU	C1S	2070055	09/2016	09/21/2016	100.020	100.030	100.0	1
KU	C1S	2070056	09/2016	09/21/2016	99.980	99.980	100.1	1
KU	C1S	2070057	09/2016	09/21/2016	100.000	99.970	100.0	1
KU	C1S	2070058	09/2016	09/21/2016	100.020	100.010	100.0	1
KU	C1S	2070059	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070060	09/2016	09/21/2016	99.960	100.000	100.0	1
KU	C1S	2070061	09/2016	09/21/2016	99.970	99.960	100.0	1
KU	C1S	2070062	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2070063	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2070064	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070065	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2070066	09/2016	09/21/2016	99.990	100.000	100.0	1
KU	C1S	2070067	09/2016	09/21/2016	100.020	99.980	100.0	1
KU	C1S	2070068	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070069	09/2016	09/21/2016	100.030	100.000	100.0	1
KU	C1S	2070070	09/2016	09/21/2016	100.030	99.960	99.9	1
KU	C1S	2070071	09/2016	09/21/2016	100.010	99.980	100.0	1
KU	C1S	2070072	09/2016	09/21/2016	99.950	100.010	100.0	1
KU	C1S	2070073	09/2016	09/21/2016	99.980	99.980	100.0	1
KU	C1S	2070074	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2070075	09/2016	09/21/2016	100.040	99.980	100.0	1
KU	C1S	2070076	09/2016	09/21/2016	99.990	100.010	100.0	1
KU	C1S	2070077	09/2016	09/21/2016	100.050	100.010	100.1	1
KU	C1S	2070078	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070079	09/2016	09/21/2016	100.030	100.030	100.0	1
KU	C1S	2070080	09/2016	09/21/2016	99.990	100.030	100.1	1
KU	C1S	2070081	09/2016	09/21/2016	100.050	99.990	100.1	1
KU	C1S	2070082	09/2016	09/21/2016	100.030	100.010	100.0	1
KU	C1S	2070083	09/2016	09/21/2016	99.990	99.980	100.0	1
KU	C1S	2070084	09/2016	09/21/2016	100.020	99.950	100.0	1
KU	C1S	2070085	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2070086	09/2016	09/21/2016	100.040	99.960	100.0	1
KU	C1S	2070087	09/2016	09/21/2016	100.000	99.990	100.0	1
KU	C1S	2070088	09/2016	09/21/2016	100.000	99.980	100.0	1
KU	C1S	2070089	09/2016	09/21/2016	100.020	99.990	100.0	1
KU	C1S	2070090	09/2016	09/21/2016	99.960	100.010	100.0	1
KU	C1S	2070091	09/2016	09/21/2016	100.010	99.990	100.0	1
KU	C1S	2070092	09/2016	09/21/2016	99.990	99.950	100.0	1
KU	C1S	2070093	09/2016	09/21/2016	100.010	99.970	100.0	1

KU	C1S	2070094	09/2016	09/21/2016	100.020	99.960	100.0	1
KU	C1S	2070095	09/2016	09/21/2016	100.030	99.990	100.1	1
KU	C1S	2070096	09/2016	09/21/2016	99.960	99.980	100.0	1
KU	C1S	2070097	09/2016	09/21/2016	100.020	99.990	100.1	1
KU	C1S	2070098	09/2016	09/21/2016	99.980	100.000	100.0	1
KU	C1S	2070099	09/2016	09/21/2016	100.010	100.030	100.1	1
KU	C1S	2070100	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2070101	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070102	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070103	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070104	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070105	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2070106	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070107	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2070108	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070109	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070110	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070111	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070112	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070113	10/2016	10/18/2016	99.990	99.980	100.1	1
KU	C1S	2070114	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070115	10/2016	10/18/2016	99.990	99.990	100.1	1
KU	C1S	2070116	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070117	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070118	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2070119	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070120	10/2016	10/18/2016	100.000	99.940	100.0	1
KU	C1S	2070121	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070122	10/2016	10/18/2016	100.010	99.940	100.0	1
KU	C1S	2070123	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070124	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070125	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2070126	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070127	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070128	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070129	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070130	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070131	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070132	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070133	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070134	10/2016	10/18/2016	99.990	99.980	100.1	1
KU	C1S	2070135	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070136	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2070137	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070138	10/2016	10/18/2016	99.990	99.990	100.0	1

KU	C1S	2070139	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070140	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070141	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070142	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070143	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2070144	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070145	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070146	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070147	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070148	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070149	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2070150	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070151	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070152	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2070153	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070154	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070155	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070156	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070157	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070158	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070159	10/2016	10/18/2016	99.970	99.960	100.1	1
KU	C1S	2070160	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070161	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070162	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070163	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2070164	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070165	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070166	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070167	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070168	10/2016	10/18/2016	100.000	99.970	100.1	1
KU	C1S	2070169	10/2016	10/18/2016	100.060	100.020	100.0	1
KU	C1S	2070170	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2070171	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070172	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070173	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070174	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070175	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070176	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070177	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070178	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070179	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070180	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070181	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070182	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070183	10/2016	10/18/2016	99.980	100.030	100.1	1

KU	C1S	2070184	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070185	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070186	10/2016	10/18/2016	99.950	99.960	100.0	1
KU	C1S	2070187	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2070188	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070189	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070190	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2070191	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070192	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070193	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070194	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070195	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070196	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070197	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070198	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070199	10/2016	10/18/2016	99.970	100.000	100.0	1
KU	C1S	2070200	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070201	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070202	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070203	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070204	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2070205	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070206	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070207	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070208	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070209	10/2016	10/18/2016	99.960	99.990	100.0	1
KU	C1S	2070210	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070211	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2070212	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2070213	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070214	10/2016	10/18/2016	99.990	99.980	100.1	1
KU	C1S	2070215	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070216	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2070217	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070218	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070219	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070220	10/2016	10/18/2016	100.040	100.030	100.0	1
KU	C1S	2070221	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070222	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070223	10/2016	10/18/2016	99.960	100.030	100.1	1
KU	C1S	2070224	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070225	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070226	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070227	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070228	10/2016	10/18/2016	100.000	100.030	100.0	1

KU	C1S	2070229	10/2016	10/18/2016	99.970	100.060	100.1	1
KU	C1S	2070230	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070231	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2070232	10/2016	10/18/2016	100.020	100.050	100.0	1
KU	C1S	2070233	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070234	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2070235	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070236	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070237	10/2016	10/18/2016	100.020	100.040	100.0	1
KU	C1S	2070238	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070239	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070240	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2070241	10/2016	10/18/2016	100.000	100.070	100.1	1
KU	C1S	2070242	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070243	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070244	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070245	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070246	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070247	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070248	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070249	10/2016	10/18/2016	99.970	100.030	100.1	1
KU	C1S	2070250	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070251	10/2016	10/18/2016	100.020	100.040	100.0	1
KU	C1S	2070252	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070253	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070254	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2070255	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070256	10/2016	10/18/2016	100.010	100.060	100.1	1
KU	C1S	2070257	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070258	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070259	10/2016	10/18/2016	99.990	100.060	100.1	1
KU	C1S	2070260	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070261	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070262	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2070263	10/2016	10/18/2016	100.000	100.050	100.0	1
KU	C1S	2070264	10/2016	10/18/2016	100.000	100.050	100.0	1
KU	C1S	2070265	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070266	10/2016	10/18/2016	99.970	100.060	100.1	1
KU	C1S	2070267	10/2016	10/18/2016	99.970	100.020	100.1	1
KU	C1S	2070268	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070269	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070270	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070271	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070272	10/2016	10/18/2016	99.980	100.050	100.1	1
KU	C1S	2070273	10/2016	10/18/2016	100.020	100.030	100.0	1

KU	C1S	2070274	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2070275	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070276	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2070277	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070278	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2070279	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070280	10/2016	10/18/2016	99.960	100.010	100.0	1
KU	C1S	2070281	10/2016	10/18/2016	100.030	100.010	100.1	1
KU	C1S	2070282	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070283	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070284	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070285	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070286	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070287	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2070288	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070289	10/2016	10/18/2016	100.030	100.060	100.1	1
KU	C1S	2070290	10/2016	10/18/2016	99.970	100.040	100.0	1
KU	C1S	2070291	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070292	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070293	10/2016	10/18/2016	99.970	100.050	100.1	1
KU	C1S	2070294	10/2016	10/18/2016	99.990	100.070	100.1	1
KU	C1S	2070295	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070296	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070297	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2070298	10/2016	10/18/2016	100.020	99.980	100.1	1
KU	C1S	2070299	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2070300	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070301	10/2016	10/18/2016	100.040	100.050	100.1	1
KU	C1S	2070302	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070303	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070304	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070305	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2070306	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070307	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2070308	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2070309	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2070310	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070311	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070312	10/2016	10/18/2016	100.000	100.010	100.1	1
KU	C1S	2070313	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070314	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070315	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070316	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2070317	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070318	10/2016	10/18/2016	99.990	100.010	100.0	1

KU	C1S	2070319	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2070320	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070321	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070322	10/2016	10/18/2016	100.000	100.060	100.1	1
KU	C1S	2070323	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070324	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070325	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070326	10/2016	10/18/2016	100.020	100.050	100.1	1
KU	C1S	2070327	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070328	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070329	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070330	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2070331	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070332	10/2016	10/18/2016	99.980	100.070	100.1	1
KU	C1S	2070333	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070334	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2070335	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070336	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070337	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2070338	10/2016	10/18/2016	100.000	99.940	100.1	1
KU	C1S	2070339	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070340	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070341	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070342	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070343	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2070344	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070345	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070346	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070347	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070348	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2070349	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070350	10/2016	10/18/2016	99.950	100.040	100.1	1
KU	C1S	2070351	10/2016	10/18/2016	99.990	100.050	100.1	1
KU	C1S	2070352	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070353	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070354	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2070355	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070356	10/2016	10/18/2016	99.980	100.060	100.1	1
KU	C1S	2070357	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2070358	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070359	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070360	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2070361	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070362	10/2016	10/18/2016	99.970	100.040	100.0	1
KU	C1S	2070363	10/2016	10/18/2016	99.980	100.030	100.1	1

KU	C1S	2070364	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070365	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070366	10/2016	10/18/2016	100.000	99.980	100.1	1
KU	C1S	2070367	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070368	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070369	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070370	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070371	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070372	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2070373	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070374	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070375	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070376	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070377	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2070378	10/2016	10/18/2016	99.950	100.030	100.0	1
KU	C1S	2070379	10/2016	10/18/2016	99.980	100.050	100.1	1
KU	C1S	2070380	10/2016	10/18/2016	99.990	100.050	100.0	1
KU	C1S	2070381	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070382	10/2016	10/18/2016	100.030	100.050	100.1	1
KU	C1S	2070383	10/2016	10/18/2016	100.000	100.050	100.0	1
KU	C1S	2070384	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070385	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070386	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070387	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070388	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070389	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070390	10/2016	10/18/2016	100.020	100.050	100.1	1
KU	C1S	2070391	10/2016	10/18/2016	100.020	100.040	100.0	1
KU	C1S	2070392	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070393	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070394	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070395	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070396	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070397	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070398	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070399	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070400	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070401	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070402	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070403	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070404	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070405	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070406	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070407	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070408	10/2016	10/18/2016	99.960	99.980	100.0	1

KU	C1S	2070409	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070410	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2070411	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070412	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070413	10/2016	10/18/2016	99.990	100.060	100.1	1
KU	C1S	2070414	10/2016	10/18/2016	99.970	100.040	100.1	1
KU	C1S	2070415	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070416	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2070417	10/2016	10/18/2016	100.010	100.060	100.1	1
KU	C1S	2070418	10/2016	10/18/2016	99.980	100.050	100.1	1
KU	C1S	2070419	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070420	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070421	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070422	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070423	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070424	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070425	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070426	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2070427	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070428	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070429	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070430	10/2016	10/18/2016	100.050	100.030	100.1	1
KU	C1S	2070431	10/2016	10/18/2016	100.010	99.940	100.0	1
KU	C1S	2070432	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070433	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070434	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070435	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2070436	10/2016	10/18/2016	99.980	100.050	100.0	1
KU	C1S	2070437	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2070438	10/2016	10/18/2016	99.970	100.030	100.1	1
KU	C1S	2070439	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070440	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070441	10/2016	10/18/2016	99.990	100.050	100.1	1
KU	C1S	2070442	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070443	10/2016	10/18/2016	100.020	99.980	100.1	1
KU	C1S	2070444	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2070445	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070446	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070447	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070448	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070449	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2070450	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070451	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070452	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070453	10/2016	10/18/2016	100.010	100.020	100.0	1

KU	C1S	2070454	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070455	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070456	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2070457	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2070458	10/2016	10/18/2016	100.050	100.000	100.1	1
KU	C1S	2070459	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070460	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070461	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2070462	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070463	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070464	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070465	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070466	10/2016	10/18/2016	99.980	100.010	100.1	1
KU	C1S	2070467	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2070468	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2070469	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070470	10/2016	10/18/2016	100.030	100.040	100.1	1
KU	C1S	2070471	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070472	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070473	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070474	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070475	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2070476	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070477	10/2016	10/18/2016	100.020	100.050	100.0	1
KU	C1S	2070478	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070479	10/2016	10/18/2016	100.000	100.060	100.1	1
KU	C1S	2070480	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070481	10/2016	10/18/2016	100.030	100.050	100.1	1
KU	C1S	2070482	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070483	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2070484	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070485	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070486	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070487	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070488	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2070489	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2070490	10/2016	10/18/2016	100.030	100.000	100.1	1
KU	C1S	2070491	10/2016	10/18/2016	100.030	100.030	100.1	1
KU	C1S	2070492	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070493	10/2016	10/18/2016	99.990	99.940	100.0	1
KU	C1S	2070494	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070495	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070496	10/2016	10/18/2016	100.030	100.010	100.1	1
KU	C1S	2070497	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070498	10/2016	10/18/2016	100.030	100.010	100.0	1

KU	C1S	2070499	10/2016	10/18/2016	100.030	99.960	100.0	-1
KU	C1S	2070500	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070501	10/2016	10/18/2016	100.010	99.990	100.0	-1
KU	C1S	2070502	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070503	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070504	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070505	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070506	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070507	10/2016	10/18/2016	100.020	100.060	100.0	-1
KU	C1S	2070508	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2070509	10/2016	10/18/2016	99.950	100.030	100.0	-1
KU	C1S	2070510	10/2016	10/18/2016	99.970	100.040	100.1	1
KU	C1S	2070511	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070512	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2070513	10/2016	10/18/2016	100.010	100.040	100.0	1
KU	C1S	2070514	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070515	10/2016	10/18/2016	99.980	100.000	100.0	-1
KU	C1S	2070516	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070517	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070518	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070519	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070520	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070521	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070522	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070523	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070524	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070525	10/2016	10/18/2016	100.030	99.990	100.1	1
KU	C1S	2070526	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070527	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2070528	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070529	10/2016	10/18/2016	99.970	99.960	100.0	-1
KU	C1S	2070530	10/2016	10/18/2016	100.040	99.970	100.0	1
KU	C1S	2070531	10/2016	10/18/2016	99.960	100.030	100.1	1
KU	C1S	2070532	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070533	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2070534	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2070535	10/2016	10/18/2016	100.010	99.990	100.1	1
KU	C1S	2070536	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070537	10/2016	10/18/2016	99.990	99.970	100.0	-1
KU	C1S	2070538	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070539	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070540	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2070541	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070542	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070543	10/2016	10/18/2016	100.000	100.020	100.0	1

KU	C1S	2070544	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2070545	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070546	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070547	10/2016	10/18/2016	100.040	99.970	100.0	1
KU	C1S	2070548	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070549	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070550	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070551	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070552	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2070553	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2070554	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2070555	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2070556	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070557	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070558	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070559	10/2016	10/18/2016	100.000	99.980	100.1	1
KU	C1S	2070560	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070561	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070562	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070563	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2070564	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2070565	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070566	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070567	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2070568	10/2016	10/18/2016	99.970	100.030	100.1	1
KU	C1S	2070569	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070570	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070571	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2070572	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070573	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2070574	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070575	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070576	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070577	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2070578	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070579	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070580	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070581	10/2016	10/18/2016	99.960	100.010	100.0	1
KU	C1S	2070582	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070583	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2070584	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2070585	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070586	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2070587	10/2016	10/18/2016	100.000	100.060	100.0	1
KU	C1S	2070588	10/2016	10/18/2016	100.010	100.010	100.1	1

KU	C1S	2070589	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070590	10/2016	10/18/2016	99.990	99.990	100.1	1
KU	C1S	2070591	10/2016	10/18/2016	100.020	99.990	100.1	1
KU	C1S	2070592	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070593	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070594	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070595	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070596	10/2016	10/18/2016	99.950	99.990	100.0	1
KU	C1S	2070597	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070598	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070599	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070600	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070601	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070602	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070603	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070604	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070605	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070606	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070607	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070608	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070609	10/2016	10/18/2016	100.040	100.000	100.1	1
KU	C1S	2070610	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070611	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070612	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070613	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070614	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070615	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070616	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070617	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2070618	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070619	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070620	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070621	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070622	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070623	10/2016	10/18/2016	99.980	100.050	100.1	1
KU	C1S	2070624	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070625	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070626	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070627	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070628	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070629	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2070630	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070631	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070632	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070633	10/2016	10/18/2016	99.980	99.960	100.0	1

KU	C1S	2070634	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070635	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070636	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070637	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070638	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070639	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070640	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070641	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070642	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2070643	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070644	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2070645	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070646	10/2016	10/18/2016	100.000	99.970	100.1	1
KU	C1S	2070647	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2070648	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070649	10/2016	10/18/2016	99.980	100.070	100.1	1
KU	C1S	2070650	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070651	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070652	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070653	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070654	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2070655	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2070656	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070657	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070658	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070659	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070660	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2070661	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2070662	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2070663	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2070664	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2070665	10/2016	10/18/2016	100.020	100.050	100.1	1
KU	C1S	2070666	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070667	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2070668	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070669	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070670	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070671	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2070672	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070673	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070674	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070675	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070676	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070677	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070678	10/2016	10/18/2016	99.980	100.010	100.0	1

KU	C1S	2070679	10/2016	10/18/2016	99.970	99.940	100.0	1
KU	C1S	2070680	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070681	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070682	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2070683	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070684	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2070685	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2070686	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070687	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2070688	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070689	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070690	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070691	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2070692	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070693	10/2016	10/18/2016	99.970	100.010	100.1	1
KU	C1S	2070694	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070695	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070696	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2070697	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2070698	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070699	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2070700	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070701	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070702	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070703	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070704	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2070705	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070706	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070707	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070708	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070709	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070710	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070711	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070712	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070713	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070714	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070715	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2070716	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070717	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070718	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070719	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070720	10/2016	10/18/2016	99.990	99.960	100.1	1
KU	C1S	2070721	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070722	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070723	10/2016	10/18/2016	100.010	100.000	100.1	1

KU	C1S	2070724	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070725	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2070726	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070727	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070728	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070729	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070730	10/2016	10/18/2016	99.950	100.050	100.0	1
KU	C1S	2070731	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070732	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070733	10/2016	10/18/2016	100.030	100.010	100.1	1
KU	C1S	2070734	10/2016	10/18/2016	99.980	100.010	100.1	1
KU	C1S	2070735	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070736	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2070737	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2070738	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070739	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070740	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070741	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070742	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070743	10/2016	10/18/2016	99.980	99.940	100.0	1
KU	C1S	2070744	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070745	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2070746	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070747	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070748	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2070749	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070750	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070751	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2070752	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070753	10/2016	10/18/2016	99.960	100.010	100.1	1
KU	C1S	2070754	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070755	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070756	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070757	10/2016	10/18/2016	99.970	100.000	100.0	1
KU	C1S	2070758	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2070759	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070760	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070761	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070762	10/2016	10/18/2016	99.930	100.000	100.0	1
KU	C1S	2070763	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2070764	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070765	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070766	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070767	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070768	10/2016	10/18/2016	100.010	100.000	100.0	1

KU	C1S	2070769	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070770	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070771	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2070772	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070773	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2070774	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070775	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070776	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070777	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070778	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070779	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070780	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2070781	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070782	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070783	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070784	10/2016	10/18/2016	99.980	99.970	100.1	1
KU	C1S	2070785	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2070786	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2070787	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070788	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070789	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070790	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070791	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070792	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070793	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070794	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070795	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070796	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2070797	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070798	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070799	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070800	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2070801	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070802	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070803	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070804	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070805	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070806	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070807	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070808	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070809	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070810	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2070811	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070812	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070813	10/2016	10/18/2016	99.990	100.010	100.0	1

KU	C1S	2070814	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070815	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070816	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070817	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070818	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070819	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070820	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070821	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070822	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070823	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070824	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070825	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070826	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070827	10/2016	10/18/2016	100.010	99.930	99.9	1
KU	C1S	2070828	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070829	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2070830	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070831	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070832	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2070833	10/2016	10/18/2016	99.990	100.050	100.0	1
KU	C1S	2070834	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2070835	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2070836	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070837	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070838	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070839	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070840	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070841	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070842	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070843	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070844	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070845	10/2016	10/18/2016	99.980	99.950	100.0	1
KU	C1S	2070846	10/2016	10/18/2016	100.020	99.990	100.1	1
KU	C1S	2070847	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070848	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070849	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070850	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070851	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070852	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070853	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070854	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070855	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070856	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2070857	10/2016	10/18/2016	100.010	99.990	100.1	1
KU	C1S	2070858	10/2016	10/18/2016	100.000	100.000	100.0	1

KU	C1S	2070859	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070860	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070861	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2070862	10/2016	10/18/2016	100.020	99.970	100.1	1
KU	C1S	2070863	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070864	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070865	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2070866	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070867	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2070868	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2070869	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2070870	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2070871	10/2016	10/18/2016	100.000	100.010	100.1	1
KU	C1S	2070872	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070873	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070874	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2070875	10/2016	10/18/2016	100.040	99.960	100.0	1
KU	C1S	2070876	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2070877	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2070878	10/2016	10/18/2016	99.980	99.950	100.0	1
KU	C1S	2070879	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070880	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070881	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070882	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070883	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070884	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2070885	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070886	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2070887	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2070888	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2070889	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2070890	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2070891	10/2016	10/18/2016	100.000	100.010	100.1	1
KU	C1S	2070892	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2070893	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070894	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070895	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070896	10/2016	10/18/2016	99.990	100.050	100.0	1
KU	C1S	2070897	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2070898	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2070899	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070900	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070901	10/2016	10/18/2016	100.010	100.040	100.0	1
KU	C1S	2070902	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2070903	10/2016	10/18/2016	99.980	100.010	100.0	1

KU	C1S	2070904	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070905	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070906	10/2016	10/18/2016	100.010	100.050	100.0	1
KU	C1S	2070907	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070908	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2070909	10/2016	10/18/2016	100.030	99.980	100.1	1
KU	C1S	2070910	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2070911	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070912	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2070913	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070914	10/2016	10/18/2016	100.050	100.020	100.1	1
KU	C1S	2070915	10/2016	10/18/2016	99.970	99.960	100.0	1
KU	C1S	2070916	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2070917	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2070918	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070919	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070920	10/2016	10/18/2016	100.020	99.940	100.0	1
KU	C1S	2070921	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2070922	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2070923	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070924	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2070925	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2070926	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2070927	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2070928	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070929	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070930	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2070931	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070932	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2070933	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2070934	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2070935	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2070936	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2070937	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070938	10/2016	10/18/2016	99.950	100.040	100.1	1
KU	C1S	2070939	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070940	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2070941	10/2016	10/18/2016	99.970	100.040	100.0	1
KU	C1S	2070942	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2070943	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2070944	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2070945	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2070946	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070947	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2070948	10/2016	10/18/2016	99.950	99.960	100.0	1

KU	C1S	2070949	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2070950	10/2016	10/18/2016	100.000	100.010	100.1	1
KU	C1S	2070951	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070952	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2070953	10/2016	10/18/2016	99.990	100.070	100.1	1
KU	C1S	2070954	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2070955	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2070956	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2070957	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2070958	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2070959	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070960	10/2016	10/18/2016	100.040	100.020	100.0	1
KU	C1S	2070961	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2070962	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070963	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2070964	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2070965	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2070966	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070967	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070968	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070969	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2070970	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2070971	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070972	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2070973	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2070974	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2070975	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2070976	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2070977	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2070978	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2070979	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2070980	10/2016	10/18/2016	100.010	100.190	100.0	1
KU	C1S	2070981	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070982	10/2016	10/18/2016	100.030	100.030	100.1	1
KU	C1S	2070983	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2070984	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070985	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2070986	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2070987	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2070988	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2070989	10/2016	10/18/2016	99.980	100.060	100.0	1
KU	C1S	2070990	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2070991	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2070992	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2070993	10/2016	10/18/2016	99.990	100.030	100.0	1

KU	C1S	2070994	10/2016	10/18/2016	100.020	100.050	100.0	1
KU	C1S	2070995	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2070996	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070997	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2070998	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2070999	10/2016	10/18/2016	100.040	100.010	100.0	1
KU	C1S	2071000	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071001	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071002	10/2016	10/18/2016	100.040	100.040	100.1	1
KU	C1S	2071003	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071004	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2071005	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071006	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071007	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2071008	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071009	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071010	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2071011	10/2016	10/18/2016	99.970	99.990	100.1	1
KU	C1S	2071012	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071013	10/2016	10/18/2016	100.040	100.050	100.0	1
KU	C1S	2071014	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071015	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071016	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2071017	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071018	10/2016	10/18/2016	100.010	100.040	100.0	1
KU	C1S	2071019	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071020	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071021	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071022	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071023	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071024	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071025	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2071026	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071027	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071028	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2071029	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071030	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071031	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071032	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071033	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071034	10/2016	10/18/2016	99.960	99.960	100.0	1
KU	C1S	2071035	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071036	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071037	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2071038	10/2016	10/18/2016	100.020	100.040	100.1	1

KU	C1S	2071039	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2071040	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071041	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071042	10/2016	10/18/2016	100.040	99.950	100.0	1
KU	C1S	2071043	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071044	10/2016	10/18/2016	99.950	100.010	100.0	1
KU	C1S	2071045	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2071046	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071047	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071048	10/2016	10/18/2016	99.970	99.960	100.0	1
KU	C1S	2071049	10/2016	10/18/2016	100.040	99.990	100.1	1
KU	C1S	2071050	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071051	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2071052	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071053	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071054	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2071055	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2071056	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2071057	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071058	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071059	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071060	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071061	10/2016	10/18/2016	100.030	99.980	100.1	1
KU	C1S	2071062	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071063	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2071064	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071065	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071066	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071067	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071068	10/2016	10/18/2016	100.040	99.980	100.0	1
KU	C1S	2071069	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2071070	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071071	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071072	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071073	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071074	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2071075	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071076	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2071077	10/2016	10/18/2016	99.990	99.990	100.1	1
KU	C1S	2071078	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2071079	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071080	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071081	10/2016	10/18/2016	99.970	99.960	100.0	1
KU	C1S	2071082	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071083	10/2016	10/18/2016	99.970	99.960	100.0	1

KU	C1S	2071084	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071085	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071086	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071087	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071088	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071089	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071090	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071091	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071092	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071093	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071094	10/2016	10/18/2016	99.960	100.000	100.1	1
KU	C1S	2071095	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071096	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071097	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071098	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2071099	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071100	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071101	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2071102	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071103	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071104	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2071105	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071106	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071107	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071108	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071109	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071110	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071111	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071112	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071113	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071114	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071115	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071116	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071117	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071118	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071119	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071120	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071121	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071122	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071123	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071124	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071125	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071126	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071127	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071128	10/2016	10/18/2016	99.990	100.000	100.1	1

KU	C1S	2071129	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2071130	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071131	10/2016	10/18/2016	99.950	100.030	100.1	1
KU	C1S	2071132	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071133	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071134	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071135	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071136	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071137	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071138	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071139	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071140	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071141	10/2016	10/18/2016	100.000	99.970	100.1	1
KU	C1S	2071142	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2071143	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071144	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071145	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2071146	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2071147	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071148	10/2016	10/18/2016	100.030	99.990	100.1	1
KU	C1S	2071149	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071150	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071151	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071152	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071153	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071154	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071155	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2071156	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071157	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071158	10/2016	10/18/2016	100.050	100.010	100.1	1
KU	C1S	2071159	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071160	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071161	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2071162	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071163	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071164	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071165	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071166	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071167	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2071168	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071169	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071170	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071171	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2071172	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071173	10/2016	10/18/2016	100.030	99.980	100.0	1

KU	C1S	2071174	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071175	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071176	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071177	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071178	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071179	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071180	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071181	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2071182	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071183	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071184	10/2016	10/18/2016	100.010	99.990	100.1	1
KU	C1S	2071185	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071186	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2071187	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071188	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071189	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071190	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071191	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071192	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071193	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071194	10/2016	10/18/2016	100.020	99.950	100.0	1
KU	C1S	2071195	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071196	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071197	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071198	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071199	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071200	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071201	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071202	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071203	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071204	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071205	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071206	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071207	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071208	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071209	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071210	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2071211	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071212	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071213	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071214	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071215	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071216	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071217	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071218	10/2016	10/18/2016	99.980	99.980	100.0	1

KU	C1S	2071219	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071220	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071221	10/2016	10/18/2016	100.040	100.040	100.0	1
KU	C1S	2071222	10/2016	10/18/2016	99.980	99.940	100.0	1
KU	C1S	2071223	10/2016	10/18/2016	99.990	99.940	100.0	1
KU	C1S	2071224	10/2016	10/18/2016	100.020	100.070	100.1	1
KU	C1S	2071225	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071226	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071227	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071228	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071229	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071230	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071231	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071232	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071233	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071234	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071235	10/2016	10/18/2016	100.000	99.980	100.1	1
KU	C1S	2071236	10/2016	10/18/2016	100.020	99.940	100.0	1
KU	C1S	2071237	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071238	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071239	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071240	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071241	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071242	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071243	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071244	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071245	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2071246	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071247	10/2016	10/18/2016	99.950	99.990	100.1	1
KU	C1S	2071248	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071249	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071250	10/2016	10/18/2016	100.040	100.020	100.0	1
KU	C1S	2071251	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2071252	10/2016	10/18/2016	100.000	100.060	100.0	1
KU	C1S	2071253	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071254	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071255	10/2016	10/18/2016	99.970	100.000	100.0	1
KU	C1S	2071256	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2071257	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071258	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071259	10/2016	10/18/2016	99.950	100.030	100.0	1
KU	C1S	2071260	10/2016	10/18/2016	99.970	100.020	100.1	1
KU	C1S	2071261	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071262	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071263	10/2016	10/18/2016	100.010	99.950	100.0	1

KU	C1S	2071264	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071265	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071266	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071267	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2071268	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071269	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071270	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071271	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071272	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2071273	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2071274	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071275	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071276	10/2016	10/18/2016	99.950	100.010	100.1	1
KU	C1S	2071277	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071278	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071279	10/2016	10/18/2016	99.950	100.000	100.0	1
KU	C1S	2071280	10/2016	10/18/2016	99.960	99.960	100.0	1
KU	C1S	2071281	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071282	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071283	10/2016	10/18/2016	99.990	100.060	100.0	1
KU	C1S	2071284	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071285	10/2016	10/18/2016	100.050	99.970	100.0	1
KU	C1S	2071286	10/2016	10/18/2016	100.040	99.970	100.0	1
KU	C1S	2071287	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071288	10/2016	10/18/2016	99.940	100.020	100.0	1
KU	C1S	2071289	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071290	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071291	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071292	10/2016	10/18/2016	100.040	100.010	100.0	1
KU	C1S	2071293	10/2016	10/18/2016	99.960	99.940	100.0	1
KU	C1S	2071294	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071295	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2071296	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071297	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071298	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071299	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071300	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071301	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071302	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071303	10/2016	10/18/2016	99.970	100.000	100.1	1
KU	C1S	2071304	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071305	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071306	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2071307	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071308	10/2016	10/18/2016	100.010	100.010	100.1	1

KU	C1S	2071309	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071310	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071311	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071312	10/2016	10/18/2016	100.010	100.000	100.1	1
KU	C1S	2071313	10/2016	10/18/2016	100.000	99.920	100.0	1
KU	C1S	2071314	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2071315	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2071316	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2071317	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2071318	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071319	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2071320	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071321	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071322	10/2016	10/18/2016	100.050	99.950	100.0	1
KU	C1S	2071323	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071324	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2071325	10/2016	10/18/2016	100.000	100.020	100.1	1
KU	C1S	2071326	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2071327	10/2016	10/18/2016	100.010	99.960	100.1	1
KU	C1S	2071328	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071329	10/2016	10/18/2016	99.980	99.960	100.1	1
KU	C1S	2071330	10/2016	10/18/2016	100.020	100.000	100.1	1
KU	C1S	2071331	10/2016	10/18/2016	99.970	99.960	100.1	1
KU	C1S	2071332	10/2016	10/18/2016	99.980	100.010	100.1	1
KU	C1S	2071333	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2071334	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2071335	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071336	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071337	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2071338	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071339	10/2016	10/18/2016	99.990	99.990	100.1	1
KU	C1S	2071340	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2071341	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2071342	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2071343	10/2016	10/18/2016	100.040	99.990	100.1	1
KU	C1S	2071344	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071345	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071346	10/2016	10/18/2016	100.040	99.980	100.1	1
KU	C1S	2071347	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071348	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071349	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071350	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2071351	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071352	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071353	10/2016	10/18/2016	100.000	100.020	100.1	1

KU	C1S	2071354	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071355	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071356	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071357	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071358	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071359	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071360	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2071361	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071362	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2071363	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071364	10/2016	10/18/2016	100.020	99.940	100.0	1
KU	C1S	2071365	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071366	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071367	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071368	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071369	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071370	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071371	10/2016	10/18/2016	100.010	100.020	99.9	1
KU	C1S	2071372	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2071373	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071374	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2071375	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071376	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071377	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071378	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071379	10/2016	10/18/2016	100.010	99.950	100.0	1
KU	C1S	2071380	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2071381	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071382	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071383	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071384	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071385	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2071386	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071387	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071388	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071389	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071390	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071391	10/2016	10/18/2016	99.980	99.940	100.0	1
KU	C1S	2071392	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2071393	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071394	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071395	10/2016	10/18/2016	99.980	99.940	100.0	1
KU	C1S	2071396	10/2016	10/18/2016	100.030	99.950	100.0	1
KU	C1S	2071397	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071398	10/2016	10/18/2016	99.980	100.010	100.0	1

KU	C1S	2071399	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071400	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071401	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071402	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071403	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071404	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071405	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2071406	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071407	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071408	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071409	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2071410	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071411	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071412	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071413	10/2016	10/18/2016	100.020	99.960	100.0	1
KU	C1S	2071414	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071415	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2071416	10/2016	10/18/2016	100.000	99.930	100.0	1
KU	C1S	2071417	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071418	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2071419	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071420	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2071421	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2071422	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2071423	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071424	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071425	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071426	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071427	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071428	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071429	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071430	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071431	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071432	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071433	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2071434	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071435	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071436	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071437	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071438	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071439	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071440	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071441	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071442	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071443	10/2016	10/18/2016	100.000	99.980	100.0	1

KU	C1S	2071444	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071445	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071446	10/2016	10/18/2016	100.040	99.980	100.0	1
KU	C1S	2071447	10/2016	10/18/2016	99.970	100.060	100.1	1
KU	C1S	2071448	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071449	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071450	10/2016	10/18/2016	99.960	99.990	100.0	1
KU	C1S	2071451	10/2016	10/18/2016	99.970	100.070	100.1	1
KU	C1S	2071452	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2071453	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071454	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071455	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071456	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071457	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071458	10/2016	10/18/2016	100.050	100.040	100.0	1
KU	C1S	2071459	10/2016	10/18/2016	100.000	100.060	100.0	1
KU	C1S	2071460	10/2016	10/18/2016	99.990	100.060	100.0	1
KU	C1S	2071461	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2071462	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071463	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071464	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071465	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071466	10/2016	10/18/2016	100.010	100.050	100.0	1
KU	C1S	2071467	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071468	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071469	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2071470	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071471	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071472	10/2016	10/18/2016	100.040	99.980	100.0	1
KU	C1S	2071473	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2071474	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071475	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071476	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071477	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2071478	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071479	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071480	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071481	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071482	10/2016	10/18/2016	99.960	100.030	100.0	1
KU	C1S	2071483	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071484	10/2016	10/18/2016	99.980	100.050	100.0	1
KU	C1S	2071485	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071486	10/2016	10/18/2016	100.030	100.030	100.1	1
KU	C1S	2071487	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071488	10/2016	10/18/2016	99.990	100.030	100.0	1

KU	C1S	2071489	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071490	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071491	10/2016	10/18/2016	100.030	100.050	100.0	1
KU	C1S	2071492	10/2016	10/18/2016	99.970	99.950	100.0	1
KU	C1S	2071493	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071494	10/2016	10/18/2016	100.000	100.030	100.1	1
KU	C1S	2071495	10/2016	10/18/2016	100.010	100.070	100.1	1
KU	C1S	2071496	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071497	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071498	10/2016	10/18/2016	100.040	100.010	100.1	1
KU	C1S	2071499	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071500	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071501	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2071502	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071503	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071504	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071505	10/2016	10/18/2016	99.950	99.980	100.0	1
KU	C1S	2071506	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071507	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071508	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071509	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071510	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071511	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071512	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071513	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071514	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071515	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071516	10/2016	10/18/2016	100.030	100.020	100.0	1
KU	C1S	2071517	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071518	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071519	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2071520	10/2016	10/18/2016	99.980	100.050	100.0	1
KU	C1S	2071521	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071522	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2071523	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2071524	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071525	10/2016	10/18/2016	99.960	99.990	100.0	1
KU	C1S	2071526	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071527	10/2016	10/18/2016	100.000	100.060	100.1	1
KU	C1S	2071528	10/2016	10/18/2016	99.990	100.050	100.1	1
KU	C1S	2071529	10/2016	10/18/2016	99.960	100.060	100.0	1
KU	C1S	2071530	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071531	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071532	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2071533	10/2016	10/18/2016	100.040	100.030	100.0	1

KU	C1S	2071534	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071535	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071536	10/2016	10/18/2016	99.980	99.960	100.0	1
KU	C1S	2071537	10/2016	10/18/2016	100.040	100.040	100.0	1
KU	C1S	2071538	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2071539	10/2016	10/18/2016	100.040	99.950	100.0	1
KU	C1S	2071540	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071541	10/2016	10/18/2016	99.970	99.970	100.0	1
KU	C1S	2071542	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071543	10/2016	10/18/2016	100.010	99.980	100.1	1
KU	C1S	2071544	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071545	10/2016	10/18/2016	99.980	99.990	100.0	1
KU	C1S	2071546	10/2016	10/18/2016	99.990	100.060	100.1	1
KU	C1S	2071547	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071548	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071549	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071550	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071551	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071552	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071553	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071554	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2071555	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2071556	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071557	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071558	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071559	10/2016	10/18/2016	100.040	100.030	100.1	1
KU	C1S	2071560	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071561	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071562	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071563	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071564	10/2016	10/18/2016	99.960	99.970	100.0	1
KU	C1S	2071565	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071566	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071567	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071568	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2071569	10/2016	10/18/2016	100.010	99.940	100.0	1
KU	C1S	2071570	10/2016	10/18/2016	99.950	100.020	100.0	1
KU	C1S	2071571	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071572	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071573	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071574	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071575	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2071576	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071577	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071578	10/2016	10/18/2016	99.980	99.990	100.0	1

KU	C1S	2071579	10/2016	10/18/2016	99.950	100.020	100.0	1
KU	C1S	2071580	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071581	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071582	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071583	10/2016	10/18/2016	99.950	99.990	100.0	1
KU	C1S	2071584	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071585	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071586	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071587	10/2016	10/18/2016	100.010	100.040	100.0	1
KU	C1S	2071588	10/2016	10/18/2016	100.040	100.020	100.1	1
KU	C1S	2071589	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071590	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071591	10/2016	10/18/2016	100.010	100.050	100.0	1
KU	C1S	2071592	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2071593	10/2016	10/18/2016	99.970	100.040	100.1	1
KU	C1S	2071594	10/2016	10/18/2016	100.020	99.980	100.1	1
KU	C1S	2071595	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071596	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2071597	10/2016	10/18/2016	100.000	99.960	100.0	1
KU	C1S	2071598	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2071599	10/2016	10/18/2016	100.010	100.070	100.1	1
KU	C1S	2071600	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071601	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2071602	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2071603	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071604	10/2016	10/18/2016	100.010	100.050	100.0	1
KU	C1S	2071605	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071606	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071607	10/2016	10/18/2016	99.980	100.050	100.0	1
KU	C1S	2071608	10/2016	10/18/2016	100.000	100.060	100.1	1
KU	C1S	2071609	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071610	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071611	10/2016	10/18/2016	100.030	99.950	100.0	1
KU	C1S	2071612	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2071613	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071614	10/2016	10/18/2016	100.030	99.970	100.0	1
KU	C1S	2071615	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071616	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071617	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071618	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071619	10/2016	10/18/2016	99.960	100.010	100.1	1
KU	C1S	2071620	10/2016	10/18/2016	99.970	99.980	100.0	1
KU	C1S	2071621	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071622	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071623	10/2016	10/18/2016	99.980	99.980	100.0	1

KU	C1S	2071624	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071625	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071626	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071627	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071628	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071629	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071630	10/2016	10/18/2016	99.950	100.010	100.0	1
KU	C1S	2071631	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071632	10/2016	10/18/2016	100.050	100.020	100.0	1
KU	C1S	2071633	10/2016	10/18/2016	99.970	100.010	100.1	1
KU	C1S	2071634	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2071635	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071636	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071637	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071638	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071639	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071640	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071641	10/2016	10/18/2016	99.960	100.010	100.1	1
KU	C1S	2071642	10/2016	10/18/2016	100.020	100.010	100.1	1
KU	C1S	2071643	10/2016	10/18/2016	99.970	99.950	100.0	1
KU	C1S	2071644	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2071645	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071646	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071647	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071648	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2071649	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071650	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071651	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071652	10/2016	10/18/2016	99.960	100.010	100.0	1
KU	C1S	2071653	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071654	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2071655	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2071656	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071657	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071658	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071659	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071660	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071661	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071662	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2071663	10/2016	10/18/2016	100.040	99.990	100.0	1
KU	C1S	2071664	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071665	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071666	10/2016	10/18/2016	100.020	100.040	100.0	1
KU	C1S	2071667	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071668	10/2016	10/18/2016	100.010	100.010	100.0	1

KU	C1S	2071669	10/2016	10/18/2016	99.970	100.030	100.1	1
KU	C1S	2071670	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2071671	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071672	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071673	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2071674	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071675	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071676	10/2016	10/18/2016	100.020	100.040	100.1	1
KU	C1S	2071677	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071678	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071679	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071680	10/2016	10/18/2016	99.960	100.010	100.0	1
KU	C1S	2071681	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071682	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071683	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071684	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071685	10/2016	10/18/2016	100.000	99.990	100.2	1
KU	C1S	2071686	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071687	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071688	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071689	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071690	10/2016	10/18/2016	99.970	100.000	100.1	1
KU	C1S	2071691	10/2016	10/18/2016	100.030	100.010	100.1	1
KU	C1S	2071692	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071693	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071694	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2071695	10/2016	10/18/2016	100.030	99.980	100.2	1
KU	C1S	2071696	10/2016	10/18/2016	99.990	99.980	100.1	1
KU	C1S	2071697	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071698	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071699	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2071700	10/2016	10/18/2016	100.040	100.040	100.1	1
KU	C1S	2071701	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071702	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071703	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071704	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071705	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071706	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071707	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071708	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071709	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071710	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071711	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071712	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071713	10/2016	10/18/2016	99.980	99.980	100.2	1

KU	C1S	2071714	10/2016	10/18/2016	100.010	100.050	100.1	1
KU	C1S	2071715	10/2016	10/18/2016	100.000	100.000	100.1	1
KU	C1S	2071716	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071717	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071718	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2071719	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071720	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071721	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2071722	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071723	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2071724	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2071725	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071726	10/2016	10/18/2016	99.930	99.990	100.0	1
KU	C1S	2071727	10/2016	10/18/2016	100.000	100.060	100.1	1
KU	C1S	2071728	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071729	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071730	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071731	10/2016	10/18/2016	99.980	100.050	100.1	1
KU	C1S	2071732	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2071733	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071734	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071735	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071736	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071737	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071738	10/2016	10/18/2016	99.970	100.030	100.0	1
KU	C1S	2071739	10/2016	10/18/2016	99.980	99.980	100.0	1
KU	C1S	2071740	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071741	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071742	10/2016	10/18/2016	99.980	100.010	100.1	1
KU	C1S	2071743	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071744	10/2016	10/18/2016	99.970	100.000	100.0	1
KU	C1S	2071745	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071746	10/2016	10/18/2016	100.020	100.050	100.1	1
KU	C1S	2071747	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071748	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071749	10/2016	10/18/2016	99.970	100.050	100.1	1
KU	C1S	2071750	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071751	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071752	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071753	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071754	10/2016	10/18/2016	100.040	100.010	100.0	1
KU	C1S	2071755	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071756	10/2016	10/18/2016	99.970	100.030	100.1	1
KU	C1S	2071757	10/2016	10/18/2016	100.000	100.050	100.1	1
KU	C1S	2071758	10/2016	10/18/2016	99.980	100.030	100.0	1

KU	C1S	2071759	10/2016	10/18/2016	99.980	100.000	100.1	1
KU	C1S	2071760	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071761	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2071762	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071763	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071764	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2071765	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071766	10/2016	10/18/2016	99.980	100.030	100.1	1
KU	C1S	2071767	10/2016	10/18/2016	100.060	100.000	100.0	1
KU	C1S	2071768	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071769	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071770	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071771	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071772	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071773	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071774	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2071775	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071776	10/2016	10/18/2016	100.020	99.990	100.1	1
KU	C1S	2071777	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071778	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071779	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2071780	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071781	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071782	10/2016	10/18/2016	100.000	100.040	100.0	1
KU	C1S	2071783	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071784	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071785	10/2016	10/18/2016	99.990	99.950	100.0	1
KU	C1S	2071786	10/2016	10/18/2016	99.960	100.040	100.0	1
KU	C1S	2071787	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071788	10/2016	10/18/2016	99.990	99.970	100.0	1
KU	C1S	2071789	10/2016	10/18/2016	100.030	100.000	100.1	1
KU	C1S	2071790	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2071791	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071792	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071793	10/2016	10/18/2016	100.040	100.020	100.0	1
KU	C1S	2071794	10/2016	10/18/2016	99.970	100.010	100.1	1
KU	C1S	2071795	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071796	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071797	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071798	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071799	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071800	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071801	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071802	10/2016	10/18/2016	100.000	99.990	100.1	1
KU	C1S	2071803	10/2016	10/18/2016	99.980	99.980	100.0	1

KU	C1S	2071804	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071805	10/2016	10/18/2016	99.990	99.960	100.0	1
KU	C1S	2071806	10/2016	10/18/2016	100.040	100.010	100.0	1
KU	C1S	2071807	10/2016	10/18/2016	99.990	100.040	100.1	1
KU	C1S	2071808	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071809	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071810	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071811	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071812	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2071813	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071814	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071815	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071816	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071817	10/2016	10/18/2016	100.040	99.970	100.0	1
KU	C1S	2071818	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071819	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071820	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071821	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071822	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071823	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2071824	10/2016	10/18/2016	100.040	100.000	100.0	1
KU	C1S	2071825	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2071826	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071827	10/2016	10/18/2016	99.980	99.970	100.0	1
KU	C1S	2071828	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071829	10/2016	10/18/2016	100.010	99.990	100.0	1
KU	C1S	2071830	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2071831	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071832	10/2016	10/18/2016	99.960	99.980	100.0	1
KU	C1S	2071833	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071834	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071835	10/2016	10/18/2016	99.960	99.990	100.0	1
KU	C1S	2071836	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071837	10/2016	10/18/2016	99.970	100.000	100.0	1
KU	C1S	2071838	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071839	10/2016	10/18/2016	100.010	100.040	100.0	1
KU	C1S	2071840	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071841	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071842	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071843	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071844	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071845	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071846	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071847	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071848	10/2016	10/18/2016	100.020	100.000	100.0	1

KU	C1S	2071849	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071850	10/2016	10/18/2016	100.010	100.030	100.1	1
KU	C1S	2071851	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071852	10/2016	10/18/2016	99.950	99.990	100.0	1
KU	C1S	2071853	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071854	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071855	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071856	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071857	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071858	10/2016	10/18/2016	100.020	99.970	100.0	1
KU	C1S	2071859	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071860	10/2016	10/18/2016	100.010	100.020	100.1	1
KU	C1S	2071861	10/2016	10/18/2016	99.960	100.000	100.0	1
KU	C1S	2071862	10/2016	10/18/2016	100.000	100.010	100.1	1
KU	C1S	2071863	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071864	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2071865	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071866	10/2016	10/18/2016	99.950	100.010	100.0	1
KU	C1S	2071867	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071868	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071869	10/2016	10/18/2016	99.980	100.000	100.0	1
KU	C1S	2071870	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071871	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071872	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071873	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2071874	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071875	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071876	10/2016	10/18/2016	100.010	99.960	100.0	1
KU	C1S	2071877	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071878	10/2016	10/18/2016	100.020	99.980	100.0	1
KU	C1S	2071879	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071880	10/2016	10/18/2016	99.970	99.960	100.0	1
KU	C1S	2071881	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071882	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071883	10/2016	10/18/2016	100.050	100.030	100.0	1
KU	C1S	2071884	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071885	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071886	10/2016	10/18/2016	100.030	99.980	100.0	1
KU	C1S	2071887	10/2016	10/18/2016	100.010	100.010	100.1	1
KU	C1S	2071888	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071889	10/2016	10/18/2016	99.970	99.990	100.0	1
KU	C1S	2071890	10/2016	10/18/2016	100.000	100.000	100.0	1
KU	C1S	2071891	10/2016	10/18/2016	99.990	100.020	100.1	1
KU	C1S	2071892	10/2016	10/18/2016	99.980	99.990	100.1	1
KU	C1S	2071893	10/2016	10/18/2016	100.000	100.010	100.1	1

KU	C1S	2071894	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071895	10/2016	10/18/2016	100.010	99.980	100.0	1
KU	C1S	2071896	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2071897	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2071898	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071899	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071900	10/2016	10/18/2016	100.020	99.990	100.0	1
KU	C1S	2071901	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071902	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071903	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2071904	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071905	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071906	10/2016	10/18/2016	100.020	100.020	100.1	1
KU	C1S	2071907	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071908	10/2016	10/18/2016	100.040	99.970	100.0	1
KU	C1S	2071909	10/2016	10/18/2016	99.950	100.010	100.0	1
KU	C1S	2071910	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2071911	10/2016	10/18/2016	99.980	100.040	100.1	1
KU	C1S	2071912	10/2016	10/18/2016	99.970	100.030	100.0	1
KU	C1S	2071913	10/2016	10/18/2016	99.990	99.990	100.0	1
KU	C1S	2071914	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071915	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071916	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2071917	10/2016	10/18/2016	100.000	100.040	100.1	1
KU	C1S	2071918	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071919	10/2016	10/18/2016	99.980	100.040	100.0	1
KU	C1S	2071920	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071921	10/2016	10/18/2016	100.010	99.970	100.0	1
KU	C1S	2071922	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2071923	10/2016	10/18/2016	100.040	100.020	100.0	1
KU	C1S	2071924	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071925	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2071926	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071927	10/2016	10/18/2016	100.020	100.040	100.0	1
KU	C1S	2071928	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071929	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071930	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071931	10/2016	10/18/2016	99.990	100.050	100.0	1
KU	C1S	2071932	10/2016	10/18/2016	99.980	100.020	100.0	1
KU	C1S	2071933	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071934	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2071935	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071936	10/2016	10/18/2016	100.010	99.980	100.1	1
KU	C1S	2071937	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2071938	10/2016	10/18/2016	99.970	100.030	100.0	1

KU	C1S	2071939	10/2016	10/18/2016	100.050	100.010	100.0	1
KU	C1S	2071940	10/2016	10/18/2016	100.010	100.040	100.1	1
KU	C1S	2071941	10/2016	10/18/2016	99.990	99.980	100.0	1
KU	C1S	2071942	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071943	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071944	10/2016	10/18/2016	99.970	100.020	100.0	1
KU	C1S	2071945	10/2016	10/18/2016	100.020	100.060	100.1	1
KU	C1S	2071946	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071947	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071948	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2071949	10/2016	10/18/2016	99.950	99.960	100.0	1
KU	C1S	2071950	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071951	10/2016	10/18/2016	99.950	100.040	100.0	1
KU	C1S	2071952	10/2016	10/18/2016	100.020	100.030	100.1	1
KU	C1S	2071953	10/2016	10/18/2016	99.990	100.000	100.1	1
KU	C1S	2071954	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071955	10/2016	10/18/2016	100.010	100.000	100.0	1
KU	C1S	2071956	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071957	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071958	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2071959	10/2016	10/18/2016	100.040	100.010	100.0	1
KU	C1S	2071960	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071961	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071962	10/2016	10/18/2016	100.030	100.020	100.1	1
KU	C1S	2071963	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2071964	10/2016	10/18/2016	99.990	100.030	100.1	1
KU	C1S	2071965	10/2016	10/18/2016	100.030	100.030	100.0	1
KU	C1S	2071966	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071967	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071968	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071969	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071970	10/2016	10/18/2016	100.020	100.060	100.0	1
KU	C1S	2071971	10/2016	10/18/2016	100.010	100.030	100.0	1
KU	C1S	2071972	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071973	10/2016	10/18/2016	100.000	99.980	100.0	1
KU	C1S	2071974	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071975	10/2016	10/18/2016	100.000	99.990	100.0	1
KU	C1S	2071976	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071977	10/2016	10/18/2016	100.020	100.000	100.0	1
KU	C1S	2071978	10/2016	10/18/2016	100.030	100.010	100.0	1
KU	C1S	2071979	10/2016	10/18/2016	99.980	100.010	100.1	1
KU	C1S	2071980	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2071981	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2071982	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071983	10/2016	10/18/2016	100.000	100.010	100.0	1

KU	C1S	2071984	10/2016	10/18/2016	99.990	100.010	100.0	1
KU	C1S	2071985	10/2016	10/18/2016	100.000	99.970	100.0	1
KU	C1S	2071986	10/2016	10/18/2016	99.980	100.030	100.0	1
KU	C1S	2071987	10/2016	10/18/2016	99.980	100.010	100.0	1
KU	C1S	2071988	10/2016	10/18/2016	100.030	99.990	100.0	1
KU	C1S	2071989	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2071990	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2071991	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2071992	10/2016	10/18/2016	99.970	100.010	100.0	1
KU	C1S	2071993	10/2016	10/18/2016	99.960	100.020	100.0	1
KU	C1S	2071994	10/2016	10/18/2016	100.040	99.950	100.0	1
KU	C1S	2071995	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2071996	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2071997	10/2016	10/18/2016	100.030	100.030	100.1	1
KU	C1S	2071998	10/2016	10/18/2016	100.060	100.010	100.0	1
KU	C1S	2071999	10/2016	10/18/2016	99.990	100.000	100.0	1
KU	C1S	2072000	10/2016	10/18/2016	99.950	100.010	100.0	1
KU	C1S	2072001	10/2016	10/18/2016	100.000	100.020	100.0	1
KU	C1S	2072002	10/2016	10/18/2016	100.010	100.020	100.0	1
KU	C1S	2072003	10/2016	10/18/2016	99.990	100.030	100.0	1
KU	C1S	2072004	10/2016	10/18/2016	99.960	100.040	100.0	1
KU	C1S	2072005	10/2016	10/18/2016	99.980	100.020	100.1	1
KU	C1S	2072006	10/2016	10/18/2016	100.030	100.000	100.0	1
KU	C1S	2072007	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2072008	10/2016	10/18/2016	99.990	100.040	100.0	1
KU	C1S	2072009	10/2016	10/18/2016	100.000	99.950	100.0	1
KU	C1S	2072010	10/2016	10/18/2016	99.990	100.010	100.1	1
KU	C1S	2072011	10/2016	10/18/2016	100.020	100.030	100.0	1
KU	C1S	2072012	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2072013	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2072014	10/2016	10/18/2016	100.000	100.010	100.0	1
KU	C1S	2072015	10/2016	10/18/2016	100.020	100.020	100.0	1
KU	C1S	2072016	10/2016	10/18/2016	100.000	100.030	100.0	1
KU	C1S	2072017	10/2016	10/18/2016	99.990	100.020	100.0	1
KU	C1S	2072018	10/2016	10/18/2016	100.020	100.010	100.0	1
KU	C1S	2072019	10/2016	10/18/2016	100.010	100.010	100.0	1
KU	C1S	2072260	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072261	08/2016	08/02/2016	99.990	99.970	100.0	1
KU	C1S	2072262	08/2016	08/02/2016	99.970	99.990	100.0	1
KU	C1S	2072263	08/2016	08/02/2016	99.970	100.000	100.0	1
KU	C1S	2072264	08/2016	08/02/2016	99.970	100.020	100.0	1
KU	C1S	2072265	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072266	08/2016	08/02/2016	99.970	99.960	100.0	1
KU	C1S	2072267	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072268	08/2016	08/02/2016	99.980	99.970	100.0	1

KU	C1S	2072269	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072270	08/2016	08/02/2016	99.980	100.020	100.0	1
KU	C1S	2072271	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072272	08/2016	08/02/2016	99.990	99.970	100.0	1
KU	C1S	2072273	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072274	08/2016	08/02/2016	99.990	100.010	99.9	1
KU	C1S	2072275	08/2016	08/02/2016	99.990	100.010	100.0	1
KU	C1S	2072276	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072277	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072278	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072279	08/2016	08/02/2016	99.980	99.970	100.0	1
KU	C1S	2072280	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072281	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072282	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072283	08/2016	08/02/2016	99.980	99.990	99.9	1
KU	C1S	2072284	08/2016	08/02/2016	99.970	99.990	100.0	1
KU	C1S	2072285	08/2016	08/02/2016	99.980	100.020	100.0	1
KU	C1S	2072286	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072287	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072288	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072289	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072290	08/2016	08/02/2016	99.970	99.970	100.0	1
KU	C1S	2072291	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072292	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072293	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072294	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072295	08/2016	08/02/2016	99.990	99.960	100.0	1
KU	C1S	2072296	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072297	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072298	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072299	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072300	08/2016	08/02/2016	99.980	100.020	100.0	1
KU	C1S	2072301	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072302	08/2016	08/02/2016	99.970	99.980	100.0	1
KU	C1S	2072303	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072304	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072305	08/2016	08/02/2016	99.980	99.970	100.0	1
KU	C1S	2072306	08/2016	08/02/2016	99.990	100.040	100.0	1
KU	C1S	2072307	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072308	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072309	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072310	08/2016	08/02/2016	99.980	99.970	100.0	1
KU	C1S	2072311	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072312	08/2016	08/02/2016	99.990	100.010	100.0	1
KU	C1S	2072313	08/2016	08/02/2016	99.980	100.000	100.0	1

KU	C1S	2072314	08/2016	08/02/2016	99.990	99.960	100.0	1
KU	C1S	2072315	08/2016	08/02/2016	99.990	100.020	100.0	1
KU	C1S	2072316	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072317	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072318	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072319	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072320	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072321	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072322	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072323	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072324	08/2016	08/02/2016	99.990	100.010	100.0	1
KU	C1S	2072325	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072326	08/2016	08/02/2016	99.970	99.960	100.0	1
KU	C1S	2072327	08/2016	08/02/2016	99.980	99.970	100.0	1
KU	C1S	2072328	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072329	08/2016	08/02/2016	99.990	100.010	100.0	1
KU	C1S	2072330	08/2016	08/02/2016	99.980	99.970	100.0	1
KU	C1S	2072331	08/2016	08/02/2016	99.980	99.960	100.0	1
KU	C1S	2072332	08/2016	08/02/2016	99.980	100.020	100.0	1
KU	C1S	2072333	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072334	08/2016	08/02/2016	99.990	100.030	100.0	1
KU	C1S	2072335	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072336	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072337	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072338	08/2016	08/02/2016	99.990	99.970	100.0	1
KU	C1S	2072339	08/2016	08/02/2016	99.970	100.000	100.0	1
KU	C1S	2072340	08/2016	08/02/2016	99.980	100.010	100.0	1
KU	C1S	2072341	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072342	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072343	08/2016	08/02/2016	99.990	100.020	100.0	1
KU	C1S	2072344	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072345	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072346	08/2016	08/02/2016	99.970	100.010	100.0	1
KU	C1S	2072347	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072348	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072349	08/2016	08/02/2016	99.980	100.020	100.0	1
KU	C1S	2072350	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072351	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072352	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072353	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072354	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072355	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072356	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072357	08/2016	08/02/2016	99.970	99.990	100.0	1
KU	C1S	2072358	08/2016	08/02/2016	99.980	100.000	100.0	1

KU	C1S	2072359	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072360	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072361	08/2016	08/02/2016	99.990	99.990	100.0	1
KU	C1S	2072362	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072363	08/2016	08/02/2016	99.990	100.040	100.0	1
KU	C1S	2072364	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1S	2072365	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072366	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072367	08/2016	08/02/2016	99.990	99.980	100.0	1
KU	C1S	2072368	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072369	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072370	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072371	08/2016	08/02/2016	99.980	100.010	100.1	1
KU	C1S	2072372	08/2016	08/02/2016	99.980	100.030	100.0	1
KU	C1S	2072373	08/2016	08/02/2016	99.990	100.000	100.0	1
KU	C1S	2072374	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072375	08/2016	08/02/2016	99.980	99.990	100.0	1
KU	C1S	2072376	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072377	08/2016	08/02/2016	99.980	99.980	100.0	1
KU	C1S	2072378	08/2016	08/02/2016	99.970	99.960	100.0	1
KU	C1S	2072379	08/2016	08/02/2016	99.980	100.000	100.0	1
KU	C1SR	2509931	04/2016	04/08/2016	100.010	100.020	100.0	1
KU	C1SR	2509932	04/2016	04/08/2016	99.980	100.020	100.0	1
KU	C1SR	2509933	04/2016	04/08/2016	99.990	100.010	100.0	1
KU	C1SR	2509934	04/2016	04/08/2016	99.980	99.970	100.0	1
KU	C1SR	2509935	04/2016	04/08/2016	99.980	100.010	100.0	1
KU	C1SR	2509936	04/2016	04/08/2016	100.000	99.950	100.0	1
KU	C1SR	2509937	04/2016	04/08/2016	99.990	100.030	100.0	1
KU	C1SR	2509938	04/2016	04/08/2016	100.010	100.020	100.0	1
KU	C1SR	2509939	04/2016	04/08/2016	100.000	100.010	100.0	1
KU	C1SR	2509940	04/2016	04/08/2016	99.970	100.000	100.0	1
KU	C1SR	2509941	04/2016	04/08/2016	99.980	100.040	100.0	1
KU	C1SR	2509942	04/2016	04/08/2016	99.990	100.040	100.0	1
KU	C1SR	2509943	04/2016	04/08/2016	100.010	100.000	100.0	1
KU	C1SR	2509944	04/2016	04/08/2016	100.040	100.040	100.1	1
KU	C1SR	2509945	04/2016	04/08/2016	100.020	100.010	100.0	1
KU	C1SR	2509946	04/2016	04/08/2016	99.990	99.990	100.0	1
KU	C1SR	2509947	04/2016	04/08/2016	100.010	100.060	100.0	1
KU	C1SR	2509948	04/2016	04/08/2016	99.990	100.000	100.0	1
KU	C1SR	2509949	04/2016	04/08/2016	100.000	100.000	100.0	1
KU	C1SR	2509950	04/2016	04/08/2016	100.010	100.000	100.0	1
KU	C1SR	2509951	04/2016	04/08/2016	99.980	100.000	100.1	1
KU	C1SR	2509952	04/2016	04/08/2016	100.010	100.040	100.1	1
KU	C1SR	2509953	04/2016	04/08/2016	99.980	100.030	100.1	1
KU	C1SR	2509954	04/2016	04/08/2016	99.980	100.040	100.1	1

KU	C1SR	2509955	04/2016	04/08/2016	100.010	100.060	100.0	1
KU	C1SR	2509956	04/2016	04/08/2016	100.010	100.030	100.0	1
KU	C1SR	2509957	04/2016	04/08/2016	99.970	100.050	100.1	1
KU	C1SR	2509958	04/2016	04/08/2016	99.960	100.050	100.1	1
KU	C1SR	2509959	04/2016	04/08/2016	100.020	100.030	100.0	1
KU	C1SR	2509960	04/2016	04/08/2016	99.950	100.030	100.0	1
KU	C1SR	2509961	04/2016	04/08/2016	100.000	100.020	100.1	1
KU	C1SR	2509962	04/2016	04/08/2016	100.000	100.010	100.0	1
KU	C1SR	2509963	04/2016	04/08/2016	100.050	100.040	100.1	1
KU	C1SR	2509964	04/2016	04/08/2016	100.010	100.070	100.1	1
KU	C1SR	2509965	04/2016	04/08/2016	100.020	100.040	100.1	1
KU	C1SR	2509966	04/2016	04/08/2016	99.990	100.020	100.0	1
KU	C1SR	2509967	04/2016	04/08/2016	99.970	100.030	100.0	1
KU	C1SR	2509968	04/2016	04/08/2016	100.000	100.030	100.0	1
KU	C1SR	2509969	04/2016	04/08/2016	100.020	100.040	100.1	1
KU	C1SR	2509970	04/2016	04/08/2016	100.000	100.060	100.1	1
KU	C1SR	2509971	04/2016	04/08/2016	100.010	100.020	100.0	1
KU	C1SR	2509972	04/2016	04/08/2016	99.990	100.030	100.1	1
KU	C1SR	2509973	04/2016	04/08/2016	100.000	100.050	100.1	1
KU	C1SR	2509974	04/2016	04/08/2016	100.010	100.050	100.1	1
KU	C1SR	2509975	04/2016	04/08/2016	100.020	100.030	100.1	1
KU	C1SR	2509976	04/2016	04/08/2016	100.010	99.980	100.0	1
KU	C1SR	2509977	04/2016	04/08/2016	100.010	100.030	100.0	1
KU	C1SR	2509978	04/2016	04/08/2016	99.990	100.050	100.0	1
KU	C1SR	2509979	04/2016	04/08/2016	100.020	100.040	100.1	1
KU	C1SR	2509980	04/2016	04/08/2016	99.950	100.020	100.1	1
KU	C1SR	2509981	04/2016	04/08/2016	99.970	100.060	100.0	1
KU	C1SR	2509982	04/2016	04/08/2016	100.000	100.020	100.0	1
KU	C1SR	2509983	04/2016	04/08/2016	100.010	100.050	100.1	1
KU	C1SR	2509984	04/2016	04/08/2016	99.970	100.060	100.1	1
KU	C1SR	2509985	04/2016	04/08/2016	100.020	100.010	100.0	1
KU	C1SR	2509986	04/2016	04/08/2016	99.990	100.000	100.0	1
KU	C1SR	2509987	04/2016	04/08/2016	100.030	100.030	100.1	1
KU	C1SR	2509988	04/2016	04/08/2016	99.980	100.040	100.1	1
KU	C1SR	2509989	04/2016	04/08/2016	100.010	100.020	100.0	1
KU	C1SR	2509990	04/2016	04/08/2016	99.990	100.030	100.0	1
KU	C1SR	2509991	04/2016	04/08/2016	100.030	100.040	100.0	1
KU	C1SR	2509992	04/2016	04/08/2016	99.970	100.010	100.0	1
KU	C1SR	2509993	04/2016	04/08/2016	99.990	100.060	100.1	1
KU	C1SR	2509994	04/2016	04/08/2016	100.010	100.030	100.1	1
KU	C1SR	2509995	04/2016	04/08/2016	100.010	99.960	100.0	1
KU	C1SR	2509996	04/2016	04/08/2016	100.010	100.010	100.0	1
KU	C1SR	2509997	04/2016	04/08/2016	100.010	100.020	100.1	1
KU	C1SR	2509998	04/2016	04/08/2016	99.980	100.050	100.0	1
KU	C1SR	2509999	04/2016	04/08/2016	99.990	100.030	100.0	1

KU	C1SR	2510000	04/2016	04/08/2016	100.030	100.070	100.0	1
KU	C1SR	2510001	04/2016	04/08/2016	99.990	100.040	100.1	1
KU	C1SR	2510002	04/2016	04/08/2016	99.980	100.050	100.1	1
KU	C1SR	2510003	04/2016	04/08/2016	100.020	100.000	100.1	1
KU	C1SR	2510004	04/2016	04/08/2016	99.990	100.070	100.1	1
KU	C1SR	2510005	04/2016	04/08/2016	100.030	100.000	100.1	1
KU	C1SR	2510006	04/2016	04/08/2016	100.000	100.080	100.1	1
KU	C1SR	2510007	04/2016	04/08/2016	99.970	100.030	100.0	1
KU	C1SR	2510008	04/2016	04/08/2016	100.000	100.050	100.1	1
KU	C1SR	2510009	04/2016	04/08/2016	99.980	100.050	100.1	1
KU	C1SR	2510010	04/2016	04/08/2016	100.010	100.030	100.0	1
KU	C1SR	2510011	04/2016	04/08/2016	99.990	100.050	100.1	1
KU	C1SR	2510012	04/2016	04/08/2016	99.990	100.040	100.0	1
KU	C1SR	2510013	04/2016	04/08/2016	100.010	99.970	100.0	1
KU	C1SR	2510014	04/2016	04/08/2016	100.000	100.060	100.1	1
KU	C1SR	2510015	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510016	04/2016	04/08/2016	100.030	100.020	100.0	1
KU	C1SR	2510017	04/2016	04/08/2016	100.010	99.990	100.0	1
KU	C1SR	2510018	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510019	04/2016	04/08/2016	99.950	100.030	100.1	1
KU	C1SR	2510020	04/2016	04/08/2016	100.010	100.040	100.0	1
KU	C1SR	2510021	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510022	04/2016	04/08/2016	100.020	100.040	100.1	1
KU	C1SR	2510023	04/2016	04/08/2016	100.000	100.050	100.1	1
KU	C1SR	2510024	04/2016	04/08/2016	100.020	100.020	100.0	1
KU	C1SR	2510025	04/2016	04/08/2016	99.980	100.010	100.0	1
KU	C1SR	2510026	04/2016	04/08/2016	99.970	100.010	100.1	1
KU	C1SR	2510027	04/2016	04/08/2016	99.990	100.090	100.1	1
KU	C1SR	2510028	04/2016	04/08/2016	100.030	100.010	100.0	1
KU	C1SR	2510029	04/2016	04/08/2016	99.970	100.070	100.1	1
KU	C1SR	2510030	04/2016	04/08/2016	100.020	99.950	100.0	1
KU	C1SR	2510031	04/2016	04/08/2016	100.000	100.040	100.1	1
KU	C1SR	2510032	04/2016	04/08/2016	100.000	100.010	100.0	1
KU	C1SR	2510033	04/2016	04/08/2016	99.990	100.050	100.1	1
KU	C1SR	2510034	04/2016	04/08/2016	99.950	100.070	100.0	1
KU	C1SR	2510035	04/2016	04/08/2016	99.980	100.020	100.0	1
KU	C1SR	2510036	04/2016	04/08/2016	99.990	100.050	100.0	1
KU	C1SR	2510037	04/2016	04/08/2016	99.990	100.040	100.0	1
KU	C1SR	2510038	04/2016	04/08/2016	100.020	100.000	100.1	1
KU	C1SR	2510039	04/2016	04/08/2016	99.970	100.020	100.0	1
KU	C1SR	2510040	04/2016	04/08/2016	99.990	100.020	100.1	1
KU	C1SR	2510041	04/2016	04/08/2016	100.020	100.030	100.1	1
KU	C1SR	2510042	04/2016	04/08/2016	100.010	100.000	100.0	1
KU	C1SR	2510043	04/2016	04/08/2016	99.990	100.040	100.1	1
KU	C1SR	2510044	04/2016	04/08/2016	100.000	100.010	100.0	1

KU	C1SR	2510045	04/2016	04/08/2016	100.000	100.020	100.0	1
KU	C1SR	2510046	04/2016	04/08/2016	100.000	100.020	100.0	1
KU	C1SR	2510047	04/2016	04/08/2016	99.990	100.000	100.0	1
KU	C1SR	2510048	04/2016	04/08/2016	99.990	100.000	100.0	1
KU	C1SR	2510049	04/2016	04/08/2016	99.970	100.070	100.1	1
KU	C1SR	2510050	04/2016	04/08/2016	100.000	100.000	100.0	1
KU	C1SR	2510051	04/2016	04/08/2016	99.990	100.030	100.1	1
KU	C1SR	2510052	04/2016	04/08/2016	100.020	100.030	100.1	1
KU	C1SR	2510053	04/2016	04/08/2016	100.020	100.030	100.0	1
KU	C1SR	2510054	04/2016	04/08/2016	100.010	100.040	100.0	1
KU	C1SR	2510055	04/2016	04/08/2016	100.000	100.020	100.0	1
KU	C1SR	2510056	04/2016	04/08/2016	100.040	100.030	100.0	1
KU	C1SR	2510057	04/2016	04/08/2016	100.030	100.010	100.1	1
KU	C1SR	2510058	04/2016	04/08/2016	100.000	100.030	100.0	1
KU	C1SR	2510059	04/2016	04/08/2016	100.010	100.030	100.1	1
KU	C1SR	2510060	04/2016	04/08/2016	99.990	100.040	100.0	1
KU	C1SR	2510061	04/2016	04/08/2016	100.000	100.010	100.1	1
KU	C1SR	2510062	04/2016	04/08/2016	100.020	99.980	100.0	1
KU	C1SR	2510063	04/2016	04/08/2016	100.030	100.030	100.0	1
KU	C1SR	2510064	04/2016	04/08/2016	99.960	100.030	100.0	1
KU	C1SR	2510065	04/2016	04/08/2016	99.990	100.070	100.1	1
KU	C1SR	2510066	04/2016	04/08/2016	100.040	100.040	100.0	1
KU	C1SR	2510067	04/2016	04/08/2016	100.000	100.040	100.1	1
KU	C1SR	2510068	04/2016	04/08/2016	100.030	100.040	100.0	1
KU	C1SR	2510069	04/2016	04/08/2016	100.020	100.000	100.0	1
KU	C1SR	2510070	04/2016	04/08/2016	99.990	100.040	100.0	1
KU	C1SR	2510071	04/2016	04/08/2016	100.030	100.050	100.1	1
KU	C1SR	2510072	04/2016	04/08/2016	100.000	100.000	100.1	1
KU	C1SR	2510073	04/2016	04/08/2016	100.000	100.050	100.1	1
KU	C1SR	2510074	04/2016	04/08/2016	99.990	100.050	100.1	1
KU	C1SR	2510075	04/2016	04/08/2016	100.010	100.030	100.1	1
KU	C1SR	2510076	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510077	04/2016	04/08/2016	100.000	100.020	100.1	1
KU	C1SR	2510078	04/2016	04/08/2016	100.020	99.940	100.0	1
KU	C1SR	2510079	04/2016	04/08/2016	100.000	100.000	100.1	1
KU	C1SR	2510080	04/2016	04/08/2016	100.010	99.990	100.0	1
KU	C1SR	2510081	04/2016	04/08/2016	99.990	99.990	100.0	1
KU	C1SR	2510082	04/2016	04/08/2016	100.020	99.970	100.0	1
KU	C1SR	2510083	04/2016	04/08/2016	100.000	100.040	100.1	1
KU	C1SR	2510084	04/2016	04/08/2016	99.990	100.090	100.1	1
KU	C1SR	2510085	04/2016	04/08/2016	100.010	100.040	100.0	1
KU	C1SR	2510086	04/2016	04/08/2016	100.000	100.030	100.0	1
KU	C1SR	2510087	04/2016	04/08/2016	100.020	100.050	100.0	1
KU	C1SR	2510088	04/2016	04/08/2016	100.020	100.080	100.1	1
KU	C1SR	2510089	04/2016	04/08/2016	99.980	99.970	100.0	1

KU	C1SR	2510090	04/2016	04/08/2016	100.010	99.950	100.0	1
KU	C1SR	2510091	04/2016	04/08/2016	100.000	100.060	100.0	1
KU	C1SR	2510092	04/2016	04/08/2016	99.980	100.060	100.0	1
KU	C1SR	2510093	04/2016	04/08/2016	100.010	100.050	100.0	1
KU	C1SR	2510094	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510095	04/2016	04/08/2016	100.030	100.030	100.0	1
KU	C1SR	2510096	04/2016	04/08/2016	100.020	100.010	100.0	1
KU	C1SR	2510097	04/2016	04/08/2016	99.980	100.000	100.0	1
KU	C1SR	2510098	04/2016	04/08/2016	99.990	100.030	100.0	1
KU	C1SR	2510099	04/2016	04/08/2016	100.010	100.060	100.1	1
KU	C1SR	2510100	04/2016	04/08/2016	100.010	100.040	100.0	1
KU	C1SR	2510101	04/2016	04/08/2016	99.980	99.980	100.0	1
KU	C1SR	2510102	04/2016	04/08/2016	99.980	99.980	100.0	1
KU	C1SR	2510103	04/2016	04/08/2016	100.000	100.040	100.0	1
KU	C1SR	2510104	04/2016	04/08/2016	100.010	100.050	100.0	1
KU	C1SR	2510105	04/2016	04/08/2016	99.990	100.050	100.1	1
KU	C1SR	2510106	04/2016	04/08/2016	100.010	100.040	100.0	1
KU	C1SR	2510107	04/2016	04/08/2016	100.000	100.050	100.0	1
KU	C1SR	2510108	04/2016	04/08/2016	100.000	100.070	100.1	1
KU	C1SR	2510109	04/2016	04/08/2016	100.020	99.970	100.0	1
KU	C1SR	2510110	04/2016	04/08/2016	100.030	100.060	100.0	1
KU	C1SR	2510111	04/2016	04/08/2016	100.010	99.970	100.0	1
KU	C1SR	2510112	04/2016	04/08/2016	99.980	100.050	100.0	1
KU	C1SR	2510113	04/2016	04/08/2016	99.980	100.000	100.0	1
KU	C1SR	2510114	04/2016	04/08/2016	99.970	100.050	100.1	1
KU	C1SR	2510115	04/2016	04/08/2016	100.040	100.040	100.0	1
KU	C1SR	2510116	04/2016	04/08/2016	99.990	100.080	100.1	1
KU	C1SR	2510117	04/2016	04/08/2016	100.000	100.000	100.0	1
KU	C1SR	2510118	04/2016	04/08/2016	100.020	100.060	100.0	1
KU	C1SR	2510119	04/2016	04/08/2016	100.000	100.010	100.0	1
KU	C1SR	2510120	04/2016	04/08/2016	100.000	99.950	100.0	1
KU	C1SR	2510121	04/2016	04/08/2016	100.010	100.060	100.1	1
KU	C1SR	2510122	04/2016	04/08/2016	100.000	99.990	100.0	1
KU	C1SR	2510123	04/2016	04/08/2016	99.990	100.030	100.0	1
KU	C1SR	2510124	04/2016	04/08/2016	99.980	100.040	100.1	1
KU	C1SR	2510125	04/2016	04/08/2016	100.000	100.020	100.0	1
KU	C1SR	2510126	04/2016	04/08/2016	100.010	100.020	100.0	1
KU	C1SR	2510127	04/2016	04/08/2016	100.000	99.990	100.0	1
KU	C1SR	2510128	04/2016	04/08/2016	100.000	100.060	100.0	1
KU	C1SR	2510129	04/2016	04/08/2016	99.980	100.050	100.0	1
KU	C1SR	2510130	04/2016	04/08/2016	100.000	99.980	100.0	1
KU	C1SR	2510131	04/2016	04/08/2016	100.020	100.030	100.1	1
KU	C1SR	2510132	04/2016	04/08/2016	100.010	100.030	100.0	1
KU	C1SR	2510133	04/2016	04/08/2016	99.990	100.050	100.0	1
KU	C1SR	2510134	04/2016	04/08/2016	100.030	100.030	100.1	1

KU	C1SR	2510135	04/2016	04/08/2016	99.980	100.060	100.1	1
KU	C1SR	2510136	04/2016	04/08/2016	100.000	100.030	100.1	1
KU	C1SR	2510137	04/2016	04/08/2016	100.000	100.060	100.0	1
KU	C1SR	2510138	04/2016	04/08/2016	99.990	100.050	100.0	1
KU	C1SR	2510139	04/2016	04/08/2016	100.000	100.050	100.0	1
KU	C1SR	2510140	04/2016	04/08/2016	100.000	100.060	100.0	1
KU	C1SR	2510141	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510142	04/2016	04/08/2016	99.970	100.060	100.0	1
KU	C1SR	2510143	04/2016	04/08/2016	99.980	99.980	100.0	1
KU	C1SR	2510144	04/2016	04/08/2016	99.980	100.030	100.0	1
KU	C1SR	2510145	04/2016	04/08/2016	100.020	100.030	100.0	1
KU	C1SR	2510146	04/2016	04/08/2016	99.980	100.000	100.0	1
KU	C1SR	2510147	04/2016	04/08/2016	100.020	100.060	100.0	1
KU	C1SR	2510148	04/2016	04/08/2016	99.990	100.070	100.1	1
KU	C1SR	2510149	04/2016	04/08/2016	100.000	100.070	100.1	1
KU	C1SR	2510150	04/2016	04/08/2016	100.000	100.050	100.1	1
KU	C1SR	2510151	04/2016	04/08/2016	99.990	99.980	100.0	1
KU	C1SR	2510152	04/2016	04/08/2016	100.020	100.050	100.0	1
KU	C1SR	2510153	04/2016	04/08/2016	100.020	100.030	100.0	1
KU	C1SR	2510154	04/2016	04/08/2016	99.950	100.040	100.1	1
KU	C1SR	2510155	04/2016	04/08/2016	100.050	100.040	100.1	1
KU	C1SR	2510156	04/2016	04/08/2016	99.970	100.050	100.0	1
KU	C1SR	2510157	04/2016	04/08/2016	100.000	100.050	100.0	1
KU	C1SR	2510158	04/2016	04/08/2016	100.010	100.070	100.1	1
KU	C1SR	2510159	04/2016	04/08/2016	99.990	100.030	100.1	1
KU	C1SR	2510160	04/2016	04/08/2016	100.020	99.980	100.0	1
KU	C1SR	2510161	04/2016	04/08/2016	100.010	99.980	100.0	1
KU	C1SR	2510162	04/2016	04/08/2016	99.970	100.030	100.0	1
KU	C1SR	2510163	04/2016	04/08/2016	100.020	100.030	100.0	1
KU	C1SR	2510164	04/2016	04/08/2016	99.980	99.990	100.0	1
KU	C1SR	2510165	04/2016	04/08/2016	100.010	99.950	100.0	1
KU	C1SR	2510166	04/2016	04/08/2016	100.030	100.020	100.1	1
KU	C1SR	2510167	04/2016	04/08/2016	100.020	99.990	100.0	1
KU	C1SR	2510168	04/2016	04/08/2016	100.010	100.010	100.0	1
KU	C1SR	2510169	04/2016	04/08/2016	100.020	99.980	100.0	1
KU	C1SR	2510170	04/2016	04/08/2016	100.030	99.980	100.0	1
KU	C1SR	2510171	05/2016	05/25/2016	99.940	99.940	99.9	1
KU	C1SR	2510172	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510173	05/2016	05/25/2016	99.980	100.020	100.1	1
KU	C1SR	2510174	05/2016	05/25/2016	99.940	99.940	100.0	1
KU	C1SR	2510175	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2510176	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510177	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2510178	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510179	05/2016	05/25/2016	100.000	99.980	100.0	1

KU	C1SR	2510180	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510181	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510182	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510183	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510184	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510185	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510186	05/2016	05/25/2016	99.960	99.990	100.0	1
KU	C1SR	2510187	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510188	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510189	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510190	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510191	05/2016	05/25/2016	99.960	99.930	100.0	1
KU	C1SR	2510192	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510193	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510194	05/2016	05/25/2016	99.950	100.010	100.0	1
KU	C1SR	2510195	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510196	05/2016	05/25/2016	100.070	99.950	100.0	1
KU	C1SR	2510197	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510198	05/2016	05/25/2016	100.030	100.030	100.1	1
KU	C1SR	2510199	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510200	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510201	05/2016	05/25/2016	99.990	99.990	100.1	1
KU	C1SR	2510202	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510203	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2510204	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510205	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510206	05/2016	05/25/2016	100.000	100.040	100.0	1
KU	C1SR	2510207	05/2016	05/25/2016	99.990	100.010	100.1	1
KU	C1SR	2510208	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510209	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2510210	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510211	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510212	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510213	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510214	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510215	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510216	05/2016	05/25/2016	99.990	99.930	100.0	1
KU	C1SR	2510217	05/2016	05/25/2016	99.970	99.930	100.0	1
KU	C1SR	2510218	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510219	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510220	05/2016	05/25/2016	100.040	99.990	100.0	1
KU	C1SR	2510221	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510222	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510223	05/2016	05/25/2016	100.020	99.920	100.0	1
KU	C1SR	2510224	05/2016	05/25/2016	100.010	100.000	100.1	1

KU	C1SR	2510225	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510226	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510227	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510228	05/2016	05/25/2016	99.960	99.960	100.1	1
KU	C1SR	2510229	05/2016	05/25/2016	100.020	100.000	100.1	1
KU	C1SR	2510230	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510231	05/2016	05/25/2016	100.020	100.010	100.1	1
KU	C1SR	2510232	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510233	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510234	05/2016	05/25/2016	99.960	99.960	100.0	1
KU	C1SR	2510235	05/2016	05/25/2016	100.000	99.930	100.0	1
KU	C1SR	2510236	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510237	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510238	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510239	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510240	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510241	05/2016	05/25/2016	100.030	100.020	100.0	1
KU	C1SR	2510242	05/2016	05/25/2016	100.010	99.980	100.1	1
KU	C1SR	2510243	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510244	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510245	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510246	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510247	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510248	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510249	05/2016	05/25/2016	100.040	99.950	100.0	1
KU	C1SR	2510250	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510251	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510252	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510253	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510254	05/2016	05/25/2016	99.990	99.910	99.9	1
KU	C1SR	2510255	05/2016	05/25/2016	99.970	99.960	100.0	1
KU	C1SR	2510256	05/2016	05/25/2016	99.960	99.970	100.0	1
KU	C1SR	2510257	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510258	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510259	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510260	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510261	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510262	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510263	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510264	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510265	05/2016	05/25/2016	99.970	99.960	100.0	1
KU	C1SR	2510266	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510267	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510268	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510269	05/2016	05/25/2016	99.990	99.950	100.0	1

KU	C1SR	2510270	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510271	05/2016	05/25/2016	99.980	100.010	100.1	1
KU	C1SR	2510272	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510273	05/2016	05/25/2016	100.050	99.980	100.0	1
KU	C1SR	2510274	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510275	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510276	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510277	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510278	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510279	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510280	05/2016	05/25/2016	99.960	99.990	100.0	1
KU	C1SR	2510281	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510282	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510283	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510284	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510285	05/2016	05/25/2016	100.020	100.030	100.1	1
KU	C1SR	2510286	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510287	05/2016	05/25/2016	100.020	99.930	100.0	1
KU	C1SR	2510288	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510289	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510290	05/2016	05/25/2016	100.050	99.990	100.0	1
KU	C1SR	2510291	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510292	05/2016	05/25/2016	100.060	99.950	100.0	1
KU	C1SR	2510293	05/2016	05/25/2016	100.040	100.030	100.1	1
KU	C1SR	2510294	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510295	05/2016	05/25/2016	99.970	100.010	100.1	1
KU	C1SR	2510296	05/2016	05/25/2016	99.980	99.940	100.0	1
KU	C1SR	2510297	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510298	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510299	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510300	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510301	05/2016	05/25/2016	100.010	99.970	100.1	1
KU	C1SR	2510302	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510303	05/2016	05/25/2016	99.960	100.010	100.1	1
KU	C1SR	2510304	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510305	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510306	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510307	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510308	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510309	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510310	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510311	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510312	05/2016	05/25/2016	100.000	100.040	100.1	1
KU	C1SR	2510313	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510314	05/2016	05/25/2016	100.040	99.980	100.0	1

KU	C1SR	2510315	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510316	05/2016	05/25/2016	100.020	100.020	100.0	1
KU	C1SR	2510317	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510318	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510319	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510320	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510321	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510322	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510323	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510324	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510325	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510326	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510327	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510328	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2510329	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510330	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510331	05/2016	05/25/2016	100.050	99.980	100.0	1
KU	C1SR	2510332	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2510333	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510334	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510335	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510336	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510337	05/2016	05/25/2016	99.990	100.010	100.1	1
KU	C1SR	2510338	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510339	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510340	05/2016	05/25/2016	99.990	100.040	100.1	1
KU	C1SR	2510341	05/2016	05/25/2016	100.000	100.030	100.1	1
KU	C1SR	2510342	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510343	05/2016	05/25/2016	100.030	99.980	100.1	1
KU	C1SR	2510344	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510345	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510346	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2510347	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510348	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510349	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510350	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510351	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510352	05/2016	05/25/2016	100.020	99.930	99.9	1
KU	C1SR	2510353	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510354	05/2016	05/25/2016	100.030	100.000	100.0	1
KU	C1SR	2510355	05/2016	05/25/2016	100.000	100.030	100.1	1
KU	C1SR	2510356	05/2016	05/25/2016	99.990	100.070	100.1	1
KU	C1SR	2510357	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510358	05/2016	05/25/2016	100.020	99.990	100.1	1
KU	C1SR	2510359	05/2016	05/25/2016	100.060	100.000	100.0	1

KU	C1SR	2510360	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510361	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510362	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510363	05/2016	05/25/2016	99.980	100.020	100.0	1
KU	C1SR	2510364	05/2016	05/25/2016	99.990	100.040	100.1	1
KU	C1SR	2510365	05/2016	05/25/2016	99.970	100.000	100.1	1
KU	C1SR	2510366	05/2016	05/25/2016	99.990	100.000	100.1	1
KU	C1SR	2510367	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510368	05/2016	05/25/2016	100.020	100.020	100.1	1
KU	C1SR	2510369	05/2016	05/25/2016	100.000	100.030	100.1	1
KU	C1SR	2510370	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510371	05/2016	05/25/2016	100.010	99.960	99.9	1
KU	C1SR	2510372	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510373	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510374	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510375	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510376	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510377	05/2016	05/25/2016	99.960	99.990	100.0	1
KU	C1SR	2510378	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510379	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510380	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510381	05/2016	05/25/2016	100.030	100.000	100.1	1
KU	C1SR	2510382	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510383	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510384	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510385	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510386	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510387	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510388	05/2016	05/25/2016	99.980	99.990	100.1	1
KU	C1SR	2510389	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510390	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510391	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510392	05/2016	05/25/2016	100.030	100.020	100.1	1
KU	C1SR	2510393	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510394	05/2016	05/25/2016	100.010	100.010	100.1	1
KU	C1SR	2510395	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510396	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510397	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510398	05/2016	05/25/2016	100.000	99.980	100.1	1
KU	C1SR	2510399	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510400	05/2016	05/25/2016	100.000	100.040	100.0	1
KU	C1SR	2510401	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510402	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510403	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510404	05/2016	05/25/2016	100.030	99.960	100.1	1

KU	C1SR	2510405	05/2016	05/25/2016	99.970	100.030	100.0	1
KU	C1SR	2510406	05/2016	05/25/2016	99.960	100.010	100.0	1
KU	C1SR	2510407	05/2016	05/25/2016	99.980	100.030	100.1	1
KU	C1SR	2510408	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510409	05/2016	05/25/2016	99.990	100.030	100.1	1
KU	C1SR	2510410	05/2016	05/25/2016	99.950	100.010	100.0	1
KU	C1SR	2510411	05/2016	05/25/2016	100.020	100.020	100.0	1
KU	C1SR	2510412	05/2016	05/25/2016	99.970	100.010	100.1	1
KU	C1SR	2510413	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510414	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510415	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510416	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510417	05/2016	05/25/2016	100.020	100.010	100.1	1
KU	C1SR	2510418	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510419	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510420	05/2016	05/25/2016	100.010	100.010	100.1	1
KU	C1SR	2510421	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510422	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510423	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510424	05/2016	05/25/2016	99.950	99.980	100.0	1
KU	C1SR	2510425	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510426	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510427	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510428	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510429	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510430	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510431	05/2016	05/25/2016	99.990	100.010	100.1	1
KU	C1SR	2510432	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510433	05/2016	05/25/2016	100.030	100.000	100.1	1
KU	C1SR	2510434	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510435	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510436	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510437	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510438	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510439	05/2016	05/25/2016	100.030	100.030	100.1	1
KU	C1SR	2510440	05/2016	05/25/2016	100.020	100.020	100.1	1
KU	C1SR	2510441	05/2016	05/25/2016	100.020	100.010	100.0	1
KU	C1SR	2510442	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510443	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510444	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510445	05/2016	05/25/2016	100.010	99.980	100.1	1
KU	C1SR	2510446	05/2016	05/25/2016	100.020	99.970	100.1	1
KU	C1SR	2510447	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510448	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510449	05/2016	05/25/2016	100.010	99.970	100.0	1

KU	C1SR	2510450	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510451	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510452	05/2016	05/25/2016	99.960	100.030	100.1	1
KU	C1SR	2510453	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510454	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510455	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510456	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510457	05/2016	05/25/2016	99.980	99.990	100.1	1
KU	C1SR	2510458	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510459	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510460	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510461	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2510462	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510463	05/2016	05/25/2016	99.970	99.950	100.0	1
KU	C1SR	2510464	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510465	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510466	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510467	05/2016	05/25/2016	100.030	100.000	100.0	1
KU	C1SR	2510468	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2510469	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510470	05/2016	05/25/2016	100.040	99.980	100.0	1
KU	C1SR	2510471	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510472	05/2016	05/25/2016	100.020	99.980	100.1	1
KU	C1SR	2510473	05/2016	05/25/2016	100.020	100.040	100.0	1
KU	C1SR	2510474	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510475	05/2016	05/25/2016	99.960	100.010	100.0	1
KU	C1SR	2510476	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2510477	05/2016	05/25/2016	100.040	100.020	100.0	1
KU	C1SR	2510478	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510479	05/2016	05/25/2016	100.020	100.020	100.0	1
KU	C1SR	2510480	05/2016	05/25/2016	100.010	100.040	100.1	1
KU	C1SR	2510481	05/2016	05/25/2016	99.990	100.040	100.1	1
KU	C1SR	2510482	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510483	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510484	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510485	05/2016	05/25/2016	100.040	99.980	100.0	1
KU	C1SR	2510486	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510487	05/2016	05/25/2016	99.960	99.960	100.0	1
KU	C1SR	2510488	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510489	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510490	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510491	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510492	05/2016	05/25/2016	100.000	100.000	100.1	1
KU	C1SR	2510493	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510494	05/2016	05/25/2016	99.990	99.980	100.0	1

KU	C1SR	2510495	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2510496	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510497	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510498	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510499	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510500	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510501	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510502	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510503	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510504	05/2016	05/25/2016	99.970	99.890	99.9	1
KU	C1SR	2510505	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510506	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510507	05/2016	05/25/2016	100.060	100.010	100.0	1
KU	C1SR	2510508	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510509	05/2016	05/25/2016	100.010	100.040	100.0	1
KU	C1SR	2510510	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510511	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510512	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510513	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510514	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510515	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510516	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510517	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510518	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510519	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510520	05/2016	05/25/2016	100.000	100.000	100.1	1
KU	C1SR	2510521	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510522	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510523	05/2016	05/25/2016	99.960	99.970	100.0	1
KU	C1SR	2510524	05/2016	05/25/2016	99.990	100.060	100.1	1
KU	C1SR	2510525	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2510526	05/2016	05/25/2016	99.970	100.030	100.0	1
KU	C1SR	2510527	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510528	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510529	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510530	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510531	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510532	05/2016	05/25/2016	99.970	99.990	100.0	1
KU	C1SR	2510533	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510534	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510535	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510536	05/2016	05/25/2016	99.980	99.920	100.0	1
KU	C1SR	2510537	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510538	05/2016	05/25/2016	100.010	99.880	99.9	1
KU	C1SR	2510539	05/2016	05/25/2016	99.990	100.060	100.1	1

KU	C1SR	2510540	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510541	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510542	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510543	05/2016	05/25/2016	100.040	99.980	100.0	1
KU	C1SR	2510544	05/2016	05/25/2016	99.970	100.030	100.0	1
KU	C1SR	2510545	05/2016	05/25/2016	99.980	100.010	100.1	1
KU	C1SR	2510546	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510547	05/2016	05/25/2016	99.980	100.020	100.0	1
KU	C1SR	2510548	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2510549	05/2016	05/25/2016	99.990	99.940	99.9	1
KU	C1SR	2510550	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510551	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510552	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510553	05/2016	05/25/2016	100.000	99.980	100.1	1
KU	C1SR	2510554	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510555	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510556	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510557	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510558	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510559	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510560	05/2016	05/25/2016	100.010	99.940	99.9	1
KU	C1SR	2510561	05/2016	05/25/2016	100.040	99.970	100.0	1
KU	C1SR	2510562	05/2016	05/25/2016	100.040	100.000	100.0	1
KU	C1SR	2510563	05/2016	05/25/2016	100.020	99.920	99.8	1
KU	C1SR	2510564	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510565	05/2016	05/25/2016	100.030	100.000	100.0	1
KU	C1SR	2510566	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510567	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510568	05/2016	05/25/2016	99.970	99.920	99.9	1
KU	C1SR	2510569	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510570	05/2016	05/25/2016	99.990	100.020	100.1	1
KU	C1SR	2510571	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510572	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510573	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510574	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510575	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510576	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510577	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2510578	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2510579	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510580	05/2016	05/25/2016	99.990	99.980	100.1	1
KU	C1SR	2510581	05/2016	05/25/2016	99.980	100.020	100.1	1
KU	C1SR	2510582	05/2016	05/25/2016	99.970	100.000	100.0	1
KU	C1SR	2510583	05/2016	05/25/2016	100.000	100.030	100.1	1
KU	C1SR	2510584	05/2016	05/25/2016	100.020	100.050	100.1	1

KU	C1SR	2510585	05/2016	05/25/2016	100.000	100.010	100.1	1
KU	C1SR	2510586	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2510587	05/2016	05/25/2016	99.980	99.960	100.1	1
KU	C1SR	2510588	05/2016	05/25/2016	99.990	100.010	100.1	1
KU	C1SR	2510589	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2510590	05/2016	05/25/2016	100.000	100.050	100.1	1
KU	C1SR	2510591	05/2016	05/25/2016	100.020	100.040	100.1	1
KU	C1SR	2510592	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510593	05/2016	05/25/2016	100.010	99.930	100.0	1
KU	C1SR	2510594	05/2016	05/25/2016	99.990	99.980	100.1	1
KU	C1SR	2510595	05/2016	05/25/2016	100.020	99.960	100.1	1
KU	C1SR	2510596	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510597	05/2016	05/25/2016	100.020	99.990	100.1	1
KU	C1SR	2510598	05/2016	05/25/2016	99.990	100.050	100.0	1
KU	C1SR	2510599	05/2016	05/25/2016	99.990	99.960	100.1	1
KU	C1SR	2510600	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510601	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510602	05/2016	05/25/2016	99.980	99.980	100.1	1
KU	C1SR	2510603	05/2016	05/25/2016	99.990	99.970	100.1	1
KU	C1SR	2510604	05/2016	05/25/2016	99.990	99.920	100.0	1
KU	C1SR	2510605	05/2016	05/25/2016	99.990	100.030	100.1	1
KU	C1SR	2510606	05/2016	05/25/2016	100.020	100.010	100.0	1
KU	C1SR	2510607	05/2016	05/25/2016	100.010	99.980	100.1	1
KU	C1SR	2510608	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510609	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510610	05/2016	05/25/2016	99.990	99.900	99.9	1
KU	C1SR	2510611	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510612	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510613	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2510614	05/2016	05/25/2016	99.980	99.980	100.1	1
KU	C1SR	2510615	05/2016	05/25/2016	99.950	99.950	100.0	1
KU	C1SR	2510616	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510617	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510618	05/2016	05/25/2016	99.990	99.980	100.1	1
KU	C1SR	2510619	05/2016	05/25/2016	100.020	99.940	100.0	1
KU	C1SR	2510620	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2510621	05/2016	05/25/2016	99.970	100.040	100.2	1
KU	C1SR	2510622	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510623	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2510624	05/2016	05/25/2016	100.060	99.990	100.0	1
KU	C1SR	2510625	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510626	05/2016	05/25/2016	100.060	99.990	100.0	1
KU	C1SR	2510627	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2510628	05/2016	05/25/2016	99.990	100.040	100.1	1
KU	C1SR	2510629	05/2016	05/25/2016	99.970	99.930	100.0	1

KU	C1SR	2510630	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510631	05/2016	05/25/2016	100.050	99.930	100.0	1
KU	C1SR	2510632	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510633	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510634	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510635	05/2016	05/25/2016	100.010	100.000	100.1	1
KU	C1SR	2510636	05/2016	05/25/2016	100.010	100.060	100.1	1
KU	C1SR	2510637	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510638	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510639	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510640	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510641	05/2016	05/25/2016	100.030	100.020	100.1	1
KU	C1SR	2510642	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510643	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510644	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510645	05/2016	05/25/2016	99.990	100.040	100.0	1
KU	C1SR	2510646	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510647	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510648	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510649	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2510650	05/2016	05/25/2016	99.980	99.950	100.0	1
KU	C1SR	2510651	05/2016	05/25/2016	99.970	100.000	100.0	1
KU	C1SR	2510652	05/2016	05/25/2016	100.020	100.000	100.1	1
KU	C1SR	2510653	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510654	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510655	05/2016	05/25/2016	99.980	100.040	100.0	1
KU	C1SR	2510656	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510657	05/2016	05/25/2016	99.970	99.990	100.1	1
KU	C1SR	2510658	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510659	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510660	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510661	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510662	05/2016	05/25/2016	100.020	100.020	100.0	1
KU	C1SR	2510663	05/2016	05/25/2016	100.010	99.990	100.1	1
KU	C1SR	2510664	05/2016	05/25/2016	100.020	100.000	100.1	1
KU	C1SR	2510665	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510666	05/2016	05/25/2016	99.950	100.020	100.1	1
KU	C1SR	2510667	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510668	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510669	05/2016	05/25/2016	99.980	99.870	99.9	1
KU	C1SR	2510670	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510671	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510672	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510673	05/2016	05/25/2016	100.000	100.010	100.1	1
KU	C1SR	2510674	05/2016	05/25/2016	100.000	99.960	100.0	1

KU	C1SR	2510675	05/2016	05/25/2016	100.000	99.970	100.1	1
KU	C1SR	2510676	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510677	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510678	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510679	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510680	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510681	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510682	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2510683	05/2016	05/25/2016	100.020	100.000	100.1	1
KU	C1SR	2510684	05/2016	05/25/2016	100.030	100.000	100.1	1
KU	C1SR	2510685	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510686	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510687	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510688	05/2016	05/25/2016	100.010	99.990	100.1	1
KU	C1SR	2510689	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510690	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510691	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510692	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510693	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510694	05/2016	05/25/2016	99.970	100.030	100.0	1
KU	C1SR	2510695	05/2016	05/25/2016	99.970	99.990	100.0	1
KU	C1SR	2510696	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510697	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510698	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510699	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510700	05/2016	05/25/2016	99.980	99.970	100.1	1
KU	C1SR	2510701	05/2016	05/25/2016	99.970	100.000	100.0	1
KU	C1SR	2510702	05/2016	05/25/2016	99.960	100.000	100.0	1
KU	C1SR	2510703	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510704	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510705	05/2016	05/25/2016	100.030	100.050	100.1	1
KU	C1SR	2510706	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510707	05/2016	05/25/2016	100.000	100.040	100.1	1
KU	C1SR	2510708	05/2016	05/25/2016	99.960	99.950	100.0	1
KU	C1SR	2510709	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510710	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510711	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510712	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510713	05/2016	05/25/2016	99.970	100.000	100.0	1
KU	C1SR	2510714	05/2016	05/25/2016	100.010	100.010	100.1	1
KU	C1SR	2510715	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510716	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510717	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2510718	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510719	05/2016	05/25/2016	100.000	99.970	100.0	1

KU	C1SR	2510720	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510721	05/2016	05/25/2016	99.970	99.970	100.1	1
KU	C1SR	2510722	05/2016	05/25/2016	99.980	100.020	100.1	1
KU	C1SR	2510723	05/2016	05/25/2016	100.030	100.020	100.1	1
KU	C1SR	2510724	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510725	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510726	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510727	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510728	05/2016	05/25/2016	99.980	99.920	100.0	1
KU	C1SR	2510729	05/2016	05/25/2016	99.990	100.040	100.1	1
KU	C1SR	2510730	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510731	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2510732	05/2016	05/25/2016	100.000	100.050	100.1	1
KU	C1SR	2510733	05/2016	05/25/2016	100.040	99.990	100.0	1
KU	C1SR	2510734	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510735	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510736	05/2016	05/25/2016	99.950	100.070	100.1	1
KU	C1SR	2510737	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510738	05/2016	05/25/2016	100.010	100.010	100.1	1
KU	C1SR	2510739	05/2016	05/25/2016	100.030	100.000	100.0	1
KU	C1SR	2510740	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510741	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510742	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510743	05/2016	05/25/2016	100.020	100.030	100.0	1
KU	C1SR	2510744	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510745	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510746	05/2016	05/25/2016	100.030	100.010	100.0	1
KU	C1SR	2510747	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510748	05/2016	05/25/2016	100.030	100.010	100.0	1
KU	C1SR	2510749	05/2016	05/25/2016	99.990	99.970	100.1	1
KU	C1SR	2510750	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510751	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510752	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510753	05/2016	05/25/2016	100.020	100.040	100.0	1
KU	C1SR	2510754	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510755	05/2016	05/25/2016	99.990	100.010	100.1	1
KU	C1SR	2510756	05/2016	05/25/2016	100.010	100.020	100.1	1
KU	C1SR	2510757	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510758	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510759	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510760	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510761	05/2016	05/25/2016	99.960	99.970	100.0	1
KU	C1SR	2510762	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510763	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510764	05/2016	05/25/2016	99.960	99.990	100.0	1

KU	C1SR	2510765	05/2016	05/25/2016	99.990	99.930	99.9	1
KU	C1SR	2510766	05/2016	05/25/2016	100.020	99.940	100.0	1
KU	C1SR	2510767	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2510768	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510769	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510770	05/2016	05/25/2016	100.030	99.910	100.0	1
KU	C1SR	2510771	05/2016	05/25/2016	100.030	99.940	100.0	1
KU	C1SR	2510772	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510773	05/2016	05/25/2016	99.970	99.930	99.9	1
KU	C1SR	2510774	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510775	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510776	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510777	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510778	05/2016	05/25/2016	100.040	99.880	99.9	1
KU	C1SR	2510779	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510780	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510781	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510782	05/2016	05/25/2016	100.000	99.970	100.1	1
KU	C1SR	2510783	05/2016	05/25/2016	99.980	99.930	100.0	1
KU	C1SR	2510784	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510785	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510786	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510787	05/2016	05/25/2016	99.970	100.030	100.0	1
KU	C1SR	2510788	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510789	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510790	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510791	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510792	05/2016	05/25/2016	99.990	99.940	100.0	1
KU	C1SR	2510793	05/2016	05/25/2016	100.000	99.930	99.9	1
KU	C1SR	2510794	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510795	05/2016	05/25/2016	100.000	99.980	100.1	1
KU	C1SR	2510796	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510797	05/2016	05/25/2016	100.020	99.920	100.0	1
KU	C1SR	2510798	05/2016	05/25/2016	100.030	100.000	100.0	1
KU	C1SR	2510799	05/2016	05/25/2016	99.990	99.990	100.1	1
KU	C1SR	2510800	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510801	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510802	05/2016	05/25/2016	100.020	100.050	100.1	1
KU	C1SR	2510803	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510804	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510805	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510806	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510807	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2510808	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510809	05/2016	05/25/2016	100.020	99.970	100.1	1

KU	C1SR	2510810	05/2016	05/25/2016	99.980	100.030	100.1	1
KU	C1SR	2510811	05/2016	05/25/2016	99.980	99.950	100.1	1
KU	C1SR	2510812	05/2016	05/25/2016	100.030	99.960	100.1	1
KU	C1SR	2510813	05/2016	05/25/2016	99.990	100.000	100.1	1
KU	C1SR	2510814	05/2016	05/25/2016	99.990	99.980	100.1	1
KU	C1SR	2510815	05/2016	05/25/2016	99.960	99.990	100.0	1
KU	C1SR	2510816	05/2016	05/25/2016	99.990	99.930	100.0	1
KU	C1SR	2510817	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510818	05/2016	05/25/2016	100.020	99.970	100.1	1
KU	C1SR	2510819	05/2016	05/25/2016	100.000	100.010	100.1	1
KU	C1SR	2510820	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510821	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510822	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510823	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510824	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510825	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2510826	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510827	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510828	05/2016	05/25/2016	100.000	100.010	100.1	1
KU	C1SR	2510829	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510830	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2510831	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510832	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510833	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510834	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510835	05/2016	05/25/2016	100.000	99.910	100.0	1
KU	C1SR	2510836	05/2016	05/25/2016	99.960	100.010	100.0	1
KU	C1SR	2510837	05/2016	05/25/2016	100.010	99.950	99.9	1
KU	C1SR	2510838	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510839	05/2016	05/25/2016	100.020	99.970	100.1	1
KU	C1SR	2510840	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510841	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510842	05/2016	05/25/2016	100.000	100.040	100.0	1
KU	C1SR	2510843	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510844	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510845	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510846	05/2016	05/25/2016	100.010	100.050	100.1	1
KU	C1SR	2510847	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510848	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510849	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510850	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510851	05/2016	05/25/2016	100.020	100.010	100.1	1
KU	C1SR	2510852	05/2016	05/25/2016	99.980	99.950	100.0	1
KU	C1SR	2510853	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2510854	05/2016	05/25/2016	100.010	99.950	100.0	1

KU	C1SR	2510855	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510856	05/2016	05/25/2016	100.020	100.040	100.1	1
KU	C1SR	2510857	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2510858	05/2016	05/25/2016	100.020	100.030	100.0	1
KU	C1SR	2510859	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510860	05/2016	05/25/2016	100.010	99.950	100.0	1
KU	C1SR	2510861	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510862	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510863	05/2016	05/25/2016	99.970	99.950	100.0	1
KU	C1SR	2510864	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510865	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510866	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510867	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510868	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510869	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510870	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510871	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2510872	05/2016	05/25/2016	99.970	99.930	100.0	1
KU	C1SR	2510873	05/2016	05/25/2016	100.000	99.960	100.1	1
KU	C1SR	2510874	05/2016	05/25/2016	100.020	99.990	100.1	1
KU	C1SR	2510875	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510876	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510877	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510878	05/2016	05/25/2016	99.960	99.940	99.9	1
KU	C1SR	2510879	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510880	05/2016	05/25/2016	100.010	99.870	99.9	1
KU	C1SR	2510881	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510882	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510883	05/2016	05/25/2016	99.990	99.920	100.0	1
KU	C1SR	2510884	05/2016	05/25/2016	99.970	99.970	100.0	1
KU	C1SR	2510885	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510886	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510887	05/2016	05/25/2016	99.980	100.020	100.0	1
KU	C1SR	2510888	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510889	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2510890	05/2016	05/25/2016	100.020	99.930	100.0	1
KU	C1SR	2510891	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510892	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2510893	05/2016	05/25/2016	99.960	100.020	100.0	1
KU	C1SR	2510894	05/2016	05/25/2016	99.990	99.850	99.9	1
KU	C1SR	2510895	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510896	05/2016	05/25/2016	100.010	100.010	99.8	1
KU	C1SR	2510897	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510898	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510899	05/2016	05/25/2016	100.020	99.990	100.0	1

KU	C1SR	2510900	05/2016	05/25/2016	99.980	99.940	100.0	1
KU	C1SR	2510901	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510902	05/2016	05/25/2016	99.980	99.920	100.0	1
KU	C1SR	2510903	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2510904	05/2016	05/25/2016	100.020	100.000	100.1	1
KU	C1SR	2510905	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510906	05/2016	05/25/2016	100.000	99.890	100.0	1
KU	C1SR	2510907	05/2016	05/25/2016	99.970	100.010	100.0	1
KU	C1SR	2510908	05/2016	05/25/2016	100.010	100.040	100.0	1
KU	C1SR	2510909	05/2016	05/25/2016	100.020	99.960	100.0	1
KU	C1SR	2510910	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2510911	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510912	05/2016	05/25/2016	99.990	99.960	99.8	1
KU	C1SR	2510913	05/2016	05/25/2016	99.970	100.050	100.1	1
KU	C1SR	2510914	05/2016	05/25/2016	99.980	99.970	100.1	1
KU	C1SR	2510915	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2510916	05/2016	05/25/2016	100.020	99.950	99.9	1
KU	C1SR	2510917	05/2016	05/25/2016	100.000	99.920	100.0	1
KU	C1SR	2510918	05/2016	05/25/2016	99.990	100.020	100.0	1
KU	C1SR	2510919	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510920	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510921	05/2016	05/25/2016	99.970	99.900	99.9	1
KU	C1SR	2510922	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2510923	05/2016	05/25/2016	100.030	99.950	100.0	1
KU	C1SR	2510924	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510925	05/2016	05/25/2016	100.000	99.910	100.0	1
KU	C1SR	2510926	05/2016	05/25/2016	100.000	99.970	100.1	1
KU	C1SR	2510927	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2510928	05/2016	05/25/2016	100.030	99.980	100.1	1
KU	C1SR	2510929	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510930	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2510931	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510932	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2510933	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2510934	05/2016	05/25/2016	100.040	100.000	100.0	1
KU	C1SR	2510935	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2510936	05/2016	05/25/2016	100.030	99.960	100.0	1
KU	C1SR	2510937	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2510938	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510939	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510940	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510941	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2510942	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2510943	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510944	05/2016	05/25/2016	100.010	99.980	100.1	1

KU	C1SR	2510945	05/2016	05/25/2016	100.030	100.040	100.0	1
KU	C1SR	2510946	05/2016	05/25/2016	100.030	99.940	100.0	1
KU	C1SR	2510947	05/2016	05/25/2016	99.960	99.930	99.9	1
KU	C1SR	2510948	05/2016	05/25/2016	100.000	99.930	100.0	1
KU	C1SR	2510949	05/2016	05/25/2016	99.970	99.900	99.9	1
KU	C1SR	2510950	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2510951	05/2016	05/25/2016	100.040	99.990	100.0	1
KU	C1SR	2510952	05/2016	05/25/2016	100.000	99.870	99.9	1
KU	C1SR	2510953	05/2016	05/25/2016	99.970	99.880	99.9	1
KU	C1SR	2510954	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510955	05/2016	05/25/2016	99.980	99.930	99.9	1
KU	C1SR	2510956	05/2016	05/25/2016	100.020	99.970	100.0	1
KU	C1SR	2510957	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510958	05/2016	05/25/2016	100.020	99.930	99.9	1
KU	C1SR	2510959	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510960	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2510961	05/2016	05/25/2016	100.000	99.930	100.0	1
KU	C1SR	2510962	05/2016	05/25/2016	99.990	99.930	100.0	1
KU	C1SR	2510963	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2510964	05/2016	05/25/2016	100.000	99.990	100.1	1
KU	C1SR	2510965	05/2016	05/25/2016	100.010	99.950	99.9	1
KU	C1SR	2510966	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510967	05/2016	05/25/2016	100.030	99.990	100.1	1
KU	C1SR	2510968	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2510969	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2510970	05/2016	05/25/2016	100.020	99.950	100.0	1
KU	C1SR	2510971	05/2016	05/25/2016	100.060	99.990	100.0	1
KU	C1SR	2510972	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2510973	05/2016	05/25/2016	100.050	99.950	100.0	1
KU	C1SR	2510974	05/2016	05/25/2016	99.970	100.030	100.1	1
KU	C1SR	2510975	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2510976	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2510977	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2510978	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510979	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2510980	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2510981	05/2016	05/25/2016	100.010	100.000	99.8	1
KU	C1SR	2510982	05/2016	05/25/2016	99.980	99.960	100.0	1
KU	C1SR	2510983	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2510984	05/2016	05/25/2016	100.050	99.990	100.0	1
KU	C1SR	2510985	05/2016	05/25/2016	99.990	99.970	99.9	1
KU	C1SR	2510986	05/2016	05/25/2016	99.980	100.020	100.0	1
KU	C1SR	2510987	05/2016	05/25/2016	100.030	99.970	100.0	1
KU	C1SR	2510988	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510989	05/2016	05/25/2016	99.990	99.940	100.0	1

KU	C1SR	2510990	05/2016	05/25/2016	99.970	99.990	100.0	1
KU	C1SR	2510991	05/2016	05/25/2016	100.020	99.920	100.0	1
KU	C1SR	2510992	05/2016	05/25/2016	99.990	99.920	99.9	1
KU	C1SR	2510993	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2510994	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2510995	05/2016	05/25/2016	100.000	99.930	100.0	1
KU	C1SR	2510996	05/2016	05/25/2016	99.960	99.980	100.0	1
KU	C1SR	2510997	05/2016	05/25/2016	100.040	99.990	100.0	1
KU	C1SR	2510998	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2510999	05/2016	05/25/2016	100.000	99.970	99.9	1
KU	C1SR	2511000	05/2016	05/25/2016	99.990	99.940	100.0	1
KU	C1SR	2511001	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2511002	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2511003	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511004	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2511005	05/2016	05/25/2016	100.000	100.030	100.0	1
KU	C1SR	2511006	05/2016	05/25/2016	100.020	99.940	100.0	1
KU	C1SR	2511007	05/2016	05/25/2016	99.960	99.960	100.0	1
KU	C1SR	2511008	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511009	05/2016	05/25/2016	99.990	99.880	99.9	1
KU	C1SR	2511010	05/2016	05/25/2016	100.010	99.940	99.9	1
KU	C1SR	2511011	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2511012	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2511013	05/2016	05/25/2016	100.010	99.910	99.8	1
KU	C1SR	2511014	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2511015	05/2016	05/25/2016	99.970	99.940	99.9	1
KU	C1SR	2511016	05/2016	05/25/2016	99.990	99.920	100.0	1
KU	C1SR	2511017	05/2016	05/25/2016	99.970	99.940	100.0	1
KU	C1SR	2511018	05/2016	05/25/2016	99.990	99.930	100.0	1
KU	C1SR	2511019	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2511020	05/2016	05/25/2016	100.000	99.870	99.9	1
KU	C1SR	2511021	05/2016	05/25/2016	100.010	99.910	99.9	1
KU	C1SR	2511022	05/2016	05/25/2016	100.020	100.020	100.0	1
KU	C1SR	2511023	05/2016	05/25/2016	100.010	99.890	99.9	1
KU	C1SR	2511024	05/2016	05/25/2016	99.940	99.930	100.0	1
KU	C1SR	2511025	05/2016	05/25/2016	100.000	100.020	100.0	1
KU	C1SR	2511026	05/2016	05/25/2016	99.990	100.020	100.1	1
KU	C1SR	2511027	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2511028	05/2016	05/25/2016	99.990	99.860	99.8	1
KU	C1SR	2511029	05/2016	05/25/2016	99.990	99.960	100.0	1
KU	C1SR	2511030	05/2016	05/25/2016	99.980	100.000	100.0	1
KU	C1SR	2511031	05/2016	05/25/2016	100.050	99.950	100.0	1
KU	C1SR	2511032	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2511033	05/2016	05/25/2016	100.000	99.970	99.9	1
KU	C1SR	2511034	05/2016	05/25/2016	100.000	100.020	100.0	1

KU	C1SR	2511035	05/2016	05/25/2016	99.980	99.940	100.0	1
KU	C1SR	2511036	05/2016	05/25/2016	100.040	99.950	100.1	1
KU	C1SR	2511037	05/2016	05/25/2016	100.010	100.030	100.0	1
KU	C1SR	2511038	05/2016	05/25/2016	99.980	99.930	99.9	1
KU	C1SR	2511039	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2511040	05/2016	05/25/2016	99.970	99.980	100.0	1
KU	C1SR	2511041	05/2016	05/25/2016	100.030	100.020	100.0	1
KU	C1SR	2511042	05/2016	05/25/2016	100.000	100.000	100.1	1
KU	C1SR	2511043	05/2016	05/25/2016	100.010	100.000	100.1	1
KU	C1SR	2511044	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2511045	05/2016	05/25/2016	100.020	99.930	100.0	1
KU	C1SR	2511046	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2511047	05/2016	05/25/2016	100.020	100.010	100.0	1
KU	C1SR	2511048	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2511049	05/2016	05/25/2016	100.000	100.000	100.1	1
KU	C1SR	2511050	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511051	05/2016	05/25/2016	99.970	99.960	100.0	1
KU	C1SR	2511052	05/2016	05/25/2016	100.000	99.950	99.9	1
KU	C1SR	2511053	05/2016	05/25/2016	99.990	100.050	100.0	1
KU	C1SR	2511054	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2511055	05/2016	05/25/2016	100.010	99.960	100.1	1
KU	C1SR	2511056	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2511057	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2511058	05/2016	05/25/2016	99.990	99.940	99.9	1
KU	C1SR	2511059	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2511060	05/2016	05/25/2016	100.030	99.930	100.0	1
KU	C1SR	2511061	05/2016	05/25/2016	100.020	99.940	100.0	1
KU	C1SR	2511062	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2511063	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2511064	05/2016	05/25/2016	100.020	99.940	99.8	1
KU	C1SR	2511065	05/2016	05/25/2016	100.020	99.930	100.0	1
KU	C1SR	2511066	05/2016	05/25/2016	100.000	99.940	100.0	1
KU	C1SR	2511067	05/2016	05/25/2016	100.000	99.950	99.9	1
KU	C1SR	2511068	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2511069	05/2016	05/25/2016	100.010	100.000	100.1	1
KU	C1SR	2511070	05/2016	05/25/2016	100.000	100.020	100.1	1
KU	C1SR	2511071	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C1SR	2511072	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511073	05/2016	05/25/2016	100.010	99.880	99.9	1
KU	C1SR	2511074	05/2016	05/25/2016	99.990	99.990	100.0	1
KU	C1SR	2511075	05/2016	05/25/2016	100.000	99.890	99.9	1
KU	C1SR	2511076	05/2016	05/25/2016	100.020	99.950	99.9	1
KU	C1SR	2511077	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2511078	05/2016	05/25/2016	99.980	100.020	99.9	1
KU	C1SR	2511079	05/2016	05/25/2016	100.010	99.960	100.1	1

KU	C1SR	2511080	05/2016	05/25/2016	100.010	100.010	100.1	1
KU	C1SR	2511081	05/2016	05/25/2016	100.000	99.980	100.0	1
KU	C1SR	2511082	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2511083	05/2016	05/25/2016	99.980	99.920	100.0	1
KU	C1SR	2511084	05/2016	05/25/2016	99.980	99.930	99.9	1
KU	C1SR	2511085	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2511086	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2511087	05/2016	05/25/2016	100.030	99.900	100.0	1
KU	C1SR	2511088	05/2016	05/25/2016	100.000	100.000	100.1	1
KU	C1SR	2511089	05/2016	05/25/2016	100.050	100.000	100.1	1
KU	C1SR	2511090	05/2016	05/25/2016	100.000	99.920	100.0	1
KU	C1SR	2511091	05/2016	05/25/2016	100.020	99.890	100.0	1
KU	C1SR	2511092	05/2016	05/25/2016	99.990	99.990	100.1	1
KU	C1SR	2511093	05/2016	05/25/2016	100.020	99.870	100.0	1
KU	C1SR	2511094	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2511095	05/2016	05/25/2016	99.970	99.970	100.1	1
KU	C1SR	2511096	05/2016	05/25/2016	100.030	99.990	100.0	1
KU	C1SR	2511097	05/2016	05/25/2016	99.980	99.950	100.0	1
KU	C1SR	2511098	05/2016	05/25/2016	99.960	99.970	100.0	1
KU	C1SR	2511099	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2511100	05/2016	05/25/2016	99.990	100.030	100.1	1
KU	C1SR	2511101	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511102	05/2016	05/25/2016	100.010	99.970	100.0	1
KU	C1SR	2511103	05/2016	05/25/2016	99.990	99.910	100.0	1
KU	C1SR	2511104	05/2016	05/25/2016	100.000	99.960	100.0	1
KU	C1SR	2511105	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2511106	05/2016	05/25/2016	100.000	99.910	99.8	1
KU	C1SR	2511107	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2511108	05/2016	05/25/2016	99.980	99.920	100.0	1
KU	C1SR	2511109	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2511110	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2511111	05/2016	05/25/2016	100.030	99.940	100.0	1
KU	C1SR	2511112	05/2016	05/25/2016	100.000	99.930	99.9	1
KU	C1SR	2511113	05/2016	05/25/2016	100.000	99.950	100.0	1
KU	C1SR	2511114	05/2016	05/25/2016	100.010	100.000	100.1	1
KU	C1SR	2511115	05/2016	05/25/2016	99.970	99.920	100.0	1
KU	C1SR	2511116	05/2016	05/25/2016	100.000	99.980	100.1	1
KU	C1SR	2511117	05/2016	05/25/2016	100.000	99.900	99.9	1
KU	C1SR	2511118	05/2016	05/25/2016	99.950	99.860	100.0	1
KU	C1SR	2511119	05/2016	05/25/2016	100.000	100.040	100.1	1
KU	C1SR	2511120	05/2016	05/25/2016	100.020	99.900	99.9	1
KU	C1SR	2511121	05/2016	05/25/2016	100.000	99.920	100.0	1
KU	C1SR	2511122	05/2016	05/25/2016	99.990	99.980	100.1	1
KU	C1SR	2511123	05/2016	05/25/2016	100.010	100.030	99.8	1
KU	C1SR	2511124	05/2016	05/25/2016	100.030	99.900	100.0	1

KU	C1SR	2511125	05/2016	05/25/2016	100.040	100.010	100.1	1
KU	C1SR	2511126	05/2016	05/25/2016	100.020	99.900	100.0	1
KU	C1SR	2511127	05/2016	05/25/2016	100.010	99.950	99.9	1
KU	C1SR	2511128	05/2016	05/25/2016	100.000	100.010	99.9	1
KU	C1SR	2511129	05/2016	05/25/2016	100.020	99.880	99.9	1
KU	C1SR	2511130	05/2016	05/25/2016	100.000	99.890	100.0	1
KU	C1SR	2511131	05/2016	05/25/2016	99.970	99.920	99.9	1
KU	C1SR	2511132	05/2016	05/25/2016	100.040	99.890	100.0	1
KU	C1SR	2511133	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2511134	05/2016	05/25/2016	99.990	99.960	100.1	1
KU	C1SR	2511135	05/2016	05/25/2016	100.000	99.930	99.9	1
KU	C1SR	2511136	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2511137	05/2016	05/25/2016	99.970	100.000	99.9	1
KU	C1SR	2511138	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2511139	05/2016	05/25/2016	100.010	99.930	100.0	1
KU	C1SR	2511140	05/2016	05/25/2016	100.030	99.980	100.0	1
KU	C1SR	2511141	05/2016	05/25/2016	100.010	99.960	100.0	1
KU	C1SR	2511142	05/2016	05/25/2016	100.010	100.030	100.1	1
KU	C1SR	2511143	05/2016	05/25/2016	99.950	100.030	100.1	1
KU	C1SR	2511144	05/2016	05/25/2016	99.990	100.010	100.0	1
KU	C1SR	2511145	05/2016	05/25/2016	99.990	99.970	100.1	1
KU	C1SR	2511146	05/2016	05/25/2016	100.010	99.940	100.0	1
KU	C1SR	2511147	05/2016	05/25/2016	100.040	99.970	100.0	1
KU	C1SR	2511148	05/2016	05/25/2016	100.020	99.940	99.9	1
KU	C1SR	2511149	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2511150	05/2016	05/25/2016	99.990	99.910	99.9	1
KU	C1SR	2511151	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2511152	05/2016	05/25/2016	100.000	99.900	100.0	1
KU	C1SR	2511153	05/2016	05/25/2016	100.000	100.030	100.1	1
KU	C1SR	2511154	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2511155	05/2016	05/25/2016	99.970	100.000	100.0	1
KU	C1SR	2511156	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2511157	05/2016	05/25/2016	100.020	99.990	100.1	1
KU	C1SR	2511158	05/2016	05/25/2016	100.000	99.940	99.8	1
KU	C1SR	2511159	05/2016	05/25/2016	100.020	100.020	100.1	1
KU	C1SR	2511160	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511161	05/2016	05/25/2016	99.980	99.990	100.0	1
KU	C1SR	2511162	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511163	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2511164	05/2016	05/25/2016	99.970	99.900	99.9	1
KU	C1SR	2511165	05/2016	05/25/2016	100.020	99.870	99.9	1
KU	C1SR	2511166	05/2016	05/25/2016	100.010	100.020	100.0	1
KU	C1SR	2511167	05/2016	05/25/2016	99.990	99.890	99.9	1
KU	C1SR	2511168	05/2016	05/25/2016	100.020	99.990	100.0	1
KU	C1SR	2511169	05/2016	05/25/2016	100.010	100.030	100.1	1

KU	C1SR	2511170	05/2016	05/25/2016	100.000	99.980	100.1	1
KU	C1SR	2511171	05/2016	05/25/2016	99.990	99.970	99.9	1
KU	C1SR	2511172	05/2016	05/25/2016	100.020	99.920	100.0	1
KU	C1SR	2511173	05/2016	05/25/2016	100.020	99.990	100.1	1
KU	C1SR	2511174	05/2016	05/25/2016	99.980	99.940	100.0	1
KU	C1SR	2511175	05/2016	05/25/2016	100.010	99.980	100.0	1
KU	C1SR	2511176	05/2016	05/25/2016	100.010	99.910	99.9	1
KU	C1SR	2511177	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2511178	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2511179	05/2016	05/25/2016	100.000	100.000	100.0	1
KU	C1SR	2511180	05/2016	05/25/2016	100.040	100.010	100.0	1
KU	C1SR	2511181	05/2016	05/25/2016	99.980	100.020	100.1	1
KU	C1SR	2511182	05/2016	05/25/2016	100.000	100.010	100.0	1
KU	C1SR	2511183	05/2016	05/25/2016	99.990	99.940	100.0	1
KU	C1SR	2511184	05/2016	05/25/2016	100.020	99.980	100.0	1
KU	C1SR	2511185	05/2016	05/25/2016	100.020	99.930	99.9	1
KU	C1SR	2511186	05/2016	05/25/2016	100.030	100.010	100.0	1
KU	C1SR	2511187	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2511188	05/2016	05/25/2016	99.990	99.950	100.0	1
KU	C1SR	2511189	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511190	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511191	05/2016	05/25/2016	99.990	99.940	100.0	1
KU	C1SR	2511192	05/2016	05/25/2016	100.020	100.050	100.1	1
KU	C1SR	2511193	05/2016	05/25/2016	99.990	99.930	100.0	1
KU	C1SR	2511194	05/2016	05/25/2016	100.000	99.920	100.0	1
KU	C1SR	2511195	05/2016	05/25/2016	100.010	99.990	100.0	1
KU	C1SR	2511196	05/2016	05/25/2016	100.000	99.920	99.9	1
KU	C1SR	2511197	05/2016	05/25/2016	100.010	99.920	99.9	1
KU	C1SR	2511198	05/2016	05/25/2016	99.980	99.970	100.0	1
KU	C1SR	2511199	05/2016	05/25/2016	99.960	99.910	99.9	1
KU	C1SR	2511200	05/2016	05/25/2016	100.000	99.990	100.0	1
KU	C1SR	2511201	05/2016	05/25/2016	100.000	99.930	100.0	1
KU	C1SR	2511202	05/2016	05/25/2016	100.000	99.950	99.9	1
KU	C1SR	2511203	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2511204	05/2016	05/25/2016	99.990	99.970	100.0	1
KU	C1SR	2511205	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2511206	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2511207	05/2016	05/25/2016	100.040	99.970	100.0	1
KU	C1SR	2511208	05/2016	05/25/2016	99.940	99.960	100.0	1
KU	C1SR	2511209	05/2016	05/25/2016	99.990	99.980	100.0	1
KU	C1SR	2511210	05/2016	05/25/2016	100.010	100.010	100.0	1
KU	C1SR	2511211	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2511212	05/2016	05/25/2016	100.030	100.010	100.0	1
KU	C1SR	2511213	05/2016	05/25/2016	99.970	99.960	100.0	1
KU	C1SR	2511214	05/2016	05/25/2016	100.000	99.940	100.0	1

KU	C1SR	2511215	05/2016	05/25/2016	100.010	100.000	100.0	1
KU	C1SR	2511216	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511217	05/2016	05/25/2016	99.980	99.980	100.0	1
KU	C1SR	2511218	05/2016	05/25/2016	100.000	99.970	100.0	1
KU	C1SR	2511219	05/2016	05/25/2016	99.980	100.010	100.0	1
KU	C1SR	2511220	05/2016	05/25/2016	100.000	100.040	100.1	1
KU	C1SR	2511221	05/2016	05/25/2016	99.990	100.000	100.0	1
KU	C1SR	2511222	05/2016	05/25/2016	100.020	100.000	100.0	1
KU	C2SOS	2401032	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401033	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401034	02/2016	02/01/2016	100.030	100.030	99.9	1
KU	C2SOS	2401035	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401036	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401037	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401038	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401039	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401040	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401041	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401042	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401043	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401044	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401045	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401046	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401047	02/2016	02/01/2016	100.040	99.990	100.0	1
KU	C2SOS	2401048	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401049	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401050	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401051	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401052	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401053	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401054	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401055	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401056	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401057	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401058	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401059	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401060	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401061	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401062	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401063	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401064	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401065	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401066	02/2016	02/01/2016	100.050	100.070	100.1	1
KU	C2SOS	2401067	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401068	02/2016	02/01/2016	100.030	100.050	100.0	1

KU	C2SOS	2401069	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401070	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401071	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401072	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401073	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401074	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401075	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401076	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401077	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401078	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401079	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401080	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401081	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401082	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401083	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401084	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401085	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401086	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401087	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401088	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401089	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401090	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401091	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401092	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401093	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401094	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401095	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401096	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401097	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401098	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401099	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401100	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401101	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401102	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401103	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401104	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401105	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401106	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401107	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401108	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401109	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401110	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401111	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401112	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401113	02/2016	02/01/2016	100.030	100.030	100.0	1

KU	C2SOS	2401114	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401115	02/2016	02/01/2016	100.040	100.080	100.1	1
KU	C2SOS	2401116	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401117	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401118	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401119	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401120	02/2016	02/01/2016	100.020	99.980	100.0	1
KU	C2SOS	2401121	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401122	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401123	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401124	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401125	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401126	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401127	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401128	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401129	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401130	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401131	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401132	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401133	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401134	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401135	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401136	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401137	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401138	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401139	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401140	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401141	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401142	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401143	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401144	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401145	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401146	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401147	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401148	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401149	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401150	02/2016	02/01/2016	100.040	100.010	100.0	1
KU	C2SOS	2401151	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401152	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401153	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401154	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401155	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401156	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401157	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401158	02/2016	02/01/2016	100.020	100.020	100.0	1

KU	C2SOS	2401159	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401160	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401161	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401162	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401163	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401164	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401165	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401166	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401167	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401168	02/2016	02/01/2016	100.030	99.980	100.0	1
KU	C2SOS	2401169	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401170	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401171	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401172	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401173	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401174	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401175	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401176	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401177	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401178	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401179	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401180	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401181	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401182	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401183	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401184	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401185	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401186	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401187	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401188	02/2016	02/01/2016	100.050	100.070	100.0	1
KU	C2SOS	2401189	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401190	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401191	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401192	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401193	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401194	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401195	02/2016	02/01/2016	100.010	99.970	100.0	1
KU	C2SOS	2401196	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401197	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401198	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401199	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401200	02/2016	02/01/2016	100.030	99.990	99.9	1
KU	C2SOS	2401201	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401202	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401203	02/2016	02/01/2016	100.040	100.050	100.0	1

KU	C2SOS	2401204	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401205	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401206	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401207	02/2016	02/01/2016	100.040	100.080	100.0	1
KU	C2SOS	2401208	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401209	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401210	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401211	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401212	02/2016	02/01/2016	100.020	100.070	100.0	1
KU	C2SOS	2401213	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401214	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401215	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401216	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401217	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401218	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401219	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401220	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401221	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401222	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401223	02/2016	02/01/2016	100.030	99.980	100.0	1
KU	C2SOS	2401224	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401225	02/2016	02/01/2016	100.040	100.090	100.0	1
KU	C2SOS	2401226	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401227	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401228	02/2016	02/01/2016	100.010	100.030	100.0	1
KU	C2SOS	2401229	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401230	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401231	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401232	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401233	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401234	02/2016	02/01/2016	100.050	100.040	100.0	1
KU	C2SOS	2401235	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401236	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401237	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401238	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401239	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401240	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401241	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401242	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401243	02/2016	02/01/2016	100.030	99.970	100.0	1
KU	C2SOS	2401244	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401245	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401246	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401247	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401248	02/2016	02/01/2016	100.040	100.080	100.0	1

KU	C2SOS	2401249	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401250	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401251	02/2016	02/01/2016	100.040	100.010	100.0	1
KU	C2SOS	2401252	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401253	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401254	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401255	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401256	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401257	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401258	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401259	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401260	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401261	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401262	02/2016	02/01/2016	100.010	100.000	100.0	1
KU	C2SOS	2401263	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401264	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401265	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401266	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401267	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401268	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401269	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401270	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401271	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401272	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401273	02/2016	02/01/2016	100.040	100.070	100.1	1
KU	C2SOS	2401274	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401275	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401276	02/2016	02/01/2016	100.040	100.060	100.1	1
KU	C2SOS	2401277	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401278	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401279	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401280	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401281	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401282	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401283	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401284	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401285	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401286	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401287	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401288	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401289	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401290	02/2016	02/01/2016	100.030	100.050	100.1	1
KU	C2SOS	2401291	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401292	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401293	02/2016	02/01/2016	100.030	100.020	100.0	1

KU	C2SOS	2401294	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401295	02/2016	02/01/2016	100.010	100.020	100.0	1
KU	C2SOS	2401296	02/2016	02/01/2016	100.040	100.000	100.0	1
KU	C2SOS	2401297	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401298	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401299	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401300	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401301	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401302	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401303	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401304	02/2016	02/01/2016	100.030	100.080	100.0	1
KU	C2SOS	2401305	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401306	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401307	02/2016	02/01/2016	100.020	100.070	100.0	1
KU	C2SOS	2401308	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401309	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401310	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401311	02/2016	02/01/2016	100.020	99.970	100.0	1
KU	C2SOS	2401312	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401313	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401314	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401315	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401316	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401317	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401318	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401319	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401320	02/2016	02/01/2016	100.010	100.050	100.0	1
KU	C2SOS	2401321	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401322	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401323	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401324	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401325	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401326	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401327	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401328	02/2016	02/01/2016	100.020	99.990	100.0	1
KU	C2SOS	2401329	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401330	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401331	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401332	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401333	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401334	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401335	02/2016	02/01/2016	100.020	99.990	100.0	1
KU	C2SOS	2401336	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401337	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401338	02/2016	02/01/2016	100.020	100.070	100.0	1

KU	C2S0S	2401339	02/2016	02/01/2016	100.020	99.980	100.0	1
KU	C2S0S	2401340	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2S0S	2401341	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2S0S	2401342	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2S0S	2401343	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2S0S	2401344	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2S0S	2401346	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2S0S	2401347	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2S0S	2401348	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2S0S	2401349	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2S0S	2401350	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2S0S	2401351	02/2016	02/01/2016	100.040	100.010	100.0	1
KU	C2S0S	2401352	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2S0S	2401353	02/2016	02/01/2016	100.030	99.970	100.0	1
KU	C2S0S	2401354	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2S0S	2401355	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2S0S	2401356	02/2016	02/01/2016	100.040	100.010	100.0	1
KU	C2S0S	2401357	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2S0S	2401358	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2S0S	2401359	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2S0S	2401360	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2S0S	2401361	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2S0S	2401362	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2S0S	2401363	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2S0S	2401364	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2S0S	2401365	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2S0S	2401366	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2S0S	2401367	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2S0S	2401368	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2S0S	2401369	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2S0S	2401370	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2S0S	2401371	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2S0S	2401372	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2S0S	2401373	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2S0S	2401374	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2S0S	2401375	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2S0S	2401376	02/2016	02/01/2016	100.040	100.080	100.0	1
KU	C2S0S	2401377	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2S0S	2401378	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2S0S	2401379	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2S0S	2401380	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2S0S	2401381	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2S0S	2401382	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2S0S	2401383	02/2016	02/01/2016	100.030	100.030	100.0	1

KU	C2SOS	2401384	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401385	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401386	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401387	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401388	02/2016	02/01/2016	100.040	100.060	100.1	1
KU	C2SOS	2401389	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401390	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401391	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401392	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401393	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401394	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401395	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401396	02/2016	02/01/2016	100.040	100.080	100.0	1
KU	C2SOS	2401397	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401398	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401399	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401400	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401401	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401402	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401403	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401404	02/2016	02/01/2016	100.020	100.070	100.0	1
KU	C2SOS	2401405	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401406	02/2016	02/01/2016	100.020	99.980	99.9	1
KU	C2SOS	2401407	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401408	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401409	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401410	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401411	02/2016	02/01/2016	100.030	99.990	100.0	1
KU	C2SOS	2401412	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401413	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401414	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401415	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401416	02/2016	02/01/2016	100.030	100.000	100.0	1
KU	C2SOS	2401417	02/2016	02/01/2016	100.030	100.050	100.1	1
KU	C2SOS	2401418	02/2016	02/01/2016	100.020	100.000	100.0	1
KU	C2SOS	2401419	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401420	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401421	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401422	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401423	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401424	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401425	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401426	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401427	02/2016	02/01/2016	100.030	100.020	100.0	1
KU	C2SOS	2401428	02/2016	02/01/2016	100.040	100.040	100.0	1

KU	C2SOS	2401429	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401430	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401431	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401432	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401433	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401434	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401435	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401436	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401437	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401438	02/2016	02/01/2016	100.020	100.010	100.0	1
KU	C2SOS	2401439	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401440	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401441	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401442	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401443	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401444	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401445	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401446	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401447	02/2016	02/01/2016	100.020	100.020	100.0	1
KU	C2SOS	2401448	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401449	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401450	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401451	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401452	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401453	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401454	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401455	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401456	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401457	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401458	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401459	02/2016	02/01/2016	100.030	99.980	100.0	1
KU	C2SOS	2401460	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401461	02/2016	02/01/2016	100.040	100.060	100.1	1
KU	C2SOS	2401462	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401463	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401464	02/2016	02/01/2016	100.030	100.070	100.0	1
KU	C2SOS	2401465	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401466	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401467	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401468	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401469	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401470	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401471	02/2016	02/01/2016	100.020	100.060	100.0	1
KU	C2SOS	2401472	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401473	02/2016	02/01/2016	100.030	100.020	100.0	1

KU	C2SOS	2401474	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401475	02/2016	02/01/2016	100.040	100.070	100.0	1
KU	C2SOS	2401476	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401477	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401478	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401479	02/2016	02/01/2016	100.020	100.080	100.0	1
KU	C2SOS	2401480	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401481	02/2016	02/01/2016	100.050	100.060	100.0	1
KU	C2SOS	2401482	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401483	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401484	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401485	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401486	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401487	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401488	02/2016	02/01/2016	100.040	100.030	100.0	1
KU	C2SOS	2401489	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401490	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401491	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401492	02/2016	02/01/2016	100.040	100.020	100.0	1
KU	C2SOS	2401493	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401494	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401495	02/2016	02/01/2016	100.030	100.040	100.0	1
KU	C2SOS	2401496	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401497	02/2016	02/01/2016	100.020	100.050	100.0	1
KU	C2SOS	2401498	02/2016	02/01/2016	100.030	100.060	100.0	1
KU	C2SOS	2401499	02/2016	02/01/2016	100.030	100.050	100.0	1
KU	C2SOS	2401500	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401501	02/2016	02/01/2016	100.030	100.010	100.0	1
KU	C2SOS	2401502	02/2016	02/01/2016	100.020	100.030	100.0	1
KU	C2SOS	2401503	02/2016	02/01/2016	100.050	100.060	100.0	1
KU	C2SOS	2401504	02/2016	02/01/2016	100.040	100.040	100.0	1
KU	C2SOS	2401505	02/2016	02/01/2016	100.040	100.060	100.0	1
KU	C2SOS	2401506	02/2016	02/01/2016	100.040	100.050	100.0	1
KU	C2SOS	2401507	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401508	02/2016	02/01/2016	100.030	100.030	100.0	1
KU	C2SOS	2401509	02/2016	02/01/2016	100.040	100.080	100.1	1
KU	C2SOS	2401510	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2401511	02/2016	02/01/2016	100.020	100.040	100.0	1
KU	C2SOS	2402376	09/2016	08/25/2016	100.020	100.010	100.0	1
KU	C2SOS	2402377	09/2016	08/25/2016	100.020	100.130	100.0	1
KU	C2SOS	2402378	09/2016	08/25/2016	100.020	100.060	100.0	1
KU	C2SOS	2402379	09/2016	08/25/2016	100.020	100.130	100.1	1
KU	C2SOS	2402380	09/2016	08/25/2016	100.040	100.000	100.1	1
KU	C2SOS	2402381	09/2016	08/25/2016	100.030	100.060	100.0	1
KU	C2SOS	2402382	09/2016	08/25/2016	100.010	100.000	100.0	1

KU	C2SOS	2402383	09/2016	08/25/2016	100.030	100.020	100.0	1
KU	C2SOS	2402384	09/2016	08/25/2016	100.020	100.000	100.0	1
KU	C2SOS	2402385	09/2016	08/25/2016	100.020	99.980	100.0	1
KU	C2SOS	2402386	09/2016	08/25/2016	100.010	100.000	100.0	1
KU	C2SOS	2402387	09/2016	08/25/2016	100.030	100.060	100.0	1
KU	C2SOS	2402388	09/2016	08/25/2016	100.030	100.010	100.0	1
KU	C2SOS	2402389	09/2016	08/25/2016	100.040	100.050	100.0	1
KU	C2SOS	2402390	09/2016	08/25/2016	100.030	100.050	100.0	1
KU	C2SOS	2402391	09/2016	08/25/2016	100.030	99.970	100.0	1
KU	C2SOS	2402392	09/2016	08/25/2016	100.010	99.980	100.0	1
KU	C2SOS	2402393	09/2016	08/25/2016	100.020	99.980	100.0	1
KU	C2SOS	2402394	09/2016	08/25/2016	100.030	99.970	100.0	1
KU	C2SOS	2402395	09/2016	08/25/2016	100.010	99.990	100.0	1
KU	C2SOS	2402400	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402401	09/2016	09/24/2016	100.030	100.050	100.1	1
KU	C2SOS	2402402	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402403	09/2016	09/24/2016	100.030	99.940	100.0	1
KU	C2SOS	2402404	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402405	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402406	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402407	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402408	09/2016	09/24/2016	100.030	100.090	100.0	1
KU	C2SOS	2402409	09/2016	09/24/2016	100.020	100.050	100.0	1
KU	C2SOS	2402410	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402411	09/2016	09/24/2016	100.030	99.970	100.0	1
KU	C2SOS	2402412	09/2016	09/24/2016	100.040	100.060	100.0	1
KU	C2SOS	2402413	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402414	09/2016	09/24/2016	100.030	99.990	100.0	1
KU	C2SOS	2402415	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402416	09/2016	09/24/2016	100.020	100.070	100.0	1
KU	C2SOS	2402417	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402418	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402419	09/2016	09/24/2016	100.030	100.060	100.1	1
KU	C2SOS	2402420	09/2016	09/24/2016	100.020	100.080	100.0	1
KU	C2SOS	2402421	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402422	09/2016	09/24/2016	100.030	100.070	100.1	1
KU	C2SOS	2402423	09/2016	09/24/2016	100.040	100.060	100.0	1
KU	C2SOS	2402424	09/2016	09/24/2016	100.040	100.040	100.0	1
KU	C2SOS	2402425	09/2016	09/24/2016	100.030	99.970	100.0	1
KU	C2SOS	2402426	09/2016	09/24/2016	100.030	99.880	100.0	1
KU	C2SOS	2402427	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402428	09/2016	09/24/2016	100.020	99.900	100.0	1
KU	C2SOS	2402429	09/2016	09/24/2016	100.030	100.030	100.0	1
KU	C2SOS	2402430	09/2016	09/24/2016	100.040	100.040	100.0	1
KU	C2SOS	2402431	09/2016	09/24/2016	100.030	100.030	100.0	1

KU	C2SOS	2402432	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402433	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402434	09/2016	09/24/2016	100.030	100.030	100.1	1
KU	C2SOS	2402435	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402436	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402437	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402438	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402439	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402440	09/2016	09/24/2016	100.030	100.040	100.0	1
KU	C2SOS	2402441	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402442	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402443	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402444	09/2016	09/24/2016	100.020	99.970	100.0	1
KU	C2SOS	2402445	09/2016	09/24/2016	100.020	100.030	100.0	1
KU	C2SOS	2402446	09/2016	09/24/2016	100.010	100.000	100.0	1
KU	C2SOS	2402447	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402448	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402449	09/2016	09/24/2016	100.030	99.980	100.0	1
KU	C2SOS	2402450	09/2016	09/24/2016	100.020	99.970	100.0	1
KU	C2SOS	2402451	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402452	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402453	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402454	09/2016	09/24/2016	100.010	100.010	100.0	1
KU	C2SOS	2402455	09/2016	09/24/2016	100.040	100.110	100.0	1
KU	C2SOS	2402456	09/2016	09/24/2016	100.030	99.960	100.0	1
KU	C2SOS	2402457	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402458	09/2016	09/24/2016	100.010	99.930	99.9	1
KU	C2SOS	2402459	09/2016	09/24/2016	100.010	100.000	100.0	1
KU	C2SOS	2402460	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402461	09/2016	09/24/2016	100.020	99.960	100.0	1
KU	C2SOS	2402462	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402463	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402464	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402465	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402466	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402467	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402468	09/2016	09/24/2016	100.020	100.080	100.0	1
KU	C2SOS	2402469	09/2016	09/24/2016	100.040	100.050	100.0	1
KU	C2SOS	2402470	09/2016	09/24/2016	100.010	100.020	100.0	1
KU	C2SOS	2402471	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402472	09/2016	09/24/2016	100.010	99.990	100.0	1
KU	C2SOS	2402473	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402474	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402475	09/2016	09/24/2016	100.030	100.130	100.1	1
KU	C2SOS	2402476	09/2016	09/24/2016	100.010	100.040	100.0	1

KU	C2SOS	2402477	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402478	09/2016	09/24/2016	100.010	99.990	100.0	1
KU	C2SOS	2402479	09/2016	09/24/2016	100.050	100.100	100.0	1
KU	C2SOS	2402480	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402481	09/2016	09/24/2016	100.030	99.930	100.0	1
KU	C2SOS	2402482	09/2016	09/24/2016	100.040	99.940	100.0	1
KU	C2SOS	2402483	09/2016	09/24/2016	100.040	100.030	100.0	1
KU	C2SOS	2402484	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402485	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402486	09/2016	09/24/2016	100.040	100.060	100.1	1
KU	C2SOS	2402487	09/2016	09/24/2016	100.030	100.030	100.0	1
KU	C2SOS	2402488	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402489	09/2016	09/24/2016	100.020	100.070	100.0	1
KU	C2SOS	2402490	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402491	09/2016	09/24/2016	100.020	99.960	100.0	1
KU	C2SOS	2402492	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402493	09/2016	09/24/2016	100.040	100.080	100.0	1
KU	C2SOS	2402494	09/2016	09/24/2016	100.030	100.110	100.1	1
KU	C2SOS	2402495	09/2016	09/24/2016	100.010	99.990	100.0	1
KU	C2SOS	2402496	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402497	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402498	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402499	09/2016	09/24/2016	100.020	99.970	100.0	1
KU	C2SOS	2402500	09/2016	09/24/2016	100.020	99.960	100.0	1
KU	C2SOS	2402501	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402502	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402503	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402504	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402505	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402506	09/2016	09/24/2016	100.030	99.960	100.0	1
KU	C2SOS	2402507	09/2016	09/24/2016	100.030	99.940	100.0	1
KU	C2SOS	2402508	09/2016	09/24/2016	100.020	100.030	100.0	1
KU	C2SOS	2402509	09/2016	09/24/2016	100.020	99.950	100.0	1
KU	C2SOS	2402510	09/2016	09/24/2016	100.040	100.000	100.0	1
KU	C2SOS	2402511	09/2016	09/24/2016	100.030	100.080	100.0	1
KU	C2SOS	2402512	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402513	09/2016	09/24/2016	100.030	99.920	100.0	1
KU	C2SOS	2402514	09/2016	09/24/2016	100.020	100.050	100.0	1
KU	C2SOS	2402515	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402516	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402517	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402518	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402519	09/2016	09/24/2016	100.040	100.000	100.0	1
KU	C2SOS	2402520	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402521	09/2016	09/24/2016	100.060	100.070	100.1	1

KU	C2SOS	2402522	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402523	09/2016	09/24/2016	100.050	100.090	100.1	1
KU	C2SOS	2402524	09/2016	09/24/2016	100.030	100.040	100.0	1
KU	C2SOS	2402525	09/2016	09/24/2016	100.020	100.030	100.0	1
KU	C2SOS	2402526	09/2016	09/24/2016	100.040	100.110	100.0	1
KU	C2SOS	2402527	09/2016	09/24/2016	100.050	100.010	100.0	1
KU	C2SOS	2402528	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402529	09/2016	09/24/2016	100.030	100.140	100.0	1
KU	C2SOS	2402530	09/2016	09/24/2016	100.050	100.040	100.0	1
KU	C2SOS	2402531	09/2016	09/24/2016	100.030	99.870	100.0	1
KU	C2SOS	2402532	09/2016	09/24/2016	100.030	99.900	100.0	1
KU	C2SOS	2402533	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402534	09/2016	09/24/2016	100.040	100.030	100.0	1
KU	C2SOS	2402535	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402536	09/2016	09/24/2016	100.060	99.920	100.0	1
KU	C2SOS	2402537	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402538	09/2016	09/24/2016	100.040	100.130	100.0	1
KU	C2SOS	2402539	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402540	09/2016	09/24/2016	100.030	100.110	100.1	1
KU	C2SOS	2402541	09/2016	09/24/2016	100.030	99.870	100.0	1
KU	C2SOS	2402542	09/2016	09/24/2016	100.010	100.000	100.0	1
KU	C2SOS	2402543	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402544	09/2016	09/24/2016	100.040	100.150	100.1	1
KU	C2SOS	2402545	09/2016	09/24/2016	100.020	100.050	100.0	1
KU	C2SOS	2402546	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402547	09/2016	09/24/2016	100.050	100.090	100.1	1
KU	C2SOS	2402548	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402549	09/2016	09/24/2016	100.040	100.090	100.1	1
KU	C2SOS	2402550	09/2016	09/24/2016	100.040	99.960	100.0	1
KU	C2SOS	2402551	09/2016	09/24/2016	100.060	100.070	100.1	1
KU	C2SOS	2402552	09/2016	09/24/2016	100.050	100.080	100.0	1
KU	C2SOS	2402553	09/2016	09/24/2016	100.030	99.880	100.0	1
KU	C2SOS	2402554	09/2016	09/24/2016	100.050	100.100	100.1	1
KU	C2SOS	2402555	09/2016	09/24/2016	100.040	100.090	100.0	1
KU	C2SOS	2402556	09/2016	09/24/2016	100.060	100.100	100.1	1
KU	C2SOS	2402557	09/2016	09/24/2016	100.040	100.140	100.0	1
KU	C2SOS	2402558	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402559	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402560	09/2016	09/24/2016	100.020	100.130	100.1	1
KU	C2SOS	2402561	09/2016	09/24/2016	100.040	100.150	100.1	1
KU	C2SOS	2402562	09/2016	09/24/2016	100.040	100.050	100.1	1
KU	C2SOS	2402563	09/2016	09/24/2016	100.040	100.130	100.0	1
KU	C2SOS	2402564	09/2016	09/24/2016	100.040	100.050	100.0	1
KU	C2SOS	2402565	09/2016	09/24/2016	100.050	100.010	100.1	1
KU	C2SOS	2402566	09/2016	09/24/2016	100.030	100.000	100.0	1

KU	C2SOS	2402567	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402568	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402569	09/2016	09/24/2016	100.040	100.120	100.1	1
KU	C2SOS	2402570	09/2016	09/24/2016	100.010	100.030	100.0	1
KU	C2SOS	2402571	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402572	09/2016	09/24/2016	100.080	100.120	100.1	1
KU	C2SOS	2402573	09/2016	09/24/2016	100.030	100.100	100.1	1
KU	C2SOS	2402574	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402575	09/2016	09/24/2016	100.030	99.980	100.0	1
KU	C2SOS	2402576	09/2016	09/24/2016	100.030	100.050	100.1	1
KU	C2SOS	2402577	09/2016	09/24/2016	100.030	99.990	100.0	1
KU	C2SOS	2402578	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402579	09/2016	09/24/2016	100.010	99.980	100.0	1
KU	C2SOS	2402580	09/2016	09/24/2016	100.020	100.060	100.0	1
KU	C2SOS	2402581	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402582	09/2016	09/24/2016	100.030	100.100	100.0	1
KU	C2SOS	2402583	09/2016	09/24/2016	100.020	100.040	100.0	1
KU	C2SOS	2402584	09/2016	09/24/2016	100.040	99.950	100.0	1
KU	C2SOS	2402585	09/2016	09/24/2016	100.040	100.030	100.0	1
KU	C2SOS	2402586	09/2016	09/24/2016	100.030	100.090	100.0	1
KU	C2SOS	2402587	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402588	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402589	09/2016	09/24/2016	100.030	100.150	100.0	1
KU	C2SOS	2402590	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402591	09/2016	09/24/2016	100.050	100.120	100.0	1
KU	C2SOS	2402592	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402593	09/2016	09/24/2016	100.030	100.000	100.0	1
KU	C2SOS	2402594	09/2016	09/24/2016	100.020	99.970	100.0	1
KU	C2SOS	2402595	09/2016	09/24/2016	100.040	99.990	100.1	1
KU	C2SOS	2402596	09/2016	09/24/2016	100.040	100.000	100.0	1
KU	C2SOS	2402597	09/2016	09/24/2016	100.030	99.880	100.0	1
KU	C2SOS	2402598	09/2016	09/24/2016	100.030	99.960	100.0	1
KU	C2SOS	2402599	09/2016	09/24/2016	100.030	100.160	100.0	1
KU	C2SOS	2402600	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402601	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402602	09/2016	09/24/2016	100.030	100.140	100.0	1
KU	C2SOS	2402603	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402604	09/2016	09/24/2016	100.030	99.990	100.0	1
KU	C2SOS	2402605	09/2016	09/24/2016	100.030	100.030	100.0	1
KU	C2SOS	2402606	09/2016	09/24/2016	100.030	99.950	100.0	1
KU	C2SOS	2402607	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402608	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402609	09/2016	09/24/2016	100.050	100.140	100.1	1
KU	C2SOS	2402610	09/2016	09/24/2016	100.040	100.130	100.1	1
KU	C2SOS	2402611	09/2016	09/24/2016	100.000	100.010	100.0	1

KU	C2SOS	2402612	09/2016	09/24/2016	100.040	100.050	100.0	1
KU	C2SOS	2402613	09/2016	09/24/2016	100.020	99.860	100.0	1
KU	C2SOS	2402614	09/2016	09/24/2016	100.050	100.050	100.0	1
KU	C2SOS	2402615	09/2016	09/24/2016	100.030	99.910	100.0	1
KU	C2SOS	2402616	09/2016	09/24/2016	100.040	100.060	100.1	1
KU	C2SOS	2402617	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402618	09/2016	09/24/2016	100.030	100.100	100.0	1
KU	C2SOS	2402619	09/2016	09/24/2016	100.030	99.920	100.0	1
KU	C2SOS	2402620	09/2016	09/24/2016	100.030	100.130	100.0	1
KU	C2SOS	2402621	09/2016	09/24/2016	100.030	99.910	100.0	1
KU	C2SOS	2402622	09/2016	09/24/2016	100.040	100.130	100.1	1
KU	C2SOS	2402623	09/2016	09/24/2016	100.050	100.140	100.0	1
KU	C2SOS	2402624	09/2016	09/24/2016	100.040	100.130	100.0	1
KU	C2SOS	2402625	09/2016	09/24/2016	100.030	100.110	100.0	1
KU	C2SOS	2402626	09/2016	09/24/2016	100.030	100.020	100.0	1
KU	C2SOS	2402627	09/2016	09/24/2016	100.040	99.950	100.0	1
KU	C2SOS	2402628	09/2016	09/24/2016	100.040	99.890	100.0	1
KU	C2SOS	2402629	09/2016	09/24/2016	100.050	99.910	100.0	1
KU	C2SOS	2402630	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402631	09/2016	09/24/2016	100.030	100.030	100.0	1
KU	C2SOS	2402632	09/2016	09/24/2016	100.030	100.080	100.1	1
KU	C2SOS	2402633	09/2016	09/24/2016	100.030	100.040	100.0	1
KU	C2SOS	2402634	09/2016	09/24/2016	100.030	99.900	100.0	1
KU	C2SOS	2402635	09/2016	09/24/2016	100.050	100.090	100.0	1
KU	C2SOS	2402636	09/2016	09/24/2016	100.020	100.070	100.0	1
KU	C2SOS	2402637	09/2016	09/24/2016	100.030	100.070	100.0	1
KU	C2SOS	2402638	09/2016	09/24/2016	100.040	100.040	100.0	1
KU	C2SOS	2402639	09/2016	09/24/2016	100.030	100.090	100.0	1
KU	C2SOS	2402640	09/2016	09/24/2016	100.040	100.150	100.0	1
KU	C2SOS	2402641	09/2016	09/24/2016	100.040	100.050	100.0	1
KU	C2SOS	2402642	09/2016	09/24/2016	100.030	99.980	100.0	1
KU	C2SOS	2402643	09/2016	09/24/2016	100.040	99.970	100.0	1
KU	C2SOS	2402644	09/2016	09/24/2016	100.050	100.000	100.1	1
KU	C2SOS	2402645	09/2016	09/24/2016	100.040	99.970	100.0	1
KU	C2SOS	2402646	09/2016	09/24/2016	100.030	99.970	100.0	1
KU	C2SOS	2402647	09/2016	09/24/2016	100.030	100.060	100.0	1
KU	C2SOS	2402648	09/2016	09/24/2016	100.040	100.170	100.0	1
KU	C2SOS	2402649	09/2016	09/24/2016	100.040	100.130	100.0	1
KU	C2SOS	2402650	09/2016	09/24/2016	100.040	99.970	100.0	1
KU	C2SOS	2402651	09/2016	09/24/2016	100.040	100.040	100.0	1
KU	C2SOS	2402652	09/2016	09/24/2016	100.040	100.140	100.0	1
KU	C2SOS	2402653	09/2016	09/24/2016	100.030	100.050	100.0	1
KU	C2SOS	2402654	09/2016	09/24/2016	100.050	100.100	100.0	1
KU	C2SOS	2402655	09/2016	09/24/2016	100.030	99.930	100.0	1
KU	C2SOS	2402656	09/2016	09/24/2016	100.030	99.970	100.0	1

KU	C2SOS	2402657	09/2016	09/24/2016	100.050	100.050	100.050	100.0	1
KU	C2SOS	2402658	09/2016	09/24/2016	100.030	99.960	100.0	1	1
KU	C2SOS	2402659	09/2016	09/24/2016	100.040	99.980	100.1	1	1
KU	C2SOS	2402660	09/2016	09/24/2016	100.020	100.060	100.0	1	1
KU	C2SOS	2402661	09/2016	09/24/2016	100.030	100.030	100.1	1	1
KU	C2SOS	2402662	09/2016	09/24/2016	100.040	100.080	100.0	1	1
KU	C2SOS	2402663	09/2016	09/24/2016	100.030	100.040	100.1	1	1
KU	C2SOS	2402664	09/2016	09/24/2016	100.050	99.890	100.0	1	1
KU	C2SOS	2402665	09/2016	09/24/2016	100.050	99.920	100.0	1	1
KU	C2SOS	2402666	09/2016	09/24/2016	100.030	100.000	100.0	1	1
KU	C2SOS	2402667	09/2016	09/24/2016	100.030	100.050	100.0	1	1
KU	C2SOS	2402668	09/2016	09/24/2016	100.040	100.120	100.1	1	1
KU	C2SOS	2402669	09/2016	09/24/2016	100.030	100.000	100.0	1	1
KU	C2SOS	2402670	09/2016	09/24/2016	100.040	100.090	100.0	1	1
KU	C2SOS	2402671	09/2016	09/24/2016	100.030	100.030	100.0	1	1
KU	C2SOS	2402672	09/2016	09/24/2016	100.040	100.070	100.0	1	1
KU	C2SOS	2402673	09/2016	09/24/2016	100.030	99.950	100.0	1	1
KU	C2SOS	2402674	09/2016	09/24/2016	100.040	100.110	100.0	1	1
KU	C2SOS	2402675	09/2016	09/24/2016	100.050	99.970	100.0	1	1
KU	C2SOS	2402676	09/2016	09/24/2016	100.040	99.960	100.0	1	1
KU	C2SOS	2402677	09/2016	09/24/2016	100.020	100.050	100.0	1	1
KU	C2SOS	2402678	09/2016	09/24/2016	100.030	99.970	100.0	1	1
KU	C2SOS	2402679	09/2016	09/24/2016	100.030	99.980	100.0	1	1
KU	C2SOS	2402680	09/2016	09/24/2016	100.040	100.130	100.1	1	1
KU	C2SOS	2402681	09/2016	09/24/2016	100.050	100.140	100.0	1	1
KU	C2SOS	2402682	09/2016	09/24/2016	100.020	100.110	100.0	1	1
KU	C2SOS	2402683	09/2016	09/24/2016	100.030	99.980	100.0	1	1
KU	C2SOS	2402684	09/2016	09/24/2016	100.040	100.130	100.0	1	1
KU	C2SOS	2402685	09/2016	09/24/2016	100.030	100.010	100.0	1	1
KU	C2SOS	2402686	09/2016	09/24/2016	100.020	100.030	100.1	1	1
KU	C2SOS	2402687	09/2016	09/24/2016	100.030	100.040	100.0	1	1
KU	C2SOS	2402688	09/2016	09/24/2016	100.020	100.040	100.0	1	1
KU	C2SOS	2402689	09/2016	09/24/2016	100.040	100.020	100.0	1	1
KU	C2SOS	2402690	09/2016	09/24/2016	100.030	100.070	100.0	1	1
KU	C2SOS	2402691	09/2016	09/24/2016	100.030	100.040	100.0	1	1
KU	C2SOS	2402692	09/2016	09/24/2016	100.030	100.040	100.0	1	1
KU	C2SOS	2402693	09/2016	09/24/2016	100.020	100.050	100.0	1	1
KU	C2SOS	2402694	09/2016	09/24/2016	100.030	100.030	100.0	1	1
KU	C2SOS	2402695	09/2016	09/24/2016	100.040	100.120	100.0	1	1
KU	C2SOS	2402696	09/2016	09/24/2016	100.050	100.090	100.1	1	1
KU	C2SOS	2402697	09/2016	09/24/2016	100.040	100.140	100.0	1	1
KU	C2SOS	2402698	09/2016	09/24/2016	100.040	100.080	100.0	1	1
KU	C2SOS	2402699	09/2016	09/24/2016	100.000	99.990	100.0	1	1
KU	C2SOS	2402700	09/2016	09/24/2016	100.040	100.030	100.1	1	1
KU	C2SOS	2402701	09/2016	09/24/2016	100.050	100.160	100.0	1	1

KU	C2SOS	2402702	09/2016	09/24/2016	100.040	99.950	100.0	1
KU	C2SOS	2402703	09/2016	09/24/2016	100.030	99.930	100.0	1
KU	C2SOS	2402704	09/2016	09/24/2016	100.020	99.980	100.0	1
KU	C2SOS	2402705	09/2016	09/24/2016	100.040	100.020	100.0	1
KU	C2SOS	2402706	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402707	09/2016	09/24/2016	100.030	100.090	100.1	1
KU	C2SOS	2402708	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402709	09/2016	09/24/2016	100.030	99.980	100.0	1
KU	C2SOS	2402710	09/2016	09/24/2016	100.030	100.040	100.0	1
KU	C2SOS	2402711	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402712	09/2016	09/24/2016	100.050	100.090	100.0	1
KU	C2SOS	2402713	09/2016	09/24/2016	100.040	100.040	100.1	1
KU	C2SOS	2402714	09/2016	09/24/2016	100.050	100.070	100.1	1
KU	C2SOS	2402715	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402716	09/2016	09/24/2016	100.040	100.050	100.1	1
KU	C2SOS	2402717	09/2016	09/24/2016	100.030	100.060	100.1	1
KU	C2SOS	2402718	09/2016	09/24/2016	100.020	100.080	100.1	1
KU	C2SOS	2402719	09/2016	09/24/2016	100.030	99.960	100.0	1
KU	C2SOS	2402720	09/2016	09/24/2016	100.040	99.950	100.0	1
KU	C2SOS	2402721	09/2016	09/24/2016	100.030	99.870	100.0	1
KU	C2SOS	2402722	09/2016	09/24/2016	100.040	100.070	100.1	1
KU	C2SOS	2402723	09/2016	09/24/2016	100.020	100.020	100.0	1
KU	C2SOS	2402724	09/2016	09/24/2016	100.050	100.060	100.1	1
KU	C2SOS	2402725	09/2016	09/24/2016	100.040	100.090	100.1	1
KU	C2SOS	2402726	09/2016	09/24/2016	100.010	99.960	100.0	1
KU	C2SOS	2402727	09/2016	09/24/2016	100.050	100.070	100.0	1
KU	C2SOS	2402728	09/2016	09/24/2016	100.030	100.010	100.0	1
KU	C2SOS	2402729	09/2016	09/24/2016	100.020	99.990	100.0	1
KU	C2SOS	2402730	09/2016	09/24/2016	100.030	99.920	100.0	1
KU	C2SOS	2402731	09/2016	09/24/2016	100.020	100.000	100.0	1
KU	C2SOS	2402732	09/2016	09/24/2016	100.020	99.970	100.0	1
KU	C2SOS	2402733	09/2016	09/24/2016	100.040	100.080	100.0	1
KU	C2SOS	2402734	09/2016	09/24/2016	100.020	100.010	100.0	1
KU	C2SOS	2402735	09/2016	09/24/2016	100.030	100.040	100.0	1
KU	C2SOS	2402736	09/2016	09/24/2016	100.030	100.170	100.1	1
KU	C2SOS	2402737	09/2016	09/24/2016	100.020	100.030	100.1	1
KU	C2SOS	2402738	09/2016	09/24/2016	100.040	100.120	100.1	1
KU	C2SOS	2402739	09/2016	09/24/2016	100.040	99.990	100.0	1
KU	C2SOS	2402740	09/2016	08/25/2016	99.990	100.030	100.0	1
KU	C2SOS	2402741	09/2016	08/25/2016	99.990	99.960	100.0	1
KU	C2SOS	2402742	09/2016	08/25/2016	100.000	99.960	100.0	1
KU	C2SOS	2402743	09/2016	08/25/2016	99.990	99.990	100.0	1
KU	C2SOS	2402744	09/2016	08/25/2016	99.990	99.950	100.1	1
KU	C2SOS	2402745	09/2016	08/25/2016	99.980	100.010	100.0	1
KU	C2SOS	2402746	09/2016	08/25/2016	99.980	99.960	100.0	1

KU	C2SOS	2402747	09/2016	08/25/2016	99.990	100.000	100.0	1
KU	C2SOS	2402748	09/2016	08/25/2016	99.990	99.940	100.0	1
KU	C2SOS	2402749	09/2016	08/25/2016	99.990	99.920	99.9	1
KU	C2SOS	2402750	09/2016	08/25/2016	99.990	99.980	100.0	1
KU	C2SOS	2402751	09/2016	08/25/2016	99.990	99.950	100.0	1
KU	C2SOS	2402752	09/2016	08/25/2016	100.000	100.000	100.0	1
KU	C2SOS	2402753	09/2016	08/25/2016	100.000	100.000	100.0	1
KU	C2SOS	2402754	09/2016	08/25/2016	99.990	100.000	100.0	1
KU	C2SOS	2402755	09/2016	08/25/2016	99.980	100.010	100.0	1
KU	C2SOS	2402756	08/2016	08/16/2016	99.990	99.950	100.0	1
KU	C2SOS	2402757	08/2016	08/16/2016	100.000	100.010	100.1	1
KU	C2SOS	2402758	08/2016	08/16/2016	100.000	100.040	100.0	1
KU	C2SOS	2402759	08/2016	08/16/2016	99.990	100.000	100.1	1
KU	C2SOS	2402760	09/2016	09/20/2016	100.000	100.020	100.0	1
KU	C2SOS	2402761	09/2016	09/20/2016	99.990	99.990	100.0	1
KU	C2SOS	2402762	09/2016	09/20/2016	99.990	100.000	100.0	1
KU	C2SOS	2402763	09/2016	09/20/2016	100.000	100.020	100.0	1
KU	C2SOS	2402764	09/2016	09/20/2016	100.000	99.970	100.0	1
KU	C2SOS	2402765	09/2016	09/20/2016	99.990	99.960	100.0	1
KU	C2SOS	2402766	09/2016	09/20/2016	100.000	100.000	100.0	1
KU	C2SOS	2402767	09/2016	09/20/2016	99.990	100.000	100.0	1
KU	C2SOS	2402768	09/2016	09/20/2016	99.990	99.990	100.0	1
KU	C2SOS	2402769	09/2016	09/20/2016	99.990	99.960	99.9	1
KU	C2SOS	2402770	09/2016	09/20/2016	99.990	100.000	100.0	1
KU	C2SOS	2402771	09/2016	09/20/2016	100.000	99.980	100.0	1
KU	C2SOS	2402772	09/2016	09/20/2016	99.990	100.010	99.9	1
KU	C2SOS	2402773	09/2016	09/20/2016	99.990	100.000	100.0	1
KU	C2SOS	2402774	09/2016	09/20/2016	100.010	100.020	100.0	1
KU	C2SOS	2402775	09/2016	09/20/2016	99.990	99.970	100.0	1
KU	C2SOS	2402776	09/2016	09/20/2016	99.990	99.990	100.0	1
KU	C2SOS	2402777	09/2016	09/20/2016	99.990	100.020	100.0	1
KU	C2SOS	2402778	09/2016	09/20/2016	100.000	99.980	100.0	1
KU	C2SOS	2402779	09/2016	09/20/2016	100.000	100.030	100.0	1
KU	C2SOS	2402780	09/2016	09/20/2016	99.980	100.040	100.0	1
KU	C2SOS	2402781	09/2016	09/20/2016	100.000	99.990	100.0	1
KU	C2SOS	2402782	09/2016	09/20/2016	100.000	100.000	100.0	1
KU	C2SOS	2402783	09/2016	09/20/2016	99.990	99.960	100.0	1
KU	C2SOS	2402784	09/2016	09/20/2016	100.000	99.980	100.0	1
KU	C2SOS	2402785	09/2016	09/20/2016	100.000	100.020	100.0	1
KU	C2SOS	2402786	09/2016	09/20/2016	99.990	100.010	100.0	1
KU	C2SOS	2402787	09/2016	09/20/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2401512	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401513	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2401514	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2401515	04/2016	04/15/2016	100.000	99.980	100.1	1

KU	FOCUS AXR-MESH	2401516	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401517	04/2016	04/15/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2401518	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401519	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2401520	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2401521	04/2016	04/15/2016	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2401522	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401523	04/2016	04/15/2016	99.970	99.910	100.0	1
KU	FOCUS AXR-MESH	2401524	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401525	04/2016	04/15/2016	99.990	100.000	99.9	1
KU	FOCUS AXR-MESH	2401526	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2401527	04/2016	04/15/2016	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2401528	04/2016	04/15/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2401529	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401530	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401531	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401532	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401533	04/2016	04/15/2016	99.970	99.980	100.1	1
KU	FOCUS AXR-MESH	2401534	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401535	04/2016	04/15/2016	99.990	99.910	100.0	1
KU	FOCUS AXR-MESH	2401536	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2401537	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401538	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2401539	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2401540	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2401541	04/2016	04/15/2016	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2401542	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401543	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2401544	04/2016	04/15/2016	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2401545	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401546	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401547	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401548	04/2016	04/15/2016	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2401549	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401550	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2401551	04/2016	04/15/2016	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2401552	04/2016	04/15/2016	100.030	99.990	100.1	1
KU	FOCUS AXR-MESH	2401553	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2401554	04/2016	04/15/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2401555	04/2016	04/15/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2401556	04/2016	04/15/2016	100.050	99.960	100.0	1
KU	FOCUS AXR-MESH	2401557	04/2016	04/15/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2401558	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2401559	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2401560	04/2016	04/15/2016	100.010	100.030	99.9	1

KU	FOCUS AXR-MESH	2401561	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401562	04/2016	04/15/2016	100.040	99.920	100.1	1
KU	FOCUS AXR-MESH	2401563	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2401564	04/2016	04/15/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2401565	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2401566	04/2016	04/15/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2401567	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2401568	04/2016	04/15/2016	100.030	99.940	100.1	1
KU	FOCUS AXR-MESH	2401569	04/2016	04/15/2016	100.040	100.050	100.0	1
KU	FOCUS AXR-MESH	2401570	04/2016	04/15/2016	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2401571	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401572	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2401573	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2401574	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2401575	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401576	04/2016	04/15/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2401577	04/2016	04/15/2016	99.990	99.920	100.1	1
KU	FOCUS AXR-MESH	2401578	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2401579	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401580	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2401581	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401582	04/2016	04/15/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2401583	04/2016	04/15/2016	100.050	99.990	100.1	1
KU	FOCUS AXR-MESH	2401584	04/2016	04/15/2016	99.980	99.930	100.1	1
KU	FOCUS AXR-MESH	2401585	04/2016	04/15/2016	99.980	99.950	100.1	1
KU	FOCUS AXR-MESH	2401586	04/2016	04/15/2016	99.970	99.930	100.1	1
KU	FOCUS AXR-MESH	2401587	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401588	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2401589	04/2016	04/15/2016	100.020	99.940	100.1	1
KU	FOCUS AXR-MESH	2401590	04/2016	04/15/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2401591	04/2016	04/15/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2401592	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2401593	04/2016	04/15/2016	100.060	100.010	100.0	1
KU	FOCUS AXR-MESH	2401594	04/2016	04/15/2016	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2401595	04/2016	04/15/2016	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2401596	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401597	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2401598	04/2016	04/15/2016	100.020	99.930	100.0	1
KU	FOCUS AXR-MESH	2401599	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401600	04/2016	04/15/2016	100.000	99.920	100.0	1
KU	FOCUS AXR-MESH	2401601	04/2016	04/15/2016	100.010	99.990	99.9	1
KU	FOCUS AXR-MESH	2401602	04/2016	04/15/2016	100.040	99.960	100.1	1
KU	FOCUS AXR-MESH	2401603	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2401604	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2401605	04/2016	04/15/2016	99.980	99.960	100.0	1

KU	FOCUS AXR-MESH	2401606	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401607	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2401608	04/2016	04/15/2016	100.050	99.970	100.1	1
KU	FOCUS AXR-MESH	2401609	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401610	04/2016	04/15/2016	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2401611	04/2016	04/15/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2401612	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2401613	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2401614	04/2016	04/15/2016	100.000	99.910	100.1	1
KU	FOCUS AXR-MESH	2401615	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401616	04/2016	04/15/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2401617	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401618	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401619	04/2016	04/15/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2401620	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2401621	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401622	04/2016	04/15/2016	100.020	99.970	99.9	1
KU	FOCUS AXR-MESH	2401623	04/2016	04/15/2016	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2401624	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2401625	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2401626	04/2016	04/15/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2401627	04/2016	04/15/2016	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2401628	04/2016	04/15/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2401629	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401630	04/2016	04/15/2016	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2401631	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2401632	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401633	04/2016	04/15/2016	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2401634	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401635	04/2016	04/15/2016	100.020	100.060	100.0	1
KU	FOCUS AXR-MESH	2401636	04/2016	04/15/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2401637	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2401638	04/2016	04/15/2016	100.030	99.980	100.1	1
KU	FOCUS AXR-MESH	2401639	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2401640	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401641	04/2016	04/15/2016	100.050	99.970	100.1	1
KU	FOCUS AXR-MESH	2401642	04/2016	04/15/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2401643	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2401644	04/2016	04/15/2016	99.990	100.020	100.0	1
KU	FOCUS AXR-MESH	2401645	04/2016	04/15/2016	99.970	99.980	99.9	1
KU	FOCUS AXR-MESH	2401646	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401647	04/2016	04/15/2016	99.990	99.980	99.9	1
KU	FOCUS AXR-MESH	2401648	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2401649	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401650	04/2016	04/15/2016	100.020	99.980	100.1	1

KU	FOCUS AXR-MESH	2401651	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2401652	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2401653	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401654	04/2016	04/15/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2401655	04/2016	04/15/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2401656	04/2016	04/15/2016	100.000	99.990	100.1	1
KU	FOCUS AXR-MESH	2401657	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2401658	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2401659	04/2016	04/15/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2401660	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401661	04/2016	04/15/2016	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2401662	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401663	04/2016	04/15/2016	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2401664	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401665	04/2016	04/15/2016	100.020	99.950	100.0	1
KU	FOCUS AXR-MESH	2401666	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401667	04/2016	04/15/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2401668	04/2016	04/15/2016	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2401669	04/2016	04/15/2016	100.000	99.980	100.1	1
KU	FOCUS AXR-MESH	2401670	04/2016	04/15/2016	99.980	100.010	99.9	1
KU	FOCUS AXR-MESH	2401671	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2401672	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2401673	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2401674	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2401675	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401676	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401677	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401678	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401679	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401680	04/2016	04/15/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2401681	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401682	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401683	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401684	04/2016	04/15/2016	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2401685	04/2016	04/15/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2401686	04/2016	04/15/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2401687	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2401688	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2401689	04/2016	04/15/2016	100.030	100.040	100.0	1
KU	FOCUS AXR-MESH	2401690	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2401691	04/2016	04/15/2016	99.990	99.960	100.1	1
KU	FOCUS AXR-MESH	2401692	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2401693	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401694	04/2016	04/15/2016	100.010	99.990	99.9	1
KU	FOCUS AXR-MESH	2401695	04/2016	04/15/2016	99.970	99.950	100.1	1

KU	FOCUS AXR-MESH	2401696	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401697	04/2016	04/15/2016	100.040	99.960	100.1	1
KU	FOCUS AXR-MESH	2401698	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2401699	04/2016	04/15/2016	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2401700	04/2016	04/15/2016	100.040	99.940	100.1	1
KU	FOCUS AXR-MESH	2401701	04/2016	04/15/2016	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2401702	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401703	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2401704	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2401705	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401706	04/2016	04/15/2016	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2401707	04/2016	04/15/2016	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2401708	04/2016	04/15/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2401709	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2401710	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2401711	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2401712	04/2016	04/15/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2401713	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401714	04/2016	04/15/2016	99.970	99.930	100.1	1
KU	FOCUS AXR-MESH	2401715	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401716	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2401717	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2401718	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401719	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401720	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401721	04/2016	04/15/2016	99.970	99.940	100.1	1
KU	FOCUS AXR-MESH	2401722	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2401723	04/2016	04/15/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2401724	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401725	04/2016	04/15/2016	99.970	100.000	99.9	1
KU	FOCUS AXR-MESH	2401726	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2401727	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2401728	04/2016	04/15/2016	100.040	100.020	99.9	1
KU	FOCUS AXR-MESH	2401729	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401730	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401731	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401732	04/2016	04/15/2016	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2401733	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2401734	04/2016	04/15/2016	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2401735	04/2016	04/15/2016	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2401736	04/2016	04/15/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2401737	04/2016	04/15/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2401738	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2401739	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2401740	04/2016	04/15/2016	99.970	99.940	100.0	1

KU	FOCUS AXR-MESH	2401741	04/2016	04/15/2016	100.030	100.010	99.9	1
KU	FOCUS AXR-MESH	2401742	04/2016	04/15/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2401743	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2401744	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2401745	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2401746	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401747	04/2016	04/15/2016	100.030	100.030	99.9	1
KU	FOCUS AXR-MESH	2401748	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2401749	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2401750	04/2016	04/15/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2401751	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401752	04/2016	04/15/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2401753	04/2016	04/15/2016	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2401754	04/2016	04/15/2016	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2401755	04/2016	04/15/2016	99.980	99.930	100.0	1
KU	FOCUS AXR-MESH	2401756	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401757	04/2016	04/15/2016	99.970	99.990	99.9	1
KU	FOCUS AXR-MESH	2401758	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2401759	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2401760	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2401761	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2401762	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401763	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401764	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2401765	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401766	04/2016	04/15/2016	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2401767	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401768	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2401769	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401770	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401771	04/2016	04/15/2016	99.950	99.950	100.0	1
KU	FOCUS AXR-MESH	2401772	04/2016	04/15/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2401773	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2401774	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401775	04/2016	04/15/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2401776	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401777	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2401778	04/2016	04/15/2016	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2401779	04/2016	04/15/2016	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2401780	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401781	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401782	04/2016	04/15/2016	100.000	99.980	100.1	1
KU	FOCUS AXR-MESH	2401783	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2401784	04/2016	04/15/2016	99.980	99.980	100.1	1
KU	FOCUS AXR-MESH	2401785	04/2016	04/15/2016	100.010	100.040	100.0	1

KU	FOCUS AXR-MESH	2401786	04/2016	04/15/2016	99.980	99.950	99.9	1
KU	FOCUS AXR-MESH	2401787	04/2016	04/15/2016	99.970	99.900	100.0	1
KU	FOCUS AXR-MESH	2401788	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2401789	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2401790	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2401791	04/2016	04/15/2016	99.980	99.980	100.1	1
KU	FOCUS AXR-MESH	2401792	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401793	04/2016	04/15/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2401794	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2401795	04/2016	04/15/2016	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2401796	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2401797	04/2016	04/15/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2401798	04/2016	04/15/2016	100.020	99.980	99.9	1
KU	FOCUS AXR-MESH	2401799	04/2016	04/15/2016	100.010	99.990	99.9	1
KU	FOCUS AXR-MESH	2401800	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401801	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401802	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2401803	04/2016	04/15/2016	100.000	99.990	100.1	1
KU	FOCUS AXR-MESH	2401804	04/2016	04/15/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2401805	04/2016	04/15/2016	100.000	100.010	99.9	1
KU	FOCUS AXR-MESH	2401806	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401807	04/2016	04/15/2016	99.960	99.990	100.0	1
KU	FOCUS AXR-MESH	2401808	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401809	04/2016	04/15/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2401810	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2401811	04/2016	04/15/2016	100.030	99.990	99.9	1
KU	FOCUS AXR-MESH	2401812	04/2016	04/15/2016	99.970	99.970	99.9	1
KU	FOCUS AXR-MESH	2401813	04/2016	04/15/2016	99.980	100.010	99.9	1
KU	FOCUS AXR-MESH	2401814	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401815	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401816	04/2016	04/15/2016	100.000	99.920	100.0	1
KU	FOCUS AXR-MESH	2401817	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401818	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2401819	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401820	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401821	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401822	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401823	04/2016	04/15/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2401824	04/2016	04/15/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2401825	04/2016	04/15/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2401826	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401827	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401828	04/2016	04/15/2016	99.990	99.930	100.1	1
KU	FOCUS AXR-MESH	2401829	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401830	04/2016	04/15/2016	100.040	99.990	100.1	1

KU	FOCUS AXR-MESH	2401831	04/2016	04/15/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2401832	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401833	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401834	04/2016	04/15/2016	100.010	100.040	100.0	1
KU	FOCUS AXR-MESH	2401835	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401836	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401837	04/2016	04/15/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2401838	04/2016	04/15/2016	100.050	100.040	100.0	1
KU	FOCUS AXR-MESH	2401839	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2401840	04/2016	04/15/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2401841	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2401842	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401843	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401844	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2401845	04/2016	04/15/2016	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2401846	04/2016	04/15/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2401847	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2401848	04/2016	04/15/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2401849	04/2016	04/15/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2401850	04/2016	04/15/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2401851	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2401852	04/2016	04/15/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2401853	04/2016	04/15/2016	99.970	99.980	99.9	1
KU	FOCUS AXR-MESH	2401854	04/2016	04/15/2016	100.030	99.980	100.1	1
KU	FOCUS AXR-MESH	2401855	04/2016	04/15/2016	99.950	99.970	99.9	1
KU	FOCUS AXR-MESH	2401856	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401857	04/2016	04/15/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2401858	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2401859	04/2016	04/15/2016	100.020	99.930	100.1	1
KU	FOCUS AXR-MESH	2401860	04/2016	04/15/2016	100.020	100.000	100.1	1
KU	FOCUS AXR-MESH	2401861	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401862	04/2016	04/15/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2401863	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401864	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2401865	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401866	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2401867	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401868	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401869	04/2016	04/15/2016	99.990	100.020	99.9	1
KU	FOCUS AXR-MESH	2401870	04/2016	04/15/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2401871	04/2016	04/15/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2401872	04/2016	04/15/2016	100.000	100.050	100.0	1
KU	FOCUS AXR-MESH	2401873	04/2016	04/15/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2401874	04/2016	04/15/2016	99.960	99.980	99.9	1
KU	FOCUS AXR-MESH	2401875	04/2016	04/15/2016	99.960	99.980	99.9	1

KU	FOCUS AXR-MESH	2401876	04/2016	04/15/2016	100.030	99.980	100.1	1
KU	FOCUS AXR-MESH	2401877	04/2016	04/15/2016	100.030	99.990	100.1	1
KU	FOCUS AXR-MESH	2401878	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2401879	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2401880	04/2016	04/15/2016	100.010	99.940	100.0	1
KU	FOCUS AXR-MESH	2401881	04/2016	04/15/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2401882	04/2016	04/15/2016	100.010	100.020	100.1	1
KU	FOCUS AXR-MESH	2401883	04/2016	04/15/2016	99.990	99.970	99.9	1
KU	FOCUS AXR-MESH	2401884	04/2016	04/15/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2401885	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2401886	04/2016	04/15/2016	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2401887	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401888	04/2016	04/15/2016	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2401889	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401890	04/2016	04/15/2016	99.970	99.990	100.0	1
KU	FOCUS AXR-MESH	2401891	04/2016	04/15/2016	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2401892	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2401893	04/2016	04/15/2016	99.960	99.920	100.0	1
KU	FOCUS AXR-MESH	2401894	04/2016	04/15/2016	100.050	100.030	99.9	1
KU	FOCUS AXR-MESH	2401895	04/2016	04/15/2016	100.030	100.030	100.0	1
KU	FOCUS AXR-MESH	2401896	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401897	04/2016	04/15/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2401898	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401899	04/2016	04/15/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2401900	04/2016	04/15/2016	99.970	99.980	99.9	1
KU	FOCUS AXR-MESH	2401901	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401902	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2401903	04/2016	04/15/2016	99.980	99.920	100.0	1
KU	FOCUS AXR-MESH	2401904	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2401905	04/2016	04/15/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2401906	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401907	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2401908	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2401909	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401910	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2401911	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401912	04/2016	04/15/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2401913	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401914	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2401915	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401916	04/2016	04/15/2016	99.980	100.010	99.9	1
KU	FOCUS AXR-MESH	2401917	04/2016	04/15/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2401918	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2401919	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2401920	04/2016	04/15/2016	100.010	99.970	100.0	1

KU	FOCUS AXR-MESH	2401921	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401922	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401923	04/2016	04/15/2016	100.030	99.990	100.1	1
KU	FOCUS AXR-MESH	2401924	04/2016	04/15/2016	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2401925	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2401926	04/2016	04/15/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2401927	04/2016	04/15/2016	100.040	99.970	100.1	1
KU	FOCUS AXR-MESH	2401928	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401929	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401930	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2401931	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2401932	04/2016	04/15/2016	100.020	100.020	99.9	1
KU	FOCUS AXR-MESH	2401933	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2401934	04/2016	04/15/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2401935	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2401936	04/2016	04/15/2016	100.020	99.940	100.0	1
KU	FOCUS AXR-MESH	2401937	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2401938	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401939	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2401940	04/2016	04/15/2016	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2401941	04/2016	04/15/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2401942	04/2016	04/15/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2401943	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2401944	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2401945	04/2016	04/15/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2401946	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401947	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2401948	04/2016	04/15/2016	100.000	100.010	99.9	1
KU	FOCUS AXR-MESH	2401949	04/2016	04/15/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2401950	04/2016	04/15/2016	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2401951	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2401952	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2401953	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401954	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2401955	04/2016	04/15/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2401956	04/2016	04/15/2016	100.000	100.000	100.1	1
KU	FOCUS AXR-MESH	2401957	04/2016	04/15/2016	100.020	100.020	100.1	1
KU	FOCUS AXR-MESH	2401958	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2401959	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2401960	04/2016	04/15/2016	99.980	100.000	99.9	1
KU	FOCUS AXR-MESH	2401961	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2401962	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2401963	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2401964	04/2016	04/15/2016	100.050	100.040	100.0	1
KU	FOCUS AXR-MESH	2401965	04/2016	04/15/2016	100.030	99.990	100.0	1

KU	FOCUS AXR-MESH	2401966	04/2016	04/15/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2401967	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2401968	04/2016	04/15/2016	100.020	99.950	100.1	1
KU	FOCUS AXR-MESH	2401969	04/2016	04/15/2016	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2401970	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2401971	04/2016	04/15/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2401972	04/2016	04/15/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2401973	04/2016	04/15/2016	99.990	100.020	100.1	1
KU	FOCUS AXR-MESH	2401974	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2401975	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2401976	04/2016	04/15/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2401977	04/2016	04/15/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2401978	04/2016	04/15/2016	99.960	100.010	100.0	1
KU	FOCUS AXR-MESH	2401979	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2401980	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401981	04/2016	04/15/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2401982	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2401983	04/2016	04/15/2016	100.060	100.040	100.0	1
KU	FOCUS AXR-MESH	2401984	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2401985	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2401986	04/2016	04/15/2016	99.970	99.920	100.0	1
KU	FOCUS AXR-MESH	2401987	04/2016	04/15/2016	99.960	99.990	100.0	1
KU	FOCUS AXR-MESH	2401988	04/2016	04/15/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2401989	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2401990	04/2016	04/15/2016	100.050	99.980	100.0	1
KU	FOCUS AXR-MESH	2401991	04/2016	04/15/2016	100.010	99.940	100.0	1
KU	FOCUS AXR-MESH	2401992	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2401993	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2401994	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2401995	04/2016	04/15/2016	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2401996	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2401997	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2401998	04/2016	04/15/2016	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2401999	04/2016	04/15/2016	99.990	100.000	99.9	1
KU	FOCUS AXR-MESH	2402000	04/2016	04/15/2016	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2402001	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402002	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402003	04/2016	04/15/2016	100.000	99.950	100.1	1
KU	FOCUS AXR-MESH	2402004	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402005	04/2016	04/15/2016	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2402006	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2402007	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402008	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2402009	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2402010	04/2016	04/15/2016	100.000	100.000	100.0	1

KU	FOCUS AXR-MESH	2402011	04/2016	04/15/2016	100.010	99.940	100.1	1
KU	FOCUS AXR-MESH	2402012	04/2016	04/15/2016	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2402013	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402014	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402015	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402016	04/2016	04/15/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2402017	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402018	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402019	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402020	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402021	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402022	04/2016	04/15/2016	100.020	99.990	100.1	1
KU	FOCUS AXR-MESH	2402023	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402024	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2402025	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2402026	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2402027	04/2016	04/15/2016	100.050	100.020	100.1	1
KU	FOCUS AXR-MESH	2402028	04/2016	04/15/2016	100.010	100.050	100.0	1
KU	FOCUS AXR-MESH	2402029	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402030	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402031	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2402032	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2402033	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402034	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402035	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2402036	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2402037	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2402038	04/2016	04/15/2016	99.960	99.970	99.9	1
KU	FOCUS AXR-MESH	2402039	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402040	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402041	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2402042	04/2016	04/15/2016	100.040	100.010	99.9	1
KU	FOCUS AXR-MESH	2402043	04/2016	04/15/2016	99.980	99.960	100.1	1
KU	FOCUS AXR-MESH	2402044	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402045	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2402046	04/2016	04/15/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402047	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402048	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402049	04/2016	04/15/2016	100.030	100.030	99.9	1
KU	FOCUS AXR-MESH	2402050	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402051	04/2016	04/15/2016	99.970	99.990	100.0	1
KU	FOCUS AXR-MESH	2402052	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2402053	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2402054	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2402055	04/2016	04/15/2016	100.010	100.010	100.0	1

KU	FOCUS AXR-MESH	2402056	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402057	04/2016	04/15/2016	100.000	100.020	100.1	1
KU	FOCUS AXR-MESH	2402058	04/2016	04/15/2016	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2402059	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402060	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2402061	04/2016	04/15/2016	100.040	100.000	100.1	1
KU	FOCUS AXR-MESH	2402062	04/2016	04/15/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2402063	04/2016	04/15/2016	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2402064	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2402065	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2402066	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2402067	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2402068	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402069	04/2016	04/15/2016	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2402070	04/2016	04/15/2016	100.030	99.980	100.1	1
KU	FOCUS AXR-MESH	2402071	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2402072	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402073	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2402074	04/2016	04/15/2016	100.000	100.070	100.0	1
KU	FOCUS AXR-MESH	2402075	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402076	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402077	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402078	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402079	04/2016	04/15/2016	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2402080	04/2016	04/15/2016	100.010	100.020	100.1	1
KU	FOCUS AXR-MESH	2402081	04/2016	04/15/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2402082	04/2016	04/15/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2402083	04/2016	04/15/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2402084	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402085	04/2016	04/15/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2402086	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402087	04/2016	04/15/2016	100.020	99.940	100.1	1
KU	FOCUS AXR-MESH	2402088	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402089	04/2016	04/15/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402090	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402091	04/2016	04/15/2016	100.040	100.010	100.1	1
KU	FOCUS AXR-MESH	2402092	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402093	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2402094	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402095	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402096	04/2016	04/15/2016	100.000	100.020	100.1	1
KU	FOCUS AXR-MESH	2402097	04/2016	04/15/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2402098	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2402099	04/2016	04/15/2016	100.020	99.990	100.1	1
KU	FOCUS AXR-MESH	2402100	04/2016	04/15/2016	100.000	99.960	100.0	1

KU	FOCUS AXR-MESH	2402101	04/2016	04/15/2016	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2402102	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2402103	04/2016	04/15/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402104	04/2016	04/15/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2402105	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2402106	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402107	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402108	04/2016	04/15/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2402109	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2402110	04/2016	04/15/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402111	04/2016	04/15/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2402112	04/2016	04/15/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2402113	04/2016	04/15/2016	100.010	99.950	99.9	1
KU	FOCUS AXR-MESH	2402114	04/2016	04/15/2016	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2402115	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402116	04/2016	04/15/2016	99.980	99.970	100.1	1
KU	FOCUS AXR-MESH	2402117	04/2016	04/15/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2402118	04/2016	04/15/2016	100.020	100.020	99.9	1
KU	FOCUS AXR-MESH	2402119	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2402120	04/2016	04/15/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2402121	04/2016	04/15/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2402122	04/2016	04/15/2016	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2402123	04/2016	04/15/2016	100.030	100.010	100.1	1
KU	FOCUS AXR-MESH	2402124	04/2016	04/15/2016	99.980	100.000	100.0	1
KU	FOCUS AXR-MESH	2402125	04/2016	04/15/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2402126	04/2016	04/15/2016	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2402127	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402128	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402129	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402130	04/2016	04/15/2016	100.020	99.950	100.1	1
KU	FOCUS AXR-MESH	2402131	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2402132	04/2016	04/15/2016	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2402133	04/2016	04/15/2016	100.050	100.040	100.0	1
KU	FOCUS AXR-MESH	2402134	04/2016	04/15/2016	100.010	100.010	100.1	1
KU	FOCUS AXR-MESH	2402135	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2402136	04/2016	04/15/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2402137	04/2016	04/15/2016	99.960	99.970	99.9	1
KU	FOCUS AXR-MESH	2402138	04/2016	04/15/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2402139	04/2016	04/15/2016	99.960	99.980	99.9	1
KU	FOCUS AXR-MESH	2402140	04/2016	04/15/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2402141	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402142	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402143	04/2016	04/15/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2402144	04/2016	04/15/2016	100.020	99.980	99.9	1
KU	FOCUS AXR-MESH	2402145	04/2016	04/15/2016	100.000	100.040	100.0	1

KU	FOCUS AXR-MESH	2402146	04/2016	04/15/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402147	04/2016	04/15/2016	99.970	100.010	100.1	1
KU	FOCUS AXR-MESH	2402148	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402149	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402150	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402151	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402152	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402153	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402154	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402155	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2402156	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2402157	04/2016	04/15/2016	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2402158	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2402159	04/2016	04/15/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2402160	04/2016	04/15/2016	99.990	99.920	100.0	1
KU	FOCUS AXR-MESH	2402161	04/2016	04/15/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2402162	04/2016	04/15/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2402163	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402164	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402165	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2402166	04/2016	04/15/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2402167	04/2016	04/15/2016	100.050	99.980	100.1	1
KU	FOCUS AXR-MESH	2402168	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2402169	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2402170	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402171	04/2016	04/15/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2402172	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2402173	04/2016	04/15/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402174	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402175	04/2016	04/15/2016	100.040	99.960	100.1	1
KU	FOCUS AXR-MESH	2402176	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2402177	04/2016	04/15/2016	99.990	99.970	100.1	1
KU	FOCUS AXR-MESH	2402178	04/2016	04/15/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2402179	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2402180	04/2016	04/15/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2402181	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402182	04/2016	04/15/2016	99.990	99.910	100.1	1
KU	FOCUS AXR-MESH	2402183	04/2016	04/15/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2402184	04/2016	04/15/2016	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2402185	04/2016	04/15/2016	100.020	99.990	100.1	1
KU	FOCUS AXR-MESH	2402186	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402187	04/2016	04/15/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402188	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2402189	04/2016	04/15/2016	100.000	99.990	100.1	1
KU	FOCUS AXR-MESH	2402190	04/2016	04/15/2016	100.000	99.950	100.1	1

KU	FOCUS AXR-MESH	2402191	04/2016	04/15/2016	100.000	100.030	100.0	1
KU	FOCUS AXR-MESH	2402192	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2402193	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402194	04/2016	04/15/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2402195	04/2016	04/15/2016	99.960	99.930	100.0	1
KU	FOCUS AXR-MESH	2402196	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2402197	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402198	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402199	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402200	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402201	04/2016	04/15/2016	99.980	100.020	100.0	1
KU	FOCUS AXR-MESH	2402202	04/2016	04/15/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2402203	04/2016	04/15/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402204	04/2016	04/15/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402205	04/2016	04/15/2016	100.040	99.950	100.1	1
KU	FOCUS AXR-MESH	2402206	04/2016	04/15/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2402207	04/2016	04/15/2016	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2402208	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402209	04/2016	04/15/2016	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2402210	04/2016	04/15/2016	100.020	100.040	99.9	1
KU	FOCUS AXR-MESH	2402211	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2402212	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402213	04/2016	04/15/2016	99.990	99.950	99.9	1
KU	FOCUS AXR-MESH	2402214	04/2016	04/15/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2402215	04/2016	04/15/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2402216	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402217	04/2016	04/15/2016	100.050	99.990	100.1	1
KU	FOCUS AXR-MESH	2402218	04/2016	04/15/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2402219	04/2016	04/15/2016	100.050	99.960	100.0	1
KU	FOCUS AXR-MESH	2402220	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2402221	04/2016	04/15/2016	100.030	100.020	99.9	1
KU	FOCUS AXR-MESH	2402222	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402223	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402224	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402225	04/2016	04/15/2016	100.010	99.950	100.1	1
KU	FOCUS AXR-MESH	2402226	04/2016	04/15/2016	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2402227	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402228	04/2016	04/15/2016	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2402229	04/2016	04/15/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402230	04/2016	04/15/2016	100.010	99.990	99.9	1
KU	FOCUS AXR-MESH	2402231	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402232	04/2016	04/15/2016	99.950	99.960	100.0	1
KU	FOCUS AXR-MESH	2402233	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402234	04/2016	04/15/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2402235	04/2016	04/15/2016	100.010	100.030	100.0	1

KU	FOCUS AXR-MESH	2402236	04/2016	04/15/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402237	04/2016	04/15/2016	100.010	99.940	99.9	1
KU	FOCUS AXR-MESH	2402238	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402239	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2402240	04/2016	04/15/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2402241	04/2016	04/15/2016	100.010	99.950	100.1	1
KU	FOCUS AXR-MESH	2402242	04/2016	04/15/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2402243	04/2016	04/15/2016	100.050	100.030	100.1	1
KU	FOCUS AXR-MESH	2402244	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402245	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402246	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402247	04/2016	04/15/2016	99.970	99.920	100.0	1
KU	FOCUS AXR-MESH	2402248	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402249	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2402250	04/2016	04/15/2016	99.970	100.010	99.9	1
KU	FOCUS AXR-MESH	2402251	04/2016	04/15/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2402252	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402253	04/2016	04/15/2016	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2402254	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402255	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2402256	04/2016	04/15/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402257	04/2016	04/15/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2402258	04/2016	04/15/2016	99.960	99.930	100.1	1
KU	FOCUS AXR-MESH	2402259	04/2016	04/15/2016	99.990	99.980	100.1	1
KU	FOCUS AXR-MESH	2402260	04/2016	04/15/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402261	04/2016	04/15/2016	100.030	100.010	99.9	1
KU	FOCUS AXR-MESH	2402262	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2402263	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2402264	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402265	04/2016	04/15/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2402266	04/2016	04/15/2016	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2402267	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2402268	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402269	04/2016	04/15/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2402270	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2402271	04/2016	04/15/2016	100.010	99.990	99.9	1
KU	FOCUS AXR-MESH	2402272	04/2016	04/15/2016	100.030	100.000	100.0	1
KU	FOCUS AXR-MESH	2402273	04/2016	04/15/2016	99.980	99.960	100.1	1
KU	FOCUS AXR-MESH	2402274	04/2016	04/15/2016	100.050	99.980	100.0	1
KU	FOCUS AXR-MESH	2402275	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402276	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402277	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402278	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402279	04/2016	04/15/2016	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2402280	04/2016	04/15/2016	100.010	100.030	100.1	1

KU	FOCUS AXR-MESH	2402281	04/2016	04/15/2016	100.020	99.990	100.1	1
KU	FOCUS AXR-MESH	2402282	04/2016	04/15/2016	100.020	100.000	100.1	1
KU	FOCUS AXR-MESH	2402283	04/2016	04/15/2016	100.040	99.940	100.1	1
KU	FOCUS AXR-MESH	2402284	04/2016	04/15/2016	99.990	99.980	100.1	1
KU	FOCUS AXR-MESH	2402285	04/2016	04/15/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2402286	04/2016	04/15/2016	100.020	100.010	100.1	1
KU	FOCUS AXR-MESH	2402287	04/2016	04/15/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402288	04/2016	04/15/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402289	04/2016	04/15/2016	99.980	99.960	100.0	1
KU	FOCUS AXR-MESH	2402290	04/2016	04/15/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2402291	04/2016	04/15/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2402292	04/2016	04/15/2016	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2402293	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402294	04/2016	04/15/2016	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2402295	04/2016	04/15/2016	99.980	100.010	99.9	1
KU	FOCUS AXR-MESH	2402296	04/2016	04/15/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2402297	04/2016	04/15/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2402298	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2402299	04/2016	04/15/2016	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2402300	04/2016	04/15/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402301	04/2016	04/15/2016	99.990	100.020	100.0	1
KU	FOCUS AXR-MESH	2402302	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402303	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2402304	04/2016	04/15/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402305	04/2016	04/15/2016	100.000	100.010	100.0	1
KU	FOCUS AXR-MESH	2402306	04/2016	04/15/2016	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2402307	04/2016	04/15/2016	100.050	99.980	100.1	1
KU	FOCUS AXR-MESH	2402308	04/2016	04/15/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402309	04/2016	04/15/2016	99.980	99.960	100.1	1
KU	FOCUS AXR-MESH	2402310	04/2016	04/15/2016	100.030	99.990	100.1	1
KU	FOCUS AXR-MESH	2402311	04/2016	04/15/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402312	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402313	04/2016	04/15/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2402314	04/2016	04/15/2016	100.020	99.940	100.1	1
KU	FOCUS AXR-MESH	2402315	04/2016	04/15/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402316	04/2016	04/15/2016	100.000	100.000	99.9	1
KU	FOCUS AXR-MESH	2402317	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402318	04/2016	04/15/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402319	04/2016	04/15/2016	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2402320	04/2016	04/15/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402321	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402322	04/2016	04/15/2016	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2402323	04/2016	04/15/2016	100.050	100.000	100.0	1
KU	FOCUS AXR-MESH	2402324	04/2016	04/15/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2402325	04/2016	04/15/2016	100.020	100.010	100.0	1

KU	FOCUS AXR-MESH	2402326	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402327	04/2016	04/15/2016	100.030	100.010	99.9	1
KU	FOCUS AXR-MESH	2402328	04/2016	04/15/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2402329	04/2016	04/15/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2402330	04/2016	04/15/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2402331	04/2016	04/18/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402332	04/2016	04/15/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2402333	04/2016	04/15/2016	99.990	100.010	100.0	1
KU	FOCUS AXR-MESH	2402334	04/2016	04/15/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402335	04/2016	04/15/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2402336	04/2016	04/15/2016	100.050	100.050	100.0	1
KU	FOCUS AXR-MESH	2402337	04/2016	04/15/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2402338	04/2016	04/15/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2402339	04/2016	04/15/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402340	04/2016	04/15/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2402341	04/2016	04/15/2016	99.980	99.930	100.0	1
KU	FOCUS AXR-MESH	2402342	04/2016	04/15/2016	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2402343	04/2016	04/15/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402344	04/2016	04/15/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402345	04/2016	04/15/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402346	04/2016	04/15/2016	99.980	100.000	100.0	1
KU	FOCUS AXR-MESH	2402347	04/2016	04/15/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402348	04/2016	04/15/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402349	04/2016	04/15/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402350	04/2016	04/15/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2402351	04/2016	04/15/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2402352	04/2016	04/15/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2402353	04/2016	04/15/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402354	04/2016	04/15/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402355	04/2016	04/15/2016	100.040	99.970	100.1	1
KU	FOCUS AXR-MESH	2402356	04/2016	04/15/2016	100.060	99.990	100.0	1
KU	FOCUS AXR-MESH	2402357	04/2016	04/15/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2402358	04/2016	04/15/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2402359	04/2016	04/15/2016	99.990	100.010	99.9	1
KU	FOCUS AXR-MESH	2402360	04/2016	04/18/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2402361	04/2016	04/18/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2402362	04/2016	04/18/2016	99.980	99.960	100.1	1
KU	FOCUS AXR-MESH	2402363	04/2016	04/18/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402364	04/2016	04/18/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402365	04/2016	04/18/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2402366	04/2016	04/18/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2402367	04/2016	04/18/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402368	04/2016	04/18/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2402369	04/2016	04/18/2016	99.970	99.970	99.9	1
KU	FOCUS AXR-MESH	2402370	04/2016	04/18/2016	99.980	100.030	100.0	1

KU	FOCUS AXR-MESH	2402371	04/2016	04/18/2016	100.000	99.910	100.0	1
KU	FOCUS AXR-MESH	2402372	04/2016	04/18/2016	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2402373	04/2016	04/18/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402374	04/2016	04/18/2016	99.980	99.980	100.1	1
KU	FOCUS AXR-MESH	2402375	04/2016	04/18/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402820	11/2016	11/17/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2402821	11/2016	11/17/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402822	11/2016	11/17/2016	100.000	99.990	100.1	1
KU	FOCUS AXR-MESH	2402823	11/2016	11/17/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402824	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402825	11/2016	11/17/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402826	11/2016	11/17/2016	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2402827	11/2016	11/17/2016	100.020	100.040	100.0	1
KU	FOCUS AXR-MESH	2402828	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402829	11/2016	11/17/2016	100.040	100.020	99.9	1
KU	FOCUS AXR-MESH	2402830	11/2016	11/17/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402831	11/2016	11/17/2016	99.970	99.970	100.1	1
KU	FOCUS AXR-MESH	2402832	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402833	11/2016	11/17/2016	100.040	99.970	100.1	1
KU	FOCUS AXR-MESH	2402834	11/2016	11/17/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2402835	11/2016	11/17/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402836	11/2016	11/17/2016	99.980	100.000	100.0	1
KU	FOCUS AXR-MESH	2402837	11/2016	11/17/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2402838	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402839	11/2016	11/17/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2402840	11/2016	11/17/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402841	11/2016	11/17/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402842	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402843	11/2016	11/17/2016	99.950	99.930	100.1	1
KU	FOCUS AXR-MESH	2402844	11/2016	11/17/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2402845	11/2016	11/17/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402846	11/2016	11/17/2016	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2402847	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2402848	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402849	11/2016	11/17/2016	100.010	99.950	100.1	1
KU	FOCUS AXR-MESH	2402850	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2402851	11/2016	11/17/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2402852	11/2016	11/17/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2402853	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402854	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2402855	11/2016	11/17/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402856	11/2016	11/17/2016	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2402857	11/2016	11/17/2016	99.990	99.970	99.9	1
KU	FOCUS AXR-MESH	2402858	11/2016	11/17/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2402859	11/2016	11/17/2016	100.010	99.960	100.0	1

KU	FOCUS AXR-MESH	2402860	11/2016	11/17/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2402861	11/2016	11/17/2016	100.030	100.020	100.0	1
KU	FOCUS AXR-MESH	2402862	11/2016	11/17/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2402863	11/2016	11/17/2016	99.960	99.920	100.0	1
KU	FOCUS AXR-MESH	2402864	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402865	11/2016	11/17/2016	100.050	99.980	100.0	1
KU	FOCUS AXR-MESH	2402866	11/2016	11/17/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2402867	11/2016	11/17/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2402868	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402869	11/2016	11/17/2016	100.040	100.030	100.1	1
KU	FOCUS AXR-MESH	2402870	11/2016	11/17/2016	99.980	100.020	100.0	1
KU	FOCUS AXR-MESH	2402871	11/2016	11/17/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2402872	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402873	11/2016	11/17/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402874	11/2016	11/17/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2402875	11/2016	11/17/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2402876	11/2016	11/17/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2402877	11/2016	11/17/2016	100.030	99.920	100.0	1
KU	FOCUS AXR-MESH	2402878	11/2016	11/17/2016	100.040	100.030	100.0	1
KU	FOCUS AXR-MESH	2402879	11/2016	11/17/2016	100.020	100.000	99.9	1
KU	FOCUS AXR-MESH	2402880	11/2016	11/17/2016	100.050	99.990	100.1	1
KU	FOCUS AXR-MESH	2402881	11/2016	11/17/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402882	11/2016	11/17/2016	100.060	99.990	100.0	1
KU	FOCUS AXR-MESH	2402883	11/2016	11/17/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2402884	11/2016	11/17/2016	100.010	100.030	100.0	1
KU	FOCUS AXR-MESH	2402885	11/2016	11/17/2016	100.000	99.940	100.1	1
KU	FOCUS AXR-MESH	2402886	11/2016	11/17/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402887	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402888	11/2016	11/17/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2402889	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402890	11/2016	11/17/2016	100.020	99.950	100.1	1
KU	FOCUS AXR-MESH	2402891	11/2016	11/17/2016	100.000	99.960	100.1	1
KU	FOCUS AXR-MESH	2402892	11/2016	11/17/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402893	11/2016	11/17/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2402894	11/2016	11/17/2016	100.050	99.970	100.0	1
KU	FOCUS AXR-MESH	2402895	11/2016	11/17/2016	100.040	100.020	100.0	1
KU	FOCUS AXR-MESH	2402896	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402897	11/2016	11/17/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2402898	11/2016	11/17/2016	100.030	99.930	100.0	1
KU	FOCUS AXR-MESH	2402899	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402900	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402901	11/2016	11/17/2016	99.970	99.950	99.9	1
KU	FOCUS AXR-MESH	2402902	11/2016	11/17/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2402903	11/2016	11/17/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2402904	11/2016	11/17/2016	100.020	99.950	100.1	1

KU	FOCUS AXR-MESH	2402905	11/2016	11/17/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2402906	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2402907	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402908	11/2016	11/17/2016	100.010	99.940	100.0	1
KU	FOCUS AXR-MESH	2402909	11/2016	11/17/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2402910	11/2016	11/17/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2402911	11/2016	11/17/2016	100.050	99.960	100.0	1
KU	FOCUS AXR-MESH	2402912	11/2016	11/17/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402913	11/2016	11/17/2016	99.970	99.920	100.1	1
KU	FOCUS AXR-MESH	2402914	11/2016	11/17/2016	100.020	100.020	99.9	1
KU	FOCUS AXR-MESH	2402915	11/2016	11/17/2016	100.020	100.020	99.9	1
KU	FOCUS AXR-MESH	2402916	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402917	11/2016	11/17/2016	99.960	99.970	99.9	1
KU	FOCUS AXR-MESH	2402918	11/2016	11/17/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402919	11/2016	11/17/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2402920	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402921	11/2016	11/17/2016	100.050	100.000	99.9	1
KU	FOCUS AXR-MESH	2402922	11/2016	11/17/2016	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2402923	11/2016	11/17/2016	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2402924	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402925	11/2016	11/17/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2402926	11/2016	11/17/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2402927	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402928	11/2016	11/17/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2402929	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402930	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402931	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402932	11/2016	11/17/2016	99.980	99.940	100.0	1
KU	FOCUS AXR-MESH	2402933	11/2016	11/17/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2402934	11/2016	11/17/2016	100.050	100.050	100.0	1
KU	FOCUS AXR-MESH	2402935	11/2016	11/17/2016	100.000	99.960	99.9	1
KU	FOCUS AXR-MESH	2402936	11/2016	11/17/2016	100.000	100.000	99.9	1
KU	FOCUS AXR-MESH	2402937	11/2016	11/17/2016	100.010	99.950	100.0	1
KU	FOCUS AXR-MESH	2402938	11/2016	11/17/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2402939	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2402940	11/2016	11/17/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2402941	11/2016	11/17/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402942	11/2016	11/17/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2402943	11/2016	11/17/2016	99.990	99.910	100.0	1
KU	FOCUS AXR-MESH	2402944	11/2016	11/17/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2402945	11/2016	11/17/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2402946	11/2016	11/17/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2402947	11/2016	11/17/2016	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2402948	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402949	11/2016	11/17/2016	99.980	99.950	100.1	1

KU	FOCUS AXR-MESH	2402950	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2402951	11/2016	11/17/2016	100.020	100.000	99.9	1
KU	FOCUS AXR-MESH	2402952	11/2016	11/17/2016	99.990	99.930	100.0	1
KU	FOCUS AXR-MESH	2402953	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2402954	11/2016	11/17/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2402955	11/2016	11/17/2016	99.990	99.960	100.1	1
KU	FOCUS AXR-MESH	2402956	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2402957	11/2016	11/17/2016	100.000	99.980	99.9	1
KU	FOCUS AXR-MESH	2402958	11/2016	11/17/2016	99.970	99.930	100.1	1
KU	FOCUS AXR-MESH	2402959	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402960	11/2016	11/17/2016	99.980	99.930	99.9	1
KU	FOCUS AXR-MESH	2402961	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2402962	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402963	11/2016	11/17/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2402964	11/2016	11/17/2016	99.960	99.930	100.0	1
KU	FOCUS AXR-MESH	2402965	11/2016	11/17/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2402966	11/2016	11/17/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402967	11/2016	11/17/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2402968	11/2016	11/17/2016	100.010	99.960	99.9	1
KU	FOCUS AXR-MESH	2402969	11/2016	11/17/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2402970	11/2016	11/17/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2402971	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2402972	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402973	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402974	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2402975	11/2016	11/17/2016	100.010	99.930	100.1	1
KU	FOCUS AXR-MESH	2402976	11/2016	11/17/2016	100.010	100.010	99.9	1
KU	FOCUS AXR-MESH	2402977	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2402978	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2402979	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2402980	11/2016	11/17/2016	100.000	100.000	99.9	1
KU	FOCUS AXR-MESH	2402981	11/2016	11/17/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2402982	11/2016	11/17/2016	100.010	99.970	99.9	1
KU	FOCUS AXR-MESH	2402983	11/2016	11/17/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2402984	11/2016	11/17/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2402985	11/2016	11/17/2016	99.980	99.930	100.1	1
KU	FOCUS AXR-MESH	2402986	11/2016	11/17/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2402987	11/2016	11/17/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2402988	11/2016	11/17/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2402989	11/2016	11/17/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2402990	11/2016	11/17/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2402991	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2402992	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2402993	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2402994	11/2016	11/17/2016	100.010	100.010	99.9	1

KU	FOCUS AXR-MESH	2402995	11/2016	11/17/2016	99.970	99.950	100.1	1
KU	FOCUS AXR-MESH	2402996	11/2016	11/17/2016	100.020	99.970	100.1	1
KU	FOCUS AXR-MESH	2402997	11/2016	11/17/2016	100.020	100.010	99.9	1
KU	FOCUS AXR-MESH	2402998	11/2016	11/17/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2402999	11/2016	11/17/2016	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2403000	11/2016	11/17/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2403001	11/2016	11/17/2016	99.970	100.000	100.0	1
KU	FOCUS AXR-MESH	2403002	11/2016	11/17/2016	100.010	99.950	99.9	1
KU	FOCUS AXR-MESH	2403003	11/2016	11/17/2016	99.960	99.910	100.0	1
KU	FOCUS AXR-MESH	2403004	11/2016	11/17/2016	100.060	100.040	100.0	1
KU	FOCUS AXR-MESH	2403005	11/2016	11/17/2016	100.000	100.010	100.1	1
KU	FOCUS AXR-MESH	2403006	11/2016	11/17/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2403007	11/2016	11/17/2016	100.050	100.020	99.9	1
KU	FOCUS AXR-MESH	2403008	11/2016	11/17/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2403009	11/2016	11/17/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2403010	11/2016	11/17/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2403011	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2403012	11/2016	11/17/2016	99.990	99.970	99.9	1
KU	FOCUS AXR-MESH	2403013	11/2016	11/17/2016	99.970	99.950	99.9	1
KU	FOCUS AXR-MESH	2403014	11/2016	11/17/2016	100.010	99.960	99.9	1
KU	FOCUS AXR-MESH	2403015	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403016	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2403017	11/2016	11/17/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2403018	11/2016	11/17/2016	99.970	99.960	99.9	1
KU	FOCUS AXR-MESH	2403019	11/2016	11/17/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2403020	11/2016	11/17/2016	99.990	99.930	100.1	1
KU	FOCUS AXR-MESH	2403021	11/2016	11/17/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2403022	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2403023	11/2016	11/17/2016	100.020	100.050	100.0	1
KU	FOCUS AXR-MESH	2403024	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2403025	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2403026	11/2016	11/17/2016	100.040	99.930	100.0	1
KU	FOCUS AXR-MESH	2403027	11/2016	11/17/2016	99.990	99.960	100.1	1
KU	FOCUS AXR-MESH	2403028	11/2016	11/17/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2403029	11/2016	11/17/2016	99.980	99.990	99.9	1
KU	FOCUS AXR-MESH	2403030	11/2016	11/17/2016	100.020	99.940	100.1	1
KU	FOCUS AXR-MESH	2403031	11/2016	11/17/2016	100.020	100.000	100.1	1
KU	FOCUS AXR-MESH	2403032	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2403033	11/2016	11/17/2016	99.980	99.970	99.9	1
KU	FOCUS AXR-MESH	2403034	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2403035	11/2016	11/17/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2403036	11/2016	11/17/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2403037	11/2016	11/17/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2403038	11/2016	11/17/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2403039	11/2016	11/17/2016	100.010	99.990	100.1	1

KU	FOCUS AXR-MESH	2403040	11/2016	11/17/2016	100.030	100.000	99.9	1
KU	FOCUS AXR-MESH	2403041	11/2016	11/17/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2403042	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2403043	11/2016	11/17/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2403044	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2403045	11/2016	11/17/2016	99.960	99.890	100.1	1
KU	FOCUS AXR-MESH	2403046	11/2016	11/17/2016	99.960	99.910	100.0	1
KU	FOCUS AXR-MESH	2403047	11/2016	11/17/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2403048	11/2016	11/17/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2403049	11/2016	11/17/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2403050	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2403051	11/2016	11/17/2016	100.020	99.930	100.1	1
KU	FOCUS AXR-MESH	2403052	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2403053	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403054	11/2016	11/17/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2403055	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2403056	11/2016	11/17/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2403057	11/2016	11/17/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2403058	11/2016	11/17/2016	99.970	99.960	100.0	1
KU	FOCUS AXR-MESH	2403059	11/2016	11/17/2016	99.970	99.980	99.9	1
KU	FOCUS AXR-MESH	2403060	11/2016	11/17/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2403061	11/2016	11/17/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2403062	11/2016	11/17/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2403063	11/2016	11/17/2016	100.000	99.920	100.0	1
KU	FOCUS AXR-MESH	2403064	11/2016	11/17/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2403065	11/2016	11/17/2016	100.010	100.010	100.1	1
KU	FOCUS AXR-MESH	2403066	11/2016	11/17/2016	99.980	99.960	99.9	1
KU	FOCUS AXR-MESH	2403067	11/2016	11/17/2016	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2403068	11/2016	11/17/2016	100.050	100.010	100.0	1
KU	FOCUS AXR-MESH	2403069	11/2016	11/17/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2403070	11/2016	11/17/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2403071	11/2016	11/17/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2403072	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2403073	11/2016	11/17/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2403074	11/2016	11/17/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2403075	11/2016	11/17/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2403076	11/2016	11/17/2016	100.000	100.020	100.0	1
KU	FOCUS AXR-MESH	2403077	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2403078	11/2016	11/17/2016	100.020	99.940	100.1	1
KU	FOCUS AXR-MESH	2403079	11/2016	11/17/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2403080	11/2016	11/17/2016	99.990	99.980	99.9	1
KU	FOCUS AXR-MESH	2403081	11/2016	11/17/2016	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2403082	11/2016	11/17/2016	99.980	99.890	100.0	1
KU	FOCUS AXR-MESH	2403083	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403084	11/2016	11/17/2016	100.030	100.000	100.1	1

KU	FOCUS AXR-MESH	2403085	11/2016	11/17/2016	100.010	99.960	100.1	1
KU	FOCUS AXR-MESH	2403086	11/2016	11/17/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2403087	11/2016	11/17/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2403088	11/2016	11/17/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2403089	11/2016	11/17/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2403090	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403091	11/2016	11/17/2016	100.010	99.940	100.1	1
KU	FOCUS AXR-MESH	2403092	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2403093	11/2016	11/17/2016	99.960	99.940	100.0	1
KU	FOCUS AXR-MESH	2403094	11/2016	11/17/2016	100.010	99.940	100.1	1
KU	FOCUS AXR-MESH	2403095	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2403096	11/2016	11/17/2016	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2403097	11/2016	11/17/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2403098	11/2016	11/17/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2403099	11/2016	11/17/2016	100.010	100.070	100.0	1
KU	FOCUS AXR-MESH	2403100	11/2016	11/17/2016	99.960	99.960	100.0	1
KU	FOCUS AXR-MESH	2403101	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2403102	11/2016	11/17/2016	100.010	100.000	99.9	1
KU	FOCUS AXR-MESH	2403103	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2403104	11/2016	11/17/2016	100.010	99.980	100.0	1
KU	FOCUS AXR-MESH	2403105	11/2016	11/17/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2403106	11/2016	11/17/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2403107	11/2016	11/17/2016	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2403108	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403109	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2403110	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2403111	11/2016	11/17/2016	99.980	99.940	99.9	1
KU	FOCUS AXR-MESH	2403112	11/2016	11/17/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2403113	11/2016	11/17/2016	99.980	99.920	100.1	1
KU	FOCUS AXR-MESH	2403114	11/2016	11/17/2016	99.980	99.930	100.0	1
KU	FOCUS AXR-MESH	2403115	11/2016	11/17/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2403116	11/2016	11/17/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2403117	11/2016	11/17/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2403118	11/2016	11/17/2016	100.050	99.930	100.1	1
KU	FOCUS AXR-MESH	2403119	11/2016	11/17/2016	99.980	99.940	100.1	1
KU	FOCUS AXR-MESH	2403120	11/2016	11/17/2016	100.000	99.960	99.9	1
KU	FOCUS AXR-MESH	2403121	11/2016	11/17/2016	99.990	99.970	100.1	1
KU	FOCUS AXR-MESH	2403122	11/2016	11/17/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2403123	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2403124	11/2016	11/17/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2403125	11/2016	11/17/2016	99.960	99.910	100.0	1
KU	FOCUS AXR-MESH	2403126	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2403127	11/2016	11/17/2016	100.010	100.010	100.0	1
KU	FOCUS AXR-MESH	2403128	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2403129	11/2016	11/17/2016	100.020	99.970	100.1	1

KU	FOCUS AXR-MESH	2403130	11/2016	11/17/2016	99.970	99.980	99.9	1
KU	FOCUS AXR-MESH	2403131	11/2016	11/17/2016	99.960	99.980	100.0	1
KU	FOCUS AXR-MESH	2403132	11/2016	11/17/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2403133	11/2016	11/17/2016	100.040	99.990	100.1	1
KU	FOCUS AXR-MESH	2403134	11/2016	11/17/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2403135	11/2016	11/17/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2403136	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2403137	11/2016	11/17/2016	100.020	99.920	100.0	1
KU	FOCUS AXR-MESH	2403138	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2403139	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403140	11/2016	11/17/2016	99.990	100.030	100.0	1
KU	FOCUS AXR-MESH	2403141	11/2016	11/17/2016	99.990	99.990	100.0	1
KU	FOCUS AXR-MESH	2403142	11/2016	11/17/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2403143	11/2016	11/17/2016	100.000	99.980	100.1	1
KU	FOCUS AXR-MESH	2403144	11/2016	11/17/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2403145	11/2016	11/17/2016	99.990	99.960	99.9	1
KU	FOCUS AXR-MESH	2403146	11/2016	11/17/2016	100.030	99.950	100.0	1
KU	FOCUS AXR-MESH	2403147	11/2016	11/17/2016	100.030	99.970	100.1	1
KU	FOCUS AXR-MESH	2403148	11/2016	11/17/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2403149	11/2016	11/17/2016	100.020	100.030	100.0	1
KU	FOCUS AXR-MESH	2403150	11/2016	11/17/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2403151	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2403152	11/2016	11/17/2016	99.970	99.990	99.9	1
KU	FOCUS AXR-MESH	2403153	11/2016	11/17/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2403154	11/2016	11/17/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2403155	11/2016	11/17/2016	100.000	99.940	100.1	1
KU	FOCUS AXR-MESH	2403156	11/2016	11/17/2016	99.960	99.930	100.0	1
KU	FOCUS AXR-MESH	2403157	11/2016	11/17/2016	99.990	99.910	100.0	1
KU	FOCUS AXR-MESH	2403158	11/2016	11/17/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2403159	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2403160	11/2016	11/17/2016	100.020	99.990	100.0	1
KU	FOCUS AXR-MESH	2403161	11/2016	11/17/2016	100.040	100.040	100.0	1
KU	FOCUS AXR-MESH	2403162	11/2016	11/17/2016	100.030	99.980	100.0	1
KU	FOCUS AXR-MESH	2403163	11/2016	11/17/2016	100.020	100.010	100.0	1
KU	FOCUS AXR-MESH	2403164	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2403165	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2403166	11/2016	11/17/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2403167	11/2016	11/17/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2403168	11/2016	11/17/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2403169	11/2016	11/17/2016	99.990	99.970	100.1	1
KU	FOCUS AXR-MESH	2403170	11/2016	11/17/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2403171	11/2016	11/17/2016	100.000	99.980	100.1	1
KU	FOCUS AXR-MESH	2403172	11/2016	11/17/2016	99.990	99.940	100.0	1
KU	FOCUS AXR-MESH	2403173	11/2016	11/17/2016	100.000	99.980	100.0	1
KU	FOCUS AXR-MESH	2403174	11/2016	11/17/2016	100.050	100.040	100.0	1

KU	FOCUS AXR-MESH	2403175	11/2016	11/17/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2403176	11/2016	11/17/2016	99.980	99.980	100.0	1
KU	FOCUS AXR-MESH	2403177	11/2016	11/17/2016	99.980	99.950	100.0	1
KU	FOCUS AXR-MESH	2403178	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2403179	11/2016	11/17/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2403180	11/2016	11/17/2016	99.970	99.940	99.9	1
KU	FOCUS AXR-MESH	2403181	11/2016	11/17/2016	100.040	99.970	100.0	1
KU	FOCUS AXR-MESH	2403182	11/2016	11/17/2016	100.000	99.930	100.0	1
KU	FOCUS AXR-MESH	2403183	11/2016	11/17/2016	100.020	99.990	99.9	1
KU	FOCUS AXR-MESH	2403184	11/2016	11/17/2016	99.970	99.980	100.0	1
KU	FOCUS AXR-MESH	2403185	11/2016	11/17/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2403186	11/2016	11/17/2016	100.000	99.990	100.0	1
KU	FOCUS AXR-MESH	2403187	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2403188	11/2016	11/17/2016	100.020	99.950	100.0	1
KU	FOCUS AXR-MESH	2403189	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403190	11/2016	11/17/2016	100.010	99.930	100.1	1
KU	FOCUS AXR-MESH	2403191	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403192	11/2016	11/17/2016	100.010	99.970	100.0	1
KU	FOCUS AXR-MESH	2403193	11/2016	11/17/2016	99.980	99.920	100.0	1
KU	FOCUS AXR-MESH	2403194	11/2016	11/17/2016	100.020	100.000	100.1	1
KU	FOCUS AXR-MESH	2403195	11/2016	11/17/2016	100.000	99.930	100.0	1
KU	FOCUS AXR-MESH	2403196	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2403197	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2403198	11/2016	11/17/2016	99.980	99.970	100.0	1
KU	FOCUS AXR-MESH	2403199	11/2016	11/17/2016	99.960	99.960	99.9	1
KU	FOCUS AXR-MESH	2403200	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2403201	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403202	11/2016	11/17/2016	100.010	99.940	100.1	1
KU	FOCUS AXR-MESH	2403203	11/2016	11/17/2016	100.000	99.970	100.1	1
KU	FOCUS AXR-MESH	2403204	11/2016	11/17/2016	99.960	99.950	100.0	1
KU	FOCUS AXR-MESH	2403205	11/2016	11/17/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2403206	11/2016	11/17/2016	99.980	99.920	100.1	1
KU	FOCUS AXR-MESH	2403207	11/2016	11/17/2016	99.990	99.980	100.0	1
KU	FOCUS AXR-MESH	2403208	11/2016	11/17/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2403209	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403210	11/2016	11/17/2016	100.050	100.030	100.0	1
KU	FOCUS AXR-MESH	2403211	11/2016	11/17/2016	99.980	100.010	100.0	1
KU	FOCUS AXR-MESH	2403212	11/2016	11/17/2016	100.030	100.020	99.9	1
KU	FOCUS AXR-MESH	2403213	11/2016	11/17/2016	99.990	99.970	100.0	1
KU	FOCUS AXR-MESH	2403214	11/2016	11/17/2016	99.990	99.980	100.1	1
KU	FOCUS AXR-MESH	2403215	11/2016	11/17/2016	100.030	99.990	100.0	1
KU	FOCUS AXR-MESH	2403216	11/2016	11/17/2016	99.970	99.940	100.0	1
KU	FOCUS AXR-MESH	2403217	11/2016	11/17/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2403218	11/2016	11/17/2016	99.990	100.000	100.0	1
KU	FOCUS AXR-MESH	2403219	11/2016	11/17/2016	100.020	99.990	100.1	1

KU	FOCUS AXR-MESH	2403220	11/2016	11/17/2016	99.980	99.930	100.0	1
KU	FOCUS AXR-MESH	2403221	11/2016	11/17/2016	99.960	99.990	100.0	1
KU	FOCUS AXR-MESH	2403222	11/2016	11/17/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2403223	11/2016	11/17/2016	100.000	99.950	100.1	1
KU	FOCUS AXR-MESH	2403224	11/2016	11/17/2016	100.030	99.970	100.0	1
KU	FOCUS AXR-MESH	2403225	11/2016	11/17/2016	100.030	99.990	100.1	1
KU	FOCUS AXR-MESH	2403226	11/2016	11/17/2016	100.000	99.980	100.1	1
KU	FOCUS AXR-MESH	2403227	11/2016	11/17/2016	99.990	99.950	100.1	1
KU	FOCUS AXR-MESH	2403228	11/2016	11/17/2016	100.020	99.960	100.1	1
KU	FOCUS AXR-MESH	2403229	11/2016	11/17/2016	100.010	100.000	100.1	1
KU	FOCUS AXR-MESH	2403230	11/2016	11/17/2016	100.000	100.010	99.9	1
KU	FOCUS AXR-MESH	2403231	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2403232	11/2016	11/17/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2403233	11/2016	11/17/2016	100.000	99.970	99.9	1
KU	FOCUS AXR-MESH	2403234	11/2016	11/17/2016	99.980	99.990	99.9	1
KU	FOCUS AXR-MESH	2403235	11/2016	11/17/2016	99.980	99.920	99.9	1
KU	FOCUS AXR-MESH	2403236	11/2016	11/17/2016	100.030	99.960	100.0	1
KU	FOCUS AXR-MESH	2403237	11/2016	11/17/2016	100.020	99.970	100.0	1
KU	FOCUS AXR-MESH	2403238	11/2016	11/17/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2403239	11/2016	11/17/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2403240	11/2016	11/17/2016	99.970	99.950	100.0	1
KU	FOCUS AXR-MESH	2403241	11/2016	11/17/2016	100.030	100.010	100.0	1
KU	FOCUS AXR-MESH	2403242	11/2016	11/17/2016	99.970	99.930	100.0	1
KU	FOCUS AXR-MESH	2403243	11/2016	11/17/2016	100.020	99.990	100.1	1
KU	FOCUS AXR-MESH	2403244	11/2016	11/17/2016	100.040	99.980	100.0	1
KU	FOCUS AXR-MESH	2403245	11/2016	11/17/2016	100.030	99.960	100.1	1
KU	FOCUS AXR-MESH	2403246	11/2016	11/17/2016	100.010	99.990	100.1	1
KU	FOCUS AXR-MESH	2403247	11/2016	11/17/2016	100.030	99.950	100.1	1
KU	FOCUS AXR-MESH	2403248	11/2016	11/17/2016	100.000	100.000	100.0	1
KU	FOCUS AXR-MESH	2403249	11/2016	11/17/2016	100.040	99.980	100.1	1
KU	FOCUS AXR-MESH	2403250	11/2016	11/17/2016	100.010	99.930	100.0	1
KU	FOCUS AXR-MESH	2403251	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403252	11/2016	11/17/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2403253	11/2016	11/17/2016	100.050	99.990	100.0	1
KU	FOCUS AXR-MESH	2403254	11/2016	11/17/2016	100.010	100.000	100.0	1
KU	FOCUS AXR-MESH	2403255	11/2016	11/17/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2403256	11/2016	11/17/2016	100.050	100.020	100.0	1
KU	FOCUS AXR-MESH	2403257	11/2016	11/17/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2403258	11/2016	11/17/2016	100.030	100.040	100.0	1
KU	FOCUS AXR-MESH	2403259	11/2016	11/17/2016	100.040	100.010	100.0	1
KU	FOCUS AXR-MESH	2403260	11/2016	11/17/2016	100.020	99.980	100.0	1
KU	FOCUS AXR-MESH	2403261	11/2016	11/17/2016	100.020	99.980	100.1	1
KU	FOCUS AXR-MESH	2403262	11/2016	11/17/2016	100.010	99.980	100.1	1
KU	FOCUS AXR-MESH	2403263	11/2016	11/17/2016	100.010	99.990	100.0	1
KU	FOCUS AXR-MESH	2403264	11/2016	11/17/2016	99.970	99.930	100.0	1

KU	FOCUS AXR-MESH	2403265	11/2016	11/17/2016	99.960	99.970	100.0	1
KU	FOCUS AXR-MESH	2403266	11/2016	11/17/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2403267	11/2016	11/17/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2403268	11/2016	11/17/2016	100.040	99.990	100.0	1
KU	FOCUS AXR-MESH	2403269	11/2016	11/17/2016	100.000	100.030	100.1	1
KU	FOCUS AXR-MESH	2403270	11/2016	11/17/2016	100.000	99.940	100.0	1
KU	FOCUS AXR-MESH	2403271	11/2016	11/17/2016	99.970	99.970	100.0	1
KU	FOCUS AXR-MESH	2403272	11/2016	11/17/2016	99.970	99.990	100.0	1
KU	FOCUS AXR-MESH	2403273	11/2016	11/17/2016	99.980	99.950	100.1	1
KU	FOCUS AXR-MESH	2403274	11/2016	11/17/2016	100.020	99.950	100.1	1
KU	FOCUS AXR-MESH	2403275	11/2016	11/17/2016	100.020	99.960	100.0	1
KU	FOCUS AXR-MESH	2403276	11/2016	11/17/2016	100.000	100.010	100.1	1
KU	FOCUS AXR-MESH	2403277	11/2016	11/17/2016	100.040	99.960	100.0	1
KU	FOCUS AXR-MESH	2403278	11/2016	11/17/2016	100.020	100.000	100.0	1
KU	FOCUS AXR-MESH	2403279	11/2016	11/17/2016	99.970	99.920	100.0	1
KU	FOCUS AXR-MESH	2403280	11/2016	11/17/2016	100.000	99.970	100.0	1
KU	FOCUS AXR-MESH	2403281	11/2016	11/17/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2403282	11/2016	11/17/2016	100.050	100.040	100.0	1
KU	FOCUS AXR-MESH	2403283	11/2016	11/17/2016	100.010	99.960	100.0	1
KU	FOCUS AXR-MESH	2403284	11/2016	11/17/2016	99.980	99.990	100.0	1
KU	FOCUS AXR-MESH	2403285	11/2016	11/17/2016	100.010	99.980	99.9	1
KU	FOCUS AXR-MESH	2403286	11/2016	11/17/2016	100.010	99.970	100.1	1
KU	FOCUS AXR-MESH	2403287	11/2016	11/17/2016	99.990	99.950	100.0	1
KU	FOCUS AXR-MESH	2403288	11/2016	11/17/2016	100.020	100.020	100.0	1
KU	FOCUS AXR-MESH	2403289	11/2016	11/17/2016	100.010	100.020	100.0	1
KU	FOCUS AXR-MESH	2403290	11/2016	11/17/2016	100.040	100.000	100.0	1
KU	FOCUS AXR-MESH	2403291	11/2016	11/17/2016	99.980	99.980	99.9	1
KU	FOCUS AXR-MESH	2403292	11/2016	11/17/2016	100.030	100.000	100.1	1
KU	FOCUS AXR-MESH	2403293	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2403294	11/2016	11/17/2016	100.000	99.960	100.0	1
KU	FOCUS AXR-MESH	2403295	11/2016	11/17/2016	99.990	99.960	100.0	1
KU	FOCUS AXR-MESH	2403296	11/2016	11/17/2016	99.970	99.930	100.1	1
KU	FOCUS AXR-MESH	2403297	11/2016	11/17/2016	100.000	99.990	99.9	1
KU	FOCUS AXR-MESH	2403298	11/2016	11/17/2016	100.000	99.950	100.0	1
KU	FOCUS AXR-MESH	2403299	11/2016	11/17/2016	100.010	99.980	100.0	1
Overall Result								17,124

**ATTACHMENT
B**

Sampling Test Results

KU
2016 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	488,697	Divided into 62 Lots
Sample Quantity	4,190	
Meters Tested	4,190	
Meters Not Tested	0	
Failed Lots	0	
Failed Lot Meters	0	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: AB1 Division: 01 Sample Lot: 1997 Lot Descr: KU AB1-1
 In Service Population: 5,025 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 1
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C333261	98.80	C333313	100.40	C333370	99.80	C333402	99.60	C333416	99.80
C333421	99.80	C334878	99.60	C334907	99.80	C335027	100.40	C335115	99.80
C335118	99.60	C335129	99.70	C344950	99.90	C408123	99.90	C408136	100.50
C408198	100.20	C408201	100.40	C408270	100.50	C408346	99.80	C408363	100.00
C408379	99.60	C408435	99.80	C408454	99.70	C408492	100.20	C408493	100.40
C408591	100.10	C408674	99.40	C408954	100.40	C409086	100.10	C409155	100.30
C409164	100.40	C409227	100.10	C409245	101.00	C409304	100.50	C409419	100.10
C409433	99.40	C409467	100.30	C409495	99.70	C409617	100.30	C409706	99.60
C409772	100.30	C409883	99.60	C433504	99.90	C433520	99.80	C433729	100.50
C433777	100.50	C433888	100.20	C434099	100.00	C434182	100.40	C434280	100.10
C434367	100.10	C434472	100.30	C434554	100.40	C434576	100.30	C434606	100.10
C434613	100.50	C434625	100.20	C434761	100.10	C434814	99.70	C435122	100.40
C435207	100.00	C435388	99.90	C435414	100.20	L302290	100.20	L302313	100.20
L302365	100.20	L302517	99.30	L302527	99.50	L302538	100.40	L302693	99.70
L302882	99.50	L303110	100.30	L303287	100.10	L303424	100.10	L303544	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.70
3 Sum of Squared Measurements	750550.07
4 Correction Factor (CF): Sum of Measurements Squared / N	750540.10
5 Corrected Sum of Squares (SS)	9.97
6 Variance (V) : SS/(N-1)	0.1348
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3671
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.35
12 Quality Index Lower (QL): (XBAR-L) / S	5.55
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: ALF Division: 01 Sample Lot: 1998 Lot Descr: KU ALF - 1
 In Service Population: 157 Sample Quantity: 15 Meters Tested: 15 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 2

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2507490	99.90	2507495	100.00	2507522	99.90	2507527	100.00	2507540	99.80
2507742	100.00	2507751	99.90	2507769	99.90	2507774	99.90	2507786	99.90
2507787	99.90	2507792	100.00	2507803	100.00	2507831	100.00	2507836	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	15
2 Sum of Measurements: (Sum X)	1499.00
3 Sum of Squared Measurements	149800.12
4 Correction Factor (CF): Sum of Measurements Squared / N	149800.07
5 Corrected Sum of Squares (SS)	0.05
6 Variance (V) : SS/(N-1)	0.0038
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0617
8 Sample Mean(XBAR): Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	33.48
12 Quality Index Lower (QL): (XBAR-L) / S	31.32
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	6.55
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: C1SR Division: 01 Sample Lot: 1999 Lot Descr: KU C1S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 3

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2000028	99.90	2000235	100.10	2000346	100.00	2000419	100.00	2000458	100.00
2000510	100.10	2001228	100.10	2001311	99.90	2001331	100.10	2001451	100.10
2001537	100.10	2001758	100.10	2001844	100.10	2002378	100.10	2002425	100.00
C352781	100.00	C352839	100.10	C352842	100.10	C352981	99.90	C352990	100.00
C369378	100.00	C369434	100.00	C380682	100.00	C380704	100.10	C381014	100.10
C381137	100.00	C381155	100.30	C381607	99.90	C381643	100.10	C382014	100.00
C382161	100.00	C382184	99.90	C382586	100.10	C382875	100.00	C382964	100.10
C383144	100.20	C383282	99.90	C406411	100.20	C407533	100.30	C407589	100.00
C407693	100.00	C407758	100.10	C407759	100.10	C407820	100.20	C407935	100.00
C415974	100.00	C416040	99.80	C416300	99.90	C416512	100.00	C416560	99.90
C417124	100.10	C417255	100.00	C417317	100.00	C417363	100.30	C417385	100.20
C465694	100.00	C465708	100.00	C465786	100.00	C466046	100.30	C466189	99.90
C466193	99.90	C466205	100.00	C466224	99.90	C466256	99.90	C466496	100.00
C466560	100.00	C466586	100.00	C466668	100.00	C466834	100.00	C466942	100.10
C467183	99.90	C467421	100.00	C467463	100.00	C467499	99.80	L317565	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.20
3 Sum of Squared Measurements	750440.94
4 Correction Factor (CF): Sum of Measurements Squared / N	750440.06
5 Corrected Sum of Squares (SS)	0.88
6 Variance (V) : SS/(N-1)	0.0118
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1088
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	18.12
12 Quality Index Lower (QL): (XBAR-L) / S	18.66
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 2000 Lot Descr: XU C1S - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 4

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2002678	100.00	2002772	100.00	2002844	100.10	2002864	100.00	2003214	100.10
2003413	100.10	2003421	100.00	2003545	100.00	2003566	100.10	2003672	100.10
2003854	100.00	2003874	100.00	2004384	99.90	2004401	100.00	2004772	99.90
2004915	100.00	2004922	99.90	2005015	99.90	2005146	99.90	2005223	100.10
2005459	100.00	2005466	100.00	2005576	99.90	2006129	100.00	2006316	100.00
2006393	100.00	2006492	99.90	2006778	100.00	2006814	100.00	2007050	99.90
2007097	99.90	2007147	100.20	2007484	100.00	2007653	99.90	2007677	100.00
2007830	100.00	2008063	99.90	2008147	99.90	2008788	100.00	2008803	99.90
2008811	100.10	2008859	99.80	2008934	100.10	2009132	99.90	2009148	100.00
2500034	100.10	2500058	100.00	2500103	100.00	2500246	100.00	2500421	100.00
2500467	100.10	2500709	100.10	2501191	100.10	2501488	100.00	2501614	100.20
2501717	100.00	2501849	100.00	2501861	100.10	2501901	100.10	2502030	99.80
C467649	100.00	C467709	100.10	C467857	100.10	C468119	100.10	C468518	100.10
C468520	100.10	C468608	100.00	C468700	99.80	C468749	99.80	C468908	100.10
C469160	100.00	C469182	100.00	C469303	100.00	C469393	100.00	C469394	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.20
3 Sum of Squared Measurements	750040.58
4 Correction Factor (CF): Sum of Measurements Squared / N	750040.00
5 Corrected Sum of Squares (SS)	0.58
6 Variance (V) : SS/(N-1)	0.0078
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0885
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	22.57
12 Quality Index Lower (QL): (XBAR-L) / S	22.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: CIS Division: 01 Sample Lot: 2001 Lot Descr: KU CIS - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 5
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2009300	100.00	2009421	100.00	2009665	100.00	2009767	99.90	2009856	100.00
2009952	99.90	2010844	99.80	2010889	100.10	2010900	99.90	2010910	100.00
2011001	100.10	2011051	100.10	2011101	99.90	2011285	100.00	2011379	100.00
2011598	100.00	2011743	100.00	2011761	100.00	2011795	99.90	2012505	99.90
2012592	100.00	2012973	99.90	2013151	100.00	2013221	99.80	2013500	99.90
2013531	100.10	2013653	100.10	2013706	100.00	2013951	100.00	2014165	99.90
2014349	100.00	2014450	99.90	2014934	99.90	2015079	100.10	2015103	100.00
2015240	100.10	2015814	99.90	2016121	99.90	2016223	100.10	2016226	100.20
2016309	99.90	2016372	99.80	2502145	100.00	2502372	100.10	2502439	100.00
2502449	100.10	2502480	99.90	2502521	100.00	2502542	100.10	2502708	100.10
2502711	100.10	2502797	100.00	2502836	99.90	2502890	100.00	2503444	100.00
2503469	99.90	2503697	100.00	2503766	100.00	2503767	99.90	2503874	100.00
2503987	100.00	2504022	99.90	2504023	100.00	2504224	100.00	2504250	100.00
2504437	100.00	2504520	100.00	2504569	99.90	2504582	100.00	2504970	100.00
2505131	100.10	2505200	100.10	2505273	100.00	2505287	100.00	2505468	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7499.00
3 Sum of Squared Measurements	749800.52
4 Correction Factor (CF): Sum of Measurements Squared / N	749800.51
5 Corrected Sum of Squares (SS)	0.51
6 Variance (V) : SS/(N-1)	0.0068
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0827
8 Sample Mean(XBAR): Sum X/N	99.99
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	24.33
12 Quality Index Lower (QL): (XBAR-L) / S	24.01
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E
In Service Population: 10,000

Model Number: CIS
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2002
Pass/ Fail: PASS

Lot Descr: KU CIS - 4

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 6

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2017145	100.00	2017186	100.10	2017322	100.10	2017420	99.90	2017728	100.00
2017951	100.00	2018601	99.90	2018718	100.10	2018751	100.00	2018936	99.80
2019080	99.80	2019218	99.90	2019288	99.80	2019296	99.90	2019525	99.90
2019808	99.90	2019921	99.90	2020004	100.00	2020010	100.00	2020208	99.90
2020211	99.90	2020256	100.00	2020560	100.00	2020856	99.90	2020929	100.10
2020997	99.90	2021295	99.90	2021354	99.90	2021755	100.00	2021771	100.00
2021918	100.00	2022107	100.00	2022114	100.00	2022189	100.10	2022236	100.10
2022626	99.90	2022800	99.80	2022873	99.80	2023002	100.00	2023396	100.00
2023665	100.00	2023874	100.00	2023888	100.00	2024005	99.80	2024032	100.00
2024063	99.90	2024153	100.00	2024288	100.00	2024296	99.80	2024555	100.00
2024582	99.90	2024713	99.90	2024840	100.00	2024977	99.90	2025460	100.00
2025619	99.90	2025624	99.90	2025880	100.00	2025905	99.80	2026134	100.00
2026203	99.90	2026232	100.00	2026243	100.10	2026398	100.00	2026456	99.90
2026565	100.00	2026586	100.10	2026636	100.10	2026637	99.90	2026857	99.90
2027196	100.10	2027385	99.90	2027575	99.90	2027675	100.10	2505776	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7496.90
3 Sum of Squared Measurements	749380.69
4 Correction Factor (CF): Sum of Measurements Squared / N	749380.13
5 Corrected Sum of Squares (SS)	0.56
6 Variance (V) : SS/(N-1)	0.0076
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0871
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.43
12 Quality Index Lower (QL): (XBAR-L) / S	22.48
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)
 Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 2003 Lot Descr: KU C1S - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 7
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2027949	100.00	2027957	100.10	2028103	99.90	2028343	99.90	2028514	99.90
2028521	99.80	2028821	100.00	2028822	100.10	2028877	100.00	2028900	99.80
2028943	100.00	2029322	100.00	2029507	100.00	2029627	99.90	2029971	100.00
2030057	100.10	2030070	100.00	2030149	99.90	2030527	100.00	2030554	100.00
2030854	100.00	2031067	100.00	2031145	100.10	2031147	100.10	2031295	100.00
2031348	99.90	2031371	100.10	2031621	99.90	2031875	100.00	2031908	100.10
2032059	100.00	2032152	100.00	2032519	100.00	2032535	100.00	2032944	100.00
2032978	100.00	2033170	99.90	2033269	100.10	2033304	100.00	2033503	100.00
2033928	100.00	2034060	100.10	2034079	100.00	2034474	100.20	2034506	100.20
2034571	99.90	2034626	100.20	2034962	100.00	2034979	100.00	2035110	100.00
2035135	100.20	2035517	100.10	2035621	100.10	2035731	99.90	2035867	99.90
2035969	100.00	2036026	100.30	2036040	100.20	2036319	100.00	2037862	100.10
2038095	100.00	2038204	100.00	2038278	100.00	2038351	100.00	2038450	100.10
2038452	99.90	2038633	100.00	2038709	100.00	2038759	99.90	2039102	100.00
2039139	100.00	2039213	100.00	2039255	100.00	2505989	100.00	2506124	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.90
3 Sum of Squared Measurements	750180.63
4 Correction Factor (CF): Sum of Measurements Squared / N	750180.01
5 Corrected Sum of Squares (SS)	0.62
6 Variance (V) : SS/(N-1)	0.0084
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0915
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	21.73
12 Quality Index Lower (QL): (XBAR-L) / S	22.00
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 2004 Lot Descr: KU C1S - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 8

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2039548	100.00	2039939	100.10	2040041	100.00	2040078	100.00	2040152	100.10
2040689	100.00	2041148	100.00	2041211	100.00	2041480	100.10	2042362	99.90
2042716	100.10	2042806	100.00	2042956	100.00	2042963	99.90	2042968	99.90
2042990	99.90	2043080	100.00	2043090	100.10	2043144	100.00	2043265	100.00
2043490	99.80	2043518	100.00	2043541	100.00	2043658	99.90	2043926	99.90
2044168	100.00	2044176	100.10	2044664	100.00	2044758	99.90	2044778	100.00
2045210	100.10	2045414	99.80	2045489	100.00	2045492	100.00	2045824	100.00
2046157	100.00	2046170	99.90	2046205	99.90	2046420	100.10	2046446	100.00
2047026	100.00	2047174	99.80	2047288	100.00	2047310	99.80	2047342	99.90
2047517	100.00	2047876	99.80	2047889	100.00	2047892	100.00	2048119	99.90
2048195	99.90	2048369	99.90	2048370	100.00	2048435	99.80	2049212	99.90
2049219	100.10	2049399	100.10	2049415	100.00	2049486	100.00	2049687	99.90
2050119	100.00	2050139	99.90	2050172	99.90	2050472	100.10	2050548	100.00
2506376	100.10	2506453	100.00	2506489	99.90	2506640	100.00	2506651	100.00
2506697	99.90	2506769	100.00	2506805	99.90	2507165	99.90	2508120	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.70
3 Sum of Squared Measurements	749540.61
4 Correction Factor (CF): Sum of Measurements Squared / N	749540.07
5 Corrected Sum of Squares (SS)	0.54
6 Variance (V) : SS/(N-1)	0.0073
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0854
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	23.78
12 Quality Index Lower (QL): (XBAR-L) / S	23.06
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: C1S Division: 01 Sample Lot: 2005 Lot Descr: KU C1S - 7
 In Service Population: 2,702 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 9

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2051566	99.90	2051782	100.00	2051803	100.00	2052049	99.90	2052076	100.00
2052077	100.00	2052282	99.90	2052351	100.00	2052376	100.00	2052422	100.00
2052445	100.00	2052492	99.90	2052529	100.00	2052593	100.00	2052598	100.00
2052709	100.10	2052717	99.90	2052755	100.00	2052829	100.10	2052880	100.00
2053100	99.80	2053199	100.00	2053228	99.90	2053286	100.00	2053987	100.00
2054454	100.00	2055431	100.10	2508243	100.00	2508265	100.00	2508371	100.10
2508461	99.90	2508492	99.90	2508494	99.90	2508506	100.00	2508564	100.00
2508613	100.00	2508639	100.00	2508669	100.00	2508714	99.90	2508717	99.90
2508765	100.10	2508767	100.10	2508832	100.00	2508841	99.90	2508856	99.90
2509020	100.00	2509315	99.90	2509389	99.80	2509506	100.10	2509738	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4998.80
3 Sum of Squared Measurements	499760.30
4 Correction Factor (CF): Sum of Measurements Squared / N	499760.03
5 Corrected Sum of Squares (SS)	0.27
6 Variance (V) : SS/(N-1)	0.0055
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0744
8 Sample Mean(XBAR): Sum X/N	99.98
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	27.21
12 Quality Index Lower (QL): (XBAR-L) / S	26.56
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: C2SOS Division: 01 Sample Lot: 2006 Lot Descr: KU C2SOS - 1
 In Service Population: 344 Sample Quantity: 20 Meters Tested: 20 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 10

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2400123	100.00	2400151	99.90	2400526	99.80	2400528	100.00	2400530	99.90
2400566	100.00	2400592	99.90	2400622	100.20	2400625	100.10	2400643	100.00
2400677	100.00	2400680	100.00	2400694	100.10	2400785	100.20	2400831	100.00
2400864	100.00	2400875	100.00	2400902	100.10	2400931	99.90	2400943	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	20
2 Sum of Measurements: (Sum X)	2000.10
3 Sum of Squared Measurements	200020.19
4 Correction Factor (CF): Sum of Measurements Squared / N	200020.00
5 Corrected Sum of Squares (SS)	0.19
6 Variance (V) : SS/(N-1)	0.0100
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0999
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	19.98
12 Quality Index Lower (QL): (XBAR-L) / S	20.08
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	6.18
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: D4S Division: 01 Sample Lot: 2007 Lot Descr: KU D4S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 11

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C222198	100.00	C222768	100.40	C226310	100.10	C226568	100.10	C226623	100.30
C226624	99.50	C228220	99.90	C228291	100.20	C228609	99.80	C229474	100.20
C229622	100.20	C229671	100.30	C230372	100.10	C230388	100.30	C230432	99.80
C230580	100.20	C230595	99.60	C230612	99.90	C231899	100.00	C231977	100.30
C232127	100.10	C232428	99.70	C233672	100.20	C234031	100.20	C234062	100.20
C236015	99.90	C236367	100.40	C236460	100.30	C237012	99.80	C240836	99.80
L001758	99.60	L002261	99.80	L136315	99.80	L136440	100.00	L136448	99.30
L140855	100.30	L141160	100.10	L141212	99.60	L141261	99.60	M350542	99.90
M351850	99.90	M353288	99.90	M353343	100.00	M353390	99.70	M353401	100.10
M354003	99.70	M354572	99.90	M354585	100.40	M367362	99.90	M367950	99.80
M367957	100.10	M375080	100.30	M375165	100.40	M375276	100.20	M375320	100.50
M375360	100.10	M375388	99.90	M376048	100.30	M376291	100.00	M376295	100.20
M376451	99.90	M376554	100.70	M376633	99.80	M389025	100.20	W101292	100.00
W102790	100.40	W104870	99.60	W105449	99.80	W105474	99.90	W105673	100.10
W106029	99.90	W108348	100.10	W108926	100.30	W109263	99.80	W109712	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7502.10
3 Sum of Squared Measurements	750425.43
4 Correction Factor (CF): Sum of Measurements Squared / N	750420.06
5 Corrected Sum of Squares (SS)	5.37
6 Variance (V) : SS/(N-1)	0.0726
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2694
8 Sample Mean(XBAR): Sum X/N	100.03
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.32
12 Quality Index Lower (QL): (XBAR-L) / S	7.53
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: D4S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2008
Pass/ Fail: PASS

Lot Descr: KU D4S - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 12

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C241384	99.90	C241524	99.80	C245355	100.40	C245791	99.90	C245964	100.00
C246136	100.10	C246193	100.20	C250789	99.60	C254340	99.80	C254451	99.70
C254454	99.70	C254650	100.10	C255079	99.40	C255164	100.30	C256853	99.70
C257054	99.70	C257109	100.20	L216298	100.30	L216538	99.60	L216660	100.10
L218933	99.80	L219043	99.50	L221688	99.90	L221710	100.10	L221727	99.60
M385067	100.10	M385213	99.60	M385474	99.70	M385833	100.40	M389107	99.70
M389278	99.60	M389861	100.10	M390028	100.20	M390259	100.10	M392297	100.30
M392431	100.00	M392865	100.00	M393015	99.90	M393071	100.20	M393107	99.80
M393173	99.70	M393207	100.10	M393336	100.00	M393410	100.40	M393490	99.90
M396378	99.50	M396889	100.00	M397006	100.10	M397013	99.50	M397050	99.80
M397148	99.60	M397189	99.80	M397258	99.50	M397336	100.00	M397362	98.90
M397533	100.20	M397908	100.20	M398164	99.60	M398377	100.10	M398702	100.30
M398936	99.80	M398967	99.70	M399192	100.10	M427817	99.80	W110339	99.60
W110340	100.20	W110644	99.90	W111247	100.00	W111466	99.60	W111508	100.00
W111739	100.50	W116873	100.30	W116955	99.70	W117087	99.50	W119656	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.10
3 Sum of Squared Measurements	748627.03
4 Correction Factor (CF): Sum of Measurements Squared / N	748620.63
5 Corrected Sum of Squares (SS)	6.40
6 Variance (V) : SS/(N-1)	0.0864
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2940
8 Sample Mean(XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.12
12 Quality Index Lower (QL): (XBAR-L) / S	6.49
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 5,307

Model Number: D4S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2009
Pass/ Fail: PASS

Lot Descr: XU D4S - 3

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 13

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C221921	99.40	C222084	99.80	C222713	99.90	C222838	99.90	C223925	100.00
C257649	100.40	C257679	99.90	C264090	100.10	L219166	100.00	L219172	100.00
L219196	100.10	L219311	99.80	L219389	99.70	L221768	100.00	L221969	100.20
L223761	100.00	L223833	100.10	L224056	99.50	L224155	100.20	L224309	100.00
L224312	100.60	L224353	99.80	L224424	99.80	L224592	99.70	L224649	99.30
L224691	99.90	L224755	99.70	L227932	100.10	L228186	99.70	L228213	99.70
L228291	100.20	L228401	99.60	L228438	99.70	L228781	99.70	L228798	99.90
L228855	100.10	M394598	100.30	M394681	100.00	M394686	100.20	M394795	100.10
M394930	100.20	M395036	100.00	M395088	99.80	M395207	100.10	M395213	99.90
M395238	100.00	M395371	100.00	M395406	99.50	M395599	100.00	M395634	100.10
M395653	99.70	M395960	99.80	M401097	100.10	M401169	100.30	M401182	99.90
M401248	100.00	M401253	99.70	M401268	99.40	M401291	99.60	M401512	100.40
M401549	99.90	M401604	100.00	M401646	99.80	M401702	100.00	M401818	100.50
M407940	100.00	M413654	100.00	W119733	99.80	W119844	100.00	W119911	99.80
W119930	100.20	W119993	99.60	W120211	99.90	W120256	99.80	W120480	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7494.80
3 Sum of Squared Measurements	748964.94
4 Correction Factor (CF): Sum of Measurements Squared / N	748960.36
5 Corrected Sum of Squares (SS)	4.58
6 Variance (V) : SS/(N-1)	0.0619
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2488
8 Sample Mean(XBAR): Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.32
12 Quality Index Lower (QL): (XBAR-L) / S	7.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: D5S Division: 01 Sample Lot: 2010 Lot Descr: KU D5S - 1
 In Service Population: 392 Sample Quantity: 20 Meters Tested: 20 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 14
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C267881	100.30	C279692	100.00	C279775	99.80	C279853	100.30	C279882	100.50
C279966	99.30	C283551	99.20	C283579	99.30	C283719	99.00	C298923	98.90
C298934	100.40	C298940	100.20	C298949	100.30	C299011	100.00	C299022	99.50
C299045	99.40	C299055	100.20	C299092	100.40	C299170	99.60	M418653	99.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	20
2 Sum of Measurements: (Sum X)	1996.10
3 Sum of Squared Measurements	199225.81
4 Correction Factor (CF): Sum of Measurements Squared / N	199220.76
5 Corrected Sum of Squares (SS)	5.05
6 Variance (V) : SS/(N-1)	0.2658
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.5155
8 Sample Mean(XBAR): Sum X/N	99.81
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.26
12 Quality Index Lower (QL): (XBAR-L) / S	3.50
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	6.18
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: Focus AXR-Mesh Division: 01 Sample Lot: 2011 Lot Descr: KU Focus AXR
 In Service Population: 30 Sample Quantity: 5 Meters Tested: 5 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 15

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
2400015	100.10	2400021	100.10	2400028	100.00	2400052	100.00	2400066	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	5
2 Sum of Measurements: (Sum X)	500.30
3 Sum of Squared Measurements	50060.03
4 Correction Factor (CF): Sum of Measurements Squared / N	50060.02
5 Corrected Sum of Squares (SS)	0.01
6 Variance (V) : SS/(N-1)	0.0030
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.0548
8 Sample Mean(XBAR): Sum X/N	100.06
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	35.42
12 Quality Index Lower (QL): (XBAR-L) / S	37.61
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	9.80
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200E Model Number: I210 Division: 01 Sample Lot: 2012 Lot Descr: KU I210 - 1
 In Service Population: 4,983 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 16

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C432107	100.00	C432200	99.90	C432225	100.10	C432295	100.00	C432348	99.90
C432367	99.90	C432379	100.00	C432385	99.90	C432461	101.10	C432481	100.00
C432569	99.90	C432644	100.10	C432778	100.00	C432798	100.00	C432827	100.00
C432845	100.30	C432864	99.90	C433019	99.90	C433033	100.10	C433165	100.00
C433176	99.90	C433213	100.10	C433256	99.90	C433276	100.00	C433287	100.00
C445616	99.90	C445621	99.90	C445725	99.90	C445958	100.00	C445994	99.90
C446118	100.00	C446318	100.00	C455960	100.00	C456033	100.00	C456038	100.00
C456421	99.80	C456436	99.90	C456445	100.00	C456471	99.90	C456592	99.90
C456877	100.00	C456908	100.00	C457072	100.00	C457237	100.00	C457255	99.90
C457261	99.90	C457341	100.00	C457407	100.00	C457427	100.10	C457445	100.00
C457623	100.00	C463955	100.10	C463975	100.10	C464138	99.90	C464243	100.10
C464278	100.10	C464307	100.00	C464350	100.00	C464492	100.10	C464646	100.00
C464661	99.90	C464827	100.00	C464946	100.00	C464968	100.10	C465070	99.90
C465152	100.10	C465213	100.00	C465346	100.10	C465347	99.80	C465352	100.00
C465438	100.00	C465491	100.10	C465517	100.10	C465578	99.90	C465603	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.30
3 Sum of Squared Measurements	750061.75
4 Correction Factor (CF): Sum of Measurements Squared / N	750060.00
5 Corrected Sum of Squares (SS)	1.75
6 Variance (V) : SS/(N-1)	0.0236
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1537
8 Sample Mean(XBAR): Sum X/N	100.00
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	12.98
12 Quality Index Lower (QL): (XBAR-L) / S	13.04
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V15AC100 Model Number: I50S Division: 01 Sample Lot: 2013 Lot Descr: KU I50 - 1
 In Service Population: 944 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 17

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
CI77209	100.50	L044816	99.90	L061049	99.70	L061264	100.40	L062051	100.00
L062107	99.90	L062114	100.10	L062264	99.70	L062322	99.80	L062576	100.00
L063211	99.70	L065134	100.20	L066469	100.30	L068503	100.10	L068535	99.50
L070480	99.80	L071297	100.20	L071558	99.80	L072552	100.00	L072674	99.50
L073076	100.20	L073721	100.00	L074170	99.70	L074259	99.30	L074537	99.70
L074848	100.00	L075613	100.20	M431126	99.80	W072179	100.00	W074832	100.30
W074880	100.30	W075253	100.10	W078150	100.00	W079251	100.10	W079346	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3498.70
3 Sum of Squared Measurements	349742.51
4 Correction Factor (CF): Sum of Measurements Squared / N	349740.05
5 Corrected Sum of Squares (SS)	2.46
6 Variance (V) : SS/(N-1)	0.0724
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2691
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.57
12 Quality Index Lower (QL): (XBAR-L) / S	7.29
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V15AC100 Model Number: I55S Division: 01 Sample Lot: 2014 Lot Descr: KU I55 - 1
 In Service Population: 827 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 18
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C200584	99.90	C298263	99.70	L075864	98.90	L076214	100.00	L076715	100.00
L076808	100.30	L077306	100.30	L077963	100.20	L078047	100.00	L078420	99.90
L079371	99.70	L079385	100.00	L079889	100.00	L079957	100.00	L080545	100.00
L081053	100.10	L081252	100.10	L081996	100.00	L082103	100.10	L082926	98.40
L083817	100.10	L084345	99.80	L084628	99.20	L085059	99.30	L085270	99.70
L085321	99.60	L085610	100.00	L088004	99.80	L088593	99.90	L089591	100.00
L089757	99.50	L089896	99.50	M417325	99.80	M431372	99.90	M451312	99.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3493.10
3 Sum of Squared Measurements	348626.61
4 Correction Factor (CF): Sum of Measurements Squared / N	348621.36
5 Corrected Sum of Squares (SS)	5.25
6 Variance (V) : SS/(N-1)	0.1544
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3929
8 Sample Mean(XBAR): Sum X/N	99.80
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.59
12 Quality Index Lower (QL): (XBAR-L) / S	4.59
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200

Model Number: I60S

Division: 01

Sample Lot: 2015

Lot Descr: KU I60 - 1

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 19

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C204190	100.10	C204192	100.30	C204324	100.60	C204388	99.90	L001333	99.80
L001607	99.90	L004391	99.70	L005243	99.60	L005330	99.80	L006351	99.50
L007247	99.60	L007299	99.70	L007938	100.00	L008745	99.80	L010247	99.70
L011147	100.00	L011771	100.20	L012549	99.90	L012583	99.80	L014746	99.80
L017831	99.90	L017846	100.10	L018275	100.20	L019116	100.10	L091134	99.90
L091146	99.90	L091494	100.00	L091699	100.20	L092032	99.80	L092073	99.60
L092258	99.90	L092693	100.00	L092764	99.70	L093104	99.90	L093529	99.90
L093637	100.10	L094386	100.00	L094720	99.90	L095344	101.00	L095947	99.60
L095956	99.70	L096117	100.20	L096210	99.90	L096846	99.70	L096866	99.40
L096943	100.20	L097867	100.20	L099220	99.70	L099320	99.80	L099815	99.90
L100223	100.10	L100389	99.70	L100684	100.10	L100989	100.10	L101021	99.70
L101034	99.60	L101136	100.10	L101223	99.80	L101602	100.30	L102584	99.80
L102919	99.90	L103736	100.00	L104379	100.30	L104595	100.10	L104948	100.00
L105195	100.10	L105735	99.50	L105846	100.00	L105859	100.20	L106305	99.20
L106373	99.80	L106648	99.20	L106793	100.10	L107272	99.60	L108425	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7493.50
3 Sum of Squared Measurements	748706.47
4 Correction Factor (CF): Sum of Measurements Squared / N	748700.56
5 Corrected Sum of Squares (SS)	5.91
6 Variance (V) : SS/(N-1)	0.0798
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2825
8 Sample Mean(XBAR): Sum X/N	99.91
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.39
12 Quality Index Lower (QL): (XBAR-L) / S	6.77
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: I60S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2016
Pass/ Fail: PASS

Lot Descr: KU I60 - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 20

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C208389	100.10	C209485	100.30	C209656	100.20	C212477	100.30	C212532	100.00
C212621	99.90	C213236	100.20	C213318	99.90	C213975	100.40	C214996	100.20
C215074	100.50	C215117	100.20	L007113	100.20	L008504	99.90	L008919	99.90
L009126	99.60	L009314	99.80	L012215	99.90	L012535	100.10	L018595	99.90
L021223	100.10	L021299	99.90	L022992	99.80	L025273	99.90	L035841	100.00
L038483	99.60	L065876	100.00	L067190	100.30	L070682	99.90	L077042	100.10
L079485	99.80	L089522	99.90	L092580	99.70	L095091	99.70	L096668	99.90
L102107	99.50	L109039	99.70	L110022	100.20	L110410	99.70	L111256	99.80
L111397	100.20	L111854	99.70	L111895	100.00	L112009	100.40	L112171	100.00
L112523	100.10	L112632	99.50	L112824	99.50	L112968	100.00	L112995	99.70
L113309	100.00	L113496	99.90	L113731	99.60	L113741	100.10	L113928	99.60
L114043	99.90	L114307	99.80	L114689	99.90	L114761	100.00	L114782	100.20
L114870	100.20	L114939	99.90	L114942	99.20	L115406	100.00	L115770	100.00
L115886	100.10	L116300	100.10	L116650	99.70	L116788	100.00	L117036	99.90
L117285	99.60	L117474	99.90	L117874	100.00	L118285	100.20	W093965	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7495.90
3 Sum of Squared Measurements	749184.51
4 Correction Factor (CF): Sum of Measurements Squared / N	749180.22
5 Corrected Sum of Squares (SS)	4.29
6 Variance (V) : SS/(N-1)	0.0579
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2407
8 Sample Mean(XBAR): Sum X/N	99.95
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.54
12 Quality Index Lower (QL): (XBAR-L) / S	8.08
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I60S Division: 01 Sample Lot: 2017 Lot Descr: XU I60 - 3
 In Service Population: 8,848 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 21

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C218816	100.10	C218839	100.10	C220076	100.20	L000630	100.30	L001153	100.00
L005360	99.90	L006148	100.10	L006723	100.10	L006946	100.00	L009263	99.80
L011785	100.20	L060047	100.10	L072193	100.40	L085679	99.90	L086096	100.10
L088222	100.10	L090281	100.10	L090634	99.80	L096723	100.20	L101997	100.50
L103253	100.20	L118407	100.20	L118651	100.30	L118668	100.00	L118688	100.30
L118711	100.20	L118771	100.10	L119428	99.80	L119481	99.80	L119755	100.10
L120072	100.30	L120240	99.50	L120284	99.80	L120800	99.70	L121007	100.20
L121036	100.30	L121140	100.10	L121262	100.10	L121425	100.20	L121925	99.90
L121942	100.20	L121979	99.40	L122267	100.10	L122689	100.00	L122751	100.10
L123031	100.20	L123091	100.10	L123103	100.20	L123154	99.90	L123190	99.90
L123200	100.10	L123282	99.80	L123444	100.00	L123557	100.00	L123563	100.00
L123692	100.10	L124055	100.00	L124254	99.70	L124407	100.20	L124447	100.20
L124495	100.00	L124532	100.20	L124737	100.20	L124752	100.10	L125006	100.20
L125282	100.30	L125443	99.80	L125780	100.00	L125822	100.10	L126304	100.00
L126741	100.30	L127172	99.90	L127418	99.80	L127596	99.60	L268388	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.00
3 Sum of Squared Measurements	750803.24
4 Correction Factor (CF): Sum of Measurements Squared / N	750800.21
5 Corrected Sum of Squares (SS)	3.03
6 Variance (V) : SS/(N-1)	0.0409
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2022
8 Sample Mean(XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.63
12 Quality Index Lower (QL): (XBAR-L) / S	10.15
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2018 Lot Descr: KU I70 - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 22

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223193	100.10	C223218	100.20	C226840	99.90	C226865	100.10	C227044	99.70
C227068	100.10	C229131	100.40	C229137	100.30	C229427	100.10	C229430	100.80
C230889	100.40	L006312	100.20	L009763	99.80	L010670	100.40	L010776	100.50
L010825	99.80	L013641	100.20	L017519	100.50	L018126	100.20	L018257	100.00
L018695	100.30	L020579	100.30	L021959	100.40	L021964	100.20	L023810	99.90
L024592	100.00	L045669	100.40	L060620	99.70	L064007	100.30	L064829	100.30
L068250	100.10	L082954	100.50	L083206	100.00	L088289	99.80	L092153	99.60
L105445	100.10	L105914	100.40	L127916	99.80	L127934	100.10	L128052	100.20
L128063	100.20	L128217	100.20	L128859	99.80	L128930	100.00	L128984	100.20
L129047	100.20	L129469	99.90	L129564	100.20	L129907	99.80	L130171	99.70
L130194	99.80	L130431	100.00	L130490	99.90	L131546	100.00	L131554	99.90
L131850	100.20	L132292	100.30	L133072	100.30	L133215	100.00	L133644	100.20
L133749	100.30	L133753	99.80	L133826	100.60	L133950	100.20	L133955	100.40
L134137	99.80	L134299	100.30	L134387	100.00	L134653	99.90	L134744	100.00
L135152	99.70	L135216	99.80	L135521	100.20	L135828	100.00	M351494	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.40
3 Sum of Squared Measurements	751685.58
4 Correction Factor (CF): Sum of Measurements Squared / N	751680.94
5 Corrected Sum of Squares (SS)	4.64
6 Variance (V) : SS/(N-1)	0.0627
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2504
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.54
12 Quality Index Lower (QL): (XBAR-L) / S	8.44
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2019 Lot Descr: KU I70 - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 23

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C233044	100.40	C233184	99.90	C234247	100.40	C235005	100.40	C235014	100.40
C235103	100.40	C235251	100.50	C238340	100.30	C238584	100.20	C239070	100.60
L136552	100.10	L136688	100.30	L137159	100.30	L137485	100.20	L137921	100.10
L138350	99.80	L138477	100.80	L138612	100.10	L138640	100.20	L138665	100.10
L138815	100.20	L138980	99.90	L139729	100.60	L139828	100.50	L140160	100.20
L140316	100.20	L140483	100.10	L140955	100.30	L141497	100.20	L141564	100.10
L141833	100.00	L142574	100.40	L142605	99.80	L143068	100.30	L143319	100.20
L143534	99.90	L143588	100.00	L143630	100.60	L143772	100.60	L143789	100.30
L144311	100.70	L144685	99.70	L144829	100.50	L144906	99.70	L145024	100.00
L145257	100.10	L145325	99.80	L145454	100.40	L145606	100.30	L145615	100.40
L145793	100.10	L145835	100.10	L146010	99.60	L146172	100.30	L146674	100.50
L146706	100.10	L146820	100.20	L146957	100.00	L147060	100.20	L147064	100.00
L147301	100.20	L147395	100.30	L148221	100.20	L148696	100.20	L148732	100.20
L148861	100.10	L149175	100.00	L170335	99.80	M374107	100.40	W104437	100.60
W104444	100.30	W107665	100.40	W108048	100.40	W108396	100.00	W108458	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7515.80
3 Sum of Squared Measurements	753167.80
4 Correction Factor (CF): Sum of Measurements Squared / N	753163.33
5 Corrected Sum of Squares (SS)	4.47
6 Variance (V) : SS/(N-1)	0.0604
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2458
8 Sample Mean(XBAR): Sum X/N	100.21
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.28
12 Quality Index Lower (QL): (XBAR-L) / S	8.99
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2020 Lot Descr: KU I70 - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 24
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C239086	99.80	C239316	100.10	C243013	100.10	C243212	99.90	C243262	100.10
C243328	100.30	C243340	100.30	C243394	100.00	L171216	100.30	L171290	100.10
L172252	100.00	L172362	100.30	L172519	99.70	L172570	100.30	L172612	99.90
L172771	100.20	L173001	100.10	L173219	99.80	L173228	99.80	L173654	100.20
L173749	100.20	L173772	99.90	L174359	99.90	L174360	100.10	L174860	99.80
L175251	100.10	L175292	99.60	L175513	99.70	L175552	100.00	L175586	100.30
L175656	99.90	L176563	100.20	L176771	100.30	L176931	99.80	L176940	100.10
L177034	99.50	L177068	100.10	L177611	100.00	L179107	99.60	L179345	99.50
L179373	99.90	L179405	100.00	L179435	99.70	L179550	100.10	L179562	100.00
L180189	99.90	L180491	100.20	L180817	100.30	L180937	100.00	L181290	100.10
L181333	100.20	L182381	100.20	L182860	100.30	L183455	100.60	L183519	100.50
L183523	100.10	L183917	99.90	L183977	100.10	L184003	100.30	L184177	100.30
L184301	100.40	L184407	100.10	L184426	100.20	L184510	100.40	L184552	100.20
L184583	100.20	L184589	100.10	L184658	99.90	L184690	99.80	L185641	100.10
L185743	100.00	L185768	100.00	L185815	100.20	L185907	99.80	L185978	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.10
3 Sum of Squared Measurements	750823.99
4 Correction Factor (CF): Sum of Measurements Squared / N	750820.22
5 Corrected Sum of Squares (SS)	3.77
6 Variance (V) : SS/(N-1)	0.0509
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2256
8 Sample Mean(XBAR): Sum X/N	100.05
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.62
12 Quality Index Lower (QL): (XBAR-L) / S	9.11
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2021 Lot Descr: KU I70 - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 25

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C243846	99.90	C243942	100.00	C243969	100.00	C247709	100.30	C247750	99.70
C247766	100.30	C247789	100.50	C247899	100.10	C247984	99.90	C247999	100.50
C248074	99.70	C248148	100.20	C248186	100.40	C248194	100.20	C248213	100.40
C248444	100.30	C248499	100.10	C248662	100.20	C248671	100.40	C252034	100.20
L186802	100.00	L186991	100.00	L186997	100.50	L187132	100.00	L187414	99.60
L187516	100.10	L187575	100.30	L187680	99.80	L188756	100.00	L188899	100.10
L189079	99.50	L189146	99.80	L189211	100.10	L189253	100.10	L189275	99.80
L189334	99.80	L189539	99.60	L190491	100.30	L190607	100.10	L191098	99.80
L191129	99.80	L191718	100.10	L192453	99.80	L192568	99.80	L192767	100.10
L192982	99.80	L195086	99.90	L195483	100.00	L195490	100.10	L195497	100.10
L195783	100.00	L196053	99.90	L196528	100.00	L196603	99.90	L196718	100.10
L196750	100.10	L196909	99.90	L197682	99.60	L197693	100.00	L198702	99.50
L199741	99.70	L199832	99.90	L199891	100.20	L200009	100.00	L200190	99.90
L200240	100.00	L200450	100.20	L200564	100.00	M384524	99.80	W112542	100.00
W113926	100.30	W114161	100.00	W114241	99.90	W114301	100.20	W114368	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7501.50
3 Sum of Squared Measurements	750304.01
4 Correction Factor (CF): Sum of Measurements Squared / N	750300.03
5 Corrected Sum of Squares (SS)	3.98
6 Variance (V) : SS/(N-1)	0.0538
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2319
8 Sample Mean(XBAR): Sum X/N	100.02
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.54
12 Quality Index Lower (QL): (XBAR-L) / S	8.71
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2022 Lot Descr: KU I70 - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 26

Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C223375	100.30	C252313	100.30	C252499	100.20	C252544	100.40	C252628	100.50
C252727	100.40	C252773	100.20	L035716	100.00	L201546	99.90	L201820	99.70
L201846	100.00	L202139	100.00	L203442	99.50	L203538	99.90	L203704	100.10
L203955	99.70	L204008	99.90	L204017	100.10	L204116	100.00	L204338	100.00
L204425	99.90	L204671	99.80	L204775	100.20	L204854	99.90	L204855	100.10
L204909	100.20	L205133	100.10	L205259	99.90	L205481	100.30	L205504	99.90
L205539	99.70	L205713	100.20	L205810	100.30	L205907	100.40	L206977	99.60
L207025	100.30	L207155	99.70	L207295	100.00	L207376	99.70	L207584	100.00
L207968	100.40	L208801	100.30	L210127	99.90	L210486	100.00	L210818	100.10
L211818	100.10	L211937	100.20	L212160	100.10	L212853	100.10	L212962	100.10
L213270	100.30	L213421	100.00	L213441	100.10	L213838	100.20	L213928	100.20
L213951	100.60	L214065	100.20	L214541	100.10	L214692	100.00	L215003	100.10
L215298	100.00	L215343	99.80	L215372	100.20	L215387	100.20	L215490	99.90
L217041	100.10	L217276	100.00	L217309	99.90	W116032	100.20	W116176	100.00
W117503	100.60	W117548	100.20	W117578	100.20	W117707	100.30	W117849	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.40
3 Sum of Squared Measurements	751284.22
4 Correction Factor (CF): Sum of Measurements Squared / N	751280.55
5 Corrected Sum of Squares (SS)	3.67
6 Variance (V) : SS/(N-1)	0.0496
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2228
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.59
12 Quality Index Lower (QL): (XBAR-L) / S	9.36
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2023 Lot Descr: KU I70 - 6
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 27

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C255559	100.10	C255674	100.10	C256113	100.10	C256340	99.80	C256380	100.30
C256404	100.30	C256441	100.30	C256482	100.20	C256576	99.60	C256634	100.10
C261833	100.40	C262072	100.00	C262127	100.10	C262624	100.30	C262642	100.30
C262695	99.90	L217942	100.00	L217967	100.20	L219554	100.30	L219558	99.90
L219708	100.10	L220163	100.20	L220183	100.00	L220411	100.60	L220509	100.40
L220543	100.00	L220813	100.40	L220955	100.10	L222026	99.70	L222291	100.40
L222369	100.30	L222424	100.10	L225106	99.90	L225122	99.80	L225265	100.00
L225396	100.30	L226006	99.90	L226044	100.30	L226104	99.80	L226366	100.40
L226394	100.00	L226464	99.90	L226596	100.10	L226887	99.90	L226909	100.00
L226965	100.40	L227018	100.10	L227377	100.30	L233500	100.10	L233549	100.60
L233591	100.20	L233729	100.30	L233767	99.80	L233828	100.20	L234050	99.70
L234116	100.00	L234356	99.80	L234423	99.90	L234505	99.80	L234535	100.10
L234543	99.90	L234590	100.10	L234776	100.20	M402573	100.30	M403705	100.20
M403855	100.00	M404408	99.90	M404723	99.60	M404784	99.90	M427231	100.10
M427319	100.30	W120743	100.20	W120773	100.10	W121013	100.00	W121044	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7506.80
3 Sum of Squared Measurements	751364.20
4 Correction Factor (CF): Sum of Measurements Squared / N	751360.62
5 Corrected Sum of Squares (SS)	3.58
6 Variance (V) : SS/(N-1)	0.0484
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2201
8 Sample Mean(XBAR): Sum X/N	100.09
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.68
12 Quality Index Lower (QL): (XBAR-L) / S	9.50
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2024 Lot Descr: KU I70 - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 28
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C266842	100.20	C267560	100.10	C267640	100.40	C267646	100.00	C267783	100.00
C271957	99.90	C272196	100.00	C272207	100.10	C272467	100.40	C272729	100.00
C272942	100.10	C272966	100.00	C272980	99.80	C272991	99.70	C273045	99.80
C273054	100.00	C276613	99.90	C276661	100.30	C276744	100.20	C277076	100.20
C277107	100.20	C277210	100.40	C277319	100.10	C277668	100.20	C281430	99.90
C281496	100.10	C281537	100.10	C282095	100.10	C286741	100.30	C286770	100.50
L101216	99.80	L235106	100.20	L235217	100.20	L235255	100.00	L235303	100.30
L235664	100.10	L237683	99.70	L237876	100.00	L238626	99.90	L238743	99.90
L238755	99.90	L238956	99.90	L239612	100.10	L239675	100.00	L241282	99.30
L241519	100.20	L241533	100.30	L241540	99.90	L241692	99.60	L241713	99.90
L242329	100.20	L242525	99.90	L242809	99.80	L244293	99.90	L244294	99.90
L244316	99.50	L244510	100.00	L244593	99.90	M416724	100.20	M416890	100.20
M420042	99.90	M420197	100.00	M420635	99.40	W121516	100.00	W121525	99.90
W122504	100.20	W122606	100.40	W123016	99.90	W123111	100.30	W123126	100.00
W123158	100.20	W123318	100.50	W124052	100.20	W124061	100.10	W125746	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7503.10
3 Sum of Squared Measurements	750624.17
4 Correction Factor (CF): Sum of Measurements Squared / N	750620.13
5 Corrected Sum of Squares (SS)	4.04
6 Variance (V) : SS/(N-1)	0.0546
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2337
8 Sample Mean(XBAR): Sum X/N	100.04
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.38
12 Quality Index Lower (QL): (XBAR-L) / S	8.73
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2025 Lot Descr: KU I70 - 8
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 29

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C286946	100.30	C286972	100.00	C287067	100.00	C287417	100.10	C287540	100.40
C290231	100.30	C290348	100.00	C290436	100.00	C290501	100.10	C290625	100.10
C290748	100.50	C291150	99.90	C292412	100.20	C292498	100.10	C292540	99.80
C292551	99.70	C292695	100.30	C292971	100.10	C293296	99.70	C293384	99.70
C293565	100.00	C293676	99.80	C293732	100.00	C293738	100.00	C293861	100.30
C294201	100.40	C294228	100.30	C294232	100.40	C294269	100.00	C294355	100.30
C294520	100.40	C295995	100.00	C296270	100.20	C296289	100.30	C296404	100.10
C296517	100.40	C296605	100.20	C296809	100.30	C296941	99.90	L262247	99.80
L262321	100.20	L262358	100.10	L262436	100.20	L262463	100.20	L262874	100.30
L262966	100.00	L263210	99.90	L263252	100.00	L263619	100.10	L263639	99.80
L263857	100.00	L263943	100.00	L263970	100.20	L264196	100.00	L264359	100.10
L264401	100.00	L264404	100.10	L264743	100.10	M420878	99.70	W126511	100.20
W126564	99.80	W126596	100.10	W127904	99.90	W128623	100.40	W128933	100.00
W129199	100.10	W129217	100.40	W129349	100.20	W130129	100.20	W131269	100.30
W131348	99.80	W131432	100.10	W131672	100.00	W131907	100.20	W132253	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7507.30
3 Sum of Squared Measurements	751463.53
4 Correction Factor (CF): Sum of Measurements Squared / N	751460.71
5 Corrected Sum of Squares (SS)	2.82
6 Variance (V) : SS/(N-1)	0.0381
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1952
8 Sample Mean(XBAR): Sum X/N	100.10
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.75
12 Quality Index Lower (QL): (XBAR-L) / S	10.74
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2026 Lot Descr: KU I70 - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 30

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C262621	99.90	C299226	100.20	C299771	100.40	C300044	100.10	C300238	100.10
C304842	100.50	C304988	100.20	C305149	100.20	C305208	100.30	C305241	100.50
C305478	100.80	C305575	100.00	C305578	100.20	C305679	100.40	C335344	99.90
C335738	99.70	L265295	99.90	L265710	100.10	L265721	100.00	L265796	100.20
L265797	100.20	L265953	99.90	L265999	100.20	L266205	100.40	L266257	100.10
L266438	100.30	L266659	100.20	L266689	100.10	L266696	100.10	L266701	100.20
L276613	100.30	L276821	100.30	L276846	100.00	L276937	100.00	L277234	100.20
L277272	99.80	L277477	100.00	L277554	100.10	L291901	99.80	L303901	99.70
L303940	99.60	L304074	99.50	L304076	99.80	M431837	99.40	M433719	100.10
M433891	100.40	M433905	100.20	M434124	100.00	M434345	100.10	M434360	100.60
M434388	100.20	M434585	100.00	M438163	100.20	M438547	100.20	W132667	100.10
W132810	100.00	W132879	100.10	W133641	100.10	W133739	100.10	W133934	100.20
W136064	100.20	W136262	100.30	W136471	99.80	W136586	100.20	W136877	100.00
W136902	100.00	W136953	100.00	W137176	100.00	W137308	100.20	W137352	100.10
W137491	100.00	W137682	100.30	W137757	100.30	W137788	100.30	W137880	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.30
3 Sum of Squared Measurements	751664.91
4 Correction Factor (CF): Sum of Measurements Squared / N	751660.92
5 Corrected Sum of Squares (SS)	3.99
6 Variance (V) : SS/(N-1)	0.0539
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2322
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.14
12 Quality Index Lower (QL): (XBAR-L) / S	9.09
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2027 Lot Descr: KU I70 - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 31

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C335919	99.80	C335940	99.90	C336404	99.40	C336485	100.30	C336546	100.10
C336585	99.80	C336762	99.50	C336842	99.40	C336952	99.60	C337095	99.60
C337291	99.30	C337372	99.90	C337474	99.70	C337518	100.10	C337621	99.20
C337643	100.00	C337710	100.00	C337840	100.10	C338119	99.60	C338124	100.10
C338329	99.90	C338440	99.90	C338472	99.60	C338491	99.50	C338498	99.80
C338554	99.50	C339166	99.80	C339308	99.80	C339356	99.20	C339392	99.40
C339474	99.90	C339608	100.10	C340079	99.90	C340249	99.70	C340371	100.20
C340549	99.50	C340901	99.60	C341129	99.70	C341424	99.80	C341718	100.00
C341793	99.90	C341995	99.80	C342669	99.70	C343026	99.70	C343437	100.00
C343577	99.70	C343668	99.50	C343699	99.90	L304166	99.90	L304257	99.70
L304404	100.00	L304426	99.50	L304449	99.70	L304482	99.80	L304518	99.80
L304560	99.90	L304936	99.60	L305120	99.80	L305181	99.60	L305578	99.90
L305873	100.10	L306058	100.00	L306226	99.70	L306366	99.60	L306434	99.70
L306657	99.70	L307079	99.80	L307105	99.80	L307113	99.40	L307127	99.80
L307174	99.60	L307384	99.60	L307657	99.90	M446760	100.00	M446816	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7482.30
3 Sum of Squared Measurements	746468.13
4 Correction Factor (CF): Sum of Measurements Squared / N	746464.18
5 Corrected Sum of Squares (SS)	3.95
6 Variance (V) : SS/(N-1)	0.0534
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2311
8 Sample Mean(XBAR): Sum X/N	99.76
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.67
12 Quality Index Lower (QL): (XBAR-L) / S	7.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2028 Lot Descr: KU I70 - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 32

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C342122	100.00	C342212	99.60	C342234	99.60	C342291	100.00	C343776	99.80
C344081	99.50	C344178	99.90	C344260	99.80	C344267	99.70	C351785	100.10
C351919	100.20	C351997	100.10	C352099	100.10	L307881	99.60	L307918	99.50
L308027	99.90	L308070	99.70	L308150	99.90	L308359	99.70	L308436	99.80
L308629	99.70	L308813	99.80	L308855	99.70	L309376	99.30	L309468	99.40
L309489	99.50	L309819	99.60	L309900	99.80	L309943	99.90	L310023	99.60
L310161	99.70	L310397	99.60	L310420	99.70	L310496	100.10	L310828	99.70
L311500	99.80	L311785	99.50	L312135	100.10	L312151	99.60	L312304	99.70
L312351	99.70	L312524	100.30	L313147	100.00	M446987	99.70	M447007	99.60
M447056	99.80	M447063	99.60	M447234	99.80	M447702	99.90	M447884	99.60
W149210	99.80	W149302	99.80	W149620	99.70	W149654	99.60	W149672	99.50
W149763	99.60	W149840	99.60	W149928	99.90	W149938	100.00	W150375	99.40
W150398	99.40	W150439	99.50	W150530	99.70	W150611	99.70	W150687	99.60
W150908	99.90	W151228	99.80	W151240	100.10	W151601	100.10	W151662	99.90
W151812	100.00	W151889	99.70	W152083	100.10	W152109	99.90	W152195	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7482.50
3 Sum of Squared Measurements	746507.41
4 Correction Factor (CF): Sum of Measurements Squared / N	746504.08
5 Corrected Sum of Squares (SS)	3.33
6 Variance (V) : SS/(N-1)	0.0450
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2120
8 Sample Mean(XBAR): Sum X/N	99.77
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.53
12 Quality Index Lower (QL): (XBAR-L) / S	8.33
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: I70S Division: 01 Sample Lot: 2029 Lot Descr: KU I70 - 12
 In Service Population: 2,867 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 33

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
L268268	101.10	W152624	100.00	W152628	100.00	W152705	99.60	W152856	99.60
W152907	100.00	W153028	99.90	W153034	99.80	W153035	99.70	W153098	99.80
W153100	99.70	W153146	99.90	W153151	99.80	W153411	100.30	W153416	100.00
W153496	99.40	W153507	99.90	W153567	100.00	W153635	100.10	W153697	99.60
W153749	99.80	W153793	99.80	W153798	99.70	W153827	100.10	W153863	99.70
W153917	99.90	W153990	99.70	W154140	99.70	W154180	99.90	W154314	99.90
W154392	99.80	W154397	100.00	W154425	99.80	W154428	100.00	W154487	99.90
W154500	99.80	W154610	99.70	W154652	99.80	W154769	99.80	W154773	100.10
W154969	99.70	W155020	100.00	W155033	99.40	W155048	100.00	W155088	99.30
W155136	100.20	W155194	99.50	W155213	99.70	W155222	99.70	W155408	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4992.40
3 Sum of Squared Measurements	498484.72
4 Correction Factor (CF): Sum of Measurements Squared / N	498481.16
5 Corrected Sum of Squares (SS)	3.56
6 Variance (V) : SS/(N-1)	0.0728
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2697
8 Sample Mean(XBAR): Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.98
12 Quality Index Lower (QL): (XBAR-L) / S	6.85
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 2030 Lot Descr: KU J4S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 34

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C228900	99.80	C233286	99.80	C233431	99.60	C233467	99.90	C233545	99.80
C235629	100.10	C235689	100.30	C239562	100.00	C239750	99.50	C240383	99.50
C240465	99.90	C240572	100.20	C244170	100.10	C244264	100.50	C244487	99.60
C244872	99.90	C245027	100.30	C248817	100.80	C248899	99.60	C249034	99.80
C249144	100.20	C249224	99.90	C249340	100.60	C249411	99.70	C249779	100.00
C253550	100.10	C262914	99.40	C262925	100.00	C263125	99.70	C263171	99.50
C263260	99.80	C263626	99.80	C263745	99.50	C267937	100.00	C268272	99.50
C268302	99.80	C268638	99.90	C268723	99.70	C268729	99.80	C268921	99.60
L240062	99.90	L240183	99.90	L240306	99.90	L240451	99.50	M374812	99.10
M381672	100.00	M391170	99.60	M391339	100.00	M391368	100.00	M391518	100.40
M393587	100.20	M393631	99.80	M394050	100.00	M394337	99.60	M408736	99.80
M408753	99.50	M408759	99.70	M409155	99.80	M410942	99.80	M412968	99.50
M413041	99.30	W104279	99.60	W104299	99.80	W104320	100.30	W105844	100.00
W106520	99.90	W107885	99.90	W108202	99.30	W108631	99.90	W110545	99.60
W111135	100.80	W113359	99.90	W113557	99.60	W118240	100.10	W122958	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7489.10
3 Sum of Squared Measurements	747829.23
4 Correction Factor (CF): Sum of Measurements Squared / N	747821.58
5 Corrected Sum of Squares (SS)	7.65
6 Variance (V) : SS/(N-1)	0.1033
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3214
8 Sample Mean(XBAR): Sum X/N	99.85
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.67
12 Quality Index Lower (QL): (XBAR-L) / S	5.77
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J4S Division: 01 Sample Lot: 2031 Lot Descr: KU J4S - 2
 In Service Population: 1,495 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 35
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C342521	99.70	C342541	99.50	C351171	99.70	C351268	99.90	C351502	99.70
C351522	100.10	C351573	100.10	C351583	100.10	L240535	100.20	L240574	99.80
L240578	99.50	L241758	99.70	L241783	99.50	L241788	99.60	L241852	99.40
L241890	99.10	L241926	99.70	L242012	99.40	L242072	99.70	L242135	99.40
L242139	99.90	L242256	99.40	L242312	99.30	L242324	99.10	L247656	100.00
M415435	100.60	M415437	99.50	M415503	99.90	M415518	99.70	M415556	100.00
M415632	99.80	M415679	99.60	M415695	99.60	M415728	99.60	M415778	99.50
M415832	99.90	M415942	99.60	M415951	99.80	M415963	99.50	M416102	99.90
M416118	100.00	M416143	99.30	M416168	99.70	M416175	99.90	M416182	99.60
W123574	99.20	W123590	99.30	W123602	99.60	W123628	99.70	W123689	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	4983.90
3 Sum of Squared Measurements	496789.37
4 Correction Factor (CF): Sum of Measurements Squared / N	496785.18
5 Corrected Sum of Squares (SS)	4.19
6 Variance (V) : SS/(N-1)	0.0854
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2923
8 Sample Mean(XBAR): Sum X/N	99.68
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.94
12 Quality Index Lower (QL): (XBAR-L) / S	5.74
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2032 Lot Descr: KU J5S - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 36

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C273153	99.70	C273381	99.60	C273670	100.00	C273944	100.40	C274018	100.10
C277755	99.70	C277942	100.20	C277993	99.90	C278002	100.00	C278488	100.10
C278719	99.80	C278754	100.20	C282315	100.10	C282408	100.60	C282713	99.60
C288072	99.90	C288124	100.10	C288126	100.10	C288352	100.30	C288614	99.90
C288649	100.20	C288672	100.70	C288873	100.00	L243055	100.40	L243177	99.20
L243231	99.80	L243404	99.40	L243420	100.00	L243434	100.20	L244697	100.20
L244734	100.00	L244744	99.40	L244759	99.80	L245005	99.90	L245064	99.90
L245175	100.20	L245795	99.90	L245804	100.50	L245894	100.20	L246095	100.30
L246274	99.90	L246288	99.50	L246410	100.20	L246618	100.30	L246997	100.00
L247013	99.80	L247257	100.00	L247624	100.10	L247929	99.30	L248032	100.00
L248243	99.70	L248384	99.80	L248465	99.80	L248941	99.50	L248968	100.10
L249158	99.80	L250327	100.10	L250482	100.40	L250547	99.90	L250827	99.80
L251014	99.00	L251302	99.90	L251501	99.60	L251585	100.40	L251786	100.30
L253118	100.20	L253219	99.50	L253601	99.80	L253864	99.80	L255144	99.90
W124218	99.80	W125278	99.60	W125818	100.30	W127053	100.10	W127158	100.30

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.00
3 Sum of Squared Measurements	749407.78
4 Correction Factor (CF): Sum of Measurements Squared / N	749400.12
5 Corrected Sum of Squares (SS)	7.66
6 Variance (V) : SS/(N-1)	0.1035
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3217
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.34
12 Quality Index Lower (QL): (XBAR-L) / S	6.09
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2033 Lot Descr: KU J5S - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 37
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C284408	100.20	C284515	99.90	C291211	99.80	C291604	100.10	C292025	100.00
C292108	100.20	C292186	100.80	L254212	100.10	L254223	99.80	L254350	99.90
L254519	99.90	L254844	100.00	L255155	100.20	L255313	99.50	L255839	100.50
L255853	100.20	L256434	100.10	L256852	99.80	L256958	100.00	L257021	99.80
L257073	99.70	L257788	99.80	L257894	99.40	L257927	99.80	L257994	100.00
L258040	99.00	L258423	100.20	L258763	100.40	L258764	100.00	L259023	99.90
L259119	99.80	L259397	99.60	L259413	100.60	L259530	100.20	L259802	100.40
M421544	99.60	M421695	100.10	M421746	99.80	M421917	99.80	M421994	99.70
M422659	100.30	M422682	100.00	M422810	100.30	M422946	99.80	M423119	100.00
M423330	99.90	M423591	100.10	M423748	100.00	M423935	100.00	M424202	100.30
M424227	99.90	M424513	99.60	M424664	99.60	M424673	99.80	M424799	99.10
M424945	100.00	M424951	99.90	M428837	100.10	M428955	100.00	M429229	100.10
M429378	100.00	M429420	99.90	M429453	100.20	W127548	100.00	W128128	100.10
W128148	99.90	W128267	100.60	W128287	100.32	W128711	99.90	W129627	100.20
W129639	99.40	W129710	100.00	W129811	100.10	W130044	99.60	W130480	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.62
3 Sum of Squared Measurements	749531.01
4 Correction Factor (CF): Sum of Measurements Squared / N	749524.08
5 Corrected Sum of Squares (SS)	6.94
6 Variance (V) : SS/(N-1)	0.0937
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3062
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.64
12 Quality Index Lower (QL): (XBAR-L) / S	6.43
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (.12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2034 Lot Descr: KU J5S - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 38
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C284025	100.00	C284245	100.20	C284293	100.30	C294923	99.70	C295041	100.00
C295046	99.90	C295073	99.60	C295085	99.90	C295235	100.30	C295294	100.20
C295359	99.80	C295728	100.00	C295772	100.10	C296966	100.40	C296969	99.60
C297121	100.00	C297447	99.50	C297452	99.90	C297653	100.10	C297710	99.80
C298064	100.20	L261052	100.10	L261300	99.60	L261429	100.00	L261539	100.00
L261653	99.80	L261823	100.40	L262097	100.20	L262124	99.90	L262131	100.30
L262162	99.90	L266986	100.00	L267137	100.20	L267296	100.30	L267325	100.20
L267431	99.70	L269083	99.80	L269217	99.60	L269742	100.00	L269745	99.80
L269755	99.80	L269840	99.90	L270033	99.50	L270034	99.50	L270094	99.90
L270165	99.50	L270388	99.60	L270547	99.90	L270661	99.80	M429734	99.80
M429743	99.90	M429771	100.20	M429793	100.20	M429955	100.00	M430038	100.00
M430087	99.90	M430485	100.20	M430739	100.20	M430977	99.80	M432093	100.20
M432396	100.50	M432430	100.00	M432436	100.20	M432444	100.10	M432886	100.20
M433261	100.20	M433291	100.00	M433337	99.80	M433466	100.00	M433468	99.80
M433490	100.30	M433548	99.80	W130581	100.00	W130780	99.80	W131190	99.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.20
3 Sum of Squared Measurements	749444.58
4 Correction Factor (CF): Sum of Measurements Squared / N	749440.10
5 Corrected Sum of Squares (SS)	4.48
6 Variance (V) : SS/(N-1)	0.0605
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2459
8 Sample Mean(XBAR): Sum X/N	99.96
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.28
12 Quality Index Lower (QL): (XBAR-L) / S	7.98
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2035 Lot Descr: KU J5S - 4
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 39
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C303394	100.10	C303819	100.20	C303820	100.10	C304096	100.00	C304275	100.10
C306114	99.80	C306134	99.50	C306234	99.90	C306475	99.90	C307041	99.80
C307130	100.10	C307135	99.50	C307702	99.90	C307729	99.90	C307826	99.90
C307974	99.80	C308132	100.10	C308141	99.80	C308203	99.70	C308246	99.50
C308533	99.70	C308811	99.90	C308826	99.40	C308942	99.70	C309001	99.50
C309020	100.10	C309037	99.40	C309044	99.90	L270795	100.30	L270831	99.70
L270991	99.90	L271100	100.10	L271157	100.10	L271296	100.00	L271354	99.80
L271357	100.10	L271591	99.90	L271881	100.30	L271890	101.40	L272055	100.20
L272131	99.80	L272161	99.70	L272280	99.70	L272380	99.30	L272534	99.80
L272628	99.70	L272903	99.30	L273180	99.70	L273236	100.00	L273243	100.30
L273325	99.90	L273386	99.90	L273409	99.80	L273467	99.70	L273541	99.50
L273762	99.80	L274010	100.30	L274106	100.10	L274239	99.80	L274245	99.80
L274259	99.70	L274381	100.10	L274409	99.60	L274838	99.80	L274910	99.50
L275088	99.80	L275181	99.70	L275642	100.00	L275702	100.20	L275798	100.10
L275814	99.70	L275831	99.40	L275861	100.10	L275981	99.80	P005268	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7490.40
3 Sum of Squared Measurements	748088.04
4 Correction Factor (CF): Sum of Measurements Squared / N	748081.23
5 Corrected Sum of Squares (SS)	6.81
6 Variance (V) : SS/(N-1)	0.0920
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3034
8 Sample Mean(XBAR): Sum X/N	99.87
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.01
12 Quality Index Lower (QL): (XBAR-L) / S	6.17
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2036 Lot Descr: KU J5S - 5
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 40

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C309087	99.80	C309181	99.20	C309189	99.90	C309247	100.20	C309270	99.60
C309799	100.00	C309829	99.80	C309842	99.50	C309857	99.50	C309905	100.20
C309926	99.80	C309986	100.00	C310076	100.00	C310339	99.60	C310364	100.30
C310500	99.50	C310503	99.60	C310887	100.30	C311267	100.20	C311418	99.80
C311518	100.20	C311528	99.80	C311701	100.20	C312054	100.60	C312109	100.10
C312295	99.70	C312401	100.00	C312415	100.10	C313178	100.20	C313315	100.20
C313344	100.30	C313394	99.80	C313413	99.80	L278110	99.60	L278126	99.60
L278395	100.00	L278439	100.00	L278471	99.50	L278571	99.90	L278937	99.80
L279176	99.90	L279302	99.80	L279598	99.70	L279604	99.90	L279645	99.20
L279682	99.90	L279718	99.70	L279751	99.60	L279790	99.90	L279976	99.60
L280566	99.90	L280809	99.70	L280812	99.80	L280819	99.80	L280833	99.70
L280997	99.60	L281172	99.70	L281413	99.90	L281523	100.20	L281533	99.80
L281722	99.60	L282021	99.70	L282255	100.00	L282369	100.30	L282538	99.50
L282722	100.10	L283145	100.10	L283259	99.80	L283304	99.80	L283320	99.70
L283377	99.80	M438826	100.00	M439083	100.00	M439178	100.00	M439184	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7489.50
3 Sum of Squared Measurements	747906.61
4 Correction Factor (CF): Sum of Measurements Squared / N	747901.47
5 Corrected Sum of Squares (SS)	5.14
6 Variance (V) : SS/(N-1)	0.0695
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2636
8 Sample Mean(XBAR): Sum X/N	99.86
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.12
12 Quality Index Lower (QL): (XBAR-L) / S	7.06
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J5S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2037
Pass/ Fail: PASS

Lot Descr: KU J5S - 6

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
One AQL Value for Both Upper and Lower Specification Limit Combined
AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 41

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C313431	99.80	C313708	99.90	C313741	99.80	C313783	100.40	C313974	100.30
C314020	99.90	C314082	99.30	C314189	100.20	C314227	99.90	C314716	100.20
C314750	100.00	C315247	100.30	C315254	99.70	C315290	99.80	C315625	100.10
C315708	99.90	C316005	99.90	C316086	100.20	C316136	100.00	C316139	100.10
C316359	100.50	C316455	100.00	C316654	99.80	C316694	100.10	C316705	100.00
C316918	99.80	C316957	100.00	C317283	99.90	C317321	100.00	C317354	99.80
C317423	100.10	C317516	100.20	C317657	99.90	C317809	99.70	C317874	100.30
C317878	99.90	C318095	99.90	C318151	99.90	C318196	99.70	C318408	100.10
C318424	99.90	C318503	99.80	C318655	99.90	C318676	100.10	C318741	100.30
C318881	100.10	C319145	99.60	C319812	100.10	C319936	100.00	C320136	99.50
C320241	99.80	C320275	99.80	C320327	100.10	C320510	99.60	C320550	100.40
L283780	99.70	L283861	100.30	L284143	99.90	L284164	99.50	L284968	99.90
L285155	100.00	L285212	99.60	W138453	99.60	W138458	100.10	W138594	100.40
W138625	100.20	W138792	100.20	W139084	99.80	W139107	99.80	W139280	100.10
W139475	99.80	W139537	99.80	W139954	100.00	W140232	100.60	W140294	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.10
3 Sum of Squared Measurements	749624.79
4 Correction Factor (CF): Sum of Measurements Squared / N	749620.05
5 Corrected Sum of Squares (SS)	4.74
6 Variance (V) : SS/(N-1)	0.0641
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2531
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.00
12 Quality Index Lower (QL): (XBAR-L) / S	7.80
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2038 Lot Descr: KU J5S - 7
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value For Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 42

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C326017	100.00	C326179	100.10	C326446	99.80	C326685	100.00	C326702	99.70
C326853	100.00	C326965	99.60	C327111	100.30	C327229	100.30	C327427	99.80
C327436	100.40	C327596	99.90	C327601	100.20	C327625	100.30	C327977	100.20
C328289	99.80	C328423	99.10	C328454	99.40	C328578	100.30	C328754	99.70
C328897	99.60	C328946	100.50	C328958	99.40	C328985	100.00	C329179	99.30
C329377	99.70	C329716	100.20	C329969	99.10	C330178	100.00	C330371	100.30
C330602	99.80	C330664	100.10	L285438	99.90	L285618	100.00	L285662	99.80
L285841	100.10	L285884	99.50	L286083	99.90	L286302	99.80	L286317	99.70
L286536	99.90	L286550	100.10	L286644	99.80	L286735	100.30	L286883	99.70
L287014	99.80	L287042	100.10	L287297	99.90	L287409	99.80	L287429	99.80
L287520	99.70	L287593	100.20	L291676	99.90	L291688	99.60	L291736	100.10
L291783	100.10	L291789	99.30	M439584	99.90	M439710	99.60	M439793	100.20
M440046	99.90	M440085	100.10	M440763	99.10	W140839	100.00	W140894	100.00
W140970	99.50	W141015	100.10	W141349	100.30	W141647	99.50	W141691	99.80
W141880	100.10	W141895	99.80	W142277	100.00	W142295	99.70	W142426	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7491.40
3 Sum of Squared Measurements	748288.06
4 Correction Factor (CF): Sum of Measurements Squared / N	748280.99
5 Corrected Sum of Squares (SS)	7.07
6 Variance (V) : SS/(N-1)	0.0956
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3092
8 Sample Mean(XBAR): Sum X/N	99.89
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.84
12 Quality Index Lower (QL): (XBAR-L) / S	6.10
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200

Model Number: J5S

Division: 01

Sample Lot: 2039

Lot Descr: KU J5S - 8

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 43

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C331214	99.60	C331256	100.20	C331304	99.60	C331706	100.40	C349266	100.00
C349278	99.60	C349386	98.60	C349423	99.70	C349432	99.70	C349667	99.40
C349705	99.40	L292779	99.70	L293140	100.20	L293360	99.90	L293519	99.90
L293566	100.00	L293861	99.80	L294066	99.20	L294068	100.20	L294131	100.30
L294435	99.70	L294449	100.20	L294692	100.30	L294730	100.00	L295183	99.70
L295294	99.90	L295297	100.10	L295549	100.20	L295651	100.30	L295754	99.50
L295939	100.40	L295997	99.90	L296021	99.50	L296151	100.10	L296317	100.20
L296352	100.30	L296489	100.30	L296533	100.00	L296696	99.70	L296708	99.70
L296714	99.20	L296794	99.80	L296937	100.50	L297122	100.30	L297123	100.00
L297327	100.00	L297487	99.80	M437218	100.30	M437537	100.60	M437578	100.20
M442636	99.80	M443076	99.80	M443720	99.90	M445896	100.20	W144397	101.00
W144761	100.20	W144831	100.10	W145016	100.60	W145201	100.10	W145333	100.30
W145361	100.10	W145524	100.40	W145547	100.50	W145585	99.90	W145829	99.90
W145991	99.80	W146003	99.50	W146066	99.70	W146143	99.60	W146351	99.70
W146385	99.80	W146437	99.50	W146556	99.90	W146623	99.70	W146714	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7495.80
3 Sum of Squared Measurements	749170.78
4 Correction Factor (CF): Sum of Measurements Squared / N	749160.24
5 Corrected Sum of Squares (SS)	10.54
6 Variance (V) : SS/(N-1)	0.1425
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3775
8 Sample Mean(XBAR): Sum X/N	99.94
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.45
12 Quality Index Lower (QL): (XBAR-L) / S	5.15
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2040 Lot Descr: KU J5S - 9
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 44
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C349956	99.70	C350241	99.70	C350386	99.40	C350480	99.70	C350718	99.30
C351098	99.30	C353102	99.50	C353460	99.40	C353550	99.60	C353915	99.30
C353980	100.00	C354217	100.30	C354281	100.00	C354309	100.10	C354332	99.60
C354518	100.10	C354554	99.40	C354556	99.60	C354678	99.60	C354766	99.70
C354827	99.60	C355071	99.60	C355245	99.40	C355865	99.90	C355869	100.00
C355872	99.40	C355906	99.20	C356508	99.00	C356624	100.10	C356643	100.00
C357162	99.70	C357234	99.80	C357274	100.80	C357276	100.20	C357305	99.80
C357343	99.30	C357376	99.50	C357565	99.60	C357788	99.80	C357871	100.20
C358036	99.80	C358132	100.20	C358444	99.60	C358603	99.70	C358712	99.80
C358881	99.70	C358949	100.10	C358966	100.40	L313241	99.40	L313299	99.80
L313462	99.10	L313464	99.50	L313550	98.90	L313594	99.70	L313606	99.60
L313776	99.20	L313809	99.90	L313842	99.10	L313962	99.30	L314171	100.10
L314338	99.80	L314646	99.60	L314659	99.80	L314696	99.00	L314713	99.10
L314980	99.70	L315231	99.60	L315258	99.70	L315395	100.10	L315397	99.60
L315733	99.30	L316879	99.20	L316980	99.10	L317046	99.50	L317258	98.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7473.10
3 Sum of Squared Measurements	744639.91
4 Correction Factor (CF): Sum of Measurements Squared / N	744629.65
5 Corrected Sum of Squares (SS)	10.26
6 Variance (V) : SS/(N-1)	0.1387
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3724
8 Sample Mean(XBAR): Sum X/N	99.64
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.33
12 Quality Index Lower (QL): (XBAR-L) / S	4.41
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2041 Lot Descr: KU J5S - 10
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 45
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C359225	99.80	C359233	98.50	C359268	99.50	C359457	100.60	C359677	100.60
C359741	100.10	C359840	99.70	C360093	99.30	C360121	99.20	C360147	100.40
C360181	99.40	C360383	99.50	C360390	99.90	C360446	99.70	C360505	99.70
C361070	99.30	C361237	99.00	C362034	99.90	C362067	99.80	C362147	99.40
C362267	99.40	C362353	99.60	C362370	99.60	C362428	99.50	C362660	99.70
C362663	99.70	C363037	99.60	C363057	99.60	C363175	99.70	C363270	99.70
C363285	100.20	C363450	99.40	C363720	99.00	C363761	99.70	C363763	99.10
C363871	100.20	C363873	99.80	C363941	99.90	C364062	99.40	C364080	100.00
C364470	98.60	C364544	99.70	C365044	99.40	C365136	99.40	C365665	100.10
C365923	99.60	C365946	98.30	C365947	99.50	C366039	99.60	C366247	99.10
C366526	99.20	C366772	99.80	C366776	100.00	C366895	99.60	C367428	99.30
C367459	100.10	M448154	99.60	M448176	99.40	M448340	99.90	M448477	99.90
M448620	99.70	M448647	99.70	M448723	99.80	M448728	99.30	M448754	98.90
M448907	99.40	M448974	99.40	M449143	99.10	M449487	99.80	M449631	100.10
M449831	99.40	M449867	100.00	M449895	99.50	M449967	99.90	M450076	99.60

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7469.80
3 Sum of Squared Measurements	743984.92
4 Correction Factor (CF): Sum of Measurements Squared / N	743972.16
5 Corrected Sum of Squares (SS)	12.76
6 Variance (V) : SS/(N-1)	0.1724
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4152
8 Sample Mean(XBAR): Sum X/N	99.60
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.79
12 Quality Index Lower (QL): (XBAR-L) / S	3.85
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2042 Lot Descr: KU J5S - 11
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 46
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C367742	100.10	C367745	99.80	C367809	100.00	C367916	99.40	C368332	99.80
C368336	99.50	C368390	100.40	C368430	100.00	C370065	99.90	C370289	99.80
C370488	99.80	C370636	100.20	C371213	99.60	C371219	99.60	C371269	100.00
C371390	99.70	C371607	99.60	C371689	99.30	C372023	99.40	C372564	99.40
C372719	99.40	C373165	99.80	C373437	99.90	C373461	99.80	C373629	99.70
C373638	99.90	C373652	100.20	C373892	99.70	C373942	99.70	C374061	99.80
C374072	99.50	C374114	100.00	C374379	99.70	C374410	99.90	C374535	99.40
C374598	99.70	C374624	99.20	C374727	100.10	C375190	99.80	C375255	99.90
C375391	100.00	C375423	99.60	C375509	100.10	C375727	100.10	C375990	99.70
C376011	98.80	C376016	99.60	C376101	100.10	C376192	99.80	C376739	100.20
C376760	100.20	C376971	99.60	C377065	99.80	C377182	100.10	C377264	99.50
C377272	99.80	C377587	100.10	C377634	100.20	C377757	99.90	C377785	99.00
C377858	99.30	C377931	99.70	C378098	100.00	C378352	99.80	C378438	99.90
C378459	99.40	C378469	99.60	C378600	99.80	C378724	99.50	C378957	99.80
M450170	98.70	M450228	99.50	M450334	99.50	M450540	99.60	M450622	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7480.50
3 Sum of Squared Measurements	746112.51
4 Correction Factor (CF): Sum of Measurements Squared / N	746105.07
5 Corrected Sum of Squares (SS)	7.44
6 Variance (V) : SS/(N-1)	0.1005
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3171
8 Sample Mean(XBAR): Sum X/N	99.74
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.13
12 Quality Index Lower (QL): (XBAR-L) / S	5.49
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J5S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2043
Pass/ Fail:-PASS

Lot Descr: KU J5S - 12

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 47

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C379025	99.80	C379038	99.70	C379410	99.30	C379549	99.60	C379939	99.80
C379956	99.70	C380152	99.50	C380550	99.70	C383517	99.70	C383578	99.80
C383616	100.20	C383811	100.10	C383890	99.10	C383932	100.20	C384063	99.30
C384370	100.00	C384647	99.60	C384751	99.60	C384793	99.80	C385048	99.90
C385050	99.90	C385118	99.90	C385172	99.80	C385289	99.80	C385390	99.80
C385592	100.00	C385775	100.30	C385918	100.30	C386069	99.50	C386108	99.40
C387195	100.00	C387502	99.10	C387582	99.40	C387940	100.10	C388085	99.70
C388092	99.80	C388103	99.90	C388108	99.80	C388159	99.90	C388327	99.40
C388417	99.70	C388427	99.70	C388986	100.00	C389069	99.60	C389142	99.50
C389415	99.60	C389461	99.80	C389541	99.60	C389595	99.80	C389695	99.40
C389813	99.80	C389851	99.80	C389875	99.70	C389950	99.60	C389973	100.10
C390087	99.90	C390210	100.20	C390406	99.40	C390431	99.60	C391862	99.70
C391880	100.20	C391932	100.00	C392046	100.00	C392105	99.80	C392390	99.80
C392594	99.90	C392825	99.60	C392990	100.10	C393414	100.30	C393428	99.80
C393546	100.10	C393565	100.20	C393749	100.00	C393924	100.10	C394077	99.70

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7484.30
3 Sum of Squared Measurements	746868.73
4 Correction Factor (CF): Sum of Measurements Squared / N	746863.29
5 Corrected Sum of Squares (SS)	5.44
6 Variance (V) : SS/(N-1)	0.0736
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2712
8 Sample Mean(XBAR): Sum X/N	99.79
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.15
12 Quality Index Lower (QL): (XBAR-L) / S	6.60
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2044 Lot Descr: KU J5S - 13
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 48

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C394325	99.50	C394410	100.00	C394423	99.30	C394536	99.70	C394556	99.30
C394770	100.20	C394930	100.30	C394955	100.00	C395212	100.30	C395566	99.50
C395852	100.10	C396063	99.70	C396114	100.10	C396278	100.10	C396287	99.90
C396293	100.60	C396437	100.10	C396782	100.00	C396996	100.10	C397071	100.20
C397142	100.60	C397207	100.70	C397365	99.90	C397402	99.60	C397422	100.00
C397486	100.00	C397524	99.90	C397633	100.20	C397687	99.90	C397704	99.80
C397780	99.70	C398298	99.60	C398403	99.70	C398541	99.70	C398598	99.80
C398791	99.90	C398839	100.30	C398961	99.00	C398984	100.20	C398999	99.60
C399350	100.20	C399503	100.20	C399566	100.30	C399632	100.20	C399832	99.90
C399881	99.80	C399950	100.00	C400016	99.70	C400150	100.10	C400156	99.80
C400635	99.90	C401551	100.40	C401589	99.90	C401863	99.90	C402251	100.20
C402282	100.10	C402293	100.00	C402351	100.40	C402547	100.40	C402554	100.10
C402683	99.80	C402710	99.70	C403024	100.80	C403057	99.90	C403179	100.00
C403208	100.00	C403478	99.60	C403736	99.90	C403782	100.40	C403840	99.90
C403937	99.50	C404147	99.50	C404677	99.90	C404791	99.90	C404977	100.40

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7497.80
3 Sum of Squared Measurements	749568.00
4 Correction Factor (CF): Sum of Measurements Squared / N	749560.06
5 Corrected Sum of Squares (SS)	7.94
6 Variance (V) : SS/(N-1)	0.1072
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3275
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.20
12 Quality Index Lower (QL): (XBAR-L) / S	6.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: J5S
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2045
Pass/ Fail: PASS

Lot Descr: KU J5S - 14

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 49

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C405081	100.10	C405466	99.90	C405680	99.60	C405807	99.20	C405929	99.10
C405938	99.10	C406047	98.50	C406052	98.50	C410196	100.00	C410504	99.00
C410731	99.80	C410753	99.70	C410795	99.10	C410966	99.00	C410982	99.20
C411728	99.70	C411730	99.70	C411807	100.60	C412046	99.60	C412117	99.30
C412189	99.70	C412394	99.40	C412415	100.40	C413043	99.60	C413052	99.40
C413122	98.80	C413176	99.40	C413311	99.90	C413439	99.00	C413495	99.70
C413790	99.50	C413808	100.40	C414154	99.00	C414171	98.80	C414507	99.60
C414540	99.70	C414607	98.80	C414736	99.70	C414753	99.00	C414818	100.00
C415050	99.40	C415058	99.70	C415078	100.00	C415171	99.60	C415175	98.80
C415242	99.30	C415490	99.90	C415644	99.60	C417783	99.80	C417883	100.00
C417962	99.40	C417976	99.30	C418025	99.60	C418040	99.60	C418073	99.20
C418176	99.80	C418254	99.50	C418346	99.20	C418537	99.60	C418549	98.60
C418824	100.60	C418860	99.00	C419365	100.10	C419398	99.70	C419871	99.90
C420459	98.80	C420471	98.80	C420511	99.00	C420687	99.20	C420691	99.50
C420699	99.60	C420782	99.30	C420929	99.00	C420983	99.60	C421072	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7460.40
3 Sum of Squared Measurements	742117.04
4 Correction Factor (CF): Sum of Measurements Squared / N	742100.91
5 Corrected Sum of Squares (SS)	16.13
6 Variance (V) : SS/(N-1)	0.2180
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4669
8 Sample Mean(XBAR): Sum X/N	99.47
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.41
12 Quality Index Lower (QL): (XBAR-L) / S	3.15
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.06
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.06
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: J5S Division: 01 Sample Lot: 2046 Lot Descr: KU J5S - 15
 In Service Population: 4,249 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 50

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C421211	99.10	C421216	99.60	C421263	98.30	C421367	99.70	C421384	98.80
C421414	99.00	C421421	99.70	C421496	99.20	C421616	99.20	C421642	99.70
C421656	99.40	C421663	99.10	C421737	100.30	C421840	100.00	C421844	98.50
C421847	98.70	C421862	98.90	C421973	98.80	C422081	99.60	C422181	99.20
C422486	100.00	C422583	99.70	C422605	99.60	C422765	99.20	C422792	99.50
C422813	98.70	C422855	99.50	C422861	99.10	C422896	99.20	C422965	99.60
C423000	99.30	C423017	99.30	C423063	98.40	C423143	99.70	C423226	99.40
C423265	99.00	C423274	99.00	C423306	99.30	C423354	99.80	C423363	99.40
C423378	99.00	C423423	99.30	C423430	98.70	C423444	99.80	C423479	98.80
C423480	98.50	C423559	99.40	C423593	99.30	C423621	99.60	C423754	99.20
C423817	99.70	C423837	99.80	C423892	99.50	C423964	98.60	C424007	99.50
C424089	99.00	C424237	99.30	C424308	99.60	C424318	99.60	C424434	99.60
C424445	99.90	C424507	98.90	C424543	100.10	C424704	99.60	C424843	99.90
C424874	99.10	C424924	100.40	C424953	100.00	C425290	100.00	C425297	99.20
C425303	100.00	C425308	99.80	C425372	99.60	C425503	99.40	C425512	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7453.10
3 Sum of Squared Measurements	740664.77
4 Correction Factor (CF): Sum of Measurements Squared / N	740649.33
5 Corrected Sum of Squares (SS)	15.44
6 Variance (V) : SS/(N-1)	0.2087
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.4568
8 Sample Mean(XBAR): Sum X/N	99.37
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.75
12 Quality Index Lower (QL): (XBAR-L) / S	3.01
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.10
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.10
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)
 Device Category: F2S40V30AC200
 Model Number: MGS
 Division: 01
 Sample Lot: 2047
 Pass/Fail: PASS

Lot Descr: KU MQ - 1

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Page 51

Serial	Full Load	Accuracy	Serial	Full Load	Accuracy	Serial	Full Load	Accuracy	Serial	Full Load	Accuracy
--------	-----------	----------	--------	-----------	----------	--------	-----------	----------	--------	-----------	----------

C205287	100.40	C205304	100.40	C205316	100.30	C20549	100.10	C207110	99.90
C207475	100.20	C207504	100.30	C208103	99.90	C208192	100.00	C208533	99.90
C208598	100.20	C208671	100.40	C208687	100.40	C209183	99.90	C209212	100.30
C209272	100.10	C209293	100.30	C209351	100.00	C209386	100.10	C209940	100.10
C210357	99.90	C211636	100.40	C211704	100.00	C211748	100.20	C212203	100.10
C212659	100.10	C213561	99.60	C213635	99.90	C213684	100.00	C214139	99.70
C214229	100.10	C214297	99.90	C214307	99.90	C214640	100.20	C214670	100.40
C215463	100.30	C216566	99.80	C217878	100.00	C217879	100.10	C218003	100.00
C218134	100.10	C219132	99.80	C219166	99.70	C219244	99.90	C220775	100.10
C221146	99.90	M362259	100.30	M362265	99.50	M371705	100.20	M371731	99.90
M372121	99.40	M380293	100.00	M387050	100.00	M387068	100.10	M387212	100.70
M092896	100.40	M092926	100.70	M094013	100.00	M094560	100.10	M094620	100.10
M094940	99.80	M095483	100.00	M095526	100.40	M095964	99.60	M096556	100.30
M097180	100.30	M097261	100.30	M097306	100.00	M097314	100.10	M099095	100.10
M099169	100.00	M099433	100.40	M099448	99.90	M100253	100.50	M101003	100.90

INFORMATION NEEDED

75

1	Sample Size (N)	75
2	Sum of Measurements: (Sum X)	7506.90
3	Sum of Squared Measurements	751385.95
4	Correction Factor (CF): Sum of Measurements Squared / N	751380.63
5	Corrected Sum of Squares (SS)	5.32
6	Variance (V) : SS/(N-1)	0.0718
7	Estimate of Lot Standard Deviation(S) : SQRT of V	0.2680
8	Sample Mean(XBAR) : Sum X/N	100.09
9	Upper Specification Limit (U)	102.00
10	Lower Specification Limit (L)	98.00
11	Quality Index Upper (QU) : (U-XBAR) / S	7.12
12	Quality Index Lower (QL) : (XBAR-L) / S	7.81
13	Estimate of Lot Percent NCF Above U (PU)	0.00
14	Estimate of Lot Percent NCF Below L (PL)	0.00
15	Total Estimate Percent NCF, In Lot (P) : PU+PL	0.00
16	Maximum Allowable Percent NCF (M)	4.83
17	Acceptability Criterion: Compare P with M	PASS
18	The Lot Meets the Acceptability Criterion if P <= M	
19	The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 2048 Lot Descr: KU MS - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 52
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C227243	100.70	C227466	100.10	C231687	100.50	C231711	100.30	C232566	101.00
C232636	100.10	C234673	99.90	C234764	99.90	C234807	100.00	C237264	100.20
C237293	100.30	C237303	99.90	C237309	100.20	C237417	100.00	C238016	99.90
C238038	100.60	C238184	100.40	C241883	100.10	C241889	100.50	C241902	100.10
C241932	100.60	C242118	100.40	C242123	100.10	C242152	100.30	L040449	100.70
L132721	100.30	L132736	99.60	L135685	100.30	L136216	100.10	L138033	99.60
L139929	100.50	L141408	100.10	L142931	99.90	L147660	100.10	L147668	100.20
L149278	99.90	L149639	100.40	L149657	100.40	L149745	99.30	L173543	99.90
L173575	100.50	L176113	100.40	L177148	99.90	L177353	100.00	L178703	100.10
L179618	99.30	L179652	99.50	L180090	100.00	L180121	100.10	L181666	100.20
L181746	100.10	L181776	100.00	L181902	100.00	L183107	99.90	L183164	99.90
L183321	99.80	L185196	99.60	L185268	100.20	L185526	100.00	L186249	100.30
L186262	100.00	L187909	100.60	L188365	100.30	M351035	100.30	M351369	100.10
M374625	99.80	M386361	100.10	M386439	99.60	W103315	99.80	W104726	100.40
W104786	100.30	W104798	100.90	W106956	100.30	W108123	101.70	W108851	100.50

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7511.90
3 Sum of Squared Measurements	752392.29
4 Correction Factor (CF): Sum of Measurements Squared / N	752381.89
5 Corrected Sum of Squares (SS)	10.40
6 Variance (V) : SS/(N-1)	0.1406
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3749
8 Sample Mean(XBAR): Sum X/N	100.16
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	4.91
12 Quality Index Lower (QL): (XBAR-L) / S	5.76
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 2049 Lot Descr: KU MS - 2
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 53

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C242250	100.20	C242475	100.40	C242550	100.00	C246448	100.10	C246695	100.20
C246700	99.80	C246977	99.90	C247298	100.20	C247413	100.00	L189945	99.80
L193091	100.30	L193179	100.00	L193427	100.00	L193632	100.10	L193677	100.10
L193755	99.90	L194120	99.90	L194152	99.90	L194499	100.10	L194589	100.60
L194694	99.90	L194720	99.90	L197048	99.90	L197248	99.80	L197253	99.60
L197442	99.70	L198400	99.70	L199060	99.50	L199119	100.30	L199218	99.90
L199281	99.90	L199323	99.70	L199346	99.80	L199502	99.70	L201072	99.10
L201304	99.80	L201372	99.80	L202662	100.00	L202867	99.60	L203016	99.80
L206272	100.10	L206288	100.10	L206460	99.70	L206634	99.90	L206693	100.10
L206697	99.80	L206776	99.60	L208195	100.20	L208237	100.00	L208376	99.70
L209400	100.10	L209418	100.20	L209736	100.20	L209917	99.80	L209918	99.80
L211304	100.20	L211318	100.30	L211426	100.20	L211678	100.00	M384296	99.90
M384346	100.40	M384564	99.70	W109828	100.70	W110108	101.00	W110162	100.20
W111900	100.10	W112185	100.20	W112809	100.20	W112881	100.00	W115099	99.50
W115124	100.20	W115132	100.40	W115407	100.20	W115493	100.10	W115505	100.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7500.50
3 Sum of Squared Measurements	750106.79
4 Correction Factor (CF): Sum of Measurements Squared / N	750100.00
5 Corrected Sum of Squares (SS)	6.79
6 Variance (V) : SS/(N-1)	0.0917
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3028
8 Sample Mean(XBAR): Sum X/N	100.01
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.58
12 Quality Index Lower (QL): (XBAR-L) / S	6.63
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 2050 Lot Descr: KU MS - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 54

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C250919	100.00	C250946	100.00	C251152	100.00	C251319	99.90	C251457	100.20
C251531	100.10	C251536	99.80	C251688	100.30	C251913	100.50	C259028	100.30
C259209	100.10	C259268	100.30	C259326	99.50	C259445	100.00	C259526	100.10
C259639	99.90	C260409	100.90	C260529	100.00	C260588	100.00	C260754	100.30
C260819	100.50	C261142	100.40	C261509	100.30	C265681	101.10	C265855	100.10
C266029	100.60	C266287	100.70	C266604	100.10	C266736	99.80	L212498	100.10
L212736	100.10	L212788	100.00	L215551	100.40	L215922	100.50	L215988	100.00
L218274	100.40	L218593	100.10	L218734	99.80	L218814	100.40	L218824	99.60
L221190	99.70	L221502	100.10	L222789	100.60	L222848	99.60	L223274	99.90
L223560	100.00	L223682	99.90	L231153	100.00	L231181	100.50	L231240	100.30
L231427	100.00	L232295	100.10	L232311	100.00	L232446	99.90	L232624	100.30
L232704	100.10	L236347	100.20	L236477	100.40	L236485	100.10	L236764	100.10
L236773	99.90	L236787	100.20	L236790	99.70	L236810	100.30	L236900	99.60
L236921	99.30	L237015	100.10	L237045	100.00	L237198	99.90	W115918	100.20
W117332	100.00	W117378	99.90	W117410	100.00	W117441	100.00	W118579	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7508.20
3 Sum of Squared Measurements	751647.66
4 Correction Factor (CF): Sum of Measurements Squared / N	751640.90
5 Corrected Sum of Squares (SS)	6.76
6 Variance (V) : SS/(N-1)	0.0914
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3023
8 Sample Mean(XBAR): Sum X/N	100.11
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.25
12 Quality Index Lower (QL): (XBAR-L) / S	6.98
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200

Model Number: MS

Division: 01

Sample Lot: 2051

Lot Descr: KU MS - 4

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 55

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C270805	99.90	C270838	100.30	C271198	100.20	C271409	99.90	C271560	99.70
C271665	100.00	C271681	100.20	C275730	99.90	C275950	100.00	C276330	99.90
C276422	100.40	C280155	100.00	C280276	100.30	C280594	100.40	C280615	100.30
C280660	100.40	C280877	100.20	C284668	99.80	C285215	99.80	C285304	100.50
C285451	99.80	C285588	100.00	C285961	99.70	C286272	100.10	C286431	100.10
C286492	99.90	C289173	100.10	C289402	99.90	C289754	100.10	C301116	100.00
L238381	99.60	L240751	100.00	L241098	100.20	L243498	100.30	L243934	99.90
L243948	100.00	L245302	99.60	L245378	100.30	L245393	100.10	L245494	99.70
L260086	100.10	L260088	100.30	L260142	99.80	L260262	99.90	L260340	99.90
L260395	100.10	L260446	100.00	M434650	100.00	M434655	100.20	M434784	100.10
M434825	99.90	M434845	100.30	M434967	100.00	M435084	100.00	M435152	100.20
M435224	100.40	M435242	100.20	M435289	100.20	M435377	100.30	W124746	99.70
W124796	100.20	W124910	100.10	W126686	99.90	W126699	99.90	W132539	100.20
W132601	99.90	W132954	100.60	W133067	100.30	W133238	100.00	W133271	99.80
W133300	100.30	W133330	100.30	W134155	100.20	W134311	100.10	W134321	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7504.90
3 Sum of Squared Measurements	750983.79
4 Correction Factor (CF): Sum of Measurements Squared / N	750980.32
5 Corrected Sum of Squares (SS)	3.47
6 Variance (V) : SS/(N-1)	0.0469
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2165
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	8.93
12 Quality Index Lower (QL): (XBAR-L) / S	9.54
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MS Division: 01 Sample Lot: 2052 Lot Descr: KU MS - 5
 In Service Population: 1,641 Sample Quantity: 50 Meters Tested: 50 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 56

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
L312416	100.20	L312425	99.90	L312443	99.90	L312463	100.30	L312565	100.20
L312899	100.20	L312929	100.00	L312976	100.10	L312987	100.30	W134450	100.20
W134469	100.00	W134500	99.90	W134515	99.90	W134544	100.50	W134582	99.80
W134607	100.20	W134619	100.10	W134635	99.90	W134719	99.70	W134803	99.80
W134897	100.00	W134945	100.00	W134962	100.00	W134974	100.00	W134994	100.10
W135097	100.00	W135141	100.20	W135144	100.00	W135253	99.80	W135264	100.10
W135310	99.90	W135355	100.30	W135374	100.10	W135422	101.70	W135535	100.10
W135580	100.20	W135609	99.80	W135618	99.90	W135630	100.20	W135632	100.10
W135642	99.90	W135711	99.60	W135713	100.10	W135716	99.90	W135773	99.90
W135800	100.30	W135875	100.00	W135969	99.90	W135994	100.30	W136022	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	50
2 Sum of Measurements: (Sum X)	5003.50
3 Sum of Squared Measurements	500704.51
4 Correction Factor (CF): Sum of Measurements Squared / N	500700.25
5 Corrected Sum of Squares (SS)	4.27
6 Variance (V) : SS/(N-1)	0.0870
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2950
8 Sample Mean(XBAR): Sum X/N	100.07
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	6.54
12 Quality Index Lower (QL): (XBAR-L) / S	7.02
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.21
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)
 Device Category: F2S240V30A2C200
 Model Number: MSII
 Division: 01
 Sample Lot: 2053
 Lot Descr: KU MSII - 1

Sample Lot: 2053
 Pass/Fail: PASS

Lot Descr: KU MSII - 1

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial	Full Load	Accuracy	Serial	Full Load	Accuracy	Serial	Full Load	Accuracy	Serial	Full Load	Accuracy
--------	-----------	----------	--------	-----------	----------	--------	-----------	----------	--------	-----------	----------

C275402	100.00	C275472	100.00	C275517	100.20	C275965	100.00	C275974	99.90
C298653	100.20	C298833	100.00	C300435	100.30	C300440	100.00	C300544	99.90
C300579	100.10	C300668	100.30	C300676	100.20	C301330	100.00	C301379	100.00
C301380	100.10	C301422	100.00	C301563	100.10	C301566	100.20	C301572	100.00
C301626	100.30	C301660	100.00	C301723	100.00	C301766	100.20	C301775	100.30
C301817	99.70	C301819	100.00	C301826	100.20	C301920	100.00	C301968	100.00
C302004	99.90	C302110	100.00	C302131	100.10	C302147	100.10	C302196	100.10
C302216	100.10	C302219	99.80	C302318	100.00	C302518	100.20	C302525	100.30
C302599	100.30	C302618	99.90	C302826	99.80	C302661	100.00	C302713	100.30
C302715	100.00	C302734	100.00	M416367	100.10	L312585	100.10	L312668	99.90
M416363	100.20	M416367	100.10	M421078	100.00	L312585	100.10	M422274	100.10
M422303	100.40	M422359	100.20	M422424	100.40	M422257	99.90	M422549	100.10
M428453	100.00	M428460	100.30	M428548	99.90	M428575	100.00	M435604	100.00
M435636	100.40	M435726	100.10	M436086	100.10	M436100	100.00	M436113	100.10
M436209	100.10	M436329	100.10	M436384	99.90	M436468	100.10	M436589	100.00

1 Sample Size (N)
 INFORMATION NEEDED

2 Sum of Measurements: (Sum X)
 7505.50
 3 Sum of Squared Measurements
 751102.19
 4 Correction Factor (CF) : Sum of Measurements Squared / N
 751100.40
 5 Corrected Sum of Squares (SS)
 1.79
 6 Variance (V) : SS/(N-1)
 0.0241
 7 Estimate of Lot Standard Deviation(S) : SQRT of V
 0.1554
 8 Sample Mean(XBAR) : Sum X/N
 100.07
 9 Upper Specification Limit (U)
 102.00
 10 Lower Specification Limit (L)
 98.00
 11 Quality Index Upper (QU) : (U-XBAR) / S
 12.40
 12 Quality Index Lower (QL) : (XBAR-L) / S
 13.34
 13 Estimate of Lot Percent NCR Above U (PU)
 0.00
 14 Estimate of Lot Percent NCR Below L (PL)
 0.00
 15 Total Estimate Percent NCR in Lot (P) : PU+PL
 0.00
 16 Maximum Allowable Percent NCR(M)
 4.83
 17 Acceptability Criterion: Compare P with M
 PASS

18 The Lot Meets the Acceptability Criterion if P <= M
 19 The Lot Falls the Acceptability Criterion if P > M

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 2054 Lot Descr: KU MX - 1
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 58

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C321145	99.60	C321146	99.80	C321362	99.80	C321370	100.00	C321405	100.10
C322126	100.00	C322130	100.00	C322429	100.10	C322488	100.00	C322508	100.20
C322513	99.90	C322759	99.90	C322858	100.10	C322929	99.80	C323013	100.10
C323270	99.70	C323340	99.90	C323625	99.90	C323800	99.70	C323883	99.90
C323938	99.80	C324020	100.10	C324050	99.80	C324241	99.50	C324326	99.90
C325131	100.10	C325189	100.30	C325268	100.40	C325274	100.00	C325393	100.10
C325429	100.00	C325573	100.10	L288460	99.80	L288631	100.20	L288818	99.90
L289046	99.90	L289229	99.90	L289612	100.10	L289783	100.10	L290140	99.70
L290146	99.90	L290305	99.90	L290339	99.60	L290762	100.20	L290926	100.10
L291094	100.10	L291223	100.00	L291314	100.10	L291418	99.60	M440875	100.30
M440913	99.80	M441029	99.90	M441168	99.70	M441282	100.30	M441340	100.00
M441359	100.20	M441599	100.50	M441728	100.10	M442183	100.30	M442495	100.30
M442503	100.40	M442523	100.40	W142545	99.80	W142568	100.10	W142611	99.60
W142733	100.00	W142762	99.60	W142782	100.00	W142869	99.90	W142974	100.10
W142990	99.50	W143001	99.70	W143141	99.80	W143222	99.90	W143273	100.10

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7498.00
3 Sum of Squared Measurements	749603.76
4 Correction Factor (CF): Sum of Measurements Squared / N	749600.05
5 Corrected Sum of Squares (SS)	3.71
6 Variance (V) : SS/(N-1)	0.0501
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2238
8 Sample Mean(XBAR): Sum X/N	99.97
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	9.06
12 Quality Index Lower (QL): (XBAR-L) / S	8.82
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200
In Service Population: 10,000

Model Number: MX
Sample Quantity: 75

Division: 01
Meters Tested: 75

Sample Lot: 2055
Pass/ Fail: PASS

Lot Descr: KU MX - 2

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 59

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C390697	100.00	C390790	99.90	C390855	99.10	C391023	99.30	C391064	99.80
C391165	100.10	C391317	100.00	C391346	99.80	C391602	100.10	C425973	99.00
C426239	99.20	C426353	99.90	C426400	99.70	C426486	99.50	C426522	99.90
C426575	99.90	C426632	99.40	C426803	99.60	C427189	99.90	C427230	99.60
C427565	99.90	C427593	99.90	C427729	99.50	C427951	99.60	C428174	99.40
C428247	99.70	C428321	100.10	C428556	100.10	C428602	99.90	C428841	100.00
C429029	99.80	C429197	99.70	C429451	99.50	C429597	99.60	C429779	99.70
C429825	99.80	C430070	99.20	C430118	99.20	C430484	99.70	C430888	99.30
C430895	99.50	C430983	99.60	C431055	99.70	C431118	99.90	C431404	99.80
C431475	99.30	C431570	99.60	C431637	99.60	C431746	99.60	C435442	99.40
C435450	99.70	C435528	99.80	C435687	99.90	C435997	99.50	C436245	99.60
C436604	99.60	C436629	99.00	C436739	99.70	C437009	99.30	C437061	99.50
C437443	99.80	C437672	99.60	C437833	99.40	C437851	99.40	C437997	99.90
C438144	100.10	C438204	99.90	C438225	99.70	C438298	99.80	W143504	100.40
W143642	99.80	W143824	99.80	W143995	100.40	W144107	99.70	W144188	100.00

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7476.60
3 Sum of Squared Measurements	745333.54
4 Correction Factor (CF): Sum of Measurements Squared / N	745327.30
5 Corrected Sum of Squares (SS)	6.24
6 Variance (V) : SS/(N-1)	0.0843
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2904
8 Sample Mean(XBAR): Sum X/N	99.69
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	7.96
12 Quality Index Lower (QL): (XBAR-L) / S	5.81
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 2056 Lot Descr: KU MX - 3
 In Service Population: 10,000 Sample Quantity: 75 Meters Tested: 75 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 60

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C438430	99.40	C439159	99.80	C439412	99.70	C439720	99.60	C439901	99.80
C439986	99.80	C439990	98.80	C440004	99.80	C440063	99.90	C440358	100.00
C440421	99.40	C440539	99.50	C440670	99.70	C440778	99.80	C440814	99.80
C440878	100.00	C441174	99.90	C441240	99.80	C441509	99.70	C441562	100.00
C441696	99.80	C441886	99.90	C441921	99.80	C441947	99.80	C442286	99.80
C442392	99.90	C442522	99.70	C442542	99.70	C442572	99.60	C442815	99.50
C442931	99.50	C443286	100.00	C443346	99.50	C443354	99.80	C443621	99.40
C443998	99.80	C444234	99.90	C444305	99.60	C444325	100.00	C444569	99.60
C444769	99.80	C444821	99.80	C444831	99.60	C445017	99.80	C446569	99.60
C446636	99.40	C446733	99.70	C446769	99.50	C446848	99.40	C447012	100.10
C447074	99.70	C447235	99.60	C447245	99.50	C447735	99.50	C448367	99.80
C448380	99.70	C448520	99.80	C448533	99.40	C448550	100.00	C448613	99.90
C448678	99.70	C448885	99.60	C449084	99.80	C449342	99.60	C449473	99.30
C449541	99.80	C449555	99.70	C449675	99.50	C449703	99.70	C449765	99.70
C449799	99.80	C450062	99.60	C450224	99.40	C450315	99.70	C450331	100.20

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7477.50
3 Sum of Squared Measurements	745510.17
4 Correction Factor (CF): Sum of Measurements Squared / N	745506.75
5 Corrected Sum of Squares (SS)	3.42
6 Variance (V) : SS/(N-1)	0.0462
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.2150
8 Sample Mean(XBAR): Sum X/N	99.70
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	10.70
12 Quality Index Lower (QL): (XBAR-L) / S	7.91
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200

Model Number: MX

Division: 01

Sample Lot: 2057

Lot Descr: KU MX - 4

In Service Population: 10,000

Sample Quantity: 75

Meters Tested: 75

Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993

Double Specification Limit - Variability Unknown - Standard Deviation Method

One AQL Value for Both Upper and Lower Specification Limit Combined

AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 61

Run Date: 01/05/2017

Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C450569	99.80	C450833	99.90	C450856	100.00	C450872	99.80	C451172	100.00
C451552	99.60	C451554	100.00	C451713	100.10	C452033	99.70	C452058	99.60
C452090	99.50	C452355	99.30	C452461	99.60	C453029	99.70	C453172	99.70
C453371	99.40	C453416	99.40	C453470	99.70	C453604	99.90	C453670	99.80
C454057	99.90	C454267	99.80	C454399	99.70	C454592	99.50	C454601	99.20
C454702	99.70	C454703	99.90	C454782	100.10	C454982	99.70	C455148	99.80
C455176	100.10	C455364	100.00	C455396	100.00	C455495	99.90	C455593	99.90
C455650	100.00	C455685	100.00	C455916	99.90	C457920	99.90	C457986	99.70
C458315	99.90	C458339	99.50	C458378	99.60	C458457	99.70	C458511	99.80
C458955	99.80	C458977	100.00	C459071	100.00	C459186	99.80	C459198	99.90
C459287	99.80	C459546	99.80	C459581	99.90	C459719	99.70	C459925	99.70
C459984	99.70	C459994	99.90	C460035	99.70	C460117	100.00	C460208	100.00
C460461	99.90	C460488	99.80	C460595	100.10	C460613	99.90	C460791	99.80
C460873	99.90	C460965	99.80	C461058	99.90	C461306	100.00	C461429	99.80
C462020	100.10	C462178	99.90	C462255	100.10	C462328	99.60	C462355	99.90

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	75
2 Sum of Measurements: (Sum X)	7485.90
3 Sum of Squared Measurements	747185.37
4 Correction Factor (CF): Sum of Measurements Squared / N	747182.65
5 Corrected Sum of Squares (SS)	2.72
6 Variance (V) : SS/(N-1)	0.0367
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.1917
8 Sample Mean(XBAR): Sum X/N	99.81
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	11.41
12 Quality Index Lower (QL): (XBAR-L) / S	9.45
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF (M)	4.83
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities

2016 Sample Test Program (01/01/2016) to (12/31/2016)

Device Category: F2S240V30AC200 Model Number: MX Division: 01 Sample Lot: 2058 Lot Descr: KU MX - 5
 In Service Population: 540 Sample Quantity: 35 Meters Tested: 35 Pass/ Fail: PASS

Test Results Per ANSI/ASQC Z1.9-1993
 Double Specification Limit - Variability Unknown - Standard Deviation Method
 One AQL Value for Both Upper and Lower Specification Limit Combined
 AQL = 2.5% - Inspection Level II "E" # Normal Inspection

Page 62
 Run Date: 01/05/2017
 Run Time: 12:28:16 AM

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
C462847	100.00	C462851	99.80	C462867	100.00	C462904	99.80	C462907	100.00
C462923	100.10	C462938	99.80	C462956	100.00	C462984	100.00	C462989	100.40
C462990	99.90	C463011	100.10	C463043	100.10	C463048	100.00	C463049	99.70
C463051	99.90	C463075	100.20	C463098	99.80	C463128	100.00	C463131	99.90
C463143	99.80	C463172	100.00	C463190	98.70	C463191	99.40	C463198	99.70
C463244	99.60	C463248	99.70	C463277	101.30	C463302	99.90	C463309	100.20
C463311	100.10	C463365	100.20	C463371	100.00	C463388	99.80	C463406	99.80

INFORMATION NEEDED

VALUE OBTAINED

1 Sample Size (N)	35
2 Sum of Measurements: (Sum X)	3497.70
3 Sum of Squared Measurements	349544.81
4 Correction Factor (CF): Sum of Measurements Squared / N	349540.15
5 Corrected Sum of Squares (SS)	4.66
6 Variance (V) : SS/(N-1)	0.1370
7 Estimate of Lot Standard Deviation(S): SQRT of V	0.3702
8 Sample Mean(XBAR): Sum X/N	99.93
9 Upper Specification Limit (U)	102.00
10 Lower Specification Limit (L)	98.00
11 Quality Index Upper (QU): (U-XBAR) / S	5.58
12 Quality Index Lower (QL): (XBAR-L) / S	5.23
13 Estimate of Lot Percent NCF Above U (PU)	0.00
14 Estimate of Lot Percent NCF Below L (PL)	0.00
15 Total Estimate Percent NCF. In Lot (P): PU+PL	0.00
16 Maximum Allowable Percent NCF(M)	5.58
17 Acceptability Criterion: Compare P with M	PASS
18 The Lot Meets the Acceptability Criterion if P <= M	
19 The Lot Fails the Acceptability Criterion if P > M	

Kentucky Utilities
2016 Sample Test Program (01/01/2016) to (12/31/2016)

LOT NAME	MANUFACTURER	MODEL	IN-SERV POP	SAMP QTY	SET	REMV	MTRS TST	PASS/FAIL	LOT NUMBER
KU ABl-1	Asea Brown Boveri (ABB)	AB1	5,025	75	0	0	75	PASS TESTING COMPLETE	1997
KU ALF - 1	Landis + Gyr	ALF	157	15	0	0	15	PASS TESTING COMPLETE	1998
KU C1S - 1	Itron	C1SR	10,000	75	0	0	75	PASS TESTING COMPLETE	1999
KU C1S - 2	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	2000
KU C1S - 3	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	2001
KU C1S - 4	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	2002
KU C1S - 5	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	2003
KU C1S - 6	Itron	C1S	10,000	75	0	0	75	PASS TESTING COMPLETE	2004
KU C1S - 7	Itron	C1S	2,702	50	0	0	50	PASS TESTING COMPLETE	2005
KU C2S0S - 1	Itron	C2S0S	344	20	0	0	20	PASS TESTING COMPLETE	2006
KU D4S - 1	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	2007
KU D4S - 2	Westinghouse	D4S	10,000	75	0	0	75	PASS TESTING COMPLETE	2008
KU D4S - 3	Westinghouse	D4S	5,307	75	0	0	75	PASS TESTING COMPLETE	2009
KU D5S - 1	Westinghouse	D5S	392	20	0	0	20	PASS TESTING COMPLETE	2010
KU Focus AXR	Landis + Gyr	Focus AXR-Mesh	30	5	0	0	5	PASS TESTING COMPLETE	2011
KU I210 - 1	General Electric	I210	4,983	75	0	0	75	PASS TESTING COMPLETE	2012
KU I50 - 1	General Electric	I50S	944	35	0	0	35	PASS TESTING COMPLETE	2013
KU I55 - 1	General Electric	I55S	827	35	0	0	35	PASS TESTING COMPLETE	2014
KU I60 - 1	General Electric	I60S	10,000	75	0	0	75	PASS TESTING COMPLETE	2015
KU I60 - 2	General Electric	I60S	10,000	75	0	0	75	PASS TESTING COMPLETE	2016
KU I60 - 3	General Electric	I60S	8,848	75	0	0	75	PASS TESTING COMPLETE	2017
KU I70 - 1	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2018
KU I70 - 2	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2019
KU I70 - 3	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2020
KU I70 - 4	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2021
KU I70 - 5	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2022
KU I70 - 6	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2023
KU I70 - 7	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2024
KU I70 - 8	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2025
KU I70 - 9	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2026
KU I70 - 10	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2027
KU I70 - 11	General Electric	I70S	10,000	75	0	0	75	PASS TESTING COMPLETE	2028
KU I70 - 12	General Electric	I70S	2,867	50	0	0	50	PASS TESTING COMPLETE	2029
KU J4S - 1	Sangamo	J4S	10,000	75	0	0	75	PASS TESTING COMPLETE	2030
KU J4S - 2	Sangamo	J4S	1,495	50	0	0	50	PASS TESTING COMPLETE	2031
KU J5S - 1	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2032
KU J5S - 2	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2033
KU J5S - 3	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2034
KU J5S - 4	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2035
KU J5S - 5	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2036
KU J5S - 6	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2037
KU J5S - 7	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2038
KU J5S - 8	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2039
KU J5S - 9	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2040
KU J5S - 10	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2041
KU J5S - 11	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2042
KU J5S - 12	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2043
KU J5S - 13	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2044
KU J5S - 14	Sangamo	J5S	10,000	75	0	0	75	PASS TESTING COMPLETE	2045
KU J5S - 15	Sangamo	J5S	4,249	75	0	0	75	PASS TESTING COMPLETE	2046
KU MQ - 1	Duncan	MQS	3,581	75	0	0	75	PASS TESTING COMPLETE	2047
KU MS - 1	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	2048
KU MS - 2	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	2049
KU MS - 3	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	2050
KU MS - 4	Duncan	MS	10,000	75	0	0	75	PASS TESTING COMPLETE	2051
KU MS - 5	Landis + Gyr	MS	1,641	50	0	0	50	PASS TESTING COMPLETE	2052

KU	MSII - 1	Landis + Gyr	MSII	4,765	75	0	0	75	PASS	TESTING COMPLETE	2053
KU	MX - 1	Landis + Gyr	MX	10,000	75	0	0	75	PASS	TESTING COMPLETE	2054
KU	MX - 2	Landis + Gyr	MX	10,000	75	0	0	75	PASS	TESTING COMPLETE	2055
KU	MX - 3	Landis + Gyr	MX	10,000	75	0	0	75	PASS	TESTING COMPLETE	2056
KU	MX - 4	Landis + Gyr	MX	10,000	75	0	0	75	PASS	TESTING COMPLETE	2057
KU	MX - 5	Landis + Gyr	MX	540	35	0	0	35	PASS	TESTING COMPLETE	2058

TOTALS	488,697	4190	0	0	4190
--------	---------	------	---	---	------

TOTAL LOTS PASSED: 62

TOTAL LOTS FAILED: 0

METERS CANNOT TEST: 0

Report completed successfully with results.