



a PPL company

Gwen R. Pinson, Executive Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
Frankfort, Kentucky 40601

February 28, 2019

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

**Annual Report – Louisville Gas and Electric Company**

Dear Ms. Pinson:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), Louisville Gas and Electric Company submits the following:

The Certified Test Results of all new meters received - (Attachment A)

2018 Statistical Sampling Test Results and Summary – (Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

Rick E. Lovekamp

RECEIVED

FEB 28 2019

PUBLIC SERVICE  
COMMISSION

**Louisville Gas and Electric Company**  
State Regulation and Rates  
220 W. Main Street  
PO Box 32010  
Louisville, KY 40232  
[www.lge-ku.com](http://www.lge-ku.com)

Rick E. Lovekamp  
Manager Regulatory  
Strategy/Policy  
T 502-627-3780  
[rick.lovekamp@lge-ku.com](mailto:rick.lovekamp@lge-ku.com)

RECEIVED

FEB 28 2019

PUBLIC SERVICE  
COMMISSION

# ATTACHMENT

## A

The Certified Test Results  
of all new meters



# LG&E and KU Energy LLC

## 5040 Annual Report of New Single Phase Meters

Last Data Update:

12/21/2018 01:26:00

### Dynamic Filters

Plant LG&E

Calendar Month/Year 01/2018 - 6/2018

Plant	Manf. Model Number	Serial Number	Calendar Month/Year	Test Date	As Left Full Load	As Left Light Load	As Left Power Factor	Number of records
LG&E	C1S	926984	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	926985	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	926986	04/2018	04/05/2018	100.000	100.080	100.1	1
LG&E	C1S	926987	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	926988	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	926989	04/2018	04/05/2018	100.030	100.080	100.0	1
LG&E	C1S	926990	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	926991	04/2018	04/05/2018	99.960	100.010	100.0	1
LG&E	C1S	926992	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	926993	04/2018	04/05/2018	99.990	100.050	100.1	1
LG&E	C1S	926994	04/2018	04/05/2018	100.030	100.090	100.1	1
LG&E	C1S	926995	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	926996	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	926997	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	926998	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	926999	04/2018	04/05/2018	100.030	100.070	100.0	1
LG&E	C1S	927000	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	927001	04/2018	04/05/2018	100.010	100.040	100.1	1
LG&E	C1S	927002	04/2018	04/05/2018	100.010	100.060	100.0	1
LG&E	C1S	927003	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927004	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927005	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927006	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927007	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927008	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927009	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927010	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927011	04/2018	04/05/2018	99.970	100.040	100.0	1
LG&E	C1S	927012	04/2018	04/05/2018	99.990	99.990	100.0	1

LG&E	C1S	927013	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927014	04/2018	04/05/2018	99.980	100.060	100.0	1
LG&E	C1S	927015	04/2018	04/05/2018	100.010	100.080	100.0	1
LG&E	C1S	927016	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927017	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927018	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927019	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	927020	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927021	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927022	04/2018	04/05/2018	99.960	100.020	100.0	1
LG&E	C1S	927023	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927024	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927025	04/2018	04/05/2018	99.990	100.060	100.0	1
LG&E	C1S	927026	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927027	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927028	04/2018	04/05/2018	100.000	100.070	100.1	1
LG&E	C1S	927029	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927030	04/2018	04/05/2018	99.980	100.090	100.0	1
LG&E	C1S	927031	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927032	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927033	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927034	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927035	04/2018	04/05/2018	99.980	100.060	100.0	1
LG&E	C1S	927036	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927037	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927038	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927039	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927040	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927041	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927042	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927043	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927044	04/2018	04/05/2018	99.960	100.030	100.0	1
LG&E	C1S	927045	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927046	04/2018	04/05/2018	99.960	100.000	99.9	1
LG&E	C1S	927047	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927048	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927049	04/2018	04/05/2018	100.000	100.060	100.0	1
LG&E	C1S	927050	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927051	04/2018	04/05/2018	100.010	100.020	100.1	1
LG&E	C1S	927052	04/2018	04/05/2018	100.000	100.050	100.1	1
LG&E	C1S	927053	04/2018	04/05/2018	99.990	100.060	100.0	1
LG&E	C1S	927054	04/2018	04/05/2018	100.010	100.020	100.0	1

LG&E	C1S	927055	04/2018	04/05/2018	99.980	100.050	100.1	1
LG&E	C1S	927056	04/2018	04/05/2018	99.970	100.070	100.1	1
LG&E	C1S	927057	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927058	04/2018	04/05/2018	99.980	99.970	100.0	1
LG&E	C1S	927059	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927060	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927061	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927062	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927063	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927064	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927065	04/2018	04/05/2018	100.050	100.040	100.0	1
LG&E	C1S	927066	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927067	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927068	04/2018	04/05/2018	100.010	99.960	100.0	1
LG&E	C1S	927069	04/2018	04/05/2018	99.990	99.910	100.0	1
LG&E	C1S	927070	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927071	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927072	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927073	04/2018	04/05/2018	100.010	99.960	99.9	1
LG&E	C1S	927074	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927075	04/2018	04/05/2018	100.040	99.960	100.0	1
LG&E	C1S	927076	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927077	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927078	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927079	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927080	04/2018	04/05/2018	100.010	100.070	100.1	1
LG&E	C1S	927081	04/2018	04/05/2018	99.970	100.010	100.0	1
LG&E	C1S	927082	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927083	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927084	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927085	04/2018	04/05/2018	100.020	100.110	100.1	1
LG&E	C1S	927086	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927087	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927088	04/2018	04/05/2018	99.990	100.020	99.9	1
LG&E	C1S	927089	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927090	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	927091	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927092	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927093	04/2018	04/05/2018	99.960	100.030	100.0	1
LG&E	C1S	927094	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927095	04/2018	04/05/2018	99.980	100.070	100.1	1
LG&E	C1S	927096	04/2018	04/05/2018	99.990	100.020	100.0	1



LG&E	C1S	927097	04/2018	04/05/2018	100.040	100.040	100.0	1
LG&E	C1S	927098	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927099	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927100	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927101	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927102	04/2018	04/05/2018	100.010	100.080	100.1	1
LG&E	C1S	927103	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927104	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927105	04/2018	04/05/2018	99.990	100.090	100.1	1
LG&E	C1S	927106	04/2018	04/05/2018	100.040	100.070	100.0	1
LG&E	C1S	927107	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927108	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927109	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927110	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927111	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927112	04/2018	04/05/2018	99.950	100.020	100.0	1
LG&E	C1S	927113	04/2018	04/05/2018	100.010	100.080	100.0	1
LG&E	C1S	927114	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927115	04/2018	04/05/2018	100.000	100.080	100.1	1
LG&E	C1S	927116	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927117	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927118	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927119	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927120	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927121	04/2018	04/05/2018	100.010	100.040	100.1	1
LG&E	C1S	927122	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927123	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927124	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927125	04/2018	04/05/2018	100.010	100.040	100.1	1
LG&E	C1S	927126	04/2018	04/05/2018	99.960	100.080	100.0	1
LG&E	C1S	927127	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	927128	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927129	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927130	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927131	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927132	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927133	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927134	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927135	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927136	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927137	04/2018	04/05/2018	100.010	100.040	100.1	1
LG&E	C1S	927138	04/2018	04/05/2018	99.980	100.060	100.1	1

LG&E	C1S	927139	04/2018	04/05/2018	100.000	100.070	100.0	1
LG&E	C1S	927140	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927141	04/2018	04/05/2018	99.990	100.070	100.1	1
LG&E	C1S	927142	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927143	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927144	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927145	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927146	04/2018	04/05/2018	99.970	100.040	100.0	1
LG&E	C1S	927147	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927148	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927149	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927150	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927151	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927152	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927153	04/2018	04/05/2018	99.960	100.030	100.1	1
LG&E	C1S	927154	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927155	04/2018	04/05/2018	100.060	100.050	100.0	1
LG&E	C1S	927156	04/2018	04/05/2018	100.000	100.040	100.1	1
LG&E	C1S	927157	04/2018	04/05/2018	99.990	100.050	100.1	1
LG&E	C1S	927158	04/2018	04/05/2018	100.010	100.070	100.0	1
LG&E	C1S	927159	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927160	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927161	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927162	04/2018	04/05/2018	99.990	100.040	100.1	1
LG&E	C1S	927163	04/2018	04/05/2018	99.980	100.080	100.1	1
LG&E	C1S	927164	04/2018	04/05/2018	100.020	100.080	100.1	1
LG&E	C1S	927165	04/2018	04/05/2018	100.030	99.960	100.0	1
LG&E	C1S	927166	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927167	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927168	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927169	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927170	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927171	04/2018	04/05/2018	99.990	100.070	100.1	1
LG&E	C1S	927172	04/2018	04/05/2018	100.000	100.070	100.1	1
LG&E	C1S	927173	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927174	04/2018	04/05/2018	100.030	100.000	100.1	1
LG&E	C1S	927175	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927176	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927177	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927178	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927179	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927180	04/2018	04/05/2018	99.980	100.010	100.1	1

LG&E	C1S	927181	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927182	04/2018	04/05/2018	99.970	100.050	100.0	1
LG&E	C1S	927183	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927184	04/2018	04/05/2018	100.020	100.060	100.1	1
LG&E	C1S	927185	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927186	04/2018	04/05/2018	99.940	99.970	100.0	1
LG&E	C1S	927187	04/2018	04/05/2018	99.990	100.070	100.0	1
LG&E	C1S	927188	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927189	04/2018	04/05/2018	99.990	100.040	100.1	1
LG&E	C1S	927190	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927191	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927192	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927193	04/2018	04/05/2018	100.000	100.060	100.1	1
LG&E	C1S	927194	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927195	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	927196	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927197	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	927198	04/2018	04/05/2018	100.000	100.060	100.0	1
LG&E	C1S	927199	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927200	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927201	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927202	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927203	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927204	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927205	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927206	04/2018	04/05/2018	100.030	100.080	100.0	1
LG&E	C1S	927207	04/2018	04/05/2018	99.970	100.010	100.0	1
LG&E	C1S	927208	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927209	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927210	04/2018	04/05/2018	99.960	100.020	100.0	1
LG&E	C1S	927211	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927212	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927213	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927214	04/2018	04/05/2018	99.980	100.000	100.1	1
LG&E	C1S	927215	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927216	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927217	04/2018	04/05/2018	99.970	99.970	100.0	1
LG&E	C1S	927218	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927219	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927220	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927221	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927222	04/2018	04/05/2018	100.010	100.040	100.0	1



LG&E	C1S	927223	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927224	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927225	04/2018	04/05/2018	99.980	99.990	99.9	1
LG&E	C1S	927226	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927227	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927228	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927229	04/2018	04/05/2018	99.990	100.070	100.1	1
LG&E	C1S	927230	04/2018	04/05/2018	100.000	100.080	100.0	1
LG&E	C1S	927231	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927232	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927233	04/2018	04/05/2018	99.980	99.960	99.9	1
LG&E	C1S	927234	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927235	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927236	04/2018	04/05/2018	100.020	99.990	99.9	1
LG&E	C1S	927237	04/2018	04/05/2018	99.950	100.070	100.0	1
LG&E	C1S	927238	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927239	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927240	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927241	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927242	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927243	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927244	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927245	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927246	04/2018	04/05/2018	99.960	99.970	100.0	1
LG&E	C1S	927247	04/2018	04/05/2018	99.970	100.070	100.0	1
LG&E	C1S	927248	04/2018	04/05/2018	100.000	99.970	100.0	1
LG&E	C1S	927249	04/2018	04/05/2018	100.000	100.020	100.1	1
LG&E	C1S	927250	04/2018	04/05/2018	99.960	100.050	100.0	1
LG&E	C1S	927251	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927252	04/2018	04/05/2018	99.980	100.100	100.1	1
LG&E	C1S	927253	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927254	04/2018	04/05/2018	100.030	100.000	100.0	1
LG&E	C1S	927255	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927256	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927257	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927258	04/2018	04/05/2018	99.980	100.050	100.1	1
LG&E	C1S	927259	04/2018	04/05/2018	100.040	100.030	100.0	1
LG&E	C1S	927260	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927261	04/2018	04/05/2018	100.020	100.030	99.9	1
LG&E	C1S	927262	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927263	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927264	04/2018	04/05/2018	100.010	100.050	100.1	1

LG&E	C1S	927265	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927266	04/2018	04/05/2018	100.020	100.060	100.1	1
LG&E	C1S	927267	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927268	04/2018	04/05/2018	100.010	99.980	99.9	1
LG&E	C1S	927269	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927270	04/2018	04/05/2018	100.020	100.030	100.1	1
LG&E	C1S	927271	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927272	04/2018	04/05/2018	99.990	100.020	100.1	1
LG&E	C1S	927273	04/2018	04/05/2018	100.040	99.960	99.9	1
LG&E	C1S	927274	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927275	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927276	04/2018	04/05/2018	100.030	99.970	100.1	1
LG&E	C1S	927277	04/2018	04/05/2018	100.030	99.960	100.0	1
LG&E	C1S	927278	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927279	04/2018	04/05/2018	99.990	100.030	100.1	1
LG&E	C1S	927280	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927281	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927282	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927283	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927284	04/2018	04/05/2018	100.000	99.950	99.9	1
LG&E	C1S	927285	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927286	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927287	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927288	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927289	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927290	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927291	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927292	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927293	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927294	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927295	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927296	04/2018	04/05/2018	99.980	99.970	100.0	1
LG&E	C1S	927297	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927298	04/2018	04/05/2018	99.990	100.030	100.1	1
LG&E	C1S	927299	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927300	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927301	04/2018	04/05/2018	99.960	99.990	100.0	1
LG&E	C1S	927302	04/2018	04/05/2018	100.030	100.000	100.1	1
LG&E	C1S	927303	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927304	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927305	04/2018	04/05/2018	100.000	100.070	100.0	1
LG&E	C1S	927306	04/2018	04/05/2018	99.990	100.020	100.0	1



LG&E	C1S	927307	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927308	04/2018	04/05/2018	99.990	99.970	100.0	1
LG&E	C1S	927309	04/2018	04/05/2018	99.980	100.020	100.1	1
LG&E	C1S	927310	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927311	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927312	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927313	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927314	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927315	04/2018	04/05/2018	100.010	99.990	99.9	1
LG&E	C1S	927316	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927317	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927318	04/2018	04/05/2018	99.970	99.990	100.0	1
LG&E	C1S	927319	04/2018	04/05/2018	99.970	99.960	100.0	1
LG&E	C1S	927320	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927321	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927322	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927323	04/2018	04/05/2018	100.010	100.080	100.1	1
LG&E	C1S	927324	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927325	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927326	04/2018	04/05/2018	99.970	99.990	100.0	1
LG&E	C1S	927327	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927328	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927329	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927330	04/2018	04/05/2018	100.010	100.000	100.1	1
LG&E	C1S	927331	04/2018	04/05/2018	100.040	100.000	100.0	1
LG&E	C1S	927332	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927333	04/2018	04/05/2018	100.030	100.010	100.0	1
LG&E	C1S	927334	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927335	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927336	04/2018	04/05/2018	100.040	100.040	100.0	1
LG&E	C1S	927337	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927338	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927339	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927340	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927341	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927342	04/2018	04/05/2018	99.980	99.960	99.9	1
LG&E	C1S	927343	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927344	04/2018	04/05/2018	100.000	100.070	100.1	1
LG&E	C1S	927345	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927346	04/2018	04/05/2018	99.980	99.980	100.0	1
LG&E	C1S	927347	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927348	04/2018	04/05/2018	99.970	100.030	100.0	1

LG&E	C1S	927349	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927350	04/2018	04/05/2018	100.010	100.010	100.1	1
LG&E	C1S	927351	04/2018	04/05/2018	99.990	99.970	100.0	1
LG&E	C1S	927352	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927353	04/2018	04/05/2018	99.990	100.080	100.1	1
LG&E	C1S	927354	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927355	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927356	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927357	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927358	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927359	04/2018	04/05/2018	100.030	100.020	100.1	1
LG&E	C1S	927360	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927361	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927362	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927363	04/2018	04/05/2018	99.990	100.040	100.1	1
LG&E	C1S	927364	04/2018	04/05/2018	99.990	100.060	100.0	1
LG&E	C1S	927365	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927366	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927367	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927368	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927369	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	927370	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927371	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927372	04/2018	04/05/2018	99.980	99.960	99.9	1
LG&E	C1S	927373	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927374	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927375	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927376	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927377	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927378	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927379	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927380	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927381	04/2018	04/05/2018	99.990	100.010	99.9	1
LG&E	C1S	927382	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927383	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927384	04/2018	04/05/2018	99.970	100.070	100.1	1
LG&E	C1S	927385	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927386	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927387	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927388	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927389	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927390	04/2018	04/05/2018	100.010	100.020	100.0	1



LG&E	C1S	927391	04/2018	04/05/2018	99.950	100.010	100.0	1
LG&E	C1S	927392	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927393	04/2018	04/05/2018	100.010	100.010	99.9	1
LG&E	C1S	927394	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927395	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927396	04/2018	04/05/2018	100.020	99.970	100.0	1
LG&E	C1S	927397	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927398	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927399	04/2018	04/05/2018	99.970	100.010	100.0	1
LG&E	C1S	927400	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927401	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927402	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927403	04/2018	04/05/2018	100.030	100.010	99.9	1
LG&E	C1S	927404	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927405	04/2018	04/05/2018	100.000	100.030	100.1	1
LG&E	C1S	927406	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927407	04/2018	04/05/2018	99.980	99.960	100.0	1
LG&E	C1S	927408	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927409	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927410	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927411	04/2018	04/05/2018	99.940	100.040	100.1	1
LG&E	C1S	927412	04/2018	04/05/2018	100.040	99.960	100.0	1
LG&E	C1S	927413	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927414	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927415	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927416	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927417	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927418	04/2018	04/05/2018	99.970	100.010	100.0	1
LG&E	C1S	927419	04/2018	04/05/2018	100.010	100.070	100.0	1
LG&E	C1S	927420	04/2018	04/05/2018	99.960	100.060	100.0	1
LG&E	C1S	927421	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927422	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927423	04/2018	04/05/2018	100.040	100.040	100.0	1
LG&E	C1S	927424	04/2018	04/05/2018	99.990	100.070	100.0	1
LG&E	C1S	927425	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927426	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927427	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927428	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927429	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927430	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927431	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927432	04/2018	04/05/2018	100.010	100.040	100.0	1

LG&E	C1S	927433	04/2018	04/05/2018	100.010	99.960	99.9	1
LG&E	C1S	927434	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	927435	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927436	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927437	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927438	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927439	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927440	04/2018	04/05/2018	100.030	100.010	100.0	1
LG&E	C1S	927441	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927442	04/2018	04/05/2018	99.960	100.010	100.0	1
LG&E	C1S	927443	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927444	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927445	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927446	04/2018	04/05/2018	99.980	100.080	100.1	1
LG&E	C1S	927447	04/2018	04/05/2018	100.030	100.030	100.1	1
LG&E	C1S	927448	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927449	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927450	04/2018	04/05/2018	99.990	100.070	100.1	1
LG&E	C1S	927451	04/2018	04/05/2018	100.040	100.000	100.0	1
LG&E	C1S	927452	04/2018	04/05/2018	99.990	100.070	100.1	1
LG&E	C1S	927453	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927454	04/2018	04/05/2018	100.000	99.940	100.0	1
LG&E	C1S	927455	04/2018	04/05/2018	99.980	100.050	100.1	1
LG&E	C1S	927456	04/2018	04/05/2018	100.010	99.950	99.9	1
LG&E	C1S	927457	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927458	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927459	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927460	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927461	04/2018	04/05/2018	100.020	100.070	100.0	1
LG&E	C1S	927462	04/2018	04/05/2018	100.000	100.010	99.9	1
LG&E	C1S	927463	04/2018	04/05/2018	99.980	100.040	100.1	1
LG&E	C1S	927464	04/2018	04/05/2018	100.010	100.070	100.1	1
LG&E	C1S	927465	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927466	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927467	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927468	04/2018	04/05/2018	99.950	100.050	100.0	1
LG&E	C1S	927469	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927470	04/2018	04/05/2018	99.980	100.030	100.1	1
LG&E	C1S	927471	04/2018	04/05/2018	100.010	99.980	99.9	1
LG&E	C1S	927472	04/2018	04/05/2018	99.990	99.970	99.9	1
LG&E	C1S	927473	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927474	04/2018	04/05/2018	100.000	100.030	100.1	1



LG&E	C1S	927475	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927476	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927477	04/2018	04/05/2018	99.980	100.020	100.1	1
LG&E	C1S	927478	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927479	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927480	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927481	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927482	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927483	04/2018	04/05/2018	100.050	100.010	100.0	1
LG&E	C1S	927484	04/2018	04/05/2018	100.000	100.050	100.1	1
LG&E	C1S	927485	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927486	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927487	04/2018	04/05/2018	99.960	100.010	100.0	1
LG&E	C1S	927488	04/2018	04/05/2018	100.020	99.990	99.9	1
LG&E	C1S	927489	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927490	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927491	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927492	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927493	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927494	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927495	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927496	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927497	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927498	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927499	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927500	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927501	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927502	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927503	04/2018	04/05/2018	100.030	100.000	100.0	1
LG&E	C1S	927504	04/2018	04/05/2018	100.030	100.000	100.0	1
LG&E	C1S	927505	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927506	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927507	04/2018	04/05/2018	99.990	99.970	99.9	1
LG&E	C1S	927508	04/2018	04/05/2018	100.000	100.060	100.1	1
LG&E	C1S	927509	04/2018	04/05/2018	99.970	100.000	100.0	1
LG&E	C1S	927510	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927511	04/2018	04/05/2018	99.950	100.030	100.0	1
LG&E	C1S	927512	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927513	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927514	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927515	04/2018	04/05/2018	100.010	99.950	99.9	1
LG&E	C1S	927516	04/2018	04/05/2018	100.000	99.960	99.9	1

LG&E	C1S	927517	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927518	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927519	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927520	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927521	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927522	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927523	04/2018	04/05/2018	99.960	100.020	100.0	1
LG&E	C1S	927524	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927525	04/2018	04/05/2018	100.000	99.970	100.0	1
LG&E	C1S	927526	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927527	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927528	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927529	04/2018	04/05/2018	100.030	99.970	100.0	1
LG&E	C1S	927530	04/2018	04/05/2018	99.980	100.040	100.1	1
LG&E	C1S	927531	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927532	04/2018	04/05/2018	99.980	100.060	100.1	1
LG&E	C1S	927533	04/2018	04/05/2018	99.970	99.970	100.0	1
LG&E	C1S	927534	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927535	04/2018	04/05/2018	100.030	99.970	100.0	1
LG&E	C1S	927536	04/2018	04/05/2018	99.990	99.980	99.9	1
LG&E	C1S	927537	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927538	04/2018	04/05/2018	99.980	100.050	100.0	1
LG&E	C1S	927539	04/2018	04/05/2018	100.000	100.040	100.1	1
LG&E	C1S	927540	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927541	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927542	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927543	04/2018	04/05/2018	100.010	100.040	100.1	1
LG&E	C1S	927544	04/2018	04/05/2018	100.000	99.970	99.9	1
LG&E	C1S	927545	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927546	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927547	04/2018	04/05/2018	99.980	100.070	100.0	1
LG&E	C1S	927548	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927549	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927550	04/2018	04/05/2018	99.980	100.020	100.0	1
LG&E	C1S	927551	04/2018	04/05/2018	100.020	99.990	99.9	1
LG&E	C1S	927552	04/2018	04/05/2018	100.060	100.020	100.0	1
LG&E	C1S	927553	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927554	04/2018	04/05/2018	100.030	100.050	100.0	1
LG&E	C1S	927555	04/2018	04/05/2018	100.050	100.040	100.0	1
LG&E	C1S	927556	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927557	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927558	04/2018	04/05/2018	100.020	100.040	100.0	1

LG&E	C1S	927559	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927560	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927561	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927562	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927563	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927564	04/2018	04/05/2018	100.020	100.020	100.1	1
LG&E	C1S	927565	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927566	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927567	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927568	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927569	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927570	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927571	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927572	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927573	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927574	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927575	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927576	04/2018	04/05/2018	100.010	100.030	100.1	1
LG&E	C1S	927577	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927578	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927579	04/2018	04/05/2018	100.020	99.990	99.9	1
LG&E	C1S	927580	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927581	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927582	04/2018	04/05/2018	100.030	100.100	100.1	1
LG&E	C1S	927583	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927584	04/2018	04/05/2018	100.020	99.970	100.0	1
LG&E	C1S	927585	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927586	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927587	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927588	04/2018	04/05/2018	99.980	99.980	100.0	1
LG&E	C1S	927589	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927590	04/2018	04/05/2018	100.050	100.040	100.0	1
LG&E	C1S	927591	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927592	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927593	04/2018	04/05/2018	99.960	100.030	100.0	1
LG&E	C1S	927594	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927595	04/2018	04/05/2018	99.970	100.030	100.1	1
LG&E	C1S	927596	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927597	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927598	04/2018	04/05/2018	100.020	100.030	100.1	1
LG&E	C1S	927599	04/2018	04/05/2018	100.050	99.990	100.0	1
LG&E	C1S	927600	04/2018	04/05/2018	100.010	100.030	100.0	1



LG&E	C1S	927601	04/2018	04/05/2018	100.030	100.010	100.0	1
LG&E	C1S	927602	04/2018	04/05/2018	100.030	100.040	100.0	1
LG&E	C1S	927603	04/2018	04/05/2018	99.980	100.070	100.0	1
LG&E	C1S	927604	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927605	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927606	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927607	04/2018	04/05/2018	99.980	100.080	100.0	1
LG&E	C1S	927608	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927609	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927610	04/2018	04/05/2018	99.970	99.970	99.9	1
LG&E	C1S	927611	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927612	04/2018	04/05/2018	100.040	100.010	100.0	1
LG&E	C1S	927613	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927614	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927615	04/2018	04/05/2018	100.010	100.060	100.1	1
LG&E	C1S	927616	04/2018	04/05/2018	100.020	100.070	100.1	1
LG&E	C1S	927617	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927618	04/2018	04/05/2018	100.000	100.080	100.0	1
LG&E	C1S	927619	04/2018	04/05/2018	100.030	99.970	100.0	1
LG&E	C1S	927620	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927621	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927622	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927623	04/2018	04/05/2018	99.990	100.030	100.1	1
LG&E	C1S	927624	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927625	04/2018	04/05/2018	99.990	99.980	100.0	1
LG&E	C1S	927626	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927627	04/2018	04/05/2018	99.970	99.930	99.9	1
LG&E	C1S	927628	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927629	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927630	04/2018	04/05/2018	99.960	99.990	100.0	1
LG&E	C1S	927631	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927632	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927633	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927634	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927635	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927636	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927637	04/2018	04/05/2018	100.020	100.060	100.0	1
LG&E	C1S	927638	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927639	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927640	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927641	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927642	04/2018	04/05/2018	100.020	100.020	100.0	1

LG&E	C1S	927643	04/2018	04/05/2018	100.030	100.060	100.1	1
LG&E	C1S	927644	04/2018	04/05/2018	99.970	100.040	100.0	1
LG&E	C1S	927645	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927646	04/2018	04/05/2018	99.970	100.000	100.0	1
LG&E	C1S	927647	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927648	04/2018	04/05/2018	99.990	100.070	100.0	1
LG&E	C1S	927649	04/2018	04/05/2018	100.030	99.980	99.9	1
LG&E	C1S	927650	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927651	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927652	04/2018	04/05/2018	100.000	100.060	100.1	1
LG&E	C1S	927653	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927654	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927655	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927656	04/2018	04/05/2018	99.960	99.990	100.0	1
LG&E	C1S	927657	04/2018	04/05/2018	99.990	100.060	100.0	1
LG&E	C1S	927658	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927659	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927660	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927661	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927662	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927663	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927664	04/2018	04/05/2018	99.950	100.040	100.0	1
LG&E	C1S	927665	04/2018	04/05/2018	100.030	100.070	100.1	1
LG&E	C1S	927666	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927667	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927668	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927669	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927670	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927671	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927672	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927673	04/2018	04/05/2018	99.970	100.030	100.1	1
LG&E	C1S	927674	04/2018	04/05/2018	100.010	100.020	99.9	1
LG&E	C1S	927675	04/2018	04/05/2018	100.030	99.980	100.0	1
LG&E	C1S	927676	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927677	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927678	04/2018	04/05/2018	100.000	99.970	99.9	1
LG&E	C1S	927679	04/2018	04/05/2018	100.020	100.040	100.0	1
LG&E	C1S	927680	04/2018	04/05/2018	99.990	100.040	100.1	1
LG&E	C1S	927681	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927682	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927683	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927684	04/2018	04/05/2018	100.010	100.030	100.0	1

LG&E	C1S	927685	04/2018	04/05/2018	99.960	99.990	100.0	1
LG&E	C1S	927686	04/2018	04/05/2018	100.030	99.980	99.9	1
LG&E	C1S	927687	04/2018	04/05/2018	99.980	99.980	100.0	1
LG&E	C1S	927688	04/2018	04/05/2018	99.980	100.000	100.0	1
LG&E	C1S	927689	04/2018	04/05/2018	100.000	100.040	100.1	1
LG&E	C1S	927690	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927691	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927692	04/2018	04/05/2018	99.970	99.990	100.0	1
LG&E	C1S	927693	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927694	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927695	04/2018	04/05/2018	99.970	100.030	100.0	1
LG&E	C1S	927696	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927697	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927698	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927699	04/2018	04/05/2018	100.020	100.050	100.0	1
LG&E	C1S	927700	04/2018	04/05/2018	100.000	100.080	100.0	1
LG&E	C1S	927701	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927702	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927703	04/2018	04/05/2018	100.040	100.000	100.0	1
LG&E	C1S	927704	04/2018	04/05/2018	100.030	100.000	100.0	1
LG&E	C1S	927705	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927706	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927707	04/2018	04/05/2018	100.010	100.070	100.1	1
LG&E	C1S	927708	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927709	04/2018	04/05/2018	100.010	99.960	100.0	1
LG&E	C1S	927710	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927711	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927712	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927713	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927714	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927715	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927716	04/2018	04/05/2018	99.960	100.010	100.0	1
LG&E	C1S	927717	04/2018	04/05/2018	100.020	100.010	100.1	1
LG&E	C1S	927718	04/2018	04/05/2018	100.020	99.960	99.9	1
LG&E	C1S	927719	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927720	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927721	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927722	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927723	04/2018	04/05/2018	100.050	99.980	100.0	1
LG&E	C1S	927724	04/2018	04/05/2018	100.050	100.020	100.0	1
LG&E	C1S	927725	04/2018	04/05/2018	99.970	100.010	100.1	1
LG&E	C1S	927726	04/2018	04/05/2018	99.990	100.020	100.0	1



LG&E	C1S	927727	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927728	04/2018	04/05/2018	100.010	100.020	100.1	1
LG&E	C1S	927729	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927730	04/2018	04/05/2018	100.010	99.940	100.0	1
LG&E	C1S	927731	04/2018	04/05/2018	100.040	100.000	100.0	1
LG&E	C1S	927732	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927733	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927734	04/2018	04/05/2018	99.950	100.030	100.0	1
LG&E	C1S	927735	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927736	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927737	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927738	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927739	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927740	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927741	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927742	04/2018	04/05/2018	99.990	100.000	99.9	1
LG&E	C1S	927743	04/2018	04/05/2018	99.980	100.060	100.1	1
LG&E	C1S	927744	04/2018	04/05/2018	99.940	100.060	100.1	1
LG&E	C1S	927745	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927746	04/2018	04/05/2018	100.030	100.010	100.0	1
LG&E	C1S	927747	04/2018	04/05/2018	99.970	100.070	100.0	1
LG&E	C1S	927748	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927749	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927750	04/2018	04/05/2018	99.970	100.050	100.0	1
LG&E	C1S	927751	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927752	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927753	04/2018	04/05/2018	99.960	99.970	100.0	1
LG&E	C1S	927754	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927755	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927756	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927757	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927758	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927759	04/2018	04/05/2018	100.040	100.020	100.0	1
LG&E	C1S	927760	04/2018	04/05/2018	99.970	100.020	100.0	1
LG&E	C1S	927761	04/2018	04/05/2018	100.020	99.980	100.0	1
LG&E	C1S	927762	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927763	04/2018	04/05/2018	100.000	100.030	100.1	1
LG&E	C1S	927764	04/2018	04/05/2018	100.030	99.980	100.0	1
LG&E	C1S	927765	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927766	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927767	04/2018	04/05/2018	100.050	100.000	100.0	1
LG&E	C1S	927768	04/2018	04/05/2018	99.970	100.000	100.0	1

LG&E	C1S	927769	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927770	04/2018	04/05/2018	100.030	100.000	100.0	1
LG&E	C1S	927771	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927772	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927773	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927774	04/2018	04/05/2018	99.990	100.060	100.0	1
LG&E	C1S	927775	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927776	04/2018	04/05/2018	100.040	99.960	99.9	1
LG&E	C1S	927777	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927778	04/2018	04/05/2018	100.040	100.000	100.0	1
LG&E	C1S	927779	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927780	04/2018	04/05/2018	100.000	99.950	100.0	1
LG&E	C1S	927781	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927782	04/2018	04/05/2018	100.010	100.010	100.1	1
LG&E	C1S	927783	04/2018	04/05/2018	100.010	100.050	100.1	1
LG&E	C1S	927784	04/2018	04/05/2018	99.990	99.950	100.0	1
LG&E	C1S	927785	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927786	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927787	04/2018	04/05/2018	99.980	99.950	100.0	1
LG&E	C1S	927788	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927789	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927790	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927791	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927792	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927793	04/2018	04/05/2018	99.990	99.970	100.0	1
LG&E	C1S	927794	04/2018	04/05/2018	99.980	99.950	100.0	1
LG&E	C1S	927795	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927796	04/2018	04/05/2018	100.000	100.010	100.0	1
LG&E	C1S	927797	04/2018	04/05/2018	99.970	100.000	100.0	1
LG&E	C1S	927798	04/2018	04/05/2018	100.010	100.020	100.1	1
LG&E	C1S	927799	04/2018	04/05/2018	99.950	100.040	100.1	1
LG&E	C1S	927800	04/2018	04/05/2018	100.000	100.010	99.9	1
LG&E	C1S	927801	04/2018	04/05/2018	99.970	100.020	100.1	1
LG&E	C1S	927802	04/2018	04/05/2018	99.970	99.980	100.0	1
LG&E	C1S	927803	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927804	04/2018	04/05/2018	99.990	100.040	100.0	1
LG&E	C1S	927805	04/2018	04/05/2018	100.050	100.000	100.0	1
LG&E	C1S	927806	04/2018	04/05/2018	100.000	99.970	100.0	1
LG&E	C1S	927807	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927808	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927809	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927810	04/2018	04/05/2018	100.010	100.060	100.0	1

LG&E	C1S	927811	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927812	04/2018	04/05/2018	99.980	100.010	100.0	1
LG&E	C1S	927813	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927814	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927815	04/2018	04/05/2018	99.980	99.990	100.1	1
LG&E	C1S	927816	04/2018	04/05/2018	99.990	100.010	100.1	1
LG&E	C1S	927817	04/2018	04/05/2018	100.020	100.030	100.0	1
LG&E	C1S	927818	04/2018	04/05/2018	99.980	99.970	100.0	1
LG&E	C1S	927819	04/2018	04/05/2018	100.000	99.950	100.0	1
LG&E	C1S	927820	04/2018	04/05/2018	100.030	99.960	100.0	1
LG&E	C1S	927821	04/2018	04/05/2018	99.970	100.000	99.9	1
LG&E	C1S	927822	04/2018	04/05/2018	100.050	100.020	100.0	1
LG&E	C1S	927823	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927824	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927825	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927826	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927827	04/2018	04/05/2018	100.010	99.970	99.9	1
LG&E	C1S	927828	04/2018	04/05/2018	100.020	100.050	100.1	1
LG&E	C1S	927829	04/2018	04/05/2018	100.030	99.990	100.1	1
LG&E	C1S	927830	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927831	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927832	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927833	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927834	04/2018	04/05/2018	100.000	100.060	100.0	1
LG&E	C1S	927835	04/2018	04/05/2018	99.950	100.030	100.0	1
LG&E	C1S	927836	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927837	04/2018	04/05/2018	99.980	100.070	100.1	1
LG&E	C1S	927838	04/2018	04/05/2018	99.970	100.040	100.0	1
LG&E	C1S	927839	04/2018	04/05/2018	100.040	99.990	100.0	1
LG&E	C1S	927840	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927841	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927842	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927843	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927844	04/2018	04/05/2018	99.990	99.980	99.9	1
LG&E	C1S	927845	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927846	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927847	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927848	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927849	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927850	04/2018	04/05/2018	100.030	99.990	100.0	1
LG&E	C1S	927851	04/2018	04/05/2018	99.990	100.050	100.0	1
LG&E	C1S	927852	04/2018	04/05/2018	100.020	100.010	100.0	1



LG&E	C1S	927853	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927854	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927855	04/2018	04/05/2018	100.020	100.080	100.1	1
LG&E	C1S	927856	04/2018	04/05/2018	99.960	100.030	100.0	1
LG&E	C1S	927857	04/2018	04/05/2018	100.020	99.990	100.0	1
LG&E	C1S	927858	04/2018	04/05/2018	100.000	100.020	100.0	1
LG&E	C1S	927859	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927860	04/2018	04/05/2018	99.960	100.050	100.0	1
LG&E	C1S	927861	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927862	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927863	04/2018	04/05/2018	100.030	99.970	99.9	1
LG&E	C1S	927864	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927865	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927866	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927867	04/2018	04/05/2018	99.990	100.030	100.1	1
LG&E	C1S	927868	04/2018	04/05/2018	99.950	99.990	100.0	1
LG&E	C1S	927869	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927870	04/2018	04/05/2018	100.030	99.940	100.0	1
LG&E	C1S	927871	04/2018	04/05/2018	100.000	99.960	99.9	1
LG&E	C1S	927872	04/2018	04/05/2018	99.990	100.010	100.0	1
LG&E	C1S	927873	04/2018	04/05/2018	100.030	100.030	100.0	1
LG&E	C1S	927874	04/2018	04/05/2018	100.010	100.070	100.1	1
LG&E	C1S	927875	04/2018	04/05/2018	99.980	100.040	100.0	1
LG&E	C1S	927876	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927877	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927878	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927879	04/2018	04/05/2018	100.040	100.040	100.0	1
LG&E	C1S	927880	04/2018	04/05/2018	99.960	99.990	99.9	1
LG&E	C1S	927881	04/2018	04/05/2018	100.010	100.010	100.0	1
LG&E	C1S	927882	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927883	04/2018	04/05/2018	99.990	100.040	100.1	1
LG&E	C1S	927884	04/2018	04/05/2018	100.000	100.050	100.0	1
LG&E	C1S	927885	04/2018	04/05/2018	100.020	100.020	100.0	1
LG&E	C1S	927886	04/2018	04/05/2018	100.050	99.990	100.0	1
LG&E	C1S	927887	04/2018	04/05/2018	99.980	100.030	100.0	1
LG&E	C1S	927888	04/2018	04/05/2018	100.040	99.990	100.0	1
LG&E	C1S	927889	04/2018	04/05/2018	99.960	100.010	100.0	1
LG&E	C1S	927890	04/2018	04/05/2018	100.010	100.070	100.0	1
LG&E	C1S	927891	04/2018	04/05/2018	100.030	99.970	100.0	1
LG&E	C1S	927892	04/2018	04/05/2018	100.000	100.000	100.1	1
LG&E	C1S	927893	04/2018	04/05/2018	100.010	99.990	100.0	1
LG&E	C1S	927894	04/2018	04/05/2018	100.000	99.950	100.0	1

LG&E	C1S	927895	04/2018	04/05/2018	99.980	99.920	99.9	1
LG&E	C1S	927896	04/2018	04/05/2018	99.990	100.050	100.1	1
LG&E	C1S	927897	04/2018	04/05/2018	100.000	100.000	100.0	1
LG&E	C1S	927898	04/2018	04/05/2018	99.980	99.990	100.0	1
LG&E	C1S	927899	04/2018	04/05/2018	100.020	99.970	99.9	1
LG&E	C1S	927900	04/2018	04/05/2018	99.960	100.020	100.0	1
LG&E	C1S	927901	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927902	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927903	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927904	04/2018	04/05/2018	99.990	100.030	100.0	1
LG&E	C1S	927905	04/2018	04/05/2018	100.020	100.020	100.1	1
LG&E	C1S	927906	04/2018	04/05/2018	100.000	99.990	100.0	1
LG&E	C1S	927907	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927908	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927909	04/2018	04/05/2018	99.980	99.980	100.0	1
LG&E	C1S	927910	04/2018	04/05/2018	99.990	100.000	100.0	1
LG&E	C1S	927911	04/2018	04/05/2018	100.000	99.960	99.9	1
LG&E	C1S	927912	04/2018	04/05/2018	100.030	99.930	99.9	1
LG&E	C1S	927913	04/2018	04/05/2018	99.990	100.060	100.1	1
LG&E	C1S	927914	04/2018	04/05/2018	100.050	100.030	100.0	1
LG&E	C1S	927915	04/2018	04/05/2018	99.980	99.980	100.0	1
LG&E	C1S	927916	04/2018	04/05/2018	100.000	100.030	100.0	1
LG&E	C1S	927917	04/2018	04/05/2018	100.010	100.030	100.0	1
LG&E	C1S	927918	04/2018	04/05/2018	100.010	100.020	100.0	1
LG&E	C1S	927919	04/2018	04/05/2018	100.010	99.970	100.0	1
LG&E	C1S	927920	04/2018	04/05/2018	100.020	100.010	100.0	1
LG&E	C1S	927921	04/2018	04/05/2018	99.980	99.920	99.9	1
LG&E	C1S	927922	04/2018	04/05/2018	100.020	100.000	100.0	1
LG&E	C1S	927923	04/2018	04/05/2018	100.030	100.020	100.0	1
LG&E	C1S	927924	04/2018	04/05/2018	100.010	99.980	100.0	1
LG&E	C1S	927925	04/2018	04/05/2018	100.040	99.930	100.0	1
LG&E	C1S	927926	04/2018	04/05/2018	100.010	100.000	100.0	1
LG&E	C1S	927927	04/2018	04/05/2018	100.010	100.050	100.0	1
LG&E	C1S	927928	04/2018	04/05/2018	99.990	99.970	99.9	1
LG&E	C1S	927929	04/2018	04/05/2018	100.020	99.970	100.0	1
LG&E	C1S	927930	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927931	04/2018	04/05/2018	100.000	100.030	100.1	1
LG&E	C1S	927932	04/2018	04/05/2018	99.990	100.050	100.1	1
LG&E	C1S	927933	04/2018	04/05/2018	99.990	99.990	100.0	1
LG&E	C1S	927934	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927935	04/2018	04/05/2018	99.980	100.020	100.1	1
LG&E	C1S	927936	04/2018	04/05/2018	100.010	100.050	100.0	1

LG&E	C1S	927937	04/2018	04/05/2018	99.980	99.990	99.9	1
LG&E	C1S	927938	04/2018	04/05/2018	100.010	100.040	100.0	1
LG&E	C1S	927939	04/2018	04/05/2018	100.000	99.980	100.0	1
LG&E	C1S	927940	04/2018	04/05/2018	99.990	100.020	100.0	1
LG&E	C1S	927941	04/2018	04/05/2018	99.970	99.970	100.0	1
LG&E	C1S	927942	04/2018	04/05/2018	100.000	100.040	100.0	1
LG&E	C1S	927943	04/2018	04/05/2018	100.020	99.960	100.0	1
LG&E	C1SR	925848	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	925849	04/2018	04/09/2018	100.000	99.940	100.0	1
LG&E	C1SR	925850	04/2018	04/09/2018	99.980	99.940	100.0	1
LG&E	C1SR	925851	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	925852	04/2018	04/09/2018	99.970	100.030	100.0	1
LG&E	C1SR	925853	04/2018	04/09/2018	99.970	100.020	100.0	1
LG&E	C1SR	925854	04/2018	04/09/2018	99.960	100.010	100.0	1
LG&E	C1SR	925855	04/2018	04/09/2018	100.020	100.040	100.0	1
LG&E	C1SR	925856	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	925857	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	925858	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	925859	04/2018	04/09/2018	100.010	99.980	100.0	1
LG&E	C1SR	925860	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	925861	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925862	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	925863	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	925864	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	925865	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	925866	04/2018	04/09/2018	99.990	99.980	99.9	1
LG&E	C1SR	925867	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	925868	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	925869	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	925870	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	925871	04/2018	04/09/2018	99.960	99.990	100.0	1
LG&E	C1SR	925872	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	925873	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	925874	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	925875	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	925876	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	925877	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925878	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	925879	04/2018	04/09/2018	100.010	100.080	100.1	1
LG&E	C1SR	925880	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925881	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	925882	04/2018	04/09/2018	100.020	99.950	99.9	1



LG&E	C1SR	925883	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	925884	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	925885	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	925886	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	925887	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	925888	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	925889	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	925890	04/2018	04/09/2018	99.970	100.000	100.1	1
LG&E	C1SR	925891	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	925892	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	925893	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	925894	04/2018	04/09/2018	99.990	100.060	100.1	1
LG&E	C1SR	925895	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	925896	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	925897	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	925898	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	925899	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	925900	04/2018	04/09/2018	100.010	100.000	100.1	1
LG&E	C1SR	925901	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	925902	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	925903	04/2018	04/09/2018	100.020	99.960	99.9	1
LG&E	C1SR	925904	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	925905	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	925906	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	925907	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	925908	04/2018	04/09/2018	100.000	100.020	100.1	1
LG&E	C1SR	925909	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	925910	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	925911	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	925912	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	925913	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	925914	04/2018	04/09/2018	99.970	100.030	100.0	1
LG&E	C1SR	925915	04/2018	04/09/2018	100.010	100.030	100.1	1
LG&E	C1SR	925916	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	925917	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	925918	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	925919	04/2018	04/09/2018	100.000	100.040	100.1	1
LG&E	C1SR	925920	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	925921	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	925922	04/2018	04/09/2018	100.030	100.030	100.1	1
LG&E	C1SR	925923	04/2018	04/09/2018	99.960	99.970	100.0	1
LG&E	C1SR	925924	04/2018	04/09/2018	100.020	100.030	100.1	1

LG&E	C1SR	925925	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	925926	04/2018	04/09/2018	100.010	99.950	100.0	1
LG&E	C1SR	925927	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	925928	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	925929	04/2018	04/09/2018	100.010	100.060	100.1	1
LG&E	C1SR	925930	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	925931	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	925932	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	925933	04/2018	04/09/2018	100.000	100.070	100.0	1
LG&E	C1SR	925934	04/2018	04/09/2018	99.990	100.060	100.0	1
LG&E	C1SR	925935	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	925936	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925937	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	925938	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	925939	04/2018	04/09/2018	100.030	100.040	100.0	1
LG&E	C1SR	925940	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	925941	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	925942	04/2018	04/09/2018	99.990	100.000	100.1	1
LG&E	C1SR	925943	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	925944	04/2018	04/09/2018	99.990	100.060	100.0	1
LG&E	C1SR	925945	04/2018	04/09/2018	100.020	100.040	100.0	1
LG&E	C1SR	925946	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	925947	04/2018	04/09/2018	99.990	100.060	100.1	1
LG&E	C1SR	925948	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	925949	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	925950	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	925951	04/2018	04/09/2018	100.000	100.020	99.9	1
LG&E	C1SR	925952	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	925953	04/2018	04/09/2018	100.020	100.060	100.1	1
LG&E	C1SR	925954	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	925955	04/2018	04/09/2018	100.010	99.960	100.0	1
LG&E	C1SR	925956	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	925957	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	925958	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	925959	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	925960	04/2018	04/09/2018	100.020	100.090	100.0	1
LG&E	C1SR	925961	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	925962	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925963	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	925964	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	925965	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	925966	04/2018	04/09/2018	100.020	99.990	100.0	1

LG&E	C1SR	925967	04/2018	04/09/2018	99.970	100.000	99.9	1
LG&E	C1SR	925968	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	925969	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	925970	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	925971	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925972	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	925973	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	925974	04/2018	04/09/2018	100.050	99.980	100.0	1
LG&E	C1SR	925975	04/2018	04/09/2018	100.020	99.960	100.0	1
LG&E	C1SR	925976	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	925977	04/2018	04/09/2018	99.990	99.950	100.0	1
LG&E	C1SR	925978	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	925979	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	925980	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	925981	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	925982	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	925983	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	925984	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	925985	04/2018	04/09/2018	100.000	100.060	100.0	1
LG&E	C1SR	925986	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	925987	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925988	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	925989	04/2018	04/09/2018	99.990	100.040	100.1	1
LG&E	C1SR	925990	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	925991	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	925992	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	925993	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	925994	04/2018	04/09/2018	100.000	100.060	100.0	1
LG&E	C1SR	925995	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	925996	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	925997	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	925998	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	925999	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926000	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926001	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926002	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926003	04/2018	04/09/2018	99.990	100.000	100.1	1
LG&E	C1SR	926004	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926005	04/2018	04/09/2018	99.960	99.990	100.0	1
LG&E	C1SR	926006	04/2018	04/09/2018	100.030	100.050	100.0	1
LG&E	C1SR	926007	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926008	04/2018	04/09/2018	100.030	100.030	100.0	1



LG&E	C1SR	926009	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926010	04/2018	04/09/2018	100.010	100.030	100.1	1
LG&E	C1SR	926011	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926012	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926013	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926014	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926015	04/2018	04/09/2018	100.020	99.980	100.0	1
LG&E	C1SR	926016	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926017	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926018	04/2018	04/09/2018	99.950	100.030	100.0	1
LG&E	C1SR	926019	04/2018	04/09/2018	100.030	100.030	100.0	1
LG&E	C1SR	926020	04/2018	04/09/2018	100.020	99.980	100.0	1
LG&E	C1SR	926021	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926022	04/2018	04/09/2018	99.980	99.970	100.0	1
LG&E	C1SR	926023	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926024	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926025	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926026	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926027	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926028	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926029	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926030	04/2018	04/09/2018	99.990	99.960	100.0	1
LG&E	C1SR	926031	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926032	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926033	04/2018	04/09/2018	100.000	99.970	99.9	1
LG&E	C1SR	926034	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926035	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926036	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926037	04/2018	04/09/2018	99.950	100.000	100.0	1
LG&E	C1SR	926038	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926039	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926040	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	926041	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926042	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926043	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926044	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926045	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926046	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926047	04/2018	04/09/2018	99.980	99.970	100.0	1
LG&E	C1SR	926048	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926049	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926050	04/2018	04/09/2018	99.960	100.020	100.1	1

LG&E	C1SR	926051	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926052	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926053	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926054	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926055	04/2018	04/09/2018	100.030	100.030	100.0	1
LG&E	C1SR	926056	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926057	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926058	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926059	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926060	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926061	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926062	04/2018	04/09/2018	100.020	100.070	100.1	1
LG&E	C1SR	926063	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	926064	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926065	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926066	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926067	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926068	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926069	04/2018	04/09/2018	100.050	100.000	100.0	1
LG&E	C1SR	926070	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926071	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926072	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926073	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926074	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926075	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926076	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926077	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926078	04/2018	04/09/2018	99.990	100.020	100.1	1
LG&E	C1SR	926079	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926080	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926081	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926082	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926083	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926084	04/2018	04/09/2018	99.990	100.010	100.1	1
LG&E	C1SR	926085	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926086	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926087	04/2018	04/09/2018	100.050	100.000	100.0	1
LG&E	C1SR	926088	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926089	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926090	04/2018	04/09/2018	99.960	100.000	100.0	1
LG&E	C1SR	926091	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926092	04/2018	04/09/2018	100.020	99.990	100.0	1

LG&E	C1SR	926093	04/2018	04/09/2018	100.010	100.070	100.1	1
LG&E	C1SR	926094	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926095	04/2018	04/09/2018	99.980	99.980	100.0	1
LG&E	C1SR	926096	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926097	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926098	04/2018	04/09/2018	99.960	99.980	100.0	1
LG&E	C1SR	926099	04/2018	04/09/2018	100.020	100.040	100.0	1
LG&E	C1SR	926100	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926101	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926102	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926103	04/2018	04/09/2018	99.970	100.050	100.0	1
LG&E	C1SR	926104	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926105	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926106	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926107	04/2018	04/09/2018	99.980	100.050	100.1	1
LG&E	C1SR	926108	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926109	04/2018	04/09/2018	100.040	100.000	99.9	1
LG&E	C1SR	926110	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926111	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926112	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926113	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926114	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926115	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926116	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926117	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926118	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926119	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926120	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926121	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926122	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926123	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926124	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926125	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926126	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926127	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926128	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926129	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926130	04/2018	04/09/2018	99.980	100.060	100.0	1
LG&E	C1SR	926131	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926132	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926133	04/2018	04/09/2018	99.980	99.980	100.0	1
LG&E	C1SR	926134	04/2018	04/09/2018	100.010	100.010	100.0	1



LG&E	C1SR	926135	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926136	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926137	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926138	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926139	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926140	04/2018	04/09/2018	99.990	100.000	99.9	1
LG&E	C1SR	926141	04/2018	04/09/2018	99.970	100.020	100.0	1
LG&E	C1SR	926142	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926143	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926144	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926145	04/2018	04/09/2018	100.020	99.980	99.9	1
LG&E	C1SR	926146	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926147	04/2018	04/09/2018	99.950	100.010	100.0	1
LG&E	C1SR	926148	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926149	04/2018	04/09/2018	99.970	99.980	99.9	1
LG&E	C1SR	926150	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926151	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926152	04/2018	04/09/2018	100.030	99.980	99.9	1
LG&E	C1SR	926153	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926154	04/2018	04/09/2018	100.030	100.030	100.1	1
LG&E	C1SR	926155	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926156	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926157	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926158	04/2018	04/09/2018	100.020	99.960	99.9	1
LG&E	C1SR	926159	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926160	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926161	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926162	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926163	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926164	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926165	04/2018	04/09/2018	100.040	100.020	100.0	1
LG&E	C1SR	926166	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926167	04/2018	04/09/2018	99.990	100.000	99.9	1
LG&E	C1SR	926168	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926169	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926170	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926171	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926172	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926173	04/2018	04/09/2018	100.020	100.040	100.0	1
LG&E	C1SR	926174	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926175	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926176	04/2018	04/09/2018	100.020	99.990	99.9	1

LG&E	C1SR	926177	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926178	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926179	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926180	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	926181	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926182	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926183	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926184	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926185	04/2018	04/09/2018	99.970	100.050	100.0	1
LG&E	C1SR	926186	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926187	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926188	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926189	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926190	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926191	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926192	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926193	04/2018	04/09/2018	99.960	100.000	100.0	1
LG&E	C1SR	926194	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926195	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926196	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926197	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926198	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926199	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926200	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926201	04/2018	04/09/2018	100.020	99.980	100.0	1
LG&E	C1SR	926202	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926203	04/2018	04/09/2018	100.020	99.950	100.0	1
LG&E	C1SR	926204	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926205	04/2018	04/09/2018	100.030	100.010	100.0	1
LG&E	C1SR	926206	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926207	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926208	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926209	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926210	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926211	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926212	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926213	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926214	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926215	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926216	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926217	04/2018	04/09/2018	100.010	100.060	100.0	1
LG&E	C1SR	926218	04/2018	04/09/2018	100.020	100.050	100.1	1

LG&E	C1SR	926219	04/2018	04/09/2018	99.960	99.980	100.0	1
LG&E	C1SR	926220	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926221	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926222	04/2018	04/09/2018	100.030	100.010	100.1	1
LG&E	C1SR	926223	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926224	04/2018	04/09/2018	99.970	100.050	100.1	1
LG&E	C1SR	926225	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926226	04/2018	04/09/2018	99.990	100.020	100.1	1
LG&E	C1SR	926227	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926228	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926229	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	926230	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926231	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926232	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926233	04/2018	04/09/2018	99.990	100.070	100.1	1
LG&E	C1SR	926234	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926235	04/2018	04/09/2018	100.010	99.960	99.9	1
LG&E	C1SR	926236	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926237	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926238	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926239	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926240	04/2018	04/09/2018	100.010	99.960	100.0	1
LG&E	C1SR	926241	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926242	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926243	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926244	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	926245	04/2018	04/09/2018	100.020	99.980	100.0	1
LG&E	C1SR	926246	04/2018	04/09/2018	99.990	100.060	100.0	1
LG&E	C1SR	926247	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926248	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926249	04/2018	04/09/2018	100.000	100.060	100.1	1
LG&E	C1SR	926250	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926251	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926252	04/2018	04/09/2018	100.000	100.040	100.1	1
LG&E	C1SR	926253	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926254	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926255	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926256	04/2018	04/09/2018	100.030	100.040	100.0	1
LG&E	C1SR	926257	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	926258	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926259	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926260	04/2018	04/09/2018	99.990	100.010	100.0	1



LG&E	C1SR	926261	04/2018	04/09/2018	100.000	100.030	100.1	1
LG&E	C1SR	926262	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926263	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926264	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926265	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926266	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926267	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926268	04/2018	04/09/2018	99.960	100.000	100.0	1
LG&E	C1SR	926269	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926270	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	926271	04/2018	04/09/2018	100.040	100.050	100.1	1
LG&E	C1SR	926272	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926273	04/2018	04/09/2018	99.960	100.030	100.0	1
LG&E	C1SR	926274	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926275	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926276	04/2018	04/09/2018	100.020	100.010	100.1	1
LG&E	C1SR	926277	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926278	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926279	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926280	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926281	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926282	04/2018	04/09/2018	99.970	100.010	100.0	1
LG&E	C1SR	926283	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926284	04/2018	04/09/2018	99.970	100.020	100.0	1
LG&E	C1SR	926285	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926286	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	926287	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926288	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926289	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926290	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926291	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926292	04/2018	04/09/2018	99.970	100.020	100.1	1
LG&E	C1SR	926293	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926294	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926295	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926296	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926297	04/2018	04/09/2018	99.980	100.030	100.0	1
LG&E	C1SR	926298	04/2018	04/09/2018	99.980	100.040	100.1	1
LG&E	C1SR	926299	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926300	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926301	04/2018	04/09/2018	100.040	100.060	100.1	1
LG&E	C1SR	926302	04/2018	04/09/2018	99.980	100.010	100.0	1

LG&E	C1SR	926303	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926304	04/2018	04/09/2018	99.980	100.040	100.1	1
LG&E	C1SR	926305	04/2018	04/09/2018	100.010	100.030	100.1	1
LG&E	C1SR	926306	04/2018	04/09/2018	100.020	100.030	100.1	1
LG&E	C1SR	926307	04/2018	04/09/2018	99.990	100.060	100.0	1
LG&E	C1SR	926308	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926309	04/2018	04/09/2018	100.020	100.040	100.0	1
LG&E	C1SR	926310	04/2018	04/09/2018	100.010	100.060	100.1	1
LG&E	C1SR	926311	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926312	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926313	04/2018	04/09/2018	100.020	100.040	100.1	1
LG&E	C1SR	926314	04/2018	04/09/2018	99.990	100.030	100.1	1
LG&E	C1SR	926315	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	926316	04/2018	04/09/2018	99.980	99.980	100.0	1
LG&E	C1SR	926317	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926318	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926319	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926320	04/2018	04/09/2018	100.000	100.070	100.1	1
LG&E	C1SR	926321	04/2018	04/09/2018	99.990	99.960	100.0	1
LG&E	C1SR	926322	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926323	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926324	04/2018	04/09/2018	99.970	100.040	100.0	1
LG&E	C1SR	926325	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926326	04/2018	04/09/2018	99.990	100.060	100.1	1
LG&E	C1SR	926327	04/2018	04/09/2018	99.990	100.060	100.0	1
LG&E	C1SR	926328	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926329	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926330	04/2018	04/09/2018	100.000	100.070	100.0	1
LG&E	C1SR	926331	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926332	04/2018	04/09/2018	100.010	100.050	100.1	1
LG&E	C1SR	926333	04/2018	04/09/2018	100.020	100.010	100.1	1
LG&E	C1SR	926334	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926335	04/2018	04/09/2018	99.960	99.980	100.0	1
LG&E	C1SR	926336	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926337	04/2018	04/09/2018	100.040	100.030	100.0	1
LG&E	C1SR	926338	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926339	04/2018	04/09/2018	100.010	100.010	100.1	1
LG&E	C1SR	926340	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926341	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	926342	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926343	04/2018	04/09/2018	99.990	100.030	100.1	1
LG&E	C1SR	926344	04/2018	04/09/2018	100.040	100.000	100.0	1

LG&E	C1SR	926345	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926346	04/2018	04/09/2018	99.990	100.020	100.1	1
LG&E	C1SR	926347	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926348	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	926349	04/2018	04/09/2018	100.030	99.970	100.0	1
LG&E	C1SR	926350	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926351	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926352	04/2018	04/09/2018	99.950	100.020	100.0	1
LG&E	C1SR	926353	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926354	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926355	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926356	04/2018	04/09/2018	100.030	99.950	100.0	1
LG&E	C1SR	926357	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926358	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926359	04/2018	04/09/2018	100.010	99.960	100.0	1
LG&E	C1SR	926360	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926361	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926362	04/2018	04/09/2018	100.010	99.970	100.0	1
LG&E	C1SR	926363	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926364	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926365	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926366	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926367	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926368	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926369	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926370	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926371	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926372	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926373	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926374	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926375	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926376	04/2018	04/09/2018	99.980	100.030	100.1	1
LG&E	C1SR	926377	04/2018	04/09/2018	100.010	99.980	100.0	1
LG&E	C1SR	926378	04/2018	04/09/2018	100.030	100.040	100.0	1
LG&E	C1SR	926379	04/2018	04/09/2018	100.020	100.060	100.1	1
LG&E	C1SR	926380	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926381	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926382	04/2018	04/09/2018	100.000	100.050	100.1	1
LG&E	C1SR	926383	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926384	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926385	04/2018	04/09/2018	99.960	100.050	100.0	1
LG&E	C1SR	926386	04/2018	04/09/2018	100.030	100.040	100.0	1



LG&E	C1SR	926387	04/2018	04/09/2018	99.980	100.060	100.0	1
LG&E	C1SR	926388	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926389	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926390	04/2018	04/09/2018	100.040	100.020	100.0	1
LG&E	C1SR	926391	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926392	04/2018	04/09/2018	99.990	100.020	100.1	1
LG&E	C1SR	926393	04/2018	04/09/2018	100.000	100.010	100.1	1
LG&E	C1SR	926394	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926395	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926396	04/2018	04/09/2018	100.000	100.010	100.1	1
LG&E	C1SR	926397	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926398	04/2018	04/09/2018	100.030	100.040	100.1	1
LG&E	C1SR	926399	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926400	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926401	04/2018	04/09/2018	100.010	99.980	100.0	1
LG&E	C1SR	926402	04/2018	04/09/2018	100.010	100.010	100.1	1
LG&E	C1SR	926403	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926404	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926405	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	926406	04/2018	04/09/2018	100.010	100.090	100.1	1
LG&E	C1SR	926407	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926408	04/2018	04/09/2018	100.030	100.070	100.1	1
LG&E	C1SR	926409	04/2018	04/09/2018	99.980	99.960	100.0	1
LG&E	C1SR	926410	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926411	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	926412	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926413	04/2018	04/09/2018	99.980	100.080	100.0	1
LG&E	C1SR	926414	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926415	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926416	04/2018	04/09/2018	99.990	99.960	100.0	1
LG&E	C1SR	926417	04/2018	04/09/2018	99.970	100.020	100.1	1
LG&E	C1SR	926418	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926419	04/2018	04/09/2018	100.030	100.030	100.0	1
LG&E	C1SR	926420	04/2018	04/09/2018	100.010	100.060	100.0	1
LG&E	C1SR	926421	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926422	04/2018	04/09/2018	100.050	100.020	100.0	1
LG&E	C1SR	926423	04/2018	04/09/2018	100.000	100.060	100.0	1
LG&E	C1SR	926424	04/2018	04/09/2018	99.990	100.020	100.1	1
LG&E	C1SR	926425	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926426	04/2018	04/09/2018	100.000	100.010	100.1	1
LG&E	C1SR	926427	04/2018	04/09/2018	100.010	100.060	100.1	1
LG&E	C1SR	926428	04/2018	04/09/2018	100.010	100.010	100.0	1

LG&E	C1SR	926429	04/2018	04/09/2018	100.000	100.060	100.0	1
LG&E	C1SR	926430	04/2018	04/09/2018	100.000	99.990	100.1	1
LG&E	C1SR	926431	04/2018	04/09/2018	100.010	99.980	100.0	1
LG&E	C1SR	926432	04/2018	04/09/2018	100.010	100.060	100.1	1
LG&E	C1SR	926433	04/2018	04/09/2018	99.980	100.040	100.0	1
LG&E	C1SR	926434	04/2018	04/09/2018	100.010	100.090	100.1	1
LG&E	C1SR	926435	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926436	04/2018	04/09/2018	100.030	100.070	100.0	1
LG&E	C1SR	926437	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926438	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926439	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	926440	04/2018	04/09/2018	99.960	100.050	100.0	1
LG&E	C1SR	926441	04/2018	04/09/2018	99.960	99.950	100.0	1
LG&E	C1SR	926442	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926443	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926444	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926445	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926446	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926447	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926448	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926449	04/2018	04/09/2018	100.040	100.060	100.0	1
LG&E	C1SR	926450	04/2018	04/09/2018	100.040	100.050	100.0	1
LG&E	C1SR	926451	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926452	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926453	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	926454	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926455	04/2018	04/09/2018	99.990	99.970	100.0	1
LG&E	C1SR	926456	04/2018	04/09/2018	100.000	100.030	100.1	1
LG&E	C1SR	926457	04/2018	04/09/2018	100.000	100.090	100.1	1
LG&E	C1SR	926458	04/2018	04/09/2018	100.020	100.050	100.0	1
LG&E	C1SR	926459	04/2018	04/09/2018	100.020	100.060	100.0	1
LG&E	C1SR	926460	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926461	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926462	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926463	04/2018	04/09/2018	100.020	100.080	100.0	1
LG&E	C1SR	926464	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926465	04/2018	04/09/2018	100.020	100.080	100.0	1
LG&E	C1SR	926466	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926467	04/2018	04/09/2018	100.050	99.980	100.0	1
LG&E	C1SR	926468	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926469	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926470	04/2018	04/09/2018	100.010	100.040	100.0	1

LG&E	C1SR	926471	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926472	04/2018	04/09/2018	99.980	100.070	100.1	1
LG&E	C1SR	926473	04/2018	04/09/2018	100.010	100.040	100.1	1
LG&E	C1SR	926474	04/2018	04/09/2018	100.030	100.040	100.0	1
LG&E	C1SR	926475	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926476	04/2018	04/09/2018	99.980	100.050	100.0	1
LG&E	C1SR	926477	04/2018	04/09/2018	99.960	100.030	100.0	1
LG&E	C1SR	926478	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926479	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926480	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926481	04/2018	04/09/2018	100.010	100.030	100.0	1
LG&E	C1SR	926482	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926483	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926484	04/2018	04/09/2018	100.020	100.050	100.1	1
LG&E	C1SR	926485	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926486	04/2018	04/09/2018	99.970	100.040	100.0	1
LG&E	C1SR	926487	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926488	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926489	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926490	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926491	04/2018	04/09/2018	100.040	100.060	100.1	1
LG&E	C1SR	926492	04/2018	04/09/2018	100.020	99.960	100.0	1
LG&E	C1SR	926493	04/2018	04/09/2018	99.980	99.970	100.0	1
LG&E	C1SR	926494	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926495	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926496	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926497	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926498	04/2018	04/09/2018	100.030	100.030	100.0	1
LG&E	C1SR	926499	04/2018	04/09/2018	100.030	100.020	100.0	1
LG&E	C1SR	926500	04/2018	04/09/2018	100.000	100.020	100.0	1
LG&E	C1SR	926501	04/2018	04/09/2018	100.030	99.950	100.0	1
LG&E	C1SR	926502	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926503	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926504	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926505	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926506	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926507	04/2018	04/09/2018	100.030	99.960	100.0	1
LG&E	C1SR	926508	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	926509	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926510	04/2018	04/09/2018	99.980	99.990	100.0	1
LG&E	C1SR	926511	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926512	04/2018	04/09/2018	99.990	100.020	100.0	1



LG&E	C1SR	926513	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926514	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926515	04/2018	04/09/2018	100.000	99.980	99.9	1
LG&E	C1SR	926516	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926517	04/2018	04/09/2018	99.970	99.970	100.0	1
LG&E	C1SR	926518	04/2018	04/09/2018	99.990	100.050	100.0	1
LG&E	C1SR	926519	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926520	04/2018	04/09/2018	100.020	100.020	100.0	1
LG&E	C1SR	926521	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926522	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926523	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926524	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926525	04/2018	04/09/2018	100.020	99.980	100.0	1
LG&E	C1SR	926526	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926527	04/2018	04/09/2018	99.970	100.020	100.0	1
LG&E	C1SR	926528	04/2018	04/09/2018	100.030	99.990	100.0	1
LG&E	C1SR	926529	04/2018	04/09/2018	100.030	100.030	100.0	1
LG&E	C1SR	926530	04/2018	04/09/2018	100.000	100.040	100.0	1
LG&E	C1SR	926531	04/2018	04/09/2018	100.000	100.020	100.1	1
LG&E	C1SR	926532	04/2018	04/09/2018	99.930	100.020	100.0	1
LG&E	C1SR	926533	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926534	04/2018	04/09/2018	99.980	99.980	100.0	1
LG&E	C1SR	926535	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	926536	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926537	04/2018	04/09/2018	100.020	100.030	100.0	1
LG&E	C1SR	926538	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926539	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926540	04/2018	04/09/2018	99.980	99.970	100.0	1
LG&E	C1SR	926541	04/2018	04/09/2018	99.960	99.980	100.0	1
LG&E	C1SR	926542	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926543	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926544	04/2018	04/09/2018	100.000	100.050	100.1	1
LG&E	C1SR	926545	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926546	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926547	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926548	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926549	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926550	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926551	04/2018	04/09/2018	99.970	99.980	100.0	1
LG&E	C1SR	926552	04/2018	04/09/2018	100.040	100.000	100.0	1
LG&E	C1SR	926553	04/2018	04/09/2018	99.970	99.960	100.0	1
LG&E	C1SR	926554	04/2018	04/09/2018	99.990	100.010	100.0	1

LG&E	C1SR	926555	04/2018	04/09/2018	99.980	99.980	100.0	1
LG&E	C1SR	926556	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926557	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926558	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926559	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926560	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926561	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926562	04/2018	04/09/2018	100.020	99.960	100.0	1
LG&E	C1SR	926563	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926564	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926565	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926566	04/2018	04/09/2018	99.990	99.980	99.9	1
LG&E	C1SR	926567	04/2018	04/09/2018	99.980	100.010	100.1	1
LG&E	C1SR	926568	04/2018	04/09/2018	100.020	99.970	100.0	1
LG&E	C1SR	926569	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926570	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926571	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926572	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926573	04/2018	04/09/2018	100.010	99.980	100.0	1
LG&E	C1SR	926574	04/2018	04/09/2018	99.980	100.040	100.1	1
LG&E	C1SR	926575	04/2018	04/09/2018	100.000	100.050	100.0	1
LG&E	C1SR	926576	04/2018	04/09/2018	99.980	99.960	100.0	1
LG&E	C1SR	926577	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926578	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	926579	04/2018	04/09/2018	99.960	100.040	100.0	1
LG&E	C1SR	926580	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926581	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926582	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926583	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926584	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926585	04/2018	04/09/2018	100.020	99.990	100.0	1
LG&E	C1SR	926586	04/2018	04/09/2018	99.990	100.000	100.0	1
LG&E	C1SR	926587	04/2018	04/09/2018	100.020	100.000	100.0	1
LG&E	C1SR	926588	04/2018	04/09/2018	99.950	99.990	100.0	1
LG&E	C1SR	926589	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926590	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926591	04/2018	04/09/2018	100.000	99.950	100.0	1
LG&E	C1SR	926592	04/2018	04/09/2018	99.990	99.990	99.9	1
LG&E	C1SR	926593	04/2018	04/09/2018	99.990	100.030	100.0	1
LG&E	C1SR	926594	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926595	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926596	04/2018	04/09/2018	99.980	99.990	100.0	1

LG&E	C1SR	926597	04/2018	04/09/2018	100.040	99.990	100.0	1
LG&E	C1SR	926598	04/2018	04/09/2018	99.990	100.010	100.0	1
LG&E	C1SR	926599	04/2018	04/09/2018	100.010	100.010	100.0	1
LG&E	C1SR	926600	04/2018	04/09/2018	99.970	99.970	100.0	1
LG&E	C1SR	926601	04/2018	04/09/2018	99.980	100.020	100.0	1
LG&E	C1SR	926602	04/2018	04/09/2018	100.030	100.000	100.0	1
LG&E	C1SR	926603	04/2018	04/09/2018	100.010	100.050	100.0	1
LG&E	C1SR	926604	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926605	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926606	04/2018	04/09/2018	100.040	100.040	100.0	1
LG&E	C1SR	926607	04/2018	04/09/2018	100.030	100.050	100.0	1
LG&E	C1SR	926608	04/2018	04/09/2018	100.010	99.990	100.0	1
LG&E	C1SR	926609	04/2018	04/09/2018	100.000	100.030	100.0	1
LG&E	C1SR	926610	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926611	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926612	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926613	04/2018	04/09/2018	100.010	100.000	100.0	1
LG&E	C1SR	926614	04/2018	04/09/2018	100.030	99.980	99.9	1
LG&E	C1SR	926615	04/2018	04/09/2018	100.000	99.990	100.0	1
LG&E	C1SR	926616	04/2018	04/09/2018	100.030	99.950	100.0	1
LG&E	C1SR	926617	04/2018	04/09/2018	100.000	99.970	100.0	1
LG&E	C1SR	926618	04/2018	04/09/2018	100.000	99.990	99.9	1
LG&E	C1SR	926619	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926620	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926621	04/2018	04/09/2018	99.990	100.020	100.0	1
LG&E	C1SR	926622	04/2018	04/09/2018	100.000	99.980	100.0	1
LG&E	C1SR	926623	04/2018	04/09/2018	100.020	100.010	100.0	1
LG&E	C1SR	926624	04/2018	04/09/2018	99.970	100.000	100.0	1
LG&E	C1SR	926625	04/2018	04/09/2018	99.970	99.990	100.0	1
LG&E	C1SR	926626	04/2018	04/09/2018	99.990	99.980	100.0	1
LG&E	C1SR	926627	04/2018	04/09/2018	99.940	100.020	100.1	1
LG&E	C1SR	926628	04/2018	04/09/2018	99.970	99.990	99.9	1
LG&E	C1SR	926629	04/2018	04/09/2018	99.980	100.010	100.0	1
LG&E	C1SR	926630	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926631	04/2018	04/09/2018	100.010	100.020	100.0	1
LG&E	C1SR	926632	04/2018	04/09/2018	99.980	100.000	100.0	1
LG&E	C1SR	926633	04/2018	04/09/2018	99.960	100.010	100.0	1
LG&E	C1SR	926634	04/2018	04/09/2018	100.020	99.960	99.9	1
LG&E	C1SR	926635	04/2018	04/09/2018	99.990	99.990	100.0	1
LG&E	C1SR	926636	04/2018	04/09/2018	100.030	99.980	100.0	1
LG&E	C1SR	926637	04/2018	04/09/2018	99.960	100.020	100.0	1
LG&E	C1SR	926638	04/2018	04/09/2018	100.000	100.020	100.0	1



LG&E	C1SR	926639	04/2018	04/09/2018	99.970	100.050	100.0	1
LG&E	C1SR	926640	04/2018	04/09/2018	100.010	99.980	99.9	1
LG&E	C1SR	926641	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926642	04/2018	04/09/2018	100.000	99.960	100.0	1
LG&E	C1SR	926643	04/2018	04/09/2018	99.950	99.990	100.0	1
LG&E	C1SR	926644	04/2018	04/09/2018	100.000	100.010	100.0	1
LG&E	C1SR	926645	04/2018	04/09/2018	99.990	100.040	100.0	1
LG&E	C1SR	926646	04/2018	04/09/2018	100.010	100.040	100.0	1
LG&E	C1SR	926647	04/2018	04/09/2018	100.000	100.000	100.0	1
LG&E	C1SR	926648	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926649	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926650	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926651	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926652	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926653	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926654	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926655	03/2018	03/19/2018	99.990	99.930	100.0	1
LG&E	C1SR	926656	03/2018	03/19/2018	100.000	99.960	100.0	1
LG&E	C1SR	926657	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926658	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926659	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926660	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926661	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926662	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926663	03/2018	03/19/2018	100.000	99.960	100.0	1
LG&E	C1SR	926664	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926665	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926666	03/2018	03/19/2018	99.980	99.950	100.0	1
LG&E	C1SR	926667	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926668	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926669	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926670	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926671	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926672	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926673	03/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	C1SR	926674	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926675	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926676	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926677	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926678	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926679	03/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	C1SR	926680	03/2018	03/19/2018	100.000	100.000	100.0	1

LG&E	C1SR	926681	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926682	03/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	C1SR	926683	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926684	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926685	03/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	C1SR	926686	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926687	03/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	C1SR	926688	03/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	C1SR	926689	03/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	C1SR	926690	03/2018	03/19/2018	100.000	99.970	100.0	1
LG&E	C1SR	926691	03/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	C1SR	926692	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926693	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926694	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926695	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926696	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926697	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926698	03/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	C1SR	926699	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926700	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926701	03/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	C1SR	926702	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926703	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926704	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926705	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926706	03/2018	03/19/2018	99.990	100.070	100.1	1
LG&E	C1SR	926707	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926708	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926709	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926710	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926711	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926712	03/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	C1SR	926713	03/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	C1SR	926714	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926715	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926716	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926717	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926718	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926719	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926720	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926721	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926722	03/2018	03/19/2018	99.980	100.030	100.0	1

LG&E	C1SR	926723	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926724	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926725	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926726	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926727	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926728	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926729	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926730	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926731	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926732	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926733	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926734	03/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	C1SR	926735	03/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	C1SR	926736	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926737	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926738	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926739	03/2018	03/19/2018	99.980	99.860	99.9	1
LG&E	C1SR	926740	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926741	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926742	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926743	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926744	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926745	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926746	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926747	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926748	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926749	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926750	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926751	03/2018	03/19/2018	99.980	99.950	100.0	1
LG&E	C1SR	926752	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926753	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926754	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926755	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926756	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926757	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926758	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926759	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926760	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926761	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926762	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926763	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926764	03/2018	03/19/2018	99.990	99.990	100.0	1



LG&E	C1SR	926765	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926766	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926767	03/2018	03/19/2018	99.990	99.950	100.0	1
LG&E	C1SR	926768	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926769	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926770	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926771	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926772	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926773	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926774	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926775	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926776	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926777	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926778	03/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	C1SR	926779	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926780	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926781	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926782	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926783	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926784	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926785	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926786	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926787	03/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	C1SR	926788	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926789	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926790	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926791	03/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	C1SR	926792	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926793	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926794	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926795	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926796	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926797	03/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	C1SR	926798	03/2018	03/19/2018	99.990	100.050	100.0	1
LG&E	C1SR	926799	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926800	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926801	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926802	03/2018	03/19/2018	99.990	100.050	100.0	1
LG&E	C1SR	926803	03/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	C1SR	926804	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926805	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926806	03/2018	03/19/2018	99.990	100.030	100.0	1

LG&E	C1SR	926807	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926808	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926809	03/2018	03/19/2018	99.990	100.050	100.0	1
LG&E	C1SR	926810	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926811	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926812	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926813	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926814	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926815	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926816	03/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	C1SR	926817	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926818	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926819	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926820	03/2018	03/19/2018	99.980	100.050	100.1	1
LG&E	C1SR	926821	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926822	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926823	03/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	C1SR	926824	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926825	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926826	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926827	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926828	03/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	C1SR	926829	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926830	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926831	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926832	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926833	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926834	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926835	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926836	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926837	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926838	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926839	03/2018	03/19/2018	99.990	99.940	100.0	1
LG&E	C1SR	926840	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926841	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926842	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926843	03/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	C1SR	926844	03/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	C1SR	926845	03/2018	03/19/2018	99.990	100.050	100.0	1
LG&E	C1SR	926846	03/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	C1SR	926847	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926848	03/2018	03/19/2018	100.000	100.010	100.0	1

LG&E	C1SR	926849	03/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	C1SR	926850	03/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	C1SR	926851	03/2018	03/19/2018	99.990	100.050	100.0	1
LG&E	C1SR	926852	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926853	03/2018	03/19/2018	99.980	100.050	100.0	1
LG&E	C1SR	926854	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926855	03/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	C1SR	926856	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926857	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926858	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926859	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926860	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926861	03/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	C1SR	926862	03/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	C1SR	926863	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926864	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926865	03/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	C1SR	926866	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926867	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926868	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926869	03/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	C1SR	926870	03/2018	03/19/2018	99.980	100.050	100.0	1
LG&E	C1SR	926871	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926872	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926873	03/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	C1SR	926874	03/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	C1SR	926875	03/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	C1SR	926876	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926877	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926878	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926879	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926880	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926881	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926882	03/2018	03/19/2018	100.000	99.950	100.0	1
LG&E	C1SR	926883	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926884	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926885	03/2018	03/19/2018	99.990	99.940	100.0	1
LG&E	C1SR	926886	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926887	03/2018	03/19/2018	99.980	100.040	100.0	1
LG&E	C1SR	926888	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926889	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926890	03/2018	03/19/2018	99.980	100.020	100.0	1



LG&E	C1SR	926891	03/2018	03/19/2018	99.980	99.940	100.0	1
LG&E	C1SR	926892	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926893	03/2018	03/19/2018	99.990	99.940	99.9	1
LG&E	C1SR	926894	03/2018	03/19/2018	99.990	99.930	100.0	1
LG&E	C1SR	926895	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926896	03/2018	03/19/2018	99.980	99.950	100.0	1
LG&E	C1SR	926897	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926898	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926899	03/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	C1SR	926900	03/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	C1SR	926901	03/2018	03/19/2018	99.980	99.940	100.0	1
LG&E	C1SR	926902	03/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	C1SR	926903	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926904	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926905	03/2018	03/19/2018	99.990	99.930	100.0	1
LG&E	C1SR	926906	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926907	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926908	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926909	03/2018	03/19/2018	99.980	99.950	100.0	1
LG&E	C1SR	926910	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926911	03/2018	03/19/2018	100.000	99.950	100.0	1
LG&E	C1SR	926912	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926913	03/2018	03/19/2018	99.990	99.950	100.0	1
LG&E	C1SR	926914	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926915	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926916	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926917	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926918	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926919	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926920	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926921	03/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	C1SR	926922	03/2018	03/19/2018	99.980	99.920	100.0	1
LG&E	C1SR	926923	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926924	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926925	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926926	03/2018	03/19/2018	100.000	99.950	100.0	1
LG&E	C1SR	926927	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926928	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926929	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926930	03/2018	03/19/2018	100.000	99.940	100.0	1
LG&E	C1SR	926931	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926932	03/2018	03/19/2018	99.980	99.960	100.0	1

LG&E	C1SR	926933	03/2018	03/19/2018	99.980	99.940	100.0	1
LG&E	C1SR	926934	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926935	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926936	03/2018	03/19/2018	99.980	100.010	100.0	1
LG&E	C1SR	926937	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926938	03/2018	03/19/2018	100.000	99.940	100.0	1
LG&E	C1SR	926939	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926940	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926941	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926942	03/2018	03/19/2018	99.990	99.950	100.0	1
LG&E	C1SR	926943	03/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	C1SR	926944	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926945	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926946	03/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	C1SR	926947	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926948	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926949	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926950	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926951	03/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	C1SR	926952	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926953	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926954	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926955	03/2018	03/19/2018	99.990	99.950	100.0	1
LG&E	C1SR	926956	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926957	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926958	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926959	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926960	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926961	03/2018	03/19/2018	99.980	99.950	100.0	1
LG&E	C1SR	926962	03/2018	03/19/2018	99.990	99.940	100.0	1
LG&E	C1SR	926963	03/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	C1SR	926964	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926965	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926966	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926967	03/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	C1SR	926968	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926969	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926970	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926971	03/2018	03/19/2018	99.980	99.990	100.0	1
LG&E	C1SR	926972	03/2018	03/19/2018	99.980	99.970	100.0	1
LG&E	C1SR	926973	03/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	C1SR	926974	03/2018	03/19/2018	99.980	99.980	100.0	1

LG&E	C1SR	926975	03/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	C1SR	926976	03/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	C1SR	926977	03/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	C1SR	926978	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	C1SR	926979	03/2018	03/19/2018	99.990	99.940	100.0	1
LG&E	C1SR	926980	03/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	C1SR	926981	03/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	C1SR	926982	03/2018	03/19/2018	100.000	99.940	100.0	1
LG&E	C1SR	926983	03/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	CN1S	924152	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924153	03/2018	02/05/2018	99.980	99.950	99.9	1
LG&E	CN1S	924154	03/2018	02/05/2018	100.000	100.010	99.9	1
LG&E	CN1S	924155	03/2018	02/05/2018	99.990	100.060	100.0	1
LG&E	CN1S	924156	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924157	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924158	03/2018	02/05/2018	99.990	99.990	99.9	1
LG&E	CN1S	924159	03/2018	02/05/2018	99.990	99.990	99.9	1
LG&E	CN1S	924160	03/2018	02/05/2018	99.980	99.970	99.9	1
LG&E	CN1S	924161	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924162	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924163	03/2018	02/05/2018	99.990	100.000	99.9	1
LG&E	CN1S	924164	03/2018	02/05/2018	99.980	100.020	99.9	1
LG&E	CN1S	924165	03/2018	02/05/2018	99.990	100.030	99.9	1
LG&E	CN1S	924166	03/2018	02/05/2018	100.000	100.000	99.9	1
LG&E	CN1S	924167	03/2018	02/05/2018	99.990	100.010	99.9	1
LG&E	CN1S	924168	03/2018	02/05/2018	99.990	100.020	99.9	1
LG&E	CN1S	924169	03/2018	02/05/2018	99.980	100.000	99.9	1
LG&E	CN1S	924170	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924171	03/2018	02/05/2018	99.970	100.020	99.9	1
LG&E	CN1S	924172	03/2018	02/05/2018	99.980	100.000	99.9	1
LG&E	CN1S	924173	03/2018	02/05/2018	99.990	99.980	99.9	1
LG&E	CN1S	924174	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924175	03/2018	02/05/2018	99.990	99.970	99.9	1
LG&E	CN1S	924176	03/2018	02/05/2018	99.980	99.950	99.9	1
LG&E	CN1S	924177	03/2018	02/05/2018	99.970	99.970	99.9	1
LG&E	CN1S	924178	03/2018	02/05/2018	99.990	99.990	99.9	1
LG&E	CN1S	924179	03/2018	02/05/2018	99.990	99.960	99.9	1
LG&E	CN1S	924180	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924181	03/2018	02/05/2018	99.990	99.970	99.9	1
LG&E	CN1S	924182	03/2018	02/05/2018	99.980	100.060	99.9	1
LG&E	CN1S	924183	03/2018	02/05/2018	99.990	99.930	99.9	1
LG&E	CN1S	924184	03/2018	02/05/2018	99.980	99.990	99.9	1



LG&E	CN1S	924185	03/2018	02/05/2018	99.990	100.000	99.9	1
LG&E	CN1S	924186	03/2018	02/05/2018	99.990	99.920	99.9	1
LG&E	CN1S	924187	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924188	03/2018	02/05/2018	100.000	99.990	99.9	1
LG&E	CN1S	924189	03/2018	02/05/2018	99.990	99.940	99.9	1
LG&E	CN1S	924190	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924191	03/2018	02/05/2018	99.980	100.040	99.9	1
LG&E	CN1S	924192	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924193	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924194	03/2018	02/05/2018	99.990	99.970	99.9	1
LG&E	CN1S	924195	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924196	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924197	03/2018	02/05/2018	99.990	100.000	100.0	1
LG&E	CN1S	924198	03/2018	02/05/2018	99.990	100.020	99.9	1
LG&E	CN1S	924199	03/2018	02/05/2018	99.990	99.970	99.9	1
LG&E	CN1S	924200	03/2018	02/05/2018	99.980	99.910	99.9	1
LG&E	CN1S	924201	03/2018	02/05/2018	99.990	100.020	99.9	1
LG&E	CN1S	924202	03/2018	02/05/2018	99.990	100.010	100.0	1
LG&E	CN1S	924203	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924204	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924205	03/2018	02/05/2018	99.990	100.010	99.9	1
LG&E	CN1S	924206	03/2018	02/05/2018	99.990	100.030	99.9	1
LG&E	CN1S	924207	03/2018	02/05/2018	99.990	99.980	99.9	1
LG&E	CN1S	924208	03/2018	02/05/2018	99.980	99.970	99.9	1
LG&E	CN1S	924209	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924210	03/2018	02/05/2018	99.990	100.000	99.9	1
LG&E	CN1S	924211	03/2018	02/05/2018	99.980	100.000	99.9	1
LG&E	CN1S	924212	03/2018	02/05/2018	99.980	100.040	99.9	1
LG&E	CN1S	924213	03/2018	02/05/2018	100.000	99.990	99.9	1
LG&E	CN1S	924214	03/2018	02/05/2018	99.990	99.930	99.9	1
LG&E	CN1S	924215	03/2018	02/05/2018	99.990	99.990	99.9	1
LG&E	CN1S	924216	03/2018	02/05/2018	99.990	99.960	99.9	1
LG&E	CN1S	924217	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924218	03/2018	02/05/2018	100.000	100.010	99.9	1
LG&E	CN1S	924219	03/2018	02/05/2018	99.990	100.020	99.9	1
LG&E	CN1S	924220	03/2018	02/05/2018	99.980	100.000	99.9	1
LG&E	CN1S	924221	03/2018	02/05/2018	99.980	100.010	99.9	1
LG&E	CN1S	924222	03/2018	02/05/2018	100.000	100.040	100.0	1
LG&E	CN1S	924223	03/2018	02/05/2018	99.990	99.980	99.9	1
LG&E	CN1S	924224	03/2018	02/05/2018	99.990	99.930	99.9	1
LG&E	CN1S	924225	03/2018	02/05/2018	99.990	99.990	99.9	1
LG&E	CN1S	924226	03/2018	02/05/2018	99.980	99.950	99.9	1

LG&E	CN1S	924227	03/2018	02/05/2018	99.990	99.980	99.9	1
LG&E	CN1S	924228	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924229	03/2018	02/05/2018	99.980	100.020	99.9	1
LG&E	CN1S	924230	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924231	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924232	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924233	03/2018	02/05/2018	99.990	100.010	99.9	1
LG&E	CN1S	924234	03/2018	02/05/2018	99.990	99.980	99.9	1
LG&E	CN1S	924235	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924236	03/2018	02/05/2018	99.980	100.020	99.9	1
LG&E	CN1S	924237	03/2018	02/05/2018	99.990	99.960	99.9	1
LG&E	CN1S	924238	03/2018	02/05/2018	99.990	100.070	99.9	1
LG&E	CN1S	924239	03/2018	02/05/2018	100.000	99.990	99.9	1
LG&E	CN1S	924240	03/2018	02/05/2018	99.980	99.990	99.9	1
LG&E	CN1S	924241	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924242	03/2018	02/05/2018	99.970	99.950	99.9	1
LG&E	CN1S	924243	03/2018	02/05/2018	99.980	99.930	99.9	1
LG&E	CN1S	924244	03/2018	02/05/2018	99.990	99.950	99.9	1
LG&E	CN1S	924245	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924246	03/2018	02/05/2018	99.980	99.950	99.9	1
LG&E	CN1S	924247	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924248	03/2018	02/05/2018	99.990	99.960	99.9	1
LG&E	CN1S	924249	03/2018	02/05/2018	99.980	99.940	99.9	1
LG&E	CN1S	924250	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924251	03/2018	02/05/2018	99.980	99.970	99.9	1
LG&E	CN1S	924252	03/2018	02/05/2018	99.980	99.980	99.9	1
LG&E	CN1S	924253	03/2018	02/05/2018	99.990	99.960	99.9	1
LG&E	CN1S	924254	03/2018	02/05/2018	99.990	100.000	99.9	1
LG&E	CN1S	924255	03/2018	02/05/2018	99.990	99.950	99.9	1
LG&E	CN1S	924256	03/2018	02/05/2018	100.000	99.980	99.9	1
LG&E	CN1S	924257	03/2018	02/05/2018	99.980	99.970	99.9	1
LG&E	CN1S	924258	03/2018	02/05/2018	99.980	99.930	99.9	1
LG&E	CN1S	924259	03/2018	02/05/2018	99.980	99.960	99.9	1
LG&E	CN1S	924260	03/2018	02/05/2018	99.990	99.910	99.9	1
LG&E	CN1S	924261	03/2018	02/05/2018	99.980	100.000	99.9	1
LG&E	CN1S	924262	03/2018	02/05/2018	99.990	100.000	99.9	1
LG&E	CN1S	924263	03/2018	02/05/2018	99.990	99.930	99.9	1
LG&E	CN1S	924264	03/2018	02/05/2018	99.990	99.970	99.9	1
LG&E	CN1S	924265	03/2018	02/05/2018	99.980	99.930	99.9	1
LG&E	CN1S	924266	03/2018	02/05/2018	100.000	99.970	99.9	1
LG&E	CN1S	924267	03/2018	02/05/2018	99.980	99.930	99.9	1
LG&E	CN1S	924268	03/2018	02/05/2018	99.980	100.000	99.9	1

LG&E	CN1S	924269	03/2018	02/05/2018	99.980	99.950	99.9	1
LG&E	CN1S	924270	03/2018	02/05/2018	99.980	100.030	100.0	1
LG&E	CN1S	924271	03/2018	02/05/2018	99.980	99.970	99.9	1
LG&E	CN1S	927944	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	927945	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	927946	05/2018	05/11/2018	99.980	100.020	99.9	1
LG&E	CN1S	927947	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	927948	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	927949	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	927950	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927951	05/2018	05/11/2018	99.990	100.020	99.9	1
LG&E	CN1S	927952	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	927953	05/2018	05/11/2018	99.990	99.970	100.0	1
LG&E	CN1S	927954	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	927955	05/2018	05/11/2018	99.980	100.060	100.0	1
LG&E	CN1S	927956	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	927957	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927958	05/2018	05/11/2018	99.990	99.980	100.0	1
LG&E	CN1S	927959	05/2018	05/11/2018	99.980	100.060	100.0	1
LG&E	CN1S	927960	05/2018	05/11/2018	99.990	99.990	99.9	1
LG&E	CN1S	927961	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	927962	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	927963	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	927964	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	927965	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	927966	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	927967	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	927968	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	927969	05/2018	05/11/2018	99.990	100.070	100.0	1
LG&E	CN1S	927970	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	927971	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	927972	05/2018	05/11/2018	99.990	100.080	100.0	1
LG&E	CN1S	927973	05/2018	05/11/2018	100.000	100.050	100.0	1
LG&E	CN1S	927974	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	927975	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	927976	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	927977	05/2018	05/11/2018	99.990	99.970	100.0	1
LG&E	CN1S	927978	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	927979	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	927980	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	927981	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927982	05/2018	05/11/2018	99.990	100.040	100.0	1



LG&E	CN1S	927983	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	927984	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	927985	05/2018	05/11/2018	100.000	100.050	100.0	1
LG&E	CN1S	927986	05/2018	05/11/2018	99.980	100.090	100.0	1
LG&E	CN1S	927987	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	927988	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927989	05/2018	05/11/2018	99.980	99.980	99.9	1
LG&E	CN1S	927990	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	927991	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	927992	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	927993	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	927994	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927995	05/2018	05/11/2018	100.000	100.080	100.0	1
LG&E	CN1S	927996	05/2018	05/11/2018	99.990	100.090	99.9	1
LG&E	CN1S	927997	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	927998	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	927999	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928000	05/2018	05/11/2018	99.980	99.980	99.9	1
LG&E	CN1S	928001	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928002	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928003	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928004	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	928005	05/2018	05/11/2018	100.000	100.020	100.0	1
LG&E	CN1S	928006	05/2018	05/11/2018	99.980	100.020	99.9	1
LG&E	CN1S	928007	05/2018	05/11/2018	99.980	99.970	100.0	1
LG&E	CN1S	928008	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928009	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928010	05/2018	05/11/2018	99.990	100.020	99.9	1
LG&E	CN1S	928011	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928012	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928013	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928014	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928015	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928016	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928017	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928018	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928019	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928020	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	928021	05/2018	05/11/2018	100.000	100.050	100.0	1
LG&E	CN1S	928022	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928023	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928024	05/2018	05/11/2018	99.990	100.030	100.0	1

LG&E	CN1S	928025	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928026	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928027	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928028	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928029	05/2018	05/11/2018	100.000	100.070	100.0	1
LG&E	CN1S	928030	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928031	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928032	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	928033	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928034	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928035	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928036	05/2018	05/11/2018	99.980	99.970	99.9	1
LG&E	CN1S	928037	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928038	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928039	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928040	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928041	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928042	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928043	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	928044	05/2018	05/11/2018	99.980	99.980	99.9	1
LG&E	CN1S	928045	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928046	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	928047	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928048	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928049	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928050	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928051	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928052	05/2018	05/11/2018	99.980	100.060	100.0	1
LG&E	CN1S	928053	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928054	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928055	05/2018	05/11/2018	99.990	100.010	99.9	1
LG&E	CN1S	928056	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	928057	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928058	05/2018	05/11/2018	99.980	99.990	99.9	1
LG&E	CN1S	928059	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928060	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928061	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928062	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928063	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928064	05/2018	05/11/2018	99.980	100.070	100.0	1
LG&E	CN1S	928065	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928066	05/2018	05/11/2018	99.980	100.060	100.0	1



LG&E	CN1S	928067	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928068	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928069	05/2018	05/11/2018	99.980	100.070	100.0	1
LG&E	CN1S	928070	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928071	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928072	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928073	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928074	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928075	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928076	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928077	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928078	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928079	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	928080	05/2018	05/11/2018	100.000	100.010	100.0	1
LG&E	CN1S	928081	05/2018	05/11/2018	100.000	100.020	100.0	1
LG&E	CN1S	928082	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928083	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928084	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	928085	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928086	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928087	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928088	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928089	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928090	05/2018	05/11/2018	99.990	99.970	99.9	1
LG&E	CN1S	928091	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928092	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928093	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	928094	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928095	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928096	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928097	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928098	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928099	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928100	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928101	05/2018	05/11/2018	99.990	100.070	100.0	1
LG&E	CN1S	928102	05/2018	05/11/2018	99.980	99.980	99.9	1
LG&E	CN1S	928103	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928104	05/2018	05/11/2018	99.980	100.070	100.0	1
LG&E	CN1S	928105	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928106	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928107	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928108	05/2018	05/11/2018	99.980	100.000	100.0	1



LG&E	CN1S	928109	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928110	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928111	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928112	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928113	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928114	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928115	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928116	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928117	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928118	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928119	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928120	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	928121	05/2018	05/11/2018	99.990	99.960	100.0	1
LG&E	CN1S	928122	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928123	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928124	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928125	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928126	05/2018	05/11/2018	99.990	100.010	99.9	1
LG&E	CN1S	928127	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928128	05/2018	05/11/2018	100.000	100.020	100.0	1
LG&E	CN1S	928129	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928130	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928131	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	928132	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928133	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928134	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	928135	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928136	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928137	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928138	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928139	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928140	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928141	05/2018	05/11/2018	100.000	100.020	100.0	1
LG&E	CN1S	928142	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928143	05/2018	05/11/2018	99.980	100.070	100.0	1
LG&E	CN1S	928144	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928145	05/2018	05/11/2018	99.990	99.980	100.0	1
LG&E	CN1S	928146	05/2018	05/11/2018	99.980	100.080	100.0	1
LG&E	CN1S	928147	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928148	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928149	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928150	05/2018	05/11/2018	99.990	100.000	100.0	1

LG&E	CN1S	928151	05/2018	05/11/2018	100.000	100.010	100.0	1
LG&E	CN1S	928152	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928153	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928154	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928155	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928156	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928157	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928158	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928159	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928160	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928161	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928162	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	928163	05/2018	05/11/2018	100.000	100.050	100.0	1
LG&E	CN1S	928164	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928165	05/2018	05/11/2018	99.990	99.990	100.0	1
LG&E	CN1S	928166	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928167	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928168	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928169	05/2018	05/11/2018	99.980	100.040	100.0	1
LG&E	CN1S	928170	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928171	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928172	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928173	05/2018	05/11/2018	99.980	99.990	100.0	1
LG&E	CN1S	928174	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928175	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928176	05/2018	05/11/2018	99.980	100.070	100.0	1
LG&E	CN1S	928177	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928178	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928179	05/2018	05/11/2018	100.000	100.010	100.0	1
LG&E	CN1S	928180	05/2018	05/11/2018	100.000	99.980	100.0	1
LG&E	CN1S	928181	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928182	05/2018	05/11/2018	100.000	100.010	100.0	1
LG&E	CN1S	928183	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928184	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928185	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928186	05/2018	05/11/2018	100.000	100.070	100.0	1
LG&E	CN1S	928187	05/2018	05/11/2018	99.980	99.960	100.0	1
LG&E	CN1S	928188	05/2018	05/11/2018	100.000	99.980	100.0	1
LG&E	CN1S	928189	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928190	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928191	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928192	05/2018	05/11/2018	99.990	100.020	100.0	1

LG&E	CN1S	928193	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928194	05/2018	05/11/2018	99.980	100.050	100.0	1
LG&E	CN1S	928195	05/2018	05/11/2018	99.990	99.970	100.0	1
LG&E	CN1S	928196	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928197	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	928198	05/2018	05/11/2018	100.000	99.980	100.0	1
LG&E	CN1S	928199	05/2018	05/11/2018	100.000	100.070	100.0	1
LG&E	CN1S	928200	05/2018	05/11/2018	99.990	99.980	100.0	1
LG&E	CN1S	928201	05/2018	05/11/2018	99.990	99.970	100.0	1
LG&E	CN1S	928202	05/2018	05/11/2018	99.990	100.050	100.0	1
LG&E	CN1S	928203	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928204	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928205	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928206	05/2018	05/11/2018	99.980	100.020	100.0	1
LG&E	CN1S	928207	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928208	05/2018	05/11/2018	99.980	100.000	100.0	1
LG&E	CN1S	928209	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	928210	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	928211	05/2018	05/11/2018	100.000	100.010	100.0	1
LG&E	CN1S	928212	05/2018	05/11/2018	100.000	100.060	100.0	1
LG&E	CN1S	928213	05/2018	05/11/2018	99.990	99.970	100.0	1
LG&E	CN1S	928214	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928215	05/2018	05/11/2018	99.980	99.980	100.0	1
LG&E	CN1S	928216	05/2018	05/11/2018	100.000	100.040	100.0	1
LG&E	CN1S	928217	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928218	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928219	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928220	05/2018	05/11/2018	99.990	100.010	100.0	1
LG&E	CN1S	928221	05/2018	05/11/2018	99.990	100.020	100.0	1
LG&E	CN1S	928222	05/2018	05/11/2018	99.980	100.010	100.0	1
LG&E	CN1S	928223	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	CN1S	928224	05/2018	05/11/2018	99.990	100.040	100.0	1
LG&E	CN1S	928225	05/2018	05/11/2018	100.000	100.000	100.0	1
LG&E	CN1S	928226	05/2018	05/11/2018	99.990	100.000	100.0	1
LG&E	CN1S	928227	05/2018	05/11/2018	99.980	100.030	100.0	1
LG&E	CN1S	928228	05/2018	05/11/2018	99.990	100.030	100.0	1
LG&E	CN1S	928229	05/2018	05/11/2018	99.990	99.980	100.0	1
LG&E	CN1S	928230	05/2018	05/11/2018	99.990	100.060	100.0	1
LG&E	CN1S	928231	05/2018	05/11/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	918158	05/2018	06/06/2017	99.990	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	918159	05/2018	06/06/2017	99.990	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	918160	05/2018	06/06/2017	100.020	100.030	100.1	1



LG&E	FOCUS AXRE-SD MESH	918161	05/2018	06/07/2017	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924408	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924409	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924410	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924411	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924412	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924413	05/2018	03/19/2018	99.960	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924414	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924415	05/2018	03/19/2018	100.010	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924416	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924417	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924418	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924419	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924420	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924421	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924422	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924423	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924424	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924425	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924426	05/2018	03/19/2018	100.010	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924427	05/2018	03/19/2018	100.020	100.060	100.2	1
LG&E	FOCUS AXRE-SD MESH	924428	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924429	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924430	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924431	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924432	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924433	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924434	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924435	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924436	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924437	05/2018	03/19/2018	99.960	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924438	05/2018	03/19/2018	100.020	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924439	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924440	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924441	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924442	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924443	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924444	05/2018	03/19/2018	100.050	100.040	99.9	1
LG&E	FOCUS AXRE-SD MESH	924445	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924446	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924447	05/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924448	05/2018	03/19/2018	100.020	100.020	100.0	1

LG&E	FOCUS AXRE-SD MESH	924449	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924450	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924451	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924452	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924453	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924454	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924455	05/2018	03/19/2018	99.980	99.950	100.1	1
LG&E	FOCUS AXRE-SD MESH	924456	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924457	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924458	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924459	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924460	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924461	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924462	05/2018	03/19/2018	99.990	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924463	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924464	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	924465	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924466	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924467	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924468	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924469	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924470	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924471	05/2018	03/19/2018	100.010	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924472	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924473	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924474	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924475	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924476	05/2018	03/19/2018	100.000	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924477	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924478	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924479	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924480	05/2018	03/19/2018	100.050	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924481	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924482	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924483	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924484	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924485	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924486	05/2018	03/19/2018	100.040	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924487	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924488	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924489	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924490	05/2018	03/19/2018	100.000	99.980	100.1	1

LG&E	FOCUS AXRE-SD MESH	924491	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924492	05/2018	03/19/2018	100.010	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924493	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924494	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924495	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924496	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924497	05/2018	03/19/2018	100.000	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924498	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924499	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924500	05/2018	03/19/2018	100.010	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924501	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924502	05/2018	03/19/2018	100.000	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924503	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924504	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924505	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924506	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924507	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924508	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924509	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924510	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924511	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924512	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924513	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924514	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924515	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924516	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924517	05/2018	03/19/2018	99.960	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924518	05/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924519	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924520	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924521	05/2018	03/19/2018	100.010	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924522	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924523	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924524	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924525	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924526	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924527	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924528	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924529	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924530	05/2018	03/19/2018	99.970	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924531	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924532	05/2018	03/19/2018	100.000	100.000	100.1	1



LG&E	FOCUS AXRE-SD MESH	924533	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924534	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924535	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924536	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924537	05/2018	03/19/2018	100.020	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924538	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924539	05/2018	03/19/2018	100.030	100.080	100.1	1
LG&E	FOCUS AXRE-SD MESH	924540	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924541	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924542	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924543	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924544	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924545	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924546	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924547	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924548	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924549	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924550	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924551	05/2018	03/19/2018	100.000	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924552	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924553	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924554	05/2018	03/19/2018	100.000	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924555	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924556	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924557	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924558	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924559	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924560	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924561	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924562	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924563	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924564	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924565	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924566	05/2018	03/19/2018	100.020	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924567	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924568	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924569	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924570	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924571	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924572	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924573	05/2018	03/19/2018	100.000	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924574	05/2018	03/19/2018	100.000	99.990	100.1	1

LG&E	FOCUS AXRE-SD MESH	924575	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924576	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924577	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924578	05/2018	03/19/2018	100.000	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924579	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924580	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924581	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924582	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924583	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924584	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924585	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924586	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924587	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924588	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924589	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924590	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924591	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924592	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924593	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924594	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924595	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924596	05/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924597	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924598	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924599	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924600	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924601	05/2018	03/19/2018	100.020	100.070	100.0	1
LG&E	FOCUS AXRE-SD MESH	924602	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924603	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924604	05/2018	03/19/2018	100.030	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924605	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924606	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924607	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924608	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924609	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924610	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924611	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924612	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924613	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924614	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924615	05/2018	03/19/2018	99.980	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924616	05/2018	03/19/2018	99.980	100.020	100.1	1



LG&E	FOCUS AXRE-SD MESH	924617	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924618	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924619	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924620	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924621	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924622	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924623	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924624	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924625	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924626	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924627	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924628	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924629	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924630	05/2018	03/19/2018	100.040	100.040	100.2	1
LG&E	FOCUS AXRE-SD MESH	924631	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924632	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924633	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924634	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924635	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924636	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924637	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924638	05/2018	03/19/2018	100.000	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924639	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924640	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924641	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924642	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924643	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924644	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924645	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924646	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924647	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924648	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924649	05/2018	03/19/2018	100.030	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924650	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924651	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924652	05/2018	03/19/2018	100.010	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924653	05/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924654	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924655	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924656	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924657	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924658	05/2018	03/19/2018	100.000	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	924659	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924660	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924661	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924662	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924663	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924664	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924665	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924666	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924667	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924668	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924669	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924670	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924671	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924672	05/2018	03/19/2018	100.010	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924673	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924674	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924675	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924676	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924677	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924678	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924679	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924680	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924681	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924682	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924683	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924684	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924685	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924686	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924687	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924688	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924689	05/2018	03/19/2018	100.040	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924690	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924691	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924692	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924693	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924694	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924695	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924696	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924697	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924698	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924699	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924700	05/2018	03/19/2018	99.990	99.980	100.0	1

LG&E	FOCUS AXRE-SD MESH	924701	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924702	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924703	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924704	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924705	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924706	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924707	05/2018	03/19/2018	99.960	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924708	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924709	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924710	05/2018	03/19/2018	100.040	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924711	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924712	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924713	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924714	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924715	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924716	05/2018	03/19/2018	100.000	100.040	99.9	1
LG&E	FOCUS AXRE-SD MESH	924717	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924718	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924719	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924720	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	924721	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924722	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924723	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924724	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924725	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924726	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924727	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924728	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924729	05/2018	03/19/2018	100.000	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924730	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924731	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924732	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924733	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924734	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924735	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924736	05/2018	03/19/2018	100.010	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924737	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924738	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924739	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924740	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924741	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924742	05/2018	03/19/2018	100.010	100.040	100.1	1



LG&E	FOCUS AXRE-SD MESH	924743	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924744	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924745	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924746	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924747	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924748	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924749	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924750	05/2018	03/19/2018	100.010	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924751	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924752	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924753	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924754	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924755	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924756	05/2018	03/19/2018	99.970	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924757	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924758	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924759	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924760	05/2018	03/19/2018	100.030	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924761	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924762	05/2018	03/19/2018	100.010	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924763	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924764	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924765	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924766	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924767	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924768	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924769	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924770	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924771	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924772	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924773	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924774	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924775	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924776	05/2018	03/19/2018	99.970	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924777	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924778	05/2018	03/19/2018	100.040	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924779	05/2018	03/19/2018	100.040	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924780	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924781	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924782	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924783	05/2018	03/19/2018	99.990	99.950	100.1	1
LG&E	FOCUS AXRE-SD MESH	924784	05/2018	03/19/2018	99.990	100.020	100.1	1



LG&E	FOCUS AXRE-SD MESH	924785	05/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924786	05/2018	03/19/2018	100.050	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924787	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924788	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924789	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924790	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924791	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924792	05/2018	03/19/2018	100.050	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924793	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924794	05/2018	03/19/2018	100.040	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924795	05/2018	03/19/2018	99.990	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924796	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924797	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	924798	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924799	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924800	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924801	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924802	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924803	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924804	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924805	05/2018	03/19/2018	100.010	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	924806	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924807	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924808	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924809	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924810	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924811	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924812	05/2018	03/19/2018	100.030	100.040	99.9	1
LG&E	FOCUS AXRE-SD MESH	924813	05/2018	03/19/2018	100.000	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924814	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924815	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924816	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924817	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924818	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924819	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924820	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924821	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924822	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924823	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924824	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924825	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924826	05/2018	03/19/2018	100.000	100.030	100.1	1

LG&E	FOCUS AXRE-SD MESH	924827	05/2018	03/19/2018	100.010	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924828	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924829	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924830	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924831	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924832	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924833	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924834	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924835	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924836	05/2018	03/19/2018	100.000	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924837	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924838	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924839	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924840	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924841	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924842	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924843	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924844	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924845	05/2018	03/19/2018	99.990	99.960	100.0	1
LG&E	FOCUS AXRE-SD MESH	924846	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924847	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924848	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924849	05/2018	03/19/2018	99.970	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924850	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924851	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924852	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924853	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924854	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924855	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924856	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924857	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924858	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924859	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924860	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924861	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924862	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924863	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924864	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924865	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924866	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924867	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924868	05/2018	03/19/2018	100.000	100.020	100.1	1



LG&E	FOCUS AXRE-SD MESH	924869	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924870	05/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924871	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924872	05/2018	03/19/2018	100.000	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924873	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924874	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	924875	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924876	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924877	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924878	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924879	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924880	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924881	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924882	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924883	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924884	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924885	05/2018	03/19/2018	100.010	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924886	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924887	05/2018	03/19/2018	100.000	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	924888	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924889	05/2018	03/19/2018	99.960	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924890	05/2018	03/19/2018	99.970	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924891	05/2018	03/19/2018	100.040	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924892	05/2018	03/19/2018	99.970	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924893	05/2018	03/19/2018	99.970	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924894	05/2018	03/19/2018	100.040	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	924895	05/2018	03/19/2018	99.990	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924896	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924897	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924898	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924899	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924900	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924901	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924902	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924903	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924904	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924905	05/2018	03/19/2018	99.960	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924906	05/2018	03/19/2018	100.000	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924907	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924908	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924909	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924910	05/2018	03/19/2018	99.990	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	924911	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924912	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924913	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924914	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924915	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924916	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924917	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924918	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924919	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924920	05/2018	03/19/2018	100.050	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924921	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924922	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924923	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924924	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924925	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924926	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924927	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924928	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	924929	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924930	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924931	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924932	05/2018	03/19/2018	100.000	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924933	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924934	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924935	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924936	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924937	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924938	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924939	05/2018	03/19/2018	100.040	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924940	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924941	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924942	05/2018	03/19/2018	100.000	100.040	100.2	1
LG&E	FOCUS AXRE-SD MESH	924943	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924944	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924945	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924946	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924947	05/2018	03/19/2018	100.020	100.020	99.9	1
LG&E	FOCUS AXRE-SD MESH	924948	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924949	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924950	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924951	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924952	05/2018	03/19/2018	100.020	100.010	100.1	1

LG&E	FOCUS AXRE-SD MESH	924953	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924954	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924955	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924956	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924957	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	924958	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924959	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924960	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924961	05/2018	03/19/2018	100.030	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	924962	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	924963	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924964	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924965	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924966	05/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	FOCUS AXRE-SD MESH	924967	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924968	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924969	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924970	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924971	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924972	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924973	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924974	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924975	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	924976	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	924977	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924978	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924979	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	924980	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	924981	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924982	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	924983	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	924984	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924985	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924986	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	924987	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	924988	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	924989	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924990	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924991	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	924992	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924993	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	924994	05/2018	03/19/2018	100.010	100.010	100.1	1

LG&E	FOCUS AXRE-SD MESH	924995	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	924996	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	924997	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	924998	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	924999	05/2018	03/19/2018	100.000	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925000	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925001	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925002	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925003	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925004	05/2018	03/19/2018	100.030	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925005	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925006	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925007	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925008	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925009	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925010	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925011	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925012	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925013	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925014	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925015	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925016	05/2018	03/19/2018	100.010	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925017	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925018	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925019	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925020	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925021	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925022	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925023	05/2018	03/19/2018	99.960	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925024	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925025	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925026	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925027	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925028	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925029	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925030	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925031	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925032	05/2018	03/19/2018	99.970	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925033	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925034	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925035	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925036	05/2018	03/19/2018	99.990	99.990	100.1	1



LG&E	FOCUS AXRE-SD MESH	925037	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925038	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925039	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925040	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925041	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925042	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925043	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925044	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925045	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925046	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925047	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925048	05/2018	03/19/2018	100.040	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925049	05/2018	03/19/2018	99.970	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925050	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925051	05/2018	03/19/2018	100.030	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925052	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925053	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925054	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925055	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925056	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925057	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925058	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925059	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925060	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925061	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925062	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925063	05/2018	03/19/2018	100.030	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925064	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925065	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925066	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925067	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925068	05/2018	03/19/2018	100.040	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925069	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925070	05/2018	03/19/2018	99.960	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925071	05/2018	03/19/2018	100.040	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925072	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925073	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925074	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925075	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925076	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925077	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925078	05/2018	03/19/2018	100.020	100.050	100.1	1

LG&E	FOCUS AXRE-SD MESH	925079	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925080	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925081	05/2018	03/19/2018	100.040	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925082	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925083	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925084	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925085	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925086	05/2018	03/19/2018	100.030	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925087	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925088	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925089	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925090	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925091	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925092	05/2018	03/19/2018	100.040	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925093	05/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925094	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925095	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925096	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925097	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925098	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925099	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925100	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925101	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925102	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925103	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925104	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925105	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925106	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925107	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925108	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925109	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925110	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925111	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925112	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925113	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925114	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925115	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925116	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925117	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925118	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925119	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925120	05/2018	03/19/2018	99.970	99.990	100.1	1

LG&E	FOCUS AXRE-SD MESH	925121	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925122	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925123	05/2018	03/19/2018	100.020	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925124	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925125	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925126	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925127	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925128	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925129	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925130	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925131	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925132	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925133	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925134	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925135	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925136	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925137	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925138	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925139	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925140	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925141	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925142	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925143	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925144	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925145	05/2018	03/19/2018	100.030	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925146	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925147	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925148	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925149	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925150	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925151	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925152	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925153	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925154	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925155	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925156	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925157	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925158	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925159	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925160	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925161	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925162	05/2018	03/19/2018	100.000	100.040	100.1	1



LG&E	FOCUS AXRE-SD MESH	925163	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925164	05/2018	03/19/2018	100.020	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925165	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925166	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925167	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925168	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925169	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925170	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925171	05/2018	03/19/2018	99.990	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925172	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925173	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925174	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925175	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925176	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925177	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925178	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925179	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925180	05/2018	03/19/2018	100.000	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925181	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925182	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925183	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925184	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925185	05/2018	03/19/2018	100.020	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925186	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925187	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925188	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925189	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925190	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925191	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925192	05/2018	03/19/2018	100.030	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925193	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925194	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925195	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925196	05/2018	03/19/2018	100.040	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925197	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925198	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925199	05/2018	03/19/2018	100.020	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925200	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925201	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925202	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925203	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925204	05/2018	03/19/2018	100.000	100.040	100.1	1

LG&E	FOCUS AXRE-SD MESH	925205	05/2018	03/19/2018	99.960	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925206	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925207	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925208	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925209	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925210	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925211	05/2018	03/19/2018	100.010	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925212	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925213	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925214	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925215	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925216	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925217	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925218	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925219	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925220	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925221	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925222	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925223	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925224	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925225	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925226	05/2018	03/19/2018	99.980	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925227	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925228	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925229	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925230	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925231	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925232	05/2018	03/19/2018	99.960	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925233	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925234	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925235	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925236	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925237	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925238	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925239	05/2018	03/19/2018	100.020	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925240	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925241	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925242	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925243	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925244	05/2018	03/19/2018	100.010	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925245	05/2018	03/19/2018	100.040	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925246	05/2018	03/19/2018	100.010	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	925247	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925248	05/2018	03/19/2018	99.990	99.950	100.1	1
LG&E	FOCUS AXRE-SD MESH	925249	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925250	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925251	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925252	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925253	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925254	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925255	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925256	05/2018	03/19/2018	100.030	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925257	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925258	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925259	05/2018	03/19/2018	99.970	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925260	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925261	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925262	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925263	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925264	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925265	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925266	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925267	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925268	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925269	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925270	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925271	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925272	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925273	05/2018	03/19/2018	100.020	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925274	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925275	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925276	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925277	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925278	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925279	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925280	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925281	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925282	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925283	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925284	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925285	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925286	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925287	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925288	05/2018	03/19/2018	100.000	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	925289	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925290	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925291	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925292	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925293	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925294	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925295	05/2018	03/19/2018	100.010	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925296	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925297	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925298	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925299	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925300	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925301	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	925302	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925303	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925304	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925305	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925306	05/2018	03/19/2018	100.020	100.050	100.2	1
LG&E	FOCUS AXRE-SD MESH	925307	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925308	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925309	05/2018	03/19/2018	100.030	100.070	100.0	1
LG&E	FOCUS AXRE-SD MESH	925310	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925311	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925312	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925313	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925314	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925315	05/2018	03/19/2018	99.970	99.970	100.2	1
LG&E	FOCUS AXRE-SD MESH	925316	05/2018	03/19/2018	99.990	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925317	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925318	05/2018	03/19/2018	100.010	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925319	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925320	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925321	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925322	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925323	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925324	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925325	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925326	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925327	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925328	05/2018	03/19/2018	100.010	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925329	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925330	05/2018	03/19/2018	100.010	100.000	100.1	1

LG&E	FOCUS AXRE-SD MESH	925331	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925332	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925333	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925334	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925335	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925336	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925337	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925338	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925339	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925340	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925341	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925342	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925343	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925344	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925345	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925346	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925347	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925348	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925349	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925350	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925351	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925352	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925353	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925354	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925355	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925356	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925357	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925358	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925359	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925360	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925361	05/2018	03/19/2018	99.970	99.980	100.2	1
LG&E	FOCUS AXRE-SD MESH	925362	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925363	05/2018	03/19/2018	100.030	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925364	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925365	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925366	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925367	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925368	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925369	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925370	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925371	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925372	05/2018	03/19/2018	100.010	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	925373	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	925374	05/2018	03/19/2018	100.000	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925375	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925376	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925377	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925378	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925379	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925380	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925381	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925382	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925383	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925384	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925385	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925386	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925387	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925388	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925389	05/2018	03/19/2018	100.000	100.050	100.2	1
LG&E	FOCUS AXRE-SD MESH	925390	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925391	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925392	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925393	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925394	05/2018	03/19/2018	100.010	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925395	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925396	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925397	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925398	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925399	05/2018	03/19/2018	99.980	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925400	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925401	05/2018	03/19/2018	100.040	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925402	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925403	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925404	05/2018	03/19/2018	100.000	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925405	05/2018	03/19/2018	100.030	100.080	100.1	1
LG&E	FOCUS AXRE-SD MESH	925406	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925407	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925408	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925409	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925410	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925411	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925412	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925413	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925414	05/2018	03/19/2018	100.000	100.050	100.1	1



LG&E	FOCUS AXRE-SD MESH	925415	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925416	05/2018	03/19/2018	99.960	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925417	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925418	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925419	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925420	05/2018	03/19/2018	99.980	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925421	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925422	05/2018	03/19/2018	100.010	100.060	100.2	1
LG&E	FOCUS AXRE-SD MESH	925423	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925424	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925425	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925426	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925427	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925428	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925429	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925430	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925431	05/2018	03/19/2018	100.000	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	925432	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925433	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925434	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925435	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925436	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925437	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925438	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925439	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925440	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925441	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925442	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925443	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925444	05/2018	03/19/2018	100.030	100.080	100.1	1
LG&E	FOCUS AXRE-SD MESH	925445	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925446	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925447	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925448	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925449	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925450	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925451	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925452	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925453	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925454	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925455	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925456	05/2018	03/19/2018	99.990	100.010	100.0	1

LG&E	FOCUS AXRE-SD MESH	925457	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925458	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925459	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925460	05/2018	03/19/2018	99.980	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925461	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925462	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925463	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925464	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925465	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925466	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925467	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925468	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925469	05/2018	03/19/2018	100.030	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	925470	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925471	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925472	05/2018	03/19/2018	99.980	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	925473	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925474	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925475	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925476	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925477	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925478	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925479	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925480	05/2018	03/19/2018	99.980	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925481	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925482	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925483	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925484	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925485	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925486	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925487	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925488	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925489	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925490	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925491	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925492	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925493	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925494	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925495	05/2018	03/19/2018	100.010	100.060	100.2	1
LG&E	FOCUS AXRE-SD MESH	925496	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925497	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925498	05/2018	03/19/2018	99.980	99.990	100.1	1



LG&E	FOCUS AXRE-SD MESH	925499	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925500	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925501	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925502	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925503	05/2018	03/19/2018	99.980	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925504	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925505	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925506	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925507	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925508	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925509	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925510	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925511	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925512	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925513	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925514	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925515	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925516	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925517	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925518	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925519	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925520	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925521	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925522	05/2018	03/19/2018	100.020	100.070	100.0	1
LG&E	FOCUS AXRE-SD MESH	925523	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925524	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925525	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925526	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925527	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925528	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925529	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925530	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925531	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925532	05/2018	03/19/2018	100.010	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925533	05/2018	03/19/2018	99.980	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925534	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925535	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925536	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925537	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925538	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925539	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925540	05/2018	03/19/2018	99.980	99.970	100.1	1



LG&E	FOCUS AXRE-SD MESH	925541	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925542	05/2018	03/19/2018	99.980	99.980	100.2	1
LG&E	FOCUS AXRE-SD MESH	925543	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925544	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925545	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925546	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925547	05/2018	03/19/2018	100.010	100.040	100.2	1
LG&E	FOCUS AXRE-SD MESH	925548	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925549	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925550	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925551	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925552	05/2018	03/19/2018	100.000	100.060	100.0	1
LG&E	FOCUS AXRE-SD MESH	925553	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925554	05/2018	03/19/2018	100.040	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925555	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925556	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925557	05/2018	03/19/2018	100.040	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925558	05/2018	03/19/2018	100.030	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925559	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925560	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925561	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925562	05/2018	03/19/2018	99.970	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925563	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925564	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925565	05/2018	03/19/2018	99.950	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925566	05/2018	03/19/2018	99.970	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925567	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925568	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925569	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925570	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925571	05/2018	03/19/2018	99.980	99.960	100.0	1
LG&E	FOCUS AXRE-SD MESH	925572	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925573	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925574	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925575	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925576	05/2018	03/19/2018	99.990	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925577	05/2018	03/19/2018	100.030	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925578	05/2018	03/19/2018	100.030	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925579	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925580	05/2018	03/19/2018	100.020	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925581	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925582	05/2018	03/19/2018	100.000	100.010	100.1	1

LG&E	FOCUS AXRE-SD MESH	925583	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925584	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925585	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925586	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925587	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925588	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925589	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925590	05/2018	03/19/2018	100.030	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925591	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925592	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925593	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925594	05/2018	03/19/2018	99.960	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925595	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925596	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925597	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925598	05/2018	03/19/2018	99.980	99.950	100.2	1
LG&E	FOCUS AXRE-SD MESH	925599	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925600	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925601	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925602	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925603	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925604	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925605	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925606	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925607	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925608	05/2018	03/19/2018	99.990	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925609	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925610	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925611	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925612	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925613	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925614	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925615	05/2018	03/19/2018	99.980	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925616	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925617	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925618	05/2018	03/19/2018	100.000	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925619	05/2018	03/19/2018	99.990	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925620	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925621	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925622	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925623	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925624	05/2018	03/19/2018	100.040	100.010	100.1	1



LG&E	FOCUS AXRE-SD MESH	925625	05/2018	03/19/2018	99.970	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925626	05/2018	03/19/2018	99.970	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925627	05/2018	03/19/2018	99.990	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925628	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925629	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925630	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925631	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925632	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925633	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925634	05/2018	03/19/2018	100.020	100.050	100.0	1
LG&E	FOCUS AXRE-SD MESH	925635	05/2018	03/19/2018	100.010	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925636	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925637	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925638	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925639	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925640	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925641	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925642	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925643	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925644	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925645	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925646	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925647	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925648	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925649	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925650	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925651	05/2018	03/19/2018	99.980	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925652	05/2018	03/19/2018	100.010	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925653	05/2018	03/19/2018	99.970	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925654	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925655	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925656	05/2018	03/19/2018	99.970	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925657	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925658	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925659	05/2018	03/19/2018	100.040	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925660	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925661	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925662	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925663	05/2018	03/19/2018	100.030	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925664	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925665	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925666	05/2018	03/19/2018	100.000	100.020	100.1	1



LG&E	FOCUS AXRE-SD MESH	925667	05/2018	03/19/2018	100.020	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925668	05/2018	03/19/2018	99.980	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	925669	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925670	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925671	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925672	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925673	05/2018	03/19/2018	99.970	99.950	100.1	1
LG&E	FOCUS AXRE-SD MESH	925674	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925675	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925676	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925677	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925678	05/2018	03/19/2018	100.000	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925679	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925680	05/2018	03/19/2018	99.980	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925681	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925682	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925683	05/2018	03/19/2018	99.970	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925684	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925685	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925686	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925687	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925688	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925689	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925690	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925691	05/2018	03/19/2018	100.000	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925692	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925693	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925694	05/2018	03/19/2018	100.000	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925695	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925696	05/2018	03/19/2018	100.000	100.030	100.2	1
LG&E	FOCUS AXRE-SD MESH	925697	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925698	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925699	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925700	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925701	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925702	05/2018	03/19/2018	99.990	99.950	100.2	1
LG&E	FOCUS AXRE-SD MESH	925703	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925704	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925705	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925706	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925707	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925708	05/2018	03/19/2018	99.980	99.990	100.1	1

LG&E	FOCUS AXRE-SD MESH	925709	05/2018	03/19/2018	100.010	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925710	05/2018	03/19/2018	100.020	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925711	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925712	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925713	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925714	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925715	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925716	05/2018	03/19/2018	100.030	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925717	05/2018	03/19/2018	100.000	99.970	100.0	1
LG&E	FOCUS AXRE-SD MESH	925718	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925719	05/2018	03/19/2018	100.000	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925720	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925721	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925722	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925723	05/2018	03/19/2018	99.990	99.980	100.2	1
LG&E	FOCUS AXRE-SD MESH	925724	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925725	05/2018	03/19/2018	99.980	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925726	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925727	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925728	05/2018	03/19/2018	99.980	99.950	100.1	1
LG&E	FOCUS AXRE-SD MESH	925729	05/2018	03/19/2018	100.000	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925730	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925731	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925732	05/2018	03/19/2018	100.000	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925733	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925734	05/2018	03/19/2018	100.040	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925735	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925736	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925737	05/2018	03/19/2018	100.010	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925738	05/2018	03/19/2018	100.000	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925739	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925740	05/2018	03/19/2018	100.000	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925741	05/2018	03/19/2018	100.020	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925742	05/2018	03/19/2018	99.980	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925743	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925744	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925745	05/2018	03/19/2018	99.980	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925746	05/2018	03/19/2018	99.970	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925747	05/2018	03/19/2018	99.960	100.010	100.0	1
LG&E	FOCUS AXRE-SD MESH	925748	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925749	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925750	05/2018	03/19/2018	100.000	100.020	100.1	1



LG&E	FOCUS AXRE-SD MESH	925751	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925752	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925753	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925754	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925755	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925756	05/2018	03/19/2018	99.970	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925757	05/2018	03/19/2018	100.000	99.970	100.2	1
LG&E	FOCUS AXRE-SD MESH	925758	05/2018	03/19/2018	100.040	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925759	05/2018	03/19/2018	99.980	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925760	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925761	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925762	05/2018	03/19/2018	99.980	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925763	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925764	05/2018	03/19/2018	99.970	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925765	05/2018	03/19/2018	99.970	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925766	05/2018	03/19/2018	99.960	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925767	05/2018	03/19/2018	100.010	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925768	05/2018	03/19/2018	100.020	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925769	05/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	FOCUS AXRE-SD MESH	925770	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925771	05/2018	03/19/2018	99.990	99.990	100.0	1
LG&E	FOCUS AXRE-SD MESH	925772	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925773	05/2018	03/19/2018	99.980	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925774	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925775	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925776	05/2018	03/19/2018	100.020	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925777	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925778	05/2018	03/19/2018	100.000	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925779	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925780	05/2018	03/19/2018	99.980	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925781	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925782	05/2018	03/19/2018	99.990	99.990	100.2	1
LG&E	FOCUS AXRE-SD MESH	925783	05/2018	03/19/2018	100.010	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925784	05/2018	03/19/2018	100.010	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925785	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925786	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925787	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925788	05/2018	03/19/2018	99.990	99.970	100.0	1
LG&E	FOCUS AXRE-SD MESH	925789	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925790	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925791	05/2018	03/19/2018	99.990	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925792	05/2018	03/19/2018	99.980	100.000	100.0	1



LG&E	FOCUS AXRE-SD MESH	925793	05/2018	03/19/2018	100.010	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925794	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925795	05/2018	03/19/2018	99.990	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925796	05/2018	03/19/2018	99.990	100.010	100.2	1
LG&E	FOCUS AXRE-SD MESH	925797	05/2018	03/19/2018	100.000	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925798	05/2018	03/19/2018	100.020	100.040	100.0	1
LG&E	FOCUS AXRE-SD MESH	925799	05/2018	03/19/2018	100.000	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925800	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925801	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925802	05/2018	03/19/2018	100.010	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925803	05/2018	03/19/2018	99.960	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925804	05/2018	03/19/2018	100.040	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925805	05/2018	03/19/2018	100.030	100.080	100.1	1
LG&E	FOCUS AXRE-SD MESH	925806	05/2018	03/19/2018	99.970	99.970	100.1	1
LG&E	FOCUS AXRE-SD MESH	925807	05/2018	03/19/2018	100.020	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925808	05/2018	03/19/2018	100.040	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925809	05/2018	03/19/2018	100.020	100.000	100.1	1
LG&E	FOCUS AXRE-SD MESH	925810	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925811	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925812	05/2018	03/19/2018	99.990	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925813	05/2018	03/19/2018	99.990	99.980	100.0	1
LG&E	FOCUS AXRE-SD MESH	925814	05/2018	03/19/2018	100.010	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925815	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925816	05/2018	03/19/2018	100.030	100.070	100.1	1
LG&E	FOCUS AXRE-SD MESH	925817	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925818	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925819	05/2018	03/19/2018	100.020	100.050	100.1	1
LG&E	FOCUS AXRE-SD MESH	925820	05/2018	03/19/2018	100.010	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925821	05/2018	03/19/2018	100.000	100.020	100.2	1
LG&E	FOCUS AXRE-SD MESH	925822	05/2018	03/19/2018	100.000	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925823	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925824	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925825	05/2018	03/19/2018	100.000	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925826	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925827	05/2018	03/19/2018	100.010	100.020	100.0	1
LG&E	FOCUS AXRE-SD MESH	925828	05/2018	03/19/2018	100.020	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925829	05/2018	03/19/2018	100.030	100.040	100.1	1
LG&E	FOCUS AXRE-SD MESH	925830	05/2018	03/19/2018	100.020	100.010	100.1	1
LG&E	FOCUS AXRE-SD MESH	925831	05/2018	03/19/2018	99.990	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925832	05/2018	03/19/2018	99.990	99.980	100.1	1
LG&E	FOCUS AXRE-SD MESH	925833	05/2018	03/19/2018	99.990	100.000	100.0	1
LG&E	FOCUS AXRE-SD MESH	925834	05/2018	03/19/2018	100.000	100.010	100.1	1

LG&E	FOCUS AXRE-SD MESH	925835	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925836	05/2018	03/19/2018	100.000	99.990	100.1	1
LG&E	FOCUS AXRE-SD MESH	925837	05/2018	03/19/2018	99.990	100.000	100.2	1
LG&E	FOCUS AXRE-SD MESH	925838	05/2018	03/19/2018	100.030	100.060	100.1	1
LG&E	FOCUS AXRE-SD MESH	925839	05/2018	03/19/2018	100.030	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925840	05/2018	03/19/2018	100.010	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925841	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925842	05/2018	03/19/2018	100.000	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925843	05/2018	03/19/2018	99.990	100.030	100.1	1
LG&E	FOCUS AXRE-SD MESH	925844	05/2018	03/19/2018	100.000	100.030	100.0	1
LG&E	FOCUS AXRE-SD MESH	925845	05/2018	03/19/2018	99.970	99.960	100.1	1
LG&E	FOCUS AXRE-SD MESH	925846	05/2018	03/19/2018	100.040	100.020	100.1	1
LG&E	FOCUS AXRE-SD MESH	925847	05/2018	03/19/2018	100.010	100.050	100.2	1
LG&E	SS2S	923912	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923913	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923914	04/2018	02/20/2018	100.040	100.030	100.0	1
LG&E	SS2S	923915	04/2018	02/20/2018	100.040	100.040	100.1	1
LG&E	SS2S	923916	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923917	04/2018	02/20/2018	100.020	100.010	100.0	1
LG&E	SS2S	923918	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923919	04/2018	02/20/2018	100.030	100.010	100.1	1
LG&E	SS2S	923920	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923921	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923922	04/2018	02/20/2018	100.040	100.020	100.1	1
LG&E	SS2S	923923	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS2S	923924	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923925	04/2018	02/20/2018	100.040	100.030	100.1	1
LG&E	SS2S	923926	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923927	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923928	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923929	04/2018	02/20/2018	100.020	100.040	100.0	1
LG&E	SS2S	923930	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923931	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923932	04/2018	02/20/2018	100.040	100.050	100.0	1
LG&E	SS2S	923933	04/2018	02/20/2018	100.020	100.010	100.0	1
LG&E	SS2S	923934	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS2S	923935	04/2018	02/20/2018	100.030	100.030	100.1	1
LG&E	SS2S	923936	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923937	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923938	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923939	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923940	04/2018	02/20/2018	100.020	100.010	100.1	1





LG&E	SS2S	923983	04/2018	02/20/2018	100.030	100.030	100.1	1
LG&E	SS2S	923984	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923985	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923986	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923987	04/2018	02/20/2018	100.020	100.010	100.1	1
LG&E	SS2S	923988	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923989	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923990	04/2018	02/20/2018	100.030	100.010	100.1	1
LG&E	SS2S	923991	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923992	04/2018	02/20/2018	100.020	100.030	100.0	1
LG&E	SS2S	923993	04/2018	02/20/2018	100.030	100.020	100.0	1
LG&E	SS2S	923994	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923995	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS2S	923996	04/2018	02/20/2018	100.030	100.030	100.1	1
LG&E	SS2S	923997	04/2018	02/20/2018	100.030	100.020	100.1	1
LG&E	SS2S	923998	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	923999	04/2018	02/20/2018	100.040	100.010	100.1	1
LG&E	SS2S	924000	04/2018	02/20/2018	100.040	100.040	100.1	1
LG&E	SS2S	924001	04/2018	02/20/2018	100.030	100.030	100.0	1
LG&E	SS2S	924002	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS2S	924003	04/2018	02/20/2018	100.010	100.010	100.0	1
LG&E	SS2S	924004	04/2018	02/20/2018	100.020	100.020	100.1	1
LG&E	SS2S	924005	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS2S	924006	04/2018	02/20/2018	100.030	100.030	100.1	1
LG&E	SS2S	924007	04/2018	02/20/2018	100.030	100.040	100.0	1
LG&E	SS3S	924008	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924009	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924010	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924011	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924012	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924013	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924014	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924015	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924016	03/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS3S	924017	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924018	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924019	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924020	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924021	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924022	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924023	03/2018	02/12/2018	100.010	100.050	100.0	1
LG&E	SS3S	924024	03/2018	02/12/2018	100.020	100.040	100.0	1

LG&E	SS3S	924025	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924026	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924027	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924028	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924029	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924030	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924031	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924032	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924033	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924034	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924035	03/2018	02/12/2018	100.030	100.030	100.0	1
LG&E	SS3S	924036	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924037	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924038	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924039	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924040	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924041	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924042	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924043	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924044	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924045	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924046	03/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS3S	924047	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924048	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924049	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924050	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924051	03/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS3S	924052	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924053	03/2018	02/12/2018	100.030	100.050	100.0	1
LG&E	SS3S	924054	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924055	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924056	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924057	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924058	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924059	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924060	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924061	03/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS3S	924062	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924063	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924064	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924065	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924066	03/2018	02/12/2018	100.020	100.050	100.0	1

LG&E	SS3S	924067	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924068	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924069	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924070	03/2018	02/12/2018	100.000	100.010	100.0	1
LG&E	SS3S	924071	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924072	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924073	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924074	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924075	03/2018	02/12/2018	100.020	100.050	100.0	1
LG&E	SS3S	924076	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924077	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924078	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924079	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924080	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924081	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924082	03/2018	02/12/2018	100.000	100.020	100.0	1
LG&E	SS3S	924083	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924084	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924085	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924086	03/2018	02/12/2018	99.990	100.020	100.0	1
LG&E	SS3S	924087	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924088	03/2018	02/12/2018	100.020	100.060	100.0	1
LG&E	SS3S	924089	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924090	03/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS3S	924091	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924092	03/2018	02/12/2018	99.990	100.030	100.0	1
LG&E	SS3S	924093	03/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS3S	924094	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924095	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924096	03/2018	02/12/2018	100.020	100.040	100.0	1
LG&E	SS3S	924097	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924098	03/2018	02/12/2018	100.030	100.040	100.0	1
LG&E	SS3S	924099	03/2018	02/12/2018	100.010	100.040	100.0	1
LG&E	SS3S	924100	03/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS3S	924101	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS3S	924102	03/2018	02/12/2018	100.000	100.030	100.0	1
LG&E	SS3S	924103	03/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	921200	02/2018	07/21/2017	100.030	100.030	100.0	1
LG&E	SS4S	921201	02/2018	07/21/2017	100.040	100.030	100.0	1
LG&E	SS4S	921202	02/2018	07/21/2017	100.020	100.020	100.0	1
LG&E	SS4S	921203	02/2018	07/21/2017	100.030	100.030	100.0	1
LG&E	SS4S	921204	02/2018	07/21/2017	100.020	100.030	100.0	1



LG&E	SS4S	921205	02/2018	07/21/2017	100.020	100.020	100.0	1
LG&E	SS4S	921206	02/2018	07/21/2017	100.060	100.050	100.0	1
LG&E	SS4S	921207	02/2018	07/21/2017	100.040	100.040	100.0	1
LG&E	SS4S	921208	02/2018	07/21/2017	100.050	100.050	100.0	1
LG&E	SS4S	921209	02/2018	07/21/2017	100.050	100.060	100.1	1
LG&E	SS4S	921210	02/2018	07/21/2017	100.020	100.010	100.0	1
LG&E	SS4S	921211	02/2018	07/21/2017	100.020	100.020	100.0	1
LG&E	SS4S	921212	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921213	02/2018	07/21/2017	100.040	100.040	100.1	1
LG&E	SS4S	921214	02/2018	07/21/2017	100.050	100.050	100.1	1
LG&E	SS4S	921215	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921216	02/2018	07/21/2017	100.020	100.010	100.0	1
LG&E	SS4S	921217	02/2018	07/21/2017	100.040	100.040	100.0	1
LG&E	SS4S	921218	02/2018	07/21/2017	100.040	100.030	100.0	1
LG&E	SS4S	921219	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921220	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921221	02/2018	07/21/2017	100.010	100.020	100.0	1
LG&E	SS4S	921222	02/2018	07/21/2017	100.050	100.050	100.0	1
LG&E	SS4S	921223	02/2018	07/21/2017	100.020	100.050	100.0	1
LG&E	SS4S	921224	02/2018	07/21/2017	100.020	100.020	100.0	1
LG&E	SS4S	921225	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921226	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921227	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921228	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921229	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921230	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921231	02/2018	07/21/2017	100.040	100.030	100.0	1
LG&E	SS4S	921232	02/2018	07/21/2017	100.040	100.020	100.0	1
LG&E	SS4S	921233	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921234	02/2018	07/21/2017	100.030	100.020	100.0	1
LG&E	SS4S	921235	02/2018	07/21/2017	100.040	100.030	100.0	1
LG&E	SS4S	921236	02/2018	07/21/2017	100.030	100.010	100.0	1
LG&E	SS4S	921237	02/2018	07/21/2017	100.030	100.030	100.0	1
LG&E	SS4S	921238	02/2018	07/21/2017	100.020	100.020	100.0	1
LG&E	SS4S	921239	02/2018	07/21/2017	100.010	100.010	100.0	1
LG&E	SS4S	921240	02/2018	07/21/2017	100.050	100.020	100.0	1
LG&E	SS4S	921241	02/2018	07/21/2017	100.030	100.050	100.0	1
LG&E	SS4S	921242	02/2018	07/21/2017	100.020	100.010	100.0	1
LG&E	SS4S	921243	02/2018	07/21/2017	100.020	100.010	100.0	1
LG&E	SS4S	921244	02/2018	07/21/2017	100.040	100.030	100.0	1
LG&E	SS4S	921245	02/2018	07/21/2017	100.030	100.030	100.0	1
LG&E	SS4S	921246	02/2018	07/21/2017	100.020	100.030	100.0	1

LG&E	SS4S	921247	02/2018	07/21/2017	100.010	100.020	100.0	1
LG&E	SS4S	924104	06/2018	02/12/2018	100.030	100.050	100.0	1
LG&E	SS4S	924105	06/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	924106	06/2018	02/12/2018	100.030	100.030	100.0	1
LG&E	SS4S	924107	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924108	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924109	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924110	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924111	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924112	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924113	06/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	924114	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924115	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924116	06/2018	02/12/2018	100.010	100.030	100.0	1
LG&E	SS4S	924117	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924118	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924119	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924120	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924121	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924122	06/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	924123	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924124	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924125	06/2018	02/12/2018	100.030	100.030	100.0	1
LG&E	SS4S	924126	06/2018	02/12/2018	100.010	100.000	100.0	1
LG&E	SS4S	924127	06/2018	02/12/2018	100.020	100.000	100.0	1
LG&E	SS4S	924128	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924129	06/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS4S	924130	06/2018	02/12/2018	100.010	100.000	100.0	1
LG&E	SS4S	924131	06/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	924132	06/2018	02/12/2018	100.030	100.020	100.0	1
LG&E	SS4S	924133	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924134	06/2018	02/12/2018	100.000	99.990	100.0	1
LG&E	SS4S	924135	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924136	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924137	06/2018	02/12/2018	100.020	100.030	100.0	1
LG&E	SS4S	924138	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924139	06/2018	02/12/2018	100.010	99.990	100.0	1
LG&E	SS4S	924140	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924141	06/2018	02/12/2018	100.030	100.030	100.0	1
LG&E	SS4S	924142	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924143	06/2018	02/12/2018	100.030	100.030	100.0	1
LG&E	SS4S	924144	06/2018	02/12/2018	100.020	100.020	100.0	1

LG&E	SS4S	924145	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924146	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924147	06/2018	02/12/2018	100.010	100.020	100.0	1
LG&E	SS4S	924148	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924149	06/2018	02/12/2018	100.020	100.010	100.0	1
LG&E	SS4S	924150	06/2018	02/12/2018	100.020	100.020	100.0	1
LG&E	SS4S	924151	06/2018	02/12/2018	100.010	100.010	100.0	1
LG&E	SS4S	924272	04/2018	03/09/2018	100.010	100.000	100.0	1
LG&E	SS4S	924273	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924274	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924275	04/2018	03/09/2018	100.020	100.030	100.0	1
LG&E	SS4S	924276	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924277	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924278	04/2018	03/09/2018	100.030	100.020	100.0	1
LG&E	SS4S	924279	04/2018	03/09/2018	100.010	100.010	100.0	1
LG&E	SS4S	924280	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924281	04/2018	03/09/2018	100.030	100.030	100.0	1
LG&E	SS4S	924282	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924283	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924284	04/2018	03/09/2018	100.020	100.030	100.0	1
LG&E	SS4S	924285	04/2018	03/09/2018	100.000	100.010	100.0	1
LG&E	SS4S	924286	04/2018	03/09/2018	100.010	100.010	100.0	1
LG&E	SS4S	924287	04/2018	03/09/2018	100.020	100.010	100.0	1
LG&E	SS4S	924288	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924289	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924290	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924291	04/2018	03/09/2018	100.020	100.020	100.0	1
LG&E	SS4S	924292	04/2018	03/09/2018	100.030	100.030	100.0	1
LG&E	SS4S	924293	04/2018	03/09/2018	100.030	100.030	100.0	1
LG&E	SS4S	924294	04/2018	03/09/2018	100.020	100.010	100.0	1
LG&E	SS4S	924295	04/2018	03/09/2018	100.020	100.010	100.0	1

4,260



ATTACHMENT  
A

The Certified Test Results  
of all new meters

# 5040 Annual Report of LG&E

7/2018 - 12/2018

							<i>Total Meter Count: 2596</i>
<b>Company (Plant)</b>	<b>Manufacturer Model No.</b>	<b>Serial Number</b>	<b>Accepted Month &amp; Year</b>	<b>Mfg Test Date</b>	<b>As Left Full Load</b>	<b>As Left Light Load</b>	<b>As Left Power Factor</b>
LGE	Focus RXR - Mesh	891799	11/2018	10/23/2018	100	100	100.05
LGE	Focus RXR - Mesh	891800	11/2018	10/23/2018	99.97	99.97	100.01
LGE	Focus RXR - Mesh	891801	11/2018	10/23/2018	99.95	99.94	99.99
LGE	Focus RXR - Mesh	891802	11/2018	10/24/2018	99.98	99.98	100.01
LGE	Focus RXR - Mesh	891803	11/2018	10/24/2018	99.98	99.99	100.05
LGE	Focus RXR - Mesh	891804	11/2018	10/24/2018	100.01	99.96	100.05
LGE	Focus RXR - Mesh	891805	11/2018	10/23/2018	100.05	99.99	100.02
LGE	Focus RXR - Mesh	891806	11/2018	10/24/2018	100	99.99	100.08
LGE	Focus RXR - Mesh	891807	11/2018	10/24/2018	99.97	99.99	99.99
LGE	Focus RXR - Mesh	891808	11/2018	10/24/2018	100	99.96	100
LGE	Focus RXR - Mesh	891809	11/2018	10/24/2018	99.96	99.91	99.96
LGE	Focus RXR - Mesh	891810	11/2018	10/24/2018	99.99	99.95	100.02
LGE	Focus RXR - Mesh	891811	11/2018	10/24/2018	100	99.98	100.02
LGE	Focus RXR - Mesh	891812	11/2018	10/24/2018	100.03	100.01	100.04
LGE	Focus RXR - Mesh	891813	11/2018	10/24/2018	99.98	99.99	99.98
LGE	Focus RXR - Mesh	891814	11/2018	10/24/2018	100.03	100.02	100.06
LGE	Focus RXR - Mesh	891815	11/2018	10/24/2018	100	99.98	99.92
LGE	Focus RXR - Mesh	891816	11/2018	10/24/2018	100.04	100.02	100.06
LGE	Focus RXR - Mesh	891817	11/2018	10/24/2018	100.01	99.99	100.07
LGE	Focus RXR - Mesh	891818	11/2018	10/24/2018	99.98	99.99	100.05
LGE	C1S	928424	8/2018	8/7/2018	99.99	100	100.03
LGE	C1S	928425	8/2018	8/7/2018	99.98	99.99	100.04
LGE	C1S	928426	8/2018	8/7/2018	100	100	100.03
LGE	C1S	928427	8/2018	8/7/2018	99.98	99.99	100.03
LGE	C1S	928428	8/2018	8/7/2018	99.99	100.02	100.03
LGE	C1S	928429	8/2018	8/7/2018	99.99	100.03	100.01
LGE	C1S	928430	8/2018	8/7/2018	99.98	100.02	100.03
LGE	C1S	928431	8/2018	8/7/2018	99.99	100.02	100.03
LGE	C1S	928432	8/2018	8/7/2018	99.98	100.01	100.02
LGE	C1S	928433	8/2018	8/7/2018	99.99	100.03	100.03
LGE	C1S	928434	8/2018	8/7/2018	99.98	100	100.01
LGE	C1S	928435	8/2018	8/7/2018	99.99	100.05	100.08
LGE	C1S	928436	8/2018	8/7/2018	99.99	100.01	100.02
LGE	C1S	928437	8/2018	8/7/2018	99.98	100.03	100.03
LGE	C1S	928438	8/2018	8/7/2018	99.98	100	100.02

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	928439	8/2018	8/7/2018	99.99	100.02	100.05
LGE	C1S	928440	8/2018	8/7/2018	100	100.02	100.01
LGE	C1S	928441	8/2018	8/7/2018	99.99	99.99	100.02
LGE	C1S	928442	8/2018	8/7/2018	99.98	99.98	100.03
LGE	C1S	928443	8/2018	8/7/2018	99.99	100.03	100.05
LGE	C1S	928444	8/2018	8/7/2018	99.99	99.97	100
LGE	C1S	928445	8/2018	8/7/2018	99.98	99.98	100
LGE	C1S	928446	8/2018	8/7/2018	100	100	100.04
LGE	C1S	928447	8/2018	8/7/2018	99.98	99.99	100.03
LGE	C1S	928448	8/2018	8/7/2018	99.99	100.04	100.02
LGE	C1S	928449	8/2018	8/7/2018	99.99	100	100.05
LGE	C1S	928450	8/2018	8/7/2018	100	100.02	100.02
LGE	C1S	928451	8/2018	8/7/2018	100	100.02	100.04
LGE	C1S	928452	8/2018	8/7/2018	99.98	99.99	100.03
LGE	C1S	928453	8/2018	8/7/2018	100	100	100.03
LGE	C1S	928454	8/2018	8/7/2018	99.99	100.02	100.05
LGE	C1S	928455	8/2018	8/7/2018	99.98	100.01	100.04
LGE	C1S	928456	8/2018	8/7/2018	99.98	100.02	100.02
LGE	C1S	928457	8/2018	8/7/2018	99.99	100.01	100.04
LGE	C1S	928458	8/2018	8/7/2018	99.98	100.01	100.01
LGE	C1S	928459	8/2018	8/7/2018	99.98	100.02	100.01
LGE	C1S	928460	8/2018	8/7/2018	99.99	100.03	100.04
LGE	C1S	928461	8/2018	8/7/2018	99.98	100.01	100.04
LGE	C1S	928462	8/2018	8/7/2018	99.99	100	100.04
LGE	C1S	928463	8/2018	8/7/2018	99.99	100.02	100.07
LGE	C1S	928464	8/2018	8/7/2018	99.98	100.02	100.03
LGE	C1S	928465	8/2018	8/7/2018	99.99	100.02	100.04
LGE	C1S	928466	8/2018	8/7/2018	99.99	100.01	100.04
LGE	C1S	928467	8/2018	8/7/2018	100	100.03	100.05
LGE	C1S	928468	8/2018	8/7/2018	99.99	100.03	100.04
LGE	C1S	928469	8/2018	8/7/2018	99.99	99.99	100.01
LGE	C1S	928470	8/2018	8/7/2018	99.99	99.99	100.02
LGE	C1S	928471	8/2018	8/7/2018	99.98	100	100.03
LGE	C1S	928472	8/2018	8/7/2018	99.98	100.03	100.04
LGE	C1S	928473	8/2018	8/7/2018	99.98	100.01	100.04
LGE	C1S	928474	8/2018	8/7/2018	99.99	100.05	100.05
LGE	C1S	928475	8/2018	8/7/2018	99.98	100.02	100.03
LGE	C1S	928476	8/2018	8/7/2018	99.98	100.02	100.05
LGE	C1S	928477	8/2018	8/7/2018	99.98	100	100.05
LGE	C1S	928478	8/2018	8/7/2018	99.98	100.02	100.06
LGE	C1S	928479	8/2018	8/7/2018	99.99	100.04	100.07
LGE	C1S	928480	8/2018	8/7/2018	99.99	99.99	100



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	928481	8/2018	8/7/2018	100	100.01	100.03
LGE	C1S	928482	8/2018	8/7/2018	99.99	100.01	100.02
LGE	C1S	928483	8/2018	8/7/2018	99.98	99.98	100.02
LGE	C1S	928484	8/2018	8/7/2018	99.98	99.99	100.02
LGE	C1S	928485	8/2018	8/7/2018	99.98	100.01	100.06
LGE	C1S	928486	8/2018	8/7/2018	99.98	100.01	100.03
LGE	C1S	928487	8/2018	8/7/2018	99.99	100	100.03
LGE	C1S	928488	8/2018	8/7/2018	99.99	100.01	100.03
LGE	C1S	928489	8/2018	8/7/2018	100	100.03	100.06
LGE	C1S	928490	8/2018	8/7/2018	99.99	100.03	100.04
LGE	C1S	928491	8/2018	8/7/2018	99.99	100.03	100.04
LGE	C1S	928492	8/2018	8/7/2018	99.98	100	100.02
LGE	C1S	928493	8/2018	8/7/2018	99.99	100.04	100.04
LGE	C1S	928494	8/2018	8/7/2018	99.98	99.99	100.02
LGE	C1S	928495	8/2018	8/7/2018	100	100.03	100.07
LGE	C1S	928496	8/2018	8/7/2018	99.99	100	100.03
LGE	C1S	928497	8/2018	8/7/2018	99.98	100.02	100.06
LGE	C1S	928498	8/2018	8/7/2018	99.99	100.05	100.03
LGE	C1S	928499	8/2018	8/7/2018	99.99	100.02	100.05
LGE	C1S	928500	8/2018	8/7/2018	99.99	100.01	100.05
LGE	C1S	928501	8/2018	8/7/2018	99.98	100.02	100.03
LGE	C1S	928502	8/2018	8/7/2018	99.98	99.99	100.03
LGE	C1S	928503	8/2018	8/7/2018	99.99	100	100.02
LGE	C1S	928504	8/2018	8/7/2018	100	100.03	100.03
LGE	C1S	928505	8/2018	8/7/2018	99.99	99.97	100.04
LGE	C1S	928506	8/2018	8/7/2018	99.99	100.02	100.04
LGE	C1S	928507	8/2018	8/7/2018	99.98	100.02	100.03
LGE	C1S	928508	8/2018	8/7/2018	99.98	100.04	100.05
LGE	C1S	928509	8/2018	8/7/2018	99.99	100.02	100.02
LGE	C1S	928510	8/2018	8/7/2018	99.99	99.99	100.01
LGE	C1S	928511	8/2018	8/7/2018	99.99	100.01	100.05
LGE	C1S	928512	8/2018	8/7/2018	99.99	100.05	100.04
LGE	C1S	928513	8/2018	8/7/2018	99.99	100.02	100.04
LGE	C1S	928514	8/2018	8/7/2018	100	100	100.03
LGE	C1S	928515	8/2018	8/7/2018	99.99	100.01	100.04
LGE	C1S	928516	8/2018	8/7/2018	100	100	100.06
LGE	C1S	928517	8/2018	8/7/2018	99.98	100	100.03
LGE	C1S	928518	8/2018	8/7/2018	100	100.02	100.04
LGE	C1S	928519	8/2018	8/7/2018	99.99	100	100.03
LGE	C1S	929756	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	929757	10/2018	10/12/2018	100.02	99.98	99.94
LGE	C1S	929758	10/2018	10/12/2018	100	100.04	99.92

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929759	10/2018	10/12/2018	100	99.99	99.97
LGE	C1S	929760	10/2018	10/12/2018	100.01	100.02	99.94
LGE	C1S	929761	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	929762	10/2018	10/12/2018	100.02	100.06	99.96
LGE	C1S	929763	10/2018	10/12/2018	100.01	100.07	100.02
LGE	C1S	929764	10/2018	10/12/2018	100.01	99.98	99.96
LGE	C1S	929765	10/2018	10/12/2018	100.01	100.04	99.99
LGE	C1S	929766	10/2018	10/12/2018	100.02	100.01	99.99
LGE	C1S	929767	10/2018	10/12/2018	99.98	100.01	99.98
LGE	C1S	929768	10/2018	10/12/2018	100.01	100.01	100.01
LGE	C1S	929769	10/2018	10/12/2018	99.99	100.04	99.95
LGE	C1S	929770	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	929771	10/2018	10/12/2018	99.99	99.98	99.93
LGE	C1S	929772	10/2018	10/12/2018	100	100.04	100.2
LGE	C1S	929773	10/2018	10/12/2018	100.01	100.03	99.96
LGE	C1S	929774	10/2018	10/12/2018	99.99	100.04	99.95
LGE	C1S	929775	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	929776	10/2018	10/12/2018	99.99	100.04	99.96
LGE	C1S	929777	10/2018	10/12/2018	100	100	99.92
LGE	C1S	929778	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	929779	10/2018	10/12/2018	99.97	100.02	99.96
LGE	C1S	929780	10/2018	10/12/2018	99.99	99.98	99.95
LGE	C1S	929781	10/2018	10/12/2018	99.98	100.03	99.96
LGE	C1S	929782	10/2018	10/12/2018	100	99.99	99.9
LGE	C1S	929783	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	929784	10/2018	10/12/2018	100.01	100	99.95
LGE	C1S	929785	10/2018	10/12/2018	100.01	100.02	99.99
LGE	C1S	929786	10/2018	10/12/2018	100.02	100.03	99.96
LGE	C1S	929787	10/2018	10/12/2018	99.98	100.02	99.97
LGE	C1S	929788	10/2018	10/12/2018	99.99	100.01	99.96
LGE	C1S	929789	10/2018	10/12/2018	100.02	100.04	99.95
LGE	C1S	929790	10/2018	10/12/2018	100	100.05	99.93
LGE	C1S	929791	10/2018	10/12/2018	99.99	99.96	99.98
LGE	C1S	929792	10/2018	10/12/2018	99.98	100.03	99.94
LGE	C1S	929793	10/2018	10/12/2018	100	100.01	99.97
LGE	C1S	929794	10/2018	10/12/2018	100.01	99.99	99.98
LGE	C1S	929795	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	929796	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	929797	10/2018	10/12/2018	99.98	99.99	99.96
LGE	C1S	929798	10/2018	10/12/2018	100.01	100.07	99.97
LGE	C1S	929799	10/2018	10/12/2018	100.02	99.99	99.93
LGE	C1S	929800	10/2018	10/12/2018	100.01	100.01	100.01

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929801	10/2018	10/12/2018	100.01	99.97	99.97
LGE	C1S	929802	10/2018	10/12/2018	99.97	99.97	99.92
LGE	C1S	929803	10/2018	10/12/2018	100.03	100.04	99.97
LGE	C1S	929804	10/2018	10/12/2018	100.02	100.06	99.97
LGE	C1S	929805	10/2018	10/12/2018	100.04	99.99	99.96
LGE	C1S	929806	10/2018	10/12/2018	99.98	100.02	99.98
LGE	C1S	929807	10/2018	10/12/2018	99.99	100	99.95
LGE	C1S	929808	10/2018	10/12/2018	100.01	99.98	99.93
LGE	C1S	929809	10/2018	10/12/2018	100	100.02	99.99
LGE	C1S	929810	10/2018	10/12/2018	100	99.95	99.98
LGE	C1S	929811	10/2018	10/12/2018	100.05	99.98	99.92
LGE	C1S	929812	10/2018	10/12/2018	99.98	100.01	99.86
LGE	C1S	929813	10/2018	10/12/2018	100	99.99	99.9
LGE	C1S	929814	10/2018	10/12/2018	99.99	100.06	100
LGE	C1S	929815	10/2018	10/12/2018	100.01	100	99.98
LGE	C1S	929816	10/2018	10/12/2018	99.99	100.03	99.98
LGE	C1S	929817	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	929818	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	929819	10/2018	10/12/2018	99.97	99.99	99.97
LGE	C1S	929820	10/2018	10/12/2018	100	100.01	99.94
LGE	C1S	929821	10/2018	10/12/2018	99.97	100.01	99.98
LGE	C1S	929822	10/2018	10/12/2018	99.99	99.99	99.94
LGE	C1S	929823	10/2018	10/12/2018	99.98	99.99	99.98
LGE	C1S	929824	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	929825	10/2018	10/12/2018	100	100.04	99.96
LGE	C1S	929826	10/2018	10/12/2018	100.03	100.03	99.99
LGE	C1S	929827	10/2018	10/12/2018	99.99	100.02	99.93
LGE	C1S	929828	10/2018	10/12/2018	99.97	100.02	99.95
LGE	C1S	929829	10/2018	10/12/2018	100.02	99.99	99.95
LGE	C1S	929830	10/2018	10/12/2018	100	100	99.92
LGE	C1S	929831	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	929832	10/2018	10/12/2018	100.01	100.06	100.03
LGE	C1S	929833	10/2018	10/12/2018	100.01	100	99.92
LGE	C1S	929834	10/2018	10/12/2018	99.98	100.04	100.01
LGE	C1S	929835	10/2018	10/12/2018	99.98	100	99.95
LGE	C1S	929836	10/2018	10/12/2018	99.98	99.98	99.94
LGE	C1S	929837	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	929838	10/2018	10/12/2018	100.02	100.02	99.9
LGE	C1S	929839	10/2018	10/12/2018	100	100.04	99.99
LGE	C1S	929840	10/2018	10/12/2018	99.98	99.97	99.97
LGE	C1S	929841	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	929842	10/2018	10/12/2018	100.01	100.02	99.92



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929843	10/2018	10/12/2018	100	100.05	99.95
LGE	C1S	929844	10/2018	10/12/2018	100	100.06	100.01
LGE	C1S	929845	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	929846	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	929847	10/2018	10/12/2018	100.03	100	99.97
LGE	C1S	929848	10/2018	10/12/2018	99.99	99.93	99.96
LGE	C1S	929849	10/2018	10/12/2018	100	100.04	99.96
LGE	C1S	929850	10/2018	10/12/2018	100.02	100.01	99.97
LGE	C1S	929851	10/2018	10/12/2018	100	100.04	99.97
LGE	C1S	929852	10/2018	10/12/2018	99.96	100.03	99.97
LGE	C1S	929853	10/2018	10/12/2018	99.98	100.04	99.99
LGE	C1S	929854	10/2018	10/12/2018	100	100.01	99.97
LGE	C1S	929855	10/2018	10/12/2018	99.98	100.04	99.98
LGE	C1S	929856	10/2018	10/12/2018	99.95	100.05	99.99
LGE	C1S	929857	10/2018	10/12/2018	100.02	100.02	99.94
LGE	C1S	929858	10/2018	10/12/2018	99.99	100.02	99.94
LGE	C1S	929859	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	929860	10/2018	10/12/2018	100.01	100	99.94
LGE	C1S	929861	10/2018	10/12/2018	99.95	100.04	100.01
LGE	C1S	929862	10/2018	10/12/2018	100.02	99.99	99.96
LGE	C1S	929863	10/2018	10/12/2018	100	100.01	99.95
LGE	C1S	929864	10/2018	10/12/2018	99.97	100.03	99.96
LGE	C1S	929865	10/2018	10/12/2018	100	100.03	99.97
LGE	C1S	929866	10/2018	10/12/2018	100	100.03	100
LGE	C1S	929867	10/2018	10/12/2018	99.96	100	99.95
LGE	C1S	929868	10/2018	10/12/2018	100.02	100.05	99.98
LGE	C1S	929869	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	929870	10/2018	10/12/2018	99.97	99.99	99.94
LGE	C1S	929871	10/2018	10/12/2018	99.98	100.01	99.96
LGE	C1S	929872	10/2018	10/12/2018	100.01	100.06	99.97
LGE	C1S	929873	10/2018	10/12/2018	100	100.02	99.96
LGE	C1S	929874	10/2018	10/12/2018	99.99	100.02	99.91
LGE	C1S	929875	10/2018	10/12/2018	99.99	100.03	99.96
LGE	C1S	929876	10/2018	10/12/2018	100	100.01	99.96
LGE	C1S	929877	10/2018	10/12/2018	99.98	100.02	99.88
LGE	C1S	929878	10/2018	10/12/2018	100.04	100.03	99.93
LGE	C1S	929879	10/2018	10/12/2018	100	99.99	99.93
LGE	C1S	929880	10/2018	10/12/2018	100.02	99.97	99.92
LGE	C1S	929881	10/2018	10/12/2018	99.97	100	99.94
LGE	C1S	929882	10/2018	10/12/2018	100.03	100.01	99.93
LGE	C1S	929883	10/2018	10/12/2018	100.02	100.02	99.9
LGE	C1S	929884	10/2018	10/12/2018	99.99	100.03	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929885	10/2018	10/12/2018	99.99	99.99	99.89
LGE	C1S	929886	10/2018	10/12/2018	99.98	100.07	99.99
LGE	C1S	929887	10/2018	10/12/2018	99.98	100.05	99.98
LGE	C1S	929888	10/2018	10/12/2018	100.02	100	99.87
LGE	C1S	929889	10/2018	10/12/2018	99.93	100.08	100.01
LGE	C1S	929890	10/2018	10/12/2018	99.98	100.04	99.93
LGE	C1S	929891	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	929892	10/2018	10/12/2018	99.99	100.04	99.98
LGE	C1S	929893	10/2018	10/12/2018	100	100.04	99.97
LGE	C1S	929894	10/2018	10/12/2018	99.98	100	99.93
LGE	C1S	929895	10/2018	10/12/2018	99.97	100	99.95
LGE	C1S	929896	10/2018	10/12/2018	99.99	100	99.9
LGE	C1S	929897	10/2018	10/12/2018	99.97	100.04	99.96
LGE	C1S	929898	10/2018	10/12/2018	100.02	100.04	99.99
LGE	C1S	929899	10/2018	10/12/2018	100.01	100.03	99.9
LGE	C1S	929900	10/2018	10/12/2018	99.99	100.01	99.94
LGE	C1S	929901	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	929902	10/2018	10/12/2018	100	100.02	99.89
LGE	C1S	929903	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	929904	10/2018	10/12/2018	99.99	100.01	99.93
LGE	C1S	929905	10/2018	10/12/2018	100.02	100.05	99.99
LGE	C1S	929906	10/2018	10/12/2018	99.99	100.03	99.96
LGE	C1S	929907	10/2018	10/12/2018	100	100.03	99.96
LGE	C1S	929908	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	929909	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	929910	10/2018	10/12/2018	99.98	100.02	99.96
LGE	C1S	929911	10/2018	10/12/2018	100	100.01	99.87
LGE	C1S	929912	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	929913	10/2018	10/12/2018	99.99	100	99.93
LGE	C1S	929914	10/2018	10/12/2018	100.01	100.04	99.89
LGE	C1S	929915	10/2018	10/12/2018	99.98	100.05	99.97
LGE	C1S	929916	10/2018	10/12/2018	100.02	100.02	99.94
LGE	C1S	929917	10/2018	10/12/2018	99.98	100.05	100
LGE	C1S	929918	10/2018	10/12/2018	100	100.03	99.94
LGE	C1S	929919	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	929920	10/2018	10/12/2018	100	100.05	99.99
LGE	C1S	929921	10/2018	10/12/2018	100	100.03	99.95
LGE	C1S	929922	10/2018	10/12/2018	100.04	100.02	99.98
LGE	C1S	929923	10/2018	10/12/2018	99.99	100.07	99.98
LGE	C1S	929924	10/2018	10/12/2018	100.01	100.05	100
LGE	C1S	929925	10/2018	10/12/2018	99.99	100.07	99.99
LGE	C1S	929926	10/2018	10/12/2018	100	100.05	99.97

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929927	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	929928	10/2018	10/12/2018	99.99	99.95	99.94
LGE	C1S	929929	10/2018	10/12/2018	100.03	100.07	99.97
LGE	C1S	929930	10/2018	10/12/2018	99.98	100.07	100.01
LGE	C1S	929931	10/2018	10/12/2018	100.02	100.05	99.95
LGE	C1S	929932	10/2018	10/12/2018	100.02	100.04	99.93
LGE	C1S	929933	10/2018	10/12/2018	99.99	100.08	99.98
LGE	C1S	929934	10/2018	10/12/2018	100.03	100.05	99.99
LGE	C1S	929935	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	929936	10/2018	10/12/2018	99.97	100.05	99.97
LGE	C1S	929937	10/2018	10/12/2018	99.99	99.94	99.91
LGE	C1S	929938	10/2018	10/12/2018	99.99	99.97	99.96
LGE	C1S	929939	10/2018	10/12/2018	99.99	100.02	99.94
LGE	C1S	929940	10/2018	10/12/2018	100.01	100.04	99.95
LGE	C1S	929941	10/2018	10/12/2018	99.98	100.1	99.98
LGE	C1S	929942	10/2018	10/12/2018	100.01	100.02	99.91
LGE	C1S	929943	10/2018	10/12/2018	100.02	100.06	100
LGE	C1S	929944	10/2018	10/12/2018	100.01	99.99	99.92
LGE	C1S	929945	10/2018	10/12/2018	100.06	100.05	99.96
LGE	C1S	929946	10/2018	10/12/2018	100.02	100.03	100.02
LGE	C1S	929947	10/2018	10/12/2018	100.04	100.06	99.97
LGE	C1S	929948	10/2018	10/12/2018	99.99	100.04	99.91
LGE	C1S	929949	10/2018	10/12/2018	99.96	100.07	99.97
LGE	C1S	929950	10/2018	10/12/2018	99.98	100	99.96
LGE	C1S	929951	10/2018	10/12/2018	100	100.04	100.01
LGE	C1S	929952	10/2018	10/12/2018	99.97	100.05	99.97
LGE	C1S	929953	10/2018	10/12/2018	99.99	100.04	99.99
LGE	C1S	929954	10/2018	10/12/2018	99.98	100.06	100.01
LGE	C1S	929955	10/2018	10/12/2018	100.03	100.01	99.91
LGE	C1S	929956	10/2018	10/12/2018	100	100.06	99.97
LGE	C1S	929957	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	929958	10/2018	10/12/2018	99.97	100.06	100.02
LGE	C1S	929959	10/2018	10/12/2018	100	100	99.97
LGE	C1S	929960	10/2018	10/12/2018	100.01	100.01	99.91
LGE	C1S	929961	10/2018	10/12/2018	100.01	99.98	99.87
LGE	C1S	929962	10/2018	10/12/2018	100.01	100.01	99.91
LGE	C1S	929963	10/2018	10/12/2018	100.02	100.05	99.99
LGE	C1S	929964	10/2018	10/12/2018	99.99	100.1	100.01
LGE	C1S	929965	10/2018	10/12/2018	99.99	100.07	99.98
LGE	C1S	929966	10/2018	10/12/2018	99.99	100.05	100
LGE	C1S	929967	10/2018	10/12/2018	99.96	100.07	99.97
LGE	C1S	929968	10/2018	10/12/2018	100.07	100.04	99.95



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	929969	10/2018	10/12/2018	99.96	100.06	99.98
LGE	C1S	929970	10/2018	10/12/2018	99.97	100.03	99.91
LGE	C1S	929971	10/2018	10/12/2018	100.02	100	99.92
LGE	C1S	929972	10/2018	10/12/2018	99.96	100	99.92
LGE	C1S	929973	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	929974	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	929975	10/2018	10/12/2018	99.99	100.02	99.95
LGE	C1S	929976	10/2018	10/12/2018	100.04	99.99	99.93
LGE	C1S	929977	10/2018	10/12/2018	100	100.03	99.93
LGE	C1S	929978	10/2018	10/12/2018	100.01	100.05	100.02
LGE	C1S	929979	10/2018	10/12/2018	99.95	100.03	99.94
LGE	C1S	929980	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	929981	10/2018	10/12/2018	99.99	100.04	99.95
LGE	C1S	929982	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	929983	10/2018	10/12/2018	100.01	100.03	99.94
LGE	C1S	929984	10/2018	10/12/2018	100	100.06	99.99
LGE	C1S	929985	10/2018	10/12/2018	99.99	99.99	99.92
LGE	C1S	929986	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	929987	10/2018	10/12/2018	100.01	100.01	99.91
LGE	C1S	929988	10/2018	10/12/2018	100	100.05	99.96
LGE	C1S	929989	10/2018	10/12/2018	100.01	100.03	99.96
LGE	C1S	929990	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	929991	10/2018	10/12/2018	99.98	100.08	99.93
LGE	C1S	929992	10/2018	10/12/2018	100.01	100.02	99.97
LGE	C1S	929993	10/2018	10/12/2018	99.99	99.98	99.88
LGE	C1S	929994	10/2018	10/12/2018	100	100.07	99.97
LGE	C1S	929995	10/2018	10/12/2018	99.98	100.01	99.92
LGE	C1S	929996	10/2018	10/12/2018	100.01	100.05	99.96
LGE	C1S	929997	10/2018	10/12/2018	99.99	100.05	99.95
LGE	C1S	929998	10/2018	10/12/2018	100.04	100	99.92
LGE	C1S	929999	10/2018	10/12/2018	100	100.05	99.97
LGE	C1S	930000	10/2018	10/12/2018	99.96	100	99.94
LGE	C1S	930001	10/2018	10/12/2018	100.02	99.99	99.98
LGE	C1S	930002	10/2018	10/12/2018	100.01	100.01	99.97
LGE	C1S	930003	10/2018	10/12/2018	100.02	100.06	99.99
LGE	C1S	930004	10/2018	10/12/2018	100	100.05	99.94
LGE	C1S	930005	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930006	10/2018	10/12/2018	100.01	100.01	99.96
LGE	C1S	930007	10/2018	10/12/2018	99.99	99.99	99.9
LGE	C1S	930008	10/2018	10/12/2018	99.95	99.97	99.87
LGE	C1S	930009	10/2018	10/12/2018	100	99.98	99.92
LGE	C1S	930010	10/2018	10/12/2018	99.99	100.01	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930011	10/2018	10/12/2018	100	100.03	99.97
LGE	C1S	930012	10/2018	10/12/2018	100.01	100.07	100
LGE	C1S	930013	10/2018	10/12/2018	99.97	100.04	99.94
LGE	C1S	930014	10/2018	10/12/2018	99.96	100.01	99.96
LGE	C1S	930015	10/2018	10/12/2018	99.96	100.08	99.99
LGE	C1S	930016	10/2018	10/12/2018	100.02	100.03	100
LGE	C1S	930017	10/2018	10/12/2018	100	100.03	99.95
LGE	C1S	930018	10/2018	10/12/2018	100	100.09	100.01
LGE	C1S	930019	10/2018	10/12/2018	100.01	100.1	100
LGE	C1S	930020	10/2018	10/12/2018	100	100.04	99.97
LGE	C1S	930021	10/2018	10/12/2018	100.01	100.01	99.92
LGE	C1S	930022	10/2018	10/12/2018	99.98	100.05	99.98
LGE	C1S	930023	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	930024	10/2018	10/12/2018	100	100.07	99.96
LGE	C1S	930025	10/2018	10/12/2018	100.01	99.99	99.91
LGE	C1S	930026	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930027	10/2018	10/12/2018	99.99	100.02	99.9
LGE	C1S	930028	10/2018	10/12/2018	100	99.99	99.98
LGE	C1S	930029	10/2018	10/12/2018	99.99	100	99.9
LGE	C1S	930030	10/2018	10/12/2018	99.97	100.06	99.98
LGE	C1S	930031	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930032	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	930033	10/2018	10/12/2018	100.04	100.01	99.9
LGE	C1S	930034	10/2018	10/12/2018	100.02	100.01	99.94
LGE	C1S	930035	10/2018	10/12/2018	99.99	100.04	99.97
LGE	C1S	930036	10/2018	10/12/2018	99.98	100.01	99.91
LGE	C1S	930037	10/2018	10/12/2018	99.99	100	99.9
LGE	C1S	930038	10/2018	10/12/2018	100	100.03	99.93
LGE	C1S	930039	10/2018	10/12/2018	99.96	100.05	99.98
LGE	C1S	930040	10/2018	10/12/2018	99.99	100	99.94
LGE	C1S	930041	10/2018	10/12/2018	100	100.01	100
LGE	C1S	930042	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	930043	10/2018	10/12/2018	100	100.01	99.97
LGE	C1S	930044	10/2018	10/12/2018	100	100.03	99.93
LGE	C1S	930045	10/2018	10/12/2018	99.99	100.03	99.91
LGE	C1S	930046	10/2018	10/12/2018	99.99	100.04	99.94
LGE	C1S	930047	10/2018	10/12/2018	99.97	99.99	99.9
LGE	C1S	930048	10/2018	10/12/2018	100.01	99.98	99.94
LGE	C1S	930049	10/2018	10/12/2018	100.02	99.98	99.9
LGE	C1S	930050	10/2018	10/12/2018	100.04	100	99.94
LGE	C1S	930051	10/2018	10/12/2018	100.04	100.06	100.01
LGE	C1S	930052	10/2018	10/12/2018	100.01	100	99.9

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930053	10/2018	10/12/2018	100	100.06	99.99
LGE	C1S	930054	10/2018	10/12/2018	99.98	100.03	99.94
LGE	C1S	930055	10/2018	10/12/2018	100.02	100.05	99.96
LGE	C1S	930056	10/2018	10/12/2018	99.97	100.03	99.94
LGE	C1S	930057	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	930058	10/2018	10/12/2018	100	100.01	99.9
LGE	C1S	930059	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	930060	10/2018	10/12/2018	100.01	100.04	99.99
LGE	C1S	930061	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	930062	10/2018	10/12/2018	100	100.02	99.95
LGE	C1S	930063	10/2018	10/12/2018	100.01	100.01	99.91
LGE	C1S	930064	10/2018	10/12/2018	99.98	100.03	99.99
LGE	C1S	930065	10/2018	10/12/2018	100.02	100.04	99.96
LGE	C1S	930066	10/2018	10/12/2018	100	100	99.89
LGE	C1S	930067	10/2018	10/12/2018	99.98	100.03	99.92
LGE	C1S	930068	10/2018	10/12/2018	99.95	100.07	99.99
LGE	C1S	930069	10/2018	10/12/2018	99.99	100.05	99.94
LGE	C1S	930070	10/2018	10/12/2018	100	100.01	99.92
LGE	C1S	930071	10/2018	10/12/2018	99.97	100.01	99.9
LGE	C1S	930072	10/2018	10/12/2018	100	100.05	99.99
LGE	C1S	930073	10/2018	10/12/2018	99.99	100.03	99.97
LGE	C1S	930074	10/2018	10/12/2018	100.01	100.03	99.96
LGE	C1S	930075	10/2018	10/12/2018	99.97	100.02	99.94
LGE	C1S	930076	10/2018	10/12/2018	100.02	100	99.91
LGE	C1S	930077	10/2018	10/12/2018	99.97	100.03	99.97
LGE	C1S	930078	10/2018	10/12/2018	100.02	100.01	99.89
LGE	C1S	930079	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	930080	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	930081	10/2018	10/12/2018	100.01	99.99	99.9
LGE	C1S	930082	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	930083	10/2018	10/12/2018	100.02	100.04	99.96
LGE	C1S	930084	10/2018	10/12/2018	100.02	100	99.92
LGE	C1S	930085	10/2018	10/12/2018	100.01	99.99	99.9
LGE	C1S	930086	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	930087	10/2018	10/12/2018	99.98	99.99	99.9
LGE	C1S	930088	10/2018	10/12/2018	100	100	99.95
LGE	C1S	930089	10/2018	10/12/2018	99.99	99.99	99.9
LGE	C1S	930090	10/2018	10/12/2018	100.01	99.99	99.89
LGE	C1S	930091	10/2018	10/12/2018	100	100.04	99.91
LGE	C1S	930092	10/2018	10/12/2018	100.01	100.06	99.99
LGE	C1S	930093	10/2018	10/12/2018	99.99	99.99	99.97
LGE	C1S	930094	10/2018	10/12/2018	99.99	100.02	99.95



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930095	10/2018	10/12/2018	100.03	100.02	99.97
LGE	C1S	930096	10/2018	10/12/2018	99.99	100.05	100
LGE	C1S	930097	10/2018	10/12/2018	99.99	100	99.91
LGE	C1S	930098	10/2018	10/12/2018	99.99	100.05	99.99
LGE	C1S	930099	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	930100	10/2018	10/12/2018	100	100.02	99.9
LGE	C1S	930101	10/2018	10/12/2018	100.02	100	99.95
LGE	C1S	930102	10/2018	10/12/2018	100	100.01	99.88
LGE	C1S	930103	10/2018	10/12/2018	100.02	100.02	99.92
LGE	C1S	930104	10/2018	10/12/2018	100	100	99.92
LGE	C1S	930105	10/2018	10/12/2018	100.03	100.02	99.92
LGE	C1S	930106	10/2018	10/12/2018	99.99	100.05	99.99
LGE	C1S	930107	10/2018	10/12/2018	100.02	100.05	99.96
LGE	C1S	930108	10/2018	10/12/2018	100.03	100.03	99.93
LGE	C1S	930109	10/2018	10/12/2018	100	100.02	99.96
LGE	C1S	930110	10/2018	10/12/2018	100	100	99.93
LGE	C1S	930111	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	930112	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930113	10/2018	10/12/2018	100	100	99.9
LGE	C1S	930114	10/2018	10/12/2018	100.03	100.02	99.91
LGE	C1S	930115	10/2018	10/12/2018	100	100.04	100
LGE	C1S	930116	10/2018	10/12/2018	100.02	100.01	99.97
LGE	C1S	930117	10/2018	10/12/2018	99.97	100.02	99.96
LGE	C1S	930118	10/2018	10/12/2018	100	99.99	99.92
LGE	C1S	930119	10/2018	10/12/2018	99.99	100.01	99.89
LGE	C1S	930120	10/2018	10/12/2018	99.97	100.08	99.95
LGE	C1S	930121	10/2018	10/12/2018	99.99	100.04	99.96
LGE	C1S	930122	10/2018	10/12/2018	100	100.02	99.96
LGE	C1S	930123	10/2018	10/12/2018	100.03	100.03	99.94
LGE	C1S	930124	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930125	10/2018	10/12/2018	99.98	100.02	99.93
LGE	C1S	930126	10/2018	10/12/2018	100.02	100.06	100.01
LGE	C1S	930127	10/2018	10/12/2018	100	100.01	99.91
LGE	C1S	930128	10/2018	10/12/2018	99.97	100.02	99.95
LGE	C1S	930129	10/2018	10/12/2018	99.99	99.98	99.92
LGE	C1S	930130	10/2018	10/12/2018	99.99	100.02	99.97
LGE	C1S	930131	10/2018	10/12/2018	100	100	99.89
LGE	C1S	930132	10/2018	10/12/2018	100	100.02	99.92
LGE	C1S	930133	10/2018	10/12/2018	99.99	99.99	99.89
LGE	C1S	930134	10/2018	10/12/2018	100	100.01	99.92
LGE	C1S	930135	10/2018	10/12/2018	100	100.01	99.91
LGE	C1S	930136	10/2018	10/12/2018	100.05	100.06	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930137	10/2018	10/12/2018	100	100.04	99.93
LGE	C1S	930138	10/2018	10/12/2018	100.01	100.03	100
LGE	C1S	930139	10/2018	10/12/2018	100.02	99.99	99.95
LGE	C1S	930140	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	930141	10/2018	10/12/2018	100.02	99.98	99.9
LGE	C1S	930142	10/2018	10/12/2018	99.97	100.03	99.94
LGE	C1S	930143	10/2018	10/12/2018	100.01	99.97	99.92
LGE	C1S	930144	10/2018	10/12/2018	100.01	100	99.91
LGE	C1S	930145	10/2018	10/12/2018	99.98	100.03	99.93
LGE	C1S	930146	10/2018	10/12/2018	99.99	100.01	99.9
LGE	C1S	930147	10/2018	10/12/2018	100	100.04	99.96
LGE	C1S	930148	10/2018	10/12/2018	99.98	100.01	99.86
LGE	C1S	930149	10/2018	10/12/2018	100.02	100.03	99.94
LGE	C1S	930150	10/2018	10/12/2018	100.02	100.02	99.96
LGE	C1S	930151	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	930152	10/2018	10/12/2018	100.01	100.05	99.95
LGE	C1S	930153	10/2018	10/12/2018	100	99.99	99.93
LGE	C1S	930154	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	930155	10/2018	10/12/2018	100	100.01	99.94
LGE	C1S	930156	10/2018	10/12/2018	100.02	100.01	100
LGE	C1S	930157	10/2018	10/12/2018	100.04	100.03	99.95
LGE	C1S	930158	10/2018	10/12/2018	99.98	100.03	99.92
LGE	C1S	930159	10/2018	10/12/2018	100	100.05	99.97
LGE	C1S	930160	10/2018	10/12/2018	100.01	100.03	99.93
LGE	C1S	930161	10/2018	10/12/2018	99.97	100.02	99.95
LGE	C1S	930162	10/2018	10/12/2018	99.95	100.06	99.94
LGE	C1S	930163	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	930164	10/2018	10/12/2018	100.01	100.02	99.94
LGE	C1S	930165	10/2018	10/12/2018	100	100.04	99.91
LGE	C1S	930166	10/2018	10/12/2018	100.02	100.05	99.92
LGE	C1S	930167	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	930168	10/2018	10/12/2018	99.99	99.97	99.93
LGE	C1S	930169	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930170	10/2018	10/12/2018	99.96	100.04	99.96
LGE	C1S	930171	10/2018	10/12/2018	99.97	100.03	99.98
LGE	C1S	930172	10/2018	10/12/2018	99.98	100.04	99.99
LGE	C1S	930173	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	930174	10/2018	10/12/2018	100.01	99.99	99.88
LGE	C1S	930175	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	930176	10/2018	10/12/2018	99.98	100.01	99.94
LGE	C1S	930177	10/2018	10/12/2018	100.02	100.02	99.93
LGE	C1S	930178	10/2018	10/12/2018	100.02	100.06	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930179	10/2018	10/12/2018	100.01	100	99.92
LGE	C1S	930180	10/2018	10/12/2018	100.02	100.04	99.94
LGE	C1S	930181	10/2018	10/12/2018	99.97	100.04	99.97
LGE	C1S	930182	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	930183	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	930184	10/2018	10/12/2018	100.01	100.02	99.94
LGE	C1S	930185	10/2018	10/12/2018	99.96	100.01	99.91
LGE	C1S	930186	10/2018	10/12/2018	99.99	100.03	99.91
LGE	C1S	930187	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	930188	10/2018	10/12/2018	100.01	100.03	99.94
LGE	C1S	930189	10/2018	10/12/2018	100	100	99.91
LGE	C1S	930190	10/2018	10/12/2018	100.03	100.04	99.98
LGE	C1S	930191	10/2018	10/12/2018	100.01	99.98	99.97
LGE	C1S	930192	10/2018	10/12/2018	99.96	99.99	99.93
LGE	C1S	930193	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	930194	10/2018	10/12/2018	99.99	100.01	99.93
LGE	C1S	930195	10/2018	10/12/2018	99.95	99.99	99.89
LGE	C1S	930196	10/2018	10/12/2018	99.98	100.02	99.94
LGE	C1S	930197	10/2018	10/12/2018	100	100.02	99.94
LGE	C1S	930198	10/2018	10/12/2018	99.98	100.02	99.92
LGE	C1S	930199	10/2018	10/12/2018	99.97	100.05	99.96
LGE	C1S	930200	10/2018	10/12/2018	100.01	100.05	99.96
LGE	C1S	930201	10/2018	10/12/2018	100	100.03	99.93
LGE	C1S	930202	10/2018	10/12/2018	100.01	100.04	99.94
LGE	C1S	930203	10/2018	10/12/2018	99.98	100.04	99.92
LGE	C1S	930204	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	930205	10/2018	10/12/2018	99.97	100.06	99.95
LGE	C1S	930206	10/2018	10/12/2018	99.98	100.05	99.96
LGE	C1S	930207	10/2018	10/12/2018	100.01	100.02	99.91
LGE	C1S	930208	10/2018	10/12/2018	100.02	100	99.92
LGE	C1S	930209	10/2018	10/12/2018	99.99	100.03	99.92
LGE	C1S	930210	10/2018	10/12/2018	100.03	100	99.96
LGE	C1S	930211	10/2018	10/12/2018	99.99	100.03	99.95
LGE	C1S	930212	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	930213	10/2018	10/12/2018	100	100	99.91
LGE	C1S	930214	10/2018	10/12/2018	100.05	100.04	99.96
LGE	C1S	930215	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	930216	10/2018	10/12/2018	100	100.06	99.97
LGE	C1S	930217	10/2018	10/12/2018	100.01	100	99.96
LGE	C1S	930218	10/2018	10/12/2018	100.01	100.04	99.94
LGE	C1S	930219	10/2018	10/12/2018	100.01	100.03	99.94
LGE	C1S	930220	10/2018	10/12/2018	99.95	100	99.91



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930221	10/2018	10/12/2018	99.99	100	99.9
LGE	C1S	930222	10/2018	10/12/2018	100.01	99.99	99.94
LGE	C1S	930223	10/2018	10/12/2018	100.01	100.07	99.99
LGE	C1S	930224	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	930225	10/2018	10/12/2018	99.98	99.99	99.92
LGE	C1S	930226	10/2018	10/12/2018	99.97	100.02	99.95
LGE	C1S	930227	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	930228	10/2018	10/12/2018	99.99	100.06	99.97
LGE	C1S	930229	10/2018	10/12/2018	100	100.04	99.98
LGE	C1S	930230	10/2018	10/12/2018	100	100.01	99.97
LGE	C1S	930231	10/2018	10/12/2018	99.95	100.06	99.95
LGE	C1S	930232	10/2018	10/12/2018	100.02	100.05	99.98
LGE	C1S	930233	10/2018	10/12/2018	100.01	100.04	99.98
LGE	C1S	930234	10/2018	10/12/2018	100.02	100.02	99.96
LGE	C1S	930235	10/2018	10/12/2018	99.98	100.06	100
LGE	C1S	930236	10/2018	10/12/2018	99.98	100.04	99.97
LGE	C1S	930237	10/2018	10/12/2018	99.98	100.06	99.97
LGE	C1S	930238	10/2018	10/12/2018	100.01	100.08	100.03
LGE	C1S	930239	10/2018	10/12/2018	100.05	100.02	100
LGE	C1S	930240	10/2018	10/12/2018	100.03	100.06	99.99
LGE	C1S	930241	10/2018	10/12/2018	99.99	100.04	99.98
LGE	C1S	930242	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	930243	10/2018	10/12/2018	99.97	100.05	99.97
LGE	C1S	930244	10/2018	10/12/2018	100.01	100.06	100.02
LGE	C1S	930245	10/2018	10/12/2018	100.02	100.1	100.02
LGE	C1S	930246	10/2018	10/12/2018	100	100	99.95
LGE	C1S	930247	10/2018	10/12/2018	100	100.04	99.94
LGE	C1S	930248	10/2018	10/12/2018	99.98	99.99	99.98
LGE	C1S	930249	10/2018	10/12/2018	100.03	100	99.94
LGE	C1S	930250	10/2018	10/12/2018	99.97	100.07	100
LGE	C1S	930251	10/2018	10/12/2018	99.97	100	99.94
LGE	C1S	930252	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	930253	10/2018	10/12/2018	99.99	100.09	100.05
LGE	C1S	930254	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	930255	10/2018	10/12/2018	100.03	99.99	99.98
LGE	C1S	930256	10/2018	10/12/2018	100.03	99.97	99.94
LGE	C1S	930257	10/2018	10/12/2018	100.02	100.08	100.03
LGE	C1S	930258	10/2018	10/12/2018	99.98	100.06	99.98
LGE	C1S	930259	10/2018	10/12/2018	99.97	100.07	99.98
LGE	C1S	930260	10/2018	10/12/2018	100.02	99.97	99.94
LGE	C1S	930261	10/2018	10/12/2018	100.03	100.02	99.97
LGE	C1S	930262	10/2018	10/12/2018	100.04	100	99.93

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930263	10/2018	10/12/2018	99.99	100.06	99.96
LGE	C1S	930264	10/2018	10/12/2018	100.05	100.05	99.99
LGE	C1S	930265	10/2018	10/12/2018	99.99	100.05	99.95
LGE	C1S	930266	10/2018	10/12/2018	100.01	100.05	99.94
LGE	C1S	930267	10/2018	10/12/2018	100.02	100.05	99.95
LGE	C1S	930268	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	930269	10/2018	10/12/2018	100.01	100.03	99.98
LGE	C1S	930270	10/2018	10/12/2018	100.02	99.98	99.91
LGE	C1S	930271	10/2018	10/12/2018	99.97	100.03	99.94
LGE	C1S	930272	10/2018	10/12/2018	99.99	99.91	99.92
LGE	C1S	930273	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	930274	10/2018	10/12/2018	100.01	100.02	99.98
LGE	C1S	930275	10/2018	10/12/2018	99.98	99.97	99.91
LGE	C1S	930276	10/2018	10/12/2018	99.99	100.06	99.97
LGE	C1S	930277	10/2018	10/12/2018	99.98	100.03	100.02
LGE	C1S	930278	10/2018	10/12/2018	100	99.99	99.9
LGE	C1S	930279	10/2018	10/12/2018	100	99.97	99.9
LGE	C1S	930280	10/2018	10/12/2018	100	99.94	99.92
LGE	C1S	930281	10/2018	10/12/2018	100	100.04	99.98
LGE	C1S	930282	10/2018	10/12/2018	99.98	99.99	100
LGE	C1S	930283	10/2018	10/12/2018	100.03	99.98	99.92
LGE	C1S	930284	10/2018	10/12/2018	100.01	99.98	99.94
LGE	C1S	930285	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	930286	10/2018	10/12/2018	100.03	100.04	99.97
LGE	C1S	930287	10/2018	10/12/2018	100.04	99.99	99.98
LGE	C1S	930288	10/2018	10/12/2018	100.05	99.93	99.92
LGE	C1S	930289	10/2018	10/12/2018	100.03	100.04	99.96
LGE	C1S	930290	10/2018	10/12/2018	99.97	100.05	99.98
LGE	C1S	930291	10/2018	10/12/2018	99.97	100	99.93
LGE	C1S	930292	10/2018	10/12/2018	100	100.04	99.95
LGE	C1S	930293	10/2018	10/12/2018	99.98	100.01	99.97
LGE	C1S	930294	10/2018	10/12/2018	100.02	100.04	99.92
LGE	C1S	930295	10/2018	10/12/2018	100	100	99.93
LGE	C1S	930296	10/2018	10/12/2018	99.97	99.98	99.95
LGE	C1S	930297	10/2018	10/12/2018	99.97	100.01	99.92
LGE	C1S	930298	10/2018	10/12/2018	100	100.03	99.99
LGE	C1S	930299	10/2018	10/12/2018	99.97	100.05	100.03
LGE	C1S	930300	10/2018	10/12/2018	100	100.06	99.98
LGE	C1S	930301	10/2018	10/12/2018	100.02	100.04	99.98
LGE	C1S	930302	10/2018	10/12/2018	100.02	99.98	99.9
LGE	C1S	930303	10/2018	10/12/2018	99.96	99.96	99.9
LGE	C1S	930304	10/2018	10/12/2018	99.98	100.04	99.97

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930305	10/2018	10/12/2018	99.94	100.05	99.97
LGE	C1S	930306	10/2018	10/12/2018	99.97	99.98	99.91
LGE	C1S	930307	10/2018	10/12/2018	100.01	100.05	99.96
LGE	C1S	930308	10/2018	10/12/2018	100.02	100.05	99.99
LGE	C1S	930309	10/2018	10/12/2018	99.99	99.98	99.91
LGE	C1S	930310	10/2018	10/12/2018	100	99.98	99.94
LGE	C1S	930311	10/2018	10/12/2018	99.99	100.07	99.93
LGE	C1S	930312	10/2018	10/12/2018	100.01	99.98	99.92
LGE	C1S	930313	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	930314	10/2018	10/12/2018	100.03	100.01	99.97
LGE	C1S	930315	10/2018	10/12/2018	99.99	100.07	99.99
LGE	C1S	930316	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	930317	10/2018	10/12/2018	100.02	100.07	99.98
LGE	C1S	930318	10/2018	10/12/2018	99.99	99.97	99.91
LGE	C1S	930319	10/2018	10/12/2018	100	100.05	99.98
LGE	C1S	930320	10/2018	10/12/2018	100.01	100.05	99.96
LGE	C1S	930321	10/2018	10/12/2018	100	100.02	99.96
LGE	C1S	930322	10/2018	10/12/2018	100.01	100.03	99.91
LGE	C1S	930323	10/2018	10/12/2018	100.03	100.06	99.96
LGE	C1S	930324	10/2018	10/12/2018	100	100.05	99.94
LGE	C1S	930325	10/2018	10/12/2018	99.98	100.04	99.96
LGE	C1S	930326	10/2018	10/12/2018	100.02	99.98	99.9
LGE	C1S	930327	10/2018	10/12/2018	100.01	100	99.91
LGE	C1S	930328	10/2018	10/12/2018	99.95	99.98	99.94
LGE	C1S	930329	10/2018	10/12/2018	99.98	100.06	100
LGE	C1S	930330	10/2018	10/12/2018	99.99	100.05	99.95
LGE	C1S	930331	10/2018	10/12/2018	100	99.99	99.94
LGE	C1S	930332	10/2018	10/12/2018	100	100.04	99.96
LGE	C1S	930333	10/2018	10/12/2018	100.02	100.07	99.97
LGE	C1S	930334	10/2018	10/12/2018	99.99	100.05	99.95
LGE	C1S	930335	10/2018	10/12/2018	99.99	100	100.01
LGE	C1S	930336	10/2018	10/12/2018	100	100.01	99.95
LGE	C1S	930337	10/2018	10/12/2018	99.99	100.04	99.98
LGE	C1S	930338	10/2018	10/12/2018	99.99	99.92	99.97
LGE	C1S	930339	10/2018	10/12/2018	99.99	100.07	99.97
LGE	C1S	930340	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	930341	10/2018	10/12/2018	100.01	100.06	100.01
LGE	C1S	930342	10/2018	10/12/2018	100.01	100.06	99.95
LGE	C1S	930343	10/2018	10/12/2018	100.05	100.02	99.94
LGE	C1S	930344	10/2018	10/12/2018	100	100.02	99.95
LGE	C1S	930345	10/2018	10/12/2018	99.97	100.08	100.02
LGE	C1S	930346	10/2018	10/12/2018	99.97	100.08	99.96



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930347	10/2018	10/12/2018	99.98	100	100.01
LGE	C1S	930348	10/2018	10/12/2018	99.98	99.98	99.94
LGE	C1S	930349	10/2018	10/12/2018	100	100	99.94
LGE	C1S	930350	10/2018	10/12/2018	99.98	100.01	99.91
LGE	C1S	930351	10/2018	10/12/2018	100.02	100.01	99.98
LGE	C1S	930352	10/2018	10/12/2018	99.99	100.04	99.96
LGE	C1S	930353	10/2018	10/12/2018	100.03	99.98	99.94
LGE	C1S	930354	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	930355	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	930356	10/2018	10/12/2018	99.94	100.05	99.97
LGE	C1S	930357	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	930358	10/2018	10/12/2018	99.99	100.03	99.93
LGE	C1S	930359	10/2018	10/12/2018	100.02	99.97	99.91
LGE	C1S	930360	10/2018	10/12/2018	99.99	100.04	99.93
LGE	C1S	930361	10/2018	10/12/2018	99.98	100.03	99.94
LGE	C1S	930362	10/2018	10/12/2018	99.99	100.06	99.94
LGE	C1S	930363	10/2018	10/12/2018	99.98	100.02	99.97
LGE	C1S	930364	10/2018	10/12/2018	99.98	100	99.96
LGE	C1S	930365	10/2018	10/12/2018	100.02	100.05	99.96
LGE	C1S	930366	10/2018	10/12/2018	99.99	100.03	99.99
LGE	C1S	930367	10/2018	10/12/2018	99.98	100.03	99.96
LGE	C1S	930368	10/2018	10/12/2018	100.01	100.01	99.92
LGE	C1S	930369	10/2018	10/12/2018	100	99.99	99.94
LGE	C1S	930370	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	930371	10/2018	10/12/2018	99.99	100	99.97
LGE	C1S	930372	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	930373	10/2018	10/12/2018	100.04	100.04	99.96
LGE	C1S	930374	10/2018	10/12/2018	100.02	100	99.96
LGE	C1S	930375	10/2018	10/12/2018	100.02	100.07	100.02
LGE	C1S	930376	10/2018	10/12/2018	100.02	100.07	99.96
LGE	C1S	930377	10/2018	10/12/2018	100.03	99.95	99.88
LGE	C1S	930378	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930379	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	930380	10/2018	10/12/2018	99.99	99.98	99.92
LGE	C1S	930381	10/2018	10/12/2018	100.04	100.02	99.96
LGE	C1S	930382	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	930383	10/2018	10/12/2018	99.99	100	99.94
LGE	C1S	930384	10/2018	10/12/2018	99.99	99.98	99.96
LGE	C1S	930385	10/2018	10/12/2018	100.01	99.99	99.93
LGE	C1S	930386	10/2018	10/12/2018	100.03	100	99.91
LGE	C1S	930387	10/2018	10/12/2018	100.02	100.01	99.98
LGE	C1S	930388	10/2018	10/12/2018	99.99	100.04	99.97

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930389	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	930390	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	930391	10/2018	10/12/2018	99.97	100.01	99.92
LGE	C1S	930392	10/2018	10/12/2018	99.98	100.01	99.94
LGE	C1S	930393	10/2018	10/12/2018	99.98	99.94	99.89
LGE	C1S	930394	10/2018	10/12/2018	99.98	100.03	99.94
LGE	C1S	930395	10/2018	10/12/2018	99.98	100.02	99.99
LGE	C1S	930396	10/2018	10/12/2018	100.02	100.06	99.96
LGE	C1S	930397	10/2018	10/12/2018	99.97	100.05	99.97
LGE	C1S	930398	10/2018	10/12/2018	100	99.97	99.92
LGE	C1S	930399	10/2018	10/12/2018	100.02	100.04	99.98
LGE	C1S	930400	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	930401	10/2018	10/12/2018	100	100.07	99.97
LGE	C1S	930402	10/2018	10/12/2018	99.99	100.01	99.98
LGE	C1S	930403	10/2018	10/12/2018	99.98	99.91	99.96
LGE	C1S	930404	10/2018	10/12/2018	100.02	100.02	99.94
LGE	C1S	930405	10/2018	10/12/2018	100.01	99.97	99.93
LGE	C1S	930406	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	930407	10/2018	10/12/2018	99.99	99.96	99.97
LGE	C1S	930408	10/2018	10/12/2018	100.02	100.06	99.96
LGE	C1S	930409	10/2018	10/12/2018	100.02	99.98	99.95
LGE	C1S	930410	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	930411	10/2018	10/12/2018	100.01	100.05	99.94
LGE	C1S	930412	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	930413	10/2018	10/12/2018	100	100.05	99.96
LGE	C1S	930414	10/2018	10/12/2018	99.98	100.02	99.92
LGE	C1S	930415	10/2018	10/12/2018	100.01	100.01	99.97
LGE	C1S	930416	10/2018	10/12/2018	100.01	100.01	99.89
LGE	C1S	930417	10/2018	10/12/2018	100.01	99.97	99.92
LGE	C1S	930418	10/2018	10/12/2018	100	100.08	99.98
LGE	C1S	930419	10/2018	10/12/2018	100.01	100.06	99.96
LGE	C1S	930420	10/2018	10/12/2018	100.01	99.98	99.97
LGE	C1S	930421	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	930422	10/2018	10/12/2018	100.03	100.07	99.97
LGE	C1S	930423	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	930424	10/2018	10/12/2018	99.97	100.03	99.93
LGE	C1S	930425	10/2018	10/12/2018	100	100.05	99.97
LGE	C1S	930426	10/2018	10/12/2018	99.98	99.98	99.93
LGE	C1S	930427	10/2018	10/12/2018	100.02	100.04	99.97
LGE	C1S	930428	10/2018	10/12/2018	99.99	100.07	100.03
LGE	C1S	930429	10/2018	10/12/2018	100.02	100.01	99.95
LGE	C1S	930430	10/2018	10/12/2018	99.99	99.98	99.88

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930431	10/2018	10/12/2018	100.01	99.99	99.94
LGE	C1S	930432	10/2018	10/12/2018	99.97	100.01	99.97
LGE	C1S	930433	10/2018	10/12/2018	100.02	100.01	99.97
LGE	C1S	930434	10/2018	10/12/2018	99.98	100.08	99.99
LGE	C1S	930435	10/2018	10/12/2018	100.01	99.98	99.89
LGE	C1S	930436	10/2018	10/12/2018	99.98	100.03	99.95
LGE	C1S	930437	10/2018	10/12/2018	99.98	100.02	100
LGE	C1S	930438	10/2018	10/12/2018	100	100.06	99.96
LGE	C1S	930439	10/2018	10/12/2018	99.98	100.05	99.99
LGE	C1S	930440	10/2018	10/12/2018	99.95	100.03	99.96
LGE	C1S	930441	10/2018	10/12/2018	100.01	99.98	99.95
LGE	C1S	930442	10/2018	10/12/2018	100.01	99.96	99.89
LGE	C1S	930443	10/2018	10/12/2018	99.99	100.03	99.96
LGE	C1S	930444	10/2018	10/12/2018	100.01	99.98	99.91
LGE	C1S	930445	10/2018	10/12/2018	99.99	99.95	99.9
LGE	C1S	930446	10/2018	10/12/2018	100.03	100.01	99.96
LGE	C1S	930447	10/2018	10/12/2018	100	100	99.94
LGE	C1S	930448	10/2018	10/12/2018	100.03	100.02	99.92
LGE	C1S	930449	10/2018	10/12/2018	100.02	100.05	99.97
LGE	C1S	930450	10/2018	10/12/2018	99.99	100.02	99.95
LGE	C1S	930451	10/2018	10/12/2018	100.05	100.02	99.93
LGE	C1S	930452	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	930453	10/2018	10/12/2018	99.97	100.01	99.93
LGE	C1S	930454	10/2018	10/12/2018	99.96	100	99.92
LGE	C1S	930455	10/2018	10/12/2018	100	100.03	99.96
LGE	C1S	930456	10/2018	10/12/2018	100	100.05	99.93
LGE	C1S	930457	10/2018	10/12/2018	100	100.05	99.96
LGE	C1S	930458	10/2018	10/12/2018	100.04	99.99	99.96
LGE	C1S	930459	10/2018	10/12/2018	99.97	99.96	99.95
LGE	C1S	930460	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	930461	10/2018	10/12/2018	99.97	100.01	99.98
LGE	C1S	930462	10/2018	10/12/2018	100	100.03	99.96
LGE	C1S	930463	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930464	10/2018	10/12/2018	99.98	100.04	99.95
LGE	C1S	930465	10/2018	10/12/2018	99.97	100.04	99.95
LGE	C1S	930466	10/2018	10/12/2018	99.98	100.02	99.94
LGE	C1S	930467	10/2018	10/12/2018	100.01	100.02	99.97
LGE	C1S	930468	10/2018	10/12/2018	100	100	99.95
LGE	C1S	930469	10/2018	10/12/2018	99.98	100.04	99.95
LGE	C1S	930470	10/2018	10/12/2018	99.94	100.04	99.96
LGE	C1S	930471	10/2018	10/12/2018	100.02	100.02	99.94
LGE	C1S	930472	10/2018	10/12/2018	100.01	100	99.92



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930473	10/2018	10/12/2018	99.97	100	99.9
LGE	C1S	930474	10/2018	10/12/2018	100.02	100.02	99.93
LGE	C1S	930475	10/2018	10/12/2018	100.04	99.98	99.92
LGE	C1S	930476	10/2018	10/12/2018	100.02	99.99	99.94
LGE	C1S	930477	10/2018	10/12/2018	99.97	100.03	99.94
LGE	C1S	930478	10/2018	10/12/2018	99.98	100.04	99.98
LGE	C1S	930479	10/2018	10/12/2018	99.98	100.01	99.95
LGE	C1S	930480	10/2018	10/12/2018	100.03	99.99	99.89
LGE	C1S	930481	10/2018	10/12/2018	100.04	100.05	99.98
LGE	C1S	930482	10/2018	10/12/2018	99.97	100.03	99.91
LGE	C1S	930483	10/2018	10/12/2018	99.97	100.07	99.99
LGE	C1S	930484	10/2018	10/12/2018	100.03	100.03	99.93
LGE	C1S	930485	10/2018	10/12/2018	100.01	100.05	99.96
LGE	C1S	930486	10/2018	10/12/2018	99.96	100.05	99.99
LGE	C1S	930487	10/2018	10/12/2018	100	99.99	99.93
LGE	C1S	930488	10/2018	10/12/2018	99.98	100.02	99.93
LGE	C1S	930489	10/2018	10/12/2018	100	99.95	99.91
LGE	C1S	930490	10/2018	10/12/2018	99.97	99.96	99.98
LGE	C1S	930491	10/2018	10/12/2018	99.99	99.94	99.97
LGE	C1S	930492	10/2018	10/12/2018	99.97	99.93	99.95
LGE	C1S	930493	10/2018	10/12/2018	99.98	99.95	99.93
LGE	C1S	930494	10/2018	10/12/2018	100	99.99	99.92
LGE	C1S	930495	10/2018	10/12/2018	100.02	99.97	99.96
LGE	C1S	930496	10/2018	10/12/2018	100.01	99.95	99.95
LGE	C1S	930497	10/2018	10/12/2018	99.99	99.98	99.94
LGE	C1S	930498	10/2018	10/12/2018	100	99.95	99.92
LGE	C1S	930499	10/2018	10/12/2018	99.98	99.95	99.93
LGE	C1S	930500	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930501	10/2018	10/12/2018	99.99	99.94	99.93
LGE	C1S	930502	10/2018	10/12/2018	99.98	99.98	99.96
LGE	C1S	930503	10/2018	10/12/2018	100	99.93	99.9
LGE	C1S	930504	10/2018	10/12/2018	100.01	99.97	99.96
LGE	C1S	930505	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930506	10/2018	10/12/2018	99.99	99.9	99.91
LGE	C1S	930507	10/2018	10/12/2018	99.99	99.95	99.92
LGE	C1S	930508	10/2018	10/12/2018	100.01	99.95	99.93
LGE	C1S	930509	10/2018	10/12/2018	100.03	99.98	99.95
LGE	C1S	930510	10/2018	10/12/2018	99.98	99.98	99.94
LGE	C1S	930511	10/2018	10/12/2018	99.99	99.96	99.9
LGE	C1S	930512	10/2018	10/12/2018	99.97	100.06	100.01
LGE	C1S	930513	10/2018	10/12/2018	100.02	99.95	99.93
LGE	C1S	930514	10/2018	10/12/2018	99.99	99.92	99.91

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930515	10/2018	10/12/2018	100.02	99.97	99.94
LGE	C1S	930516	10/2018	10/12/2018	99.99	99.94	99.92
LGE	C1S	930517	10/2018	10/12/2018	99.99	99.96	99.93
LGE	C1S	930518	10/2018	10/12/2018	100	99.94	99.94
LGE	C1S	930519	10/2018	10/12/2018	100	99.97	99.94
LGE	C1S	930520	10/2018	10/12/2018	100	100	99.92
LGE	C1S	930521	10/2018	10/12/2018	100.01	99.98	99.93
LGE	C1S	930522	10/2018	10/12/2018	100.01	99.93	99.95
LGE	C1S	930523	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930524	10/2018	10/12/2018	100.01	99.97	99.98
LGE	C1S	930525	10/2018	10/12/2018	99.99	99.94	99.93
LGE	C1S	930526	10/2018	10/12/2018	100.01	99.98	99.91
LGE	C1S	930527	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930528	10/2018	10/12/2018	99.99	99.97	99.97
LGE	C1S	930529	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	930530	10/2018	10/12/2018	100.05	99.95	99.9
LGE	C1S	930531	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	930532	10/2018	10/12/2018	100.01	99.97	99.93
LGE	C1S	930533	10/2018	10/12/2018	100	99.98	99.99
LGE	C1S	930534	10/2018	10/12/2018	100.03	99.99	99.96
LGE	C1S	930535	10/2018	10/12/2018	100.02	99.97	99.92
LGE	C1S	930536	10/2018	10/12/2018	100.01	99.98	99.92
LGE	C1S	930537	10/2018	10/12/2018	100	99.96	99.95
LGE	C1S	930538	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	930539	10/2018	10/12/2018	100.02	99.96	99.94
LGE	C1S	930540	10/2018	10/12/2018	100.01	99.94	99.99
LGE	C1S	930541	10/2018	10/12/2018	100	99.96	99.95
LGE	C1S	930542	10/2018	10/12/2018	100.04	99.98	99.92
LGE	C1S	930543	10/2018	10/12/2018	99.97	99.97	99.97
LGE	C1S	930544	10/2018	10/12/2018	99.94	99.98	99.93
LGE	C1S	930545	10/2018	10/12/2018	99.94	99.95	99.91
LGE	C1S	930546	10/2018	10/12/2018	99.98	99.96	99.96
LGE	C1S	930547	10/2018	10/12/2018	100	99.96	99.95
LGE	C1S	930548	10/2018	10/12/2018	99.98	99.97	99.93
LGE	C1S	930549	10/2018	10/12/2018	100	99.96	99.93
LGE	C1S	930550	10/2018	10/12/2018	100.03	99.96	99.95
LGE	C1S	930551	10/2018	10/12/2018	100.01	99.94	99.94
LGE	C1S	930552	10/2018	10/12/2018	100.01	99.99	100.02
LGE	C1S	930553	10/2018	10/12/2018	99.99	99.96	99.93
LGE	C1S	930554	10/2018	10/12/2018	99.98	99.96	99.92
LGE	C1S	930555	10/2018	10/12/2018	100.01	100	99.95
LGE	C1S	930556	10/2018	10/12/2018	99.98	99.99	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930557	10/2018	10/12/2018	100.01	99.91	99.85
LGE	C1S	930558	10/2018	10/12/2018	100	99.94	99.93
LGE	C1S	930559	10/2018	10/12/2018	100.01	99.96	99.98
LGE	C1S	930560	10/2018	10/12/2018	100.01	99.95	99.95
LGE	C1S	930561	10/2018	10/12/2018	99.97	99.92	99.91
LGE	C1S	930562	10/2018	10/12/2018	99.97	99.92	99.88
LGE	C1S	930563	10/2018	10/12/2018	100.01	99.97	99.96
LGE	C1S	930564	10/2018	10/12/2018	99.97	99.96	99.93
LGE	C1S	930565	10/2018	10/12/2018	100.03	99.96	99.93
LGE	C1S	930566	10/2018	10/12/2018	99.99	99.94	99.89
LGE	C1S	930567	10/2018	10/12/2018	99.97	100	100.01
LGE	C1S	930568	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	930569	10/2018	10/12/2018	100	99.96	99.91
LGE	C1S	930570	10/2018	10/12/2018	99.99	99.97	99.96
LGE	C1S	930571	10/2018	10/12/2018	100.01	99.93	99.9
LGE	C1S	930572	10/2018	10/12/2018	100	99.96	99.87
LGE	C1S	930573	10/2018	10/12/2018	99.99	99.99	99.94
LGE	C1S	930574	10/2018	10/12/2018	100.01	99.96	99.97
LGE	C1S	930575	10/2018	10/12/2018	99.98	99.95	99.9
LGE	C1S	930576	10/2018	10/12/2018	100.01	99.93	99.92
LGE	C1S	930577	10/2018	10/12/2018	100.04	99.96	99.95
LGE	C1S	930578	10/2018	10/12/2018	99.96	99.96	99.91
LGE	C1S	930579	10/2018	10/12/2018	100.02	99.95	99.91
LGE	C1S	930580	10/2018	10/12/2018	100.02	99.96	99.93
LGE	C1S	930581	10/2018	10/12/2018	100.01	99.94	99.93
LGE	C1S	930582	10/2018	10/12/2018	100	99.94	99.91
LGE	C1S	930583	10/2018	10/12/2018	99.96	100	99.92
LGE	C1S	930584	10/2018	10/12/2018	100.01	99.92	99.86
LGE	C1S	930585	10/2018	10/12/2018	99.97	99.94	99.89
LGE	C1S	930586	10/2018	10/12/2018	99.99	99.99	99.98
LGE	C1S	930587	10/2018	10/12/2018	100	99.98	99.96
LGE	C1S	930588	10/2018	10/12/2018	99.98	99.94	99.91
LGE	C1S	930589	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	930590	10/2018	10/12/2018	99.99	99.97	99.96
LGE	C1S	930591	10/2018	10/12/2018	99.97	100	99.92
LGE	C1S	930592	10/2018	10/12/2018	100.05	99.96	99.89
LGE	C1S	930593	10/2018	10/12/2018	100	99.94	99.93
LGE	C1S	930594	10/2018	10/12/2018	99.97	100.03	99.97
LGE	C1S	930595	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930596	10/2018	10/12/2018	100	99.99	99.94
LGE	C1S	930597	10/2018	10/12/2018	99.96	99.98	99.9
LGE	C1S	930598	10/2018	10/12/2018	100	99.94	99.91



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930599	10/2018	10/12/2018	100.03	99.95	99.89
LGE	C1S	930600	10/2018	10/12/2018	99.99	99.94	99.89
LGE	C1S	930601	10/2018	10/12/2018	100.01	99.99	99.93
LGE	C1S	930602	10/2018	10/12/2018	99.99	99.96	99.94
LGE	C1S	930603	10/2018	10/12/2018	100	99.99	99.91
LGE	C1S	930604	10/2018	10/12/2018	99.98	99.96	99.89
LGE	C1S	930605	10/2018	10/12/2018	99.97	99.95	99.98
LGE	C1S	930606	10/2018	10/12/2018	100.01	99.97	99.94
LGE	C1S	930607	10/2018	10/12/2018	100.01	99.94	99.88
LGE	C1S	930608	10/2018	10/12/2018	100	99.98	99.94
LGE	C1S	930609	10/2018	10/12/2018	99.98	100.01	99.94
LGE	C1S	930610	10/2018	10/12/2018	100	99.99	99.91
LGE	C1S	930611	10/2018	10/12/2018	100.01	99.97	99.91
LGE	C1S	930612	10/2018	10/12/2018	100	99.97	99.93
LGE	C1S	930613	10/2018	10/12/2018	99.99	100	99.93
LGE	C1S	930614	10/2018	10/12/2018	99.96	99.97	99.89
LGE	C1S	930615	10/2018	10/12/2018	100.01	99.95	99.9
LGE	C1S	930616	10/2018	10/12/2018	99.98	99.96	99.93
LGE	C1S	930617	10/2018	10/12/2018	100	99.97	99.96
LGE	C1S	930618	10/2018	10/12/2018	99.98	99.92	99.95
LGE	C1S	930619	10/2018	10/12/2018	99.98	99.99	99.92
LGE	C1S	930620	10/2018	10/12/2018	100.01	99.96	99.95
LGE	C1S	930621	10/2018	10/12/2018	99.98	100.01	100.01
LGE	C1S	930622	10/2018	10/12/2018	99.99	100	100.01
LGE	C1S	930623	10/2018	10/12/2018	100.01	99.98	99.98
LGE	C1S	930624	10/2018	10/12/2018	100.01	99.99	99.98
LGE	C1S	930625	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	930626	10/2018	10/12/2018	99.98	99.95	99.93
LGE	C1S	930627	10/2018	10/12/2018	100.03	99.97	99.99
LGE	C1S	930628	10/2018	10/12/2018	99.99	99.99	99.96
LGE	C1S	930629	10/2018	10/12/2018	100	100	99.97
LGE	C1S	930630	10/2018	10/12/2018	100.01	99.98	99.9
LGE	C1S	930631	10/2018	10/12/2018	99.97	100	99.98
LGE	C1S	930632	10/2018	10/12/2018	99.99	99.96	99.95
LGE	C1S	930633	10/2018	10/12/2018	99.94	100.01	100
LGE	C1S	930634	10/2018	10/12/2018	99.99	99.98	100.01
LGE	C1S	930635	10/2018	10/12/2018	99.98	100.01	99.96
LGE	C1S	930636	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930637	10/2018	10/12/2018	100	99.96	99.88
LGE	C1S	930638	10/2018	10/12/2018	99.99	99.98	99.95
LGE	C1S	930639	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930640	10/2018	10/12/2018	100.01	99.96	99.93

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930641	10/2018	10/12/2018	99.97	99.97	99.99
LGE	C1S	930642	10/2018	10/12/2018	100	100	99.95
LGE	C1S	930643	10/2018	10/12/2018	100	99.97	99.87
LGE	C1S	930644	10/2018	10/12/2018	99.99	99.94	100
LGE	C1S	930645	10/2018	10/12/2018	99.99	99.96	99.96
LGE	C1S	930646	10/2018	10/12/2018	99.97	100	99.99
LGE	C1S	930647	10/2018	10/12/2018	100	99.98	99.93
LGE	C1S	930648	10/2018	10/12/2018	99.98	99.96	99.94
LGE	C1S	930649	10/2018	10/12/2018	100.01	99.98	99.93
LGE	C1S	930650	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	930651	10/2018	10/12/2018	99.99	99.96	99.95
LGE	C1S	930652	10/2018	10/12/2018	99.98	100.02	99.96
LGE	C1S	930653	10/2018	10/12/2018	100.02	99.99	99.92
LGE	C1S	930654	10/2018	10/12/2018	99.99	100.01	99.96
LGE	C1S	930655	10/2018	10/12/2018	100	99.94	99.95
LGE	C1S	930656	10/2018	10/12/2018	99.99	99.97	99.9
LGE	C1S	930657	10/2018	10/12/2018	99.99	99.99	99.97
LGE	C1S	930658	10/2018	10/12/2018	100.03	99.97	99.97
LGE	C1S	930659	10/2018	10/12/2018	99.98	99.99	99.93
LGE	C1S	930660	10/2018	10/12/2018	99.96	99.95	99.94
LGE	C1S	930661	10/2018	10/12/2018	99.97	99.99	99.99
LGE	C1S	930662	10/2018	10/12/2018	99.95	99.97	99.99
LGE	C1S	930663	10/2018	10/12/2018	99.99	99.97	99.93
LGE	C1S	930664	10/2018	10/12/2018	100.03	99.95	99.99
LGE	C1S	930665	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	930666	10/2018	10/12/2018	99.99	99.94	99.92
LGE	C1S	930667	10/2018	10/12/2018	99.98	99.96	99.94
LGE	C1S	930668	10/2018	10/12/2018	100.01	99.98	99.95
LGE	C1S	930669	10/2018	10/12/2018	100.01	99.96	99.94
LGE	C1S	930670	10/2018	10/12/2018	100	99.93	99.91
LGE	C1S	930671	10/2018	10/12/2018	100.02	99.96	99.95
LGE	C1S	930672	10/2018	10/12/2018	100.01	99.98	99.92
LGE	C1S	930673	10/2018	10/12/2018	99.99	99.97	99.94
LGE	C1S	930674	10/2018	10/12/2018	100.02	100.01	99.96
LGE	C1S	930675	10/2018	10/12/2018	100	99.98	99.93
LGE	C1S	930676	10/2018	10/12/2018	100.01	99.99	99.98
LGE	C1S	930677	10/2018	10/12/2018	99.96	99.99	99.94
LGE	C1S	930678	10/2018	10/12/2018	99.98	99.97	99.91
LGE	C1S	930679	10/2018	10/12/2018	100	99.96	99.93
LGE	C1S	930680	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	930681	10/2018	10/12/2018	100	99.95	99.93
LGE	C1S	930682	10/2018	10/12/2018	100.01	100.02	99.92

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930683	10/2018	10/12/2018	100.01	99.99	99.92
LGE	C1S	930684	10/2018	10/12/2018	100	99.97	99.97
LGE	C1S	930685	10/2018	10/12/2018	100.03	99.97	99.92
LGE	C1S	930686	10/2018	10/12/2018	100.02	99.99	99.92
LGE	C1S	930687	10/2018	10/12/2018	99.97	100.02	99.95
LGE	C1S	930688	10/2018	10/12/2018	99.98	99.95	99.93
LGE	C1S	930689	10/2018	10/12/2018	100.03	99.98	99.95
LGE	C1S	930690	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	930691	10/2018	10/12/2018	100.01	99.98	99.95
LGE	C1S	930692	10/2018	10/12/2018	100.02	99.97	99.93
LGE	C1S	930693	10/2018	10/12/2018	99.97	99.98	99.98
LGE	C1S	930694	10/2018	10/12/2018	99.99	99.97	99.94
LGE	C1S	930695	10/2018	10/12/2018	100.02	99.96	99.96
LGE	C1S	930696	10/2018	10/12/2018	100	99.94	99.9
LGE	C1S	930697	10/2018	10/12/2018	99.99	99.98	99.96
LGE	C1S	930698	10/2018	10/12/2018	100.01	99.99	99.94
LGE	C1S	930699	10/2018	10/12/2018	100	99.98	99.96
LGE	C1S	930700	10/2018	10/12/2018	99.99	99.97	99.96
LGE	C1S	930701	10/2018	10/12/2018	99.99	99.99	99.98
LGE	C1S	930702	10/2018	10/12/2018	100.01	99.97	99.9
LGE	C1S	930703	10/2018	10/12/2018	100	99.99	99.93
LGE	C1S	930704	10/2018	10/12/2018	99.98	99.97	99.88
LGE	C1S	930705	10/2018	10/12/2018	100.02	99.99	99.95
LGE	C1S	930706	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	930707	10/2018	10/12/2018	100.01	100	99.98
LGE	C1S	930708	10/2018	10/12/2018	100	99.98	99.93
LGE	C1S	930709	10/2018	10/12/2018	99.98	99.99	99.92
LGE	C1S	930710	10/2018	10/12/2018	100.02	99.96	99.93
LGE	C1S	930711	10/2018	10/12/2018	99.97	99.92	99.88
LGE	C1S	930712	10/2018	10/12/2018	99.99	100	99.89
LGE	C1S	930713	10/2018	10/12/2018	99.98	100.01	99.9
LGE	C1S	930714	10/2018	10/12/2018	99.99	99.95	99.89
LGE	C1S	930715	10/2018	10/12/2018	99.99	99.97	99.88
LGE	C1S	930716	10/2018	10/12/2018	99.99	99.96	99.95
LGE	C1S	930717	10/2018	10/12/2018	99.98	100.03	99.98
LGE	C1S	930718	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	930719	10/2018	10/12/2018	100.06	99.99	99.93
LGE	C1S	930720	10/2018	10/12/2018	99.97	99.99	99.93
LGE	C1S	930721	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	930722	10/2018	10/12/2018	100.03	100.02	99.93
LGE	C1S	930723	10/2018	10/12/2018	100.01	99.97	99.93
LGE	C1S	930724	10/2018	10/12/2018	100.02	100	99.97



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930725	10/2018	10/12/2018	99.97	100.02	100
LGE	C1S	930726	10/2018	10/12/2018	100.01	100	100.02
LGE	C1S	930727	10/2018	10/12/2018	100.01	99.95	99.88
LGE	C1S	930728	10/2018	10/12/2018	99.97	99.95	99.93
LGE	C1S	930729	10/2018	10/12/2018	100	100	99.98
LGE	C1S	930730	10/2018	10/12/2018	99.98	99.95	99.89
LGE	C1S	930731	10/2018	10/12/2018	99.99	99.99	99.94
LGE	C1S	930732	10/2018	10/12/2018	100.01	100	99.96
LGE	C1S	930733	10/2018	10/12/2018	99.99	99.96	99.94
LGE	C1S	930734	10/2018	10/12/2018	100.02	100.01	100.01
LGE	C1S	930735	10/2018	10/12/2018	100.05	99.97	99.92
LGE	C1S	930736	10/2018	10/12/2018	100.03	99.96	99.92
LGE	C1S	930737	10/2018	10/12/2018	100.03	99.97	99.93
LGE	C1S	930738	10/2018	10/12/2018	99.96	99.99	99.94
LGE	C1S	930739	10/2018	10/12/2018	99.99	100.01	100
LGE	C1S	930740	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	930741	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	930742	10/2018	10/12/2018	99.99	99.99	99.97
LGE	C1S	930743	10/2018	10/12/2018	99.99	99.97	99.95
LGE	C1S	930744	10/2018	10/12/2018	100.04	100.02	99.92
LGE	C1S	930745	10/2018	10/12/2018	99.98	99.98	99.99
LGE	C1S	930746	10/2018	10/12/2018	99.95	99.99	99.96
LGE	C1S	930747	10/2018	10/12/2018	100.03	99.95	99.97
LGE	C1S	930748	10/2018	10/12/2018	100.01	99.94	99.88
LGE	C1S	930749	10/2018	10/12/2018	99.98	99.96	99.95
LGE	C1S	930750	10/2018	10/12/2018	99.99	99.97	99.91
LGE	C1S	930751	10/2018	10/12/2018	100	99.95	99.92
LGE	C1S	930752	10/2018	10/12/2018	100.01	99.98	99.95
LGE	C1S	930753	10/2018	10/12/2018	99.98	99.97	99.92
LGE	C1S	930754	10/2018	10/12/2018	99.98	99.92	99.94
LGE	C1S	930755	10/2018	10/12/2018	99.99	99.98	99.95
LGE	C1S	930756	10/2018	10/12/2018	100	99.97	99.96
LGE	C1S	930757	10/2018	10/12/2018	99.99	99.97	99.95
LGE	C1S	930758	10/2018	10/12/2018	100	100	99.97
LGE	C1S	930759	10/2018	10/12/2018	100.01	99.99	99.98
LGE	C1S	930760	10/2018	10/12/2018	100.02	99.98	99.97
LGE	C1S	930761	10/2018	10/12/2018	99.98	99.98	99.96
LGE	C1S	930762	10/2018	10/12/2018	100.03	99.98	99.94
LGE	C1S	930763	10/2018	10/12/2018	99.99	99.98	99.97
LGE	C1S	930764	10/2018	10/12/2018	99.98	99.97	99.98
LGE	C1S	930765	10/2018	10/12/2018	99.99	99.99	99.99
LGE	C1S	930766	10/2018	10/12/2018	100.02	99.97	99.93

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930767	10/2018	10/12/2018	99.98	99.96	99.91
LGE	C1S	930768	10/2018	10/12/2018	99.99	99.96	99.95
LGE	C1S	930769	10/2018	10/12/2018	100	100	99.92
LGE	C1S	930770	10/2018	10/12/2018	100.04	99.99	100.01
LGE	C1S	930771	10/2018	10/12/2018	99.97	99.96	99.92
LGE	C1S	930772	10/2018	10/12/2018	99.99	99.98	99.97
LGE	C1S	930773	10/2018	10/12/2018	100.01	100.02	100
LGE	C1S	930774	10/2018	10/12/2018	99.99	100.02	99.97
LGE	C1S	930775	10/2018	10/12/2018	100.02	99.98	99.97
LGE	C1S	930776	10/2018	10/12/2018	100.02	99.96	99.97
LGE	C1S	930777	10/2018	10/12/2018	100	99.97	99.95
LGE	C1S	930778	10/2018	10/12/2018	100.03	99.97	99.93
LGE	C1S	930779	10/2018	10/12/2018	100.02	99.95	99.9
LGE	C1S	930780	10/2018	10/12/2018	99.98	100.01	100
LGE	C1S	930781	10/2018	10/12/2018	100	99.95	99.92
LGE	C1S	930782	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	930783	10/2018	10/12/2018	100.02	99.97	99.93
LGE	C1S	930784	10/2018	10/12/2018	100.03	99.97	99.93
LGE	C1S	930785	10/2018	10/12/2018	100	100.01	99.94
LGE	C1S	930786	10/2018	10/12/2018	99.99	100.03	99.97
LGE	C1S	930787	10/2018	10/12/2018	100.01	99.95	99.95
LGE	C1S	930788	10/2018	10/12/2018	100.04	99.98	99.92
LGE	C1S	930789	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	930790	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930791	10/2018	10/12/2018	100.02	99.97	99.9
LGE	C1S	930792	10/2018	10/12/2018	99.98	99.96	99.93
LGE	C1S	930793	10/2018	10/12/2018	99.99	99.96	99.95
LGE	C1S	930794	10/2018	10/12/2018	99.98	99.99	99.95
LGE	C1S	930795	10/2018	10/12/2018	99.99	99.96	99.96
LGE	C1S	930796	10/2018	10/12/2018	100	99.98	99.98
LGE	C1S	930797	10/2018	10/12/2018	99.98	99.98	99.97
LGE	C1S	930798	10/2018	10/12/2018	99.99	99.99	99.96
LGE	C1S	930799	10/2018	10/12/2018	100	99.96	99.94
LGE	C1S	930800	10/2018	10/12/2018	99.96	99.96	99.97
LGE	C1S	930801	10/2018	10/12/2018	99.98	100.01	100.02
LGE	C1S	930802	10/2018	10/12/2018	99.98	99.95	99.92
LGE	C1S	930803	10/2018	10/12/2018	100.01	100	99.95
LGE	C1S	930804	10/2018	10/12/2018	100	99.96	99.91
LGE	C1S	930805	10/2018	10/12/2018	99.98	99.99	99.98
LGE	C1S	930806	10/2018	10/12/2018	100.01	99.97	99.94
LGE	C1S	930807	10/2018	10/12/2018	99.99	100	99.98
LGE	C1S	930808	10/2018	10/12/2018	100.02	99.98	99.98

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930809	10/2018	10/12/2018	100.06	99.96	99.97
LGE	C1S	930810	10/2018	10/12/2018	99.99	99.99	99.92
LGE	C1S	930811	10/2018	10/12/2018	99.99	100	99.98
LGE	C1S	930812	10/2018	10/12/2018	100.01	99.97	99.99
LGE	C1S	930813	10/2018	10/12/2018	100.04	99.99	99.97
LGE	C1S	930814	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	930815	10/2018	10/12/2018	99.97	99.96	99.92
LGE	C1S	930816	10/2018	10/12/2018	99.96	99.97	99.95
LGE	C1S	930817	10/2018	10/12/2018	99.98	99.98	99.98
LGE	C1S	930818	10/2018	10/12/2018	100.01	99.95	99.9
LGE	C1S	930819	10/2018	10/12/2018	100	99.97	99.96
LGE	C1S	930820	10/2018	10/12/2018	100	100.01	99.96
LGE	C1S	930821	10/2018	10/12/2018	99.98	100.02	99.96
LGE	C1S	930822	10/2018	10/12/2018	99.99	99.97	99.9
LGE	C1S	930823	10/2018	10/12/2018	100	99.97	99.93
LGE	C1S	930824	10/2018	10/12/2018	99.97	99.95	99.92
LGE	C1S	930825	10/2018	10/12/2018	100.03	100.02	99.99
LGE	C1S	930826	10/2018	10/12/2018	99.99	99.98	99.92
LGE	C1S	930827	10/2018	10/12/2018	100.03	99.95	99.91
LGE	C1S	930828	10/2018	10/12/2018	99.97	99.95	99.93
LGE	C1S	930829	10/2018	10/12/2018	100	99.92	99.93
LGE	C1S	930830	10/2018	10/12/2018	99.99	99.96	99.93
LGE	C1S	930831	10/2018	10/12/2018	100.04	99.95	99.94
LGE	C1S	930832	10/2018	10/12/2018	100.01	99.97	99.97
LGE	C1S	930833	10/2018	10/12/2018	99.97	99.99	99.96
LGE	C1S	930834	10/2018	10/12/2018	99.98	99.99	99.95
LGE	C1S	930835	10/2018	10/12/2018	100.03	99.97	99.91
LGE	C1S	930836	10/2018	10/12/2018	99.97	99.98	99.92
LGE	C1S	930837	10/2018	10/12/2018	99.97	99.93	99.91
LGE	C1S	930838	10/2018	10/12/2018	99.99	100	99.95
LGE	C1S	930839	10/2018	10/12/2018	100.01	99.95	99.95
LGE	C1S	930840	10/2018	10/12/2018	99.97	99.97	99.96
LGE	C1S	930841	10/2018	10/12/2018	100.01	99.99	99.92
LGE	C1S	930842	10/2018	10/12/2018	100	99.95	99.95
LGE	C1S	930843	10/2018	10/12/2018	100.02	99.98	99.97
LGE	C1S	930844	10/2018	10/12/2018	99.97	99.95	99.92
LGE	C1S	930845	10/2018	10/12/2018	99.99	99.98	99.95
LGE	C1S	930846	10/2018	10/12/2018	100	99.94	99.93
LGE	C1S	930847	10/2018	10/12/2018	100.02	99.95	99.98
LGE	C1S	930848	10/2018	10/12/2018	99.99	99.97	99.96
LGE	C1S	930849	10/2018	10/12/2018	99.98	99.96	99.91
LGE	C1S	930850	10/2018	10/12/2018	99.98	100.01	99.96



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930851	10/2018	10/12/2018	99.98	99.95	99.98
LGE	C1S	930852	10/2018	10/12/2018	100	99.97	99.95
LGE	C1S	930853	10/2018	10/12/2018	100.01	99.97	99.92
LGE	C1S	930854	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930855	10/2018	10/12/2018	100.02	99.97	99.93
LGE	C1S	930856	10/2018	10/12/2018	100.02	100.01	99.96
LGE	C1S	930857	10/2018	10/12/2018	99.96	99.98	99.91
LGE	C1S	930858	10/2018	10/12/2018	99.97	99.96	99.95
LGE	C1S	930859	10/2018	10/12/2018	100.03	100	99.92
LGE	C1S	930860	10/2018	10/12/2018	99.96	100	100.01
LGE	C1S	930861	10/2018	10/12/2018	100.01	100	99.96
LGE	C1S	930862	10/2018	10/12/2018	99.99	99.96	99.96
LGE	C1S	930863	10/2018	10/12/2018	99.99	99.95	99.93
LGE	C1S	930864	10/2018	10/12/2018	100.02	99.99	99.92
LGE	C1S	930865	10/2018	10/12/2018	99.99	99.98	99.94
LGE	C1S	930866	10/2018	10/12/2018	100.03	100	99.93
LGE	C1S	930867	10/2018	10/12/2018	99.98	99.99	99.89
LGE	C1S	930868	10/2018	10/12/2018	100.02	99.94	99.91
LGE	C1S	930869	10/2018	10/12/2018	100.01	99.96	99.94
LGE	C1S	930870	10/2018	10/12/2018	100	99.99	99.93
LGE	C1S	930871	10/2018	10/12/2018	100	99.99	99.94
LGE	C1S	930872	10/2018	10/12/2018	100.01	99.96	99.93
LGE	C1S	930873	10/2018	10/12/2018	100.01	99.96	99.94
LGE	C1S	930874	10/2018	10/12/2018	100	99.96	99.91
LGE	C1S	930875	10/2018	10/12/2018	100.02	99.99	99.96
LGE	C1S	930876	10/2018	10/12/2018	99.97	99.96	99.9
LGE	C1S	930877	10/2018	10/12/2018	99.96	99.98	99.89
LGE	C1S	930878	10/2018	10/12/2018	99.99	99.95	99.93
LGE	C1S	930879	10/2018	10/12/2018	99.98	99.94	99.94
LGE	C1S	930880	10/2018	10/12/2018	100	99.99	99.97
LGE	C1S	930881	10/2018	10/12/2018	100.01	99.95	99.93
LGE	C1S	930882	10/2018	10/12/2018	100.01	99.96	99.9
LGE	C1S	930883	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	930884	10/2018	10/12/2018	100	100.01	99.96
LGE	C1S	930885	10/2018	10/12/2018	100.01	99.94	99.89
LGE	C1S	930886	10/2018	10/12/2018	99.99	99.97	99.9
LGE	C1S	930887	10/2018	10/12/2018	99.97	99.98	99.97
LGE	C1S	930888	10/2018	10/12/2018	99.98	99.97	99.92
LGE	C1S	930889	10/2018	10/12/2018	99.99	99.96	99.93
LGE	C1S	930890	10/2018	10/12/2018	100	99.94	99.94
LGE	C1S	930891	10/2018	10/12/2018	100.01	99.94	99.94
LGE	C1S	930892	10/2018	10/12/2018	100.02	99.98	99.93

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930893	10/2018	10/12/2018	100	99.96	99.94
LGE	C1S	930894	10/2018	10/12/2018	100.02	99.94	99.92
LGE	C1S	930895	10/2018	10/12/2018	100.02	99.98	99.95
LGE	C1S	930896	10/2018	10/12/2018	100.03	99.97	99.93
LGE	C1S	930897	10/2018	10/12/2018	100	99.95	99.95
LGE	C1S	930898	10/2018	10/12/2018	99.96	99.99	99.92
LGE	C1S	930899	10/2018	10/12/2018	99.98	99.97	99.9
LGE	C1S	930900	10/2018	10/12/2018	100	99.96	99.94
LGE	C1S	930901	10/2018	10/12/2018	99.96	99.99	99.95
LGE	C1S	930902	10/2018	10/12/2018	100.01	99.99	99.97
LGE	C1S	930903	10/2018	10/12/2018	99.98	99.98	99.95
LGE	C1S	930904	10/2018	10/12/2018	100	99.98	99.98
LGE	C1S	930905	10/2018	10/12/2018	100.01	99.97	99.92
LGE	C1S	930906	10/2018	10/12/2018	99.97	99.97	99.92
LGE	C1S	930907	10/2018	10/12/2018	99.97	99.97	99.94
LGE	C1S	930908	10/2018	10/12/2018	100.03	99.99	99.96
LGE	C1S	930909	10/2018	10/12/2018	99.97	99.96	99.97
LGE	C1S	930910	10/2018	10/12/2018	100.02	100	99.98
LGE	C1S	930911	10/2018	10/12/2018	99.99	99.95	99.96
LGE	C1S	930912	10/2018	10/12/2018	100.01	99.97	99.93
LGE	C1S	930913	10/2018	10/12/2018	99.98	99.97	99.95
LGE	C1S	930914	10/2018	10/12/2018	100.02	99.94	99.92
LGE	C1S	930915	10/2018	10/12/2018	99.98	99.97	99.93
LGE	C1S	930916	10/2018	10/12/2018	99.96	99.96	99.91
LGE	C1S	930917	10/2018	10/12/2018	99.98	99.98	99.97
LGE	C1S	930918	10/2018	10/12/2018	99.99	99.98	99.93
LGE	C1S	930919	10/2018	10/12/2018	100.01	99.98	99.94
LGE	C1S	930920	10/2018	10/12/2018	99.98	99.99	99.95
LGE	C1S	930921	10/2018	10/12/2018	100.02	99.97	99.94
LGE	C1S	930922	10/2018	10/12/2018	100.01	99.95	99.92
LGE	C1S	930923	10/2018	10/12/2018	100	99.98	99.97
LGE	C1S	930924	10/2018	10/12/2018	100	99.97	99.89
LGE	C1S	930925	10/2018	10/12/2018	100.01	100.05	99.94
LGE	C1S	930926	10/2018	10/12/2018	99.98	99.98	99.93
LGE	C1S	930927	10/2018	10/12/2018	100.01	99.94	99.92
LGE	C1S	930928	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930929	10/2018	10/12/2018	100.01	99.93	99.91
LGE	C1S	930930	10/2018	10/12/2018	99.99	100	99.92
LGE	C1S	930931	10/2018	10/12/2018	100	99.96	99.92
LGE	C1S	930932	10/2018	10/12/2018	100.01	99.97	99.95
LGE	C1S	930933	10/2018	10/12/2018	100.01	99.97	99.96
LGE	C1S	930934	10/2018	10/12/2018	100.02	99.96	99.95

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930935	10/2018	10/12/2018	99.99	99.94	99.92
LGE	C1S	930936	10/2018	10/12/2018	99.98	100.01	99.95
LGE	C1S	930937	10/2018	10/12/2018	100.02	100	99.93
LGE	C1S	930938	10/2018	10/12/2018	99.99	99.98	99.93
LGE	C1S	930939	10/2018	10/12/2018	99.97	99.99	99.98
LGE	C1S	930940	10/2018	10/12/2018	100	99.93	99.92
LGE	C1S	930941	10/2018	10/12/2018	100	99.95	99.95
LGE	C1S	930942	10/2018	10/12/2018	99.98	99.95	99.89
LGE	C1S	930943	10/2018	10/12/2018	100	99.97	99.97
LGE	C1S	930944	10/2018	10/12/2018	99.99	99.98	99.92
LGE	C1S	930945	10/2018	10/12/2018	100	99.96	99.94
LGE	C1S	930946	10/2018	10/12/2018	100.01	99.93	99.93
LGE	C1S	930947	10/2018	10/12/2018	99.99	99.97	100
LGE	C1S	930948	10/2018	10/12/2018	100.02	99.97	99.91
LGE	C1S	930949	10/2018	10/12/2018	100	99.98	99.93
LGE	C1S	930950	10/2018	10/12/2018	100.02	99.96	99.95
LGE	C1S	930951	10/2018	10/12/2018	100	99.96	99.92
LGE	C1S	930952	10/2018	10/12/2018	100	99.99	99.98
LGE	C1S	930953	10/2018	10/12/2018	100.03	99.95	99.91
LGE	C1S	930954	10/2018	10/12/2018	100.01	100.03	99.92
LGE	C1S	930955	10/2018	10/12/2018	100.02	100.03	99.89
LGE	C1S	930956	10/2018	10/12/2018	100	100.07	99.98
LGE	C1S	930957	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	930958	10/2018	10/12/2018	100.03	100.05	100
LGE	C1S	930959	10/2018	10/12/2018	100.03	100.05	99.99
LGE	C1S	930960	10/2018	10/12/2018	99.98	100.02	99.95
LGE	C1S	930961	10/2018	10/12/2018	100	100.06	99.98
LGE	C1S	930962	10/2018	10/12/2018	100.01	100.05	99.95
LGE	C1S	930963	10/2018	10/12/2018	99.98	100.05	100.01
LGE	C1S	930964	10/2018	10/12/2018	100.02	100.01	99.94
LGE	C1S	930965	10/2018	10/12/2018	99.98	100	99.92
LGE	C1S	930966	10/2018	10/12/2018	100.02	99.97	99.92
LGE	C1S	930967	10/2018	10/12/2018	99.97	99.98	99.9
LGE	C1S	930968	10/2018	10/12/2018	100.04	99.99	99.92
LGE	C1S	930969	10/2018	10/12/2018	99.99	100.03	99.96
LGE	C1S	930970	10/2018	10/12/2018	100	100	99.94
LGE	C1S	930971	10/2018	10/12/2018	100.03	100	99.99
LGE	C1S	930972	10/2018	10/12/2018	100.05	100	99.96
LGE	C1S	930973	10/2018	10/12/2018	99.99	100.01	99.94
LGE	C1S	930974	10/2018	10/12/2018	99.98	99.98	99.94
LGE	C1S	930975	10/2018	10/12/2018	100.01	100.01	99.92
LGE	C1S	930976	10/2018	10/12/2018	99.97	100.01	99.96



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	930977	10/2018	10/12/2018	99.98	100.03	99.95
LGE	C1S	930978	10/2018	10/12/2018	99.97	99.98	99.94
LGE	C1S	930979	10/2018	10/12/2018	99.96	100.06	99.97
LGE	C1S	930980	10/2018	10/12/2018	100.01	100.03	99.98
LGE	C1S	930981	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	930982	10/2018	10/12/2018	100	100.04	99.91
LGE	C1S	930983	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	930984	10/2018	10/12/2018	100	99.99	99.92
LGE	C1S	930985	10/2018	10/12/2018	100	100	99.91
LGE	C1S	930986	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	930987	10/2018	10/12/2018	99.99	99.98	100
LGE	C1S	930988	10/2018	10/12/2018	99.99	100.01	99.95
LGE	C1S	930989	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	930990	10/2018	10/12/2018	99.99	100.01	99.95
LGE	C1S	930991	10/2018	10/12/2018	99.98	99.99	99.95
LGE	C1S	930992	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	930993	10/2018	10/12/2018	99.99	100.02	99.94
LGE	C1S	930994	10/2018	10/12/2018	100	100	99.94
LGE	C1S	930995	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	930996	10/2018	10/12/2018	99.99	100	99.95
LGE	C1S	930997	10/2018	10/12/2018	99.98	99.98	99.9
LGE	C1S	930998	10/2018	10/12/2018	100.05	100.03	100
LGE	C1S	930999	10/2018	10/12/2018	99.98	100	99.91
LGE	C1S	931000	10/2018	10/12/2018	100.04	99.99	99.92
LGE	C1S	931001	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931002	10/2018	10/12/2018	100	100	99.9
LGE	C1S	931003	10/2018	10/12/2018	100.01	100	99.95
LGE	C1S	931004	10/2018	10/12/2018	100	100.01	99.92
LGE	C1S	931005	10/2018	10/12/2018	100.06	100	99.99
LGE	C1S	931006	10/2018	10/12/2018	99.99	100.01	99.96
LGE	C1S	931007	10/2018	10/12/2018	100.03	99.99	99.92
LGE	C1S	931008	10/2018	10/12/2018	100	100.06	100.01
LGE	C1S	931009	10/2018	10/12/2018	99.98	100.01	99.97
LGE	C1S	931010	10/2018	10/12/2018	100.01	99.91	99.91
LGE	C1S	931011	10/2018	10/12/2018	99.98	100.01	99.97
LGE	C1S	931012	10/2018	10/12/2018	100.01	100.01	99.92
LGE	C1S	931013	10/2018	10/12/2018	99.99	100.05	99.95
LGE	C1S	931014	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	931015	10/2018	10/12/2018	100.04	100.02	99.95
LGE	C1S	931016	10/2018	10/12/2018	99.99	100.01	99.94
LGE	C1S	931017	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	931018	10/2018	10/12/2018	100.02	99.97	99.97

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931019	10/2018	10/12/2018	99.99	100.01	99.96
LGE	C1S	931020	10/2018	10/12/2018	99.98	100.02	99.95
LGE	C1S	931021	10/2018	10/12/2018	99.99	100	99.95
LGE	C1S	931022	10/2018	10/12/2018	99.95	100.02	99.96
LGE	C1S	931023	10/2018	10/12/2018	100	100	99.94
LGE	C1S	931024	10/2018	10/12/2018	100.01	100	99.92
LGE	C1S	931025	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	931026	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	931027	10/2018	10/12/2018	99.98	100.02	99.99
LGE	C1S	931028	10/2018	10/12/2018	100	100.01	99.95
LGE	C1S	931029	10/2018	10/12/2018	99.98	100.01	99.91
LGE	C1S	931030	10/2018	10/12/2018	100.01	100.05	99.99
LGE	C1S	931031	10/2018	10/12/2018	100	100.03	100.01
LGE	C1S	931032	10/2018	10/12/2018	100.04	100.04	99.95
LGE	C1S	931033	10/2018	10/12/2018	100.01	100.01	99.97
LGE	C1S	931034	10/2018	10/12/2018	100.03	100.01	99.93
LGE	C1S	931035	10/2018	10/12/2018	100.02	100.03	99.95
LGE	C1S	931036	10/2018	10/12/2018	99.99	100.03	99.95
LGE	C1S	931037	10/2018	10/12/2018	99.97	100.07	100.03
LGE	C1S	931038	10/2018	10/12/2018	99.99	100.02	99.96
LGE	C1S	931039	10/2018	10/12/2018	100.04	99.99	99.95
LGE	C1S	931040	10/2018	10/12/2018	100	100.06	100
LGE	C1S	931041	10/2018	10/12/2018	100.03	100.05	100.02
LGE	C1S	931042	10/2018	10/12/2018	100	100.07	99.99
LGE	C1S	931043	10/2018	10/12/2018	99.97	99.99	99.95
LGE	C1S	931044	10/2018	10/12/2018	99.99	100.05	99.97
LGE	C1S	931045	10/2018	10/12/2018	100.01	100.05	99.98
LGE	C1S	931046	10/2018	10/12/2018	100.01	100.06	100
LGE	C1S	931047	10/2018	10/12/2018	99.99	100.05	99.99
LGE	C1S	931048	10/2018	10/12/2018	99.98	100.05	99.98
LGE	C1S	931049	10/2018	10/12/2018	100	100.01	99.91
LGE	C1S	931050	10/2018	10/12/2018	99.99	100.04	99.98
LGE	C1S	931051	10/2018	10/12/2018	99.98	100	99.95
LGE	C1S	931052	10/2018	10/12/2018	100	100.05	99.96
LGE	C1S	931053	10/2018	10/12/2018	99.99	100.07	99.98
LGE	C1S	931054	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	931055	10/2018	10/12/2018	100	100.06	100
LGE	C1S	931056	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	931057	10/2018	10/12/2018	100.03	100.01	100
LGE	C1S	931058	10/2018	10/12/2018	100.01	100.07	100
LGE	C1S	931059	10/2018	10/12/2018	100.03	100.01	100
LGE	C1S	931060	10/2018	10/12/2018	100.03	99.95	99.88

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931061	10/2018	10/12/2018	100.01	100	99.9
LGE	C1S	931062	10/2018	10/12/2018	99.99	100.01	100.01
LGE	C1S	931063	10/2018	10/12/2018	100	100.04	99.95
LGE	C1S	931064	10/2018	10/12/2018	99.97	100.04	99.98
LGE	C1S	931065	10/2018	10/12/2018	100.01	100.01	99.98
LGE	C1S	931066	10/2018	10/12/2018	99.98	100.05	99.98
LGE	C1S	931067	10/2018	10/12/2018	100	99.99	99.92
LGE	C1S	931068	10/2018	10/12/2018	100.02	99.98	99.94
LGE	C1S	931069	10/2018	10/12/2018	100.01	100.06	100.03
LGE	C1S	931070	10/2018	10/12/2018	100.01	100.07	99.96
LGE	C1S	931071	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931072	10/2018	10/12/2018	99.98	100	100.03
LGE	C1S	931073	10/2018	10/12/2018	100.03	100.05	99.95
LGE	C1S	931074	10/2018	10/12/2018	100	100.02	99.96
LGE	C1S	931075	10/2018	10/12/2018	100	100.05	100
LGE	C1S	931076	10/2018	10/12/2018	99.98	100.02	99.95
LGE	C1S	931077	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	931078	10/2018	10/12/2018	100.02	100	99.94
LGE	C1S	931079	10/2018	10/12/2018	100	100	99.92
LGE	C1S	931080	10/2018	10/12/2018	100.02	100.03	99.92
LGE	C1S	931081	10/2018	10/12/2018	99.99	99.99	99.93
LGE	C1S	931082	10/2018	10/12/2018	100	100.02	99.98
LGE	C1S	931083	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	931084	10/2018	10/12/2018	99.99	100.03	99.95
LGE	C1S	931085	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	931086	10/2018	10/12/2018	100.02	100.05	99.98
LGE	C1S	931087	10/2018	10/12/2018	99.99	100.04	99.93
LGE	C1S	931088	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	931089	10/2018	10/12/2018	99.99	100	99.94
LGE	C1S	931090	10/2018	10/12/2018	100.04	100.01	99.95
LGE	C1S	931091	10/2018	10/12/2018	99.99	100.03	99.92
LGE	C1S	931092	10/2018	10/12/2018	99.98	100.02	99.93
LGE	C1S	931093	10/2018	10/12/2018	100.04	100.06	99.93
LGE	C1S	931094	10/2018	10/12/2018	100.02	100.03	99.93
LGE	C1S	931095	10/2018	10/12/2018	99.99	100.04	99.94
LGE	C1S	931096	10/2018	10/12/2018	99.99	100	99.93
LGE	C1S	931097	10/2018	10/12/2018	100.02	100	99.8
LGE	C1S	931098	10/2018	10/12/2018	100.01	100	99.89
LGE	C1S	931099	10/2018	10/12/2018	99.99	99.99	99.9
LGE	C1S	931100	10/2018	10/12/2018	100.03	100.02	99.92
LGE	C1S	931101	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	931102	10/2018	10/12/2018	100.03	100.06	99.97



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931103	10/2018	10/12/2018	99.98	100.03	99.95
LGE	C1S	931104	10/2018	10/12/2018	99.97	100.06	99.93
LGE	C1S	931105	10/2018	10/12/2018	99.98	100.02	99.91
LGE	C1S	931106	10/2018	10/12/2018	99.97	100.03	99.95
LGE	C1S	931107	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	931108	10/2018	10/12/2018	99.99	100.02	99.93
LGE	C1S	931109	10/2018	10/12/2018	99.99	100.04	99.95
LGE	C1S	931110	10/2018	10/12/2018	100	99.99	99.92
LGE	C1S	931111	10/2018	10/12/2018	99.99	100.02	99.93
LGE	C1S	931112	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	931113	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	931114	10/2018	10/12/2018	100.01	100.03	99.93
LGE	C1S	931115	10/2018	10/12/2018	100.01	99.98	99.9
LGE	C1S	931116	10/2018	10/12/2018	99.99	100.06	99.96
LGE	C1S	931117	10/2018	10/12/2018	99.99	100	99.92
LGE	C1S	931118	10/2018	10/12/2018	99.98	99.99	99.92
LGE	C1S	931119	10/2018	10/12/2018	100	100	99.91
LGE	C1S	931120	10/2018	10/12/2018	99.98	100.03	99.98
LGE	C1S	931121	10/2018	10/12/2018	100	100	99.89
LGE	C1S	931122	10/2018	10/12/2018	100.02	100.01	99.94
LGE	C1S	931123	10/2018	10/12/2018	99.98	100.01	99.94
LGE	C1S	931124	10/2018	10/12/2018	99.99	100	99.97
LGE	C1S	931125	10/2018	10/12/2018	100	99.99	99.94
LGE	C1S	931126	10/2018	10/12/2018	100	100.01	99.91
LGE	C1S	931127	10/2018	10/12/2018	100.01	100.03	99.93
LGE	C1S	931128	10/2018	10/12/2018	100.02	99.99	99.92
LGE	C1S	931129	10/2018	10/12/2018	99.99	99.99	99.92
LGE	C1S	931130	10/2018	10/12/2018	100.01	99.99	99.96
LGE	C1S	931131	10/2018	10/12/2018	100	100.05	99.98
LGE	C1S	931132	10/2018	10/12/2018	100.05	99.99	99.9
LGE	C1S	931133	10/2018	10/12/2018	100.02	100.07	99.99
LGE	C1S	931134	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	931135	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	931136	10/2018	10/12/2018	99.98	100.01	99.9
LGE	C1S	931137	10/2018	10/12/2018	100	100	99.9
LGE	C1S	931138	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931139	10/2018	10/12/2018	100	100.04	99.93
LGE	C1S	931140	10/2018	10/12/2018	99.98	100.05	99.93
LGE	C1S	931141	10/2018	10/12/2018	100.02	100.04	99.99
LGE	C1S	931142	10/2018	10/12/2018	100.03	100.03	99.96
LGE	C1S	931143	10/2018	10/12/2018	100.01	100.05	99.92
LGE	C1S	931144	10/2018	10/12/2018	100.02	100.01	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931145	10/2018	10/12/2018	99.98	100.03	99.95
LGE	C1S	931146	10/2018	10/12/2018	100	100.02	99.94
LGE	C1S	931147	10/2018	10/12/2018	100.02	100.01	99.9
LGE	C1S	931148	10/2018	10/12/2018	100.02	99.99	99.92
LGE	C1S	931149	10/2018	10/12/2018	100	100.02	99.88
LGE	C1S	931150	10/2018	10/12/2018	100.04	100.01	99.9
LGE	C1S	931151	10/2018	10/12/2018	100	100.04	99.92
LGE	C1S	931152	10/2018	10/12/2018	99.99	100.05	99.94
LGE	C1S	931153	10/2018	10/12/2018	100.02	100.03	99.91
LGE	C1S	931154	10/2018	10/12/2018	100.01	100.03	99.9
LGE	C1S	931155	10/2018	10/12/2018	99.97	100.03	99.95
LGE	C1S	931156	10/2018	10/12/2018	99.99	99.97	99.86
LGE	C1S	931157	10/2018	10/12/2018	99.96	100.01	99.92
LGE	C1S	931158	10/2018	10/12/2018	100.01	100	99.88
LGE	C1S	931159	10/2018	10/12/2018	100.01	100.02	99.91
LGE	C1S	931160	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	931161	10/2018	10/12/2018	100	100	99.93
LGE	C1S	931162	10/2018	10/12/2018	99.98	100.01	99.89
LGE	C1S	931163	10/2018	10/12/2018	100.03	100.05	99.93
LGE	C1S	931164	10/2018	10/12/2018	100	100.02	99.91
LGE	C1S	931165	10/2018	10/12/2018	100	100.03	99.95
LGE	C1S	931166	10/2018	10/12/2018	100	100.03	99.9
LGE	C1S	931167	10/2018	10/12/2018	100.01	100	99.91
LGE	C1S	931168	10/2018	10/12/2018	99.99	100	99.93
LGE	C1S	931169	10/2018	10/12/2018	100.02	100.01	99.9
LGE	C1S	931170	10/2018	10/12/2018	100.04	100.04	99.99
LGE	C1S	931171	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931172	10/2018	10/12/2018	99.97	100.04	100.03
LGE	C1S	931173	10/2018	10/12/2018	100	100.04	99.96
LGE	C1S	931174	10/2018	10/12/2018	100.02	100.04	99.95
LGE	C1S	931175	10/2018	10/12/2018	100.01	99.99	99.89
LGE	C1S	931176	10/2018	10/12/2018	99.98	100.02	99.96
LGE	C1S	931177	10/2018	10/12/2018	100.04	100.04	99.96
LGE	C1S	931178	10/2018	10/12/2018	99.98	100.04	99.95
LGE	C1S	931179	10/2018	10/12/2018	100.01	100	99.94
LGE	C1S	931180	10/2018	10/12/2018	100.01	100.01	99.9
LGE	C1S	931181	10/2018	10/12/2018	99.99	100.05	99.93
LGE	C1S	931182	10/2018	10/12/2018	100	100.02	99.94
LGE	C1S	931183	10/2018	10/12/2018	100.03	99.98	99.91
LGE	C1S	931184	10/2018	10/12/2018	100.02	100.02	99.96
LGE	C1S	931185	10/2018	10/12/2018	99.98	99.99	99.93
LGE	C1S	931186	10/2018	10/12/2018	100.01	100.01	99.91

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931187	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	931188	10/2018	10/12/2018	100	100.03	99.96
LGE	C1S	931189	10/2018	10/12/2018	100.01	100	99.94
LGE	C1S	931190	10/2018	10/12/2018	99.97	100.01	99.93
LGE	C1S	931191	10/2018	10/12/2018	100	100	99.92
LGE	C1S	931192	10/2018	10/12/2018	99.98	100.03	99.93
LGE	C1S	931193	10/2018	10/12/2018	100.01	100.02	99.94
LGE	C1S	931194	10/2018	10/12/2018	99.97	99.98	99.91
LGE	C1S	931195	10/2018	10/12/2018	99.98	100.01	99.93
LGE	C1S	931196	10/2018	10/12/2018	100.01	99.97	99.88
LGE	C1S	931197	10/2018	10/12/2018	100.05	100.03	99.98
LGE	C1S	931198	10/2018	10/12/2018	100	100.04	100
LGE	C1S	931199	10/2018	10/12/2018	100	100.01	100
LGE	C1S	931200	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	931201	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	931202	10/2018	10/12/2018	99.98	100.02	99.94
LGE	C1S	931203	10/2018	10/12/2018	99.99	100.02	99.96
LGE	C1S	931204	10/2018	10/12/2018	99.98	100.04	99.97
LGE	C1S	931205	10/2018	10/12/2018	100.02	100.03	99.99
LGE	C1S	931206	10/2018	10/12/2018	100.02	100.03	99.99
LGE	C1S	931207	10/2018	10/12/2018	99.99	100.02	99.97
LGE	C1S	931208	10/2018	10/12/2018	100.01	100.01	99.94
LGE	C1S	931209	10/2018	10/12/2018	100	100.01	99.98
LGE	C1S	931210	10/2018	10/12/2018	100.02	99.98	99.91
LGE	C1S	931211	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	931212	10/2018	10/12/2018	99.96	100.04	99.97
LGE	C1S	931213	10/2018	10/12/2018	100.03	100.04	99.94
LGE	C1S	931214	10/2018	10/12/2018	99.99	100.03	99.97
LGE	C1S	931215	10/2018	10/12/2018	99.99	100	99.96
LGE	C1S	931216	10/2018	10/12/2018	99.97	100.02	99.94
LGE	C1S	931217	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	931218	10/2018	10/12/2018	100.02	100.01	99.99
LGE	C1S	931219	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	931220	10/2018	10/12/2018	100.02	99.99	99.9
LGE	C1S	931221	10/2018	10/12/2018	100	100.03	99.97
LGE	C1S	931222	10/2018	10/12/2018	99.98	100.02	99.91
LGE	C1S	931223	10/2018	10/12/2018	100.03	100.01	99.92
LGE	C1S	931224	10/2018	10/12/2018	100	100.02	99.94
LGE	C1S	931225	10/2018	10/12/2018	100.01	100.02	99.91
LGE	C1S	931226	10/2018	10/12/2018	99.99	100.02	100
LGE	C1S	931227	10/2018	10/12/2018	100	100.01	99.94
LGE	C1S	931228	10/2018	10/12/2018	99.99	100.01	99.95



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931229	10/2018	10/12/2018	100.02	100.03	100
LGE	C1S	931230	10/2018	10/12/2018	99.99	100.06	99.99
LGE	C1S	931231	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	931232	10/2018	10/12/2018	99.99	100.01	99.94
LGE	C1S	931233	10/2018	10/12/2018	100.01	100.05	99.95
LGE	C1S	931234	10/2018	10/12/2018	99.98	100.02	99.96
LGE	C1S	931235	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	931236	10/2018	10/12/2018	99.98	100.04	99.96
LGE	C1S	931237	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	931238	10/2018	10/12/2018	100.02	100.04	100.02
LGE	C1S	931239	10/2018	10/12/2018	100.01	99.99	99.9
LGE	C1S	931240	10/2018	10/12/2018	100.03	100.03	99.93
LGE	C1S	931241	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	931242	10/2018	10/12/2018	99.97	99.98	99.9
LGE	C1S	931243	10/2018	10/12/2018	100.02	100	99.95
LGE	C1S	931244	10/2018	10/12/2018	100	100.04	99.94
LGE	C1S	931245	10/2018	10/12/2018	100.01	100.01	99.9
LGE	C1S	931246	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	931247	10/2018	10/12/2018	100.01	99.98	99.9
LGE	C1S	931248	10/2018	10/12/2018	100	100.01	99.95
LGE	C1S	931249	10/2018	10/12/2018	100.02	100.04	99.91
LGE	C1S	931250	10/2018	10/12/2018	100.04	100.02	99.96
LGE	C1S	931251	10/2018	10/12/2018	100	100.02	100
LGE	C1S	931252	10/2018	10/12/2018	100.03	100.02	99.92
LGE	C1S	931253	10/2018	10/12/2018	99.99	100.03	99.98
LGE	C1S	931254	10/2018	10/12/2018	99.96	100.03	99.95
LGE	C1S	931255	10/2018	10/12/2018	99.99	100	99.93
LGE	C1S	931256	10/2018	10/12/2018	100.01	100.03	99.96
LGE	C1S	931257	10/2018	10/12/2018	100	100.05	99.93
LGE	C1S	931258	10/2018	10/12/2018	99.99	99.99	99.91
LGE	C1S	931259	10/2018	10/12/2018	100	100.02	99.95
LGE	C1S	931260	10/2018	10/12/2018	100	99.98	99.91
LGE	C1S	931261	10/2018	10/12/2018	100.02	100	99.91
LGE	C1S	931262	10/2018	10/12/2018	99.98	100.05	100.01
LGE	C1S	931263	10/2018	10/12/2018	100.02	100.04	99.96
LGE	C1S	931264	10/2018	10/12/2018	99.99	99.99	99.93
LGE	C1S	931265	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931266	10/2018	10/12/2018	100.04	100.01	99.95
LGE	C1S	931267	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	931268	10/2018	10/12/2018	99.99	99.98	99.88
LGE	C1S	931269	10/2018	10/12/2018	100.01	100.04	100
LGE	C1S	931270	10/2018	10/12/2018	100.03	100.02	99.92

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931271	10/2018	10/12/2018	100.03	99.99	99.91
LGE	C1S	931272	10/2018	10/12/2018	100.01	100.05	99.98
LGE	C1S	931273	10/2018	10/12/2018	100	100.02	99.95
LGE	C1S	931274	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931275	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	931276	10/2018	10/12/2018	100.02	99.96	99.93
LGE	C1S	931277	10/2018	10/12/2018	99.99	100.04	99.9
LGE	C1S	931278	10/2018	10/12/2018	99.99	99.98	99.91
LGE	C1S	931279	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	931280	10/2018	10/12/2018	100	100.01	99.91
LGE	C1S	931281	10/2018	10/12/2018	99.97	100.04	99.99
LGE	C1S	931282	10/2018	10/12/2018	100.03	100.01	99.95
LGE	C1S	931283	10/2018	10/12/2018	99.96	100	99.95
LGE	C1S	931284	10/2018	10/12/2018	99.98	100.06	99.94
LGE	C1S	931285	10/2018	10/12/2018	100.02	100.02	99.91
LGE	C1S	931286	10/2018	10/12/2018	99.99	100	99.99
LGE	C1S	931287	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	931288	10/2018	10/12/2018	100.01	100.01	99.89
LGE	C1S	931289	10/2018	10/12/2018	100	100	99.92
LGE	C1S	931290	10/2018	10/12/2018	99.99	99.96	99.93
LGE	C1S	931291	10/2018	10/12/2018	99.98	100.04	99.93
LGE	C1S	931292	10/2018	10/12/2018	100.02	100	99.92
LGE	C1S	931293	10/2018	10/12/2018	100	99.98	99.94
LGE	C1S	931294	10/2018	10/12/2018	100.02	100	99.89
LGE	C1S	931295	10/2018	10/12/2018	99.99	99.97	99.92
LGE	C1S	931296	10/2018	10/12/2018	99.97	99.98	99.94
LGE	C1S	931297	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931298	10/2018	10/12/2018	99.97	100.02	99.96
LGE	C1S	931299	10/2018	10/12/2018	100.05	99.96	99.91
LGE	C1S	931300	10/2018	10/12/2018	100.02	99.98	99.86
LGE	C1S	931301	10/2018	10/12/2018	99.97	99.98	99.97
LGE	C1S	931302	10/2018	10/12/2018	100.03	100	99.88
LGE	C1S	931303	10/2018	10/12/2018	99.99	100.02	99.88
LGE	C1S	931304	10/2018	10/12/2018	100.01	99.98	99.94
LGE	C1S	931305	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	931306	10/2018	10/12/2018	100.04	100.05	99.94
LGE	C1S	931307	10/2018	10/12/2018	100.02	100.03	99.97
LGE	C1S	931308	10/2018	10/12/2018	99.98	100.02	99.94
LGE	C1S	931309	10/2018	10/12/2018	99.99	100.02	99.9
LGE	C1S	931310	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	931311	10/2018	10/12/2018	99.98	100.04	99.97
LGE	C1S	931312	10/2018	10/12/2018	100	100.02	99.91

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931313	10/2018	10/12/2018	100.02	99.99	99.93
LGE	C1S	931314	10/2018	10/12/2018	99.99	100.03	99.92
LGE	C1S	931315	10/2018	10/12/2018	100	100.01	99.87
LGE	C1S	931316	10/2018	10/12/2018	100	100	99.97
LGE	C1S	931317	10/2018	10/12/2018	100	99.95	99.95
LGE	C1S	931318	10/2018	10/12/2018	100.01	100.01	99.9
LGE	C1S	931319	10/2018	10/12/2018	100.01	100.04	99.95
LGE	C1S	931320	10/2018	10/12/2018	99.97	100	99.96
LGE	C1S	931321	10/2018	10/12/2018	100	100.02	99.91
LGE	C1S	931322	10/2018	10/12/2018	100.01	100.03	99.91
LGE	C1S	931323	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931324	10/2018	10/12/2018	99.97	100.01	99.91
LGE	C1S	931325	10/2018	10/12/2018	99.98	99.99	99.95
LGE	C1S	931326	10/2018	10/12/2018	99.99	99.99	99.91
LGE	C1S	931327	10/2018	10/12/2018	100.02	100.05	99.92
LGE	C1S	931328	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931329	10/2018	10/12/2018	100	100.02	99.89
LGE	C1S	931330	10/2018	10/12/2018	100.04	100	99.92
LGE	C1S	931331	10/2018	10/12/2018	99.97	100.01	99.97
LGE	C1S	931332	10/2018	10/12/2018	99.99	100.04	99.94
LGE	C1S	931333	10/2018	10/12/2018	100.02	100	99.9
LGE	C1S	931334	10/2018	10/12/2018	100	100	99.93
LGE	C1S	931335	10/2018	10/12/2018	99.96	100.04	99.93
LGE	C1S	931336	10/2018	10/12/2018	100.01	99.99	99.92
LGE	C1S	931337	10/2018	10/12/2018	99.97	100.02	99.94
LGE	C1S	931338	10/2018	10/12/2018	100	100.04	99.92
LGE	C1S	931339	10/2018	10/12/2018	100.02	100.01	99.91
LGE	C1S	931340	10/2018	10/12/2018	100	100.08	100.02
LGE	C1S	931341	10/2018	10/12/2018	100.03	100.06	99.97
LGE	C1S	931342	10/2018	10/12/2018	99.98	100.01	99.91
LGE	C1S	931343	10/2018	10/12/2018	99.99	100.07	99.97
LGE	C1S	931344	10/2018	10/12/2018	99.97	100.02	99.94
LGE	C1S	931345	10/2018	10/12/2018	99.97	100.02	99.9
LGE	C1S	931346	10/2018	10/12/2018	99.98	99.99	99.88
LGE	C1S	931347	10/2018	10/12/2018	99.99	99.98	99.91
LGE	C1S	931348	10/2018	10/12/2018	100.01	100.04	100.02
LGE	C1S	931349	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	931350	10/2018	10/12/2018	99.99	100.04	99.92
LGE	C1S	931351	10/2018	10/12/2018	100.03	100.03	99.96
LGE	C1S	931352	10/2018	10/12/2018	100	100.06	99.99
LGE	C1S	931353	10/2018	10/12/2018	99.99	100.03	99.9
LGE	C1S	931354	10/2018	10/12/2018	100.05	100.01	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931355	10/2018	10/12/2018	99.98	100.04	99.95
LGE	C1S	931356	10/2018	10/12/2018	100	100.07	99.96
LGE	C1S	931357	10/2018	10/12/2018	100	100.03	99.98
LGE	C1S	931358	10/2018	10/12/2018	100.01	99.96	99.91
LGE	C1S	931359	10/2018	10/12/2018	100.04	99.96	99.91
LGE	C1S	931360	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	931361	10/2018	10/12/2018	100.04	100.04	99.96
LGE	C1S	931362	10/2018	10/12/2018	99.99	100	99.9
LGE	C1S	931363	10/2018	10/12/2018	99.99	99.98	99.91
LGE	C1S	931364	10/2018	10/12/2018	100.02	100.02	99.91
LGE	C1S	931365	10/2018	10/12/2018	99.99	100.05	99.97
LGE	C1S	931366	10/2018	10/12/2018	99.96	100.03	99.95
LGE	C1S	931367	10/2018	10/12/2018	100.02	100	99.93
LGE	C1S	931368	10/2018	10/12/2018	100	100.01	99.89
LGE	C1S	931369	10/2018	10/12/2018	100.02	100.02	99.99
LGE	C1S	931370	10/2018	10/12/2018	100.04	99.96	99.92
LGE	C1S	931371	10/2018	10/12/2018	99.99	99.99	99.95
LGE	C1S	931372	10/2018	10/12/2018	100	99.98	99.91
LGE	C1S	931373	10/2018	10/12/2018	100.01	99.95	99.95
LGE	C1S	931374	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	931375	10/2018	10/12/2018	99.94	100.06	99.93
LGE	C1S	931376	10/2018	10/12/2018	100.02	99.98	99.89
LGE	C1S	931377	10/2018	10/12/2018	100	100.02	99.89
LGE	C1S	931378	10/2018	10/12/2018	100.01	99.96	99.92
LGE	C1S	931379	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	931380	10/2018	10/12/2018	100.01	100.06	99.94
LGE	C1S	931381	10/2018	10/12/2018	100.01	99.99	99.95
LGE	C1S	931382	10/2018	10/12/2018	100.01	100.03	99.9
LGE	C1S	931383	10/2018	10/12/2018	100.03	100	99.92
LGE	C1S	931384	10/2018	10/12/2018	99.96	99.92	99.89
LGE	C1S	931385	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931386	10/2018	10/12/2018	99.99	100.01	99.98
LGE	C1S	931387	10/2018	10/12/2018	99.98	99.99	99.9
LGE	C1S	931388	10/2018	10/12/2018	100.02	100.02	99.96
LGE	C1S	931389	10/2018	10/12/2018	100	100.06	99.95
LGE	C1S	931390	10/2018	10/12/2018	99.99	100.03	99.91
LGE	C1S	931391	10/2018	10/12/2018	99.95	100.05	99.96
LGE	C1S	931392	10/2018	10/12/2018	99.98	100.03	99.96
LGE	C1S	931393	10/2018	10/12/2018	100	100.01	99.9
LGE	C1S	931394	10/2018	10/12/2018	100.01	99.99	99.88
LGE	C1S	931395	10/2018	10/12/2018	99.98	100.04	99.96
LGE	C1S	931396	10/2018	10/12/2018	100	100.02	99.94



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931397	10/2018	10/12/2018	100.01	100.04	99.94
LGE	C1S	931398	10/2018	10/12/2018	100.01	100.06	99.99
LGE	C1S	931399	10/2018	10/12/2018	100.01	100.01	99.9
LGE	C1S	931400	10/2018	10/12/2018	100.03	100.01	99.93
LGE	C1S	931401	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	931402	10/2018	10/12/2018	99.98	100	99.9
LGE	C1S	931403	10/2018	10/12/2018	99.95	100.05	99.95
LGE	C1S	931404	10/2018	10/12/2018	100	100.04	99.92
LGE	C1S	931405	10/2018	10/12/2018	100.01	100	99.93
LGE	C1S	931406	10/2018	10/12/2018	100.01	100	99.9
LGE	C1S	931407	10/2018	10/12/2018	100.01	100	99.94
LGE	C1S	931408	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	931409	10/2018	10/12/2018	100.02	99.98	99.92
LGE	C1S	931410	10/2018	10/12/2018	99.99	99.98	99.96
LGE	C1S	931411	10/2018	10/12/2018	99.98	100	99.92
LGE	C1S	931412	10/2018	10/12/2018	100.02	100.05	99.97
LGE	C1S	931413	10/2018	10/12/2018	100.03	100.01	99.93
LGE	C1S	931414	10/2018	10/12/2018	100.01	99.96	99.91
LGE	C1S	931415	10/2018	10/12/2018	99.98	99.93	99.9
LGE	C1S	931416	10/2018	10/12/2018	100.03	100.04	99.96
LGE	C1S	931417	10/2018	10/12/2018	99.97	100.04	99.91
LGE	C1S	931418	10/2018	10/12/2018	99.99	100.04	99.92
LGE	C1S	931419	10/2018	10/12/2018	99.97	100.02	100.01
LGE	C1S	931420	10/2018	10/12/2018	100	99.99	99.87
LGE	C1S	931421	10/2018	10/12/2018	100	100.02	99.94
LGE	C1S	931422	10/2018	10/12/2018	100.01	100.03	99.98
LGE	C1S	931423	10/2018	10/12/2018	100.03	100.01	99.93
LGE	C1S	931424	10/2018	10/12/2018	100.02	100.03	99.95
LGE	C1S	931425	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	931426	10/2018	10/12/2018	99.99	100.05	99.93
LGE	C1S	931427	10/2018	10/12/2018	99.99	99.99	99.92
LGE	C1S	931428	10/2018	10/12/2018	100.02	100.01	99.96
LGE	C1S	931429	10/2018	10/12/2018	99.96	100.03	99.91
LGE	C1S	931430	10/2018	10/12/2018	100	100.02	99.92
LGE	C1S	931431	10/2018	10/12/2018	100.04	100.06	99.93
LGE	C1S	931432	10/2018	10/12/2018	99.97	100.01	99.89
LGE	C1S	931433	10/2018	10/12/2018	99.98	99.99	99.94
LGE	C1S	931434	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	931435	10/2018	10/12/2018	99.98	100.07	99.96
LGE	C1S	931436	10/2018	10/12/2018	99.99	100.01	99.93
LGE	C1S	931437	10/2018	10/12/2018	100	100.06	99.98
LGE	C1S	931438	10/2018	10/12/2018	99.99	100.04	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931439	10/2018	10/12/2018	100.03	100.05	99.94
LGE	C1S	931440	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931441	10/2018	10/12/2018	99.98	100.01	99.91
LGE	C1S	931442	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931443	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	931444	10/2018	10/12/2018	100.01	99.99	99.91
LGE	C1S	931445	10/2018	10/12/2018	99.99	100.02	99.97
LGE	C1S	931446	10/2018	10/12/2018	100.04	100.02	99.97
LGE	C1S	931447	10/2018	10/12/2018	100	100.05	99.92
LGE	C1S	931448	10/2018	10/12/2018	100	100.03	99.95
LGE	C1S	931449	10/2018	10/12/2018	99.99	100	99.94
LGE	C1S	931450	10/2018	10/12/2018	100.05	100.06	99.99
LGE	C1S	931451	10/2018	10/12/2018	100.02	100.01	99.92
LGE	C1S	931452	10/2018	10/12/2018	99.97	100.04	99.94
LGE	C1S	931453	10/2018	10/12/2018	100.04	100	99.89
LGE	C1S	931454	10/2018	10/12/2018	100	99.99	99.96
LGE	C1S	931455	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	931456	10/2018	10/12/2018	99.98	100.03	99.96
LGE	C1S	931457	10/2018	10/12/2018	100	100.03	99.91
LGE	C1S	931458	10/2018	10/12/2018	100.02	100.04	99.95
LGE	C1S	931459	10/2018	10/12/2018	100	100.05	99.95
LGE	C1S	931460	10/2018	10/12/2018	99.98	100.02	99.92
LGE	C1S	931461	10/2018	10/12/2018	99.97	100.01	99.92
LGE	C1S	931462	10/2018	10/12/2018	99.99	100.05	99.93
LGE	C1S	931463	10/2018	10/12/2018	100	100	99.91
LGE	C1S	931464	10/2018	10/12/2018	100.02	100.01	99.93
LGE	C1S	931465	10/2018	10/12/2018	99.99	100.05	99.94
LGE	C1S	931466	10/2018	10/12/2018	100.01	100.01	99.88
LGE	C1S	931467	10/2018	10/12/2018	100	100.04	99.92
LGE	C1S	931468	10/2018	10/12/2018	99.98	100.05	99.9
LGE	C1S	931469	10/2018	10/12/2018	100.03	100.02	99.95
LGE	C1S	931470	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931471	10/2018	10/12/2018	99.98	100.03	99.91
LGE	C1S	931472	10/2018	10/12/2018	99.96	100	99.94
LGE	C1S	931473	10/2018	10/12/2018	99.96	100.02	99.9
LGE	C1S	931474	10/2018	10/12/2018	100.02	100.02	99.93
LGE	C1S	931475	10/2018	10/12/2018	100	100.03	99.94
LGE	C1S	931476	10/2018	10/12/2018	99.97	100.01	99.9
LGE	C1S	931477	10/2018	10/12/2018	100	100.01	99.92
LGE	C1S	931478	10/2018	10/12/2018	99.98	100.03	99.98
LGE	C1S	931479	10/2018	10/12/2018	100.01	100.07	99.98
LGE	C1S	931480	10/2018	10/12/2018	100.01	100.02	99.88

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931481	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	931482	10/2018	10/12/2018	100	100.08	100.02
LGE	C1S	931483	10/2018	10/12/2018	100.02	100.01	99.88
LGE	C1S	931484	10/2018	10/12/2018	99.98	100	99.9
LGE	C1S	931485	10/2018	10/12/2018	100.01	100.05	99.95
LGE	C1S	931486	10/2018	10/12/2018	100	100	99.95
LGE	C1S	931487	10/2018	10/12/2018	99.98	100.08	99.96
LGE	C1S	931488	10/2018	10/12/2018	99.99	99.97	99.89
LGE	C1S	931489	10/2018	10/12/2018	100	100.04	99.94
LGE	C1S	931490	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	931491	10/2018	10/12/2018	100.03	100	99.93
LGE	C1S	931492	10/2018	10/12/2018	100	100	99.94
LGE	C1S	931493	10/2018	10/12/2018	99.98	100	99.9
LGE	C1S	931494	10/2018	10/12/2018	100.01	100.05	99.98
LGE	C1S	931495	10/2018	10/12/2018	100.04	99.99	99.95
LGE	C1S	931496	10/2018	10/12/2018	99.98	99.99	99.88
LGE	C1S	931497	10/2018	10/12/2018	100.02	100.05	99.94
LGE	C1S	931498	10/2018	10/12/2018	100.02	100.01	99.9
LGE	C1S	931499	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	931500	10/2018	10/12/2018	99.99	100.03	99.91
LGE	C1S	931501	10/2018	10/12/2018	100.03	100.01	99.95
LGE	C1S	931502	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	931503	10/2018	10/12/2018	100.03	100.04	99.91
LGE	C1S	931504	10/2018	10/12/2018	99.99	100.03	99.93
LGE	C1S	931505	10/2018	10/12/2018	100.03	99.99	99.88
LGE	C1S	931506	10/2018	10/12/2018	99.99	100	99.95
LGE	C1S	931507	10/2018	10/12/2018	99.95	100.01	99.97
LGE	C1S	931508	10/2018	10/12/2018	100.01	99.99	99.93
LGE	C1S	931509	10/2018	10/12/2018	100.01	100.07	99.98
LGE	C1S	931510	10/2018	10/12/2018	100.01	100.02	99.93
LGE	C1S	931511	10/2018	10/12/2018	99.99	100.02	99.94
LGE	C1S	931512	10/2018	10/12/2018	100.03	100.01	99.95
LGE	C1S	931513	10/2018	10/12/2018	100.04	100	99.93
LGE	C1S	931514	10/2018	10/12/2018	100	100.06	99.97
LGE	C1S	931515	10/2018	10/12/2018	100	99.99	99.95
LGE	C1S	931516	10/2018	10/12/2018	100.01	100.02	99.91
LGE	C1S	931517	10/2018	10/12/2018	100	100.03	99.95
LGE	C1S	931518	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	931519	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	931520	10/2018	10/12/2018	100.02	100.06	99.94
LGE	C1S	931521	10/2018	10/12/2018	99.98	100.04	100.02
LGE	C1S	931522	10/2018	10/12/2018	99.98	100.04	99.93

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931523	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	931524	10/2018	10/12/2018	99.99	100.05	99.97
LGE	C1S	931525	10/2018	10/12/2018	100.03	100.01	99.9
LGE	C1S	931526	10/2018	10/12/2018	100.02	99.98	99.86
LGE	C1S	931527	10/2018	10/12/2018	99.97	99.98	99.95
LGE	C1S	931528	10/2018	10/12/2018	99.98	100.02	99.94
LGE	C1S	931529	10/2018	10/12/2018	100.01	99.97	99.88
LGE	C1S	931530	10/2018	10/12/2018	99.99	100.03	99.94
LGE	C1S	931531	10/2018	10/12/2018	100.02	100.03	99.98
LGE	C1S	931532	10/2018	10/12/2018	100.02	99.99	99.95
LGE	C1S	931533	10/2018	10/12/2018	100	100	99.93
LGE	C1S	931534	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931535	10/2018	10/12/2018	100.01	100.02	99.94
LGE	C1S	931536	10/2018	10/12/2018	100.02	100.02	99.93
LGE	C1S	931537	10/2018	10/12/2018	99.99	100.05	99.93
LGE	C1S	931538	10/2018	10/12/2018	100	100	99.9
LGE	C1S	931539	10/2018	10/12/2018	99.96	100.01	99.92
LGE	C1S	931540	10/2018	10/12/2018	100.01	99.98	99.9
LGE	C1S	931541	10/2018	10/12/2018	100	100.01	99.92
LGE	C1S	931542	10/2018	10/12/2018	99.99	100.01	99.88
LGE	C1S	931543	10/2018	10/12/2018	100	99.99	99.9
LGE	C1S	931544	10/2018	10/12/2018	100.02	100.06	99.97
LGE	C1S	931545	10/2018	10/12/2018	100.03	100	99.91
LGE	C1S	931546	10/2018	10/12/2018	99.96	100.01	99.98
LGE	C1S	931547	10/2018	10/12/2018	100.02	100.06	99.92
LGE	C1S	931548	10/2018	10/12/2018	100.01	100.01	99.92
LGE	C1S	931549	10/2018	10/12/2018	100.02	99.99	99.93
LGE	C1S	931550	10/2018	10/12/2018	100.01	100.02	99.96
LGE	C1S	931551	10/2018	10/12/2018	100.04	100.01	99.92
LGE	C1S	931552	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931553	10/2018	10/12/2018	100.01	100.02	99.9
LGE	C1S	931554	10/2018	10/12/2018	99.98	100.02	99.91
LGE	C1S	931555	10/2018	10/12/2018	100	100.02	99.93
LGE	C1S	931556	10/2018	10/12/2018	100.02	100.02	99.95
LGE	C1S	931557	10/2018	10/12/2018	100	100.02	99.97
LGE	C1S	931558	10/2018	10/12/2018	100	100.04	99.93
LGE	C1S	931559	10/2018	10/12/2018	99.99	100.08	100.03
LGE	C1S	931560	10/2018	10/12/2018	99.96	100.05	99.92
LGE	C1S	931561	10/2018	10/12/2018	99.98	99.94	99.89
LGE	C1S	931562	10/2018	10/12/2018	100.02	100.03	99.96
LGE	C1S	931563	10/2018	10/12/2018	100.01	100.04	99.95
LGE	C1S	931564	10/2018	10/12/2018	100	100.03	100.02



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931565	10/2018	10/12/2018	100	100.05	99.94
LGE	C1S	931566	10/2018	10/12/2018	99.96	100.04	99.95
LGE	C1S	931567	10/2018	10/12/2018	100.02	100.03	99.96
LGE	C1S	931568	10/2018	10/12/2018	100.03	100.02	99.97
LGE	C1S	931569	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931570	10/2018	10/12/2018	100.04	100.02	99.92
LGE	C1S	931571	10/2018	10/12/2018	99.98	100	99.91
LGE	C1S	931572	10/2018	10/12/2018	100.02	99.97	99.88
LGE	C1S	931573	10/2018	10/12/2018	99.98	100.08	99.94
LGE	C1S	931574	10/2018	10/12/2018	99.99	100.02	99.88
LGE	C1S	931575	10/2018	10/12/2018	99.98	100.07	99.95
LGE	C1S	931576	10/2018	10/12/2018	99.99	100.02	100
LGE	C1S	931577	10/2018	10/12/2018	99.96	100.05	99.99
LGE	C1S	931578	10/2018	10/12/2018	99.99	100.02	99.92
LGE	C1S	931579	10/2018	10/12/2018	99.99	99.96	99.94
LGE	C1S	931580	10/2018	10/12/2018	99.99	100.03	99.93
LGE	C1S	931581	10/2018	10/12/2018	99.99	100	99.97
LGE	C1S	931582	10/2018	10/12/2018	100	100.01	99.97
LGE	C1S	931583	10/2018	10/12/2018	100.02	100.04	99.93
LGE	C1S	931584	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	931585	10/2018	10/12/2018	100.01	100.04	99.96
LGE	C1S	931586	10/2018	10/12/2018	100.01	100.05	99.98
LGE	C1S	931587	10/2018	10/12/2018	100	100	99.92
LGE	C1S	931588	10/2018	10/12/2018	100.02	100.05	100.02
LGE	C1S	931589	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	931590	10/2018	10/12/2018	99.98	100.07	99.97
LGE	C1S	931591	10/2018	10/12/2018	99.99	100.02	99.95
LGE	C1S	931592	10/2018	10/12/2018	100.03	100.05	99.98
LGE	C1S	931593	10/2018	10/12/2018	100.02	100.02	99.92
LGE	C1S	931594	10/2018	10/12/2018	100.01	100.07	100
LGE	C1S	931595	10/2018	10/12/2018	100	100	99.92
LGE	C1S	931596	10/2018	10/12/2018	99.97	100	99.89
LGE	C1S	931597	10/2018	10/12/2018	100.02	100.01	99.95
LGE	C1S	931598	10/2018	10/12/2018	99.98	100	99.94
LGE	C1S	931599	10/2018	10/12/2018	100.01	100.02	99.95
LGE	C1S	931600	10/2018	10/12/2018	100.05	99.99	99.94
LGE	C1S	931601	10/2018	10/12/2018	100.01	100	99.96
LGE	C1S	931602	10/2018	10/12/2018	100.04	99.96	99.93
LGE	C1S	931603	10/2018	10/12/2018	99.98	100.06	99.97
LGE	C1S	931604	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	931605	10/2018	10/12/2018	100	99.94	99.92
LGE	C1S	931606	10/2018	10/12/2018	99.98	100.01	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931607	10/2018	10/12/2018	99.99	99.99	99.91
LGE	C1S	931608	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	931609	10/2018	10/12/2018	100.01	100.03	99.99
LGE	C1S	931610	10/2018	10/12/2018	99.97	99.99	99.9
LGE	C1S	931611	10/2018	10/12/2018	100.02	100.03	99.94
LGE	C1S	931612	10/2018	10/12/2018	100	100.03	99.96
LGE	C1S	931613	10/2018	10/12/2018	100.02	100.02	99.94
LGE	C1S	931614	10/2018	10/12/2018	100.02	100.01	99.93
LGE	C1S	931615	10/2018	10/12/2018	100	100.03	99.92
LGE	C1S	931616	10/2018	10/12/2018	100.02	100	99.96
LGE	C1S	931617	10/2018	10/12/2018	100.01	100.06	99.96
LGE	C1S	931618	10/2018	10/12/2018	99.99	100.06	99.96
LGE	C1S	931619	10/2018	10/12/2018	100	100.05	99.99
LGE	C1S	931620	10/2018	10/12/2018	100.03	100.03	99.94
LGE	C1S	931621	10/2018	10/12/2018	99.98	100.01	99.95
LGE	C1S	931622	10/2018	10/12/2018	100.04	100.03	99.93
LGE	C1S	931623	10/2018	10/12/2018	99.98	100.02	99.95
LGE	C1S	931624	10/2018	10/12/2018	100.03	100.02	100
LGE	C1S	931625	10/2018	10/12/2018	99.99	100.02	99.96
LGE	C1S	931626	10/2018	10/12/2018	100.03	100.09	100.03
LGE	C1S	931627	10/2018	10/12/2018	100.01	99.98	99.93
LGE	C1S	931628	10/2018	10/12/2018	100	100.06	99.99
LGE	C1S	931629	10/2018	10/12/2018	99.99	100.05	99.97
LGE	C1S	931630	10/2018	10/12/2018	100.01	100.03	99.95
LGE	C1S	931631	10/2018	10/12/2018	99.98	100.03	99.98
LGE	C1S	931632	10/2018	10/12/2018	100	100.01	99.95
LGE	C1S	931633	10/2018	10/12/2018	100.01	100.03	99.97
LGE	C1S	931634	10/2018	10/12/2018	100	100.06	99.98
LGE	C1S	931635	10/2018	10/12/2018	99.97	100.01	99.92
LGE	C1S	931636	10/2018	10/12/2018	100.03	100.07	99.96
LGE	C1S	931637	10/2018	10/12/2018	99.99	99.99	99.96
LGE	C1S	931638	10/2018	10/12/2018	100.03	100	99.91
LGE	C1S	931639	10/2018	10/12/2018	100.01	100	99.94
LGE	C1S	931640	10/2018	10/12/2018	100	100.03	99.93
LGE	C1S	931641	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931642	10/2018	10/12/2018	100.01	100.01	99.95
LGE	C1S	931643	10/2018	10/12/2018	99.99	100.01	99.92
LGE	C1S	931644	10/2018	10/12/2018	99.97	100.02	99.93
LGE	C1S	931645	10/2018	10/12/2018	100.01	100	99.91
LGE	C1S	931646	10/2018	10/12/2018	100.03	100.04	99.96
LGE	C1S	931647	10/2018	10/12/2018	100.03	100.05	100
LGE	C1S	931648	10/2018	10/12/2018	100	100.06	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1S	931649	10/2018	10/12/2018	99.98	100.03	99.97
LGE	C1S	931650	10/2018	10/12/2018	99.99	100.04	99.97
LGE	C1S	931651	10/2018	10/12/2018	100.02	100.04	99.98
LGE	C1S	931652	10/2018	10/12/2018	99.99	100.03	99.97
LGE	C1S	931653	10/2018	10/12/2018	99.99	100.01	99.95
LGE	C1S	931654	10/2018	10/12/2018	100	100.07	99.99
LGE	C1S	931655	10/2018	10/12/2018	100.01	100.04	99.93
LGE	C1S	931656	10/2018	10/12/2018	100.01	100.01	99.93
LGE	C1S	931657	10/2018	10/12/2018	99.99	100.04	99.97
LGE	C1S	931658	10/2018	10/12/2018	99.97	100.06	99.97
LGE	C1S	931659	10/2018	10/12/2018	100.04	100.01	99.89
LGE	C1S	931660	10/2018	10/12/2018	100.01	100.04	99.97
LGE	C1S	931661	10/2018	10/12/2018	100.02	99.99	99.91
LGE	C1S	931662	10/2018	10/12/2018	100	100.03	99.91
LGE	C1S	931663	10/2018	10/12/2018	100.01	99.99	99.93
LGE	C1S	931664	10/2018	10/12/2018	100.02	100.07	99.96
LGE	C1S	931665	10/2018	10/12/2018	99.98	100.04	99.97
LGE	C1S	931666	10/2018	10/12/2018	99.98	100.03	99.93
LGE	C1S	931667	10/2018	10/12/2018	100	100.01	99.93
LGE	C1S	931668	10/2018	10/12/2018	99.99	100	99.92
LGE	C1S	931669	10/2018	10/12/2018	99.97	100.01	99.92
LGE	C1S	931670	10/2018	10/12/2018	100	100.03	99.94
LGE	C1S	931671	10/2018	10/12/2018	100.01	100.02	99.92
LGE	C1S	931672	10/2018	10/12/2018	99.99	100.03	99.93
LGE	C1S	931673	10/2018	10/12/2018	99.99	100.07	99.95
LGE	C1S	931674	10/2018	10/12/2018	100.04	100	99.88
LGE	C1S	931675	10/2018	10/12/2018	100.01	100.02	99.89
LGE	C1SR	932300	10/2018	10/19/2018	100	100.05	99.97
LGE	C1SR	932301	10/2018	10/19/2018	100.01	100.03	99.96
LGE	C1SR	932302	10/2018	10/19/2018	100	100.08	99.98
LGE	C1SR	932303	10/2018	10/19/2018	100	100.05	99.99
LGE	C1SR	932304	10/2018	10/19/2018	100.02	100.06	99.99
LGE	C1SR	932305	10/2018	10/19/2018	100	100.01	99.95
LGE	C1SR	932306	10/2018	10/19/2018	100.01	100.01	99.96
LGE	C1SR	932307	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932308	10/2018	10/19/2018	100	99.98	99.95
LGE	C1SR	932309	10/2018	10/19/2018	100	100.08	100.02
LGE	C1SR	932310	10/2018	10/19/2018	100	100	99.95
LGE	C1SR	932311	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932312	10/2018	10/19/2018	99.98	100.02	99.98
LGE	C1SR	932313	10/2018	10/19/2018	100.02	100.05	99.96
LGE	C1SR	932314	10/2018	10/19/2018	100.01	100.01	100

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932315	10/2018	10/19/2018	99.99	100.08	100.01
LGE	C1SR	932316	10/2018	10/19/2018	100.01	100.01	99.91
LGE	C1SR	932317	10/2018	10/19/2018	100	100.05	100.03
LGE	C1SR	932318	10/2018	10/19/2018	100.02	100.06	99.97
LGE	C1SR	932319	10/2018	10/19/2018	99.97	99.97	99.94
LGE	C1SR	932320	10/2018	10/19/2018	100	100.01	99.96
LGE	C1SR	932321	10/2018	10/19/2018	100	100.01	99.95
LGE	C1SR	932322	10/2018	10/19/2018	100.02	100.01	99.94
LGE	C1SR	932323	10/2018	10/19/2018	100	100	99.96
LGE	C1SR	932324	10/2018	10/19/2018	99.99	100.02	99.94
LGE	C1SR	932325	10/2018	10/19/2018	100.03	100.03	99.95
LGE	C1SR	932326	10/2018	10/19/2018	99.98	100.04	99.98
LGE	C1SR	932327	10/2018	10/19/2018	99.96	99.96	99.94
LGE	C1SR	932328	10/2018	10/19/2018	100.05	100.05	100.02
LGE	C1SR	932329	10/2018	10/19/2018	100	99.96	99.94
LGE	C1SR	932330	10/2018	10/19/2018	100	100.03	99.96
LGE	C1SR	932331	10/2018	10/19/2018	99.99	99.97	99.98
LGE	C1SR	932332	10/2018	10/19/2018	100.03	100.04	99.99
LGE	C1SR	932333	10/2018	10/19/2018	99.98	100.03	99.99
LGE	C1SR	932334	10/2018	10/19/2018	100.03	100.03	99.97
LGE	C1SR	932335	10/2018	10/19/2018	100.01	100.05	99.99
LGE	C1SR	932336	10/2018	10/19/2018	100.01	100.03	100.01
LGE	C1SR	932337	10/2018	10/19/2018	100	100.03	99.95
LGE	C1SR	932338	10/2018	10/19/2018	100.01	100.07	99.99
LGE	C1SR	932339	10/2018	10/19/2018	99.98	100.03	99.97
LGE	C1SR	932340	10/2018	10/19/2018	99.97	99.98	99.93
LGE	C1SR	932341	10/2018	10/19/2018	100.01	100.05	100.04
LGE	C1SR	932342	10/2018	10/19/2018	99.95	100.05	99.95
LGE	C1SR	932343	10/2018	10/19/2018	99.97	100.05	99.96
LGE	C1SR	932344	10/2018	10/19/2018	100	100	99.94
LGE	C1SR	932345	10/2018	10/19/2018	99.99	100.07	99.99
LGE	C1SR	932346	10/2018	10/19/2018	99.99	100.02	99.96
LGE	C1SR	932347	10/2018	10/19/2018	100.02	100.04	99.94
LGE	C1SR	932348	10/2018	10/19/2018	99.98	100.03	99.96
LGE	C1SR	932349	10/2018	10/19/2018	99.96	100.03	99.97
LGE	C1SR	932350	10/2018	10/19/2018	100.03	100.05	99.97
LGE	C1SR	932351	10/2018	10/19/2018	99.99	100.02	99.98
LGE	C1SR	932352	10/2018	10/19/2018	99.97	100.05	100
LGE	C1SR	932353	10/2018	10/19/2018	99.99	100.02	99.96
LGE	C1SR	932354	10/2018	10/19/2018	100.01	100.02	100.04
LGE	C1SR	932355	10/2018	10/19/2018	100	100.06	99.97
LGE	C1SR	932356	10/2018	10/19/2018	99.98	99.95	99.97



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932357	10/2018	10/19/2018	99.98	100.05	99.97
LGE	C1SR	932358	10/2018	10/19/2018	99.99	100.04	99.99
LGE	C1SR	932359	10/2018	10/19/2018	100	100.07	99.99
LGE	C1SR	932360	10/2018	10/19/2018	99.99	100	99.96
LGE	C1SR	932361	10/2018	10/19/2018	99.96	100.07	100.02
LGE	C1SR	932362	10/2018	10/19/2018	99.99	100.06	99.93
LGE	C1SR	932363	10/2018	10/19/2018	99.98	100.03	99.96
LGE	C1SR	932364	10/2018	10/19/2018	100.02	100.01	99.93
LGE	C1SR	932365	10/2018	10/19/2018	100.02	100.04	99.99
LGE	C1SR	932366	10/2018	10/19/2018	100.02	100.03	99.98
LGE	C1SR	932367	10/2018	10/19/2018	99.96	99.98	99.96
LGE	C1SR	932368	10/2018	10/19/2018	100.02	100.03	99.95
LGE	C1SR	932369	10/2018	10/19/2018	99.97	100.04	99.99
LGE	C1SR	932370	10/2018	10/19/2018	99.98	99.99	99.95
LGE	C1SR	932371	10/2018	10/19/2018	100.02	100.04	99.96
LGE	C1SR	932372	10/2018	10/19/2018	100.03	100.01	99.96
LGE	C1SR	932373	10/2018	10/19/2018	99.99	100.04	99.98
LGE	C1SR	932374	10/2018	10/19/2018	99.97	100.05	100.02
LGE	C1SR	932375	10/2018	10/19/2018	100.03	99.96	99.99
LGE	C1SR	932376	10/2018	10/19/2018	100.02	100.03	99.98
LGE	C1SR	932377	10/2018	10/19/2018	99.98	100.06	100
LGE	C1SR	932378	10/2018	10/19/2018	100	100.05	99.94
LGE	C1SR	932379	10/2018	10/19/2018	99.99	99.96	99.91
LGE	C1SR	932380	10/2018	10/19/2018	100	99.98	99.95
LGE	C1SR	932381	10/2018	10/19/2018	99.95	100.02	100.01
LGE	C1SR	932382	10/2018	10/19/2018	100.01	100.04	99.94
LGE	C1SR	932383	10/2018	10/19/2018	100.02	100.04	99.98
LGE	C1SR	932384	10/2018	10/19/2018	100.01	100.01	99.96
LGE	C1SR	932385	10/2018	10/19/2018	99.99	100.01	99.93
LGE	C1SR	932386	10/2018	10/19/2018	99.99	100.03	99.94
LGE	C1SR	932387	10/2018	10/19/2018	99.97	100.02	99.95
LGE	C1SR	932388	10/2018	10/19/2018	100.01	100.06	100.04
LGE	C1SR	932389	10/2018	10/19/2018	100	100.02	99.92
LGE	C1SR	932390	10/2018	10/19/2018	99.99	100.03	99.95
LGE	C1SR	932391	10/2018	10/19/2018	100.01	100.07	100.04
LGE	C1SR	932392	10/2018	10/19/2018	99.98	100.05	99.93
LGE	C1SR	932393	10/2018	10/19/2018	99.97	100.02	99.99
LGE	C1SR	932394	10/2018	10/19/2018	100	100.02	99.94
LGE	C1SR	932395	10/2018	10/19/2018	99.99	100.03	99.95
LGE	C1SR	932396	10/2018	10/19/2018	99.98	100.03	99.93
LGE	C1SR	932397	10/2018	10/19/2018	99.99	99.97	99.93
LGE	C1SR	932398	10/2018	10/19/2018	100.01	100.03	99.97

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932399	10/2018	10/19/2018	100.02	100.02	99.93
LGE	C1SR	932400	10/2018	10/19/2018	99.98	100.05	100.01
LGE	C1SR	932401	10/2018	10/19/2018	100	100.06	99.98
LGE	C1SR	932402	10/2018	10/19/2018	100	100.03	99.95
LGE	C1SR	932403	10/2018	10/19/2018	100.02	100	99.94
LGE	C1SR	932404	10/2018	10/19/2018	100.02	100.05	99.95
LGE	C1SR	932405	10/2018	10/19/2018	100.03	99.99	99.89
LGE	C1SR	932406	10/2018	10/19/2018	100.02	100.03	99.97
LGE	C1SR	932407	10/2018	10/19/2018	100.01	100.04	99.98
LGE	C1SR	932408	10/2018	10/19/2018	100.01	100.04	99.97
LGE	C1SR	932409	10/2018	10/19/2018	100	100.04	100
LGE	C1SR	932410	10/2018	10/19/2018	100	99.99	99.88
LGE	C1SR	932411	10/2018	10/19/2018	100	100.03	99.98
LGE	C1SR	932412	10/2018	10/19/2018	99.99	100.05	99.92
LGE	C1SR	932413	10/2018	10/19/2018	99.96	100.05	99.98
LGE	C1SR	932414	10/2018	10/19/2018	100	99.95	99.95
LGE	C1SR	932415	10/2018	10/19/2018	100.01	100.07	99.97
LGE	C1SR	932416	10/2018	10/19/2018	100.05	99.95	99.91
LGE	C1SR	932417	10/2018	10/19/2018	100.04	100.04	100
LGE	C1SR	932418	10/2018	10/19/2018	99.99	100.01	99.92
LGE	C1SR	932419	10/2018	10/19/2018	99.99	100.05	100.02
LGE	C1SR	932420	10/2018	10/19/2018	99.97	100.05	99.96
LGE	C1SR	932421	10/2018	10/19/2018	99.99	99.98	99.96
LGE	C1SR	932422	10/2018	10/19/2018	100.02	100.06	99.98
LGE	C1SR	932423	10/2018	10/19/2018	99.98	100.02	99.94
LGE	C1SR	932424	10/2018	10/19/2018	99.98	100.06	99.98
LGE	C1SR	932425	10/2018	10/19/2018	99.99	99.99	99.94
LGE	C1SR	932426	10/2018	10/19/2018	100.01	99.97	99.9
LGE	C1SR	932427	10/2018	10/19/2018	100.03	100.04	99.97
LGE	C1SR	932428	10/2018	10/19/2018	100	100.02	99.93
LGE	C1SR	932429	10/2018	10/19/2018	100	100.01	99.95
LGE	C1SR	932430	10/2018	10/19/2018	100.05	100.05	100
LGE	C1SR	932431	10/2018	10/19/2018	99.99	99.99	99.91
LGE	C1SR	932432	10/2018	10/19/2018	99.99	99.93	99.89
LGE	C1SR	932433	10/2018	10/19/2018	99.99	100	99.93
LGE	C1SR	932434	10/2018	10/19/2018	99.99	100.04	99.98
LGE	C1SR	932435	10/2018	10/19/2018	100	99.93	99.89
LGE	C1SR	932436	10/2018	10/19/2018	99.99	99.98	99.92
LGE	C1SR	932437	10/2018	10/19/2018	99.99	100.01	99.93
LGE	C1SR	932438	10/2018	10/19/2018	100.01	100.04	100
LGE	C1SR	932439	10/2018	10/19/2018	100	100	99.99
LGE	C1SR	932440	10/2018	10/19/2018	99.99	100	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932441	10/2018	10/19/2018	100.01	100.04	99.93
LGE	C1SR	932442	10/2018	10/19/2018	100.01	100.03	99.94
LGE	C1SR	932443	10/2018	10/19/2018	100.01	99.98	99.97
LGE	C1SR	932444	10/2018	10/19/2018	100.02	100.05	100.02
LGE	C1SR	932445	10/2018	10/19/2018	100.02	100.05	99.99
LGE	C1SR	932446	10/2018	10/19/2018	100.02	100.04	99.95
LGE	C1SR	932447	10/2018	10/19/2018	100	100.02	100.01
LGE	C1SR	932448	10/2018	10/19/2018	100.02	99.99	99.95
LGE	C1SR	932449	10/2018	10/19/2018	100.02	100.06	100.02
LGE	C1SR	932450	10/2018	10/19/2018	100.01	99.98	99.96
LGE	C1SR	932451	10/2018	10/19/2018	100.04	100.01	99.96
LGE	C1SR	932452	10/2018	10/19/2018	100	100.01	99.92
LGE	C1SR	932453	10/2018	10/19/2018	100.02	100.04	100
LGE	C1SR	932454	10/2018	10/19/2018	100.02	100.02	99.98
LGE	C1SR	932455	10/2018	10/19/2018	100.02	100.02	99.98
LGE	C1SR	932456	10/2018	10/19/2018	100	100.03	100.01
LGE	C1SR	932457	10/2018	10/19/2018	100	99.98	99.91
LGE	C1SR	932458	10/2018	10/19/2018	100	100.04	99.98
LGE	C1SR	932459	10/2018	10/19/2018	100.01	100.02	99.98
LGE	C1SR	932460	10/2018	10/19/2018	100.02	100.01	99.97
LGE	C1SR	932461	10/2018	10/19/2018	99.98	100.04	100
LGE	C1SR	932462	10/2018	10/19/2018	100.01	100.03	99.93
LGE	C1SR	932463	10/2018	10/19/2018	100.01	100	99.98
LGE	C1SR	932464	10/2018	10/19/2018	100	100.03	100
LGE	C1SR	932465	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932466	10/2018	10/19/2018	100.01	99.99	99.92
LGE	C1SR	932467	10/2018	10/19/2018	100.01	100.08	99.98
LGE	C1SR	932468	10/2018	10/19/2018	99.98	100.04	99.98
LGE	C1SR	932469	10/2018	10/19/2018	99.97	100.01	99.96
LGE	C1SR	932470	10/2018	10/19/2018	100	100.05	99.98
LGE	C1SR	932471	10/2018	10/19/2018	100	100.03	99.94
LGE	C1SR	932472	10/2018	10/19/2018	100.01	100.06	99.93
LGE	C1SR	932473	10/2018	10/19/2018	99.98	100.01	99.94
LGE	C1SR	932474	10/2018	10/19/2018	99.96	99.99	99.96
LGE	C1SR	932475	10/2018	10/19/2018	99.99	100.07	100.02
LGE	C1SR	932476	10/2018	10/19/2018	99.99	100.01	99.95
LGE	C1SR	932477	10/2018	10/19/2018	99.98	100.02	99.99
LGE	C1SR	932478	10/2018	10/19/2018	100	100.02	100
LGE	C1SR	932479	10/2018	10/19/2018	99.96	100.02	99.89
LGE	C1SR	932480	10/2018	10/19/2018	100.01	100.04	99.97
LGE	C1SR	932481	10/2018	10/19/2018	100.03	100.03	99.93
LGE	C1SR	932482	10/2018	10/19/2018	100	100.01	99.92

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932483	10/2018	10/19/2018	99.99	99.97	99.95
LGE	C1SR	932484	10/2018	10/19/2018	100.01	100.04	100
LGE	C1SR	932485	10/2018	10/19/2018	100	100.03	99.95
LGE	C1SR	932486	10/2018	10/19/2018	100.01	100.04	99.98
LGE	C1SR	932487	10/2018	10/19/2018	99.99	100.02	99.94
LGE	C1SR	932488	10/2018	10/19/2018	99.99	99.99	99.93
LGE	C1SR	932489	10/2018	10/19/2018	100.01	100.02	99.94
LGE	C1SR	932490	10/2018	10/19/2018	99.96	99.98	99.93
LGE	C1SR	932491	10/2018	10/19/2018	99.97	100.02	99.93
LGE	C1SR	932492	10/2018	10/19/2018	100.02	99.98	99.96
LGE	C1SR	932493	10/2018	10/19/2018	100.02	100.05	99.98
LGE	C1SR	932494	10/2018	10/19/2018	100	100.05	99.99
LGE	C1SR	932495	10/2018	10/19/2018	99.99	100.01	99.98
LGE	C1SR	932496	10/2018	10/19/2018	100.02	100.01	100
LGE	C1SR	932497	10/2018	10/19/2018	99.99	99.96	99.91
LGE	C1SR	932498	10/2018	10/19/2018	100.01	100.02	99.99
LGE	C1SR	932499	10/2018	10/19/2018	99.99	100	99.96
LGE	C1SR	932500	10/2018	10/19/2018	100.01	100.03	99.97
LGE	C1SR	932501	10/2018	10/19/2018	99.99	100.06	100.02
LGE	C1SR	932502	10/2018	10/19/2018	99.99	100.04	99.98
LGE	C1SR	932503	10/2018	10/19/2018	99.96	100.04	99.93
LGE	C1SR	932504	10/2018	10/19/2018	100.01	100.02	99.97
LGE	C1SR	932505	10/2018	10/19/2018	100.02	100	99.94
LGE	C1SR	932506	10/2018	10/19/2018	99.97	100.04	99.96
LGE	C1SR	932507	10/2018	10/19/2018	99.96	100	99.97
LGE	C1SR	932508	10/2018	10/19/2018	100.03	100.05	99.97
LGE	C1SR	932509	10/2018	10/19/2018	100.01	100.03	99.92
LGE	C1SR	932510	10/2018	10/19/2018	99.98	100.02	99.97
LGE	C1SR	932511	10/2018	10/19/2018	100.02	100.04	99.98
LGE	C1SR	932512	10/2018	10/19/2018	99.98	100.05	100.01
LGE	C1SR	932513	10/2018	10/19/2018	99.98	100.04	99.96
LGE	C1SR	932514	10/2018	10/19/2018	100	100.01	100.02
LGE	C1SR	932515	10/2018	10/19/2018	99.97	100.02	99.98
LGE	C1SR	932516	10/2018	10/19/2018	100.02	100.05	99.98
LGE	C1SR	932517	10/2018	10/19/2018	99.99	100.01	99.96
LGE	C1SR	932518	10/2018	10/19/2018	100.01	100.02	99.95
LGE	C1SR	932519	10/2018	10/19/2018	99.99	99.96	99.99
LGE	C1SR	932520	10/2018	10/19/2018	99.99	99.99	99.93
LGE	C1SR	932521	10/2018	10/19/2018	100.02	100.05	99.99
LGE	C1SR	932522	10/2018	10/19/2018	100.01	100.04	99.98
LGE	C1SR	932523	10/2018	10/19/2018	99.96	100.01	99.98
LGE	C1SR	932524	10/2018	10/19/2018	99.99	100.06	99.95



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932525	10/2018	10/19/2018	100.02	100.06	100
LGE	C1SR	932526	10/2018	10/19/2018	100	100.03	99.95
LGE	C1SR	932527	10/2018	10/19/2018	100.01	100.02	99.98
LGE	C1SR	932528	10/2018	10/19/2018	99.98	100	99.93
LGE	C1SR	932529	10/2018	10/19/2018	100.02	100	99.95
LGE	C1SR	932530	10/2018	10/19/2018	100.05	100.04	99.96
LGE	C1SR	932531	10/2018	10/19/2018	99.99	100	99.9
LGE	C1SR	932532	10/2018	10/19/2018	100	100.05	99.96
LGE	C1SR	932533	10/2018	10/19/2018	100	99.98	99.93
LGE	C1SR	932534	10/2018	10/19/2018	100	100.03	99.97
LGE	C1SR	932535	10/2018	10/19/2018	99.97	100.03	99.93
LGE	C1SR	932536	10/2018	10/19/2018	100	99.95	99.96
LGE	C1SR	932537	10/2018	10/19/2018	100	100.06	99.97
LGE	C1SR	932538	10/2018	10/19/2018	100.01	100.05	99.96
LGE	C1SR	932539	10/2018	10/19/2018	100.04	99.95	99.96
LGE	C1SR	932540	10/2018	10/19/2018	100.01	100.01	99.96
LGE	C1SR	932541	10/2018	10/19/2018	100.01	100.02	99.93
LGE	C1SR	932542	10/2018	10/19/2018	100	100.03	99.94
LGE	C1SR	932543	10/2018	10/19/2018	100.01	100.01	100.01
LGE	C1SR	932544	10/2018	10/19/2018	99.99	100.01	99.97
LGE	C1SR	932545	10/2018	10/19/2018	100.05	100.02	99.96
LGE	C1SR	932546	10/2018	10/19/2018	100.01	99.99	99.93
LGE	C1SR	932547	10/2018	10/19/2018	100.01	100.02	99.94
LGE	C1SR	932548	10/2018	10/19/2018	100.01	100.05	99.96
LGE	C1SR	932549	10/2018	10/19/2018	100.02	100.05	99.96
LGE	C1SR	932550	10/2018	10/19/2018	100.01	100.06	99.99
LGE	C1SR	932551	10/2018	10/19/2018	99.99	100.08	100.01
LGE	C1SR	932552	10/2018	10/19/2018	99.99	100.02	99.92
LGE	C1SR	932553	10/2018	10/19/2018	100.03	100.07	99.97
LGE	C1SR	932554	10/2018	10/19/2018	100.03	99.99	99.9
LGE	C1SR	932555	10/2018	10/19/2018	100.01	100.01	99.93
LGE	C1SR	932556	10/2018	10/19/2018	100	99.93	99.94
LGE	C1SR	932557	10/2018	10/19/2018	100.01	100.01	99.94
LGE	C1SR	932558	10/2018	10/19/2018	99.99	100.03	99.97
LGE	C1SR	932559	10/2018	10/19/2018	99.97	100.04	99.96
LGE	C1SR	932560	10/2018	10/19/2018	100.01	99.98	99.94
LGE	C1SR	932561	10/2018	10/19/2018	100	99.99	99.99
LGE	C1SR	932562	10/2018	10/19/2018	100.02	100	99.96
LGE	C1SR	932563	10/2018	10/19/2018	100.01	100.06	99.97
LGE	C1SR	932564	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932565	10/2018	10/19/2018	100.01	100.02	99.96
LGE	C1SR	932566	10/2018	10/19/2018	100	100	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932567	10/2018	10/19/2018	100	99.98	99.95
LGE	C1SR	932568	10/2018	10/19/2018	99.98	100.07	99.98
LGE	C1SR	932569	10/2018	10/19/2018	100.03	100.01	99.99
LGE	C1SR	932570	10/2018	10/19/2018	100	100.03	99.96
LGE	C1SR	932571	10/2018	10/19/2018	100.01	100.02	99.92
LGE	C1SR	932572	10/2018	10/19/2018	99.97	100.02	99.96
LGE	C1SR	932573	10/2018	10/19/2018	100.02	100.03	99.98
LGE	C1SR	932574	10/2018	10/19/2018	99.99	100.02	99.97
LGE	C1SR	932575	10/2018	10/19/2018	99.99	99.99	99.94
LGE	C1SR	932576	10/2018	10/19/2018	100.01	100.03	99.95
LGE	C1SR	932577	10/2018	10/19/2018	99.99	99.96	99.79
LGE	C1SR	932578	10/2018	10/19/2018	100.02	100.01	99.92
LGE	C1SR	932579	10/2018	10/19/2018	100.01	100.04	100
LGE	C1SR	932580	10/2018	10/19/2018	100.02	100.03	100.01
LGE	C1SR	932581	10/2018	10/19/2018	100.02	99.99	99.99
LGE	C1SR	932582	10/2018	10/19/2018	99.97	100.02	99.94
LGE	C1SR	932583	10/2018	10/19/2018	100.02	100.04	99.94
LGE	C1SR	932584	10/2018	10/19/2018	99.98	100.04	100.03
LGE	C1SR	932585	10/2018	10/19/2018	100.01	100.01	99.98
LGE	C1SR	932586	10/2018	10/19/2018	100.05	100.04	99.95
LGE	C1SR	932587	10/2018	10/19/2018	100	99.97	99.95
LGE	C1SR	932588	10/2018	10/19/2018	100.01	99.99	99.96
LGE	C1SR	932589	10/2018	10/19/2018	100	100.05	99.94
LGE	C1SR	932590	10/2018	10/19/2018	99.99	100.03	99.95
LGE	C1SR	932591	10/2018	10/19/2018	99.97	100.01	99.95
LGE	C1SR	932592	10/2018	10/19/2018	99.96	100.02	99.91
LGE	C1SR	932593	10/2018	10/19/2018	99.95	100	99.93
LGE	C1SR	932594	10/2018	10/19/2018	100.03	100.05	99.99
LGE	C1SR	932595	10/2018	10/19/2018	100	100.04	99.97
LGE	C1SR	932596	10/2018	10/19/2018	99.97	100.03	99.96
LGE	C1SR	932597	10/2018	10/19/2018	100	100.07	99.98
LGE	C1SR	932598	10/2018	10/19/2018	100.02	100.01	99.94
LGE	C1SR	932599	10/2018	10/19/2018	100	100.01	99.93
LGE	C1SR	932600	10/2018	10/19/2018	99.99	100.03	99.92
LGE	C1SR	932601	10/2018	10/19/2018	100.01	100.06	100.01
LGE	C1SR	932602	10/2018	10/19/2018	100.03	100.01	99.94
LGE	C1SR	932603	10/2018	10/19/2018	99.98	100.04	99.98
LGE	C1SR	932604	10/2018	10/19/2018	100.02	100.02	99.93
LGE	C1SR	932605	10/2018	10/19/2018	100.01	100.03	99.96
LGE	C1SR	932606	10/2018	10/19/2018	100.06	100.03	99.97
LGE	C1SR	932607	10/2018	10/19/2018	99.98	100.04	99.98
LGE	C1SR	932608	10/2018	10/19/2018	100	99.98	99.98

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932609	10/2018	10/19/2018	100.02	100.04	99.93
LGE	C1SR	932610	10/2018	10/19/2018	99.98	100.01	99.92
LGE	C1SR	932611	10/2018	10/19/2018	100.01	100.02	99.94
LGE	C1SR	932612	10/2018	10/19/2018	100.02	99.96	99.98
LGE	C1SR	932613	10/2018	10/19/2018	99.99	99.95	99.98
LGE	C1SR	932614	10/2018	10/19/2018	100	99.95	99.94
LGE	C1SR	932615	10/2018	10/19/2018	100.03	99.97	99.93
LGE	C1SR	932616	10/2018	10/19/2018	100.03	99.96	99.95
LGE	C1SR	932617	10/2018	10/19/2018	100	100.06	99.99
LGE	C1SR	932618	10/2018	10/19/2018	99.99	99.97	99.9
LGE	C1SR	932619	10/2018	10/19/2018	100	99.94	99.91
LGE	C1SR	932620	10/2018	10/19/2018	100	100.01	99.94
LGE	C1SR	932621	10/2018	10/19/2018	99.97	99.96	99.97
LGE	C1SR	932622	10/2018	10/19/2018	100	99.96	99.96
LGE	C1SR	932623	10/2018	10/19/2018	100.01	100.03	99.99
LGE	C1SR	932624	10/2018	10/19/2018	100	99.95	99.94
LGE	C1SR	932625	10/2018	10/19/2018	100	99.94	99.89
LGE	C1SR	932626	10/2018	10/19/2018	100	99.95	99.95
LGE	C1SR	932627	10/2018	10/19/2018	99.97	99.97	99.95
LGE	C1SR	932628	10/2018	10/19/2018	99.98	99.98	99.93
LGE	C1SR	932629	10/2018	10/19/2018	100.04	99.96	99.92
LGE	C1SR	932630	10/2018	10/19/2018	100.03	100.02	99.96
LGE	C1SR	932631	10/2018	10/19/2018	100	99.96	99.91
LGE	C1SR	932632	10/2018	10/19/2018	99.99	99.94	99.91
LGE	C1SR	932633	10/2018	10/19/2018	99.98	99.97	99.92
LGE	C1SR	932634	10/2018	10/19/2018	100.03	100.01	99.97
LGE	C1SR	932635	10/2018	10/19/2018	99.99	99.97	99.92
LGE	C1SR	932636	10/2018	10/19/2018	100	100.02	99.9
LGE	C1SR	932637	10/2018	10/19/2018	100	99.98	99.86
LGE	C1SR	932638	10/2018	10/19/2018	99.99	100.07	99.98
LGE	C1SR	932639	10/2018	10/19/2018	99.98	99.94	99.89
LGE	C1SR	932640	10/2018	10/19/2018	99.99	99.98	99.95
LGE	C1SR	932641	10/2018	10/19/2018	100	100.08	99.99
LGE	C1SR	932642	10/2018	10/19/2018	99.98	100.05	99.97
LGE	C1SR	932643	10/2018	10/19/2018	99.99	100.03	99.92
LGE	C1SR	932644	10/2018	10/19/2018	99.97	100.06	99.98
LGE	C1SR	932645	10/2018	10/19/2018	99.98	100	99.93
LGE	C1SR	932646	10/2018	10/19/2018	100.01	100.02	99.94
LGE	C1SR	932647	10/2018	10/19/2018	99.99	100.02	99.92
LGE	C1SR	932648	10/2018	10/19/2018	99.99	100.01	99.92
LGE	C1SR	932649	10/2018	10/19/2018	100.03	99.98	99.92
LGE	C1SR	932650	10/2018	10/19/2018	100	100	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932651	10/2018	10/19/2018	100.01	100.03	99.92
LGE	C1SR	932652	10/2018	10/19/2018	99.98	100.02	99.93
LGE	C1SR	932653	10/2018	10/19/2018	100.01	100.01	99.96
LGE	C1SR	932654	10/2018	10/19/2018	100.02	100.01	99.98
LGE	C1SR	932655	10/2018	10/19/2018	99.99	100.01	99.96
LGE	C1SR	932656	10/2018	10/19/2018	100	99.94	99.9
LGE	C1SR	932657	10/2018	10/19/2018	100	100.02	99.95
LGE	C1SR	932658	10/2018	10/19/2018	100.01	100.01	99.94
LGE	C1SR	932659	10/2018	10/19/2018	100.03	99.96	99.96
LGE	C1SR	932660	10/2018	10/19/2018	99.98	99.97	99.9
LGE	C1SR	932661	10/2018	10/19/2018	99.97	100.02	99.92
LGE	C1SR	932662	10/2018	10/19/2018	100.01	100.07	100
LGE	C1SR	932663	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932664	10/2018	10/19/2018	100.04	100.03	99.96
LGE	C1SR	932665	10/2018	10/19/2018	100	100	99.92
LGE	C1SR	932666	10/2018	10/19/2018	99.99	100	99.9
LGE	C1SR	932667	10/2018	10/19/2018	100.02	100	99.95
LGE	C1SR	932668	10/2018	10/19/2018	100.04	99.96	99.93
LGE	C1SR	932669	10/2018	10/19/2018	99.99	99.96	99.94
LGE	C1SR	932670	10/2018	10/19/2018	99.98	99.94	99.9
LGE	C1SR	932671	10/2018	10/19/2018	100.01	99.96	99.89
LGE	C1SR	932672	10/2018	10/19/2018	99.97	99.96	99.92
LGE	C1SR	932673	10/2018	10/19/2018	100.01	99.99	99.98
LGE	C1SR	932674	10/2018	10/19/2018	100.02	99.97	99.94
LGE	C1SR	932675	10/2018	10/19/2018	100	99.96	99.91
LGE	C1SR	932676	10/2018	10/19/2018	100.03	99.93	99.9
LGE	C1SR	932677	10/2018	10/19/2018	100.01	100.01	99.96
LGE	C1SR	932678	10/2018	10/19/2018	100	100.01	99.9
LGE	C1SR	932679	10/2018	10/19/2018	100	99.95	99.91
LGE	C1SR	932680	10/2018	10/19/2018	100.01	100	99.93
LGE	C1SR	932681	10/2018	10/19/2018	99.98	100.02	99.89
LGE	C1SR	932682	10/2018	10/19/2018	100	100	99.91
LGE	C1SR	932683	10/2018	10/19/2018	99.97	100.09	100
LGE	C1SR	932684	10/2018	10/19/2018	100.03	100	99.9
LGE	C1SR	932685	10/2018	10/19/2018	100.06	100.05	99.93
LGE	C1SR	932686	10/2018	10/19/2018	99.99	100.05	100
LGE	C1SR	932687	10/2018	10/19/2018	99.98	100.05	99.95
LGE	C1SR	932688	10/2018	10/19/2018	99.96	100.03	99.9
LGE	C1SR	932689	10/2018	10/19/2018	99.97	100.03	99.89
LGE	C1SR	932690	10/2018	10/19/2018	100	100.08	99.97
LGE	C1SR	932691	10/2018	10/19/2018	100	99.98	99.92
LGE	C1SR	932692	10/2018	10/19/2018	100	100.02	99.89



# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932693	10/2018	10/19/2018	99.98	100.03	99.92
LGE	C1SR	932694	10/2018	10/19/2018	99.99	100.01	99.9
LGE	C1SR	932695	10/2018	10/19/2018	99.97	99.98	99.89
LGE	C1SR	932696	10/2018	10/19/2018	100.01	100.01	99.94
LGE	C1SR	932697	10/2018	10/19/2018	99.98	100.05	99.98
LGE	C1SR	932698	10/2018	10/19/2018	100	99.99	99.95
LGE	C1SR	932699	10/2018	10/19/2018	99.98	100.03	99.94
LGE	C1SR	932700	10/2018	10/19/2018	99.99	99.98	99.91
LGE	C1SR	932701	10/2018	10/19/2018	99.98	99.94	99.94
LGE	C1SR	932702	10/2018	10/19/2018	100.04	99.93	99.93
LGE	C1SR	932703	10/2018	10/19/2018	100.03	100.04	99.91
LGE	C1SR	932704	10/2018	10/19/2018	100	99.97	99.88
LGE	C1SR	932705	10/2018	10/19/2018	100.02	100	99.9
LGE	C1SR	932706	10/2018	10/19/2018	99.96	99.95	99.94
LGE	C1SR	932707	10/2018	10/19/2018	99.98	100.03	99.97
LGE	C1SR	932708	10/2018	10/19/2018	99.99	99.99	99.93
LGE	C1SR	932709	10/2018	10/19/2018	100	99.93	99.92
LGE	C1SR	932710	10/2018	10/19/2018	99.99	99.99	99.89
LGE	C1SR	932711	10/2018	10/19/2018	99.99	100	99.91
LGE	C1SR	932712	10/2018	10/19/2018	100.05	100	99.89
LGE	C1SR	932713	10/2018	10/19/2018	99.97	100.01	99.93
LGE	C1SR	932714	10/2018	10/19/2018	100.02	99.98	99.93
LGE	C1SR	932715	10/2018	10/19/2018	99.98	99.97	99.92
LGE	C1SR	932716	10/2018	10/19/2018	100.02	100.08	100
LGE	C1SR	932717	10/2018	10/19/2018	100	99.99	99.95
LGE	C1SR	932718	10/2018	10/19/2018	99.98	100.02	99.94
LGE	C1SR	932719	10/2018	10/19/2018	99.99	100.02	100.04
LGE	C1SR	932720	10/2018	10/19/2018	99.99	100.01	99.96
LGE	C1SR	932721	10/2018	10/19/2018	99.99	100.01	99.96
LGE	C1SR	932722	10/2018	10/19/2018	100.01	99.95	99.95
LGE	C1SR	932723	10/2018	10/19/2018	99.99	100	99.93
LGE	C1SR	932724	10/2018	10/19/2018	100.01	99.94	99.97
LGE	C1SR	932725	10/2018	10/19/2018	100.02	100	99.94
LGE	C1SR	932726	10/2018	10/19/2018	100	99.92	99.92
LGE	C1SR	932727	10/2018	10/19/2018	100.05	100	99.96
LGE	C1SR	932728	10/2018	10/19/2018	99.95	100.07	99.99
LGE	C1SR	932729	10/2018	10/19/2018	99.99	99.97	99.98
LGE	C1SR	932730	10/2018	10/19/2018	100.02	100.02	99.95
LGE	C1SR	932731	10/2018	10/19/2018	99.99	100.03	99.96
LGE	C1SR	932732	10/2018	10/19/2018	100	99.97	99.95
LGE	C1SR	932733	10/2018	10/19/2018	100	99.99	99.93
LGE	C1SR	932734	10/2018	10/19/2018	100.02	99.97	99.96

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932735	10/2018	10/19/2018	99.99	99.95	99.93
LGE	C1SR	932736	10/2018	10/19/2018	99.98	100.01	99.93
LGE	C1SR	932737	10/2018	10/19/2018	100	99.96	99.94
LGE	C1SR	932738	10/2018	10/19/2018	100	100.01	99.9
LGE	C1SR	932739	10/2018	10/19/2018	100.01	100.02	99.96
LGE	C1SR	932740	10/2018	10/19/2018	100.01	100.04	99.95
LGE	C1SR	932741	10/2018	10/19/2018	100.04	99.99	99.94
LGE	C1SR	932742	10/2018	10/19/2018	99.99	99.99	99.94
LGE	C1SR	932743	10/2018	10/19/2018	99.99	99.94	99.94
LGE	C1SR	932744	10/2018	10/19/2018	100.01	100	99.95
LGE	C1SR	932745	10/2018	10/19/2018	100.03	99.97	99.93
LGE	C1SR	932746	10/2018	10/19/2018	100.02	99.97	99.91
LGE	C1SR	932747	10/2018	10/19/2018	100	100.01	99.93
LGE	C1SR	932748	10/2018	10/19/2018	100	100.01	99.95
LGE	C1SR	932749	10/2018	10/19/2018	100.01	100.08	99.98
LGE	C1SR	932750	10/2018	10/19/2018	99.97	99.97	99.98
LGE	C1SR	932751	10/2018	10/19/2018	100.02	99.99	99.9
LGE	C1SR	932752	10/2018	10/19/2018	100	99.98	99.89
LGE	C1SR	932753	10/2018	10/19/2018	100.01	99.94	99.89
LGE	C1SR	932754	10/2018	10/19/2018	99.99	99.95	99.91
LGE	C1SR	932755	10/2018	10/19/2018	100.01	100.04	99.98
LGE	C1SR	932756	10/2018	10/19/2018	100.04	99.96	99.93
LGE	C1SR	932757	10/2018	10/19/2018	100.01	100.04	99.98
LGE	C1SR	932758	10/2018	10/19/2018	99.97	100	99.98
LGE	C1SR	932759	10/2018	10/19/2018	99.98	100.02	99.98
LGE	C1SR	932760	10/2018	10/19/2018	100.02	99.98	99.95
LGE	C1SR	932761	10/2018	10/19/2018	100	100	99.94
LGE	C1SR	932762	10/2018	10/19/2018	100	99.93	99.92
LGE	C1SR	932763	10/2018	10/19/2018	99.99	100.02	99.94
LGE	C1SR	932764	10/2018	10/19/2018	99.99	100	99.97
LGE	C1SR	932765	10/2018	10/19/2018	99.99	100.02	99.94
LGE	C1SR	932766	10/2018	10/19/2018	100.01	99.94	99.94
LGE	C1SR	932767	10/2018	10/19/2018	99.96	100.05	99.98
LGE	C1SR	932768	10/2018	10/19/2018	100.01	100.07	99.98
LGE	C1SR	932769	10/2018	10/19/2018	99.95	99.93	99.96
LGE	C1SR	932770	10/2018	10/19/2018	100	100.01	99.94
LGE	C1SR	932771	10/2018	10/19/2018	99.99	99.92	99.91
LGE	C1SR	932772	10/2018	10/19/2018	100.05	99.98	99.97
LGE	C1SR	932773	10/2018	10/19/2018	100.03	99.93	99.95
LGE	C1SR	932774	10/2018	10/19/2018	100.03	99.96	99.91
LGE	C1SR	932775	10/2018	10/19/2018	100	100.04	99.96
LGE	C1SR	932776	10/2018	10/19/2018	99.98	99.96	99.91

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932777	10/2018	10/19/2018	99.95	99.94	99.95
LGE	C1SR	932778	10/2018	10/19/2018	100	99.95	99.91
LGE	C1SR	932779	10/2018	10/19/2018	100	99.98	99.97
LGE	C1SR	932780	10/2018	10/19/2018	100.01	99.97	99.97
LGE	C1SR	932781	10/2018	10/19/2018	100	99.97	99.93
LGE	C1SR	932782	10/2018	10/19/2018	100	99.99	99.91
LGE	C1SR	932783	10/2018	10/19/2018	99.96	99.96	100
LGE	C1SR	932784	10/2018	10/19/2018	99.95	100.01	99.93
LGE	C1SR	932785	10/2018	10/19/2018	100.02	100.02	99.95
LGE	C1SR	932786	10/2018	10/19/2018	99.99	99.96	99.97
LGE	C1SR	932787	10/2018	10/19/2018	100.02	99.99	99.96
LGE	C1SR	932788	10/2018	10/19/2018	99.97	99.97	99.94
LGE	C1SR	932789	10/2018	10/19/2018	99.99	99.96	99.93
LGE	C1SR	932790	10/2018	10/19/2018	100.02	99.95	99.94
LGE	C1SR	932791	10/2018	10/19/2018	100.04	100.05	99.94
LGE	C1SR	932792	10/2018	10/19/2018	99.99	99.99	99.9
LGE	C1SR	932793	10/2018	10/19/2018	100.01	100	99.96
LGE	C1SR	932794	10/2018	10/19/2018	100	99.96	99.92
LGE	C1SR	932795	10/2018	10/19/2018	100	99.98	99.94
LGE	C1SR	932796	10/2018	10/19/2018	99.98	99.98	99.93
LGE	C1SR	932797	10/2018	10/19/2018	100	99.98	99.94
LGE	C1SR	932798	10/2018	10/19/2018	100	99.94	99.98
LGE	C1SR	932799	10/2018	10/19/2018	99.98	99.94	99.91
LGE	C1SR	932800	10/2018	10/19/2018	99.97	99.96	99.95
LGE	C1SR	932801	10/2018	10/19/2018	100.02	100.07	99.96
LGE	C1SR	932802	10/2018	10/19/2018	100.01	100	99.94
LGE	C1SR	932803	10/2018	10/19/2018	99.98	100.06	100
LGE	C1SR	932804	10/2018	10/19/2018	99.97	100.02	99.97
LGE	C1SR	932805	10/2018	10/19/2018	100	100	99.94
LGE	C1SR	932806	10/2018	10/19/2018	100	100.03	100.01
LGE	C1SR	932807	10/2018	10/19/2018	100.01	100.01	99.94
LGE	C1SR	932808	10/2018	10/19/2018	99.99	100.07	100
LGE	C1SR	932809	10/2018	10/19/2018	100.05	100.04	99.96
LGE	C1SR	932810	10/2018	10/19/2018	99.95	100	99.96
LGE	C1SR	932811	10/2018	10/19/2018	100	100.02	99.93
LGE	C1SR	932812	10/2018	10/19/2018	100.01	100.04	99.96
LGE	C1SR	932813	10/2018	10/19/2018	100.04	99.97	99.98
LGE	C1SR	932814	10/2018	10/19/2018	99.99	100.04	99.95
LGE	C1SR	932815	10/2018	10/19/2018	100	100.06	99.96
LGE	C1SR	932816	10/2018	10/19/2018	100	99.98	99.92
LGE	C1SR	932817	10/2018	10/19/2018	99.99	100.04	99.96
LGE	C1SR	932818	10/2018	10/19/2018	99.99	100.03	99.94

# 5040 Annual Report of

7/2018 - 12/2018

LGE	C1SR	932819	10/2018	10/19/2018	100.01	99.98	99.93
LGE	C1SR	932820	10/2018	10/19/2018	100.02	100.06	99.97
LGE	C1SR	932821	10/2018	10/19/2018	100.02	99.99	99.9
LGE	C1SR	932822	10/2018	10/19/2018	100	100.01	99.94
LGE	C1SR	932823	10/2018	10/19/2018	100.02	100.04	99.98
LGE	C1SR	932824	10/2018	10/19/2018	100	100.03	99.99
LGE	C1SR	932825	10/2018	10/19/2018	100.02	99.96	99.95
LGE	C1SR	932826	10/2018	10/19/2018	99.97	100.03	100.02
LGE	C1SR	932827	10/2018	10/19/2018	99.96	100.03	99.94
LGE	C1SR	932828	10/2018	10/19/2018	99.99	99.99	99.98
LGE	C1SR	932829	10/2018	10/19/2018	99.97	100.05	99.97
LGE	C1SR	932830	10/2018	10/19/2018	100.04	99.97	99.94
LGE	C1SR	932831	10/2018	10/19/2018	100.02	99.94	99.95
LGE	C1SR	932832	10/2018	10/19/2018	99.99	100.01	99.98
LGE	C1SR	932833	10/2018	10/19/2018	99.99	100.01	99.95
LGE	C1SR	932834	10/2018	10/19/2018	99.99	100.03	99.95
LGE	C1SR	932835	10/2018	10/19/2018	100	100.07	99.95
LGE	C1SR	932836	10/2018	10/19/2018	99.97	100.03	99.93
LGE	C1SR	932837	10/2018	10/19/2018	100	100.03	99.97
LGE	C1SR	932838	10/2018	10/19/2018	99.99	100	99.96
LGE	C1SR	932839	10/2018	10/19/2018	99.96	100.03	99.95
LGE	C1SR	932840	10/2018	10/19/2018	99.93	100.04	100
LGE	C1SR	932841	10/2018	10/19/2018	100.02	99.98	99.96
LGE	C1SR	932842	10/2018	10/19/2018	100.01	99.97	99.97
LGE	C1SR	932843	10/2018	10/19/2018	100	99.95	99.94
LGE	C1SR	932844	10/2018	10/19/2018	100	100	99.95
LGE	C1SR	932845	10/2018	10/19/2018	99.99	99.96	99.97
LGE	C1SR	932846	10/2018	10/19/2018	100	99.95	99.92
LGE	C1SR	932847	10/2018	10/19/2018	99.99	99.94	99.99
LGE	C1SR	932848	10/2018	10/19/2018	100.01	99.99	99.95
LGE	C1SR	932849	10/2018	10/19/2018	99.98	99.98	99.93
LGE	C1SR	932850	10/2018	10/19/2018	100.01	100	99.94
LGE	C1SR	932851	10/2018	10/19/2018	100.02	100	99.94
LGE	C1SR	932852	10/2018	10/19/2018	99.99	99.98	100.02
LGE	C1SR	932853	10/2018	10/19/2018	100	99.97	99.97
LGE	C1SR	932854	10/2018	10/19/2018	99.97	100.03	99.98
LGE	C1SR	932855	10/2018	10/19/2018	100.01	100.05	99.96
LGE	C1SR	932856	10/2018	10/19/2018	100.02	100.06	99.99
LGE	C1SR	932857	10/2018	10/19/2018	100	100.05	100
LGE	C1SR	932858	10/2018	10/19/2018	100.03	100.03	99.96
LGE	C1SR	932859	10/2018	10/19/2018	100.02	100.05	99.98



# 5040 Annual Report of

7/2018 - 12/2018

<b>Total Meter Count: 2596</b>
------------------------------------

**ATTACHMENT  
B**

**2018 Statistical Sampling Test Results  
and Summary**

**LG&E**  
**2018 SAMPLE**  
**ELECTRIC METER SUMMARY**

**SAMPLE**

In-Service Population	390,609	Divided into 51 Lots
Sample Quantity	3,325	
Meters Tested	3,325	
Meters Not Tested	0	
Failed Lots	0	
Failed Lot Meters	0	

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : ALF      Division : 01      Sample Lot : 2415      Lot Descr : LGE ALF-1  
 In Service Population : 452      Sample Quantity : 25      Meters Tested : 25      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
833529	100	833582	100	833677	100	833875	100	833881	99.9
833924	99.9	833958	100	834042	100	834394	99.9	834607	100
834655	100.2	834676	99.9	834780	100	834908	99.99	834939	99.9
835055	100	855821	99.9	855823	100	863361	99.9	863365	99.8
863380	100	863409	99.9	863418	99.8	863423	99.8	863426	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	25	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	2498.69	Lower Specification Limit (L)	98
Sum of Squared Measurements	249738.25	Quality Index Upper (QU) : (U - XBAR) / S	23.61
Correction Factor (CF) : Sum of Measurements Sqaures / N	249738.07	Quality Index Lower (QL) : (XBAR - L) / S	22.40
Corrected Sum of Squares (SS)	0.18	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.09	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.95	Maximum Allowable Percent NCF (M)	5.98
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1SR      Division : 01      Sample Lot : 2416      Lot Descr : LGE C1S-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
754199	100	754208	100	754495	99.7	755501	100.1	755539	100
755643	100.1	755794	100	755811	99.9	755849	100.2	756172	100.2
756376	100.1	766222	100	766599	100.2	767301	100.2	767339	100
777049	100.2	777067	100.3	777240	100.1	777739	100.2	777760	100.2
777950	100.2	777957	100.2	778156	100.2	778191	99.9	778251	100.4
778293	100	778356	100.1	778415	100.3	778585	100.07	778742	100.1
778821	99.9	778932	100.1	778937	100.1	779166	100.1	779361	99.9
779397	99.6	779821	100.2	793764	100	793819	100.6	793838	100.1
793867	99.9	794253	99.5	794356	99.9	794396	100.2	794463	100
794567	100	794596	100	794623	100	794705	100.1	794984	99.9
795023	100.2	795266	100	795610	100.1	795749	100.2	795839	100.1
795942	100	796165	100	796428	100.2	796582	100	796596	100.1
796604	100	796777	100	796814	100	797033	100	797292	100
797595	100.2	797681	100.1	797838	100.1	797873	100.1	797986	100.2
797988	99.9	798696	100.2	798849	100.1	799521	100.15	808869	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7505.22	Lower Specification Limit (L)	98
Sum of Squared Measurements	751046.21	Quality Index Upper (QU) : (U - XBAR) / S	12.22
Correction Factor (CF) : Sum of Measurements Squares / N	751044.36	Quality Index Lower (QL) : (XBAR - L) / S	13.10
Corrected Sum of Squares (SS)	1.85	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.02	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.16	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.07	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1SR      Division : 01      Sample Lot : 2417      Lot Descr : LGE C1S-2  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
808910	100.1	809052	100.07	843289	100.1	843317	100.1	843503	100
843596	100	843622	99.9	844161	99.8	844279	100	844288	99.9
844427	99.9	844485	100.4	844593	99.9	845164	100.2	845546	100.1
845851	100.1	845856	100	846263	99.9	846381	100.1	846507	99.9
846886	100.1	846927	100	847556	100	847669	100.2	848102	99.9
848563	99.8	848683	100	848828	100	848851	99.9	848912	100
848921	100.1	848966	100.2	849070	100	849086	99.9	849280	100
849367	99.8	849380	99.9	849802	100.1	849892	100	849991	100.1
850007	100.2	850455	100.1	850813	100.2	850948	100.3	851431	99.9
851518	99.9	851591	99.8	852443	100	852530	100.1	852536	100.1
852544	99.9	852695	100.1	852702	99.9	852858	100.1	852964	100.2
854282	100.1	854362	100	854679	100	854724	99.9	854863	100
868461	99.9	868519	100.1	868645	100	868659	100.1	868720	100
868762	100.1	868780	100.1	868794	99.94	868825	100.1	869111	100
869134	100	869160	99.9	869328	100	869428	100	869475	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7501.51	Lower Specification Limit (L)	98
Sum of Squared Measurements	750303.04	Quality Index Upper (QU) : (U - XBAR) / S	16.95
Correction Factor (CF) : Sum of Measurements Squares / N	750302.03	Quality Index Lower (QL) : (XBAR - L) / S	17.30
Corrected Sum of Squares (SS)	1.01	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.12	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.02	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1S      Division : 01      Sample Lot : 2418      Lot Descr : LGE C1S-3  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
854985	100	855022	100.1	855132	100	855458	100	855471	100
855501	99.8	855647	100.1	856238	99.9	856490	100	856621	99.9
856666	100	856766	100	856857	100.1	856888	100.1	857108	99.9
857171	99.8	857206	99.9	857691	99.9	857974	99.9	858027	100
858160	100	858248	100	858272	99.9	858317	99.9	858332	100
858373	100	858461	99.9	858482	100.1	858486	100	858772	99.9
858792	100	859819	100	859843	100	860027	99.9	860077	100
860303	100.1	860660	100	860798	100	860944	100	860968	100
861196	100.1	861963	100	862211	100	862779	99.9	862785	100.1
863584	99.9	863640	99.9	863821	99.98	863988	100.1	864025	100
864093	100	864126	100	864145	99.9	865220	100	865249	100.1
865513	100	865600	99.8	865616	100.1	865624	100	865899	100
866018	99.9	866231	100	866403	99.9	866416	99.9	866678	99.9
866752	99.9	866868	100.2	866936	100.1	867003	99.9	867301	100
870581	100	870792	100	870995	100.1	871073	99.9	871124	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.68	Lower Specification Limit (L)	98
Sum of Squared Measurements	749736.51	Quality Index Upper (QU) : (U - XBAR) / S	24.88
Correction Factor (CF) : Sum of Measurements Sqaures / N	749736.02	Quality Index Lower (QL) : (XBAR - L) / S	24.44
Corrected Sum of Squares (SS)	0.49	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.08	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.98	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1S      Division : 01      Sample Lot : 2419      Lot Descr : LGE C1S-4  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
871852	99.9	873339	100	873387	99.9	873671	100.1	873739	100.1
873822	100	873970	100.1	874002	99.9	874019	100.1	874327	100
874378	100.1	874510	100	874534	99.9	874658	100	876619	100
876792	100	876956	100	876976	100.1	876982	99.8	877089	100
877201	99.9	877279	100.1	877375	100.2	877379	100	877506	99.9
877735	100	878176	100.1	878209	100	878332	100	878373	100.1
878424	99.9	878573	100	878583	100.1	878872	100.1	879095	99.9
879359	100.2	879734	99.8	879916	100.2	880208	100.2	880259	100
880359	100	880421	100.1	881559	100	881690	100.2	882020	99.9
882080	100.5	882145	100	882177	100.2	882204	99.9	882286	100.1
882370	100	882393	100	882394	100	883165	100	883330	100
883391	100	883426	99.8	883727	99.9	883730	100	883782	100
883861	100.1	884150	99.9	884204	100.2	884478	100.2	884516	99.9
884567	100	884586	100	884630	99.9	884790	100	885675	100
885685	99.9	885861	100	885909	100	886150	100.1	886179	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7501.40	Lower Specification Limit (L)	98
Sum of Squared Measurements	750281.00	Quality Index Upper (QU) : (U - XBAR) / S	17.27
Correction Factor (CF) : Sum of Measurements Squares / N	750280.03	Quality Index Lower (QL) : (XBAR - L) / S	17.60
Corrected Sum of Squares (SS)	0.97	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.11	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.02	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1S      Division : 01      Sample Lot : 2420      Lot Descr : LGE C1S-5  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
886442	100	886638	99.9	886651	100	886939	99.9	886999	100
887343	100	887382	100	887416	99.9	887604	100	890056	100
890135	100	890261	100	890464	100	890612	100	890772	100
890822	99.9	892098	99.9	892214	100.1	892221	100.1	892809	100
892878	100.1	892902	100	893009	100	893206	99.9	893384	99.8
893430	99.7	893761	99.9	893788	100.1	893907	100.1	893976	100
894080	100	894117	100	894268	100	894398	100	894554	100
894596	100	894735	100	894956	100	895466	100.1	895476	99.9
895579	99.9	895761	100	896850	100	897109	99.9	897199	99.9
897209	100	897366	99.9	897924	100	897931	99.96	898005	99.9
898200	100.1	898256	99.9	898500	100	898862	100	898921	99.9
899178	99.9	899250	100	899383	100	899439	100	899523	100
899580	99.9	899612	99.9	900106	100	900163	99.9	900440	100
900485	99.9	900569	99.9	900595	100.1	900762	100	900850	99.9
900984	100	901108	100.1	901165	100.2	901185	100.1	901277	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.56	Lower Specification Limit (L)	98
Sum of Squared Measurements	749712.50	Quality Index Upper (QU) : (U - XBAR) / S	25.27
Correction Factor (CF) : Sum of Measurements Squares / N	749712.03	Quality Index Lower (QL) : (XBAR - L) / S	24.79
Corrected Sum of Squares (SS)	0.47	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.08	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.98	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C1S      Division : 01      Sample Lot : 2421      Lot Descr : LGE C1S-6  
 In Service Population : 8839      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
901461	100.1	901504	100	901651	100	901958	100	902359	100
902503	100	902513	100	902547	100	902593	100	902608	100
902698	100	902729	100	903090	100.2	903105	100	903112	100
904102	100	904170	99.9	904316	99.9	904485	99.9	904504	99.9
904553	99.9	904581	99.9	904746	99.9	904771	99.8	904821	99.9
905131	100	905258	100	905310	99.9	905364	100	905454	100.1
905483	99.9	905565	100.02	905822	99.9	905838	100	905965	100
908987	100.2	909157	100	909428	100	909579	99.9	909705	100
909758	99.9	909828	100.1	910009	100	910080	100	910162	100
910247	100	910291	100	910351	100	910564	100	910612	99.9
911799	99.9	911855	99.9	911887	99.9	912295	99.9	912353	99.9
912503	99.8	912524	99.9	912544	100.1	912582	100.1	913955	100
913995	100	914188	100.1	914338	100	914609	100.1	914644	100.2
914875	100	914992	100	915250	99.9	915384	100	915435	99.9
915466	100	915921	100	918428	99.95	918738	100	920176	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.57	Lower Specification Limit (L)	98
Sum of Squared Measurements	749714.50	Quality Index Upper (QU) : (U - XBAR) / S	25.26
Correction Factor (CF) : Sum of Measurements Squares / N	749714.03	Quality Index Lower (QL) : (XBAR - L) / S	24.78
Corrected Sum of Squares (SS)	0.47	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.08	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.98	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : C2SOS      Division : 01      Sample Lot : 2422      Lot Descr : LGE C2SOS-1  
 In Service Population : 541      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
903706	99.9	908109	100	908136	99.9	908208	100	908240	100.1
908290	99.9	908309	100.1	908324	100	908357	100	908377	99.9
908426	100	908467	100	908489	100	908535	100	908599	99.9
908600	99.9	908631	99.9	908634	100	908645	100	908658	100
908686	100	908687	100	908693	100.1	910727	100	910747	100
910795	99.9	910808	99.8	910818	99.9	910821	100	910851	99.9
910868	100	910898	99.9	910945	99.9	911041	100	913412	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3499.00	Lower Specification Limit (L)	98
Sum of Squared Measurements	349800.20	Quality Index Upper (QU) : (U - XBAR) / S	28.57
Correction Factor (CF) : Sum of Measurements Sqaures / N	349800.03	Quality Index Lower (QL) : (XBAR - L) / S	27.76
Corrected Sum of Squares (SS)	0.17	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.07	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.97	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : D4S      Division : 01      Sample Lot : 2423      Lot Descr : LGE D4S-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
367272	99.7	367297	99.7	367464	99.7	371796	99.9	372483	100.4
376224	100.1	376333	100.7	376337	100	376461	99.9	376633	100.3
376665	100.7	376811	99.8	376877	100	381397	99.3	381482	100.3
381550	100.3	386228	99.5	386319	100.2	391092	99.4	391119	99.6
391457	99.9	391478	98.7	391653	99.3	391673	99.6	391927	99.2
395625	99.8	396127	99.2	400356	100	400371	100	400387	99.7
401365	100.1	405486	99.9	405767	99.6	405931	100	410207	100.2
410664	100.2	410707	99.7	414923	100.1	415473	100.3	415630	99.7
419615	100.6	420107	100.1	420293	99.4	420304	100.5	425437	100.3
425670	99.8	426846	99.6	431098	100.3	431397	100	431912	99.7
437021	99.8	437374	100.2	441047	99.3	446457	100	446579	100.2
446658	99.4	448085	100	448087	99.9	449151	99.9	451563	100.2
451605	100.1	451636	99.3	451699	100.5	451849	100.8	453907	100.3
456634	100.2	458213	100.2	458411	100	458565	100.1	460980	100.2
461361	99.9	464444	100.2	464501	99.9	464820	100.2	465236	100.2

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7496.00	Lower Specification Limit (L)	98
Sum of Squared Measurements	749211.58	Quality Index Upper (QU) : (U - XBAR) / S	5.24
Correction Factor (CF) : Sum of Measurements Sqaures / N	749200.21	Quality Index Lower (QL) : (XBAR - L) / S	4.97
Corrected Sum of Squares (SS)	11.37	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.15	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.39	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.95	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (J00) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : D4S      Division : 01      Sample Lot : 2424      Lot Descr : LGE D4S-2  
 In Service Population : 1813      Sample Quantity : 50      Meters Tested : 50      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
465305	100	465406	100.4	465503	100.2	465583	100.3	468602	100
468716	100.1	468907	100.4	470025	101.2	470648	99.5	470659	100.3
470875	99.9	470987	100	470989	100.3	470991	100.1	471088	100.6
471283	100.3	471337	99.7	471363	100.1	472556	99.9	472662	99.9
472696	99.8	472700	99.8	472926	100.1	472945	100.5	474911	100
475533	100.3	475576	99.9	475585	100.1	475750	100.1	475774	100.2
475841	99.9	475905	99.7	475930	100.1	475969	100	478318	99.9
478337	100	478361	99.5	478441	99.9	478443	99.7	478506	100.9
478515	100.1	478538	99.4	478619	100	479970	100	481457	100.2
483356	100.1	483446	100.1	483453	100.1	483547	100.4	483589	100.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	50	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	5004.90	Lower Specification Limit (L)	98
Sum of Squared Measurements	500986.11	Quality Index Upper (QU) : (U - XBAR) / S	5.61
Correction Factor (CF) : Sum of Measurements Sqaures / N	500980.48	Quality Index Lower (QL) : (XBAR - L) / S	6.19
Corrected Sum of Squares (SS)	5.63	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.11	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.34	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.10	Maximum Allowable Percent NCF (M)	5.21
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : Focus AXR - Mesh      Division : 01      Sample Lot : 2425      Lot Descr : LGE Focus AXR-1

In Service Population : 2608      Sample Quantity : 50      Meters Tested : 50      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
903284	99.9	903313	99.9	906347	99.9	906415	100	906426	99.9
906444	99.9	906481	99.9	906576	99.9	906665	99.9	906718	100
906727	99.9	906730	99.9	906745	99.9	906785	99.9	906831	99.9
907089	99.9	907132	99.9	907206	99.9	907253	99.9	907297	99.9
907381	99.9	907387	99.9	911265	100.1	911377	99.9	911408	99.9
911486	100	911557	99.9	916599	99.9	916730	100	916765	99.9
916793	99.9	916807	99.9	916864	99.9	916925	99.9	916933	100
916965	99.9	917013	99.9	917026	99.9	917054	99.9	917059	99.9
917065	99.9	917097	99.9	917183	99.9	917260	99.9	917316	99.9
917370	99.9	917396	99.9	917402	99.9	917468	100	917576	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	50	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	4995.80	Lower Specification Limit (L)	98
Sum of Squared Measurements	499160.44	Quality Index Upper (QU) : (U - XBAR) / S	49.40
Correction Factor (CF) : Sum of Measurements Sqaures / N	499160.35	Quality Index Lower (QL) : (XBAR - L) / S	45.42
Corrected Sum of Squares (SS)	0.09	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.00	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.04	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.92	Maximum Allowable Percent NCF (M)	5.21
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E      Model Number : I-210      Division : 01      Sample Lot : 2426      Lot Descr : LGE I210-1  
 In Service Population : 972      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
832157	100	832189	99.9	832205	100	832219	100	832223	100
832225	99.9	832264	100	832267	100.1	832271	99.9	832277	100
832280	100.1	832284	99.9	832334	99.9	832361	99.7	832424	100.1
832449	100	832522	100	832533	99.9	832574	99.9	832638	99.9
832696	100	832727	100	832797	100	832836	99.9	832849	100.1
832850	99.9	832878	100.1	832921	99.9	835331	100.2	838192	99.9
838200	100	838214	99.8	838271	99.9	838319	100	838336	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3498.80	Lower Specification Limit (L)	98
Sum of Squared Measurements	349760.36	Quality Index Upper (QU) : (U - XBAR) / S	21.01
Correction Factor (CF) : Sum of Measurements Sqaures / N	349760.04	Quality Index Lower (QL) : (XBAR - L) / S	20.30
Corrected Sum of Squares (SS)	0.32	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.01	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.10	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.97	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V15AC100      Model Number : I-50S      Division : 01      Sample Lot : 2427      Lot Descr : LGE I50-1  
 In Service Population : 814      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
186635	99.9	198536	100	200159	100.5	201291	100.2	206533	100.3
208685	99.9	208954	100.2	211287	100.29	211595	100.28	212344	100.4
212797	100.2	213816	100	214382	100.4	214407	100.1	215925	100.2
215942	99.4	216185	100.4	218261	100.7	218537	100	221103	100.32
222583	99.7	223608	100.05	224033	100.26	226934	100.4	229357	100.1
230025	100.3	231651	99.8	231873	99.8	232621	100	232999	100.3
235967	100.1	236082	99.9	236106	100	237001	100.4	237082	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3504.70	Lower Specification Limit (L)	98
Sum of Squared Measurements	350942.91	Quality Index Upper (QU) : (U - XBAR) / S	7.21
Correction Factor (CF) : Sum of Measurements Sqaures / N	350940.63	Quality Index Lower (QL) : (XBAR - L) / S	8.24
Corrected Sum of Squares (SS)	2.28	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.07	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.26	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.13	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V15AC100      Model Number : I-555      Division : 01      Sample Lot : 2428      Lot Descr : LGE I55-1  
 In Service Population : 1085      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
238255	100	239481	100.3	240733	100.5	240817	100.3	245857	100
246232	100.2	246308	99.7	247262	100.3	248761	100.4	250258	100.1
250545	100.1	250583	99.97	250980	100.6	252098	99.7	253151	100.4
256509	100.6	257422	100.1	257429	100.2	257618	99.9	263002	100
263456	99.9	263467	99.8	264132	100.3	264231	100	264354	99.8
264715	100.2	264731	100	264927	99.8	264991	99.8	265289	99.8
265661	100.3	265688	100	265774	99.9	265858	100.1	312807	99.3

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3502.37	Lower Specification Limit (L)	98
Sum of Squared Measurements	350476.80	Quality Index Upper (QU) : (U - XBAR) / S	6.94
Correction Factor (CF) : Sum of Measurements Squares / N	350474.16	Quality Index Lower (QL) : (XBAR - L) / S	7.42
Corrected Sum of Squares (SS)	2.64	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.07	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-60S      Division : 01      Sample Lot : 2429      Lot Descr : LGE I60-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
269036	99.9	269221	99.8	271085	99.6	275125	100.2	276085	100.4
278716	99.8	280407	99.7	280484	100.4	281174	100	281685	100
281794	99.8	281874	100.4	282126	99.8	282480	99.6	284875	99.7
285927	100.3	286560	99.9	291627	100.3	292339	100	294174	100.1
294362	99.8	294900	100	295043	99.8	295127	99.5	295797	99.4
297235	99.6	298653	99.8	298898	99.7	299062	100.3	299482	100.2
299499	99.39	300368	99.4	303821	99.8	304021	99.8	304564	99.8
307290	99.7	307832	99.9	312034	100	312811	100.1	313653	99.6
313884	100	316327	100.4	316332	100	316373	100.1	316547	100.2
316724	99.7	317173	99.9	317538	100.3	317575	99.8	317609	100.1
317728	100.3	318115	100	318218	99.9	320005	100.1	320307	100.3
320326	99.4	324045	99.6	324116	100	326559	100	332013	99.7
333612	100.2	333695	100.1	333824	100.2	334088	100.5	334200	99.4
334446	99.8	334534	99.8	334556	100.2	335855	100.4	336226	99.8
336249	100.2	336453	100	338233	99.9	338290	100	338476	99.8

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7495.39	Lower Specification Limit (L)	98
Sum of Squared Measurements	749083.99	Quality Index Upper (QU) : (U - XBAR) / S	7.42
Correction Factor (CF) : Sum of Measurements Squares / N	749078.28	Quality Index Lower (QL) : (XBAR - L) / S	6.98
Corrected Sum of Squares (SS)	5.71	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.94	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-60S      Division : 01      Sample Lot : 2430      Lot Descr : LGE I60-2  
 In Service Population : 1689      Sample Quantity : 50      Meters Tested : 50      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
340262	100.3	340288	99.9	340378	99.9	340652	100	340982	99.9
342800	100.2	342828	100.3	342831	100	342953	100	343082	100.1
343094	100.2	343688	100	345157	100	345350	100.2	345489	100.1
345714	100.2	347447	100.2	347491	99.87	347646	100.1	347775	100
347880	100.1	347952	100.1	349670	100.2	349977	100	350087	99.5
350349	99.7	352021	100	352044	100.1	352225	99.9	352260	99.9
352271	99.9	352403	99.9	352481	99.7	352490	100	352564	99.82
352607	100.2	352650	100	352654	100	352721	99.9	352815	100.21
354479	99.6	354499	100.15	357362	100.2	357387	100.6	357429	99.7
357614	99.71	359175	99.9	359286	100.2	359457	99.9	359504	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	50	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	5000.56	Lower Specification Limit (L)	98
Sum of Squared Measurements	500113.94	Quality Index Upper (QU) : (U - XBAR) / S	10.01
Correction Factor (CF) : Sum of Measurements Sqaures / N	500112.01	Quality Index Lower (QL) : (XBAR - L) / S	10.12
Corrected Sum of Squares (SS)	1.93	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.04	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.20	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.01	Maximum Allowable Percent NCF (M)	5.21
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2431      Lot Descr : LGE I70-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
361373	100.2	361531	100.4	361589	100.1	361718	99.6	361892	100.3
363805	100.2	364139	100.7	364145	100	364258	100.1	364288	100.1
365884	100.2	366112	99.6	366230	99.9	366243	100.1	366351	99.9
366704	99.9	366713	99.9	368179	100.1	368212	100.1	368419	100.2
368876	99.8	369009	100.1	369025	100.1	370938	100.2	371207	100.3
373268	100.3	373326	100.3	373355	100.5	373356	100.4	375287	100.3
375397	99.9	375466	100.6	375870	100.4	376084	100.4	377116	100.4
377125	100.2	377153	100.6	377390	100	377480	100.1	377505	100.2
377769	99.7	377897	100.3	377968	100.3	380519	100.1	380542	100.4
380584	100.2	380747	100.3	380757	100.1	380797	100.1	380882	100
381035	100.4	381112	100.2	382362	100.2	382491	99.9	382652	100.4
382733	100.1	382839	100.4	382848	99.9	384761	100	385166	99.8
385213	100.3	385602	100.2	387096	100.3	387198	100.5	387370	100
387466	99.8	387525	100.2	387545	100.1	387870	99.9	390215	100.1
390632	100.4	390642	100.2	390940	100.2	392736	99.6	392940	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7511.40	Lower Specification Limit (L)	98
Sum of Squared Measurements	752285.70	Quality Index Upper (QU) : (U - XBAR) / S	7.98
Correction Factor (CF) : Sum of Measurements Squares / N	752281.73	Quality Index Lower (QL) : (XBAR - L) / S	9.29
Corrected Sum of Squares (SS)	3.97	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.05	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.23	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.15	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2432      Lot Descr : LGE I70-2  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
394773	100.2	394904	100	395504	100.2	396643	100.3	396673	99.9
396684	100.2	396886	100.2	396942	100	397200	99.7	397262	100.2
399020	100.1	399286	99.8	399842	100.1	400003	99.9	401531	100.2
401627	100	401819	100.2	401830	100	401847	100.4	401948	99.8
402004	99.9	402399	100.3	402433	100.1	404497	100.5	404532	99.9
404551	100.2	404556	100.1	404561	99.9	405049	100.5	405111	100
405220	100.3	406407	100.1	406409	100	406791	100	406837	100.1
406943	99.9	407205	100.2	409183	100.3	409208	100.3	409241	100.3
409646	99.9	409764	100	411066	100.4	411176	100.1	411277	100.4
411409	100	411509	100.1	411733	100.1	411869	100.2	413894	100.1
413943	99.8	414193	98.3	414534	100.1	414551	100.1	414608	100.8
416336	100.4	416567	99.8	416780	100.3	416995	100	417065	100.4
418627	100	419126	99.9	419151	100.2	419166	100.3	419206	100
419282	100	421203	99.9	421319	100	421323	99.8	421673	100
421740	100	423903	100.3	424530	99.8	424627	100.1	425869	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7506.00	Lower Specification Limit (L)	98
Sum of Squared Measurements	751206.64	Quality Index Upper (QU) : (U - XBAR) / S	6.65
Correction Factor (CF) : Sum of Measurements Squares / N	751200.48	Quality Index Lower (QL) : (XBAR - L) / S	7.21
Corrected Sum of Squares (SS)	6.16	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.29	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.08	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2433      Lot Descr : LGE I70-3  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
426386	100.1	426416	100.2	426507	100.2	429226	100.3	429288	99.9
429296	100.1	429928	99.9	432102	99.7	432385	100.1	432668	99.9
432725	100.4	436051	100.2	436197	100.2	436433	100.6	436481	100.1
436541	100.2	437698	99.8	437721	100.6	437756	99.4	437778	99.8
437783	100.1	437791	100.1	438001	100	438263	99.9	438392	99.9
442512	99.7	442517	99.9	442606	99.8	442618	99.7	442684	99.8
442765	99.9	442924	99.9	444916	99.9	444988	99.8	445032	100
445372	100.2	445402	100.4	445473	100.1	445623	100	445675	100.1
448333	100.1	449342	99.9	449411	100.4	449480	99.9	449502	100.2
449573	99.7	450933	100.5	451155	100	451206	99.9	453111	100.1
455453	100.1	455490	100	455559	100	455735	100	456159	100
457650	99.9	459143	100.1	459326	100.1	459406	100.1	459415	100.1
459717	100.1	459964	99.7	461617	100.2	461712	100.2	463384	100.1
463422	99.7	463715	100.1	463942	100.5	463961	100.31	464013	100.2
464111	100.3	465656	100.7	465752	99.9	465820	100.1	465847	99.8

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7503.91	Lower Specification Limit (L)	98
Sum of Squared Measurements	750786.34	Quality Index Upper (QU) : (U - XBAR) / S	8.24
Correction Factor (CF) : Sum of Measurements Squares / N	750782.20	Quality Index Lower (QL) : (XBAR - L) / S	8.68
Corrected Sum of Squares (SS)	4.14	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.06	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.24	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.05	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2434      Lot Descr : LGE I70-4  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
467359	100.1	467588	100	467593	100.1	467823	100.2	471635	100
471644	99.9	472257	100	472491	100	474454	100	474872	100.2
475973	100	476416	100.1	476436	100	476567	99.8	476676	100.1
476748	99.8	476853	100	479089	100.2	479375	99.9	479413	100.1
479726	100.3	479750	100.3	480267	99.7	480349	100.1	482627	100.2
482798	99.9	482931	100.4	483068	100.3	483112	100.2	483895	99.9
483946	100.14	484050	100.1	484284	99.9	484324	99.8	484326	100.2
484709	100.1	484748	100	484927	99.8	487261	99.9	487287	100.1
487488	100	487602	100.2	487736	100	487885	100.1	487988	100.2
488054	100.2	489562	99.6	489624	100.3	489654	99.7	489758	99.6
490116	100.11	490614	100.2	490645	100.1	490721	99.7	490929	99.9
493178	100.2	493251	100.1	493390	100	493860	100.2	493992	99.8
494121	99.4	498336	99.6	498528	100	498715	100.8	498779	99.7
498994	100	499238	100.1	499399	100.1	500213	99.8	500908	100.2
500943	100.1	501126	100	501314	100.2	501320	100	501331	100.2

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7502.25	Lower Specification Limit (L)	98
Sum of Squared Measurements	750453.45	Quality Index Upper (QU) : (U - XBAR) / S	9.21
Correction Factor (CF) : Sum of Measurements Sqaures / N	750450.07	Quality Index Lower (QL) : (XBAR - L) / S	9.49
Corrected Sum of Squares (SS)	3.38	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.05	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.21	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.03	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2435      Lot Descr : LGE I70-5  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
501604	100.1	501712	100.3	505975	99.8	506107	100.15	506247	100
506268	99.8	506390	100.2	506439	99.9	506461	100	506530	99.8
506618	99.8	506774	99.7	506885	99.6	507100	100.3	509869	99.97
510056	99.8	510366	100	510402	100.2	511465	100.1	511729	99.8
511732	99.8	512210	100.9	515717	100.1	515875	100	515919	99.7
515962	100.1	516035	100	516039	99.9	516053	99.9	516061	99.8
516212	100	516328	100.1	516346	99.9	516526	99.9	516604	99.9
520041	99.5	522184	99.6	522723	99.9	522864	99.8	522938	99.9
523971	99.4	524028	99.8	524118	99.8	524434	100.3	524455	99.7
524651	99.9	526582	100.1	526828	100.4	526927	100.6	529197	100.3
529276	99.9	529752	100	529857	99.4	532892	99.9	532989	100.1
533088	99.9	533115	100.1	533137	100.2	540528	99.6	540811	100.1
541330	99.9	541449	100.1	541605	100.3	541624	99.9	541925	99.8
542159	99.7	542217	100.1	545193	100.1	545210	100.2	545263	100.2
545351	99.9	545516	100.2	551678	100.3	551779	100.2	551850	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.32	Lower Specification Limit (L)	98
Sum of Squared Measurements	749668.74	Quality Index Upper (QU) : (U - XBAR) / S	8.02
Correction Factor (CF) : Sum of Measurements Squares / N	749664.04	Quality Index Lower (QL) : (XBAR - L) / S	7.85
Corrected Sum of Squares (SS)	4.70	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.06	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.25	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.98	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2436      Lot Descr : LGE I70-6  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
551946	99.7	552072	100.1	552143	100	552159	100.1	552195	100
552691	100.1	552713	100.1	552717	100.1	552904	100	552961	100
553049	100	553307	100	553340	99.8	553398	100	553449	100.4
553769	100	553899	100.3	553970	100.3	555426	100	555454	100.2
555530	99.9	555559	100	555583	100.19	561677	100	561691	99.9
562228	99.9	563035	99.9	563099	100	563293	100.4	563410	100.2
563564	99.8	563581	100	563629	100.1	563637	99.8	563958	100
564109	99.8	564214	100.2	564647	100.2	565368	99.7	565420	100
568488	100.2	568500	99.8	568945	99.9	568970	100.2	569172	100.3
569210	100.3	569346	100.1	569418	100.2	569436	100.1	569664	99.9
569852	100.2	569890	99.9	569911	100.1	569994	100.2	570075	100
570123	99.9	570488	100.1	570569	99.9	570891	100	571264	99.8
571295	100.1	571489	100	571692	100.2	571766	100.3	572178	99.6
572180	100	572326	100.1	572373	100	572448	100.3	572563	99.9
572620	100.2	572769	100.1	573336	100	573657	100.2	573678	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7503.39	Lower Specification Limit (L)	98
Sum of Squared Measurements	750680.20	Quality Index Upper (QU) : (U - XBAR) / S	11.75
Correction Factor (CF) : Sum of Measurements Squares / N	750678.15	Quality Index Lower (QL) : (XBAR - L) / S	12.30
Corrected Sum of Squares (SS)	2.05	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.17	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.05	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2437      Lot Descr : LGE I70-7  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
582209	100.1	582225	100	582420	100.2	582453	100.4	583142	100
583170	100	583171	100.1	583224	100.2	583411	100	583423	100.2
583503	100.2	591440	100.3	591473	100	591664	100	591808	99.8
591809	100.2	591885	100.1	592292	99.9	592423	100.6	592773	100.1
592815	100.2	592979	99.9	593190	100.3	593363	100.43	593621	100
593622	100	593735	100.1	594290	100.2	594415	100.4	594419	100.3
594442	100.1	594471	100.5	594827	100.2	594942	100.2	598794	100.3
598870	99.9	598945	99.9	599047	100	599069	100	602824	100.2
603049	99.7	603379	100	604061	100.1	604227	99.9	604365	100
604371	100.4	604402	100.1	604511	99.8	604786	99.8	604824	100
605196	100	605499	99.8	605673	100.3	605830	99.9	605864	100.1
606043	100.1	606053	100.3	606123	100.1	606500	100	606557	99.9
623672	100.3	624056	100.2	624185	100.3	624491	100.2	624502	99.9
624577	99.9	624875	100.1	624906	100.2	625106	100.3	625128	100.1
625285	100.3	625329	100.2	625358	100.2	625491	100.2	625571	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7508.33	Lower Specification Limit (L)	98
Sum of Squared Measurements	751669.29	Quality Index Upper (QU) : (U - XBAR) / S	10.57
Correction Factor (CF) : Sum of Measurements Sqaures / N	751666.93	Quality Index Lower (QL) : (XBAR - L) / S	11.81
Corrected Sum of Squares (SS)	2.36	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.18	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.11	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-70S

Division : 01

Sample Lot : 2438

Lot Descr : LGE I70-8

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
626059	100.1	626203	99.91	626280	99.6	626298	100.6	626448	100.1
626532	100.2	626550	99.9	627029	99.9	627419	100.4	627435	99.9
627558	99.8	627673	100.2	627718	100.1	627762	99.7	628181	99.9
628304	99.61	628382	100.1	628420	100.1	628495	99.9	628622	100.2
628651	100.4	628738	100.1	628927	100.2	628945	100.1	629015	100.5
629056	100.1	629319	100	629575	100.2	629636	99.9	630227	99.9
630310	99.9	630379	100.4	630501	100.2	630766	100.1	631071	100.3
631100	100	631213	100	631341	100.3	631442	99.9	631520	100.2
631734	99.8	631781	100.1	631911	100.1	633724	99.97	639641	99.7
639683	100.1	639927	100.5	640038	99.9	640049	100.1	640185	100
640325	100.6	640625	100.3	641007	100.12	641329	99.6	641359	100.1
641553	100.1	641696	99.9	641743	100.2	641952	100.3	642052	100.1
642131	99.9	642249	100.2	642269	100.2	642335	100.2	642791	99.7
642836	99.8	642853	100	643111	100.1	643365	99.8	643557	99.9
643666	100.2	644004	100.1	644159	100.2	644539	100.4	644648	100.3

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7505.51	Lower Specification Limit (L)	98
Sum of Squared Measurements	751106.07	Quality Index Upper (QU) : (U - XBAR) / S	8.66
Correction Factor (CF) : Sum of Measurements Squares / N	751102.40	Quality Index Lower (QL) : (XBAR - L) / S	9.32
Corrected Sum of Squares (SS)	3.67	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.05	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.22	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.07	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2439      Lot Descr : LGE I70-9  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
645327	100.1	654256	100.2	654607	100	654718	100.3	655016	100
655103	100.1	655250	99.6	655300	100.1	655543	99.9	655573	100
655692	100	655934	99.9	655957	100	655993	99.7	656373	100.3
656500	100.1	656654	100.2	656795	100.2	656897	100.1	677030	100.1
677157	100	677198	100.1	677302	99.9	677311	99.8	677319	99.8
677374	100.1	677424	100	677439	99.8	677562	100	677888	99.8
677929	99.8	678156	100	678465	99.9	678595	100.1	678606	99.6
678614	99.8	678716	99.7	678800	99.9	678849	100.1	679352	99.9
679466	99.8	679531	100.2	679568	99.8	679774	100.1	679956	100.1
680081	99.7	680289	99.9	680557	99.9	680561	99.8	680668	99.9
680670	100.1	680732	100.2	680836	100.1	680923	100	680999	99.9
681187	100.1	681234	99.2	681718	100.1	681841	100	681956	99.7
682125	100.245	682197	99.9	682215	99.6	682291	99.8	689590	100.1
689818	100.3	690161	100.2	690492	100.1	690798	100.2	690849	100
690904	100.2	691064	100	691164	100.24	691179	100.1	691297	100.4

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.99	Lower Specification Limit (L)	98
Sum of Squared Measurements	749800.05	Quality Index Upper (QU) : (U - XBAR) / S	12.14
Correction Factor (CF) : Sum of Measurements Squares / N	749798.01	Quality Index Lower (QL) : (XBAR - L) / S	11.98
Corrected Sum of Squares (SS)	2.04	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.17	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.99	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : I-70S      Division : 01      Sample Lot : 2440      Lot Descr : LGE I70-10  
 In Service Population : 474      Sample Quantity : 25      Meters Tested : 25      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
691558	99.9	691562	100.2	691575	100.1	691595	100.2	691608	100.3
691624	99.7	691633	100.2	691654	100.2	691696	100.6	691704	99.9
691752	99.9	691775	100.2	691809	100.31	691824	100.2	691838	100.1
691842	100	691866	100.3	691892	100.3	691906	100	691951	100
691998	100.1	692021	100.1	692084	100.1	692085	100.1	692087	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	25	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	2502.91	Lower Specification Limit (L)	98
Sum of Squared Measurements	250583.16	Quality Index Upper (QU) : (U - XBAR) / S	10.18
Correction Factor (CF) : Sum of Measurements Squares / N	250582.34	Quality Index Lower (QL) : (XBAR - L) / S	11.44
Corrected Sum of Squares (SS)	0.82	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.18	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.12	Maximum Allowable Percent NCF (M)	5.98
		Acceptability Criterion : Compare P with M	Pass



# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J4S      Division : 01      Sample Lot : 2441      Lot Descr : LGE J4S-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
388031	98.8	388389	100.72	388438	99.4	388457	99.9	388742	100.7
393186	99.7	393415	100.2	393695	100.1	397670	99.7	397969	100.4
398031	99.1	398093	100.1	398330	99.7	402706	100.2	403254	100
403367	100	407667	100.3	407710	100.5	407899	99.6	408454	99.8
408513	100.1	408535	100.2	412245	100.2	412264	100.2	412312	100.2
412378	100.1	412563	100.1	422392	100.8	422520	99.9	422702	100
427271	99.7	427721	99.9	433245	100.3	433300	100.1	433359	99.8
433376	99.8	433779	100.2	438488	100.3	439111	100.5	439232	99.7
439414	100.35	443040	99.8	443423	100.2	446841	99.4	446978	100
447079	100.1	449869	99.9	449946	100	450030	100.2	450078	99.9
450107	100	453829	100	457062	99.82	457118	100.3	460041	100.3
460203	99.7	468109	99.8	468119	99.5	473624	99.7	473838	100.7
473916	99.6	477956	99.7	478179	99.8	486155	100	492709	100
492743	99.6	493012	99.8	496089	100.1	499630	100.1	499632	99.8
499862	99.7	499904	99.8	502090	99.9	734244	100.1	740212	99.6

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7498.29	Lower Specification Limit (L)	98
Sum of Squared Measurements	749666.95	Quality Index Upper (QU) : (U - XBAR) / S	5.83
Correction Factor (CF) : Sum of Measurements Squares / N	749658.04	Quality Index Lower (QL) : (XBAR - L) / S	5.70
Corrected Sum of Squares (SS)	8.91	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.12	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.35	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.98	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC320      Model Number : J4ES      Division : 01      Sample Lot : 2442      Lot Descr : LGE J4S-2  
 In Service Population : 230      Sample Quantity : 15      Meters Tested : 15      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
740239	100.3	740253	100.6	740282	101.2	740285	99.7	740306	100.3
740313	100.6	740339	99.7	740340	100	740368	99.9	740389	100.7
740399	100.6	740404	99.9	740409	99.7	756225	99.9	756236	99.7

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	15	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	1502.80	Lower Specification Limit (L)	98
Sum of Squared Measurements	150563.58	Quality Index Upper (QU) : (U - XBAR) / S	3.88
Correction Factor (CF) : Sum of Measurements Sqaures / N	150560.52	Quality Index Lower (QL) : (XBAR - L) / S	4.68
Corrected Sum of Squares (SS)	3.06	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.22	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.47	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.19	Maximum Allowable Percent NCF (M)	6.55
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2443      Lot Descr : LGE J5S-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
512305	99.9	512673	99.8	512843	99.8	512993	99.6	513126	99.8
513855	99.6	513872	99.8	513992	100.1	514069	100.6	514550	100.1
514736	99.9	516873	100.2	516978	99.7	517353	100.5	517496	99.9
517639	99.8	517780	100.3	517786	100.3	518209	99.9	518331	100
518665	100	518679	99.4	521781	100.4	521910	99.72	521960	100.11
525544	100.1	525702	99.7	525756	100.1	525891	99.8	525915	99.6
526123	100.5	526188	100	526258	99.6	527300	99.7	527444	99.8
527501	99.9	527828	99.4	527883	99.8	528069	99.8	528121	99.9
528270	99.8	528915	99.7	530476	99.7	530500	100.2	530622	99.9
530708	99.4	530719	99.9	530737	99.4	530889	99.9	531185	99.1
531254	99.6	531319	99.4	534138	100.3	534176	100.1	535078	99.7
535103	99.8	535175	99.4	535218	99.8	535367	99.9	535658	100
539601	99.8	540053	99.9	543261	99.9	543425	100.5	543612	100.3
543905	100.5	543939	100	544003	100.1	544026	100.4	544037	99.9
544115	99.9	544370	100.1	544737	100	545022	100.4	548723	100.6

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7494.23	Lower Specification Limit (L)	98
Sum of Squared Measurements	748853.77	Quality Index Upper (QU) : (U - XBAR) / S	6.60
Correction Factor (CF) : Sum of Measurements Squares / N	748846.44	Quality Index Lower (QL) : (XBAR - L) / S	6.11
Corrected Sum of Squares (SS)	7.33	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.10	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.31	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.92	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2444      Lot Descr : LGE J5S-2  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
548958	100.2	549403	99.9	549444	99.9	549613	100.1	549618	100.3
549707	100	549993	100.6	550213	100.5	550313	100.3	550321	100.18
550415	100.1	550631	99.7	550636	100.2	555979	100	556051	99.8
556107	99.7	556358	99.8	556908	99.3	557074	99.9	557215	99.7
557514	100.1	557894	99.9	558144	100.1	558173	99.9	558362	99.6
558461	100	565702	99.7	565759	100.4	566642	99.9	566884	99.5
567126	99.9	567138	99.7	567159	99.5	567515	100.1	567615	99.9
567627	100.2	567689	100.2	567956	100	568023	99.7	568107	99.6
568142	99.5	574077	99.2	574175	99.8	574277	99.7	574287	99.9
574313	100.1	579085	99.9	579124	100	579265	100	579278	100.1
579759	100.2	579831	100.2	579834	100.2	579845	100.1	579847	100.3
579871	99.8	579984	100.6	580097	98.8	580175	99.95	580376	100
580665	99.7	580693	100	580931	99.8	580980	99.6	581007	100.3
581208	100.1	581391	100	581889	99.8	584111	100	584463	99.9
585323	99.3	585439	99.9	585741	100.1	585821	99.7	585861	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7494.53	Lower Specification Limit (L)	98
Sum of Squared Measurements	748913.37	Quality Index Upper (QU) : (U - XBAR) / S	6.75
Correction Factor (CF) : Sum of Measurements Squares / N	748906.40	Quality Index Lower (QL) : (XBAR - L) / S	6.28
Corrected Sum of Squares (SS)	6.97	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.09	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.31	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.93	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2445      Lot Descr : LGE J5S-3  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
586154	99.8	586165	100.3	586166	99.9	586285	99.8	586385	99.7
586740	100.4	588623	99.8	588756	100.1	588865	99.5	588953	100
588964	100.1	589228	100	589379	100.2	589476	100.01	589519	100.2
589529	99.6	589758	100.1	589832	99.9	590065	99.9	590337	99.8
590408	100.4	590607	100.3	591268	100.3	591334	100.4	591400	99.4
599692	99.8	599817	100.3	599861	99.8	599968	99.9	600068	100.2
600291	99.8	600757	99.7	601010	100.1	601224	99.8	601276	99.9
601506	100.3	601588	99.9	601696	100.1	601759	99.9	601850	100.3
601917	99.9	602028	99.8	602048	100.4	602221	99.8	607970	99.7
608230	100.3	608298	100.2	608461	100.3	608698	100.3	608765	99.9
608906	100.1	608968	99.9	608973	100.2	609058	99.7	609185	100.2
609242	100.1	609691	100	609764	99.8	609907	100	610051	100.1
610200	100.3	610366	100.3	610397	99.8	634065	100.3	634252	100.1
634346	99.8	634609	100	634736	100.2	634816	99.8	634955	100
635138	100	635293	99.9	635464	99.9	635575	100.1	635997	99.6

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7500.51	Lower Specification Limit (L)	98
Sum of Squared Measurements	750106.07	Quality Index Upper (QU) : (U - XBAR) / S	8.50
Correction Factor (CF) : Sum of Measurements Squares / N	750102.00	Quality Index Lower (QL) : (XBAR - L) / S	8.56
Corrected Sum of Squares (SS)	4.07	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.05	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.23	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.01	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F1S120V15AC100      Model Number : J5S      Division : 01      Sample Lot : 2446      Lot Descr : LGE J5S-4  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
578704	99.8	578738	99.3	578860	99.7	636542	100.1	636546	100
657507	100	662112	99.1	662266	99.7	662288	99.6	662298	99.8
662444	99.9	662555	99.4	662623	99.6	663047	100.1	663142	99.7
663271	99.6	663326	99.9	663683	99.9	664253	99.3	664365	99.4
664378	99.7	664583	99.4	664586	99.6	665151	99.9	665259	99.6
665271	100.1	665375	99.9	665401	99.6	665477	99.5	665571	99.5
666212	99.4	666223	99.6	666228	99.9	666317	99.7	666351	100.2
666562	100	666903	99.4	666904	100.3	667096	100	667146	99.3
667254	99.2	667310	99.4	667315	100	667443	99.8	667826	99.9
668017	99.9	668171	99.2	668406	100.2	668433	99.68	668466	99.9
668511	99.5	668780	100	668799	99.7	668917	100	669040	99.8
669173	100	669466	99.9	669735	99.7	669805	100.2	669973	99.4
669980	100	670130	99.1	670271	99.4	670392	99.7	683487	99.8
683543	99.9	683709	99.7	683741	100.2	683947	100.1	684024	99.9
684067	99.8	684092	99.7	684319	99.2	684363	99.6	684542	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7479.98	Lower Specification Limit (L)	98
Sum of Squared Measurements	746007.57	Quality Index Upper (QU) : (U - XBAR) / S	7.82
Correction Factor (CF) : Sum of Measurements Squares / N	746001.34	Quality Index Lower (QL) : (XBAR - L) / S	5.97
Corrected Sum of Squares (SS)	6.23	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.29	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.73	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J55      Division : 01      Sample Lot : 2447      Lot Descr : LGE J5S-5  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
685636	99.8	685679	100.2	685682	100.2	685741	100.4	685749	100.1
685895	100.2	686020	100	686297	100	686321	100.4	686358	100.2
686691	99.2	686807	99.8	687072	100	687378	99.5	687575	99.6
687579	99.9	688337	100	688405	99.9	688546	99.7	688594	99.7
688787	100	688984	100.3	689065	99.8	689129	100.2	689157	99.7
692180	100.2	692234	100.3	692602	100	692738	99.6	692797	100.2
692908	100.3	693314	99.9	693366	99.8	693572	99.9	693619	99.4
693814	99.9	694663	100.1	694693	99.6	694926	100	695657	100.1
695795	100	695835	100.2	695852	99.6	696489	99.9	697557	100.4
697707	100.4	697818	100	697992	99.7	698117	99.9	698238	100.6
698890	100	699255	100.2	699484	99.8	699720	99.9	699735	100.2
699847	100.1	699884	99.5	700032	100	700145	100.1	700220	100.1
700676	99.7	705711	99.8	705753	99.7	705791	100.3	706256	100.2
706316	99.9	706317	99.8	706432	99.8	706759	99.6	706956	99.6
706993	100	707360	99.2	707634	99.8	707637	99.8	724034	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7495.80	Lower Specification Limit (L)	98
Sum of Squared Measurements	749166.00	Quality Index Upper (QU) : (U - XBAR) / S	7.37
Correction Factor (CF) : Sum of Measurements Squares / N	749160.24	Quality Index Lower (QL) : (XBAR - L) / S	6.96
Corrected Sum of Squares (SS)	5.76	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.94	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2448      Lot Descr : LGE J5S-6  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
724554	100.3	724584	99.7	724744	99.9	726160	99.7	726240	100.3
726387	100.2	726631	100.2	726700	100.5	726877	100.06	727005	99.9
728156	99.8	728329	100.3	728579	100.1	728635	100.4	728933	99.9
729209	100.2	729400	100	729429	100.3	729546	99.8	729675	99.9
729796	99.9	729851	99.4	730010	100.1	730044	99.9	731009	100.3
731665	100	731890	100.1	731918	99.7	731992	100.2	732105	99.8
732313	100	732651	99.7	732728	100.4	732751	100.2	732753	99.2
732918	99.7	733064	99.6	733067	100.46	733320	99.6	733484	100.1
733497	99.5	733526	100.1	733706	99.6	733824	99.55	733845	100.1
733849	100.3	734020	103.2	734978	99.8	735004	99.8	735024	100.1
735149	100.4	735158	99.5	735202	100.1	735346	100.2	735417	100
735505	99.4	735602	100	735626	100.1	735636	99.8	735660	99.8
735743	99.7	737563	99.9	737572	100.8	737594	100.2	737698	100.6
737801	99.7	737833	99.2	738018	100	738134	100.1	738212	100.2
738266	100.1	738267	99.9	738361	99.9	738729	100.4	738812	99.7

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7501.57	Lower Specification Limit (L)	98
Sum of Squared Measurements	750331.59	Quality Index Upper (QU) : (U - XBAR) / S	4.06
Correction Factor (CF) : Sum of Measurements Squares / N	750314.03	Quality Index Lower (QL) : (XBAR - L) / S	4.15
Corrected Sum of Squares (SS)	17.56	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.24	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.49	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.02	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2449      Lot Descr : LGE J5S-7  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
735758	100.1	735879	100.6	736125	100.2	736258	99.8	736287	100.2
736406	100.6	736417	100	736458	99.4	736704	99.9	738991	99.9
739576	99.3	740600	99.6	740645	100.16	740745	99.9	740992	100.8
741014	99.8	741040	99.7	741282	99.9	741466	99.4	741551	99.1
741784	99.4	741789	99.9	741879	99.4	741909	99.6	742013	100.2
742237	100	742247	99.7	742322	99.2	742466	99.6	743333	100.2
743353	99.2	743480	100.3	743694	99.7	743824	99.9	743900	99.5
743918	99.6	744106	99.9	744191	99.3	744456	99.4	744582	100.3
744707	100.1	744708	100.1	744785	99.6	745137	100.4	745144	99.8
745186	99.6	745494	99.5	745710	99.2	745875	100.1	746328	99.3
746373	99.2	746379	99.4	746751	99.4	747054	99.5	747223	99.7
747233	98.8	747412	99.6	747532	99.2	747632	99.8	747713	100.2
748041	99.8	748046	98.9	748070	99.6	748242	99.13	748259	99.2
748418	98.9	748439	98.9	748535	99.7	748727	99.5	749145	99.6
749213	99.2	749305	100.1	749408	99.9	749442	100.2	749848	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7477.69	Lower Specification Limit (L)	98
Sum of Squared Measurements	745558.30	Quality Index Upper (QU) : (U - XBAR) / S	5.35
Correction Factor (CF) : Sum of Measurements Squares / N	745544.64	Quality Index Lower (QL) : (XBAR - L) / S	3.96
Corrected Sum of Squares (SS)	13.66	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.18	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.43	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.70	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2450      Lot Descr : LGE J5S-8  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
749921	99.4	749940	99.2	749951	99.44	750031	98.6	750185	99.3
750216	99.8	750638	99.7	750667	99.7	750729	99.5	750766	99.4
750935	99.6	751186	100.2	751359	99.7	751662	100.1	751868	99.5
751872	98.9	752000	99.3	752366	98.9	752456	99.2	752519	99.18
752573	99.1	752587	99.3	752692	99.7	752701	99.1	752839	100.1
752840	99.8	752861	99.4	753145	99.8	757478	100	757591	99.3
757609	99.8	757627	100.1	757662	98.4	757845	99.5	757850	100
758017	98.6	758091	99.5	758233	99.4	758277	98.8	758746	99.5
758773	100	758867	100.1	758957	99.9	759108	99.4	759337	100.2
759475	99.9	759827	100.3	760312	99.5	760394	100.5	760402	100.3
761020	99.7	761024	99.3	761034	99.49	761039	99.9	761077	99.4
761160	99.5	761335	99.6	761410	99.5	761475	100.2	761795	100
761852	99.8	762360	99.2	762379	99.6	762497	99.6	762576	99.6
762640	99	762815	99.8	762888	99.7	762949	99.8	763099	99.4
763314	99.3	764025	99.6	764158	99.7	764278	99.9	764693	99.6

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7468.11	Lower Specification Limit (L)	98
Sum of Squared Measurements	743648.25	Quality Index Upper (QU) : (U - XBAR) / S	5.86
Correction Factor (CF) : Sum of Measurements Squares / N	743635.56	Quality Index Lower (QL) : (XBAR - L) / S	3.80
Corrected Sum of Squares (SS)	12.69	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.17	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.41	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.57	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J55      Division : 01      Sample Lot : 2451      Lot Descr : LGE J55-9  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
767565	99.9	767974	99.7	768060	99.9	768314	99.9	768369	99.5
768791	99.3	768960	99.7	768990	99.8	769358	99.4	769470	100.2
769571	99.2	769595	99.6	769730	99.9	769897	99.9	770041	99.4
770125	99.6	770150	100	770203	99.9	770226	100	770362	99.6
770386	99.9	770683	99.7	770878	99.8	771095	99.3	771215	99.4
771437	99.7	771464	99.4	771540	99.4	771649	99.7	771736	99.3
771877	99.8	771973	99.8	772015	99.8	772269	100	772312	100.2
772450	99.8	772457	100	772590	100	772729	99.8	772791	99.4
772921	99.7	773163	100	773236	99.8	773479	99.4	773542	100
773669	99.7	773820	99.9	773847	99.88	773964	99.6	774308	100
774601	100.2	774923	100	774977	99.6	775091	99.5	775173	99.9
775184	99.9	775284	100.1	775324	100	775353	100.2	775543	100.1
779905	99.7	779939	99.9	780017	99.8	780083	100.1	780119	100.1
780142	99.7	780342	100.2	780910	100.1	781061	99.2	781302	100.5
781629	100	781775	100.2	781961	99.6	782109	100.1	782243	99.6

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7484.88	Lower Specification Limit (L)	98
Sum of Squared Measurements	746984.73	Quality Index Upper (QU) : (U - XBAR) / S	7.95
Correction Factor (CF) : Sum of Measurements Squares / N	746979.05	Quality Index Lower (QL) : (XBAR - L) / S	6.49
Corrected Sum of Squares (SS)	5.68	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.80	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F25240V30AC200      Model Number : J55      Division : 01      Sample Lot : 2452      Lot Descr : LGE J55-10  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
782650	100.5	783034	99.9	783222	100	783294	99.7	783305	99.8
783390	99.1	783624	100	783914	99.6	783967	99.7	783980	99.4
784037	99.7	784053	100.1	784159	99.9	784610	99	784622	99.3
784647	100.4	784965	99.9	785036	99.6	785083	100.2	785127	100.1
785511	99.4	785515	100.4	785523	100.4	785603	100.2	785882	100
786225	100.1	786555	100	786926	99.8	787017	100	787207	100
787277	100.3	787343	100.9	787454	99.9	787538	100.6	787624	100.17
787917	100.2	788438	99.6	788875	99.6	788907	99.8	789026	100
789135	99.6	789140	100.6	789407	99.16	789464	99.4	789514	100.1
789524	100.1	789973	99.9	790121	99.6	790217	99.6	790231	100
790456	99.4	790554	100.2	790677	99.7	790821	100	791086	99.8
791127	99.8	791152	99.9	791173	99.6	791382	100	791554	100
792686	99.7	792722	100.4	792756	100.2	792772	99.5	792868	99.8
792924	100.1	792967	99.8	793148	99.9	793370	100.4	793499	100.2
793521	100.1	800899	99.6	800941	99.1	800962	98.9	801207	98.4

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7489.83	Lower Specification Limit (L)	98
Sum of Squared Measurements	747980.52	Quality Index Upper (QU) : (U - XBAR) / S	5.07
Correction Factor (CF) : Sum of Measurements Squares / N	747967.38	Quality Index Lower (QL) : (XBAR - L) / S	4.42
Corrected Sum of Squares (SS)	13.14	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.18	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.42	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.86	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J5S      Division : 01      Sample Lot : 2453      Lot Descr : LGE J5S-11  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
801416	99.9	801457	99.4	801502	99.2	801609	99.2	801652	99
802094	100.3	802454	99.7	802651	99.1	802773	99.5	802866	100.4
803174	99.6	803262	99.6	803338	99.4	803427	99.6	803488	99.4
803600	99.6	803665	100.3	803714	99	804000	99.9	804042	99.3
804527	99.1	804569	99.9	804572	100.3	804609	99.8	804812	99
805132	99.2	805212	99.8	805530	99.8	805700	99.7	805748	98.7
805897	99.9	806164	99.4	806312	99.4	806319	100.1	806493	99.3
806914	99.4	806936	99.6	807019	99.4	807253	100.2	807262	99.4
807274	100.1	807746	99.7	807788	99.8	807826	100.3	808003	98.6
808047	98.8	808136	98.6	808142	99.3	810236	99.5	810493	99
810680	98.5	810686	99.4	811104	98.7	811532	99.7	811820	98.9
811934	99.7	811946	100.2	812050	99.6	812137	99.4	812175	100.3
812211	99.6	812249	98.6	812260	99.9	812329	99.9	812637	98.8
812947	99.4	813111	99.4	813178	99.9	813202	98.7	813239	100
813245	99.7	813402	99.3	813409	100	813417	99.85	813432	99

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7462.95	Lower Specification Limit (L)	98
Sum of Squared Measurements	742625.23	Quality Index Upper (QU) : (U - XBAR) / S	5.21
Correction Factor (CF) : Sum of Measurements Squares / N	742608.30	Quality Index Lower (QL) : (XBAR - L) / S	3.15
Corrected Sum of Squares (SS)	16.93	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.23	Estimate of Lot Percent NCF Below L (PL)	0.06
Estimate of Lot Standard Deviation (S) : SQRT of V	0.48	Total Estimate Percent NCF In Lot (P) : PU + PL	0.06
Sample Mean (XBAR) : Sum X / N	99.51	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : J55      Division : 01      Sample Lot : 2454      Lot Descr : LGE J55-12  
 In Service Population : 799      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
813483	99.4	813622	99.5	813689	98.9	813701	99.5	813709	99.9
813729	99	813739	99.8	814079	99.6	814088	98.9	814112	99.4
814128	99.4	814189	99.4	814200	99.6	814233	99.7	814248	100.4
814257	99.9	814266	99.6	814275	99.9	814295	99.8	814312	99.7
814331	99.7	814360	99.4	814362	99.4	814454	99.8	814457	99.4
814466	100	814475	99.2	814484	100.1	814505	98.6	814513	99.7
814540	99.8	814547	98.6	917986	99.9	917991	100.1	918061	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3485.00	Lower Specification Limit (L)	98
Sum of Squared Measurements	347012.22	Quality Index Upper (QU) : (U - XBAR) / S	5.88
Correction Factor (CF) : Sum of Measurements Squares / N	347006.43	Quality Index Lower (QL) : (XBAR - L) / S	3.81
Corrected Sum of Squares (SS)	5.79	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.17	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.41	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.57	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MS      Division : 01      Sample Lot : 2455      Lot Descr : LGE MS-1  
 In Service Population : 7861      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
378448	99.9	389174	100.4	389425	100.1	389675	99.9	389776	100.1
394120	100.2	394151	100.2	394259	100.2	394340	100.3	394410	100.3
398524	100.6	398653	100.5	398730	100.3	398789	100.1	398793	100.2
398820	100.1	403401	100.1	403438	100.1	403456	100.8	403714	100.5
403826	100	403984	100.4	404001	100.3	404050	100.3	412919	100.2
413247	100.4	413265	100	413406	100.7	413429	100.7	413541	99.2
413745	100.6	413772	100.6	418169	100.9	418294	99.5	418566	100.4
422906	99.5	423007	100.7	423171	100.2	423619	100.5	428044	100.3
428237	100.2	428342	99.7	428453	99.9	428504	100.2	428678	100
428747	99.8	428937	99.7	434785	100.1	435059	100.7	435138	99.9
435262	99.7	435498	100.6	439612	100.8	440059	100.4	444281	100
444464	99.6	445918	99.9	445946	99.8	446108	99.6	447316	99.7
447415	99.9	447479	99.6	447714	99.6	450117	99.8	450174	99.9
450222	99	450241	99.4	450346	100	450381	100.02	450471	99.94
452186	99.9	452388	99.5	452509	99.7	537234	100.1	676261	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7506.86	Lower Specification Limit (L)	98
Sum of Squared Measurements	751384.03	Quality Index Upper (QU) : (U - XBAR) / S	4.86
Correction Factor (CF) : Sum of Measurements Squares / N	751372.63	Quality Index Lower (QL) : (XBAR - L) / S	5.33
Corrected Sum of Squares (SS)	11.40	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.15	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.39	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.09	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2456      Lot Descr : LGE MSII-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
423364	100.5	454426	99.7	454722	99.6	457860	99.9	457891	100.4
457941	100.4	458163	100.3	460801	100.2	462947	100.2	466584	100.3
466723	100.1	466733	99.97	466882	100.1	466888	100.6	468972	99.9
469145	100	469291	100.6	469412	100	469429	99.9	469436	99.8
473059	100.4	473173	100.16	473175	100.3	473211	100	473403	99.9
477531	100.2	480596	99.7	480771	99.7	481941	99.8	481944	99.9
481957	99.4	482159	99.9	482316	99.8	485035	100.1	485232	99.9
485302	100.2	488266	100.2	488436	99.8	488525	100.4	488615	100.3
491148	100	491256	100.3	491356	99.6	491477	100.2	491499	99.9
494793	100	494853	100.1	495158	100	502392	100	502830	99.7
503006	100	503065	99.9	503134	99.9	503441	100.2	503833	100.4
503916	100	504049	99.9	507190	100.1	507279	100.1	507524	100.3
507584	99.7	507759	99.9	507968	100.4	508180	99.9	518820	100.3
518828	100.3	518962	99.9	518999	100.1	519079	99.3	519096	100.4
519656	100.3	523107	99.8	523392	100.2	523688	99.6	532332	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7503.33	Lower Specification Limit (L)	98
Sum of Squared Measurements	750671.45	Quality Index Upper (QU) : (U - XBAR) / S	7.31
Correction Factor (CF) : Sum of Measurements Squares / N	750666.15	Quality Index Lower (QL) : (XBAR - L) / S	7.64
Corrected Sum of Squares (SS)	5.30	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.07	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.27	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.04	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2457      Lot Descr : LGE MSII-2  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
532393	100	532532	100.1	532551	100.2	532729	100.3	532790	99.8
532799	99.9	535945	100	536207	99.7	536230	100.3	536248	99.9
536450	99.9	536551	99.9	537138	100.2	537243	99.5	537255	100.1
537276	100.3	537560	99.7	542391	100.1	542434	99.8	542476	99.8
542599	100	542712	100.6	545644	100	545733	99.9	545950	100.5
545981	100.2	546057	100.2	546177	100.2	546322	100.1	546881	99.7
547056	100.3	547237	100.6	547359	100.2	547652	100.5	547711	99.8
547791	100.1	547934	100.1	548218	99.9	548314	100.2	548370	100.4
558668	100.2	558817	100.1	559115	100.6	559196	100.6	559322	100.1
559384	100	559675	100.2	559787	99.9	559984	100.4	560500	100.2
560729	100	560732	100.43	560753	101.5	560870	100	561133	100.4
575580	100.4	575636	100.1	576011	100.1	576308	100.6	576312	100.2
576362	100.3	576387	100.3	576401	100.2	576580	100.2	576989	100.1
577143	100.4	577166	100	577208	100.3	577315	100.1	577579	100.5
577823	100.3	577840	100.3	577890	100.2	578015	100.1	578132	99.96

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7512.29	Lower Specification Limit (L)	98
Sum of Squared Measurements	752466.04	Quality Index Upper (QU) : (U - XBAR) / S	6.43
Correction Factor (CF) : Sum of Measurements Sqaures / N	752460.01	Quality Index Lower (QL) : (XBAR - L) / S	7.58
Corrected Sum of Squares (SS)	6.03	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.29	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.16	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2458      Lot Descr : LGE MSII-3  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
578308	100.4	595973	99.8	596083	99.7	596524	100	597103	100.3
597120	100.1	597125	100.1	597336	99.8	597517	100	597860	99.9
598209	99.8	598307	100	598328	99.8	598572	99.9	611594	100.2
611628	100.3	611735	100.6	611752	100.3	612004	100.6	612085	100.3
612183	100.3	612460	100.6	612705	100.5	612717	100.2	612962	100.6
613003	100	613073	100.2	613113	100.1	613661	100.5	613898	100.4
614308	100.1	614312	100.2	614820	100.1	615171	100	615399	101
615461	99.8	615467	100.2	615487	100.4	615512	99.6	615735	100.34
615830	100	615927	99.9	615933	100.2	615960	99.9	616035	100
616181	100.5	616399	100.4	616452	99.6	616519	99.8	616781	99.9
617102	99.4	617218	100.4	617272	100	617310	99.8	617568	100.4
617585	99.9	617922	100	617990	100.1	617996	100.2	618224	100.5
618342	99.8	618346	99.4	618467	99.85	618572	99.7	618733	99.4
618763	99.4	618769	99.6	619040	100	619117	100	619396	100
619412	99.8	620003	100.1	620034	99.4	620070	99.9	620187	99

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7503.29	Lower Specification Limit (L)	98
Sum of Squared Measurements	750667.23	Quality Index Upper (QU) : (U - XBAR) / S	5.58
Correction Factor (CF) : Sum of Measurements Sqaures / N	750658.14	Quality Index Lower (QL) : (XBAR - L) / S	5.83
Corrected Sum of Squares (SS)	9.09	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.12	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.35	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.04	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2459      Lot Descr : LGE MSII-4  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
620298	100	620592	100.4	620721	100.2	620728	99.9	620757	99.7
620763	100.4	620766	100.3	620974	99.8	621041	100.2	621161	99.7
621176	99.7	621191	99.97	621201	99.7	621276	99.3	621502	100.1
621744	99.7	621907	100.6	621909	99.8	622571	99.8	622635	100.7
622721	99.2	622812	99.9	622903	99.8	623007	99.6	623307	99.7
623341	99.5	623351	100.3	636805	100	637130	100.3	637312	100.2
637495	100	637821	100.2	638085	100.1	638296	100	638549	100.3
638653	99.8	638658	100.1	639062	100	639194	100.1	639322	100.2
639481	100.1	639489	100.4	646013	100.3	646015	101.6	646168	100
646379	100	646504	100.1	646649	100.2	646827	100.1	647049	100.2
647113	100.2	647186	100	647606	100.1	647705	100.3	647720	100.09
647966	100.1	648184	100.1	648492	100.1	648739	100.1	648799	99.9
648914	100	648942	100.2	649246	100.2	649285	100.1	649553	99.9
649796	100.3	649852	100.2	649874	100.4	649920	99.9	649928	100.2
649936	100.4	650291	100.2	650482	100	650594	99.9	650632	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7505.26	Lower Specification Limit (L)	98
Sum of Squared Measurements	751059.85	Quality Index Upper (QU) : (U - XBAR) / S	6.07
Correction Factor (CF) : Sum of Measurements Sqaures / N	751052.37	Quality Index Lower (QL) : (XBAR - L) / S	6.51
Corrected Sum of Squares (SS)	7.48	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.10	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.32	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.07	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2460      Lot Descr : LGE MSII-5  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
650798	100.1	650845	100	650953	100.1	650997	100.1	651023	100.1
651120	100.1	651165	100.2	651347	100.1	651633	100	651725	100
651803	100	651942	100.2	652037	99.9	652296	99.9	652365	99.9
652422	100.1	652553	100	652976	100	652989	100.1	653077	100
653147	99.7	653475	100.3	653499	99.9	653556	100.2	653564	100.2
653742	100	653928	100.3	653945	100.1	653969	99.8	654019	99.8
654031	99.9	654054	100.2	654156	100	658190	100.3	658703	100.2
658728	100.2	658885	100.4	658970	100.2	659059	100.4	659071	100.4
659182	100.4	659429	100.4	659701	100.4	660007	100.3	660214	100.1
660263	100.3	660531	100.6	660709	100.4	660770	100.2	671049	100
671211	100.1	671215	100.1	671278	100.04	671342	100.1	671649	99.9
671976	100.3	672076	99.9	672333	100.2	672469	100.4	673168	100.2
673174	100.1	673197	99.9	673234	99.8	673254	100.1	673302	100.2
673321	99.9	673716	100	673887	99.9	673972	100.1	674085	99.8
674548	100.2	674552	100.1	674909	99.9	674969	100.2	675219	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7507.94	Lower Specification Limit (L)	98
Sum of Squared Measurements	751591.27	Quality Index Upper (QU) : (U - XBAR) / S	10.45
Correction Factor (CF) : Sum of Measurements Squares / N	751588.84	Quality Index Lower (QL) : (XBAR - L) / S	11.62
Corrected Sum of Squares (SS)	2.43	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.18	Total Estimate Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.11	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MSII      Division : 01      Sample Lot : 2461      Lot Descr : LGE MSII-6  
 In Service Population : 805      Sample Quantity : 35      Meters Tested : 35      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
675713	100.2	675748	100	675766	100.3	675775	100.2	675793	100.6
675813	100	675817	100.2	675842	100.2	675957	100.1	675979	100.3
675995	100.5	676038	99.5	676066	100.2	676169	100.1	676170	99.9
676177	100.1	676204	100.3	676209	99.9	676237	99.8	676244	100
676257	99.7	676287	99.4	676298	100.2	676321	100	676333	100
676345	100.1	676386	100.1	676396	99.9	676453	100.1	676465	99.9
676537	99.9	676544	100.1	676581	99.9	676611	99.9	676632	100.1

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	35	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	3501.70	Lower Specification Limit (L)	98
Sum of Squared Measurements	350342.01	Quality Index Upper (QU) : (U - XBAR) / S	8.20
Correction Factor (CF) : Sum of Measurements Sqaures / N	350340.08	Quality Index Lower (QL) : (XBAR - L) / S	8.60
Corrected Sum of Squares (SS)	1.93	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.06	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.24	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	100.05	Maximum Allowable Percent NCF (M)	5.58
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MX      Division : 01      Sample Lot : 2462      Lot Descr : LGE MX-1  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
702544	100	702600	100.2	702624	99.9	702668	100	702776	100.1
702799	99.7	703012	100	703598	99.8	703757	100.1	703985	100.1
704067	99.6	704194	99.9	704274	100.1	704348	99.2	704427	99.7
704460	99.8	704589	99.9	704624	99.9	704716	100	704819	99.9
704872	100.2	704887	99.8	704953	100	705154	100	708969	100.1
709149	99.8	709428	100	709552	99.9	709773	100	709774	99.3
709831	99.8	710283	99.6	710359	100	710410	99.6	710459	99.8
710462	99.9	710862	99.9	710983	99.7	711916	99.6	711995	100
712103	100	712163	100.4	712225	100.2	712375	99.9	712425	99.4
712537	99	713316	100	713391	99.5	713580	99.8	713866	99.8
714114	99.4	714186	100	714224	100.13	714237	99.6	714288	100.1
714491	100.1	714735	99.88	715081	99.7	715239	99.9	715439	99.3
715533	99.6	715738	99.9	715775	99.8	715825	99.7	715847	99.9
715915	99.9	716112	99.6	716379	99.7	716597	99.2	716618	99.2
716619	100.1	716656	100.4	716682	100.1	716697	100.1	716765	99.4

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7487.61	Lower Specification Limit (L)	98
Sum of Squared Measurements	747529.95	Quality Index Upper (QU) : (U - XBAR) / S	7.67
Correction Factor (CF) : Sum of Measurements Sqaures / N	747524.05	Quality Index Lower (QL) : (XBAR - L) / S	6.50
Corrected Sum of Squares (SS)	5.90	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.83	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MX      Division : 01      Sample Lot : 2463      Lot Descr : LGE MX-2  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
717200	99.6	717207	99.8	717237	99.8	717348	99.6	717391	99.6
717457	99.4	717498	100	717499	99.8	717771	99.4	717813	99.9
717912	99.7	718096	99.9	718153	99.6	718186	99.8	718542	100.1
718604	100.1	718732	99.7	719266	99.6	719290	99.8	719301	99.7
719394	99.8	719486	99.7	719624	99.8	719696	99.3	719856	99.4
719958	99.9	719959	99.9	720059	99.9	720187	99.6	720241	99.8
720261	99.9	720312	99.8	720589	99.9	720779	99.4	720792	99.8
720906	100.1	720964	99.88	721106	99.7	721273	99.9	721421	100.2
721470	100.2	721543	99.9	721547	99.5	722198	99.3	722270	100.8
722503	99.7	722656	99.6	722678	99.7	722741	99.9	722926	99.8
723335	99.7	814849	99.5	814892	99.7	815010	99.8	815319	99.4
815321	99.2	815328	99.6	815365	99.4	815890	99.9	816173	99.6
816374	98.8	816379	99.6	816664	99.6	817049	99.4	817209	99.3
817301	99.9	817455	99.2	817485	99.6	817531	99.8	817728	99.8
817746	99.5	818046	99.6	819375	99.9	819387	99.9	819768	99.5

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7478.18	Lower Specification Limit (L)	98
Sum of Squared Measurements	745648.06	Quality Index Upper (QU) : (U - XBAR) / S	8.25
Correction Factor (CF) : Sum of Measurements Squares / N	745642.35	Quality Index Lower (QL) : (XBAR - L) / S	6.15
Corrected Sum of Squares (SS)	5.71	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.08	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.28	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.71	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (100) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MX      Division : 01      Sample Lot : 2464      Lot Descr : LGE MX-3  
 In Service Population : 10000      Sample Quantity : 75      Meters Tested : 75      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
820270	99.9	820280	99.8	820306	99.6	820475	99.4	820554	100.1
820591	99.1	820618	99.8	820679	99.4	820781	100.03	821003	99.8
821141	99.7	821148	99.7	821165	99.6	821216	100.1	821362	99.9
821608	99.7	821848	99.6	822165	99.8	822226	99.1	822246	99.3
822292	99.6	822370	98.8	822499	99.5	822584	99.8	822637	99.4
822659	99.6	822746	99.4	822781	99.8	822830	99.4	822963	99.4
823075	99.5	824433	99.2	824464	99.4	824549	99.7	824643	99.7
824798	99.6	824993	99	825221	99.7	825250	99.8	825384	99.4
825544	99.8	825607	99.2	825615	100	825787	99.7	826639	99.3
826973	99.3	827017	99.6	827122	99.5	827169	99.6	827334	98.6
827414	99.7	827677	99.3	827700	99.6	827755	100.1	828000	99.5
830111	99.8	830405	99.9	830600	99.4	830871	99.3	831028	99.7
831068	99.4	831342	99.66	831409	99.1	831645	99.7	831672	99
831825	98.9	836368	99.8	836447	99.9	836760	99.7	836915	99.9
837359	99.9	837412	99.9	837530	100	837542	100	837738	99.9

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	75	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	7468.79	Lower Specification Limit (L)	98
Sum of Squared Measurements	743778.43	Quality Index Upper (QU) : (U - XBAR) / S	7.62
Correction Factor (CF) : Sum of Measurements Squares / N	743770.99	Quality Index Lower (QL) : (XBAR - L) / S	4.99
Corrected Sum of Squares (SS)	7.44	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.10	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.32	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.58	Maximum Allowable Percent NCF (M)	4.83
		Acceptability Criterion : Compare P with M	Pass

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200      Model Number : MX      Division : 01      Sample Lot : 2465      Lot Descr : LGE MX-4  
 In Service Population : 1627      Sample Quantity : 50      Meters Tested : 50      Pass / Fail : Pass

Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy	Serial Number	Full Load Accuracy
839170	100	839290	99.8	839328	99.9	839350	99.7	839351	100
839392	99.6	839475	99.8	839503	99.9	839504	99.9	839523	100.3
839533	100	839549	100	839569	99.9	839603	99.7	839628	99.8
839661	99.7	839689	99.8	839717	99.6	839784	99.6	839891	99.9
839893	99.7	839926	99.9	839931	99.4	839936	99.5	839964	99.9
840085	99.8	840102	100.1	840115	99.8	840124	99.8	840152	99.9
840174	99.9	840218	99.7	840308	99.8	840314	99.7	840340	99.8
840382	99.6	840406	99.9	840505	99.8	840522	99.9	840538	99.9
840544	100	840642	99.7	840660	99.8	840662	100	840722	99.6
840734	100.2	840847	99.6	840862	99.7	840864	100	840878	100

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model  
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

Sample Size (N)	50	Upper Specification Limit (U)	102
Sum of Measurements (Sum X)	4991.30	Lower Specification Limit (L)	98
Sum of Squared Measurements	498262.99	Quality Index Upper (QU) : (U - XBAR) / S	12.53
Correction Factor (CF) : Sum of Measurements Sqaures / N	498261.51	Quality Index Lower (QL) : (XBAR - L) / S	10.52
Corrected Sum of Squares (SS)	1.48	Estimate of Lot Percent NCF Above U (PU)	0.00
Variance (V) : SS / (N-1)	0.03	Estimate of Lot Percent NCF Below L (PL)	0.00
Estimate of Lot Standard Deviation (S) : SQRT of V	0.17	Total Estiamte Percent NCF In Lot (P) : PU + PL	0.00
Sample Mean (XBAR) : Sum X / N	99.83	Maximum Allowable Percent NCF (M)	5.21
		Acceptability Criterion : Compare P with M	Pass



# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Lot Number	Lot Name	Manufacturer	Model	In Service Population	Sample Quantity	Devices Set	Removed	Meters Tested	Pass / Fail	Lot Status
2415	LGE ALF-1	Landis + Gyr	ALF	452	25	0	0	25	Pass	Testing Complete
2416	LGE C1S-1	ITRON	C1SR	10000	75	0	0	75	Pass	Testing Complete
2417	LGE C1S-2	ITRON	C1S	10000	75	0	0	75	Pass	Testing Complete
2418	LGE C1S-3	ITRON	C1S	10000	75	0	0	75	Pass	Testing Complete
2419	LGE C1S-4	ITRON	C1S	10000	75	0	0	75	Pass	Testing Complete
2420	LGE C1S-5	ITRON	C1S	10000	75	0	0	75	Pass	Testing Complete
2421	LGE C1S-6	ITRON	C1S	8839	75	0	0	75	Pass	Testing Complete
2422	LGE C2SOS-1	ITRON	C2SOS	541	35	0	0	35	Pass	Testing Complete
2423	LGE D4S-1	Westinghouse	D4S	10000	75	0	0	75	Pass	Testing Complete
2424	LGE D4S-2	Westinghouse	D4S	1813	50	0	0	50	Pass	Testing Complete
2425	LGE Focus AXR-1	Landis + Gyr	Focus AXR - Mesh	2608	50	0	0	50	Pass	Testing Complete
2426	LGE I210-1	General Electric	I-210	972	35	0	0	35	Pass	Testing Complete
2427	LGE I50-1	General Electric	I-50S	814	35	0	0	35	Pass	Testing Complete
2428	LGE I55-1	General Electric	I-55S	1085	35	0	0	35	Pass	Testing Complete
2429	LGE I60-1	General Electric	I-60S	10000	75	0	0	75	Pass	Testing Complete
2430	LGE I60-2	General Electric	I-60S	1689	50	0	0	50	Pass	Testing Complete
2431	LGE I70-1	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2432	LGE I70-2	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2433	LGE I70-3	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2434	LGE I70-4	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2435	LGE I70-5	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2436	LGE I70-6	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2437	LGE I70-7	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2438	LGE I70-8	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2439	LGE I70-9	General Electric	I-70S	10000	75	0	0	75	Pass	Testing Complete
2440	LGE I70-10	General Electric	I-70S	474	25	0	0	25	Pass	Testing Complete

# LG&E (1000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

2441	LGE J4S-1	Sangamo	J4S	10000	75	0	0	75	Pass	Testing Complete
2442	LGE J4S-2	Sangamo	J4ES	230	15	0	0	15	Pass	Testing Complete
2443	LGE J5S-1	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2444	LGE J5S-2	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2445	LGE J5S-3	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2446	LGE J5S-4	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2447	LGE J5S-5	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2448	LGE J5S-6	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2449	LGE J5S-7	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2450	LGE J5S-8	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2451	LGE J5S-9	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2452	LGE J5S-10	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2453	LGE J5S-11	Sangamo	J5S	10000	75	0	0	75	Pass	Testing Complete
2454	LGE J5S-12	Sangamo	J5S	799	35	0	0	35	Pass	Testing Complete
2455	LGE MS-1	Landis + Gyr	MS	7861	75	0	0	75	Pass	Testing Complete
2456	LGE MSII-1	Landis + Gyr	MSII	10000	75	0	0	75	Pass	Testing Complete
2457	LGE MSII-2	Landis + Gyr	MSII	10000	75	0	0	75	Pass	Testing Complete
2458	LGE MSII-3	Landis + Gyr	MSII	10000	75	0	0	75	Pass	Testing Complete
2459	LGE MSII-4	Landis + Gyr	MSII	10000	75	0	0	75	Pass	Testing Complete
2460	LGE MSII-5	Landis + Gyr	MSII	10000	75	0	0	75	Pass	Testing Complete
2461	LGE MSII-6	Landis + Gyr	MSII	805	35	0	0	35	Pass	Testing Complete
2462	LGE MX-1	Landis + Gyr	MX	10000	75	0	0	75	Pass	Testing Complete
2463	LGE MX-2	Landis + Gyr	MX	10000	75	0	0	75	Pass	Testing Complete
2464	LGE MX-3	Landis + Gyr	MX	10000	75	0	0	75	Pass	Testing Complete
2465	LGE MX-4	Landis + Gyr	MX	1627	50	0	0	50	Pass	Testing Complete
<b>Totals</b>				<b>390609</b>	<b>3325</b>	<b>0</b>	<b>0</b>	<b>3325</b>		

**TOTAL LOTS PASSED: 51**

---

**TOTAL LOTS FAILED: 0**