

RECEIVED

FEB 28 2019

PUBLIC SERVICE
COMMISSION



a PPL company

Gwen R. Pinson, Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

February 28, 2019

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Kentucky Utilities Company

State Regulation and Rates
220 W. Main Street
PO Box 32010
Louisville, KY 40232
www.lge-ku.com

Rick E. Lovekamp
Manager Regulatory
Strategy/Policy
T 502-627-3780
rick.lovekamp@lge-ku.com

Annual Report – Kentucky Utilities Company

Dear Ms. Pinson:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.

Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), Kentucky Utilities Company submits the following:

The Certified Test Results of all new meters received - (Attachment A)

2018 Statistical Sampling Test Results and Summary - (Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

Rick E. Lovekamp

RECEIVED

FEB 28 2019

PUBLIC SERVICE
COMMISSION

ATTACHMENT

A

The Certified Test Results
of all new meters

LG&E and KU Energy LLC

5040 Annual Report of New Single Phase Meters

Last Data Update:

12/21/2018 01:26:00

Dynamic Filters

Plant KU

Month/Year 01/2018 - 6/2018

| Plant | Manf. Model Number | Serial Number | Calendar Month/Year | Test Date | As Left Full Load | As Left Light Load | As Left Power Factor | Number of records |
|-------|--------------------|---------------|---------------------|------------|-------------------|--------------------|----------------------|-------------------|
| KU | C1S | 2082652 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082653 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082654 | 02/2018 | 01/19/2018 | 99.960 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082655 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082656 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082657 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082658 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082659 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082660 | 02/2018 | 01/19/2018 | 100.070 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082661 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082662 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | C1S | 2082663 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082664 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082665 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082666 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082667 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082668 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082669 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082670 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082671 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082672 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.1 | 1 |
| KU | C1S | 2082673 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082674 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082675 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082676 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082677 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082678 | 02/2018 | 01/19/2018 | 99.950 | 99.950 | 99.9 | 1 |
| KU | C1S | 2082679 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082680 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082681 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082682 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082683 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082684 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082685 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082686 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082687 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082688 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082689 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082690 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082691 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082692 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082693 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082694 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082695 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082696 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082697 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082698 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082699 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082700 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2082701 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082702 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082703 | 02/2018 | 01/19/2018 | 99.980 | 100.030 | 100.1 | 1 |
| KU | C1S | 2082704 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082705 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082706 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082707 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082708 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082709 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.1 | 1 |
| KU | C1S | 2082710 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082711 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082712 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082713 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082714 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082715 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082716 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082717 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082718 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082719 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082720 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082721 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082722 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082723 | 02/2018 | 01/19/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | C1S | 2082724 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082725 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082726 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082727 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082728 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082729 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082730 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082731 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082732 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082733 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082734 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082735 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082736 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082737 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082738 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082739 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082740 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082741 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082742 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082743 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082744 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082745 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082746 | 02/2018 | 01/19/2018 | 99.950 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082747 | 02/2018 | 01/19/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2082748 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 99.9 | 1 |
| KU | C1S | 2082749 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082750 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082751 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082752 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2082753 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082754 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082755 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082756 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082757 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082758 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082759 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082760 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082761 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082762 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082763 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082764 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082765 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082766 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082767 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082768 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082769 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082770 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082771 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082772 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082773 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082774 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082775 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082776 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082777 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082778 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082779 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082780 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082781 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082782 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082783 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082784 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082785 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082786 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082787 | 02/2018 | 01/19/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2082788 | 02/2018 | 01/19/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082789 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082790 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082791 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082792 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082793 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082794 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082795 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082796 | 02/2018 | 01/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2082797 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082798 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082799 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082800 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082801 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082802 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082803 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082804 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082805 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082806 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082807 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082808 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082809 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082810 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2082811 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082812 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082813 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082814 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2082815 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082816 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082817 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082818 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082819 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082820 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082821 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082822 | 02/2018 | 01/19/2018 | 99.950 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082823 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 99.9 | 1 |
| KU | C1S | 2082824 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082825 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082826 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082827 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082828 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082829 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082830 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C1S | 2082831 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082832 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082833 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082834 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082835 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082836 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082837 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082838 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 99.9 | 1 |
| KU | C1S | 2082839 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082840 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082841 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082842 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082843 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2082844 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082845 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082846 | 02/2018 | 01/19/2018 | 100.040 | 99.920 | 100.0 | 1 |
| KU | C1S | 2082847 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082848 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082849 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082850 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082851 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082852 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082853 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 99.9 | 1 |
| KU | C1S | 2082854 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082855 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2082856 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082857 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082858 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 99.9 | 1 |
| KU | C1S | 2082859 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082860 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2082861 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082862 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082863 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082864 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082865 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082866 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082867 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082868 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082869 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082870 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082871 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082872 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082873 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082874 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082875 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082876 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082877 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082878 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082879 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082880 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082881 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082882 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082883 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082884 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082885 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082886 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082887 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082888 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082889 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082890 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082891 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082892 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082893 | 02/2018 | 01/19/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1S | 2082894 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082895 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1S | 2082896 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082897 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082898 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082899 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082900 | 02/2018 | 01/19/2018 | 99.960 | 100.020 | 100.1 | 1 |
| KU | C1S | 2082901 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2082902 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082903 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082904 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082905 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082906 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082907 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082908 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 99.9 | 1 |
| KU | C1S | 2082909 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082910 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082911 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082912 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082913 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082914 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082915 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1S | 2082916 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082917 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2082918 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082919 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082920 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082921 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082922 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082923 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082924 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082925 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082926 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082927 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082928 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082929 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082930 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2082931 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082932 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082933 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082934 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082935 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082936 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082937 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082938 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082939 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082940 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082941 | 02/2018 | 01/19/2018 | 99.980 | 99.910 | 100.0 | 1 |
| KU | C1S | 2082942 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082943 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082944 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082945 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082946 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082947 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082948 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082949 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082950 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082951 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082952 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082953 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1S | 2082954 | 02/2018 | 01/19/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2082955 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082956 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082957 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082958 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082959 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082960 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082961 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082962 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2082963 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082964 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082965 | 02/2018 | 01/19/2018 | 99.970 | 99.910 | 99.9 | 1 |
| KU | C1S | 2082966 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082967 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082968 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082969 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082970 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082971 | 02/2018 | 01/19/2018 | 99.990 | 99.920 | 100.0 | 1 |
| KU | C1S | 2082972 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082973 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082974 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2082975 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2082976 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082977 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082978 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082979 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082980 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082981 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082982 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082983 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | C1S | 2082984 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2082985 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082986 | 02/2018 | 01/19/2018 | 100.040 | 100.000 | 100.1 | 1 |
| KU | C1S | 2082987 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082988 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082989 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082990 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082991 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082992 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082993 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2082994 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2082995 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2082996 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2082997 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2082998 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2082999 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083000 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083001 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083002 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083003 | 02/2018 | 01/19/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083004 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083005 | 02/2018 | 01/19/2018 | 100.050 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083006 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083007 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083008 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083009 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083010 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083011 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083012 | 02/2018 | 01/19/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083013 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083014 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083015 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083016 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083017 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083018 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083019 | 02/2018 | 01/19/2018 | 100.050 | 100.000 | 100.1 | 1 |
| KU | C1S | 2083020 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083021 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083022 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083023 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083024 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083025 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083026 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083027 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083028 | 02/2018 | 01/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083029 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083030 | 02/2018 | 01/19/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1S | 2083031 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C1S | 2083032 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083033 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083034 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083035 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083036 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083037 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083038 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083039 | 02/2018 | 01/19/2018 | 99.960 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083040 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083041 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083042 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083043 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083044 | 02/2018 | 01/19/2018 | 100.040 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083045 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083046 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083047 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083048 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083049 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083050 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083051 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083052 | 02/2018 | 01/19/2018 | 99.950 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083053 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083054 | 02/2018 | 01/19/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083055 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083056 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083057 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083058 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083059 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083060 | 02/2018 | 01/19/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083061 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083062 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083063 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083064 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083065 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083066 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083067 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083068 | 02/2018 | 01/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083069 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083070 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083071 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083072 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083073 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083074 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083075 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083076 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C1S | 2083077 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083078 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083079 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083080 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083081 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083082 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083083 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083084 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083085 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083086 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083087 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083088 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083089 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083090 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083091 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083092 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083093 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083094 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083095 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083096 | 02/2018 | 01/19/2018 | 99.970 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083097 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083098 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083099 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083100 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083101 | 02/2018 | 01/19/2018 | 100.050 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083102 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083103 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083104 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083105 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083106 | 02/2018 | 01/19/2018 | 100.050 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083107 | 02/2018 | 01/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083108 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083109 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083110 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083111 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083112 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083113 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083114 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083115 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083116 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083117 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083118 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083119 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083120 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083121 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083122 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083123 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083124 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083125 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083126 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083127 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083128 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083129 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083130 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083131 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083132 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083133 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083134 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083135 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083136 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083137 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083138 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083139 | 02/2018 | 01/19/2018 | 100.060 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083140 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083141 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083142 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083143 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083144 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083145 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083146 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083147 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083148 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083149 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083150 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083151 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083152 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083153 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083154 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083155 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083156 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083157 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083158 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083159 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083160 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083161 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083162 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083163 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083164 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083165 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2083166 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083167 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083168 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083169 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083170 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083171 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083172 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083173 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083174 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083175 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083176 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083177 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083178 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083179 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083180 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083181 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083182 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083183 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083184 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083185 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083186 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083187 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083188 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083189 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083190 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083191 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083192 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083193 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083194 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083195 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083196 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083197 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083198 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083199 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083200 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083201 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083202 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083203 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083204 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083205 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083206 | 02/2018 | 01/19/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083207 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083208 | 02/2018 | 01/19/2018 | 100.040 | 99.910 | 100.0 | 1 |
| KU | C1S | 2083209 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083210 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083211 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083212 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083213 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083214 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083215 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083216 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083217 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083218 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083219 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083220 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083221 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083222 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083223 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083224 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083225 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083226 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083227 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083228 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083229 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083230 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083231 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083232 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083233 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083234 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083235 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083236 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083237 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083238 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083239 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083240 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083241 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083242 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083243 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083244 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083245 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083246 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083247 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083248 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083249 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083250 | 02/2018 | 01/19/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2083251 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083252 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083253 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083254 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083255 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083256 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083257 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083258 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083259 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083260 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083261 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083262 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083263 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083264 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083265 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083266 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083267 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083268 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083269 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083270 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083271 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083272 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083273 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083274 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083275 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083276 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083277 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083278 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083279 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083280 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083281 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083282 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083283 | 02/2018 | 01/19/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083284 | 02/2018 | 01/19/2018 | 99.960 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083285 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083286 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083287 | 02/2018 | 01/19/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083288 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083289 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083290 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083291 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083292 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083293 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083294 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083295 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083296 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083297 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083298 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083299 | 02/2018 | 01/19/2018 | 100.060 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083300 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083301 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083302 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083303 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083304 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083305 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083306 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083307 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083308 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083309 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083310 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083311 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083312 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083313 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083314 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1S | 2083315 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083316 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083317 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083318 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083319 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083320 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083321 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083322 | 02/2018 | 01/19/2018 | 99.940 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083323 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083324 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083325 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083326 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083327 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083328 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083329 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2083330 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083331 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083332 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083333 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083334 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083335 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083336 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083337 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083338 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083339 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083340 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083341 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083342 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083343 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083344 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083345 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083346 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083347 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083348 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083349 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083350 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083351 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083352 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083353 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083354 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | C1S | 2083355 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083356 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083357 | 02/2018 | 01/19/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083358 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083359 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083360 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083361 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083362 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083363 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083364 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083365 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083366 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083367 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083368 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083369 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083370 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083371 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083372 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083373 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083374 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083375 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083376 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083377 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083378 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083379 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083380 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083381 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083382 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083383 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083384 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083385 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083386 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083387 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083388 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083389 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083390 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083391 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083392 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083393 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083394 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083395 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083396 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083397 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083398 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083399 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083400 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083401 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083402 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083403 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083404 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083405 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083406 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083407 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083408 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083409 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083410 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083411 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083412 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083413 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083414 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083415 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083416 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083417 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083418 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083419 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083420 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083421 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083422 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083423 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083424 | 02/2018 | 01/19/2018 | 99.960 | 100.040 | 100.1 | 1 |
| KU | C1S | 2083425 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083426 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083427 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083428 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083429 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083430 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083431 | 02/2018 | 01/19/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083432 | 02/2018 | 01/19/2018 | 100.050 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083433 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083434 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083435 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083436 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083437 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.1 | 1 |
| KU | C1S | 2083438 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083439 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083440 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083441 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083442 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083443 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083444 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083445 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083446 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083447 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083448 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083449 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083450 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083451 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083452 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083453 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083454 | 02/2018 | 01/19/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083455 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083456 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083457 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083458 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083459 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083460 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083461 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083462 | 02/2018 | 01/19/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083463 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083464 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083465 | 02/2018 | 01/19/2018 | 100.050 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083466 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083467 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083468 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083469 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083470 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083471 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083472 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083473 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083474 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083475 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083476 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083477 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083478 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.1 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083479 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083480 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083481 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083482 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083483 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083484 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083485 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 99.9 | 1 |
| KU | C1S | 2083486 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083487 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083488 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083489 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083490 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.1 | 1 |
| KU | C1S | 2083491 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083492 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083493 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083494 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083495 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.1 | 1 |
| KU | C1S | 2083496 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083497 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083498 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083499 | 02/2018 | 01/19/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083500 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083501 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083502 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083503 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083504 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083505 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083506 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083507 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083508 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083509 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083510 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083511 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083512 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083513 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083514 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083515 | 02/2018 | 01/19/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C1S | 2083516 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083517 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083518 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083519 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083520 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083521 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083522 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083523 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083524 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083525 | 02/2018 | 01/19/2018 | 99.960 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083526 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083527 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083528 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083529 | 02/2018 | 01/19/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083530 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083531 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083532 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083533 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083534 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083535 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083536 | 02/2018 | 01/19/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083537 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083538 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083539 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083540 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083541 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083542 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083543 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083544 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083545 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083546 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083547 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083548 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083549 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083550 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083551 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083552 | 02/2018 | 01/19/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083553 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083554 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083555 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083556 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083557 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083558 | 02/2018 | 01/19/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083559 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083560 | 02/2018 | 01/19/2018 | 99.970 | 100.060 | 100.1 | 1 |
| KU | C1S | 2083561 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083562 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.1 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083563 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083564 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083565 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083566 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083567 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083568 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083569 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083570 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083571 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083572 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083573 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083574 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083575 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083576 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083577 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083578 | 02/2018 | 01/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083579 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083580 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083581 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083582 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083583 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083584 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083585 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083586 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083587 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083588 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083589 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083590 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083591 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083592 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083593 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083594 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083595 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083596 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083597 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083598 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083599 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083600 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083601 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083602 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083603 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083604 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083605 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083606 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083607 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083608 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083609 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | C1S | 2083610 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083611 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083612 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083613 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083614 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083615 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083616 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083617 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083618 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083619 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083620 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083621 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083622 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083623 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083624 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083625 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083626 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083627 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083628 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | C1S | 2083629 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083630 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | C1S | 2083631 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083632 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083633 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083634 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083635 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083636 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083637 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083638 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083639 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083640 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083641 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083642 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083643 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083644 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083645 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083646 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083647 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083648 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083649 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083650 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083651 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083652 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083653 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083654 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083655 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083656 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083657 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083658 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083659 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083660 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | C1S | 2083661 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083662 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083663 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083664 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083665 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083666 | 02/2018 | 01/19/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083667 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083668 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083669 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083670 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083671 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083672 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083673 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083674 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083675 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083676 | 02/2018 | 01/19/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2083677 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083678 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083679 | 02/2018 | 01/19/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2083680 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083681 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083682 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083683 | 02/2018 | 01/19/2018 | 100.050 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083684 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083685 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083686 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083687 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083688 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083689 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083690 | 02/2018 | 01/19/2018 | 100.050 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083691 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083692 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083693 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083694 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083695 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083696 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 99.9 | 1 |
| KU | C1S | 2083697 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083698 | 02/2018 | 01/19/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2083699 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083700 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1S | 2083701 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083702 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083703 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083704 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083705 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083706 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.1 | 1 |
| KU | C1S | 2083707 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083708 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083709 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083710 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083711 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083712 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083713 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083714 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083715 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083716 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 99.9 | 1 |
| KU | C1S | 2083717 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083718 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083719 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083720 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083721 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083722 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083723 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083724 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083725 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083726 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083727 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083728 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083729 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083730 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083731 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083732 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083733 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083734 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083735 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.1 | 1 |
| KU | C1S | 2083736 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083737 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083738 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083739 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083740 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083741 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083742 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083743 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083744 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083745 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083746 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083747 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083748 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083749 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083750 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083751 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083752 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083753 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083754 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083755 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083756 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083757 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083758 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083759 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083760 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083761 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083762 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083763 | 02/2018 | 01/19/2018 | 99.950 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083764 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083765 | 02/2018 | 01/19/2018 | 100.060 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083766 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083767 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083768 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083769 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083770 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083771 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083772 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083773 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083774 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083775 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083776 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083777 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083778 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083779 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083780 | 02/2018 | 01/19/2018 | 99.950 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083781 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083782 | 02/2018 | 01/19/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083783 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2083784 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083785 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083786 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083787 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083788 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083789 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083790 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083791 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083792 | 02/2018 | 01/19/2018 | 99.950 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083793 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083794 | 02/2018 | 01/19/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083795 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083796 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083797 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083798 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083799 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083800 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083801 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083802 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083803 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083804 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083805 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083806 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083807 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083808 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083809 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083810 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083811 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083812 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083813 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083814 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.1 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083815 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083816 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.1 | 1 |
| KU | C1S | 2083817 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C1S | 2083818 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083819 | 02/2018 | 01/19/2018 | 99.950 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083820 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083821 | 02/2018 | 01/19/2018 | 100.070 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083822 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083823 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083824 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083825 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083826 | 02/2018 | 01/19/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2083827 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083828 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2083829 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083830 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083831 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083832 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083833 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083834 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083835 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083836 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083837 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083838 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083839 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083840 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083841 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083842 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083843 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083844 | 02/2018 | 01/19/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083845 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083846 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083847 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083848 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083849 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083850 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083851 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083852 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083853 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.1 | 1 |
| KU | C1S | 2083854 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083855 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083856 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083857 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083858 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083859 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083860 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083861 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2083862 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083863 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083864 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083865 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083866 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083867 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083868 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083869 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083870 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083871 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083872 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083873 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083874 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2083875 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083876 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083877 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083878 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083879 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083880 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083881 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | C1S | 2083882 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083883 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083884 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083885 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083886 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083887 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083888 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083889 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083890 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083891 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083892 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083893 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083894 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083895 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083896 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083897 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083898 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083899 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083900 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083901 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083902 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083903 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2083904 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083905 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083906 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083907 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083908 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083909 | 02/2018 | 01/19/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083910 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083911 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083912 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083913 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083914 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083915 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083916 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1S | 2083917 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083918 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083919 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083920 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083921 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083922 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083923 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083924 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083925 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083926 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083927 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083928 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083929 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083930 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083931 | 02/2018 | 01/19/2018 | 100.000 | 99.900 | 99.9 | 1 |
| KU | C1S | 2083932 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083933 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 99.9 | 1 |
| KU | C1S | 2083934 | 02/2018 | 01/19/2018 | 100.040 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083935 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083936 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083937 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083938 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083939 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083940 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083941 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083942 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083943 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083944 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083945 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083946 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083947 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083948 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083949 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083950 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083951 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083952 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083953 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083954 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083955 | 02/2018 | 01/19/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1S | 2083956 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083957 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2083958 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083959 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083960 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083961 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083962 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083963 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083964 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083965 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2083966 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083967 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083968 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083969 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083970 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083971 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083972 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083973 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 100.0 | 1 |
| KU | C1S | 2083974 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083975 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083976 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2083977 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2083978 | 02/2018 | 01/19/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1S | 2083979 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083980 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083981 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083982 | 02/2018 | 01/19/2018 | 100.060 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2083983 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083984 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083985 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 99.9 | 1 |
| KU | C1S | 2083986 | 02/2018 | 01/19/2018 | 100.030 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083987 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.1 | 1 |
| KU | C1S | 2083988 | 02/2018 | 01/19/2018 | 100.010 | 99.910 | 100.0 | 1 |
| KU | C1S | 2083989 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2083990 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083991 | 02/2018 | 01/19/2018 | 99.960 | 99.930 | 100.0 | 1 |
| KU | C1S | 2083992 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2083993 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2083994 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083995 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2083996 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2083997 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2083998 | 02/2018 | 01/19/2018 | 100.020 | 99.900 | 99.9 | 1 |
| KU | C1S | 2083999 | 02/2018 | 01/19/2018 | 99.970 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084000 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084001 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084002 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084003 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084004 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084005 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084006 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084007 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084008 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084009 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084010 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084011 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084012 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084013 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084014 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084015 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084016 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084017 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084018 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084019 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084020 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084021 | 02/2018 | 01/19/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084022 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084023 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084024 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084025 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084026 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084027 | 02/2018 | 01/19/2018 | 99.990 | 99.900 | 99.9 | 1 |
| KU | C1S | 2084028 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084029 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084030 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084031 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084032 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084033 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084034 | 02/2018 | 01/19/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084035 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084036 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084037 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084038 | 02/2018 | 01/19/2018 | 99.950 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084039 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084040 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084041 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084042 | 02/2018 | 01/19/2018 | 100.050 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084043 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084044 | 02/2018 | 01/19/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084045 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084046 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084047 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084048 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084049 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084050 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084051 | 02/2018 | 01/19/2018 | 100.050 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084052 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084053 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084054 | 02/2018 | 01/19/2018 | 100.020 | 99.890 | 99.9 | 1 |
| KU | C1S | 2084055 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084056 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084057 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084058 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084059 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084060 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084061 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084062 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084063 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084064 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084065 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084066 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084067 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084068 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084069 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084070 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084071 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084072 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084073 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084074 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084075 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084076 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084077 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084078 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084079 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084080 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084081 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084082 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084083 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084084 | 02/2018 | 01/19/2018 | 100.060 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084085 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084086 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084087 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084088 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084089 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084090 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084091 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084092 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084093 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084094 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084095 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084096 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084097 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 99.9 | 1 |
| KU | C1S | 2084098 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084099 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084100 | 02/2018 | 01/19/2018 | 99.990 | 99.910 | 100.0 | 1 |
| KU | C1S | 2084101 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084102 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084103 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084104 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084105 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084106 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084107 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084108 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084109 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084110 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084111 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084112 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084113 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084114 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084115 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084116 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084117 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084118 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084119 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084120 | 02/2018 | 01/19/2018 | 100.050 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084121 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084122 | 02/2018 | 01/19/2018 | 99.940 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084123 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084124 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084125 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084126 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084127 | 02/2018 | 01/19/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2084128 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084129 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084130 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084131 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084132 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084133 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2084134 | 02/2018 | 01/19/2018 | 99.950 | 99.980 | 99.9 | 1 |
| KU | C1S | 2084135 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084136 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084137 | 02/2018 | 01/19/2018 | 99.990 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084138 | 02/2018 | 01/19/2018 | 100.050 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084139 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084140 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084141 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084142 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084143 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084144 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084145 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084146 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084147 | 02/2018 | 01/19/2018 | 100.000 | 99.900 | 99.9 | 1 |
| KU | C1S | 2084148 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084149 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084150 | 02/2018 | 01/19/2018 | 99.950 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084151 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084152 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084153 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084154 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084155 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084156 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084157 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084158 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084159 | 02/2018 | 01/19/2018 | 99.950 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084160 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084161 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084162 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084163 | 02/2018 | 01/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084164 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084165 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084166 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084167 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084168 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084169 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084170 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084171 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084172 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084173 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.1 | 1 |
| KU | C1S | 2084174 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084175 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084176 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084177 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084178 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084179 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084180 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084181 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084182 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084183 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084184 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084185 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084186 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084187 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084188 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084189 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084190 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084191 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084192 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|--------|-------|---|
| KU | C1S | 2084193 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084194 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084195 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084196 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084197 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084198 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084199 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084200 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084201 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084202 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084203 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084204 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084205 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084206 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084207 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084208 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084209 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084210 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084211 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084212 | 02/2018 | 01/19/2018 | 99.960 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084213 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084214 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084215 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084216 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084217 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084218 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084219 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084220 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084221 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084222 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084223 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084224 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084225 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084226 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084227 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084228 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084229 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084230 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.1 | 1 |
| KU | C1S | 2084231 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084232 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084233 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084234 | 02/2018 | 01/19/2018 | 99.950 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084235 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084236 | 02/2018 | 01/19/2018 | 99.960 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084237 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084238 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084239 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084240 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084241 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084242 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084243 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084244 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084245 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084246 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084247 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084248 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084249 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084250 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084251 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084252 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084253 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084254 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084255 | 02/2018 | 01/19/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084256 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084257 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084258 | 02/2018 | 01/19/2018 | 100.050 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084259 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084260 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084261 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084262 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084263 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084264 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084265 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084266 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084267 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084268 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084269 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084270 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084271 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084272 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084273 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084274 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084275 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084276 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|--------|-------|---|
| KU | C1S | 2084277 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084278 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084279 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084280 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084281 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084282 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084283 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084284 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084285 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084286 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084287 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084288 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084289 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084290 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084291 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084292 | 02/2018 | 01/19/2018 | 100.010 | 99.890 | 99.9 | 1 |
| KU | C1S | 2084293 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084294 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084295 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084296 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084297 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084298 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084299 | 02/2018 | 01/19/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084300 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084301 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084302 | 02/2018 | 01/19/2018 | 100.030 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084303 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084304 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084305 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084306 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084307 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084308 | 02/2018 | 01/19/2018 | 100.000 | 99.910 | 100.0 | 1 |
| KU | C1S | 2084309 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084310 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084311 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084312 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084313 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084314 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084315 | 02/2018 | 01/19/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1S | 2084316 | 02/2018 | 01/19/2018 | 100.030 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084317 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084318 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084319 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084320 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084321 | 02/2018 | 01/19/2018 | 99.970 | 99.900 | 99.9 | 1 |
| KU | C1S | 2084322 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084323 | 02/2018 | 01/19/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084324 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084325 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084326 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084327 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084328 | 02/2018 | 01/19/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084329 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084330 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084331 | 02/2018 | 01/19/2018 | 99.980 | 99.900 | 99.9 | 1 |
| KU | C1S | 2084332 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084333 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084334 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084335 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084336 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084337 | 02/2018 | 01/19/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084338 | 02/2018 | 01/19/2018 | 100.000 | 99.910 | 99.9 | 1 |
| KU | C1S | 2084339 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084340 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084341 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084342 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084343 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084344 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084345 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084346 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084347 | 02/2018 | 01/19/2018 | 100.000 | 99.910 | 99.9 | 1 |
| KU | C1S | 2084348 | 02/2018 | 01/19/2018 | 100.040 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084349 | 02/2018 | 01/19/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084350 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084351 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084352 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084353 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084354 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084355 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084356 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084357 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084358 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084359 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084360 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084361 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084362 | 02/2018 | 01/19/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084363 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084364 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084365 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084366 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084367 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084368 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084369 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084370 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084371 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084372 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084373 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084374 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084375 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084376 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084377 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084378 | 02/2018 | 01/19/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084379 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084380 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084381 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084382 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084383 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084384 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084385 | 02/2018 | 01/19/2018 | 99.990 | 99.900 | 99.9 | 1 |
| KU | C1S | 2084386 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084387 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084388 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084389 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084390 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.1 | 1 |
| KU | C1S | 2084391 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084392 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084393 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084394 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | C1S | 2084395 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | C1S | 2084396 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084397 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084398 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084399 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084400 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084401 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084402 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084403 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.1 | 1 |
| KU | C1S | 2084404 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084405 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084406 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084407 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084408 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084409 | 02/2018 | 01/19/2018 | 100.000 | 99.910 | 100.0 | 1 |
| KU | C1S | 2084410 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084411 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084412 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084413 | 02/2018 | 01/19/2018 | 100.040 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084414 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084415 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084416 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084417 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084418 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084419 | 02/2018 | 01/19/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084420 | 02/2018 | 01/19/2018 | 99.980 | 99.900 | 100.0 | 1 |
| KU | C1S | 2084421 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084422 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084423 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084424 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084425 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084426 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084427 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084428 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084429 | 02/2018 | 01/19/2018 | 100.020 | 99.880 | 100.0 | 1 |
| KU | C1S | 2084430 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084431 | 02/2018 | 01/19/2018 | 99.980 | 99.910 | 100.0 | 1 |
| KU | C1S | 2084432 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084433 | 02/2018 | 01/19/2018 | 99.960 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084434 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084435 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084436 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084437 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084438 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084439 | 02/2018 | 01/19/2018 | 100.020 | 99.900 | 100.0 | 1 |
| KU | C1S | 2084440 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084441 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084442 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084443 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084444 | 02/2018 | 01/19/2018 | 100.020 | 99.900 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084445 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084446 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084447 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084448 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084449 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084450 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084451 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084452 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084453 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084454 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084455 | 02/2018 | 01/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | C1S | 2084456 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084457 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084458 | 02/2018 | 01/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2084459 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084460 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084461 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084462 | 02/2018 | 01/19/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C1S | 2084463 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084464 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084465 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084466 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084467 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084468 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084469 | 02/2018 | 01/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084470 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084471 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084472 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084473 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084474 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084475 | 02/2018 | 01/19/2018 | 100.050 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084476 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084477 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084478 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084479 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084480 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084481 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084482 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084483 | 02/2018 | 01/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084484 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084485 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084486 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084487 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084488 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084489 | 02/2018 | 01/19/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2084490 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084491 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084492 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084493 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084494 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084495 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084496 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084497 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084498 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084499 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084500 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084501 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084502 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084503 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084504 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084505 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | C1S | 2084506 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084507 | 02/2018 | 01/19/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2084508 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084509 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084510 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084511 | 02/2018 | 01/19/2018 | 100.050 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084512 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084513 | 02/2018 | 01/19/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084514 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084515 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084516 | 02/2018 | 01/19/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084517 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084518 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084519 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084520 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084521 | 02/2018 | 01/19/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084522 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084523 | 02/2018 | 01/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084524 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084525 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084526 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084527 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084528 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084529 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084530 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084531 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084532 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084533 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084534 | 02/2018 | 01/19/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2084535 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 99.9 | 1 |
| KU | C1S | 2084536 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084537 | 02/2018 | 01/19/2018 | 99.970 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084538 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084539 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084540 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084541 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084542 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084543 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084544 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084545 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084546 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084547 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084548 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084549 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084550 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084551 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084552 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084553 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.1 | 1 |
| KU | C1S | 2084554 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084555 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084556 | 02/2018 | 01/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084557 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084558 | 02/2018 | 01/19/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084559 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084560 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.1 | 1 |
| KU | C1S | 2084561 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084562 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084563 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084564 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084565 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084566 | 02/2018 | 01/19/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | C1S | 2084567 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084568 | 02/2018 | 01/19/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084569 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084570 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084571 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 99.9 | 1 |
| KU | C1S | 2084572 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.1 | 1 |
| KU | C1S | 2084573 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084574 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084575 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084576 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084577 | 02/2018 | 01/19/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2084578 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084579 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084580 | 02/2018 | 01/19/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084581 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084582 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084583 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084584 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084585 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084586 | 02/2018 | 01/19/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084587 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084588 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084589 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084590 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084591 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084592 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084593 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084594 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084595 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084596 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084597 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084598 | 02/2018 | 01/19/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084599 | 02/2018 | 01/19/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084600 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084601 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084602 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084603 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084604 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084605 | 02/2018 | 01/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084606 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084607 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084608 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084609 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084610 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084611 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084612 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084613 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084614 | 02/2018 | 01/19/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084615 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084616 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084617 | 02/2018 | 01/19/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084618 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084619 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084620 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084621 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084622 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084623 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084624 | 02/2018 | 01/19/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2084625 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084626 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084627 | 02/2018 | 01/19/2018 | 100.050 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084628 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084629 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084630 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084631 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084632 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084633 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084634 | 02/2018 | 01/19/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084635 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084636 | 02/2018 | 01/19/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084637 | 02/2018 | 01/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084638 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084639 | 02/2018 | 01/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2084640 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084641 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084642 | 02/2018 | 01/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | C1S | 2084643 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084644 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084645 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084646 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084647 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084648 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084649 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084650 | 02/2018 | 01/19/2018 | 100.050 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084651 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084652 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084653 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084654 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.1 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|--------|-------|---|
| KU | C1S | 2084655 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084656 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084657 | 02/2018 | 01/19/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084658 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.1 | 1 |
| KU | C1S | 2084659 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084660 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084661 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084662 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084663 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084664 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.1 | 1 |
| KU | C1S | 2084665 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084666 | 02/2018 | 01/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084667 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084668 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.1 | 1 |
| KU | C1S | 2084669 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084670 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084671 | 02/2018 | 01/19/2018 | 99.950 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084672 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084673 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084674 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084675 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084676 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084677 | 02/2018 | 01/19/2018 | 99.950 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084678 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.1 | 1 |
| KU | C1S | 2084679 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084680 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084681 | 02/2018 | 01/19/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084682 | 02/2018 | 01/19/2018 | 100.050 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084683 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084684 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084685 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084686 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084687 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084688 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084689 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084690 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084691 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084692 | 02/2018 | 01/19/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084693 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084694 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084695 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084696 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084697 | 02/2018 | 01/19/2018 | 100.040 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084698 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 99.9 | 1 |
| KU | C1S | 2084699 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084700 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084701 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084702 | 02/2018 | 01/19/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084703 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084704 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084705 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084706 | 02/2018 | 01/19/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2084707 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084708 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084709 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084710 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084711 | 02/2018 | 01/19/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084712 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084713 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084714 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084715 | 02/2018 | 01/19/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084716 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084717 | 02/2018 | 01/19/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084718 | 02/2018 | 01/19/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084719 | 02/2018 | 01/19/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084720 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084721 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084722 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084723 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084724 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084725 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084726 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084727 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084728 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084729 | 02/2018 | 01/19/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084730 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084731 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084732 | 02/2018 | 01/19/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084733 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084734 | 02/2018 | 01/19/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084735 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084736 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084737 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084738 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084739 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084740 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084741 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084742 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084743 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084744 | 02/2018 | 01/19/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084745 | 02/2018 | 01/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084746 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084747 | 02/2018 | 01/19/2018 | 100.060 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084748 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084749 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | C1S | 2084750 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2084751 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084752 | 02/2018 | 01/19/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084753 | 02/2018 | 01/19/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084754 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084755 | 02/2018 | 01/19/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084756 | 02/2018 | 01/19/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084757 | 02/2018 | 01/19/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084758 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084759 | 02/2018 | 01/19/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084760 | 02/2018 | 01/19/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084761 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084762 | 02/2018 | 01/19/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084763 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084764 | 02/2018 | 01/19/2018 | 100.040 | 100.030 | 100.1 | 1 |
| KU | C1S | 2084765 | 02/2018 | 01/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084766 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.1 | 1 |
| KU | C1S | 2084767 | 02/2018 | 01/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2084768 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2084769 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084770 | 02/2018 | 01/19/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084771 | 02/2018 | 01/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084772 | 02/2018 | 01/19/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084773 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084774 | 02/2018 | 01/19/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084775 | 02/2018 | 01/19/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2084776 | 02/2018 | 01/19/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084777 | 02/2018 | 01/19/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084778 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084779 | 02/2018 | 01/19/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084780 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2084781 | 02/2018 | 01/19/2018 | 99.950 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084782 | 02/2018 | 01/19/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1S | 2084783 | 02/2018 | 01/19/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2084784 | 02/2018 | 01/19/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084785 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084786 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084787 | 02/2018 | 01/19/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084788 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084789 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084790 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084791 | 02/2018 | 01/19/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084792 | 02/2018 | 01/19/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084793 | 02/2018 | 01/19/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084794 | 02/2018 | 01/19/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2084795 | 02/2018 | 01/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | C1S | 2084796 | 02/2018 | 01/19/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084797 | 02/2018 | 01/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084798 | 02/2018 | 01/19/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084799 | 02/2018 | 01/19/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2084800 | 02/2018 | 01/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2084801 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2084802 | 02/2018 | 01/19/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084803 | 02/2018 | 01/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2084804 | 02/2018 | 01/19/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084805 | 02/2018 | 01/19/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084806 | 02/2018 | 01/19/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2084807 | 02/2018 | 01/19/2018 | 100.010 | 99.940 | 100.1 | 1 |
| KU | C1S | 2084808 | 02/2018 | 01/19/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2084809 | 02/2018 | 01/19/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2084810 | 02/2018 | 01/19/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1S | 2084811 | 02/2018 | 01/19/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085316 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085317 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085318 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085319 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085320 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085321 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085322 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085323 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085324 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085325 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2085326 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085327 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085328 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085329 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085330 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085331 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085332 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085333 | 04/2018 | 04/18/2018 | 100.050 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085334 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085335 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085336 | 04/2018 | 04/18/2018 | 99.940 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085337 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085338 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085339 | 04/2018 | 04/18/2018 | 100.040 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085340 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085341 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085342 | 04/2018 | 04/18/2018 | 99.970 | 99.980 | 99.9 | 1 |
| KU | C1S | 2085343 | 04/2018 | 04/18/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085344 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085345 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085346 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085347 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085348 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085349 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085350 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085351 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085352 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085353 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085354 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085355 | 04/2018 | 04/18/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085356 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085357 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085358 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085359 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085360 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085361 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085362 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 99.9 | 1 |
| KU | C1S | 2085363 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085364 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085365 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085366 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085367 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085368 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085369 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | C1S | 2085370 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085371 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085372 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085373 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085374 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085375 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085376 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085377 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085378 | 04/2018 | 04/18/2018 | 99.950 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085379 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085380 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085381 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085382 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085383 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085384 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085385 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085386 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085387 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085388 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085389 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085390 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085391 | 04/2018 | 04/18/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085392 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085393 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085394 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085395 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085396 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085397 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085398 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085399 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085400 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085401 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085402 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085403 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085404 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085405 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085406 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085407 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085408 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085409 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085410 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085411 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085412 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085413 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085414 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085415 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085416 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085417 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085418 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085419 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2085420 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085421 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085422 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085423 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085424 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085425 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085426 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085427 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085428 | 04/2018 | 04/18/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085429 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085430 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085431 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085432 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085433 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085434 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085435 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085436 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085437 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085438 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085439 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085440 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085441 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085442 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085443 | 04/2018 | 04/18/2018 | 100.040 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085444 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085445 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085446 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085447 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085448 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | C1S | 2085449 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085450 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085451 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085452 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085453 | 04/2018 | 04/18/2018 | 99.960 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085454 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085455 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085456 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085457 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085458 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085459 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085460 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085461 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085462 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085463 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085464 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.1 | 1 |
| KU | C1S | 2085465 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085466 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085467 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085468 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085469 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085470 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085471 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085472 | 04/2018 | 04/18/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085473 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2085474 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085475 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085476 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085477 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085478 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085479 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085480 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085481 | 04/2018 | 04/18/2018 | 100.030 | 100.070 | 100.1 | 1 |
| KU | C1S | 2085482 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085483 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085484 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085485 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085486 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085487 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085488 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085489 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085490 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085491 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085492 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085493 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085494 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085495 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085496 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085497 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085498 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085499 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085500 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085501 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085502 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085503 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C1S | 2085504 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085505 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085506 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085507 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085508 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085509 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085510 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2085511 | 04/2018 | 04/18/2018 | 100.060 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085512 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085513 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085514 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.1 | 1 |
| KU | C1S | 2085515 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085516 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085517 | 04/2018 | 04/18/2018 | 99.960 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085518 | 04/2018 | 04/18/2018 | 99.950 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085519 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085520 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085521 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085522 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085523 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085524 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085525 | 04/2018 | 04/18/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085526 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085527 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085528 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085529 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085530 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085531 | 04/2018 | 04/18/2018 | 99.960 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085532 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085533 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 99.9 | 1 |
| KU | C1S | 2085534 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085535 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085536 | 04/2018 | 04/18/2018 | 99.970 | 100.070 | 100.1 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085537 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085538 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085539 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085540 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085541 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085542 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085543 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085544 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085545 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085546 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085547 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085548 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085549 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085550 | 04/2018 | 04/18/2018 | 100.010 | 100.090 | 100.1 | 1 |
| KU | C1S | 2085551 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085552 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 99.9 | 1 |
| KU | C1S | 2085553 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085554 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085555 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085556 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085557 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085558 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085559 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085560 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | C1S | 2085561 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085562 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085563 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085564 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085565 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085566 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085567 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085568 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085569 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085570 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085571 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085572 | 04/2018 | 04/18/2018 | 99.960 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085573 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085574 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085575 | 04/2018 | 04/18/2018 | 100.050 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085576 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085577 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085578 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085579 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085580 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085581 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085582 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085583 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085584 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085585 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085586 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085587 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085588 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085589 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085590 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085591 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085592 | 04/2018 | 04/18/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085593 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085594 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085595 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085596 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085597 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085598 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085599 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085600 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085601 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085602 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085603 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085604 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085605 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085606 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085607 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085608 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085609 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085610 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085611 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085612 | 04/2018 | 04/18/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085613 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 99.9 | 1 |
| KU | C1S | 2085614 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085615 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085616 | 04/2018 | 04/18/2018 | 99.970 | 100.100 | 100.1 | 1 |
| KU | C1S | 2085617 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085618 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085619 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085620 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085621 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085622 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085623 | 04/2018 | 04/18/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085624 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085625 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085626 | 04/2018 | 04/18/2018 | 99.990 | 100.110 | 100.1 | 1 |
| KU | C1S | 2085627 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 99.9 | 1 |
| KU | C1S | 2085628 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085629 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085630 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085631 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085632 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085633 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085634 | 04/2018 | 04/18/2018 | 99.950 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085635 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085636 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085637 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085638 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085639 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085640 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085641 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085642 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085643 | 04/2018 | 04/18/2018 | 100.050 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085644 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085645 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085646 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.1 | 1 |
| KU | C1S | 2085647 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085648 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085649 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085650 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 99.9 | 1 |
| KU | C1S | 2085651 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085652 | 04/2018 | 04/18/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085653 | 04/2018 | 04/18/2018 | 99.950 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085654 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.1 | 1 |
| KU | C1S | 2085655 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085656 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085657 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085658 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085659 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085660 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085661 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085662 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085663 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085664 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085665 | 04/2018 | 04/18/2018 | 99.950 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085666 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085667 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085668 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085669 | 04/2018 | 04/18/2018 | 100.040 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085670 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085671 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085672 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085673 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085674 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085675 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085676 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085677 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085678 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085679 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085680 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085681 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.1 | 1 |
| KU | C1S | 2085682 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085683 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085684 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085685 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085686 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085687 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085688 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085689 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085690 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085691 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085692 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085693 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085694 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085695 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085696 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085697 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085698 | 04/2018 | 04/18/2018 | 99.960 | 99.960 | 99.9 | 1 |
| KU | C1S | 2085699 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085700 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085701 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085702 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085703 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085704 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085705 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085706 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085707 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085708 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085709 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085710 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085711 | 04/2018 | 04/18/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085712 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085713 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085714 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085715 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085716 | 04/2018 | 04/18/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085717 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085718 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085719 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085720 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085721 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085722 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085723 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085724 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085725 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085726 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085727 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085728 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085729 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085730 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085731 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085732 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085733 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085734 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 99.9 | 1 |
| KU | C1S | 2085735 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085736 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085737 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085738 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085739 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085740 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085741 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085742 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085743 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085744 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085745 | 04/2018 | 04/18/2018 | 99.950 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085746 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085747 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085748 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085749 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085750 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085751 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085752 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085753 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085754 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085755 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085756 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085757 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085758 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085759 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085760 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085761 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085762 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085763 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085764 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085765 | 04/2018 | 04/18/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085766 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085767 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085768 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085769 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085770 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085771 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085772 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085773 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085774 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085775 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085776 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085777 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085778 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085779 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085780 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085781 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085782 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085783 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085784 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085785 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085786 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085787 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085788 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085789 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085790 | 04/2018 | 04/18/2018 | 99.950 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085791 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085792 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085793 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085794 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085795 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085796 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085797 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085798 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085799 | 04/2018 | 04/18/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085800 | 04/2018 | 04/18/2018 | 99.950 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085801 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085802 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085803 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085804 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085805 | 04/2018 | 04/18/2018 | 99.950 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085806 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085807 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085808 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085809 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085810 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085811 | 04/2018 | 04/18/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085812 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085813 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085814 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085815 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085816 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085817 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085818 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085819 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085820 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | C1S | 2085821 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085822 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085823 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085824 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085825 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085826 | 04/2018 | 04/18/2018 | 100.010 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085827 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085828 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085829 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085830 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085831 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085832 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085833 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085834 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085835 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085836 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085837 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085838 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085839 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085840 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085841 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085842 | 04/2018 | 04/18/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085843 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085844 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085845 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085846 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085847 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085848 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085849 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085850 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085851 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085852 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085853 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085854 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085855 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085856 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085857 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085858 | 04/2018 | 04/18/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085859 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085860 | 04/2018 | 04/18/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085861 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085862 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085863 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085864 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.1 | 1 |
| KU | C1S | 2085865 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085866 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085867 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085868 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085869 | 04/2018 | 04/18/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085870 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085871 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085872 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085873 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085874 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085875 | 04/2018 | 04/18/2018 | 99.980 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085876 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085877 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085878 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085879 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085880 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085881 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085882 | 04/2018 | 04/18/2018 | 99.950 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085883 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085884 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085885 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085886 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085887 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085888 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085889 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085890 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085891 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085892 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085893 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085894 | 04/2018 | 04/18/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085895 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085896 | 04/2018 | 04/18/2018 | 100.010 | 100.080 | 100.1 | 1 |
| KU | C1S | 2085897 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085898 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085899 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085900 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085901 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085902 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085903 | 04/2018 | 04/18/2018 | 99.950 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085904 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085905 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085906 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085907 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085908 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085909 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085910 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085911 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085912 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085913 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085914 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085915 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085916 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2085917 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2085918 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2085919 | 04/2018 | 04/18/2018 | 100.020 | 100.070 | 100.0 | 1 |
| KU | C1S | 2085920 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2085921 | 04/2018 | 04/18/2018 | 100.020 | 99.900 | 99.9 | 1 |
| KU | C1S | 2085922 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2085923 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1S | 2085924 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2085925 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2085926 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085927 | 04/2018 | 04/18/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2085928 | 04/2018 | 04/18/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1S | 2085929 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085930 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085931 | 04/2018 | 04/18/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1S | 2085932 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2085933 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2085934 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2085935 | 04/2018 | 04/18/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2085936 | 04/2018 | 04/18/2018 | 100.020 | 99.910 | 99.9 | 1 |
| KU | C1S | 2085937 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085938 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2085939 | 04/2018 | 04/18/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2085940 | 04/2018 | 04/18/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1S | 2085941 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2085942 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085943 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.1 | 1 |
| KU | C1S | 2085944 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085945 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2085946 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085947 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085948 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085949 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085950 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2085951 | 04/2018 | 04/18/2018 | 100.010 | 99.900 | 99.9 | 1 |
| KU | C1S | 2085952 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085953 | 04/2018 | 04/18/2018 | 100.020 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085954 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085955 | 04/2018 | 04/18/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2085956 | 04/2018 | 04/18/2018 | 100.020 | 99.940 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085957 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085958 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085959 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085960 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085961 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2085962 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2085963 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2085964 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085965 | 04/2018 | 04/18/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1S | 2085966 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085967 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085968 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085969 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | C1S | 2085970 | 04/2018 | 04/18/2018 | 99.950 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085971 | 04/2018 | 04/18/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2085972 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | C1S | 2085973 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085974 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085975 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085976 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085977 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085978 | 04/2018 | 04/18/2018 | 99.960 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085979 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.1 | 1 |
| KU | C1S | 2085980 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.1 | 1 |
| KU | C1S | 2085981 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085982 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085983 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085984 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085985 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2085986 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2085987 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085988 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085989 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2085990 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085991 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2085992 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2085993 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2085994 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2085995 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2085996 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2085997 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2085998 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2085999 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086000 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086001 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086002 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086003 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086004 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086005 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086006 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086007 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086008 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086009 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 99.9 | 1 |
| KU | C1S | 2086010 | 04/2018 | 04/18/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086011 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086012 | 04/2018 | 04/18/2018 | 99.990 | 100.090 | 100.0 | 1 |
| KU | C1S | 2086013 | 04/2018 | 04/18/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086014 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086015 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086016 | 04/2018 | 04/18/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086017 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086018 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086019 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086020 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086021 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086022 | 04/2018 | 04/18/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086023 | 04/2018 | 04/18/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086024 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086025 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086026 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086027 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 100.0 | 1 |
| KU | C1S | 2086028 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086029 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1S | 2086030 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086031 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086032 | 04/2018 | 04/18/2018 | 99.940 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086033 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086034 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086035 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086036 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086037 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086038 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086039 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086040 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086041 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086042 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086043 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086044 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086045 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086046 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086047 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086048 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086049 | 04/2018 | 04/18/2018 | 100.020 | 100.090 | 100.1 | 1 |
| KU | C1S | 2086050 | 04/2018 | 04/18/2018 | 100.000 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086051 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086052 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086053 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086054 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086055 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086056 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086057 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086058 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086059 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086060 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086061 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086062 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086063 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086064 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086065 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086066 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086067 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086068 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086069 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086070 | 04/2018 | 04/18/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086071 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086072 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086073 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086074 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086075 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086076 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086077 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086078 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086079 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086080 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086081 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086082 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086083 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086084 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086085 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086086 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086087 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086088 | 04/2018 | 04/18/2018 | 99.960 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086089 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086090 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086091 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086092 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086093 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086094 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086095 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086096 | 04/2018 | 04/18/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086097 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086098 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086099 | 04/2018 | 04/18/2018 | 100.040 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086100 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086101 | 04/2018 | 04/18/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086102 | 04/2018 | 04/18/2018 | 100.020 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086103 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086104 | 04/2018 | 04/18/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086105 | 04/2018 | 04/18/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086106 | 04/2018 | 04/18/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086107 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086108 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086109 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086110 | 04/2018 | 04/18/2018 | 99.970 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086111 | 04/2018 | 04/18/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086112 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086113 | 04/2018 | 04/18/2018 | 100.030 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086114 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086115 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086116 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086117 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086118 | 04/2018 | 04/18/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086119 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086120 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086121 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086122 | 04/2018 | 04/18/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086123 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086124 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086125 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086126 | 04/2018 | 04/18/2018 | 100.050 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086127 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086128 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086129 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086130 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086131 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086132 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086133 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086134 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086135 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086136 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086137 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086138 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086139 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086140 | 04/2018 | 04/18/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086141 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086142 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086143 | 04/2018 | 04/18/2018 | 100.050 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086144 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086145 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086146 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086147 | 04/2018 | 04/18/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086148 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086149 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086150 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086151 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086152 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086153 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086154 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086155 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086156 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086157 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086158 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086159 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086160 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086161 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086162 | 04/2018 | 04/18/2018 | 100.070 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086163 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086164 | 04/2018 | 04/18/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086165 | 04/2018 | 04/18/2018 | 100.020 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086166 | 04/2018 | 04/18/2018 | 99.980 | 99.900 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086167 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086168 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086169 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086170 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086171 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086172 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086173 | 04/2018 | 04/18/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086174 | 04/2018 | 04/18/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1S | 2086175 | 04/2018 | 04/18/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086176 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086177 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086178 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086179 | 04/2018 | 04/18/2018 | 100.040 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086180 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086181 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086182 | 04/2018 | 04/18/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086183 | 04/2018 | 04/18/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086184 | 04/2018 | 04/18/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086185 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086186 | 04/2018 | 04/18/2018 | 99.980 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086187 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086188 | 04/2018 | 04/18/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086189 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086190 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086191 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086192 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086193 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086194 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086195 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086196 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086197 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086198 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086199 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086200 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086201 | 04/2018 | 04/18/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086202 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086203 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086204 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086205 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086206 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086207 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086208 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086209 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 99.9 | 1 |
| KU | C1S | 2086210 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086211 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.1 | 1 |
| KU | C1S | 2086212 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086213 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2086214 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086215 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086216 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086217 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086218 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086219 | 04/2018 | 04/18/2018 | 100.050 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086220 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086221 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086222 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086223 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086224 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086225 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086226 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086227 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086228 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086229 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086230 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086231 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086232 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086233 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086234 | 04/2018 | 04/18/2018 | 99.980 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086235 | 04/2018 | 04/18/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086236 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086237 | 04/2018 | 04/18/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1S | 2086238 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086239 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086240 | 04/2018 | 04/18/2018 | 99.990 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086241 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086242 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086243 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086244 | 04/2018 | 04/18/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086245 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086246 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086247 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086248 | 04/2018 | 04/18/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086249 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086250 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086251 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086252 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1S | 2086253 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086254 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086255 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086256 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086257 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086258 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086259 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086260 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086261 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086262 | 04/2018 | 04/18/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086263 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.1 | 1 |
| KU | C1S | 2086264 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086265 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086266 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086267 | 04/2018 | 04/18/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086268 | 04/2018 | 04/18/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086269 | 04/2018 | 04/18/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086270 | 04/2018 | 04/18/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086271 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086272 | 04/2018 | 04/18/2018 | 100.030 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086273 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086274 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086275 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086276 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086277 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086278 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086279 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 100.0 | 1 |
| KU | C1S | 2086280 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086281 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086282 | 04/2018 | 04/18/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086283 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086284 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086285 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086286 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086287 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086288 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086289 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086290 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086291 | 04/2018 | 04/18/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086292 | 04/2018 | 04/18/2018 | 99.950 | 99.950 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086293 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086294 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086295 | 04/2018 | 04/18/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086296 | 04/2018 | 04/18/2018 | 100.050 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086297 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086298 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086299 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086300 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086301 | 04/2018 | 04/18/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086302 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086303 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086304 | 04/2018 | 04/18/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086305 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086306 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086307 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086308 | 04/2018 | 04/18/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086309 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086310 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086311 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086312 | 04/2018 | 04/18/2018 | 99.990 | 100.090 | 100.1 | 1 |
| KU | C1S | 2086313 | 04/2018 | 04/18/2018 | 100.020 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086314 | 04/2018 | 04/18/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086315 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086316 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086317 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086318 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086319 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086320 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086321 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086322 | 04/2018 | 04/18/2018 | 99.970 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086323 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086324 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086325 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086326 | 04/2018 | 04/18/2018 | 100.030 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086327 | 04/2018 | 04/18/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086328 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086329 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086330 | 04/2018 | 04/18/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086331 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086332 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086333 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086334 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086335 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086336 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086337 | 04/2018 | 04/18/2018 | 100.050 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086338 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086339 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086340 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086341 | 04/2018 | 04/18/2018 | 99.970 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086342 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086343 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086344 | 04/2018 | 04/18/2018 | 100.070 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086345 | 04/2018 | 04/18/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086346 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086347 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086348 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086349 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086350 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086351 | 04/2018 | 04/18/2018 | 100.050 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086352 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | C1S | 2086353 | 04/2018 | 04/18/2018 | 100.020 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086354 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086355 | 04/2018 | 04/18/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086356 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086357 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086358 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086359 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086360 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086361 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086362 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086363 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086364 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086365 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086366 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086367 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086368 | 04/2018 | 04/18/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086369 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086370 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086371 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086372 | 04/2018 | 04/18/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086373 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086374 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086375 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086376 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086377 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086378 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 99.9 | 1 |
| KU | C1S | 2086379 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086380 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086381 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086382 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 99.9 | 1 |
| KU | C1S | 2086383 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086384 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086385 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086386 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086387 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086388 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086389 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086390 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086391 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086392 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086393 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086394 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086395 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086396 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086397 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086398 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086399 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086400 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086401 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086402 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086403 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086404 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086405 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086406 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086407 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086408 | 04/2018 | 04/18/2018 | 100.060 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086409 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086410 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086411 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086412 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086413 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086414 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086415 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086416 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C1S | 2086417 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086418 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086419 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086420 | 04/2018 | 04/18/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086421 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086422 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086423 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C1S | 2086424 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086425 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086426 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086427 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086428 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086429 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086430 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086431 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086432 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086433 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086434 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086435 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086436 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086437 | 04/2018 | 04/18/2018 | 99.970 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086438 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086439 | 04/2018 | 04/18/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086440 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086441 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086442 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086443 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086444 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086445 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086446 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086447 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086448 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086449 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086450 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 99.9 | 1 |
| KU | C1S | 2086451 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086452 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 99.9 | 1 |
| KU | C1S | 2086453 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086454 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086455 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086456 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086457 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086458 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086459 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086460 | 04/2018 | 04/18/2018 | 99.960 | 99.970 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086461 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086462 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | C1S | 2086463 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086464 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086465 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086466 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086467 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086468 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086469 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086470 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086471 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086472 | 04/2018 | 04/18/2018 | 99.960 | 100.000 | 99.9 | 1 |
| KU | C1S | 2086473 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086474 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086475 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086476 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086477 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1S | 2086478 | 04/2018 | 04/18/2018 | 100.030 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086479 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086480 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086481 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086482 | 04/2018 | 04/18/2018 | 99.950 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086483 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086484 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086485 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086486 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086487 | 04/2018 | 04/18/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086488 | 04/2018 | 04/18/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086489 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086490 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086491 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086492 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086493 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086494 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086495 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086496 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086497 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086498 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086499 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086500 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C1S | 2086501 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086502 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086503 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086504 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086505 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086506 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086507 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086508 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086509 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086510 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086511 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086512 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086513 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086514 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086515 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086516 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086517 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086518 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086519 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086520 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086521 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086522 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086523 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086524 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086525 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086526 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086527 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086528 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086529 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086530 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086531 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | C1S | 2086532 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086533 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086534 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086535 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086536 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086537 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086538 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086539 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086540 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086541 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086542 | 04/2018 | 04/18/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086543 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086544 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086545 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086546 | 04/2018 | 04/18/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086547 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086548 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086549 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086550 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086551 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086552 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086553 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086554 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086555 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086556 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086557 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.1 | 1 |
| KU | C1S | 2086558 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086559 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086560 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086561 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086562 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086563 | 04/2018 | 04/18/2018 | 100.020 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086564 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086565 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086566 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086567 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086568 | 04/2018 | 04/18/2018 | 100.000 | 100.090 | 100.1 | 1 |
| KU | C1S | 2086569 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086570 | 04/2018 | 04/18/2018 | 100.020 | 100.100 | 100.1 | 1 |
| KU | C1S | 2086571 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086572 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086573 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086574 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086575 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086576 | 04/2018 | 04/18/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086577 | 04/2018 | 04/18/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086578 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086579 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086580 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086581 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086582 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086583 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086584 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086585 | 04/2018 | 04/18/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086586 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086587 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086588 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086589 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086590 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086591 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086592 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086593 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086594 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086595 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086596 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 99.9 | 1 |
| KU | C1S | 2086597 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086598 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086599 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086600 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086601 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086602 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086603 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086604 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086605 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086606 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086607 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086608 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086609 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086610 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086611 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086612 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086613 | 04/2018 | 04/18/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086614 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086615 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086616 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086617 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086618 | 04/2018 | 04/18/2018 | 99.950 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086619 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086620 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086621 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086622 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086623 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086624 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086625 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086626 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086627 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086628 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086629 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086630 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086631 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086632 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086633 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086634 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086635 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086636 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086637 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | C1S | 2086638 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086639 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086640 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086641 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086642 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086643 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086644 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086645 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086646 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086647 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086648 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086649 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086650 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086651 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086652 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086653 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086654 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086655 | 04/2018 | 04/18/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086656 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086657 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | C1S | 2086658 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C1S | 2086659 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086660 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086661 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086662 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086663 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086664 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086665 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086666 | 04/2018 | 04/18/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086667 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086668 | 04/2018 | 04/18/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086669 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086670 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086671 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086672 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086673 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086674 | 04/2018 | 04/18/2018 | 99.950 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086675 | 04/2018 | 04/18/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086676 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086677 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086678 | 04/2018 | 04/18/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1S | 2086679 | 04/2018 | 04/18/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086680 | 04/2018 | 04/18/2018 | 99.960 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086681 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086682 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086683 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086684 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086685 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086686 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086687 | 04/2018 | 04/18/2018 | 100.040 | 99.890 | 99.9 | 1 |
| KU | C1S | 2086688 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086689 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086690 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086691 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086692 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086693 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086694 | 04/2018 | 04/18/2018 | 100.030 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086695 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086696 | 04/2018 | 04/18/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086697 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086698 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086699 | 04/2018 | 04/18/2018 | 100.080 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086700 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086701 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086702 | 04/2018 | 04/18/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086703 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086704 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086705 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086706 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086707 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086708 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086709 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 99.9 | 1 |
| KU | C1S | 2086710 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086711 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086712 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086713 | 04/2018 | 04/18/2018 | 100.080 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086714 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086715 | 04/2018 | 04/18/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086716 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086717 | 04/2018 | 04/18/2018 | 100.030 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086718 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086719 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086720 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086721 | 04/2018 | 04/18/2018 | 99.950 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086722 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086723 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086724 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086725 | 04/2018 | 04/18/2018 | 100.010 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086726 | 04/2018 | 04/18/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086727 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086728 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086729 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086730 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1S | 2086731 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086732 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086733 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086734 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086735 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086736 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086737 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086738 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 99.9 | 1 |
| KU | C1S | 2086739 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086740 | 04/2018 | 04/18/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1S | 2086741 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086742 | 04/2018 | 04/18/2018 | 99.970 | 99.980 | 99.9 | 1 |
| KU | C1S | 2086743 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086744 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086745 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086746 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086747 | 04/2018 | 04/18/2018 | 100.050 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086748 | 04/2018 | 04/18/2018 | 100.020 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086749 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086750 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086751 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086752 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1S | 2086753 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086754 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086755 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086756 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086757 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086758 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086759 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086760 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086761 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086762 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086763 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086764 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086765 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086766 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086767 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086768 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086769 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086770 | 04/2018 | 04/18/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086771 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086772 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086773 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086774 | 04/2018 | 04/18/2018 | 99.930 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086775 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086776 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086777 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086778 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086779 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2086780 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086781 | 04/2018 | 04/18/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086782 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086783 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086784 | 04/2018 | 04/18/2018 | 100.000 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086785 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086786 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086787 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086788 | 04/2018 | 04/18/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086789 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086790 | 04/2018 | 04/18/2018 | 99.960 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086791 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086792 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086793 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086794 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086795 | 04/2018 | 04/18/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086796 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086797 | 04/2018 | 04/18/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086798 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086799 | 04/2018 | 04/18/2018 | 100.030 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086800 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086801 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | C1S | 2086802 | 04/2018 | 04/18/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086803 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086804 | 04/2018 | 04/18/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086805 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086806 | 04/2018 | 04/18/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086807 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086808 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086809 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086810 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086811 | 04/2018 | 04/18/2018 | 100.040 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086812 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086813 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086814 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086815 | 04/2018 | 04/18/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086816 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086817 | 04/2018 | 04/18/2018 | 100.050 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086818 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086819 | 04/2018 | 04/18/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1S | 2086820 | 04/2018 | 04/18/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086821 | 04/2018 | 04/18/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086822 | 04/2018 | 04/18/2018 | 99.970 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086823 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086824 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086825 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086826 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.1 | 1 |
| KU | C1S | 2086827 | 04/2018 | 04/18/2018 | 99.950 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086828 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086829 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086830 | 04/2018 | 04/18/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086831 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086832 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086833 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086834 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086835 | 04/2018 | 04/18/2018 | 99.960 | 99.930 | 100.0 | 1 |
| KU | C1S | 2086836 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086837 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086838 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086839 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086840 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086841 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086842 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086843 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086844 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | C1S | 2086845 | 04/2018 | 04/18/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086846 | 04/2018 | 04/18/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086847 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086848 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086849 | 04/2018 | 04/18/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086850 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086851 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1S | 2086852 | 04/2018 | 04/18/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086853 | 04/2018 | 04/18/2018 | 99.960 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086854 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086855 | 04/2018 | 04/18/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086856 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086857 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086858 | 04/2018 | 04/18/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086859 | 04/2018 | 04/18/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086860 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086861 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086862 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086863 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086864 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086865 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086866 | 04/2018 | 04/18/2018 | 99.970 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086867 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086868 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086869 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086870 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086871 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086872 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086873 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086874 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086875 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086876 | 04/2018 | 04/18/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086877 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086878 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086879 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086880 | 04/2018 | 04/18/2018 | 99.980 | 99.990 | 99.9 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086881 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086882 | 04/2018 | 04/18/2018 | 99.980 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086883 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086884 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086885 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086886 | 04/2018 | 04/18/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086887 | 04/2018 | 04/18/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086888 | 04/2018 | 04/18/2018 | 99.970 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086889 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086890 | 04/2018 | 04/18/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086891 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2086892 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086893 | 04/2018 | 04/18/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086894 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086895 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086896 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086897 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086898 | 04/2018 | 04/18/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086899 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086900 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086901 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086902 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086903 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086904 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086905 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086906 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 99.9 | 1 |
| KU | C1S | 2086907 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086908 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086909 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086910 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086911 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086912 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086913 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086914 | 04/2018 | 04/18/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086915 | 04/2018 | 04/18/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086916 | 04/2018 | 04/18/2018 | 99.960 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086917 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086918 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1S | 2086919 | 04/2018 | 04/18/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086920 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086921 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086922 | 04/2018 | 04/18/2018 | 100.010 | 99.950 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086923 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086924 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086925 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086926 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086927 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2086928 | 04/2018 | 04/18/2018 | 99.960 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086929 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086930 | 04/2018 | 04/18/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086931 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086932 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086933 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.1 | 1 |
| KU | C1S | 2086934 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086935 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086936 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086937 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086938 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086939 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086940 | 04/2018 | 04/18/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086941 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 99.9 | 1 |
| KU | C1S | 2086942 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086943 | 04/2018 | 04/18/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086944 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086945 | 04/2018 | 04/18/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086946 | 04/2018 | 04/18/2018 | 99.960 | 99.940 | 99.9 | 1 |
| KU | C1S | 2086947 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086948 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2086949 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086950 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086951 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086952 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086953 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2086954 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086955 | 04/2018 | 04/18/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086956 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086957 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086958 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086959 | 04/2018 | 04/18/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086960 | 04/2018 | 04/18/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1S | 2086961 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086962 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C1S | 2086963 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086964 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2086965 | 04/2018 | 04/18/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086966 | 04/2018 | 04/18/2018 | 100.040 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086967 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1S | 2086968 | 04/2018 | 04/18/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086969 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2086970 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086971 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086972 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086973 | 04/2018 | 04/18/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086974 | 04/2018 | 04/18/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086975 | 04/2018 | 04/18/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1S | 2086976 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086977 | 04/2018 | 04/18/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086978 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086979 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.1 | 1 |
| KU | C1S | 2086980 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086981 | 04/2018 | 04/18/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1S | 2086982 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086983 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086984 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086985 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086986 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086987 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2086988 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2086989 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2086990 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086991 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2086992 | 04/2018 | 04/18/2018 | 100.030 | 99.920 | 99.9 | 1 |
| KU | C1S | 2086993 | 04/2018 | 04/18/2018 | 100.010 | 99.900 | 99.9 | 1 |
| KU | C1S | 2086994 | 04/2018 | 04/18/2018 | 100.060 | 100.020 | 100.0 | 1 |
| KU | C1S | 2086995 | 04/2018 | 04/18/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086996 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2086997 | 04/2018 | 04/18/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1S | 2086998 | 04/2018 | 04/18/2018 | 99.990 | 100.070 | 100.1 | 1 |
| KU | C1S | 2086999 | 04/2018 | 04/18/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1S | 2087000 | 04/2018 | 04/18/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1S | 2087001 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | C1S | 2087002 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087003 | 04/2018 | 04/18/2018 | 100.050 | 100.070 | 100.1 | 1 |
| KU | C1S | 2087004 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087005 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087006 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087007 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.1 | 1 |
| KU | C1S | 2087008 | 04/2018 | 04/18/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087009 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087010 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087011 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087012 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | C1S | 2087013 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087014 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087015 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087016 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.1 | 1 |
| KU | C1S | 2087017 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087018 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087019 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087020 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087021 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087022 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087023 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2087024 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087025 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | C1S | 2087026 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087027 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087028 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087029 | 04/2018 | 04/18/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087030 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087031 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087032 | 04/2018 | 04/18/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087033 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087034 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087035 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087036 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087037 | 04/2018 | 04/18/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1S | 2087038 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087039 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087040 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087041 | 04/2018 | 04/18/2018 | 100.060 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087042 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087043 | 04/2018 | 04/18/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1S | 2087044 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087045 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087046 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087047 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087048 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087049 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087050 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087051 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 99.9 | 1 |
| KU | C1S | 2087052 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087053 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087054 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087055 | 04/2018 | 04/18/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1S | 2087056 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087057 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087058 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087059 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087060 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087061 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087062 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087063 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087064 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087065 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087066 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087067 | 04/2018 | 04/18/2018 | 100.000 | 99.990 | 99.9 | 1 |
| KU | C1S | 2087068 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.1 | 1 |
| KU | C1S | 2087069 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087070 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087071 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087072 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087073 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087074 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087075 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087076 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087077 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087078 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | C1S | 2087079 | 04/2018 | 04/18/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087080 | 04/2018 | 04/18/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1S | 2087081 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087082 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087083 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087084 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087085 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087086 | 04/2018 | 04/18/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087087 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087088 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087089 | 04/2018 | 04/18/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1S | 2087090 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087091 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087092 | 04/2018 | 04/18/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087093 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087094 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087095 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087096 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087097 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087098 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.1 | 1 |
| KU | C1S | 2087099 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087100 | 04/2018 | 04/18/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1S | 2087101 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087102 | 04/2018 | 04/18/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087103 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087104 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087105 | 04/2018 | 04/18/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087106 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087107 | 04/2018 | 04/18/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1S | 2087108 | 04/2018 | 04/18/2018 | 99.970 | 100.070 | 100.0 | 1 |
| KU | C1S | 2087109 | 04/2018 | 04/18/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1S | 2087110 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087111 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087112 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2087113 | 04/2018 | 04/18/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087114 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087115 | 04/2018 | 04/18/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1S | 2087116 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087117 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087118 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087119 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087120 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087121 | 04/2018 | 04/18/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087122 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087123 | 04/2018 | 04/18/2018 | 100.040 | 100.060 | 100.1 | 1 |
| KU | C1S | 2087124 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087125 | 04/2018 | 04/18/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087126 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087127 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087128 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | C1S | 2087129 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087130 | 04/2018 | 04/18/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087131 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087132 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087133 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087134 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087135 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087136 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087137 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087138 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087139 | 04/2018 | 04/18/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087140 | 04/2018 | 04/18/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087141 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087142 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087143 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087144 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087145 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | C1S | 2087146 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087147 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087148 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087149 | 04/2018 | 04/18/2018 | 99.990 | 100.080 | 100.0 | 1 |
| KU | C1S | 2087150 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087151 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087152 | 04/2018 | 04/18/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087153 | 04/2018 | 04/18/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087154 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | C1S | 2087155 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087156 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087157 | 04/2018 | 04/18/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087158 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087159 | 04/2018 | 04/18/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087160 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087161 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087162 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087163 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087164 | 04/2018 | 04/18/2018 | 99.960 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087165 | 04/2018 | 04/18/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087166 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.1 | 1 |
| KU | C1S | 2087167 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087168 | 04/2018 | 04/18/2018 | 99.970 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087169 | 04/2018 | 04/18/2018 | 100.040 | 100.050 | 100.1 | 1 |
| KU | C1S | 2087170 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087171 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087172 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087173 | 04/2018 | 04/18/2018 | 100.010 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087174 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |

| | | | | | | | | |
|----|-----|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087175 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087176 | 04/2018 | 04/18/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087177 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087178 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087179 | 04/2018 | 04/18/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087180 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087181 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087182 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087183 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087184 | 04/2018 | 04/18/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087185 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087186 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087187 | 04/2018 | 04/18/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087188 | 04/2018 | 04/18/2018 | 99.980 | 100.070 | 100.0 | 1 |
| KU | C1S | 2087189 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087190 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087191 | 04/2018 | 04/18/2018 | 99.990 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087192 | 04/2018 | 04/18/2018 | 99.990 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087193 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087194 | 04/2018 | 04/18/2018 | 100.000 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087195 | 04/2018 | 04/18/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087196 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | C1S | 2087197 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087198 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087199 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087200 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087201 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087202 | 04/2018 | 04/18/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087203 | 04/2018 | 04/18/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1S | 2087204 | 04/2018 | 04/18/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087205 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087206 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | C1S | 2087207 | 04/2018 | 04/18/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | C1S | 2087208 | 04/2018 | 04/18/2018 | 100.030 | 100.080 | 100.0 | 1 |
| KU | C1S | 2087209 | 04/2018 | 04/18/2018 | 99.980 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087210 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | C1S | 2087211 | 04/2018 | 04/18/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087212 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087213 | 04/2018 | 04/18/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087214 | 04/2018 | 04/18/2018 | 100.000 | 100.080 | 100.1 | 1 |
| KU | C1S | 2087215 | 04/2018 | 04/18/2018 | 100.000 | 100.000 | 99.9 | 1 |
| KU | C1S | 2087216 | 04/2018 | 04/18/2018 | 99.970 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1S | 2087217 | 04/2018 | 04/18/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1S | 2087218 | 04/2018 | 04/18/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087219 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087220 | 04/2018 | 04/18/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087221 | 04/2018 | 04/18/2018 | 100.010 | 100.060 | 100.1 | 1 |
| KU | C1S | 2087222 | 04/2018 | 04/18/2018 | 100.010 | 100.080 | 100.0 | 1 |
| KU | C1S | 2087223 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087224 | 04/2018 | 04/18/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087225 | 04/2018 | 04/18/2018 | 100.000 | 100.040 | 100.0 | 1 |
| KU | C1S | 2087226 | 04/2018 | 04/18/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087227 | 04/2018 | 04/18/2018 | 99.990 | 100.060 | 100.0 | 1 |
| KU | C1S | 2087228 | 04/2018 | 04/18/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C1S | 2087229 | 04/2018 | 04/18/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087230 | 04/2018 | 04/18/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | C1S | 2087231 | 04/2018 | 04/18/2018 | 99.950 | 100.020 | 100.0 | 1 |
| KU | C1S | 2087232 | 04/2018 | 04/18/2018 | 99.980 | 100.050 | 100.0 | 1 |
| KU | C1S | 2087233 | 04/2018 | 04/18/2018 | 100.000 | 100.070 | 100.0 | 1 |
| KU | C1S | 2087234 | 04/2018 | 04/18/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1S | 2087235 | 04/2018 | 04/18/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512223 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512224 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512225 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512226 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512227 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512228 | 01/2018 | 01/16/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512229 | 01/2018 | 01/16/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512230 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512231 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512232 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512233 | 01/2018 | 01/16/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512234 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512235 | 01/2018 | 01/16/2018 | 99.930 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512236 | 01/2018 | 01/16/2018 | 99.950 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512237 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512238 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512239 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512240 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 99.9 | 1 |
| KU | C1SR | 2512241 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512242 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512243 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512244 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512245 | 01/2018 | 01/16/2018 | 99.960 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512246 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512247 | 01/2018 | 01/16/2018 | 100.040 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512248 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512249 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512250 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512251 | 01/2018 | 01/16/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512252 | 01/2018 | 01/16/2018 | 99.940 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512253 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512254 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512255 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512256 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512257 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512258 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512259 | 01/2018 | 01/16/2018 | 100.010 | 99.890 | 100.0 | 1 |
| KU | C1SR | 2512260 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512261 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512262 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512263 | 01/2018 | 01/16/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512264 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512265 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512266 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512267 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512268 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512269 | 01/2018 | 01/16/2018 | 99.970 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512270 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512271 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512272 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512273 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512274 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512275 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512276 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512277 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512278 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512279 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512280 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512281 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512282 | 01/2018 | 01/16/2018 | 99.960 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512283 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512284 | 01/2018 | 01/16/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512285 | 01/2018 | 01/16/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512286 | 01/2018 | 01/16/2018 | 99.960 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512287 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512288 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512289 | 01/2018 | 01/16/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512290 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512291 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512292 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512293 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512294 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512295 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512296 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512297 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512298 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512299 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512300 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512301 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512302 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512303 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512304 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512305 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512306 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512307 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512308 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512309 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512310 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512311 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512312 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512313 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512314 | 01/2018 | 01/16/2018 | 100.060 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512315 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512316 | 01/2018 | 01/16/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512317 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512318 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512319 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512320 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512321 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512322 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512323 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512324 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512325 | 01/2018 | 01/16/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512326 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512327 | 01/2018 | 01/16/2018 | 99.970 | 100.050 | 100.0 | 1 |
| KU | C1SR | 2512328 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512329 | 01/2018 | 01/16/2018 | 99.970 | 99.910 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512330 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512331 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512332 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512333 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512334 | 01/2018 | 01/16/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512335 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512336 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512337 | 01/2018 | 01/16/2018 | 99.960 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512338 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512339 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512340 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512341 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512342 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512343 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512344 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512345 | 01/2018 | 01/16/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2512346 | 01/2018 | 01/16/2018 | 100.010 | 99.900 | 99.9 | 1 |
| KU | C1SR | 2512347 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512348 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512349 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512350 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512351 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512352 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512353 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512354 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512355 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512356 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512357 | 01/2018 | 01/16/2018 | 100.040 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512358 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512359 | 01/2018 | 01/16/2018 | 100.030 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512360 | 01/2018 | 01/16/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512361 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512362 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512363 | 01/2018 | 01/16/2018 | 100.020 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512364 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512365 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512366 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512367 | 01/2018 | 01/16/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512368 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512369 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512370 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512371 | 01/2018 | 01/16/2018 | 100.020 | 100.030 | 100.1 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512372 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512373 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512374 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512375 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512376 | 01/2018 | 01/16/2018 | 99.950 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512377 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512378 | 01/2018 | 01/16/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512379 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512380 | 01/2018 | 01/16/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512381 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512382 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512383 | 01/2018 | 01/16/2018 | 100.010 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512384 | 01/2018 | 01/16/2018 | 99.960 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512385 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512386 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512387 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512388 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512389 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512390 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 99.9 | 1 |
| KU | C1SR | 2512391 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512392 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512393 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512394 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512395 | 01/2018 | 01/16/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512396 | 01/2018 | 01/16/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512397 | 01/2018 | 01/16/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512398 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512399 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512400 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512401 | 01/2018 | 01/16/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512402 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512403 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512404 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512405 | 01/2018 | 01/16/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512406 | 01/2018 | 01/16/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512407 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512408 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512409 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512410 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512411 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512412 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512413 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512414 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512415 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512416 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512417 | 01/2018 | 01/16/2018 | 99.970 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512418 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512419 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512420 | 01/2018 | 01/16/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512421 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512422 | 01/2018 | 01/16/2018 | 99.950 | 99.830 | 99.9 | 1 |
| KU | C1SR | 2512423 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512424 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512425 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512426 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512427 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512428 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512429 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512430 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512431 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512432 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512433 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512434 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512435 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512436 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512437 | 01/2018 | 01/16/2018 | 99.950 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512438 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512439 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512440 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512441 | 01/2018 | 01/16/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | C1SR | 2512442 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512443 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512444 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512445 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512446 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512447 | 01/2018 | 01/16/2018 | 100.050 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512448 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512449 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512450 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512451 | 01/2018 | 01/16/2018 | 99.970 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512452 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512453 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512454 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512455 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512456 | 01/2018 | 01/16/2018 | 100.000 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512457 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512458 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512459 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512460 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512461 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512462 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512463 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512464 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512465 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512466 | 01/2018 | 01/16/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512467 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512468 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512469 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512470 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512471 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512472 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512473 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512474 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512475 | 01/2018 | 01/16/2018 | 99.980 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512476 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | C1SR | 2512477 | 01/2018 | 01/16/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512478 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512479 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512480 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512481 | 01/2018 | 01/16/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512482 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512483 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512484 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512485 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512486 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512487 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512488 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512489 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512490 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512491 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512492 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512493 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512494 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512495 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512496 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512497 | 01/2018 | 01/16/2018 | 99.970 | 99.980 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512498 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512499 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512500 | 01/2018 | 01/16/2018 | 99.970 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512501 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512502 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512503 | 01/2018 | 01/16/2018 | 100.050 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512504 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512505 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512506 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512507 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512508 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512509 | 01/2018 | 01/16/2018 | 99.990 | 99.900 | 100.0 | 1 |
| KU | C1SR | 2512510 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512511 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512512 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512513 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512514 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512515 | 01/2018 | 01/16/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512516 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512517 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512518 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512519 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512520 | 01/2018 | 01/16/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512521 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512522 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512523 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512524 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512525 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512526 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512527 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512528 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512529 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512530 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512531 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512532 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512533 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512534 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512535 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512536 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512537 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512538 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512539 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512540 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512541 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512542 | 01/2018 | 01/16/2018 | 99.970 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512543 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512544 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512545 | 01/2018 | 01/16/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512546 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512547 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512548 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512549 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512550 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512551 | 01/2018 | 01/16/2018 | 100.050 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512552 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512553 | 01/2018 | 01/16/2018 | 100.030 | 99.900 | 99.9 | 1 |
| KU | C1SR | 2512554 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512555 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512556 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512557 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512558 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512559 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512560 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512561 | 01/2018 | 01/16/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512562 | 01/2018 | 01/16/2018 | 99.960 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512563 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512564 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512565 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512566 | 01/2018 | 01/16/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512567 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512568 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512569 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512570 | 01/2018 | 01/16/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512571 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512572 | 01/2018 | 01/16/2018 | 99.970 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512573 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512574 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512575 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512576 | 01/2018 | 01/16/2018 | 99.950 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512577 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512578 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512579 | 01/2018 | 01/16/2018 | 99.970 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512580 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512581 | 01/2018 | 01/16/2018 | 100.000 | 99.910 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512582 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512583 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512584 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512585 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512586 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512587 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512588 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512589 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512590 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512591 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 99.9 | 1 |
| KU | C1SR | 2512592 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512593 | 01/2018 | 01/16/2018 | 99.960 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512594 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512595 | 01/2018 | 01/16/2018 | 99.960 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512596 | 01/2018 | 01/16/2018 | 99.960 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512597 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512598 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512599 | 01/2018 | 01/16/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512600 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512601 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512602 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512603 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512604 | 01/2018 | 01/16/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512605 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512606 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512607 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512608 | 01/2018 | 01/16/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512609 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512610 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512611 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512612 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512613 | 01/2018 | 01/16/2018 | 99.940 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512614 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512615 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512616 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512617 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512618 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512619 | 01/2018 | 01/16/2018 | 100.040 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512620 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512621 | 01/2018 | 01/16/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512622 | 01/2018 | 01/16/2018 | 99.960 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512623 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512624 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512625 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512626 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512627 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512628 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512629 | 01/2018 | 01/16/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512630 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512631 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512632 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512633 | 01/2018 | 01/16/2018 | 100.030 | 100.010 | 99.9 | 1 |
| KU | C1SR | 2512634 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512635 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512636 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512637 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512638 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512639 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512640 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512641 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512642 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512643 | 01/2018 | 01/16/2018 | 100.020 | 99.890 | 99.9 | 1 |
| KU | C1SR | 2512644 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512645 | 01/2018 | 01/16/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512646 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512647 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512648 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512649 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512650 | 01/2018 | 01/16/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512651 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512652 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.1 | 1 |
| KU | C1SR | 2512653 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512654 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512655 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512656 | 01/2018 | 01/16/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C1SR | 2512657 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512658 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512659 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512660 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512661 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512662 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512663 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512664 | 01/2018 | 01/16/2018 | 99.950 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512665 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512666 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512667 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512668 | 01/2018 | 01/16/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512669 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512670 | 01/2018 | 01/16/2018 | 100.010 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512671 | 01/2018 | 01/16/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | C1SR | 2512672 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512673 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512674 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512675 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512676 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512677 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512678 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512679 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512680 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512681 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512682 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512683 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512684 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512685 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512686 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512687 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512688 | 01/2018 | 01/16/2018 | 99.990 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512689 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512690 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512691 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512692 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512693 | 01/2018 | 01/16/2018 | 100.020 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512694 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512695 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512696 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512697 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C1SR | 2512698 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512699 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512700 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512701 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512702 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512703 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512704 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512705 | 01/2018 | 01/16/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512706 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512707 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512708 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512709 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512710 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512711 | 01/2018 | 01/16/2018 | 100.030 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512712 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512713 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512714 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512715 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512716 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512717 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512718 | 01/2018 | 01/16/2018 | 100.030 | 99.990 | 99.9 | 1 |
| KU | C1SR | 2512719 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512720 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512721 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512722 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512723 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512724 | 01/2018 | 01/16/2018 | 100.040 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512725 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512726 | 01/2018 | 01/16/2018 | 100.020 | 99.890 | 99.9 | 1 |
| KU | C1SR | 2512727 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512728 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512729 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512730 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512731 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512732 | 01/2018 | 01/16/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512733 | 01/2018 | 01/16/2018 | 100.050 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512734 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512735 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512736 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512737 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512738 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512739 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512740 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512741 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512742 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512743 | 01/2018 | 01/16/2018 | 99.970 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512744 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512745 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512746 | 01/2018 | 01/16/2018 | 100.000 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512747 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512748 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512749 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512750 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512751 | 01/2018 | 01/16/2018 | 100.010 | 99.890 | 99.9 | 1 |
| KU | C1SR | 2512752 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512753 | 01/2018 | 01/16/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512754 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512755 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512756 | 01/2018 | 01/16/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2512757 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512758 | 01/2018 | 01/16/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512759 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512760 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512761 | 01/2018 | 01/16/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512762 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512763 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512764 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512765 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512766 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512767 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512768 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512769 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512770 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512771 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512772 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512773 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512774 | 01/2018 | 01/16/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512775 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512776 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512777 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512778 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512779 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512780 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512781 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512782 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512783 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512784 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512785 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512786 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512787 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512788 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512789 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512790 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512791 | 01/2018 | 01/16/2018 | 99.960 | 99.920 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512792 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512793 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512794 | 01/2018 | 01/16/2018 | 100.020 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512795 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512796 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512797 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512798 | 01/2018 | 01/16/2018 | 100.040 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512799 | 01/2018 | 01/16/2018 | 99.990 | 99.880 | 99.9 | 1 |
| KU | C1SR | 2512800 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512801 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512802 | 01/2018 | 01/16/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512803 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512804 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512805 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512806 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512807 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512808 | 01/2018 | 01/16/2018 | 99.980 | 99.880 | 99.9 | 1 |
| KU | C1SR | 2512809 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512810 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512811 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512812 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512813 | 01/2018 | 01/16/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512814 | 01/2018 | 01/16/2018 | 100.040 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512815 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512816 | 01/2018 | 01/16/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2512817 | 01/2018 | 01/16/2018 | 100.000 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512818 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512819 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512820 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512821 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512822 | 01/2018 | 01/16/2018 | 99.950 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512823 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512824 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512825 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512826 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512827 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512828 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512829 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512830 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512831 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512832 | 01/2018 | 01/16/2018 | 100.060 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512833 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512834 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512835 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512836 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512837 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512838 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512839 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512840 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512841 | 01/2018 | 01/16/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512842 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512843 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512844 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512845 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512846 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512847 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512848 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512849 | 01/2018 | 01/16/2018 | 100.050 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512850 | 01/2018 | 01/16/2018 | 100.030 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512851 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512852 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512853 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512854 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512855 | 01/2018 | 01/16/2018 | 99.990 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512856 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512857 | 01/2018 | 01/16/2018 | 99.990 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512858 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512859 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512860 | 01/2018 | 01/16/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512861 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512862 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512863 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512864 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512865 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512866 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512867 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512868 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512869 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512870 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512871 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512872 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512873 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512874 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512875 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512876 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512877 | 01/2018 | 01/16/2018 | 100.010 | 99.920 | 100.0 | 1 |
| KU | C1SR | 2512878 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512879 | 01/2018 | 01/16/2018 | 99.970 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512880 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512881 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512882 | 01/2018 | 01/16/2018 | 100.040 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512883 | 01/2018 | 01/16/2018 | 99.980 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512884 | 01/2018 | 01/16/2018 | 99.960 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512885 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512886 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512887 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512888 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512889 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512890 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512891 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512892 | 01/2018 | 01/16/2018 | 100.060 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512893 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512894 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512895 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512896 | 01/2018 | 01/16/2018 | 99.970 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512897 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512898 | 01/2018 | 01/16/2018 | 99.970 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512899 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512900 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512901 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512902 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 99.9 | 1 |
| KU | C1SR | 2512903 | 01/2018 | 01/16/2018 | 99.960 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512904 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512905 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512906 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512907 | 01/2018 | 01/16/2018 | 100.010 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2512908 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512909 | 01/2018 | 01/16/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2512910 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512911 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512912 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512913 | 01/2018 | 01/16/2018 | 100.030 | 99.900 | 99.9 | 1 |
| KU | C1SR | 2512914 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512915 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512916 | 01/2018 | 01/16/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512917 | 01/2018 | 01/16/2018 | 99.980 | 99.920 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512918 | 01/2018 | 01/16/2018 | 100.060 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512919 | 01/2018 | 01/16/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512920 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512921 | 01/2018 | 01/16/2018 | 99.970 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512922 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512923 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512924 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512925 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512926 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512927 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512928 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512929 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512930 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512931 | 01/2018 | 01/16/2018 | 100.040 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512932 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512933 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512934 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512935 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512936 | 01/2018 | 01/16/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512937 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512938 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512939 | 01/2018 | 01/16/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512940 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512941 | 01/2018 | 01/16/2018 | 99.950 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512942 | 01/2018 | 01/16/2018 | 100.050 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512943 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512944 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512945 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512946 | 01/2018 | 01/16/2018 | 99.960 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2512947 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512948 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512949 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512950 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512951 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512952 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512953 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512954 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512955 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512956 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512957 | 01/2018 | 01/16/2018 | 99.980 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512958 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512959 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2512960 | 01/2018 | 01/16/2018 | 99.970 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512961 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512962 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512963 | 01/2018 | 01/16/2018 | 99.960 | 99.980 | 99.9 | 1 |
| KU | C1SR | 2512964 | 01/2018 | 01/16/2018 | 100.000 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512965 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512966 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 99.9 | 1 |
| KU | C1SR | 2512967 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512968 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512969 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512970 | 01/2018 | 01/16/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512971 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2512972 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512973 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512974 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512975 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512976 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512977 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2512978 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 99.9 | 1 |
| KU | C1SR | 2512979 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512980 | 01/2018 | 01/16/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2512981 | 01/2018 | 01/16/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512982 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2512983 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512984 | 01/2018 | 01/16/2018 | 99.990 | 99.910 | 100.0 | 1 |
| KU | C1SR | 2512985 | 01/2018 | 01/16/2018 | 99.980 | 99.970 | 99.9 | 1 |
| KU | C1SR | 2512986 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512987 | 01/2018 | 01/16/2018 | 99.980 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2512988 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512989 | 01/2018 | 01/16/2018 | 100.000 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2512990 | 01/2018 | 01/16/2018 | 100.030 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2512991 | 01/2018 | 01/16/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512992 | 01/2018 | 01/16/2018 | 100.010 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2512993 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2512994 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 99.9 | 1 |
| KU | C1SR | 2512995 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2512996 | 01/2018 | 01/16/2018 | 99.980 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2512997 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2512998 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2512999 | 01/2018 | 01/16/2018 | 99.990 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2513000 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2513001 | 01/2018 | 01/16/2018 | 100.030 | 99.960 | 99.9 | 1 |

| | | | | | | | | |
|----|------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2513002 | 01/2018 | 01/16/2018 | 100.010 | 99.900 | 99.9 | 1 |
| KU | C1SR | 2513003 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2513004 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2513005 | 01/2018 | 01/16/2018 | 99.990 | 99.990 | 99.9 | 1 |
| KU | C1SR | 2513006 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513007 | 01/2018 | 01/16/2018 | 99.980 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513008 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2513009 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2513010 | 01/2018 | 01/16/2018 | 99.990 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513011 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 100.0 | 1 |
| KU | C1SR | 2513012 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C1SR | 2513013 | 01/2018 | 01/16/2018 | 100.000 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2513014 | 01/2018 | 01/16/2018 | 100.010 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2513015 | 01/2018 | 01/16/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513016 | 01/2018 | 01/16/2018 | 100.000 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2513017 | 01/2018 | 01/16/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513018 | 01/2018 | 01/16/2018 | 99.980 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513019 | 01/2018 | 01/16/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2513020 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C1SR | 2513021 | 01/2018 | 01/16/2018 | 99.990 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2513022 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513023 | 01/2018 | 01/16/2018 | 100.000 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513024 | 01/2018 | 01/16/2018 | 99.990 | 99.970 | 100.0 | 1 |
| KU | C1SR | 2513025 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2513026 | 01/2018 | 01/16/2018 | 100.020 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2513027 | 01/2018 | 01/16/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2513028 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 99.9 | 1 |
| KU | C1SR | 2513029 | 01/2018 | 01/16/2018 | 99.970 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2513030 | 01/2018 | 01/16/2018 | 99.970 | 100.040 | 100.0 | 1 |
| KU | C1SR | 2513031 | 01/2018 | 01/16/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513032 | 01/2018 | 01/16/2018 | 99.980 | 100.040 | 100.0 | 1 |
| KU | C1SR | 2513033 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513034 | 01/2018 | 01/16/2018 | 99.960 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513035 | 01/2018 | 01/16/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513036 | 01/2018 | 01/16/2018 | 99.980 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2513037 | 01/2018 | 01/16/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513038 | 01/2018 | 01/16/2018 | 99.990 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513039 | 01/2018 | 01/16/2018 | 100.020 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2513040 | 01/2018 | 01/16/2018 | 99.970 | 99.910 | 99.9 | 1 |
| KU | C1SR | 2513041 | 01/2018 | 01/16/2018 | 100.050 | 100.010 | 100.0 | 1 |
| KU | C1SR | 2513042 | 01/2018 | 01/16/2018 | 100.020 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513043 | 01/2018 | 01/16/2018 | 100.040 | 99.960 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C1SR | 2513044 | 01/2018 | 01/16/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513045 | 01/2018 | 01/16/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2513046 | 01/2018 | 01/16/2018 | 100.010 | 99.940 | 99.9 | 1 |
| KU | C1SR | 2513047 | 01/2018 | 01/16/2018 | 99.970 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513048 | 01/2018 | 01/16/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513049 | 01/2018 | 01/16/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513050 | 01/2018 | 01/16/2018 | 100.000 | 99.920 | 99.9 | 1 |
| KU | C1SR | 2513051 | 01/2018 | 01/16/2018 | 100.040 | 99.960 | 99.9 | 1 |
| KU | C1SR | 2513052 | 01/2018 | 01/16/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513053 | 01/2018 | 01/16/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513054 | 01/2018 | 01/16/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513055 | 01/2018 | 01/16/2018 | 100.020 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2513056 | 01/2018 | 01/16/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | C1SR | 2513057 | 01/2018 | 01/16/2018 | 99.970 | 99.990 | 100.0 | 1 |
| KU | C1SR | 2513058 | 01/2018 | 01/16/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C1SR | 2513059 | 01/2018 | 01/16/2018 | 99.960 | 99.930 | 99.9 | 1 |
| KU | C1SR | 2513060 | 01/2018 | 01/16/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | C1SR | 2513061 | 01/2018 | 01/16/2018 | 100.010 | 99.950 | 100.0 | 1 |
| KU | C1SR | 2513062 | 01/2018 | 01/16/2018 | 100.030 | 99.930 | 100.0 | 1 |
| KU | C2SOS | 2404038 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404039 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404040 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404041 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404042 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404043 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404044 | 03/2018 | 02/28/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404045 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404046 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404047 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404048 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404049 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404050 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404051 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404052 | 03/2018 | 02/28/2018 | 100.040 | 100.040 | 100.1 | 1 |
| KU | C2SOS | 2404053 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 99.9 | 1 |
| KU | C2SOS | 2404054 | 03/2018 | 02/28/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404055 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404056 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404057 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404058 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404059 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404060 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404061 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404062 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404063 | 03/2018 | 02/28/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404064 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404065 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404066 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404067 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404068 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404069 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404070 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404071 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404072 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404073 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404074 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404075 | 03/2018 | 02/28/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404076 | 03/2018 | 02/28/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404077 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404078 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404079 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404080 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404081 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404082 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404083 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | C2SOS | 2404084 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404085 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404086 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404087 | 03/2018 | 02/28/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404088 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404089 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404090 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404091 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404092 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404093 | 03/2018 | 02/28/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404094 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404095 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404096 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404097 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404098 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404099 | 03/2018 | 02/28/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404100 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404101 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404102 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404103 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404104 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404105 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404106 | 03/2018 | 02/28/2018 | 100.010 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404107 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404108 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404109 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404110 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404111 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404112 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404113 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404114 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404115 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404116 | 03/2018 | 02/28/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404117 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404118 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404119 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404120 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404121 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404122 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404123 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404124 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C2SOS | 2404125 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404126 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404127 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404128 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404129 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404130 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | C2SOS | 2404131 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404132 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404133 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404134 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404135 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404136 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404137 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404138 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404139 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404140 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404141 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404142 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404143 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404144 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404145 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404146 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404147 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404148 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404149 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404150 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404151 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404152 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404153 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404154 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404155 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404156 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404157 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 99.9 | 1 |
| KU | C2SOS | 2404158 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404159 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404160 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404161 | 03/2018 | 02/28/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404162 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404163 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404164 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404165 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404166 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404167 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404168 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404169 | 03/2018 | 02/28/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404170 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404171 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404172 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404173 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404174 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404175 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404176 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404177 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404178 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 99.9 | 1 |
| KU | C2SOS | 2404179 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404180 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404181 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404182 | 03/2018 | 02/28/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404183 | 03/2018 | 02/28/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C2SOS | 2404184 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404185 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404186 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404187 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404188 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.1 | 1 |
| KU | C2SOS | 2404189 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404190 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404191 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404192 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404193 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404194 | 03/2018 | 02/28/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404195 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404196 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404197 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404198 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404199 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404200 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404201 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404202 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404203 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404204 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404205 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404206 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C2SOS | 2404207 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404208 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404209 | 03/2018 | 02/28/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404210 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404211 | 03/2018 | 02/28/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404212 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404213 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404214 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404215 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404216 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404217 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404218 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404219 | 03/2018 | 02/28/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404220 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404221 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404222 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404223 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404224 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404225 | 03/2018 | 02/28/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404226 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404227 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404228 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404229 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404230 | 03/2018 | 02/28/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404231 | 03/2018 | 02/28/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404232 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404233 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404234 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404235 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404236 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404237 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404238 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404239 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404240 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404241 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404242 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404243 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404244 | 03/2018 | 02/28/2018 | 100.030 | 100.080 | 100.1 | 1 |
| KU | C2SOS | 2404245 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404246 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 99.9 | 1 |
| KU | C2SOS | 2404247 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404248 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404249 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404250 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404251 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404252 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404253 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404254 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404255 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404256 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404257 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404258 | 03/2018 | 02/28/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404259 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404260 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404261 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404262 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404263 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404264 | 03/2018 | 02/28/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404265 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404266 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404267 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404268 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404269 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404270 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.1 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404271 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404272 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404273 | 03/2018 | 02/28/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404274 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404275 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404276 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404277 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404278 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404279 | 03/2018 | 02/28/2018 | 100.010 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404280 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404281 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404282 | 03/2018 | 02/28/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404283 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | C2SOS | 2404284 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404285 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404286 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404287 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404288 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.1 | 1 |
| KU | C2SOS | 2404289 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404290 | 03/2018 | 02/28/2018 | 100.030 | 100.070 | 100.1 | 1 |
| KU | C2SOS | 2404291 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404292 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404293 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404294 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404295 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404296 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404297 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404298 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404299 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404300 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404301 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404302 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404303 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404304 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404305 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404306 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404307 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404308 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | C2SOS | 2404309 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404310 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404311 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404312 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404313 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404314 | 03/2018 | 02/28/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404315 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404316 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404317 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404318 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404319 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404320 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404321 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404322 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404323 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404324 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404325 | 03/2018 | 02/28/2018 | 100.030 | 99.950 | 100.0 | 1 |
| KU | C2SOS | 2404326 | 03/2018 | 02/28/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C2SOS | 2404327 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404328 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404329 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404330 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404331 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C2SOS | 2404332 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404333 | 03/2018 | 02/28/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404334 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404335 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404336 | 03/2018 | 02/28/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404337 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404338 | 03/2018 | 02/28/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404339 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404340 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 99.9 | 1 |
| KU | C2SOS | 2404341 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404342 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404343 | 03/2018 | 02/28/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404344 | 03/2018 | 02/28/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404345 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404346 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404347 | 03/2018 | 02/28/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | C2SOS | 2404348 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404349 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404350 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404351 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404352 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404353 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 99.9 | 1 |
| KU | C2SOS | 2404354 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404355 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404356 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404357 | 03/2018 | 02/28/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404358 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404359 | 03/2018 | 02/28/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404360 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404361 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404362 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404363 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404364 | 03/2018 | 02/28/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404365 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404366 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404367 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404368 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404369 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404370 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404371 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404372 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404373 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404374 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404375 | 03/2018 | 02/28/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | C2SOS | 2404376 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404377 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404378 | 03/2018 | 02/28/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404379 | 03/2018 | 02/28/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404380 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404381 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404382 | 03/2018 | 02/28/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404383 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404384 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404385 | 03/2018 | 02/28/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404386 | 03/2018 | 02/28/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404387 | 03/2018 | 02/28/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404388 | 03/2018 | 02/28/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | C2SOS | 2404389 | 03/2018 | 02/28/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404390 | 03/2018 | 02/28/2018 | 100.010 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404391 | 03/2018 | 02/28/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404392 | 03/2018 | 02/28/2018 | 100.020 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404393 | 03/2018 | 02/28/2018 | 100.020 | 100.070 | 100.1 | 1 |
| KU | C2SOS | 2404394 | 03/2018 | 02/28/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404395 | 03/2018 | 02/28/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404396 | 03/2018 | 02/28/2018 | 100.030 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404397 | 03/2018 | 02/28/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404398 | 03/2018 | 03/08/2018 | 100.040 | 99.980 | 99.9 | 1 |
| KU | C2SOS | 2404399 | 03/2018 | 03/08/2018 | 100.040 | 99.940 | 100.0 | 1 |
| KU | C2SOS | 2404400 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404401 | 03/2018 | 03/08/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404402 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404403 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404404 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404405 | 03/2018 | 03/08/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404406 | 03/2018 | 03/08/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | C2SOS | 2404407 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404408 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404409 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404410 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404411 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404412 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404413 | 03/2018 | 03/08/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404414 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404415 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | C2SOS | 2404416 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404417 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404418 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404419 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404420 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404421 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404422 | 03/2018 | 03/08/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404423 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.1 | 1 |
| KU | C2SOS | 2404424 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404425 | 03/2018 | 03/08/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404426 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404427 | 03/2018 | 03/08/2018 | 100.040 | 99.940 | 100.0 | 1 |
| KU | C2SOS | 2404428 | 03/2018 | 03/08/2018 | 100.010 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404429 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404430 | 03/2018 | 03/08/2018 | 100.030 | 99.930 | 100.0 | 1 |
| KU | C2SOS | 2404431 | 03/2018 | 03/08/2018 | 100.040 | 100.180 | 100.1 | 1 |
| KU | C2SOS | 2404432 | 03/2018 | 03/08/2018 | 100.050 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404433 | 03/2018 | 03/08/2018 | 100.040 | 99.950 | 100.0 | 1 |
| KU | C2SOS | 2404434 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404435 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404436 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404437 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404438 | 03/2018 | 03/08/2018 | 100.040 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404439 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404440 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404441 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404442 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404443 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404444 | 03/2018 | 03/08/2018 | 100.050 | 100.070 | 100.1 | 1 |
| KU | C2SOS | 2404445 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404446 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | C2SOS | 2404447 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404448 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404449 | 03/2018 | 03/08/2018 | 100.040 | 100.070 | 100.1 | 1 |
| KU | C2SOS | 2404450 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404451 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404452 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404453 | 03/2018 | 03/08/2018 | 100.040 | 100.100 | 100.1 | 1 |
| KU | C2SOS | 2404454 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404455 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404456 | 03/2018 | 03/08/2018 | 100.050 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404457 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404458 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404459 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404460 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404461 | 03/2018 | 03/08/2018 | 100.020 | 99.940 | 100.0 | 1 |
| KU | C2SOS | 2404462 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404463 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404464 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404465 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404466 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404467 | 03/2018 | 03/08/2018 | 100.040 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404468 | 03/2018 | 03/08/2018 | 100.040 | 100.150 | 100.0 | 1 |
| KU | C2SOS | 2404469 | 03/2018 | 03/08/2018 | 100.040 | 100.090 | 100.0 | 1 |
| KU | C2SOS | 2404470 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404471 | 03/2018 | 03/08/2018 | 100.050 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404472 | 03/2018 | 03/08/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404473 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404474 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404475 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404476 | 03/2018 | 03/08/2018 | 100.040 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404477 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404478 | 03/2018 | 03/08/2018 | 100.030 | 100.090 | 100.1 | 1 |
| KU | C2SOS | 2404479 | 03/2018 | 03/08/2018 | 100.020 | 99.990 | 99.9 | 1 |
| KU | C2SOS | 2404480 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404481 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404482 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404483 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404484 | 03/2018 | 03/08/2018 | 100.040 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404485 | 03/2018 | 03/08/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404486 | 03/2018 | 03/08/2018 | 100.030 | 100.130 | 100.1 | 1 |
| KU | C2SOS | 2404487 | 03/2018 | 03/08/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404488 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404489 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404490 | 03/2018 | 03/08/2018 | 100.030 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404491 | 03/2018 | 03/08/2018 | 100.020 | 99.930 | 100.0 | 1 |
| KU | C2SOS | 2404492 | 03/2018 | 03/08/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404493 | 03/2018 | 03/08/2018 | 100.030 | 100.110 | 100.1 | 1 |
| KU | C2SOS | 2404494 | 03/2018 | 03/08/2018 | 100.020 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404495 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404496 | 03/2018 | 03/08/2018 | 100.030 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404497 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404498 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 99.9 | 1 |
| KU | C2SOS | 2404499 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404500 | 03/2018 | 03/08/2018 | 100.040 | 100.120 | 100.1 | 1 |
| KU | C2SOS | 2404501 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404502 | 03/2018 | 03/08/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404503 | 03/2018 | 03/08/2018 | 100.030 | 100.090 | 100.0 | 1 |
| KU | C2SOS | 2404504 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404505 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404506 | 03/2018 | 03/08/2018 | 100.040 | 100.110 | 100.1 | 1 |
| KU | C2SOS | 2404507 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404508 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404509 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404510 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404511 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404512 | 03/2018 | 03/08/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404513 | 03/2018 | 03/08/2018 | 100.040 | 100.130 | 100.1 | 1 |
| KU | C2SOS | 2404514 | 03/2018 | 03/08/2018 | 100.020 | 99.950 | 100.0 | 1 |
| KU | C2SOS | 2404515 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404516 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404517 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404518 | 03/2018 | 03/08/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404519 | 03/2018 | 03/08/2018 | 100.030 | 100.090 | 100.0 | 1 |
| KU | C2SOS | 2404520 | 03/2018 | 03/08/2018 | 100.040 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404521 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404522 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404523 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404524 | 03/2018 | 03/08/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404525 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404526 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404527 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404528 | 03/2018 | 03/08/2018 | 100.030 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404529 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404530 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404531 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404532 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404533 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404534 | 03/2018 | 03/08/2018 | 100.040 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404535 | 03/2018 | 03/08/2018 | 100.050 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404536 | 03/2018 | 03/08/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404537 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404538 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404539 | 03/2018 | 03/08/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404540 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404541 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.1 | 1 |
| KU | C2SOS | 2404542 | 03/2018 | 03/08/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404543 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404544 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404545 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404546 | 03/2018 | 03/08/2018 | 100.040 | 100.100 | 100.0 | 1 |
| KU | C2SOS | 2404547 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404548 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404549 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404550 | 03/2018 | 03/08/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404551 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404552 | 03/2018 | 03/08/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404553 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404554 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404555 | 03/2018 | 03/08/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404556 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404557 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404558 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404559 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404560 | 03/2018 | 03/08/2018 | 100.020 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404561 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404562 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404563 | 03/2018 | 03/08/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404564 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404565 | 03/2018 | 03/08/2018 | 100.040 | 100.080 | 100.0 | 1 |
| KU | C2SOS | 2404566 | 03/2018 | 03/08/2018 | 100.040 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404567 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404568 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404569 | 03/2018 | 03/08/2018 | 100.030 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404570 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404571 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404572 | 03/2018 | 03/08/2018 | 100.020 | 100.070 | 100.1 | 1 |
| KU | C2SOS | 2404573 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404574 | 03/2018 | 03/08/2018 | 100.030 | 100.090 | 100.1 | 1 |
| KU | C2SOS | 2404575 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404576 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404577 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | C2SOS | 2404578 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404579 | 03/2018 | 03/08/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404580 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404581 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404582 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404583 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404584 | 03/2018 | 03/08/2018 | 100.040 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404585 | 03/2018 | 03/08/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404586 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404587 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404588 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404589 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404590 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404591 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404592 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404593 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404594 | 03/2018 | 03/08/2018 | 100.030 | 99.970 | 100.0 | 1 |
| KU | C2SOS | 2404595 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404596 | 03/2018 | 03/08/2018 | 100.050 | 100.060 | 100.1 | 1 |
| KU | C2SOS | 2404597 | 03/2018 | 03/08/2018 | 100.030 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404598 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404599 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404600 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404601 | 03/2018 | 03/08/2018 | 100.040 | 100.120 | 100.0 | 1 |
| KU | C2SOS | 2404602 | 03/2018 | 03/08/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404603 | 03/2018 | 03/08/2018 | 100.020 | 99.980 | 100.0 | 1 |
| KU | C2SOS | 2404604 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404605 | 03/2018 | 03/08/2018 | 100.040 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404606 | 03/2018 | 03/08/2018 | 100.030 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|-------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404607 | 03/2018 | 03/08/2018 | 100.020 | 100.080 | 100.1 | 1 |
| KU | C2SOS | 2404608 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404609 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404610 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.1 | 1 |
| KU | C2SOS | 2404611 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404612 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404613 | 03/2018 | 03/08/2018 | 100.040 | 100.110 | 100.1 | 1 |
| KU | C2SOS | 2404614 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404615 | 03/2018 | 03/08/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404616 | 03/2018 | 03/08/2018 | 100.030 | 100.090 | 100.1 | 1 |
| KU | C2SOS | 2404617 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404618 | 03/2018 | 03/08/2018 | 100.040 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404619 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404620 | 03/2018 | 03/08/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404621 | 03/2018 | 03/08/2018 | 100.040 | 100.110 | 100.1 | 1 |
| KU | C2SOS | 2404622 | 03/2018 | 03/08/2018 | 100.030 | 99.990 | 100.0 | 1 |
| KU | C2SOS | 2404623 | 03/2018 | 03/08/2018 | 100.040 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404624 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404625 | 03/2018 | 03/08/2018 | 100.030 | 100.120 | 100.1 | 1 |
| KU | C2SOS | 2404626 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404627 | 03/2018 | 03/08/2018 | 100.030 | 100.060 | 100.0 | 1 |
| KU | C2SOS | 2404628 | 03/2018 | 03/08/2018 | 100.020 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404629 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | C2SOS | 2404630 | 03/2018 | 03/08/2018 | 100.040 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404631 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404632 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404633 | 03/2018 | 03/08/2018 | 100.040 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404634 | 03/2018 | 03/08/2018 | 100.030 | 100.130 | 100.1 | 1 |
| KU | C2SOS | 2404635 | 03/2018 | 03/08/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404636 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404637 | 03/2018 | 03/08/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404638 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404639 | 03/2018 | 03/08/2018 | 100.020 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404640 | 03/2018 | 03/08/2018 | 100.030 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404641 | 03/2018 | 03/08/2018 | 100.030 | 99.960 | 100.0 | 1 |
| KU | C2SOS | 2404642 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | C2SOS | 2404643 | 03/2018 | 03/08/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | C2SOS | 2404644 | 03/2018 | 03/08/2018 | 100.030 | 100.000 | 100.0 | 1 |
| KU | C2SOS | 2404645 | 03/2018 | 03/08/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404646 | 03/2018 | 03/08/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | C2SOS | 2404647 | 03/2018 | 03/08/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | C2SOS | 2404648 | 03/2018 | 03/08/2018 | 100.020 | 100.040 | 100.0 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | C2SOS | 2404649 | 03/2018 | 03/08/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | C2SOS | 2404650 | 03/2018 | 03/08/2018 | 100.020 | 100.070 | 100.0 | 1 |
| KU | C2SOS | 2404651 | 03/2018 | 03/08/2018 | 100.030 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403356 | 05/2018 | 06/07/2017 | 99.990 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403357 | 05/2018 | 06/07/2017 | 99.980 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403358 | 05/2018 | 06/07/2017 | 99.980 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403359 | 05/2018 | 06/07/2017 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403586 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403587 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403588 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403589 | 05/2018 | 03/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403590 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403591 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403592 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403593 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403594 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403595 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403596 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403597 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403598 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403599 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403600 | 05/2018 | 03/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403601 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403602 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403603 | 05/2018 | 03/19/2018 | 100.040 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403604 | 05/2018 | 03/19/2018 | 99.970 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403605 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403606 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403607 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403608 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403609 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403610 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403611 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403612 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403613 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403614 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403615 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403616 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403617 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403618 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403619 | 05/2018 | 03/19/2018 | 100.010 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403620 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403621 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403622 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403623 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403624 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403625 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403626 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403627 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403628 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403629 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403630 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403631 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403632 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403633 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403634 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403635 | 05/2018 | 03/19/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403636 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403637 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403638 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403639 | 05/2018 | 03/19/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403640 | 05/2018 | 03/19/2018 | 99.970 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403641 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403642 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403643 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403644 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403645 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403646 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403647 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403648 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403649 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403650 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403651 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403652 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403653 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403654 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403655 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403656 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403657 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403658 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403659 | 05/2018 | 03/19/2018 | 99.970 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403660 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403661 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403662 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403663 | 05/2018 | 03/19/2018 | 100.040 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403664 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403665 | 05/2018 | 03/19/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403666 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403667 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403668 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403669 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403670 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403671 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403672 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403673 | 05/2018 | 03/19/2018 | 100.010 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403674 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403675 | 05/2018 | 03/19/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403676 | 05/2018 | 03/19/2018 | 100.030 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403677 | 05/2018 | 03/19/2018 | 100.030 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403678 | 05/2018 | 03/19/2018 | 100.020 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403679 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403680 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403681 | 05/2018 | 03/19/2018 | 100.000 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403682 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403683 | 05/2018 | 03/19/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403684 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403685 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403686 | 05/2018 | 03/19/2018 | 100.030 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403687 | 05/2018 | 03/19/2018 | 99.980 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403688 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403689 | 05/2018 | 03/19/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403690 | 05/2018 | 03/19/2018 | 100.010 | 99.970 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403691 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403692 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403693 | 05/2018 | 03/19/2018 | 100.030 | 100.070 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403694 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403695 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403696 | 05/2018 | 03/19/2018 | 99.970 | 99.940 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403697 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403698 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403699 | 05/2018 | 03/19/2018 | 99.980 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403700 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403701 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403702 | 05/2018 | 03/19/2018 | 99.960 | 99.990 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403703 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403704 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403705 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403706 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403707 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403708 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403709 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403710 | 05/2018 | 03/19/2018 | 99.960 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403711 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403712 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403713 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403714 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403715 | 05/2018 | 03/19/2018 | 99.990 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403716 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403717 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403718 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403719 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403720 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403721 | 05/2018 | 03/19/2018 | 99.970 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403722 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403723 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403724 | 05/2018 | 03/19/2018 | 99.980 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403725 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403726 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403727 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403728 | 05/2018 | 03/19/2018 | 99.970 | 99.950 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403729 | 05/2018 | 03/19/2018 | 100.010 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403730 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403731 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403732 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403733 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403734 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403735 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403736 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403737 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403738 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403739 | 05/2018 | 03/19/2018 | 100.020 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403740 | 05/2018 | 03/19/2018 | 100.040 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403741 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403742 | 05/2018 | 03/19/2018 | 100.000 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403743 | 05/2018 | 03/19/2018 | 99.960 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403744 | 05/2018 | 03/19/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403745 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403746 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.0 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403747 | 05/2018 | 03/19/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403748 | 05/2018 | 03/19/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403749 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403750 | 05/2018 | 03/19/2018 | 100.040 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403751 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403752 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403753 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403754 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403755 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403756 | 05/2018 | 03/19/2018 | 100.000 | 99.990 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403757 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403758 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403759 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403760 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403761 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403762 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403763 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403764 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403765 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403766 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403767 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403768 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403769 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403770 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403771 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403772 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403773 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403774 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403775 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403776 | 05/2018 | 03/19/2018 | 99.980 | 99.970 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403777 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403778 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403779 | 05/2018 | 03/19/2018 | 100.000 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403780 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403781 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403782 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403783 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403784 | 05/2018 | 03/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403785 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403786 | 05/2018 | 03/19/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403787 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403788 | 05/2018 | 03/19/2018 | 100.000 | 99.980 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403789 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403790 | 05/2018 | 03/19/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403791 | 05/2018 | 03/19/2018 | 99.980 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403792 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403793 | 05/2018 | 03/19/2018 | 99.980 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403794 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403795 | 05/2018 | 03/19/2018 | 99.980 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403796 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403797 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403798 | 05/2018 | 03/19/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403799 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403800 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403801 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403802 | 05/2018 | 03/19/2018 | 99.970 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403803 | 05/2018 | 03/19/2018 | 100.040 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403804 | 05/2018 | 03/19/2018 | 99.990 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403805 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403806 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403807 | 05/2018 | 03/19/2018 | 100.000 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403808 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403809 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403810 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403811 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403812 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403813 | 05/2018 | 03/19/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403814 | 05/2018 | 03/19/2018 | 100.010 | 100.070 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403815 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403816 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403817 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403818 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403819 | 05/2018 | 03/19/2018 | 99.970 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403820 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403821 | 05/2018 | 03/19/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403822 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403823 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403824 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403825 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403826 | 05/2018 | 03/19/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403827 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403828 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403829 | 05/2018 | 03/19/2018 | 100.030 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403830 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403831 | 05/2018 | 03/19/2018 | 99.980 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403832 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403833 | 05/2018 | 03/19/2018 | 99.970 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403834 | 05/2018 | 03/19/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403835 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403836 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403837 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403838 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403839 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403840 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403841 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403842 | 05/2018 | 03/19/2018 | 99.960 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403843 | 05/2018 | 03/19/2018 | 100.030 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403844 | 05/2018 | 03/19/2018 | 99.960 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403845 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403846 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403847 | 05/2018 | 03/19/2018 | 100.030 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403848 | 05/2018 | 03/19/2018 | 99.970 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403849 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403850 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403851 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403852 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403853 | 05/2018 | 03/19/2018 | 99.960 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403854 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403855 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403856 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403857 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403858 | 05/2018 | 03/19/2018 | 100.030 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403859 | 05/2018 | 03/19/2018 | 99.990 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403860 | 05/2018 | 03/19/2018 | 100.010 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403861 | 05/2018 | 03/19/2018 | 99.970 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403862 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403863 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403864 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403865 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403866 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403867 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403868 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403869 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403870 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403871 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403872 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403873 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403874 | 05/2018 | 03/19/2018 | 99.980 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403875 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403876 | 05/2018 | 03/19/2018 | 100.040 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403877 | 05/2018 | 03/19/2018 | 99.980 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403878 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403879 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403880 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403881 | 05/2018 | 03/19/2018 | 100.020 | 100.080 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403882 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403883 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403884 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403885 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403886 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403887 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403888 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403889 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403890 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403891 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403892 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403893 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403894 | 05/2018 | 03/19/2018 | 99.980 | 99.960 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403895 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403896 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403897 | 05/2018 | 03/19/2018 | 99.970 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403898 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403899 | 05/2018 | 03/19/2018 | 99.970 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403900 | 05/2018 | 03/19/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403901 | 05/2018 | 03/19/2018 | 99.980 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403902 | 05/2018 | 03/19/2018 | 99.970 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403903 | 05/2018 | 03/19/2018 | 100.040 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403904 | 05/2018 | 03/19/2018 | 100.000 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403905 | 05/2018 | 03/19/2018 | 100.040 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403906 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403907 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403908 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403909 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403910 | 05/2018 | 03/19/2018 | 99.970 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403911 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403912 | 05/2018 | 03/19/2018 | 99.980 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403913 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403914 | 05/2018 | 03/19/2018 | 100.030 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403915 | 05/2018 | 03/19/2018 | 99.990 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403916 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403917 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403918 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403919 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403920 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403921 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403922 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403923 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403924 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403925 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403926 | 05/2018 | 03/19/2018 | 100.000 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403927 | 05/2018 | 03/19/2018 | 100.000 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403928 | 05/2018 | 03/19/2018 | 100.000 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403929 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403930 | 05/2018 | 03/19/2018 | 100.030 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403931 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403932 | 05/2018 | 03/19/2018 | 100.030 | 100.070 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403933 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403934 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403935 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403936 | 05/2018 | 03/19/2018 | 99.990 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403937 | 05/2018 | 03/19/2018 | 100.000 | 99.980 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403938 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403939 | 05/2018 | 03/19/2018 | 100.030 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403940 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403941 | 05/2018 | 03/19/2018 | 99.970 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403942 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403943 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403944 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403945 | 05/2018 | 03/19/2018 | 99.960 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403946 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403947 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403948 | 05/2018 | 03/19/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403949 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403950 | 05/2018 | 03/19/2018 | 100.010 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403951 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403952 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403953 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403954 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403955 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403956 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.0 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403957 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403958 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403959 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403960 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403961 | 05/2018 | 03/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403962 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403963 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403964 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403965 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403966 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403967 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403968 | 05/2018 | 03/19/2018 | 100.020 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403969 | 05/2018 | 03/19/2018 | 99.980 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403970 | 05/2018 | 03/19/2018 | 100.010 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403971 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403972 | 05/2018 | 03/19/2018 | 99.990 | 99.970 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403973 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403974 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403975 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403976 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403977 | 05/2018 | 03/19/2018 | 100.020 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403978 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403979 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403980 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403981 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403982 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403983 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403984 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403985 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403986 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403987 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403988 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403989 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403990 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403991 | 05/2018 | 03/19/2018 | 99.970 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403992 | 05/2018 | 03/19/2018 | 100.000 | 100.060 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403993 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403994 | 05/2018 | 03/19/2018 | 100.020 | 100.010 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403995 | 05/2018 | 03/19/2018 | 100.020 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403996 | 05/2018 | 03/19/2018 | 100.020 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403997 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2403998 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |

| | | | | | | | | |
|----|--------------------|---------|---------|------------|---------|---------|-------|---|
| KU | FOCUS AXRE-SD MESH | 2403999 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404000 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404001 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404002 | 05/2018 | 03/19/2018 | 100.020 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404003 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404004 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404005 | 05/2018 | 03/19/2018 | 100.020 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404006 | 05/2018 | 03/19/2018 | 99.970 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404007 | 05/2018 | 03/19/2018 | 100.010 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404008 | 05/2018 | 03/19/2018 | 100.010 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404009 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404010 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404011 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404012 | 05/2018 | 03/19/2018 | 100.000 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404013 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404014 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404015 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404016 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404017 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404018 | 05/2018 | 03/19/2018 | 100.000 | 100.020 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404019 | 05/2018 | 03/19/2018 | 100.010 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404020 | 05/2018 | 03/19/2018 | 99.990 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404021 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404022 | 05/2018 | 03/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404023 | 05/2018 | 03/19/2018 | 99.990 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404024 | 05/2018 | 03/19/2018 | 99.970 | 100.020 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404025 | 05/2018 | 03/19/2018 | 100.020 | 100.030 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404026 | 05/2018 | 03/19/2018 | 100.000 | 100.040 | 100.2 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404027 | 05/2018 | 03/19/2018 | 100.000 | 100.050 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404028 | 05/2018 | 03/19/2018 | 99.990 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404029 | 05/2018 | 03/19/2018 | 100.000 | 100.000 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404030 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404031 | 05/2018 | 03/19/2018 | 99.980 | 100.010 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404032 | 05/2018 | 03/19/2018 | 99.980 | 99.980 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404033 | 05/2018 | 03/19/2018 | 99.980 | 99.990 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404034 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404035 | 05/2018 | 03/19/2018 | 100.000 | 100.030 | 100.0 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404036 | 05/2018 | 03/19/2018 | 100.030 | 100.040 | 100.1 | 1 |
| KU | FOCUS AXRE-SD MESH | 2404037 | 05/2018 | 03/19/2018 | 100.010 | 100.030 | 100.1 | 1 |

5,990

ATTACHMENT
A

The Certified Test Results
of all new meters

5040 Annual Report of

7/2018 - 12/2018

KU

**Total Meter
Count: 4699**

| Company (Plant) | Manufacturer Model No. | Serial Number | Accepted Month & Year | Mfg Test Date | As Left Full Load | As Left Light Load | As Left Power Factor |
|-----------------|------------------------|---------------|-----------------------|---------------|-------------------|--------------------|----------------------|
| KU | C1S | 2087236 | 7/2018 | 7/10/2018 | 99.95 | 100.05 | 100.09 |
| KU | C1S | 2087237 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2087238 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2087239 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.05 |
| KU | C1S | 2087240 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.02 |
| KU | C1S | 2087241 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2087242 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2087243 | 7/2018 | 7/10/2018 | 100.04 | 100.05 | 100.02 |
| KU | C1S | 2087244 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2087245 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2087246 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2087247 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.97 |
| KU | C1S | 2087248 | 7/2018 | 7/10/2018 | 100.03 | 99.98 | 100.04 |
| KU | C1S | 2087249 | 7/2018 | 7/10/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2087250 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.04 |
| KU | C1S | 2087251 | 7/2018 | 7/10/2018 | 100.06 | 100.06 | 100.01 |
| KU | C1S | 2087252 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 99.99 |
| KU | C1S | 2087253 | 7/2018 | 7/10/2018 | 100.04 | 100.01 | 100.01 |
| KU | C1S | 2087254 | 7/2018 | 7/10/2018 | 100.03 | 99.98 | 99.97 |
| KU | C1S | 2087255 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 99.99 |
| KU | C1S | 2087256 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.01 |
| KU | C1S | 2087257 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.03 |
| KU | C1S | 2087258 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.01 |
| KU | C1S | 2087259 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.99 |
| KU | C1S | 2087260 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 99.99 |
| KU | C1S | 2087261 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.99 |
| KU | C1S | 2087262 | 7/2018 | 7/10/2018 | 100.04 | 100.09 | 100.04 |
| KU | C1S | 2087263 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100.1 |
| KU | C1S | 2087264 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.05 |
| KU | C1S | 2087265 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.02 |
| KU | C1S | 2087266 | 7/2018 | 7/10/2018 | 100.05 | 100.04 | 100.03 |
| KU | C1S | 2087267 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.06 |
| KU | C1S | 2087268 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.01 |
| KU | C1S | 2087269 | 7/2018 | 7/10/2018 | 99.97 | 100.05 | 100.04 |
| KU | C1S | 2087270 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.05 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087271 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.02 |
| KU | C1S | 2087272 | 7/2018 | 7/10/2018 | 99.97 | 100.05 | 100.06 |
| KU | C1S | 2087273 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087274 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 99.99 |
| KU | C1S | 2087275 | 7/2018 | 7/10/2018 | 100.03 | 100 | 100.01 |
| KU | C1S | 2087276 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.02 |
| KU | C1S | 2087277 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.06 |
| KU | C1S | 2087278 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2087279 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2087280 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.03 |
| KU | C1S | 2087281 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 100.03 |
| KU | C1S | 2087282 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.06 |
| KU | C1S | 2087283 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087284 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.05 |
| KU | C1S | 2087285 | 7/2018 | 7/10/2018 | 99.95 | 100.04 | 100.06 |
| KU | C1S | 2087286 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.96 |
| KU | C1S | 2087287 | 7/2018 | 7/10/2018 | 99.98 | 99.96 | 99.97 |
| KU | C1S | 2087288 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.01 |
| KU | C1S | 2087289 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100 |
| KU | C1S | 2087290 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.06 |
| KU | C1S | 2087291 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.08 |
| KU | C1S | 2087292 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100.03 |
| KU | C1S | 2087293 | 7/2018 | 7/10/2018 | 99.96 | 100.03 | 100 |
| KU | C1S | 2087294 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2087295 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.98 |
| KU | C1S | 2087296 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2087297 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.09 |
| KU | C1S | 2087298 | 7/2018 | 7/10/2018 | 100.03 | 99.97 | 99.99 |
| KU | C1S | 2087299 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2087300 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.09 |
| KU | C1S | 2087301 | 7/2018 | 7/10/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2087302 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.06 |
| KU | C1S | 2087303 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |
| KU | C1S | 2087304 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.03 |
| KU | C1S | 2087305 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2087306 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.01 |
| KU | C1S | 2087307 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2087308 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100 |
| KU | C1S | 2087309 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2087310 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100.04 |
| KU | C1S | 2087311 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.06 |
| KU | C1S | 2087312 | 7/2018 | 7/10/2018 | 100 | 100 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087313 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.99 |
| KU | C1S | 2087314 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.98 |
| KU | C1S | 2087315 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2087316 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.01 |
| KU | C1S | 2087317 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100 |
| KU | C1S | 2087318 | 7/2018 | 7/10/2018 | 100 | 100.05 | 99.98 |
| KU | C1S | 2087319 | 7/2018 | 7/10/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2087320 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.03 |
| KU | C1S | 2087321 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.02 |
| KU | C1S | 2087322 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2087323 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.03 |
| KU | C1S | 2087324 | 7/2018 | 7/10/2018 | 99.99 | 100.07 | 100.03 |
| KU | C1S | 2087325 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.02 |
| KU | C1S | 2087326 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.01 |
| KU | C1S | 2087327 | 7/2018 | 7/10/2018 | 100.05 | 100.01 | 100 |
| KU | C1S | 2087328 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087329 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100 |
| KU | C1S | 2087330 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100.05 |
| KU | C1S | 2087331 | 7/2018 | 7/10/2018 | 100.04 | 99.98 | 100.01 |
| KU | C1S | 2087332 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 99.99 |
| KU | C1S | 2087333 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2087334 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2087335 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.02 |
| KU | C1S | 2087336 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2087337 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.05 |
| KU | C1S | 2087338 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.08 |
| KU | C1S | 2087339 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.07 |
| KU | C1S | 2087340 | 7/2018 | 7/10/2018 | 99.97 | 100.05 | 100.02 |
| KU | C1S | 2087341 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.01 |
| KU | C1S | 2087342 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2087343 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 100 |
| KU | C1S | 2087344 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2087345 | 7/2018 | 7/10/2018 | 99.97 | 100.06 | 100.09 |
| KU | C1S | 2087346 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.01 |
| KU | C1S | 2087347 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.02 |
| KU | C1S | 2087348 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 100.04 |
| KU | C1S | 2087349 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.07 |
| KU | C1S | 2087350 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 100 |
| KU | C1S | 2087351 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2087352 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2087353 | 7/2018 | 7/10/2018 | 100.03 | 100.06 | 100.07 |
| KU | C1S | 2087354 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 99.99 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087355 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.05 |
| KU | C1S | 2087356 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.01 |
| KU | C1S | 2087357 | 7/2018 | 7/10/2018 | 99.97 | 99.97 | 99.99 |
| KU | C1S | 2087358 | 7/2018 | 7/10/2018 | 100.04 | 100.04 | 100.07 |
| KU | C1S | 2087359 | 7/2018 | 7/10/2018 | 100 | 100 | 100.03 |
| KU | C1S | 2087360 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2087361 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100.05 |
| KU | C1S | 2087362 | 7/2018 | 7/10/2018 | 100.02 | 100.06 | 100.05 |
| KU | C1S | 2087363 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087364 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.06 |
| KU | C1S | 2087365 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2087366 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.04 |
| KU | C1S | 2087367 | 7/2018 | 7/10/2018 | 99.96 | 99.99 | 99.95 |
| KU | C1S | 2087368 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.03 |
| KU | C1S | 2087369 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.07 |
| KU | C1S | 2087370 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.03 |
| KU | C1S | 2087371 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.01 |
| KU | C1S | 2087372 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.03 |
| KU | C1S | 2087373 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.05 |
| KU | C1S | 2087374 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.08 |
| KU | C1S | 2087375 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2087376 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.02 |
| KU | C1S | 2087377 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.06 |
| KU | C1S | 2087378 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100.08 |
| KU | C1S | 2087379 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087380 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100 |
| KU | C1S | 2087381 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100 |
| KU | C1S | 2087382 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.04 |
| KU | C1S | 2087383 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2087384 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100.01 |
| KU | C1S | 2087385 | 7/2018 | 7/10/2018 | 100.04 | 100.03 | 100.08 |
| KU | C1S | 2087386 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.02 |
| KU | C1S | 2087387 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100 |
| KU | C1S | 2087388 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.03 |
| KU | C1S | 2087389 | 7/2018 | 7/10/2018 | 100.04 | 99.96 | 99.98 |
| KU | C1S | 2087390 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.02 |
| KU | C1S | 2087391 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.04 |
| KU | C1S | 2087392 | 7/2018 | 7/10/2018 | 100 | 100.07 | 100.05 |
| KU | C1S | 2087393 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.06 |
| KU | C1S | 2087394 | 7/2018 | 7/10/2018 | 100.02 | 99.94 | 99.96 |
| KU | C1S | 2087395 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2087396 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087397 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.03 |
| KU | C1S | 2087398 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.03 |
| KU | C1S | 2087399 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100.04 |
| KU | C1S | 2087400 | 7/2018 | 7/10/2018 | 100.04 | 100.03 | 100.01 |
| KU | C1S | 2087401 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 99.99 |
| KU | C1S | 2087402 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 99.99 |
| KU | C1S | 2087403 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.03 |
| KU | C1S | 2087404 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2087405 | 7/2018 | 7/10/2018 | 100 | 100.07 | 100.09 |
| KU | C1S | 2087406 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.03 |
| KU | C1S | 2087407 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 99.97 |
| KU | C1S | 2087408 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100.02 |
| KU | C1S | 2087409 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087410 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.01 |
| KU | C1S | 2087411 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2087412 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2087413 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2087414 | 7/2018 | 7/10/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1S | 2087415 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 99.97 |
| KU | C1S | 2087416 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.04 |
| KU | C1S | 2087417 | 7/2018 | 7/10/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2087418 | 7/2018 | 7/10/2018 | 100.02 | 100.06 | 100.07 |
| KU | C1S | 2087419 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.04 |
| KU | C1S | 2087420 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100.02 |
| KU | C1S | 2087421 | 7/2018 | 7/10/2018 | 100.04 | 100 | 100.04 |
| KU | C1S | 2087422 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100.02 |
| KU | C1S | 2087423 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.03 |
| KU | C1S | 2087424 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.09 |
| KU | C1S | 2087425 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2087426 | 7/2018 | 7/10/2018 | 99.97 | 100.07 | 100.09 |
| KU | C1S | 2087427 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.01 |
| KU | C1S | 2087428 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100.05 |
| KU | C1S | 2087429 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.04 |
| KU | C1S | 2087430 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2087431 | 7/2018 | 7/10/2018 | 99.98 | 100.06 | 100.03 |
| KU | C1S | 2087432 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.04 |
| KU | C1S | 2087433 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.03 |
| KU | C1S | 2087434 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100 |
| KU | C1S | 2087435 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.02 |
| KU | C1S | 2087436 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.01 |
| KU | C1S | 2087437 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.03 |
| KU | C1S | 2087438 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.04 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087439 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2087440 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100.03 |
| KU | C1S | 2087441 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2087442 | 7/2018 | 7/10/2018 | 100.06 | 100.03 | 100.01 |
| KU | C1S | 2087443 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.06 |
| KU | C1S | 2087444 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 99.99 |
| KU | C1S | 2087445 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.01 |
| KU | C1S | 2087446 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.07 |
| KU | C1S | 2087447 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2087448 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2087449 | 7/2018 | 7/10/2018 | 99.96 | 100.03 | 100.03 |
| KU | C1S | 2087450 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.09 |
| KU | C1S | 2087451 | 7/2018 | 7/10/2018 | 100.01 | 99.97 | 99.97 |
| KU | C1S | 2087452 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2087453 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2087454 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.02 |
| KU | C1S | 2087455 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2087456 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2087457 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100 |
| KU | C1S | 2087458 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100 |
| KU | C1S | 2087459 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2087460 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 99.98 |
| KU | C1S | 2087461 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087462 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2087463 | 7/2018 | 7/10/2018 | 100.03 | 99.97 | 99.97 |
| KU | C1S | 2087464 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.02 |
| KU | C1S | 2087465 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.94 |
| KU | C1S | 2087466 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.07 |
| KU | C1S | 2087467 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2087468 | 7/2018 | 7/10/2018 | 99.97 | 100 | 99.98 |
| KU | C1S | 2087469 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.03 |
| KU | C1S | 2087470 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.01 |
| KU | C1S | 2087471 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.06 |
| KU | C1S | 2087472 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.03 |
| KU | C1S | 2087473 | 7/2018 | 7/10/2018 | 99.95 | 100.01 | 100.04 |
| KU | C1S | 2087474 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100 |
| KU | C1S | 2087475 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 99.98 |
| KU | C1S | 2087476 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.02 |
| KU | C1S | 2087477 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.01 |
| KU | C1S | 2087478 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.02 |
| KU | C1S | 2087479 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.04 |
| KU | C1S | 2087480 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.99 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087481 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100 |
| KU | C1S | 2087482 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.05 |
| KU | C1S | 2087483 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 100 |
| KU | C1S | 2087484 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100.05 |
| KU | C1S | 2087485 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 99.98 |
| KU | C1S | 2087486 | 7/2018 | 7/10/2018 | 100.02 | 100.1 | 100.05 |
| KU | C1S | 2087487 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.02 |
| KU | C1S | 2087488 | 7/2018 | 7/10/2018 | 100.02 | 100.06 | 100.02 |
| KU | C1S | 2087489 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.98 |
| KU | C1S | 2087490 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2087491 | 7/2018 | 7/10/2018 | 100.02 | 100.07 | 100.05 |
| KU | C1S | 2087492 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.01 |
| KU | C1S | 2087493 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.06 |
| KU | C1S | 2087494 | 7/2018 | 7/10/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2087495 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.01 |
| KU | C1S | 2087496 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.01 |
| KU | C1S | 2087497 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 99.99 |
| KU | C1S | 2087498 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.02 |
| KU | C1S | 2087499 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 99.98 |
| KU | C1S | 2087500 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.07 |
| KU | C1S | 2087501 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 99.99 |
| KU | C1S | 2087502 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.06 |
| KU | C1S | 2087503 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.08 |
| KU | C1S | 2087504 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.04 |
| KU | C1S | 2087505 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2087506 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.1 |
| KU | C1S | 2087507 | 7/2018 | 7/10/2018 | 99.96 | 100 | 100 |
| KU | C1S | 2087508 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2087509 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.02 |
| KU | C1S | 2087510 | 7/2018 | 7/10/2018 | 99.95 | 100.02 | 100.01 |
| KU | C1S | 2087511 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.01 |
| KU | C1S | 2087512 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.04 |
| KU | C1S | 2087513 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.98 |
| KU | C1S | 2087514 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100 |
| KU | C1S | 2087515 | 7/2018 | 7/10/2018 | 100.01 | 100.07 | 100.07 |
| KU | C1S | 2087516 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100 |
| KU | C1S | 2087517 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.03 |
| KU | C1S | 2087518 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.01 |
| KU | C1S | 2087519 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2087520 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.06 |
| KU | C1S | 2087521 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.03 |
| KU | C1S | 2087522 | 7/2018 | 7/10/2018 | 100.05 | 100 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087523 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.01 |
| KU | C1S | 2087524 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 100.05 |
| KU | C1S | 2087525 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.02 |
| KU | C1S | 2087526 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100.03 |
| KU | C1S | 2087527 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087528 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.02 |
| KU | C1S | 2087529 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2087530 | 7/2018 | 7/10/2018 | 100.05 | 100 | 100 |
| KU | C1S | 2087531 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100.03 |
| KU | C1S | 2087532 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 99.98 |
| KU | C1S | 2087533 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.98 |
| KU | C1S | 2087534 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.98 |
| KU | C1S | 2087535 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 99.97 |
| KU | C1S | 2087536 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 100.02 |
| KU | C1S | 2087537 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.04 |
| KU | C1S | 2087538 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2087539 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.02 |
| KU | C1S | 2087540 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 99.98 |
| KU | C1S | 2087541 | 7/2018 | 7/10/2018 | 99.99 | 99.96 | 99.98 |
| KU | C1S | 2087542 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 99.99 |
| KU | C1S | 2087543 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2087544 | 7/2018 | 7/10/2018 | 100.03 | 99.97 | 99.95 |
| KU | C1S | 2087545 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.01 |
| KU | C1S | 2087546 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.02 |
| KU | C1S | 2087547 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 99.97 |
| KU | C1S | 2087548 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2087549 | 7/2018 | 7/10/2018 | 100.04 | 99.95 | 99.98 |
| KU | C1S | 2087550 | 7/2018 | 7/10/2018 | 99.97 | 99.98 | 99.96 |
| KU | C1S | 2087551 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2087552 | 7/2018 | 7/10/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2087553 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.01 |
| KU | C1S | 2087554 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.01 |
| KU | C1S | 2087555 | 7/2018 | 7/10/2018 | 100 | 100.08 | 100.04 |
| KU | C1S | 2087556 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2087557 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.02 |
| KU | C1S | 2087558 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.06 |
| KU | C1S | 2087559 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.01 |
| KU | C1S | 2087560 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.05 |
| KU | C1S | 2087561 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2087562 | 7/2018 | 7/10/2018 | 99.95 | 99.96 | 99.97 |
| KU | C1S | 2087563 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2087564 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087565 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100 |
| KU | C1S | 2087566 | 7/2018 | 7/10/2018 | 100 | 100 | 100 |
| KU | C1S | 2087567 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.06 |
| KU | C1S | 2087568 | 7/2018 | 7/10/2018 | 100.02 | 99.96 | 99.97 |
| KU | C1S | 2087569 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 100.01 |
| KU | C1S | 2087570 | 7/2018 | 7/10/2018 | 99.95 | 99.98 | 99.99 |
| KU | C1S | 2087571 | 7/2018 | 7/10/2018 | 99.97 | 100 | 99.99 |
| KU | C1S | 2087572 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2087573 | 7/2018 | 7/10/2018 | 99.95 | 99.98 | 99.97 |
| KU | C1S | 2087574 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2087575 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2087576 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2087577 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 100.05 |
| KU | C1S | 2087578 | 7/2018 | 7/10/2018 | 99.95 | 100 | 100.02 |
| KU | C1S | 2087579 | 7/2018 | 7/10/2018 | 100.04 | 99.96 | 99.95 |
| KU | C1S | 2087580 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 100 |
| KU | C1S | 2087581 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.03 |
| KU | C1S | 2087582 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.03 |
| KU | C1S | 2087583 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2087584 | 7/2018 | 7/10/2018 | 99.99 | 99.96 | 99.98 |
| KU | C1S | 2087585 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.99 |
| KU | C1S | 2087586 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2087587 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.06 |
| KU | C1S | 2087588 | 7/2018 | 7/10/2018 | 100 | 100 | 100.09 |
| KU | C1S | 2087589 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 99.97 |
| KU | C1S | 2087590 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.98 |
| KU | C1S | 2087591 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.98 |
| KU | C1S | 2087592 | 7/2018 | 7/10/2018 | 100.02 | 100.07 | 100.04 |
| KU | C1S | 2087593 | 7/2018 | 7/10/2018 | 100 | 100 | 100.01 |
| KU | C1S | 2087594 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2087595 | 7/2018 | 7/10/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2087596 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.02 |
| KU | C1S | 2087597 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2087598 | 7/2018 | 7/10/2018 | 100.03 | 99.96 | 99.98 |
| KU | C1S | 2087599 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2087600 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.09 |
| KU | C1S | 2087601 | 7/2018 | 7/10/2018 | 100 | 100 | 100 |
| KU | C1S | 2087602 | 7/2018 | 7/10/2018 | 99.97 | 100.05 | 100.05 |
| KU | C1S | 2087603 | 7/2018 | 7/10/2018 | 99.99 | 100.07 | 100.08 |
| KU | C1S | 2087604 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100 |
| KU | C1S | 2087605 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2087606 | 7/2018 | 7/10/2018 | 100.01 | 99.97 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087607 | 7/2018 | 7/10/2018 | 99.98 | 100.07 | 100.08 |
| KU | C1S | 2087608 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2087609 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.05 |
| KU | C1S | 2087610 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.02 |
| KU | C1S | 2087611 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2087612 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 100 |
| KU | C1S | 2087613 | 7/2018 | 7/10/2018 | 99.97 | 99.98 | 99.98 |
| KU | C1S | 2087614 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.97 |
| KU | C1S | 2087615 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2087616 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.07 |
| KU | C1S | 2087617 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100.02 |
| KU | C1S | 2087618 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.03 |
| KU | C1S | 2087619 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2087620 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 100.01 |
| KU | C1S | 2087621 | 7/2018 | 7/10/2018 | 100.02 | 99.97 | 100.01 |
| KU | C1S | 2087622 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2087623 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.01 |
| KU | C1S | 2087624 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2087625 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 99.99 |
| KU | C1S | 2087626 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.05 |
| KU | C1S | 2087627 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.02 |
| KU | C1S | 2087628 | 7/2018 | 7/10/2018 | 100 | 100 | 100 |
| KU | C1S | 2087629 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 100 |
| KU | C1S | 2087630 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 99.99 |
| KU | C1S | 2087631 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.02 |
| KU | C1S | 2087632 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2087633 | 7/2018 | 7/10/2018 | 99.96 | 99.98 | 99.98 |
| KU | C1S | 2087634 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2087635 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.06 |
| KU | C1S | 2087636 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2087637 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.02 |
| KU | C1S | 2087638 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.98 |
| KU | C1S | 2087639 | 7/2018 | 7/10/2018 | 99.98 | 99.96 | 99.98 |
| KU | C1S | 2087640 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.01 |
| KU | C1S | 2087641 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.97 |
| KU | C1S | 2087642 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 99.98 |
| KU | C1S | 2087643 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 100.01 |
| KU | C1S | 2087644 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100 |
| KU | C1S | 2087645 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 100 |
| KU | C1S | 2087646 | 7/2018 | 7/10/2018 | 100 | 99.98 | 100.06 |
| KU | C1S | 2087647 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100.02 |
| KU | C1S | 2087648 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087649 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.01 |
| KU | C1S | 2087650 | 7/2018 | 7/10/2018 | 100.04 | 100 | 100.02 |
| KU | C1S | 2087651 | 7/2018 | 7/10/2018 | 99.99 | 99.96 | 99.98 |
| KU | C1S | 2087652 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2087653 | 7/2018 | 7/10/2018 | 100.03 | 99.98 | 100.06 |
| KU | C1S | 2087654 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.04 |
| KU | C1S | 2087655 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 100.01 |
| KU | C1S | 2087656 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.02 |
| KU | C1S | 2087657 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.02 |
| KU | C1S | 2087658 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.04 |
| KU | C1S | 2087659 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.11 |
| KU | C1S | 2087660 | 7/2018 | 7/10/2018 | 100.04 | 100.05 | 100.04 |
| KU | C1S | 2087661 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 99.97 |
| KU | C1S | 2087662 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2087663 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.02 |
| KU | C1S | 2087664 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2087665 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.08 |
| KU | C1S | 2087666 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.01 |
| KU | C1S | 2087667 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2087668 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2087669 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 100 |
| KU | C1S | 2087670 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.06 |
| KU | C1S | 2087671 | 7/2018 | 7/10/2018 | 100.01 | 99.96 | 99.98 |
| KU | C1S | 2087672 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.1 |
| KU | C1S | 2087673 | 7/2018 | 7/10/2018 | 100.02 | 100.06 | 100.02 |
| KU | C1S | 2087674 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 99.99 |
| KU | C1S | 2087675 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.97 |
| KU | C1S | 2087676 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.07 |
| KU | C1S | 2087677 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.03 |
| KU | C1S | 2087678 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.03 |
| KU | C1S | 2087679 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.01 |
| KU | C1S | 2087680 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2087681 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.01 |
| KU | C1S | 2087682 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100.04 |
| KU | C1S | 2087683 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2087684 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 99.99 |
| KU | C1S | 2087685 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2087686 | 7/2018 | 7/10/2018 | 100.04 | 100.03 | 100.02 |
| KU | C1S | 2087687 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.02 |
| KU | C1S | 2087688 | 7/2018 | 7/10/2018 | 99.96 | 100.02 | 100.02 |
| KU | C1S | 2087689 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |
| KU | C1S | 2087690 | 7/2018 | 7/10/2018 | 99.98 | 100 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087691 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2087692 | 7/2018 | 7/10/2018 | 100.04 | 99.95 | 99.98 |
| KU | C1S | 2087693 | 7/2018 | 7/10/2018 | 99.95 | 99.99 | 100.01 |
| KU | C1S | 2087694 | 7/2018 | 7/10/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2087695 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.01 |
| KU | C1S | 2087696 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.04 |
| KU | C1S | 2087697 | 7/2018 | 7/10/2018 | 99.95 | 99.96 | 99.95 |
| KU | C1S | 2087698 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 99.97 |
| KU | C1S | 2087699 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.04 |
| KU | C1S | 2087700 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.02 |
| KU | C1S | 2087701 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100 |
| KU | C1S | 2087702 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2087703 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.02 |
| KU | C1S | 2087704 | 7/2018 | 7/10/2018 | 100 | 100 | 100.01 |
| KU | C1S | 2087705 | 7/2018 | 7/10/2018 | 99.96 | 99.97 | 99.98 |
| KU | C1S | 2087706 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.09 |
| KU | C1S | 2087707 | 7/2018 | 7/10/2018 | 100 | 99.95 | 99.97 |
| KU | C1S | 2087708 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2087709 | 7/2018 | 7/10/2018 | 100 | 100.02 | 99.99 |
| KU | C1S | 2087710 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.03 |
| KU | C1S | 2087711 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.99 |
| KU | C1S | 2087712 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2087713 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 100.01 |
| KU | C1S | 2087714 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2087715 | 7/2018 | 7/10/2018 | 100 | 100 | 100.02 |
| KU | C1S | 2087716 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.06 |
| KU | C1S | 2087717 | 7/2018 | 7/10/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1S | 2087718 | 7/2018 | 7/10/2018 | 100.04 | 100.01 | 99.98 |
| KU | C1S | 2087719 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 99.99 |
| KU | C1S | 2087720 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.02 |
| KU | C1S | 2087721 | 7/2018 | 7/10/2018 | 99.97 | 99.97 | 99.96 |
| KU | C1S | 2087722 | 7/2018 | 7/10/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1S | 2087723 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.08 |
| KU | C1S | 2087724 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 99.97 |
| KU | C1S | 2087725 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.06 |
| KU | C1S | 2087726 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.94 |
| KU | C1S | 2087727 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2087728 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.11 |
| KU | C1S | 2087729 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 99.99 |
| KU | C1S | 2087730 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2087731 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2087732 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087733 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2087734 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2087735 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.99 |
| KU | C1S | 2087736 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 99.99 |
| KU | C1S | 2087737 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 100.05 |
| KU | C1S | 2087738 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1S | 2087739 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.03 |
| KU | C1S | 2087740 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.02 |
| KU | C1S | 2087741 | 7/2018 | 7/10/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2087742 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2087743 | 7/2018 | 7/10/2018 | 100.05 | 99.93 | 99.96 |
| KU | C1S | 2087744 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 99.98 |
| KU | C1S | 2087745 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100.08 |
| KU | C1S | 2087746 | 7/2018 | 7/10/2018 | 100 | 100 | 100 |
| KU | C1S | 2087747 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2087748 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.02 |
| KU | C1S | 2087749 | 7/2018 | 7/10/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1S | 2087750 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100 |
| KU | C1S | 2087751 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.04 |
| KU | C1S | 2087752 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2087753 | 7/2018 | 7/10/2018 | 99.96 | 99.99 | 100.01 |
| KU | C1S | 2087754 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.02 |
| KU | C1S | 2087755 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087756 | 7/2018 | 7/10/2018 | 100.02 | 99.95 | 99.98 |
| KU | C1S | 2087757 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 99.96 |
| KU | C1S | 2087758 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.01 |
| KU | C1S | 2087759 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2087760 | 7/2018 | 7/10/2018 | 99.96 | 100.04 | 100.02 |
| KU | C1S | 2087761 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2087762 | 7/2018 | 7/10/2018 | 99.95 | 100.03 | 100.1 |
| KU | C1S | 2087763 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2087764 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.09 |
| KU | C1S | 2087765 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2087766 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.05 |
| KU | C1S | 2087767 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100 |
| KU | C1S | 2087768 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2087769 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.08 |
| KU | C1S | 2087770 | 7/2018 | 7/10/2018 | 100.04 | 99.98 | 99.99 |
| KU | C1S | 2087771 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 99.91 |
| KU | C1S | 2087772 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.09 |
| KU | C1S | 2087773 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2087774 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087775 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.02 |
| KU | C1S | 2087776 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2087777 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 99.99 |
| KU | C1S | 2087778 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 99.98 |
| KU | C1S | 2087779 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.01 |
| KU | C1S | 2087780 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2087781 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.07 |
| KU | C1S | 2087782 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 99.97 |
| KU | C1S | 2087783 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2087784 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2087785 | 7/2018 | 7/10/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2087786 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2087787 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.95 |
| KU | C1S | 2087788 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2087789 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2087790 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2087791 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.01 |
| KU | C1S | 2087792 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2087793 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.06 |
| KU | C1S | 2087794 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2087795 | 7/2018 | 7/10/2018 | 100.04 | 100 | 100.01 |
| KU | C1S | 2087796 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100.05 |
| KU | C1S | 2087797 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2087798 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.07 |
| KU | C1S | 2087799 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2087800 | 7/2018 | 7/10/2018 | 99.96 | 100.03 | 100.06 |
| KU | C1S | 2087801 | 7/2018 | 7/10/2018 | 100.05 | 100.05 | 100.04 |
| KU | C1S | 2087802 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.02 |
| KU | C1S | 2087803 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100 |
| KU | C1S | 2087804 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.05 |
| KU | C1S | 2087805 | 7/2018 | 7/10/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2087806 | 7/2018 | 7/10/2018 | 99.95 | 100.01 | 100.01 |
| KU | C1S | 2087807 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100 |
| KU | C1S | 2087808 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2087809 | 7/2018 | 7/10/2018 | 99.96 | 99.99 | 99.98 |
| KU | C1S | 2087810 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087811 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.06 |
| KU | C1S | 2087812 | 7/2018 | 7/10/2018 | 100.04 | 100.01 | 99.99 |
| KU | C1S | 2087813 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100 |
| KU | C1S | 2087814 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.11 |
| KU | C1S | 2087815 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.02 |
| KU | C1S | 2087816 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087817 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.04 |
| KU | C1S | 2087818 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2087819 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2087820 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.04 |
| KU | C1S | 2087821 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.07 |
| KU | C1S | 2087822 | 7/2018 | 7/10/2018 | 99.96 | 100.02 | 100.03 |
| KU | C1S | 2087823 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 99.99 |
| KU | C1S | 2087824 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.05 |
| KU | C1S | 2087825 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2087826 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.02 |
| KU | C1S | 2087827 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.99 |
| KU | C1S | 2087828 | 7/2018 | 7/10/2018 | 100 | 99.96 | 99.99 |
| KU | C1S | 2087829 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2087830 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2087831 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 99.95 |
| KU | C1S | 2087832 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100.01 |
| KU | C1S | 2087833 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.99 |
| KU | C1S | 2087834 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100.02 |
| KU | C1S | 2087835 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2087836 | 7/2018 | 7/10/2018 | 99.96 | 100.06 | 100.07 |
| KU | C1S | 2087837 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2087838 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2087839 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.05 |
| KU | C1S | 2087840 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2087841 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 99.97 |
| KU | C1S | 2087842 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.97 |
| KU | C1S | 2087843 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.08 |
| KU | C1S | 2087844 | 7/2018 | 7/10/2018 | 99.97 | 100.04 | 100.07 |
| KU | C1S | 2087845 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.01 |
| KU | C1S | 2087846 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 99.99 |
| KU | C1S | 2087847 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.06 |
| KU | C1S | 2087848 | 7/2018 | 7/10/2018 | 100.05 | 100.02 | 100.02 |
| KU | C1S | 2087849 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2087850 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100.01 |
| KU | C1S | 2087851 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.98 |
| KU | C1S | 2087852 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 100.02 |
| KU | C1S | 2087853 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2087854 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.01 |
| KU | C1S | 2087855 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.06 |
| KU | C1S | 2087856 | 7/2018 | 7/10/2018 | 100.05 | 99.98 | 99.98 |
| KU | C1S | 2087857 | 7/2018 | 7/10/2018 | 99.98 | 100 | 100 |
| KU | C1S | 2087858 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087859 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2087860 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.03 |
| KU | C1S | 2087861 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.02 |
| KU | C1S | 2087862 | 7/2018 | 7/10/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2087863 | 7/2018 | 7/10/2018 | 99.97 | 100 | 100.03 |
| KU | C1S | 2087864 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 100 |
| KU | C1S | 2087865 | 7/2018 | 7/10/2018 | 99.99 | 100.07 | 100.09 |
| KU | C1S | 2087866 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.07 |
| KU | C1S | 2087867 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2087868 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.01 |
| KU | C1S | 2087869 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100 |
| KU | C1S | 2087870 | 7/2018 | 7/10/2018 | 100.04 | 100 | 100 |
| KU | C1S | 2087871 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2087872 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.06 |
| KU | C1S | 2087873 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2087874 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100 |
| KU | C1S | 2087875 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.02 |
| KU | C1S | 2087876 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.1 |
| KU | C1S | 2087877 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2087878 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2087879 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100 |
| KU | C1S | 2087880 | 7/2018 | 7/10/2018 | 100 | 100.07 | 100.08 |
| KU | C1S | 2087881 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.98 |
| KU | C1S | 2087882 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.06 |
| KU | C1S | 2087883 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.03 |
| KU | C1S | 2087884 | 7/2018 | 7/10/2018 | 100 | 100.04 | 99.99 |
| KU | C1S | 2087885 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.05 |
| KU | C1S | 2087886 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.02 |
| KU | C1S | 2087887 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.99 |
| KU | C1S | 2087888 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.05 |
| KU | C1S | 2087889 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2087890 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.02 |
| KU | C1S | 2087891 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.02 |
| KU | C1S | 2087892 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.03 |
| KU | C1S | 2087893 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100 |
| KU | C1S | 2087894 | 7/2018 | 7/10/2018 | 99.95 | 100.03 | 100.05 |
| KU | C1S | 2087895 | 7/2018 | 7/10/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2087896 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 100.07 |
| KU | C1S | 2087897 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2087898 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.05 |
| KU | C1S | 2087899 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.99 |
| KU | C1S | 2087900 | 7/2018 | 7/10/2018 | 100.02 | 100.07 | 100.08 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087901 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.03 |
| KU | C1S | 2087902 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2087903 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.02 |
| KU | C1S | 2087904 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2087905 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.05 |
| KU | C1S | 2087906 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.01 |
| KU | C1S | 2087907 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.08 |
| KU | C1S | 2087908 | 7/2018 | 7/10/2018 | 100 | 100 | 100 |
| KU | C1S | 2087909 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.08 |
| KU | C1S | 2087910 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.02 |
| KU | C1S | 2087911 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2087912 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.01 |
| KU | C1S | 2087913 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2087914 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.01 |
| KU | C1S | 2087915 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.09 |
| KU | C1S | 2087916 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.07 |
| KU | C1S | 2087917 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.97 |
| KU | C1S | 2087918 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.06 |
| KU | C1S | 2087919 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.02 |
| KU | C1S | 2087920 | 7/2018 | 7/10/2018 | 100.03 | 100.07 | 100.06 |
| KU | C1S | 2087921 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2087922 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.03 |
| KU | C1S | 2087923 | 7/2018 | 7/10/2018 | 100.03 | 99.95 | 99.95 |
| KU | C1S | 2087924 | 7/2018 | 7/10/2018 | 100.04 | 100.01 | 99.99 |
| KU | C1S | 2087925 | 7/2018 | 7/10/2018 | 100.04 | 99.98 | 99.97 |
| KU | C1S | 2087926 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2087927 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2087928 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 100.01 |
| KU | C1S | 2087929 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1S | 2087930 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 100.03 |
| KU | C1S | 2087931 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.04 |
| KU | C1S | 2087932 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2087933 | 7/2018 | 7/10/2018 | 100.04 | 100.06 | 100.06 |
| KU | C1S | 2087934 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100 |
| KU | C1S | 2087935 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100.01 |
| KU | C1S | 2087936 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.02 |
| KU | C1S | 2087937 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.01 |
| KU | C1S | 2087938 | 7/2018 | 7/10/2018 | 99.98 | 100.07 | 100.04 |
| KU | C1S | 2087939 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.96 |
| KU | C1S | 2087940 | 7/2018 | 7/10/2018 | 99.97 | 99.97 | 99.99 |
| KU | C1S | 2087941 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.05 |
| KU | C1S | 2087942 | 7/2018 | 7/10/2018 | 99.94 | 99.99 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087943 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 99.99 |
| KU | C1S | 2087944 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2087945 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.03 |
| KU | C1S | 2087946 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2087947 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100 |
| KU | C1S | 2087948 | 7/2018 | 7/10/2018 | 100.01 | 99.96 | 99.96 |
| KU | C1S | 2087949 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2087950 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 100.01 |
| KU | C1S | 2087951 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.05 |
| KU | C1S | 2087952 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.04 |
| KU | C1S | 2087953 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2087954 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |
| KU | C1S | 2087955 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.02 |
| KU | C1S | 2087956 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2087957 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.09 |
| KU | C1S | 2087958 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.05 |
| KU | C1S | 2087959 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2087960 | 7/2018 | 7/10/2018 | 99.97 | 100.06 | 100.04 |
| KU | C1S | 2087961 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 100.01 |
| KU | C1S | 2087962 | 7/2018 | 7/10/2018 | 99.95 | 100 | 99.99 |
| KU | C1S | 2087963 | 7/2018 | 7/10/2018 | 99.94 | 100 | 99.98 |
| KU | C1S | 2087964 | 7/2018 | 7/10/2018 | 99.99 | 99.97 | 100.06 |
| KU | C1S | 2087965 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100 |
| KU | C1S | 2087966 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2087967 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100 |
| KU | C1S | 2087968 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100 |
| KU | C1S | 2087969 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2087970 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 100 |
| KU | C1S | 2087971 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.05 |
| KU | C1S | 2087972 | 7/2018 | 7/10/2018 | 100.03 | 100 | 99.99 |
| KU | C1S | 2087973 | 7/2018 | 7/10/2018 | 99.94 | 99.99 | 99.97 |
| KU | C1S | 2087974 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.06 |
| KU | C1S | 2087975 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2087976 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.03 |
| KU | C1S | 2087977 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.09 |
| KU | C1S | 2087978 | 7/2018 | 7/10/2018 | 100.03 | 99.96 | 99.99 |
| KU | C1S | 2087979 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.02 |
| KU | C1S | 2087980 | 7/2018 | 7/10/2018 | 99.97 | 100.03 | 100.05 |
| KU | C1S | 2087981 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2087982 | 7/2018 | 7/10/2018 | 100.03 | 100 | 99.97 |
| KU | C1S | 2087983 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.01 |
| KU | C1S | 2087984 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.07 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2087985 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.04 |
| KU | C1S | 2087986 | 7/2018 | 7/10/2018 | 99.98 | 99.96 | 99.99 |
| KU | C1S | 2087987 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2087988 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2087989 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100 |
| KU | C1S | 2087990 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100 |
| KU | C1S | 2087991 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.05 |
| KU | C1S | 2087992 | 7/2018 | 7/10/2018 | 99.97 | 99.97 | 100.01 |
| KU | C1S | 2087993 | 7/2018 | 7/10/2018 | 100 | 100.04 | 99.97 |
| KU | C1S | 2087994 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 100.01 |
| KU | C1S | 2087995 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.02 |
| KU | C1S | 2087996 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100 |
| KU | C1S | 2087997 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.05 |
| KU | C1S | 2087998 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.03 |
| KU | C1S | 2087999 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2088000 | 7/2018 | 7/10/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2088001 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.11 |
| KU | C1S | 2088002 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 99.98 |
| KU | C1S | 2088003 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100 |
| KU | C1S | 2088004 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100.07 |
| KU | C1S | 2088005 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.98 |
| KU | C1S | 2088006 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2088007 | 7/2018 | 7/10/2018 | 100.01 | 100.06 | 100.08 |
| KU | C1S | 2088008 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 100 |
| KU | C1S | 2088009 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2088010 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 99.99 |
| KU | C1S | 2088011 | 7/2018 | 7/10/2018 | 99.98 | 99.96 | 100.06 |
| KU | C1S | 2088012 | 7/2018 | 7/10/2018 | 100.04 | 100.05 | 100.02 |
| KU | C1S | 2088013 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2088014 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 100.02 |
| KU | C1S | 2088015 | 7/2018 | 7/10/2018 | 99.96 | 100 | 99.98 |
| KU | C1S | 2088016 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2088017 | 7/2018 | 7/10/2018 | 100 | 99.99 | 100 |
| KU | C1S | 2088018 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.04 |
| KU | C1S | 2088019 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.04 |
| KU | C1S | 2088020 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2088021 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2088022 | 7/2018 | 7/10/2018 | 100.02 | 99.96 | 100 |
| KU | C1S | 2088023 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100 |
| KU | C1S | 2088024 | 7/2018 | 7/10/2018 | 99.97 | 99.99 | 99.99 |
| KU | C1S | 2088025 | 7/2018 | 7/10/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2088026 | 7/2018 | 7/10/2018 | 99.98 | 99.94 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2088027 | 7/2018 | 7/10/2018 | 100.04 | 99.97 | 99.95 |
| KU | C1S | 2088028 | 7/2018 | 7/10/2018 | 100.03 | 99.96 | 99.95 |
| KU | C1S | 2088029 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2088030 | 7/2018 | 7/10/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088031 | 7/2018 | 7/10/2018 | 99.96 | 99.95 | 99.98 |
| KU | C1S | 2088032 | 7/2018 | 7/10/2018 | 100.04 | 100.04 | 100.04 |
| KU | C1S | 2088033 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2088034 | 7/2018 | 7/10/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2088035 | 7/2018 | 7/10/2018 | 100.03 | 100.08 | 100.07 |
| KU | C1S | 2088036 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 99.99 |
| KU | C1S | 2088037 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2088038 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2088039 | 7/2018 | 7/10/2018 | 100.07 | 100.05 | 100.06 |
| KU | C1S | 2088040 | 7/2018 | 7/10/2018 | 99.96 | 100.03 | 99.98 |
| KU | C1S | 2088041 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100.06 |
| KU | C1S | 2088042 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2088043 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 99.98 |
| KU | C1S | 2088044 | 7/2018 | 7/10/2018 | 100.02 | 100.04 | 100.05 |
| KU | C1S | 2088045 | 7/2018 | 7/10/2018 | 99.96 | 99.97 | 99.98 |
| KU | C1S | 2088046 | 7/2018 | 7/10/2018 | 100 | 100.02 | 99.98 |
| KU | C1S | 2088047 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.05 |
| KU | C1S | 2088048 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 99.99 |
| KU | C1S | 2088049 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088050 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2088051 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2088052 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 99.99 |
| KU | C1S | 2088053 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2088054 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2088055 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.02 |
| KU | C1S | 2088056 | 7/2018 | 7/10/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2088057 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 99.99 |
| KU | C1S | 2088058 | 7/2018 | 7/10/2018 | 100 | 100.02 | 99.98 |
| KU | C1S | 2088059 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.02 |
| KU | C1S | 2088060 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 100.01 |
| KU | C1S | 2088061 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.06 |
| KU | C1S | 2088062 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.05 |
| KU | C1S | 2088063 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.99 |
| KU | C1S | 2088064 | 7/2018 | 7/10/2018 | 100.02 | 100.06 | 100.07 |
| KU | C1S | 2088065 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2088066 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.03 |
| KU | C1S | 2088067 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100.03 |
| KU | C1S | 2088068 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2088069 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 100 |
| KU | C1S | 2088070 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.03 |
| KU | C1S | 2088071 | 7/2018 | 7/10/2018 | 100 | 100.03 | 99.98 |
| KU | C1S | 2088072 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2088073 | 7/2018 | 7/10/2018 | 100.05 | 100.02 | 100.02 |
| KU | C1S | 2088074 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100.1 |
| KU | C1S | 2088075 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 99.99 |
| KU | C1S | 2088076 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.99 |
| KU | C1S | 2088077 | 7/2018 | 7/10/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1S | 2088078 | 7/2018 | 7/10/2018 | 100.02 | 100.03 | 100 |
| KU | C1S | 2088079 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.06 |
| KU | C1S | 2088080 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.03 |
| KU | C1S | 2088081 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.1 |
| KU | C1S | 2088082 | 7/2018 | 7/10/2018 | 100.03 | 100.04 | 100.08 |
| KU | C1S | 2088083 | 7/2018 | 7/10/2018 | 100.04 | 100 | 100.01 |
| KU | C1S | 2088084 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.02 |
| KU | C1S | 2088085 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100 |
| KU | C1S | 2088086 | 7/2018 | 7/10/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2088087 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.08 |
| KU | C1S | 2088088 | 7/2018 | 7/10/2018 | 100 | 99.95 | 99.99 |
| KU | C1S | 2088089 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 99.99 |
| KU | C1S | 2088090 | 7/2018 | 7/10/2018 | 99.97 | 100.02 | 100.01 |
| KU | C1S | 2088091 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |
| KU | C1S | 2088092 | 7/2018 | 7/10/2018 | 99.96 | 100.04 | 100.02 |
| KU | C1S | 2088093 | 7/2018 | 7/10/2018 | 100.03 | 100.05 | 100.1 |
| KU | C1S | 2088094 | 7/2018 | 7/10/2018 | 100 | 100.02 | 99.99 |
| KU | C1S | 2088095 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100 |
| KU | C1S | 2088096 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2088097 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.03 |
| KU | C1S | 2088098 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2088099 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.02 |
| KU | C1S | 2088100 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2088101 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2088102 | 7/2018 | 7/10/2018 | 100.01 | 99.95 | 99.97 |
| KU | C1S | 2088103 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100 |
| KU | C1S | 2088104 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100 |
| KU | C1S | 2088105 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.05 |
| KU | C1S | 2088106 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.01 |
| KU | C1S | 2088107 | 7/2018 | 7/10/2018 | 100.01 | 100.03 | 100.04 |
| KU | C1S | 2088108 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.99 |
| KU | C1S | 2088109 | 7/2018 | 7/10/2018 | 100.02 | 100 | 100.01 |
| KU | C1S | 2088110 | 7/2018 | 7/10/2018 | 100.03 | 99.99 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2088111 | 7/2018 | 7/10/2018 | 99.99 | 100.03 | 99.99 |
| KU | C1S | 2088112 | 7/2018 | 7/10/2018 | 100.04 | 100.02 | 99.99 |
| KU | C1S | 2088113 | 7/2018 | 7/10/2018 | 100.05 | 100.03 | 100 |
| KU | C1S | 2088114 | 7/2018 | 7/10/2018 | 100 | 100.01 | 99.98 |
| KU | C1S | 2088115 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.04 |
| KU | C1S | 2088116 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2088117 | 7/2018 | 7/10/2018 | 99.96 | 100.02 | 100.01 |
| KU | C1S | 2088118 | 7/2018 | 7/10/2018 | 100.01 | 99.98 | 100 |
| KU | C1S | 2088119 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2088120 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 100.01 |
| KU | C1S | 2088121 | 7/2018 | 7/10/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2088122 | 7/2018 | 7/10/2018 | 99.98 | 99.96 | 99.96 |
| KU | C1S | 2088123 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100.04 |
| KU | C1S | 2088124 | 7/2018 | 7/10/2018 | 100 | 100.06 | 100.04 |
| KU | C1S | 2088125 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2088126 | 7/2018 | 7/10/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2088127 | 7/2018 | 7/10/2018 | 99.96 | 100.01 | 99.99 |
| KU | C1S | 2088128 | 7/2018 | 7/10/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2088129 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100.04 |
| KU | C1S | 2088130 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2088131 | 7/2018 | 7/10/2018 | 100.02 | 100.05 | 100.06 |
| KU | C1S | 2088132 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.01 |
| KU | C1S | 2088133 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.02 |
| KU | C1S | 2088134 | 7/2018 | 7/10/2018 | 99.96 | 100.07 | 100.08 |
| KU | C1S | 2088135 | 7/2018 | 7/10/2018 | 99.98 | 100.05 | 100.02 |
| KU | C1S | 2088136 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.02 |
| KU | C1S | 2088137 | 7/2018 | 7/10/2018 | 100.02 | 99.99 | 100.02 |
| KU | C1S | 2088138 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 100 |
| KU | C1S | 2088139 | 7/2018 | 7/10/2018 | 100.02 | 100 | 99.99 |
| KU | C1S | 2088140 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.05 |
| KU | C1S | 2088141 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100 |
| KU | C1S | 2088142 | 7/2018 | 7/10/2018 | 99.97 | 100.01 | 100.05 |
| KU | C1S | 2088143 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100 |
| KU | C1S | 2088144 | 7/2018 | 7/10/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2088145 | 7/2018 | 7/10/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088146 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100 |
| KU | C1S | 2088147 | 7/2018 | 7/10/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2088148 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100.01 |
| KU | C1S | 2088149 | 7/2018 | 7/10/2018 | 99.98 | 100.03 | 100 |
| KU | C1S | 2088150 | 7/2018 | 7/10/2018 | 100.04 | 100.05 | 100 |
| KU | C1S | 2088151 | 7/2018 | 7/10/2018 | 100.01 | 100.02 | 99.98 |
| KU | C1S | 2088152 | 7/2018 | 7/10/2018 | 100.03 | 100.01 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|--------|-----------|--------|--------|--------|
| KU | C1S | 2088153 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.06 |
| KU | C1S | 2088154 | 7/2018 | 7/10/2018 | 100 | 100.06 | 99.99 |
| KU | C1S | 2088155 | 7/2018 | 7/10/2018 | 100.03 | 100.03 | 99.99 |
| KU | C1S | 2088156 | 7/2018 | 7/10/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2088157 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.03 |
| KU | C1S | 2088158 | 7/2018 | 7/10/2018 | 100 | 100.01 | 100.06 |
| KU | C1S | 2088159 | 7/2018 | 7/10/2018 | 99.95 | 100.08 | 100.05 |
| KU | C1S | 2088160 | 7/2018 | 7/10/2018 | 100.01 | 100.04 | 100 |
| KU | C1S | 2088161 | 7/2018 | 7/10/2018 | 99.99 | 100.05 | 100.04 |
| KU | C1S | 2088162 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100 |
| KU | C1S | 2088163 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.06 |
| KU | C1S | 2088164 | 7/2018 | 7/10/2018 | 99.98 | 100.04 | 100.05 |
| KU | C1S | 2088165 | 7/2018 | 7/10/2018 | 100 | 100 | 100.02 |
| KU | C1S | 2088166 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.05 |
| KU | C1S | 2088167 | 7/2018 | 7/10/2018 | 99.99 | 100.04 | 100.08 |
| KU | C1S | 2088168 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 100 |
| KU | C1S | 2088169 | 7/2018 | 7/10/2018 | 100.05 | 100.01 | 99.97 |
| KU | C1S | 2088170 | 7/2018 | 7/10/2018 | 99.99 | 100.01 | 100.04 |
| KU | C1S | 2088171 | 7/2018 | 7/10/2018 | 100 | 100.05 | 100.02 |
| KU | C1S | 2088172 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.03 |
| KU | C1S | 2088173 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.03 |
| KU | C1S | 2088174 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 100 |
| KU | C1S | 2088175 | 7/2018 | 7/10/2018 | 100 | 100.04 | 100.05 |
| KU | C1S | 2088176 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.02 |
| KU | C1S | 2088177 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.03 |
| KU | C1S | 2088178 | 7/2018 | 7/10/2018 | 99.99 | 100.08 | 100.1 |
| KU | C1S | 2088179 | 7/2018 | 7/10/2018 | 99.97 | 100.08 | 100.04 |
| KU | C1S | 2088180 | 7/2018 | 7/10/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2088181 | 7/2018 | 7/10/2018 | 100.01 | 100.01 | 100.06 |
| KU | C1S | 2088182 | 7/2018 | 7/10/2018 | 99.95 | 99.98 | 99.99 |
| KU | C1S | 2088183 | 7/2018 | 7/10/2018 | 99.99 | 100.06 | 100.03 |
| KU | C1S | 2088184 | 7/2018 | 7/10/2018 | 100.01 | 100.05 | 100.01 |
| KU | C1S | 2088185 | 7/2018 | 7/10/2018 | 100.02 | 100.01 | 100.03 |
| KU | C1S | 2088186 | 7/2018 | 7/10/2018 | 100.02 | 100.02 | 99.99 |
| KU | C1S | 2088187 | 7/2018 | 7/10/2018 | 100.03 | 100.02 | 100.02 |
| KU | C1S | 2088188 | 7/2018 | 7/10/2018 | 100.01 | 100 | 100.01 |
| KU | C1S | 2088189 | 7/2018 | 7/10/2018 | 100 | 100.03 | 100.02 |
| KU | C1S | 2088190 | 7/2018 | 7/10/2018 | 100.01 | 99.99 | 100.01 |
| KU | C1S | 2088191 | 7/2018 | 7/10/2018 | 100.01 | 100.07 | 100.02 |
| KU | C1S | 2088192 | 7/2018 | 7/10/2018 | 99.98 | 100.01 | 100.01 |
| KU | C1S | 2088193 | 7/2018 | 7/10/2018 | 100.02 | 100.07 | 100.07 |
| KU | C1S | 2088194 | 7/2018 | 7/10/2018 | 99.99 | 100.02 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088195 | 7/2018 | 7/10/2018 | 99.98 | 100.02 | 99.99 |
| KU | C1S | 2088196 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2088197 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2088198 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088199 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.9 |
| KU | C1S | 2088200 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.93 |
| KU | C1S | 2088201 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2088202 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2088203 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.88 |
| KU | C1S | 2088204 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.95 |
| KU | C1S | 2088205 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.96 |
| KU | C1S | 2088206 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2088207 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.89 |
| KU | C1S | 2088208 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.91 |
| KU | C1S | 2088209 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088210 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2088211 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2088212 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.89 |
| KU | C1S | 2088213 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.92 |
| KU | C1S | 2088214 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.89 |
| KU | C1S | 2088215 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.94 |
| KU | C1S | 2088216 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.91 |
| KU | C1S | 2088217 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2088218 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.88 |
| KU | C1S | 2088219 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.95 |
| KU | C1S | 2088220 | 10/2018 | 10/12/2018 | 99.96 | 100.01 | 99.95 |
| KU | C1S | 2088221 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2088222 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2088223 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.94 |
| KU | C1S | 2088224 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.89 |
| KU | C1S | 2088225 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.9 |
| KU | C1S | 2088226 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.93 |
| KU | C1S | 2088227 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2088228 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.9 |
| KU | C1S | 2088229 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.89 |
| KU | C1S | 2088230 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2088231 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.89 |
| KU | C1S | 2088232 | 10/2018 | 10/12/2018 | 100.05 | 99.97 | 99.95 |
| KU | C1S | 2088233 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.92 |
| KU | C1S | 2088234 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.94 |
| KU | C1S | 2088235 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088236 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088237 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2088238 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2088239 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2088240 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2088241 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.93 |
| KU | C1S | 2088242 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.99 |
| KU | C1S | 2088243 | 10/2018 | 10/12/2018 | 100.04 | 100 | 99.94 |
| KU | C1S | 2088244 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2088245 | 10/2018 | 10/12/2018 | 100.01 | 99.92 | 99.93 |
| KU | C1S | 2088246 | 10/2018 | 10/12/2018 | 99.97 | 99.93 | 99.93 |
| KU | C1S | 2088247 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2088248 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.93 |
| KU | C1S | 2088249 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.99 |
| KU | C1S | 2088250 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2088251 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.92 |
| KU | C1S | 2088252 | 10/2018 | 10/12/2018 | 100.02 | 99.9 | 99.9 |
| KU | C1S | 2088253 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.87 |
| KU | C1S | 2088254 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.95 |
| KU | C1S | 2088255 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.99 |
| KU | C1S | 2088256 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.93 |
| KU | C1S | 2088257 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2088258 | 10/2018 | 10/12/2018 | 100.03 | 99.94 | 99.93 |
| KU | C1S | 2088259 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.95 |
| KU | C1S | 2088260 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 100.02 |
| KU | C1S | 2088261 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.93 |
| KU | C1S | 2088262 | 10/2018 | 10/12/2018 | 100 | 100.05 | 99.97 |
| KU | C1S | 2088263 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1S | 2088264 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1S | 2088265 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2088266 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088267 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100 |
| KU | C1S | 2088268 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.91 |
| KU | C1S | 2088269 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.94 |
| KU | C1S | 2088270 | 10/2018 | 10/12/2018 | 100.03 | 99.93 | 99.9 |
| KU | C1S | 2088271 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.96 |
| KU | C1S | 2088272 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.92 |
| KU | C1S | 2088273 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2088274 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2088275 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2088276 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.97 |
| KU | C1S | 2088277 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.89 |
| KU | C1S | 2088278 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088279 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2088280 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1S | 2088281 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2088282 | 10/2018 | 10/12/2018 | 100.02 | 99.9 | 99.87 |
| KU | C1S | 2088283 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.93 |
| KU | C1S | 2088284 | 10/2018 | 10/12/2018 | 99.95 | 99.96 | 99.93 |
| KU | C1S | 2088285 | 10/2018 | 10/12/2018 | 99.94 | 99.99 | 99.98 |
| KU | C1S | 2088286 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2088287 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.99 |
| KU | C1S | 2088288 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.95 |
| KU | C1S | 2088289 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.95 |
| KU | C1S | 2088290 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.92 |
| KU | C1S | 2088291 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.88 |
| KU | C1S | 2088292 | 10/2018 | 10/12/2018 | 99.98 | 99.92 | 99.92 |
| KU | C1S | 2088293 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.96 |
| KU | C1S | 2088294 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.94 |
| KU | C1S | 2088295 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.95 |
| KU | C1S | 2088296 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2088297 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.96 |
| KU | C1S | 2088298 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.94 |
| KU | C1S | 2088299 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.93 |
| KU | C1S | 2088300 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.93 |
| KU | C1S | 2088301 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2088302 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2088303 | 10/2018 | 10/12/2018 | 99.98 | 100 | 100 |
| KU | C1S | 2088304 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2088305 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.98 |
| KU | C1S | 2088306 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.93 |
| KU | C1S | 2088307 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1S | 2088308 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2088309 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.9 |
| KU | C1S | 2088310 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.95 |
| KU | C1S | 2088311 | 10/2018 | 10/12/2018 | 99.96 | 100 | 99.95 |
| KU | C1S | 2088312 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2088313 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2088314 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.98 |
| KU | C1S | 2088315 | 10/2018 | 10/12/2018 | 99.92 | 99.97 | 99.98 |
| KU | C1S | 2088316 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.91 |
| KU | C1S | 2088317 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.91 |
| KU | C1S | 2088318 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.9 |
| KU | C1S | 2088319 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.88 |
| KU | C1S | 2088320 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088321 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1S | 2088322 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2088323 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2088324 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2088325 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.95 |
| KU | C1S | 2088326 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.94 |
| KU | C1S | 2088327 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.91 |
| KU | C1S | 2088328 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.93 |
| KU | C1S | 2088329 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.91 |
| KU | C1S | 2088330 | 10/2018 | 10/12/2018 | 99.97 | 100 | 99.97 |
| KU | C1S | 2088331 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2088332 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.94 |
| KU | C1S | 2088333 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.93 |
| KU | C1S | 2088334 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.99 |
| KU | C1S | 2088335 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2088336 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2088337 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088338 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2088339 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2088340 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.94 |
| KU | C1S | 2088341 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2088342 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2088343 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2088344 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.92 |
| KU | C1S | 2088345 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.9 |
| KU | C1S | 2088346 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.98 |
| KU | C1S | 2088347 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2088348 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.91 |
| KU | C1S | 2088349 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.94 |
| KU | C1S | 2088350 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2088351 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1S | 2088352 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.95 |
| KU | C1S | 2088353 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.93 |
| KU | C1S | 2088354 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2088355 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.92 |
| KU | C1S | 2088356 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.93 |
| KU | C1S | 2088357 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.92 |
| KU | C1S | 2088358 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.92 |
| KU | C1S | 2088359 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.96 |
| KU | C1S | 2088360 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2088361 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.91 |
| KU | C1S | 2088362 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.9 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088363 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2088364 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2088365 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.92 |
| KU | C1S | 2088366 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.93 |
| KU | C1S | 2088367 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.95 |
| KU | C1S | 2088368 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.97 |
| KU | C1S | 2088369 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2088370 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.9 |
| KU | C1S | 2088371 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.99 |
| KU | C1S | 2088372 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.95 |
| KU | C1S | 2088373 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.9 |
| KU | C1S | 2088374 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.93 |
| KU | C1S | 2088375 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.93 |
| KU | C1S | 2088376 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.98 |
| KU | C1S | 2088377 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.98 |
| KU | C1S | 2088378 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2088379 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.93 |
| KU | C1S | 2088380 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2088381 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.91 |
| KU | C1S | 2088382 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2088383 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.91 |
| KU | C1S | 2088384 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.94 |
| KU | C1S | 2088385 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.97 |
| KU | C1S | 2088386 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.93 |
| KU | C1S | 2088387 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100 |
| KU | C1S | 2088388 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.91 |
| KU | C1S | 2088389 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2088390 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.99 |
| KU | C1S | 2088391 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.92 |
| KU | C1S | 2088392 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.97 |
| KU | C1S | 2088393 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.94 |
| KU | C1S | 2088394 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2088395 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.99 |
| KU | C1S | 2088396 | 10/2018 | 10/12/2018 | 99.99 | 99.91 | 99.92 |
| KU | C1S | 2088397 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.91 |
| KU | C1S | 2088398 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.95 |
| KU | C1S | 2088399 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.9 |
| KU | C1S | 2088400 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2088401 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.94 |
| KU | C1S | 2088402 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.96 |
| KU | C1S | 2088403 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2088404 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|-------|--------|
| KU | C1S | 2088405 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2088406 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.92 |
| KU | C1S | 2088407 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.98 |
| KU | C1S | 2088408 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.9 |
| KU | C1S | 2088409 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2088410 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2088411 | 10/2018 | 10/12/2018 | 99.99 | 99.92 | 99.9 |
| KU | C1S | 2088412 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.97 |
| KU | C1S | 2088413 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1S | 2088414 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1S | 2088415 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1S | 2088416 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.96 |
| KU | C1S | 2088417 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2088418 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.89 |
| KU | C1S | 2088419 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088420 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.89 |
| KU | C1S | 2088421 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2088422 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2088423 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2088424 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.98 |
| KU | C1S | 2088425 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.94 |
| KU | C1S | 2088426 | 10/2018 | 10/12/2018 | 100.05 | 99.98 | 99.93 |
| KU | C1S | 2088427 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2088428 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2088429 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2088430 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088431 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2088432 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.96 |
| KU | C1S | 2088433 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2088434 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2088435 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.92 |
| KU | C1S | 2088436 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2088437 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.93 |
| KU | C1S | 2088438 | 10/2018 | 10/12/2018 | 99.98 | 99.92 | 99.89 |
| KU | C1S | 2088439 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.94 |
| KU | C1S | 2088440 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.93 |
| KU | C1S | 2088441 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.94 |
| KU | C1S | 2088442 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.96 |
| KU | C1S | 2088443 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100.02 |
| KU | C1S | 2088444 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2088445 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2088446 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|-------|--------|
| KU | C1S | 2088447 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2088448 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.97 |
| KU | C1S | 2088449 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2088450 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1S | 2088451 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2088452 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.93 |
| KU | C1S | 2088453 | 10/2018 | 10/12/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2088454 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2088455 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.97 |
| KU | C1S | 2088456 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 100.01 |
| KU | C1S | 2088457 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088458 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2088459 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.93 |
| KU | C1S | 2088460 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2088461 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.98 |
| KU | C1S | 2088462 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2088463 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2088464 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 100.01 |
| KU | C1S | 2088465 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.95 |
| KU | C1S | 2088466 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2088467 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.96 |
| KU | C1S | 2088468 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.98 |
| KU | C1S | 2088469 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2088470 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.9 |
| KU | C1S | 2088471 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.96 |
| KU | C1S | 2088472 | 10/2018 | 10/12/2018 | 99.94 | 99.94 | 99.91 |
| KU | C1S | 2088473 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.94 |
| KU | C1S | 2088474 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 100.01 |
| KU | C1S | 2088475 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2088476 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.92 |
| KU | C1S | 2088477 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.97 |
| KU | C1S | 2088478 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.99 |
| KU | C1S | 2088479 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 100 |
| KU | C1S | 2088480 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.93 |
| KU | C1S | 2088481 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2088482 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2088483 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2088484 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1S | 2088485 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.94 |
| KU | C1S | 2088486 | 10/2018 | 10/12/2018 | 99.97 | 100 | 99.97 |
| KU | C1S | 2088487 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2088488 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088489 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.98 |
| KU | C1S | 2088490 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2088491 | 10/2018 | 10/12/2018 | 100.07 | 99.94 | 99.94 |
| KU | C1S | 2088492 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.94 |
| KU | C1S | 2088493 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.93 |
| KU | C1S | 2088494 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |
| KU | C1S | 2088495 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.94 |
| KU | C1S | 2088496 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.95 |
| KU | C1S | 2088497 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1S | 2088498 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.99 |
| KU | C1S | 2088499 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.95 |
| KU | C1S | 2088500 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.91 |
| KU | C1S | 2088501 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.97 |
| KU | C1S | 2088502 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2088503 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1S | 2088504 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2088505 | 10/2018 | 10/12/2018 | 100.05 | 100.01 | 99.96 |
| KU | C1S | 2088506 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2088507 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.9 |
| KU | C1S | 2088508 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.99 |
| KU | C1S | 2088509 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.94 |
| KU | C1S | 2088510 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2088511 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088512 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.9 |
| KU | C1S | 2088513 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2088514 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2088515 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1S | 2088516 | 10/2018 | 10/12/2018 | 99.98 | 100.03 | 100.02 |
| KU | C1S | 2088517 | 10/2018 | 10/12/2018 | 100.03 | 100.03 | 99.99 |
| KU | C1S | 2088518 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.99 |
| KU | C1S | 2088519 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2088520 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2088521 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100.02 |
| KU | C1S | 2088522 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2088523 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.94 |
| KU | C1S | 2088524 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2088525 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.9 |
| KU | C1S | 2088526 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.95 |
| KU | C1S | 2088527 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2088528 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.98 |
| KU | C1S | 2088529 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.96 |
| KU | C1S | 2088530 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088531 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2088532 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2088533 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.91 |
| KU | C1S | 2088534 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2088535 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.95 |
| KU | C1S | 2088536 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.93 |
| KU | C1S | 2088537 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1S | 2088538 | 10/2018 | 10/12/2018 | 100.03 | 100.05 | 100.02 |
| KU | C1S | 2088539 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1S | 2088540 | 10/2018 | 10/12/2018 | 100.03 | 99.94 | 99.93 |
| KU | C1S | 2088541 | 10/2018 | 10/12/2018 | 100.05 | 100 | 99.93 |
| KU | C1S | 2088542 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2088543 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.94 |
| KU | C1S | 2088544 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.92 |
| KU | C1S | 2088545 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.91 |
| KU | C1S | 2088546 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.92 |
| KU | C1S | 2088547 | 10/2018 | 10/12/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2088548 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.95 |
| KU | C1S | 2088549 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1S | 2088550 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1S | 2088551 | 10/2018 | 10/12/2018 | 99.95 | 100.02 | 99.94 |
| KU | C1S | 2088552 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.97 |
| KU | C1S | 2088553 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.93 |
| KU | C1S | 2088554 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2088555 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2088556 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2088557 | 10/2018 | 10/12/2018 | 100.04 | 99.95 | 99.93 |
| KU | C1S | 2088558 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.93 |
| KU | C1S | 2088559 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.95 |
| KU | C1S | 2088560 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088561 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.95 |
| KU | C1S | 2088562 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2088563 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.99 |
| KU | C1S | 2088564 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1S | 2088565 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2088566 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2088567 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2088568 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.98 |
| KU | C1S | 2088569 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2088570 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.96 |
| KU | C1S | 2088571 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2088572 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088573 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.99 |
| KU | C1S | 2088574 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.92 |
| KU | C1S | 2088575 | 10/2018 | 10/12/2018 | 100.05 | 100.04 | 99.96 |
| KU | C1S | 2088576 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.89 |
| KU | C1S | 2088577 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.94 |
| KU | C1S | 2088578 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2088579 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1S | 2088580 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2088581 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.91 |
| KU | C1S | 2088582 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2088583 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.91 |
| KU | C1S | 2088584 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.91 |
| KU | C1S | 2088585 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.97 |
| KU | C1S | 2088586 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2088587 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088588 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088589 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2088590 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.92 |
| KU | C1S | 2088591 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1S | 2088592 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.98 |
| KU | C1S | 2088593 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2088594 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2088595 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2088596 | 10/2018 | 10/12/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2088597 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 100 |
| KU | C1S | 2088598 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2088599 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2088600 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.91 |
| KU | C1S | 2088601 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 100.01 |
| KU | C1S | 2088602 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1S | 2088603 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 100 |
| KU | C1S | 2088604 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2088605 | 10/2018 | 10/12/2018 | 99.96 | 99.93 | 99.92 |
| KU | C1S | 2088606 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.91 |
| KU | C1S | 2088607 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2088608 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2088609 | 10/2018 | 10/12/2018 | 100.05 | 100.04 | 99.98 |
| KU | C1S | 2088610 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2088611 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.92 |
| KU | C1S | 2088612 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.89 |
| KU | C1S | 2088613 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.99 |
| KU | C1S | 2088614 | 10/2018 | 10/12/2018 | 99.98 | 99.91 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088615 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.96 |
| KU | C1S | 2088616 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2088617 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.93 |
| KU | C1S | 2088618 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2088619 | 10/2018 | 10/12/2018 | 100.05 | 99.94 | 99.92 |
| KU | C1S | 2088620 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2088621 | 10/2018 | 10/12/2018 | 100.05 | 99.98 | 99.94 |
| KU | C1S | 2088622 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.94 |
| KU | C1S | 2088623 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.91 |
| KU | C1S | 2088624 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2088625 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.96 |
| KU | C1S | 2088626 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.93 |
| KU | C1S | 2088627 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.94 |
| KU | C1S | 2088628 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.93 |
| KU | C1S | 2088629 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2088630 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.95 |
| KU | C1S | 2088631 | 10/2018 | 10/12/2018 | 100.03 | 99.94 | 99.96 |
| KU | C1S | 2088632 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2088633 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.9 |
| KU | C1S | 2088634 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.89 |
| KU | C1S | 2088635 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.93 |
| KU | C1S | 2088636 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2088637 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.93 |
| KU | C1S | 2088638 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.96 |
| KU | C1S | 2088639 | 10/2018 | 10/12/2018 | 100.01 | 99.91 | 99.89 |
| KU | C1S | 2088640 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2088641 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.97 |
| KU | C1S | 2088642 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2088643 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.94 |
| KU | C1S | 2088644 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.92 |
| KU | C1S | 2088645 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.93 |
| KU | C1S | 2088646 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1S | 2088647 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1S | 2088648 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 100 |
| KU | C1S | 2088649 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2088650 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.98 |
| KU | C1S | 2088651 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2088652 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.94 |
| KU | C1S | 2088653 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2088654 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088655 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.96 |
| KU | C1S | 2088656 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2088657 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.91 |
| KU | C1S | 2088658 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2088659 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.95 |
| KU | C1S | 2088660 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.91 |
| KU | C1S | 2088661 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.93 |
| KU | C1S | 2088662 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088663 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2088664 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2088665 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.93 |
| KU | C1S | 2088666 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2088667 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2088668 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.89 |
| KU | C1S | 2088669 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.93 |
| KU | C1S | 2088670 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.88 |
| KU | C1S | 2088671 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.95 |
| KU | C1S | 2088672 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 100 |
| KU | C1S | 2088673 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.89 |
| KU | C1S | 2088674 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.98 |
| KU | C1S | 2088675 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 100 |
| KU | C1S | 2088676 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2088677 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.93 |
| KU | C1S | 2088678 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.98 |
| KU | C1S | 2088679 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.93 |
| KU | C1S | 2088680 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2088681 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2088682 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.9 |
| KU | C1S | 2088683 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2088684 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.93 |
| KU | C1S | 2088685 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2088686 | 10/2018 | 10/12/2018 | 100.03 | 99.92 | 99.88 |
| KU | C1S | 2088687 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.93 |
| KU | C1S | 2088688 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.93 |
| KU | C1S | 2088689 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.97 |
| KU | C1S | 2088690 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2088691 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2088692 | 10/2018 | 10/12/2018 | 100.01 | 99.92 | 99.9 |
| KU | C1S | 2088693 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.9 |
| KU | C1S | 2088694 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1S | 2088695 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.95 |
| KU | C1S | 2088696 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2088697 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.97 |
| KU | C1S | 2088698 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088699 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 100.03 |
| KU | C1S | 2088700 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.93 |
| KU | C1S | 2088701 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2088702 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100.02 |
| KU | C1S | 2088703 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2088704 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2088705 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2088706 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 100 |
| KU | C1S | 2088707 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1S | 2088708 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2088709 | 10/2018 | 10/12/2018 | 99.99 | 99.92 | 99.9 |
| KU | C1S | 2088710 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.98 |
| KU | C1S | 2088711 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2088712 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.95 |
| KU | C1S | 2088713 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2088714 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088715 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2088716 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.91 |
| KU | C1S | 2088717 | 10/2018 | 10/12/2018 | 99.97 | 100 | 99.96 |
| KU | C1S | 2088718 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.9 |
| KU | C1S | 2088719 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.97 |
| KU | C1S | 2088720 | 10/2018 | 10/12/2018 | 99.97 | 99.93 | 99.9 |
| KU | C1S | 2088721 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.91 |
| KU | C1S | 2088722 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.91 |
| KU | C1S | 2088723 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.91 |
| KU | C1S | 2088724 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2088725 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2088726 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2088727 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1S | 2088728 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.93 |
| KU | C1S | 2088729 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.89 |
| KU | C1S | 2088730 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.94 |
| KU | C1S | 2088731 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.88 |
| KU | C1S | 2088732 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2088733 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.94 |
| KU | C1S | 2088734 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2088735 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2088736 | 10/2018 | 10/12/2018 | 100 | 100 | 99.92 |
| KU | C1S | 2088737 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.97 |
| KU | C1S | 2088738 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2088739 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.94 |
| KU | C1S | 2088740 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|-------|--------|
| KU | C1S | 2088741 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1S | 2088742 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1S | 2088743 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.99 |
| KU | C1S | 2088744 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.01 |
| KU | C1S | 2088745 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2088746 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2088747 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.93 |
| KU | C1S | 2088748 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088749 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 100.02 |
| KU | C1S | 2088750 | 10/2018 | 10/12/2018 | 100.01 | 100 | 100.02 |
| KU | C1S | 2088751 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.94 |
| KU | C1S | 2088752 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2088753 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2088754 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2088755 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2088756 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.91 |
| KU | C1S | 2088757 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1S | 2088758 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.94 |
| KU | C1S | 2088759 | 10/2018 | 10/12/2018 | 100 | 100 | 99.92 |
| KU | C1S | 2088760 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1S | 2088761 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2088762 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1S | 2088763 | 10/2018 | 10/12/2018 | 100.03 | 99.93 | 99.94 |
| KU | C1S | 2088764 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 100 |
| KU | C1S | 2088765 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2088766 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.98 |
| KU | C1S | 2088767 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.91 |
| KU | C1S | 2088768 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.91 |
| KU | C1S | 2088769 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2088770 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2088771 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2088772 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2088773 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2088774 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2088775 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.94 |
| KU | C1S | 2088776 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.97 |
| KU | C1S | 2088777 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.96 |
| KU | C1S | 2088778 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2088779 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2088780 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2088781 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.91 |
| KU | C1S | 2088782 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088783 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2088784 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.99 |
| KU | C1S | 2088785 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2088786 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.89 |
| KU | C1S | 2088787 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2088788 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2088789 | 10/2018 | 10/12/2018 | 100.06 | 99.92 | 99.91 |
| KU | C1S | 2088790 | 10/2018 | 10/12/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2088791 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2088792 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2088793 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2088794 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.92 |
| KU | C1S | 2088795 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100.02 |
| KU | C1S | 2088796 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.93 |
| KU | C1S | 2088797 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.95 |
| KU | C1S | 2088798 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1S | 2088799 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2088800 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.92 |
| KU | C1S | 2088801 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.95 |
| KU | C1S | 2088802 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.98 |
| KU | C1S | 2088803 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 100 |
| KU | C1S | 2088804 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.93 |
| KU | C1S | 2088805 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.9 |
| KU | C1S | 2088806 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.9 |
| KU | C1S | 2088807 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2088808 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2088809 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.93 |
| KU | C1S | 2088810 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2088811 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.89 |
| KU | C1S | 2088812 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.97 |
| KU | C1S | 2088813 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.97 |
| KU | C1S | 2088814 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.94 |
| KU | C1S | 2088815 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1S | 2088816 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2088817 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.98 |
| KU | C1S | 2088818 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100.06 |
| KU | C1S | 2088819 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2088820 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2088821 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.95 |
| KU | C1S | 2088822 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2088823 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.94 |
| KU | C1S | 2088824 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.87 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088825 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.96 |
| KU | C1S | 2088826 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.94 |
| KU | C1S | 2088827 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2088828 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.95 |
| KU | C1S | 2088829 | 10/2018 | 10/12/2018 | 100.03 | 100.02 | 100.02 |
| KU | C1S | 2088830 | 10/2018 | 10/12/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2088831 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.93 |
| KU | C1S | 2088832 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2088833 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2088834 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.96 |
| KU | C1S | 2088835 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2088836 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2088837 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1S | 2088838 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.98 |
| KU | C1S | 2088839 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088840 | 10/2018 | 10/12/2018 | 99.98 | 100 | 100.01 |
| KU | C1S | 2088841 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2088842 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2088843 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2088844 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.97 |
| KU | C1S | 2088845 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2088846 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.95 |
| KU | C1S | 2088847 | 10/2018 | 10/12/2018 | 100 | 100 | 100.02 |
| KU | C1S | 2088848 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2088849 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1S | 2088850 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.93 |
| KU | C1S | 2088851 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2088852 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.94 |
| KU | C1S | 2088853 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.93 |
| KU | C1S | 2088854 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2088855 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.99 |
| KU | C1S | 2088856 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1S | 2088857 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.95 |
| KU | C1S | 2088858 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2088859 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.95 |
| KU | C1S | 2088860 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088861 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2088862 | 10/2018 | 10/12/2018 | 100.04 | 100.02 | 99.97 |
| KU | C1S | 2088863 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.96 |
| KU | C1S | 2088864 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2088865 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2088866 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088867 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2088868 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2088869 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2088870 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2088871 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2088872 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2088873 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.99 |
| KU | C1S | 2088874 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.96 |
| KU | C1S | 2088875 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1S | 2088876 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.94 |
| KU | C1S | 2088877 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.97 |
| KU | C1S | 2088878 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 100.01 |
| KU | C1S | 2088879 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.94 |
| KU | C1S | 2088880 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 100.02 |
| KU | C1S | 2088881 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.98 |
| KU | C1S | 2088882 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2088883 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.97 |
| KU | C1S | 2088884 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.05 |
| KU | C1S | 2088885 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1S | 2088886 | 10/2018 | 10/12/2018 | 99.95 | 99.96 | 99.95 |
| KU | C1S | 2088887 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.94 |
| KU | C1S | 2088888 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 100.01 |
| KU | C1S | 2088889 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100.03 |
| KU | C1S | 2088890 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2088891 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1S | 2088892 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.97 |
| KU | C1S | 2088893 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 100 |
| KU | C1S | 2088894 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2088895 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.98 |
| KU | C1S | 2088896 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088897 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1S | 2088898 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.99 |
| KU | C1S | 2088899 | 10/2018 | 10/12/2018 | 99.97 | 100.03 | 100.01 |
| KU | C1S | 2088900 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2088901 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.95 |
| KU | C1S | 2088902 | 10/2018 | 10/12/2018 | 100.05 | 100 | 99.94 |
| KU | C1S | 2088903 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2088904 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2088905 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.99 |
| KU | C1S | 2088906 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2088907 | 10/2018 | 10/12/2018 | 99.98 | 100.03 | 100.01 |
| KU | C1S | 2088908 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088909 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.98 |
| KU | C1S | 2088910 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1S | 2088911 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.92 |
| KU | C1S | 2088912 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.96 |
| KU | C1S | 2088913 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.98 |
| KU | C1S | 2088914 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1S | 2088915 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1S | 2088916 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 100 |
| KU | C1S | 2088917 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.94 |
| KU | C1S | 2088918 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.91 |
| KU | C1S | 2088919 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2088920 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2088921 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.96 |
| KU | C1S | 2088922 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.92 |
| KU | C1S | 2088923 | 10/2018 | 10/12/2018 | 100.04 | 100.01 | 99.99 |
| KU | C1S | 2088924 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2088925 | 10/2018 | 10/12/2018 | 100.05 | 99.97 | 99.95 |
| KU | C1S | 2088926 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2088927 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2088928 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.96 |
| KU | C1S | 2088929 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2088930 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.98 |
| KU | C1S | 2088931 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2088932 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.9 |
| KU | C1S | 2088933 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.98 |
| KU | C1S | 2088934 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2088935 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2088936 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2088937 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2088938 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2088939 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2088940 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1S | 2088941 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100 |
| KU | C1S | 2088942 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2088943 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2088944 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.95 |
| KU | C1S | 2088945 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2088946 | 10/2018 | 10/12/2018 | 100.02 | 100.02 | 99.96 |
| KU | C1S | 2088947 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 100 |
| KU | C1S | 2088948 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.94 |
| KU | C1S | 2088949 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2088950 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088951 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.92 |
| KU | C1S | 2088952 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2088953 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2088954 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.97 |
| KU | C1S | 2088955 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2088956 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2088957 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.95 |
| KU | C1S | 2088958 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2088959 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2088960 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 100 |
| KU | C1S | 2088961 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2088962 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.94 |
| KU | C1S | 2088963 | 10/2018 | 10/12/2018 | 100.01 | 100.04 | 100 |
| KU | C1S | 2088964 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.97 |
| KU | C1S | 2088965 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.97 |
| KU | C1S | 2088966 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2088967 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2088968 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2088969 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.96 |
| KU | C1S | 2088970 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1S | 2088971 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.95 |
| KU | C1S | 2088972 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.93 |
| KU | C1S | 2088973 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2088974 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100.01 |
| KU | C1S | 2088975 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.96 |
| KU | C1S | 2088976 | 10/2018 | 10/12/2018 | 100.04 | 99.95 | 99.93 |
| KU | C1S | 2088977 | 10/2018 | 10/12/2018 | 100.06 | 100 | 99.99 |
| KU | C1S | 2088978 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2088979 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2088980 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2088981 | 10/2018 | 10/12/2018 | 100 | 99.99 | 100.02 |
| KU | C1S | 2088982 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 100.01 |
| KU | C1S | 2088983 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.97 |
| KU | C1S | 2088984 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.97 |
| KU | C1S | 2088985 | 10/2018 | 10/12/2018 | 99.95 | 100.01 | 100.01 |
| KU | C1S | 2088986 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2088987 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2088988 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.93 |
| KU | C1S | 2088989 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.95 |
| KU | C1S | 2088990 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2088991 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.89 |
| KU | C1S | 2088992 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2088993 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2088994 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.96 |
| KU | C1S | 2088995 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2088996 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.9 |
| KU | C1S | 2088997 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2088998 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.95 |
| KU | C1S | 2088999 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2089000 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2089001 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1S | 2089002 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 100.02 |
| KU | C1S | 2089003 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 100.01 |
| KU | C1S | 2089004 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.94 |
| KU | C1S | 2089005 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1S | 2089006 | 10/2018 | 10/12/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2089007 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.96 |
| KU | C1S | 2089008 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.94 |
| KU | C1S | 2089009 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2089010 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.95 |
| KU | C1S | 2089011 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.93 |
| KU | C1S | 2089012 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.96 |
| KU | C1S | 2089013 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2089014 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 100.01 |
| KU | C1S | 2089015 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.95 |
| KU | C1S | 2089016 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2089017 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.92 |
| KU | C1S | 2089018 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2089019 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.96 |
| KU | C1S | 2089020 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1S | 2089021 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2089022 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100.03 |
| KU | C1S | 2089023 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2089024 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2089025 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2089026 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2089027 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.94 |
| KU | C1S | 2089028 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.94 |
| KU | C1S | 2089029 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.99 |
| KU | C1S | 2089030 | 10/2018 | 10/12/2018 | 99.96 | 99.93 | 99.9 |
| KU | C1S | 2089031 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.92 |
| KU | C1S | 2089032 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2089033 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1S | 2089034 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089035 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2089036 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2089037 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2089038 | 10/2018 | 10/12/2018 | 99.96 | 100 | 100.01 |
| KU | C1S | 2089039 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2089040 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2089041 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2089042 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089043 | 10/2018 | 10/12/2018 | 100 | 99.98 | 100.02 |
| KU | C1S | 2089044 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.95 |
| KU | C1S | 2089045 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.99 |
| KU | C1S | 2089046 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089047 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2089048 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.95 |
| KU | C1S | 2089049 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1S | 2089050 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2089051 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2089052 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.96 |
| KU | C1S | 2089053 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2089054 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2089055 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 100.02 |
| KU | C1S | 2089056 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089057 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2089058 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.97 |
| KU | C1S | 2089059 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2089060 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.93 |
| KU | C1S | 2089061 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.96 |
| KU | C1S | 2089062 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2089063 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2089064 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089065 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2089066 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.99 |
| KU | C1S | 2089067 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1S | 2089068 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.96 |
| KU | C1S | 2089069 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089070 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.96 |
| KU | C1S | 2089071 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.98 |
| KU | C1S | 2089072 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.96 |
| KU | C1S | 2089073 | 10/2018 | 10/12/2018 | 100.02 | 100.05 | 99.98 |
| KU | C1S | 2089074 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 100.01 |
| KU | C1S | 2089075 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2089076 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089077 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2089078 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089079 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.92 |
| KU | C1S | 2089080 | 10/2018 | 10/12/2018 | 100.02 | 100.02 | 99.98 |
| KU | C1S | 2089081 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.97 |
| KU | C1S | 2089082 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2089083 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089084 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2089085 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2089086 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.97 |
| KU | C1S | 2089087 | 10/2018 | 10/12/2018 | 100.03 | 100.02 | 99.98 |
| KU | C1S | 2089088 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 100.05 |
| KU | C1S | 2089089 | 10/2018 | 10/12/2018 | 99.98 | 100.05 | 100.02 |
| KU | C1S | 2089090 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1S | 2089091 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.99 |
| KU | C1S | 2089092 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2089093 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100.01 |
| KU | C1S | 2089094 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089095 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 100.03 |
| KU | C1S | 2089096 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.96 |
| KU | C1S | 2089097 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.93 |
| KU | C1S | 2089098 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.92 |
| KU | C1S | 2089099 | 10/2018 | 10/12/2018 | 100 | 99.99 | 100 |
| KU | C1S | 2089100 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2089101 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.99 |
| KU | C1S | 2089102 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2089103 | 10/2018 | 10/12/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2089104 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.94 |
| KU | C1S | 2089105 | 10/2018 | 10/12/2018 | 100.02 | 100 | 100 |
| KU | C1S | 2089106 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.99 |
| KU | C1S | 2089107 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.99 |
| KU | C1S | 2089108 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.98 |
| KU | C1S | 2089109 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2089110 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2089111 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2089112 | 10/2018 | 10/12/2018 | 100.04 | 100.02 | 100.02 |
| KU | C1S | 2089113 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089114 | 10/2018 | 10/12/2018 | 100.04 | 100 | 99.99 |
| KU | C1S | 2089115 | 10/2018 | 10/12/2018 | 100.05 | 100.06 | 100.03 |
| KU | C1S | 2089116 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 100.02 |
| KU | C1S | 2089117 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089118 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089119 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.93 |
| KU | C1S | 2089120 | 10/2018 | 10/12/2018 | 100.04 | 100.03 | 100.04 |
| KU | C1S | 2089121 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2089122 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2089123 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2089124 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 100.01 |
| KU | C1S | 2089125 | 10/2018 | 10/12/2018 | 100.04 | 100.03 | 99.98 |
| KU | C1S | 2089126 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 100.02 |
| KU | C1S | 2089127 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.96 |
| KU | C1S | 2089128 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.95 |
| KU | C1S | 2089129 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.92 |
| KU | C1S | 2089130 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089131 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089132 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2089133 | 10/2018 | 10/12/2018 | 99.97 | 100.02 | 100.03 |
| KU | C1S | 2089134 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.98 |
| KU | C1S | 2089135 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089136 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.98 |
| KU | C1S | 2089137 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.92 |
| KU | C1S | 2089138 | 10/2018 | 10/12/2018 | 100.05 | 100.02 | 100.07 |
| KU | C1S | 2089139 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2089140 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.93 |
| KU | C1S | 2089141 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.97 |
| KU | C1S | 2089142 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2089143 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2089144 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.98 |
| KU | C1S | 2089145 | 10/2018 | 10/12/2018 | 99.95 | 100.01 | 99.94 |
| KU | C1S | 2089146 | 10/2018 | 10/12/2018 | 99.95 | 99.95 | 99.93 |
| KU | C1S | 2089147 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.96 |
| KU | C1S | 2089148 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2089149 | 10/2018 | 10/12/2018 | 99.99 | 100.06 | 100 |
| KU | C1S | 2089150 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2089151 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.97 |
| KU | C1S | 2089152 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.97 |
| KU | C1S | 2089153 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2089154 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 100.01 |
| KU | C1S | 2089155 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2089156 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100.03 |
| KU | C1S | 2089157 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.98 |
| KU | C1S | 2089158 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2089159 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2089160 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089161 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.98 |
| KU | C1S | 2089162 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.92 |
| KU | C1S | 2089163 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2089164 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2089165 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1S | 2089166 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2089167 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.96 |
| KU | C1S | 2089168 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.96 |
| KU | C1S | 2089169 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2089170 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2089171 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 100.01 |
| KU | C1S | 2089172 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2089173 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2089174 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2089175 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.96 |
| KU | C1S | 2089176 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2089177 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2089178 | 10/2018 | 10/12/2018 | 99.96 | 100.01 | 100.03 |
| KU | C1S | 2089179 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100.04 |
| KU | C1S | 2089180 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.98 |
| KU | C1S | 2089181 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.99 |
| KU | C1S | 2089182 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 100 |
| KU | C1S | 2089183 | 10/2018 | 10/12/2018 | 100.05 | 99.99 | 99.97 |
| KU | C1S | 2089184 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2089185 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2089186 | 10/2018 | 10/12/2018 | 100.04 | 100.01 | 99.99 |
| KU | C1S | 2089187 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.95 |
| KU | C1S | 2089188 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.97 |
| KU | C1S | 2089189 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 99.98 |
| KU | C1S | 2089190 | 10/2018 | 10/12/2018 | 100.05 | 100.01 | 99.96 |
| KU | C1S | 2089191 | 10/2018 | 10/12/2018 | 99.99 | 100.04 | 100.02 |
| KU | C1S | 2089192 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.93 |
| KU | C1S | 2089193 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2089194 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 100.02 |
| KU | C1S | 2089195 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1S | 2089196 | 10/2018 | 10/12/2018 | 100 | 100.05 | 100.03 |
| KU | C1S | 2089197 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2089198 | 10/2018 | 10/12/2018 | 99.97 | 100.02 | 100.01 |
| KU | C1S | 2089199 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2089200 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089201 | 10/2018 | 10/12/2018 | 99.95 | 100.02 | 100 |
| KU | C1S | 2089202 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089203 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089204 | 10/2018 | 10/12/2018 | 100.03 | 100.02 | 100 |
| KU | C1S | 2089205 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089206 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.95 |
| KU | C1S | 2089207 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.97 |
| KU | C1S | 2089208 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 99.99 |
| KU | C1S | 2089209 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2089210 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2089211 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.99 |
| KU | C1S | 2089212 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |
| KU | C1S | 2089213 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.94 |
| KU | C1S | 2089214 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2089215 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2089216 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 100.01 |
| KU | C1S | 2089217 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2089218 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.97 |
| KU | C1S | 2089219 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2089220 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1S | 2089221 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.95 |
| KU | C1S | 2089222 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.98 |
| KU | C1S | 2089223 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.92 |
| KU | C1S | 2089224 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2089225 | 10/2018 | 10/12/2018 | 100.03 | 100.03 | 99.99 |
| KU | C1S | 2089226 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2089227 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2089228 | 10/2018 | 10/12/2018 | 100.03 | 99.94 | 99.89 |
| KU | C1S | 2089229 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.99 |
| KU | C1S | 2089230 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.97 |
| KU | C1S | 2089231 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2089232 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2089233 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 100.01 |
| KU | C1S | 2089234 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.92 |
| KU | C1S | 2089235 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2089236 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2089237 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.98 |
| KU | C1S | 2089238 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.93 |
| KU | C1S | 2089239 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2089240 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2089241 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.99 |
| KU | C1S | 2089242 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 99.96 |
| KU | C1S | 2089243 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.94 |
| KU | C1S | 2089244 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.89 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089245 | 10/2018 | 10/12/2018 | 99.96 | 99.99 | 99.99 |
| KU | C1S | 2089246 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1S | 2089247 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2089248 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2089249 | 10/2018 | 10/12/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2089250 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089251 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 100.03 |
| KU | C1S | 2089252 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089253 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089254 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.91 |
| KU | C1S | 2089255 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.97 |
| KU | C1S | 2089256 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.92 |
| KU | C1S | 2089257 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100.02 |
| KU | C1S | 2089258 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2089259 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.95 |
| KU | C1S | 2089260 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.9 |
| KU | C1S | 2089261 | 10/2018 | 10/12/2018 | 100.01 | 100.04 | 100.03 |
| KU | C1S | 2089262 | 10/2018 | 10/12/2018 | 100.04 | 100.02 | 99.98 |
| KU | C1S | 2089263 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2089264 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 100 |
| KU | C1S | 2089265 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2089266 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.92 |
| KU | C1S | 2089267 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2089268 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.96 |
| KU | C1S | 2089269 | 10/2018 | 10/12/2018 | 99.97 | 100.04 | 100.03 |
| KU | C1S | 2089270 | 10/2018 | 10/12/2018 | 100.03 | 100 | 100 |
| KU | C1S | 2089271 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.96 |
| KU | C1S | 2089272 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.94 |
| KU | C1S | 2089273 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.94 |
| KU | C1S | 2089274 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2089275 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2089276 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.91 |
| KU | C1S | 2089277 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2089278 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2089279 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.91 |
| KU | C1S | 2089280 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 100.02 |
| KU | C1S | 2089281 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.99 |
| KU | C1S | 2089282 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.93 |
| KU | C1S | 2089283 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.94 |
| KU | C1S | 2089284 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.93 |
| KU | C1S | 2089285 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2089286 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089287 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.95 |
| KU | C1S | 2089288 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.95 |
| KU | C1S | 2089289 | 10/2018 | 10/12/2018 | 99.97 | 100.02 | 99.96 |
| KU | C1S | 2089290 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.94 |
| KU | C1S | 2089291 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.97 |
| KU | C1S | 2089292 | 10/2018 | 10/12/2018 | 100 | 100 | 99.91 |
| KU | C1S | 2089293 | 10/2018 | 10/12/2018 | 100.02 | 100.03 | 100 |
| KU | C1S | 2089294 | 10/2018 | 10/12/2018 | 99.98 | 100 | 100 |
| KU | C1S | 2089295 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |
| KU | C1S | 2089296 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.94 |
| KU | C1S | 2089297 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.94 |
| KU | C1S | 2089298 | 10/2018 | 10/12/2018 | 99.99 | 99.88 | 99.85 |
| KU | C1S | 2089299 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2089300 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.98 |
| KU | C1S | 2089301 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.96 |
| KU | C1S | 2089302 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2089303 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1S | 2089304 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.9 |
| KU | C1S | 2089305 | 10/2018 | 10/12/2018 | 100.03 | 100 | 100 |
| KU | C1S | 2089306 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.88 |
| KU | C1S | 2089307 | 10/2018 | 10/12/2018 | 100 | 100 | 99.95 |
| KU | C1S | 2089308 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2089309 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.99 |
| KU | C1S | 2089310 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.94 |
| KU | C1S | 2089311 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.92 |
| KU | C1S | 2089312 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.91 |
| KU | C1S | 2089313 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.95 |
| KU | C1S | 2089314 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 100 |
| KU | C1S | 2089315 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.93 |
| KU | C1S | 2089316 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.99 |
| KU | C1S | 2089317 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 100.01 |
| KU | C1S | 2089318 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1S | 2089319 | 10/2018 | 10/12/2018 | 99.97 | 100.03 | 100.01 |
| KU | C1S | 2089320 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.92 |
| KU | C1S | 2089321 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2089322 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2089323 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.94 |
| KU | C1S | 2089324 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.94 |
| KU | C1S | 2089325 | 10/2018 | 10/12/2018 | 100.05 | 99.96 | 99.95 |
| KU | C1S | 2089326 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2089327 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089328 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.99 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089329 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.89 |
| KU | C1S | 2089330 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.9 |
| KU | C1S | 2089331 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.96 |
| KU | C1S | 2089332 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.91 |
| KU | C1S | 2089333 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2089334 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.92 |
| KU | C1S | 2089335 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.92 |
| KU | C1S | 2089336 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2089337 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 99.96 |
| KU | C1S | 2089338 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2089339 | 10/2018 | 10/12/2018 | 100.02 | 100.03 | 100 |
| KU | C1S | 2089340 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2089341 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.96 |
| KU | C1S | 2089342 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.95 |
| KU | C1S | 2089343 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.92 |
| KU | C1S | 2089344 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089345 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2089346 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089347 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |
| KU | C1S | 2089348 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.95 |
| KU | C1S | 2089349 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2089350 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.97 |
| KU | C1S | 2089351 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2089352 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.9 |
| KU | C1S | 2089353 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2089354 | 10/2018 | 10/12/2018 | 100.06 | 99.97 | 99.93 |
| KU | C1S | 2089355 | 10/2018 | 10/12/2018 | 100.05 | 99.97 | 99.89 |
| KU | C1S | 2089356 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2089357 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.93 |
| KU | C1S | 2089358 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.92 |
| KU | C1S | 2089359 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2089360 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2089361 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.94 |
| KU | C1S | 2089362 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.96 |
| KU | C1S | 2089363 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1S | 2089364 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.88 |
| KU | C1S | 2089365 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2089366 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2089367 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2089368 | 10/2018 | 10/12/2018 | 100.03 | 100 | 100.02 |
| KU | C1S | 2089369 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089370 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089371 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2089372 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1S | 2089373 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2089374 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.89 |
| KU | C1S | 2089375 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2089376 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.98 |
| KU | C1S | 2089377 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2089378 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.94 |
| KU | C1S | 2089379 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2089380 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2089381 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2089382 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2089383 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.99 |
| KU | C1S | 2089384 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2089385 | 10/2018 | 10/12/2018 | 100.02 | 100.06 | 100 |
| KU | C1S | 2089386 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2089387 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2089388 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.9 |
| KU | C1S | 2089389 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.92 |
| KU | C1S | 2089390 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.9 |
| KU | C1S | 2089391 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.9 |
| KU | C1S | 2089392 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.93 |
| KU | C1S | 2089393 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2089394 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.88 |
| KU | C1S | 2089395 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.88 |
| KU | C1S | 2089396 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2089397 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.95 |
| KU | C1S | 2089398 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.92 |
| KU | C1S | 2089399 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089400 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2089401 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2089402 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2089403 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2089404 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.96 |
| KU | C1S | 2089405 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2089406 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.94 |
| KU | C1S | 2089407 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2089408 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2089409 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.92 |
| KU | C1S | 2089410 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2089411 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1S | 2089412 | 10/2018 | 10/12/2018 | 100 | 100 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089413 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.91 |
| KU | C1S | 2089414 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.95 |
| KU | C1S | 2089415 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.88 |
| KU | C1S | 2089416 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.96 |
| KU | C1S | 2089417 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2089418 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089419 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.89 |
| KU | C1S | 2089420 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1S | 2089421 | 10/2018 | 10/12/2018 | 100.02 | 100.04 | 99.96 |
| KU | C1S | 2089422 | 10/2018 | 10/12/2018 | 99.99 | 100.05 | 99.96 |
| KU | C1S | 2089423 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.91 |
| KU | C1S | 2089424 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1S | 2089425 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.85 |
| KU | C1S | 2089426 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.86 |
| KU | C1S | 2089427 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.87 |
| KU | C1S | 2089428 | 10/2018 | 10/12/2018 | 100.01 | 100.06 | 99.96 |
| KU | C1S | 2089429 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.9 |
| KU | C1S | 2089430 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.9 |
| KU | C1S | 2089431 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2089432 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.88 |
| KU | C1S | 2089433 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.86 |
| KU | C1S | 2089434 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.87 |
| KU | C1S | 2089435 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.86 |
| KU | C1S | 2089436 | 10/2018 | 10/12/2018 | 99.97 | 100.05 | 99.93 |
| KU | C1S | 2089437 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.9 |
| KU | C1S | 2089438 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.89 |
| KU | C1S | 2089439 | 10/2018 | 10/12/2018 | 100 | 100.05 | 99.95 |
| KU | C1S | 2089440 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.89 |
| KU | C1S | 2089441 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.91 |
| KU | C1S | 2089442 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2089443 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.87 |
| KU | C1S | 2089444 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.88 |
| KU | C1S | 2089445 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.96 |
| KU | C1S | 2089446 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.89 |
| KU | C1S | 2089447 | 10/2018 | 10/12/2018 | 99.99 | 100.06 | 99.98 |
| KU | C1S | 2089448 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.89 |
| KU | C1S | 2089449 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2089450 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.88 |
| KU | C1S | 2089451 | 10/2018 | 10/12/2018 | 100.01 | 100.04 | 99.92 |
| KU | C1S | 2089452 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.96 |
| KU | C1S | 2089453 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.9 |
| KU | C1S | 2089454 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089455 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.89 |
| KU | C1S | 2089456 | 10/2018 | 10/12/2018 | 99.99 | 100.05 | 99.93 |
| KU | C1S | 2089457 | 10/2018 | 10/12/2018 | 100 | 100.05 | 99.93 |
| KU | C1S | 2089458 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.9 |
| KU | C1S | 2089459 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.87 |
| KU | C1S | 2089460 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.88 |
| KU | C1S | 2089461 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.87 |
| KU | C1S | 2089462 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.93 |
| KU | C1S | 2089463 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1S | 2089464 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.88 |
| KU | C1S | 2089465 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.91 |
| KU | C1S | 2089466 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.87 |
| KU | C1S | 2089467 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.91 |
| KU | C1S | 2089468 | 10/2018 | 10/12/2018 | 99.99 | 100.05 | 99.94 |
| KU | C1S | 2089469 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.89 |
| KU | C1S | 2089470 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.88 |
| KU | C1S | 2089471 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.86 |
| KU | C1S | 2089472 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.91 |
| KU | C1S | 2089473 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.9 |
| KU | C1S | 2089474 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.88 |
| KU | C1S | 2089475 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.96 |
| KU | C1S | 2089476 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.94 |
| KU | C1S | 2089477 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.86 |
| KU | C1S | 2089478 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2089479 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1S | 2089480 | 10/2018 | 10/12/2018 | 100.01 | 100.03 | 99.97 |
| KU | C1S | 2089481 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.87 |
| KU | C1S | 2089482 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2089483 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.95 |
| KU | C1S | 2089484 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.93 |
| KU | C1S | 2089485 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.93 |
| KU | C1S | 2089486 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.89 |
| KU | C1S | 2089487 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.87 |
| KU | C1S | 2089488 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089489 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.91 |
| KU | C1S | 2089490 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.9 |
| KU | C1S | 2089491 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 99.93 |
| KU | C1S | 2089492 | 10/2018 | 10/12/2018 | 99.98 | 99.92 | 99.89 |
| KU | C1S | 2089493 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.93 |
| KU | C1S | 2089494 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 99.93 |
| KU | C1S | 2089495 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.85 |
| KU | C1S | 2089496 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089497 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.91 |
| KU | C1S | 2089498 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.93 |
| KU | C1S | 2089499 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.88 |
| KU | C1S | 2089500 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.96 |
| KU | C1S | 2089501 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.88 |
| KU | C1S | 2089502 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.89 |
| KU | C1S | 2089503 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.88 |
| KU | C1S | 2089504 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.87 |
| KU | C1S | 2089505 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2089506 | 10/2018 | 10/12/2018 | 99.98 | 100.06 | 99.95 |
| KU | C1S | 2089507 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1S | 2089508 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.98 |
| KU | C1S | 2089509 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.94 |
| KU | C1S | 2089510 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089511 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089512 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.96 |
| KU | C1S | 2089513 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2089514 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089515 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.93 |
| KU | C1S | 2089516 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.88 |
| KU | C1S | 2089517 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.9 |
| KU | C1S | 2089518 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.91 |
| KU | C1S | 2089519 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2089520 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2089521 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2089522 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.9 |
| KU | C1S | 2089523 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2089524 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2089525 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2089526 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2089527 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2089528 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.91 |
| KU | C1S | 2089529 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2089530 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2089531 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1S | 2089532 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2089533 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2089534 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1S | 2089535 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1S | 2089536 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2089537 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.92 |
| KU | C1S | 2089538 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089539 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.92 |
| KU | C1S | 2089540 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100 |
| KU | C1S | 2089541 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2089542 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.91 |
| KU | C1S | 2089543 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.94 |
| KU | C1S | 2089544 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.98 |
| KU | C1S | 2089545 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2089546 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089547 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2089548 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.93 |
| KU | C1S | 2089549 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.91 |
| KU | C1S | 2089550 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.94 |
| KU | C1S | 2089551 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2089552 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.91 |
| KU | C1S | 2089553 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2089554 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.88 |
| KU | C1S | 2089555 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.9 |
| KU | C1S | 2089556 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2089557 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.91 |
| KU | C1S | 2089558 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2089559 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089560 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.88 |
| KU | C1S | 2089561 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2089562 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.94 |
| KU | C1S | 2089563 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.95 |
| KU | C1S | 2089564 | 10/2018 | 10/12/2018 | 99.96 | 99.94 | 99.89 |
| KU | C1S | 2089565 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.91 |
| KU | C1S | 2089566 | 10/2018 | 10/12/2018 | 100.02 | 100.02 | 99.98 |
| KU | C1S | 2089567 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2089568 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.98 |
| KU | C1S | 2089569 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2089570 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2089571 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.9 |
| KU | C1S | 2089572 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.91 |
| KU | C1S | 2089573 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.99 |
| KU | C1S | 2089574 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.92 |
| KU | C1S | 2089575 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.96 |
| KU | C1S | 2089576 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.93 |
| KU | C1S | 2089577 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.9 |
| KU | C1S | 2089578 | 10/2018 | 10/12/2018 | 99.99 | 99.92 | 99.91 |
| KU | C1S | 2089579 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.97 |
| KU | C1S | 2089580 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089581 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.94 |
| KU | C1S | 2089582 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.91 |
| KU | C1S | 2089583 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.92 |
| KU | C1S | 2089584 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2089585 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.9 |
| KU | C1S | 2089586 | 10/2018 | 10/12/2018 | 100.05 | 100 | 99.91 |
| KU | C1S | 2089587 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2089588 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.99 |
| KU | C1S | 2089589 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.92 |
| KU | C1S | 2089590 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089591 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2089592 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2089593 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1S | 2089594 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2089595 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2089596 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2089597 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2089598 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.94 |
| KU | C1S | 2089599 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2089600 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089601 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.92 |
| KU | C1S | 2089602 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.94 |
| KU | C1S | 2089603 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.95 |
| KU | C1S | 2089604 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.94 |
| KU | C1S | 2089605 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.91 |
| KU | C1S | 2089606 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089607 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2089608 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2089609 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2089610 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.92 |
| KU | C1S | 2089611 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089612 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2089613 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2089614 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089615 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2089616 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.94 |
| KU | C1S | 2089617 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.9 |
| KU | C1S | 2089618 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1S | 2089619 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2089620 | 10/2018 | 10/12/2018 | 99.95 | 99.98 | 99.94 |
| KU | C1S | 2089621 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.93 |
| KU | C1S | 2089622 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2089623 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.94 |
| KU | C1S | 2089624 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2089625 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.94 |
| KU | C1S | 2089626 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2089627 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.98 |
| KU | C1S | 2089628 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.93 |
| KU | C1S | 2089629 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1S | 2089630 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.93 |
| KU | C1S | 2089631 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2089632 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.93 |
| KU | C1S | 2089633 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.93 |
| KU | C1S | 2089634 | 10/2018 | 10/12/2018 | 100.04 | 99.92 | 99.89 |
| KU | C1S | 2089635 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.95 |
| KU | C1S | 2089636 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.93 |
| KU | C1S | 2089637 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2089638 | 10/2018 | 10/12/2018 | 99.95 | 99.96 | 99.91 |
| KU | C1S | 2089639 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.94 |
| KU | C1S | 2089640 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.89 |
| KU | C1S | 2089641 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.92 |
| KU | C1S | 2089642 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.94 |
| KU | C1S | 2089643 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.93 |
| KU | C1S | 2089644 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.92 |
| KU | C1S | 2089645 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2089646 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.96 |
| KU | C1S | 2089647 | 10/2018 | 10/12/2018 | 100.04 | 99.99 | 99.94 |
| KU | C1S | 2089648 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.95 |
| KU | C1S | 2089649 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2089650 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2089651 | 10/2018 | 10/12/2018 | 100.03 | 100.03 | 99.93 |
| KU | C1S | 2089652 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.9 |
| KU | C1S | 2089653 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |
| KU | C1S | 2089654 | 10/2018 | 10/12/2018 | 100.06 | 99.98 | 99.96 |
| KU | C1S | 2089655 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2089656 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 99.99 |
| KU | C1S | 2089657 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1S | 2089658 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2089659 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.92 |
| KU | C1S | 2089660 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.92 |
| KU | C1S | 2089661 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.92 |
| KU | C1S | 2089662 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.97 |
| KU | C1S | 2089663 | 10/2018 | 10/12/2018 | 99.94 | 99.98 | 99.93 |
| KU | C1S | 2089664 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089665 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.92 |
| KU | C1S | 2089666 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.97 |
| KU | C1S | 2089667 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2089668 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.97 |
| KU | C1S | 2089669 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1S | 2089670 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.92 |
| KU | C1S | 2089671 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.97 |
| KU | C1S | 2089672 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2089673 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.9 |
| KU | C1S | 2089674 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2089675 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.97 |
| KU | C1S | 2089676 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 100.02 |
| KU | C1S | 2089677 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.94 |
| KU | C1S | 2089678 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.92 |
| KU | C1S | 2089679 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.91 |
| KU | C1S | 2089680 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089681 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2089682 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2089683 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1S | 2089684 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2089685 | 10/2018 | 10/12/2018 | 100.02 | 100.02 | 99.97 |
| KU | C1S | 2089686 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2089687 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089688 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2089689 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.93 |
| KU | C1S | 2089690 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.9 |
| KU | C1S | 2089691 | 10/2018 | 10/12/2018 | 100.04 | 100 | 100.03 |
| KU | C1S | 2089692 | 10/2018 | 10/12/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1S | 2089693 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.94 |
| KU | C1S | 2089694 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.93 |
| KU | C1S | 2089695 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.9 |
| KU | C1S | 2089696 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.92 |
| KU | C1S | 2089697 | 10/2018 | 10/12/2018 | 100.05 | 99.98 | 99.94 |
| KU | C1S | 2089698 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.97 |
| KU | C1S | 2089699 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.92 |
| KU | C1S | 2089700 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1S | 2089701 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.96 |
| KU | C1S | 2089702 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.92 |
| KU | C1S | 2089703 | 10/2018 | 10/12/2018 | 100 | 99.97 | 100 |
| KU | C1S | 2089704 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.94 |
| KU | C1S | 2089705 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2089706 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089707 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.97 |
| KU | C1S | 2089708 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.97 |
| KU | C1S | 2089709 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.98 |
| KU | C1S | 2089710 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2089711 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.98 |
| KU | C1S | 2089712 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2089713 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2089714 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.95 |
| KU | C1S | 2089715 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2089716 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2089717 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.91 |
| KU | C1S | 2089718 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.92 |
| KU | C1S | 2089719 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2089720 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.97 |
| KU | C1S | 2089721 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2089722 | 10/2018 | 10/12/2018 | 99.96 | 100.04 | 100.02 |
| KU | C1S | 2089723 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.95 |
| KU | C1S | 2089724 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.92 |
| KU | C1S | 2089725 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1S | 2089726 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.98 |
| KU | C1S | 2089727 | 10/2018 | 10/12/2018 | 100.04 | 99.95 | 99.94 |
| KU | C1S | 2089728 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.98 |
| KU | C1S | 2089729 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2089730 | 10/2018 | 10/12/2018 | 100.03 | 99.94 | 99.93 |
| KU | C1S | 2089731 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.99 |
| KU | C1S | 2089732 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1S | 2089733 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.92 |
| KU | C1S | 2089734 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1S | 2089735 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.96 |
| KU | C1S | 2089736 | 10/2018 | 10/12/2018 | 100.02 | 99.92 | 99.96 |
| KU | C1S | 2089737 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2089738 | 10/2018 | 10/12/2018 | 99.98 | 99.92 | 99.91 |
| KU | C1S | 2089739 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.97 |
| KU | C1S | 2089740 | 10/2018 | 10/12/2018 | 100 | 99.9 | 99.91 |
| KU | C1S | 2089741 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 100 |
| KU | C1S | 2089742 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1S | 2089743 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100.04 |
| KU | C1S | 2089744 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.95 |
| KU | C1S | 2089745 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.95 |
| KU | C1S | 2089746 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.99 |
| KU | C1S | 2089747 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2089748 | 10/2018 | 10/12/2018 | 99.96 | 99.94 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089749 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.92 |
| KU | C1S | 2089750 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2089751 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.93 |
| KU | C1S | 2089752 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1S | 2089753 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2089754 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2089755 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2089756 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 100.01 |
| KU | C1S | 2089757 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.96 |
| KU | C1S | 2089758 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.99 |
| KU | C1S | 2089759 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2089760 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1S | 2089761 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2089762 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2089763 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089764 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1S | 2089765 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.96 |
| KU | C1S | 2089766 | 10/2018 | 10/12/2018 | 100.02 | 100.05 | 100.03 |
| KU | C1S | 2089767 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2089768 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2089769 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1S | 2089770 | 10/2018 | 10/12/2018 | 100.02 | 100.01 | 99.99 |
| KU | C1S | 2089771 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1S | 2089772 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2089773 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2089774 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.94 |
| KU | C1S | 2089775 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1S | 2089776 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2089777 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1S | 2089778 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.96 |
| KU | C1S | 2089779 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2089780 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.97 |
| KU | C1S | 2089781 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089782 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.92 |
| KU | C1S | 2089783 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2089784 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089785 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2089786 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2089787 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2089788 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1S | 2089789 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2089790 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089791 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.96 |
| KU | C1S | 2089792 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2089793 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2089794 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2089795 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.93 |
| KU | C1S | 2089796 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 100.03 |
| KU | C1S | 2089797 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.92 |
| KU | C1S | 2089798 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.91 |
| KU | C1S | 2089799 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2089800 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.96 |
| KU | C1S | 2089801 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.96 |
| KU | C1S | 2089802 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 100 |
| KU | C1S | 2089803 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.99 |
| KU | C1S | 2089804 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2089805 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.93 |
| KU | C1S | 2089806 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.95 |
| KU | C1S | 2089807 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 100.01 |
| KU | C1S | 2089808 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2089809 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.97 |
| KU | C1S | 2089810 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2089811 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2089812 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.92 |
| KU | C1S | 2089813 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2089814 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.95 |
| KU | C1S | 2089815 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2089816 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.98 |
| KU | C1S | 2089817 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.99 |
| KU | C1S | 2089818 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2089819 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2089820 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2089821 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.9 |
| KU | C1S | 2089822 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.98 |
| KU | C1S | 2089823 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089824 | 10/2018 | 10/12/2018 | 100.03 | 100.03 | 99.96 |
| KU | C1S | 2089825 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.95 |
| KU | C1S | 2089826 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.94 |
| KU | C1S | 2089827 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.92 |
| KU | C1S | 2089828 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 100.01 |
| KU | C1S | 2089829 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.99 |
| KU | C1S | 2089830 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2089831 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.99 |
| KU | C1S | 2089832 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089833 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.99 |
| KU | C1S | 2089834 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.93 |
| KU | C1S | 2089835 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.91 |
| KU | C1S | 2089836 | 10/2018 | 10/12/2018 | 100.04 | 99.93 | 99.95 |
| KU | C1S | 2089837 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.99 |
| KU | C1S | 2089838 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2089839 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2089840 | 10/2018 | 10/12/2018 | 100.01 | 100 | 100.01 |
| KU | C1S | 2089841 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 100 |
| KU | C1S | 2089842 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.97 |
| KU | C1S | 2089843 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.97 |
| KU | C1S | 2089844 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.93 |
| KU | C1S | 2089845 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2089846 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089847 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1S | 2089848 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2089849 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.96 |
| KU | C1S | 2089850 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2089851 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2089852 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2089853 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.98 |
| KU | C1S | 2089854 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2089855 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.95 |
| KU | C1S | 2089856 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2089857 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.98 |
| KU | C1S | 2089858 | 10/2018 | 10/12/2018 | 100.05 | 99.99 | 99.99 |
| KU | C1S | 2089859 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.95 |
| KU | C1S | 2089860 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.93 |
| KU | C1S | 2089861 | 10/2018 | 10/12/2018 | 99.96 | 99.95 | 99.98 |
| KU | C1S | 2089862 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2089863 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089864 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.97 |
| KU | C1S | 2089865 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.99 |
| KU | C1S | 2089866 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.89 |
| KU | C1S | 2089867 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089868 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2089869 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2089870 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2089871 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2089872 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089873 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.92 |
| KU | C1S | 2089874 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089875 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.98 |
| KU | C1S | 2089876 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.92 |
| KU | C1S | 2089877 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.99 |
| KU | C1S | 2089878 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.96 |
| KU | C1S | 2089879 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.9 |
| KU | C1S | 2089880 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2089881 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.93 |
| KU | C1S | 2089882 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 100 |
| KU | C1S | 2089883 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2089884 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.97 |
| KU | C1S | 2089885 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.9 |
| KU | C1S | 2089886 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.88 |
| KU | C1S | 2089887 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.95 |
| KU | C1S | 2089888 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.96 |
| KU | C1S | 2089889 | 10/2018 | 10/12/2018 | 100 | 100.03 | 100.01 |
| KU | C1S | 2089890 | 10/2018 | 10/12/2018 | 100 | 99.91 | 99.85 |
| KU | C1S | 2089891 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2089892 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.9 |
| KU | C1S | 2089893 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.9 |
| KU | C1S | 2089894 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089895 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.94 |
| KU | C1S | 2089896 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.9 |
| KU | C1S | 2089897 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.91 |
| KU | C1S | 2089898 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.9 |
| KU | C1S | 2089899 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1S | 2089900 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.91 |
| KU | C1S | 2089901 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2089902 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1S | 2089903 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.97 |
| KU | C1S | 2089904 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.91 |
| KU | C1S | 2089905 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.97 |
| KU | C1S | 2089906 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.9 |
| KU | C1S | 2089907 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2089908 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.9 |
| KU | C1S | 2089909 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1S | 2089910 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.9 |
| KU | C1S | 2089911 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.99 |
| KU | C1S | 2089912 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.92 |
| KU | C1S | 2089913 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1S | 2089914 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.97 |
| KU | C1S | 2089915 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.92 |
| KU | C1S | 2089916 | 10/2018 | 10/12/2018 | 99.98 | 100.03 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089917 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.91 |
| KU | C1S | 2089918 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.88 |
| KU | C1S | 2089919 | 10/2018 | 10/12/2018 | 100 | 100 | 99.91 |
| KU | C1S | 2089920 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.95 |
| KU | C1S | 2089921 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.95 |
| KU | C1S | 2089922 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.9 |
| KU | C1S | 2089923 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2089924 | 10/2018 | 10/12/2018 | 100.06 | 99.99 | 99.94 |
| KU | C1S | 2089925 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.93 |
| KU | C1S | 2089926 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2089927 | 10/2018 | 10/12/2018 | 99.98 | 100.03 | 99.98 |
| KU | C1S | 2089928 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.98 |
| KU | C1S | 2089929 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2089930 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.93 |
| KU | C1S | 2089931 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2089932 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.98 |
| KU | C1S | 2089933 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.95 |
| KU | C1S | 2089934 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.91 |
| KU | C1S | 2089935 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.9 |
| KU | C1S | 2089936 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.96 |
| KU | C1S | 2089937 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.9 |
| KU | C1S | 2089938 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.91 |
| KU | C1S | 2089939 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.94 |
| KU | C1S | 2089940 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2089941 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 100 |
| KU | C1S | 2089942 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.92 |
| KU | C1S | 2089943 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2089944 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.92 |
| KU | C1S | 2089945 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.93 |
| KU | C1S | 2089946 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.86 |
| KU | C1S | 2089947 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1S | 2089948 | 10/2018 | 10/12/2018 | 100.04 | 99.94 | 99.89 |
| KU | C1S | 2089949 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.92 |
| KU | C1S | 2089950 | 10/2018 | 10/12/2018 | 100 | 99.92 | 99.89 |
| KU | C1S | 2089951 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.92 |
| KU | C1S | 2089952 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2089953 | 10/2018 | 10/12/2018 | 100 | 99.91 | 99.85 |
| KU | C1S | 2089954 | 10/2018 | 10/12/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2089955 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1S | 2089956 | 10/2018 | 10/12/2018 | 99.95 | 100.01 | 99.95 |
| KU | C1S | 2089957 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.9 |
| KU | C1S | 2089958 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.03 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2089959 | 10/2018 | 10/12/2018 | 99.99 | 99.92 | 99.91 |
| KU | C1S | 2089960 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1S | 2089961 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.93 |
| KU | C1S | 2089962 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.97 |
| KU | C1S | 2089963 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2089964 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.92 |
| KU | C1S | 2089965 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2089966 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2089967 | 10/2018 | 10/12/2018 | 100 | 100.03 | 100 |
| KU | C1S | 2089968 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.97 |
| KU | C1S | 2089969 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.89 |
| KU | C1S | 2089970 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2089971 | 10/2018 | 10/12/2018 | 100.04 | 99.95 | 99.91 |
| KU | C1S | 2089972 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.89 |
| KU | C1S | 2089973 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.95 |
| KU | C1S | 2089974 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.91 |
| KU | C1S | 2089975 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 100.01 |
| KU | C1S | 2089976 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.9 |
| KU | C1S | 2089977 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2089978 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.91 |
| KU | C1S | 2089979 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1S | 2089980 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.92 |
| KU | C1S | 2089981 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.95 |
| KU | C1S | 2089982 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2089983 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.98 |
| KU | C1S | 2089984 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2089985 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.93 |
| KU | C1S | 2089986 | 10/2018 | 10/12/2018 | 99.98 | 100.02 | 99.98 |
| KU | C1S | 2089987 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.89 |
| KU | C1S | 2089988 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.92 |
| KU | C1S | 2089989 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.95 |
| KU | C1S | 2089990 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.92 |
| KU | C1S | 2089991 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2089992 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2089993 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.89 |
| KU | C1S | 2089994 | 10/2018 | 10/12/2018 | 99.96 | 100 | 99.97 |
| KU | C1S | 2089995 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.9 |
| KU | C1S | 2089996 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.91 |
| KU | C1S | 2089997 | 10/2018 | 10/12/2018 | 100.06 | 100.01 | 99.92 |
| KU | C1S | 2089998 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.97 |
| KU | C1S | 2089999 | 10/2018 | 10/12/2018 | 100.02 | 100.05 | 99.98 |
| KU | C1S | 2090000 | 10/2018 | 10/12/2018 | 100.04 | 100.01 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2090001 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.94 |
| KU | C1S | 2090002 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.91 |
| KU | C1S | 2090003 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1S | 2090004 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.94 |
| KU | C1S | 2090005 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.94 |
| KU | C1S | 2090006 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.95 |
| KU | C1S | 2090007 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2090008 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.87 |
| KU | C1S | 2090009 | 10/2018 | 10/12/2018 | 100.01 | 100.02 | 99.99 |
| KU | C1S | 2090010 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2090011 | 10/2018 | 10/12/2018 | 99.95 | 100.01 | 99.99 |
| KU | C1S | 2090012 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.95 |
| KU | C1S | 2090013 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2090014 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2090015 | 10/2018 | 10/12/2018 | 100.01 | 99.93 | 99.9 |
| KU | C1S | 2090016 | 10/2018 | 10/12/2018 | 100.04 | 99.94 | 99.91 |
| KU | C1S | 2090017 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.98 |
| KU | C1S | 2090018 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2090019 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.92 |
| KU | C1S | 2090020 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 100 |
| KU | C1S | 2090021 | 10/2018 | 10/12/2018 | 99.96 | 100 | 99.94 |
| KU | C1S | 2090022 | 10/2018 | 10/12/2018 | 100 | 100 | 99.97 |
| KU | C1S | 2090023 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.97 |
| KU | C1S | 2090024 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2090025 | 10/2018 | 10/12/2018 | 100.03 | 100.02 | 99.96 |
| KU | C1S | 2090026 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.91 |
| KU | C1S | 2090027 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2090028 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.95 |
| KU | C1S | 2090029 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.97 |
| KU | C1S | 2090030 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.95 |
| KU | C1S | 2090031 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.95 |
| KU | C1S | 2090032 | 10/2018 | 10/12/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2090033 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.93 |
| KU | C1S | 2090034 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.89 |
| KU | C1S | 2090035 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.9 |
| KU | C1S | 2090036 | 10/2018 | 10/12/2018 | 100.03 | 100.03 | 99.97 |
| KU | C1S | 2090037 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2090038 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.91 |
| KU | C1S | 2090039 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.96 |
| KU | C1S | 2090040 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1S | 2090041 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.98 |
| KU | C1S | 2090042 | 10/2018 | 10/12/2018 | 99.97 | 100 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2090043 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.93 |
| KU | C1S | 2090044 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.91 |
| KU | C1S | 2090045 | 10/2018 | 10/12/2018 | 100.03 | 100.02 | 99.98 |
| KU | C1S | 2090046 | 10/2018 | 10/12/2018 | 100 | 100.01 | 100 |
| KU | C1S | 2090047 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2090048 | 10/2018 | 10/12/2018 | 99.98 | 99.9 | 99.91 |
| KU | C1S | 2090049 | 10/2018 | 10/12/2018 | 99.96 | 99.94 | 99.95 |
| KU | C1S | 2090050 | 10/2018 | 10/12/2018 | 100.03 | 99.99 | 99.94 |
| KU | C1S | 2090051 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.98 |
| KU | C1S | 2090052 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.93 |
| KU | C1S | 2090053 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.89 |
| KU | C1S | 2090054 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.92 |
| KU | C1S | 2090055 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2090056 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2090057 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2090058 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.95 |
| KU | C1S | 2090059 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.93 |
| KU | C1S | 2090060 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.97 |
| KU | C1S | 2090061 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1S | 2090062 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.98 |
| KU | C1S | 2090063 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.98 |
| KU | C1S | 2090064 | 10/2018 | 10/12/2018 | 99.95 | 100 | 99.93 |
| KU | C1S | 2090065 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2090066 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.94 |
| KU | C1S | 2090067 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.97 |
| KU | C1S | 2090068 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.93 |
| KU | C1S | 2090069 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.94 |
| KU | C1S | 2090070 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1S | 2090071 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2090072 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.92 |
| KU | C1S | 2090073 | 10/2018 | 10/12/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1S | 2090074 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.91 |
| KU | C1S | 2090075 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |
| KU | C1S | 2090076 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.94 |
| KU | C1S | 2090077 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.9 |
| KU | C1S | 2090078 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2090079 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.91 |
| KU | C1S | 2090080 | 10/2018 | 10/12/2018 | 100.05 | 100.01 | 99.96 |
| KU | C1S | 2090081 | 10/2018 | 10/12/2018 | 100 | 100 | 99.93 |
| KU | C1S | 2090082 | 10/2018 | 10/12/2018 | 99.95 | 99.97 | 99.93 |
| KU | C1S | 2090083 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2090084 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.91 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090085 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 100 |
| KU | C1S | 2090086 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.95 |
| KU | C1S | 2090087 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.89 |
| KU | C1S | 2090088 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.95 |
| KU | C1S | 2090089 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.98 |
| KU | C1S | 2090090 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.89 |
| KU | C1S | 2090091 | 10/2018 | 10/12/2018 | 100.06 | 99.97 | 99.96 |
| KU | C1S | 2090092 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.93 |
| KU | C1S | 2090093 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1S | 2090094 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2090095 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 100 |
| KU | C1S | 2090096 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2090097 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.98 |
| KU | C1S | 2090098 | 10/2018 | 10/12/2018 | 100.05 | 99.95 | 99.91 |
| KU | C1S | 2090099 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.97 |
| KU | C1S | 2090100 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.93 |
| KU | C1S | 2090101 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.92 |
| KU | C1S | 2090102 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2090103 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.94 |
| KU | C1S | 2090104 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.95 |
| KU | C1S | 2090105 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2090106 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.97 |
| KU | C1S | 2090107 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.03 |
| KU | C1S | 2090108 | 10/2018 | 10/12/2018 | 99.97 | 99.94 | 99.94 |
| KU | C1S | 2090109 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.9 |
| KU | C1S | 2090110 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2090111 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1S | 2090112 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.97 |
| KU | C1S | 2090113 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1S | 2090114 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.99 |
| KU | C1S | 2090115 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.98 |
| KU | C1S | 2090116 | 10/2018 | 10/12/2018 | 99.98 | 99.93 | 99.9 |
| KU | C1S | 2090117 | 10/2018 | 10/12/2018 | 100.02 | 99.93 | 99.9 |
| KU | C1S | 2090118 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2090119 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2090120 | 10/2018 | 10/12/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2090121 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2090122 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1S | 2090123 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2090124 | 10/2018 | 10/12/2018 | 99.98 | 100.03 | 99.97 |
| KU | C1S | 2090125 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.92 |
| KU | C1S | 2090126 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090127 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2090128 | 10/2018 | 10/12/2018 | 100.05 | 100 | 99.95 |
| KU | C1S | 2090129 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.94 |
| KU | C1S | 2090130 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2090131 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.91 |
| KU | C1S | 2090132 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2090133 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.98 |
| KU | C1S | 2090134 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.92 |
| KU | C1S | 2090135 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2090136 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.91 |
| KU | C1S | 2090137 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2090138 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 100.02 |
| KU | C1S | 2090139 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.96 |
| KU | C1S | 2090140 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.88 |
| KU | C1S | 2090141 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2090142 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2090143 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.97 |
| KU | C1S | 2090144 | 10/2018 | 10/12/2018 | 99.98 | 100.01 | 99.99 |
| KU | C1S | 2090145 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1S | 2090146 | 10/2018 | 10/12/2018 | 100 | 99.94 | 99.92 |
| KU | C1S | 2090147 | 10/2018 | 10/12/2018 | 100.02 | 100.02 | 100 |
| KU | C1S | 2090148 | 10/2018 | 10/12/2018 | 100 | 100 | 99.94 |
| KU | C1S | 2090149 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.99 |
| KU | C1S | 2090150 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.91 |
| KU | C1S | 2090151 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.99 |
| KU | C1S | 2090152 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.86 |
| KU | C1S | 2090153 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2090154 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.95 |
| KU | C1S | 2090155 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.96 |
| KU | C1S | 2090156 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.95 |
| KU | C1S | 2090157 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1S | 2090158 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1S | 2090159 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.97 |
| KU | C1S | 2090160 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 100 |
| KU | C1S | 2090161 | 10/2018 | 10/12/2018 | 100.02 | 99.95 | 99.92 |
| KU | C1S | 2090162 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2090163 | 10/2018 | 10/12/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2090164 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.92 |
| KU | C1S | 2090165 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2090166 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2090167 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2090168 | 10/2018 | 10/12/2018 | 100.03 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2090169 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2090170 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2090171 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.94 |
| KU | C1S | 2090172 | 10/2018 | 10/12/2018 | 100.04 | 99.94 | 99.88 |
| KU | C1S | 2090173 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.97 |
| KU | C1S | 2090174 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.94 |
| KU | C1S | 2090175 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.97 |
| KU | C1S | 2090176 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.92 |
| KU | C1S | 2090177 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.97 |
| KU | C1S | 2090178 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2090179 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 100 |
| KU | C1S | 2090180 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.89 |
| KU | C1S | 2090181 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.96 |
| KU | C1S | 2090182 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2090183 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.9 |
| KU | C1S | 2090184 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.96 |
| KU | C1S | 2090185 | 10/2018 | 10/12/2018 | 100.03 | 100 | 99.99 |
| KU | C1S | 2090186 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.98 |
| KU | C1S | 2090187 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2090188 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1S | 2090189 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2090190 | 10/2018 | 10/12/2018 | 100.02 | 99.92 | 99.85 |
| KU | C1S | 2090191 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.93 |
| KU | C1S | 2090192 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2090193 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.88 |
| KU | C1S | 2090194 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.93 |
| KU | C1S | 2090195 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2090196 | 10/2018 | 10/12/2018 | 100.04 | 99.97 | 99.94 |
| KU | C1S | 2090197 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2090198 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.98 |
| KU | C1S | 2090199 | 10/2018 | 10/12/2018 | 100 | 100.04 | 99.97 |
| KU | C1S | 2090200 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.98 |
| KU | C1S | 2090201 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.94 |
| KU | C1S | 2090202 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1S | 2090203 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.91 |
| KU | C1S | 2090204 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.89 |
| KU | C1S | 2090205 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2090206 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2090207 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.92 |
| KU | C1S | 2090208 | 10/2018 | 10/12/2018 | 100.01 | 99.92 | 99.88 |
| KU | C1S | 2090209 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2090210 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|-------|
| KU | C1S | 2090211 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.95 |
| KU | C1S | 2090212 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.93 |
| KU | C1S | 2090213 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.94 |
| KU | C1S | 2090214 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.92 |
| KU | C1S | 2090215 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1S | 2090216 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.94 |
| KU | C1S | 2090217 | 10/2018 | 10/12/2018 | 100.02 | 99.98 | 99.91 |
| KU | C1S | 2090218 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.92 |
| KU | C1S | 2090219 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.96 |
| KU | C1S | 2090220 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.95 |
| KU | C1S | 2090221 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.96 |
| KU | C1S | 2090222 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.92 |
| KU | C1S | 2090223 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.89 |
| KU | C1S | 2090224 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1S | 2090225 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.91 |
| KU | C1S | 2090226 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.91 |
| KU | C1S | 2090227 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1S | 2090228 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.92 |
| KU | C1S | 2090229 | 10/2018 | 10/12/2018 | 99.97 | 99.99 | 99.95 |
| KU | C1S | 2090230 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2090231 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.91 |
| KU | C1S | 2090232 | 10/2018 | 10/12/2018 | 100.03 | 100.01 | 99.97 |
| KU | C1S | 2090233 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.94 |
| KU | C1S | 2090234 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2090235 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.91 |
| KU | C1S | 2090236 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.93 |
| KU | C1S | 2090237 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.96 |
| KU | C1S | 2090238 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.9 |
| KU | C1S | 2090239 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.96 |
| KU | C1S | 2090240 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.97 |
| KU | C1S | 2090241 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.92 |
| KU | C1S | 2090242 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.91 |
| KU | C1S | 2090243 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.93 |
| KU | C1S | 2090244 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.91 |
| KU | C1S | 2090245 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2090246 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.9 |
| KU | C1S | 2090247 | 10/2018 | 10/12/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1S | 2090248 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.95 |
| KU | C1S | 2090249 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.95 |
| KU | C1S | 2090250 | 10/2018 | 10/12/2018 | 99.99 | 100.01 | 99.94 |
| KU | C1S | 2090251 | 10/2018 | 10/12/2018 | 100.05 | 99.99 | 99.94 |
| KU | C1S | 2090252 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090253 | 10/2018 | 10/12/2018 | 99.96 | 99.98 | 99.92 |
| KU | C1S | 2090254 | 10/2018 | 10/12/2018 | 99.96 | 99.96 | 99.91 |
| KU | C1S | 2090255 | 10/2018 | 10/12/2018 | 99.99 | 99.95 | 99.91 |
| KU | C1S | 2090256 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.98 |
| KU | C1S | 2090257 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.87 |
| KU | C1S | 2090258 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.93 |
| KU | C1S | 2090259 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.96 |
| KU | C1S | 2090260 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.94 |
| KU | C1S | 2090261 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.9 |
| KU | C1S | 2090262 | 10/2018 | 10/12/2018 | 99.98 | 99.97 | 99.98 |
| KU | C1S | 2090263 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.94 |
| KU | C1S | 2090264 | 10/2018 | 10/12/2018 | 100.01 | 99.96 | 99.89 |
| KU | C1S | 2090265 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.96 |
| KU | C1S | 2090266 | 10/2018 | 10/12/2018 | 99.97 | 100 | 100.02 |
| KU | C1S | 2090267 | 10/2018 | 10/12/2018 | 100 | 100.01 | 99.95 |
| KU | C1S | 2090268 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1S | 2090269 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.91 |
| KU | C1S | 2090270 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.9 |
| KU | C1S | 2090271 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2090272 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.96 |
| KU | C1S | 2090273 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.94 |
| KU | C1S | 2090274 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1S | 2090275 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.97 |
| KU | C1S | 2090276 | 10/2018 | 10/12/2018 | 100.04 | 99.96 | 99.91 |
| KU | C1S | 2090277 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2090278 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.94 |
| KU | C1S | 2090279 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2090280 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.97 |
| KU | C1S | 2090281 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.91 |
| KU | C1S | 2090282 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2090283 | 10/2018 | 10/12/2018 | 100.01 | 99.94 | 99.92 |
| KU | C1S | 2090284 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.95 |
| KU | C1S | 2090285 | 10/2018 | 10/12/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1S | 2090286 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1S | 2090287 | 10/2018 | 10/12/2018 | 99.96 | 99.97 | 99.92 |
| KU | C1S | 2090288 | 10/2018 | 10/12/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1S | 2090289 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2090290 | 10/2018 | 10/12/2018 | 99.99 | 99.93 | 99.95 |
| KU | C1S | 2090291 | 10/2018 | 10/12/2018 | 100 | 99.97 | 99.94 |
| KU | C1S | 2090292 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.96 |
| KU | C1S | 2090293 | 10/2018 | 10/12/2018 | 100 | 99.99 | 99.96 |
| KU | C1S | 2090294 | 10/2018 | 10/12/2018 | 100.03 | 99.96 | 99.97 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090295 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.98 |
| KU | C1S | 2090296 | 10/2018 | 10/12/2018 | 99.97 | 99.96 | 99.98 |
| KU | C1S | 2090297 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.95 |
| KU | C1S | 2090298 | 10/2018 | 10/12/2018 | 99.98 | 99.95 | 99.91 |
| KU | C1S | 2090299 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.94 |
| KU | C1S | 2090300 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1S | 2090301 | 10/2018 | 10/12/2018 | 99.98 | 99.98 | 99.95 |
| KU | C1S | 2090302 | 10/2018 | 10/12/2018 | 100 | 99.99 | 100 |
| KU | C1S | 2090303 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2090304 | 10/2018 | 10/12/2018 | 100.06 | 100.01 | 99.96 |
| KU | C1S | 2090305 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2090306 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.91 |
| KU | C1S | 2090307 | 10/2018 | 10/12/2018 | 99.97 | 100.01 | 99.97 |
| KU | C1S | 2090308 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.92 |
| KU | C1S | 2090309 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.97 |
| KU | C1S | 2090310 | 10/2018 | 10/12/2018 | 100.03 | 99.98 | 99.93 |
| KU | C1S | 2090311 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.96 |
| KU | C1S | 2090312 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.96 |
| KU | C1S | 2090313 | 10/2018 | 10/12/2018 | 100.01 | 100 | 99.97 |
| KU | C1S | 2090314 | 10/2018 | 10/12/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2090315 | 10/2018 | 10/12/2018 | 100.04 | 100.02 | 99.96 |
| KU | C1S | 2090316 | 10/2018 | 10/12/2018 | 100.01 | 99.98 | 99.92 |
| KU | C1S | 2090317 | 10/2018 | 10/12/2018 | 100.03 | 99.97 | 99.96 |
| KU | C1S | 2090318 | 10/2018 | 10/12/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1S | 2090319 | 10/2018 | 10/12/2018 | 100.04 | 99.98 | 99.95 |
| KU | C1S | 2090320 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.91 |
| KU | C1S | 2090321 | 10/2018 | 10/12/2018 | 100 | 100.03 | 99.96 |
| KU | C1S | 2090322 | 10/2018 | 10/12/2018 | 99.96 | 99.99 | 99.98 |
| KU | C1S | 2090323 | 10/2018 | 10/12/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1S | 2090324 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.9 |
| KU | C1S | 2090325 | 10/2018 | 10/12/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1S | 2090326 | 10/2018 | 10/12/2018 | 100.02 | 99.99 | 99.97 |
| KU | C1S | 2090327 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 100.01 |
| KU | C1S | 2090328 | 10/2018 | 10/12/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1S | 2090329 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.96 |
| KU | C1S | 2090330 | 10/2018 | 10/12/2018 | 100 | 100.02 | 99.98 |
| KU | C1S | 2090331 | 10/2018 | 10/12/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2090332 | 10/2018 | 10/12/2018 | 100 | 99.93 | 99.86 |
| KU | C1S | 2090333 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.96 |
| KU | C1S | 2090334 | 10/2018 | 10/12/2018 | 99.99 | 100 | 99.95 |
| KU | C1S | 2090335 | 10/2018 | 10/12/2018 | 100.02 | 100 | 100.01 |
| KU | C1S | 2090336 | 10/2018 | 10/12/2018 | 99.97 | 99.95 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090337 | 10/2018 | 10/12/2018 | 99.99 | 99.98 | 99.9 |
| KU | C1S | 2090338 | 10/2018 | 10/12/2018 | 100.02 | 99.97 | 99.89 |
| KU | C1S | 2090339 | 10/2018 | 10/12/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2090340 | 10/2018 | 10/12/2018 | 100.02 | 100 | 99.95 |
| KU | C1S | 2090341 | 10/2018 | 10/12/2018 | 100 | 99.95 | 99.92 |
| KU | C1S | 2090342 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.93 |
| KU | C1S | 2090343 | 10/2018 | 10/12/2018 | 100.04 | 100 | 99.95 |
| KU | C1S | 2090344 | 10/2018 | 10/12/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2090345 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.98 |
| KU | C1S | 2090346 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.95 |
| KU | C1S | 2090347 | 10/2018 | 10/12/2018 | 100 | 99.96 | 99.9 |
| KU | C1S | 2090348 | 10/2018 | 10/12/2018 | 100.01 | 100.01 | 99.99 |
| KU | C1S | 2090349 | 10/2018 | 10/12/2018 | 99.96 | 100.01 | 100 |
| KU | C1S | 2090350 | 10/2018 | 10/12/2018 | 100.02 | 99.94 | 99.97 |
| KU | C1S | 2090351 | 10/2018 | 10/12/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1S | 2090352 | 10/2018 | 10/12/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1S | 2090353 | 10/2018 | 10/12/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2090354 | 10/2018 | 10/12/2018 | 100 | 99.98 | 99.99 |
| KU | C1S | 2090355 | 10/2018 | 10/12/2018 | 99.97 | 99.98 | 99.92 |
| KU | C1S | 2090356 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.04 |
| KU | C1S | 2090357 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100.04 |
| KU | C1S | 2090358 | 11/2018 | 11/5/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2090359 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100 |
| KU | C1S | 2090360 | 11/2018 | 11/5/2018 | 100 | 99.98 | 100.02 |
| KU | C1S | 2090361 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 100.06 |
| KU | C1S | 2090362 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2090363 | 11/2018 | 11/5/2018 | 99.98 | 100 | 99.99 |
| KU | C1S | 2090364 | 11/2018 | 11/5/2018 | 99.98 | 100 | 100 |
| KU | C1S | 2090365 | 11/2018 | 11/5/2018 | 99.99 | 99.97 | 100.01 |
| KU | C1S | 2090366 | 11/2018 | 11/5/2018 | 100 | 100 | 100.03 |
| KU | C1S | 2090367 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.06 |
| KU | C1S | 2090368 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100.01 |
| KU | C1S | 2090369 | 11/2018 | 11/5/2018 | 99.98 | 100.01 | 100.04 |
| KU | C1S | 2090370 | 11/2018 | 11/5/2018 | 99.98 | 100 | 100.02 |
| KU | C1S | 2090371 | 11/2018 | 11/5/2018 | 99.98 | 100 | 100.03 |
| KU | C1S | 2090372 | 11/2018 | 11/5/2018 | 99.98 | 100.02 | 100.05 |
| KU | C1S | 2090373 | 11/2018 | 11/5/2018 | 100 | 100.02 | 100.01 |
| KU | C1S | 2090374 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2090375 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2090376 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100.01 |
| KU | C1S | 2090377 | 11/2018 | 11/5/2018 | 99.99 | 100.03 | 99.98 |
| KU | C1S | 2090378 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100.01 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|-----------|-------|--------|--------|
| KU | C1S | 2090379 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.04 |
| KU | C1S | 2090380 | 11/2018 | 11/5/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2090381 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2090382 | 11/2018 | 11/5/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2090383 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2090384 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 99.99 |
| KU | C1S | 2090385 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2090386 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.06 |
| KU | C1S | 2090387 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.05 |
| KU | C1S | 2090388 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2090389 | 11/2018 | 11/5/2018 | 99.98 | 100.03 | 100.01 |
| KU | C1S | 2090390 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100 |
| KU | C1S | 2090391 | 11/2018 | 11/5/2018 | 100 | 100.03 | 100.05 |
| KU | C1S | 2090392 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2090393 | 11/2018 | 11/5/2018 | 99.98 | 100.01 | 100.04 |
| KU | C1S | 2090394 | 11/2018 | 11/5/2018 | 99.99 | 100.05 | 100.02 |
| KU | C1S | 2090395 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100.01 |
| KU | C1S | 2090396 | 11/2018 | 11/5/2018 | 100 | 100.02 | 100.02 |
| KU | C1S | 2090397 | 11/2018 | 11/5/2018 | 100 | 100.02 | 100 |
| KU | C1S | 2090398 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1S | 2090399 | 11/2018 | 11/5/2018 | 99.98 | 99.99 | 100.01 |
| KU | C1S | 2090400 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.03 |
| KU | C1S | 2090401 | 11/2018 | 11/5/2018 | 99.98 | 100.02 | 100.06 |
| KU | C1S | 2090402 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.08 |
| KU | C1S | 2090403 | 11/2018 | 11/5/2018 | 99.98 | 100.02 | 100.02 |
| KU | C1S | 2090404 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 100.04 |
| KU | C1S | 2090405 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100.03 |
| KU | C1S | 2090406 | 11/2018 | 11/5/2018 | 99.98 | 100.02 | 100.01 |
| KU | C1S | 2090407 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 100.03 |
| KU | C1S | 2090408 | 11/2018 | 11/5/2018 | 99.98 | 100 | 100.04 |
| KU | C1S | 2090409 | 11/2018 | 11/5/2018 | 99.98 | 100.02 | 100.03 |
| KU | C1S | 2090410 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 100 |
| KU | C1S | 2090411 | 11/2018 | 11/5/2018 | 99.98 | 100.03 | 100.01 |
| KU | C1S | 2090412 | 11/2018 | 11/5/2018 | 100 | 99.99 | 99.97 |
| KU | C1S | 2090413 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1S | 2090414 | 11/2018 | 11/5/2018 | 99.98 | 100.01 | 100.01 |
| KU | C1S | 2090415 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 99.97 |
| KU | C1S | 2090416 | 11/2018 | 11/5/2018 | 99.98 | 99.99 | 100.03 |
| KU | C1S | 2090417 | 11/2018 | 11/5/2018 | 99.98 | 100.01 | 100.05 |
| KU | C1S | 2090418 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.96 |
| KU | C1S | 2090419 | 11/2018 | 11/5/2018 | 99.99 | 100.02 | 100.01 |
| KU | C1S | 2090420 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-----|---------|---------|-----------|-------|--------|--------|
| KU | C1S | 2090421 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.01 |
| KU | C1S | 2090422 | 11/2018 | 11/5/2018 | 99.99 | 99.96 | 100 |
| KU | C1S | 2090423 | 11/2018 | 11/5/2018 | 100 | 100 | 100.03 |
| KU | C1S | 2090424 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 100.02 |
| KU | C1S | 2090425 | 11/2018 | 11/5/2018 | 99.98 | 99.97 | 100.01 |
| KU | C1S | 2090426 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 100 |
| KU | C1S | 2090427 | 11/2018 | 11/5/2018 | 99.98 | 99.97 | 100.01 |
| KU | C1S | 2090428 | 11/2018 | 11/5/2018 | 100 | 100 | 100.02 |
| KU | C1S | 2090429 | 11/2018 | 11/5/2018 | 100 | 99.99 | 100.01 |
| KU | C1S | 2090430 | 11/2018 | 11/5/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2090431 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.98 |
| KU | C1S | 2090432 | 11/2018 | 11/5/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2090433 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 99.98 |
| KU | C1S | 2090434 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.99 |
| KU | C1S | 2090435 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100.03 |
| KU | C1S | 2090436 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100 |
| KU | C1S | 2090437 | 11/2018 | 11/5/2018 | 99.98 | 99.97 | 99.98 |
| KU | C1S | 2090438 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2090439 | 11/2018 | 11/5/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1S | 2090440 | 11/2018 | 11/5/2018 | 99.99 | 99.97 | 100.03 |
| KU | C1S | 2090441 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2090442 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2090443 | 11/2018 | 11/5/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2090444 | 11/2018 | 11/5/2018 | 99.99 | 99.96 | 99.99 |
| KU | C1S | 2090445 | 11/2018 | 11/5/2018 | 100 | 99.98 | 100 |
| KU | C1S | 2090446 | 11/2018 | 11/5/2018 | 99.98 | 100 | 99.98 |
| KU | C1S | 2090447 | 11/2018 | 11/5/2018 | 99.98 | 99.96 | 99.95 |
| KU | C1S | 2090448 | 11/2018 | 11/5/2018 | 100 | 99.99 | 100.02 |
| KU | C1S | 2090449 | 11/2018 | 11/5/2018 | 99.98 | 100 | 99.99 |
| KU | C1S | 2090450 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 99.96 |
| KU | C1S | 2090451 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 100 |
| KU | C1S | 2090452 | 11/2018 | 11/5/2018 | 100 | 100 | 99.98 |
| KU | C1S | 2090453 | 11/2018 | 11/5/2018 | 99.98 | 99.99 | 99.99 |
| KU | C1S | 2090454 | 11/2018 | 11/5/2018 | 99.98 | 100.01 | 100 |
| KU | C1S | 2090455 | 11/2018 | 11/5/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1S | 2090456 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 99.99 |
| KU | C1S | 2090457 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 99.98 |
| KU | C1S | 2090458 | 11/2018 | 11/5/2018 | 100 | 100.01 | 99.97 |
| KU | C1S | 2090459 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 100 |
| KU | C1S | 2090460 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2090461 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 99.95 |
| KU | C1S | 2090462 | 11/2018 | 11/5/2018 | 99.99 | 100 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C1S | 2090463 | 11/2018 | 11/5/2018 | 99.99 | 99.99 | 99.97 |
| KU | C1S | 2090464 | 11/2018 | 11/5/2018 | 99.98 | 99.96 | 99.99 |
| KU | C1S | 2090465 | 11/2018 | 11/5/2018 | 100 | 100 | 100.01 |
| KU | C1S | 2090466 | 11/2018 | 11/5/2018 | 99.99 | 100.01 | 100.02 |
| KU | C1S | 2090467 | 11/2018 | 11/5/2018 | 99.98 | 99.98 | 99.99 |
| KU | C1S | 2090468 | 11/2018 | 11/5/2018 | 99.98 | 100 | 100.03 |
| KU | C1S | 2090469 | 11/2018 | 11/5/2018 | 99.99 | 100 | 100.02 |
| KU | C1S | 2090470 | 11/2018 | 11/5/2018 | 99.98 | 100 | 99.99 |
| KU | C1S | 2090471 | 11/2018 | 11/5/2018 | 100 | 100.01 | 99.99 |
| KU | C1S | 2090472 | 11/2018 | 11/5/2018 | 99.99 | 99.98 | 99.99 |
| KU | C1S | 2090473 | 11/2018 | 11/5/2018 | 100 | 100 | 99.99 |
| KU | C1S | 2090474 | 11/2018 | 11/5/2018 | 100 | 99.99 | 99.99 |
| KU | C1S | 2090475 | 11/2018 | 11/5/2018 | 99.98 | 99.99 | 99.99 |
| KU | C2SOS | 2404652 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.03 |
| KU | C2SOS | 2404653 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.04 |
| KU | C2SOS | 2404654 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 100.03 |
| KU | C2SOS | 2404655 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.05 |
| KU | C2SOS | 2404656 | 12/2018 | 11/30/2018 | 100.04 | 100.01 | 100.03 |
| KU | C2SOS | 2404657 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404658 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.03 |
| KU | C2SOS | 2404659 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404660 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100 |
| KU | C2SOS | 2404661 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.04 |
| KU | C2SOS | 2404662 | 12/2018 | 11/30/2018 | 100.02 | 100.06 | 100.01 |
| KU | C2SOS | 2404663 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.01 |
| KU | C2SOS | 2404664 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100 |
| KU | C2SOS | 2404665 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.04 |
| KU | C2SOS | 2404666 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 99.99 |
| KU | C2SOS | 2404667 | 12/2018 | 11/30/2018 | 100.03 | 100.07 | 100.04 |
| KU | C2SOS | 2404668 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100 |
| KU | C2SOS | 2404669 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2404670 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 99.99 |
| KU | C2SOS | 2404671 | 12/2018 | 11/30/2018 | 100.02 | 100.06 | 100.03 |
| KU | C2SOS | 2404672 | 12/2018 | 11/30/2018 | 100.03 | 99.96 | 100.01 |
| KU | C2SOS | 2404673 | 12/2018 | 11/30/2018 | 100.02 | 99.96 | 100.03 |
| KU | C2SOS | 2404674 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2404675 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2404676 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 100.03 |
| KU | C2SOS | 2404677 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.03 |
| KU | C2SOS | 2404678 | 12/2018 | 11/30/2018 | 100.03 | 100.07 | 100.02 |
| KU | C2SOS | 2404679 | 12/2018 | 11/30/2018 | 100.04 | 99.98 | 100 |
| KU | C2SOS | 2404680 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404681 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.05 |
| KU | C2SOS | 2404682 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2404683 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.04 |
| KU | C2SOS | 2404684 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2404685 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 99.98 |
| KU | C2SOS | 2404686 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404687 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100 |
| KU | C2SOS | 2404688 | 12/2018 | 11/30/2018 | 100.02 | 100.07 | 100.02 |
| KU | C2SOS | 2404689 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.99 |
| KU | C2SOS | 2404690 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.04 |
| KU | C2SOS | 2404691 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404692 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2404693 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404694 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2404695 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.01 |
| KU | C2SOS | 2404696 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 100.02 |
| KU | C2SOS | 2404697 | 12/2018 | 11/30/2018 | 100.04 | 100.09 | 100.04 |
| KU | C2SOS | 2404698 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.05 |
| KU | C2SOS | 2404699 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.01 |
| KU | C2SOS | 2404700 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.04 |
| KU | C2SOS | 2404701 | 12/2018 | 11/30/2018 | 100.03 | 99.94 | 100 |
| KU | C2SOS | 2404702 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.03 |
| KU | C2SOS | 2404703 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.03 |
| KU | C2SOS | 2404704 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.02 |
| KU | C2SOS | 2404705 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 100.01 |
| KU | C2SOS | 2404706 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 99.96 |
| KU | C2SOS | 2404707 | 12/2018 | 11/30/2018 | 100.04 | 99.99 | 100.04 |
| KU | C2SOS | 2404708 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 99.99 |
| KU | C2SOS | 2404709 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2404710 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2404711 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.04 |
| KU | C2SOS | 2404712 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2404713 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404714 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.02 |
| KU | C2SOS | 2404715 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.04 |
| KU | C2SOS | 2404716 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.01 |
| KU | C2SOS | 2404717 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100 |
| KU | C2SOS | 2404718 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.02 |
| KU | C2SOS | 2404719 | 12/2018 | 11/30/2018 | 100.04 | 100 | 100.04 |
| KU | C2SOS | 2404720 | 12/2018 | 11/30/2018 | 100.03 | 99.96 | 100.03 |
| KU | C2SOS | 2404721 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.03 |
| KU | C2SOS | 2404722 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.03 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404723 | 12/2018 | 11/30/2018 | 100.04 | 100 | 100.05 |
| KU | C2SOS | 2404724 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.01 |
| KU | C2SOS | 2404725 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.01 |
| KU | C2SOS | 2404726 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.05 |
| KU | C2SOS | 2404727 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100 |
| KU | C2SOS | 2404728 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2404729 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2404730 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404731 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 99.99 |
| KU | C2SOS | 2404732 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100 |
| KU | C2SOS | 2404733 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 99.99 |
| KU | C2SOS | 2404734 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404735 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100 |
| KU | C2SOS | 2404736 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100 |
| KU | C2SOS | 2404737 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.01 |
| KU | C2SOS | 2404738 | 12/2018 | 11/30/2018 | 100.02 | 100.09 | 100.03 |
| KU | C2SOS | 2404739 | 12/2018 | 11/30/2018 | 100.02 | 100.08 | 100 |
| KU | C2SOS | 2404740 | 12/2018 | 11/30/2018 | 100.03 | 100.12 | 100.03 |
| KU | C2SOS | 2404741 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.01 |
| KU | C2SOS | 2404742 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.02 |
| KU | C2SOS | 2404743 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.01 |
| KU | C2SOS | 2404744 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.03 |
| KU | C2SOS | 2404745 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2404746 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2404747 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404748 | 12/2018 | 11/30/2018 | 100.04 | 99.99 | 99.99 |
| KU | C2SOS | 2404749 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.04 |
| KU | C2SOS | 2404750 | 12/2018 | 11/30/2018 | 100.04 | 100.09 | 100.06 |
| KU | C2SOS | 2404751 | 12/2018 | 11/30/2018 | 100.03 | 99.97 | 99.99 |
| KU | C2SOS | 2404752 | 12/2018 | 11/30/2018 | 100.03 | 100 | 99.99 |
| KU | C2SOS | 2404753 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100 |
| KU | C2SOS | 2404754 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404755 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100 |
| KU | C2SOS | 2404756 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.03 |
| KU | C2SOS | 2404757 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.04 |
| KU | C2SOS | 2404758 | 12/2018 | 11/30/2018 | 100.04 | 100.08 | 100.04 |
| KU | C2SOS | 2404759 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.04 |
| KU | C2SOS | 2404760 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.04 |
| KU | C2SOS | 2404761 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2404762 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2404763 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.03 |
| KU | C2SOS | 2404764 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.06 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404765 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100 |
| KU | C2SOS | 2404766 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 99.99 |
| KU | C2SOS | 2404767 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100 |
| KU | C2SOS | 2404768 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404769 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.05 |
| KU | C2SOS | 2404770 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.01 |
| KU | C2SOS | 2404771 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.98 |
| KU | C2SOS | 2404772 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100 |
| KU | C2SOS | 2404773 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 100 |
| KU | C2SOS | 2404774 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.99 |
| KU | C2SOS | 2404775 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2404776 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.02 |
| KU | C2SOS | 2404777 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.02 |
| KU | C2SOS | 2404778 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404779 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404780 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 99.99 |
| KU | C2SOS | 2404781 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.04 |
| KU | C2SOS | 2404782 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404783 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.02 |
| KU | C2SOS | 2404784 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.05 |
| KU | C2SOS | 2404785 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.96 |
| KU | C2SOS | 2404786 | 12/2018 | 11/30/2018 | 100.03 | 100.08 | 100.01 |
| KU | C2SOS | 2404787 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.03 |
| KU | C2SOS | 2404788 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.96 |
| KU | C2SOS | 2404789 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.04 |
| KU | C2SOS | 2404790 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.03 |
| KU | C2SOS | 2404791 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2404792 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2404793 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.03 |
| KU | C2SOS | 2404794 | 12/2018 | 11/30/2018 | 100.04 | 99.99 | 100.01 |
| KU | C2SOS | 2404795 | 12/2018 | 11/30/2018 | 100.04 | 100.11 | 100.03 |
| KU | C2SOS | 2404796 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2404797 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.03 |
| KU | C2SOS | 2404798 | 12/2018 | 11/30/2018 | 100.03 | 100.11 | 100.02 |
| KU | C2SOS | 2404799 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100 |
| KU | C2SOS | 2404800 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.03 |
| KU | C2SOS | 2404801 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.03 |
| KU | C2SOS | 2404802 | 12/2018 | 11/30/2018 | 100.02 | 100.07 | 100.04 |
| KU | C2SOS | 2404803 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.02 |
| KU | C2SOS | 2404804 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2404805 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.05 |
| KU | C2SOS | 2404806 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404807 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 99.99 |
| KU | C2SOS | 2404808 | 12/2018 | 11/30/2018 | 100.02 | 99.98 | 100.02 |
| KU | C2SOS | 2404809 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.03 |
| KU | C2SOS | 2404810 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.01 |
| KU | C2SOS | 2404811 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2404812 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404813 | 12/2018 | 11/30/2018 | 100.03 | 99.97 | 99.99 |
| KU | C2SOS | 2404814 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2404815 | 12/2018 | 11/30/2018 | 100.03 | 99.97 | 100.03 |
| KU | C2SOS | 2404816 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.04 |
| KU | C2SOS | 2404817 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.03 |
| KU | C2SOS | 2404818 | 12/2018 | 11/30/2018 | 100.02 | 100.07 | 100.03 |
| KU | C2SOS | 2404819 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.01 |
| KU | C2SOS | 2404820 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.06 |
| KU | C2SOS | 2404821 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.03 |
| KU | C2SOS | 2404822 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2404823 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2404824 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.02 |
| KU | C2SOS | 2404825 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 100.05 |
| KU | C2SOS | 2404826 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.05 |
| KU | C2SOS | 2404827 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.04 |
| KU | C2SOS | 2404828 | 12/2018 | 11/30/2018 | 100.04 | 99.97 | 100.04 |
| KU | C2SOS | 2404829 | 12/2018 | 11/30/2018 | 100.03 | 100.1 | 100 |
| KU | C2SOS | 2404830 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404831 | 12/2018 | 11/30/2018 | 100.03 | 100.07 | 100.01 |
| KU | C2SOS | 2404832 | 12/2018 | 11/30/2018 | 100.01 | 100.01 | 100 |
| KU | C2SOS | 2404833 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100 |
| KU | C2SOS | 2404834 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404835 | 12/2018 | 11/30/2018 | 100.03 | 100.08 | 100.01 |
| KU | C2SOS | 2404836 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.03 |
| KU | C2SOS | 2404837 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.03 |
| KU | C2SOS | 2404838 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2404839 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2404840 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.03 |
| KU | C2SOS | 2404841 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.02 |
| KU | C2SOS | 2404842 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.06 |
| KU | C2SOS | 2404843 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100 |
| KU | C2SOS | 2404844 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 99.99 |
| KU | C2SOS | 2404845 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.06 |
| KU | C2SOS | 2404846 | 12/2018 | 11/30/2018 | 100.03 | 100.09 | 100.01 |
| KU | C2SOS | 2404847 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.01 |
| KU | C2SOS | 2404848 | 12/2018 | 11/30/2018 | 100.04 | 100.01 | 100.05 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404849 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.02 |
| KU | C2SOS | 2404850 | 12/2018 | 11/30/2018 | 100.03 | 100 | 99.97 |
| KU | C2SOS | 2404851 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404852 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.05 |
| KU | C2SOS | 2404853 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.04 |
| KU | C2SOS | 2404854 | 12/2018 | 11/30/2018 | 100.03 | 100.06 | 100.01 |
| KU | C2SOS | 2404855 | 12/2018 | 11/30/2018 | 100.05 | 100.03 | 100.04 |
| KU | C2SOS | 2404856 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.05 |
| KU | C2SOS | 2404857 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.06 |
| KU | C2SOS | 2404858 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100 |
| KU | C2SOS | 2404859 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.05 |
| KU | C2SOS | 2404860 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2404861 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2404862 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100 |
| KU | C2SOS | 2404863 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2404864 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2404865 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.02 |
| KU | C2SOS | 2404866 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2404867 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.05 |
| KU | C2SOS | 2404868 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.02 |
| KU | C2SOS | 2404869 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2404870 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2404871 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100 |
| KU | C2SOS | 2404872 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |
| KU | C2SOS | 2404873 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.04 |
| KU | C2SOS | 2404874 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404875 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2404876 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.03 |
| KU | C2SOS | 2404877 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100 |
| KU | C2SOS | 2404878 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.04 |
| KU | C2SOS | 2404879 | 12/2018 | 11/30/2018 | 100.03 | 100.06 | 100.03 |
| KU | C2SOS | 2404880 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |
| KU | C2SOS | 2404881 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100 |
| KU | C2SOS | 2404882 | 12/2018 | 11/30/2018 | 100.02 | 100.07 | 100.01 |
| KU | C2SOS | 2404883 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2404884 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404885 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.04 |
| KU | C2SOS | 2404886 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2404887 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.9 |
| KU | C2SOS | 2404888 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.02 |
| KU | C2SOS | 2404889 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.04 |
| KU | C2SOS | 2404890 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404891 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100 |
| KU | C2SOS | 2404892 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2404893 | 12/2018 | 11/30/2018 | 100.04 | 99.98 | 100.02 |
| KU | C2SOS | 2404894 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100 |
| KU | C2SOS | 2404895 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 100.01 |
| KU | C2SOS | 2404896 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 99.98 |
| KU | C2SOS | 2404897 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2404898 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2404899 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404900 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.04 |
| KU | C2SOS | 2404901 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2404902 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |
| KU | C2SOS | 2404903 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.03 |
| KU | C2SOS | 2404904 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.96 |
| KU | C2SOS | 2404905 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.03 |
| KU | C2SOS | 2404906 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.04 |
| KU | C2SOS | 2404907 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.98 |
| KU | C2SOS | 2404908 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2404909 | 12/2018 | 11/30/2018 | 100.02 | 99.98 | 99.99 |
| KU | C2SOS | 2404910 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.01 |
| KU | C2SOS | 2404911 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404912 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404913 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404914 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100 |
| KU | C2SOS | 2404915 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.99 |
| KU | C2SOS | 2404916 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.05 |
| KU | C2SOS | 2404917 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 99.99 |
| KU | C2SOS | 2404918 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2404919 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.01 |
| KU | C2SOS | 2404920 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.03 |
| KU | C2SOS | 2404921 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.03 |
| KU | C2SOS | 2404922 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2404923 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.03 |
| KU | C2SOS | 2404925 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404926 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2404927 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.06 |
| KU | C2SOS | 2404928 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.01 |
| KU | C2SOS | 2404929 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.03 |
| KU | C2SOS | 2404930 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2404931 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 99.99 |
| KU | C2SOS | 2404932 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.01 |
| KU | C2SOS | 2404933 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404934 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 99.98 |
| KU | C2SOS | 2404935 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2404936 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.05 |
| KU | C2SOS | 2404937 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.03 |
| KU | C2SOS | 2404938 | 12/2018 | 11/30/2018 | 100.02 | 100.06 | 100.06 |
| KU | C2SOS | 2404939 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404940 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.01 |
| KU | C2SOS | 2404941 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404942 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.99 |
| KU | C2SOS | 2404943 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.06 |
| KU | C2SOS | 2404944 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.98 |
| KU | C2SOS | 2404945 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.05 |
| KU | C2SOS | 2404946 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404947 | 12/2018 | 11/30/2018 | 100.03 | 99.96 | 99.99 |
| KU | C2SOS | 2404948 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.05 |
| KU | C2SOS | 2404949 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2404950 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.01 |
| KU | C2SOS | 2404951 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.04 |
| KU | C2SOS | 2404952 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404953 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2404954 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404955 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.02 |
| KU | C2SOS | 2404956 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100 |
| KU | C2SOS | 2404957 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 99.98 |
| KU | C2SOS | 2404958 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2404959 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.97 |
| KU | C2SOS | 2404960 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404961 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.04 |
| KU | C2SOS | 2404962 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404963 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.04 |
| KU | C2SOS | 2404964 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100 |
| KU | C2SOS | 2404965 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |
| KU | C2SOS | 2404966 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2404967 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.02 |
| KU | C2SOS | 2404968 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404969 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.04 |
| KU | C2SOS | 2404970 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.03 |
| KU | C2SOS | 2404971 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 99.99 |
| KU | C2SOS | 2404972 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2404973 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.03 |
| KU | C2SOS | 2404974 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.02 |
| KU | C2SOS | 2404975 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2404976 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.01 |
| KU | C2SOS | 2404977 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.01 |
| KU | C2SOS | 2404978 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2404979 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.03 |
| KU | C2SOS | 2404980 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.02 |
| KU | C2SOS | 2404981 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.01 |
| KU | C2SOS | 2404982 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.02 |
| KU | C2SOS | 2404983 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.02 |
| KU | C2SOS | 2404984 | 12/2018 | 11/30/2018 | 100.03 | 100.06 | 100.04 |
| KU | C2SOS | 2404985 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.99 |
| KU | C2SOS | 2404986 | 12/2018 | 11/30/2018 | 100.02 | 99.97 | 99.98 |
| KU | C2SOS | 2404987 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.01 |
| KU | C2SOS | 2404988 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.02 |
| KU | C2SOS | 2404989 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.01 |
| KU | C2SOS | 2404990 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2404991 | 12/2018 | 11/30/2018 | 100.05 | 100.06 | 100.05 |
| KU | C2SOS | 2404992 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 99.97 |
| KU | C2SOS | 2404993 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.02 |
| KU | C2SOS | 2404994 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2404995 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.03 |
| KU | C2SOS | 2404996 | 12/2018 | 11/30/2018 | 100.02 | 100.1 | 100.04 |
| KU | C2SOS | 2404997 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.04 |
| KU | C2SOS | 2404998 | 12/2018 | 11/30/2018 | 100.03 | 100 | 99.99 |
| KU | C2SOS | 2404999 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.04 |
| KU | C2SOS | 2405000 | 12/2018 | 11/30/2018 | 100.03 | 100.07 | 100.01 |
| KU | C2SOS | 2405001 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2405002 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 100.01 |
| KU | C2SOS | 2405003 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 100.04 |
| KU | C2SOS | 2405004 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.01 |
| KU | C2SOS | 2405005 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.02 |
| KU | C2SOS | 2405006 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.04 |
| KU | C2SOS | 2405007 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2405008 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.04 |
| KU | C2SOS | 2405009 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.02 |
| KU | C2SOS | 2405010 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100 |
| KU | C2SOS | 2405011 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.95 |
| KU | C2SOS | 2405012 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.01 |
| KU | C2SOS | 2405013 | 12/2018 | 11/30/2018 | 100.01 | 100.01 | 100.02 |
| KU | C2SOS | 2405014 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100.01 |
| KU | C2SOS | 2405015 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.01 |
| KU | C2SOS | 2405016 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2405017 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2405018 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.01 |
| KU | C2SOS | 2405019 | 12/2018 | 11/30/2018 | 100.02 | 100.06 | 100.05 |
| KU | C2SOS | 2405020 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.03 |
| KU | C2SOS | 2405021 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.03 |
| KU | C2SOS | 2405022 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2405023 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.03 |
| KU | C2SOS | 2405024 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2405025 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2405026 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.98 |
| KU | C2SOS | 2405027 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.01 |
| KU | C2SOS | 2405028 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.04 |
| KU | C2SOS | 2405029 | 12/2018 | 11/30/2018 | 100.02 | 99.98 | 99.99 |
| KU | C2SOS | 2405030 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.02 |
| KU | C2SOS | 2405031 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2405032 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.02 |
| KU | C2SOS | 2405033 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.01 |
| KU | C2SOS | 2405034 | 12/2018 | 11/30/2018 | 100.04 | 99.98 | 100.02 |
| KU | C2SOS | 2405035 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100 |
| KU | C2SOS | 2405036 | 12/2018 | 11/30/2018 | 100.04 | 100 | 100.06 |
| KU | C2SOS | 2405037 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.01 |
| KU | C2SOS | 2405038 | 12/2018 | 11/30/2018 | 100.02 | 100.04 | 100.02 |
| KU | C2SOS | 2405039 | 12/2018 | 11/30/2018 | 100.03 | 100.06 | 100.01 |
| KU | C2SOS | 2405040 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 99.98 |
| KU | C2SOS | 2405041 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.03 |
| KU | C2SOS | 2405042 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2405043 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.02 |
| KU | C2SOS | 2405044 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.04 |
| KU | C2SOS | 2405045 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100 |
| KU | C2SOS | 2405046 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.06 |
| KU | C2SOS | 2405047 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.01 |
| KU | C2SOS | 2405048 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 99.94 |
| KU | C2SOS | 2405049 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.01 |
| KU | C2SOS | 2405050 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 99.98 |
| KU | C2SOS | 2405051 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.03 |
| KU | C2SOS | 2405052 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2405053 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100.02 |
| KU | C2SOS | 2405054 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.03 |
| KU | C2SOS | 2405055 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2405056 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100 |
| KU | C2SOS | 2405057 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100.05 |
| KU | C2SOS | 2405058 | 12/2018 | 11/30/2018 | 100.02 | 99.94 | 100.01 |
| KU | C2SOS | 2405059 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.08 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|-------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2405060 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.02 |
| KU | C2SOS | 2405061 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.06 |
| KU | C2SOS | 2405062 | 12/2018 | 11/30/2018 | 100.04 | 100.03 | 100.09 |
| KU | C2SOS | 2405063 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 100.05 |
| KU | C2SOS | 2405064 | 12/2018 | 11/30/2018 | 100.02 | 100.08 | 100.01 |
| KU | C2SOS | 2405065 | 12/2018 | 11/30/2018 | 100.03 | 99.99 | 100.02 |
| KU | C2SOS | 2405066 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2405067 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.04 |
| KU | C2SOS | 2405068 | 12/2018 | 11/30/2018 | 100.02 | 100.05 | 99.99 |
| KU | C2SOS | 2405069 | 12/2018 | 11/30/2018 | 100.04 | 100.01 | 99.99 |
| KU | C2SOS | 2405070 | 12/2018 | 11/30/2018 | 100.04 | 100.06 | 100.04 |
| KU | C2SOS | 2405071 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.03 |
| KU | C2SOS | 2405072 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.03 |
| KU | C2SOS | 2405073 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.04 |
| KU | C2SOS | 2405074 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.04 |
| KU | C2SOS | 2405075 | 12/2018 | 11/30/2018 | 100.03 | 100.07 | 100.03 |
| KU | C2SOS | 2405076 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 99.99 |
| KU | C2SOS | 2405077 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.03 |
| KU | C2SOS | 2405078 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 100 |
| KU | C2SOS | 2405079 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2405080 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.06 |
| KU | C2SOS | 2405081 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 99.99 |
| KU | C2SOS | 2405082 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2405083 | 12/2018 | 11/30/2018 | 100.03 | 100.02 | 99.99 |
| KU | C2SOS | 2405084 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.03 |
| KU | C2SOS | 2405085 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.01 |
| KU | C2SOS | 2405086 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 99.98 |
| KU | C2SOS | 2405087 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100 |
| KU | C2SOS | 2405088 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 99.99 |
| KU | C2SOS | 2405089 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.02 |
| KU | C2SOS | 2405090 | 12/2018 | 11/30/2018 | 100.03 | 100 | 100 |
| KU | C2SOS | 2405091 | 12/2018 | 11/30/2018 | 100.03 | 100 | 99.96 |
| KU | C2SOS | 2405092 | 12/2018 | 11/30/2018 | 100.02 | 99.97 | 100.04 |
| KU | C2SOS | 2405093 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2405094 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2405095 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100 |
| KU | C2SOS | 2405096 | 12/2018 | 11/30/2018 | 100.03 | 100.08 | 100.01 |
| KU | C2SOS | 2405097 | 12/2018 | 11/30/2018 | 100.01 | 100.01 | 100.03 |
| KU | C2SOS | 2405098 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.03 |
| KU | C2SOS | 2405099 | 12/2018 | 11/30/2018 | 100.03 | 99.94 | 100.02 |
| KU | C2SOS | 2405100 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.03 |
| KU | C2SOS | 2405101 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | C2SOS | 2405102 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.02 |
| KU | C2SOS | 2405103 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100.04 |
| KU | C2SOS | 2405104 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100.02 |
| KU | C2SOS | 2405105 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100 |
| KU | C2SOS | 2405106 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100 |
| KU | C2SOS | 2405107 | 12/2018 | 11/30/2018 | 100.02 | 100.02 | 100.09 |
| KU | C2SOS | 2405108 | 12/2018 | 11/30/2018 | 100.02 | 100 | 99.99 |
| KU | C2SOS | 2405109 | 12/2018 | 11/30/2018 | 100.03 | 100.01 | 100 |
| KU | C2SOS | 2405110 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 99.96 |
| KU | C2SOS | 2405111 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.04 |
| KU | C2SOS | 2405112 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2405113 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.03 |
| KU | C2SOS | 2405114 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100.03 |
| KU | C2SOS | 2405115 | 12/2018 | 11/30/2018 | 100.02 | 99.99 | 100 |
| KU | C2SOS | 2405116 | 12/2018 | 11/30/2018 | 100.04 | 100.02 | 100.04 |
| KU | C2SOS | 2405117 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100 |
| KU | C2SOS | 2405118 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.01 |
| KU | C2SOS | 2405119 | 12/2018 | 11/30/2018 | 100.04 | 100.01 | 100.07 |
| KU | C2SOS | 2405120 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2405121 | 12/2018 | 11/30/2018 | 100.02 | 100.01 | 100.02 |
| KU | C2SOS | 2405122 | 12/2018 | 11/30/2018 | 100.04 | 100.07 | 100.05 |
| KU | C2SOS | 2405123 | 12/2018 | 11/30/2018 | 100.02 | 100.03 | 100.02 |
| KU | C2SOS | 2405124 | 12/2018 | 11/30/2018 | 100.03 | 100.05 | 100.02 |
| KU | C2SOS | 2405125 | 12/2018 | 11/30/2018 | 100.04 | 100.05 | 100.05 |
| KU | C2SOS | 2405126 | 12/2018 | 11/30/2018 | 100.04 | 100.04 | 100 |
| KU | C2SOS | 2405127 | 12/2018 | 11/30/2018 | 100.03 | 100.04 | 100.03 |
| KU | C2SOS | 2405128 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100 |
| KU | C2SOS | 2405129 | 12/2018 | 11/30/2018 | 100.03 | 99.98 | 100 |
| KU | C2SOS | 2405130 | 12/2018 | 11/30/2018 | 100.03 | 100.03 | 100 |
| KU | C2SOS | 2405131 | 12/2018 | 11/30/2018 | 100.02 | 100 | 100 |
| KU | Focus AXRe-SD Mesh | 2405132 | 11/2018 | 11/10/2018 | 99.98 | 100.01 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405133 | 11/2018 | 11/10/2018 | 100.01 | 100.02 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405134 | 11/2018 | 11/10/2018 | 99.98 | 99.98 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405135 | 11/2018 | 11/10/2018 | 99.97 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405136 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405137 | 11/2018 | 11/11/2018 | 100.04 | 100.02 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405138 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405139 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405140 | 11/2018 | 11/11/2018 | 100 | 99.98 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405141 | 11/2018 | 11/11/2018 | 100 | 100.06 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405142 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100 |
| KU | Focus AXRe-SD Mesh | 2405143 | 11/2018 | 11/11/2018 | 100 | 100.04 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405144 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405145 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405146 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405147 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405148 | 11/2018 | 11/11/2018 | 99.97 | 99.96 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405149 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405150 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405151 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405152 | 11/2018 | 11/11/2018 | 100 | 99.99 | 100 |
| KU | Focus AXRe-SD Mesh | 2405153 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405154 | 11/2018 | 11/11/2018 | 100.02 | 100.05 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405155 | 11/2018 | 11/11/2018 | 100.02 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405156 | 11/2018 | 11/11/2018 | 99.99 | 100.06 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405157 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 100 |
| KU | Focus AXRe-SD Mesh | 2405158 | 11/2018 | 11/11/2018 | 100.03 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405159 | 11/2018 | 11/11/2018 | 100.02 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405160 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405161 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405162 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405163 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405164 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405165 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405166 | 11/2018 | 11/11/2018 | 100.02 | 100.05 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405167 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405168 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405169 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405170 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405171 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405172 | 11/2018 | 11/11/2018 | 100.04 | 100.02 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405173 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405174 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405175 | 11/2018 | 11/11/2018 | 99.95 | 99.96 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405176 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405177 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405178 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405179 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405180 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405181 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405182 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405183 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405184 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405185 | 11/2018 | 11/11/2018 | 100.01 | 100.05 | 100.06 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405186 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405187 | 11/2018 | 11/11/2018 | 100.01 | 100.05 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405188 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405189 | 11/2018 | 11/11/2018 | 99.99 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405190 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405191 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405192 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405193 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405194 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405195 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405196 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405197 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405198 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405199 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405200 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405201 | 11/2018 | 11/11/2018 | 100 | 100.05 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405202 | 11/2018 | 11/11/2018 | 100.02 | 100.05 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405203 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405204 | 11/2018 | 11/11/2018 | 100.03 | 100.01 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405205 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405206 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405207 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405208 | 11/2018 | 11/11/2018 | 100.02 | 100 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405209 | 11/2018 | 11/11/2018 | 99.96 | 100.02 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405210 | 11/2018 | 11/11/2018 | 100.04 | 100.01 | 100.14 |
| KU | Focus AXRe-SD Mesh | 2405211 | 11/2018 | 11/11/2018 | 99.98 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405212 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405213 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405214 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405215 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405216 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405217 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405218 | 11/2018 | 11/11/2018 | 100 | 100.04 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405219 | 11/2018 | 11/11/2018 | 99.99 | 100.04 | 100 |
| KU | Focus AXRe-SD Mesh | 2405220 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405221 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405222 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405223 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405224 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405225 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405226 | 11/2018 | 11/11/2018 | 100 | 99.98 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405227 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405228 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405229 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405230 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405231 | 11/2018 | 11/11/2018 | 99.96 | 99.99 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405232 | 11/2018 | 11/11/2018 | 100.01 | 99.98 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405233 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405234 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405235 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405236 | 11/2018 | 11/11/2018 | 100 | 100.05 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405237 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405238 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405239 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405240 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405241 | 11/2018 | 11/11/2018 | 100 | 100 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405242 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100 |
| KU | Focus AXRe-SD Mesh | 2405243 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405244 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405245 | 11/2018 | 11/11/2018 | 99.97 | 100 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405246 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405247 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405248 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405249 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405250 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405251 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405252 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405253 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405254 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405255 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405256 | 11/2018 | 11/11/2018 | 100.03 | 100.05 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405257 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405258 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405259 | 11/2018 | 11/11/2018 | 99.95 | 99.97 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405260 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405261 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405262 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405263 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405264 | 11/2018 | 11/11/2018 | 99.95 | 99.97 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405265 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405266 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 99.91 |
| KU | Focus AXRe-SD Mesh | 2405267 | 11/2018 | 11/11/2018 | 99.95 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405268 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405269 | 11/2018 | 11/11/2018 | 99.98 | 100.03 | 100 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405270 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405271 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405272 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405273 | 11/2018 | 11/11/2018 | 100.01 | 99.98 | 100 |
| KU | Focus AXRe-SD Mesh | 2405274 | 11/2018 | 11/11/2018 | 99.99 | 100.04 | 100 |
| KU | Focus AXRe-SD Mesh | 2405275 | 11/2018 | 11/11/2018 | 100 | 100.06 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405276 | 11/2018 | 11/11/2018 | 100.04 | 100.03 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405277 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405278 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405279 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100 |
| KU | Focus AXRe-SD Mesh | 2405280 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405281 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405282 | 11/2018 | 11/11/2018 | 99.96 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405283 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405284 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405285 | 11/2018 | 11/11/2018 | 100.04 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405286 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.91 |
| KU | Focus AXRe-SD Mesh | 2405287 | 11/2018 | 11/11/2018 | 100 | 100.04 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405288 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405289 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405290 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405291 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405292 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405293 | 11/2018 | 11/11/2018 | 99.95 | 99.98 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405294 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405295 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405296 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405297 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405298 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405299 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405300 | 11/2018 | 11/11/2018 | 99.95 | 99.99 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405301 | 11/2018 | 11/11/2018 | 100.01 | 100.06 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405302 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405303 | 11/2018 | 11/11/2018 | 99.97 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405304 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405305 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405306 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405307 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405308 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405309 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405310 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405311 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405312 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405313 | 11/2018 | 11/11/2018 | 99.99 | 100.05 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405314 | 11/2018 | 11/11/2018 | 99.99 | 100.05 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405315 | 11/2018 | 11/11/2018 | 100.02 | 99.99 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405316 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405317 | 11/2018 | 11/11/2018 | 99.97 | 100.01 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405318 | 11/2018 | 11/11/2018 | 99.96 | 100.01 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405319 | 11/2018 | 11/11/2018 | 100.01 | 99.98 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405320 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405321 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405322 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405323 | 11/2018 | 11/11/2018 | 99.99 | 99.97 | 100 |
| KU | Focus AXRe-SD Mesh | 2405324 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405325 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405326 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405327 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405328 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405329 | 11/2018 | 11/11/2018 | 100 | 100.07 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405330 | 11/2018 | 11/11/2018 | 100 | 100.04 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405331 | 11/2018 | 11/11/2018 | 100.02 | 99.99 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405332 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405333 | 11/2018 | 11/11/2018 | 100.02 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405334 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405335 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405336 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405337 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405338 | 11/2018 | 11/11/2018 | 100.02 | 100.07 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405339 | 11/2018 | 11/11/2018 | 100 | 100.05 | 100 |
| KU | Focus AXRe-SD Mesh | 2405340 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405341 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405342 | 11/2018 | 11/11/2018 | 100.05 | 100.07 | 100 |
| KU | Focus AXRe-SD Mesh | 2405343 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405344 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405345 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405346 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405347 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405348 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405349 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405350 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405351 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405352 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405353 | 11/2018 | 11/11/2018 | 100.05 | 100.05 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405354 | 11/2018 | 11/11/2018 | 100.04 | 100.08 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405355 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405356 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405357 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.12 |
| KU | Focus AXRe-SD Mesh | 2405358 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405359 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100 |
| KU | Focus AXRe-SD Mesh | 2405360 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405361 | 11/2018 | 11/11/2018 | 100.02 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405362 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405363 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405364 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405365 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405366 | 11/2018 | 11/11/2018 | 99.97 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405367 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405368 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405369 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405370 | 11/2018 | 11/11/2018 | 99.96 | 99.96 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405371 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405372 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405373 | 11/2018 | 11/11/2018 | 100 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405374 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 99.91 |
| KU | Focus AXRe-SD Mesh | 2405375 | 11/2018 | 11/11/2018 | 100.02 | 100.05 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405376 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405377 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405378 | 11/2018 | 11/11/2018 | 100.05 | 100.05 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405379 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405380 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405381 | 11/2018 | 11/11/2018 | 100.03 | 100.06 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405382 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405383 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405384 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405385 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405386 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405387 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405388 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405389 | 11/2018 | 11/11/2018 | 99.99 | 100 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405390 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405391 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405392 | 11/2018 | 11/11/2018 | 99.97 | 99.99 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405393 | 11/2018 | 11/11/2018 | 100.03 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405394 | 11/2018 | 11/11/2018 | 100.02 | 100.05 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405395 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.06 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405396 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405397 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405398 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405399 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405400 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405401 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405402 | 11/2018 | 11/11/2018 | 100.04 | 100.07 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405403 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405404 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405405 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405406 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100 |
| KU | Focus AXRe-SD Mesh | 2405407 | 11/2018 | 11/11/2018 | 100.01 | 99.97 | 100 |
| KU | Focus AXRe-SD Mesh | 2405408 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405409 | 11/2018 | 11/11/2018 | 99.99 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405410 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405411 | 11/2018 | 11/11/2018 | 100.04 | 100.07 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405412 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405413 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405414 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405415 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100 |
| KU | Focus AXRe-SD Mesh | 2405416 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405417 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405418 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405419 | 11/2018 | 11/11/2018 | 100.05 | 100.03 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405420 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405421 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405422 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100 |
| KU | Focus AXRe-SD Mesh | 2405423 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405424 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405425 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405426 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405427 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405428 | 11/2018 | 11/11/2018 | 100.04 | 100.02 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405429 | 11/2018 | 11/11/2018 | 100.02 | 100 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405430 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405431 | 11/2018 | 11/11/2018 | 100.05 | 100.02 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405432 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405433 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405434 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100 |
| KU | Focus AXRe-SD Mesh | 2405435 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405436 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405437 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.1 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405438 | 11/2018 | 11/11/2018 | 99.99 | 99.98 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405439 | 11/2018 | 11/11/2018 | 100 | 100.01 | 100.14 |
| KU | Focus AXRe-SD Mesh | 2405440 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405441 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405442 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405443 | 11/2018 | 11/11/2018 | 99.97 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405444 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405445 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100 |
| KU | Focus AXRe-SD Mesh | 2405446 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100 |
| KU | Focus AXRe-SD Mesh | 2405447 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405448 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405449 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405450 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405451 | 11/2018 | 11/11/2018 | 99.97 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405452 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405453 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405454 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405455 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405456 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405457 | 11/2018 | 11/11/2018 | 100.04 | 100.07 | 99.91 |
| KU | Focus AXRe-SD Mesh | 2405458 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405459 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.91 |
| KU | Focus AXRe-SD Mesh | 2405460 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405461 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405462 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405463 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405464 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405465 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405466 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405467 | 11/2018 | 11/11/2018 | 100 | 100 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405468 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405469 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405470 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405471 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405472 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405473 | 11/2018 | 11/11/2018 | 99.96 | 99.98 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405474 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405475 | 11/2018 | 11/11/2018 | 99.96 | 99.96 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405476 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405477 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405478 | 11/2018 | 11/11/2018 | 100 | 100 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405479 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 99.98 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405480 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405481 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405482 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405483 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405484 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405485 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405486 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405487 | 11/2018 | 11/11/2018 | 100.02 | 100.01 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405488 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405489 | 11/2018 | 11/11/2018 | 100 | 100.05 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405490 | 11/2018 | 11/11/2018 | 99.99 | 100.04 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405491 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100 |
| KU | Focus AXRe-SD Mesh | 2405492 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405493 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405494 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.9 |
| KU | Focus AXRe-SD Mesh | 2405495 | 11/2018 | 11/11/2018 | 100.05 | 100.09 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405496 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405497 | 11/2018 | 11/11/2018 | 99.97 | 99.97 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405498 | 11/2018 | 11/11/2018 | 99.96 | 99.99 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405499 | 11/2018 | 11/11/2018 | 100.03 | 100.01 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405500 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405501 | 11/2018 | 11/11/2018 | 100.03 | 100 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405502 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405503 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405504 | 11/2018 | 11/11/2018 | 99.96 | 100 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405505 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405506 | 11/2018 | 11/11/2018 | 100.03 | 100.01 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405507 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405508 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405509 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405510 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405511 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405512 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405513 | 11/2018 | 11/11/2018 | 99.98 | 100.04 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405514 | 11/2018 | 11/11/2018 | 100.03 | 100.01 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405515 | 11/2018 | 11/11/2018 | 100.02 | 100.01 | 100 |
| KU | Focus AXRe-SD Mesh | 2405516 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405517 | 11/2018 | 11/11/2018 | 99.98 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405518 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405519 | 11/2018 | 11/11/2018 | 99.98 | 99.98 | 100 |
| KU | Focus AXRe-SD Mesh | 2405520 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405521 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.02 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405522 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405523 | 11/2018 | 11/11/2018 | 100.02 | 100.01 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405524 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405525 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405526 | 11/2018 | 11/11/2018 | 100.01 | 100.03 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405527 | 11/2018 | 11/11/2018 | 99.99 | 100 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405528 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405529 | 11/2018 | 11/11/2018 | 99.99 | 99.99 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405530 | 11/2018 | 11/11/2018 | 99.99 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405531 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405532 | 11/2018 | 11/11/2018 | 100.03 | 100.06 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405533 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405534 | 11/2018 | 11/11/2018 | 100.03 | 100.04 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405535 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405536 | 11/2018 | 11/11/2018 | 99.98 | 100.01 | 100 |
| KU | Focus AXRe-SD Mesh | 2405537 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405538 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405539 | 11/2018 | 11/11/2018 | 100.01 | 100.04 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405540 | 11/2018 | 11/11/2018 | 99.97 | 99.98 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405541 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405542 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405543 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 99.9 |
| KU | Focus AXRe-SD Mesh | 2405544 | 11/2018 | 11/11/2018 | 99.99 | 100.03 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405545 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405546 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405547 | 11/2018 | 11/11/2018 | 99.98 | 100 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405548 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405549 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.07 |
| KU | Focus AXRe-SD Mesh | 2405550 | 11/2018 | 11/11/2018 | 99.99 | 100 | 100.11 |
| KU | Focus AXRe-SD Mesh | 2405551 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405552 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405553 | 11/2018 | 11/11/2018 | 99.99 | 100 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405554 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405555 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405556 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405557 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405558 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405559 | 11/2018 | 11/11/2018 | 99.99 | 100 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405560 | 11/2018 | 11/11/2018 | 100 | 100.05 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405561 | 11/2018 | 11/11/2018 | 100 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405562 | 11/2018 | 11/11/2018 | 100 | 100.01 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405563 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.01 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405564 | 11/2018 | 11/11/2018 | 100 | 100.03 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405565 | 11/2018 | 11/11/2018 | 99.99 | 100.02 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405566 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405567 | 11/2018 | 11/11/2018 | 100.01 | 100 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405568 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 100 |
| KU | Focus AXRe-SD Mesh | 2405569 | 11/2018 | 11/11/2018 | 100 | 100.02 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405570 | 11/2018 | 11/11/2018 | 100 | 100 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405571 | 11/2018 | 11/11/2018 | 99.98 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405572 | 11/2018 | 11/11/2018 | 100.01 | 100.01 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405573 | 11/2018 | 11/11/2018 | 99.96 | 99.97 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405574 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405575 | 11/2018 | 11/11/2018 | 99.95 | 99.98 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405576 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405577 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405578 | 11/2018 | 11/11/2018 | 100.06 | 100.09 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405579 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405580 | 11/2018 | 11/11/2018 | 100.03 | 100.02 | 100 |
| KU | Focus AXRe-SD Mesh | 2405581 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405582 | 11/2018 | 11/11/2018 | 100.02 | 100.01 | 99.96 |
| KU | Focus AXRe-SD Mesh | 2405583 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 99.92 |
| KU | Focus AXRe-SD Mesh | 2405584 | 11/2018 | 11/11/2018 | 100.01 | 99.99 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405585 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.04 |
| KU | Focus AXRe-SD Mesh | 2405586 | 11/2018 | 11/11/2018 | 100 | 100.03 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405587 | 11/2018 | 11/11/2018 | 100.02 | 100.04 | 100.03 |
| KU | Focus AXRe-SD Mesh | 2405588 | 11/2018 | 11/11/2018 | 100.03 | 100.03 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405589 | 11/2018 | 11/11/2018 | 100 | 100.04 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405590 | 11/2018 | 11/11/2018 | 100.02 | 100.03 | 100.05 |
| KU | Focus AXRe-SD Mesh | 2405591 | 11/2018 | 11/11/2018 | 100.02 | 100.02 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405592 | 11/2018 | 11/11/2018 | 99.96 | 100 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405593 | 11/2018 | 11/11/2018 | 100.05 | 100.06 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405594 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405595 | 11/2018 | 11/11/2018 | 100.04 | 100.06 | 99.98 |
| KU | Focus AXRe-SD Mesh | 2405596 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.99 |
| KU | Focus AXRe-SD Mesh | 2405597 | 11/2018 | 11/11/2018 | 100 | 100 | 100.02 |
| KU | Focus AXRe-SD Mesh | 2405598 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405599 | 11/2018 | 11/11/2018 | 99.98 | 99.99 | 100.09 |
| KU | Focus AXRe-SD Mesh | 2405600 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 99.93 |
| KU | Focus AXRe-SD Mesh | 2405601 | 11/2018 | 11/11/2018 | 100.04 | 100.05 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405602 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.95 |
| KU | Focus AXRe-SD Mesh | 2405603 | 11/2018 | 11/11/2018 | 100.01 | 100 | 100.08 |
| KU | Focus AXRe-SD Mesh | 2405604 | 11/2018 | 11/11/2018 | 100.02 | 100.01 | 100.01 |
| KU | Focus AXRe-SD Mesh | 2405605 | 11/2018 | 11/11/2018 | 100.01 | 100.05 | 100.05 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|--------------------|---------|---------|------------|--------|--------|--------|
| KU | Focus AXRe-SD Mesh | 2405606 | 11/2018 | 11/11/2018 | 100 | 100.02 | 99.97 |
| KU | Focus AXRe-SD Mesh | 2405607 | 11/2018 | 11/11/2018 | 100.01 | 99.98 | 100 |
| KU | Focus AXRe-SD Mesh | 2405608 | 11/2018 | 11/11/2018 | 99.98 | 99.97 | 100.06 |
| KU | Focus AXRe-SD Mesh | 2405609 | 11/2018 | 11/11/2018 | 99.99 | 100.01 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405610 | 11/2018 | 11/11/2018 | 100.04 | 100.04 | 99.94 |
| KU | Focus AXRe-SD Mesh | 2405611 | 11/2018 | 11/11/2018 | 100.01 | 100.02 | 100.03 |
| KU | C1SR | 2513063 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.96 |
| KU | C1SR | 2513064 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.94 |
| KU | C1SR | 2513065 | 10/2018 | 10/16/2018 | 100 | 99.99 | 99.94 |
| KU | C1SR | 2513066 | 10/2018 | 10/16/2018 | 99.98 | 99.94 | 99.94 |
| KU | C1SR | 2513067 | 10/2018 | 10/16/2018 | 99.99 | 100.06 | 100.04 |
| KU | C1SR | 2513068 | 10/2018 | 10/16/2018 | 99.99 | 100.05 | 99.99 |
| KU | C1SR | 2513069 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.99 |
| KU | C1SR | 2513070 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.9 |
| KU | C1SR | 2513071 | 10/2018 | 10/16/2018 | 99.99 | 99.98 | 99.94 |
| KU | C1SR | 2513072 | 10/2018 | 10/16/2018 | 99.99 | 99.93 | 99.91 |
| KU | C1SR | 2513073 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1SR | 2513074 | 10/2018 | 10/16/2018 | 99.99 | 99.92 | 99.92 |
| KU | C1SR | 2513075 | 10/2018 | 10/16/2018 | 99.96 | 100.07 | 99.96 |
| KU | C1SR | 2513076 | 10/2018 | 10/16/2018 | 99.99 | 100.05 | 99.96 |
| KU | C1SR | 2513077 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.93 |
| KU | C1SR | 2513078 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.94 |
| KU | C1SR | 2513079 | 10/2018 | 10/16/2018 | 100.02 | 100.07 | 99.97 |
| KU | C1SR | 2513080 | 10/2018 | 10/16/2018 | 99.97 | 100.05 | 99.96 |
| KU | C1SR | 2513081 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.98 |
| KU | C1SR | 2513082 | 10/2018 | 10/16/2018 | 100.03 | 99.9 | 99.87 |
| KU | C1SR | 2513083 | 10/2018 | 10/16/2018 | 100 | 100.08 | 100.02 |
| KU | C1SR | 2513084 | 10/2018 | 10/16/2018 | 100.06 | 99.99 | 99.94 |
| KU | C1SR | 2513085 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.92 |
| KU | C1SR | 2513086 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.98 |
| KU | C1SR | 2513087 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1SR | 2513088 | 10/2018 | 10/16/2018 | 99.97 | 99.99 | 99.96 |
| KU | C1SR | 2513089 | 10/2018 | 10/16/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1SR | 2513090 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 99.96 |
| KU | C1SR | 2513091 | 10/2018 | 10/16/2018 | 100.02 | 99.91 | 99.87 |
| KU | C1SR | 2513092 | 10/2018 | 10/16/2018 | 99.98 | 99.91 | 99.9 |
| KU | C1SR | 2513093 | 10/2018 | 10/16/2018 | 99.96 | 99.91 | 99.88 |
| KU | C1SR | 2513094 | 10/2018 | 10/16/2018 | 99.98 | 100.06 | 99.96 |
| KU | C1SR | 2513095 | 10/2018 | 10/16/2018 | 100.01 | 100.05 | 99.97 |
| KU | C1SR | 2513096 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.93 |
| KU | C1SR | 2513097 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.95 |
| KU | C1SR | 2513098 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.95 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513099 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.96 |
| KU | C1SR | 2513100 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.95 |
| KU | C1SR | 2513101 | 10/2018 | 10/16/2018 | 99.98 | 100 | 99.93 |
| KU | C1SR | 2513102 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.94 |
| KU | C1SR | 2513103 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.91 |
| KU | C1SR | 2513104 | 10/2018 | 10/16/2018 | 100.01 | 100.06 | 99.96 |
| KU | C1SR | 2513105 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.93 |
| KU | C1SR | 2513106 | 10/2018 | 10/16/2018 | 100.01 | 99.91 | 99.95 |
| KU | C1SR | 2513107 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.94 |
| KU | C1SR | 2513108 | 10/2018 | 10/16/2018 | 99.99 | 100.07 | 99.99 |
| KU | C1SR | 2513109 | 10/2018 | 10/16/2018 | 99.98 | 100 | 99.96 |
| KU | C1SR | 2513110 | 10/2018 | 10/16/2018 | 100.01 | 100.05 | 99.95 |
| KU | C1SR | 2513111 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.97 |
| KU | C1SR | 2513112 | 10/2018 | 10/16/2018 | 100.04 | 99.97 | 99.89 |
| KU | C1SR | 2513113 | 10/2018 | 10/16/2018 | 100 | 100.04 | 100.01 |
| KU | C1SR | 2513114 | 10/2018 | 10/16/2018 | 99.96 | 99.94 | 99.91 |
| KU | C1SR | 2513115 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.96 |
| KU | C1SR | 2513116 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.92 |
| KU | C1SR | 2513117 | 10/2018 | 10/16/2018 | 100.01 | 100.04 | 99.93 |
| KU | C1SR | 2513118 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.95 |
| KU | C1SR | 2513119 | 10/2018 | 10/16/2018 | 99.96 | 99.99 | 99.92 |
| KU | C1SR | 2513120 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.9 |
| KU | C1SR | 2513121 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1SR | 2513122 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.97 |
| KU | C1SR | 2513123 | 10/2018 | 10/16/2018 | 100.02 | 100.05 | 99.98 |
| KU | C1SR | 2513124 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.97 |
| KU | C1SR | 2513125 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.93 |
| KU | C1SR | 2513126 | 10/2018 | 10/16/2018 | 99.97 | 100.01 | 99.93 |
| KU | C1SR | 2513127 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.98 |
| KU | C1SR | 2513128 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.91 |
| KU | C1SR | 2513129 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.97 |
| KU | C1SR | 2513130 | 10/2018 | 10/16/2018 | 99.97 | 100.02 | 99.95 |
| KU | C1SR | 2513131 | 10/2018 | 10/16/2018 | 99.97 | 100.02 | 99.98 |
| KU | C1SR | 2513132 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.95 |
| KU | C1SR | 2513133 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.97 |
| KU | C1SR | 2513134 | 10/2018 | 10/16/2018 | 100 | 100.07 | 99.99 |
| KU | C1SR | 2513135 | 10/2018 | 10/16/2018 | 100.01 | 100.05 | 100 |
| KU | C1SR | 2513136 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1SR | 2513137 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 100 |
| KU | C1SR | 2513138 | 10/2018 | 10/16/2018 | 100.03 | 99.98 | 99.88 |
| KU | C1SR | 2513139 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.99 |
| KU | C1SR | 2513140 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513141 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.94 |
| KU | C1SR | 2513142 | 10/2018 | 10/16/2018 | 99.99 | 100.05 | 99.97 |
| KU | C1SR | 2513143 | 10/2018 | 10/16/2018 | 100.04 | 100.02 | 99.93 |
| KU | C1SR | 2513144 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.97 |
| KU | C1SR | 2513145 | 10/2018 | 10/16/2018 | 99.97 | 99.95 | 99.95 |
| KU | C1SR | 2513146 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.96 |
| KU | C1SR | 2513147 | 10/2018 | 10/16/2018 | 100.02 | 99.91 | 99.95 |
| KU | C1SR | 2513148 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.99 |
| KU | C1SR | 2513149 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.98 |
| KU | C1SR | 2513150 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.97 |
| KU | C1SR | 2513151 | 10/2018 | 10/16/2018 | 99.99 | 100.06 | 99.96 |
| KU | C1SR | 2513152 | 10/2018 | 10/16/2018 | 99.98 | 99.94 | 99.96 |
| KU | C1SR | 2513153 | 10/2018 | 10/16/2018 | 99.99 | 100.04 | 99.99 |
| KU | C1SR | 2513154 | 10/2018 | 10/16/2018 | 100 | 99.99 | 100 |
| KU | C1SR | 2513155 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.92 |
| KU | C1SR | 2513156 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1SR | 2513157 | 10/2018 | 10/16/2018 | 99.99 | 99.97 | 100 |
| KU | C1SR | 2513158 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.93 |
| KU | C1SR | 2513159 | 10/2018 | 10/16/2018 | 100.01 | 100.08 | 100.01 |
| KU | C1SR | 2513160 | 10/2018 | 10/16/2018 | 100.03 | 100.06 | 99.96 |
| KU | C1SR | 2513161 | 10/2018 | 10/16/2018 | 99.98 | 99.99 | 99.93 |
| KU | C1SR | 2513162 | 10/2018 | 10/16/2018 | 100 | 100.05 | 99.97 |
| KU | C1SR | 2513163 | 10/2018 | 10/16/2018 | 99.96 | 100.01 | 99.94 |
| KU | C1SR | 2513164 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1SR | 2513165 | 10/2018 | 10/16/2018 | 100 | 100.06 | 100.01 |
| KU | C1SR | 2513166 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.98 |
| KU | C1SR | 2513167 | 10/2018 | 10/16/2018 | 100.01 | 99.94 | 99.95 |
| KU | C1SR | 2513168 | 10/2018 | 10/16/2018 | 100.03 | 99.95 | 99.96 |
| KU | C1SR | 2513169 | 10/2018 | 10/16/2018 | 99.97 | 99.95 | 99.9 |
| KU | C1SR | 2513170 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.93 |
| KU | C1SR | 2513171 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 100 |
| KU | C1SR | 2513172 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.93 |
| KU | C1SR | 2513173 | 10/2018 | 10/16/2018 | 99.98 | 100.01 | 99.94 |
| KU | C1SR | 2513174 | 10/2018 | 10/16/2018 | 100 | 100.02 | 100 |
| KU | C1SR | 2513175 | 10/2018 | 10/16/2018 | 99.97 | 99.97 | 99.91 |
| KU | C1SR | 2513176 | 10/2018 | 10/16/2018 | 100.03 | 99.95 | 99.93 |
| KU | C1SR | 2513177 | 10/2018 | 10/16/2018 | 100 | 100.06 | 99.97 |
| KU | C1SR | 2513178 | 10/2018 | 10/16/2018 | 99.98 | 100.04 | 99.96 |
| KU | C1SR | 2513179 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.97 |
| KU | C1SR | 2513180 | 10/2018 | 10/16/2018 | 100.03 | 99.92 | 99.89 |
| KU | C1SR | 2513181 | 10/2018 | 10/16/2018 | 99.99 | 99.96 | 99.95 |
| KU | C1SR | 2513182 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513183 | 10/2018 | 10/16/2018 | 100.03 | 99.98 | 99.98 |
| KU | C1SR | 2513184 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.97 |
| KU | C1SR | 2513185 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1SR | 2513186 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 100.01 |
| KU | C1SR | 2513187 | 10/2018 | 10/16/2018 | 99.97 | 99.96 | 99.94 |
| KU | C1SR | 2513188 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.98 |
| KU | C1SR | 2513189 | 10/2018 | 10/16/2018 | 99.97 | 99.92 | 99.9 |
| KU | C1SR | 2513190 | 10/2018 | 10/16/2018 | 100.03 | 99.98 | 99.95 |
| KU | C1SR | 2513191 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.94 |
| KU | C1SR | 2513192 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.95 |
| KU | C1SR | 2513193 | 10/2018 | 10/16/2018 | 99.97 | 99.92 | 99.88 |
| KU | C1SR | 2513194 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.92 |
| KU | C1SR | 2513195 | 10/2018 | 10/16/2018 | 100.02 | 99.93 | 99.95 |
| KU | C1SR | 2513196 | 10/2018 | 10/16/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1SR | 2513197 | 10/2018 | 10/16/2018 | 100.01 | 99.94 | 99.92 |
| KU | C1SR | 2513198 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.96 |
| KU | C1SR | 2513199 | 10/2018 | 10/16/2018 | 100 | 99.91 | 99.92 |
| KU | C1SR | 2513200 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.94 |
| KU | C1SR | 2513201 | 10/2018 | 10/16/2018 | 99.97 | 99.96 | 99.97 |
| KU | C1SR | 2513202 | 10/2018 | 10/16/2018 | 100 | 100.05 | 99.98 |
| KU | C1SR | 2513203 | 10/2018 | 10/16/2018 | 100.04 | 99.95 | 99.95 |
| KU | C1SR | 2513204 | 10/2018 | 10/16/2018 | 100.03 | 99.94 | 99.94 |
| KU | C1SR | 2513205 | 10/2018 | 10/16/2018 | 100.01 | 100.04 | 99.94 |
| KU | C1SR | 2513206 | 10/2018 | 10/16/2018 | 100.03 | 100.07 | 100.02 |
| KU | C1SR | 2513207 | 10/2018 | 10/16/2018 | 99.94 | 99.97 | 99.94 |
| KU | C1SR | 2513208 | 10/2018 | 10/16/2018 | 100.01 | 99.92 | 99.89 |
| KU | C1SR | 2513209 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 100.01 |
| KU | C1SR | 2513210 | 10/2018 | 10/16/2018 | 99.97 | 99.94 | 99.99 |
| KU | C1SR | 2513211 | 10/2018 | 10/16/2018 | 99.97 | 100.07 | 99.98 |
| KU | C1SR | 2513212 | 10/2018 | 10/16/2018 | 100.01 | 99.97 | 99.95 |
| KU | C1SR | 2513213 | 10/2018 | 10/16/2018 | 100.01 | 99.99 | 99.96 |
| KU | C1SR | 2513214 | 10/2018 | 10/16/2018 | 100.02 | 99.94 | 99.92 |
| KU | C1SR | 2513215 | 10/2018 | 10/16/2018 | 100 | 99.94 | 99.97 |
| KU | C1SR | 2513216 | 10/2018 | 10/16/2018 | 100.02 | 100.07 | 99.99 |
| KU | C1SR | 2513217 | 10/2018 | 10/16/2018 | 99.98 | 99.98 | 99.92 |
| KU | C1SR | 2513218 | 10/2018 | 10/16/2018 | 99.99 | 99.98 | 99.9 |
| KU | C1SR | 2513219 | 10/2018 | 10/16/2018 | 99.99 | 99.97 | 99.95 |
| KU | C1SR | 2513220 | 10/2018 | 10/16/2018 | 100 | 99.92 | 99.94 |
| KU | C1SR | 2513221 | 10/2018 | 10/16/2018 | 100.03 | 100.03 | 99.99 |
| KU | C1SR | 2513222 | 10/2018 | 10/16/2018 | 100.04 | 100.01 | 99.99 |
| KU | C1SR | 2513223 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.92 |
| KU | C1SR | 2513224 | 10/2018 | 10/16/2018 | 100.03 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513225 | 10/2018 | 10/16/2018 | 100.02 | 99.99 | 99.92 |
| KU | C1SR | 2513226 | 10/2018 | 10/16/2018 | 99.99 | 99.93 | 99.91 |
| KU | C1SR | 2513227 | 10/2018 | 10/16/2018 | 100.03 | 100 | 99.95 |
| KU | C1SR | 2513228 | 10/2018 | 10/16/2018 | 99.94 | 100.02 | 100 |
| KU | C1SR | 2513229 | 10/2018 | 10/16/2018 | 100 | 99.94 | 99.95 |
| KU | C1SR | 2513230 | 10/2018 | 10/16/2018 | 100.04 | 99.97 | 99.93 |
| KU | C1SR | 2513231 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.94 |
| KU | C1SR | 2513232 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.94 |
| KU | C1SR | 2513233 | 10/2018 | 10/16/2018 | 100 | 99.94 | 99.89 |
| KU | C1SR | 2513234 | 10/2018 | 10/16/2018 | 100.01 | 100.05 | 100.02 |
| KU | C1SR | 2513235 | 10/2018 | 10/16/2018 | 100 | 99.9 | 99.91 |
| KU | C1SR | 2513236 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.92 |
| KU | C1SR | 2513237 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1SR | 2513238 | 10/2018 | 10/16/2018 | 99.96 | 99.91 | 99.88 |
| KU | C1SR | 2513239 | 10/2018 | 10/16/2018 | 100 | 99.92 | 99.91 |
| KU | C1SR | 2513240 | 10/2018 | 10/16/2018 | 99.97 | 99.93 | 99.86 |
| KU | C1SR | 2513241 | 10/2018 | 10/16/2018 | 100.04 | 99.95 | 99.98 |
| KU | C1SR | 2513242 | 10/2018 | 10/16/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1SR | 2513243 | 10/2018 | 10/16/2018 | 99.99 | 99.92 | 99.9 |
| KU | C1SR | 2513244 | 10/2018 | 10/16/2018 | 99.99 | 99.91 | 99.89 |
| KU | C1SR | 2513245 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.94 |
| KU | C1SR | 2513246 | 10/2018 | 10/16/2018 | 100.03 | 99.97 | 99.95 |
| KU | C1SR | 2513247 | 10/2018 | 10/16/2018 | 100.03 | 99.91 | 99.88 |
| KU | C1SR | 2513248 | 10/2018 | 10/16/2018 | 100 | 100.02 | 100.03 |
| KU | C1SR | 2513249 | 10/2018 | 10/16/2018 | 99.99 | 100.04 | 99.99 |
| KU | C1SR | 2513250 | 10/2018 | 10/16/2018 | 100 | 99.94 | 99.96 |
| KU | C1SR | 2513251 | 10/2018 | 10/16/2018 | 99.97 | 99.95 | 99.9 |
| KU | C1SR | 2513252 | 10/2018 | 10/16/2018 | 100.01 | 99.91 | 99.9 |
| KU | C1SR | 2513253 | 10/2018 | 10/16/2018 | 100.01 | 99.92 | 99.87 |
| KU | C1SR | 2513254 | 10/2018 | 10/16/2018 | 100.04 | 99.93 | 99.94 |
| KU | C1SR | 2513255 | 10/2018 | 10/16/2018 | 100.01 | 100.04 | 99.98 |
| KU | C1SR | 2513256 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.93 |
| KU | C1SR | 2513257 | 10/2018 | 10/16/2018 | 99.96 | 100.02 | 99.93 |
| KU | C1SR | 2513258 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 99.94 |
| KU | C1SR | 2513259 | 10/2018 | 10/16/2018 | 99.98 | 100.05 | 99.97 |
| KU | C1SR | 2513260 | 10/2018 | 10/16/2018 | 99.97 | 99.92 | 99.9 |
| KU | C1SR | 2513261 | 10/2018 | 10/16/2018 | 99.99 | 99.92 | 99.88 |
| KU | C1SR | 2513262 | 10/2018 | 10/16/2018 | 100 | 99.91 | 99.9 |
| KU | C1SR | 2513263 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.93 |
| KU | C1SR | 2513264 | 10/2018 | 10/16/2018 | 100.02 | 99.94 | 99.91 |
| KU | C1SR | 2513265 | 10/2018 | 10/16/2018 | 99.99 | 99.97 | 99.98 |
| KU | C1SR | 2513266 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.99 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|-------|
| KU | C1SR | 2513267 | 10/2018 | 10/16/2018 | 100.01 | 99.92 | 99.89 |
| KU | C1SR | 2513268 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.92 |
| KU | C1SR | 2513269 | 10/2018 | 10/16/2018 | 100 | 100.05 | 99.98 |
| KU | C1SR | 2513270 | 10/2018 | 10/16/2018 | 100 | 99.94 | 99.89 |
| KU | C1SR | 2513271 | 10/2018 | 10/16/2018 | 100 | 100 | 99.96 |
| KU | C1SR | 2513272 | 10/2018 | 10/16/2018 | 99.98 | 100.04 | 100 |
| KU | C1SR | 2513273 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.97 |
| KU | C1SR | 2513274 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.95 |
| KU | C1SR | 2513275 | 10/2018 | 10/16/2018 | 99.99 | 99.99 | 99.94 |
| KU | C1SR | 2513276 | 10/2018 | 10/16/2018 | 99.99 | 99.98 | 99.92 |
| KU | C1SR | 2513277 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.93 |
| KU | C1SR | 2513278 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.91 |
| KU | C1SR | 2513279 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.89 |
| KU | C1SR | 2513280 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.98 |
| KU | C1SR | 2513281 | 10/2018 | 10/16/2018 | 99.99 | 99.99 | 99.96 |
| KU | C1SR | 2513282 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.99 |
| KU | C1SR | 2513283 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.97 |
| KU | C1SR | 2513284 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.93 |
| KU | C1SR | 2513285 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.93 |
| KU | C1SR | 2513286 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.94 |
| KU | C1SR | 2513287 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.95 |
| KU | C1SR | 2513288 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.97 |
| KU | C1SR | 2513289 | 10/2018 | 10/16/2018 | 99.97 | 99.97 | 99.98 |
| KU | C1SR | 2513290 | 10/2018 | 10/16/2018 | 99.99 | 99.99 | 99.91 |
| KU | C1SR | 2513291 | 10/2018 | 10/16/2018 | 99.95 | 100 | 99.9 |
| KU | C1SR | 2513292 | 10/2018 | 10/16/2018 | 100.02 | 99.99 | 99.93 |
| KU | C1SR | 2513293 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.96 |
| KU | C1SR | 2513294 | 10/2018 | 10/16/2018 | 100.03 | 100.01 | 99.94 |
| KU | C1SR | 2513295 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.93 |
| KU | C1SR | 2513296 | 10/2018 | 10/16/2018 | 99.98 | 99.99 | 99.91 |
| KU | C1SR | 2513297 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.96 |
| KU | C1SR | 2513298 | 10/2018 | 10/16/2018 | 100.02 | 100 | 99.92 |
| KU | C1SR | 2513299 | 10/2018 | 10/16/2018 | 100.05 | 100.04 | 99.98 |
| KU | C1SR | 2513300 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.93 |
| KU | C1SR | 2513301 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.96 |
| KU | C1SR | 2513302 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.99 |
| KU | C1SR | 2513303 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.99 |
| KU | C1SR | 2513304 | 10/2018 | 10/16/2018 | 100.02 | 100 | 99.93 |
| KU | C1SR | 2513305 | 10/2018 | 10/16/2018 | 99.97 | 99.96 | 99.92 |
| KU | C1SR | 2513306 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.92 |
| KU | C1SR | 2513307 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.93 |
| KU | C1SR | 2513308 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.96 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513309 | 10/2018 | 10/16/2018 | 99.96 | 100.05 | 99.95 |
| KU | C1SR | 2513310 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.97 |
| KU | C1SR | 2513311 | 10/2018 | 10/16/2018 | 99.97 | 100.04 | 99.94 |
| KU | C1SR | 2513312 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.93 |
| KU | C1SR | 2513313 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.98 |
| KU | C1SR | 2513314 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.95 |
| KU | C1SR | 2513315 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 99.95 |
| KU | C1SR | 2513316 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.93 |
| KU | C1SR | 2513317 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.91 |
| KU | C1SR | 2513318 | 10/2018 | 10/16/2018 | 100 | 100.06 | 100 |
| KU | C1SR | 2513319 | 10/2018 | 10/16/2018 | 99.96 | 100.01 | 99.94 |
| KU | C1SR | 2513320 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.94 |
| KU | C1SR | 2513321 | 10/2018 | 10/16/2018 | 100.03 | 100.04 | 99.98 |
| KU | C1SR | 2513322 | 10/2018 | 10/16/2018 | 100 | 100.03 | 100.05 |
| KU | C1SR | 2513323 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1SR | 2513324 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.93 |
| KU | C1SR | 2513325 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.97 |
| KU | C1SR | 2513326 | 10/2018 | 10/16/2018 | 100.01 | 99.99 | 99.92 |
| KU | C1SR | 2513327 | 10/2018 | 10/16/2018 | 100.04 | 100.04 | 99.94 |
| KU | C1SR | 2513328 | 10/2018 | 10/16/2018 | 100.05 | 99.99 | 99.89 |
| KU | C1SR | 2513329 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.95 |
| KU | C1SR | 2513330 | 10/2018 | 10/16/2018 | 99.97 | 100.01 | 99.94 |
| KU | C1SR | 2513331 | 10/2018 | 10/16/2018 | 100 | 99.99 | 99.9 |
| KU | C1SR | 2513332 | 10/2018 | 10/16/2018 | 100 | 99.99 | 99.95 |
| KU | C1SR | 2513333 | 10/2018 | 10/16/2018 | 100.02 | 100.06 | 99.97 |
| KU | C1SR | 2513334 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.93 |
| KU | C1SR | 2513335 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.93 |
| KU | C1SR | 2513336 | 10/2018 | 10/16/2018 | 100 | 100.07 | 100 |
| KU | C1SR | 2513337 | 10/2018 | 10/16/2018 | 99.97 | 100.02 | 99.95 |
| KU | C1SR | 2513338 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.96 |
| KU | C1SR | 2513339 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.94 |
| KU | C1SR | 2513340 | 10/2018 | 10/16/2018 | 100.03 | 100 | 99.93 |
| KU | C1SR | 2513341 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.93 |
| KU | C1SR | 2513342 | 10/2018 | 10/16/2018 | 100.04 | 100.02 | 99.94 |
| KU | C1SR | 2513343 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.93 |
| KU | C1SR | 2513344 | 10/2018 | 10/16/2018 | 100 | 100.05 | 99.96 |
| KU | C1SR | 2513345 | 10/2018 | 10/16/2018 | 100 | 100 | 99.91 |
| KU | C1SR | 2513346 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.95 |
| KU | C1SR | 2513347 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.97 |
| KU | C1SR | 2513348 | 10/2018 | 10/16/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1SR | 2513349 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.96 |
| KU | C1SR | 2513350 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513351 | 10/2018 | 10/16/2018 | 99.98 | 100 | 99.99 |
| KU | C1SR | 2513352 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 100.01 |
| KU | C1SR | 2513353 | 10/2018 | 10/16/2018 | 99.99 | 99.93 | 99.93 |
| KU | C1SR | 2513354 | 10/2018 | 10/16/2018 | 100 | 100.05 | 99.97 |
| KU | C1SR | 2513355 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.98 |
| KU | C1SR | 2513356 | 10/2018 | 10/16/2018 | 100 | 100.01 | 100 |
| KU | C1SR | 2513357 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.92 |
| KU | C1SR | 2513358 | 10/2018 | 10/16/2018 | 99.97 | 99.99 | 99.97 |
| KU | C1SR | 2513359 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.92 |
| KU | C1SR | 2513360 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.94 |
| KU | C1SR | 2513361 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.96 |
| KU | C1SR | 2513362 | 10/2018 | 10/16/2018 | 99.97 | 100.04 | 100.02 |
| KU | C1SR | 2513363 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.97 |
| KU | C1SR | 2513364 | 10/2018 | 10/16/2018 | 99.98 | 99.94 | 99.9 |
| KU | C1SR | 2513365 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.96 |
| KU | C1SR | 2513366 | 10/2018 | 10/16/2018 | 100.06 | 99.93 | 99.92 |
| KU | C1SR | 2513367 | 10/2018 | 10/16/2018 | 99.98 | 100.06 | 99.98 |
| KU | C1SR | 2513368 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.99 |
| KU | C1SR | 2513369 | 10/2018 | 10/16/2018 | 100 | 100.05 | 100 |
| KU | C1SR | 2513370 | 10/2018 | 10/16/2018 | 100.01 | 99.94 | 99.93 |
| KU | C1SR | 2513371 | 10/2018 | 10/16/2018 | 100 | 99.92 | 99.96 |
| KU | C1SR | 2513372 | 10/2018 | 10/16/2018 | 99.98 | 100.08 | 100 |
| KU | C1SR | 2513373 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1SR | 2513374 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.93 |
| KU | C1SR | 2513375 | 10/2018 | 10/16/2018 | 100.02 | 99.91 | 99.91 |
| KU | C1SR | 2513376 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.95 |
| KU | C1SR | 2513377 | 10/2018 | 10/16/2018 | 100 | 99.93 | 99.91 |
| KU | C1SR | 2513378 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.94 |
| KU | C1SR | 2513379 | 10/2018 | 10/16/2018 | 99.98 | 99.96 | 99.91 |
| KU | C1SR | 2513380 | 10/2018 | 10/16/2018 | 99.97 | 100.05 | 100.04 |
| KU | C1SR | 2513381 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.9 |
| KU | C1SR | 2513382 | 10/2018 | 10/16/2018 | 100.01 | 100.07 | 99.99 |
| KU | C1SR | 2513383 | 10/2018 | 10/16/2018 | 99.96 | 100.05 | 99.98 |
| KU | C1SR | 2513384 | 10/2018 | 10/16/2018 | 100 | 99.96 | 99.92 |
| KU | C1SR | 2513385 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.95 |
| KU | C1SR | 2513386 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.93 |
| KU | C1SR | 2513387 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.98 |
| KU | C1SR | 2513388 | 10/2018 | 10/16/2018 | 100.03 | 100.02 | 99.93 |
| KU | C1SR | 2513389 | 10/2018 | 10/16/2018 | 99.97 | 100.04 | 99.98 |
| KU | C1SR | 2513390 | 10/2018 | 10/16/2018 | 100 | 100.03 | 100.01 |
| KU | C1SR | 2513391 | 10/2018 | 10/16/2018 | 99.97 | 99.95 | 99.91 |
| KU | C1SR | 2513392 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.87 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|-------|
| KU | C1SR | 2513393 | 10/2018 | 10/16/2018 | 99.97 | 100.01 | 99.93 |
| KU | C1SR | 2513394 | 10/2018 | 10/16/2018 | 100 | 99.96 | 99.97 |
| KU | C1SR | 2513395 | 10/2018 | 10/16/2018 | 99.98 | 99.98 | 99.87 |
| KU | C1SR | 2513396 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.97 |
| KU | C1SR | 2513397 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.92 |
| KU | C1SR | 2513398 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.92 |
| KU | C1SR | 2513399 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.91 |
| KU | C1SR | 2513400 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.89 |
| KU | C1SR | 2513401 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.95 |
| KU | C1SR | 2513402 | 10/2018 | 10/16/2018 | 99.98 | 100.01 | 99.92 |
| KU | C1SR | 2513403 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.96 |
| KU | C1SR | 2513404 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.91 |
| KU | C1SR | 2513405 | 10/2018 | 10/16/2018 | 100.03 | 99.96 | 99.94 |
| KU | C1SR | 2513406 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.93 |
| KU | C1SR | 2513407 | 10/2018 | 10/16/2018 | 100.02 | 100 | 99.93 |
| KU | C1SR | 2513408 | 10/2018 | 10/16/2018 | 99.99 | 100.05 | 99.98 |
| KU | C1SR | 2513409 | 10/2018 | 10/16/2018 | 99.99 | 99.98 | 99.91 |
| KU | C1SR | 2513410 | 10/2018 | 10/16/2018 | 99.96 | 100 | 99.96 |
| KU | C1SR | 2513411 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.92 |
| KU | C1SR | 2513412 | 10/2018 | 10/16/2018 | 100.03 | 99.97 | 99.92 |
| KU | C1SR | 2513413 | 10/2018 | 10/16/2018 | 99.99 | 100.01 | 100 |
| KU | C1SR | 2513414 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.95 |
| KU | C1SR | 2513415 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.88 |
| KU | C1SR | 2513416 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.92 |
| KU | C1SR | 2513417 | 10/2018 | 10/16/2018 | 99.99 | 99.99 | 99.93 |
| KU | C1SR | 2513418 | 10/2018 | 10/16/2018 | 100.02 | 99.99 | 99.94 |
| KU | C1SR | 2513419 | 10/2018 | 10/16/2018 | 100 | 100 | 99.93 |
| KU | C1SR | 2513420 | 10/2018 | 10/16/2018 | 100 | 100.01 | 99.92 |
| KU | C1SR | 2513421 | 10/2018 | 10/16/2018 | 100.04 | 99.98 | 99.95 |
| KU | C1SR | 2513422 | 10/2018 | 10/16/2018 | 100 | 100 | 99.92 |
| KU | C1SR | 2513423 | 10/2018 | 10/16/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1SR | 2513424 | 10/2018 | 10/16/2018 | 100.02 | 99.97 | 99.95 |
| KU | C1SR | 2513425 | 10/2018 | 10/16/2018 | 99.96 | 100.06 | 99.95 |
| KU | C1SR | 2513426 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.97 |
| KU | C1SR | 2513427 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.96 |
| KU | C1SR | 2513428 | 10/2018 | 10/16/2018 | 99.98 | 100.02 | 99.93 |
| KU | C1SR | 2513429 | 10/2018 | 10/16/2018 | 100.07 | 100.04 | 99.94 |
| KU | C1SR | 2513430 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.96 |
| KU | C1SR | 2513431 | 10/2018 | 10/16/2018 | 99.96 | 99.96 | 99.96 |
| KU | C1SR | 2513432 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1SR | 2513433 | 10/2018 | 10/16/2018 | 100.01 | 99.95 | 99.96 |
| KU | C1SR | 2513434 | 10/2018 | 10/16/2018 | 99.99 | 99.96 | 99.92 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|-------|
| KU | C1SR | 2513435 | 10/2018 | 10/16/2018 | 100.03 | 100.01 | 99.93 |
| KU | C1SR | 2513436 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.94 |
| KU | C1SR | 2513437 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.9 |
| KU | C1SR | 2513438 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.99 |
| KU | C1SR | 2513439 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.94 |
| KU | C1SR | 2513440 | 10/2018 | 10/16/2018 | 99.97 | 100.02 | 99.92 |
| KU | C1SR | 2513441 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.94 |
| KU | C1SR | 2513442 | 10/2018 | 10/16/2018 | 100 | 100 | 99.95 |
| KU | C1SR | 2513443 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.95 |
| KU | C1SR | 2513444 | 10/2018 | 10/16/2018 | 100 | 100 | 99.91 |
| KU | C1SR | 2513445 | 10/2018 | 10/16/2018 | 100.01 | 99.97 | 99.94 |
| KU | C1SR | 2513446 | 10/2018 | 10/16/2018 | 100.01 | 99.96 | 99.97 |
| KU | C1SR | 2513447 | 10/2018 | 10/16/2018 | 100 | 99.96 | 99.93 |
| KU | C1SR | 2513448 | 10/2018 | 10/16/2018 | 100.01 | 100.04 | 99.92 |
| KU | C1SR | 2513449 | 10/2018 | 10/16/2018 | 99.95 | 99.97 | 99.92 |
| KU | C1SR | 2513450 | 10/2018 | 10/16/2018 | 100.04 | 100.05 | 99.95 |
| KU | C1SR | 2513451 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.95 |
| KU | C1SR | 2513452 | 10/2018 | 10/16/2018 | 99.98 | 99.97 | 99.97 |
| KU | C1SR | 2513453 | 10/2018 | 10/16/2018 | 100.02 | 99.95 | 99.98 |
| KU | C1SR | 2513454 | 10/2018 | 10/16/2018 | 100.04 | 99.96 | 99.91 |
| KU | C1SR | 2513455 | 10/2018 | 10/16/2018 | 100 | 100 | 99.94 |
| KU | C1SR | 2513456 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.95 |
| KU | C1SR | 2513457 | 10/2018 | 10/16/2018 | 100.01 | 99.99 | 99.91 |
| KU | C1SR | 2513458 | 10/2018 | 10/16/2018 | 100.02 | 100.01 | 99.92 |
| KU | C1SR | 2513459 | 10/2018 | 10/16/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1SR | 2513460 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.99 |
| KU | C1SR | 2513461 | 10/2018 | 10/16/2018 | 100 | 100 | 99.95 |
| KU | C1SR | 2513462 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.93 |
| KU | C1SR | 2513463 | 10/2018 | 10/16/2018 | 100.01 | 99.97 | 99.96 |
| KU | C1SR | 2513464 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.94 |
| KU | C1SR | 2513465 | 10/2018 | 10/16/2018 | 100.02 | 99.97 | 99.92 |
| KU | C1SR | 2513466 | 10/2018 | 10/16/2018 | 99.97 | 99.96 | 99.96 |
| KU | C1SR | 2513467 | 10/2018 | 10/16/2018 | 99.97 | 99.94 | 99.91 |
| KU | C1SR | 2513468 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.96 |
| KU | C1SR | 2513469 | 10/2018 | 10/16/2018 | 100.01 | 100.03 | 99.99 |
| KU | C1SR | 2513470 | 10/2018 | 10/16/2018 | 100.03 | 99.98 | 99.94 |
| KU | C1SR | 2513471 | 10/2018 | 10/16/2018 | 99.99 | 100.04 | 99.98 |
| KU | C1SR | 2513472 | 10/2018 | 10/16/2018 | 100.02 | 100.06 | 99.96 |
| KU | C1SR | 2513473 | 10/2018 | 10/16/2018 | 100.02 | 99.97 | 99.93 |
| KU | C1SR | 2513474 | 10/2018 | 10/16/2018 | 100.01 | 99.93 | 99.87 |
| KU | C1SR | 2513475 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.97 |
| KU | C1SR | 2513476 | 10/2018 | 10/16/2018 | 100.03 | 99.95 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513477 | 10/2018 | 10/16/2018 | 100.02 | 100 | 99.97 |
| KU | C1SR | 2513478 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 100.01 |
| KU | C1SR | 2513479 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 99.93 |
| KU | C1SR | 2513480 | 10/2018 | 10/16/2018 | 100 | 99.97 | 99.93 |
| KU | C1SR | 2513481 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1SR | 2513482 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 99.97 |
| KU | C1SR | 2513483 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.95 |
| KU | C1SR | 2513484 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.91 |
| KU | C1SR | 2513485 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.96 |
| KU | C1SR | 2513486 | 10/2018 | 10/16/2018 | 100.02 | 100.04 | 100.02 |
| KU | C1SR | 2513487 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.96 |
| KU | C1SR | 2513488 | 10/2018 | 10/16/2018 | 100.03 | 100.03 | 99.96 |
| KU | C1SR | 2513489 | 10/2018 | 10/16/2018 | 99.97 | 99.98 | 99.97 |
| KU | C1SR | 2513490 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.92 |
| KU | C1SR | 2513491 | 10/2018 | 10/16/2018 | 100.02 | 99.96 | 99.93 |
| KU | C1SR | 2513492 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1SR | 2513493 | 10/2018 | 10/16/2018 | 99.98 | 99.99 | 99.92 |
| KU | C1SR | 2513494 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.94 |
| KU | C1SR | 2513495 | 10/2018 | 10/16/2018 | 100.02 | 99.94 | 99.9 |
| KU | C1SR | 2513496 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.93 |
| KU | C1SR | 2513497 | 10/2018 | 10/16/2018 | 100.03 | 100 | 99.93 |
| KU | C1SR | 2513498 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.9 |
| KU | C1SR | 2513499 | 10/2018 | 10/16/2018 | 99.98 | 99.94 | 99.92 |
| KU | C1SR | 2513500 | 10/2018 | 10/16/2018 | 100.02 | 100.02 | 99.91 |
| KU | C1SR | 2513501 | 10/2018 | 10/16/2018 | 99.98 | 100.07 | 100 |
| KU | C1SR | 2513502 | 10/2018 | 10/16/2018 | 99.99 | 99.97 | 99.96 |
| KU | C1SR | 2513503 | 10/2018 | 10/16/2018 | 99.96 | 99.94 | 99.93 |
| KU | C1SR | 2513504 | 10/2018 | 10/16/2018 | 99.99 | 100 | 99.93 |
| KU | C1SR | 2513505 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.93 |
| KU | C1SR | 2513506 | 10/2018 | 10/16/2018 | 100.03 | 99.98 | 99.92 |
| KU | C1SR | 2513507 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.95 |
| KU | C1SR | 2513508 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.95 |
| KU | C1SR | 2513509 | 10/2018 | 10/16/2018 | 99.98 | 100.01 | 99.96 |
| KU | C1SR | 2513510 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.92 |
| KU | C1SR | 2513511 | 10/2018 | 10/16/2018 | 100 | 100.03 | 99.94 |
| KU | C1SR | 2513512 | 10/2018 | 10/16/2018 | 100 | 99.99 | 99.96 |
| KU | C1SR | 2513513 | 10/2018 | 10/16/2018 | 100 | 99.98 | 99.94 |
| KU | C1SR | 2513514 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.97 |
| KU | C1SR | 2513515 | 10/2018 | 10/16/2018 | 99.98 | 99.96 | 99.94 |
| KU | C1SR | 2513516 | 10/2018 | 10/16/2018 | 99.95 | 99.96 | 99.95 |
| KU | C1SR | 2513517 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.91 |
| KU | C1SR | 2513518 | 10/2018 | 10/16/2018 | 100.04 | 99.98 | 99.93 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|--------|
| KU | C1SR | 2513519 | 10/2018 | 10/16/2018 | 99.98 | 100 | 99.89 |
| KU | C1SR | 2513520 | 10/2018 | 10/16/2018 | 100.04 | 100.05 | 99.97 |
| KU | C1SR | 2513521 | 10/2018 | 10/16/2018 | 99.97 | 99.94 | 99.89 |
| KU | C1SR | 2513522 | 10/2018 | 10/16/2018 | 100 | 100.02 | 99.92 |
| KU | C1SR | 2513523 | 10/2018 | 10/16/2018 | 99.99 | 100.04 | 99.93 |
| KU | C1SR | 2513524 | 10/2018 | 10/16/2018 | 99.99 | 99.96 | 99.97 |
| KU | C1SR | 2513525 | 10/2018 | 10/16/2018 | 99.99 | 99.94 | 99.95 |
| KU | C1SR | 2513526 | 10/2018 | 10/16/2018 | 99.97 | 100.01 | 99.95 |
| KU | C1SR | 2513527 | 10/2018 | 10/16/2018 | 99.99 | 100.03 | 99.98 |
| KU | C1SR | 2513528 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.94 |
| KU | C1SR | 2513529 | 10/2018 | 10/16/2018 | 99.99 | 100.01 | 99.95 |
| KU | C1SR | 2513530 | 10/2018 | 10/16/2018 | 100.01 | 100 | 99.92 |
| KU | C1SR | 2513531 | 10/2018 | 10/16/2018 | 100 | 99.99 | 99.94 |
| KU | C1SR | 2513532 | 10/2018 | 10/16/2018 | 100 | 99.93 | 99.92 |
| KU | C1SR | 2513533 | 10/2018 | 10/16/2018 | 99.99 | 99.92 | 99.91 |
| KU | C1SR | 2513534 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.93 |
| KU | C1SR | 2513535 | 10/2018 | 10/16/2018 | 99.99 | 100.02 | 99.94 |
| KU | C1SR | 2513536 | 10/2018 | 10/16/2018 | 99.97 | 99.96 | 99.96 |
| KU | C1SR | 2513537 | 10/2018 | 10/16/2018 | 99.99 | 100.04 | 99.96 |
| KU | C1SR | 2513538 | 10/2018 | 10/16/2018 | 99.96 | 100.02 | 99.94 |
| KU | C1SR | 2513539 | 10/2018 | 10/16/2018 | 99.96 | 100.04 | 100.01 |
| KU | C1SR | 2513540 | 10/2018 | 10/16/2018 | 99.98 | 100 | 99.94 |
| KU | C1SR | 2513541 | 10/2018 | 10/16/2018 | 100.01 | 99.98 | 99.95 |
| KU | C1SR | 2513542 | 10/2018 | 10/16/2018 | 100 | 100.04 | 99.93 |
| KU | C1SR | 2513543 | 10/2018 | 10/16/2018 | 100.02 | 100 | 99.9 |
| KU | C1SR | 2513544 | 10/2018 | 10/16/2018 | 100.01 | 99.97 | 99.93 |
| KU | C1SR | 2513545 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.93 |
| KU | C1SR | 2513546 | 10/2018 | 10/16/2018 | 99.99 | 99.95 | 99.93 |
| KU | C1SR | 2513547 | 10/2018 | 10/16/2018 | 100 | 99.95 | 99.92 |
| KU | C1SR | 2513548 | 10/2018 | 10/16/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1SR | 2513549 | 10/2018 | 10/16/2018 | 99.98 | 99.95 | 99.9 |
| KU | C1SR | 2513550 | 10/2018 | 10/16/2018 | 99.97 | 100.05 | 99.96 |
| KU | C1SR | 2513551 | 10/2018 | 10/16/2018 | 99.98 | 100.03 | 99.96 |
| KU | C1SR | 2513552 | 10/2018 | 10/16/2018 | 100.01 | 100.01 | 99.96 |
| KU | C1SR | 2513553 | 10/2018 | 10/16/2018 | 100.02 | 100.05 | 99.94 |
| KU | C1SR | 2513554 | 10/2018 | 10/16/2018 | 99.98 | 100.04 | 99.94 |
| KU | C1SR | 2513555 | 10/2018 | 10/16/2018 | 99.97 | 100.07 | 100.01 |
| KU | C1SR | 2513556 | 10/2018 | 10/16/2018 | 100.02 | 99.98 | 99.95 |
| KU | C1SR | 2513557 | 10/2018 | 10/16/2018 | 99.98 | 99.97 | 99.93 |
| KU | C1SR | 2513558 | 10/2018 | 10/16/2018 | 100.01 | 100.02 | 99.93 |
| KU | C1SR | 2513559 | 10/2018 | 10/16/2018 | 99.99 | 99.96 | 99.94 |
| KU | C1SR | 2513560 | 10/2018 | 10/16/2018 | 100.02 | 99.99 | 99.94 |

5040 Annual Report of

7/2018 - 12/2018

| | | | | | | | |
|----|------|---------|---------|------------|--------|--------|------------------------------------|
| KU | C1SR | 2513561 | 10/2018 | 10/16/2018 | 100.02 | 100.03 | 99.93 |
| KU | C1SR | 2513562 | 10/2018 | 10/16/2018 | 100 | 99.96 | 99.94 |
| | | | | | | | Total Meter Count: 4699 |

**ATTACHMENT
B**

**2018 Statistical Sampling Test Results
and Summary**

KU
2018 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE

In-Service Population 501,774 Divided into 63 Lots

Sample Quantity 4,269

Meters Tested 4,269

Meters Not Tested 0

Failed Lots 0

Failed Lot Meters 0

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : Focus AXR - Mesh Division : 01 Sample Lot : 2466 Lot Descr : KU Focus AX-1

In Service Population : 1059 Sample Quantity : 35 Meters Tested : 35 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2400072 | 99.9 | 2400197 | 99.9 | 2400217 | 99.9 | 2400226 | 99.9 | 2400236 | 100 |
| 2400251 | 99.9 | 2400277 | 100.1 | 2400365 | 99.9 | 2400386 | 100 | 2400387 | 99.889 |
| 2400392 | 100 | 2400399 | 99.9 | 2400441 | 99.9 | 2400448 | 100 | 2400463 | 100 |
| 2400466 | 100.1 | 2400474 | 100 | 2402010 | 100 | 2402021 | 100 | 2402023 | 100 |
| 2402024 | 100 | 2402134 | 100.1 | 2402301 | 100 | 2402319 | 100 | 2402370 | 100 |
| 2403001 | 99.9 | 2403028 | 99.9 | 2403096 | 100.02 | 2403128 | 100 | 2403149 | 100 |
| 2403160 | 100 | 2403172 | 100 | 2403186 | 99.9 | 2403216 | 99.882 | 2403298 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 35 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 3498.99 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 349798.37 | Quality Index Upper (QU) : (U - XBAR) / S | 20.26 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 349798.03 | Quality Index Lower (QL) : (XBAR - L) / S | 19.69 |
| Corrected Sum of Squares (SS) | 0.34 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.10 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.97 | Maximum Allowable Percent NCF (M) | 5.58 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : AB1R Division : 01 Sample Lot : 2467 Lot Descr : KU AB1-1
 In Service Population : 5584 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C333251 | 99.9 | C333304 | 99.3 | C333314 | 99.329 | C333487 | 99.8 | C333517 | 100.204 |
| C334428 | 99.9 | C334642 | 100.3 | C334758 | 99.4 | C334790 | 99.2 | C334875 | 99.9 |
| C335121 | 99.6 | C335156 | 99.1 | C344913 | 99.9 | C344919 | 100.5 | C408203 | 99.7 |
| C408205 | 100.2 | C408241 | 100.2 | C408242 | 99.3 | C408602 | 100.3 | C408620 | 100.5 |
| C408725 | 99.7 | C408910 | 99.2 | C408980 | 100.4 | C408990 | 99.9 | C409125 | 99.5 |
| C409139 | 100.2 | C409177 | 99.4 | C409182 | 99.4 | C409275 | 99.2 | C409460 | 99.5 |
| C409492 | 99.6 | C409511 | 99.817 | C409553 | 99.3 | C409560 | 99.4 | C409577 | 99.2 |
| C409637 | 100.2 | C409701 | 99.1 | C409711 | 100.3 | C409832 | 98.5 | C409850 | 100.2 |
| C409872 | 100.1 | C409967 | 100.3 | C409970 | 100.1 | C433843 | 100.303 | C433852 | 100.2 |
| C433948 | 100.1 | C434257 | 100.4 | C434424 | 100.2 | C434474 | 100.4 | C434555 | 100 |
| C434582 | 99.9 | C434735 | 100.295 | C434741 | 100.3 | C434893 | 100.2 | C435110 | 100 |
| C435133 | 100 | C435148 | 99.9 | C435170 | 100 | C435189 | 100.1 | C435358 | 100.1 |
| L300410 | 99.5 | L300833 | 100.187 | L302457 | 100.5 | L302534 | 100.1 | L302686 | 100 |
| L302820 | 98.9 | L302849 | 99.939 | L303068 | 99.3 | L303109 | 99.7 | L303151 | 99.5 |
| L303159 | 100.5 | L303280 | 99.8 | L303397 | 100 | M444660 | 100.1 | W147191 | 99.5 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7488.97 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 747810.89 | Quality Index Upper (QU) : (U - XBAR) / S | 4.73 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 747795.62 | Quality Index Lower (QL) : (XBAR - L) / S | 4.08 |
| Corrected Sum of Squares (SS) | 15.27 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.21 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.45 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.85 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : ALF Division : 01 Sample Lot : 2468 Lot Descr : KU ALF-1

In Service Population : 394 Sample Quantity : 20 Meters Tested : 20 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2505759 | 100.02 | 2506206 | 99.981 | 2507497 | 99.9 | 2507511 | 100 | 2507542 | 100 |
| 2507543 | 99.9 | 2507547 | 99.8 | 2507678 | 99.9 | 2507715 | 99.9 | 2507717 | 99.878 |
| 2507781 | 100 | 2507801 | 100 | 2507816 | 100 | 2507825 | 100 | 2507876 | 100 |
| 2507886 | 99.9 | 2507943 | 100 | 2507970 | 100 | 2508000 | 100 | 2508010 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 20 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 1999.08 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 199815.92 | Quality Index Upper (QU) : (U - XBAR) / S | 25.50 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 199816.04 | Quality Index Lower (QL) : (XBAR - L) / S | 24.35 |
| Corrected Sum of Squares (SS) | 0.12 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.08 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.95 | Maximum Allowable Percent NCF (M) | 6.18 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2469 Lot Descr : KU C1S-1
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2000043 | 100 | 2000317 | 100 | 2000474 | 100 | 2000709 | 100 | C352363 | 99.927 |
| C352390 | 99.9 | C352393 | 99.9 | C352435 | 100 | C352462 | 100 | C352529 | 100 |
| C352720 | 100.1 | C352972 | 100.1 | C369091 | 100.1 | C369126 | 100.2 | C380752 | 99.997 |
| C380866 | 100 | C380907 | 100 | C380960 | 100.1 | C381093 | 100.1 | C381415 | 100 |
| C381665 | 100.1 | C381696 | 100.3 | C381716 | 100.151 | C381928 | 100 | C382084 | 100.147 |
| C383071 | 99.9 | C383339 | 100 | C407189 | 100.1 | C407398 | 100.2 | C407430 | 100.1 |
| C407575 | 99.8 | C407582 | 100.1 | C407818 | 100 | C416006 | 100.174 | C416135 | 100.022 |
| C416227 | 100.1 | C416321 | 100 | C416730 | 100 | C416967 | 100.2 | C416971 | 100.1 |
| C417154 | 100 | C417225 | 100 | C417488 | 100 | C417530 | 100.307 | C465628 | 99.8 |
| C466041 | 99.918 | C466104 | 100 | C466223 | 99.9 | C466447 | 100 | C466457 | 100.1 |
| C466481 | 100.1 | C466492 | 100.1 | C466580 | 100 | C466692 | 100.1 | C466706 | 100.048 |
| C466839 | 99.8 | C466851 | 100 | C466866 | 100 | C466921 | 99.8 | C467115 | 100 |
| C467407 | 100.142 | C467540 | 100.2 | C468030 | 100.1 | C468086 | 100.1 | C468123 | 99.9 |
| C468182 | 100.1 | C468535 | 100 | C468538 | 100 | C468561 | 99.9 | C468586 | 100 |
| C468667 | 100.1 | C468862 | 100 | C469033 | 100 | C469039 | 100 | C469277 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7502.23 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 750447.50 | Quality Index Upper (QU) : (U - XBAR) / S | 14.16 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 750446.07 | Quality Index Lower (QL) : (XBAR - L) / S | 14.58 |
| Corrected Sum of Squares (SS) | 1.43 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.02 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.14 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.03 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2470 Lot Descr : KU C1S-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2000829 | 100.1 | 2000969 | 100 | 2001029 | 100.2 | 2001113 | 100 | 2001289 | 100.2 |
| 2001356 | 100 | 2001688 | 100 | 2001835 | 100.1 | 2002157 | 100.007 | 2002378 | 100 |
| 2002435 | 100 | 2002442 | 100.1 | 2002626 | 100.1 | 2002647 | 100.1 | 2002739 | 100 |
| 2002823 | 100 | 2003351 | 99.995 | 2003828 | 100 | 2003914 | 100 | 2003917 | 99.9 |
| 2004055 | 100.1 | 2004376 | 99.8 | 2004401 | 100 | 2004408 | 100.1 | 2004411 | 100 |
| 2004549 | 99.963 | 2004575 | 99.9 | 2004759 | 99.9 | 2004784 | 99.8 | 2005083 | 100.1 |
| 2005085 | 100 | 2005177 | 100 | 2005438 | 100 | 2005460 | 100 | 2005551 | 99.7 |
| 2006128 | 99.8 | 2006238 | 100 | 2006380 | 100 | 2006430 | 100 | 2006440 | 99.9 |
| 2006509 | 100 | 2006510 | 100 | 2006996 | 100.038 | 2007033 | 100 | 2007151 | 99.864 |
| 2007180 | 100 | 2007414 | 99.9 | 2007545 | 99.9 | 2007569 | 99.9 | 2007649 | 99.9 |
| 2007883 | 99.8 | 2008004 | 100 | 2008074 | 99.9 | 2008134 | 100 | 2008186 | 100 |
| 2008403 | 99.8 | 2008432 | 99.9 | 2008649 | 100 | 2008701 | 99.9 | 2008861 | 99.796 |
| 2008898 | 100 | 2009624 | 99.9 | 2009687 | 99.916 | 2010003 | 100 | 2010606 | 99.9 |
| 2010649 | 100 | 2010678 | 100.133 | 2011023 | 100.1 | 2011057 | 100 | 2011096 | 99.9 |
| 2011112 | 100.1 | 2011140 | 100 | 2011439 | 100 | 2011537 | 100.1 | 2011607 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7498.41 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749683.12 | Quality Index Upper (QU) : (U - XBAR) / S | 16.68 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749682.03 | Quality Index Lower (QL) : (XBAR - L) / S | 16.33 |
| Corrected Sum of Squares (SS) | 1.09 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.12 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.98 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C15 Division : 01 Sample Lot : 2471 Lot Descr : KU C1S-3
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2011756 | 100 | 2012582 | 100.1 | 2012739 | 100 | 2012755 | 100.073 | 2012845 | 99.939 |
| 2013349 | 99.8 | 2013542 | 99.771 | 2013546 | 99.8 | 2013788 | 100 | 2013913 | 100 |
| 2014095 | 99.7 | 2014343 | 100 | 2014893 | 99.9 | 2015010 | 99.95 | 2015270 | 100 |
| 2015329 | 100 | 2015331 | 99.9 | 2015445 | 99.9 | 2015494 | 100.1 | 2015603 | 99.9 |
| 2015631 | 100 | 2015686 | 99.9 | 2015748 | 100.1 | 2015796 | 99.9 | 2015814 | 100 |
| 2015842 | 100 | 2015995 | 100.1 | 2016072 | 99.9 | 2016237 | 100 | 2017111 | 99.9 |
| 2017147 | 99.9 | 2017418 | 100.1 | 2017543 | 100 | 2017615 | 99.9 | 2017721 | 99.7 |
| 2017874 | 100.1 | 2017925 | 99.9 | 2017945 | 100 | 2018033 | 100.1 | 2018062 | 100.1 |
| 2018523 | 99.8 | 2018574 | 99.8 | 2018641 | 99.9 | 2018980 | 99.8 | 2019152 | 100 |
| 2019184 | 99.9 | 2019346 | 99.9 | 2019406 | 100.2 | 2019629 | 99.9 | 2019862 | 99.8 |
| 2019891 | 99.9 | 2019907 | 99.8 | 2020046 | 100 | 2020117 | 99.9 | 2020216 | 99.9 |
| 2020425 | 100 | 2020516 | 100 | 2020523 | 100.1 | 2020612 | 99.9 | 2020691 | 100 |
| 2021025 | 100.1 | 2021339 | 100 | 2021343 | 99.9 | 2021468 | 100 | 2021541 | 99.9 |
| 2021553 | 100.1 | 2022023 | 100.061 | 2022116 | 100.1 | 2022321 | 100.1 | 2022913 | 100.087 |
| 2022943 | 99.7 | 2023019 | 99.8 | 2023056 | 100.098 | 2023087 | 100.1 | 2023164 | 100.15 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7497.13 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749426.89 | Quality Index Upper (QU) : (U - XBAR) / S | 19.85 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749426.11 | Quality Index Lower (QL) : (XBAR - L) / S | 19.11 |
| Corrected Sum of Squares (SS) | 0.78 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.10 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.96 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2472 Lot Descr : KU C1S-4
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2023344 | 100 | 2023794 | 100 | 2023825 | 100 | 2024219 | 100 | 2024447 | 100.037 |
| 2024815 | 100.1 | 2024912 | 100.1 | 2024941 | 100 | 2025051 | 100 | 2025096 | 100 |
| 2025300 | 100 | 2025313 | 99.9 | 2025377 | 100.1 | 2025629 | 100 | 2025635 | 100 |
| 2025644 | 100.1 | 2025815 | 99.8 | 2025834 | 99.9 | 2026082 | 100 | 2026251 | 99.8 |
| 2026315 | 100 | 2026484 | 99.9 | 2026819 | 99.9 | 2026842 | 99.9 | 2026954 | 100 |
| 2027013 | 99.9 | 2027015 | 99.7 | 2027071 | 100.051 | 2027394 | 99.9 | 2027433 | 99.9 |
| 2027443 | 99.8 | 2027445 | 100.1 | 2027456 | 99.941 | 2027487 | 100 | 2027549 | 100 |
| 2027852 | 99.9 | 2028019 | 100.017 | 2028029 | 99.9 | 2028141 | 100 | 2028290 | 99.9 |
| 2028293 | 100 | 2028977 | 100.1 | 2029082 | 100.085 | 2029193 | 99.9 | 2029540 | 100.2 |
| 2029668 | 100 | 2030089 | 100.1 | 2030142 | 100 | 2030177 | 99.9 | 2030252 | 100 |
| 2030344 | 100 | 2030498 | 100 | 2030826 | 100.1 | 2031118 | 100.2 | 2031438 | 100.1 |
| 2031464 | 100 | 2031497 | 100.1 | 2031531 | 100 | 2031574 | 100 | 2031660 | 99.9 |
| 2031732 | 100 | 2031821 | 99.986 | 2032101 | 100 | 2032125 | 100 | 2032431 | 100 |
| 2032687 | 99.9 | 2032891 | 100.055 | 2033069 | 100.1 | 2033111 | 99.859 | 2033217 | 100.1 |
| 2033592 | 100 | 2033641 | 100 | 2033681 | 99.9 | 2033724 | 99.9 | 2033821 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7498.83 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749766.86 | Quality Index Upper (QU) : (U - XBAR) / S | 18.90 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749766.02 | Quality Index Lower (QL) : (XBAR - L) / S | 18.61 |
| Corrected Sum of Squares (SS) | 0.84 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.11 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.98 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2473 Lot Descr : KU C1S-5
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2034127 | 100 | 2034378 | 99.9 | 2034383 | 100 | 2034530 | 100 | 2035182 | 100 |
| 2035243 | 100.1 | 2035245 | 99.9 | 2035304 | 99.9 | 2035431 | 100.1 | 2035551 | 100 |
| 2035552 | 100.1 | 2035611 | 100 | 2035777 | 100.1 | 2035788 | 99.9 | 2035822 | 100 |
| 2036148 | 100.1 | 2036213 | 100 | 2036295 | 100.1 | 2036453 | 100 | 2037783 | 100.1 |
| 2037817 | 99.9 | 2037878 | 100.1 | 2037880 | 99.9 | 2038233 | 99.8 | 2038240 | 99.984 |
| 2038297 | 100 | 2038462 | 99.9 | 2038499 | 100 | 2038695 | 100.1 | 2038698 | 100 |
| 2038940 | 100.1 | 2038962 | 99.9 | 2039076 | 100.002 | 2039097 | 100 | 2039365 | 99.9 |
| 2039532 | 100 | 2039575 | 100.3 | 2039915 | 100.1 | 2040173 | 99.9 | 2040517 | 100.1 |
| 2040518 | 99.8 | 2040636 | 99.9 | 2040842 | 100.1 | 2040992 | 100 | 2041016 | 99.998 |
| 2041259 | 100 | 2041674 | 100 | 2042429 | 100.1 | 2042484 | 99.9 | 2042542 | 100.1 |
| 2042627 | 99.8 | 2043058 | 99.9 | 2043126 | 100 | 2043131 | 100.1 | 2043183 | 99.961 |
| 2043281 | 99.9 | 2043326 | 99.9 | 2043692 | 99.964 | 2044702 | 100 | 2044807 | 100 |
| 2044974 | 100.1 | 2045021 | 99.9 | 2045065 | 100 | 2045334 | 100 | 2045348 | 100 |
| 2045638 | 100 | 2045878 | 100 | 2045886 | 99.9 | 2046015 | 100 | 2046069 | 100 |
| 2046188 | 100 | 2046339 | 100 | 2046356 | 100 | 2046490 | 100.1 | 2046491 | 99.974 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7499.68 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749937.16 | Quality Index Upper (QU) : (U - XBAR) / S | 16.02 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749936.00 | Quality Index Lower (QL) : (XBAR - L) / S | 15.95 |
| Corrected Sum of Squares (SS) | 1.16 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.02 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.13 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.00 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2474 Lot Descr : KU C1S-6
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2046563 | 100.1 | 2046883 | 99.9 | 2046954 | 100 | 2047098 | 99.9 | 2047249 | 99.8 |
| 2047263 | 99.9 | 2047767 | 100 | 2048576 | 99.9 | 2048795 | 100.1 | 2048916 | 99.7 |
| 2048990 | 100.1 | 2049097 | 99.85 | 2049102 | 99.9 | 2049319 | 100 | 2049348 | 100 |
| 2049448 | 100.1 | 2049606 | 100 | 2049657 | 100 | 2049715 | 100 | 2050147 | 100.1 |
| 2050155 | 100 | 2050183 | 100.1 | 2050301 | 100 | 2050322 | 100 | 2051816 | 100 |
| 2051968 | 100 | 2051991 | 99.9 | 2052021 | 99.9 | 2052124 | 99.8 | 2052492 | 99.934 |
| 2052570 | 99.9 | 2052605 | 99.9 | 2052785 | 100 | 2053051 | 99.986 | 2053571 | 100.018 |
| 2053735 | 100.046 | 2053928 | 100 | 2053952 | 99.9 | 2054005 | 99.9 | 2054046 | 99.9 |
| 2054151 | 99.9 | 2054237 | 99.928 | 2054269 | 100 | 2054407 | 99.8 | 2054821 | 99.945 |
| 2054930 | 100.08 | 2054953 | 100 | 2055019 | 99.9 | 2055223 | 99.9 | 2055230 | 100 |
| 2055318 | 99.7 | 2055342 | 99.9 | 2055620 | 100 | 2055810 | 99.9 | 2055816 | 100 |
| 2055851 | 100 | 2055858 | 99.9 | 2055863 | 100 | 2055959 | 100 | 2056030 | 100 |
| 2056261 | 99.9 | 2056989 | 100.01 | 2057038 | 99.9 | 2057048 | 100 | 2057135 | 100 |
| 2057173 | 100 | 2057209 | 99.9 | 2057221 | 99.8 | 2057381 | 100 | 2057502 | 99.9 |
| 2057539 | 99.9 | 2057707 | 99.9 | 2057796 | 100 | 2057800 | 100 | 2057849 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7496.50 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749300.09 | Quality Index Upper (QU) : (U - XBAR) / S | 65.01 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749300.16 | Quality Index Lower (QL) : (XBAR - L) / S | 62.05 |
| Corrected Sum of Squares (SS) | 0.07 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.00 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.03 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.95 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2475 Lot Descr : KU C1S-7
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2058669 | 99.9 | 2058861 | 100 | 2058862 | 99.9 | 2059078 | 99.9 | 2059265 | 100 |
| 2059527 | 100 | 2059686 | 100 | 2059733 | 99.9 | 2059885 | 99.9 | 2060063 | 100 |
| 2060088 | 99.9 | 2060124 | 99.9 | 2060258 | 100 | 2060264 | 99.9 | 2060429 | 100 |
| 2060642 | 99.8 | 2060854 | 99.908 | 2060939 | 99.9 | 2061071 | 100 | 2061218 | 99.9 |
| 2061315 | 99.9 | 2061444 | 99.9 | 2061489 | 100 | 2061496 | 99.871 | 2061527 | 99.8 |
| 2061558 | 100 | 2061596 | 99.8 | 2061636 | 99.835 | 2062145 | 100 | 2062302 | 99.9 |
| 2062319 | 99.8 | 2062595 | 99.9 | 2062719 | 99.9 | 2062988 | 100 | 2063177 | 99.991 |
| 2063200 | 100 | 2063221 | 99.9 | 2063242 | 99.9 | 2063580 | 100 | 2064189 | 99.9 |
| 2064419 | 100 | 2064490 | 99.9 | 2064513 | 99.9 | 2064864 | 100 | 2065045 | 99.8 |
| 2065162 | 99.9 | 2065263 | 99.9 | 2065271 | 99.8 | 2065385 | 99.9 | 2065452 | 100.1 |
| 2065602 | 100 | 2065657 | 99.8 | 2065733 | 99.8 | 2065942 | 100.046 | 2066152 | 100 |
| 2066320 | 100 | 2066474 | 99.9 | 2066655 | 100 | 2067064 | 100 | 2067140 | 99.9 |
| 2067428 | 100 | 2067475 | 100 | 2067628 | 100 | 2067739 | 100 | 2068082 | 100 |
| 2068102 | 99.982 | 2068241 | 100 | 2068284 | 100 | 2068589 | 99.8 | 2068910 | 100 |
| 2069185 | 100 | 2069348 | 100 | 2069400 | 100 | 2069509 | 100 | 2069540 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7495.33 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749067.28 | Quality Index Upper (QU) : (U - XBAR) / S | 17.84 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749066.29 | Quality Index Lower (QL) : (XBAR - L) / S | 16.76 |
| Corrected Sum of Squares (SS) | 0.99 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.12 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.94 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2476 Lot Descr : KU C1S-8
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2070015 | 100.1 | 2070060 | 100 | 2070213 | 100 | 2070255 | 100 | 2070525 | 100 |
| 2070803 | 100 | 2071026 | 100 | 2071225 | 100 | 2071510 | 100 | 2071518 | 100 |
| 2071677 | 100 | 2071956 | 99.993 | 2072703 | 100.02 | 2072787 | 99.876 | 2073031 | 100 |
| 2073287 | 100.1 | 2073307 | 100 | 2073422 | 99.9 | 2073583 | 99.981 | 2073683 | 99.941 |
| 2073816 | 99.9 | 2074105 | 99.9 | 2074123 | 100 | 2074463 | 99.9 | 2074882 | 100 |
| 2074907 | 99.9 | 2075002 | 100.1 | 2075029 | 100 | 2075232 | 99.9 | 2075484 | 100 |
| 2075667 | 100 | 2076086 | 100.1 | 2076148 | 99.954 | 2076300 | 99.951 | 2076403 | 100 |
| 2076605 | 100 | 2076905 | 99.9 | 2077118 | 99.9 | 2080303 | 99.9 | 2082061 | 99.9 |
| 2500050 | 100.1 | 2500129 | 100 | 2500426 | 100 | 2500506 | 100.1 | 2500567 | 100.1 |
| 2500790 | 100.2 | 2500878 | 100.1 | 2500979 | 100.1 | 2501101 | 100.1 | 2501213 | 100 |
| 2501227 | 100 | 2501279 | 99.9 | 2501336 | 100.1 | 2501383 | 99.9 | 2501617 | 100.1 |
| 2501833 | 99.8 | 2501979 | 99.9 | 2502104 | 100.1 | 2502182 | 100.1 | 2502593 | 100 |
| 2502626 | 100.1 | 2502643 | 100 | 2502701 | 100 | 2502755 | 99.8 | 2502801 | 100.1 |
| 2502850 | 100 | 2502940 | 100 | 2503012 | 100 | 2503203 | 99.9 | 2503270 | 100 |
| 2503601 | 100 | 2503663 | 100 | 2503678 | 100 | 2503753 | 100.1 | 2503987 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7499.82 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749963.65 | Quality Index Upper (QU) : (U - XBAR) / S | 29.10 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749964.00 | Quality Index Lower (QL) : (XBAR - L) / S | 29.03 |
| Corrected Sum of Squares (SS) | 0.35 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.00 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.07 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.00 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C1S Division : 01 Sample Lot : 2477 Lot Descr : KU C1S-9
 In Service Population : 5991 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2504443 | 100 | 2504495 | 99.9 | 2504507 | 100 | 2504659 | 100.2 | 2504669 | 99.9 |
| 2504749 | 99.9 | 2505042 | 100 | 2505137 | 99.9 | 2505300 | 100.1 | 2505372 | 100 |
| 2505479 | 99.8 | 2505494 | 99.9 | 2505576 | 100.1 | 2505584 | 100 | 2505705 | 99.9 |
| 2505852 | 100 | 2505992 | 100 | 2506008 | 100.1 | 2506027 | 100 | 2506043 | 100.1 |
| 2506084 | 99.9 | 2506453 | 100.1 | 2506463 | 100 | 2506687 | 100.1 | 2506712 | 99.9 |
| 2506791 | 99.8 | 2506794 | 99.8 | 2506872 | 100 | 2506986 | 99.986 | 2507289 | 100 |
| 2507325 | 100.002 | 2508160 | 100 | 2508192 | 100 | 2508231 | 100 | 2508289 | 99.9 |
| 2508391 | 100.1 | 2508431 | 100.1 | 2508432 | 99.9 | 2508660 | 100 | 2508681 | 100 |
| 2508841 | 99.9 | 2509013 | 99.946 | 2509091 | 100.1 | 2509094 | 100 | 2509095 | 99.9 |
| 2509170 | 99.8 | 2509186 | 99.9 | 2509308 | 100.2 | 2509309 | 100 | 2509498 | 99.96 |
| 2509565 | 99.9 | 2509583 | 100.1 | 2509661 | 99.9 | 2509674 | 99.866 | 2509739 | 99.9 |
| 2509831 | 100.1 | 2509894 | 100.045 | 2510184 | 99.9 | 2510430 | 100 | 2510536 | 100 |
| 2510543 | 100 | 2510569 | 100 | 2510667 | 100 | 2510712 | 100.046 | 2510849 | 99.9 |
| 2510917 | 99.9 | 2510939 | 99.8 | 2510972 | 99.9 | 2511008 | 99.984 | 2511094 | 100 |
| 2511161 | 99.9 | 2511174 | 100 | 2511467 | 99.9 | 2511566 | 100 | 2512007 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7498.13 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749627.64 | Quality Index Upper (QU) : (U - XBAR) / S | 13.80 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749626.05 | Quality Index Lower (QL) : (XBAR - L) / S | 13.46 |
| Corrected Sum of Squares (SS) | 1.59 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.02 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.15 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.98 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : C2SOS Division : 01 Sample Lot : 2478 Lot Descr : KU C2SOS-1
 In Service Population : 1509 Sample Quantity : 50 Meters Tested : 50 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| 2400141 | 100.1 | 2400559 | 99.934 | 2400584 | 100 | 2400586 | 99.97 | 2400641 | 100 |
| 2400658 | 100 | 2400695 | 99.9 | 2400713 | 100 | 2400721 | 100 | 2400735 | 100 |
| 2400754 | 100 | 2400821 | 100 | 2400874 | 100 | 2400919 | 100 | 2400959 | 100.1 |
| 2400997 | 100 | 2400999 | 100.1 | 2401040 | 100.1 | 2401082 | 100.1 | 2401091 | 100.063 |
| 2401103 | 100.163 | 2401112 | 99.9 | 2401113 | 99.882 | 2401146 | 100.152 | 2401199 | 100 |
| 2401263 | 100.031 | 2401278 | 100 | 2401282 | 99.975 | 2401336 | 100 | 2401346 | 100.039 |
| 2401374 | 99.9 | 2401445 | 100 | 2401458 | 99.825 | 2402381 | 100 | 2402393 | 100 |
| 2402399 | 99.9 | 2402420 | 99.948 | 2402432 | 99.655 | 2402491 | 100 | 2402567 | 100.1 |
| 2402584 | 100.1 | 2402639 | 100.04 | 2402686 | 100.078 | 2402716 | 100.1 | 2403400 | 99.9 |
| 2403435 | 100 | 2403446 | 100 | 2403475 | 100.06 | 2403525 | 100 | 2403532 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 50 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 5000.11 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 500023.37 | Quality Index Upper (QU) : (U - XBAR) / S | 11.95 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 500022.00 | Quality Index Lower (QL) : (XBAR - L) / S | 11.98 |
| Corrected Sum of Squares (SS) | 1.37 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.03 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.17 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.00 | Maximum Allowable Percent NCF (M) | 5.21 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : D4S Division : 01 Sample Lot : 2479 Lot Descr : KU D4S-1
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C222238 | 100.2 | C225305 | 100.1 | C227617 | 100.1 | C227798 | 100.1 | C228486 | 100 |
| C228650 | 99.9 | C229467 | 100 | C229484 | 99.5 | C229515 | 99.6 | C229724 | 99.8 |
| C229800 | 99.9 | C229869 | 99.8 | C230072 | 100.1 | C230213 | 99.9 | C230545 | 99.4 |
| C230670 | 99.9 | C230690 | 100.106 | C230694 | 100.1 | C233585 | 100.2 | C233641 | 100 |
| C233769 | 100.3 | C233922 | 100.3 | C236058 | 99.9 | C236564 | 100.4 | C236884 | 99.6 |
| C240637 | 100 | C240701 | 100.3 | C241111 | 100.3 | L011006 | 100.2 | L136273 | 99.8 |
| L140742 | 100 | L140788 | 99.4 | M345596 | 100.1 | M345979 | 99.6 | M350871 | 100.1 |
| M352659 | 99.8 | M353151 | 99.9 | M353225 | 99.7 | M353314 | 99.8 | M354089 | 100.175 |
| M354613 | 100.2 | M354710 | 100.3 | M354726 | 99.8 | M354780 | 100.3 | M367417 | 100 |
| M367532 | 99.2 | M367700 | 99.9 | M367767 | 99.6 | M367804 | 100 | M367904 | 99.9 |
| M367958 | 99.8 | M367990 | 100.165 | M367997 | 99.9 | M375130 | 99.4 | M375310 | 100 |
| M375903 | 99.9 | M375938 | 100 | M375985 | 100 | M376001 | 100.3 | M376081 | 100.3 |
| M376139 | 100.3 | M376644 | 100 | M380872 | 99.6 | M381345 | 100 | M389624 | 99.7 |
| W101118 | 99.854 | W104205 | 100.374 | W104213 | 100 | W106004 | 99.9 | W106901 | 100 |
| W107512 | 100.014 | W108318 | 99.5 | W108324 | 100.36 | W108365 | 100 | W108937 | 100.021 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7496.97 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749398.95 | Quality Index Upper (QU) : (U - XBAR) / S | 7.99 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749394.12 | Quality Index Lower (QL) : (XBAR - L) / S | 7.67 |
| Corrected Sum of Squares (SS) | 4.83 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.26 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.96 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : D4S Division : 01 Sample Lot : 2480 Lot Descr : KU D4S-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C221904 | 100.1 | C241340 | 99.9 | C241366 | 99.7 | C241759 | 100 | C245228 | 99.8 |
| C245882 | 100 | C246155 | 99.6 | C250566 | 99.5 | C250609 | 99.9 | C254923 | 100.2 |
| C255010 | 100.2 | C255044 | 100.1 | C255177 | 100 | C256828 | 100 | C256971 | 100 |
| C257070 | 100.2 | C257202 | 99.3 | L216274 | 100.1 | L221962 | 100 | L223965 | 99.7 |
| M385051 | 100 | M385128 | 99.8 | M385139 | 99.9 | M385352 | 100 | M385629 | 99.3 |
| M389865 | 99.8 | M390083 | 99.6 | M390233 | 100.2 | M390329 | 99.4 | M390344 | 99.9 |
| M390627 | 100 | M390680 | 98.8 | M392080 | 100.2 | M392281 | 99.7 | M392285 | 100.1 |
| M392377 | 99.8 | M392489 | 99.9 | M392500 | 99.9 | M392521 | 99.7 | M392675 | 99.5 |
| M392877 | 99.7 | M392964 | 100.2 | M393480 | 100.2 | M396009 | 100 | M396629 | 99.9 |
| M396760 | 99.8 | M397196 | 99.8 | M397439 | 99.1 | M397678 | 99.6 | M397680 | 99.6 |
| M397957 | 100.1 | M398125 | 100.3 | M398750 | 100.2 | M398848 | 99.9 | M399405 | 99.7 |
| M399452 | 100.4 | W110052 | 99.8 | W110084 | 100.173 | W110647 | 100 | W110880 | 99.9 |
| W110959 | 99.8 | W111462 | 100.212 | W111504 | 99.1 | W111822 | 99.4 | W112082 | 99.994 |
| W113080 | 99.677 | W114530 | 99.8 | W114677 | 100.293 | W114951 | 99.777 | W116359 | 100.488 |
| W116741 | 100.337 | W116879 | 99.8 | W116893 | 99.7 | W117072 | 99.7 | W119537 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7490.35 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748078.61 | Quality Index Upper (QU) : (U - XBAR) / S | 6.75 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 748071.24 | Quality Index Lower (QL) : (XBAR - L) / S | 5.93 |
| Corrected Sum of Squares (SS) | 7.37 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.32 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.87 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : D4S Division : 01 Sample Lot : 2481 Lot Descr : KU D4S-3
 In Service Population : 4100 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C221938 | 99.9 | C222026 | 100.2 | C223051 | 100.3 | C223052 | 100.2 | C224034 | 100.3 |
| C224057 | 99.7 | C257618 | 99.5 | C257674 | 100.1 | C257708 | 100.3 | C257745 | 100.1 |
| C263864 | 99.6 | C263937 | 100 | L224397 | 99.3 | L224528 | 99.7 | L224642 | 99.8 |
| L224713 | 99.7 | L224722 | 99.5 | L224853 | 99.8 | L228084 | 100 | L228297 | 100.672 |
| L228556 | 100 | L228566 | 99.4 | L228570 | 100.2 | L228600 | 99.8 | L228644 | 99.6 |
| L228712 | 99.888 | L228742 | 99.9 | L228772 | 99.8 | L228842 | 99.7 | L228845 | 100 |
| L228889 | 99.8 | L228910 | 99.7 | L228926 | 99.3 | L228936 | 100.3 | M394528 | 99.7 |
| M394606 | 100.1 | M394650 | 100.1 | M394693 | 99.898 | M394700 | 100 | M394778 | 100 |
| M394806 | 99.7 | M394811 | 100.1 | M394862 | 99.6 | M394949 | 99.8 | M395153 | 99.7 |
| M395301 | 99.7 | M395409 | 100.1 | M395436 | 100 | M395592 | 100.2 | M395595 | 99.2 |
| M395757 | 100.3 | M395832 | 99.8 | M395836 | 99.6 | M395896 | 99.9 | M395934 | 99.7 |
| M395948 | 100.105 | M401072 | 99.9 | M401203 | 99.6 | M401671 | 99.689 | M401770 | 100.1 |
| M401787 | 99.8 | M401810 | 99.8 | M401847 | 100 | W119756 | 99.9 | W119763 | 99.8 |
| W119791 | 99.6 | W119918 | 100.3 | W119919 | 99.7 | W120003 | 99.9 | W120057 | 99.8 |
| W120107 | 99.8 | W120147 | 99.8 | W120194 | 100.195 | W120534 | 99.6 | W120660 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7490.35 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748076.05 | Quality Index Upper (QU) : (U - XBAR) / S | 8.35 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 748071.24 | Quality Index Lower (QL) : (XBAR - L) / S | 7.34 |
| Corrected Sum of Squares (SS) | 4.81 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.25 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.87 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : D5S Division : 01 Sample Lot : 2482 Lot Descr : KU D5S-1
 In Service Population : 350 Sample Quantity : 20 Meters Tested : 20 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C279706 | 99.4 | C279756 | 99.8 | C279768 | 99.7 | C279773 | 99.6 | C279831 | 100 |
| C283470 | 99.4 | C283504 | 99.8 | C283571 | 99.2 | C283633 | 99.7 | C298899 | 99.1 |
| C298942 | 100.2 | C298963 | 100.3 | C298982 | 99.936 | C299002 | 100.216 | C299028 | 100.2 |
| C299031 | 99.4 | C299033 | 100.083 | C299063 | 99.1 | C299160 | 98.9 | M397181 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 20 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 1993.73 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 198752.29 | Quality Index Upper (QU) : (U - XBAR) / S | 4.85 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 198747.97 | Quality Index Lower (QL) : (XBAR - L) / S | 3.54 |
| Corrected Sum of Squares (SS) | 4.32 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.23 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.48 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.69 | Maximum Allowable Percent NCF (M) | 6.18 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200E Model Number : I-210 Division : 01 Sample Lot : 2484 Lot Descr : KU I210-1
 In Service Population : 4682 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C431964 | 99.8 | C432024 | 99.866 | C432068 | 99.9 | C432082 | 99.9 | C432148 | 99.9 |
| C432152 | 100.093 | C432199 | 99.9 | C432280 | 100 | C432397 | 99.5 | C432407 | 100.1 |
| C432431 | 99.8 | C432565 | 99.927 | C432710 | 99.9 | C432733 | 99.9 | C432739 | 99.9 |
| C432771 | 100 | C433044 | 99.7 | C433115 | 100.1 | C433328 | 99.9 | C433420 | 100.496 |
| C433423 | 99.8 | C445374 | 99.9 | C445378 | 99.9 | C445380 | 99.9 | C445400 | 99.9 |
| C445404 | 100.032 | C445440 | 100 | C445475 | 100 | C445560 | 100.006 | C445577 | 99.9 |
| C445827 | 100 | C445920 | 99.9 | C445989 | 99.9 | C446019 | 100.009 | C446056 | 99.9 |
| C446058 | 99.952 | C446078 | 99.9 | C446117 | 99.9 | C446125 | 100 | C446211 | 99.8 |
| C446250 | 100.038 | C446260 | 100 | C446332 | 100.14 | C456587 | 100 | C456715 | 99.881 |
| C456845 | 100 | C457000 | 99.951 | C457029 | 99.894 | C457040 | 99.9 | C457098 | 100 |
| C457102 | 100 | C457241 | 99.9 | C457298 | 100 | C457376 | 100.015 | C457413 | 100 |
| C457443 | 99.9 | C457560 | 99.9 | C457593 | 100 | C463564 | 100 | C463886 | 100 |
| C463888 | 100.1 | C464055 | 99.9 | C464246 | 100 | C464342 | 99.915 | C464454 | 100.1 |
| C464597 | 100 | C464803 | 100.2 | C464831 | 100.1 | C464958 | 100 | C465070 | 99.9 |
| C465116 | 100.1 | C465187 | 100 | C465284 | 100.1 | C465288 | 100 | C465521 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7497.12 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749424.19 | Quality Index Upper (QU) : (U - XBAR) / S | 62.23 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749424.11 | Quality Index Lower (QL) : (XBAR - L) / S | 59.88 |
| Corrected Sum of Squares (SS) | 0.08 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.00 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.03 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.96 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V15AC100 Model Number : I-50S Division : 01 Sample Lot : 2485 Lot Descr : KU I50-1
 In Service Population : 808 Sample Quantity : 35 Meters Tested : 35 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| L049513 | 100 | L061020 | 100.1 | L061567 | 99.119 | L061676 | 99.908 | L061680 | 100 |
| L062028 | 99.8 | L062127 | 100.1 | L062472 | 100.1 | L063181 | 99.8 | L065671 | 100 |
| L067582 | 99.9 | L068548 | 100.2 | L069665 | 100.1 | L070396 | 99.6 | L070448 | 98.399 |
| L070463 | 99.8 | L071647 | 99.9 | L071849 | 99.6 | L072205 | 99.8 | L072291 | 100.065 |
| L072742 | 99.9 | L073128 | 99.9 | L073638 | 99.4 | L073718 | 99.9 | L074252 | 100 |
| L074350 | 99.9 | W072162 | 101.416 | W074903 | 100.1 | W077776 | 100.135 | W078107 | 100.2 |
| W078137 | 100.5 | W078144 | 100.117 | W079024 | 100 | W079345 | 100.077 | W081930 | 100.089 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 35 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 3497.92 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 349591.68 | Quality Index Upper (QU) : (U - XBAR) / S | 4.37 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 349584.12 | Quality Index Lower (QL) : (XBAR - L) / S | 4.12 |
| Corrected Sum of Squares (SS) | 7.56 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.22 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.47 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.94 | Maximum Allowable Percent NCF (M) | 5.58 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F1S120V15AC100 Model Number : I-55S Division : 01 Sample Lot : 2486 Lot Descr : KU I55-1
 In Service Population : 682 Sample Quantity : 35 Meters Tested : 35 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C289104 | 99.8 | C298281 | 100 | L011799 | 99.68 | L075985 | 99.9 | L076733 | 99.827 |
| L076751 | 100.2 | L076906 | 100 | L077301 | 100 | L078183 | 100.2 | L078336 | 100.2 |
| L079009 | 99.7 | L079377 | 99.7 | L080898 | 100 | L081329 | 99.8 | L081749 | 99.8 |
| L081971 | 99.8 | L082021 | 99.8 | L082933 | 99.7 | L084024 | 99.7 | L084074 | 99.6 |
| L084141 | 100.1 | L084675 | 99.6 | L084679 | 99.469 | L084688 | 99.8 | L085808 | 99.687 |
| L085848 | 99.8 | L085876 | 100 | L088672 | 98.9 | L089041 | 99.7 | L089179 | 100.1 |
| L089203 | 99.886 | L089326 | 99.9 | M417576 | 99.144 | M417610 | 100.7 | M417729 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 35 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 3493.89 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 348782.86 | Quality Index Upper (QU) : (U - XBAR) / S | 6.51 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 348779.07 | Quality Index Lower (QL) : (XBAR - L) / S | 5.47 |
| Corrected Sum of Squares (SS) | 3.79 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.11 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.33 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.83 | Maximum Allowable Percent NCF (M) | 5.58 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-60S

Division : 01

Sample Lot : 2487

Lot Descr : KU I60-1

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C203916 | 100.2 | C203925 | 100.5 | C204348 | 100.9 | C204629 | 100 | C206047 | 100.2 |
| C206095 | 100.2 | L002497 | 99.9 | L003799 | 100.2 | L004307 | 99.665 | L004683 | 99.9 |
| L005685 | 100 | L005878 | 99.8 | L006132 | 99.3 | L006905 | 99.8 | L007119 | 100.3 |
| L010117 | 99.8 | L010299 | 99.9 | L013960 | 99.6 | L014142 | 99.6 | L014988 | 100.2 |
| L016186 | 100.1 | L088254 | 99.8 | L090778 | 100 | L090823 | 100.1 | L091155 | 100.1 |
| L091233 | 100.5 | L091432 | 99.8 | L091685 | 99.8 | L091743 | 99.8 | L091933 | 100 |
| L092262 | 100.1 | L092631 | 100 | L092720 | 99.9 | L092869 | 99.6 | L092955 | 99.625 |
| L093289 | 99.8 | L094502 | 99.9 | L095254 | 99.8 | L095400 | 100 | L095662 | 100.2 |
| L096189 | 100.2 | L096194 | 100.2 | L096218 | 99.8 | L096429 | 99.8 | L096519 | 100 |
| L096987 | 99.8 | L097115 | 100.2 | L097559 | 99.9 | L098405 | 99.7 | L099321 | 99.9 |
| L099420 | 100.2 | L099943 | 99.8 | L100307 | 99.9 | L100370 | 100.1 | L100980 | 100 |
| L101260 | 100.1 | L101426 | 99.3 | L102396 | 100.2 | L102956 | 99.8 | L103143 | 99.7 |
| L103410 | 99.7 | L104963 | 100.2 | L105026 | 100.1 | L105244 | 100.2 | L105600 | 100.2 |
| L105754 | 99.9 | L106042 | 100.111 | L107073 | 99.9 | L107199 | 100 | L107527 | 99.3 |
| L107675 | 99.8 | L107838 | 100 | L108633 | 100.2 | L108848 | 99.963 | L109153 | 99.4 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7496.46 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749298.42 | Quality Index Upper (QU) : (U - XBAR) / S | 7.04 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749292.17 | Quality Index Lower (QL) : (XBAR - L) / S | 6.72 |
| Corrected Sum of Squares (SS) | 6.25 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.29 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.95 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-60S Division : 01 Sample Lot : 2488 Lot Descr : KU I60-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C210866 | 99.9 | C213146 | 99.8 | C214104 | 100.4 | C215053 | 100.1 | L000025 | 99.749 |
| L000932 | 99.8 | L000987 | 99.9 | L002023 | 99.8 | L002687 | 100.1 | L004359 | 100 |
| L004558 | 99.7 | L007072 | 99.9 | L007174 | 100.1 | L008530 | 99.9 | L008693 | 99.9 |
| L009236 | 100 | L009243 | 99.7 | L010284 | 100 | L013470 | 99.6 | L014325 | 99.7 |
| L016577 | 99.9 | L016649 | 99.6 | L019448 | 99.8 | L022300 | 100.1 | L028474 | 99.9 |
| L035196 | 100.1 | L060029 | 99.8 | L063360 | 99.7 | L065877 | 99.617 | L067180 | 99.9 |
| L068356 | 99.6 | L069619 | 99.7 | L072138 | 99.6 | L079810 | 100.1 | L080084 | 100.1 |
| L081421 | 99.9 | L084866 | 100 | L090987 | 100.4 | L091579 | 99.9 | L095232 | 99.9 |
| L101505 | 99.9 | L103370 | 99.9 | L103945 | 99.8 | L105413 | 99.7 | L109566 | 99.7 |
| L109886 | 100.5 | L110563 | 99.9 | L110565 | 99.65 | L110873 | 99.8 | L111018 | 100.2 |
| L111616 | 99.6 | L111750 | 100.2 | L112441 | 100.3 | L113146 | 99.6 | L113574 | 99.6 |
| L113694 | 99.7 | L114085 | 100 | L114331 | 100 | L114680 | 100.1 | L114686 | 99.7 |
| L114741 | 100.3 | L115001 | 99.6 | L115563 | 99.7 | L115944 | 100.1 | L115945 | 99.718 |
| L116463 | 99.3 | L116973 | 99.9 | L117225 | 100.3 | L117452 | 99.9 | L117479 | 98.9 |
| L117566 | 100 | L117689 | 99.6 | L118139 | 100.1 | L118482 | 99.899 | L119039 | 100.4 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7491.23 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748252.68 | Quality Index Upper (QU) : (U - XBAR) / S | 7.66 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 748247.03 | Quality Index Lower (QL) : (XBAR - L) / S | 6.81 |
| Corrected Sum of Squares (SS) | 5.65 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.28 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.88 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-60S Division : 01 Sample Lot : 2489 Lot Descr : KU I60-3
 In Service Population : 7415 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C216692 | 100.2 | C216731 | 100.4 | C216825 | 100.5 | C217621 | 99.9 | C217753 | 100.2 |
| C217781 | 99.957 | C219035 | 100.1 | C220089 | 100.4 | L000091 | 99.909 | L003191 | 100.1 |
| L003238 | 99.9 | L007937 | 100.2 | L009377 | 100 | L011864 | 100.3 | L015011 | 100.1 |
| L015199 | 100.1 | L018109 | 100.1 | L027425 | 100.5 | L060249 | 100.1 | L068871 | 100.1 |
| L081301 | 99.9 | L084545 | 100 | L087713 | 100.1 | L087813 | 99.9 | L089274 | 100.3 |
| L096025 | 100.2 | L099157 | 100 | L100834 | 100.1 | L103240 | 99.7 | L103392 | 100.2 |
| L119508 | 99.6 | L119650 | 100.3 | L119707 | 99.7 | L120211 | 99.9 | L120530 | 100 |
| L120551 | 99.8 | L120902 | 99.6 | L121003 | 99.9 | L121013 | 100.2 | L121134 | 100.2 |
| L121381 | 100.498 | L121382 | 99.9 | L121446 | 100.124 | L121710 | 100.2 | L121751 | 99.9 |
| L122112 | 100.1 | L122142 | 100 | L122218 | 100.2 | L122234 | 99 | L122779 | 100.2 |
| L123006 | 100.1 | L123065 | 99.9 | L123124 | 100.1 | L123428 | 100.1 | L123443 | 99.7 |
| L123621 | 100.2 | L123636 | 100.3 | L123793 | 100 | L123832 | 99.8 | L123958 | 100.1 |
| L124249 | 100 | L124546 | 99.8 | L124558 | 99.8 | L124644 | 99.7 | L124666 | 100.1 |
| L124713 | 99.6 | L125271 | 100.1 | L126167 | 100 | L126226 | 100.1 | L126834 | 99.8 |
| L126937 | 100.4 | L127344 | 100.038 | L127470 | 100 | L127507 | 99.7 | L190352 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7502.23 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 750449.64 | Quality Index Upper (QU) : (U - XBAR) / S | 8.97 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 750446.07 | Quality Index Lower (QL) : (XBAR - L) / S | 9.24 |
| Corrected Sum of Squares (SS) | 3.57 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.05 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.22 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.03 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-70S

Division : 01

Sample Lot : 2490

Lot Descr : KU I70-1

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C221685 | 100 | C223277 | 100.2 | C225513 | 100 | C225622 | 100.3 | C225664 | 100.3 |
| C226804 | 100.7 | C229126 | 100.6 | C229175 | 100.1 | C229265 | 101.1 | C230923 | 100.2 |
| C230961 | 100 | L008274 | 100 | L011745 | 100.1 | L011827 | 100.3 | L012362 | 100.2 |
| L012474 | 99.9 | L022292 | 100.4 | L025143 | 100.2 | L045897 | 100 | L049199 | 100.3 |
| L062756 | 100 | L062971 | 100.3 | L066549 | 100.1 | L071727 | 99.9 | L073200 | 100.1 |
| L073265 | 100.1 | L086107 | 100.2 | L094288 | 99.8 | L099589 | 100 | L103995 | 100.2 |
| L127979 | 100 | L128133 | 100.2 | L128274 | 100 | L128351 | 100.3 | L128789 | 100.2 |
| L128857 | 99.7 | L128957 | 100.4 | L129369 | 99.7 | L129507 | 99.8 | L129549 | 99.7 |
| L129701 | 100.4 | L129731 | 100.2 | L129836 | 100.3 | L130358 | 100.2 | L130533 | 100.084 |
| L130768 | 100.4 | L130806 | 100.3 | L131207 | 100.1 | L131442 | 99.9 | L131564 | 100.3 |
| L131605 | 100.3 | L131928 | 100.1 | L132060 | 100.3 | L132080 | 99.8 | L132202 | 100.5 |
| L132358 | 100.6 | L132760 | 100.5 | L132913 | 100.4 | L133082 | 100.1 | L133100 | 100.2 |
| L133305 | 100.458 | L133343 | 100.348 | L133676 | 100.5 | L133784 | 100.4 | L134295 | 100.4 |
| L134309 | 100.4 | L135082 | 100.1 | L135191 | 100.1 | L136012 | 100 | L136539 | 99.9 |
| L136558 | 100.3 | L136916 | 100.4 | M345344 | 100.4 | M373063 | 100 | W100639 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7514.39 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 752885.17 | Quality Index Upper (QU) : (U - XBAR) / S | 7.41 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 752880.76 | Quality Index Lower (QL) : (XBAR - L) / S | 8.98 |
| Corrected Sum of Squares (SS) | 4.41 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.24 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.19 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-70S

Division : 01

Sample Lot : 2491

Lot Descr : KU I70-2

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C232852 | 100.4 | C232974 | 100.5 | C232989 | 100.4 | C233036 | 100.2 | C233080 | 100.4 |
| C238461 | 100.4 | C238603 | 100.1 | C238624 | 100.7 | C238682 | 100.5 | C239034 | 100.2 |
| L137171 | 99.9 | L137298 | 100.6 | L137301 | 99.6 | L137496 | 100 | L137896 | 100.1 |
| L138000 | 100 | L138468 | 100.2 | L138576 | 100 | L138614 | 100.2 | L138724 | 100.3 |
| L138811 | 100.4 | L138818 | 100.1 | L138976 | 99.9 | L139061 | 100.5 | L139153 | 100.4 |
| L139390 | 100.1 | L139769 | 99.8 | L139841 | 100.373 | L140322 | 100.1 | L140456 | 100.5 |
| L140687 | 100 | L141628 | 100 | L141737 | 100.3 | L141801 | 99.7 | L141933 | 100 |
| L142010 | 100.3 | L143014 | 100.1 | L143883 | 100.2 | L143959 | 100.2 | L144003 | 100.1 |
| L144030 | 100.4 | L144136 | 100.2 | L144631 | 100.4 | L144700 | 99.9 | L145254 | 100.2 |
| L145534 | 99.9 | L145593 | 100.2 | L145705 | 100.3 | L145834 | 100.2 | L146043 | 100.1 |
| L146157 | 100.2 | L146308 | 100.4 | L146334 | 99.8 | L146373 | 100.5 | L146404 | 100.4 |
| L146457 | 100.1 | L146574 | 99.9 | L146635 | 100.6 | L147181 | 100.1 | L147273 | 100 |
| L147345 | 100.5 | L148263 | 100.3 | L148789 | 100 | L149132 | 99.6 | L170040 | 100.5 |
| L170072 | 100.3 | L170081 | 100 | L170346 | 100.238 | L170680 | 100.5 | L171651 | 100.2 |
| L171662 | 100.5 | L171680 | 100.3 | W103663 | 100.6 | W104098 | 101.363 | W104120 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7516.27 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 753264.06 | Quality Index Upper (QU) : (U - XBAR) / S | 6.00 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 753257.53 | Quality Index Lower (QL) : (XBAR - L) / S | 7.46 |
| Corrected Sum of Squares (SS) | 6.53 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.09 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.30 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.22 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-70S Division : 01 Sample Lot : 2492 Lot Descr : KU I70-3
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C239168 | 100.1 | C239177 | 100.3 | C239222 | 100.3 | C242967 | 100.206 | C243055 | 100.3 |
| C243427 | 100.324 | C243527 | 100.2 | C243546 | 99.9 | L172307 | 100.1 | L172394 | 100.5 |
| L173051 | 100.9 | L173122 | 100.3 | L173124 | 100.2 | L173841 | 100.1 | L173967 | 99.9 |
| L174177 | 99.7 | L174422 | 100.1 | L174625 | 100.07 | L174651 | 100.1 | L174777 | 99.7 |
| L175077 | 99.9 | L175106 | 99.823 | L175217 | 99.7 | L175467 | 99.9 | L176321 | 100 |
| L176483 | 100.3 | L176662 | 99.7 | L176809 | 100.3 | L176855 | 100.5 | L177520 | 100 |
| L177542 | 99.9 | L177720 | 100.158 | L178083 | 100.1 | L178447 | 100.5 | L179091 | 100 |
| L179218 | 100.2 | L179471 | 100.4 | L179527 | 100.3 | L180358 | 99.8 | L180467 | 99.9 |
| L180679 | 100.1 | L181026 | 100.3 | L181271 | 100.3 | L181336 | 100.3 | L182051 | 99.8 |
| L182184 | 100.1 | L182301 | 99.9 | L182359 | 100.1 | L182535 | 100.1 | L182615 | 100.4 |
| L182759 | 100.2 | L183561 | 100.2 | L183591 | 100.3 | L183863 | 100.5 | L184213 | 100.3 |
| L184592 | 100.4 | L184720 | 100.4 | L184745 | 100.4 | L184758 | 99.8 | L184909 | 100.2 |
| L184926 | 100 | L186076 | 100.6 | L186729 | 100 | L186767 | 99.7 | L187264 | 99.7 |
| L187282 | 99.8 | L187478 | 99.9 | L187505 | 100.2 | L188445 | 100 | M388573 | 100 |
| M388590 | 100.1 | M388627 | 100.1 | M388632 | 100.4 | M388757 | 99.3 | W109003 | 100.4 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7508.98 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751802.45 | Quality Index Upper (QU) : (U - XBAR) / S | 6.98 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 751797.08 | Quality Index Lower (QL) : (XBAR - L) / S | 7.87 |
| Corrected Sum of Squares (SS) | 5.37 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.27 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.12 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-70S Division : 01 Sample Lot : 2493 Lot Descr : KU I70-4
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C221323 | 100.3 | C221431 | 100 | C221648 | 100.2 | C243689 | 100.3 | C243698 | 100.7 |
| C243970 | 100 | C247576 | 99.9 | C247768 | 100.6 | C247792 | 100.3 | C247833 | 100.3 |
| C247929 | 100.4 | C248316 | 100.3 | C252135 | 100.3 | C252255 | 100.246 | L188723 | 99.9 |
| L188744 | 99.89 | L188794 | 99.8 | L188908 | 100.3 | L188912 | 99.9 | L189181 | 99.9 |
| L189287 | 99.8 | L189342 | 99.9 | L189437 | 100 | L190176 | 100 | L190589 | 99.9 |
| L190757 | 100 | L190928 | 100.1 | L191011 | 100.1 | L191101 | 100.1 | L191580 | 99.9 |
| L191600 | 100.2 | L191863 | 100.1 | L191954 | 99.5 | L192426 | 99.9 | L192607 | 100 |
| L192628 | 100 | L192647 | 99.9 | L192807 | 100.2 | L192821 | 99.5 | L194955 | 100.1 |
| L195053 | 99.6 | L195132 | 100 | L195254 | 100 | L195272 | 99.9 | L195281 | 100.3 |
| L195325 | 100.2 | L195555 | 100.3 | L195577 | 100.3 | L195639 | 99.9 | L196100 | 100.2 |
| L196128 | 99.8 | L196468 | 99.9 | L197686 | 99.819 | L197812 | 99.918 | L198609 | 100.1 |
| L198681 | 99.9 | L198726 | 99.8 | L198775 | 100.3 | L198821 | 100.1 | L199995 | 99.9 |
| L200060 | 100 | L200430 | 99.8 | L201506 | 100 | L201571 | 100.2 | L201610 | 100.2 |
| L201730 | 100 | L201984 | 99.9 | L202204 | 99.6 | L203475 | 99.9 | L203662 | 100.1 |
| L203719 | 99.7 | L204382 | 99.9 | W112603 | 100.4 | W113962 | 100.806 | W113966 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7503.58 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 750720.37 | Quality Index Upper (QU) : (U - XBAR) / S | 8.20 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 750716.17 | Quality Index Lower (QL) : (XBAR - L) / S | 8.60 |
| Corrected Sum of Squares (SS) | 4.20 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.24 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.05 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-70S

Division : 01

Sample Lot : 2494

Lot Descr : KU I70-5

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C252444 | 100.1 | C253040 | 100.3 | C255897 | 100.1 | C256001 | 100.1 | C256022 | 100.3 |
| L036005 | 99.9 | L037712 | 100.2 | L096673 | 99.9 | L204603 | 100.1 | L204736 | 99.5 |
| L204777 | 100 | L205078 | 100.1 | L205229 | 99.6 | L205802 | 99.9 | L206201 | 100.3 |
| L206892 | 99.9 | L206981 | 99.9 | L207000 | 99.5 | L207009 | 99.7 | L207212 | 100.5 |
| L207459 | 100.1 | L207657 | 100.2 | L207842 | 99.9 | L207988 | 99.8 | L208838 | 100.2 |
| L209211 | 99.9 | L209249 | 100.1 | L209260 | 99.9 | L210074 | 100 | L210268 | 100.4 |
| L210307 | 99.7 | L210310 | 100.1 | L210473 | 100.4 | L210617 | 100.2 | L210679 | 100.475 |
| L211979 | 100.4 | L212089 | 100.5 | L212207 | 99.9 | L212252 | 100 | L212956 | 100.2 |
| L213031 | 100.1 | L213271 | 100.3 | L213315 | 100 | L213366 | 100.1 | L213380 | 100.1 |
| L213669 | 99.7 | L213742 | 100.5 | L214239 | 100.3 | L214338 | 100.1 | L214567 | 99.6 |
| L214605 | 100.1 | L214702 | 100.47 | L215003 | 100.187 | L215183 | 100 | L215307 | 100.1 |
| L215326 | 100 | L215389 | 100.5 | L215496 | 99.5 | L216970 | 99.8 | L217199 | 100 |
| L217463 | 99.914 | L218169 | 100 | L219702 | 100.4 | L219791 | 100 | L219885 | 100.216 |
| L219968 | 100.2 | L220045 | 100 | L220055 | 100.3 | L220074 | 100.4 | L220136 | 100.2 |
| W116131 | 100.1 | W116286 | 100 | W117506 | 100.1 | W119012 | 99.9 | W119335 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7505.16 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751037.33 | Quality Index Upper (QU) : (U - XBAR) / S | 7.45 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 751032.36 | Quality Index Lower (QL) : (XBAR - L) / S | 7.98 |
| Corrected Sum of Squares (SS) | 4.97 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.26 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.07 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-70S Division : 01 Sample Lot : 2495 Lot Descr : KU I70-6
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C256464 | 99.1 | C256554 | 100.6 | C256606 | 100.3 | C261567 | 100.1 | C261745 | 100.5 |
| C261811 | 100.3 | C261925 | 100.4 | C261926 | 100 | C262010 | 100.3 | C262045 | 100.4 |
| C262080 | 99.9 | C262352 | 100.2 | C262434 | 99.963 | C262441 | 100.3 | C262497 | 100.2 |
| C262579 | 99.9 | C262671 | 100.1 | C262676 | 99.9 | C266916 | 100 | C266977 | 100.3 |
| L220294 | 100.2 | L220582 | 100.2 | L220592 | 100.4 | L220653 | 99.9 | L220940 | 99.8 |
| L222243 | 99.8 | L222477 | 99.9 | L225226 | 100.4 | L225422 | 99.958 | L225810 | 100 |
| L226122 | 100.2 | L226161 | 100.161 | L226215 | 100.2 | L226273 | 100.3 | L226361 | 100.3 |
| L226422 | 100.1 | L226648 | 100.5 | L226972 | 100.2 | L227372 | 99.9 | L227515 | 100.2 |
| L227757 | 100.4 | L233419 | 100.1 | L233456 | 100.3 | L234156 | 100.1 | L234771 | 99.9 |
| L234948 | 100 | L235199 | 99.9 | L235228 | 100.1 | L235435 | 100.2 | L235590 | 99.8 |
| L237661 | 100.1 | L237832 | 100 | L237880 | 100.1 | L238000 | 100 | L238841 | 100 |
| L238998 | 99.9 | M402095 | 100.4 | M402290 | 100 | M402329 | 100.3 | M402489 | 100.4 |
| M403704 | 99.9 | M403909 | 99.8 | M404336 | 100.2 | M404490 | 100.3 | M404621 | 100.1 |
| M427225 | 99.7 | W120785 | 100.1 | W120812 | 99.9 | W121082 | 100.518 | W121086 | 100 |
| W121088 | 100.2 | W121215 | 99.9 | W122393 | 100 | W122432 | 99.8 | W122660 | 99.971 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7507.77 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751559.14 | Quality Index Upper (QU) : (U - XBAR) / S | 7.84 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 751554.80 | Quality Index Lower (QL) : (XBAR - L) / S | 8.69 |
| Corrected Sum of Squares (SS) | 4.34 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.24 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.10 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : I-70S

Division : 01

Sample Lot : 2496

Lot Descr : KU I70-7

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C267210 | 100.1 | C267365 | 100.2 | C267453 | 100.2 | C272052 | 100.1 | C272118 | 100 |
| C272145 | 100.1 | C272292 | 100.1 | C272356 | 100.2 | C272602 | 100.1 | C272785 | 100.2 |
| C272865 | 100.1 | C273004 | 100.4 | C276605 | 100.1 | C276673 | 100.1 | C277030 | 100.2 |
| C277056 | 100.1 | C277094 | 100.2 | C277493 | 100 | C281368 | 100.3 | C281617 | 100 |
| C281673 | 100 | C281794 | 100.3 | C281845 | 100.2 | C281960 | 100.2 | C282006 | 100.2 |
| C282030 | 100.1 | C282193 | 100.2 | C282232 | 100.2 | C282243 | 100.3 | C286906 | 100.1 |
| C286921 | 99.8 | C286964 | 100 | C287176 | 100.1 | C287276 | 100.1 | C287279 | 100 |
| L238693 | 99.8 | L238759 | 100.2 | L239541 | 100.1 | L239752 | 99.956 | L239834 | 99.9 |
| L239919 | 100.1 | L241229 | 100.3 | L241246 | 100.1 | L241413 | 100.1 | L242455 | 100.2 |
| L242668 | 99.9 | L242780 | 99.9 | L244253 | 100 | L244318 | 100.2 | L244437 | 100.3 |
| L244570 | 100 | L244585 | 100 | L252013 | 100.4 | M420153 | 100.11 | M420334 | 100.127 |
| M420627 | 99.7 | M420682 | 99.6 | M420772 | 100 | M420936 | 100 | W123405 | 99.9 |
| W123848 | 100.4 | W123872 | 100.2 | W124005 | 100.1 | W124060 | 100.5 | W125516 | 100.1 |
| W125620 | 100.2 | W125625 | 100.49 | W126362 | 100.035 | W127826 | 99.9 | W127861 | 100.2 |
| W127864 | 100.3 | W127955 | 100.354 | W128006 | 100.2 | W128366 | 99.9 | W128448 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7508.47 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751697.38 | Quality Index Upper (QU) : (U - XBAR) / S | 10.43 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 751694.96 | Quality Index Lower (QL) : (XBAR - L) / S | 11.68 |
| Corrected Sum of Squares (SS) | 2.42 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.03 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.18 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.11 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-70S Division : 01 Sample Lot : 2497 Lot Descr : KU I70-8
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C290267 | 100.1 | C290355 | 100.1 | C290366 | 100.2 | C290382 | 100.2 | C290684 | 99.9 |
| C290776 | 100.4 | C290905 | 100.2 | C292723 | 100.1 | C292986 | 100.4 | C293228 | 99.9 |
| C293348 | 100.1 | C293651 | 100.1 | C293907 | 99.9 | C293932 | 100.4 | C293934 | 100.3 |
| C294059 | 100.1 | C294088 | 99.9 | C294158 | 100.3 | C294205 | 100.349 | C294276 | 100.1 |
| C296175 | 100.1 | C296231 | 100.3 | C296318 | 99.9 | C296331 | 100.2 | C296469 | 100.4 |
| C296643 | 100.2 | C296652 | 100.4 | C296855 | 100.2 | L262216 | 100.2 | L262221 | 100.3 |
| L262502 | 100.3 | L262510 | 100.2 | L263292 | 100.1 | L263700 | 99.9 | L263862 | 99.9 |
| L263975 | 100.2 | L264065 | 100.1 | L264102 | 99.9 | L264398 | 99.8 | L264407 | 100.3 |
| L264669 | 100.3 | L264720 | 99.9 | L264985 | 100.2 | L265090 | 100.2 | L265468 | 100.1 |
| L265498 | 100.2 | L265534 | 100.2 | L265574 | 100 | L265970 | 100.1 | L266305 | 100.1 |
| L266478 | 100.1 | L266566 | 100.2 | L266648 | 100.2 | L266785 | 100.1 | M433628 | 100.2 |
| M433728 | 100 | M434081 | 100.2 | M434535 | 101.7 | W128922 | 100.1 | W128995 | 100.2 |
| W129205 | 100.187 | W129461 | 100.1 | W129469 | 100.3 | W130196 | 100.2 | W131242 | 100.134 |
| W131455 | 100.1 | W131580 | 100.2 | W131797 | 100 | W131815 | 100.6 | W131971 | 100.8 |
| W132014 | 100.4 | W132033 | 100.2 | W132279 | 100.099 | W132284 | 100.5 | W132669 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7513.87 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 752780.99 | Quality Index Upper (QU) : (U - XBAR) / S | 7.42 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 752776.57 | Quality Index Lower (QL) : (XBAR - L) / S | 8.94 |
| Corrected Sum of Squares (SS) | 4.42 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.24 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.18 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : I-705 Division : 01 Sample Lot : 2498 Lot Descr : KU I70-9
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C262621 | 99.9 | C299282 | 100.6 | C299292 | 100.4 | C299655 | 100 | C300068 | 100.4 |
| C300121 | 100.5 | C300193 | 100.1 | C300205 | 100.3 | C300228 | 100.4 | C304498 | 101.211 |
| C304615 | 100.5 | C304645 | 100.6 | C304692 | 99.7 | C304907 | 100.4 | C305088 | 99.9 |
| C305094 | 99.8 | C305282 | 99.5 | C305452 | 100.2 | C305531 | 100.2 | C305535 | 100.5 |
| C335427 | 99.8 | C335673 | 99.9 | L276455 | 100.1 | L276584 | 100.1 | L276730 | 100.2 |
| L276960 | 100.1 | L277147 | 100.1 | L277191 | 100 | L277219 | 99.8 | L277251 | 99.9 |
| L277400 | 100.2 | L291937 | 99.7 | L303919 | 99.7 | L303992 | 99.7 | L304096 | 99.6 |
| L304338 | 99.8 | L304413 | 99.7 | L304576 | 99.7 | L304655 | 99.9 | L304671 | 99.9 |
| L304965 | 99.7 | L304967 | 99.5 | L305844 | 99.7 | L305909 | 99.6 | L306132 | 99.9 |
| L306133 | 100 | L306140 | 99.8 | L306141 | 99.9 | L306229 | 100 | L306312 | 99.7 |
| L306586 | 99.6 | L306684 | 99.7 | L306926 | 99.9 | L307127 | 99.7 | M437938 | 100 |
| M438302 | 100.1 | W133768 | 100.3 | W133779 | 100.1 | W133911 | 100 | W136060 | 99.9 |
| W136077 | 100.3 | W136388 | 100.132 | W136588 | 100.2 | W136671 | 100.023 | W136760 | 100.2 |
| W136912 | 100.2 | W136956 | 100.3 | W136968 | 99.8 | W137173 | 100.2 | W137258 | 100 |
| W137349 | 100.2 | W137380 | 99.9 | W137590 | 100 | W137646 | 100.3 | W137732 | 100.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7502.17 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 750440.08 | Quality Index Upper (QU) : (U - XBAR) / S | 6.91 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 750434.06 | Quality Index Lower (QL) : (XBAR - L) / S | 7.12 |
| Corrected Sum of Squares (SS) | 6.02 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.29 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.03 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F1S120V15AC100 Model Number : I-70S Division : 01 Sample Lot : 2499 Lot Descr : KU I70-10
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C298584 | 99.7 | C335928 | 99.5 | C336211 | 99.59 | C336360 | 99.5 | C336375 | 99.6 |
| C336460 | 99.8 | C336658 | 99.8 | C336712 | 99.7 | C336906 | 99.5 | C337009 | 98.9 |
| C337141 | 99.4 | C337347 | 99.9 | C337367 | 100 | C337580 | 99.8 | C338046 | 99.9 |
| C338338 | 100 | C338374 | 99.8 | C338426 | 99.7 | C338918 | 99.9 | C339310 | 100.1 |
| C339494 | 100 | C340130 | 99.8 | C340173 | 99.7 | C340435 | 99.6 | C341016 | 99.8 |
| C341370 | 99.9 | C341460 | 100.1 | C341570 | 99.9 | C341626 | 99.8 | C341740 | 99.8 |
| C341812 | 100.1 | C341923 | 99.9 | C341973 | 99.9 | C341981 | 99.9 | C342587 | 99.9 |
| C342637 | 99.9 | C342698 | 99.6 | C342705 | 99.9 | C342744 | 100 | C342843 | 100.33 |
| C343116 | 99.9 | C343586 | 99.8 | C343588 | 100 | C343632 | 99.6 | C344041 | 100.1 |
| C344047 | 99.8 | C344051 | 99.6 | C344290 | 99.6 | C344333 | 99.6 | L307438 | 100 |
| L307526 | 99.708 | L307572 | 101.3 | L307601 | 99.975 | L307677 | 99.6 | L307715 | 99.7 |
| L307785 | 99.7 | L308045 | 99.8 | L308097 | 99.6 | L308104 | 99.9 | L308134 | 99.5 |
| L308177 | 99.9 | L308619 | 99.5 | L308719 | 99.7 | L308781 | 99.7 | L308904 | 99.9 |
| L309208 | 99.6 | L309345 | 99.5 | M446958 | 99.6 | M446985 | 99.9 | M447021 | 99.8 |
| M447029 | 99.5 | M447079 | 99.5 | M447172 | 99.666 | M447399 | 99.2 | M447844 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7483.47 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 746703.37 | Quality Index Upper (QU) : (U - XBAR) / S | 7.98 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 746697.64 | Quality Index Lower (QL) : (XBAR - L) / S | 6.40 |
| Corrected Sum of Squares (SS) | 5.73 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.28 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.78 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F15120V15AC100 Model Number : I-70S Division : 01 Sample Lot : 2500 Lot Descr : KU I70-11
 In Service Population : 9218 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C298477 | 99.4 | C342178 | 99.7 | C351763 | 100.1 | C351947 | 100 | C352192 | 100.185 |
| L309863 | 99.6 | L309933 | 99.5 | L309959 | 99.8 | L310067 | 99.827 | L310154 | 99.9 |
| L310250 | 99.8 | L310263 | 100.1 | L310666 | 100 | L311220 | 99.481 | L311604 | 100 |
| L311741 | 99.6 | L311955 | 99.6 | L311996 | 100.2 | L312144 | 99.8 | L312528 | 100.2 |
| L312685 | 100.2 | L312802 | 100.2 | L313133 | 100.1 | W149338 | 99.578 | W149454 | 99.8 |
| W149471 | 99.7 | W149697 | 99.6 | W149710 | 99.679 | W149881 | 99.027 | W150216 | 99.2 |
| W150268 | 99.5 | W150387 | 99.7 | W150490 | 98.9 | W150586 | 100 | W150858 | 99.9 |
| W150864 | 99.8 | W150885 | 99.8 | W150914 | 100 | W151240 | 100.1 | W151285 | 99.7 |
| W151606 | 100.071 | W152023 | 99.8 | W152087 | 99.9 | W152147 | 100 | W152246 | 99.8 |
| W152267 | 99.7 | W152452 | 99.65 | W152506 | 99.8 | W152523 | 99.8 | W152531 | 99.7 |
| W152562 | 99.9 | W152895 | 99.8 | W152955 | 99.8 | W153000 | 100.2 | W153020 | 99.7 |
| W153094 | 99.9 | W153246 | 99.8 | W153587 | 100 | W153726 | 99.7 | W154185 | 99.4 |
| W154528 | 99.6 | W154575 | 99.8 | W154661 | 100.1 | W154714 | 100.1 | W154720 | 100.1 |
| W154758 | 99.7 | W154765 | 99.8 | W154779 | 99.7 | W155037 | 100 | W155128 | 99.9 |
| W155177 | 99.714 | W155238 | 99.8 | W155546 | 99.9 | W155561 | 100.1 | W155594 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7485.71 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 747150.02 | Quality Index Upper (QU) : (U - XBAR) / S | 8.19 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 747144.72 | Quality Index Lower (QL) : (XBAR - L) / S | 6.76 |
| Corrected Sum of Squares (SS) | 5.30 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.27 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.81 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : J4S

Division : 01

Sample Lot : 2501

Lot Descr : KU J4S-1

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C228785 | 100 | C233240 | 99.6 | C233317 | 99.8 | C233380 | 100.5 | C233505 | 100.2 |
| C240089 | 100 | C240288 | 99.9 | C240586 | 99.9 | C245094 | 99.9 | C248747 | 100.1 |
| C248878 | 100.4 | C248922 | 100.1 | C249048 | 100 | C249248 | 99.6 | C249634 | 100.5 |
| C249695 | 100.075 | C253370 | 99.6 | C253560 | 100 | C253923 | 100.4 | C254052 | 99.4 |
| C262836 | 100 | C262902 | 99.6 | C262979 | 100.1 | C263053 | 100 | C263332 | 99.8 |
| C263402 | 99.831 | C263651 | 99.6 | C263767 | 99.7 | C268086 | 99.9 | C268622 | 100 |
| C268655 | 100 | C268725 | 99.7 | C268855 | 99.6 | C268856 | 99.3 | C268960 | 99.5 |
| L240082 | 99.4 | L240259 | 99.9 | L241952 | 99.6 | L242046 | 99.6 | L242085 | 99.7 |
| L242189 | 99.6 | M352405 | 99.7 | M373857 | 100.2 | M374773 | 100.1 | M381563 | 99.4 |
| M381565 | 99.5 | M388177 | 100.1 | M393745 | 99.8 | M394237 | 100.9 | M408702 | 99.5 |
| M409071 | 99.8 | M409170 | 99.632 | M409337 | 100 | M409347 | 100.2 | M410688 | 99.8 |
| M412635 | 99.8 | M412908 | 99.7 | M412944 | 99.977 | M413190 | 99.8 | M415692 | 100.9 |
| M415757 | 100.2 | M415810 | 99.9 | M415862 | 100 | W103852 | 99.8 | W104268 | 99.361 |
| W105232 | 99.7 | W105253 | 100.3 | W106155 | 100.4 | W106796 | 100 | W108269 | 99.704 |
| W110794 | 100.1 | W111387 | 99.6 | W112242 | 99.7 | W112289 | 99.757 | W117950 | 99.834 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7491.57 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748322.79 | Quality Index Upper (QU) : (U - XBAR) / S | 6.49 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 748314.95 | Quality Index Lower (QL) : (XBAR - L) / S | 5.80 |
| Corrected Sum of Squares (SS) | 7.84 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.11 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.33 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.89 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J4S Division : 01 Sample Lot : 2502 Lot Descr : KU J4S-2
 In Service Population : 611 Sample Quantity : 35 Meters Tested : 35 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C351165 | 100 | C351252 | 99.9 | C351287 | 100 | C351358 | 100.027 | C351419 | 99.8 |
| C351475 | 99.4 | C351508 | 99.4 | C351532 | 99.6 | C351555 | 99.6 | C351575 | 99.8 |
| C351606 | 100.1 | C351626 | 99.7 | C351635 | 100.5 | L244917 | 99.7 | L245887 | 100 |
| M415923 | 100 | M415983 | 99.9 | M416024 | 99.7 | M416030 | 99.3 | M416063 | 99.5 |
| M416065 | 99.5 | M416106 | 99.6 | M416107 | 99.3 | M416117 | 99.7 | M428133 | 99.9 |
| P000587 | 99.7 | P000588 | 100.5 | W123591 | 99.4 | W123641 | 99.7 | W123664 | 99.7 |
| W123725 | 99.745 | W123737 | 99.8 | W123770 | 99.6 | W123807 | 99.1 | W123811 | 99.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 35 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 3490.47 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 348100.26 | Quality Index Upper (QU) : (U - XBAR) / S | 6.92 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 348096.59 | Quality Index Lower (QL) : (XBAR - L) / S | 5.26 |
| Corrected Sum of Squares (SS) | 3.67 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.11 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.33 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.73 | Maximum Allowable Percent NCF (M) | 5.58 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J55 Division : 01 Sample Lot : 2503 Lot Descr : KU J55-1
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C273084 | 99.9 | C273433 | 100.2 | C273757 | 99.7 | C273998 | 100.1 | C277698 | 99.6 |
| C277764 | 100.1 | C278289 | 99.9 | C278372 | 99.9 | C278431 | 100 | C278573 | 100 |
| C278711 | 100 | C278740 | 100 | C282287 | 99.8 | C282345 | 100.3 | C282468 | 100.3 |
| C282768 | 99.9 | C287915 | 100 | C288014 | 100 | C288393 | 99.6 | C288550 | 99.7 |
| C288677 | 100.4 | C288681 | 99.6 | L242927 | 99.9 | L243427 | 100.3 | L244736 | 100.3 |
| L244885 | 100.3 | L244945 | 100.2 | L245886 | 99.5 | L246233 | 99.8 | L246237 | 100.2 |
| L246275 | 100.3 | L246283 | 99.9 | L246925 | 99.8 | L246948 | 99.9 | L247162 | 100.3 |
| L247214 | 99.6 | L247311 | 99.9 | L247541 | 100 | L247620 | 100.042 | L247906 | 99.4 |
| L248315 | 99.7 | L248328 | 99.8 | L248532 | 99.8 | L248689 | 99.9 | L248788 | 99.957 |
| L250252 | 99.8 | L250345 | 99.8 | L250441 | 99.9 | L250558 | 100.1 | L250780 | 99.785 |
| L250794 | 99.6 | L251103 | 99.7 | L251395 | 99.6 | L251775 | 100.045 | L252502 | 99.7 |
| L252541 | 99.9 | L252654 | 100.2 | L252785 | 99.9 | L253246 | 100 | L253474 | 99.7 |
| L253499 | 99.6 | L253831 | 99.9 | L253936 | 100.1 | L254368 | 100.1 | L254487 | 100.3 |
| L254568 | 100.2 | L254577 | 99.6 | L254633 | 99.6 | W124120 | 100.1 | W124269 | 99.8 |
| W126078 | 100.2 | W126180 | 100.2 | W126274 | 100 | W127101 | 99.916 | W127142 | 100.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7495.45 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749093.41 | Quality Index Upper (QU) : (U - XBAR) / S | 10.01 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749090.28 | Quality Index Lower (QL) : (XBAR - L) / S | 9.42 |
| Corrected Sum of Squares (SS) | 3.13 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.04 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.21 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.94 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2500) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2504 Lot Descr : KU J5S-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C283783 | 99.7 | C283950 | 99.9 | C284548 | 99.9 | C291450 | 99.9 | C291575 | 99.8 |
| C291631 | 100.1 | C292011 | 100.5 | C292156 | 100.305 | C292217 | 100 | C292318 | 100.2 |
| C292328 | 99.9 | L254827 | 100 | L255151 | 100.43 | L255538 | 99.9 | L255597 | 100.4 |
| L255675 | 99.8 | L255709 | 100.4 | L255862 | 100.1 | L256771 | 99.9 | L256867 | 99.2 |
| L257168 | 99.8 | L257305 | 100.1 | L257416 | 99.4 | L257565 | 99.9 | L257761 | 100.06 |
| L257798 | 100 | L257907 | 99.9 | L258072 | 100 | L258179 | 99.8 | L258286 | 100.3 |
| L258319 | 100.1 | L258648 | 100.4 | L258651 | 99.8 | L258955 | 100.2 | L259172 | 100.2 |
| L259511 | 100 | L259775 | 100.2 | L259805 | 100.2 | L260605 | 99.9 | M421509 | 100.134 |
| M421692 | 99.6 | M422669 | 100.5 | M422670 | 100 | M422909 | 99.9 | M423036 | 99.6 |
| M423054 | 99.8 | M423100 | 99.9 | M423310 | 100.1 | M423430 | 100.1 | M423574 | 100 |
| M423847 | 100 | M423986 | 100.1 | M424032 | 99.7 | M424285 | 98.9 | M424347 | 100 |
| M424374 | 100 | M424494 | 99.6 | M424521 | 99.9 | M424533 | 100.4 | M424680 | 100.2 |
| M424690 | 99.5 | M424818 | 99.9 | M428611 | 100.2 | M429154 | 99.8 | M429223 | 100.2 |
| M429274 | 100.4 | M429373 | 100 | M429453 | 100.1 | M429479 | 100.1 | W128112 | 99.709 |
| W129583 | 99.98 | W130616 | 100.1 | W130720 | 99.8 | W130760 | 100 | W130892 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7498.72 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749749.37 | Quality Index Upper (QU) : (U - XBAR) / S | 7.50 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749744.02 | Quality Index Lower (QL) : (XBAR - L) / S | 7.38 |
| Corrected Sum of Squares (SS) | 5.35 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.27 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.98 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : J55

Division : 01

Sample Lot : 2505

Lot Descr : KU J55-3

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C294688 | 100.3 | C294711 | 99.6 | C295023 | 100 | C295173 | 99.9 | C295356 | 100.1 |
| C295463 | 100.1 | C295631 | 100.1 | C295777 | 100.3 | C297307 | 99.7 | C297328 | 100.4 |
| C297334 | 100 | C297811 | 99.8 | C297949 | 100.2 | C297978 | 99.6 | C302885 | 100.1 |
| C302989 | 99.8 | C302996 | 99.4 | C303094 | 99.6 | C303096 | 100 | C303221 | 100.2 |
| C303327 | 100 | C303513 | 100.2 | C303553 | 100.1 | C303842 | 100.1 | C304024 | 99.5 |
| C304127 | 99.6 | L260741 | 99.8 | L260758 | 99.9 | L260839 | 99.7 | L261040 | 100.1 |
| L261572 | 100.3 | L261684 | 100.1 | L261713 | 100.2 | L261747 | 100.4 | L261922 | 99.9 |
| L261925 | 100.1 | L262091 | 100.1 | L262139 | 100.2 | L262149 | 100.4 | L267049 | 100.2 |
| L267268 | 99.9 | L267426 | 100.2 | L267559 | 99.8 | L267754 | 99.9 | L268955 | 100 |
| L269144 | 99.9 | L269276 | 100 | L269359 | 100.2 | L269519 | 99.8 | L269598 | 99.9 |
| L269761 | 99.7 | L270013 | 100.2 | L270112 | 99.7 | L270298 | 99.6 | L270310 | 99.6 |
| L270370 | 99.6 | L270569 | 100 | M430100 | 99.9 | M430111 | 100.1 | M430474 | 99.6 |
| M430522 | 100.1 | M430541 | 99.8 | M430686 | 100 | M430803 | 99.8 | M430878 | 100.1 |
| M432331 | 100.3 | M432380 | 100.4 | M432735 | 100 | M432772 | 99.8 | M432869 | 99.7 |
| M432883 | 99.921 | M433120 | 100.3 | M433569 | 99.8 | W131010 | 100.1 | W131114 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7497.72 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749548.59 | Quality Index Upper (QU) : (U - XBAR) / S | 8.21 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749544.07 | Quality Index Lower (QL) : (XBAR - L) / S | 7.97 |
| Corrected Sum of Squares (SS) | 4.52 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.25 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.97 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2500) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2506 Lot Descr : KU J5S-4
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C304315 | 99.7 | C304407 | 99.891 | C305812 | 99.4 | C305910 | 99.6 | C306042 | 99.4 |
| C306161 | 99.7 | C306624 | 99.4 | C306909 | 100.1 | C306976 | 99.6 | C307042 | 99.1 |
| C307078 | 99.8 | C307495 | 99.6 | C307565 | 99.6 | C307656 | 99.7 | C307794 | 99.7 |
| C307899 | 99.8 | C307980 | 99.6 | C308042 | 99.8 | C308105 | 99.7 | C308379 | 99.7 |
| C308904 | 99.7 | C308915 | 99.7 | C309090 | 99.7 | C309286 | 99.6 | C309327 | 99.7 |
| C309339 | 99.9 | C309393 | 99.5 | C309642 | 99.7 | C309661 | 99.7 | C309763 | 100 |
| C309931 | 99.7 | C310021 | 99.9 | C310106 | 99.8 | C310186 | 99.7 | C310253 | 99.6 |
| C310288 | 99.7 | C310304 | 99.6 | C310390 | 99.3 | C310427 | 99.8 | L268239 | 100 |
| L270869 | 99.9 | L271781 | 100 | L271925 | 100 | L271952 | 100.1 | L272172 | 99.538 |
| L272300 | 99.6 | L272403 | 99.8 | L272698 | 99.7 | L272917 | 99.6 | L272987 | 100.2 |
| L273034 | 99.6 | L273116 | 100.3 | L273382 | 100.3 | L273396 | 100 | L273464 | 100.3 |
| L273482 | 99.9 | L273549 | 99.7 | L273587 | 100.2 | L273705 | 99.6 | L273826 | 99.8 |
| L273962 | 100 | L273964 | 100 | L274233 | 99.869 | L274362 | 99.8 | L274560 | 99.5 |
| L274599 | 99.8 | L274614 | 100.3 | L274797 | 99.7 | L274810 | 100.3 | L274865 | 99.8 |
| L274954 | 99.5 | L275453 | 99.9 | L276290 | 99.7 | L276316 | 99.8 | P005223 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7483.30 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 746667.64 | Quality Index Upper (QU) : (U - XBAR) / S | 9.66 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 746663.72 | Quality Index Lower (QL) : (XBAR - L) / S | 7.72 |
| Corrected Sum of Squares (SS) | 3.92 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.05 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.23 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.78 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F25240V30AC200 Model Number : J55 Division : 01 Sample Lot : 2507 Lot Descr : KU J55-5
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C310553 | 99.7 | C310737 | 100 | C310813 | 100.1 | C310878 | 100.2 | C311017 | 100.2 |
| C311254 | 100.5 | C311716 | 99.4 | C311792 | 99.5 | C311947 | 99.7 | C312106 | 100 |
| C312186 | 99.8 | C312428 | 100.3 | C312552 | 99.9 | C312698 | 99.7 | C312844 | 100 |
| C313458 | 100 | C313656 | 100 | C313737 | 99.6 | C313751 | 99.8 | C313825 | 99.9 |
| C313876 | 100.2 | C314004 | 99.8 | C314164 | 99.8 | C314259 | 100.3 | C314403 | 100.1 |
| C314446 | 99.8 | C314585 | 99.6 | C314674 | 100.103 | C314704 | 99.7 | C314716 | 100.1 |
| C314931 | 99.5 | C314935 | 99.74 | L277602 | 99.4 | L277698 | 100.3 | L277784 | 99.8 |
| L277846 | 99.5 | L278176 | 99.702 | L278226 | 99.7 | L278311 | 99.6 | L279073 | 100 |
| L279364 | 99.9 | L279722 | 100 | L279763 | 99.6 | L279928 | 100.1 | L280236 | 99.7 |
| L280655 | 99.8 | L280674 | 99.9 | L280740 | 99.8 | L280982 | 100.3 | L281163 | 99.6 |
| L281242 | 100 | L281246 | 99.9 | L281556 | 99.6 | L281655 | 100 | L281667 | 99.7 |
| L281777 | 99.779 | L281895 | 100.4 | L282300 | 99.9 | L282389 | 99.9 | L282683 | 99.8 |
| L282807 | 100 | L282966 | 99.4 | L283023 | 99.5 | L283224 | 99.8 | L283288 | 99.6 |
| L283331 | 100.1 | L283457 | 99.7 | L283529 | 99.7 | M438671 | 99.6 | M438751 | 99.2 |
| M438834 | 99.7 | M438837 | 99.9 | M438844 | 100.2 | M439088 | 100 | M439157 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7488.82 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 747771.47 | Quality Index Upper (QU) : (U - XBAR) / S | 7.67 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 747765.67 | Quality Index Lower (QL) : (XBAR - L) / S | 6.61 |
| Corrected Sum of Squares (SS) | 5.80 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.28 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.85 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2508 Lot Descr : KU J5S-6
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C315485 | 99.8 | C316002 | 100 | C316144 | 99.9 | C316148 | 100 | C316181 | 99.7 |
| C316402 | 99.8 | C316497 | 100 | C316934 | 99.6 | C317122 | 100.2 | C317655 | 99.8 |
| C317735 | 99.9 | C317816 | 99.6 | C317852 | 100 | C317870 | 100.082 | C317898 | 99.8 |
| C317915 | 100.2 | C317918 | 99.4 | C318093 | 99.9 | C318338 | 100 | C318345 | 99.8 |
| C318373 | 99.9 | C318823 | 99.8 | C318889 | 100 | C319170 | 100 | C319238 | 99.7 |
| C319265 | 99.9 | C319268 | 99.6 | C319426 | 99.5 | C319526 | 100.3 | C319555 | 100.1 |
| C319600 | 100.1 | C319921 | 99.9 | C319931 | 100.1 | C320286 | 99.5 | C320377 | 100.2 |
| L283760 | 99.8 | L283778 | 99.848 | L283896 | 99.8 | L284114 | 99.5 | L284196 | 99.6 |
| L284498 | 99.9 | L284705 | 100.1 | L284878 | 99.7 | L284902 | 99.9 | L285123 | 99.5 |
| L285142 | 100.1 | L285150 | 100.3 | L285358 | 99.7 | L285377 | 99.9 | L285536 | 99.4 |
| L285547 | 99.7 | L286208 | 99.967 | L286228 | 99.9 | L286316 | 100 | L286429 | 100.1 |
| L286789 | 100.2 | M437162 | 100.1 | W138463 | 99.484 | W138660 | 99.7 | W138945 | 99.8 |
| W139236 | 99.961 | W139289 | 99.8 | W139418 | 100.012 | W139449 | 99.6 | W139515 | 99.9 |
| W139593 | 99.8 | W139616 | 99.6 | W139645 | 100.5 | W139792 | 100.3 | W139884 | 99.9 |
| W140242 | 100 | W140243 | 99.705 | W140255 | 99.8 | W140302 | 100.1 | W140331 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7491.06 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748216.77 | Quality Index Upper (QU) : (U - XBAR) / S | 9.47 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 748213.07 | Quality Index Lower (QL) : (XBAR - L) / S | 8.41 |
| Corrected Sum of Squares (SS) | 3.70 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.05 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.22 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.88 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F25240V30AC200 Model Number : J55 Division : 01 Sample Lot : 2509 Lot Descr : KU J55-7
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C325908 | 99.8 | C326062 | 99.9 | C326154 | 100.3 | C326255 | 100 | C326361 | 100 |
| C326457 | 99.7 | C326495 | 100 | C326571 | 100.3 | C326704 | 100.5 | C327153 | 99.6 |
| C327203 | 100 | C327237 | 100.183 | C327253 | 100.1 | C327485 | 99.7 | C327563 | 99.7 |
| C327988 | 99.7 | C328274 | 99.6 | C328638 | 99.3 | C328707 | 100.1 | C328876 | 99.8 |
| C328991 | 100 | C329019 | 99.2 | C329205 | 100.4 | C329507 | 99.7 | C329726 | 100.2 |
| C329795 | 99.9 | C329812 | 99.8 | C329925 | 99.5 | C329945 | 99.2 | C330606 | 99.842 |
| C330702 | 99.8 | C330768 | 100.4 | L287253 | 99.6 | L287448 | 99.8 | L287451 | 100 |
| L287463 | 100 | L287498 | 99.4 | L287511 | 99.5 | L291656 | 99.8 | L291887 | 100.3 |
| L292532 | 100.1 | L292617 | 100 | L292636 | 99.5 | L292673 | 99.6 | L292822 | 99.7 |
| L292962 | 100 | L293004 | 99.7 | L293197 | 100.4 | L293339 | 100 | L293548 | 99.8 |
| L293607 | 100.2 | L293863 | 100.2 | L293888 | 99.8 | L294019 | 99.9 | L294163 | 100.3 |
| L294328 | 99.9 | L294366 | 100.141 | L294442 | 100.3 | L294544 | 99.7 | M439551 | 100.3 |
| M439600 | 99.6 | M439891 | 100.5 | M440565 | 99.5 | M440683 | 100 | W140456 | 99.8 |
| W140929 | 99.9 | W141029 | 100.1 | W141220 | 100.2 | W141265 | 99.7 | W141566 | 99.5 |
| W141584 | 99.7 | W141593 | 99.7 | W141799 | 100.057 | W142297 | 100.1 | W142356 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7492.52 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748511.99 | Quality Index Upper (QU) : (U - XBAR) / S | 6.71 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 748504.75 | Quality Index Lower (QL) : (XBAR - L) / S | 6.07 |
| Corrected Sum of Squares (SS) | 7.24 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.31 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.90 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2510 Lot Descr : KU J5S-8
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C331273 | 100.1 | C331474 | 99.5 | C331493 | 99.7 | C349453 | 100.2 | C349568 | 99.7 |
| C349698 | 98.9 | C349741 | 99.5 | C350122 | 99.214 | C350177 | 100.1 | C350191 | 99.2 |
| C350335 | 98.7 | C350336 | 100 | C350365 | 99.3 | C350664 | 99.2 | C350833 | 100 |
| C351149 | 99.4 | L294751 | 100.7 | L294830 | 100.4 | L294939 | 100.1 | L295319 | 99.6 |
| L295795 | 99.5 | L295809 | 100.1 | L296464 | 99.8 | L296486 | 99.5 | L296678 | 100.4 |
| L296754 | 99.7 | L296829 | 100.3 | L296899 | 100.214 | L296986 | 99.6 | L297000 | 99.8 |
| L297150 | 99.4 | L297319 | 99.2 | L297329 | 99.1 | L313292 | 99.5 | L313312 | 99.6 |
| L313408 | 99.8 | L313476 | 99.695 | L313707 | 98.9 | L313780 | 99 | L313797 | 99.5 |
| L314018 | 99.5 | L314028 | 100.2 | M437373 | 99.9 | M442663 | 99.8 | M442696 | 99.752 |
| M443167 | 99.9 | M443175 | 99.983 | M443232 | 100.1 | M443268 | 99.8 | M443272 | 100.5 |
| M443449 | 100.4 | M443740 | 99.5 | M444093 | 99.9 | M444124 | 100 | M444206 | 100.4 |
| M444308 | 100.1 | M445917 | 100.3 | M446050 | 100.1 | M446092 | 99.9 | M446286 | 100.3 |
| M446333 | 100.3 | W144642 | 99.98 | W144813 | 99.6 | W144835 | 100.3 | W144878 | 99.8 |
| W144879 | 100.1 | W145041 | 99.9 | W145098 | 100.2 | W145128 | 100.3 | W145285 | 100 |
| W145506 | 99.9 | W146149 | 100 | W146323 | 99.4 | W146359 | 99.906 | W146513 | 100.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7486.44 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 747304.46 | Quality Index Upper (QU) : (U - XBAR) / S | 5.01 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 747290.45 | Quality Index Lower (QL) : (XBAR - L) / S | 4.18 |
| Corrected Sum of Squares (SS) | 14.01 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.19 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.44 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.82 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2511 Lot Descr : KU J5S-9
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C353408 | 99.4 | C353486 | 99.8 | C353597 | 99.5 | C353669 | 99.8 | C353885 | 99.1 |
| C354134 | 100.3 | C354385 | 99.4 | C354390 | 100.4 | C354446 | 99.889 | C354448 | 100.2 |
| C354509 | 100.5 | C354563 | 99.3 | C354644 | 100.027 | C354770 | 99 | C354811 | 99.5 |
| C355006 | 100.002 | C355015 | 99.4 | C355041 | 99.1 | C355195 | 99.1 | C355475 | 99.3 |
| C356049 | 99.6 | C356720 | 99 | C356746 | 100 | C357121 | 100.5 | C357290 | 99.2 |
| C357291 | 99.9 | C357386 | 99.8 | C357611 | 99.9 | C357704 | 99.6 | C357776 | 99.4 |
| C357860 | 100 | C357943 | 99.4 | C358245 | 99.4 | C358332 | 99.6 | C358374 | 99.5 |
| C358394 | 99.2 | C358589 | 99.9 | C359018 | 99.7 | C359059 | 99.3 | C359226 | 99.9 |
| C359280 | 100.3 | C359557 | 99.7 | C359587 | 99 | C359853 | 100.2 | C360009 | 99.4 |
| C360046 | 100.2 | C360131 | 99.7 | C360140 | 99.6 | C360364 | 99.7 | C360389 | 99.2 |
| C360630 | 99.1 | C361009 | 99.1 | C361040 | 99.9 | C361070 | 99.6 | C361180 | 99.8 |
| C361195 | 99.4 | L314189 | 99.087 | L314215 | 99.5 | L314344 | 99.7 | L314984 | 100.1 |
| L314996 | 99.1 | L315128 | 99.3 | L315375 | 100 | L315750 | 99.9 | L315895 | 99.4 |
| L315896 | 100 | L316400 | 99.3 | L316428 | 99.3 | L316521 | 99.4 | L316758 | 99 |
| L316944 | 99.7 | L317018 | 99.4 | L317232 | 99.6 | L317349 | 99.6 | L317376 | 99.4 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7470.51 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 744123.74 | Quality Index Upper (QU) : (U - XBAR) / S | 6.46 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 744113.60 | Quality Index Lower (QL) : (XBAR - L) / S | 4.34 |
| Corrected Sum of Squares (SS) | 10.14 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.14 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.37 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.61 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2512 Lot Descr : KU J5S-10
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C361607 | 99.5 | C361953 | 99.6 | C362023 | 99.8 | C362055 | 100.2 | C362295 | 99.8 |
| C362340 | 99.6 | C362393 | 100 | C362491 | 99.4 | C362531 | 98.6 | C363026 | 99.3 |
| C363133 | 99.5 | C363161 | 100 | C363186 | 99.5 | C363377 | 98.8 | C363630 | 99.3 |
| C363723 | 99.8 | C363790 | 99.7 | C364110 | 99.4 | C364114 | 99.7 | C364163 | 99.4 |
| C364339 | 99 | C364402 | 99.8 | C364685 | 100.1 | C364756 | 99.4 | C364883 | 98.8 |
| C364935 | 99.6 | C365006 | 99.033 | C365245 | 99.2 | C365405 | 99.2 | C365495 | 99.4 |
| C365574 | 99.3 | C366056 | 99 | C366145 | 100 | C366155 | 99.5 | C366190 | 99.9 |
| C366312 | 99.9 | C366502 | 99.1 | C366650 | 99.7 | C366753 | 99.4 | C366765 | 99.8 |
| C366908 | 99.1 | C366917 | 99.3 | C367464 | 99.94 | C367711 | 99.6 | C367759 | 100.2 |
| C368086 | 99 | C368247 | 100 | C368360 | 99.5 | C370375 | 100.1 | C370553 | 98.8 |
| C370891 | 100 | C370926 | 99.7 | M448093 | 99.6 | M448278 | 99.8 | M448377 | 99.4 |
| M448503 | 99.8 | M448603 | 99 | M448805 | 99.4 | M448930 | 99.5 | M449095 | 99.9 |
| M449119 | 99.3 | M449131 | 99.7 | M449215 | 99.5 | M449302 | 100 | M449342 | 99.6 |
| M449409 | 99.2 | M449454 | 99.9 | M449936 | 99.7 | M450221 | 99.3 | M450323 | 98.7 |
| M450459 | 99.6 | M450483 | 99.7 | M450665 | 99.6 | M450737 | 100.1 | M450762 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7465.57 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 743140.96 | Quality Index Upper (QU) : (U - XBAR) / S | 6.33 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 743129.81 | Quality Index Lower (QL) : (XBAR - L) / S | 3.97 |
| Corrected Sum of Squares (SS) | 11.15 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.15 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.39 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.54 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2513 Lot Descr : KU J5S-11
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C371034 | 99.3 | C371046 | 99.9 | C371093 | 99.3 | C371125 | 99.9 | C371216 | 99.9 |
| C371220 | 99.6 | C371334 | 99.4 | C371528 | 99.1 | C371665 | 100 | C371749 | 99 |
| C371880 | 99.2 | C372268 | 99.4 | C372824 | 99 | C372874 | 99.5 | C373054 | 99.3 |
| C373071 | 100 | C373132 | 99.7 | C373136 | 100 | C373381 | 99.8 | C373435 | 99.498 |
| C374240 | 99.3 | C374591 | 99.8 | C374758 | 99.2 | C375183 | 100 | C375200 | 99.6 |
| C375826 | 100.1 | C375842 | 99.961 | C375863 | 99.6 | C376045 | 99.977 | C376109 | 99.9 |
| C376166 | 99.8 | C376201 | 99.9 | C376271 | 99.8 | C376370 | 99.8 | C376427 | 100 |
| C376430 | 100 | C376473 | 100 | C376598 | 100.1 | C376731 | 100.2 | C376954 | 100 |
| C376963 | 100.5 | C377029 | 100 | C377110 | 99.8 | C377450 | 99.6 | C377555 | 99.9 |
| C377691 | 99.7 | C377874 | 99.7 | C378041 | 99.7 | C378081 | 99.4 | C378110 | 99.3 |
| C378285 | 99.9 | C378407 | 100.2 | C378447 | 99.8 | C378905 | 99.5 | C378926 | 99.917 |
| C379252 | 99.7 | C379587 | 99.7 | C379713 | 99.9 | C379760 | 99.6 | C379808 | 99.1 |
| C379840 | 99.5 | C379963 | 99.4 | C380040 | 99.8 | C380269 | 99.6 | C380273 | 99.641 |
| C383510 | 99.7 | C383559 | 99.9 | C383569 | 99.8 | C383698 | 99.6 | C383743 | 99.5 |
| C383952 | 99.7 | C384084 | 100.4 | C384618 | 100 | C384628 | 99.9 | L317706 | 100 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7479.19 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 745851.79 | Quality Index Upper (QU) : (U - XBAR) / S | 6.92 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 745843.77 | Quality Index Lower (QL) : (XBAR - L) / S | 5.23 |
| Corrected Sum of Squares (SS) | 8.02 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.11 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.33 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.72 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200

Model Number : J5S

Division : 01

Sample Lot : 2514

Lot Descr : KU J5S-12

In Service Population : 10000

Sample Quantity : 75

Meters Tested : 75

Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C384928 | 99.8 | C384933 | 99.5 | C385140 | 100.9 | C385185 | 99.6 | C385512 | 99.4 |
| C385899 | 99.9 | C385922 | 100.1 | C385960 | 99.8 | C386015 | 99.7 | C386254 | 99.7 |
| C386275 | 99.4 | C386295 | 99.8 | C386343 | 100 | C386355 | 100.1 | C386660 | 100.2 |
| C386713 | 99.8 | C386805 | 99.8 | C386940 | 99.9 | C387111 | 100.1 | C387187 | 100 |
| C387383 | 99.8 | C387414 | 99.9 | C387438 | 99.7 | C387468 | 100.1 | C387486 | 100.686 |
| C387494 | 99.8 | C388031 | 99.6 | C388054 | 99.7 | C388071 | 99.3 | C388197 | 99.8 |
| C388346 | 99.7 | C388640 | 99.6 | C388864 | 99.7 | C388914 | 100.2 | C389272 | 100.1 |
| C389405 | 100 | C389547 | 99.9 | C389585 | 99.1 | C389693 | 99.8 | C390132 | 100.1 |
| C392282 | 100.2 | C392337 | 99.6 | C392417 | 100.1 | C392553 | 100.1 | C392563 | 100.2 |
| C392700 | 99.8 | C392805 | 100.4 | C392878 | 99.8 | C392892 | 99.5 | C392984 | 99.9 |
| C393054 | 99.9 | C393099 | 99.9 | C393286 | 99.8 | C393316 | 100.2 | C393990 | 99.6 |
| C394340 | 100.1 | C394413 | 99.9 | C394630 | 100.2 | C394641 | 100.2 | C394804 | 99.6 |
| C394850 | 99.8 | C395042 | 100.1 | C395239 | 99.6 | C395621 | 99.8 | C395867 | 100.1 |
| C395886 | 100 | C396004 | 100.189 | C396190 | 100.5 | C396236 | 100.3 | C396305 | 100.1 |
| C396367 | 100.2 | C396396 | 99.9 | C396476 | 99.8 | C396937 | 99.9 | C397013 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model

One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7493.48 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 748702.15 | Quality Index Upper (QU) : (U - XBAR) / S | 7.60 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 748696.57 | Quality Index Lower (QL) : (XBAR - L) / S | 6.96 |
| Corrected Sum of Squares (SS) | 5.58 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.08 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.27 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.91 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2515 Lot Descr : KU J5S-13
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C397471 | 99.865 | C397498 | 97.6 | C398329 | 99.9 | C398461 | 100.1 | C398466 | 100.1 |
| C398528 | 99.5 | C398615 | 100 | C398654 | 100.2 | C398735 | 100.065 | C399036 | 100.1 |
| C399200 | 99.9 | C399205 | 99.2 | C399502 | 99.4 | C399842 | 100.1 | C399846 | 99.2 |
| C400014 | 99.9 | C400109 | 100.3 | C400216 | 100.5 | C400697 | 99.8 | C400735 | 101.4 |
| C400865 | 100 | C401003 | 99.7 | C401008 | 99.8 | C401120 | 100 | C401146 | 100.3 |
| C401194 | 100.1 | C401263 | 99.5 | C401343 | 99.8 | C401399 | 99.8 | C401430 | 99.6 |
| C401507 | 100.1 | C401729 | 99.4 | C401735 | 100.9 | C401771 | 100.6 | C401851 | 100.2 |
| C402089 | 99.9 | C402125 | 100 | C402137 | 99.7 | C402176 | 100 | C402182 | 100.3 |
| C402241 | 99.6 | C402259 | 100 | C402465 | 99.2 | C402764 | 99.4 | C403106 | 99.7 |
| C403574 | 100.147 | C403695 | 99.9 | C403848 | 100.1 | C403868 | 99.5 | C403871 | 99.9 |
| C404109 | 99.4 | C404174 | 99.8 | C404197 | 100 | C404207 | 98.8 | C404511 | 100.2 |
| C405000 | 99.5 | C405040 | 99.6 | C405114 | 99.8 | C405190 | 100.1 | C405220 | 99.8 |
| C405284 | 99.8 | C405648 | 99.7 | C405795 | 100.2 | C405829 | 99.461 | C406065 | 99.2 |
| C406137 | 99.4 | C410046 | 98.7 | C410066 | 99.2 | C410421 | 98.704 | C410661 | 99.8 |
| C411029 | 98.7 | C411227 | 99.7 | C411240 | 99.995 | C411446 | 99.8 | C411948 | 99.5 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7483.14 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 746651.52 | Quality Index Upper (QU) : (U - XBAR) / S | 4.31 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 746631.79 | Quality Index Lower (QL) : (XBAR - L) / S | 3.44 |
| Corrected Sum of Squares (SS) | 19.73 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.27 | Estimate of Lot Percent NCF Below L (PL) | 0.02 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.52 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.02 |
| Sample Mean (XBAR) : Sum X / N | 99.78 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J5S Division : 01 Sample Lot : 2516 Lot Descr : KU J5S-14
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C412229 | 99.7 | C412316 | 99.7 | C412407 | 99.5 | C412618 | 99.8 | C412734 | 99 |
| C412759 | 99.8 | C412804 | 99.4 | C413301 | 99.3 | C413458 | 98.4 | C413658 | 99.7 |
| C413921 | 98.9 | C413922 | 100 | C414157 | 98.4 | C414256 | 99 | C414314 | 99.3 |
| C414484 | 99.1 | C415142 | 99.1 | C415204 | 99.2 | C415278 | 99.5 | C415510 | 99.7 |
| C417618 | 99.6 | C417644 | 99.5 | C417827 | 99.5 | C418029 | 98.5 | C418055 | 99.1 |
| C418475 | 99.3 | C418700 | 99 | C418790 | 99.7 | C418806 | 99.4 | C418830 | 99.9 |
| C419069 | 99.7 | C419130 | 99.7 | C419215 | 98.7 | C419353 | 99.9 | C419884 | 99.4 |
| C420013 | 99 | C420321 | 98.5 | C420346 | 98.9 | C420352 | 99.6 | C420354 | 100.1 |
| C420673 | 99.6 | C420680 | 100.1 | C420744 | 98.6 | C420909 | 99.5 | C421004 | 99.7 |
| C421160 | 99.7 | C421334 | 99.9 | C421387 | 99.1 | C421441 | 99.3 | C421519 | 99.7 |
| C421578 | 99.9 | C421787 | 99.8 | C421905 | 98.765 | C422043 | 99.144 | C422083 | 98.9 |
| C422095 | 99.8 | C422300 | 99.7 | C422301 | 99.4 | C422381 | 98.8 | C422412 | 99.396 |
| C422600 | 99.3 | C422717 | 99.1 | C423031 | 99.7 | C423315 | 98.7 | C423589 | 99.9 |
| C423608 | 99.8 | C423664 | 99.3 | C423685 | 99 | C423869 | 99.9 | C423911 | 99.9 |
| C424087 | 99.5 | C424178 | 100.3 | C424236 | 98.9 | C424470 | 100.2 | C424471 | 99.6 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7455.40 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 741122.57 | Quality Index Upper (QU) : (U - XBAR) / S | 5.57 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 741106.52 | Quality Index Lower (QL) : (XBAR - L) / S | 3.02 |
| Corrected Sum of Squares (SS) | 16.05 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.22 | Estimate of Lot Percent NCF Below L (PL) | 0.09 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.47 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.09 |
| Sample Mean (XBAR) : Sum X / N | 99.41 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : J55 Division : 01 Sample Lot : 2517 Lot Descr : KU J55-15
 In Service Population : 962 Sample Quantity : 35 Meters Tested : 35 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C424527 | 99.9 | C424544 | 100.2 | C424548 | 99.1 | C424561 | 99.7 | C424566 | 99.9 |
| C424587 | 99.7 | C424628 | 99.3 | C424640 | 99.269 | C424660 | 99.6 | C424679 | 99.9 |
| C424808 | 99.096 | C424816 | 99.5 | C424877 | 99.698 | C424880 | 100 | C424881 | 99.7 |
| C424905 | 99.9 | C424941 | 99.7 | C424948 | 100.4 | C425006 | 99.6 | C425112 | 99.2 |
| C425113 | 99.3 | C425114 | 99.9 | C425185 | 99.7 | C425262 | 99.8 | C425317 | 99.6 |
| C425359 | 99.8 | C425376 | 99.7 | C425397 | 99.9 | C425436 | 99.7 | C425441 | 99.8 |
| C425452 | 100.1 | C425460 | 99.8 | C425465 | 99.8 | C425466 | 99.8 | C425533 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 35 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 3489.76 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 347958.43 | Quality Index Upper (QU) : (U - XBAR) / S | 7.21 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 347955.00 | Quality Index Lower (QL) : (XBAR - L) / S | 5.37 |
| Corrected Sum of Squares (SS) | 3.43 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.32 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.71 | Maximum Allowable Percent NCF (M) | 5.58 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MQS Division : 01 Sample Lot : 2518 Lot Descr : KU MQ-1
 In Service Population : 3286 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C205257 | 100.2 | C205670 | 100.1 | C205680 | 100.1 | C206542 | 100.1 | C206591 | 99.9 |
| C207009 | 100.3 | C207573 | 99.7 | C208034 | 100 | C208110 | 99.6 | C208187 | 100.1 |
| C208684 | 100.3 | C209100 | 100.2 | C209292 | 100.1 | C209328 | 100 | C209421 | 100.2 |
| C209852 | 99.9 | C209893 | 100 | C209926 | 99.7 | C210292 | 99.9 | C210314 | 99.7 |
| C210421 | 100.1 | C210430 | 99.3 | C210439 | 99.7 | C210450 | 100 | C210464 | 99.2 |
| C211239 | 100.1 | C211629 | 100.2 | C212086 | 100 | C213619 | 100.2 | C213699 | 99.8 |
| C214293 | 99.9 | C215474 | 53.74 | C215516 | 100.1 | C215644 | 100.7 | C216458 | 99.8 |
| C216530 | 100.3 | C217855 | 99.9 | C217859 | 100.8 | C217989 | 99.9 | C218102 | 100.1 |
| C218161 | 100 | C219161 | 100.4 | C220779 | 99.6 | C221123 | 99.7 | C221201 | 99.8 |
| C222605 | 99.8 | C223581 | 100.2 | M345325 | 100.1 | M380286 | 100 | M387464 | 99.849 |
| M452372 | 99.8 | W093978 | 100.338 | W094098 | 100.018 | W094548 | 99.994 | W094557 | 100.002 |
| W094632 | 99.885 | W094844 | 99.964 | W094922 | 100.2 | W095168 | 100 | W095952 | 99.9 |
| W096121 | 100.054 | W096147 | 100.07 | W096168 | 100.566 | W096470 | 100.484 | W097324 | 99.961 |
| W098217 | 99.8 | W098226 | 99.9 | W099087 | 100.415 | W099516 | 100.3 | W100274 | 100.051 |
| W100720 | 100 | W100817 | 100.3 | W100995 | 100.5 | W101405 | 99.841 | W101684 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 6300.38 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 630080.51 | Quality Index Upper (QU) : (U - XBAR) / S | 7.39 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 630076.00 | Quality Index Lower (QL) : (XBAR - L) / S | 7.44 |
| Corrected Sum of Squares (SS) | 4.51 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.27 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.01 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MS Division : 01 Sample Lot : 2519 Lot Descr : KU MS-1
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C224781 | 100.6 | C225022 | 100.5 | C231313 | 100.5 | C234718 | 100.3 | C234723 | 100.2 |
| C234887 | 100.1 | C237802 | 100.6 | C238184 | 100.3 | C242152 | 100.45 | L133527 | 100.3 |
| L136137 | 99.7 | L137801 | 99.7 | L138171 | 100.2 | L139241 | 99.7 | L139256 | 100.3 |
| L142902 | 100.1 | L142916 | 100.1 | L142919 | 100.3 | L144381 | 99.6 | L148138 | 100.393 |
| L149595 | 99.9 | L149629 | 100 | L149749 | 100.6 | L149774 | 100.3 | L149946 | 100.1 |
| L171862 | 100 | L171943 | 100.3 | L172002 | 99.8 | L172064 | 100.4 | L173267 | 99.8 |
| L173374 | 99.7 | L173573 | 100.2 | L173589 | 100.2 | L177185 | 100 | L177229 | 100.3 |
| L178700 | 100 | L178786 | 100.3 | L178822 | 99.5 | L178967 | 100 | L179775 | 100 |
| L179828 | 100.3 | L181378 | 100.2 | L181390 | 100.2 | L181446 | 100.1 | L181526 | 100 |
| L181748 | 99.8 | L183108 | 100.2 | L183229 | 100.3 | L183317 | 100.2 | L185337 | 99.7 |
| L185487 | 100.4 | L186532 | 100.6 | L187890 | 99.6 | L187925 | 100.4 | L188034 | 100 |
| L189620 | 100 | L189961 | 100.1 | L190075 | 99.4 | M351344 | 99.5 | M352133 | 100.4 |
| M386439 | 99.7 | M388541 | 99.8 | W103465 | 99.8 | W105043 | 99.899 | W105914 | 99.9 |
| W105948 | 100.323 | W105949 | 99.975 | W107758 | 100.3 | W108095 | 100.4 | W108121 | 100.146 |
| W108496 | 100.2 | W108524 | 100.8 | W108780 | 99.7 | W109149 | 100.339 | W110429 | 100.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7508.32 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751672.61 | Quality Index Upper (QU) : (U - XBAR) / S | 5.86 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 751664.92 | Quality Index Lower (QL) : (XBAR - L) / S | 6.55 |
| Corrected Sum of Squares (SS) | 7.69 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.32 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.11 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MS Division : 01 Sample Lot : 2520 Lot Descr : KU MS-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C242223 | 100.6 | C242418 | 100.5 | C242503 | 100.2 | C242557 | 100 | C246485 | 100.2 |
| C246753 | 100.2 | C246786 | 100.1 | C246957 | 100 | C247239 | 99.8 | C247340 | 99.8 |
| C247440 | 99.5 | C250897 | 100.1 | C250909 | 100.2 | L193200 | 99.4 | L193591 | 100.7 |
| L193723 | 99.9 | L193742 | 100.1 | L193834 | 100 | L193909 | 100.1 | L193912 | 99.955 |
| L194261 | 99.9 | L194348 | 100.3 | L194551 | 99.6 | L194581 | 100 | L194775 | 100 |
| L196983 | 99.5 | L197149 | 100.2 | L197179 | 99.9 | L197359 | 99.8 | L197897 | 99.8 |
| L198196 | 99.9 | L199339 | 99.6 | L201001 | 100 | L201024 | 99.9 | L201128 | 99.4 |
| L201277 | 99.6 | L201395 | 100.1 | L202331 | 99.7 | L202601 | 99.961 | L202619 | 99.6 |
| L202654 | 99.8 | L202730 | 99.7 | L202886 | 100.1 | L203002 | 100.1 | L203243 | 99.6 |
| L203350 | 99.4 | L206298 | 99.9 | L206670 | 99.627 | L209546 | 100.2 | L209759 | 100.2 |
| L209840 | 100.2 | L209843 | 99.7 | L211307 | 100.2 | L211445 | 100.1 | L211550 | 100 |
| L211640 | 100.3 | M384319 | 100.1 | M384367 | 100.2 | M384680 | 100.9 | M384687 | 99.091 |
| W111016 | 99.999 | W111290 | 100 | W111603 | 99.7 | W112188 | 99.7 | W112195 | 100.197 |
| W112889 | 100.1 | W115096 | 99.8 | W115108 | 100.2 | W115123 | 99.867 | W115175 | 99.9 |
| W115177 | 100.1 | W115667 | 100.116 | W115787 | 100.3 | W115942 | 100 | W117196 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7497.41 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749489.52 | Quality Index Upper (QU) : (U - XBAR) / S | 6.42 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 749482.09 | Quality Index Lower (QL) : (XBAR - L) / S | 6.20 |
| Corrected Sum of Squares (SS) | 7.43 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.32 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.97 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MS Division : 01 Sample Lot : 2521 Lot Descr : KU MS-3
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C251354 | 100 | C251428 | 100.1 | C251553 | 100.1 | C251554 | 100.2 | C251602 | 100.1 |
| C251653 | 101.1 | C251727 | 100.6 | C259277 | 100.3 | C259401 | 100.1 | C259593 | 99.8 |
| C259986 | 100.1 | C259988 | 100.2 | C260091 | 100.2 | C260531 | 100.2 | C260682 | 100.5 |
| C260883 | 100 | C260903 | 100.1 | C261053 | 99.9 | C261127 | 100.3 | C261167 | 100.4 |
| C261490 | 100.2 | C265612 | 100 | C265792 | 100.6 | C265894 | 100.5 | C266106 | 100.2 |
| C266677 | 100.5 | C271602 | 99.9 | L212281 | 100.2 | L212431 | 99.6 | L215557 | 100 |
| L215653 | 100.2 | L215724 | 99.6 | L215855 | 99.9 | L216013 | 100.4 | L218279 | 99.9 |
| L218580 | 100 | L218828 | 100.2 | L221352 | 99.8 | L221354 | 100.1 | L222878 | 100.1 |
| L222883 | 99.5 | L222946 | 100.2 | L223304 | 100.1 | L231032 | 100.1 | L231054 | 99.4 |
| L231099 | 99.543 | L231158 | 100.7 | L231304 | 100.3 | L231346 | 100.2 | L232359 | 99.8 |
| L232438 | 99.3 | L236450 | 100.5 | L236707 | 99.6 | L236838 | 100.1 | L237084 | 100 |
| L237141 | 100.3 | L237152 | 100.4 | L237251 | 100.1 | L237288 | 100.1 | L237311 | 100.3 |
| L237431 | 100.2 | L238244 | 100 | L238322 | 100.3 | L238565 | 99.7 | L240921 | 99.9 |
| L240976 | 99.8 | L241099 | 99.8 | W118391 | 99.6 | W118404 | 100.333 | W118434 | 100.1 |
| W118448 | 100.3 | W118536 | 100.372 | W118660 | 100.2 | W118705 | 100.3 | W118828 | 99.8 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7507.45 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751497.46 | Quality Index Upper (QU) : (U - XBAR) / S | 6.31 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 751490.74 | Quality Index Lower (QL) : (XBAR - L) / S | 6.97 |
| Corrected Sum of Squares (SS) | 6.72 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.09 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.30 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.10 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MS Division : 01 Sample Lot : 2522 Lot Descr : KU MS-4

In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C270727 | 100.8 | C270921 | 100.2 | C271672 | 100.1 | C271778 | 99.9 | C275934 | 99.7 |
| C276182 | 100 | C276328 | 99.6 | C280097 | 100.2 | C280209 | 99.9 | C280387 | 100.6 |
| C280919 | 99.7 | C280946 | 100 | C280966 | 100.1 | C284633 | 100.3 | C285288 | 100 |
| C285384 | 99.7 | C285455 | 100.3 | C285793 | 99.8 | C286098 | 99.7 | C286102 | 99.8 |
| C286450 | 99.8 | C286686 | 100.2 | C286708 | 100.3 | C289041 | 100.291 | C289133 | 100.6 |
| C289284 | 100.3 | C289341 | 100.2 | C289510 | 100.1 | C289645 | 99.82 | C289685 | 100.2 |
| C289694 | 100.2 | C289735 | 100 | C289782 | 99.7 | C301050 | 100.1 | C301101 | 100.2 |
| L243811 | 100 | L243952 | 100.1 | L243953 | 99.9 | L244043 | 100.1 | L245207 | 99.9 |
| L245271 | 100 | L245286 | 100.2 | L245489 | 100 | L245643 | 99.6 | L245649 | 99.9 |
| L260098 | 100 | M434615 | 100.3 | M434623 | 100.2 | M434923 | 100.1 | M434958 | 100.2 |
| M435267 | 100.3 | M435539 | 100 | M435560 | 100.1 | W124868 | 100 | W126880 | 100 |
| W132387 | 99.6 | W132485 | 100.1 | W132542 | 100.4 | W132561 | 104.22 | W132625 | 100.8 |
| W133427 | 100.2 | W133542 | 100.277 | W133599 | 99.969 | W134280 | 100.13 | W134282 | 99.799 |
| W134673 | 100 | W134675 | 100.3 | W134720 | 99.84 | W135149 | 99.829 | W135160 | 100.1 |
| W135186 | 100.3 | W135217 | 100 | W135287 | 100.3 | W135332 | 100 | W135419 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7509.58 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 751937.74 | Quality Index Upper (QU) : (U - XBAR) / S | 3.56 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 751917.22 | Quality Index Lower (QL) : (XBAR - L) / S | 4.04 |
| Corrected Sum of Squares (SS) | 20.52 | Estimate of Lot Percent NCF Above U (PU) | 0.01 |
| Variance (V) : SS / (N-1) | 0.28 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.53 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.01 |
| Sample Mean (XBAR) : Sum X / N | 100.13 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MS Division : 01 Sample Lot : 2523 Lot Descr : KU MS-5
 In Service Population : 422 Sample Quantity : 25 Meters Tested : 25 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| L312408 | 100 | L312423 | 99.6 | L312570 | 100 | L312891 | 100.6 | L312902 | 99.8 |
| L312909 | 100.2 | L312991 | 99.9 | L313007 | 99.7 | L313014 | 100.3 | L313028 | 99.7 |
| L313045 | 99.9 | L313051 | 100 | W135786 | 99.7 | W135795 | 100.2 | W135811 | 100.4 |
| W135851 | 99.6 | W135866 | 100.06 | W135899 | 100 | W135914 | 100.3 | W135925 | 100 |
| W135955 | 99.932 | W135987 | 99.536 | W135989 | 99.9 | W135990 | 100.185 | W136014 | 100.1 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 25 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 2499.61 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 249924.31 | Quality Index Upper (QU) : (U - XBAR) / S | 6.51 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 249922.01 | Quality Index Lower (QL) : (XBAR - L) / S | 6.40 |
| Corrected Sum of Squares (SS) | 2.30 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.31 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.98 | Maximum Allowable Percent NCF (M) | 5.98 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MSII Division : 01 Sample Lot : 2524 Lot Descr : KU MSII-1
 In Service Population : 4684 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C275397 | 99.9 | C275506 | 99.8 | C275514 | 100 | C275583 | 99.8 | C275585 | 100.1 |
| C275629 | 100.1 | C275975 | 100 | C285741 | 100 | C298633 | 100.4 | C298827 | 99.8 |
| C300531 | 99.8 | C300548 | 100 | C300611 | 100 | C300641 | 100 | C300711 | 99.7 |
| C300806 | 100 | C300811 | 100 | C300878 | 99.8 | C300968 | 100 | C301372 | 100 |
| C301563 | 100 | C301598 | 100 | C301654 | 100.2 | C301694 | 100.1 | C301717 | 99.8 |
| C301734 | 100.1 | C301818 | 99.9 | C301940 | 100.1 | C302020 | 100 | C302045 | 100.1 |
| C302132 | 99.8 | C302283 | 100.3 | C302408 | 99.7 | C302455 | 99.8 | C302460 | 100 |
| C302478 | 100.143 | C302511 | 100.3 | C302536 | 100 | C302658 | 99.9 | L312851 | 99.7 |
| M416333 | 99.8 | M416537 | 100.4 | M416575 | 99.6 | M421196 | 99.929 | M421359 | 99.8 |
| M422007 | 100.1 | M422027 | 100.2 | M422275 | 100 | M422382 | 100.2 | M422479 | 100.2 |
| M422486 | 99.7 | M422514 | 100.1 | M428484 | 99.8 | M428494 | 100.2 | M428558 | 100 |
| M435653 | 100.1 | M435718 | 99.9 | M435743 | 100.1 | M435773 | 100.4 | M435843 | 100 |
| M435924 | 100.2 | M435971 | 100.2 | M435998 | 100.2 | M436079 | 100.1 | M436086 | 100 |
| M436092 | 100.1 | M436241 | 100.102 | M436281 | 100.2 | M436343 | 99.9 | M436384 | 100.188 |
| M436413 | 100.1 | M436507 | 100.2 | M436510 | 99.9 | M436537 | 99.9 | M436599 | 100.3 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|-------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7501.26 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 750254.78 | Quality Index Upper (QU) : (U - XBAR) / S | 10.27 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 750252.02 | Quality Index Lower (QL) : (XBAR - L) / S | 10.45 |
| Corrected Sum of Squares (SS) | 2.76 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.04 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.19 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 100.02 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MX Division : 01 Sample Lot : 2525 Lot Descr : KU MX-1
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C320821 | 100 | C320948 | 100.2 | C320976 | 99.5 | C321146 | 99.8 | C321280 | 100.1 |
| C321476 | 99.9 | C321488 | 99.8 | C321623 | 100 | C321676 | 100.1 | C321772 | 99.8 |
| C322191 | 99.9 | C322195 | 99.9 | C322474 | 100.1 | C322600 | 99.8 | C322869 | 100.2 |
| C323021 | 99.8 | C323224 | 99.9 | C323229 | 100 | C323239 | 99.452 | C323299 | 99.8 |
| C323306 | 100 | C323346 | 100.1 | C323674 | 99.8 | C323777 | 99.9 | C324016 | 99.6 |
| C324234 | 99.3 | C324257 | 99.8 | C324417 | 99.7 | C324506 | 99.7 | C324856 | 100 |
| C324858 | 100.2 | C324973 | 100 | C325050 | 100.2 | C325217 | 100 | C325339 | 100 |
| C325572 | 100.2 | C325625 | 100.3 | C325701 | 100 | L288012 | 100.1 | L288283 | 100.1 |
| L288318 | 99.7 | L288537 | 99.915 | L288648 | 100.1 | L288701 | 100.2 | L288772 | 100.1 |
| L288859 | 99.9 | L289015 | 99.6 | L289169 | 99.8 | L289232 | 100.2 | L289338 | 99.8 |
| L289404 | 99.7 | L289542 | 99.9 | L289645 | 99.7 | L290042 | 100.1 | L290387 | 100.7 |
| L290554 | 100 | L290672 | 99.8 | L290979 | 99.827 | L291384 | 100.1 | L292191 | 99.9 |
| M440923 | 100.1 | M440938 | 99.8 | M440999 | 99.9 | M441233 | 100.016 | M441502 | 99.8 |
| M441733 | 99.9 | M442440 | 100.1 | M442453 | 100.5 | M442555 | 100.3 | W142527 | 100.102 |
| W142855 | 99.9 | W143035 | 99.8 | W143127 | 99.688 | W143301 | 99.9 | W143432 | 99.9 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7495.80 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 749163.97 | Quality Index Upper (QU) : (U - XBAR) / S | 9.15 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 749160.24 | Quality Index Lower (QL) : (XBAR - L) / S | 8.65 |
| Corrected Sum of Squares (SS) | 3.73 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.05 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.22 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.94 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MX Division : 01 Sample Lot : 2526 Lot Descr : KU MX-2
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C390772 | 99.8 | C391292 | 99 | C391468 | 99.6 | C391564 | 99.6 | C425962 | 99.7 |
| C426116 | 99.7 | C426255 | 100.2 | C426265 | 99.4 | C426615 | 99.6 | C426616 | 99.2 |
| C426757 | 99.9 | C426870 | 99.544 | C426891 | 99.6 | C426978 | 99.8 | C426984 | 99.2 |
| C427051 | 99.6 | C427088 | 99.6 | C427139 | 99.5 | C427320 | 99.5 | C427336 | 99.6 |
| C427450 | 99.8 | C427511 | 99.4 | C427717 | 99.1 | C427823 | 99.4 | C427837 | 99.8 |
| C427861 | 99.8 | C428297 | 100 | C428473 | 99.9 | C428872 | 99.8 | C428942 | 99.3 |
| C428982 | 100 | C429062 | 100 | C429250 | 99.8 | C429474 | 99.6 | C429562 | 99.6 |
| C429686 | 100 | C429847 | 99.4 | C430030 | 99.4 | C430204 | 99.8 | C430244 | 99.4 |
| C431068 | 99.4 | C431078 | 99.5 | C431097 | 98.9 | C431369 | 99.7 | C431502 | 99.5 |
| C431608 | 99.5 | C431793 | 99.852 | C435475 | 99.7 | C435639 | 99.1 | C435857 | 99.4 |
| C435892 | 99.5 | C436123 | 99.6 | C436140 | 99.7 | C436274 | 99.6 | C436342 | 99.7 |
| C436418 | 99.4 | C436455 | 99.4 | C436507 | 99.6 | C436592 | 99.5 | C436750 | 100.1 |
| C436760 | 99.6 | C436770 | 99.5 | C436772 | 99.7 | C436861 | 99.619 | C436926 | 99.4 |
| C436949 | 99.9 | C437128 | 99.2 | C437535 | 99.4 | C437827 | 99.6 | C437929 | 99.3 |
| C437943 | 99.1 | C438095 | 99.5 | C438121 | 99.3 | C438570 | 100 | W143570 | 100.402 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7469.12 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 743841.81 | Quality Index Upper (QU) : (U - XBAR) / S | 9.19 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 743836.71 | Quality Index Lower (QL) : (XBAR - L) / S | 6.05 |
| Corrected Sum of Squares (SS) | 5.10 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.07 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.26 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.59 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MX Division : 01 Sample Lot : 2527 Lot Descr : KU MX-3
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C439093 | 99.7 | C439331 | 99.7 | C439860 | 100 | C439865 | 100.1 | C440052 | 100.3 |
| C440201 | 99.9 | C440300 | 99.5 | C440350 | 99.9 | C440463 | 99.9 | C440482 | 99.8 |
| C440496 | 99.8 | C440630 | 99.9 | C440644 | 99.8 | C440726 | 100 | C441041 | 99.8 |
| C441146 | 99.8 | C441333 | 99.8 | C441382 | 99.9 | C441461 | 99.3 | C441591 | 99.761 |
| C441996 | 99.8 | C442026 | 99.6 | C442378 | 99.7 | C442529 | 99.3 | C442716 | 99.6 |
| C442855 | 99.6 | C442931 | 99.607 | C443087 | 99.5 | C443479 | 99.6 | C443574 | 98.6 |
| C443595 | 98.9 | C443635 | 99.2 | C443661 | 98.398 | C443678 | 99.359 | C443802 | 100.1 |
| C443997 | 99.7 | C444079 | 99.9 | C444095 | 99.7 | C444185 | 99.1 | C444282 | 98.7 |
| C444671 | 99.5 | C444675 | 99.8 | C444962 | 99.1 | C444993 | 99.3 | C446384 | 99.6 |
| C446519 | 99.688 | C446579 | 99.1 | C446604 | 99.6 | C446960 | 99.5 | C447145 | 100 |
| C447364 | 99.5 | C447563 | 99.7 | C447599 | 99.5 | C447985 | 99.2 | C448088 | 99.2 |
| C448180 | 99.6 | C448305 | 99.7 | C448324 | 99.6 | C448534 | 99.4 | C448561 | 99.5 |
| C448768 | 99.5 | C448956 | 99.5 | C448972 | 99.634 | C449086 | 99.8 | C449521 | 99.8 |
| C449639 | 99.5 | C449641 | 99.5 | C449741 | 99.7 | C449752 | 99.6 | C449953 | 99.8 |
| C450057 | 99.9 | C450283 | 99.9 | C450519 | 99.7 | C450524 | 99.8 | C450692 | 99.6 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7469.95 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 744009.69 | Quality Index Upper (QU) : (U - XBAR) / S | 7.47 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 744002.04 | Quality Index Lower (QL) : (XBAR - L) / S | 4.97 |
| Corrected Sum of Squares (SS) | 7.65 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.10 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.32 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.60 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MX Division : 01 Sample Lot : 2528 Lot Descr : KU MX-4
 In Service Population : 10000 Sample Quantity : 75 Meters Tested : 75 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C450868 | 99.7 | C450951 | 99.9 | C451046 | 100 | C451104 | 99.8 | C451237 | 99.6 |
| C451281 | 99.7 | C451367 | 99.9 | C451424 | 99.6 | C451602 | 99.7 | C451670 | 99.8 |
| C451818 | 99.582 | C451912 | 100.2 | C452002 | 99.8 | C452023 | 99.9 | C452127 | 99.5 |
| C452192 | 99.5 | C452365 | 99 | C452494 | 99.6 | C452586 | 99.6 | C452939 | 99.487 |
| C452994 | 99.4 | C452997 | 99.3 | C453268 | 99.5 | C453281 | 99.3 | C453284 | 99.8 |
| C453370 | 99.648 | C453620 | 99.4 | C453695 | 99.4 | C453867 | 99.3 | C454183 | 99.9 |
| C454521 | 99.8 | C454716 | 99.942 | C455096 | 99.8 | C455170 | 100 | C455354 | 99.9 |
| C455412 | 99.8 | C455566 | 99.8 | C457688 | 99.9 | C457815 | 99.8 | C457968 | 99.8 |
| C458555 | 99.6 | C458702 | 99.4 | C458962 | 100.2 | C459395 | 99.8 | C459481 | 99.7 |
| C459527 | 99.7 | C459536 | 99.7 | C459577 | 99.7 | C460018 | 99.9 | C460196 | 99.9 |
| C460289 | 99.9 | C460545 | 99.9 | C460898 | 99.8 | C461044 | 99.9 | C461482 | 100.1 |
| C461514 | 99.7 | C461575 | 100 | C461654 | 99.9 | C461679 | 100.045 | C461709 | 99.9 |
| C461715 | 99.8 | C461768 | 99.8 | C461939 | 99.9 | C461947 | 99.8 | C462014 | 99.96 |
| C462015 | 99.8 | C462332 | 99.7 | C462521 | 100 | C462793 | 100 | C463003 | 99.9 |
| C463077 | 99.9 | C463126 | 100.1 | C463162 | 99.6 | C463244 | 99.7 | C463391 | 99.7 |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Inspection

| | | | |
|--|-----------|---|------|
| Sample Size (N) | 75 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 7481.76 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 746360.88 | Quality Index Upper (QU) : (U - XBAR) / S | 9.15 |
| Correction Factor (CF) : Sum of Measurements Squares / N | 746356.44 | Quality Index Lower (QL) : (XBAR - L) / S | 7.17 |
| Corrected Sum of Squares (SS) | 4.44 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.06 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.25 | Total Estimate Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.76 | Maximum Allowable Percent NCF (M) | 4.83 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

Device Category : F2S240V30AC200 Model Number : MX Division : 01 Sample Lot : 2529 Lot Descr : KU MX-5
 In Service Population : 17 Sample Quantity : 4 Meters Tested : 4 Pass / Fail : Pass

| Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy | Serial Number | Full Load Accuracy |
|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|---------------|--------------------|
| C463398 | 99.8 | C463402 | 99.9 | C463406 | 99.9 | C463414 | 100 | | |

Test Results per ANSI/ASQC Z1.9 - 1993 Double Specification Limit - Variability Unknown - Standard Deviation Model
 One AQL Value for Both Upper and Lower Specification Limit Combined AQL = 2.5% - Inspection Level II "E" - Normal Insepection

| | | | |
|--|----------|---|-------|
| Sample Size (N) | 4 | Upper Specification Limit (U) | 102 |
| Sum of Measurements (Sum X) | 399.60 | Lower Specification Limit (L) | 98 |
| Sum of Squared Measurements | 39920.06 | Quality Index Upper (QU) : (U - XBAR) / S | 25.72 |
| Correction Factor (CF) : Sum of Measurements Sqaures / N | 39920.04 | Quality Index Lower (QL) : (XBAR - L) / S | 23.27 |
| Corrected Sum of Squares (SS) | 0.02 | Estimate of Lot Percent NCF Above U (PU) | 0.00 |
| Variance (V) : SS / (N-1) | 0.01 | Estimate of Lot Percent NCF Below L (PL) | 0.00 |
| Estimate of Lot Standard Deviation (S) : SQRT of V | 0.08 | Total Estiamte Percent NCF In Lot (P) : PU + PL | 0.00 |
| Sample Mean (XBAR) : Sum X / N | 99.90 | Maximum Allowable Percent NCF (M) | 10.88 |
| | | Acceptability Criterion : Compare P with M | Pass |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

| Lot Number | Lot Name | Manufacturer | Model | In Service Population | Sample Quantity | Devices Set | Removed | Meters Tested | Pass / Fail | Lot Status |
|------------|---------------|-------------------------|------------------|-----------------------|-----------------|-------------|---------|---------------|-------------|------------------|
| 2466 | KU Focus AX-1 | Landis + Gyr | Focus AXR - Mesh | 1059 | 35 | 0 | 0 | 35 | Pass | Testing Complete |
| 2467 | KU AB1-1 | Asea Brown Boveri (ABB) | AB1 | 5584 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2468 | KU ALF-1 | Landis + Gyr | ALF | 394 | 20 | 0 | 0 | 20 | Pass | Testing Complete |
| 2469 | KU C1S-1 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2470 | KU C1S-2 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2471 | KU C1S-3 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2472 | KU C1S-4 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2473 | KU C1S-5 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2474 | KU C1S-6 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2475 | KU C1S-7 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2476 | KU C1S-8 | ITRON | C1S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2477 | KU C1S-9 | ITRON | C1SR | 5991 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2478 | KU C2SOS-1 | ITRON | C2SOS | 1509 | 50 | 0 | 0 | 50 | Pass | Testing Complete |
| 2479 | KU D4S-1 | Westinghouse | D4S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2480 | KU D4S-2 | Westinghouse | D4S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2481 | KU D4S-3 | Westinghouse | D4S | 4100 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2482 | KU D5S-1 | Westinghouse | D5S | 350 | 20 | 0 | 0 | 20 | Pass | Testing Complete |
| 2484 | KU I210-1 | General Electric | I-210 | 4682 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2485 | KU I50-1 | General Electric | I-50S | 808 | 35 | 0 | 0 | 35 | Pass | Testing Complete |
| 2486 | KU I55-1 | General Electric | I-55S | 682 | 35 | 0 | 0 | 35 | Pass | Testing Complete |
| 2487 | KU I60-1 | General Electric | I-60S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2488 | KU I60-2 | General Electric | I-60S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2489 | KU I60-3 | General Electric | I-60S | 7415 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2490 | KU I70-1 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2491 | KU I70-2 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2492 | KU I70-3 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

| | | | | | | | | | | |
|------|-----------|------------------|-------|-------|----|---|---|----|------|------------------|
| 2493 | KU I70-4 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2494 | KU I70-5 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2495 | KU I70-6 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2496 | KU I70-7 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2497 | KU I70-8 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2498 | KU I70-9 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2499 | KU I70-10 | General Electric | I-70S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2500 | KU I70-11 | General Electric | I-70S | 9218 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2501 | KU J4S-1 | Sangamo | J4S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2502 | KU J4S-2 | Sangamo | J4S | 611 | 35 | 0 | 0 | 35 | Pass | Testing Complete |
| 2503 | KU J5S-1 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2504 | KU J5S-2 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2505 | KU J5S-3 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2506 | KU J5S-4 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2507 | KU J5S-5 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2508 | KU J5S-6 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2509 | KU J5S-7 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2510 | KU J5S-8 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2511 | KU J5S-9 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2512 | KU J5S-10 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2513 | KU J5S-11 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2514 | KU J5S-12 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2515 | KU J5S-13 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2516 | KU J5S-14 | Sangamo | J5S | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2517 | KU J5S-15 | Sangamo | J5S | 962 | 35 | 0 | 0 | 35 | Pass | Testing Complete |
| 2518 | KU MQ-1 | Duncan | MQS | 3286 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2519 | KU MS-1 | Duncan | MS | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |

KU (2000) PSC Electric Meter Sample Report

2018 Sample Test Program 1/1/2018 to 12/31/2018

| | | | | | | | | | | |
|---------------|-----------|--------------|------|---------------|-------------|----------|----------|-------------|------|------------------|
| 2520 | KU MS-2 | Duncan | MS | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2521 | KU MS-3 | Duncan | MS | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2522 | KU MS-4 | Duncan | MS | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2523 | KU MS-5 | Landis + Gyr | MS | 422 | 25 | 0 | 0 | 25 | Pass | Testing Complete |
| 2524 | KU MSII-1 | Landis + Gyr | MSII | 4684 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2525 | KU MX-1 | Landis + Gyr | MX | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2526 | KU MX-2 | Landis + Gyr | MX | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2527 | KU MX-3 | Landis + Gyr | MX | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2528 | KU MX-4 | Landis + Gyr | MX | 10000 | 75 | 0 | 0 | 75 | Pass | Testing Complete |
| 2529 | KU MX-5 | Landis + Gyr | MX | 17 | 4 | 0 | 0 | 4 | Pass | Testing Complete |
| Totals | | | | 501774 | 4269 | 0 | 0 | 4269 | | |

TOTAL LOTS PASSED: 63

TOTAL LOTS FAILED: 0